

DOCKETED

Docket Number:	03-AFC-01C
Project Title:	Roseville Energy Park Compliance
TN #:	236730
Document Title:	Roseville Energy Park Quarterly Air Quality Report - Q4 2020
Description:	As required by various air quality Conditions of Certification, Roseville Energy Park hereby submits the Quarterly Air Quality Report for the Fourth Quarter 2020.
Filer:	Roseville Electric Compliance
Organization:	Roseville Electric
Submitter Role:	Public Agency
Submission Date:	2/10/2021 4:28:18 PM
Docketed Date:	2/10/2021

City of Roseville
Roseville Energy Park
(03-AFC-1)

California Energy Commission
Quarterly Operational Report
Fourth Quarter 2020

List of Attachments

AQ15 - SCR Installed before commissioning in 2007

AQ20 - The gas turbine engine shall be fired exclusively on pipeline quality natural gas with sulfur content no greater than 0.50 grains of sulfur compounds per 100 dry scf of natural gas

AQ21 – Startups and Shutdowns

AQ32 – All hourly, quarter NOx and CO emissions AQ-SC6

AQ33 – All hourly, daily, and quarterly SOx AQ-SC6

AQ34 – Startups and Shutdowns

AQ36 – Breakdown condition

AQ37 – Violations of Emissions

AQ40 – CEMS quality assurance test failures

AQ41 – Excess Emissions

AQ42 – Running 12-month summary

AQ47 – All nuisance violations

AQ48 – Nuisance complaints and stack emission opacity as dark as Ringlemann No. 1 (20% opacity) for periods aggregating more than 3 min.

AQ51 – Ammonia slip exceedances

AQ55 – Emission rates from each gas turbine and heat recovery steam generator exhaust during startup and shutdown – NOx and CO

AQ57 – Emission exceedance rates during startup and shutdown – CO, NOx, PM-10, SOx, and VOC

AQ59 – Emission limit exceedances – NOx, CO, VOC, PM-10, SO₂

AQ60 – Quarterly emission exceedances for Alstom GTX100 turbine – NOx, CO, VOCs, PMO, SOx

AQ63 – Total facility emission exceedances – NOx, CO, VOC, PM-10, SO₂

AQ68 – Annual water sample analysis of cooling tower water

AQ69 – Nuisance complaints

AQ70 – PM-10 quarterly emission rate exceedances from cooling tower

AQ71 – Exceedance of cooling tower PM-10 emission limit – PM-10 = cooling water recirculation rate*total dissolved solids concentration in the blow own water* design drift rate

AQ86 – Limits for operation for maintenance and testing of emergency diesel engine and generator limited to 50 hours per year

AQ87 – Operation for maintenance and testing purposes shall be limited to involuntary interruptions of electrical power. Operation shall not exceed 24 hours

AQ88 – Sulfur content of diesel fuel used shall not exceed 15 ppm by weight

AQ89 – Records of hours of operation engine run for maintenance and testing, during interruption of electrical power, records of sulfur content of diesel used for five years

AQ90 – No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance

AQ91 – Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited and is in violation of PCAPCD Rule 202, Visible Emissions

AQ99 – Operation for maintenance and testing of the emergency diesel engine and generator shall be limited to 50 hours per year.

AQ100 – Emergency diesel Generator; Operation for other than maintenance and testing purposes shall be limited to involuntary interruptions of electrical power

AQ101 - The sulfur content of the diesel used shall not exceed 15ppm by weight

AQ102 – Records of operation and maintenance shall be kept by the owner or operator for a period of five years

AQ103 – No emissions are permitted, from any source, which are a nuisance

AQ104 – Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited

AQ-15

AQ-15 The Project owner shall install a selective catalytic reduction (SCR) system and an oxidation catalyst on the gas turbine. The SCR and oxidation catalyst equipment shall be operated whenever the gas turbine is operated.

Verification: The Project owner shall submit to the CPM a written statement by a California registered Professional Engineer stating that said engineer has reviewed the as built designs or inspected the identified equipment and certifies that it is operational and air tight. The Project owner shall include the operational status of the SCR and oxidation catalyst during all hours of operation as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

This document is on file from the 2007 4Q QAQR.

AQ-20

AQ-20 The gas turbine engine shall be fired exclusively on pipeline quality natural gas with sulfur content no greater than 0.50 grains of sulfur compounds per 100 dry scf of natural gas.

Verification: The Project owner shall submit to the CPM the most recent fuel testing analysis performed as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

AQ20 ROSEVILLE ENERGY PARK

4Q20

Fuel Quality Analysis BTU values

<http://www.pge.com/pij>

	OCT	NOV	DEC
1	1040.66	1046.46	1040.40
2	1039.27	1046.22	1042.66
3	1038.64	1046.32	1042.10
4	1038.61	1048.85	1040.78
5	1043.55	1050.66	1042.24
6	1050.50	1050.63	1040.58
7	1058.02	1048.61	1040.63
8	1057.88	1051.08	1042.11
9	1057.94	1052.21	1042.65
10	1060.35	1052.38	1042.21
11	1059.97	1051.34	1041.09
12	1057.68	1051.44	1041.29
13	1058.00	1,051.49	1041.33
14	1057.39	1054.22	1042.08
15	1057.46	1054.26	1042.08
16	1055.14	1050.92	1042.78
17	1054.24	1050.98	1041.89
18	1057.47	1047.71	1041.74
19	1053.47	1044.21	1039.66
20	1050.15	1044.38	1039.79
21	1050.59	1047.93	1038.84
22	1048.87	1049.58	1039.84
23	1051.41	1048.71	1039.96
24	1053.65	1044.90	1039.51
25	1048.98	1044.90	1041.22
26	1046.23	1041.32	1046.96
27	1046.24	1041.19	1045.88
28	1047.40	1039.02	1041.81
29	1047.99	1040.26	1040.81
30	1047.60	1039.70	1042.91
31	1045.01	N/A	1042.31

odeline/operations/gas_quality/p01_2_weeks.shtml



California Gas Transmission

Pipe Ranger

Go

Log in

About CGT

Products

Tools & Services

Operating Data

Reference/Library

Current Pipeline Status

Forecasts

Historical Archives

Gas Quality/Heating Values

Gas System Sulfur Survey Results

Date	Total Sulfur Maximum		Total Sulfur Average all sites	
	PPMv	gr/100 scf	PPMv	gr/100 scf
2020				
Fourth Quarter	4.9	0.31	3.4	0.21
Third Quarter	4.5	0.28	3.2	0.20
Second Quarter	4.7	0.29	3.5	0.22
First Quarter	4.8	0.30	4.0	0.25

[+] Feedback

AQ-21

AQ-21 Startup is defined as the period beginning with the turbine light-off until the unit meets the lb/hr and ppmv emission limits in Conditions of Certification AQ-52, -54 and -55. Shutdown is defined as the period beginning with initiation of turbine shutdown sequence and ending with cessation of firing of the gas turbine engine. Startup and shutdown durations shall not exceed 3.0 hours and one hour, respectively, per occurrence.

Verification: The Project owner shall identify and submit to the CPM as part of the Quarterly Air Quality Report all startups and shutdowns for all units including the maximum hourly emission rate, total emissions and duration.

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 12:18 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
10/01/2020	32.04	128.83	12.37	24.70	41.20
10/02/2020	37.70	110.80	10.63	21.24	35.40
10/03/2020	37.26	113.45	10.83	21.71	36.17
10/04/2020	31.54	126.61	12.04	24.11	40.18
10/05/2020	29.96	129.77	12.47	24.89	41.48
10/06/2020	29.58	126.33	12.11	24.21	40.36
10/07/2020	36.16	123.04	11.69	23.44	39.02
10/08/2020	26.60	72.18	6.85	13.71	22.80
10/09/2020	18.68	64.29	6.12	12.24	20.43
10/10/2020	37.04	63.33	5.09	10.18	17.03
10/11/2020	14.62	58.73	5.62	11.24	18.76
10/12/2020	18.41	64.20	6.16	12.27	20.48
10/13/2020	37.78	108.80	10.71	21.47	35.71
10/14/2020	28.78	124.11	11.86	23.70	39.52
10/15/2020	41.98	108.68	10.11	20.24	33.73
10/16/2020	29.49	123.57	11.89	23.74	39.62
10/17/2020	31.44	119.97	11.44	22.86	38.07
10/18/2020	37.04	115.83	11.09	22.22	37.04
10/19/2020	37.58	119.41	11.81	23.59	39.37
10/20/2020	33.39	122.46	11.68	23.32	38.87
10/21/2020	33.46	103.89	9.96	19.90	33.10
10/22/2020	35.35	110.14	10.66	21.30	35.41
10/23/2020	45.98	105.28	10.02	20.03	33.31
10/24/2020	19.31	58.09	5.58	11.12	18.57
10/25/2020	22.17	63.02	6.00	11.97	19.95
10/26/2020	18.74	70.73	6.73	13.43	22.38
10/27/2020	25.70	59.82	5.72	11.44	19.03
10/28/2020	29.48	59.42	5.61	11.29	18.79
10/29/2020	28.36	61.90	5.90	11.78	19.69
10/30/2020	28.36	63.68	6.02	12.02	20.07
10/31/2020	26.13	58.71	5.71	11.41	19.04
Monthly Avg/Sum*:	940.11 *	2,939.07 *	280.48 *	560.77 *	934.58 *
Daily Min:	14.62	58.09	5.09	10.18	17.03
Daily Max:	45.98	129.77	12.47	24.89	41.48
Oct 2020 - Oct 2020	940.11	2,939.07	280.48	560.77	934.58
QTD:	940.11 *	2,939.07 *	280.48 *	560.77 *	934.58 *
YTD 2020:	4,136.69 *	13,982.18 *	1,319.05 *	2,638.18 *	4,395.42 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 12:18 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
11/01/2020	22.05	59.02	5.65	11.24	18.74
11/02/2020	25.02	68.39	6.52	13.03	21.72
11/03/2020	22.06	69.00	6.59	13.16	21.95
11/04/2020	25.74	58.94	5.63	11.25	18.79
11/05/2020	23.48	57.64	5.79	11.48	19.19
11/06/2020	22.66	53.49	5.21	10.42	17.32
11/07/2020	24.13	54.36	5.20	10.33	17.25
11/08/2020	25.80	53.58	5.10	10.24	17.12
11/09/2020	30.19	57.78	5.50	11.01	18.36
11/10/2020	27.77	59.60	5.71	11.42	19.04
11/11/2020	26.25	55.03	5.28	10.58	17.63
11/12/2020	26.64	54.55	5.19	10.38	17.29
11/13/2020	29.66	57.27	5.49	10.95	18.30
11/14/2020	26.10	55.72	5.30	10.64	17.73
11/15/2020	29.68	58.41	5.54	11.13	18.54
11/16/2020	33.26	58.52	5.55	11.10	18.49
11/17/2020	24.10	55.50	5.32	10.62	17.72
11/18/2020	19.38	56.27	5.41	10.79	18.00
11/19/2020	16.49	55.86	5.32	10.69	17.82
11/20/2020	26.00	59.46	5.63	11.29	18.82
11/21/2020	21.74	58.98	5.60	11.29	18.75
11/22/2020	23.55	60.68	5.74	11.54	19.21
11/23/2020	25.27	56.90	5.46	10.92	18.17
11/24/2020	26.87	57.33	5.50	11.00	18.33
11/25/2020	18.50	58.11	5.49	11.00	18.35
11/26/2020	15.65	0.61	0.00	0.01	0.02
11/27/2020	0.00	0.00	0.00	0.00	0.00
11/28/2020	0.00	0.00	0.00	0.00	0.00
11/29/2020	0.00	0.00	0.00	0.00	0.00
11/30/2020	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	638.04 *	1,451.00 *	138.72 *	277.51 *	462.65 *
Daily Min:	15.65	0.61	0.00	0.01	0.02
Daily Max:	33.26	69.00	6.59	13.16	21.95
Oct 2020 - Nov 2020	1,578.15	4,390.07	419.20	838.28	1,397.23
QTD:	1,578.15 *	4,390.07 *	419.20 *	838.28 *	1,397.23 *
YTD 2020:	4,774.73 *	15,433.18 *	1,457.77 *	2,915.69 *	4,858.07 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 12:18 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
12/01/2020	0.00	0.00	0.00	0.00	0.00
12/02/2020	0.00	0.00	0.00	0.00	0.00
12/03/2020	0.00	0.00	0.00	0.00	0.00
12/04/2020	0.00	0.00	0.00	0.00	0.00
12/05/2020	0.00	0.00	0.00	0.00	0.00
12/06/2020	0.00	0.00	0.00	0.00	0.00
12/07/2020	0.00	0.00	0.00	0.00	0.00
12/08/2020	0.00	0.00	0.00	0.00	0.00
12/09/2020	0.00	0.00	0.00	0.00	0.00
12/10/2020	0.00	0.00	0.00	0.00	0.00
12/11/2020	0.00	0.00	0.00	0.00	0.00
12/12/2020	0.00	0.00	0.00	0.00	0.00
12/13/2020	0.00	0.00	0.00	0.00	0.00
12/14/2020	0.00	0.00	0.00	0.00	0.00
12/15/2020	0.00	0.00	0.00	0.00	0.00
12/16/2020	0.00	0.00	0.00	0.00	0.00
12/17/2020	0.00	0.00	0.00	0.00	0.00
12/18/2020	0.00	0.00	0.00	0.00	0.00
12/19/2020	0.00	0.00	0.00	0.00	0.00
12/20/2020	0.00	0.00	0.00	0.00	0.00
12/21/2020	0.00	0.00	0.00	0.00	0.00
12/22/2020	104.87	39.49	1.21	2.42	4.01
12/23/2020	0.00	0.00	0.00	0.00	0.00
12/24/2020	0.00	0.00	0.00	0.00	0.00
12/25/2020	0.00	0.00	0.00	0.00	0.00
12/26/2020	0.00	0.00	0.00	0.00	0.00
12/27/2020	0.00	0.00	0.00	0.00	0.00
12/28/2020	0.00	0.00	0.00	0.00	0.00
12/29/2020	0.00	0.00	0.00	0.00	0.00
12/30/2020	0.00	0.00	0.00	0.00	0.00
12/31/2020	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	104.87 *	39.49 *	1.21 *	2.42 *	4.01 *
Daily Min:	104.87	39.49	1.21	2.42	4.01
Daily Max:	104.87	39.49	1.21	2.42	4.01
Oct 2020 - Dec 2020	1,683.02	4,429.56	420.41	840.70	1,401.24
QTD:	1,683.02 *	4,429.56 *	420.41 *	840.70 *	1,401.24 *
YTD 2020:	4,879.60 *	15,472.67 *	1,458.98 *	2,918.11 *	4,862.08 *

Monthly Summary By Day Report



From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/05/2021 12:19 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr	Unit CT1 NOX_SUSD, LbPerHr	Unit CT2 CO_SUSD, LbPerHr	Unit CT2 NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/01/2020	0.0	0.0	0.0	0.0
10/02/2020	0.0	0.0	0.0	0.0
10/03/2020	0.0	0.0	0.0	0.0
10/04/2020	0.0	0.0	0.0	0.0
10/05/2020	0.0	0.0	0.0	0.0
10/06/2020	0.0	0.0	0.0	0.0
10/07/2020	0.0	0.0	0.0	0.0
10/08/2020	5.1	0.8	0.0	0.0
10/09/2020	0.0	0.0	0.0	0.0
10/10/2020	21.0	11.7	1.1	0.0
10/11/2020	0.0	0.0	0.0	0.0
10/12/2020	0.0	0.0	0.0	0.0
10/13/2020	0.0	0.0	0.0	0.0
10/14/2020	0.0	0.0	0.0	0.0
10/15/2020	18.6	4.3	0.0	0.0
10/16/2020	0.0	0.0	0.0	0.0
10/17/2020	0.0	0.0	0.0	0.0
10/18/2020	0.0	0.0	0.0	0.0
10/19/2020	0.0	0.0	0.0	0.0
10/20/2020	0.0	0.0	0.0	0.0
10/21/2020	0.0	0.0	0.0	0.0
10/22/2020	0.0	0.0	0.0	0.0
10/23/2020	5.4	0.8	0.0	0.0
10/24/2020	0.0	0.0	0.0	0.0
10/25/2020	0.0	0.0	0.0	0.0
10/26/2020	0.0	0.0	0.0	0.0
10/27/2020	0.0	0.0	0.0	0.0
10/28/2020	0.0	0.0	0.0	0.0
10/29/2020	0.0	0.0	0.0	0.0
10/30/2020	0.0	0.0	0.0	0.0
10/31/2020	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	50.1 *	17.6 *	1.1 *	0.0 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	21.0	11.7	1.1	0.0
Oct 2020 - Oct 2020	50.1	17.6	1.1	0.0
QTD:	50.1 *	17.6 *	1.1 *	0.0 *
YTD 2020:	530.0 *	145.4 *	255.7 *	116.3 *

Monthly Summary By Day Report



From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/05/2021 12:19 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr	Unit CT1 NOX_SUSD, LbPerHr	Unit CT2 CO_SUSD, LbPerHr	Unit CT2 NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/01/2020	0.0	0.0	0.0	0.0
11/02/2020	0.0	0.0	0.0	0.0
11/03/2020	0.0	0.0	0.0	0.0
11/04/2020	0.0	0.0	0.0	0.0
11/05/2020	0.0	0.0	0.0	0.0
11/06/2020	0.0	0.0	0.0	0.0
11/07/2020	0.0	0.0	0.0	0.0
11/08/2020	0.0	0.0	0.0	0.0
11/09/2020	0.0	0.0	0.0	0.0
11/10/2020	0.0	0.0	0.0	0.0
11/11/2020	0.0	0.0	0.0	0.0
11/12/2020	0.0	0.0	0.0	0.0
11/13/2020	0.0	0.0	0.0	0.0
11/14/2020	0.0	0.0	0.0	0.0
11/15/2020	0.0	0.0	0.0	0.0
11/16/2020	0.0	0.0	0.0	0.0
11/17/2020	0.0	0.0	0.0	0.0
11/18/2020	0.0	0.0	0.0	0.0
11/19/2020	0.0	0.0	0.0	0.0
11/20/2020	0.0	0.0	0.0	0.0
11/21/2020	0.0	0.0	0.0	0.0
11/22/2020	0.0	0.0	0.0	0.0
11/23/2020	0.0	0.0	0.0	0.0
11/24/2020	0.0	0.0	0.0	0.0
11/25/2020	0.0	0.0	0.0	0.6
11/26/2020	0.0	0.0	10.2	0.6
11/27/2020	0.0	0.0	0.0	0.0
11/28/2020	0.0	0.0	0.0	0.0
11/29/2020	0.0	0.0	0.0	0.0
11/30/2020	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	- *	- *	10.2 *	1.2 *
Daily Min:	-	-	0.0	0.0
Daily Max:	-	-	10.2	0.6
Oct 2020 - Nov 2020	50.1	17.6	11.3	1.2
QTD:	50.1 *	17.6 *	11.3 *	1.2 *
YTD 2020:	530.0 *	145.4 *	265.9 *	117.5 *

Monthly Summary By Day Report



From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/05/2021 12:19 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr	Unit CT1 NOX_SUSD, LbPerHr	Unit CT2 CO_SUSD, LbPerHr	Unit CT2 NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/01/2020	0.0	0.0	0.0	0.0
12/02/2020	0.0	0.0	0.0	0.0
12/03/2020	0.0	0.0	0.0	0.0
12/04/2020	0.0	0.0	0.0	0.0
12/05/2020	0.0	0.0	0.0	0.0
12/06/2020	0.0	0.0	0.0	0.0
12/07/2020	0.0	0.0	0.0	0.0
12/08/2020	0.0	0.0	0.0	0.0
12/09/2020	0.0	0.0	0.0	0.0
12/10/2020	0.0	0.0	0.0	0.0
12/11/2020	0.0	0.0	0.0	0.0
12/12/2020	0.0	0.0	0.0	0.0
12/13/2020	0.0	0.0	0.0	0.0
12/14/2020	0.0	0.0	0.0	0.0
12/15/2020	0.0	0.0	0.0	0.0
12/16/2020	0.0	0.0	0.0	0.0
12/17/2020	0.0	0.0	0.0	0.0
12/18/2020	0.0	0.0	0.0	0.0
12/19/2020	0.0	0.0	0.0	0.0
12/20/2020	0.0	0.0	0.0	0.0
12/21/2020	0.0	0.0	0.0	0.0
12/22/2020	44.1	12.0	39.6	14.7
12/23/2020	0.0	0.0	0.0	0.0
12/24/2020	0.0	0.0	0.0	0.0
12/25/2020	0.0	0.0	0.0	0.0
12/26/2020	0.0	0.0	0.0	0.0
12/27/2020	0.0	0.0	0.0	0.0
12/28/2020	0.0	0.0	0.0	0.0
12/29/2020	0.0	0.0	0.0	0.0
12/30/2020	0.0	0.0	0.0	0.0
12/31/2020	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	44.1 *	12.0 *	39.6 *	14.7 *
Daily Min:	44.1	12.0	39.6	14.7
Daily Max:	44.1	12.0	39.6	14.7
Oct 2020 - Dec 2020	94.2	29.6	50.9	15.9
QTD:	94.2 *	29.6 *	50.9 *	15.9 *
YTD 2020:	574.1 *	157.4 *	305.5 *	132.2 *

Startup / Shutdown Events

CT1



From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/05/2021 12:14 **Location:** Roseville, CA

Unit offline

Tag Name: CT1_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
10/08/2020 06:00	10/10/2020 14:00	57
10/15/2020 09:00	10/15/2020 14:00	6
10/24/2020 00:00	12/22/2020 16:00	1433
12/22/2020 21:00	12/31/2020 23:00	219

Startup / Shutdown Events

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 12:14 Location: Roseville, CA

Operating Time Summary

Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	1,715.00 Hour(s)
Offline Percentage:	77.67 %
Total Online:	493.00 Hour(s)
Online Percentage:	22.33 %

Startup / Shutdown Events

CT1



From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/05/2021 12:14 **Location:** Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	10/08/2020 04:54	10/08/2020 05:02	Shutdown	9
2	10/10/2020 15:14	10/10/2020 16:11	cold Startup	58
3	10/15/2020 08:02	10/15/2020 08:02	Shutdown	1
4	10/15/2020 15:20	10/15/2020 15:58	cold Startup	39
5	10/23/2020 22:55	10/23/2020 23:03	Shutdown	9
6	12/22/2020 17:26	12/22/2020 18:24	cold Startup	59
7	12/22/2020 20:00	12/22/2020 20:08	Shutdown	9

Startup / Shutdown Events

CT1



From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/05/2021 12:14 **Location:** Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	3	156	0.53
Warm Startup	0		0.00
Shutdown	4	28	0.10
Total Process Events:	7	184	0.63

Total Report Time:	2,207.98 Hour(s)
Total Operating Time:	488.32 Hour(s)
Total Startup Time:	156 Minute(s)
Total Shutdown Time:	28 Minute(s)
Total Startup/Shutdown Time:	184 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	0.63 %

Startup / Shutdown Events

CT2



From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/05/2021 12:17 **Location:** Roseville, CA

Unit offline

Tag Name: CT2_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
10/10/2020 15:00	10/11/2020 14:00	24
10/11/2020 16:00	10/13/2020 03:00	36
11/26/2020 01:00	12/22/2020 14:00	638
12/22/2020 19:00	12/31/2020 23:00	221

Startup / Shutdown Events

CT2



From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/05/2021 12:17 **Location:** Roseville, CA

Operating Time Summary

Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	919.00 Hour(s)
Offline Percentage:	41.62 %
Total Online:	1,289.00 Hour(s)
Online Percentage:	58.38 %

Startup / Shutdown Events

CT2



From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/05/2021 12:17 **Location:** Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	10/10/2020 13:52	10/10/2020 13:52	Shutdown	1
2	10/10/2020 14:09	10/10/2020 14:13	Warm Startup	5
3	10/10/2020 14:13	10/10/2020 14:13	Shutdown	1
4	10/10/2020 14:29	10/10/2020 14:32	Cold Startup	4
5	10/10/2020 14:32	10/10/2020 14:32	Shutdown	1
6	10/11/2020 15:11	10/11/2020 15:12	Cold Startup	2
7	10/11/2020 15:12	10/11/2020 15:12	Shutdown	1
8	10/13/2020 04:43	10/13/2020 04:50	Cold Startup	8
9	10/13/2020 04:49	10/13/2020 04:50	Shutdown	2
10	10/13/2020 05:18	10/13/2020 05:25	Cold Startup	8
11	10/13/2020 05:24	10/13/2020 05:25	Shutdown	2
12	10/13/2020 06:25	10/13/2020 06:31	Cold Startup	7
13	10/13/2020 06:31	10/13/2020 06:31	Shutdown	1
14	10/13/2020 06:59	10/13/2020 07:05	Cold Startup	7
15	10/13/2020 07:05	10/13/2020 07:05	Shutdown	1
16	10/13/2020 08:02	10/13/2020 09:03	Cold Startup	62
17	11/25/2020 23:55	11/26/2020 00:03	Shutdown	9
18	12/22/2020 15:42	12/22/2020 16:31	Cold Startup	50
19	12/22/2020 18:23	12/22/2020 18:32	Shutdown	10

Startup / Shutdown Events

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 12:17 Location: Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	8	148	0.19
Warm Startup	1	5	0.01
Shutdown	10	29	0.04
Total Process Events:	19	182	0.24

Total Report Time:	2,207.98 Hour(s)
Total Operating Time:	1,281.45 Hour(s)
Total Startup Time:	153 Minute(s)
Total Shutdown Time:	29 Minute(s)
Total Startup/Shutdown Time:	182 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	0.24 %

CT1 SUSD EVENT 1

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/08/20 4:49	284266			0.7			1.69			0.43			1.84			0		
10/08/20 4:50	284959.1			0.7			1.69			0.43			1.84			0		
10/08/20 4:51	284497			0.7			1.78			0.43			1.94			0		
10/08/20 4:52	284805.1			0.7			1.78			0.43			1.94			0		
10/08/20 4:53	284574			0.7			1.78			0.43			1.94			0		
10/08/20 4:54	284266			0.7			1.78			0.43			1.94			1		
10/08/20 4:55	268785.8			0.7			1.78			0.41			1.83			1		
10/08/20 4:56	245758			0.7			2.9			0.38			2.73			1		
10/08/20 4:57	227197.1			0.6			6.58			0.31			5.73			1		
10/08/20 4:58	201319.8			0.5			9.36			0.24			7.22			1		
10/08/20 4:59	176597.6			0.5			13.96			0.19			9.44			1		
10/08/20 5:00	155187.2			7.3			15.9			2.64			9.46			1		
10/08/20 5:01	135548.1			507.1			16.08			160.05			8.35			1		
10/08/20 5:02	35273.3			1716.6			17.7			141.02			2.39			1		
10/08/20 5:03	0			0			19.54			0			0			0		
10/08/20 5:04	0			0			0.1			0			0			0		
10/08/20 5:05	0			0			0.1			0			0			0		
10/08/20 5:06	0			0			0.1			0			0			0		
10/08/20 5:07	0			0			0.1			0			0			0		

CT1 SUSD EVENT 2

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/10/20 15:09	0			0			0			0			0			0		
10/10/20 15:10	0			0			0			0			0			0		
10/10/20 15:11	0			0			0			0			0			0		
10/10/20 15:12	0			0			0			0			0			0		
10/10/20 15:13	0			0			0			0			0			0		
10/10/20 15:14	0			0			0			0			0			1		
10/10/20 15:15	16327.4			0.2			0			0			0			1		
10/10/20 15:16	36890.7			59			28.52			5.07			4.03			1		
10/10/20 15:17	50599.5			526.7			19.67			62.02			3.81			1		
10/10/20 15:18	71701.9			329.5			26.08			55.02			7.17			1		
10/10/20 15:19	118527.6			156.9			32.45			43.3			14.74			1		
10/10/20 15:20	137165.5			52.4			49.82			16.75			26.19			1		
10/10/20 15:21	151644.5			265.1			58.11			93.6			33.76			1		
10/10/20 15:22	171899.7			1676.1			51.49			670.85			33.92			1		
10/10/20 15:23	195235.5			555.2			63.19			252.3			47.26			1		
10/10/20 15:24	221035.8			56.5			67.85			29.05			57.47			1		
10/10/20 15:25	241830.2			2.7			67.38			1.53			62.43			1		
10/10/20 15:26	270018			1.4			60.14			0.91			62.21			1		
10/10/20 15:27	292352.6			1.4			43.64			0.96			48.88			1		
10/10/20 15:28	309681.2			1.5			23.51			1.1			27.9			1		
10/10/20 15:29	315149.3			1.7			15.02			1.25			18.14			1		
10/10/20 15:30	315072.3			1.7			13.21			1.23			15.95			1		
10/10/20 15:31	314764.3			1.6			10.83			1.16			13.06			1		
10/10/20 15:32	312684.8			1.5			9.83			1.11			11.78			1		
10/10/20 15:33	312222.8			1.4			8.22			1.04			9.84			1		
10/10/20 15:34	311991.7			1.4			7.44			0.99			8.9			1		
10/10/20 15:35	311375.6			1.2			6.99			0.86			8.34			1		
10/10/20 15:36	310990.5			1.1			6.72			0.79			8			1		
10/10/20 15:37	310297.3			1.1			6.17			0.79			7.34			1		
10/10/20 15:38	309912.3			1			6.08			0.72			7.22			1		
10/10/20 15:39	309681.2			1			6.08			0.72			7.22			1		
10/10/20 15:40	308911.1			0.9			5.99			0.65			7.09			1		
10/10/20 15:41	308526			0.9			5.99			0.66			7.08			1		
10/10/20 15:42	308757			0.9			5.9			0.66			6.98			1		
10/10/20 15:43	308757			0.9			5.9			0.66			6.98			1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSDTF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/10/20 15:44	308371.9			0.8			5.9			0.6			6.97			1		
10/10/20 15:45	308526			0.8			5.81			0.6			6.87			1		
10/10/20 15:46	308294.9			0.8			5.72			0.6			6.75			1		
10/10/20 15:47	307678.8			0.8			5.62			0.59			6.63			1		
10/10/20 15:48	307293.7			0.8			5.62			0.59			6.62			1		
10/10/20 15:49	307909.8			0.7			5.62			0.53			6.63			1		
10/10/20 15:50	307832.8			0.7			5.62			0.53			6.63			1		
10/10/20 15:51	307139.7			0.7			5.72			0.53			6.73			1		
10/10/20 15:52	307062.7			0.7			5.9			0.53			6.94			1		
10/10/20 15:53	306446.6			0.7			5.9			0.53			6.93			1		
10/10/20 15:54	306985.7			0.7			5.99			0.53			7.05			1		
10/10/20 15:55	307216.7			0.7			6.18			0.53			7.27			1		
10/10/20 15:56	306908.7			0.7			5.72			0.53			6.72			1		
10/10/20 15:57	307062.7			0.7			3.41			0.53			4.01			1		
10/10/20 15:58	306754.6			0.7			2.67			0.53			3.14			1		
10/10/20 15:59	306908.7			0.7			2.67			0.53			3.14			1		
10/10/20 16:00	306369.5			0.7			2.67			0.53			3.14			1		
10/10/20 16:01	306908.7			0.7			2.77			0.53			3.25			1		
10/10/20 16:02	306369.5			0.7			2.77			0.53			3.25			1		
10/10/20 16:03	306677.6			0.7			2.77			0.53			3.25			1		
10/10/20 16:04	306292.5			0.7			2.67			0.53			3.14			1		
10/10/20 16:05	306600.6			0.7			2.49			0.53			2.92			1		
10/10/20 16:06	306138.5			0.7			2.4			0.53			2.81			1		
10/10/20 16:07	306138.5			0.7			2.21			0.53			2.6			1		
10/10/20 16:08	306061.5			0.7			2.12			0.53			2.49			1		
10/10/20 16:09	306138.5			0.7			2.03			0.53			2.38			1		
10/10/20 16:10	305830.4			0.7			1.94			0.53			2.27			1		
10/10/20 16:11	305522.4			0.7			1.94			0.52			2.27			1		
10/10/20 16:12	305445.3			0.7			1.84			0.52			2.16			0		
10/10/20 16:13	306446.6			0.7			1.75			0.53			2.06			0		
10/10/20 16:14	306292.5			0.7			1.66			0.53			1.95			0		
10/10/20 16:15	306446.6			0.7			1.66			0.53			1.95			0		
10/10/20 16:16	306446.6			0.7			1.66			0.53			1.95			0		

CT1 SUSD EVENT 3

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/15/20 7:57	393782.7			0.7			1.55			0.62			2.33			0		
10/15/20 7:58	393551.6			0.7			1.43			0.61			2.15			0		
10/15/20 7:59	381460.1			0.7			1.43			0.59			2.09			0		
10/15/20 8:00	368444.4			0.7			1.5			0.56			2.12			0		
10/15/20 8:01	363977.5			0.7			1.66			0.62			2.31			0		
10/15/20 8:02	45901.5			0.7			1.84			0.08			0.32			1		
10/15/20 8:03	0			0			2.95			0			0			0		
10/15/20 8:04	0			0			0			0			0			0		
10/15/20 8:05	0			0			0			0			0			0		
10/15/20 8:06	0			0			0			0			0			0		
10/15/20 8:07	0			0			0			0			0			0		

CT1 SUSD EVENT 4

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/15/20 15:15	0			0			0			0			0			0		
10/15/20 15:16	0			0			0			0			0			0		
10/15/20 15:17	0			0			0			0			0			0		
10/15/20 15:18	0			0			0			0			0			0		
10/15/20 15:19	0			0			0			0			0			0		
10/15/20 15:20	2310.5			-0.1			0			0			0			1		
10/15/20 15:21	23258.8			-0.1			0			0			0			1		
10/15/20 15:22	38122.9			47.2			2.95			4.18			0.43			1		
10/15/20 15:23	52447.9			247.1			2.62			30.15			0.53			1		
10/15/20 15:24	69314.4			153.4			4.35			24.76			1.15			1		
10/15/20 15:25	113136.5			77.8			6.44			20.49			2.79			1		
10/15/20 15:26	136626.3			32.9			12.03			10.47			6.3			1		
10/15/20 15:27	141940.4			12.3			16.45			4.08			8.94			1		
10/15/20 15:28	158652.9			1605.4			16.78			592.93			10.2			1		
10/15/20 15:29	180756.5			840			16.01			353.49			11.09			1		
10/15/20 15:30	204785.5			112.1			21.39			53.45			16.78			1		
10/15/20 15:31	228737.4			5.9			24.73			3.14			21.67			1		
10/15/20 15:32	251842.2			1.3			26			0.77			25.09			1		
10/15/20 15:33	275794.2			1.2			22.6			0.77			23.88			1		
10/15/20 15:34	297435.7			1.1			11.7			0.79			13.34			1		
10/15/20 15:35	307678.8			1.2			7.65			0.86			9.02			1		
10/15/20 15:36	307524.8			1.3			7.26			0.91			8.56			1		
10/15/20 15:37	309065.1			1.2			5.9			0.85			6.99			1		
10/15/20 15:38	313301			1.1			5.81			0.79			6.97			1		
10/15/20 15:39	313069.9			1			5.63			0.72			6.76			1		
10/15/20 15:40	312992.9			1			5.54			0.72			6.65			1		
10/15/20 15:41	308757			0.9			5.45			0.64			6.45			1		
10/15/20 15:42	305753.4			0.9			5.45			0.64			6.39			1		
10/15/20 15:43	305291.3			0.8			5.54			0.58			6.48			1		
10/15/20 15:44	304290.1			0.8			5.54			0.58			6.46			1		
10/15/20 15:45	304367.1			0.8			5.54			0.58			6.46			1		
10/15/20 15:46	303905			0.7			5.54			0.51			6.45			1		
10/15/20 15:47	303982			0.7			3.72			0.51			4.33			1		
10/15/20 15:48	304290.1			0.7			2.77			0.52			3.22			1		
10/15/20 15:49	304059.1			0.7			2.58			0.52			3.01			1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/15/20 15:50	303674			0.7			2.58			0.52			3			1		
10/15/20 15:51	301363.5			0.7			2.67			0.52			3.09			1		
10/15/20 15:52	306600.6			0.7			2.77			0.53			3.25			1		
10/15/20 15:53	318769.1			0.7			2.77			0.55			3.38			1		
10/15/20 15:54	329859.4			0.7			2.67			0.57			3.38			1		
10/15/20 15:55	341334.8			0.6			2.03			0.51			2.65			1		
10/15/20 15:56	355274.7			0.7			1.87			0.54			2.55			1		
10/15/20 15:57	369907.7			0.7			1.9			0.57			2.7			1		
10/15/20 15:58	388237.5			0.6			1.93			0.52			2.88			1		
10/15/20 15:59	404487.9			0.6			1.93			0.55			3			0		
10/15/20 16:00	401253.2			0.6			1.93			0.54			2.97			0		
10/15/20 16:01	400945.2			0.6			1.9			0.53			2.92			0		
10/15/20 16:02	400483.1			0.6			1.84			0.54			2.82			0		
10/15/20 16:03	400175			0.6			1.74			0.55			2.69			0		

CT1 SUSD EVENT 5

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/23/20 22:50	285036.1			0.7			1.78			0.5			1.94			0		
10/23/20 22:51	285036.1			0.7			1.78			0.5			1.94			0		
10/23/20 22:52	284959.1			0.7			1.78			0.5			1.94			0		
10/23/20 22:53	284959.1			0.7			1.69			0.5			1.84			0		
10/23/20 22:54	285036.1			0.7			1.69			0.5			1.84			0		
10/23/20 22:55	284343			0.7			1.69			0.5			1.84			1		
10/23/20 22:56	266398.3			0.7			1.69			0.46			1.72			1		
10/23/20 22:57	242754.3			0.8			3.24			0.43			3.01			1		
10/23/20 22:58	222807.2			0.7			7.38			0.36			6.3			1		
10/23/20 22:59	196082.7			0.5			7.76			0.24			5.83			1		
10/23/20 23:00	172977.9			0.9			14.52			0.37			9.63			1		
10/23/20 23:01	151259.4			9.3			16.39			3.28			9.5			1		
10/23/20 23:02	131466.3			746.7			16.64			228.5			8.38			1		
10/23/20 23:03	21795.5			1839.6			17.53			93.48			1.47			1		
10/23/20 23:04	0			0			20.92			0			0			0		
10/23/20 23:05	0			0			0.1			0			0			0		
10/23/20 23:06	0			0			0.1			0			0			0		
10/23/20 23:07	0			0			0.1			0			0			0		
10/23/20 23:08	0			0			0.1			0			0			0		

CT1 SUSD EVENT 6

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/22/20 17:21	0			0			0			0			0			0		
12/22/20 17:22	0			0			0			0			0			0		
12/22/20 17:23	0			0			0			0			0			0		
12/22/20 17:24	0			0			0			0			0			0		
12/22/20 17:25	0			0			0			0			0			0		
12/22/20 17:26	0			0.1			0			0			0			1		
12/22/20 17:27	0			1			0			0			0			1		
12/22/20 17:28	6546.4			6.6			7.21			0.1			0.18			1		
12/22/20 17:29	36582.6			524.2			11.8			44.94			1.66			1		
12/22/20 17:30	69699.5			363.4			18.29			59.39			4.92			1		
12/22/20 17:31	119913.9			220.4			23.87			62.03			11.05			1		
12/22/20 17:32	139475.9			101.4			43.27			33.18			23.3			1		
12/22/20 17:33	147408.6			549.8			45.05			190.13			25.64			1		
12/22/20 17:34	164275.1			1888			37.55			727.75			23.82			1		
12/22/20 17:35	185993.6			1584.2			43.05			691.16			30.91			1		
12/22/20 17:36	211408.8			433.1			52.52			214.86			42.88			1		
12/22/20 17:37	231972.1			47.2			53.73			25.68			48.12			1		
12/22/20 17:38	255076.9			5.8			53.1			3.46			52.29			1		
12/22/20 17:39	282340.6			4.5			51.34			2.95			55.97			1		
12/22/20 17:40	301132.4			4.1			38.9			2.87			45.23			1		
12/22/20 17:41	303982			4			22.3			2.85			26.17			1		
12/22/20 17:42	303828			4.2			16.59			2.99			19.46			1		
12/22/20 17:43	303365.9			4.5			14.11			3.22			16.52			1		
12/22/20 17:44	301902.6			5.4			12.58			3.81			14.66			1		
12/22/20 17:45	300747.4			6.2			11.02			4.35			12.8			1		
12/22/20 17:46	300439.3			14.2			9.77			9.99			11.34			1		
12/22/20 17:47	300670.3			14.8			9.33			10.43			10.84			1		
12/22/20 17:48	300670.3			12.7			8.28			8.94			9.61			1		
12/22/20 17:49	300054.2			8.4			7.49			5.89			8.67			1		
12/22/20 17:50	299438.1			6.7			6.78			4.7			7.84			1		
12/22/20 17:51	298745			6.1			5.9			4.26			6.81			1		
12/22/20 17:52	298205.8			5.2			5.72			3.63			6.59			1		
12/22/20 17:53	298359.9			4.2			5.27			2.94			6.08			1		
12/22/20 17:54	298128.8			3.4			5.1			2.38			5.86			1		
12/22/20 17:55	297897.8			2.9			5.01			2			5.76			1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/22/20 17:56	298282.9			2.4			4.83			1.69			5.56			1		
12/22/20 17:57	297820.8			2.1			4.65			1.5			5.34			1		
12/22/20 17:58	297897.8			2			4.56			1.37			5.24			1		
12/22/20 17:59	297435.7			1.9			4.47			1.31			5.13			1		
12/22/20 18:00	297281.7			1.8			4.47			1.25			5.13			1		
12/22/20 18:01	296896.6			1.7			4.47			1.18			5.12			1		
12/22/20 18:02	296357.5			1.6			4.38			1.12			5.01			1		
12/22/20 18:03	296665.5			1.5			4.54			1.07			5.2			1		
12/22/20 18:04	296280.4			1.4			4.63			0.95			5.3			1		
12/22/20 18:05	296126.4			1.3			4.81			0.88			5.5			1		
12/22/20 18:06	296049.4			1.2			4.9			0.82			5.6			1		
12/22/20 18:07	296126.4			1.1			4.99			0.76			5.71			1		
12/22/20 18:08	295895.4			1			5.08			0.69			5.81			1		
12/22/20 18:09	296126.4			1			5.17			0.69			5.91			1		
12/22/20 18:10	295895.4			0.9			5.17			0.63			5.91			1		
12/22/20 18:11	296126.4			0.9			4.45			0.63			5.08			1		
12/22/20 18:12	296203.4			0.9			3.18			0.63			3.63			1		
12/22/20 18:13	295972.4			0.8			3			0.57			3.42			1		
12/22/20 18:14	295664.3			0.8			2.81			0.57			3.21			1		
12/22/20 18:15	295125.2			0.8			2.63			0.57			3			1		
12/22/20 18:16	295510.3			0.8			2.54			0.57			2.9			1		
12/22/20 18:17	295356.3			0.8			2.45			0.57			2.79			1		
12/22/20 18:18	295356.3			0.8			2.36			0.57			2.69			1		
12/22/20 18:19	295279.3			0.8			2.27			0.57			2.59			1		
12/22/20 18:20	295279.3			0.7			2.18			0.5			2.48			1		
12/22/20 18:21	300901.4			0.7			2.09			0.51			2.42			1		
12/22/20 18:22	320694.5			0.7			2			0.55			2.47			1		
12/22/20 18:23	338562.2			0.7			1.88			0.57			2.45			1		
12/22/20 18:24	354427.5			0.8			1.79			0.67			2.45			1		
12/22/20 18:25	376916.2			0.7			1.72			0.64			2.51			0		
12/22/20 18:26	399558.9			0.7			1.48			0.69			2.28			0		
12/22/20 18:27	428285.8			0.7			1.4			0.66			2.32			0		
12/22/20 18:28	436757.6			0.7			1.5			0.67			2.53			0		
12/22/20 18:29	433908			0.6			1.57			0.66			2.63			0		

CT1 SUSD EVENT 7

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/22/20 19:55	361821			0.7			1.97			0.61			2.75			0		
12/22/20 19:56	339794.5			0.7			1.94			0.56			2.54			0		
12/22/20 19:57	315149.3			0.8			1.91			0.58			2.32			0		
12/22/20 19:58	293738.9			0.9			1.91			0.6			2.16			0		
12/22/20 19:59	285960.3			0.8			1.76			0.53			1.94			0		
12/22/20 20:00	283264.8			0.7			2.27			0.48			2.48			1		
12/22/20 20:01	265782.1			0.6			2.72			0.4			2.79			1		
12/22/20 20:02	241137			0.6			5.62			0.37			5.24			1		
12/22/20 20:03	221112.9			0.6			8.95			0.31			7.64			1		
12/22/20 20:04	195774.6			0.4			14.12			0.19			10.67			1		
12/22/20 20:05	172130.7			3.2			16.64			1.29			11.06			1		
12/22/20 20:06	150643.2			168.2			18.24			59.43			10.61			1		
12/22/20 20:07	132852.5			1067.6			18.46			332.66			9.46			1		
12/22/20 20:08	23181.8			1829			19.61			99.49			1.76			1		
12/22/20 20:09	0			0			21.45			0			0			0		
12/22/20 20:10	0			0			17.7			0			0			0		
12/22/20 20:11	0			0			0.2			0			0			0		
12/22/20 20:12	0			0			0.2			0			0			0		
12/22/20 20:13	0			0			0.2			0			0			0		

CT2 SUSD EVENT 1

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/10/20 13:47	382384.3			1.6			1.72			1.45			2.53			0		
10/10/20 13:48	381537.1			1.6			1.72			1.45			2.52			0		
10/10/20 13:49	380921			1.6			1.72			1.45			2.52			0		
10/10/20 13:50	381075			1.7			1.75			1.47			2.56			0		
10/10/20 13:51	252535.4			1.7			1.75			0.98			1.69			0		
10/10/20 13:52	69468.4			1.9			1.83			0.31			0.49			1		
10/10/20 13:53	0			0			5.02			0			0			0		
10/10/20 13:54	0			0			0.84			0			0			0		
10/10/20 13:55	0			0			0			0			0			0		
10/10/20 13:56	0			0			0			0			0			0		
10/10/20 13:57	0			0			0			0			0			0		

CT2 SUSD EVENT 2

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/10/20 14:04	0			0			0			0			0			0		
10/10/20 14:05	0			0			0			0			0			0		
10/10/20 14:06	0			0			0			0			0			0		
10/10/20 14:07	0			0			0			0			0			0		
10/10/20 14:08	0			0			0			0			0			0		
10/10/20 14:09	1463.3			0.2			0			0			0			1		
10/10/20 14:10	17867.7			0.2			0			0			0			1		
10/10/20 14:11	32962.8			64.9			0			4.98			0			1		
10/10/20 14:12	44361.2			183.2			1.04			18.91			0.18			1		
10/10/20 14:13	4466.9			202.9			1.64			2.09			0.03			1		
10/10/20 14:14	0			0			1.69			0			0			0		
10/10/20 14:15	0			0			0			0			0			0		
10/10/20 14:16	0			0			0			0			0			0		
10/10/20 14:17	0			0			0			0			0			0		
10/10/20 14:18	0			0			0			0			0			0		

CT2 SUSD EVENT 3

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/10/20 14:08	0			0			0			0			0			0		
10/10/20 14:09	1463.3			0.2			0			0			0			1		
10/10/20 14:10	17867.7			0.2			0			0			0			1		
10/10/20 14:11	32962.8			64.9			0			4.98			0			1		
10/10/20 14:12	44361.2			183.2			1.04			18.91			0.18			1		
10/10/20 14:13	4466.9			202.9			1.64			2.09			0.03			1		
10/10/20 14:14	0			0			1.69			0			0			0		
10/10/20 14:15	0			0			0			0			0			0		
10/10/20 14:16	0			0			0			0			0			0		
10/10/20 14:17	0			0			0			0			0			0		
10/10/20 14:18	0			0			0			0			0			0		

CT2 SUSD EVENT 4

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/10/20 14:24	0			0			0			0			0			0		
10/10/20 14:25	0			0			0			0			0			0		
10/10/20 14:26	0			0			0			0			0			0		
10/10/20 14:27	0			0			0			0			0			0		
10/10/20 14:28	0			0			0			0			0			0		
10/10/20 14:29	15865.3			0			0			0			0			1		
10/10/20 14:30	30036.2			1.6			0			0			0			1		
10/10/20 14:31	40972.5			272.3			0.91			25.97			0.14			1		
10/10/20 14:32	24568.1			273			2.48			15.64			0.23			1		
10/10/20 14:33	0			0			3.42			0			0			0		
10/10/20 14:34	0			0			0			0			0			0		
10/10/20 14:35	0			0			0			0			0			0		
10/10/20 14:36	0			0			0			0			0			0		
10/10/20 14:37	0			0			0			0			0			0		

CT2 SUSD EVENT 5

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/10/20 14:24	0			0			0			0			0			0		
10/10/20 14:25	0			0			0			0			0			0		
10/10/20 14:26	0			0			0			0			0			0		
10/10/20 14:27	0			0			0			0			0			0		
10/10/20 14:28	0			0			0			0			0			0		
10/10/20 14:29	15865.3			0			0			0			0			1		
10/10/20 14:30	30036.2			1.6			0			0			0			1		
10/10/20 14:31	40972.5			272.3			0.91			25.97			0.14			1		
10/10/20 14:32	24568.1			273			2.48			15.64			0.23			1		
10/10/20 14:33	0			0			3.42			0			0			0		
10/10/20 14:34	0			0			0			0			0			0		
10/10/20 14:35	0			0			0			0			0			0		
10/10/20 14:36	0			0			0			0			0			0		
10/10/20 14:37	0			0			0			0			0			0		

CT2 SUSD EVENT 6

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/11/20 15:06	0			0			0			0			0			0		
10/11/20 15:07	0			0			0			0			0			0		
10/11/20 15:08	0			0			0			0			0			0		
10/11/20 15:09	0			0			0			0			0			0		
10/11/20 15:10	0			0			0			0			0			0		
10/11/20 15:11	2310.5			0			0			0			0			1		
10/11/20 15:12	6623.4			0			0			0			0			1		
10/11/20 15:13	0			0			0.1			0			0			0		
10/11/20 15:14	0			0			15.17			0			0			0		
10/11/20 15:15	0			0			8.85			0			0			0		
10/11/20 15:16	0			0			23.6			0			0			0		
10/11/20 15:17	0			0			0.6			0			0			0		

CT2 SUSD EVENT 7

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/11/20 15:06	0			0			0			0			0			0		
10/11/20 15:07	0			0			0			0			0			0		
10/11/20 15:08	0			0			0			0			0			0		
10/11/20 15:09	0			0			0			0			0			0		
10/11/20 15:10	0			0			0			0			0			0		
10/11/20 15:11	2310.5			0			0			0			0			1		
10/11/20 15:12	6623.4			0			0			0			0			1		
10/11/20 15:13	0			0			0.1			0			0			0		
10/11/20 15:14	0			0			15.17			0			0			0		
10/11/20 15:15	0			0			8.85			0			0			0		
10/11/20 15:16	0			0			23.6			0			0			0		
10/11/20 15:17	0			0			0.6			0			0			0		

CT2 SUSD EVENT 8

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/13/20 4:38	0			0	X		0	X		0	X		0	X		0		
10/13/20 4:39	0			0	X		0	X		0	X		0	X		0		
10/13/20 4:40	0			0	X		0	X		0	X		0	X		0		
10/13/20 4:41	0			0	X		0	X		0	X		0	X		0		
10/13/20 4:42	0			0	X		0	X		0	X		0	X		0		
10/13/20 4:43	6700.4			0.1	X		0	X		0	X		0	X		1		
10/13/20 4:44	25184.2			0.1	X		0	X		0	X		0	X		1		
10/13/20 4:45	37275.7			37.4	X		39.33	X		3.25	X		5.62	X		1		
10/13/20 4:46	47672.9			523.4	X		19.78	X		58.11	X		3.61	X		1		
10/13/20 4:47	58917.2			380.7	X		24.84	X		52.24	X		5.61	X		1		
10/13/20 4:48	87875.2			234.8	X		28.62	X		48.04	X		9.64	X		1		
10/13/20 4:49	118527.6			119.8	X		44.12	X		33.06	X		20.04	X		1		
10/13/20 4:50	42050.7			265.1	X		53.71	X		25.93	X		8.65	X		1		
10/13/20 4:51	0			0	X		42.34	X		0	X		0	X		0		
10/13/20 4:52	0			0	X		0.9	X		0	X		0	X		0		
10/13/20 4:53	0			0	X		0.6	X		0	X		0	X		0		
10/13/20 4:54	0			0	X		0.7	X		0	X		0	X		0		
10/13/20 4:55	0			0	X		1.2	X		0	X		0	X		0		

CT2 SUSD EVENT 9

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/13/20 4:38	0			0	X		0	X		0	X		0	X		0		
10/13/20 4:39	0			0	X		0	X		0	X		0	X		0		
10/13/20 4:40	0			0	X		0	X		0	X		0	X		0		
10/13/20 4:41	0			0	X		0	X		0	X		0	X		0		
10/13/20 4:42	0			0	X		0	X		0	X		0	X		0		
10/13/20 4:43	6700.4			0.1	X		0	X		0	X		0	X		1		
10/13/20 4:44	25184.2			0.1	X		0	X		0	X		0	X		1		
10/13/20 4:45	37275.7			37.4	X		39.33	X		3.25	X		5.62	X		1		
10/13/20 4:46	47672.9			523.4	X		19.78	X		58.11	X		3.61	X		1		
10/13/20 4:47	58917.2			380.7	X		24.84	X		52.24	X		5.61	X		1		
10/13/20 4:48	87875.2			234.8	X		28.62	X		48.04	X		9.64	X		1		
10/13/20 4:49	118527.6			119.8	X		44.12	X		33.06	X		20.04	X		1		
10/13/20 4:50	42050.7			265.1	X		53.71	X		25.93	X		8.65	X		1		
10/13/20 4:51	0			0	X		42.34	X		0	X		0	X		0		
10/13/20 4:52	0			0	X		0.9	X		0	X		0	X		0		
10/13/20 4:53	0			0	X		0.6	X		0	X		0	X		0		
10/13/20 4:54	0			0	X		0.7	X		0	X		0	X		0		
10/13/20 4:55	0			0	X		1.2	X		0	X		0	X		0		

CT2 SUSD EVENT 10

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/13/20 5:13	0			0	X		0.5	X		0	X		0	X		0		
10/13/20 5:14	0			0	X		0.7	X		0	X		0	X		0		
10/13/20 5:15	0			0	X		0.8	X		0	X		0	X		0		
10/13/20 5:16	0			0	X		1	X		0	X		0	X		0		
10/13/20 5:17	0			0	X		1.1	X		0	X		0	X		0		
10/13/20 5:18	13708.8			0.4	X		1.2	X		0	X		0	X		1		
10/13/20 5:19	30036.2			1.7	X		1.9	X		0	X		0	X		1		
10/13/20 5:20	41049.5			486.4	X		107.51	X		46.49	X		16.91	X		1		
10/13/20 5:21	51908.8			454.3	X		41.3	X		54.91	X		8.22	X		1		
10/13/20 5:22	66849.9			169.1	X		28.32	X		26.31	X		7.25	X		1		
10/13/20 5:23	104125.6			181.2	X		62.37	X		43.93	X		24.88	X		1		
10/13/20 5:24	117141.3			87	X		66.38	X		23.73	X		29.78	X		1		
10/13/20 5:25	0			84.6	X		56.25	X		0	X		0	X		1		
10/13/20 5:26	0			0	X		58.02	X		0	X		0	X		0		
10/13/20 5:27	0			0	X		0.9	X		0	X		0	X		0		
10/13/20 5:28	0			0	X		0.9	X		0	X		0	X		0		
10/13/20 5:29	0			0	X		0.9	X		0	X		0	X		0		
10/13/20 5:30	0			0	X		0.9	X		0	X		0	X		0		

CT2 SUSD EVENT 11

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/13/20 5:13	0			0	X		0.5	X		0	X		0	X		0		
10/13/20 5:14	0			0	X		0.7	X		0	X		0	X		0		
10/13/20 5:15	0			0	X		0.8	X		0	X		0	X		0		
10/13/20 5:16	0			0	X		1	X		0	X		0	X		0		
10/13/20 5:17	0			0	X		1.1	X		0	X		0	X		0		
10/13/20 5:18	13708.8			0.4	X		1.2	X		0	X		0	X		1		
10/13/20 5:19	30036.2			1.7	X		1.9	X		0	X		0	X		1		
10/13/20 5:20	41049.5			486.4	X		107.51	X		46.49	X		16.91	X		1		
10/13/20 5:21	51908.8			454.3	X		41.3	X		54.91	X		8.22	X		1		
10/13/20 5:22	66849.9			169.1	X		28.32	X		26.31	X		7.25	X		1		
10/13/20 5:23	104125.6			181.2	X		62.37	X		43.93	X		24.88	X		1		
10/13/20 5:24	117141.3			87	X		66.38	X		23.73	X		29.78	X		1		
10/13/20 5:25	0			84.6	X		56.25	X		0	X		0	X		1		
10/13/20 5:26	0			0	X		58.02	X		0	X		0	X		0		
10/13/20 5:27	0			0	X		0.9	X		0	X		0	X		0		
10/13/20 5:28	0			0	X		0.9	X		0	X		0	X		0		
10/13/20 5:29	0			0	X		0.9	X		0	X		0	X		0		
10/13/20 5:30	0			0	X		0.9	X		0	X		0	X		0		

CT2 SUSD EVENT 12

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/13/20 6:20	0			0	X		0.1	X		0	X		0	X		0		
10/13/20 6:21	0			0	X		0.1	X		0	X		0	X		0		
10/13/20 6:22	0			0	X		0.1	X		0	X		0	X		0		
10/13/20 6:23	0			0	X		0.1	X		0	X		0	X		0		
10/13/20 6:24	0			0	X		0.1	X		0	X		0	X		0		
10/13/20 6:25	22796.7			0.8	X		0.1	X		0	X		0	X		1		
10/13/20 6:26	34195.1			3.2	X		1.9	X		0	X		0	X		1		
10/13/20 6:27	45670.5			538.6	X		35.4	X		57.27	X		6.19	X		1		
10/13/20 6:28	55990.6			449.7	X		31.47	X		58.59	X		6.75	X		1		
10/13/20 6:29	74782.5			279.4	X		36.58	X		48.65	X		10.48	X		1		
10/13/20 6:30	113906.6			181.8	X		46.64	X		48.22	X		20.36	X		1		
10/13/20 6:31	84486.5			83.7	X		60.97	X		16.47	X		19.74	X		1		
10/13/20 6:32	0			0	X		46.49	X		0	X		0	X		0		
10/13/20 6:33	0			0	X		1	X		0	X		0	X		0		
10/13/20 6:34	0			0	X		0.4	X		0	X		0	X		0		
10/13/20 6:35	0			0	X		0.4	X		0	X		0	X		0		
10/13/20 6:36	0			0	X		0.3	X		0	X		0	X		0		

CT2 SUSD EVENT 13

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/13/20 6:20	0			0	X		0.1	X		0	X		0	X		0		
10/13/20 6:21	0			0	X		0.1	X		0	X		0	X		0		
10/13/20 6:22	0			0	X		0.1	X		0	X		0	X		0		
10/13/20 6:23	0			0	X		0.1	X		0	X		0	X		0		
10/13/20 6:24	0			0	X		0.1	X		0	X		0	X		0		
10/13/20 6:25	22796.7			0.8	X		0.1	X		0	X		0	X		1		
10/13/20 6:26	34195.1			3.2	X		1.9	X		0	X		0	X		1		
10/13/20 6:27	45670.5			538.6	X		35.4	X		57.27	X		6.19	X		1		
10/13/20 6:28	55990.6			449.7	X		31.47	X		58.59	X		6.75	X		1		
10/13/20 6:29	74782.5			279.4	X		36.58	X		48.65	X		10.48	X		1		
10/13/20 6:30	113906.6			181.8	X		46.64	X		48.22	X		20.36	X		1		
10/13/20 6:31	84486.5			83.7	X		60.97	X		16.47	X		19.74	X		1		
10/13/20 6:32	0			0	X		46.49	X		0	X		0	X		0		
10/13/20 6:33	0			0	X		1	X		0	X		0	X		0		
10/13/20 6:34	0			0	X		0.4	X		0	X		0	X		0		
10/13/20 6:35	0			0	X		0.4	X		0	X		0	X		0		
10/13/20 6:36	0			0	X		0.3	X		0	X		0	X		0		

CT2 SUSD EVENT 14

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/13/20 6:54	0			0	X		0.1	X		0	X		0	X		0		
10/13/20 6:55	0			0	X		0.1	X		0	X		0	X		0		
10/13/20 6:56	0			0	X		0.1	X		0	X		0	X		0		
10/13/20 6:57	0			0	X		0.1	X		0	X		0	X		0		
10/13/20 6:58	0			0	X		0.1	X		0	X		0	X		0		
10/13/20 6:59	20563.3			1.4	X		0.1	X		0	X		0	X		1		
10/13/20 7:00	32962.8			3.4	X		1.7	X		0	X		0	X		1		
10/13/20 7:01	44207.2			486.9	X		30.68	X		50.14	X		5.2	X		1		
10/13/20 7:02	54604.3			440.2	X		30.16	X		55.97	X		6.31	X		1		
10/13/20 7:03	76091.8			272	X		36.29	X		48.16	X		10.57	X		1		
10/13/20 7:04	112520.3			183.7	X		44.67	X		48.12	X		19.25	X		1		
10/13/20 7:05	77940.2			81.1	X		60.97	X		14.72	X		18.22	X		1		
10/13/20 7:06	0			0	X		45.23	X		0	X		0	X		0		
10/13/20 7:07	0			0	X		1.2	X		0	X		0	X		0		
10/13/20 7:08	0			0	X		0.4	X		0	X		0	X		0		
10/13/20 7:09	0			0	X		0.3	X		0	X		0	X		0		
10/13/20 7:10	0			0	X		0.3	X		0	X		0	X		0		

CT2 SUSD EVENT 15

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/13/20 6:54	0			0	X		0.1	X		0	X		0	X		0		
10/13/20 6:55	0			0	X		0.1	X		0	X		0	X		0		
10/13/20 6:56	0			0	X		0.1	X		0	X		0	X		0		
10/13/20 6:57	0			0	X		0.1	X		0	X		0	X		0		
10/13/20 6:58	0			0	X		0.1	X		0	X		0	X		0		
10/13/20 6:59	20563.3			1.4	X		0.1	X		0	X		0	X		1		
10/13/20 7:00	32962.8			3.4	X		1.7	X		0	X		0	X		1		
10/13/20 7:01	44207.2			486.9	X		30.68	X		50.14	X		5.2	X		1		
10/13/20 7:02	54604.3			440.2	X		30.16	X		55.97	X		6.31	X		1		
10/13/20 7:03	76091.8			272	X		36.29	X		48.16	X		10.57	X		1		
10/13/20 7:04	112520.3			183.7	X		44.67	X		48.12	X		19.25	X		1		
10/13/20 7:05	77940.2			81.1	X		60.97	X		14.72	X		18.22	X		1		
10/13/20 7:06	0			0	X		45.23	X		0	X		0	X		0		
10/13/20 7:07	0			0	X		1.2	X		0	X		0	X		0		
10/13/20 7:08	0			0	X		0.4	X		0	X		0	X		0		
10/13/20 7:09	0			0	X		0.3	X		0	X		0	X		0		
10/13/20 7:10	0			0	X		0.3	X		0	X		0	X		0		

CT2 SUSD EVENT 16

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/13/20 7:57	0			0	X		0	X		0	X		0	X		0		
10/13/20 7:58	0			0	X		0	X		0	X		0	X		0		
10/13/20 7:59	0			0	X		0	X		0	X		0	X		0		
10/13/20 8:00	0			0	X		0	X		0	X		0	X		0		
10/13/20 8:01	0			0	X		0	X		0	X		0	X		0		
10/13/20 8:02	2695.6			0.8	X		0	X		0	X		0	X		1		
10/13/20 8:03	22719.7			0.7	X		0	X		0	X		0	X		1		
10/13/20 8:04	35350.3			141.6	X		177	X		11.66	X		24	X		1		
10/13/20 8:05	46209.6			473.7	X		28.81	X		51.01	X		5.1	X		1		
10/13/20 8:06	57299.9			377	X		30.12	X		50.29	X		6.61	X		1		
10/13/20 8:07	82176			239	X		39.24	X		45.73	X		12.36	X		1		
10/13/20 8:08	124072.7			127.2	X		49.25	X		36.74	X		23.41	X		1		
10/13/20 8:09	130619.1			45	X		69.58	X		13.67	X		34.81	X		1		
10/13/20 8:10	136087.2			901.4	X		61.4	X		285.51	X		32.01	X		1		
10/13/20 8:11	153338.8			2005	X		59	X		715.87	X		34.67	X		1		
10/13/20 8:12	174210.1			1239.5	X		58.16	X		502.76	X		38.82	X		1		
10/13/20 8:13	195081.5			273.9	X		55.76	X		124.4	X		41.68	X		1		
10/13/20 8:14	215490.7			20	X		54.25	X		10.04	X		44.79	X		1		
10/13/20 8:15	237748.3			3.5	X		48.79	X		1.95	X		44.45	X		1		
10/13/20 8:16	258696.7			2.9	X		44.51	X		1.75	X		44.11	X		1		
10/13/20 8:17	277873.6			2.7	X		31.02	X		1.72	X		33.03	X		1		
10/13/20 8:18	278027.7			2.7	X		15.03	X		1.73	X		16.01	X		1		
10/13/20 8:19	277642.6			2.8	X		11.98	X		1.82	X		12.74	X		1		
10/13/20 8:20	277950.7			2.7	X		10.35	X		1.76	X		11.02	X		1		
10/13/20 8:21	289888.1			2.4	X		9.03	X		1.62	X		10.03	X		1		
10/13/20 8:22	298359.9			2.2	X		7.74	X		1.54	X		8.85	X		1		
10/13/20 8:23	310066.3			2	X		7.35	X		1.44	X		8.74	X		1		
10/13/20 8:24	320386.4			1.9	X		6.08	X		1.42	X		7.47	X		1		
10/13/20 8:25	325777.6			1.9	X		5.44	X		1.47	X		6.79	X		1		
10/13/20 8:26	329936.4			1.8	X		5.44	X		1.42	X		6.87	X		1		
10/13/20 8:27	342182			1.8	X		5.35	X		1.4	X		7.01	X		1		
10/13/20 8:28	345647.7			1.7	X		5.24	X		1.36	X		6.95	X		1		
10/13/20 8:29	344107.4			1.6	X		5.42	X		1.3	X		7.15	X		1		
10/13/20 8:30	346571.9			1.6	X		5.71	X		1.31	X		7.58	X		1		
10/13/20 8:31	346417.8			1.5	X		5.9	X		1.23	X		7.83	X		1		

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/13/20 8:32	345262.6			1.5	X		5.9	X		1.2	X		7.81	X		1		
10/13/20 8:33	345724.7			1.5	X		6.18	X		1.21	X		8.19	X		1		
10/13/20 8:34	344646.5			1.4	X		6.65	X		1.13	X		8.78	X		1		
10/13/20 8:35	343722.3			1.4	X		6.74	X		1.12	X		8.88	X		1		
10/13/20 8:36	342413			1.4	X		7.12	X		1.12	X		9.34	X		1		
10/13/20 8:37	338023.1			1.4	X		7.61	X		1.12	X		9.86	X		1		
10/13/20 8:38	321002.6			1.3	X		6.93	X		0.98	X		8.52	X		1		
10/13/20 8:39	306831.6			1.3	X		4.79	X		0.92	X		5.64	X		1		
10/13/20 8:40	302364.7			1.4	X		4.43	X		0.97	X		5.13	X		1		
10/13/20 8:41	310374.4			1.4	X		4.15	X		1	X		4.93	X		1		
10/13/20 8:42	314148.2			1.3	X		3.6	X		0.94	X		4.33	X		1		
10/13/20 8:43	311914.7			1.3	X		3.28	X		0.95	X		3.92	X		1		
10/13/20 8:44	301440.5			1.3	X		3.13	X		0.91	X		3.62	X		1		
10/13/20 8:45	300747.4			1.3	X		3.23	X		0.9	X		3.72	X		1		
10/13/20 8:46	301209.5			1.3	X		3.32	X		0.91	X		3.83	X		1		
10/13/20 8:47	301748.6			1.3	X		3.23	X		0.91	X		3.73	X		1		
10/13/20 8:48	298513.9			1.3	X		3.04	X		0.9	X		3.48	X		1		
10/13/20 8:49	299900.2			1.3	X		2.95	X		0.9	X		3.39	X		1		
10/13/20 8:50	302518.8			1.3	X		2.86	X		0.91	X		3.31	X		1		
10/13/20 8:51	304367.1			1.3	X		2.67	X		0.91	X		3.12	X		1		
10/13/20 8:52	302210.7			1.3	X		2.49	X		0.91	X		2.88	X		1		
10/13/20 8:53	302056.7			1.2	X		2.4	X		0.84	X		2.77	X		1		
10/13/20 8:54	302056.7			1.2	X		2.4	X		0.84	X		2.77	X		1		
10/13/20 8:55	300978.4			1.2	X		2.4	X		0.84	X		2.76	X		1		
10/13/20 8:56	296819.6			1.2	X		2.3	X		0.83	X		2.62	X		1		
10/13/20 8:57	296896.6			1.1	X		2.3	X		0.76	X		2.62	X		1		
10/13/20 8:58	297820.8			1.2	X		2.4	X		0.83	X		2.73	X		1		
10/13/20 8:59	297666.7			1.2	X		2.4	X		0.83	X		2.73	X		1		
10/13/20 9:00	296973.6			1.1	X		2.12	X		0.76	X		2.41	X		1		
10/13/20 9:01	295972.4			1.1	X		1.84	X		0.76	X		2.09	X		1		
10/13/20 9:02	297589.7			1.1	X		1.57	X		0.77	X		1.79	X		1		
10/13/20 9:03	296588.5			1.1	X		1.29	X		0.76	X		1.47	X		1		
10/13/20 9:04	297050.6			1	X		1.11	X		0.7	X		1.26	X		0		
10/13/20 9:05	294817.2			1	X		0.92	X		0.7	X		1.04	X		0		
10/13/20 9:06	295202.2			1	X		0.83	X		0.7	X		0.94	X		0		
10/13/20 9:07	297743.8			3	X		0.87	X		2.04	X		1	X		0		
10/13/20 9:08	296280.4			5.7	X		0	X		3.92	X		0	X		0		

CT2 SUSD EVENT 17

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/25/20 23:50	328627.2			0.8			1.66			0.64			2.11			0		
11/25/20 23:51	315534.4			0.8			1.75			0.62			2.14			0		
11/25/20 23:52	294432.1			0.9			1.82			0.63			2.07			0		
11/25/20 23:53	277488.6			1			1.91			0.65			2.05			0		
11/25/20 23:54	274176.9			1			2.3			0.65			2.45			0		
11/25/20 23:55	264395.8			0.9			2.9			0.58			2.97			1		
11/25/20 23:56	245603.9			0.9			4.09			0.49			3.89			1		
11/25/20 23:57	229276.5			0.9			7.25			0.47			6.44			1		
11/25/20 23:58	204323.4			0.7			13.33			0.34			10.54			1		
11/25/20 23:59	181372.6			0.6			16.79			0.24			11.79			1		
11/26/20 0:00	159962.2			5.1			18.6			1.93			11.52			1		
11/26/20 0:01	142710.6			486.2			20.8			163.24			11.49			1		
11/26/20 0:02	127076.4			1495.6			21.24			447.26			10.45			1		
11/26/20 0:03	0			2080.9			24.58			0			0			1		
11/26/20 0:04	0			0			44.25			0			0			0		
11/26/20 0:05	0			0			0.1			0			0			0		
11/26/20 0:06	0			0			0.1			0			0			0		
11/26/20 0:07	0			0			0.1			0			0			0		
11/26/20 0:08	0			0			0.1			0			0			0		

CT2 SUSD EVENT 18

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/22/20 15:37	0			0			0			0			0			0		
12/22/20 15:38	0			0			0			0			0			0		
12/22/20 15:39	0			0			0			0			0			0		
12/22/20 15:40	0			0			0			0			0			0		
12/22/20 15:41	1232.3			0			0			0			0			0		
12/22/20 15:42	2387.5			0.2			0			0			0			1		
12/22/20 15:43	20640.3			0.1			0			0			0			1		
12/22/20 15:44	34349.1			47.2			0			3.8			0			1		
12/22/20 15:45	45362.4			559.3			3.93			59.47			0.69			1		
12/22/20 15:46	55836.6			487.2			7.76			63.8			1.67			1		
12/22/20 15:47	76091.8			328.6			14.75			58.63			4.33			1		
12/22/20 15:48	119913.9			196			21.19			55.16			9.81			1		
12/22/20 15:49	133776.8			88.3			38.46			27.71			19.86			1		
12/22/20 15:50	140785.2			365.4			42.04			120.66			22.84			1		
12/22/20 15:51	159423.1			1857.4			33.37			694.75			20.54			1		
12/22/20 15:52	178754.1			1246			45.07			522.42			31.1			1		
12/22/20 15:53	201088.7			296.6			54.4			139.88			42.22			1		
12/22/20 15:54	222499.1			22			55.99			11.47			48.1			1		
12/22/20 15:55	244217.6			5.9			60.48			3.38			57.01			1		
12/22/20 15:56	267091.4			4.8			60.12			3			61.99			1		
12/22/20 15:57	291505.5			4.1			40.01			2.84			45.03			1		
12/22/20 15:58	307370.8			3.9			21.72			2.84			25.78			1		
12/22/20 15:59	324314.3			4.1			20.22			3.1			25.31			1		
12/22/20 16:00	340872.7			4.6			16.75			3.68			22.04			1		
12/22/20 16:01	361667			5.5			13.41			4.7			18.72			1		
12/22/20 16:02	380381.9			13.3			12.44			11.82			18.26			1		
12/22/20 16:03	404410.9			14.8			11.25			13.99			17.56			1		
12/22/20 16:04	411804.4			9.2			11.52			8.87			18.32			1		
12/22/20 16:05	410187.1			6.1			10.88			5.86			17.23			1		
12/22/20 16:06	409031.8			5.3			9.77			5.13			15.43			1		
12/22/20 16:07	410110.1			4.6			9.55			4.41			15.12			1		
12/22/20 16:08	409185.9			3.5			9.18			3.33			14.5			1		
12/22/20 16:09	407645.5			2.7			8.8			2.6			13.85			1		
12/22/20 16:10	407491.5			2.2			9.74			2.06			15.32			1		
12/22/20 16:11	409108.8			1.9			9.83			1.8			15.53			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSDTF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/22/20 16:12	407491.5			1.7			10.11			1.61			15.91			1		
12/22/20 16:13	408338.7			1.7			10.4			1.61			16.39			1		
12/22/20 16:14	408107.6			1.6			10.58			1.52			16.67			1		
12/22/20 16:15	407491.5			1.5			10.68			1.43			16.79			1		
12/22/20 16:16	407799.6			1.4			11.05			1.34			17.4			1		
12/22/20 16:17	406952.4			1.4			11.52			1.34			18.1			1		
12/22/20 16:18	408415.7			1.3			12.08			1.26			19.05			1		
12/22/20 16:19	408492.7			1.2			12.55			1.17			19.79			1		
12/22/20 16:20	405951.2			1.1			11.89			1.07			18.64			1		
12/22/20 16:21	409648			1			6.74			0.99			10.66			1		
12/22/20 16:22	408646.8			1			4.68			0.99			7.39			1		
12/22/20 16:23	409493.9			0.9			4.03			0.9			6.37			1		
12/22/20 16:24	408184.7			0.9			3.47			0.9			5.46			1		
12/22/20 16:25	409339.9			0.9			3.28			0.9			5.18			1		
12/22/20 16:26	408030.6			0.9			2.9			0.9			4.57			1		
12/22/20 16:27	409108.8			0.8			2.53			0.81			3.99			1		
12/22/20 16:28	409185.9			0.8			2.25			0.81			3.55			1		
12/22/20 16:29	408877.8			0.8			1.97			0.81			3.1			1		
12/22/20 16:30	410495.1			0.8			1.78			0.81			2.82			1		
12/22/20 16:31	408569.7			0.8			1.59			0.81			2.51			1		
12/22/20 16:32	409493.9			0.8			1.5			0.81			2.37			0		
12/22/20 16:33	407645.5			0.8			1.4			0.81			2.21			0		
12/22/20 16:34	409956			0.8			1.4			0.81			2.22			0		
12/22/20 16:35	410264.1			0.8			1.31			0.81			2.08			0		
12/22/20 16:36	407414.5			0.9			1.31			0.9			2.06			0		

CT2 SUSD EVENT 19

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/22/20 18:18	272790.6			0.7			1.97			0.48			2.07			0		
12/22/20 18:19	274099.8			0.7			1.97			0.48			2.08			0		
12/22/20 18:20	272713.6			0.7			1.87			0.48			1.97			0		
12/22/20 18:21	274484.9			0.7			1.87			0.48			1.99			0		
12/22/20 18:22	273021.6			0.7			1.78			0.48			1.88			0		
12/22/20 18:23	273791.8			0.7			1.78			0.48			1.88			1		
12/22/20 18:24	263163.6			0.7			1.69			0.46			1.71			1		
12/22/20 18:25	243293.5			0.7			2.15			0.43			2.02			1		
12/22/20 18:26	222961.2			0.8			5.04			0.4			4.34			1		
12/22/20 18:27	202937.1			0.7			8.75			0.34			6.85			1		
12/22/20 18:28	178215			0.6			12.58			0.23			8.66			1		
12/22/20 18:29	158036.8			7			14.44			2.61			8.81			1		
12/22/20 18:30	140015			433.9			16.69			142.47			9.02			1		
12/22/20 18:31	113598.6			1387			18.19			369.77			7.98			1		
12/22/20 18:32	0			1909.8			22.22			0			0			1		
12/22/20 18:33	0			0			35.4			0			0			0		
12/22/20 18:34	0			0			0.2			0			0			0		
12/22/20 18:35	0			0			0.1			0			0			0		
12/22/20 18:36	0			0			0.1			0			0			0		
12/22/20 18:37	0			0			0.1			0			0			0		

AQ-32

AQ-32 The Project owner shall maintain hourly records of NO_x and CO emission concentrations (ppmv @ 15% O₂), and hourly, daily, and quarterly records of NO_x and CO emissions. Ongoing compliance with the CO emission limits during normal operation shall be deemed compliance with the VOC emission limits during normal operation.

Verification: The project owner shall submit to the CPM all concentration, hourly, daily, and quarter NO_x and CO emissions as part of the Quarterly Air Quality Report required by Condition of Certification AQ-SC6

AQ32 DAILY NOX CO

Date/Time	CT1_CO_Lb_1D			CT1_NOx_Lb_1D			CT2_CO_Lb_1D			CT2_NOx_Lb_1D			Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc						
10/01/20 0:00	14.27			65.16			17.77			63.67								
10/02/20 0:00	17.29			56.31			20.41			54.49								
10/03/20 0:00	17.03			57.75			20.23			55.7								
10/04/20 0:00	13.9			63.87			17.64			62.74								
10/05/20 0:00	13.31			65.65			16.65			64.12								
10/06/20 0:00	12.72			64.47			16.86			61.86								
10/07/20 0:00	16.45			62.48			19.71			60.56								
10/08/20 0:00	10.65			9.92			15.95			62.26								
10/09/20 0:00	0			0			18.68			64.29								
10/10/20 0:00	25.53			30.6			11.51			32.73								
10/11/20 0:00	14.62			58.73			0			0								
10/12/20 0:00	18.41			64.2			0			0								
10/13/20 0:00	16.38			69.47			11.62			39.33								
10/14/20 0:00	12.76			62.36			16.02			61.75								
10/15/20 0:00	27.55			42.95			14.43			65.73								
10/16/20 0:00	12.31			61.74			17.18			61.83								
10/17/20 0:00	13.37			60.23			18.07			59.74								
10/18/20 0:00	15.8			58.03			21.24			57.8								
10/19/20 0:00	16.29			58.36			21.29			61.05								
10/20/20 0:00	14.34			61.81			19.05			60.65								
10/21/20 0:00	14.84			52.09			18.62			51.8								
10/22/20 0:00	15.49			55.63			19.86			54.51								
10/23/20 0:00	25.75			51.73			20.23			53.55								
10/24/20 0:00	0			0			19.31			58.09								
10/25/20 0:00	0			0			22.17			63.02								
10/26/20 0:00	0			0			18.74			70.73								
10/27/20 0:00	0			0			25.7			59.82								
10/28/20 0:00	0			0			29.48			59.42								
10/29/20 0:00	0			0			28.36			61.9								
10/30/20 0:00	0			0			28.36			63.68								
10/31/20 0:00	0			0			26.13			58.71								
11/01/20 0:00	0			0			22.05			59.02								
11/02/20 0:00	0			0			25.02			68.39								
11/03/20 0:00	0			0			22.06			69								
11/04/20 0:00	0			0			25.74			58.94								

Date/Time	CT1_CO_Lb_1D			CT1_NOx_Lb_1D			CT2_CO_Lb_1D			CT2_NOx_Lb_1D			Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc						
11/05/20 0:00	0			0			23.48			57.64								
11/06/20 0:00	0			0			22.66			53.49								
11/07/20 0:00	0			0			24.13			54.36								
11/08/20 0:00	0			0			25.8			53.58								
11/09/20 0:00	0			0			30.19			57.78								
11/10/20 0:00	0			0			27.77			59.6								
11/11/20 0:00	0			0			26.25			55.03								
11/12/20 0:00	0			0			26.64			54.55								
11/13/20 0:00	0			0			29.66			57.27								
11/14/20 0:00	0			0			26.1			55.72								
11/15/20 0:00	0			0			29.68			58.41								
11/16/20 0:00	0			0			33.26			58.52								
11/17/20 0:00	0			0			24.1			55.5								
11/18/20 0:00	0			0			19.38			56.27								
11/19/20 0:00	0			0			16.49			55.86								
11/20/20 0:00	0			0			26			59.46								
11/21/20 0:00	0			0			21.74			58.98								
11/22/20 0:00	0			0			23.55			60.68								
11/23/20 0:00	0			0			25.27			56.9								
11/24/20 0:00	0			0			26.87			57.33								
11/25/20 0:00	0			0			18.5			58.11								
11/26/20 0:00	0			0			15.65			0.61								
11/27/20 0:00	0			0			0			0								
11/28/20 0:00	0			0			0			0								
11/29/20 0:00	0			0			0			0								
11/30/20 0:00	0			0			0			0								
12/01/20 0:00	0			0			0			0								
12/02/20 0:00	0			0			0			0								
12/03/20 0:00	0			0			0			0								
12/04/20 0:00	0			0			0			0								
12/05/20 0:00	0			0			0			0								
12/06/20 0:00	0			0			0			0								
12/07/20 0:00	0			0			0			0								
12/08/20 0:00	0			0			0			0								
12/09/20 0:00	0			0			0			0								
12/10/20 0:00	0			0			0			0								
12/11/20 0:00	0			0			0			0								
12/12/20 0:00	0			0			0			0								

Date/Time	CT1_CO_Lb_1D			CT1_NOx_Lb_1D			CT2_CO_Lb_1D			CT2_NOx_Lb_1D			Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc						
12/13/20 0:00	0			0			0			0								
12/14/20 0:00	0			0			0			0								
12/15/20 0:00	0			0			0			0								
12/16/20 0:00	0			0			0			0								
12/17/20 0:00	0			0			0			0								
12/18/20 0:00	0			0			0			0								
12/19/20 0:00	0			0			0			0								
12/20/20 0:00	0			0			0			0								
12/21/20 0:00	0			0			0			0								
12/22/20 0:00	51.18			16.92			53.69			22.57								
12/23/20 0:00	0			0			0			0								
12/24/20 0:00	0			0			0			0								
12/25/20 0:00	0			0			0			0								
12/26/20 0:00	0			0			0			0								
12/27/20 0:00	0			0			0			0								
12/28/20 0:00	0			0			0			0								
12/29/20 0:00	0			0			0			0								
12/30/20 0:00	0			0			0			0								
12/31/20 0:00	0			0			0			0								

AQ32 HOURLY NOX CO

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/01/20 0:00	0.8			1.7			14.4		1	1			1.7			14.6		1
10/01/20 1:00	0.7			1.7			14.5		1	0.9			1.7			14.6		1
10/01/20 2:00	0.7			1.7			14.5		1	1			1.7			14.6		1
10/01/20 3:00	0.7			1.7			14.5		1	0.9			1.7			14.6		1
10/01/20 4:00	1.3			1.7			14.5		1	1.4			1.7			14.6		1
10/01/20 5:00	1.3			1.7			14.5		1	1.5			1.7			14.6		1
10/01/20 6:00	0.8			1.7			14.5		1	0.9			1.7			14.6		1
10/01/20 7:00	1.1			1.7			14.4		1	1.3			1.7			14.5		1
10/01/20 8:00	1			1.7			14.4		1	1.1			1.7			14.6		1
10/01/20 9:00	0.7			1.7			14.6		1	1			1.7			14.7		1
10/01/20 10:00	1.2			1.7			14.1		1	1.2			1.7			13.9		1
10/01/20 11:00	0.2			1.6			12.7		1	0.4			1.7			12.9		1
10/01/20 12:00	0.1			1.7			12.4		1	0.3			1.7			12.5		1
10/01/20 13:00	0.1			1.7			11.9		1	0.3			1.7			12.3		1
10/01/20 14:00	0.1			1.7			11.7		1	0.3			1.7			12		1
10/01/20 15:00	0.1			1.7			12.5		1	0.3			1.7			12.7		1
10/01/20 16:00	0.1			1.7			11.8		1	0.3			1.7			12		1
10/01/20 17:00	0.1			1.7			12		1	0.3			1.7			12.2		1
10/01/20 18:00	0.7			1.8			14.5		1	0.9			1.8			14.5		1
10/01/20 19:00	1.2			1.7			14		1	1.3			1.7			14.1		1
10/01/20 20:00	1.1			1.7			13.9		1	1.2			1.7			14		1
10/01/20 21:00	0.7			1.7			13.4		1	0.9			1.7			13.5		1
10/01/20 22:00	0.8			1.8			14.5		1	1			1.7			14.6		1
10/01/20 23:00	0.8			1.7			14.5		1	1			1.7			14.6		1
10/02/20 0:00	0.9			1.7			14.4		1	1			1.7			14.6		1
10/02/20 1:00	0.7			1.7			14.5		1	1			1.7			14.6		1
10/02/20 2:00	0.7			1.7			14.5		1	1			1.7			14.5		1
10/02/20 3:00	0.8			1.7			14.5		1	1.1			1.7			14.5		1
10/02/20 4:00	0.8			1.6			14.4		1	1.1			1.7			14.4		1
10/02/20 5:00	0.9			1.7			14.5		1	0.9			1.7			14.6		1
10/02/20 6:00	1.1			1.7			14.5		1	1.3			1.7			14.6		1
10/02/20 7:00	1			1.7			14.5		1	1.2			1.7			14.6		1
10/02/20 8:00	0.9			1.7			14.5		1	1.1			1.7			14.7		1
10/02/20 9:00	0.8			1.7			14.4		1	1			1.7			14.6		1
10/02/20 10:00	0.8			1.7			14.5		1	0.9			1.7			14.7		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/02/20 11:00	0.7			1.7			14.6		1	0.9			1.7			14.7		1
10/02/20 12:00	1.1			1.7			14.3		1	1.5			1.7			14.5		1
10/02/20 13:00	1			1.7			14		1	1.1			1.7			14.1		1
10/02/20 14:00	0.7			1.7			13.5		1	0.8			1.7			13.6		1
10/02/20 15:00	0.9			1.7			14.4		1	1.1			1.7			14.5		1
10/02/20 16:00	0.3			1.6			12.7		1	0.5			1.7			12.8		1
10/02/20 17:00	0.5			1.7			13.2		1	0.6			1.7			13.3		1
10/02/20 18:00	0.8			1.8			14.3		1	1			1.8			14.4		1
10/02/20 19:00	1.2			1.7			14.1		1	1.3			1.7			14.1		1
10/02/20 20:00	1			1.7			14.4		1	1.1			1.7			14.5		1
10/02/20 21:00	1.1			1.7			14.2		1	1.3			1.7			14.2		1
10/02/20 22:00	1			1.8			14.6		1	1.2			1.7			14.7		1
10/02/20 23:00	1			1.7			14.4		1	1.1			1.7			14.6		1
10/03/20 0:00	0.9			1.7			14.4		1	1.1			1.7			14.5		1
10/03/20 1:00	0.8			1.7			14.5		1	1.2			1.7			14.5		1
10/03/20 2:00	1			1.7			14.5		1	1.2			1.7			14.6		1
10/03/20 3:00	1			1.7			14.5		1	1.2			1.7			14.6		1
10/03/20 4:00	1			1.7			14.5		1	1.1			1.7			14.6		1
10/03/20 5:00	1			1.7			14.5		1	1			1.7			14.6		1
10/03/20 6:00	0.8			1.7			14.5		1	0.9			1.7			14.6		1
10/03/20 7:00	0.9			1.7			14.5		1	1			1.7			14.6		1
10/03/20 8:00	1			1.7			14.4		1	1.2			1.7			14.5		1
10/03/20 9:00	0.9			1.7			14.5		1	1			1.7			14.7		1
10/03/20 10:00	0.7			1.7			14.6		1	1			1.7			14.8		1
10/03/20 11:00	0.7			1.7			14.4		1	0.9			1.7			14.6		1
10/03/20 12:00	0.7			1.7			14.4		1	0.9			1.7			14.6		1
10/03/20 13:00	1.2			1.7			14.1		1	1.5			1.7			14.2		1
10/03/20 14:00	0.4			1.7			13.1		1	0.5			1.7			13.2		1
10/03/20 15:00	0.8			1.8			14.3		1	0.9			1.7			14.4		1
10/03/20 16:00	1.1			1.7			14.1		1	1.3			1.7			14.2		1
10/03/20 17:00	0.7			1.7			14.5		1	0.9			1.7			14.6		1
10/03/20 18:00	0.3			1.6			12.4		1	0.5			1.7			12.6		1
10/03/20 19:00	0.7			1.7			13.5		1	0.9			1.7			13.6		1
10/03/20 20:00	0.8			1.8			14.5		1	1			1.7			14.6		1
10/03/20 21:00	1.1			1.7			14		1	1.3			1.7			14		1
10/03/20 22:00	0.8			1.7			14.5		1	1			1.7			14.7		1
10/03/20 23:00	0.8			1.7			14.4		1	1			1.7			14.7		1
10/04/20 0:00	0.8			1.7			14.5		1	1			1.7			14.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/04/20 1:00	0.8			1.7			14.4		1	1			1.7			14.6		1
10/04/20 2:00	0.7			1.7			14.5		1	1			1.7			14.5		1
10/04/20 3:00	0.7			1.7			14.5		1	0.9			1.7			14.7		1
10/04/20 4:00	0.7			1.7			14.5		1	0.9			1.7			14.6		1
10/04/20 5:00	0.8			1.7			14.4		1	1			1.7			14.5		1
10/04/20 6:00	0.9			1.7			14.5		1	1.2			1.7			14.5		1
10/04/20 7:00	1.3			1.7			14.4		1	1.5			1.7			14.6		1
10/04/20 8:00	1.1			1.7			14.5		1	1.2			1.7			14.7		1
10/04/20 9:00	0.7			1.7			14.5		1	0.9			1.7			14.6		1
10/04/20 10:00	1.2			1.7			14.3		1	1.7			1.7			14.4		1
10/04/20 11:00	0.7			1.7			13.5		1	0.8			1.7			13.6		1
10/04/20 12:00	0.2			1.7			12.5		1	0.3			1.7			12.7		1
10/04/20 13:00	0.1			1.7			11.9		1	0.2			1.7			12.1		1
10/04/20 14:00	0.1			1.7			11.9		1	0.2			1.7			12		1
10/04/20 15:00	0.1			1.7			11.9		1	0.2			1.7			12		1
10/04/20 16:00	0.1			1.7			12.2		1	0.2			1.7			12.3		1
10/04/20 17:00	0.2			1.7			12.7		1	0.4			1.7			12.8		1
10/04/20 18:00	0.3			1.7			13		1	0.5			1.7			13.1		1
10/04/20 19:00	1.1			1.8			14.3		1	1.6			1.7			14.4		1
10/04/20 20:00	1.2			1.7			14.5		1	1.4			1.7			14.6		1
10/04/20 21:00	0.9			1.7			14.5		1	1			1.7			14.6		1
10/04/20 22:00	0.8			1.7			14.4		1	0.9			1.7			14.5		1
10/04/20 23:00	0.8			1.7			14.4		1	0.9			1.7			14.5		1
10/05/20 0:00	0.7			1.7			14.5		1	0.9			1.7			14.5		1
10/05/20 1:00	0.7			1.7			14.5		1	0.9			1.7			14.7		1
10/05/20 2:00	0.8			1.7			14.5		1	0.9			1.7			14.6		1
10/05/20 3:00	0.8			1.7			14.5		1	0.9			1.7			14.6		1
10/05/20 4:00	0.7			1.7			14.5		1	0.9			1.6			14.5		1
10/05/20 5:00	1			1.7			14.3		1	1			1.7			14.5		1
10/05/20 6:00	0.9			1.7			14.3		1	1			1.7			14.5		1
10/05/20 7:00	0.9			1.7			14.3		1	1			1.7			14.6		1
10/05/20 8:00	0.8			1.7			14.5		1	1			1.7			14.7		1
10/05/20 9:00	0.7			1.7			14.5		1	0.9			1.7			14.6		1
10/05/20 10:00	1			1.6			14.1		1	1.6			1.7			14.2		1
10/05/20 11:00	0.5			1.7			13.3		1	0.7			1.7			13.5		1
10/05/20 12:00	0.6			1.7			13.5		1	0.7			1.6			13.6		1
10/05/20 13:00	0.1			1.7			12.1		1	0.3			1.7			12.3		1
10/05/20 14:00	0.1			1.7			11.7		1	0.2			1.7			12		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/05/20 15:00	0.1			1.7			11.7		1	0.2			1.7			12		1
10/05/20 16:00	0.1			1.7			11.7		1	0.2			1.7			12		1
10/05/20 17:00	0.1			1.7			12.2		1	0.2			1.7			12.4		1
10/05/20 18:00	0.2			1.7			12.7		1	0.3			1.7			12.9		1
10/05/20 19:00	0.4			1.7			13		1	0.6			1.7			13.2		1
10/05/20 20:00	0.9			1.7			13.7		1	1.1			1.7			13.9		1
10/05/20 21:00	1			1.8			14.5		1	1.3			1.7			14.7		1
10/05/20 22:00	1.1			1.7			14.4		1	1.2			1.7			14.6		1
10/05/20 23:00	1			1.7			14.4		1	1.2			1.7			14.6		1
10/06/20 0:00	1.4			1.7			14.5		1	1.7			1.7			14.6		1
10/06/20 1:00	1.1			1.7			14.5		1	1.2			1.7			14.7		1
10/06/20 2:00	0.8			1.7			14.5		1	1			1.7			14.7		1
10/06/20 3:00	0.7			1.7			14.5		1	0.9			1.7			14.7		1
10/06/20 4:00	0.7			1.7			14.5		1	0.9			1.7			14.7		1
10/06/20 5:00	0.9			1.7			14.3		1	1			1.7			14.5		1
10/06/20 6:00	0.9			1.7			14.3		1	1			1.7			14.5		1
10/06/20 7:00	0.9			1.7			14.4		1	1			1.7			14.6		1
10/06/20 8:00	0.8			1.7			14.5		1	1			1.7			14.8		1
10/06/20 9:00	0.7			1.7			14.5		1	0.9			1.7			14.7		1
10/06/20 10:00	0.9			1.6			14.3		1	1.4			1.7			14.3		1
10/06/20 11:00	0.6			1.7			13.5		1	0.8			1.7			13.7		1
10/06/20 12:00	0.7			1.8			14		1	1.3			1.8			14.3		1
10/06/20 13:00	0.2			1.5			12.5		1	0.6			1.5			13		1
10/06/20 14:00	0.1			1.7			12.7		1	0.3			1.7			12.7		1
10/06/20 15:00	0			1.7			12.1		1	0.2			1.7			12.1		1
10/06/20 16:00	0			1.7			12.1		1	0.2			1.7			12.2		1
10/06/20 17:00	0.1			1.7			12.7		1	0.3			1.7			12.8		1
10/06/20 18:00	0.3			1.7			13.3		1	0.5			1.7			13.3		1
10/06/20 19:00	0.2			1.7			13		1	0.4			1.7			13		1
10/06/20 20:00	0.3			1.7			13		1	0.4			1.7			13		1
10/06/20 21:00	1.1			1.8			14.4		1	1.3			1.7			14.4		1
10/06/20 22:00	0.8			1.7			14.7		1	1			1.7			14.7		1
10/06/20 23:00	0.8			1.7			14.6		1	0.9			1.7			14.6		1
10/07/20 0:00	0.7			1.7			14.7		1	0.9			1.7			14.6		1
10/07/20 1:00	0.7			1.7			14.7		1	0.9			1.7			14.7		1
10/07/20 2:00	0.7			1.7			14.7		1	0.9			1.7			14.7		1
10/07/20 3:00	0.7			1.7			14.7		1	0.9			1.7			14.7		1
10/07/20 4:00	0.8			1.7			14.7		1	1			1.6			14.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/07/20 5:00	1.1			1.7			14.5		1	1.3			1.7			14.5		1
10/07/20 6:00	1.1			1.7			14.4		1	1.3			1.7			14.4		1
10/07/20 7:00	0.8			1.7			14.6		1	1			1.7			14.6		1
10/07/20 8:00	0.8			1.7			14.6		1	1			1.7			14.7		1
10/07/20 9:00	0.8			1.7			14.7		1	1			1.7			14.8		1
10/07/20 10:00	1.1			1.7			14.4		1	1.5			1.7			14.4		1
10/07/20 11:00	1			1.7			14		1	1.1			1.7			14.1		1
10/07/20 12:00	0.7			1.7			13.7		1	0.8			1.7			13.7		1
10/07/20 13:00	0.4			1.7			13.2		1	0.5			1.7			13.2		1
10/07/20 14:00	0.1			1.7			12		1	0.2			1.7			12.1		1
10/07/20 15:00	0.1			1.7			12.1		1	0.2			1.7			12.2		1
10/07/20 16:00	0.7			1.7			13.8		1	0.8			1.7			13.8		1
10/07/20 17:00	1			1.7			14.3		1	1.2			1.7			14.3		1
10/07/20 18:00	1.1			1.7			14.4		1	1.3			1.7			14.5		1
10/07/20 19:00	1.1			1.7			14.4		1	1.3			1.7			14.4		1
10/07/20 20:00	0.9			1.7			13.9		1	1			1.7			13.9		1
10/07/20 21:00	0.7			1.8			14.6		1	0.9			1.7			14.6		1
10/07/20 22:00	0.8			1.7			14.5		1	0.9			1.7			14.6		1
10/07/20 23:00	0.7			1.7			14.6		1	0.9			1.7			14.5		1
10/08/20 0:00	0.7			1.7			14.6		1	0.8			1.7			14.6		1
10/08/20 1:00	0.7			1.7			14.6		1	0.9			1.7			14.7		1
10/08/20 2:00	0.7			1.7			14.6		1	0.9			1.7			14.7		1
10/08/20 3:00	0.7			1.7			14.6		1	0.8			1.7			14.7		1
10/08/20 4:00	0.7			1.7			14.6		1	0.8			1.7			14.6		1
10/08/20 5:00	0			0			16.9		1	0.8			1.7			14.6		1
10/08/20 6:00	0	X		0	X		0	X	1	0.8			1.7			14.6		1
10/08/20 7:00	0	X		0	X		0	X	1	0.9			1.7			14.7		1
10/08/20 8:00	0	X		0	X		0	X	1	1.5			1.7			14.5		1
10/08/20 9:00	0	X		0	X		0	X	1	0.9			1.7			13.7		1
10/08/20 10:00	0	X		0	X		0	X	1	0.5			1.7			13.1		1
10/08/20 11:00	0	X		0	X		0	X	1	0.6			1.7			13.3		1
10/08/20 12:00	0	X		0	X		0	X	1	0.4			1.7			13		1
10/08/20 13:00	0	X		0	X		0	X	1	0.4			1.7			12.9		1
10/08/20 14:00	0	X		0	X		0	X	1	0.6			1.7			13.4		1
10/08/20 15:00	0	X		0	X		0	X	1	0.9			1.7			14.6		1
10/08/20 16:00	0	X		0	X		0	X	1	0.9			1.7			14.6		1
10/08/20 17:00	0	X		0	X		0	X	1	0.9			1.7			14.6		1
10/08/20 18:00	0	X		0	X		0	X	1	0.9			1.7			14.7		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/08/20 19:00	0	X		0	X		0	X	1	0.5			1.7			12.3		1
10/08/20 20:00	0	X		0	X		0	X	1	1			1.7			13.9		1
10/08/20 21:00	0	X		0	X		0	X	1	0.5			1.7			12.4		1
10/08/20 22:00	0	X		0	X		0	X	1	0.3			1.7			12		1
10/08/20 23:00	0	X		0	X		0	X	1	0.9			1.8			14.5		1
10/09/20 0:00	0	X		0	X		0	X	1	0.9			1.7			14.5		1
10/09/20 1:00	0	X		0	X		0	X	1	0.9			1.7			14.5		1
10/09/20 2:00	0	X		0	X		0	X	1	1			1.7			14.5		1
10/09/20 3:00	0	X		0	X		0	X	1	1			1.7			14.5		1
10/09/20 4:00	0	X		0	X		0	X	1	0.9			1.7			14.5		1
10/09/20 5:00	0	X		0	X		0	X	1	0.8			1.7			14.6		1
10/09/20 6:00	0	X		0	X		0	X	1	1			1.7			14.6		1
10/09/20 7:00	0	X		0	X		0	X	1	1.7			1.7			14.5		1
10/09/20 8:00	0	X		0	X		0	X	1	1.1			1.7			13.9		1
10/09/20 9:00	0	X		0	X		0	X	1	0.6			1.7			13.3		1
10/09/20 10:00	0	X		0	X		0	X	1	0.4			1.7			13		1
10/09/20 11:00	0	X		0	X		0	X	1	0.3			1.7			12.7		1
10/09/20 12:00	0	X		0	X		0	X	1	0.3			1.7			12.5		1
10/09/20 13:00	0	X		0	X		0	X	1	0.5			1.7			13.1		1
10/09/20 14:00	0	X		0	X		0	X	1	0.4			1.7			12.8		1
10/09/20 15:00	0	X		0	X		0	X	1	1			1.7			14		1
10/09/20 16:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1
10/09/20 17:00	0	X		0	X		0	X	1	1.1			1.7			13.9		1
10/09/20 18:00	0	X		0	X		0	X	1	0.9			1.7			13.8		1
10/09/20 19:00	0	X		0	X		0	X	1	1			1.7			14.1		1
10/09/20 20:00	0	X		0	X		0	X	1	1			1.7			14.7		1
10/09/20 21:00	0	X		0	X		0	X	1	1			1.7			14.7		1
10/09/20 22:00	0	X		0	X		0	X	1	0.9			1.7			14.7		1
10/09/20 23:00	0	X		0	X		0	X	1	0.9			1.7			14.6		1
10/10/20 0:00	0	X		0	X		0	X	1	0.9			1.7			14.5		1
10/10/20 1:00	0	X		0	X		0	X	1	0.9			1.7			14.5		1
10/10/20 2:00	0	X		0	X		0	X	1	0.8			1.7			14.6		1
10/10/20 3:00	0	X		0	X		0	X	1	0.8			1.7			14.5		1
10/10/20 4:00	0	X		0	X		0	X	1	0.8			1.7			14.6		1
10/10/20 5:00	0	X		0	X		0	X	1	0.9			1.7			14.5		1
10/10/20 6:00	0	X		0	X		0	X	1	0.9			1.7			14.5		1
10/10/20 7:00	0	X		0	X		0	X	1	0.8			1.7			14.6		1
10/10/20 8:00	0	X		0	X		0	X	1	0.9			1.7			14.7		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/10/20 9:00	0	X		0	X		0	X	1	0.8			1.7			13.7		1
10/10/20 10:00	0	X		0	X		0	X	1	0.5			1.7			13.4		1
10/10/20 11:00	0	X		0	X		0	X	1	0.5			1.7			13.3		1
10/10/20 12:00	0	X		0	X		0	X	1	0.6			1.7			13.4		1
10/10/20 13:00	0	X		0	X		0	X	1	1.4			1.8			14.5		1
10/10/20 14:00	0	X		0	X		0	X	1	0			0			20.2		1
10/10/20 15:00	0			0			15.5		1	0	X		0	X		0	X	1
10/10/20 16:00	0.7			1.6			14.6		1	0	X		0	X		0	X	1
10/10/20 17:00	0.6			1.7			14.7		1	0	X		0	X		0	X	1
10/10/20 18:00	0.7			1.7			14.6		1	0	X		0	X		0	X	1
10/10/20 19:00	0.7			1.7			14.5		1	0	X		0	X		0	X	1
10/10/20 20:00	0.7			1.7			14.6		1	0	X		0	X		0	X	1
10/10/20 21:00	0.9			1.7			14.5		1	0	X		0	X		0	X	1
10/10/20 22:00	0.7			1.7			14.6		1	0	X		0	X		0	X	1
10/10/20 23:00	0.7			1.7			14.6		1	0	X		0	X		0	X	1
10/11/20 0:00	0.7			1.7			14.5		1	0	X		0	X		0	X	1
10/11/20 1:00	0.7			1.7			14.4		1	0	X		0	X		0	X	1
10/11/20 2:00	0.7			1.7			14.4		1	0	X		0	X		0	X	1
10/11/20 3:00	0.8			1.7			14.4		1	0	X		0	X		0	X	1
10/11/20 4:00	0.7			1.6			14.4		1	0	X		0	X		0	X	1
10/11/20 5:00	0.8			1.7			14.6		1	0	X		0	X		0	X	1
10/11/20 6:00	0.7			1.7			14.7		1	0	X		0	X		0	X	1
10/11/20 7:00	0.7			1.7			14.6		1	0	X		0	X		0	X	1
10/11/20 8:00	0.7			1.7			14.6		1	0	X		0	X		0	X	1
10/11/20 9:00	0.7			1.7			14.7		1	0	X		0	X		0	X	1
10/11/20 10:00	0.7			1.7			14.8		1	0	X		0	X		0	X	1
10/11/20 11:00	0.7			1.7			14.6		1	0	X		0	X		0	X	1
10/11/20 12:00	0.7			1.7			14.6		1	0	X		0	X		0	X	1
10/11/20 13:00	0.8			1.7			14.6		1	0	X		0	X		0	X	1
10/11/20 14:00	0.1			1.6			12.2		1	0	X		0	X		0	X	1
10/11/20 15:00	0.3			1.7			13.1		1	0			0			21.1		1
10/11/20 16:00	0.8			1.8			14.7		1	0	X		0	X		0	X	1
10/11/20 17:00	0.7			1.7			14.5		1	0	X		0	X		0	X	1
10/11/20 18:00	0.7			1.7			14.5		1	0	X		0	X		0	X	1
10/11/20 19:00	0.6			1.7			14.5		1	0	X		0	X		0	X	1
10/11/20 20:00	0.7			1.7			14.6		1	0	X		0	X		0	X	1
10/11/20 21:00	1.3			1.7			14.6		1	0	X		0	X		0	X	1
10/11/20 22:00	0.9			1.7			14.5		1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/11/20 23:00	0.8			1.7			14.4		1	0	X		0	X		0	X	1
10/12/20 0:00	0.8			1.7			14.4		1	0	X		0	X		0	X	1
10/12/20 1:00	0.9			1.7			14.4		1	0	X		0	X		0	X	1
10/12/20 2:00	0.8			1.7			14.5		1	0	X		0	X		0	X	1
10/12/20 3:00	0.8			1.7			14.5		1	0	X		0	X		0	X	1
10/12/20 4:00	0.9			1.7			14.5		1	0	X		0	X		0	X	1
10/12/20 5:00	1.2			1.7			14.3		1	0	X		0	X		0	X	1
10/12/20 6:00	1.1			1.7			13.9		1	0	X		0	X		0	X	1
10/12/20 7:00	1.5			1.7			13.9		1	0	X		0	X		0	X	1
10/12/20 8:00	1.3			1.7			14.1		1	0	X		0	X		0	X	1
10/12/20 9:00	1			1.7			14.1		1	0	X		0	X		0	X	1
10/12/20 10:00	0.8			1.7			13.9		1	0	X		0	X		0	X	1
10/12/20 11:00	0.8			1.8			14.6		1	0	X		0	X		0	X	1
10/12/20 12:00	0.7			1.7			14.7		1	0	X		0	X		0	X	1
10/12/20 13:00	0.2			1.6			12.7		1	0	X		0	X		0	X	1
10/12/20 14:00	0.1			1.7			11.9		1	0	X		0	X		0	X	1
10/12/20 15:00	0.1			1.7			11.9		1	0	X		0	X		0	X	1
10/12/20 16:00	0.7			1.8			14.4		1	0	X		0	X		0	X	1
10/12/20 17:00	0.7			1.7			14.6		1	0	X		0	X		0	X	1
10/12/20 18:00	0.7			1.7			14.6		1	0	X		0	X		0	X	1
10/12/20 19:00	1.2			1.7			14.5		1	0	X		0	X		0	X	1
10/12/20 20:00	0.9			1.7			14.6		1	0	X		0	X		0	X	1
10/12/20 21:00	0.9			1.7			14.6		1	0	X		0	X		0	X	1
10/12/20 22:00	1			1.7			14.7		1	0	X		0	X		0	X	1
10/12/20 23:00	1.3			1.7			14.5		1	0	X		0	X		0	X	1
10/13/20 0:00	0.9			1.7			14.6		1	0	X		0	X		0	X	1
10/13/20 1:00	0.8			1.7			14.6		1	0	X		0	X		0	X	1
10/13/20 2:00	0.7			1.7			14.6		1	0	X		0	X		0	X	1
10/13/20 3:00	0.8			1.7			14.6		1	0	X		0	X		0	X	1
10/13/20 4:00	0.8			1.7			14.6		1	0	X		0	X		0	X	0
10/13/20 5:00	0.2			1.7			12		1	0	X		0	X		0	X	0
10/13/20 6:00	0.4			1.7			11.8		1	0	X		0	X		0	X	0
10/13/20 7:00	0.3			1.7			11.9		1	0	X		0	X		0	X	0
10/13/20 8:00	0.9			1.8			13.8		1	0	X		0	X		0	X	0
10/13/20 9:00	0.8			1.7			14.5		1	0.9			1.1			14.7		1
10/13/20 10:00	1.1			1.7			14.3		1	1.1			1.6			14.4		1
10/13/20 11:00	0.4			1.7			13.3		1	0.6			1.7			13.5		1
10/13/20 12:00	0.3			1.7			13.2		1	0.4			1.7			13.3		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/13/20 13:00	0.3			1.7			13.1		1	0.3			1.7			13.1		1
10/13/20 14:00	0.5			1.7			13.6		1	0.6			1.7			13.6		1
10/13/20 15:00	0.7			1.7			13.8		1	0.8			1.7			13.8		1
10/13/20 16:00	0.6			1.7			13.6		1	0.7			1.7			13.6		1
10/13/20 17:00	0.8			1.7			13.9		1	0.8			1.7			13.9		1
10/13/20 18:00	0.9			1.7			14.2		1	1.1			1.7			14.2		1
10/13/20 19:00	0.7			1.8			14.7		1	0.8			1.7			14.7		1
10/13/20 20:00	0.9			1.7			14		1	1			1.7			14		1
10/13/20 21:00	1			1.8			14.6		1	1.2			1.7			14.6		1
10/13/20 22:00	1			1.7			14.5		1	1.1			1.7			14.6		1
10/13/20 23:00	0.8			1.7			14.5		1	1.1			1.7			14.5		1
10/14/20 0:00	0.8			1.7			14.6		1	1			1.7			14.5		1
10/14/20 1:00	0.7			1.7			14.6		1	0.9			1.7			14.6		1
10/14/20 2:00	0.7			1.7			14.7		1	0.9			1.7			14.7		1
10/14/20 3:00	0.7			1.7			14.7		1	0.8			1.7			14.7		1
10/14/20 4:00	0.7			1.7			14.6		1	0.9			1.7			14.6		1
10/14/20 5:00	0.9			1.7			14.5		1	0.9			1.7			14.6		1
10/14/20 6:00	0.8			1.7			14.5		1	0.9			1.7			14.6		1
10/14/20 7:00	0.8			1.7			14.5		1	0.8			1.7			14.6		1
10/14/20 8:00	0.7			1.7			14.6		1	0.8			1.7			14.8		1
10/14/20 9:00	0.7			1.7			14.7		1	0.8			1.7			14.7		1
10/14/20 10:00	1.2			1.7			14.6		1	1.6			1.7			14.6		1
10/14/20 11:00	1			1.7			14.3		1	1.1			1.7			14.2		1
10/14/20 12:00	0.8			1.7			13.8		1	0.9			1.7			13.8		1
10/14/20 13:00	0.3			1.7			13.2		1	0.5			1.7			13.2		1
10/14/20 14:00	0.1			1.7			12		1	0.2			1.7			12.1		1
10/14/20 15:00	0			1.7			11.9		1	0.2			1.7			12.1		1
10/14/20 16:00	0.1			1.7			12.4		1	0.2			1.7			12.4		1
10/14/20 17:00	0.2			1.7			13		1	0.4			1.7			13		1
10/14/20 18:00	0.3			1.7			13.2		1	0.5			1.7			13.3		1
10/14/20 19:00	0.7			1.8			14.6		1	0.8			1.8			14.6		1
10/14/20 20:00	0.9			1.7			14.2		1	1.1			1.7			14.2		1
10/14/20 21:00	0.7			1.8			14.7		1	0.8			1.7			14.6		1
10/14/20 22:00	0.7			1.7			14.6		1	0.8			1.7			14.6		1
10/14/20 23:00	0.7			1.7			14.5		1	0.8			1.7			14.5		1
10/15/20 0:00	0.6			1.7			14.7		1	0.9			1.7			14.6		1
10/15/20 1:00	0.6			1.7			14.7		1	0.9			1.7			14.6		1
10/15/20 2:00	0.6			1.7			14.7		1	0.8			1.7			14.7		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/15/20 3:00	0.7			1.7			14.7		1	0.9			1.7			14.7		1
10/15/20 4:00	0.7			1.7			14.7		1	0.9			1.6			14.6		1
10/15/20 5:00	0.8			1.7			14.5		1	0.9			1.7			14.5		1
10/15/20 6:00	0.7			1.7			14.6		1	0.9			1.7			14.7		1
10/15/20 7:00	0.7			1.7			14.6		1	0.9			1.7			14.8		1
10/15/20 8:00	0.7			1.6			14.5		1	0.8			1.7			12.7		1
10/15/20 9:00	0	X		0	X		0	X	1	0.3			1.7			12.1		1
10/15/20 10:00	0	X		0	X		0	X	1	0.3			1.7			12.4		1
10/15/20 11:00	0	X		0	X		0	X	1	0.2			1.7			12.2		1
10/15/20 12:00	0	X		0	X		0	X	1	0.3			1.7			12.4		1
10/15/20 13:00	0	X		0	X		0	X	1	0.3			1.7			12.7		1
10/15/20 14:00	0	X		0	X		0	X	1	0.3			1.7			12.7		1
10/15/20 15:00	0.6			1.9			15.8		1	0.6			1.7			13.5		1
10/15/20 16:00	0.3			1.6			12.8		1	0.4			1.5			12.6		1
10/15/20 17:00	0.1			1.7			12.7		1	0.3			1.6			12.8		1
10/15/20 18:00	0.4			1.7			13.3		1	0.6			1.7			13.3		1
10/15/20 19:00	0.7			1.8			14.5		1	0.9			1.7			14.5		1
10/15/20 20:00	0.9			1.7			14		1	1.1			1.7			14		1
10/15/20 21:00	0.7			1.8			14.6		1	1			1.7			14.7		1
10/15/20 22:00	0.9			1.7			14.5		1	1			1.7			14.6		1
10/15/20 23:00	0.8			1.7			14.6		1	1			1.7			14.7		1
10/16/20 0:00	0.7			1.7			14.7		1	1			1.7			14.6		1
10/16/20 1:00	1			1.7			14.7		1	1.3			1.7			14.5		1
10/16/20 2:00	0.8			1.7			14.7		1	1.1			1.7			14.6		1
10/16/20 3:00	0.7			1.7			14.7		1	1			1.7			14.5		1
10/16/20 4:00	0.8			1.7			14.6		1	1.1			1.6			14.6		1
10/16/20 5:00	0.8			1.7			14.5		1	0.9			1.7			14.6		1
10/16/20 6:00	0.8			1.7			14.5		1	1			1.7			14.7		1
10/16/20 7:00	1			1.7			14.5		1	1.1			1.7			14.7		1
10/16/20 8:00	0.7			1.7			14.6		1	0.9			1.7			14.8		1
10/16/20 9:00	0.7			1.7			14.7		1	0.9			1.7			14.8		1
10/16/20 10:00	0.7			1.7			14.8		1	0.9			1.7			14.9		1
10/16/20 11:00	0.7			1.7			14.8		1	0.9			1.7			14.8		1
10/16/20 12:00	1			1.7			14.3		1	1.2			1.7			14.3		1
10/16/20 13:00	0.4			1.7			13.4		1	0.6			1.7			13.5		1
10/16/20 14:00	0.1			1.7			12.8		1	0.4			1.7			12.8		1
10/16/20 15:00	0.1			1.7			12.1		1	0.2			1.7			12.2		1
10/16/20 16:00	0.1			1.7			12.1		1	0.2			1.7			12.2		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/16/20 17:00	0.1			1.7			12.5		1	0.3			1.7			12.5		1
10/16/20 18:00	0.3			1.7			13.2		1	0.5			1.7			13.2		1
10/16/20 19:00	0.3			1.7			13.2		1	0.5			1.7			13.2		1
10/16/20 20:00	0.8			1.7			13.9		1	1			1.7			13.9		1
10/16/20 21:00	0.8			1.8			14.8		1	1			1.7			14.8		1
10/16/20 22:00	0.8			1.7			14.6		1	1			1.7			14.7		1
10/16/20 23:00	0.8			1.7			14.5		1	1			1.7			14.6		1
10/17/20 0:00	0.8			1.7			14.7		1	1.1			1.7			14.6		1
10/17/20 1:00	0.9			1.7			14.7		1	1			1.7			14.7		1
10/17/20 2:00	0.8			1.7			14.6		1	1			1.7			14.7		1
10/17/20 3:00	0.7			1.7			14.6		1	1			1.7			14.7		1
10/17/20 4:00	0.8			1.7			14.7		1	1			1.7			14.7		1
10/17/20 5:00	1.1			1.7			14.5		1	1.3			1.7			14.5		1
10/17/20 6:00	1			1.7			14.6		1	1.4			1.7			14.5		1
10/17/20 7:00	0.9			1.7			14.5		1	1.1			1.7			14.6		1
10/17/20 8:00	0.7			1.7			14.6		1	1			1.7			14.8		1
10/17/20 9:00	0.7			1.7			14.8		1	0.9			1.7			14.8		1
10/17/20 10:00	0.7			1.7			14.8		1	0.9			1.7			14.7		1
10/17/20 11:00	0.7			1.7			14.8		1	0.9			1.7			14.7		1
10/17/20 12:00	0.6			1.7			14.7		1	0.9			1.7			14.7		1
10/17/20 13:00	0.9			1.6			14.1		1	1.1			1.7			14.3		1
10/17/20 14:00	0.1			1.7			12.2		1	0.3			1.7			12.2		1
10/17/20 15:00	0			1.7			12.6		1	0.3			1.7			12.7		1
10/17/20 16:00	0.1			1.7			12.7		1	0.4			1.7			12.8		1
10/17/20 17:00	0.5			1.7			13.5		1	0.7			1.7			13.5		1
10/17/20 18:00	1			1.7			14.4		1	1.3			1.7			14.4		1
10/17/20 19:00	0.2			1.7			12.9		1	0.5			1.7			12.9		1
10/17/20 20:00	0.8			1.7			13.8		1	1			1.7			13.9		1
10/17/20 21:00	0.8			1.8			14.7		1	1			1.7			14.7		1
10/17/20 22:00	0.8			1.7			14.6		1	1			1.7			14.7		1
10/17/20 23:00	0.7			1.7			14.6		1	1			1.7			14.7		1
10/18/20 0:00	0.7			1.7			14.6		1	1.1			1.7			14.6		1
10/18/20 1:00	0.7			1.7			14.7		1	1			1.7			14.6		1
10/18/20 2:00	0.7			1.7			14.6		1	1.1			1.7			14.5		1
10/18/20 3:00	0.7			1.7			14.6		1	1			1.7			14.6		1
10/18/20 4:00	0.8			1.7			14.6		1	1.1			1.7			14.5		1
10/18/20 5:00	0.9			1.7			14.6		1	1.2			1.7			14.5		1
10/18/20 6:00	0.9			1.7			14.6		1	1.2			1.7			14.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/18/20 7:00	0.9			1.7			14.5		1	1.1			1.7			14.7		1
10/18/20 8:00	1			1.7			14.6		1	1.2			1.7			14.8		1
10/18/20 9:00	0.8			1.7			14.8		1	1			1.7			14.8		1
10/18/20 10:00	1.1			1.7			14.4		1	1.7			1.7			14.4		1
10/18/20 11:00	0.9			1.7			14.3		1	1.3			1.7			14.3		1
10/18/20 12:00	1			1.7			14.4		1	1.3			1.7			14.5		1
10/18/20 13:00	0.8			1.7			14		1	1.1			1.7			14.1		1
10/18/20 14:00	0.4			1.7			13.2		1	0.6			1.7			13.3		1
10/18/20 15:00	0.1			1.7			12.5		1	0.3			1.7			12.5		1
10/18/20 16:00	0.7			1.8			13.8		1	0.9			1.7			13.8		1
10/18/20 17:00	0.7			1.8			14.5		1	1			1.7			14.5		1
10/18/20 18:00	0.7			1.7			14.6		1	0.9			1.7			14.6		1
10/18/20 19:00	0.7			1.7			14.6		1	0.9			1.7			14.7		1
10/18/20 20:00	1			1.7			14.1		1	1.2			1.7			14.1		1
10/18/20 21:00	0.8			1.7			14.6		1	1			1.7			14.7		1
10/18/20 22:00	0.8			1.7			14.5		1	1			1.7			14.6		1
10/18/20 23:00	0.8			1.7			14.5		1	1			1.7			14.5		1
10/19/20 0:00	0.7			1.7			14.6		1	1			1.7			14.5		1
10/19/20 1:00	0.7			1.7			14.6		1	1			1.7			14.6		1
10/19/20 2:00	0.7			1.7			14.6		1	1			1.7			14.7		1
10/19/20 3:00	0.7			1.7			14.6		1	1			1.7			14.7		1
10/19/20 4:00	1.7			1.7			14.6		1	1.8			1.6			14.5		1
10/19/20 5:00	1.1			1.7			14.5		1	1.3			1.7			14.6		1
10/19/20 6:00	0.9			1.7			14.5		1	1			1.7			14.6		1
10/19/20 7:00	0.8			1.5			14.6		1	1			1.7			14.7		1
10/19/20 8:00	0.8			1.5			14.6		1	1.1			1.7			14.8		1
10/19/20 9:00	1.2			1.5			14.6		1	1.8			1.7			14.6		1
10/19/20 10:00	1			1.5			14.3		1	1.3			1.7			14.3		1
10/19/20 11:00	0.8			1.5			13.9		1	1			1.7			14		1
10/19/20 12:00	0.7			1.5			13.8		1	0.9			1.7			13.8		1
10/19/20 13:00	0.5			1.5			13.4		1	0.6			1.7			13.5		1
10/19/20 14:00	0.2			1.5			13		1	0.5			1.7			13		1
10/19/20 15:00	0.1			1.5			12		1	0.3			1.7			12.1		1
10/19/20 16:00	0.1			1.5			12.5		1	0.3			1.7			12.5		1
10/19/20 17:00	0.3			1.6			13.2		1	0.5			1.7			13.2		1
10/19/20 18:00	0.8			1.7			13.9		1	1.1			1.7			13.9		1
10/19/20 19:00	0.8			1.8			14.6		1	1			1.7			14.6		1
10/19/20 20:00	1			1.7			14.2		1	1.4			1.7			14.2		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/19/20 21:00	0.8			1.8			14.7		1	1			1.7			14.7		1
10/19/20 22:00	0.9			1.7			14.5		1	1			1.7			14.6		1
10/19/20 23:00	1.5			1.7			14.5		1	1.7			1.7			14.6		1
10/20/20 0:00	0.9			1.7			14.6		1	1.1			1.7			14.6		1
10/20/20 1:00	1.1			1.7			14.6		1	1.5			1.7			14.6		1
10/20/20 2:00	1.1			1.7			14.6		1	1.3			1.7			14.7		1
10/20/20 3:00	0.8			1.7			14.6		1	1			1.7			14.7		1
10/20/20 4:00	0.8			1.7			14.6		1	1			1.7			14.6		1
10/20/20 5:00	1			1.7			14.5		1	1.2			1.7			14.5		1
10/20/20 6:00	1			1.7			14.5		1	1.2			1.6			14.6		1
10/20/20 7:00	0.9			1.7			14.5		1	1			1.7			14.6		1
10/20/20 8:00	0.8			1.7			14.6		1	1			1.7			14.8		1
10/20/20 9:00	0.7			1.7			14.8		1	1			1.7			14.8		1
10/20/20 10:00	0.9			1.7			14.3		1	1.2			1.7			14.2		1
10/20/20 11:00	0.5			1.7			13.4		1	0.6			1.7			13.4		1
10/20/20 12:00	0.4			1.7			13.3		1	0.6			1.7			13.3		1
10/20/20 13:00	0.1			1.7			12.2		1	0.3			1.7			12.3		1
10/20/20 14:00	0.1			1.7			12.1		1	0.3			1.7			12.2		1
10/20/20 15:00	0.1			1.7			12.2		1	0.3			1.7			12.2		1
10/20/20 16:00	0.6			1.7			13.7		1	0.8			1.7			13.7		1
10/20/20 17:00	0.8			1.8			14.3		1	1			1.7			14.3		1
10/20/20 18:00	0.7			1.7			14.7		1	0.9			1.7			14.7		1
10/20/20 19:00	0.7			1.7			13.8		1	1			1.7			13.8		1
10/20/20 20:00	1			1.7			14.6		1	1.2			1.7			14.6		1
10/20/20 21:00	0.8			1.7			14.5		1	1			1.7			14.6		1
10/20/20 22:00	0.8			1.7			14.4		1	1			1.7			14.5		1
10/20/20 23:00	0.7			1.7			14.6		1	1.1			1.7			14.5		1
10/21/20 0:00	0.7			1.7			14.7		1	1			1.7			14.7		1
10/21/20 1:00	0.7			1.7			14.6		1	1			1.7			14.7		1
10/21/20 2:00	0.7			1.7			14.6		1	1			1.7			14.7		1
10/21/20 3:00	0.7			1.7			14.6		1	1			1.7			14.7		1
10/21/20 4:00	0.8			1.7			14.6		1	1			1.7			14.7		1
10/21/20 5:00	0.8			1.7			14.6		1	1			1.7			14.6		1
10/21/20 6:00	0.8			1.7			14.6		1	1			1.7			14.7		1
10/21/20 7:00	0.8			1.7			14.6		1	1			1.7			14.7		1
10/21/20 8:00	0.8			1.7			14.6		1	1			1.7			14.6		1
10/21/20 9:00	0.8			1.7			14.6		1	1			1.7			14.7		1
10/21/20 10:00	0.8			1.7			14.7		1	1			1.7			14.8		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/21/20 11:00	0.7			1.7			14.6		1	0.9			1.7			14.7		1
10/21/20 12:00	0.8			1.7			14.7		1	1.1			1.7			14.7		1
10/21/20 13:00	1.1			1.7			14.3		1	1.6			1.7			14.3		1
10/21/20 14:00	0.6			1.7			13.6		1	0.7			1.7			13.6		1
10/21/20 15:00	0.8			1.8			14.6		1	1			1.7			14.7		1
10/21/20 16:00	0.7			1.7			14.6		1	0.9			1.7			14.7		1
10/21/20 17:00	0.7			1.7			14.6		1	0.9			1.7			14.7		1
10/21/20 18:00	0.7			1.7			14.6		1	1			1.7			14.6		1
10/21/20 19:00	1.2			1.7			14.7		1	1.3			1.7			14.7		1
10/21/20 20:00	0.9			1.7			14.6		1	1.1			1.7			14.6		1
10/21/20 21:00	0.9			1.7			14.6		1	1			1.7			14.7		1
10/21/20 22:00	0.8			1.7			14.6		1	1			1.7			14.6		1
10/21/20 23:00	0.8			1.7			14.6		1	1.1			1.7			14.6		1
10/22/20 0:00	0.7			1.7			14.6		1	1			1.7			14.7		1
10/22/20 1:00	0.7			1.7			14.6		1	1			1.7			14.7		1
10/22/20 2:00	0.9			1.7			14.6		1	1.1			1.7			14.7		1
10/22/20 3:00	0.8			1.7			14.6		1	1			1.7			14.7		1
10/22/20 4:00	0.8			1.6			14.6		1	1			1.6			14.6		1
10/22/20 5:00	0.8			1.7			14.6		1	1			1.7			14.6		1
10/22/20 6:00	0.7			1.7			14.6		1	0.9			1.7			14.6		1
10/22/20 7:00	0.7			1.6			14.5		1	1			1.7			14.6		1
10/22/20 8:00	0.7			1.7			14.6		1	0.9			1.7			14.7		1
10/22/20 9:00	0.7			1.6			14.8		1	1			1.7			14.7		1
10/22/20 10:00	0.7			1.7			14.8		1	1			1.7			14.8		1
10/22/20 11:00	0.7			1.6			14.8		1	1			1.7			14.8		1
10/22/20 12:00	0.7			1.7			14.7		1	0.9			1.7			14.7		1
10/22/20 13:00	0.7			1.7			14.7		1	0.9			1.7			14.7		1
10/22/20 14:00	1			1.6			14.4		1	1.2			1.7			14.4		1
10/22/20 15:00	0.7			1.7			14.6		1	0.9			1.7			14.6		1
10/22/20 16:00	1			1.7			14.5		1	1.4			1.7			14.6		1
10/22/20 17:00	1.1			1.7			14.3		1	1.3			1.7			14.3		1
10/22/20 18:00	0.7			1.7			14.6		1	0.9			1.7			14.6		1
10/22/20 19:00	0.7			1.7			14.6		1	0.9			1.7			14.6		1
10/22/20 20:00	0.7			1.7			14.7		1	1			1.7			14.7		1
10/22/20 21:00	0.7			1.7			14.5		1	1			1.7			14.5		1
10/22/20 22:00	0.7			1.7			14.7		1	1			1.7			14.7		1
10/22/20 23:00	0.7			1.7			14.7		1	1			1.7			14.7		1
10/23/20 0:00	0.7			1.7			14.7		1	1			1.7			14.7		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/23/20 1:00	0.8			1.7			14.7		1	1			1.7			14.7		1
10/23/20 2:00	0.7			1.7			14.7		1	1			1.7			14.7		1
10/23/20 3:00	0.7			1.7			14.7		1	1			1.7			14.7		1
10/23/20 4:00	0.7			1.6			14.6		1	1			1.6			14.7		1
10/23/20 5:00	0.9			1.7			14.5		1	1.2			1.7			14.4		1
10/23/20 6:00	0.8			1.7			14.5		1	1.1			1.7			14.5		1
10/23/20 7:00	0.8			1.7			14.5		1	1			1.7			14.6		1
10/23/20 8:00	0.8			1.7			14.5		1	1			1.7			14.7		1
10/23/20 9:00	0.7			1.7			14.6		1	1			1.7			14.7		1
10/23/20 10:00	0.7			1.7			14.6		1	1			1.7			14.8		1
10/23/20 11:00	0.7			1.7			14.8		1	1			1.7			14.8		1
10/23/20 12:00	0.7			1.7			14.8		1	1			1.7			14.8		1
10/23/20 13:00	1.1			1.7			14.4		1	1.3			1.7			14.4		1
10/23/20 14:00	1.1			1.7			14.4		1	1.4			1.7			14.4		1
10/23/20 15:00	1.1			1.7			14.4		1	1.3			1.7			14.4		1
10/23/20 16:00	0.7			1.7			14.6		1	1			1.7			14.5		1
10/23/20 17:00	0.9			1.7			14.1		1	1.2			1.7			14.2		1
10/23/20 18:00	0.8			1.7			14.5		1	1			1.7			14.5		1
10/23/20 19:00	0.7			1.7			14.5		1	1.1			1.7			14.5		1
10/23/20 20:00	0.7			1.7			14.6		1	1			1.7			14.7		1
10/23/20 21:00	0.8			1.7			14.4		1	1			1.7			14.5		1
10/23/20 22:00	0.7			1.7			14.6		1	1			1.7			14.5		1
10/23/20 23:00	0			0			16.7		1	1.1			1.7			14.5		1
10/24/20 0:00	0	X		0	X		0	X	1	1			1.7			14.5		1
10/24/20 1:00	0	X		0	X		0	X	1	0.9			1.7			14.6		1
10/24/20 2:00	0	X		0	X		0	X	1	1			1.7			14.6		1
10/24/20 3:00	0	X		0	X		0	X	1	1			1.7			14.6		1
10/24/20 4:00	0	X		0	X		0	X	1	1			1.7			14.6		1
10/24/20 5:00	0	X		0	X		0	X	1	1.2			1.7			14.4		1
10/24/20 6:00	0	X		0	X		0	X	1	1.1			1.7			14.5		1
10/24/20 7:00	0	X		0	X		0	X	1	1			1.7			14.6		1
10/24/20 8:00	0	X		0	X		0	X	1	1			1.7			14.7		1
10/24/20 9:00	0	X		0	X		0	X	1	0.9			1.7			14.6		1
10/24/20 10:00	0	X		0	X		0	X	1	1.3			1.7			14		1
10/24/20 11:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
10/24/20 12:00	0	X		0	X		0	X	1	1			1.7			14.6		1
10/24/20 13:00	0	X		0	X		0	X	1	0.6			1.7			13.2		1
10/24/20 14:00	0	X		0	X		0	X	1	0.4			1.7			12.8		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/24/20 15:00	0	X		0	X		0	X	1	0.9			1.8			14.3		1
10/24/20 16:00	0	X		0	X		0	X	1	1			1.7			14.6		1
10/24/20 17:00	0	X		0	X		0	X	1	1			1.7			14.6		1
10/24/20 18:00	0	X		0	X		0	X	1	1			1.7			14.6		1
10/24/20 19:00	0	X		0	X		0	X	1	0.5			1.6			12.6		1
10/24/20 20:00	0	X		0	X		0	X	1	0.6			1.7			13.2		1
10/24/20 21:00	0	X		0	X		0	X	1	1.2			1.7			14		1
10/24/20 22:00	0	X		0	X		0	X	1	0.9			1.7			14.6		1
10/24/20 23:00	0	X		0	X		0	X	1	1			1.7			14.5		1
10/25/20 0:00	0	X		0	X		0	X	1	1			1.7			14.5		1
10/25/20 1:00	0	X		0	X		0	X	1	1			1.7			14.5		1
10/25/20 2:00	0	X		0	X		0	X	1	1			1.7			14.5		1
10/25/20 3:00	0	X		0	X		0	X	1	1			1.7			14.5		1
10/25/20 4:00	0	X		0	X		0	X	1	1.1			1.7			14.4		1
10/25/20 5:00	0	X		0	X		0	X	1	1			1.7			14.5		1
10/25/20 6:00	0	X		0	X		0	X	1	0.9			1.7			14.6		1
10/25/20 7:00	0	X		0	X		0	X	1	0.9			1.7			14.6		1
10/25/20 8:00	0	X		0	X		0	X	1	2			1.7			14.5		1
10/25/20 9:00	0	X		0	X		0	X	1	1.2			1.7			13.9		1
10/25/20 10:00	0	X		0	X		0	X	1	1			1.7			13.6		1
10/25/20 11:00	0	X		0	X		0	X	1	0.9			1.7			13.6		1
10/25/20 12:00	0	X		0	X		0	X	1	0.7			1.7			13.4		1
10/25/20 13:00	0	X		0	X		0	X	1	0.8			1.7			13.4		1
10/25/20 14:00	0	X		0	X		0	X	1	0.5			1.7			13		1
10/25/20 15:00	0	X		0	X		0	X	1	0.5			1.7			13		1
10/25/20 16:00	0	X		0	X		0	X	1	1			1.8			14.6		1
10/25/20 17:00	0	X		0	X		0	X	1	1.2			1.7			13.9		1
10/25/20 18:00	0	X		0	X		0	X	1	1.2			1.7			14.2		1
10/25/20 19:00	0	X		0	X		0	X	1	1.2			1.7			14.2		1
10/25/20 20:00	0	X		0	X		0	X	1	0.9			1.7			14.6		1
10/25/20 21:00	0	X		0	X		0	X	1	0.9			1.7			14.6		1
10/25/20 22:00	0	X		0	X		0	X	1	1			1.7			14.6		1
10/25/20 23:00	0	X		0	X		0	X	1	1			1.7			14.5		1
10/26/20 0:00	0	X		0	X		0	X	1	1			1.7			14.6		1
10/26/20 1:00	0	X		0	X		0	X	1	1			1.7			14.6		1
10/26/20 2:00	0	X		0	X		0	X	1	1			1.7			14.6		1
10/26/20 3:00	0	X		0	X		0	X	1	1			1.7			14.6		1
10/26/20 4:00	0	X		0	X		0	X	1	1.1			1.8			14.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/26/20 5:00	0	X		0	X		0	X	1	1			1.7			14.6		1
10/26/20 6:00	0	X		0	X		0	X	1	1			1.7			14.6		1
10/26/20 7:00	0	X		0	X		0	X	1	1.2			1.7			14.2		1
10/26/20 8:00	0	X		0	X		0	X	1	1			1.7			13.7		1
10/26/20 9:00	0	X		0	X		0	X	1	0.9			1.7			13.5		1
10/26/20 10:00	0	X		0	X		0	X	1	0.4			1.7			12.7		1
10/26/20 11:00	0	X		0	X		0	X	1	0.3			1.7			12.3		1
10/26/20 12:00	0	X		0	X		0	X	1	0.3			1.7			12.3		1
10/26/20 13:00	0	X		0	X		0	X	1	0.3			1.7			12.4		1
10/26/20 14:00	0	X		0	X		0	X	1	0.4			1.7			12.3		1
10/26/20 15:00	0	X		0	X		0	X	1	0.5			1.7			13		1
10/26/20 16:00	0	X		0	X		0	X	1	1.4			1.8			14.4		1
10/26/20 17:00	0	X		0	X		0	X	1	0.9			1.7			13.6		1
10/26/20 18:00	0	X		0	X		0	X	1	0.3			1.7			12.3		1
10/26/20 19:00	0	X		0	X		0	X	1	0.4			1.7			12.3		1
10/26/20 20:00	0	X		0	X		0	X	1	0.5			1.7			12.7		1
10/26/20 21:00	0	X		0	X		0	X	1	1.3			1.8			14.3		1
10/26/20 22:00	0	X		0	X		0	X	1	1.1			1.7			14.7		1
10/26/20 23:00	0	X		0	X		0	X	1	1			1.7			14.7		1
10/27/20 0:00	0	X		0	X		0	X	1	1			1.7			14.6		1
10/27/20 1:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1
10/27/20 2:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1
10/27/20 3:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1
10/27/20 4:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
10/27/20 5:00	0	X		0	X		0	X	1	1			1.7			14.7		1
10/27/20 6:00	0	X		0	X		0	X	1	1.1			1.7			14.7		1
10/27/20 7:00	0	X		0	X		0	X	1	1.1			1.7			14.7		1
10/27/20 8:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1
10/27/20 9:00	0	X		0	X		0	X	1	0.9			1.7			13.5		1
10/27/20 10:00	0	X		0	X		0	X	1	0.7			1.7			13.4		1
10/27/20 11:00	0	X		0	X		0	X	1	0.7			1.7			13.3		1
10/27/20 12:00	0	X		0	X		0	X	1	1			1.8			14.5		1
10/27/20 13:00	0	X		0	X		0	X	1	1			1.7			14.6		1
10/27/20 14:00	0	X		0	X		0	X	1	1			1.7			14.6		1
10/27/20 15:00	0	X		0	X		0	X	1	1.8			1.7			14.4		1
10/27/20 16:00	0	X		0	X		0	X	1	1.8			1.7			14.4		1
10/27/20 17:00	0	X		0	X		0	X	1	1.8			1.7			14.5		1
10/27/20 18:00	0	X		0	X		0	X	1	1.8			1.7			14.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/27/20 19:00	0	X		0	X		0	X	1	1			1.7			14.7		1
10/27/20 20:00	0	X		0	X		0	X	1	1.4			1.7			14.4		1
10/27/20 21:00	0	X		0	X		0	X	1	1.5			1.7			14.4		1
10/27/20 22:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
10/27/20 23:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
10/28/20 0:00	0	X		0	X		0	X	1	1.3			1.7			14.5		1
10/28/20 1:00	0	X		0	X		0	X	1	1.3			1.7			14.5		1
10/28/20 2:00	0	X		0	X		0	X	1	1.2			1.7			14.4		1
10/28/20 3:00	0	X		0	X		0	X	1	1.2			1.7			14.4		1
10/28/20 4:00	0	X		0	X		0	X	1	1.3			1.7			14.5		1
10/28/20 5:00	0	X		0	X		0	X	1	2			1.7			14.4		1
10/28/20 6:00	0	X		0	X		0	X	1	2.1			1.7			14.4		1
10/28/20 7:00	0	X		0	X		0	X	1	2.1			1.7			14.4		1
10/28/20 8:00	0	X		0	X		0	X	1	1.6			1.7			14.5		1
10/28/20 9:00	0	X		0	X		0	X	1	1			1.7			14.7		1
10/28/20 10:00	0	X		0	X		0	X	1	1			1.7			14.7		1
10/28/20 11:00	0	X		0	X		0	X	1	1.3			1.7			14.4		1
10/28/20 12:00	0	X		0	X		0	X	1	1.2			1.7			14.1		1
10/28/20 13:00	0	X		0	X		0	X	1	1.2			1.7			14.1		1
10/28/20 14:00	0	X		0	X		0	X	1	1.2			1.7			14.1		1
10/28/20 15:00	0	X		0	X		0	X	1	1.2			1.7			14.8		1
10/28/20 16:00	0	X		0	X		0	X	1	1.1			1.7			14.9		1
10/28/20 17:00	0	X		0	X		0	X	1	1.7			1.7			14.4		1
10/28/20 18:00	0	X		0	X		0	X	1	2.2			1.7			14.4		1
10/28/20 19:00	0	X		0	X		0	X	1	1.3			1.7			14.6		1
10/28/20 20:00	0	X		0	X		0	X	1	1.2			1.7			14.7		1
10/28/20 21:00	0	X		0	X		0	X	1	1.2			1.7			14.7		1
10/28/20 22:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
10/28/20 23:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
10/29/20 0:00	0	X		0	X		0	X	1	1.3			1.7			14.5		1
10/29/20 1:00	0	X		0	X		0	X	1	1.4			1.7			14.4		1
10/29/20 2:00	0	X		0	X		0	X	1	1.4			1.7			14.5		1
10/29/20 3:00	0	X		0	X		0	X	1	1.3			1.7			14.4		1
10/29/20 4:00	0	X		0	X		0	X	1	1.3			1.8			14.5		1
10/29/20 5:00	0	X		0	X		0	X	1	2.2			1.7			14.6		1
10/29/20 6:00	0	X		0	X		0	X	1	2.1			1.7			14.6		1
10/29/20 7:00	0	X		0	X		0	X	1	1.6			1.7			14.6		1
10/29/20 8:00	0	X		0	X		0	X	1	1.1			1.7			13.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/29/20 9:00	0	X		0	X		0	X	1	0.8			1.7			13.5		1
10/29/20 10:00	0	X		0	X		0	X	1	0.8			1.7			13.5		1
10/29/20 11:00	0	X		0	X		0	X	1	0.9			1.7			13.5		1
10/29/20 12:00	0	X		0	X		0	X	1	0.8			1.7			13.4		1
10/29/20 13:00	0	X		0	X		0	X	1	1.1			1.7			14.5		1
10/29/20 14:00	0	X		0	X		0	X	1	1.2			1.7			14		1
10/29/20 15:00	0	X		0	X		0	X	1	1.5			1.7			14.5		1
10/29/20 16:00	0	X		0	X		0	X	1	1.4			1.7			14.6		1
10/29/20 17:00	0	X		0	X		0	X	1	1.3			1.7			14.2		1
10/29/20 18:00	0	X		0	X		0	X	1	1.5			1.7			14.3		1
10/29/20 19:00	0	X		0	X		0	X	1	1.5			1.7			14.1		1
10/29/20 20:00	0	X		0	X		0	X	1	1.2			1.7			14.7		1
10/29/20 21:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
10/29/20 22:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
10/29/20 23:00	0	X		0	X		0	X	1	1.3			1.7			14.6		1
10/30/20 0:00	0	X		0	X		0	X	1	1.4			1.7			14.5		1
10/30/20 1:00	0	X		0	X		0	X	1	1.4			1.7			14.5		1
10/30/20 2:00	0	X		0	X		0	X	1	1.5			1.7			14.4		1
10/30/20 3:00	0	X		0	X		0	X	1	1.5			1.7			14.4		1
10/30/20 4:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
10/30/20 5:00	0	X		0	X		0	X	1	2.2			1.7			14.5		1
10/30/20 6:00	0	X		0	X		0	X	1	2.3			1.7			14.5		1
10/30/20 7:00	0	X		0	X		0	X	1	2			1.7			14.4		1
10/30/20 8:00	0	X		0	X		0	X	1	1.7			1.7			14.3		1
10/30/20 9:00	0	X		0	X		0	X	1	1.3			1.7			14		1
10/30/20 10:00	0	X		0	X		0	X	1	1			1.7			13.5		1
10/30/20 11:00	0	X		0	X		0	X	1	0.9			1.7			13.5		1
10/30/20 12:00	0	X		0	X		0	X	1	0.8			1.7			13.3		1
10/30/20 13:00	0	X		0	X		0	X	1	0.4			1.7			12.3		1
10/30/20 14:00	0	X		0	X		0	X	1	0.4			1.7			12.4		1
10/30/20 15:00	0	X		0	X		0	X	1	1.4			1.8			14.4		1
10/30/20 16:00	0	X		0	X		0	X	1	1.2			1.7			14.8		1
10/30/20 17:00	0	X		0	X		0	X	1	1.1			1.7			14.8		1
10/30/20 18:00	0	X		0	X		0	X	1	1.2			1.7			14.8		1
10/30/20 19:00	0	X		0	X		0	X	1	1.4			1.7			14.1		1
10/30/20 20:00	0	X		0	X		0	X	1	1.7			1.7			14.5		1
10/30/20 21:00	0	X		0	X		0	X	1	1.2			1.7			14.7		1
10/30/20 22:00	0	X		0	X		0	X	1	1.2			1.7			14.7		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/30/20 23:00	0	X		0	X		0	X	1	1.2			1.7			14.7		1
10/31/20 0:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
10/31/20 1:00	0	X		0	X		0	X	1	1.4			1.7			14.5		1
10/31/20 2:00	0	X		0	X		0	X	1	1.6			1.7			14.4		1
10/31/20 3:00	0	X		0	X		0	X	1	1.6			1.7			14.5		1
10/31/20 4:00	0	X		0	X		0	X	1	1.6			1.7			14.5		1
10/31/20 5:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
10/31/20 6:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
10/31/20 7:00	0	X		0	X		0	X	1	2.3			1.7			14.5		1
10/31/20 8:00	0	X		0	X		0	X	1	1.5			1.7			14		1
10/31/20 9:00	0	X		0	X		0	X	1	1			1.7			13.6		1
10/31/20 10:00	0	X		0	X		0	X	1	0.9			1.7			13.6		1
10/31/20 11:00	0	X		0	X		0	X	1	0.8			1.7			13.5		1
10/31/20 12:00	0	X		0	X		0	X	1	1.1			1.6			14.6		1
10/31/20 13:00	0	X		0	X		0	X	1	1.7			1.5			14.5		1
10/31/20 14:00	0	X		0	X		0	X	1	0.5			1.4			12.5		1
10/31/20 15:00	0	X		0	X		0	X	1	1.1			1.6			14.6		1
10/31/20 16:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1
10/31/20 17:00	0	X		0	X		0	X	1	1			1.7			14.7		1
10/31/20 18:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1
10/31/20 19:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
10/31/20 20:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
10/31/20 21:00	0	X		0	X		0	X	1	1.2			1.7			14.7		1
10/31/20 22:00	0	X		0	X		0	X	1	1.2			1.7			14.7		1
10/31/20 23:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
11/01/20 0:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1
11/01/20 1:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1
11/01/20 2:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
11/01/20 3:00	0	X		0	X		0	X	1	1.3			1.7			14.6		1
11/01/20 4:00	0	X		0	X		0	X	1	1.3			1.7			14.6		1
11/01/20 5:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
11/01/20 6:00	0	X		0	X		0	X	1	1.3			1.7			14.4		1
11/01/20 7:00	0	X		0	X		0	X	1	1.4			1.7			14.5		1
11/01/20 8:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
11/01/20 9:00	0	X		0	X		0	X	1	1.1			1.7			14.7		1
11/01/20 10:00	0	X		0	X		0	X	1	1.6			1.7			14.6		1
11/01/20 11:00	0	X		0	X		0	X	1	0.9			1.6			13.6		1
11/01/20 12:00	0	X		0	X		0	X	1	0.9			1.7			13.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/01/20 13:00	0	X		0	X		0	X	1	0.6			1.7			12.9		1
11/01/20 14:00	0	X		0	X		0	X	1	0.4			1.7			12.4		1
11/01/20 15:00	0	X		0	X		0	X	1	0.4			1.7			12.3		1
11/01/20 16:00	0	X		0	X		0	X	1	0.4			1.7			12.4		1
11/01/20 17:00	0	X		0	X		0	X	1	1			1.8			14.3		1
11/01/20 18:00	0	X		0	X		0	X	1	1.1			1.7			14.8		1
11/01/20 19:00	0	X		0	X		0	X	1	1.2			1.7			14.7		1
11/01/20 20:00	0	X		0	X		0	X	1	1.5			1.7			14.7		1
11/01/20 21:00	0	X		0	X		0	X	1	1.8			1.7			14.4		1
11/01/20 22:00	0	X		0	X		0	X	1	1.4			1.7			14.6		1
11/01/20 23:00	0	X		0	X		0	X	1	1.3			1.7			14.6		1
11/02/20 0:00	0	X		0	X		0	X	1	1.2			1.7			14.7		1
11/02/20 1:00	0	X		0	X		0	X	1	1.7			1.7			14.7		1
11/02/20 2:00	0	X		0	X		0	X	1	1.6			1.7			14.6		1
11/02/20 3:00	0	X		0	X		0	X	1	1.7			1.7			14.5		1
11/02/20 4:00	0	X		0	X		0	X	1	1.8			1.7			14.5		1
11/02/20 5:00	0	X		0	X		0	X	1	1.6			1.7			14.5		1
11/02/20 6:00	0	X		0	X		0	X	1	1.5			1.7			14.7		1
11/02/20 7:00	0	X		0	X		0	X	1	2.7			1.7			14.5		1
11/02/20 8:00	0	X		0	X		0	X	1	2.4			1.7			14.5		1
11/02/20 9:00	0	X		0	X		0	X	1	1.4			1.7			14.4		1
11/02/20 10:00	0	X		0	X		0	X	1	1.3			1.7			14.3		1
11/02/20 11:00	0	X		0	X		0	X	1	0.7			1.7			13.2		1
11/02/20 12:00	0	X		0	X		0	X	1	0.4			1.7			12.1		1
11/02/20 13:00	0	X		0	X		0	X	1	0.4			1.7			12		1
11/02/20 14:00	0	X		0	X		0	X	1	0.4			1.7			12		1
11/02/20 15:00	0	X		0	X		0	X	1	0.4			1.7			12		1
11/02/20 16:00	0	X		0	X		0	X	1	0.4			1.7			12		1
11/02/20 17:00	0	X		0	X		0	X	1	0.4			1.7			12.1		1
11/02/20 18:00	0	X		0	X		0	X	1	0.4			1.7			12.1		1
11/02/20 19:00	0	X		0	X		0	X	1	0.6			1.7			12.9		1
11/02/20 20:00	0	X		0	X		0	X	1	1.2			1.8			14.5		1
11/02/20 21:00	0	X		0	X		0	X	1	1			1.7			13.5		1
11/02/20 22:00	0	X		0	X		0	X	1	1.3			1.8			14.6		1
11/02/20 23:00	0	X		0	X		0	X	1	1.3			1.7			14.5		1
11/03/20 0:00	0	X		0	X		0	X	1	1.3			1.7			14.4		1
11/03/20 1:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1
11/03/20 2:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/03/20 3:00	0	X		0	X		0	X	1	1.3			1.7			14.5		1
11/03/20 4:00	0	X		0	X		0	X	1	1.3			1.6			14.5		1
11/03/20 5:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
11/03/20 6:00	0	X		0	X		0	X	1	1.8			1.7			14.5		1
11/03/20 7:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
11/03/20 8:00	0	X		0	X		0	X	1	1.6			1.7			14.2		1
11/03/20 9:00	0	X		0	X		0	X	1	0.7			1.7			12.9		1
11/03/20 10:00	0	X		0	X		0	X	1	0.5			1.7			12.6		1
11/03/20 11:00	0	X		0	X		0	X	1	0.4			1.7			12.5		1
11/03/20 12:00	0	X		0	X		0	X	1	0.4			1.7			12.5		1
11/03/20 13:00	0	X		0	X		0	X	1	0.5			1.7			12.7		1
11/03/20 14:00	0	X		0	X		0	X	1	0.5			1.7			12.7		1
11/03/20 15:00	0	X		0	X		0	X	1	0.4			1.7			12		1
11/03/20 16:00	0	X		0	X		0	X	1	0.4			1.7			12		1
11/03/20 17:00	0	X		0	X		0	X	1	0.5			1.7			12.7		1
11/03/20 18:00	0	X		0	X		0	X	1	1			1.8			13.3		1
11/03/20 19:00	0	X		0	X		0	X	1	1.5			1.7			14.3		1
11/03/20 20:00	0	X		0	X		0	X	1	1.4			1.7			14.1		1
11/03/20 21:00	0	X		0	X		0	X	1	1			1.7			13.5		1
11/03/20 22:00	0	X		0	X		0	X	1	1			1.8			13.9		1
11/03/20 23:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
11/04/20 0:00	0	X		0	X		0	X	1	1.3			1.7			14.4		1
11/04/20 1:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
11/04/20 2:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
11/04/20 3:00	0	X		0	X		0	X	1	1.3			1.7			14.5		1
11/04/20 4:00	0	X		0	X		0	X	1	1.3			1.7			14.5		1
11/04/20 5:00	0	X		0	X		0	X	1	1.6			1.7			14.5		1
11/04/20 6:00	0	X		0	X		0	X	1	1.6			1.7			14.5		1
11/04/20 7:00	0	X		0	X		0	X	1	1.6			1.7			14.6		1
11/04/20 8:00	0	X		0	X		0	X	1	1.4			1.7			14.6		1
11/04/20 9:00	0	X		0	X		0	X	1	1.6			1.7			14.5		1
11/04/20 10:00	0	X		0	X		0	X	1	1.3			1.7			14.3		1
11/04/20 11:00	0	X		0	X		0	X	1	1.3			1.7			14.2		1
11/04/20 12:00	0	X		0	X		0	X	1	1.3			1.7			14.1		1
11/04/20 13:00	0	X		0	X		0	X	1	0.7			1.7			13.2		1
11/04/20 14:00	0	X		0	X		0	X	1	0.5			1.7			12.8		1
11/04/20 15:00	0	X		0	X		0	X	1	0.5			1.7			12.8		1
11/04/20 16:00	0	X		0	X		0	X	1	1			1.7			13.8		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/04/20 17:00	0	X		0	X		0	X	1	1.5			1.7			14.6		1
11/04/20 18:00	0	X		0	X		0	X	1	1.2			1.7			14.7		1
11/04/20 19:00	0	X		0	X		0	X	1	1.1			1.7			14.7		1
11/04/20 20:00	0	X		0	X		0	X	1	1.2			1.7			14.7		1
11/04/20 21:00	0	X		0	X		0	X	1	1.5			1.7			14.4		1
11/04/20 22:00	0	X		0	X		0	X	1	1.5			1.7			14.4		1
11/04/20 23:00	0	X		0	X		0	X	1	1.3			1.7			14.7		1
11/05/20 0:00	0	X		0	X		0	X	1	1.4			1.7			14.5		1
11/05/20 1:00	0	X		0	X		0	X	1	1.3			1.7			14.5		1
11/05/20 2:00	0	X		0	X		0	X	1	1.3			1.7			14.5		1
11/05/20 3:00	0	X		0	X		0	X	1	1.3			1.7			14.5		1
11/05/20 4:00	0	X		0	X		0	X	1	1.3			1.7			14.5		1
11/05/20 5:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
11/05/20 6:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
11/05/20 7:00	0	X		0	X		0	X	1	1.1			1.6			14.6		1
11/05/20 8:00	0	X		0	X		0	X	1	1.1			1.6			14.7		1
11/05/20 9:00	0	X		0	X		0	X	1	1.1			1.6			14.7		1
11/05/20 10:00	0	X		0	X		0	X	1	1.4			1.6			14.3		1
11/05/20 11:00	0	X		0	X		0	X	1	1.3			1.6			14.2		1
11/05/20 12:00	0	X		0	X		0	X	1	1.3			1.6			14.2		1
11/05/20 13:00	0	X		0	X		0	X	1	0.7			1.6			13.1		1
11/05/20 14:00	0	X		0	X		0	X	1	0.4			1.6			12.3		1
11/05/20 15:00	0	X		0	X		0	X	1	0.5			1.6			12.8		1
11/05/20 16:00	0	X		0	X		0	X	1	0.5			1.6			12.8		1
11/05/20 17:00	0	X		0	X		0	X	1	1.1			1.6			14.5		1
11/05/20 18:00	0	X		0	X		0	X	1	1.2			1.6			14.7		1
11/05/20 19:00	0	X		0	X		0	X	1	1.2			1.6			14.7		1
11/05/20 20:00	0	X		0	X		0	X	1	1.4			1.6			14		1
11/05/20 21:00	0	X		0	X		0	X	1	1.4			1.6			14.1		1
11/05/20 22:00	0	X		0	X		0	X	1	1.2			1.6			14.5		1
11/05/20 23:00	0	X		0	X		0	X	1	1.1			1.6			14.6		1
11/06/20 0:00	0	X		0	X		0	X	1	1.1			1.6			14.5		1
11/06/20 1:00	0	X		0	X		0	X	1	1.1			1.6			14.5		1
11/06/20 2:00	0	X		0	X		0	X	1	1.2			1.6			14.5		1
11/06/20 3:00	0	X		0	X		0	X	1	1.2			1.6			14.5		1
11/06/20 4:00	0	X		0	X		0	X	1	1.2			1.6			14.5		1
11/06/20 5:00	0	X		0	X		0	X	1	1.3			1.6			14.4		1
11/06/20 6:00	0	X		0	X		0	X	1	1.2			1.7			14.4		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/06/20 7:00	0	X		0	X		0	X	1	1.1			1.7			14.5		1
11/06/20 8:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1
11/06/20 9:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1
11/06/20 10:00	0	X		0	X		0	X	1	1			1.7			14.7		1
11/06/20 11:00	0	X		0	X		0	X	1	1			1.7			14.7		1
11/06/20 12:00	0	X		0	X		0	X	1	1.1			1.7			14.7		1
11/06/20 13:00	0	X		0	X		0	X	1	1.5			1.7			14.5		1
11/06/20 14:00	0	X		0	X		0	X	1	1.4			1.7			14.4		1
11/06/20 15:00	0	X		0	X		0	X	1	1.2			1.7			14.7		1
11/06/20 16:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1
11/06/20 17:00	0	X		0	X		0	X	1	1			1.7			13.9		1
11/06/20 18:00	0	X		0	X		0	X	1	1.2			1.8			14.5		1
11/06/20 19:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
11/06/20 20:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
11/06/20 21:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1
11/06/20 22:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1
11/06/20 23:00	0	X		0	X		0	X	1	1.1			1.7			14.5		1
11/07/20 0:00	0	X		0	X		0	X	1	1.1			1.7			14.5		1
11/07/20 1:00	0	X		0	X		0	X	1	1.3			1.7			14.4		1
11/07/20 2:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
11/07/20 3:00	0	X		0	X		0	X	1	1.1			1.7			14.5		1
11/07/20 4:00	0	X		0	X		0	X	1	1.1			1.7			14.5		1
11/07/20 5:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
11/07/20 6:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
11/07/20 7:00	0	X		0	X		0	X	1	1.2			1.7			14.4		1
11/07/20 8:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
11/07/20 9:00	0	X		0	X		0	X	1	2			1.7			14.4		1
11/07/20 10:00	0	X		0	X		0	X	1	1.8			1.7			14.4		1
11/07/20 11:00	0	X		0	X		0	X	1	1.8			1.7			14.5		1
11/07/20 12:00	0	X		0	X		0	X	1	1.1			1.7			14.7		1
11/07/20 13:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1
11/07/20 14:00	0	X		0	X		0	X	1	1.1			1.7			14.7		1
11/07/20 15:00	0	X		0	X		0	X	1	1.1			1.7			14.7		1
11/07/20 16:00	0	X		0	X		0	X	1	1.1			1.7			14.5		1
11/07/20 17:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1
11/07/20 18:00	0	X		0	X		0	X	1	1.1			1.7			14.7		1
11/07/20 19:00	0	X		0	X		0	X	1	1.1			1.7			14.7		1
11/07/20 20:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/07/20 21:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1
11/07/20 22:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1
11/07/20 23:00	0	X		0	X		0	X	1	1.1			1.7			14.5		1
11/08/20 0:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
11/08/20 1:00	0	X		0	X		0	X	1	1.3			1.7			14.4		1
11/08/20 2:00	0	X		0	X		0	X	1	1.2			1.7			14.4		1
11/08/20 3:00	0	X		0	X		0	X	1	1.2			1.7			14.4		1
11/08/20 4:00	0	X		0	X		0	X	1	1.3			1.7			14.4		1
11/08/20 5:00	0	X		0	X		0	X	1	1.3			1.7			14.4		1
11/08/20 6:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
11/08/20 7:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
11/08/20 8:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1
11/08/20 9:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
11/08/20 10:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
11/08/20 11:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
11/08/20 12:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
11/08/20 13:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
11/08/20 14:00	0	X		0	X		0	X	1	1.6			1.7			14.5		1
11/08/20 15:00	0	X		0	X		0	X	1	1.6			1.7			14.5		1
11/08/20 16:00	0	X		0	X		0	X	1	1.7			1.7			14.5		1
11/08/20 17:00	0	X		0	X		0	X	1	1.9			1.7			14.6		1
11/08/20 18:00	0	X		0	X		0	X	1	1.7			1.7			14.6		1
11/08/20 19:00	0	X		0	X		0	X	1	1.9			1.7			14.5		1
11/08/20 20:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1
11/08/20 21:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
11/08/20 22:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
11/08/20 23:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
11/09/20 0:00	0	X		0	X		0	X	1	1.3			1.7			14.4		1
11/09/20 1:00	0	X		0	X		0	X	1	1.3			1.7			14.4		1
11/09/20 2:00	0	X		0	X		0	X	1	1.3			1.7			14.4		1
11/09/20 3:00	0	X		0	X		0	X	1	1.3			1.7			14.4		1
11/09/20 4:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
11/09/20 5:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
11/09/20 6:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
11/09/20 7:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
11/09/20 8:00	0	X		0	X		0	X	1	2.2			1.7			14.5		1
11/09/20 9:00	0	X		0	X		0	X	1	1.9			1.7			14.4		1
11/09/20 10:00	0	X		0	X		0	X	1	1.9			1.7			14.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/09/20 11:00	0	X		0	X		0	X	1	1.8			1.7			14.5		1
11/09/20 12:00	0	X		0	X		0	X	1	1.8			1.7			14.5		1
11/09/20 13:00	0	X		0	X		0	X	1	1.8			1.7			14.5		1
11/09/20 14:00	0	X		0	X		0	X	1	1.6			1.7			14.4		1
11/09/20 15:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1
11/09/20 16:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1
11/09/20 17:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1
11/09/20 18:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
11/09/20 19:00	0	X		0	X		0	X	1	1.3			1.7			14.6		1
11/09/20 20:00	0	X		0	X		0	X	1	1.6			1.7			14.6		1
11/09/20 21:00	0	X		0	X		0	X	1	1.7			1.7			14.5		1
11/09/20 22:00	0	X		0	X		0	X	1	1.3			1.7			14.5		1
11/09/20 23:00	0	X		0	X		0	X	1	1.4			1.7			14.6		1
11/10/20 0:00	0	X		0	X		0	X	1	1.4			1.7			14.4		1
11/10/20 1:00	0	X		0	X		0	X	1	1.3			1.7			14.5		1
11/10/20 2:00	0	X		0	X		0	X	1	1.3			1.7			14.5		1
11/10/20 3:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
11/10/20 4:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
11/10/20 5:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1
11/10/20 6:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
11/10/20 7:00	0	X		0	X		0	X	1	2.2			1.7			14.4		1
11/10/20 8:00	0	X		0	X		0	X	1	1.3			1.7			13.7		1
11/10/20 9:00	0	X		0	X		0	X	1	1.2			1.7			14		1
11/10/20 10:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
11/10/20 11:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1
11/10/20 12:00	0	X		0	X		0	X	1	1.1			1.7			14.7		1
11/10/20 13:00	0	X		0	X		0	X	1	1.8			1.7			14.5		1
11/10/20 14:00	0	X		0	X		0	X	1	1.3			1.7			14.6		1
11/10/20 15:00	0	X		0	X		0	X	1	1.2			1.7			14.8		1
11/10/20 16:00	0	X		0	X		0	X	1	1.1			1.7			14.7		1
11/10/20 17:00	0	X		0	X		0	X	1	1.3			1.7			14.7		1
11/10/20 18:00	0	X		0	X		0	X	1	1.2			1.7			14.7		1
11/10/20 19:00	0	X		0	X		0	X	1	1.2			1.7			14.7		1
11/10/20 20:00	0	X		0	X		0	X	1	1.2			1.7			14.7		1
11/10/20 21:00	0	X		0	X		0	X	1	1.2			1.7			14.7		1
11/10/20 22:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
11/10/20 23:00	0	X		0	X		0	X	1	1.3			1.7			14.5		1
11/11/20 0:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/11/20 1:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
11/11/20 2:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
11/11/20 3:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1
11/11/20 4:00	0	X		0	X		0	X	1	1.1			1.6			14.6		1
11/11/20 5:00	0	X		0	X		0	X	1	1.3			1.7			14.4		1
11/11/20 6:00	0	X		0	X		0	X	1	1.3			1.7			14.5		1
11/11/20 7:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
11/11/20 8:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1
11/11/20 9:00	0	X		0	X		0	X	1	1.9			1.7			14.5		1
11/11/20 10:00	0	X		0	X		0	X	1	1.8			1.7			14.5		1
11/11/20 11:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
11/11/20 12:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1
11/11/20 13:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1
11/11/20 14:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1
11/11/20 15:00	0	X		0	X		0	X	1	1.4			1.7			14.2		1
11/11/20 16:00	0	X		0	X		0	X	1	1.3			1.7			14.4		1
11/11/20 17:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1
11/11/20 18:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
11/11/20 19:00	0	X		0	X		0	X	1	1.3			1.7			14.5		1
11/11/20 20:00	0	X		0	X		0	X	1	1.8			1.7			14.6		1
11/11/20 21:00	0	X		0	X		0	X	1	1.6			1.7			14.6		1
11/11/20 22:00	0	X		0	X		0	X	1	1.3			1.7			14.5		1
11/11/20 23:00	0	X		0	X		0	X	1	1.5			1.7			14.4		1
11/12/20 0:00	0	X		0	X		0	X	1	1.4			1.7			14.5		1
11/12/20 1:00	0	X		0	X		0	X	1	1.4			1.7			14.6		1
11/12/20 2:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
11/12/20 3:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
11/12/20 4:00	0	X		0	X		0	X	1	1.3			1.8			14.5		1
11/12/20 5:00	0	X		0	X		0	X	1	1.4			1.7			14.4		1
11/12/20 6:00	0	X		0	X		0	X	1	1.4			1.7			14.5		1
11/12/20 7:00	0	X		0	X		0	X	1	1.4			1.7			14.6		1
11/12/20 8:00	0	X		0	X		0	X	1	2.4			1.7			14.5		1
11/12/20 9:00	0	X		0	X		0	X	1	2			1.7			14.5		1
11/12/20 10:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
11/12/20 11:00	0	X		0	X		0	X	1	1.3			1.7			14.5		1
11/12/20 12:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
11/12/20 13:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
11/12/20 14:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/12/20 15:00	0	X		0	X		0	X	1	1.2			1.7			14.8		1
11/12/20 16:00	0	X		0	X		0	X	1	1.1			1.7			14.7		1
11/12/20 17:00	0	X		0	X		0	X	1	1.2			1.7			14.7		1
11/12/20 18:00	0	X		0	X		0	X	1	1.2			1.7			14.7		1
11/12/20 19:00	0	X		0	X		0	X	1	1.3			1.7			14.7		1
11/12/20 20:00	0	X		0	X		0	X	1	1.3			1.7			14.7		1
11/12/20 21:00	0	X		0	X		0	X	1	1.3			1.7			14.7		1
11/12/20 22:00	0	X		0	X		0	X	1	1.3			1.7			14.5		1
11/12/20 23:00	0	X		0	X		0	X	1	1.4			1.7			14.4		1
11/13/20 0:00	0	X		0	X		0	X	1	1.3			1.7			14.5		1
11/13/20 1:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1
11/13/20 2:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1
11/13/20 3:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
11/13/20 4:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1
11/13/20 5:00	0	X		0	X		0	X	1	1.3			1.7			14.5		1
11/13/20 6:00	0	X		0	X		0	X	1	1.2			1.8			14.6		1
11/13/20 7:00	0	X		0	X		0	X	1	2.1			1.7			14.5		1
11/13/20 8:00	0	X		0	X		0	X	1	1.9			1.7			14.5		1
11/13/20 9:00	0	X		0	X		0	X	1	1.9			1.7			14.5		1
11/13/20 10:00	0	X		0	X		0	X	1	1.9			1.7			14.4		1
11/13/20 11:00	0	X		0	X		0	X	1	1.5			1.7			14		1
11/13/20 12:00	0	X		0	X		0	X	1	1.5			1.7			14.2		1
11/13/20 13:00	0	X		0	X		0	X	1	1.4			1.7			14		1
11/13/20 14:00	0	X		0	X		0	X	1	1.5			1.7			14.3		1
11/13/20 15:00	0	X		0	X		0	X	1	1.6			1.7			14.4		1
11/13/20 16:00	0	X		0	X		0	X	1	1.9			1.7			14.6		1
11/13/20 17:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
11/13/20 18:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
11/13/20 19:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
11/13/20 20:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1
11/13/20 21:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1
11/13/20 22:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
11/13/20 23:00	0	X		0	X		0	X	1	1.3			1.7			14.5		1
11/14/20 0:00	0	X		0	X		0	X	1	1.2			1.8			14.5		1
11/14/20 1:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
11/14/20 2:00	0	X		0	X		0	X	1	1.3			1.7			14.6		1
11/14/20 3:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1
11/14/20 4:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/14/20 5:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1
11/14/20 6:00	0	X		0	X		0	X	1	1.3			1.7			14.5		1
11/14/20 7:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
11/14/20 8:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
11/14/20 9:00	0	X		0	X		0	X	1	2.1			1.7			14.3		1
11/14/20 10:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
11/14/20 11:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
11/14/20 12:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
11/14/20 13:00	0	X		0	X		0	X	1	1.4			1.7			14.6		1
11/14/20 14:00	0	X		0	X		0	X	1	1.3			1.7			14.7		1
11/14/20 15:00	0	X		0	X		0	X	1	1.2			1.7			14.7		1
11/14/20 16:00	0	X		0	X		0	X	1	1.5			1.7			14.2		1
11/14/20 17:00	0	X		0	X		0	X	1	1.2			1.7			14.7		1
11/14/20 18:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1
11/14/20 19:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
11/14/20 20:00	0	X		0	X		0	X	1	1.2			1.7			14.7		1
11/14/20 21:00	0	X		0	X		0	X	1	1.5			1.7			14.5		1
11/14/20 22:00	0	X		0	X		0	X	1	1.6			1.7			14		1
11/14/20 23:00	0	X		0	X		0	X	1	1.3			1.7			14.5		1
11/15/20 0:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
11/15/20 1:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
11/15/20 2:00	0	X		0	X		0	X	1	1.3			1.7			14.5		1
11/15/20 3:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
11/15/20 4:00	0	X		0	X		0	X	1	1.2			1.6			14.5		1
11/15/20 5:00	0	X		0	X		0	X	1	1.4			1.7			14.4		1
11/15/20 6:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
11/15/20 7:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
11/15/20 8:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1
11/15/20 9:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1
11/15/20 10:00	0	X		0	X		0	X	1	1.2			1.7			14.7		1
11/15/20 11:00	0	X		0	X		0	X	1	1.8			1.7			14.5		1
11/15/20 12:00	0	X		0	X		0	X	1	1.8			1.7			14.5		1
11/15/20 13:00	0	X		0	X		0	X	1	1.7			1.7			14.5		1
11/15/20 14:00	0	X		0	X		0	X	1	1.3			1.7			14.2		1
11/15/20 15:00	0	X		0	X		0	X	1	1.1			1.7			13.8		1
11/15/20 16:00	0	X		0	X		0	X	1	1.3			1.7			14.1		1
11/15/20 17:00	0	X		0	X		0	X	1	1.4			1.7			14.4		1
11/15/20 18:00	0	X		0	X		0	X	1	1.8			1.7			14.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/15/20 19:00	0	X		0	X		0	X	1	2.2			1.7			14.2		1
11/15/20 20:00	0	X		0	X		0	X	1	2.1			1.7			14.2		1
11/15/20 21:00	0	X		0	X		0	X	1	1.7			1.7			14.4		1
11/15/20 22:00	0	X		0	X		0	X	1	1.3			1.7			14.5		1
11/15/20 23:00	0	X		0	X		0	X	1	1.4			1.7			14.4		1
11/16/20 0:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
11/16/20 1:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
11/16/20 2:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
11/16/20 3:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
11/16/20 4:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
11/16/20 5:00	0	X		0	X		0	X	1	1.5			1.7			14.4		1
11/16/20 6:00	0	X		0	X		0	X	1	1.4			1.7			14.6		1
11/16/20 7:00	0	X		0	X		0	X	1	2.3			1.7			14.4		1
11/16/20 8:00	0	X		0	X		0	X	1	2.1			1.7			14.4		1
11/16/20 9:00	0	X		0	X		0	X	1	1.7			1.7			14.4		1
11/16/20 10:00	0	X		0	X		0	X	1	1.6			1.7			14.4		1
11/16/20 11:00	0	X		0	X		0	X	1	1.4			1.7			14.3		1
11/16/20 12:00	0	X		0	X		0	X	1	1.4			1.7			14.2		1
11/16/20 13:00	0	X		0	X		0	X	1	1.4			1.7			14.1		1
11/16/20 14:00	0	X		0	X		0	X	1	1.5			1.7			14.3		1
11/16/20 15:00	0	X		0	X		0	X	1	1.6			1.7			14.5		1
11/16/20 16:00	0	X		0	X		0	X	1	1.4			1.7			14.6		1
11/16/20 17:00	0	X		0	X		0	X	1	1.5			1.7			14.7		1
11/16/20 18:00	0	X		0	X		0	X	1	2.3			1.7			14.7		1
11/16/20 19:00	0	X		0	X		0	X	1	2			1.7			14.5		1
11/16/20 20:00	0	X		0	X		0	X	1	2.2			1.7			14.4		1
11/16/20 21:00	0	X		0	X		0	X	1	1.7			1.7			14.3		1
11/16/20 22:00	0	X		0	X		0	X	1	1.3			1.7			14.5		1
11/16/20 23:00	0	X		0	X		0	X	1	1.5			1.7			14.4		1
11/17/20 0:00	0	X		0	X		0	X	1	1.3			1.7			14.5		1
11/17/20 1:00	0	X		0	X		0	X	1	1.3			1.7			14.6		1
11/17/20 2:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
11/17/20 3:00	0	X		0	X		0	X	1	1.2			1.7			14.6		1
11/17/20 4:00	0	X		0	X		0	X	1	1.2			1.6			14.6		1
11/17/20 5:00	0	X		0	X		0	X	1	1.3			1.7			14.5		1
11/17/20 6:00	0	X		0	X		0	X	1	1.3			1.7			14.5		1
11/17/20 7:00	0	X		0	X		0	X	1	1.3			1.7			14.6		1
11/17/20 8:00	0	X		0	X		0	X	1	2.2			1.7			14.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/17/20 9:00	0	X		0	X		0	X	1	1.6			1.7			14.3		1
11/17/20 10:00	0	X		0	X		0	X	1	1.5			1.7			14.3		1
11/17/20 11:00	0	X		0	X		0	X	1	1.2			1.7			14.3		1
11/17/20 12:00	0	X		0	X		0	X	1	1.1			1.7			14.2		1
11/17/20 13:00	0	X		0	X		0	X	1	1.1			1.7			14.2		1
11/17/20 14:00	0	X		0	X		0	X	1	1.3			1.7			14.5		1
11/17/20 15:00	0	X		0	X		0	X	1	1.2			1.7			14.4		1
11/17/20 16:00	0	X		0	X		0	X	1	1.2			1.7			14.4		1
11/17/20 17:00	0	X		0	X		0	X	1	1.2			1.7			14.4		1
11/17/20 18:00	0	X		0	X		0	X	1	1.1			1.7			14.4		1
11/17/20 19:00	0	X		0	X		0	X	1	0.8			1.7			14.5		1
11/17/20 20:00	0	X		0	X		0	X	1	0.7			1.7			14.6		1
11/17/20 21:00	0	X		0	X		0	X	1	0.8			1.7			14.5		1
11/17/20 22:00	0	X		0	X		0	X	1	0.8			1.7			14.5		1
11/17/20 23:00	0	X		0	X		0	X	1	0.8			1.7			14.5		1
11/18/20 0:00	0	X		0	X		0	X	1	0.8			1.7			14.5		1
11/18/20 1:00	0	X		0	X		0	X	1	0.7			1.7			14.6		1
11/18/20 2:00	0	X		0	X		0	X	1	0.7			1.7			14.6		1
11/18/20 3:00	0	X		0	X		0	X	1	0.7			1.7			14.6		1
11/18/20 4:00	0	X		0	X		0	X	1	0.7			1.6			14.6		1
11/18/20 5:00	0	X		0	X		0	X	1	0.8			1.7			14.4		1
11/18/20 6:00	0	X		0	X		0	X	1	0.8			1.7			14.5		1
11/18/20 7:00	0	X		0	X		0	X	1	0.7			1.7			14.6		1
11/18/20 8:00	0	X		0	X		0	X	1	1.8			1.7			14.3		1
11/18/20 9:00	0	X		0	X		0	X	1	1.5			1.7			14.3		1
11/18/20 10:00	0	X		0	X		0	X	1	1.2			1.7			14.3		1
11/18/20 11:00	0	X		0	X		0	X	1	1.2			1.7			14.3		1
11/18/20 12:00	0	X		0	X		0	X	1	1.1			1.7			14.2		1
11/18/20 13:00	0	X		0	X		0	X	1	0.9			1.7			14.7		1
11/18/20 14:00	0	X		0	X		0	X	1	0.8			1.7			14.7		1
11/18/20 15:00	0	X		0	X		0	X	1	0.8			1.7			14.7		1
11/18/20 16:00	0	X		0	X		0	X	1	0.8			1.7			14.7		1
11/18/20 17:00	0	X		0	X		0	X	1	0.8			1.7			14.7		1
11/18/20 18:00	0	X		0	X		0	X	1	0.8			1.7			14.7		1
11/18/20 19:00	0	X		0	X		0	X	1	0.7			1.7			14.6		1
11/18/20 20:00	0	X		0	X		0	X	1	1.5			1.7			14.5		1
11/18/20 21:00	0	X		0	X		0	X	1	0.8			1.7			14.5		1
11/18/20 22:00	0	X		0	X		0	X	1	0.8			1.7			14.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/18/20 23:00	0	X		0	X		0	X	1	0.9			1.7			14.4		1
11/19/20 0:00	0	X		0	X		0	X	1	0.8			1.7			14.5		1
11/19/20 1:00	0	X		0	X		0	X	1	0.7			1.7			14.6		1
11/19/20 2:00	0	X		0	X		0	X	1	0.7			1.7			14.6		1
11/19/20 3:00	0	X		0	X		0	X	1	0.7			1.7			14.6		1
11/19/20 4:00	0	X		0	X		0	X	1	0.7			1.6			14.6		1
11/19/20 5:00	0	X		0	X		0	X	1	0.9			1.7			14.4		1
11/19/20 6:00	0	X		0	X		0	X	1	0.8			1.7			14.5		1
11/19/20 7:00	0	X		0	X		0	X	1	0.9			1.7			14.6		1
11/19/20 8:00	0	X		0	X		0	X	1	0.8			1.7			14.6		1
11/19/20 9:00	0	X		0	X		0	X	1	1.2			1.7			14.3		1
11/19/20 10:00	0	X		0	X		0	X	1	0.8			1.7			14.6		1
11/19/20 11:00	0	X		0	X		0	X	1	0.8			1.7			14.7		1
11/19/20 12:00	0	X		0	X		0	X	1	0.8			1.7			14.7		1
11/19/20 13:00	0	X		0	X		0	X	1	0.8			1.7			14.7		1
11/19/20 14:00	0	X		0	X		0	X	1	0.8			1.7			14.7		1
11/19/20 15:00	0	X		0	X		0	X	1	0.8			1.7			14.7		1
11/19/20 16:00	0	X		0	X		0	X	1	0.8			1.7			14.6		1
11/19/20 17:00	0	X		0	X		0	X	1	0.8			1.7			14.7		1
11/19/20 18:00	0	X		0	X		0	X	1	1.1			1.7			14.3		1
11/19/20 19:00	0	X		0	X		0	X	1	0.8			1.7			14.6		1
11/19/20 20:00	0	X		0	X		0	X	1	0.7			1.7			14.6		1
11/19/20 21:00	0	X		0	X		0	X	1	0.7			1.7			14.6		1
11/19/20 22:00	0	X		0	X		0	X	1	0.7			1.7			14.5		1
11/19/20 23:00	0	X		0	X		0	X	1	0.9			1.7			14.4		1
11/20/20 0:00	0	X		0	X		0	X	1	0.8			1.7			14.5		1
11/20/20 1:00	0	X		0	X		0	X	1	0.7			1.7			14.6		1
11/20/20 2:00	0	X		0	X		0	X	1	0.8			1.7			14.6		1
11/20/20 3:00	0	X		0	X		0	X	1	1			1.7			14.6		1
11/20/20 4:00	0	X		0	X		0	X	1	1.1			1.7			14.4		1
11/20/20 5:00	0	X		0	X		0	X	1	1.1			1.7			14.4		1
11/20/20 6:00	0	X		0	X		0	X	1	2			1.7			14.4		1
11/20/20 7:00	0	X		0	X		0	X	1	2.2			1.7			14.4		1
11/20/20 8:00	0	X		0	X		0	X	1	2.2			1.8			14.4		1
11/20/20 9:00	0	X		0	X		0	X	1	0.9			1.7			13.7		1
11/20/20 10:00	0	X		0	X		0	X	1	0.9			1.7			13.9		1
11/20/20 11:00	0	X		0	X		0	X	1	1.1			1.7			14.3		1
11/20/20 12:00	0	X		0	X		0	X	1	1			1.7			14.7		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/20/20 13:00	0	X		0	X		0	X	1	0.8			1.7			14.7		1
11/20/20 14:00	0	X		0	X		0	X	1	0.8			1.7			14.7		1
11/20/20 15:00	0	X		0	X		0	X	1	0.8			1.7			14.7		1
11/20/20 16:00	0	X		0	X		0	X	1	0.9			1.7			14.7		1
11/20/20 17:00	0	X		0	X		0	X	1	1.3			1.7			14.5		1
11/20/20 18:00	0	X		0	X		0	X	1	1.6			1.7			14.5		1
11/20/20 19:00	0	X		0	X		0	X	1	1.5			1.7			14.4		1
11/20/20 20:00	0	X		0	X		0	X	1	1.8			1.7			14.5		1
11/20/20 21:00	0	X		0	X		0	X	1	1.8			1.7			14.4		1
11/20/20 22:00	0	X		0	X		0	X	1	1			1.7			14.6		1
11/20/20 23:00	0	X		0	X		0	X	1	1			1.7			14.5		1
11/21/20 0:00	0	X		0	X		0	X	1	1			1.7			14.5		1
11/21/20 1:00	0	X		0	X		0	X	1	1.5			1.7			14.5		1
11/21/20 2:00	0	X		0	X		0	X	1	1.2			1.7			14.4		1
11/21/20 3:00	0	X		0	X		0	X	1	1.1			1.7			14.4		1
11/21/20 4:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
11/21/20 5:00	0	X		0	X		0	X	1	1.4			1.7			14.4		1
11/21/20 6:00	0	X		0	X		0	X	1	1.3			1.7			14.4		1
11/21/20 7:00	0	X		0	X		0	X	1	1.1			1.7			14.5		1
11/21/20 8:00	0	X		0	X		0	X	1	1			1.7			14.5		1
11/21/20 9:00	0	X		0	X		0	X	1	0.9			1.7			14.6		1
11/21/20 10:00	0	X		0	X		0	X	1	1			1.7			14.7		1
11/21/20 11:00	0	X		0	X		0	X	1	0.8			1.7			14.7		1
11/21/20 12:00	0	X		0	X		0	X	1	0.8			1.7			14.7		1
11/21/20 13:00	0	X		0	X		0	X	1	0.8			1.7			14.7		1
11/21/20 14:00	0	X		0	X		0	X	1	0.8			1.7			14.7		1
11/21/20 15:00	0	X		0	X		0	X	1	0.8			1.7			14.7		1
11/21/20 16:00	0	X		0	X		0	X	1	0.9			1.7			14.7		1
11/21/20 17:00	0	X		0	X		0	X	1	0.9			1.7			14.7		1
11/21/20 18:00	0	X		0	X		0	X	1	0.9			1.7			14.7		1
11/21/20 19:00	0	X		0	X		0	X	1	1			1.7			14.7		1
11/21/20 20:00	0	X		0	X		0	X	1	1			1.7			14.7		1
11/21/20 21:00	0	X		0	X		0	X	1	1.8			1.7			14.4		1
11/21/20 22:00	0	X		0	X		0	X	1	1.2			1.7			14.2		1
11/21/20 23:00	0	X		0	X		0	X	1	0.9			1.7			14.6		1
11/22/20 0:00	0	X		0	X		0	X	1	1			1.7			14.4		1
11/22/20 1:00	0	X		0	X		0	X	1	1			1.7			14.5		1
11/22/20 2:00	0	X		0	X		0	X	1	0.9			1.7			14.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/22/20 3:00	0	X		0	X		0	X	1	0.9			1.7			14.5		1
11/22/20 4:00	0	X		0	X		0	X	1	0.9			1.7			14.5		1
11/22/20 5:00	0	X		0	X		0	X	1	0.9			1.7			14.5		1
11/22/20 6:00	0	X		0	X		0	X	1	1.1			1.7			14.4		1
11/22/20 7:00	0	X		0	X		0	X	1	0.9			1.7			14.6		1
11/22/20 8:00	0	X		0	X		0	X	1	1.7			1.7			14.5		1
11/22/20 9:00	0	X		0	X		0	X	1	1.3			1.7			14.2		1
11/22/20 10:00	0	X		0	X		0	X	1	1.2			1.7			14		1
11/22/20 11:00	0	X		0	X		0	X	1	1.3			1.9			14.5		1
11/22/20 12:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
11/22/20 13:00	0	X		0	X		0	X	1	1.1			1.7			14.4		1
11/22/20 14:00	0	X		0	X		0	X	1	1.6			1.7			14.5		1
11/22/20 15:00	0	X		0	X		0	X	1	1			1.7			14		1
11/22/20 16:00	0	X		0	X		0	X	1	0.5			1.7			13.1		1
11/22/20 17:00	0	X		0	X		0	X	1	0.7			1.7			13.7		1
11/22/20 18:00	0	X		0	X		0	X	1	0.8			1.7			13.7		1
11/22/20 19:00	0	X		0	X		0	X	1	1.6			1.8			14.4		1
11/22/20 20:00	0	X		0	X		0	X	1	1.4			1.7			14.3		1
11/22/20 21:00	0	X		0	X		0	X	1	1.3			1.7			14.3		1
11/22/20 22:00	0	X		0	X		0	X	1	1			1.7			14.6		1
11/22/20 23:00	0	X		0	X		0	X	1	1			1.7			14.4		1
11/23/20 0:00	0	X		0	X		0	X	1	1			1.7			14.5		1
11/23/20 1:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
11/23/20 2:00	0	X		0	X		0	X	1	0.9			1.7			14.5		1
11/23/20 3:00	0	X		0	X		0	X	1	1			1.7			14.5		1
11/23/20 4:00	0	X		0	X		0	X	1	1			1.7			14.5		1
11/23/20 5:00	0	X		0	X		0	X	1	1			1.7			14.4		1
11/23/20 6:00	0	X		0	X		0	X	1	0.8			1.7			14.6		1
11/23/20 7:00	0	X		0	X		0	X	1	0.9			1.7			14.5		1
11/23/20 8:00	0	X		0	X		0	X	1	1.5			1.7			14.5		1
11/23/20 9:00	0	X		0	X		0	X	1	1.9			1.7			14.6		1
11/23/20 10:00	0	X		0	X		0	X	1	1.7			1.7			14.5		1
11/23/20 11:00	0	X		0	X		0	X	1	1.6			1.7			14.5		1
11/23/20 12:00	0	X		0	X		0	X	1	1.5			1.7			14.5		1
11/23/20 13:00	0	X		0	X		0	X	1	1.5			1.7			14.5		1
11/23/20 14:00	0	X		0	X		0	X	1	1.5			1.7			14.5		1
11/23/20 15:00	0	X		0	X		0	X	1	1.4			1.7			14.5		1
11/23/20 16:00	0	X		0	X		0	X	1	1.1			1.7			14.3		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/23/20 17:00	0	X		0	X		0	X	1	1.1			1.7			14.5		1
11/23/20 18:00	0	X		0	X		0	X	1	1.7			1.7			14.5		1
11/23/20 19:00	0	X		0	X		0	X	1	1.1			1.7			14.6		1
11/23/20 20:00	0	X		0	X		0	X	1	1			1.7			14.6		1
11/23/20 21:00	0	X		0	X		0	X	1	0.8			1.7			14.6		1
11/23/20 22:00	0	X		0	X		0	X	1	0.9			1.7			14.6		1
11/23/20 23:00	0	X		0	X		0	X	1	1.1			1.7			14.5		1
11/24/20 0:00	0	X		0	X		0	X	1	1			1.7			14.5		1
11/24/20 1:00	0	X		0	X		0	X	1	1.3			1.7			14.5		1
11/24/20 2:00	0	X		0	X		0	X	1	1.2			1.7			14.5		1
11/24/20 3:00	0	X		0	X		0	X	1	1.1			1.7			14.5		1
11/24/20 4:00	0	X		0	X		0	X	1	1			1.7			14.5		1
11/24/20 5:00	0	X		0	X		0	X	1	1			1.7			14.5		1
11/24/20 6:00	0	X		0	X		0	X	1	1.8			1.7			14.5		1
11/24/20 7:00	0	X		0	X		0	X	1	1.8			1.7			14.5		1
11/24/20 8:00	0	X		0	X		0	X	1	1.7			1.7			14.4		1
11/24/20 9:00	0	X		0	X		0	X	1	1.7			1.7			14.6		1
11/24/20 10:00	0	X		0	X		0	X	1	1.7			1.7			14.5		1
11/24/20 11:00	0	X		0	X		0	X	1	1.5			1.7			14.4		1
11/24/20 12:00	0	X		0	X		0	X	1	1.3			1.7			14.4		1
11/24/20 13:00	0	X		0	X		0	X	1	1.7			1.7			14.6		1
11/24/20 14:00	0	X		0	X		0	X	1	1.6			1.7			14.5		1
11/24/20 15:00	0	X		0	X		0	X	1	1.5			1.7			14.5		1
11/24/20 16:00	0	X		0	X		0	X	1	1.5			1.7			14.5		1
11/24/20 17:00	0	X		0	X		0	X	1	1.5			1.7			14.5		1
11/24/20 18:00	0	X		0	X		0	X	1	1			1.7			14.7		1
11/24/20 19:00	0	X		0	X		0	X	1	0.8			1.7			14.6		1
11/24/20 20:00	0	X		0	X		0	X	1	0.9			1.7			14.7		1
11/24/20 21:00	0	X		0	X		0	X	1	0.9			1.7			14.7		1
11/24/20 22:00	0	X		0	X		0	X	1	0.8			1.7			14.6		1
11/24/20 23:00	0	X		0	X		0	X	1	0.9			1.7			14.5		1
11/25/20 0:00	0	X		0	X		0	X	1	1			1.7			14.4		1
11/25/20 1:00	0	X		0	X		0	X	1	0.8			1.7			14.5		1
11/25/20 2:00	0	X		0	X		0	X	1	0.8			1.7			14.5		1
11/25/20 3:00	0	X		0	X		0	X	1	0.9			1.7			14.4		1
11/25/20 4:00	0	X		0	X		0	X	1	0.9			1.6			14.4		1
11/25/20 5:00	0	X		0	X		0	X	1	0.9			1.8			14.5		1
11/25/20 6:00	0	X		0	X		0	X	1	1.7			1.7			14.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/25/20 7:00	0	X		0	X		0	X	1	0.9			1.7			14.6		1
11/25/20 8:00	0	X		0	X		0	X	1	0.8			1.7			14.6		1
11/25/20 9:00	0	X		0	X		0	X	1	0.8			1.7			14.6		1
11/25/20 10:00	0	X		0	X		0	X	1	0.8			1.7			14.7		1
11/25/20 11:00	0	X		0	X		0	X	1	0.8			1.7			14.7		1
11/25/20 12:00	0	X		0	X		0	X	1	0.8			1.7			14.7		1
11/25/20 13:00	0	X		0	X		0	X	1	0.8			1.7			14.6		1
11/25/20 14:00	0	X		0	X		0	X	1	0.8			1.7			14.7		1
11/25/20 15:00	0	X		0	X		0	X	1	0.8			1.7			14.8		1
11/25/20 16:00	0	X		0	X		0	X	1	0.8			1.7			14.7		1
11/25/20 17:00	0	X		0	X		0	X	1	0.8			1.7			14.6		1
11/25/20 18:00	0	X		0	X		0	X	1	0.8			1.7			14.7		1
11/25/20 19:00	0	X		0	X		0	X	1	0.8			1.7			14.7		1
11/25/20 20:00	0	X		0	X		0	X	1	0.8			1.7			14.6		1
11/25/20 21:00	0	X		0	X		0	X	1	1.5			1.7			14.5		1
11/25/20 22:00	0	X		0	X		0	X	1	0.8			1.7			14.6		1
11/25/20 23:00	0	X		0	X		0	X	1	0.9			1.7			14.5		1
11/26/20 0:00	0	X		0	X		0	X	1	0			0			17.1		1
11/26/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/26/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/26/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/26/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/26/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/26/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/26/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/26/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/26/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/26/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/26/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/26/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/26/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/26/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/26/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/26/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/26/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/26/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/26/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/26/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/26/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/26/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/26/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/27/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/27/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/27/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/27/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/27/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/27/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/27/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/27/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/27/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/27/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/27/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/27/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/27/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/27/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/27/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/27/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/27/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/27/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/27/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/27/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/27/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/27/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/27/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/27/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/28/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/28/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/28/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/28/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/28/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/28/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/28/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/28/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/28/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/28/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/28/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/28/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/28/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/28/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/28/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/28/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/28/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/28/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/28/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/28/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/28/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/28/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/28/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/28/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/29/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/29/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/29/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/29/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/29/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/29/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/29/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/29/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/29/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/29/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/29/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/29/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/29/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/29/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/29/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/29/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/29/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/29/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/29/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/29/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/29/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/29/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/29/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/29/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/30/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/30/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/30/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/30/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/30/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/30/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/30/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/30/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/30/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/30/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/30/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/30/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/30/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/30/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/30/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/30/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/30/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/30/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/30/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/30/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/30/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/30/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/30/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
11/30/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/01/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/01/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/01/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/01/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/01/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/01/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/01/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/01/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/01/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/01/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/01/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/01/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/01/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/01/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/01/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/01/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/01/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/01/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/01/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/01/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/01/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/01/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/01/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/01/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/02/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/02/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/02/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/02/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/02/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/02/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/02/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/02/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/02/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/02/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/02/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/02/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/02/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/02/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/02/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/02/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/02/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/02/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/02/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/02/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/02/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/02/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/02/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/02/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/03/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/03/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/03/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/03/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/03/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/03/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/03/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/03/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/03/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/03/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/03/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/03/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/03/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/03/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/03/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/03/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/03/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/03/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/03/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/03/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/03/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/03/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/03/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/03/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/04/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/04/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/04/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/04/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/04/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/04/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/04/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/04/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/04/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/04/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/04/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/04/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/04/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/04/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/04/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/04/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/04/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/04/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/04/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/04/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/04/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/04/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/04/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/04/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/05/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/06/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/06/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/07/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/07/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/08/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/09/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/09/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/10/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/11/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/11/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/12/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/12/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/13/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/14/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/14/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/15/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/15/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/16/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/17/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/17/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/18/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/19/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/19/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/20/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/20/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/21/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/22/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/22/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/22/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/22/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/22/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/22/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/22/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/22/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/22/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/22/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/22/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/22/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/22/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/22/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/22/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/22/20 15:00	0	X		0	X		0	X	1	0			0			17.6		1
12/22/20 16:00	0	X		0	X		0	X	1	0.8			1.3			14.6		1
12/22/20 17:00	0			0			15.8		1	0.8			1.7			14.5		1
12/22/20 18:00	0.8			1.6			14.4		1	0.7			1.8			14.9		1
12/22/20 19:00	0.7			1.7			14.5		1	0	X		0	X		0	X	1
12/22/20 20:00	0			0			15.6		1	0	X		0	X		0	X	1
12/22/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/22/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/22/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/23/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/23/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/24/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/25/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/25/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/26/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/26/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/27/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/28/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/28/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/29/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/30/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/30/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/20 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/20 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/20 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/20 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/20 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/20 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/20 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/20 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/20 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/20 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/20 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/20 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/20 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/20 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/20 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/20 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/20 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/31/20 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/20 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/20 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/20 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/20 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/20 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
12/31/20 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

Tons 12 Month Rolling Summary

CT1 and CT2 Combined



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:17 Location: Roseville, CA

* = Excess Emission

Date	Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2	
	CO, Ton		NOx, Ton		PM10, Ton		SO2, Ton		VOC, Ton	
	1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)	
	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum
Oct 2020	0.4702	2.7037	1.4695	8.2453	0.2805	1.5473	0.1402	0.7736	0.4673	2.5777
Nov 2020	0.3189	2.4722	0.7256	7.9558	0.1387	1.5036	0.0696	0.7521	0.2316	2.5050
Dec 2020	0.0524	2.4405	0.0197	7.7366	0.0012	1.4593	0.0006	0.7300	0.0020	2.4312
Sum/Avg	2.4405		7.7366		1.4593		0.7300		2.4312	
Limit Value										

AQ-33

AQ-33 The Project owner shall maintain records of Sox lb/hr, lb/day, and lb, quarter emissions. Sox emissions shall be based on fuel use records, natural gas sulfur content, and mass balance calculations.

Verification: The Project owner shall submit to the CPM all hourly, daily, and quarterly Sox emissions as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

AQ33 DAILY SOX

Date/Time	CT1_SO2_Lb_1D			CT2_SO2_Lb_1D														
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/01/20 0:00	6.4			6.1														
10/02/20 0:00	5.6			5.3														
10/03/20 0:00	5.6			5.4														
10/04/20 0:00	6.2			5.8														
10/05/20 0:00	6.6			6.2														
10/06/20 0:00	6.2			5.8														
10/07/20 0:00	6.3			6														
10/08/20 0:00	1			5.9														
10/09/20 0:00	0			5.9														
10/10/20 0:00	1.8			3.2														
10/11/20 0:00	5.3			0														
10/12/20 0:00	6.1			0														
10/13/20 0:00	6.9			4.2														
10/14/20 0:00	6.1			5.9														
10/15/20 0:00	3.8			6.2														
10/16/20 0:00	5.9			5.9														
10/17/20 0:00	5.6			5.5														
10/18/20 0:00	5.7			5.5														
10/19/20 0:00	6			5.9														
10/20/20 0:00	6.2			5.7														
10/21/20 0:00	5			5														
10/22/20 0:00	5.5			5														
10/23/20 0:00	5			5.1														
10/24/20 0:00	0			5.4														
10/25/20 0:00	0			5.9														
10/26/20 0:00	0			6.9														
10/27/20 0:00	0			5.5														
10/28/20 0:00	0			5.7														
10/29/20 0:00	0			5.9														
10/30/20 0:00	0			5.8														
10/31/20 0:00	0			5.3														
11/01/20 0:00	0			5.8														
11/02/20 0:00	0			6.7														
11/03/20 0:00	0			6.5														
11/04/20 0:00	0			5.8														

Date/Time	CT1_SO2_Lb_1D			CT2_SO2_Lb_1D														
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/05/20 0:00	0			5.7														
11/06/20 0:00	0			4.9														
11/07/20 0:00	0			5														
11/08/20 0:00	0			5														
11/09/20 0:00	0			5.6														
11/10/20 0:00	0			5.4														
11/11/20 0:00	0			4.9														
11/12/20 0:00	0			5.1														
11/13/20 0:00	0			5.7														
11/14/20 0:00	0			5.3														
11/15/20 0:00	0			5.5														
11/16/20 0:00	0			6														
11/17/20 0:00	0			5.3														
11/18/20 0:00	0			5.3														
11/19/20 0:00	0			5.1														
11/20/20 0:00	0			5.6														
11/21/20 0:00	0			5.2														
11/22/20 0:00	0			6.1														
11/23/20 0:00	0			5.1														
11/24/20 0:00	0			5.4														
11/25/20 0:00	0			5.2														
11/26/20 0:00	0			0														
11/27/20 0:00	0			0														
11/28/20 0:00	0			0														
11/29/20 0:00	0			0														
11/30/20 0:00	0			0														
12/01/20 0:00	0			0														
12/02/20 0:00	0			0														
12/03/20 0:00	0			0														
12/04/20 0:00	0			0														
12/05/20 0:00	0			0														
12/06/20 0:00	0			0														
12/07/20 0:00	0			0														
12/08/20 0:00	0			0														
12/09/20 0:00	0			0														
12/10/20 0:00	0			0														
12/11/20 0:00	0			0														
12/12/20 0:00	0			0														

Date/Time	CT1_SO2_Lb_1D			CT2_SO2_Lb_1D														
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/13/20 0:00	0			0														
12/14/20 0:00	0			0														
12/15/20 0:00	0			0														
12/16/20 0:00	0			0														
12/17/20 0:00	0			0														
12/18/20 0:00	0			0														
12/19/20 0:00	0			0														
12/20/20 0:00	0			0														
12/21/20 0:00	0			0														
12/22/20 0:00	0.6			0.6														
12/23/20 0:00	0			0														
12/24/20 0:00	0			0														
12/25/20 0:00	0			0														
12/26/20 0:00	0			0														
12/27/20 0:00	0			0														
12/28/20 0:00	0			0														
12/29/20 0:00	0			0														
12/30/20 0:00	0			0														
12/31/20 0:00	0			0														

AQ33 HOURLY SOX

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
10/01/20 0:00	0.20676			0.20682			0.41											
10/01/20 1:00	0.1833			0.1962			0.38											
10/01/20 2:00	0.1797			0.20064			0.38											
10/01/20 3:00	0.17904			0.2025			0.38											
10/01/20 4:00	0.17898			0.20052			0.38											
10/01/20 5:00	0.17886			0.16932			0.35											
10/01/20 6:00	0.17952			0.16968			0.35											
10/01/20 7:00	0.1905			0.18468			0.38											
10/01/20 8:00	0.2088			0.20892			0.42											
10/01/20 9:00	0.23364			0.23124			0.46											
10/01/20 10:00	0.2805			0.27264			0.55											
10/01/20 11:00	0.33264			0.31728			0.65											
10/01/20 12:00	0.3471			0.33144			0.68											
10/01/20 13:00	0.36258			0.34692			0.71											
10/01/20 14:00	0.3705			0.35496			0.73											
10/01/20 15:00	0.33708			0.32256			0.66											
10/01/20 16:00	0.37056			0.35568			0.73											
10/01/20 17:00	0.3579			0.3432			0.7											
10/01/20 18:00	0.25104			0.23988			0.49											
10/01/20 19:00	0.26922			0.2586			0.53											
10/01/20 20:00	0.27564			0.2613			0.54											
10/01/20 21:00	0.30066			0.28644			0.59											
10/01/20 22:00	0.24072			0.23526			0.48											
10/01/20 23:00	0.21954			0.21678			0.44											
10/02/20 0:00	0.19374			0.20184			0.4											
10/02/20 1:00	0.17994			0.19734			0.38											
10/02/20 2:00	0.17946			0.1821			0.36											
10/02/20 3:00	0.18054			0.18102			0.36											
10/02/20 4:00	0.18552			0.19122			0.38											
10/02/20 5:00	0.17916			0.16968			0.35											
10/02/20 6:00	0.17892			0.16968			0.35											
10/02/20 7:00	0.17898			0.16962			0.35											
10/02/20 8:00	0.17952			0.16932			0.35											
10/02/20 9:00	0.18654			0.17778			0.36											
10/02/20 10:00	0.19788			0.19548			0.39											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
10/02/20 11:00	0.23154			0.21972			0.45											
10/02/20 12:00	0.26046			0.24612			0.51											
10/02/20 13:00	0.2739			0.25878			0.53											
10/02/20 14:00	0.29622			0.2814			0.58											
10/02/20 15:00	0.25218			0.23874			0.49											
10/02/20 16:00	0.32994			0.31542			0.65											
10/02/20 17:00	0.30798			0.29388			0.6											
10/02/20 18:00	0.2256			0.21582			0.44											
10/02/20 19:00	0.26526			0.25866			0.52											
10/02/20 20:00	0.20778			0.19884			0.41											
10/02/20 21:00	0.25782			0.24738			0.51											
10/02/20 22:00	0.23898			0.23118			0.47											
10/02/20 23:00	0.21906			0.21852			0.44											
10/03/20 0:00	0.18642			0.198			0.38											
10/03/20 1:00	0.17862			0.1833			0.36											
10/03/20 2:00	0.17904			0.16932			0.35											
10/03/20 3:00	0.17928			0.16962			0.35											
10/03/20 4:00	0.1788			0.16962			0.35											
10/03/20 5:00	0.17886			0.16962			0.35											
10/03/20 6:00	0.17922			0.16962			0.35											
10/03/20 7:00	0.17916			0.16968			0.35											
10/03/20 8:00	0.19176			0.1833			0.38											
10/03/20 9:00	0.21636			0.21372			0.43											
10/03/20 10:00	0.22302			0.22656			0.45											
10/03/20 11:00	0.2328			0.23946			0.47											
10/03/20 12:00	0.2253			0.23304			0.46											
10/03/20 13:00	0.2679			0.2553			0.52											
10/03/20 14:00	0.31416			0.30024			0.61											
10/03/20 15:00	0.25176			0.2388			0.49											
10/03/20 16:00	0.26442			0.25122			0.52											
10/03/20 17:00	0.24546			0.23724			0.48											
10/03/20 18:00	0.3426			0.32868			0.67											
10/03/20 19:00	0.29304			0.2799			0.57											
10/03/20 20:00	0.25404			0.24048			0.49											
10/03/20 21:00	0.2697			0.26232			0.53											
10/03/20 22:00	0.23676			0.23364			0.47											
10/03/20 23:00	0.21984			0.22542			0.45											
10/04/20 0:00	0.18378			0.20058			0.38											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
10/04/20 1:00	0.18342			0.20418			0.39											
10/04/20 2:00	0.17892			0.1809			0.36											
10/04/20 3:00	0.1791			0.16944			0.35											
10/04/20 4:00	0.1815			0.17208			0.35											
10/04/20 5:00	0.18408			0.17964			0.36											
10/04/20 6:00	0.18066			0.18444			0.37											
10/04/20 7:00	0.2004			0.20772			0.41											
10/04/20 8:00	0.21264			0.22506			0.44											
10/04/20 9:00	0.24486			0.23598			0.48											
10/04/20 10:00	0.2634			0.2448			0.51											
10/04/20 11:00	0.2997			0.2841			0.58											
10/04/20 12:00	0.342			0.32652			0.67											
10/04/20 13:00	0.3645			0.34974			0.71											
10/04/20 14:00	0.3669			0.3522			0.72											
10/04/20 15:00	0.36612			0.35178			0.72											
10/04/20 16:00	0.35256			0.3384			0.69											
10/04/20 17:00	0.3315			0.31746			0.65											
10/04/20 18:00	0.31302			0.29994			0.61											
10/04/20 19:00	0.25782			0.24276			0.5											
10/04/20 20:00	0.24966			0.23856			0.49											
10/04/20 21:00	0.24906			0.24006			0.49											
10/04/20 22:00	0.21738			0.2145			0.43											
10/04/20 23:00	0.1875			0.19482			0.38											
10/05/20 0:00	0.17892			0.18006			0.36											
10/05/20 1:00	0.1788			0.16908			0.35											
10/05/20 2:00	0.17868			0.16938			0.35											
10/05/20 3:00	0.17946			0.17034			0.35											
10/05/20 4:00	0.18402			0.17994			0.36											
10/05/20 5:00	0.19722			0.19896			0.4											
10/05/20 6:00	0.19962			0.20898			0.41											
10/05/20 7:00	0.20844			0.22332			0.43											
10/05/20 8:00	0.22422			0.24078			0.47											
10/05/20 9:00	0.2598			0.24624			0.51											
10/05/20 10:00	0.27162			0.25782			0.53											
10/05/20 11:00	0.30972			0.29526			0.6											
10/05/20 12:00	0.2976			0.28362			0.58											
10/05/20 13:00	0.35964			0.34554			0.71											
10/05/20 14:00	0.37242			0.35748			0.73											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
10/05/20 15:00	0.37152			0.35706			0.73											
10/05/20 16:00	0.37182			0.35736			0.73											
10/05/20 17:00	0.3525			0.339			0.69											
10/05/20 18:00	0.33126			0.31752			0.65											
10/05/20 19:00	0.32088			0.30744			0.63											
10/05/20 20:00	0.28392			0.27108			0.56											
10/05/20 21:00	0.25506			0.24216			0.5											
10/05/20 22:00	0.22482			0.2163			0.44											
10/05/20 23:00	0.19884			0.19914			0.4											
10/06/20 0:00	0.17856			0.18108			0.36											
10/06/20 1:00	0.17802			0.1707			0.35											
10/06/20 2:00	0.17844			0.16884			0.35											
10/06/20 3:00	0.17856			0.16902			0.35											
10/06/20 4:00	0.17844			0.16908			0.35											
10/06/20 5:00	0.19992			0.1944			0.39											
10/06/20 6:00	0.20214			0.19926			0.4											
10/06/20 7:00	0.21546			0.20994			0.43											
10/06/20 8:00	0.23292			0.2328			0.47											
10/06/20 9:00	0.24942			0.24192			0.49											
10/06/20 10:00	0.25908			0.2565			0.52											
10/06/20 11:00	0.29982			0.28458			0.58											
10/06/20 12:00	0.26256			0.24066			0.5											
10/06/20 13:00	0.32652			0.30264			0.63											
10/06/20 14:00	0.33624			0.32202			0.66											
10/06/20 15:00	0.36132			0.34716			0.71											
10/06/20 16:00	0.36096			0.34698			0.71											
10/06/20 17:00	0.3333			0.31998			0.65											
10/06/20 18:00	0.3123			0.29898			0.61											
10/06/20 19:00	0.3255			0.3123			0.64											
10/06/20 20:00	0.32316			0.3105			0.63											
10/06/20 21:00	0.261			0.2436			0.5											
10/06/20 22:00	0.22248			0.21504			0.44											
10/06/20 23:00	0.19266			0.19668			0.39											
10/07/20 0:00	0.17808			0.19362			0.37											
10/07/20 1:00	0.17742			0.1776			0.36											
10/07/20 2:00	0.1773			0.16764			0.34											
10/07/20 3:00	0.17742			0.16824			0.35											
10/07/20 4:00	0.1821			0.17688			0.36											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
10/07/20 5:00	0.26376			0.2481			0.51											
10/07/20 6:00	0.26454			0.25002			0.51											
10/07/20 7:00	0.21648			0.20508			0.42											
10/07/20 8:00	0.22788			0.2238			0.45											
10/07/20 9:00	0.2391			0.23538			0.47											
10/07/20 10:00	0.26406			0.2505			0.51											
10/07/20 11:00	0.27882			0.26538			0.54											
10/07/20 12:00	0.29466			0.28056			0.58											
10/07/20 13:00	0.31824			0.30402			0.62											
10/07/20 14:00	0.36666			0.3522			0.72											
10/07/20 15:00	0.36276			0.34872			0.71											
10/07/20 16:00	0.28758			0.27438			0.56											
10/07/20 17:00	0.26694			0.25398			0.52											
10/07/20 18:00	0.26136			0.2433			0.5											
10/07/20 19:00	0.26352			0.2505			0.51											
10/07/20 20:00	0.28356			0.27264			0.56											
10/07/20 21:00	0.22392			0.22146			0.45											
10/07/20 22:00	0.19236			0.20274			0.4											
10/07/20 23:00	0.17778			0.19122			0.37											
10/08/20 0:00	0.17772			0.17322			0.35											
10/08/20 1:00	0.17748			0.16824			0.35											
10/08/20 2:00	0.17754			0.16824			0.35											
10/08/20 3:00	0.17772			0.16836			0.35											
10/08/20 4:00	0.17442			0.1689			0.34											
10/08/20 5:00	0.0678			0.21324			0.22											
10/08/20 6:00	0	X		0.21606			0.22											
10/08/20 7:00	0	X		0.23244			0.23											
10/08/20 8:00	0	X		0.24288			0.24											
10/08/20 9:00	0	X		0.28302			0.28											
10/08/20 10:00	0	X		0.30858			0.31											
10/08/20 11:00	0	X		0.2979			0.3											
10/08/20 12:00	0	X		0.3117			0.31											
10/08/20 13:00	0	X		0.31434			0.31											
10/08/20 14:00	0	X		0.29172			0.29											
10/08/20 15:00	0	X		0.20568			0.21											
10/08/20 16:00	0	X		0.20376			0.2											
10/08/20 17:00	0	X		0.20496			0.2											
10/08/20 18:00	0	X		0.22176			0.22											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
10/08/20 19:00	0	X		0.34962			0.35											
10/08/20 20:00	0	X		0.2754			0.28											
10/08/20 21:00	0	X		0.34728			0.35											
10/08/20 22:00	0	X		0.36246			0.36											
10/08/20 23:00	0	X		0.22596			0.23											
10/09/20 0:00	0	X		0.2058			0.21											
10/09/20 1:00	0	X		0.19392			0.19											
10/09/20 2:00	0	X		0.19488			0.19											
10/09/20 3:00	0	X		0.1959			0.2											
10/09/20 4:00	0	X		0.2124			0.21											
10/09/20 5:00	0	X		0.23142			0.23											
10/09/20 6:00	0	X		0.24234			0.24											
10/09/20 7:00	0	X		0.24504			0.25											
10/09/20 8:00	0	X		0.27528			0.28											
10/09/20 9:00	0	X		0.30486			0.3											
10/09/20 10:00	0	X		0.31518			0.32											
10/09/20 11:00	0	X		0.32838			0.33											
10/09/20 12:00	0	X		0.33414			0.33											
10/09/20 13:00	0	X		0.30912			0.31											
10/09/20 14:00	0	X		0.32214			0.32											
10/09/20 15:00	0	X		0.26928			0.27											
10/09/20 16:00	0	X		0.24138			0.24											
10/09/20 17:00	0	X		0.2727			0.27											
10/09/20 18:00	0	X		0.28122			0.28											
10/09/20 19:00	0	X		0.2544			0.25											
10/09/20 20:00	0	X		0.22608			0.23											
10/09/20 21:00	0	X		0.22962			0.23											
10/09/20 22:00	0	X		0.23472			0.23											
10/09/20 23:00	0	X		0.20622			0.21											
10/10/20 0:00	0	X		0.1926			0.19											
10/10/20 1:00	0	X		0.1821			0.18											
10/10/20 2:00	0	X		0.17658			0.18											
10/10/20 3:00	0	X		0.1761			0.18											
10/10/20 4:00	0	X		0.17646			0.18											
10/10/20 5:00	0	X		0.19284			0.19											
10/10/20 6:00	0	X		0.19722			0.2											
10/10/20 7:00	0	X		0.2196			0.22											
10/10/20 8:00	0	X		0.22968			0.23											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H								
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/10/20 9:00	0	X		0.282			0.28								
10/10/20 10:00	0	X		0.29664			0.3								
10/10/20 11:00	0	X		0.30084			0.3								
10/10/20 12:00	0	X		0.29352			0.29								
10/10/20 13:00	0	X		0.23232			0.2								
10/10/20 14:00	0	X		0.01476			0								
10/10/20 15:00	0.16104			0	X		0.12								
10/10/20 16:00	0.20436			0	X		0.2								
10/10/20 17:00	0.24744			0	X		0.25								
10/10/20 18:00	0.2301			0	X		0.23								
10/10/20 19:00	0.19104			0	X		0.19								
10/10/20 20:00	0.24468			0	X		0.24								
10/10/20 21:00	0.25614			0	X		0.26								
10/10/20 22:00	0.2433			0	X		0.24								
10/10/20 23:00	0.24084			0	X		0.24								
10/11/20 0:00	0.22326			0	X		0.22								
10/11/20 1:00	0.20226			0	X		0.2								
10/11/20 2:00	0.19482			0	X		0.19								
10/11/20 3:00	0.1926			0	X		0.19								
10/11/20 4:00	0.19974			0	X		0.2								
10/11/20 5:00	0.23964			0	X		0.24								
10/11/20 6:00	0.24786			0	X		0.25								
10/11/20 7:00	0.22698			0	X		0.23								
10/11/20 8:00	0.24024			0	X		0.24								
10/11/20 9:00	0.24816			0	X		0.25								
10/11/20 10:00	0.24618			0	X		0.25								
10/11/20 11:00	0.20976			0	X		0.21								
10/11/20 12:00	0.20496			0	X		0.2								
10/11/20 13:00	0.25482			0	X		0.25								
10/11/20 14:00	0.36612			0	X		0.37								
10/11/20 15:00	0.32658			0.00276			0.33								
10/11/20 16:00	0.24486			0	X		0.24								
10/11/20 17:00	0.21576			0	X		0.22								
10/11/20 18:00	0.20118			0	X		0.2								
10/11/20 19:00	0.18822			0	X		0.19								
10/11/20 20:00	0.24234			0	X		0.24								
10/11/20 21:00	0.2592			0	X		0.26								
10/11/20 22:00	0.23634			0	X		0.24								

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H								
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/11/20 23:00	0.21192			0	X		0.21								
10/12/20 0:00	0.19974			0	X		0.2								
10/12/20 1:00	0.19248			0	X		0.19								
10/12/20 2:00	0.1857			0	X		0.19								
10/12/20 3:00	0.18846			0	X		0.19								
10/12/20 4:00	0.21642			0	X		0.22								
10/12/20 5:00	0.26298			0	X		0.26								
10/12/20 6:00	0.29028			0	X		0.29								
10/12/20 7:00	0.29034			0	X		0.29								
10/12/20 8:00	0.28476			0	X		0.28								
10/12/20 9:00	0.28116			0	X		0.28								
10/12/20 10:00	0.28524			0	X		0.29								
10/12/20 11:00	0.24522			0	X		0.25								
10/12/20 12:00	0.25548			0	X		0.26								
10/12/20 13:00	0.34548			0	X		0.35								
10/12/20 14:00	0.37506			0	X		0.38								
10/12/20 15:00	0.37308			0	X		0.37								
10/12/20 16:00	0.24318			0	X		0.24								
10/12/20 17:00	0.23622			0	X		0.24								
10/12/20 18:00	0.23118			0	X		0.23								
10/12/20 19:00	0.20682			0	X		0.21								
10/12/20 20:00	0.22734			0	X		0.23								
10/12/20 21:00	0.20928			0	X		0.21								
10/12/20 22:00	0.24876			0	X		0.25								
10/12/20 23:00	0.26466			0	X		0.26								
10/13/20 0:00	0.25338			0	X		0.25								
10/13/20 1:00	0.2556			0	X		0.26								
10/13/20 2:00	0.25944			0	X		0.26								
10/13/20 3:00	0.26484			0	X		0.26								
10/13/20 4:00	0.25542			0.03312			0.26								
10/13/20 5:00	0.38814			0.03312			0.39								
10/13/20 6:00	0.39408			0.03528			0.4								
10/13/20 7:00	0.38454			0.0414			0.39								
10/13/20 8:00	0.24084			0.16476			0.4								
10/13/20 9:00	0.18516			0.17856			0.36								
10/13/20 10:00	0.26802			0.25356			0.52								
10/13/20 11:00	0.31512			0.288			0.6								
10/13/20 12:00	0.31908			0.28854			0.61								

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
10/13/20 13:00	0.32064			0.2871			0.61											
10/13/20 14:00	0.29886			0.27354			0.57											
10/13/20 15:00	0.28716			0.27636			0.56											
10/13/20 16:00	0.29598			0.28524			0.58											
10/13/20 17:00	0.28716			0.27606			0.56											
10/13/20 18:00	0.27102			0.25902			0.53											
10/13/20 19:00	0.2451			0.23772			0.48											
10/13/20 20:00	0.28482			0.27378			0.56											
10/13/20 21:00	0.24552			0.23478			0.48											
10/13/20 22:00	0.219			0.21678			0.44											
10/13/20 23:00	0.18426			0.1956			0.38											
10/14/20 0:00	0.17832			0.18762			0.37											
10/14/20 1:00	0.17862			0.17262			0.35											
10/14/20 2:00	0.17808			0.16836			0.35											
10/14/20 3:00	0.17844			0.16902			0.35											
10/14/20 4:00	0.18204			0.1785			0.36											
10/14/20 5:00	0.19716			0.2013			0.4											
10/14/20 6:00	0.19716			0.21054			0.41											
10/14/20 7:00	0.20004			0.22044			0.42											
10/14/20 8:00	0.21258			0.23658			0.45											
10/14/20 9:00	0.23976			0.23712			0.48											
10/14/20 10:00	0.25464			0.24306			0.5											
10/14/20 11:00	0.2697			0.25842			0.53											
10/14/20 12:00	0.2886			0.27762			0.57											
10/14/20 13:00	0.3174			0.30636			0.62											
10/14/20 14:00	0.36654			0.35562			0.72											
10/14/20 15:00	0.36654			0.35592			0.72											
10/14/20 16:00	0.35088			0.34044			0.69											
10/14/20 17:00	0.32706			0.3162			0.64											
10/14/20 18:00	0.31656			0.3054			0.62											
10/14/20 19:00	0.22824			0.22602			0.45											
10/14/20 20:00	0.2715			0.2595			0.53											
10/14/20 21:00	0.24564			0.23592			0.48											
10/14/20 22:00	0.21942			0.21744			0.44											
10/14/20 23:00	0.19806			0.20766			0.41											
10/15/20 0:00	0.17838			0.19398			0.37											
10/15/20 1:00	0.17754			0.17868			0.36											
10/15/20 2:00	0.17796			0.17118			0.35											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
10/15/20 3:00	0.17832			0.17472			0.35											
10/15/20 4:00	0.1794			0.17622			0.36											
10/15/20 5:00	0.19044			0.19062			0.38											
10/15/20 6:00	0.21384			0.21858			0.43											
10/15/20 7:00	0.22542			0.23574			0.46											
10/15/20 8:00	0.16188			0.33048			0.34											
10/15/20 9:00	0	X		0.3654			0.37											
10/15/20 10:00	0	X		0.34698			0.35											
10/15/20 11:00	0	X		0.35484			0.35											
10/15/20 12:00	0	X		0.34278			0.34											
10/15/20 13:00	0	X		0.32892			0.33											
10/15/20 14:00	0	X		0.32898			0.33											
10/15/20 15:00	0.15918			0.25092			0.36											
10/15/20 16:00	0.34086			0.32802			0.67											
10/15/20 17:00	0.33504			0.32316			0.66											
10/15/20 18:00	0.31344			0.3015			0.61											
10/15/20 19:00	0.25056			0.24192			0.49											
10/15/20 20:00	0.28422			0.27492			0.56											
10/15/20 21:00	0.2319			0.23754			0.47											
10/15/20 22:00	0.20076			0.21702			0.42											
10/15/20 23:00	0.18996			0.2145			0.4											
10/16/20 0:00	0.1779			0.19026			0.37											
10/16/20 1:00	0.1776			0.1848			0.36											
10/16/20 2:00	0.17742			0.18216			0.36											
10/16/20 3:00	0.17748			0.18222			0.36											
10/16/20 4:00	0.18456			0.19224			0.38											
10/16/20 5:00	0.19176			0.20616			0.4											
10/16/20 6:00	0.1938			0.21642			0.41											
10/16/20 7:00	0.19266			0.22332			0.42											
10/16/20 8:00	0.2097			0.23886			0.45											
10/16/20 9:00	0.22644			0.23592			0.46											
10/16/20 10:00	0.22644			0.22956			0.46											
10/16/20 11:00	0.22092			0.22428			0.45											
10/16/20 12:00	0.27186			0.25854			0.53											
10/16/20 13:00	0.30636			0.29472			0.6											
10/16/20 14:00	0.3327			0.32142			0.65											
10/16/20 15:00	0.36222			0.35106			0.71											
10/16/20 16:00	0.36252			0.35136			0.71											

CT1_SO2_LbPerHr_1H				CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H								
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/16/20 17:00	0.34626			0.33558			0.68								
10/16/20 18:00	0.31752			0.30714			0.62								
10/16/20 19:00	0.31716			0.306			0.62								
10/16/20 20:00	0.28434			0.27234			0.56								
10/16/20 21:00	0.24318			0.23454			0.48								
10/16/20 22:00	0.21696			0.21408			0.43								
10/16/20 23:00	0.20496			0.21036			0.42								
10/17/20 0:00	0.18042			0.19602			0.38								
10/17/20 1:00	0.17736			0.16836			0.35								
10/17/20 2:00	0.1782			0.16836			0.35								
10/17/20 3:00	0.17826			0.16878			0.35								
10/17/20 4:00	0.17832			0.1692			0.35								
10/17/20 5:00	0.18756			0.18378			0.37								
10/17/20 6:00	0.18366			0.1896			0.37								
10/17/20 7:00	0.19728			0.20766			0.4								
10/17/20 8:00	0.21792			0.23016			0.45								
10/17/20 9:00	0.23346			0.23502			0.47								
10/17/20 10:00	0.24192			0.24468			0.49								
10/17/20 11:00	0.24144			0.24252			0.48								
10/17/20 12:00	0.24816			0.24102			0.49								
10/17/20 13:00	0.27726			0.25206			0.53								
10/17/20 14:00	0.3456			0.34878			0.69								
10/17/20 15:00	0.31212			0.32604			0.64								
10/17/20 16:00	0.31686			0.32244			0.64								
10/17/20 17:00	0.30186			0.28968			0.59								
10/17/20 18:00	0.2613			0.2493			0.51								
10/17/20 19:00	0.33312			0.32034			0.65								
10/17/20 20:00	0.28722			0.27402			0.56								
10/17/20 21:00	0.24576			0.2352			0.48								
10/17/20 22:00	0.219			0.21654			0.44								
10/17/20 23:00	0.19884			0.20742			0.41								
10/18/20 0:00	0.19062			0.18744			0.38								
10/18/20 1:00	0.17748			0.18252			0.36								
10/18/20 2:00	0.17856			0.18324			0.36								
10/18/20 3:00	0.17778			0.17892			0.36								
10/18/20 4:00	0.1797			0.18186			0.36								
10/18/20 5:00	0.1833			0.1902			0.37								
10/18/20 6:00	0.18408			0.19812			0.38								

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
10/18/20 7:00	0.19494			0.2139			0.41											
10/18/20 8:00	0.21036			0.23094			0.44											
10/18/20 9:00	0.23598			0.2352			0.47											
10/18/20 10:00	0.26778			0.25446			0.52											
10/18/20 11:00	0.27084			0.25686			0.53											
10/18/20 12:00	0.26574			0.24156			0.51											
10/18/20 13:00	0.2817			0.26862			0.55											
10/18/20 14:00	0.31572			0.30336			0.62											
10/18/20 15:00	0.3441			0.33228			0.68											
10/18/20 16:00	0.28962			0.27792			0.57											
10/18/20 17:00	0.25284			0.24084			0.49											
10/18/20 18:00	0.23148			0.22326			0.45											
10/18/20 19:00	0.23226			0.23058			0.46											
10/18/20 20:00	0.27678			0.26586			0.54											
10/18/20 21:00	0.23868			0.23622			0.47											
10/18/20 22:00	0.20676			0.21354			0.42											
10/18/20 23:00	0.18756			0.20532			0.39											
10/19/20 0:00	0.17874			0.19248			0.37											
10/19/20 1:00	0.18072			0.17622			0.36											
10/19/20 2:00	0.17832			0.17046			0.35											
10/19/20 3:00	0.17934			0.17136			0.35											
10/19/20 4:00	0.18552			0.18366			0.37											
10/19/20 5:00	0.20124			0.20592			0.41											
10/19/20 6:00	0.2046			0.21648			0.42											
10/19/20 7:00	0.2163			0.23394			0.45											
10/19/20 8:00	0.22656			0.24234			0.47											
10/19/20 9:00	0.2547			0.24678			0.5											
10/19/20 10:00	0.27246			0.25926			0.53											
10/19/20 11:00	0.28872			0.27606			0.56											
10/19/20 12:00	0.2943			0.28176			0.58											
10/19/20 13:00	0.30744			0.2949			0.6											
10/19/20 14:00	0.32694			0.31446			0.64											
10/19/20 15:00	0.3645			0.35184			0.72											
10/19/20 16:00	0.34704			0.33474			0.68											
10/19/20 17:00	0.31872			0.30558			0.62											
10/19/20 18:00	0.28668			0.27492			0.56											
10/19/20 19:00	0.23568			0.22764			0.46											
10/19/20 20:00	0.27312			0.2619			0.54											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
10/19/20 21:00	0.23844			0.22902			0.47											
10/19/20 22:00	0.2046			0.20478			0.41											
10/19/20 23:00	0.19026			0.2001			0.39											
10/20/20 0:00	0.17934			0.19326			0.37											
10/20/20 1:00	0.17814			0.17616			0.35											
10/20/20 2:00	0.17766			0.1686			0.35											
10/20/20 3:00	0.17838			0.16884			0.35											
10/20/20 4:00	0.18414			0.17868			0.36											
10/20/20 5:00	0.1974			0.20004			0.4											
10/20/20 6:00	0.19728			0.2094			0.41											
10/20/20 7:00	0.19596			0.21612			0.41											
10/20/20 8:00	0.21222			0.23616			0.45											
10/20/20 9:00	0.24492			0.23664			0.48											
10/20/20 10:00	0.26808			0.25836			0.53											
10/20/20 11:00	0.31158			0.2979			0.61											
10/20/20 12:00	0.31638			0.303			0.62											
10/20/20 13:00	0.36072			0.3474			0.71											
10/20/20 14:00	0.36492			0.35184			0.72											
10/20/20 15:00	0.35904			0.34662			0.71											
10/20/20 16:00	0.29382			0.28242			0.58											
10/20/20 17:00	0.261			0.24972			0.51											
10/20/20 18:00	0.25194			0.24108			0.49											
10/20/20 19:00	0.29016			0.2835			0.57											
10/20/20 20:00	0.25476			0.2424			0.5											
10/20/20 21:00	0.2211			0.2139			0.44											
10/20/20 22:00	0.19536			0.19884			0.39											
10/20/20 23:00	0.17844			0.18774			0.37											
10/21/20 0:00	0.17736			0.1686			0.35											
10/21/20 1:00	0.17784			0.16818			0.35											
10/21/20 2:00	0.17808			0.16854			0.35											
10/21/20 3:00	0.17796			0.16848			0.35											
10/21/20 4:00	0.17946			0.17046			0.35											
10/21/20 5:00	0.22092			0.21462			0.44											
10/21/20 6:00	0.22284			0.22218			0.45											
10/21/20 7:00	0.17946			0.17226			0.35											
10/21/20 8:00	0.18636			0.18144			0.37											
10/21/20 9:00	0.19824			0.19932			0.4											
10/21/20 10:00	0.21			0.21696			0.43											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
10/21/20 11:00	0.2349			0.23292			0.47											
10/21/20 12:00	0.24606			0.2421			0.49											
10/21/20 13:00	0.26712			0.2556			0.52											
10/21/20 14:00	0.29808			0.28632			0.58											
10/21/20 15:00	0.23916			0.2307			0.47											
10/21/20 16:00	0.23394			0.23256			0.47											
10/21/20 17:00	0.22938			0.23448			0.46											
10/21/20 18:00	0.2049			0.19836			0.4											
10/21/20 19:00	0.17898			0.17334			0.35											
10/21/20 20:00	0.183			0.18156			0.36											
10/21/20 21:00	0.21258			0.21594			0.43											
10/21/20 22:00	0.18666			0.20316			0.39											
10/21/20 23:00	0.17904			0.1962			0.38											
10/22/20 0:00	0.1782			0.16956			0.35											
10/22/20 1:00	0.1776			0.1686			0.35											
10/22/20 2:00	0.1779			0.16872			0.35											
10/22/20 3:00	0.17796			0.16884			0.35											
10/22/20 4:00	0.18324			0.17406			0.36											
10/22/20 5:00	0.26124			0.2481			0.51											
10/22/20 6:00	0.2598			0.24726			0.51											
10/22/20 7:00	0.21348			0.20922			0.42											
10/22/20 8:00	0.2226			0.2268			0.45											
10/22/20 9:00	0.24294			0.24234			0.49											
10/22/20 10:00	0.24			0.23886			0.48											
10/22/20 11:00	0.24582			0.2373			0.48											
10/22/20 12:00	0.26016			0.24756			0.51											
10/22/20 13:00	0.26022			0.24726			0.51											
10/22/20 14:00	0.26586			0.25326			0.52											
10/22/20 15:00	0.2334			0.22488			0.46											
10/22/20 16:00	0.2592			0.24834			0.51											
10/22/20 17:00	0.27306			0.2598			0.53											
10/22/20 18:00	0.24114			0.23322			0.47											
10/22/20 19:00	0.23976			0.24036			0.48											
10/22/20 20:00	0.24114			0.23436			0.48											
10/22/20 21:00	0.19542			0.19104			0.39											
10/22/20 22:00	0.17838			0.171			0.35											
10/22/20 23:00	0.17814			0.16896			0.35											
10/23/20 0:00	0.17766			0.16908			0.35											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
10/23/20 1:00	0.17802			0.16932			0.35											
10/23/20 2:00	0.1782			0.16932			0.35											
10/23/20 3:00	0.17802			0.16926			0.35											
10/23/20 4:00	0.17892			0.17028			0.35											
10/23/20 5:00	0.189			0.18606			0.38											
10/23/20 6:00	0.19494			0.19974			0.39											
10/23/20 7:00	0.20076			0.21294			0.41											
10/23/20 8:00	0.21138			0.2283			0.44											
10/23/20 9:00	0.2109			0.23592			0.45											
10/23/20 10:00	0.20382			0.23724			0.44											
10/23/20 11:00	0.23358			0.2391			0.47											
10/23/20 12:00	0.24288			0.23676			0.48											
10/23/20 13:00	0.26556			0.25602			0.52											
10/23/20 14:00	0.2691			0.25194			0.52											
10/23/20 15:00	0.26748			0.23784			0.51											
10/23/20 16:00	0.22608			0.19956			0.43											
10/23/20 17:00	0.2796			0.26526			0.54											
10/23/20 18:00	0.20796			0.20214			0.41											
10/23/20 19:00	0.19062			0.19548			0.39											
10/23/20 20:00	0.228			0.23796			0.47											
10/23/20 21:00	0.2046			0.2235			0.43											
10/23/20 22:00	0.1773			0.21366			0.39											
10/23/20 23:00	0.07446			0.19638			0.2											
10/24/20 0:00	0	X		0.20034			0.2											
10/24/20 1:00	0	X		0.17088			0.17											
10/24/20 2:00	0	X		0.1752			0.18											
10/24/20 3:00	0	X		0.17526			0.18											
10/24/20 4:00	0	X		0.17634			0.18											
10/24/20 5:00	0	X		0.18894			0.19											
10/24/20 6:00	0	X		0.19656			0.2											
10/24/20 7:00	0	X		0.22422			0.22											
10/24/20 8:00	0	X		0.24456			0.24											
10/24/20 9:00	0	X		0.2487			0.25											
10/24/20 10:00	0	X		0.27216			0.27											
10/24/20 11:00	0	X		0.24816			0.25											
10/24/20 12:00	0	X		0.24648			0.25											
10/24/20 13:00	0	X		0.31098			0.31											
10/24/20 14:00	0	X		0.32892			0.33											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
10/24/20 15:00	0	X		0.21828			0.22											
10/24/20 16:00	0	X		0.18258			0.18											
10/24/20 17:00	0	X		0.19512			0.2											
10/24/20 18:00	0	X		0.19956			0.2											
10/24/20 19:00	0	X		0.33558			0.34											
10/24/20 20:00	0	X		0.31176			0.31											
10/24/20 21:00	0	X		0.26952			0.27											
10/24/20 22:00	0	X		0.23244			0.23											
10/24/20 23:00	0	X		0.20928			0.21											
10/25/20 0:00	0	X		0.19626			0.2											
10/25/20 1:00	0	X		0.18096			0.18											
10/25/20 2:00	0	X		0.18084			0.18											
10/25/20 3:00	0	X		0.18306			0.18											
10/25/20 4:00	0	X		0.19284			0.19											
10/25/20 5:00	0	X		0.20826			0.21											
10/25/20 6:00	0	X		0.22986			0.23											
10/25/20 7:00	0	X		0.23856			0.24											
10/25/20 8:00	0	X		0.24738			0.25											
10/25/20 9:00	0	X		0.28488			0.28											
10/25/20 10:00	0	X		0.29622			0.3											
10/25/20 11:00	0	X		0.29688			0.3											
10/25/20 12:00	0	X		0.30666			0.31											
10/25/20 13:00	0	X		0.30768			0.31											
10/25/20 14:00	0	X		0.32802			0.33											
10/25/20 15:00	0	X		0.32664			0.33											
10/25/20 16:00	0	X		0.25092			0.25											
10/25/20 17:00	0	X		0.2874			0.29											
10/25/20 18:00	0	X		0.27342			0.27											
10/25/20 19:00	0	X		0.26928			0.27											
10/25/20 20:00	0	X		0.23838			0.24											
10/25/20 21:00	0	X		0.23664			0.24											
10/25/20 22:00	0	X		0.22362			0.22											
10/25/20 23:00	0	X		0.20052			0.2											
10/26/20 0:00	0	X		0.17988			0.18											
10/26/20 1:00	0	X		0.17976			0.18											
10/26/20 2:00	0	X		0.17904			0.18											
10/26/20 3:00	0	X		0.18288			0.18											
10/26/20 4:00	0	X		0.20388			0.2											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
10/26/20 5:00	0	X		0.23394			0.23											
10/26/20 6:00	0	X		0.23238			0.23											
10/26/20 7:00	0	X		0.26502			0.27											
10/26/20 8:00	0	X		0.29796			0.3											
10/26/20 9:00	0	X		0.30786			0.31											
10/26/20 10:00	0	X		0.34434			0.34											
10/26/20 11:00	0	X		0.35526			0.36											
10/26/20 12:00	0	X		0.3555			0.36											
10/26/20 13:00	0	X		0.35052			0.35											
10/26/20 14:00	0	X		0.36204			0.36											
10/26/20 15:00	0	X		0.32976			0.33											
10/26/20 16:00	0	X		0.25554			0.26											
10/26/20 17:00	0	X		0.3066			0.31											
10/26/20 18:00	0	X		0.36636			0.37											
10/26/20 19:00	0	X		0.36384			0.36											
10/26/20 20:00	0	X		0.34722			0.35											
10/26/20 21:00	0	X		0.27102			0.27											
10/26/20 22:00	0	X		0.23694			0.24											
10/26/20 23:00	0	X		0.20766			0.21											
10/27/20 0:00	0	X		0.19716			0.2											
10/27/20 1:00	0	X		0.18708			0.19											
10/27/20 2:00	0	X		0.1797			0.18											
10/27/20 3:00	0	X		0.18114			0.18											
10/27/20 4:00	0	X		0.19818			0.2											
10/27/20 5:00	0	X		0.2475			0.25											
10/27/20 6:00	0	X		0.24336			0.24											
10/27/20 7:00	0	X		0.25266			0.25											
10/27/20 8:00	0	X		0.25152			0.25											
10/27/20 9:00	0	X		0.30288			0.3											
10/27/20 10:00	0	X		0.30744			0.31											
10/27/20 11:00	0	X		0.3084			0.31											
10/27/20 12:00	0	X		0.23682			0.24											
10/27/20 13:00	0	X		0.23484			0.23											
10/27/20 14:00	0	X		0.23688			0.24											
10/27/20 15:00	0	X		0.24852			0.25											
10/27/20 16:00	0	X		0.24888			0.25											
10/27/20 17:00	0	X		0.24948			0.25											
10/27/20 18:00	0	X		0.2475			0.25											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
10/27/20 19:00	0	X		0.22992			0.23											
10/27/20 20:00	0	X		0.25758			0.26											
10/27/20 21:00	0	X		0.25338			0.25											
10/27/20 22:00	0	X		0.21744			0.22											
10/27/20 23:00	0	X		0.1932			0.19											
10/28/20 0:00	0	X		0.1932			0.19											
10/28/20 1:00	0	X		0.19242			0.19											
10/28/20 2:00	0	X		0.18792			0.19											
10/28/20 3:00	0	X		0.19416			0.19											
10/28/20 4:00	0	X		0.2181			0.22											
10/28/20 5:00	0	X		0.2625			0.26											
10/28/20 6:00	0	X		0.255			0.26											
10/28/20 7:00	0	X		0.2514			0.25											
10/28/20 8:00	0	X		0.25236			0.25											
10/28/20 9:00	0	X		0.24918			0.25											
10/28/20 10:00	0	X		0.24468			0.24											
10/28/20 11:00	0	X		0.25176			0.25											
10/28/20 12:00	0	X		0.2676			0.27											
10/28/20 13:00	0	X		0.26388			0.26											
10/28/20 14:00	0	X		0.26526			0.27											
10/28/20 15:00	0	X		0.2325			0.23											
10/28/20 16:00	0	X		0.23442			0.23											
10/28/20 17:00	0	X		0.2562			0.26											
10/28/20 18:00	0	X		0.24876			0.25											
10/28/20 19:00	0	X		0.2139			0.21											
10/28/20 20:00	0	X		0.22422			0.22											
10/28/20 21:00	0	X		0.24528			0.25											
10/28/20 22:00	0	X		0.22356			0.22											
10/28/20 23:00	0	X		0.2034			0.2											
10/29/20 0:00	0	X		0.19164			0.19											
10/29/20 1:00	0	X		0.18834			0.19											
10/29/20 2:00	0	X		0.18504			0.19											
10/29/20 3:00	0	X		0.1896			0.19											
10/29/20 4:00	0	X		0.21198			0.21											
10/29/20 5:00	0	X		0.24762			0.25											
10/29/20 6:00	0	X		0.24804			0.25											
10/29/20 7:00	0	X		0.25368			0.25											
10/29/20 8:00	0	X		0.30252			0.3											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
10/29/20 9:00	0	X		0.3054			0.31											
10/29/20 10:00	0	X		0.30132			0.3											
10/29/20 11:00	0	X		0.30162			0.3											
10/29/20 12:00	0	X		0.3093			0.31											
10/29/20 13:00	0	X		0.2514			0.25											
10/29/20 14:00	0	X		0.2787			0.28											
10/29/20 15:00	0	X		0.24636			0.25											
10/29/20 16:00	0	X		0.24474			0.24											
10/29/20 17:00	0	X		0.26736			0.27											
10/29/20 18:00	0	X		0.2658			0.27											
10/29/20 19:00	0	X		0.27246			0.27											
10/29/20 20:00	0	X		0.22974			0.23											
10/29/20 21:00	0	X		0.17874			0.18											
10/29/20 22:00	0	X		0.21078			0.21											
10/29/20 23:00	0	X		0.21234			0.21											
10/30/20 0:00	0	X		0.19656			0.2											
10/30/20 1:00	0	X		0.19206			0.19											
10/30/20 2:00	0	X		0.19158			0.19											
10/30/20 3:00	0	X		0.19332			0.19											
10/30/20 4:00	0	X		0.21588			0.22											
10/30/20 5:00	0	X		0.24942			0.25											
10/30/20 6:00	0	X		0.24732			0.25											
10/30/20 7:00	0	X		0.24096			0.24											
10/30/20 8:00	0	X		0.25698			0.26											
10/30/20 9:00	0	X		0.27948			0.28											
10/30/20 10:00	0	X		0.30252			0.3											
10/30/20 11:00	0	X		0.30498			0.3											
10/30/20 12:00	0	X		0.3123			0.31											
10/30/20 13:00	0	X		0.35436			0.35											
10/30/20 14:00	0	X		0.35034			0.35											
10/30/20 15:00	0	X		0.24756			0.25											
10/30/20 16:00	0	X		0.2313			0.23											
10/30/20 17:00	0	X		0.22728			0.23											
10/30/20 18:00	0	X		0.23022			0.23											
10/30/20 19:00	0	X		0.2664			0.27											
10/30/20 20:00	0	X		0.24768			0.25											
10/30/20 21:00	0	X		0.2289			0.23											
10/30/20 22:00	0	X		0.231			0.23											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
10/30/20 23:00	0	X		0.21894			0.22											
10/31/20 0:00	0	X		0.20634			0.21											
10/31/20 1:00	0	X		0.1956			0.2											
10/31/20 2:00	0	X		0.18804			0.19											
10/31/20 3:00	0	X		0.19086			0.19											
10/31/20 4:00	0	X		0.1998			0.2											
10/31/20 5:00	0	X		0.22704			0.23											
10/31/20 6:00	0	X		0.24258			0.24											
10/31/20 7:00	0	X		0.2487			0.25											
10/31/20 8:00	0	X		0.27936			0.28											
10/31/20 9:00	0	X		0.2994			0.3											
10/31/20 10:00	0	X		0.29472			0.29											
10/31/20 11:00	0	X		0.29298			0.29											
10/31/20 12:00	0	X		0.23946			0.24											
10/31/20 13:00	0	X		0.24966			0.25											
10/31/20 14:00	0	X		0.34728			0.35											
10/31/20 15:00	0	X		0.23376			0.23											
10/31/20 16:00	0	X		0.19092			0.19											
10/31/20 17:00	0	X		0.2406			0.24											
10/31/20 18:00	0	X		0.23064			0.23											
10/31/20 19:00	0	X		0.22596			0.23											
10/31/20 20:00	0	X		0.21342			0.21											
10/31/20 21:00	0	X		0.2325			0.23											
10/31/20 22:00	0	X		0.23658			0.24											
10/31/20 23:00	0	X		0.19746			0.2											
11/01/20 0:00	0	X		0.17682			0.18											
11/01/20 1:00	0	X		0.17658			0.18											
11/01/20 2:00	0	X		0.17652			0.18											
11/01/20 3:00	0	X		0.17646			0.18											
11/01/20 4:00	0	X		0.17682			0.18											
11/01/20 5:00	0	X		0.17832			0.18											
11/01/20 6:00	0	X		0.18642			0.19											
11/01/20 7:00	0	X		0.20088			0.2											
11/01/20 8:00	0	X		0.21678			0.22											
11/01/20 9:00	0	X		0.22788			0.23											
11/01/20 10:00	0	X		0.24642			0.25											
11/01/20 11:00	0	X		0.29394			0.29											
11/01/20 12:00	0	X		0.29994			0.3											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
11/01/20 13:00	0	X		0.32694			0.33											
11/01/20 14:00	0	X		0.35142			0.35											
11/01/20 15:00	0	X		0.35172			0.35											
11/01/20 16:00	0	X		0.35154			0.35											
11/01/20 17:00	0	X		0.23874			0.24											
11/01/20 18:00	0	X		0.2256			0.23											
11/01/20 19:00	0	X		0.21252			0.21											
11/01/20 20:00	0	X		0.17808			0.18											
11/01/20 21:00	0	X		0.25314			0.25											
11/01/20 22:00	0	X		0.21894			0.22											
11/01/20 23:00	0	X		0.18306			0.18											
11/02/20 0:00	0	X		0.17064			0.17											
11/02/20 1:00	0	X		0.17118			0.17											
11/02/20 2:00	0	X		0.1734			0.17											
11/02/20 3:00	0	X		0.18222			0.18											
11/02/20 4:00	0	X		0.20334			0.2											
11/02/20 5:00	0	X		0.20898			0.21											
11/02/20 6:00	0	X		0.24732			0.25											
11/02/20 7:00	0	X		0.24816			0.25											
11/02/20 8:00	0	X		0.24624			0.25											
11/02/20 9:00	0	X		0.25842			0.26											
11/02/20 10:00	0	X		0.26118			0.26											
11/02/20 11:00	0	X		0.3066			0.31											
11/02/20 12:00	0	X		0.36276			0.36											
11/02/20 13:00	0	X		0.36582			0.37											
11/02/20 14:00	0	X		0.36582			0.37											
11/02/20 15:00	0	X		0.36528			0.37											
11/02/20 16:00	0	X		0.3657			0.37											
11/02/20 17:00	0	X		0.363			0.36											
11/02/20 18:00	0	X		0.363			0.36											
11/02/20 19:00	0	X		0.32634			0.33											
11/02/20 20:00	0	X		0.22494			0.22											
11/02/20 21:00	0	X		0.29184			0.29											
11/02/20 22:00	0	X		0.243			0.24											
11/02/20 23:00	0	X		0.19896			0.2											
11/03/20 0:00	0	X		0.18618			0.19											
11/03/20 1:00	0	X		0.17946			0.18											
11/03/20 2:00	0	X		0.17694			0.18											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
11/03/20 3:00	0	X		0.17982			0.18											
11/03/20 4:00	0	X		0.18432			0.18											
11/03/20 5:00	0	X		0.20916			0.21											
11/03/20 6:00	0	X		0.24246			0.24											
11/03/20 7:00	0	X		0.23238			0.23											
11/03/20 8:00	0	X		0.27018			0.27											
11/03/20 9:00	0	X		0.33192			0.33											
11/03/20 10:00	0	X		0.33888			0.34											
11/03/20 11:00	0	X		0.33996			0.34											
11/03/20 12:00	0	X		0.33876			0.34											
11/03/20 13:00	0	X		0.33438			0.33											
11/03/20 14:00	0	X		0.33702			0.34											
11/03/20 15:00	0	X		0.36678			0.37											
11/03/20 16:00	0	X		0.36468			0.36											
11/03/20 17:00	0	X		0.3375			0.34											
11/03/20 18:00	0	X		0.3066			0.31											
11/03/20 19:00	0	X		0.26202			0.26											
11/03/20 20:00	0	X		0.27672			0.28											
11/03/20 21:00	0	X		0.30396			0.3											
11/03/20 22:00	0	X		0.27018			0.27											
11/03/20 23:00	0	X		0.21906			0.22											
11/04/20 0:00	0	X		0.1914			0.19											
11/04/20 1:00	0	X		0.17964			0.18											
11/04/20 2:00	0	X		0.1782			0.18											
11/04/20 3:00	0	X		0.17934			0.18											
11/04/20 4:00	0	X		0.17928			0.18											
11/04/20 5:00	0	X		0.20022			0.2											
11/04/20 6:00	0	X		0.18486			0.18											
11/04/20 7:00	0	X		0.21222			0.21											
11/04/20 8:00	0	X		0.21552			0.22											
11/04/20 9:00	0	X		0.25458			0.25											
11/04/20 10:00	0	X		0.2625			0.26											
11/04/20 11:00	0	X		0.26496			0.26											
11/04/20 12:00	0	X		0.26688			0.27											
11/04/20 13:00	0	X		0.30678			0.31											
11/04/20 14:00	0	X		0.32178			0.32											
11/04/20 15:00	0	X		0.32196			0.32											
11/04/20 16:00	0	X		0.27588			0.28											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
11/04/20 17:00	0	X		0.23502			0.24											
11/04/20 18:00	0	X		0.21444			0.21											
11/04/20 19:00	0	X		0.22698			0.23											
11/04/20 20:00	0	X		0.23118			0.23											
11/04/20 21:00	0	X		0.2553			0.26											
11/04/20 22:00	0	X		0.25176			0.25											
11/04/20 23:00	0	X		0.22482			0.22											
11/05/20 0:00	0	X		0.18738			0.19											
11/05/20 1:00	0	X		0.18696			0.19											
11/05/20 2:00	0	X		0.18702			0.19											
11/05/20 3:00	0	X		0.18642			0.19											
11/05/20 4:00	0	X		0.18606			0.19											
11/05/20 5:00	0	X		0.1845			0.18											
11/05/20 6:00	0	X		0.21018			0.21											
11/05/20 7:00	0	X		0.22836			0.23											
11/05/20 8:00	0	X		0.23556			0.24											
11/05/20 9:00	0	X		0.23538			0.24											
11/05/20 10:00	0	X		0.25662			0.26											
11/05/20 11:00	0	X		0.26076			0.26											
11/05/20 12:00	0	X		0.26022			0.26											
11/05/20 13:00	0	X		0.30918			0.31											
11/05/20 14:00	0	X		0.34038			0.34											
11/05/20 15:00	0	X		0.3195			0.32											
11/05/20 16:00	0	X		0.31662			0.32											
11/05/20 17:00	0	X		0.2355			0.24											
11/05/20 18:00	0	X		0.21528			0.22											
11/05/20 19:00	0	X		0.21738			0.22											
11/05/20 20:00	0	X		0.26946			0.27											
11/05/20 21:00	0	X		0.27228			0.27											
11/05/20 22:00	0	X		0.22932			0.23											
11/05/20 23:00	0	X		0.22374			0.22											
11/06/20 0:00	0	X		0.1779			0.18											
11/06/20 1:00	0	X		0.17622			0.18											
11/06/20 2:00	0	X		0.17658			0.18											
11/06/20 3:00	0	X		0.17826			0.18											
11/06/20 4:00	0	X		0.17964			0.18											
11/06/20 5:00	0	X		0.18828			0.19											
11/06/20 6:00	0	X		0.19398			0.19											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
11/06/20 7:00	0	X		0.21048			0.21											
11/06/20 8:00	0	X		0.23292			0.23											
11/06/20 9:00	0	X		0.22794			0.23											
11/06/20 10:00	0	X		0.23502			0.24											
11/06/20 11:00	0	X		0.2343			0.23											
11/06/20 12:00	0	X		0.23244			0.23											
11/06/20 13:00	0	X		0.24528			0.25											
11/06/20 14:00	0	X		0.25278			0.25											
11/06/20 15:00	0	X		0.23298			0.23											
11/06/20 16:00	0	X		0.20478			0.2											
11/06/20 17:00	0	X		0.24978			0.25											
11/06/20 18:00	0	X		0.19548			0.2											
11/06/20 19:00	0	X		0.24594			0.25											
11/06/20 20:00	0	X		0.23868			0.24											
11/06/20 21:00	0	X		0.23484			0.23											
11/06/20 22:00	0	X		0.23514			0.24											
11/06/20 23:00	0	X		0.21966			0.22											
11/07/20 0:00	0	X		0.2064			0.21											
11/07/20 1:00	0	X		0.18444			0.18											
11/07/20 2:00	0	X		0.1764			0.18											
11/07/20 3:00	0	X		0.17634			0.18											
11/07/20 4:00	0	X		0.17682			0.18											
11/07/20 5:00	0	X		0.17898			0.18											
11/07/20 6:00	0	X		0.18024			0.18											
11/07/20 7:00	0	X		0.2016			0.2											
11/07/20 8:00	0	X		0.2328			0.23											
11/07/20 9:00	0	X		0.25002			0.25											
11/07/20 10:00	0	X		0.25002			0.25											
11/07/20 11:00	0	X		0.24744			0.25											
11/07/20 12:00	0	X		0.23526			0.24											
11/07/20 13:00	0	X		0.21576			0.22											
11/07/20 14:00	0	X		0.22536			0.23											
11/07/20 15:00	0	X		0.22674			0.23											
11/07/20 16:00	0	X		0.19812			0.2											
11/07/20 17:00	0	X		0.2193			0.22											
11/07/20 18:00	0	X		0.23904			0.24											
11/07/20 19:00	0	X		0.2424			0.24											
11/07/20 20:00	0	X		0.23724			0.24											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
11/07/20 21:00	0	X		0.2289			0.23											
11/07/20 22:00	0	X		0.23124			0.23											
11/07/20 23:00	0	X		0.21486			0.21											
11/08/20 0:00	0	X		0.20472			0.2											
11/08/20 1:00	0	X		0.18966			0.19											
11/08/20 2:00	0	X		0.18228			0.18											
11/08/20 3:00	0	X		0.18252			0.18											
11/08/20 4:00	0	X		0.18444			0.18											
11/08/20 5:00	0	X		0.18822			0.19											
11/08/20 6:00	0	X		0.21156			0.21											
11/08/20 7:00	0	X		0.22092			0.22											
11/08/20 8:00	0	X		0.2415			0.24											
11/08/20 9:00	0	X		0.18372			0.18											
11/08/20 10:00	0	X		0.18234			0.18											
11/08/20 11:00	0	X		0.19356			0.19											
11/08/20 12:00	0	X		0.19338			0.19											
11/08/20 13:00	0	X		0.20214			0.2											
11/08/20 14:00	0	X		0.25002			0.25											
11/08/20 15:00	0	X		0.25236			0.25											
11/08/20 16:00	0	X		0.24156			0.24											
11/08/20 17:00	0	X		0.23664			0.24											
11/08/20 18:00	0	X		0.24222			0.24											
11/08/20 19:00	0	X		0.24666			0.25											
11/08/20 20:00	0	X		0.23718			0.24											
11/08/20 21:00	0	X		0.23202			0.23											
11/08/20 22:00	0	X		0.22116			0.22											
11/08/20 23:00	0	X		0.21414			0.21											
11/09/20 0:00	0	X		0.19314			0.19											
11/09/20 1:00	0	X		0.1977			0.2											
11/09/20 2:00	0	X		0.1938			0.19											
11/09/20 3:00	0	X		0.20058			0.2											
11/09/20 4:00	0	X		0.21216			0.21											
11/09/20 5:00	0	X		0.23166			0.23											
11/09/20 6:00	0	X		0.23256			0.23											
11/09/20 7:00	0	X		0.25056			0.25											
11/09/20 8:00	0	X		0.2529			0.25											
11/09/20 9:00	0	X		0.25704			0.26											
11/09/20 10:00	0	X		0.25542			0.26											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
11/09/20 11:00	0	X		0.25638			0.26											
11/09/20 12:00	0	X		0.25218			0.25											
11/09/20 13:00	0	X		0.25188			0.25											
11/09/20 14:00	0	X		0.25854			0.26											
11/09/20 15:00	0	X		0.2211			0.22											
11/09/20 16:00	0	X		0.2163			0.22											
11/09/20 17:00	0	X		0.21636			0.22											
11/09/20 18:00	0	X		0.21798			0.22											
11/09/20 19:00	0	X		0.21888			0.22											
11/09/20 20:00	0	X		0.22098			0.22											
11/09/20 21:00	0	X		0.22314			0.22											
11/09/20 22:00	0	X		0.2319			0.23											
11/09/20 23:00	0	X		0.24414			0.24											
11/10/20 0:00	0	X		0.19614			0.2											
11/10/20 1:00	0	X		0.20922			0.21											
11/10/20 2:00	0	X		0.20742			0.21											
11/10/20 3:00	0	X		0.21348			0.21											
11/10/20 4:00	0	X		0.22638			0.23											
11/10/20 5:00	0	X		0.24762			0.25											
11/10/20 6:00	0	X		0.24378			0.24											
11/10/20 7:00	0	X		0.2595			0.26											
11/10/20 8:00	0	X		0.30012			0.3											
11/10/20 9:00	0	X		0.28536			0.29											
11/10/20 10:00	0	X		0.22938			0.23											
11/10/20 11:00	0	X		0.23064			0.23											
11/10/20 12:00	0	X		0.23328			0.23											
11/10/20 13:00	0	X		0.25428			0.25											
11/10/20 14:00	0	X		0.22002			0.22											
11/10/20 15:00	0	X		0.24768			0.25											
11/10/20 16:00	0	X		0.2388			0.24											
11/10/20 17:00	0	X		0.23652			0.24											
11/10/20 18:00	0	X		0.23082			0.23											
11/10/20 19:00	0	X		0.25128			0.25											
11/10/20 20:00	0	X		0.24372			0.24											
11/10/20 21:00	0	X		0.2511			0.25											
11/10/20 22:00	0	X		0.24246			0.24											
11/10/20 23:00	0	X		0.21			0.21											
11/11/20 0:00	0	X		0.17856			0.18											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
11/11/20 1:00	0	X		0.17442			0.17											
11/11/20 2:00	0	X		0.17436			0.17											
11/11/20 3:00	0	X		0.17424			0.17											
11/11/20 4:00	0	X		0.17616			0.18											
11/11/20 5:00	0	X		0.20136			0.2											
11/11/20 6:00	0	X		0.22146			0.22											
11/11/20 7:00	0	X		0.24			0.24											
11/11/20 8:00	0	X		0.24786			0.25											
11/11/20 9:00	0	X		0.24954			0.25											
11/11/20 10:00	0	X		0.24552			0.25											
11/11/20 11:00	0	X		0.23016			0.23											
11/11/20 12:00	0	X		0.23016			0.23											
11/11/20 13:00	0	X		0.23022			0.23											
11/11/20 14:00	0	X		0.23316			0.23											
11/11/20 15:00	0	X		0.27042			0.27											
11/11/20 16:00	0	X		0.249			0.25											
11/11/20 17:00	0	X		0.22446			0.22											
11/11/20 18:00	0	X		0.22854			0.23											
11/11/20 19:00	0	X		0.2154			0.22											
11/11/20 20:00	0	X		0.23532			0.24											
11/11/20 21:00	0	X		0.24486			0.24											
11/11/20 22:00	0	X		0.21864			0.22											
11/11/20 23:00	0	X		0.19008			0.19											
11/12/20 0:00	0	X		0.18054			0.18											
11/12/20 1:00	0	X		0.17376			0.17											
11/12/20 2:00	0	X		0.17394			0.17											
11/12/20 3:00	0	X		0.17526			0.18											
11/12/20 4:00	0	X		0.18624			0.19											
11/12/20 5:00	0	X		0.2082			0.21											
11/12/20 6:00	0	X		0.2391			0.24											
11/12/20 7:00	0	X		0.25404			0.25											
11/12/20 8:00	0	X		0.25686			0.26											
11/12/20 9:00	0	X		0.25668			0.26											
11/12/20 10:00	0	X		0.2253			0.23											
11/12/20 11:00	0	X		0.19476			0.19											
11/12/20 12:00	0	X		0.18096			0.18											
11/12/20 13:00	0	X		0.18114			0.18											
11/12/20 14:00	0	X		0.1821			0.18											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
11/12/20 15:00	0	X		0.24012			0.24											
11/12/20 16:00	0	X		0.2382			0.24											
11/12/20 17:00	0	X		0.24186			0.24											
11/12/20 18:00	0	X		0.24276			0.24											
11/12/20 19:00	0	X		0.24936			0.25											
11/12/20 20:00	0	X		0.24924			0.25											
11/12/20 21:00	0	X		0.24414			0.24											
11/12/20 22:00	0	X		0.21564			0.22											
11/12/20 23:00	0	X		0.19776			0.2											
11/13/20 0:00	0	X		0.18234			0.18											
11/13/20 1:00	0	X		0.17424			0.17											
11/13/20 2:00	0	X		0.17442			0.17											
11/13/20 3:00	0	X		0.17466			0.17											
11/13/20 4:00	0	X		0.17442			0.17											
11/13/20 5:00	0	X		0.1965			0.2											
11/13/20 6:00	0	X		0.23148			0.23											
11/13/20 7:00	0	X		0.25068			0.25											
11/13/20 8:00	0	X		0.255			0.26											
11/13/20 9:00	0	X		0.25482			0.25											
11/13/20 10:00	0	X		0.25836			0.26											
11/13/20 11:00	0	X		0.2811			0.28											
11/13/20 12:00	0	X		0.2712			0.27											
11/13/20 13:00	0	X		0.28548			0.29											
11/13/20 14:00	0	X		0.26568			0.27											
11/13/20 15:00	0	X		0.25176			0.25											
11/13/20 16:00	0	X		0.24702			0.25											
11/13/20 17:00	0	X		0.22218			0.22											
11/13/20 18:00	0	X		0.22734			0.23											
11/13/20 19:00	0	X		0.21318			0.21											
11/13/20 20:00	0	X		0.23658			0.24											
11/13/20 21:00	0	X		0.23862			0.24											
11/13/20 22:00	0	X		0.22638			0.23											
11/13/20 23:00	0	X		0.19542			0.2											
11/14/20 0:00	0	X		0.18624			0.19											
11/14/20 1:00	0	X		0.17334			0.17											
11/14/20 2:00	0	X		0.17466			0.17											
11/14/20 3:00	0	X		0.17478			0.17											
11/14/20 4:00	0	X		0.17466			0.17											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
11/14/20 5:00	0	X		0.17574			0.18											
11/14/20 6:00	0	X		0.1902			0.19											
11/14/20 7:00	0	X		0.21996			0.22											
11/14/20 8:00	0	X		0.24072			0.24											
11/14/20 9:00	0	X		0.26568			0.27											
11/14/20 10:00	0	X		0.21738			0.22											
11/14/20 11:00	0	X		0.19962			0.2											
11/14/20 12:00	0	X		0.2064			0.21											
11/14/20 13:00	0	X		0.2487			0.25											
11/14/20 14:00	0	X		0.24564			0.25											
11/14/20 15:00	0	X		0.23982			0.24											
11/14/20 16:00	0	X		0.26256			0.26											
11/14/20 17:00	0	X		0.2346			0.23											
11/14/20 18:00	0	X		0.23886			0.24											
11/14/20 19:00	0	X		0.23466			0.23											
11/14/20 20:00	0	X		0.25374			0.25											
11/14/20 21:00	0	X		0.25446			0.25											
11/14/20 22:00	0	X		0.28404			0.28											
11/14/20 23:00	0	X		0.21954			0.22											
11/15/20 0:00	0	X		0.18216			0.18											
11/15/20 1:00	0	X		0.18018			0.18											
11/15/20 2:00	0	X		0.2085			0.21											
11/15/20 3:00	0	X		0.2091			0.21											
11/15/20 4:00	0	X		0.17844			0.18											
11/15/20 5:00	0	X		0.19356			0.19											
11/15/20 6:00	0	X		0.21378			0.21											
11/15/20 7:00	0	X		0.21294			0.21											
11/15/20 8:00	0	X		0.2301			0.23											
11/15/20 9:00	0	X		0.23556			0.24											
11/15/20 10:00	0	X		0.24282			0.24											
11/15/20 11:00	0	X		0.25374			0.25											
11/15/20 12:00	0	X		0.24552			0.25											
11/15/20 13:00	0	X		0.24918			0.25											
11/15/20 14:00	0	X		0.26814			0.27											
11/15/20 15:00	0	X		0.28488			0.28											
11/15/20 16:00	0	X		0.27228			0.27											
11/15/20 17:00	0	X		0.25716			0.26											
11/15/20 18:00	0	X		0.24786			0.25											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
11/15/20 19:00	0	X		0.27048			0.27											
11/15/20 20:00	0	X		0.27144			0.27											
11/15/20 21:00	0	X		0.243			0.24											
11/15/20 22:00	0	X		0.2106			0.21											
11/15/20 23:00	0	X		0.19458			0.19											
11/16/20 0:00	0	X		0.17922			0.18											
11/16/20 1:00	0	X		0.17802			0.18											
11/16/20 2:00	0	X		0.17574			0.18											
11/16/20 3:00	0	X		0.17742			0.18											
11/16/20 4:00	0	X		0.17868			0.18											
11/16/20 5:00	0	X		0.19842			0.2											
11/16/20 6:00	0	X		0.2526			0.25											
11/16/20 7:00	0	X		0.25878			0.26											
11/16/20 8:00	0	X		0.26106			0.26											
11/16/20 9:00	0	X		0.26478			0.26											
11/16/20 10:00	0	X		0.26088			0.26											
11/16/20 11:00	0	X		0.26712			0.27											
11/16/20 12:00	0	X		0.26928			0.27											
11/16/20 13:00	0	X		0.27096			0.27											
11/16/20 14:00	0	X		0.258			0.26											
11/16/20 15:00	0	X		0.2427			0.24											
11/16/20 16:00	0	X		0.2109			0.21											
11/16/20 17:00	0	X		0.23802			0.24											
11/16/20 18:00	0	X		0.23712			0.24											
11/16/20 19:00	0	X		0.2514			0.25											
11/16/20 20:00	0	X		0.25476			0.25											
11/16/20 21:00	0	X		0.25956			0.26											
11/16/20 22:00	0	X		0.2115			0.21											
11/16/20 23:00	0	X		0.18768			0.19											
11/17/20 0:00	0	X		0.18144			0.18											
11/17/20 1:00	0	X		0.17658			0.18											
11/17/20 2:00	0	X		0.17424			0.17											
11/17/20 3:00	0	X		0.1746			0.17											
11/17/20 4:00	0	X		0.17544			0.18											
11/17/20 5:00	0	X		0.19392			0.19											
11/17/20 6:00	0	X		0.20934			0.21											
11/17/20 7:00	0	X		0.22176			0.22											
11/17/20 8:00	0	X		0.24588			0.25											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
11/17/20 9:00	0	X		0.2613			0.26											
11/17/20 10:00	0	X		0.26244			0.26											
11/17/20 11:00	0	X		0.2637			0.26											
11/17/20 12:00	0	X		0.26496			0.26											
11/17/20 13:00	0	X		0.26364			0.26											
11/17/20 14:00	0	X		0.2466			0.25											
11/17/20 15:00	0	X		0.23724			0.24											
11/17/20 16:00	0	X		0.23694			0.24											
11/17/20 17:00	0	X		0.23706			0.24											
11/17/20 18:00	0	X		0.23778			0.24											
11/17/20 19:00	0	X		0.21672			0.22											
11/17/20 20:00	0	X		0.22722			0.23											
11/17/20 21:00	0	X		0.21786			0.22											
11/17/20 22:00	0	X		0.2088			0.21											
11/17/20 23:00	0	X		0.18396			0.18											
11/18/20 0:00	0	X		0.17994			0.18											
11/18/20 1:00	0	X		0.17262			0.17											
11/18/20 2:00	0	X		0.1728			0.17											
11/18/20 3:00	0	X		0.17286			0.17											
11/18/20 4:00	0	X		0.1731			0.17											
11/18/20 5:00	0	X		0.18528			0.19											
11/18/20 6:00	0	X		0.20874			0.21											
11/18/20 7:00	0	X		0.23934			0.24											
11/18/20 8:00	0	X		0.2616			0.26											
11/18/20 9:00	0	X		0.26196			0.26											
11/18/20 10:00	0	X		0.26394			0.26											
11/18/20 11:00	0	X		0.26502			0.27											
11/18/20 12:00	0	X		0.26706			0.27											
11/18/20 13:00	0	X		0.24612			0.25											
11/18/20 14:00	0	X		0.2454			0.25											
11/18/20 15:00	0	X		0.24552			0.25											
11/18/20 16:00	0	X		0.24534			0.25											
11/18/20 17:00	0	X		0.2454			0.25											
11/18/20 18:00	0	X		0.2421			0.24											
11/18/20 19:00	0	X		0.22758			0.23											
11/18/20 20:00	0	X		0.24906			0.25											
11/18/20 21:00	0	X		0.21714			0.22											
11/18/20 22:00	0	X		0.21264			0.21											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
11/18/20 23:00	0	X		0.19086			0.19											
11/19/20 0:00	0	X		0.1809			0.18											
11/19/20 1:00	0	X		0.17316			0.17											
11/19/20 2:00	0	X		0.17304			0.17											
11/19/20 3:00	0	X		0.17298			0.17											
11/19/20 4:00	0	X		0.17466			0.17											
11/19/20 5:00	0	X		0.19668			0.2											
11/19/20 6:00	0	X		0.22038			0.22											
11/19/20 7:00	0	X		0.24828			0.25											
11/19/20 8:00	0	X		0.25962			0.26											
11/19/20 9:00	0	X		0.267			0.27											
11/19/20 10:00	0	X		0.24042			0.24											
11/19/20 11:00	0	X		0.23958			0.24											
11/19/20 12:00	0	X		0.23982			0.24											
11/19/20 13:00	0	X		0.23904			0.24											
11/19/20 14:00	0	X		0.24648			0.25											
11/19/20 15:00	0	X		0.23916			0.24											
11/19/20 16:00	0	X		0.23316			0.23											
11/19/20 17:00	0	X		0.24144			0.24											
11/19/20 18:00	0	X		0.2541			0.25											
11/19/20 19:00	0	X		0.22068			0.22											
11/19/20 20:00	0	X		0.22446			0.22											
11/19/20 21:00	0	X		0.228			0.23											
11/19/20 22:00	0	X		0.22386			0.22											
11/19/20 23:00	0	X		0.2004			0.2											
11/20/20 0:00	0	X		0.1827			0.18											
11/20/20 1:00	0	X		0.17508			0.18											
11/20/20 2:00	0	X		0.17472			0.17											
11/20/20 3:00	0	X		0.1752			0.18											
11/20/20 4:00	0	X		0.18792			0.19											
11/20/20 5:00	0	X		0.21126			0.21											
11/20/20 6:00	0	X		0.26034			0.26											
11/20/20 7:00	0	X		0.26178			0.26											
11/20/20 8:00	0	X		0.26112			0.26											
11/20/20 9:00	0	X		0.30492			0.3											
11/20/20 10:00	0	X		0.29298			0.29											
11/20/20 11:00	0	X		0.2715			0.27											
11/20/20 12:00	0	X		0.24228			0.24											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
11/20/20 13:00	0	X		0.23484			0.23											
11/20/20 14:00	0	X		0.23142			0.23											
11/20/20 15:00	0	X		0.2337			0.23											
11/20/20 16:00	0	X		0.23718			0.24											
11/20/20 17:00	0	X		0.25806			0.26											
11/20/20 18:00	0	X		0.24588			0.25											
11/20/20 19:00	0	X		0.24354			0.24											
11/20/20 20:00	0	X		0.24972			0.25											
11/20/20 21:00	0	X		0.25266			0.25											
11/20/20 22:00	0	X		0.23622			0.24											
11/20/20 23:00	0	X		0.22158			0.22											
11/21/20 0:00	0	X		0.2304			0.23											
11/21/20 1:00	0	X		0.21834			0.22											
11/21/20 2:00	0	X		0.20856			0.21											
11/21/20 3:00	0	X		0.20496			0.2											
11/21/20 4:00	0	X		0.21768			0.22											
11/21/20 5:00	0	X		0.20124			0.2											
11/21/20 6:00	0	X		0.20082			0.2											
11/21/20 7:00	0	X		0.23478			0.23											
11/21/20 8:00	0	X		0.24252			0.24											
11/21/20 9:00	0	X		0.2499			0.25											
11/21/20 10:00	0	X		0.24792			0.25											
11/21/20 11:00	0	X		0.23796			0.24											
11/21/20 12:00	0	X		0.23274			0.23											
11/21/20 13:00	0	X		0.23154			0.23											
11/21/20 14:00	0	X		0.23796			0.24											
11/21/20 15:00	0	X		0.23826			0.24											
11/21/20 16:00	0	X		0.23754			0.24											
11/21/20 17:00	0	X		0.23166			0.23											
11/21/20 18:00	0	X		0.24312			0.24											
11/21/20 19:00	0	X		0.25368			0.25											
11/21/20 20:00	0	X		0.25416			0.25											
11/21/20 21:00	0	X		0.25374			0.25											
11/21/20 22:00	0	X		0.27324			0.27											
11/21/20 23:00	0	X		0.24018			0.24											
11/22/20 0:00	0	X		0.18966			0.19											
11/22/20 1:00	0	X		0.18438			0.18											
11/22/20 2:00	0	X		0.18396			0.18											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
11/22/20 3:00	0	X		0.18402			0.18											
11/22/20 4:00	0	X		0.18408			0.18											
11/22/20 5:00	0	X		0.1863			0.19											
11/22/20 6:00	0	X		0.20352			0.2											
11/22/20 7:00	0	X		0.23556			0.24											
11/22/20 8:00	0	X		0.25464			0.25											
11/22/20 9:00	0	X		0.27132			0.27											
11/22/20 10:00	0	X		0.28122			0.28											
11/22/20 11:00	0	X		0.25272			0.25											
11/22/20 12:00	0	X		0.25146			0.25											
11/22/20 13:00	0	X		0.25614			0.26											
11/22/20 14:00	0	X		0.24318			0.24											
11/22/20 15:00	0	X		0.27858			0.28											
11/22/20 16:00	0	X		0.32052			0.32											
11/22/20 17:00	0	X		0.29652			0.3											
11/22/20 18:00	0	X		0.2937			0.29											
11/22/20 19:00	0	X		0.2613			0.26											
11/22/20 20:00	0	X		0.26406			0.26											
11/22/20 21:00	0	X		0.26298			0.26											
11/22/20 22:00	0	X		0.22752			0.23											
11/22/20 23:00	0	X		0.19686			0.2											
11/23/20 0:00	0	X		0.18096			0.18											
11/23/20 1:00	0	X		0.18102			0.18											
11/23/20 2:00	0	X		0.1812			0.18											
11/23/20 3:00	0	X		0.18096			0.18											
11/23/20 4:00	0	X		0.18144			0.18											
11/23/20 5:00	0	X		0.20508			0.21											
11/23/20 6:00	0	X		0.23766			0.24											
11/23/20 7:00	0	X		0.23922			0.24											
11/23/20 8:00	0	X		0.25026			0.25											
11/23/20 9:00	0	X		0.25116			0.25											
11/23/20 10:00	0	X		0.24882			0.25											
11/23/20 11:00	0	X		0.24984			0.25											
11/23/20 12:00	0	X		0.24732			0.25											
11/23/20 13:00	0	X		0.24504			0.25											
11/23/20 14:00	0	X		0.24312			0.24											
11/23/20 15:00	0	X		0.24834			0.25											
11/23/20 16:00	0	X		0.26196			0.26											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
11/23/20 17:00	0	X		0.23904			0.24											
11/23/20 18:00	0	X		0.24834			0.25											
11/23/20 19:00	0	X		0.23682			0.24											
11/23/20 20:00	0	X		0.23496			0.23											
11/23/20 21:00	0	X		0.23448			0.23											
11/23/20 22:00	0	X		0.22812			0.23											
11/23/20 23:00	0	X		0.20472			0.2											
11/24/20 0:00	0	X		0.18048			0.18											
11/24/20 1:00	0	X		0.18006			0.18											
11/24/20 2:00	0	X		0.18078			0.18											
11/24/20 3:00	0	X		0.18042			0.18											
11/24/20 4:00	0	X		0.18144			0.18											
11/24/20 5:00	0	X		0.20628			0.21											
11/24/20 6:00	0	X		0.25506			0.26											
11/24/20 7:00	0	X		0.25356			0.25											
11/24/20 8:00	0	X		0.25596			0.26											
11/24/20 9:00	0	X		0.25206			0.25											
11/24/20 10:00	0	X		0.24804			0.25											
11/24/20 11:00	0	X		0.24294			0.24											
11/24/20 12:00	0	X		0.25254			0.25											
11/24/20 13:00	0	X		0.24534			0.25											
11/24/20 14:00	0	X		0.24348			0.24											
11/24/20 15:00	0	X		0.24048			0.24											
11/24/20 16:00	0	X		0.24426			0.24											
11/24/20 17:00	0	X		0.24648			0.25											
11/24/20 18:00	0	X		0.2388			0.24											
11/24/20 19:00	0	X		0.23232			0.23											
11/24/20 20:00	0	X		0.25128			0.25											
11/24/20 21:00	0	X		0.24846			0.25											
11/24/20 22:00	0	X		0.23622			0.24											
11/24/20 23:00	0	X		0.2049			0.2											
11/25/20 0:00	0	X		0.19488			0.19											
11/25/20 1:00	0	X		0.18144			0.18											
11/25/20 2:00	0	X		0.18192			0.18											
11/25/20 3:00	0	X		0.19752			0.2											
11/25/20 4:00	0	X		0.19878			0.2											
11/25/20 5:00	0	X		0.21198			0.21											
11/25/20 6:00	0	X		0.25278			0.25											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/25/20 7:00	0	X		0.23778			0.24											
11/25/20 8:00	0	X		0.24228			0.24											
11/25/20 9:00	0	X		0.2499			0.25											
11/25/20 10:00	0	X		0.25698			0.26											
11/25/20 11:00	0	X		0.25482			0.25											
11/25/20 12:00	0	X		0.25128			0.25											
11/25/20 13:00	0	X		0.225			0.23											
11/25/20 14:00	0	X		0.23226			0.23											
11/25/20 15:00	0	X		0.24768			0.25											
11/25/20 16:00	0	X		0.24432			0.24											
11/25/20 17:00	0	X		0.23226			0.23											
11/25/20 18:00	0	X		0.23928			0.24											
11/25/20 19:00	0	X		0.23952			0.24											
11/25/20 20:00	0	X		0.23958			0.24											
11/25/20 21:00	0	X		0.249			0.25											
11/25/20 22:00	0	X		0.24174			0.24											
11/25/20 23:00	0	X		0.20178			0.2											
11/26/20 0:00	0	X		0.06774			0											
11/26/20 1:00	0	X		0	X		0											
11/26/20 2:00	0	X		0	X		0											
11/26/20 3:00	0	X		0	X		0											
11/26/20 4:00	0	X		0	X		0											
11/26/20 5:00	0	X		0	X		0											
11/26/20 6:00	0	X		0	X		0											
11/26/20 7:00	0	X		0	X		0											
11/26/20 8:00	0	X		0	X		0											
11/26/20 9:00	0	X		0	X		0											
11/26/20 10:00	0	X		0	X		0											
11/26/20 11:00	0	X		0	X		0											
11/26/20 12:00	0	X		0	X		0											
11/26/20 13:00	0	X		0	X		0											
11/26/20 14:00	0	X		0	X		0											
11/26/20 15:00	0	X		0	X		0											
11/26/20 16:00	0	X		0	X		0											
11/26/20 17:00	0	X		0	X		0											
11/26/20 18:00	0	X		0	X		0											
11/26/20 19:00	0	X		0	X		0											
11/26/20 20:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/26/20 21:00	0	X		0	X		0											
11/26/20 22:00	0	X		0	X		0											
11/26/20 23:00	0	X		0	X		0											
11/27/20 0:00	0	X		0	X		0											
11/27/20 1:00	0	X		0	X		0											
11/27/20 2:00	0	X		0	X		0											
11/27/20 3:00	0	X		0	X		0											
11/27/20 4:00	0	X		0	X		0											
11/27/20 5:00	0	X		0	X		0											
11/27/20 6:00	0	X		0	X		0											
11/27/20 7:00	0	X		0	X		0											
11/27/20 8:00	0	X		0	X		0											
11/27/20 9:00	0	X		0	X		0											
11/27/20 10:00	0	X		0	X		0											
11/27/20 11:00	0	X		0	X		0											
11/27/20 12:00	0	X		0	X		0											
11/27/20 13:00	0	X		0	X		0											
11/27/20 14:00	0	X		0	X		0											
11/27/20 15:00	0	X		0	X		0											
11/27/20 16:00	0	X		0	X		0											
11/27/20 17:00	0	X		0	X		0											
11/27/20 18:00	0	X		0	X		0											
11/27/20 19:00	0	X		0	X		0											
11/27/20 20:00	0	X		0	X		0											
11/27/20 21:00	0	X		0	X		0											
11/27/20 22:00	0	X		0	X		0											
11/27/20 23:00	0	X		0	X		0											
11/28/20 0:00	0	X		0	X		0											
11/28/20 1:00	0	X		0	X		0											
11/28/20 2:00	0	X		0	X		0											
11/28/20 3:00	0	X		0	X		0											
11/28/20 4:00	0	X		0	X		0											
11/28/20 5:00	0	X		0	X		0											
11/28/20 6:00	0	X		0	X		0											
11/28/20 7:00	0	X		0	X		0											
11/28/20 8:00	0	X		0	X		0											
11/28/20 9:00	0	X		0	X		0											
11/28/20 10:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
11/28/20 11:00	0	X		0	X		0											
11/28/20 12:00	0	X		0	X		0											
11/28/20 13:00	0	X		0	X		0											
11/28/20 14:00	0	X		0	X		0											
11/28/20 15:00	0	X		0	X		0											
11/28/20 16:00	0	X		0	X		0											
11/28/20 17:00	0	X		0	X		0											
11/28/20 18:00	0	X		0	X		0											
11/28/20 19:00	0	X		0	X		0											
11/28/20 20:00	0	X		0	X		0											
11/28/20 21:00	0	X		0	X		0											
11/28/20 22:00	0	X		0	X		0											
11/28/20 23:00	0	X		0	X		0											
11/29/20 0:00	0	X		0	X		0											
11/29/20 1:00	0	X		0	X		0											
11/29/20 2:00	0	X		0	X		0											
11/29/20 3:00	0	X		0	X		0											
11/29/20 4:00	0	X		0	X		0											
11/29/20 5:00	0	X		0	X		0											
11/29/20 6:00	0	X		0	X		0											
11/29/20 7:00	0	X		0	X		0											
11/29/20 8:00	0	X		0	X		0											
11/29/20 9:00	0	X		0	X		0											
11/29/20 10:00	0	X		0	X		0											
11/29/20 11:00	0	X		0	X		0											
11/29/20 12:00	0	X		0	X		0											
11/29/20 13:00	0	X		0	X		0											
11/29/20 14:00	0	X		0	X		0											
11/29/20 15:00	0	X		0	X		0											
11/29/20 16:00	0	X		0	X		0											
11/29/20 17:00	0	X		0	X		0											
11/29/20 18:00	0	X		0	X		0											
11/29/20 19:00	0	X		0	X		0											
11/29/20 20:00	0	X		0	X		0											
11/29/20 21:00	0	X		0	X		0											
11/29/20 22:00	0	X		0	X		0											
11/29/20 23:00	0	X		0	X		0											
11/30/20 0:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
11/30/20 1:00	0	X		0	X		0											
11/30/20 2:00	0	X		0	X		0											
11/30/20 3:00	0	X		0	X		0											
11/30/20 4:00	0	X		0	X		0											
11/30/20 5:00	0	X		0	X		0											
11/30/20 6:00	0	X		0	X		0											
11/30/20 7:00	0	X		0	X		0											
11/30/20 8:00	0	X		0	X		0											
11/30/20 9:00	0	X		0	X		0											
11/30/20 10:00	0	X		0	X		0											
11/30/20 11:00	0	X		0	X		0											
11/30/20 12:00	0	X		0	X		0											
11/30/20 13:00	0	X		0	X		0											
11/30/20 14:00	0	X		0	X		0											
11/30/20 15:00	0	X		0	X		0											
11/30/20 16:00	0	X		0	X		0											
11/30/20 17:00	0	X		0	X		0											
11/30/20 18:00	0	X		0	X		0											
11/30/20 19:00	0	X		0	X		0											
11/30/20 20:00	0	X		0	X		0											
11/30/20 21:00	0	X		0	X		0											
11/30/20 22:00	0	X		0	X		0											
11/30/20 23:00	0	X		0	X		0											
12/01/20 0:00	0	X		0	X		0											
12/01/20 1:00	0	X		0	X		0											
12/01/20 2:00	0	X		0	X		0											
12/01/20 3:00	0	X		0	X		0											
12/01/20 4:00	0	X		0	X		0											
12/01/20 5:00	0	X		0	X		0											
12/01/20 6:00	0	X		0	X		0											
12/01/20 7:00	0	X		0	X		0											
12/01/20 8:00	0	X		0	X		0											
12/01/20 9:00	0	X		0	X		0											
12/01/20 10:00	0	X		0	X		0											
12/01/20 11:00	0	X		0	X		0											
12/01/20 12:00	0	X		0	X		0											
12/01/20 13:00	0	X		0	X		0											
12/01/20 14:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/01/20 15:00	0	X		0	X		0											
12/01/20 16:00	0	X		0	X		0											
12/01/20 17:00	0	X		0	X		0											
12/01/20 18:00	0	X		0	X		0											
12/01/20 19:00	0	X		0	X		0											
12/01/20 20:00	0	X		0	X		0											
12/01/20 21:00	0	X		0	X		0											
12/01/20 22:00	0	X		0	X		0											
12/01/20 23:00	0	X		0	X		0											
12/02/20 0:00	0	X		0	X		0											
12/02/20 1:00	0	X		0	X		0											
12/02/20 2:00	0	X		0	X		0											
12/02/20 3:00	0	X		0	X		0											
12/02/20 4:00	0	X		0	X		0											
12/02/20 5:00	0	X		0	X		0											
12/02/20 6:00	0	X		0	X		0											
12/02/20 7:00	0	X		0	X		0											
12/02/20 8:00	0	X		0	X		0											
12/02/20 9:00	0	X		0	X		0											
12/02/20 10:00	0	X		0	X		0											
12/02/20 11:00	0	X		0	X		0											
12/02/20 12:00	0	X		0	X		0											
12/02/20 13:00	0	X		0	X		0											
12/02/20 14:00	0	X		0	X		0											
12/02/20 15:00	0	X		0	X		0											
12/02/20 16:00	0	X		0	X		0											
12/02/20 17:00	0	X		0	X		0											
12/02/20 18:00	0	X		0	X		0											
12/02/20 19:00	0	X		0	X		0											
12/02/20 20:00	0	X		0	X		0											
12/02/20 21:00	0	X		0	X		0											
12/02/20 22:00	0	X		0	X		0											
12/02/20 23:00	0	X		0	X		0											
12/03/20 0:00	0	X		0	X		0											
12/03/20 1:00	0	X		0	X		0											
12/03/20 2:00	0	X		0	X		0											
12/03/20 3:00	0	X		0	X		0											
12/03/20 4:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/03/20 5:00	0	X		0	X		0											
12/03/20 6:00	0	X		0	X		0											
12/03/20 7:00	0	X		0	X		0											
12/03/20 8:00	0	X		0	X		0											
12/03/20 9:00	0	X		0	X		0											
12/03/20 10:00	0	X		0	X		0											
12/03/20 11:00	0	X		0	X		0											
12/03/20 12:00	0	X		0	X		0											
12/03/20 13:00	0	X		0	X		0											
12/03/20 14:00	0	X		0	X		0											
12/03/20 15:00	0	X		0	X		0											
12/03/20 16:00	0	X		0	X		0											
12/03/20 17:00	0	X		0	X		0											
12/03/20 18:00	0	X		0	X		0											
12/03/20 19:00	0	X		0	X		0											
12/03/20 20:00	0	X		0	X		0											
12/03/20 21:00	0	X		0	X		0											
12/03/20 22:00	0	X		0	X		0											
12/03/20 23:00	0	X		0	X		0											
12/04/20 0:00	0	X		0	X		0											
12/04/20 1:00	0	X		0	X		0											
12/04/20 2:00	0	X		0	X		0											
12/04/20 3:00	0	X		0	X		0											
12/04/20 4:00	0	X		0	X		0											
12/04/20 5:00	0	X		0	X		0											
12/04/20 6:00	0	X		0	X		0											
12/04/20 7:00	0	X		0	X		0											
12/04/20 8:00	0	X		0	X		0											
12/04/20 9:00	0	X		0	X		0											
12/04/20 10:00	0	X		0	X		0											
12/04/20 11:00	0	X		0	X		0											
12/04/20 12:00	0	X		0	X		0											
12/04/20 13:00	0	X		0	X		0											
12/04/20 14:00	0	X		0	X		0											
12/04/20 15:00	0	X		0	X		0											
12/04/20 16:00	0	X		0	X		0											
12/04/20 17:00	0	X		0	X		0											
12/04/20 18:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/04/20 19:00	0	X		0	X		0											
12/04/20 20:00	0	X		0	X		0											
12/04/20 21:00	0	X		0	X		0											
12/04/20 22:00	0	X		0	X		0											
12/04/20 23:00	0	X		0	X		0											
12/05/20 0:00	0	X		0	X		0											
12/05/20 1:00	0	X		0	X		0											
12/05/20 2:00	0	X		0	X		0											
12/05/20 3:00	0	X		0	X		0											
12/05/20 4:00	0	X		0	X		0											
12/05/20 5:00	0	X		0	X		0											
12/05/20 6:00	0	X		0	X		0											
12/05/20 7:00	0	X		0	X		0											
12/05/20 8:00	0	X		0	X		0											
12/05/20 9:00	0	X		0	X		0											
12/05/20 10:00	0	X		0	X		0											
12/05/20 11:00	0	X		0	X		0											
12/05/20 12:00	0	X		0	X		0											
12/05/20 13:00	0	X		0	X		0											
12/05/20 14:00	0	X		0	X		0											
12/05/20 15:00	0	X		0	X		0											
12/05/20 16:00	0	X		0	X		0											
12/05/20 17:00	0	X		0	X		0											
12/05/20 18:00	0	X		0	X		0											
12/05/20 19:00	0	X		0	X		0											
12/05/20 20:00	0	X		0	X		0											
12/05/20 21:00	0	X		0	X		0											
12/05/20 22:00	0	X		0	X		0											
12/05/20 23:00	0	X		0	X		0											
12/06/20 0:00	0	X		0	X		0											
12/06/20 1:00	0	X		0	X		0											
12/06/20 2:00	0	X		0	X		0											
12/06/20 3:00	0	X		0	X		0											
12/06/20 4:00	0	X		0	X		0											
12/06/20 5:00	0	X		0	X		0											
12/06/20 6:00	0	X		0	X		0											
12/06/20 7:00	0	X		0	X		0											
12/06/20 8:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/06/20 9:00	0	X		0	X		0											
12/06/20 10:00	0	X		0	X		0											
12/06/20 11:00	0	X		0	X		0											
12/06/20 12:00	0	X		0	X		0											
12/06/20 13:00	0	X		0	X		0											
12/06/20 14:00	0	X		0	X		0											
12/06/20 15:00	0	X		0	X		0											
12/06/20 16:00	0	X		0	X		0											
12/06/20 17:00	0	X		0	X		0											
12/06/20 18:00	0	X		0	X		0											
12/06/20 19:00	0	X		0	X		0											
12/06/20 20:00	0	X		0	X		0											
12/06/20 21:00	0	X		0	X		0											
12/06/20 22:00	0	X		0	X		0											
12/06/20 23:00	0	X		0	X		0											
12/07/20 0:00	0	X		0	X		0											
12/07/20 1:00	0	X		0	X		0											
12/07/20 2:00	0	X		0	X		0											
12/07/20 3:00	0	X		0	X		0											
12/07/20 4:00	0	X		0	X		0											
12/07/20 5:00	0	X		0	X		0											
12/07/20 6:00	0	X		0	X		0											
12/07/20 7:00	0	X		0	X		0											
12/07/20 8:00	0	X		0	X		0											
12/07/20 9:00	0	X		0	X		0											
12/07/20 10:00	0	X		0	X		0											
12/07/20 11:00	0	X		0	X		0											
12/07/20 12:00	0	X		0	X		0											
12/07/20 13:00	0	X		0	X		0											
12/07/20 14:00	0	X		0	X		0											
12/07/20 15:00	0	X		0	X		0											
12/07/20 16:00	0	X		0	X		0											
12/07/20 17:00	0	X		0	X		0											
12/07/20 18:00	0	X		0	X		0											
12/07/20 19:00	0	X		0	X		0											
12/07/20 20:00	0	X		0	X		0											
12/07/20 21:00	0	X		0	X		0											
12/07/20 22:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
12/07/20 23:00	0	X		0	X		0											
12/08/20 0:00	0	X		0	X		0											
12/08/20 1:00	0	X		0	X		0											
12/08/20 2:00	0	X		0	X		0											
12/08/20 3:00	0	X		0	X		0											
12/08/20 4:00	0	X		0	X		0											
12/08/20 5:00	0	X		0	X		0											
12/08/20 6:00	0	X		0	X		0											
12/08/20 7:00	0	X		0	X		0											
12/08/20 8:00	0	X		0	X		0											
12/08/20 9:00	0	X		0	X		0											
12/08/20 10:00	0	X		0	X		0											
12/08/20 11:00	0	X		0	X		0											
12/08/20 12:00	0	X		0	X		0											
12/08/20 13:00	0	X		0	X		0											
12/08/20 14:00	0	X		0	X		0											
12/08/20 15:00	0	X		0	X		0											
12/08/20 16:00	0	X		0	X		0											
12/08/20 17:00	0	X		0	X		0											
12/08/20 18:00	0	X		0	X		0											
12/08/20 19:00	0	X		0	X		0											
12/08/20 20:00	0	X		0	X		0											
12/08/20 21:00	0	X		0	X		0											
12/08/20 22:00	0	X		0	X		0											
12/08/20 23:00	0	X		0	X		0											
12/09/20 0:00	0	X		0	X		0											
12/09/20 1:00	0	X		0	X		0											
12/09/20 2:00	0	X		0	X		0											
12/09/20 3:00	0	X		0	X		0											
12/09/20 4:00	0	X		0	X		0											
12/09/20 5:00	0	X		0	X		0											
12/09/20 6:00	0	X		0	X		0											
12/09/20 7:00	0	X		0	X		0											
12/09/20 8:00	0	X		0	X		0											
12/09/20 9:00	0	X		0	X		0											
12/09/20 10:00	0	X		0	X		0											
12/09/20 11:00	0	X		0	X		0											
12/09/20 12:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
12/09/20 13:00	0	X		0	X		0											
12/09/20 14:00	0	X		0	X		0											
12/09/20 15:00	0	X		0	X		0											
12/09/20 16:00	0	X		0	X		0											
12/09/20 17:00	0	X		0	X		0											
12/09/20 18:00	0	X		0	X		0											
12/09/20 19:00	0	X		0	X		0											
12/09/20 20:00	0	X		0	X		0											
12/09/20 21:00	0	X		0	X		0											
12/09/20 22:00	0	X		0	X		0											
12/09/20 23:00	0	X		0	X		0											
12/10/20 0:00	0	X		0	X		0											
12/10/20 1:00	0	X		0	X		0											
12/10/20 2:00	0	X		0	X		0											
12/10/20 3:00	0	X		0	X		0											
12/10/20 4:00	0	X		0	X		0											
12/10/20 5:00	0	X		0	X		0											
12/10/20 6:00	0	X		0	X		0											
12/10/20 7:00	0	X		0	X		0											
12/10/20 8:00	0	X		0	X		0											
12/10/20 9:00	0	X		0	X		0											
12/10/20 10:00	0	X		0	X		0											
12/10/20 11:00	0	X		0	X		0											
12/10/20 12:00	0	X		0	X		0											
12/10/20 13:00	0	X		0	X		0											
12/10/20 14:00	0	X		0	X		0											
12/10/20 15:00	0	X		0	X		0											
12/10/20 16:00	0	X		0	X		0											
12/10/20 17:00	0	X		0	X		0											
12/10/20 18:00	0	X		0	X		0											
12/10/20 19:00	0	X		0	X		0											
12/10/20 20:00	0	X		0	X		0											
12/10/20 21:00	0	X		0	X		0											
12/10/20 22:00	0	X		0	X		0											
12/10/20 23:00	0	X		0	X		0											
12/11/20 0:00	0	X		0	X		0											
12/11/20 1:00	0	X		0	X		0											
12/11/20 2:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/11/20 3:00	0	X		0	X		0											
12/11/20 4:00	0	X		0	X		0											
12/11/20 5:00	0	X		0	X		0											
12/11/20 6:00	0	X		0	X		0											
12/11/20 7:00	0	X		0	X		0											
12/11/20 8:00	0	X		0	X		0											
12/11/20 9:00	0	X		0	X		0											
12/11/20 10:00	0	X		0	X		0											
12/11/20 11:00	0	X		0	X		0											
12/11/20 12:00	0	X		0	X		0											
12/11/20 13:00	0	X		0	X		0											
12/11/20 14:00	0	X		0	X		0											
12/11/20 15:00	0	X		0	X		0											
12/11/20 16:00	0	X		0	X		0											
12/11/20 17:00	0	X		0	X		0											
12/11/20 18:00	0	X		0	X		0											
12/11/20 19:00	0	X		0	X		0											
12/11/20 20:00	0	X		0	X		0											
12/11/20 21:00	0	X		0	X		0											
12/11/20 22:00	0	X		0	X		0											
12/11/20 23:00	0	X		0	X		0											
12/12/20 0:00	0	X		0	X		0											
12/12/20 1:00	0	X		0	X		0											
12/12/20 2:00	0	X		0	X		0											
12/12/20 3:00	0	X		0	X		0											
12/12/20 4:00	0	X		0	X		0											
12/12/20 5:00	0	X		0	X		0											
12/12/20 6:00	0	X		0	X		0											
12/12/20 7:00	0	X		0	X		0											
12/12/20 8:00	0	X		0	X		0											
12/12/20 9:00	0	X		0	X		0											
12/12/20 10:00	0	X		0	X		0											
12/12/20 11:00	0	X		0	X		0											
12/12/20 12:00	0	X		0	X		0											
12/12/20 13:00	0	X		0	X		0											
12/12/20 14:00	0	X		0	X		0											
12/12/20 15:00	0	X		0	X		0											
12/12/20 16:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
12/12/20 17:00	0	X		0	X		0											
12/12/20 18:00	0	X		0	X		0											
12/12/20 19:00	0	X		0	X		0											
12/12/20 20:00	0	X		0	X		0											
12/12/20 21:00	0	X		0	X		0											
12/12/20 22:00	0	X		0	X		0											
12/12/20 23:00	0	X		0	X		0											
12/13/20 0:00	0	X		0	X		0											
12/13/20 1:00	0	X		0	X		0											
12/13/20 2:00	0	X		0	X		0											
12/13/20 3:00	0	X		0	X		0											
12/13/20 4:00	0	X		0	X		0											
12/13/20 5:00	0	X		0	X		0											
12/13/20 6:00	0	X		0	X		0											
12/13/20 7:00	0	X		0	X		0											
12/13/20 8:00	0	X		0	X		0											
12/13/20 9:00	0	X		0	X		0											
12/13/20 10:00	0	X		0	X		0											
12/13/20 11:00	0	X		0	X		0											
12/13/20 12:00	0	X		0	X		0											
12/13/20 13:00	0	X		0	X		0											
12/13/20 14:00	0	X		0	X		0											
12/13/20 15:00	0	X		0	X		0											
12/13/20 16:00	0	X		0	X		0											
12/13/20 17:00	0	X		0	X		0											
12/13/20 18:00	0	X		0	X		0											
12/13/20 19:00	0	X		0	X		0											
12/13/20 20:00	0	X		0	X		0											
12/13/20 21:00	0	X		0	X		0											
12/13/20 22:00	0	X		0	X		0											
12/13/20 23:00	0	X		0	X		0											
12/14/20 0:00	0	X		0	X		0											
12/14/20 1:00	0	X		0	X		0											
12/14/20 2:00	0	X		0	X		0											
12/14/20 3:00	0	X		0	X		0											
12/14/20 4:00	0	X		0	X		0											
12/14/20 5:00	0	X		0	X		0											
12/14/20 6:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/14/20 7:00	0	X		0	X		0											
12/14/20 8:00	0	X		0	X		0											
12/14/20 9:00	0	X		0	X		0											
12/14/20 10:00	0	X		0	X		0											
12/14/20 11:00	0	X		0	X		0											
12/14/20 12:00	0	X		0	X		0											
12/14/20 13:00	0	X		0	X		0											
12/14/20 14:00	0	X		0	X		0											
12/14/20 15:00	0	X		0	X		0											
12/14/20 16:00	0	X		0	X		0											
12/14/20 17:00	0	X		0	X		0											
12/14/20 18:00	0	X		0	X		0											
12/14/20 19:00	0	X		0	X		0											
12/14/20 20:00	0	X		0	X		0											
12/14/20 21:00	0	X		0	X		0											
12/14/20 22:00	0	X		0	X		0											
12/14/20 23:00	0	X		0	X		0											
12/15/20 0:00	0	X		0	X		0											
12/15/20 1:00	0	X		0	X		0											
12/15/20 2:00	0	X		0	X		0											
12/15/20 3:00	0	X		0	X		0											
12/15/20 4:00	0	X		0	X		0											
12/15/20 5:00	0	X		0	X		0											
12/15/20 6:00	0	X		0	X		0											
12/15/20 7:00	0	X		0	X		0											
12/15/20 8:00	0	X		0	X		0											
12/15/20 9:00	0	X		0	X		0											
12/15/20 10:00	0	X		0	X		0											
12/15/20 11:00	0	X		0	X		0											
12/15/20 12:00	0	X		0	X		0											
12/15/20 13:00	0	X		0	X		0											
12/15/20 14:00	0	X		0	X		0											
12/15/20 15:00	0	X		0	X		0											
12/15/20 16:00	0	X		0	X		0											
12/15/20 17:00	0	X		0	X		0											
12/15/20 18:00	0	X		0	X		0											
12/15/20 19:00	0	X		0	X		0											
12/15/20 20:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
12/15/20 21:00	0	X		0	X		0											
12/15/20 22:00	0	X		0	X		0											
12/15/20 23:00	0	X		0	X		0											
12/16/20 0:00	0	X		0	X		0											
12/16/20 1:00	0	X		0	X		0											
12/16/20 2:00	0	X		0	X		0											
12/16/20 3:00	0	X		0	X		0											
12/16/20 4:00	0	X		0	X		0											
12/16/20 5:00	0	X		0	X		0											
12/16/20 6:00	0	X		0	X		0											
12/16/20 7:00	0	X		0	X		0											
12/16/20 8:00	0	X		0	X		0											
12/16/20 9:00	0	X		0	X		0											
12/16/20 10:00	0	X		0	X		0											
12/16/20 11:00	0	X		0	X		0											
12/16/20 12:00	0	X		0	X		0											
12/16/20 13:00	0	X		0	X		0											
12/16/20 14:00	0	X		0	X		0											
12/16/20 15:00	0	X		0	X		0											
12/16/20 16:00	0	X		0	X		0											
12/16/20 17:00	0	X		0	X		0											
12/16/20 18:00	0	X		0	X		0											
12/16/20 19:00	0	X		0	X		0											
12/16/20 20:00	0	X		0	X		0											
12/16/20 21:00	0	X		0	X		0											
12/16/20 22:00	0	X		0	X		0											
12/16/20 23:00	0	X		0	X		0											
12/17/20 0:00	0	X		0	X		0											
12/17/20 1:00	0	X		0	X		0											
12/17/20 2:00	0	X		0	X		0											
12/17/20 3:00	0	X		0	X		0											
12/17/20 4:00	0	X		0	X		0											
12/17/20 5:00	0	X		0	X		0											
12/17/20 6:00	0	X		0	X		0											
12/17/20 7:00	0	X		0	X		0											
12/17/20 8:00	0	X		0	X		0											
12/17/20 9:00	0	X		0	X		0											
12/17/20 10:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/17/20 11:00	0	X		0	X		0											
12/17/20 12:00	0	X		0	X		0											
12/17/20 13:00	0	X		0	X		0											
12/17/20 14:00	0	X		0	X		0											
12/17/20 15:00	0	X		0	X		0											
12/17/20 16:00	0	X		0	X		0											
12/17/20 17:00	0	X		0	X		0											
12/17/20 18:00	0	X		0	X		0											
12/17/20 19:00	0	X		0	X		0											
12/17/20 20:00	0	X		0	X		0											
12/17/20 21:00	0	X		0	X		0											
12/17/20 22:00	0	X		0	X		0											
12/17/20 23:00	0	X		0	X		0											
12/18/20 0:00	0	X		0	X		0											
12/18/20 1:00	0	X		0	X		0											
12/18/20 2:00	0	X		0	X		0											
12/18/20 3:00	0	X		0	X		0											
12/18/20 4:00	0	X		0	X		0											
12/18/20 5:00	0	X		0	X		0											
12/18/20 6:00	0	X		0	X		0											
12/18/20 7:00	0	X		0	X		0											
12/18/20 8:00	0	X		0	X		0											
12/18/20 9:00	0	X		0	X		0											
12/18/20 10:00	0	X		0	X		0											
12/18/20 11:00	0	X		0	X		0											
12/18/20 12:00	0	X		0	X		0											
12/18/20 13:00	0	X		0	X		0											
12/18/20 14:00	0	X		0	X		0											
12/18/20 15:00	0	X		0	X		0											
12/18/20 16:00	0	X		0	X		0											
12/18/20 17:00	0	X		0	X		0											
12/18/20 18:00	0	X		0	X		0											
12/18/20 19:00	0	X		0	X		0											
12/18/20 20:00	0	X		0	X		0											
12/18/20 21:00	0	X		0	X		0											
12/18/20 22:00	0	X		0	X		0											
12/18/20 23:00	0	X		0	X		0											
12/19/20 0:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
12/19/20 1:00	0	X		0	X		0											
12/19/20 2:00	0	X		0	X		0											
12/19/20 3:00	0	X		0	X		0											
12/19/20 4:00	0	X		0	X		0											
12/19/20 5:00	0	X		0	X		0											
12/19/20 6:00	0	X		0	X		0											
12/19/20 7:00	0	X		0	X		0											
12/19/20 8:00	0	X		0	X		0											
12/19/20 9:00	0	X		0	X		0											
12/19/20 10:00	0	X		0	X		0											
12/19/20 11:00	0	X		0	X		0											
12/19/20 12:00	0	X		0	X		0											
12/19/20 13:00	0	X		0	X		0											
12/19/20 14:00	0	X		0	X		0											
12/19/20 15:00	0	X		0	X		0											
12/19/20 16:00	0	X		0	X		0											
12/19/20 17:00	0	X		0	X		0											
12/19/20 18:00	0	X		0	X		0											
12/19/20 19:00	0	X		0	X		0											
12/19/20 20:00	0	X		0	X		0											
12/19/20 21:00	0	X		0	X		0											
12/19/20 22:00	0	X		0	X		0											
12/19/20 23:00	0	X		0	X		0											
12/20/20 0:00	0	X		0	X		0											
12/20/20 1:00	0	X		0	X		0											
12/20/20 2:00	0	X		0	X		0											
12/20/20 3:00	0	X		0	X		0											
12/20/20 4:00	0	X		0	X		0											
12/20/20 5:00	0	X		0	X		0											
12/20/20 6:00	0	X		0	X		0											
12/20/20 7:00	0	X		0	X		0											
12/20/20 8:00	0	X		0	X		0											
12/20/20 9:00	0	X		0	X		0											
12/20/20 10:00	0	X		0	X		0											
12/20/20 11:00	0	X		0	X		0											
12/20/20 12:00	0	X		0	X		0											
12/20/20 13:00	0	X		0	X		0											
12/20/20 14:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/20/20 15:00	0	X		0	X		0											
12/20/20 16:00	0	X		0	X		0											
12/20/20 17:00	0	X		0	X		0											
12/20/20 18:00	0	X		0	X		0											
12/20/20 19:00	0	X		0	X		0											
12/20/20 20:00	0	X		0	X		0											
12/20/20 21:00	0	X		0	X		0											
12/20/20 22:00	0	X		0	X		0											
12/20/20 23:00	0	X		0	X		0											
12/21/20 0:00	0	X		0	X		0											
12/21/20 1:00	0	X		0	X		0											
12/21/20 2:00	0	X		0	X		0											
12/21/20 3:00	0	X		0	X		0											
12/21/20 4:00	0	X		0	X		0											
12/21/20 5:00	0	X		0	X		0											
12/21/20 6:00	0	X		0	X		0											
12/21/20 7:00	0	X		0	X		0											
12/21/20 8:00	0	X		0	X		0											
12/21/20 9:00	0	X		0	X		0											
12/21/20 10:00	0	X		0	X		0											
12/21/20 11:00	0	X		0	X		0											
12/21/20 12:00	0	X		0	X		0											
12/21/20 13:00	0	X		0	X		0											
12/21/20 14:00	0	X		0	X		0											
12/21/20 15:00	0	X		0	X		0											
12/21/20 16:00	0	X		0	X		0											
12/21/20 17:00	0	X		0	X		0											
12/21/20 18:00	0	X		0	X		0											
12/21/20 19:00	0	X		0	X		0											
12/21/20 20:00	0	X		0	X		0											
12/21/20 21:00	0	X		0	X		0											
12/21/20 22:00	0	X		0	X		0											
12/21/20 23:00	0	X		0	X		0											
12/22/20 0:00	0	X		0	X		0											
12/22/20 1:00	0	X		0	X		0											
12/22/20 2:00	0	X		0	X		0											
12/22/20 3:00	0	X		0	X		0											
12/22/20 4:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/22/20 5:00	0	X		0	X		0											
12/22/20 6:00	0	X		0	X		0											
12/22/20 7:00	0	X		0	X		0											
12/22/20 8:00	0	X		0	X		0											
12/22/20 9:00	0	X		0	X		0											
12/22/20 10:00	0	X		0	X		0											
12/22/20 11:00	0	X		0	X		0											
12/22/20 12:00	0	X		0	X		0											
12/22/20 13:00	0	X		0	X		0											
12/22/20 14:00	0	X		0	X		0											
12/22/20 15:00	0	X		0.0987			0.03											
12/22/20 16:00	0	X		0.25578			0.26											
12/22/20 17:00	0.1452			0.22776			0.31											
12/22/20 18:00	0.23808			0.15558			0.32											
12/22/20 19:00	0.26694			0	X		0.27											
12/22/20 20:00	0.11778			0	X		0.02											
12/22/20 21:00	0	X		0	X		0											
12/22/20 22:00	0	X		0	X		0											
12/22/20 23:00	0	X		0	X		0											
12/23/20 0:00	0	X		0	X		0											
12/23/20 1:00	0	X		0	X		0											
12/23/20 2:00	0	X		0	X		0											
12/23/20 3:00	0	X		0	X		0											
12/23/20 4:00	0	X		0	X		0											
12/23/20 5:00	0	X		0	X		0											
12/23/20 6:00	0	X		0	X		0											
12/23/20 7:00	0	X		0	X		0											
12/23/20 8:00	0	X		0	X		0											
12/23/20 9:00	0	X		0	X		0											
12/23/20 10:00	0	X		0	X		0											
12/23/20 11:00	0	X		0	X		0											
12/23/20 12:00	0	X		0	X		0											
12/23/20 13:00	0	X		0	X		0											
12/23/20 14:00	0	X		0	X		0											
12/23/20 15:00	0	X		0	X		0											
12/23/20 16:00	0	X		0	X		0											
12/23/20 17:00	0	X		0	X		0											
12/23/20 18:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/23/20 19:00	0	X		0	X		0											
12/23/20 20:00	0	X		0	X		0											
12/23/20 21:00	0	X		0	X		0											
12/23/20 22:00	0	X		0	X		0											
12/23/20 23:00	0	X		0	X		0											
12/24/20 0:00	0	X		0	X		0											
12/24/20 1:00	0	X		0	X		0											
12/24/20 2:00	0	X		0	X		0											
12/24/20 3:00	0	X		0	X		0											
12/24/20 4:00	0	X		0	X		0											
12/24/20 5:00	0	X		0	X		0											
12/24/20 6:00	0	X		0	X		0											
12/24/20 7:00	0	X		0	X		0											
12/24/20 8:00	0	X		0	X		0											
12/24/20 9:00	0	X		0	X		0											
12/24/20 10:00	0	X		0	X		0											
12/24/20 11:00	0	X		0	X		0											
12/24/20 12:00	0	X		0	X		0											
12/24/20 13:00	0	X		0	X		0											
12/24/20 14:00	0	X		0	X		0											
12/24/20 15:00	0	X		0	X		0											
12/24/20 16:00	0	X		0	X		0											
12/24/20 17:00	0	X		0	X		0											
12/24/20 18:00	0	X		0	X		0											
12/24/20 19:00	0	X		0	X		0											
12/24/20 20:00	0	X		0	X		0											
12/24/20 21:00	0	X		0	X		0											
12/24/20 22:00	0	X		0	X		0											
12/24/20 23:00	0	X		0	X		0											
12/25/20 0:00	0	X		0	X		0											
12/25/20 1:00	0	X		0	X		0											
12/25/20 2:00	0	X		0	X		0											
12/25/20 3:00	0	X		0	X		0											
12/25/20 4:00	0	X		0	X		0											
12/25/20 5:00	0	X		0	X		0											
12/25/20 6:00	0	X		0	X		0											
12/25/20 7:00	0	X		0	X		0											
12/25/20 8:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/25/20 9:00	0	X		0	X		0											
12/25/20 10:00	0	X		0	X		0											
12/25/20 11:00	0	X		0	X		0											
12/25/20 12:00	0	X		0	X		0											
12/25/20 13:00	0	X		0	X		0											
12/25/20 14:00	0	X		0	X		0											
12/25/20 15:00	0	X		0	X		0											
12/25/20 16:00	0	X		0	X		0											
12/25/20 17:00	0	X		0	X		0											
12/25/20 18:00	0	X		0	X		0											
12/25/20 19:00	0	X		0	X		0											
12/25/20 20:00	0	X		0	X		0											
12/25/20 21:00	0	X		0	X		0											
12/25/20 22:00	0	X		0	X		0											
12/25/20 23:00	0	X		0	X		0											
12/26/20 0:00	0	X		0	X		0											
12/26/20 1:00	0	X		0	X		0											
12/26/20 2:00	0	X		0	X		0											
12/26/20 3:00	0	X		0	X		0											
12/26/20 4:00	0	X		0	X		0											
12/26/20 5:00	0	X		0	X		0											
12/26/20 6:00	0	X		0	X		0											
12/26/20 7:00	0	X		0	X		0											
12/26/20 8:00	0	X		0	X		0											
12/26/20 9:00	0	X		0	X		0											
12/26/20 10:00	0	X		0	X		0											
12/26/20 11:00	0	X		0	X		0											
12/26/20 12:00	0	X		0	X		0											
12/26/20 13:00	0	X		0	X		0											
12/26/20 14:00	0	X		0	X		0											
12/26/20 15:00	0	X		0	X		0											
12/26/20 16:00	0	X		0	X		0											
12/26/20 17:00	0	X		0	X		0											
12/26/20 18:00	0	X		0	X		0											
12/26/20 19:00	0	X		0	X		0											
12/26/20 20:00	0	X		0	X		0											
12/26/20 21:00	0	X		0	X		0											
12/26/20 22:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/26/20 23:00	0	X		0	X		0											
12/27/20 0:00	0	X		0	X		0											
12/27/20 1:00	0	X		0	X		0											
12/27/20 2:00	0	X		0	X		0											
12/27/20 3:00	0	X		0	X		0											
12/27/20 4:00	0	X		0	X		0											
12/27/20 5:00	0	X		0	X		0											
12/27/20 6:00	0	X		0	X		0											
12/27/20 7:00	0	X		0	X		0											
12/27/20 8:00	0	X		0	X		0											
12/27/20 9:00	0	X		0	X		0											
12/27/20 10:00	0	X		0	X		0											
12/27/20 11:00	0	X		0	X		0											
12/27/20 12:00	0	X		0	X		0											
12/27/20 13:00	0	X		0	X		0											
12/27/20 14:00	0	X		0	X		0											
12/27/20 15:00	0	X		0	X		0											
12/27/20 16:00	0	X		0	X		0											
12/27/20 17:00	0	X		0	X		0											
12/27/20 18:00	0	X		0	X		0											
12/27/20 19:00	0	X		0	X		0											
12/27/20 20:00	0	X		0	X		0											
12/27/20 21:00	0	X		0	X		0											
12/27/20 22:00	0	X		0	X		0											
12/27/20 23:00	0	X		0	X		0											
12/28/20 0:00	0	X		0	X		0											
12/28/20 1:00	0	X		0	X		0											
12/28/20 2:00	0	X		0	X		0											
12/28/20 3:00	0	X		0	X		0											
12/28/20 4:00	0	X		0	X		0											
12/28/20 5:00	0	X		0	X		0											
12/28/20 6:00	0	X		0	X		0											
12/28/20 7:00	0	X		0	X		0											
12/28/20 8:00	0	X		0	X		0											
12/28/20 9:00	0	X		0	X		0											
12/28/20 10:00	0	X		0	X		0											
12/28/20 11:00	0	X		0	X		0											
12/28/20 12:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/28/20 13:00	0	X		0	X		0											
12/28/20 14:00	0	X		0	X		0											
12/28/20 15:00	0	X		0	X		0											
12/28/20 16:00	0	X		0	X		0											
12/28/20 17:00	0	X		0	X		0											
12/28/20 18:00	0	X		0	X		0											
12/28/20 19:00	0	X		0	X		0											
12/28/20 20:00	0	X		0	X		0											
12/28/20 21:00	0	X		0	X		0											
12/28/20 22:00	0	X		0	X		0											
12/28/20 23:00	0	X		0	X		0											
12/29/20 0:00	0	X		0	X		0											
12/29/20 1:00	0	X		0	X		0											
12/29/20 2:00	0	X		0	X		0											
12/29/20 3:00	0	X		0	X		0											
12/29/20 4:00	0	X		0	X		0											
12/29/20 5:00	0	X		0	X		0											
12/29/20 6:00	0	X		0	X		0											
12/29/20 7:00	0	X		0	X		0											
12/29/20 8:00	0	X		0	X		0											
12/29/20 9:00	0	X		0	X		0											
12/29/20 10:00	0	X		0	X		0											
12/29/20 11:00	0	X		0	X		0											
12/29/20 12:00	0	X		0	X		0											
12/29/20 13:00	0	X		0	X		0											
12/29/20 14:00	0	X		0	X		0											
12/29/20 15:00	0	X		0	X		0											
12/29/20 16:00	0	X		0	X		0											
12/29/20 17:00	0	X		0	X		0											
12/29/20 18:00	0	X		0	X		0											
12/29/20 19:00	0	X		0	X		0											
12/29/20 20:00	0	X		0	X		0											
12/29/20 21:00	0	X		0	X		0											
12/29/20 22:00	0	X		0	X		0											
12/29/20 23:00	0	X		0	X		0											
12/30/20 0:00	0	X		0	X		0											
12/30/20 1:00	0	X		0	X		0											
12/30/20 2:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/30/20 3:00	0	X		0	X		0											
12/30/20 4:00	0	X		0	X		0											
12/30/20 5:00	0	X		0	X		0											
12/30/20 6:00	0	X		0	X		0											
12/30/20 7:00	0	X		0	X		0											
12/30/20 8:00	0	X		0	X		0											
12/30/20 9:00	0	X		0	X		0											
12/30/20 10:00	0	X		0	X		0											
12/30/20 11:00	0	X		0	X		0											
12/30/20 12:00	0	X		0	X		0											
12/30/20 13:00	0	X		0	X		0											
12/30/20 14:00	0	X		0	X		0											
12/30/20 15:00	0	X		0	X		0											
12/30/20 16:00	0	X		0	X		0											
12/30/20 17:00	0	X		0	X		0											
12/30/20 18:00	0	X		0	X		0											
12/30/20 19:00	0	X		0	X		0											
12/30/20 20:00	0	X		0	X		0											
12/30/20 21:00	0	X		0	X		0											
12/30/20 22:00	0	X		0	X		0											
12/30/20 23:00	0	X		0	X		0											
12/31/20 0:00	0	X		0	X		0											
12/31/20 1:00	0	X		0	X		0											
12/31/20 2:00	0	X		0	X		0											
12/31/20 3:00	0	X		0	X		0											
12/31/20 4:00	0	X		0	X		0											
12/31/20 5:00	0	X		0	X		0											
12/31/20 6:00	0	X		0	X		0											
12/31/20 7:00	0	X		0	X		0											
12/31/20 8:00	0	X		0	X		0											
12/31/20 9:00	0	X		0	X		0											
12/31/20 10:00	0	X		0	X		0											
12/31/20 11:00	0	X		0	X		0											
12/31/20 12:00	0	X		0	X		0											
12/31/20 13:00	0	X		0	X		0											
12/31/20 14:00	0	X		0	X		0											
12/31/20 15:00	0	X		0	X		0											
12/31/20 16:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/31/20 17:00	0	X		0	X		0											
12/31/20 18:00	0	X		0	X		0											
12/31/20 19:00	0	X		0	X		0											
12/31/20 20:00	0	X		0	X		0											
12/31/20 21:00	0	X		0	X		0											
12/31/20 22:00	0	X		0	X		0											
12/31/20 23:00	0	X		0	X		0											

Tons 12 Month Rolling Summary

CT1 and CT2 Combined



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:17 Location: Roseville, CA

* = Excess Emission

Date	Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2	
	CO, Ton		NOx, Ton		PM10, Ton		SO2, Ton		VOC, Ton	
	1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)	
	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum
Oct 2020	0.4702	2.7037	1.4695	8.2453	0.2805	1.5473	0.1402	0.7736	0.4673	2.5777
Nov 2020	0.3189	2.4722	0.7256	7.9558	0.1387	1.5036	0.0696	0.7521	0.2316	2.5050
Dec 2020	0.0524	2.4405	0.0197	7.7366	0.0012	1.4593	0.0006	0.7300	0.0020	2.4312
Sum/Avg	2.4405		7.7366		1.4593		0.7300		2.4312	
Limit Value										

AQ-34

AQ-34 the Project owner shall maintain the following records: occurrence, duration, and type of any startup, shutdown, or malfunction: performance testing, evaluations, calibrations, check, adjustments, any period during which a continuous monitoring system or monitoring device was inoperative, maintenance of any continuous emission monitor; emission measurements, total daily and rolling twelve month averages hours of operation, hourly quantity of fuel used and gross three hour average operating load.

Verification; The Project owner shall submit to the CPM all data identified in this condition as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:29

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/01/20 04:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/01/20 04:24	200.0	180.5	180.8	R-A /Span * 100		0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/01/20 04:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/01/20 04:19	10.0	9.3	9.4	R-A /Span * 100		1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/01/20 04:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/01/20 04:25	200.0	180.0	181.5	R-A /Span * 100		0.8
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/01/20 04:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/01/20 04:19	10.0	9.3	9.4	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/01/20 05:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/01/20 05:25	200.0	181.3	180.8	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/01/20 05:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	10/01/20 05:20	10.0	9.2	9.1	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/01/20 05:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/01/20 05:25	200.0	180.0	179.8	R-A /Span * 100		0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/01/20 05:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/01/20 05:20	10.0	9.3	9.3	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/01/20 05:14	21.0	18.0	18.0	R-A		0.0
	Zero	10/01/20 05:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/01/20 05:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	10/01/20 05:25	200.0	181.3	181.7	R-A /Span * 100		0.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/01/20 05:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	10/01/20 05:20	10.0	8.9	9.0	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/01/20 05:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/01/20 05:25	200.0	180.0	179.7	R-A /Span * 100		0.2

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:29

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/01/20 05:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/01/20 05:20	10.0	9.3	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/01/20 05:14	21.0	18.1	R-A		0.0
	Zero	10/01/20 05:20	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/02/20 04:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/02/20 04:24	200.0	180.5	R-A /Span * 100		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/02/20 04:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/02/20 04:19	10.0	9.3	R-A /Span * 100		1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/02/20 04:15	200.0	0.0	R-A /Span * 100		0.0
	High	10/02/20 04:25	200.0	180.0	R-A /Span * 100		0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/02/20 04:15	10.0	0.0	R-A /Span * 100		0.0
	High	10/02/20 04:19	10.0	9.3	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/02/20 05:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/02/20 05:25	200.0	181.3	R-A /Span * 100		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/02/20 05:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/02/20 05:20	10.0	9.2	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/02/20 05:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/02/20 05:25	200.0	180.0	R-A /Span * 100		0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/02/20 05:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/02/20 05:20	10.0	9.3	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/02/20 05:14	21.0	18.0	R-A		0.0
	Zero	10/02/20 05:20	21.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/02/20 05:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/02/20 05:25	200.0	181.3	R-A /Span * 100		0.4

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:29

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/02/20 05:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/02/20 05:20	10.0	8.9	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/02/20 05:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/02/20 05:25	200.0	180.0	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/02/20 05:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/02/20 05:20	10.0	9.3	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/02/20 05:14	21.0	18.1	R-A		0.0
	Zero	10/02/20 05:20	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/03/20 04:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/03/20 04:25	200.0	180.5	R-A /Span * 100		0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/03/20 04:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/03/20 04:19	10.0	9.3	R-A /Span * 100		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/03/20 04:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/03/20 04:25	200.0	180.5	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/03/20 04:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/03/20 04:20	10.0	9.3	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/03/20 05:14	200.0	0.0	R-A /Span * 100		0.1
	High	10/03/20 05:24	200.0	181.3	R-A /Span * 100		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/03/20 05:14	10.0	0.0	R-A /Span * 100		1.0
	High	10/03/20 05:20	10.0	9.2	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/03/20 05:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/03/20 05:24	200.0	180.0	R-A /Span * 100		0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/03/20 05:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/03/20 05:20	10.0	9.3	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:29

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/03/20 05:14	21.0	18.0	R-A		0.0
	Zero	10/03/20 05:20	21.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/03/20 05:14	200.0	0.1	R-A /Span * 100		0.1
	High	10/03/20 05:24	200.0	181.3	R-A /Span * 100		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/03/20 05:14	10.0	0.1	R-A /Span * 100		1.0
	High	10/03/20 05:19	10.0	9.0	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/03/20 05:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/03/20 05:24	200.0	179.7	R-A /Span * 100		0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/03/20 05:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/03/20 05:19	10.0	9.3	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/03/20 05:14	21.0	18.1	R-A		0.0
	Zero	10/03/20 05:19	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/04/20 04:15	200.0	0.0	R-A /Span * 100		0.0
	High	10/04/20 04:25	200.0	180.9	R-A /Span * 100		0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/04/20 04:15	10.0	0.0	R-A /Span * 100		0.0
	High	10/04/20 04:20	10.0	9.4	R-A /Span * 100		1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/04/20 04:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/04/20 04:25	200.0	180.4	R-A /Span * 100		0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/04/20 04:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/04/20 04:19	10.0	9.4	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/04/20 05:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/04/20 05:25	200.0	181.3	R-A /Span * 100		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/04/20 05:14	10.0	0.1	R-A /Span * 100		1.0
	High	10/04/20 05:20	10.0	9.1	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:29

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/04/20 05:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/04/20 05:25	200.0	180.0		R-A /Span * 100	0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/04/20 05:14	10.0	0.0		R-A /Span * 100	0.0
	High	10/04/20 05:20	10.0	9.3		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/04/20 05:14	21.0	18.0		R-A	0.0
	Zero	10/04/20 05:20	21.0	0.0		R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/04/20 05:15	200.0	0.0		R-A /Span * 100	0.0
	High	10/04/20 05:25	200.0	181.3		R-A /Span * 100	0.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/04/20 05:15	10.0	0.0		R-A /Span * 100	0.0
	High	10/04/20 05:19	10.0	8.9		R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/04/20 05:15	200.0	0.0		R-A /Span * 100	0.0
	High	10/04/20 05:25	200.0	180.0		R-A /Span * 100	0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/04/20 05:15	10.0	0.0		R-A /Span * 100	0.0
	High	10/04/20 05:19	10.0	9.3		R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/04/20 05:15	21.0	18.1		R-A	0.0
	Zero	10/04/20 05:19	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/05/20 04:15	200.0	0.0		R-A /Span * 100	0.0
	High	10/05/20 04:25	200.0	180.5		R-A /Span * 100	0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/05/20 04:15	10.0	0.0		R-A /Span * 100	0.0
	High	10/05/20 04:20	10.0	9.3		R-A /Span * 100	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/05/20 04:14	200.0	0.0		R-A /Span * 100	0.1
	High	10/05/20 04:24	200.0	180.0		R-A /Span * 100	0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/05/20 04:14	10.0	0.0		R-A /Span * 100	0.0
	High	10/05/20 04:19	10.0	9.3		R-A /Span * 100	1.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:29

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/05/20 05:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/05/20 05:24	200.0	181.3	180.8	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/05/20 05:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	10/05/20 05:19	10.0	9.2	9.1	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/05/20 05:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/05/20 05:24	200.0	180.0	179.1	R-A /Span * 100		0.5
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/05/20 05:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/05/20 05:19	10.0	9.3	9.3	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/05/20 05:14	21.0	18.0	18.0	R-A		0.0
	Zero	10/05/20 05:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/05/20 05:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/05/20 05:24	200.0	181.3	180.6	R-A /Span * 100		0.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/05/20 05:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	10/05/20 05:20	10.0	8.9	9.0	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/05/20 05:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/05/20 05:24	200.0	180.0	180.0	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/05/20 05:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/05/20 05:20	10.0	9.3	9.3	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/05/20 05:14	21.0	18.1	18.1	R-A		0.0
	Zero	10/05/20 05:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/06/20 04:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/06/20 04:25	200.0	180.5	181.1	R-A /Span * 100		0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/06/20 04:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/06/20 04:20	10.0	9.3	9.4	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:29

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/06/20 04:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	10/06/20 04:25	200.0	180.0	183.2	R-A /Span * 100		1.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/06/20 04:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	10/06/20 04:20	10.0	9.3	9.4	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/06/20 05:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/06/20 05:25	200.0	181.3	181.1	R-A /Span * 100		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/06/20 05:15	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	10/06/20 05:20	10.0	9.2	9.2	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/06/20 05:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/06/20 05:25	200.0	180.0	179.1	R-A /Span * 100		0.5
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/06/20 05:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/06/20 05:20	10.0	9.3	9.3	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/06/20 05:15	21.0	18.0	18.0	R-A		0.0
	Zero	10/06/20 05:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/06/20 05:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/06/20 05:25	200.0	181.3	181.5	R-A /Span * 100		0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/06/20 05:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/06/20 05:20	10.0	8.9	8.9	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/06/20 05:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/06/20 05:25	200.0	180.0	184.1	R-A /Span * 100		2.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/06/20 05:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/06/20 05:20	10.0	9.3	9.5	R-A /Span * 100		2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/06/20 05:15	21.0	18.1	18.2	R-A		0.1
	Zero	10/06/20 05:20	21.0	0.0	0.0	R-A		0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:29

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/07/20 04:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/07/20 04:25	200.0	180.5	181.0	R-A /Span * 100		0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/07/20 04:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/07/20 04:20	10.0	9.3	9.4	R-A /Span * 100		1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/07/20 04:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	10/07/20 04:24	200.0	180.0	182.9	R-A /Span * 100		1.5
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/07/20 04:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	10/07/20 04:20	10.0	9.3	9.4	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/07/20 05:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/07/20 05:24	200.0	181.3	181.5	R-A /Span * 100		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/07/20 05:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/07/20 05:19	10.0	9.2	9.2	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/07/20 05:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/07/20 05:24	200.0	180.0	185.9	>1x Alert	R-A /Span * 100	3.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/07/20 05:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/07/20 05:19	10.0	9.3	9.6	>1x Alert	R-A /Span * 100	3.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/07/20 05:14	21.0	18.0	18.2	R-A		0.2
	Zero	10/07/20 05:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/07/20 05:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/07/20 05:25	200.0	181.3	181.8	R-A /Span * 100		0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/07/20 05:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	10/07/20 05:19	10.0	8.9	9.0	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/07/20 05:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/07/20 05:25	200.0	180.0	184.2	R-A /Span * 100		2.1

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:29

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/07/20 05:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/07/20 05:19	10.0	9.3	R-A /Span * 100		2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/07/20 05:14	21.0	18.1	R-A		0.1
	Zero	10/07/20 05:19	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/08/20 04:15	200.0	0.0	R-A /Span * 100		0.0
	High	10/08/20 04:25	200.0	180.5	R-A /Span * 100		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/08/20 04:15	10.0	0.0	R-A /Span * 100		0.0
	High	10/08/20 04:20	10.0	9.3	R-A /Span * 100		1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/08/20 04:15	200.0	0.0	R-A /Span * 100		0.1
	High	10/08/20 04:25	200.0	180.0	R-A /Span * 100		1.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/08/20 04:15	10.0	0.0	R-A /Span * 100		1.0
	High	10/08/20 04:20	10.0	9.3	R-A /Span * 100		1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/08/20 05:15	200.0	0.0	R-A /Span * 100		0.0
	High	10/08/20 05:24	200.0	181.3	R-A /Span * 100		0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/08/20 05:15	10.0	0.0	R-A /Span * 100		0.0
	High	10/08/20 05:19	10.0	8.9	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/08/20 05:15	200.0	0.0	R-A /Span * 100		0.0
	High	10/08/20 05:24	200.0	180.0	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/08/20 05:15	10.0	0.0	R-A /Span * 100		0.0
	High	10/08/20 05:19	10.0	9.3	R-A /Span * 100		2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/08/20 05:15	21.0	18.1	R-A		0.1
	Zero	10/08/20 05:19	21.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/09/20 04:15	200.0	0.0	R-A /Span * 100		0.1
	High	10/09/20 04:25	200.0	180.0	R-A /Span * 100		2.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:29

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/09/20 04:15	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	10/09/20 04:20	10.0	9.3	9.5	R-A /Span * 100		2.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/09/20 05:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/09/20 05:25	200.0	181.3	182.8	R-A /Span * 100		0.8
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/09/20 05:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	10/09/20 05:19	10.0	8.9	9.0	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/09/20 05:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/09/20 05:25	200.0	180.0	183.7	R-A /Span * 100		1.9
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/09/20 05:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/09/20 05:19	10.0	9.3	9.5	R-A /Span * 100		2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/09/20 05:14	21.0	18.1	18.2	R-A		0.1
	Zero	10/09/20 05:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/10/20 04:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	10/10/20 04:25	200.0	180.0	183.8	R-A /Span * 100		1.9
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/10/20 04:15	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	10/10/20 04:20	10.0	9.3	9.5	R-A /Span * 100		2.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/10/20 05:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/10/20 05:25	200.0	181.3	182.4	R-A /Span * 100		0.6
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/10/20 05:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/10/20 05:19	10.0	8.9	8.9	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/10/20 05:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/10/20 05:25	200.0	180.0	183.7	R-A /Span * 100		1.9
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/10/20 05:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/10/20 05:19	10.0	9.3	9.5	R-A /Span * 100		2.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:29

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/10/20 05:15	21.0	18.1	18.2	R-A	0.1
	Zero	10/10/20 05:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/10/20 18:49	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/10/20 18:59	200.0	181.3	181.3	R-A /Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/10/20 18:49	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/10/20 18:54	10.0	9.2	9.2	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/10/20 18:49	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/10/20 18:59	200.0	180.0	186.2	>1x Alert R-A /Span * 100	3.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/10/20 18:49	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/10/20 18:54	10.0	9.3	9.5	R-A /Span * 100	2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/10/20 18:49	21.0	18.0	18.2	R-A	0.2
	Zero	10/10/20 18:54	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/11/20 04:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/11/20 04:25	200.0	180.5	178.2	R-A /Span * 100	1.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/11/20 04:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/11/20 04:20	10.0	9.3	9.3	R-A /Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/11/20 05:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/11/20 05:25	200.0	181.3	181.1	R-A /Span * 100	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/11/20 05:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	10/11/20 05:20	10.0	9.2	9.2	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/11/20 05:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/11/20 05:25	200.0	180.0	186.7	>1x Alert R-A /Span * 100	3.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/11/20 05:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/11/20 05:20	10.0	9.3	9.5	R-A /Span * 100	2.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:29

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/11/20 05:14	21.0	18.0	18.2	R-A	0.2
	Zero	10/11/20 05:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/12/20 04:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/12/20 04:25	200.0	180.5	179.7	R-A /Span * 100	0.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/12/20 04:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/12/20 04:20	10.0	9.3	9.3	R-A /Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/12/20 05:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/12/20 05:25	200.0	181.3	181.1	R-A /Span * 100	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/12/20 05:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/12/20 05:20	10.0	9.2	9.2	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/12/20 05:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/12/20 05:25	200.0	180.0	186.0	>1x Alert R-A /Span * 100	3.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/12/20 05:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/12/20 05:20	10.0	9.3	9.5	R-A /Span * 100	2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/12/20 05:15	21.0	18.0	18.2	R-A	0.2
	Zero	10/12/20 05:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/13/20 04:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/13/20 04:24	200.0	180.5	179.6	R-A /Span * 100	0.5
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/13/20 04:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/13/20 04:19	10.0	9.3	9.3	R-A /Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/13/20 05:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/13/20 05:25	200.0	181.3	180.8	R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/13/20 05:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/13/20 05:20	10.0	9.2	9.2	R-A /Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:29

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/13/20 05:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/13/20 05:25	200.0	180.0	185.9 >1x Alert	R-A /Span * 100	3.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/13/20 05:14	10.0	0.0		R-A /Span * 100	0.0
	High	10/13/20 05:20	10.0	9.3	9.5	R-A /Span * 100	2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/13/20 05:14	21.0	18.0	18.2	R-A	0.2
	Zero	10/13/20 05:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/13/20 09:12	200.0	0.0		R-A /Span * 100	0.0
	High	10/13/20 09:22	200.0	181.3	181.4	R-A /Span * 100	0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/13/20 09:12	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/13/20 09:17	10.0	8.9	9.0	R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/13/20 09:12	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/13/20 09:22	200.0	180.0	184.9	R-A /Span * 100	2.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/13/20 09:12	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/13/20 09:17	10.0	9.3	9.5	R-A /Span * 100	2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/13/20 09:12	21.0	18.1	18.2	R-A	0.1
	Zero	10/13/20 09:17	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/14/20 04:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/14/20 04:25	200.0	180.5	178.9	R-A /Span * 100	0.8
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/14/20 04:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/14/20 04:19	10.0	9.3	9.2	R-A /Span * 100	1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/14/20 04:15	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	10/14/20 04:25	200.0	180.0	184.2	R-A /Span * 100	2.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/14/20 04:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/14/20 04:19	10.0	9.3	9.5	R-A /Span * 100	2.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:29

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/14/20 05:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/14/20 05:25	200.0	181.3	180.8	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/14/20 05:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/14/20 05:20	10.0	9.2	9.2	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/14/20 05:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/14/20 05:25	200.0	180.0	180.2	R-A /Span * 100		0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/14/20 05:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/14/20 05:20	10.0	9.3	9.3	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/14/20 05:14	21.0	18.0	18.2	R-A		0.2
	Zero	10/14/20 05:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/14/20 05:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/14/20 05:24	200.0	181.3	181.9	R-A /Span * 100		0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/14/20 05:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	10/14/20 05:20	10.0	8.9	9.0	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/14/20 05:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/14/20 05:24	200.0	180.0	184.2	R-A /Span * 100		2.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/14/20 05:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/14/20 05:20	10.0	9.3	9.5	R-A /Span * 100		2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/14/20 05:14	21.0	18.1	18.2	R-A		0.1
	Zero	10/14/20 05:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/15/20 04:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/15/20 04:25	200.0	180.5	181.4	R-A /Span * 100		0.5
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/15/20 04:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/15/20 04:20	10.0	9.3	9.4	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:29

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/15/20 04:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	10/15/20 04:24	200.0	180.0	185.4	R-A /Span * 100	2.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/15/20 04:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	10/15/20 04:19	10.0	9.3	9.5	R-A /Span * 100	2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/15/20 05:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/15/20 05:25	200.0	181.3	181.1	R-A /Span * 100	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/15/20 05:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/15/20 05:20	10.0	9.2	9.2	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/15/20 05:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/15/20 05:25	200.0	180.0	179.9	R-A /Span * 100	0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/15/20 05:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/15/20 05:20	10.0	9.3	9.3	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/15/20 05:14	21.0	18.0	18.2	R-A	0.2
	Zero	10/15/20 05:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/15/20 05:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/15/20 05:25	200.0	181.3	181.9	R-A /Span * 100	0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/15/20 05:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	10/15/20 05:19	10.0	8.9	8.9	R-A /Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/15/20 05:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/15/20 05:25	200.0	180.0	184.6	R-A /Span * 100	2.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/15/20 05:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/15/20 05:19	10.0	9.3	9.5	R-A /Span * 100	2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/15/20 05:14	21.0	18.1	18.2	R-A	0.1
	Zero	10/15/20 05:19	21.0	0.0	0.0	R-A	0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:29

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/15/20 16:23	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/15/20 16:34	200.0	181.3	181.1	R-A /Span * 100		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/15/20 16:23	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/15/20 16:29	10.0	9.2	9.2	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/15/20 16:23	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/15/20 16:34	200.0	180.0	179.0	R-A /Span * 100		0.5
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/15/20 16:23	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/15/20 16:29	10.0	9.3	9.2	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/15/20 16:23	21.0	18.0	18.2	R-A		0.2
	Zero	10/15/20 16:29	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/16/20 04:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	10/16/20 04:24	200.0	180.0	183.9	R-A /Span * 100		2.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/16/20 04:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	10/16/20 04:20	10.0	9.3	9.5	R-A /Span * 100		2.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/16/20 04:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/16/20 04:25	200.0	180.5	180.7	R-A /Span * 100		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/16/20 04:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/16/20 04:20	10.0	9.3	9.3	R-A /Span * 100		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/16/20 05:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/16/20 05:24	200.0	181.3	181.5	R-A /Span * 100		0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/16/20 05:15	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	10/16/20 05:19	10.0	8.9	9.1	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/16/20 05:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/16/20 05:24	200.0	180.0	184.7	R-A /Span * 100		2.4

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:29 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/16/20 05:15	10.0	0.0	R-A /Span * 100		0.0
	High	10/16/20 05:19	10.0	9.3	R-A /Span * 100		2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/16/20 05:15	21.0	18.1	R-A		0.1
	Zero	10/16/20 05:19	21.0	0.0	R-A		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/16/20 05:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/16/20 05:25	200.0	181.3	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/16/20 05:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/16/20 05:19	10.0	9.2	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/16/20 05:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/16/20 05:25	200.0	180.0	R-A /Span * 100		0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/16/20 05:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/16/20 05:19	10.0	9.3	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/16/20 05:14	21.0	18.0	R-A		0.2
	Zero	10/16/20 05:19	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/17/20 04:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/17/20 04:25	200.0	180.5	R-A /Span * 100		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/17/20 04:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/17/20 04:20	10.0	9.3	R-A /Span * 100		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/17/20 04:15	200.0	0.0	R-A /Span * 100		0.1
	High	10/17/20 04:25	200.0	180.0	R-A /Span * 100		2.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/17/20 04:15	10.0	0.0	R-A /Span * 100		1.0
	High	10/17/20 04:20	10.0	9.3	R-A /Span * 100		2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/17/20 05:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/17/20 05:24	200.0	181.3	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:29

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/17/20 05:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/17/20 05:20	10.0	9.2	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/17/20 05:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/17/20 05:24	200.0	180.0	R-A /Span * 100		0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/17/20 05:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/17/20 05:20	10.0	9.3	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/17/20 05:14	21.0	18.0	R-A		0.2
	Zero	10/17/20 05:20	21.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/17/20 05:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/17/20 05:24	200.0	181.3	R-A /Span * 100		0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/17/20 05:14	10.0	0.0	R-A /Span * 100		1.0
	High	10/17/20 05:19	10.0	8.9	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/17/20 05:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/17/20 05:24	200.0	180.0	R-A /Span * 100		2.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/17/20 05:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/17/20 05:19	10.0	9.3	R-A /Span * 100		2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/17/20 05:14	21.0	18.1	R-A		0.1
	Zero	10/17/20 05:19	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/18/20 04:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/18/20 04:24	200.0	180.5	R-A /Span * 100		0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/18/20 04:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/18/20 04:19	10.0	9.0	R-A /Span * 100		1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/18/20 04:14	200.0	0.0	R-A /Span * 100		0.1
	High	10/18/20 04:24	200.0	180.0	R-A /Span * 100		1.9

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:29

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/18/20 04:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	10/18/20 04:19	10.0	9.3	9.5	R-A /Span * 100	2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/18/20 05:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/18/20 05:24	200.0	181.3	181.4	R-A /Span * 100	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/18/20 05:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/18/20 05:19	10.0	9.1	9.0	R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/18/20 05:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/18/20 05:24	200.0	180.0	180.1	R-A /Span * 100	0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/18/20 05:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/18/20 05:19	10.0	9.0	9.3	R-A /Span * 100	3.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/18/20 05:14	21.0	18.0	18.2	R-A	0.2
	Zero	10/18/20 05:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/18/20 05:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	10/18/20 05:25	200.0	181.3	182.4	R-A /Span * 100	0.6
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/18/20 05:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	10/18/20 05:19	10.0	8.9	9.1	R-A /Span * 100	2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/18/20 05:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/18/20 05:25	200.0	180.0	184.3	R-A /Span * 100	2.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/18/20 05:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/18/20 05:19	10.0	9.3	9.5	R-A /Span * 100	2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/18/20 05:14	21.0	18.0	18.1	R-A	0.1
	Zero	10/18/20 05:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/19/20 04:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/19/20 04:25	200.0	180.5	180.4	R-A /Span * 100	0.1

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:29

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/19/20 04:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/19/20 04:20	10.0	9.0	9.2	R-A /Span * 100		2.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/19/20 04:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	10/19/20 04:24	200.0	180.0	184.1	R-A /Span * 100		2.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/19/20 04:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	10/19/20 04:19	10.0	9.3	9.5	R-A /Span * 100		2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/19/20 05:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/19/20 05:24	200.0	181.3	181.7	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/19/20 05:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	10/19/20 05:19	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/19/20 05:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/19/20 05:24	200.0	180.0	180.4	R-A /Span * 100		0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/19/20 05:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/19/20 05:19	10.0	9.0	9.3	>1x Alert R-A /Span * 100		3.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/19/20 05:14	21.0	18.0	18.2	R-A		0.2
	Zero	10/19/20 05:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/19/20 05:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	10/19/20 05:25	200.0	181.3	182.1	R-A /Span * 100		0.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/19/20 05:15	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	10/19/20 05:20	10.0	8.9	9.0	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/19/20 05:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/19/20 05:25	200.0	180.0	184.3	R-A /Span * 100		2.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/19/20 05:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/19/20 05:20	10.0	9.3	9.5	R-A /Span * 100		2.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:29

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/19/20 05:15	21.0	18.0	18.1	R-A	0.1
	Zero	10/19/20 05:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/20/20 04:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/20/20 04:25	200.0	180.5	180.3	R-A /Span * 100	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/20/20 04:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/20/20 04:19	10.0	9.0	9.0	R-A /Span * 100	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Fail	
	Zero	10/20/20 04:15	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	10/20/20 04:25	200.0	179.0	20.5	>4x R-A /Span * 100	79.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/20/20 04:15	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	10/20/20 04:20	10.0	9.3	9.5	R-A /Span * 100	2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/20/20 05:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/20/20 05:25	200.0	181.3	181.7	R-A /Span * 100	0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/20/20 05:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/20/20 05:19	10.0	9.1	9.0	R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/20/20 05:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/20/20 05:25	200.0	180.0	179.8	R-A /Span * 100	0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/20/20 05:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/20/20 05:19	10.0	9.0	9.0	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/20/20 05:14	21.0	18.0	18.2	R-A	0.2
	Zero	10/20/20 05:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/20/20 05:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	10/20/20 05:25	200.0	180.9	181.9	R-A /Span * 100	0.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/20/20 05:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	10/20/20 05:19	10.0	8.9	9.1	R-A /Span * 100	2.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:29

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/20/20 05:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/20/20 05:25	200.0	179.0		R-A /Span * 100	2.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/20/20 05:14	10.0	0.0		R-A /Span * 100	0.0
	High	10/20/20 05:19	10.0	9.3		R-A /Span * 100	2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/20/20 05:14	21.0	18.0		R-A	0.2
	Zero	10/20/20 05:19	21.0	0.0		R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/20/20 06:28	200.0	0.0		R-A /Span * 100	0.1
	High	10/20/20 06:38	200.0	179.0		R-A /Span * 100	2.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/20/20 06:28	10.0	0.0		R-A /Span * 100	1.0
	High	10/20/20 06:34	10.0	9.3		R-A /Span * 100	2.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/21/20 04:15	200.0	0.0		R-A /Span * 100	0.0
	High	10/21/20 04:25	200.0	180.5		R-A /Span * 100	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/21/20 04:15	10.0	0.0		R-A /Span * 100	0.0
	High	10/21/20 04:20	10.0	9.0		R-A /Span * 100	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/21/20 04:14	200.0	0.0		R-A /Span * 100	0.1
	High	10/21/20 04:25	200.0	179.0		R-A /Span * 100	2.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/21/20 04:14	10.0	0.0		R-A /Span * 100	1.0
	High	10/21/20 04:19	10.0	9.3		R-A /Span * 100	2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/21/20 05:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/21/20 05:25	200.0	181.3		R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/21/20 05:14	10.0	0.0		R-A /Span * 100	0.0
	High	10/21/20 05:20	10.0	9.1		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/21/20 05:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/21/20 05:25	200.0	180.0		R-A /Span * 100	0.2

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:29

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/21/20 05:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/21/20 05:20	10.0	9.0	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/21/20 05:14	21.0	18.2	R-A		0.2
	Zero	10/21/20 05:20	21.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/21/20 05:14	200.0	0.1	R-A /Span * 100		0.1
	High	10/21/20 05:25	200.0	182.6	R-A /Span * 100		0.9
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/21/20 05:14	10.0	0.1	R-A /Span * 100		1.0
	High	10/21/20 05:19	10.0	9.1	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/21/20 05:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/21/20 05:25	200.0	179.0	R-A /Span * 100		2.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/21/20 05:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/21/20 05:19	10.0	9.3	R-A /Span * 100		2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/21/20 05:14	21.0	18.1	R-A		0.1
	Zero	10/21/20 05:19	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/22/20 04:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/22/20 04:25	200.0	180.6	R-A /Span * 100		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/22/20 04:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/22/20 04:19	10.0	9.0	R-A /Span * 100		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/22/20 04:14	200.0	0.1	R-A /Span * 100		0.1
	High	10/22/20 04:25	200.0	183.6	R-A /Span * 100		2.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/22/20 04:14	10.0	0.1	R-A /Span * 100		1.0
	High	10/22/20 04:19	10.0	9.3	R-A /Span * 100		2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/22/20 05:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/22/20 05:25	200.0	181.3	R-A /Span * 100		0.3

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:29

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/22/20 05:14	10.0	0.0		R-A /Span * 100	1.0
	High	10/22/20 05:20	10.0	9.1		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/22/20 05:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/22/20 05:25	200.0	180.0		R-A /Span * 100	0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/22/20 05:14	10.0	0.0		R-A /Span * 100	0.0
	High	10/22/20 05:20	10.0	9.0		R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/22/20 05:14	21.0	18.0		R-A	0.2
	Zero	10/22/20 05:20	21.0	0.0		R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/22/20 05:14	200.0	0.0		R-A /Span * 100	0.1
	High	10/22/20 05:24	200.0	180.9		R-A /Span * 100	1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/22/20 05:14	10.0	0.0		R-A /Span * 100	1.0
	High	10/22/20 05:19	10.0	8.9		R-A /Span * 100	3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/22/20 05:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/22/20 05:24	200.0	179.0		R-A /Span * 100	2.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/22/20 05:14	10.0	0.0		R-A /Span * 100	0.0
	High	10/22/20 05:19	10.0	9.3		R-A /Span * 100	2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/22/20 05:14	21.0	18.0		R-A	0.1
	Zero	10/22/20 05:19	21.0	0.0		R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/23/20 04:14	200.0	0.0		R-A /Span * 100	0.1
	High	10/23/20 04:24	200.0	179.0		R-A /Span * 100	2.9
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/23/20 04:14	10.0	0.0		R-A /Span * 100	1.0
	High	10/23/20 04:20	10.0	9.3		R-A /Span * 100	2.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/23/20 04:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/23/20 04:24	200.0	180.5		R-A /Span * 100	0.3

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:29

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/23/20 04:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/23/20 04:19	10.0	9.3	9.0	>1x Alert	R-A /Span * 100	3.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/23/20 05:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	10/23/20 05:24	200.0	180.9	183.3	R-A /Span * 100		1.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/23/20 05:14	10.0	0.0	0.2	R-A /Span * 100		2.0
	High	10/23/20 05:19	10.0	8.9	9.1	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/23/20 05:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/23/20 05:24	200.0	179.0	183.6	R-A /Span * 100		2.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/23/20 05:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/23/20 05:19	10.0	9.3	9.5	R-A /Span * 100		2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/23/20 05:14	21.0	18.0	18.1	R-A		0.1
	Zero	10/23/20 05:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/23/20 05:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/23/20 05:25	200.0	181.3	181.7	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/23/20 05:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/23/20 05:19	10.0	8.9	9.0	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/23/20 05:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/23/20 05:25	200.0	180.0	178.1	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/23/20 05:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/23/20 05:19	10.0	9.3	8.9	>1x Alert	R-A /Span * 100	4.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/23/20 05:14	21.0	18.2	18.3	R-A		0.1
	Zero	10/23/20 05:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/24/20 04:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	10/24/20 04:24	200.0	179.0	184.3	>1x Alert	R-A /Span * 100	2.7

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:29

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/24/20 04:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	10/24/20 04:19	10.0	9.3	9.6	R-A /Span * 100	3.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/24/20 05:15	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	10/24/20 05:25	200.0	180.9	183.3	R-A /Span * 100	1.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/24/20 05:15	10.0	0.0	0.2	R-A /Span * 100	2.0
	High	10/24/20 05:20	10.0	8.9	9.2	R-A /Span * 100	3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/24/20 05:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/24/20 05:25	200.0	179.0	182.8	R-A /Span * 100	1.9
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/24/20 05:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/24/20 05:20	10.0	9.3	9.5	R-A /Span * 100	2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/24/20 05:15	21.0	18.0	18.1	R-A	0.1
	Zero	10/24/20 05:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/25/20 04:15	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	10/25/20 04:24	200.0	179.0	184.1	R-A /Span * 100	2.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/25/20 04:15	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	10/25/20 04:19	10.0	9.3	9.6	R-A /Span * 100	3.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/25/20 05:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	10/25/20 05:25	200.0	180.9	183.2	R-A /Span * 100	1.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/25/20 05:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	10/25/20 05:20	10.0	8.9	9.2	R-A /Span * 100	3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/25/20 05:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/25/20 05:25	200.0	179.0	182.6	R-A /Span * 100	1.8
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/25/20 05:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/25/20 05:20	10.0	9.3	9.5	R-A /Span * 100	2.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:29

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/25/20 05:14	21.0	18.0	18.1	R-A	0.1
	Zero	10/25/20 05:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/26/20 04:15	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	10/26/20 04:25	200.0	179.0	185.6	>1x Alert R-A /Span * 100	3.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/26/20 04:15	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	10/26/20 04:20	10.0	9.3	9.6	>1x Alert R-A /Span * 100	3.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/26/20 05:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	10/26/20 05:24	200.0	180.9	182.6	R-A /Span * 100	0.9
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/26/20 05:14	10.0	0.0	0.2	R-A /Span * 100	2.0
	High	10/26/20 05:19	10.0	8.9	9.2	R-A /Span * 100	3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/26/20 05:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/26/20 05:24	200.0	179.0	184.0	R-A /Span * 100	2.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/26/20 05:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/26/20 05:19	10.0	9.3	9.6	>1x Alert R-A /Span * 100	3.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/26/20 05:14	21.0	18.0	18.1	R-A	0.1
	Zero	10/26/20 05:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/27/20 04:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	10/27/20 04:24	200.0	179.0	184.6	>1x Alert R-A /Span * 100	2.8
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/27/20 04:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	10/27/20 04:19	10.0	9.3	9.6	>1x Alert R-A /Span * 100	3.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/27/20 05:15	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	10/27/20 05:25	200.0	180.9	182.4	R-A /Span * 100	0.8
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/27/20 05:15	10.0	0.0	0.2	R-A /Span * 100	2.0
	High	10/27/20 05:20	10.0	8.9	9.2	R-A /Span * 100	3.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:29

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/27/20 05:15	200.0	0.0		R-A /Span * 100	0.0
	High	10/27/20 05:25	200.0	179.0		R-A /Span * 100	2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/27/20 05:15	10.0	0.0		R-A /Span * 100	0.0
	High	10/27/20 05:20	10.0	9.3		R-A /Span * 100	2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/27/20 05:15	21.0	18.0		R-A	0.1
	Zero	10/27/20 05:20	21.0	0.0		R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/28/20 04:14	200.0	0.0		R-A /Span * 100	0.1
	High	10/28/20 04:24	200.0	179.0		R-A /Span * 100	0.5
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/28/20 04:14	10.0	0.0		R-A /Span * 100	1.0
	High	10/28/20 04:20	10.0	9.3		R-A /Span * 100	1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/28/20 05:14	200.0	0.0		R-A /Span * 100	0.1
	High	10/28/20 05:25	200.0	180.9		R-A /Span * 100	0.9
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/28/20 05:14	10.0	0.0		R-A /Span * 100	2.0
	High	10/28/20 05:20	10.0	8.9		R-A /Span * 100	3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/28/20 05:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/28/20 05:25	200.0	179.0		R-A /Span * 100	2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/28/20 05:14	10.0	0.0		R-A /Span * 100	0.0
	High	10/28/20 05:20	10.0	9.3		R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/28/20 05:14	21.0	18.0		R-A	0.1
	Zero	10/28/20 05:20	21.0	0.0		R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/29/20 04:14	200.0	0.0		R-A /Span * 100	0.1
	High	10/29/20 04:24	200.0	179.0		R-A /Span * 100	0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/29/20 04:14	10.0	0.0		R-A /Span * 100	1.0
	High	10/29/20 04:19	10.0	9.3		R-A /Span * 100	1.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:29

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/29/20 05:14	200.0	0.0	0.3	R-A /Span * 100	0.2
	High	10/29/20 05:24	200.0	180.9	183.3	R-A /Span * 100	1.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/29/20 05:14	10.0	0.0	0.3	R-A /Span * 100	3.0
	High	10/29/20 05:19	10.0	8.9	9.2	R-A /Span * 100	3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/29/20 05:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/29/20 05:24	200.0	179.0	182.8	R-A /Span * 100	1.9
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/29/20 05:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/29/20 05:19	10.0	9.3	9.3	R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/29/20 05:14	21.0	18.0	18.1	R-A	0.1
	Zero	10/29/20 05:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/30/20 04:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	10/30/20 04:25	200.0	179.0	177.3	R-A /Span * 100	0.9
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/30/20 04:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	10/30/20 04:19	10.0	9.3	9.2	R-A /Span * 100	1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/30/20 05:14	200.0	0.0	0.3	R-A /Span * 100	0.2
	High	10/30/20 05:25	200.0	180.9	182.5	R-A /Span * 100	0.8
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/30/20 05:14	10.0	0.0	0.2	R-A /Span * 100	2.0
	High	10/30/20 05:19	10.0	8.9	9.2	R-A /Span * 100	3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/30/20 05:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/30/20 05:25	200.0	179.0	183.1	R-A /Span * 100	2.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/30/20 05:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	10/30/20 05:19	10.0	9.3	9.3	R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/30/20 05:14	21.0	18.0	18.1	R-A	0.1
	Zero	10/30/20 05:19	21.0	0.0	0.0	R-A	0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:29

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/31/20 04:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	10/31/20 04:25	200.0	179.0	177.3	R-A /Span * 100		0.9
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/31/20 04:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	10/31/20 04:19	10.0	9.3	9.2	R-A /Span * 100		1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/31/20 05:15	200.0	0.0	0.3	R-A /Span * 100		0.2
	High	10/31/20 05:25	200.0	180.9	182.6	R-A /Span * 100		0.9
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/31/20 05:15	10.0	0.0	0.3	R-A /Span * 100		3.0
	High	10/31/20 05:20	10.0	8.9	9.3	R-A /Span * 100		4.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/31/20 05:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/31/20 05:25	200.0	179.0	183.0	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/31/20 05:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/31/20 05:20	10.0	9.3	9.3	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/31/20 05:15	21.0	18.0	18.1	R-A		0.1
	Zero	10/31/20 05:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/01/20 04:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	11/01/20 04:25	200.0	179.0	177.5	R-A /Span * 100		0.8
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/01/20 04:15	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	11/01/20 04:20	10.0	9.3	9.2	R-A /Span * 100		1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/01/20 05:14	200.0	0.0	0.3	R-A /Span * 100		0.2
	High	11/01/20 05:24	200.0	180.9	182.5	R-A /Span * 100		0.8
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/01/20 05:14	10.0	0.0	0.2	R-A /Span * 100		2.0
	High	11/01/20 05:19	10.0	8.9	9.3	R-A /Span * 100		4.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/01/20 05:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/01/20 05:24	200.0	179.0	183.0	R-A /Span * 100		2.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:29

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/01/20 05:14	10.0	0.0	R-A /Span * 100		0.0
	High	11/01/20 05:19	10.0	9.3	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/01/20 05:14	21.0	18.0	R-A		0.2
	Zero	11/01/20 05:19	21.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/02/20 04:15	200.0	0.1	R-A /Span * 100		0.1
	High	11/02/20 04:25	200.0	179.0	R-A /Span * 100		1.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/02/20 04:15	10.0	0.1	R-A /Span * 100		1.0
	High	11/02/20 04:20	10.0	9.3	R-A /Span * 100		1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/02/20 05:14	200.0	0.3	R-A /Span * 100		0.2
	High	11/02/20 05:25	200.0	180.9	R-A /Span * 100		1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/02/20 05:14	10.0	0.3	R-A /Span * 100		3.0
	High	11/02/20 05:20	10.0	9.2	R-A /Span * 100		3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/02/20 05:14	200.0	0.0	R-A /Span * 100		0.0
	High	11/02/20 05:25	200.0	179.0	R-A /Span * 100		1.9
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/02/20 05:14	10.0	0.0	R-A /Span * 100		0.0
	High	11/02/20 05:20	10.0	9.3	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/02/20 05:14	21.0	18.0	R-A		0.1
	Zero	11/02/20 05:20	21.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/03/20 04:14	200.0	0.1	R-A /Span * 100		0.1
	High	11/03/20 04:24	200.0	179.0	R-A /Span * 100		0.9
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/03/20 04:14	10.0	0.1	R-A /Span * 100		1.0
	High	11/03/20 04:20	10.0	9.3	R-A /Span * 100		1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/03/20 05:14	200.0	0.3	R-A /Span * 100		0.2
	High	11/03/20 05:24	200.0	180.9	R-A /Span * 100		1.1

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:29

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/03/20 05:14	10.0	0.0	0.3	R-A /Span * 100		3.0
	High	11/03/20 05:19	10.0	8.9	9.4	R-A /Span * 100		5.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/03/20 05:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/03/20 05:24	200.0	179.0	182.9	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/03/20 05:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/03/20 05:19	10.0	9.3	9.3	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/03/20 05:14	21.0	18.0	18.2	R-A		0.2
	Zero	11/03/20 05:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/04/20 04:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	11/04/20 04:24	200.0	179.0	177.2	R-A /Span * 100		0.9
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/04/20 04:15	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	11/04/20 04:19	10.0	9.3	9.2	R-A /Span * 100		1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/04/20 05:15	200.0	0.0	0.3	R-A /Span * 100		0.2
	High	11/04/20 05:25	200.0	180.9	182.9	R-A /Span * 100		1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/04/20 05:15	10.0	0.0	0.3	R-A /Span * 100		3.0
	High	11/04/20 05:20	10.0	8.9	9.3	R-A /Span * 100		4.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/04/20 05:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/04/20 05:25	200.0	179.0	182.9	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/04/20 05:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/04/20 05:20	10.0	9.3	9.3	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/04/20 05:15	21.0	18.0	18.1	R-A		0.1
	Zero	11/04/20 05:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/05/20 04:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	11/05/20 04:25	200.0	179.0	177.1	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:29

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/05/20 04:15	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	11/05/20 04:20	10.0	9.3	9.2	R-A /Span * 100		1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/05/20 05:14	200.0	0.0	0.3	R-A /Span * 100		0.2
	High	11/05/20 05:25	200.0	180.9	182.6	R-A /Span * 100		0.9
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/05/20 05:14	10.0	0.0	0.3	R-A /Span * 100		3.0
	High	11/05/20 05:20	10.0	8.9	9.2	R-A /Span * 100		3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/05/20 05:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/05/20 05:25	200.0	179.0	182.9	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/05/20 05:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/05/20 05:20	10.0	9.3	9.3	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/05/20 05:14	21.0	18.0	18.2	R-A		0.2
	Zero	11/05/20 05:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/06/20 04:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	11/06/20 04:25	200.0	179.0	177.6	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/06/20 04:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	11/06/20 04:19	10.0	9.3	9.2	R-A /Span * 100		1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/06/20 05:14	200.0	0.0	0.3	R-A /Span * 100		0.2
	High	11/06/20 05:24	200.0	180.9	184.2	R-A /Span * 100		1.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/06/20 05:14	10.0	0.0	0.4	R-A /Span * 100		4.0
	High	11/06/20 05:19	10.0	8.9	9.3	R-A /Span * 100		4.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/06/20 05:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/06/20 05:24	200.0	179.0	182.7	R-A /Span * 100		1.9
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/06/20 05:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/06/20 05:19	10.0	9.3	9.3	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:29

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/06/20 05:14	21.0	18.0	18.1	R-A	0.1
	Zero	11/06/20 05:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/07/20 04:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	11/07/20 04:25	200.0	179.0	178.8	R-A /Span * 100	0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/07/20 04:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	11/07/20 04:19	10.0	9.3	9.2	R-A /Span * 100	1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/07/20 05:14	200.0	0.0	0.3	R-A /Span * 100	0.2
	High	11/07/20 05:24	200.0	180.9	185.0	R-A /Span * 100	2.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/07/20 05:14	10.0	0.0	0.3	R-A /Span * 100	3.0
	High	11/07/20 05:19	10.0	8.9	9.3	R-A /Span * 100	4.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/07/20 05:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/07/20 05:24	200.0	179.0	182.9	R-A /Span * 100	2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/07/20 05:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/07/20 05:19	10.0	9.3	9.3	R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/07/20 05:14	21.0	18.0	18.1	R-A	0.1
	Zero	11/07/20 05:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/08/20 04:15	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	11/08/20 04:25	200.0	179.0	179.4	R-A /Span * 100	0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/08/20 04:15	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	11/08/20 04:20	10.0	9.3	9.2	R-A /Span * 100	1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/08/20 05:14	200.0	0.0	0.3	R-A /Span * 100	0.2
	High	11/08/20 05:24	200.0	180.9	185.3	R-A /Span * 100	2.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/08/20 05:14	10.0	0.0	0.3	R-A /Span * 100	3.0
	High	11/08/20 05:19	10.0	8.9	9.3	R-A /Span * 100	4.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:29

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/08/20 05:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/08/20 05:24	200.0	179.0		R-A /Span * 100	1.9
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/08/20 05:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/08/20 05:19	10.0	9.3		R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/08/20 05:14	21.0	18.0		R-A	0.1
	Zero	11/08/20 05:19	21.0	0.0		R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/09/20 04:14	200.0	0.0		R-A /Span * 100	0.1
	High	11/09/20 04:25	200.0	179.0		R-A /Span * 100	0.4
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/09/20 04:14	10.0	0.0		R-A /Span * 100	1.0
	High	11/09/20 04:19	10.0	9.3		R-A /Span * 100	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/09/20 05:14	200.0	0.0		R-A /Span * 100	0.2
	High	11/09/20 05:24	200.0	180.9		R-A /Span * 100	1.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/09/20 05:14	10.0	0.0		R-A /Span * 100	3.0
	High	11/09/20 05:20	10.0	8.9		R-A /Span * 100	4.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/09/20 05:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/09/20 05:24	200.0	179.0		R-A /Span * 100	2.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/09/20 05:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/09/20 05:20	10.0	9.3		R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/09/20 05:14	21.0	18.0		R-A	0.1
	Zero	11/09/20 05:20	21.0	0.0		R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/10/20 04:14	200.0	0.0		R-A /Span * 100	0.1
	High	11/10/20 04:24	200.0	179.0		R-A /Span * 100	0.4
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/10/20 04:14	10.0	0.0		R-A /Span * 100	1.0
	High	11/10/20 04:20	10.0	9.3		R-A /Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:29

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/10/20 05:14	200.0	0.0	0.3	R-A /Span * 100	0.2
	High	11/10/20 05:25	200.0	180.9	183.1	R-A /Span * 100	1.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/10/20 05:14	10.0	0.0	0.3	R-A /Span * 100	3.0
	High	11/10/20 05:19	10.0	8.9	9.4	R-A /Span * 100	5.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/10/20 05:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/10/20 05:25	200.0	179.0	182.8	R-A /Span * 100	1.9
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/10/20 05:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/10/20 05:19	10.0	9.3	9.3	R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/10/20 05:14	21.0	18.0	18.1	R-A	0.1
	Zero	11/10/20 05:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/11/20 04:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	11/11/20 04:25	200.0	179.0	179.3	R-A /Span * 100	0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/11/20 04:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	11/11/20 04:19	10.0	9.3	9.2	R-A /Span * 100	1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/11/20 05:15	200.0	0.0	0.4	R-A /Span * 100	0.2
	High	11/11/20 05:25	200.0	180.9	183.5	R-A /Span * 100	1.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/11/20 05:15	10.0	0.0	0.4	R-A /Span * 100	4.0
	High	11/11/20 05:20	10.0	8.9	9.4	R-A /Span * 100	5.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/11/20 05:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/11/20 05:25	200.0	179.0	182.7	R-A /Span * 100	1.9
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/11/20 05:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/11/20 05:20	10.0	9.3	9.3	R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/11/20 05:15	21.0	18.0	18.1	R-A	0.1
	Zero	11/11/20 05:20	21.0	0.0	0.0	R-A	0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:29

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/12/20 04:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	11/12/20 04:25	200.0	179.0	179.8	R-A /Span * 100	0.4
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/12/20 04:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	11/12/20 04:20	10.0	9.3	9.3	R-A /Span * 100	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/12/20 05:15	200.0	0.0	0.3	R-A /Span * 100	0.2
	High	11/12/20 05:25	200.0	180.9	184.2	R-A /Span * 100	1.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/12/20 05:15	10.0	0.0	0.4	R-A /Span * 100	4.0
	High	11/12/20 05:19	10.0	8.9	9.4	R-A /Span * 100	5.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/12/20 05:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/12/20 05:25	200.0	179.0	182.9	R-A /Span * 100	2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/12/20 05:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/12/20 05:19	10.0	9.3	9.3	R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/12/20 05:15	21.0	18.0	18.1	R-A	0.1
	Zero	11/12/20 05:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/13/20 04:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	11/13/20 04:25	200.0	179.0	178.6	R-A /Span * 100	0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/13/20 04:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	11/13/20 04:20	10.0	9.3	9.3	R-A /Span * 100	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/13/20 05:15	200.0	0.0	0.4	R-A /Span * 100	0.2
	High	11/13/20 05:25	200.0	180.9	183.2	R-A /Span * 100	1.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/13/20 05:15	10.0	0.0	0.4	R-A /Span * 100	4.0
	High	11/13/20 05:19	10.0	8.9	9.4	R-A /Span * 100	5.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/13/20 05:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/13/20 05:25	200.0	179.0	182.7	R-A /Span * 100	1.9

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:29

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/13/20 05:15	10.0	0.0		R-A /Span * 100	0.0
	High	11/13/20 05:19	10.0	9.3		R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/13/20 05:15	21.0	18.0		R-A	0.2
	Zero	11/13/20 05:19	21.0	0.0		R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/14/20 04:15	200.0	0.0		R-A /Span * 100	0.1
	High	11/14/20 04:24	200.0	179.0		R-A /Span * 100	0.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/14/20 04:15	10.0	0.0		R-A /Span * 100	1.0
	High	11/14/20 04:19	10.0	9.3		R-A /Span * 100	1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/14/20 05:14	200.0	0.0		R-A /Span * 100	0.2
	High	11/14/20 05:24	200.0	180.9		R-A /Span * 100	0.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/14/20 05:14	10.0	0.0		R-A /Span * 100	4.0
	High	11/14/20 05:19	10.0	8.9		R-A /Span * 100	5.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/14/20 05:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/14/20 05:24	200.0	179.0		R-A /Span * 100	1.6
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/14/20 05:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/14/20 05:19	10.0	9.3		R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/14/20 05:14	21.0	18.0		R-A	0.2
	Zero	11/14/20 05:19	21.0	0.0		R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/15/20 04:14	200.0	0.0		R-A /Span * 100	0.1
	High	11/15/20 04:25	200.0	179.0		R-A /Span * 100	0.5
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/15/20 04:14	10.0	0.0		R-A /Span * 100	1.0
	High	11/15/20 04:19	10.0	9.3		R-A /Span * 100	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/15/20 05:15	200.0	0.0		R-A /Span * 100	0.2
	High	11/15/20 05:25	200.0	180.9		R-A /Span * 100	0.8

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:29

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/15/20 05:15	10.0	0.0	0.4	R-A /Span * 100		4.0
	High	11/15/20 05:20	10.0	8.9	9.3	R-A /Span * 100		4.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/15/20 05:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/15/20 05:25	200.0	179.0	182.7	R-A /Span * 100		1.9
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/15/20 05:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/15/20 05:20	10.0	9.3	9.3	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/15/20 05:15	21.0	18.0	18.1	R-A		0.1
	Zero	11/15/20 05:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/16/20 04:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	11/16/20 04:25	200.0	179.0	180.4	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/16/20 04:15	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	11/16/20 04:20	10.0	9.3	9.3	R-A /Span * 100		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/16/20 05:14	200.0	0.0	0.3	R-A /Span * 100		0.2
	High	11/16/20 05:25	200.0	180.9	183.2	R-A /Span * 100		1.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/16/20 05:14	10.0	0.0	0.3	R-A /Span * 100		3.0
	High	11/16/20 05:20	10.0	8.9	9.4	R-A /Span * 100		5.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/16/20 05:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/16/20 05:25	200.0	179.0	182.8	R-A /Span * 100		1.9
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/16/20 05:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/16/20 05:20	10.0	9.3	9.2	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/16/20 05:14	21.0	18.0	18.1	R-A		0.1
	Zero	11/16/20 05:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/17/20 04:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	11/17/20 04:25	200.0	179.0	181.5	R-A /Span * 100		1.3

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:29

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/17/20 04:15	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	11/17/20 04:19	10.0	9.3	9.4	R-A /Span * 100		1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/17/20 05:15	200.0	0.0	0.3	R-A /Span * 100		0.2
	High	11/17/20 05:25	200.0	180.9	184.7	R-A /Span * 100		1.9
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/17/20 05:15	10.0	0.0	0.3	R-A /Span * 100		3.0
	High	11/17/20 05:20	10.0	8.9	9.4	R-A /Span * 100		5.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/17/20 05:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/17/20 05:25	200.0	179.0	182.8	R-A /Span * 100		1.9
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/17/20 05:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/17/20 05:20	10.0	9.3	9.3	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/17/20 05:15	21.0	18.0	18.1	R-A		0.1
	Zero	11/17/20 05:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/18/20 04:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	11/18/20 04:25	200.0	179.0	181.1	R-A /Span * 100		1.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/18/20 04:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	11/18/20 04:19	10.0	9.3	9.3	R-A /Span * 100		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/18/20 05:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/18/20 05:24	200.0	180.9	180.0	R-A /Span * 100		0.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/18/20 05:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/18/20 05:19	10.0	8.9	8.9	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/18/20 05:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/18/20 05:24	200.0	179.0	182.0	R-A /Span * 100		1.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/18/20 05:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/18/20 05:19	10.0	9.3	9.2	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:29 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/18/20 05:14	21.0	18.0	18.1	R-A	0.1
	Zero	11/18/20 05:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/19/20 04:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	11/19/20 04:24	200.0	179.0	182.4	R-A /Span * 100	1.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/19/20 04:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	11/19/20 04:19	10.0	9.3	9.5	R-A /Span * 100	2.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/19/20 05:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/19/20 05:25	200.0	180.9	179.0	R-A /Span * 100	1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/19/20 05:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/19/20 05:20	10.0	8.9	8.9	R-A /Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/19/20 05:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/19/20 05:25	200.0	179.0	182.6	R-A /Span * 100	1.8
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/19/20 05:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/19/20 05:20	10.0	9.3	9.2	R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/19/20 05:15	21.0	18.0	18.1	R-A	0.1
	Zero	11/19/20 05:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/20/20 04:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	11/20/20 04:24	200.0	179.0	183.6	R-A /Span * 100	2.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/20/20 04:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	11/20/20 04:19	10.0	9.3	9.5	R-A /Span * 100	2.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/20/20 05:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/20/20 05:24	200.0	180.9	179.7	R-A /Span * 100	0.6
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/20/20 05:14	10.0	0.0	-0.1	R-A /Span * 100	1.0
	High	11/20/20 05:19	10.0	8.9	8.9	R-A /Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:29 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/20/20 05:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/20/20 05:24	200.0	179.0		R-A /Span * 100	1.9
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/20/20 05:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/20/20 05:19	10.0	9.3		R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/20/20 05:14	21.0	18.0		R-A	0.1
	Zero	11/20/20 05:19	21.0	0.0		R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Warning	
	Zero	11/21/20 04:15	200.0	0.0		R-A /Span * 100	0.1
	High	11/21/20 04:25	200.0	179.0	>2x	R-A /Span * 100	9.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Warning	
	Zero	11/21/20 04:15	10.0	0.0		R-A /Span * 100	1.0
	High	11/21/20 04:20	10.0	9.3	>2x	R-A /Span * 100	10.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/21/20 05:15	200.0	0.0		R-A /Span * 100	0.0
	High	11/21/20 05:25	200.0	180.9		R-A /Span * 100	0.8
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/21/20 05:15	10.0	0.0		R-A /Span * 100	0.0
	High	11/21/20 05:20	10.0	8.9		R-A /Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/21/20 05:15	200.0	0.0		R-A /Span * 100	0.0
	High	11/21/20 05:25	200.0	179.0		R-A /Span * 100	2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/21/20 05:15	10.0	0.0		R-A /Span * 100	0.0
	High	11/21/20 05:20	10.0	9.3		R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/21/20 05:15	21.0	18.0		R-A	0.1
	Zero	11/21/20 05:20	21.0	0.0		R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Warning	
	Zero	11/22/20 04:15	200.0	0.0		R-A /Span * 100	0.1
	High	11/22/20 04:25	200.0	179.0	>2x	R-A /Span * 100	9.8
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Warning	
	Zero	11/22/20 04:15	10.0	0.0		R-A /Span * 100	2.0
	High	11/22/20 04:19	10.0	9.3	>2x	R-A /Span * 100	10.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:29

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/22/20 05:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/22/20 05:25	200.0	180.9	180.3	R-A /Span * 100		0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/22/20 05:15	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	11/22/20 05:20	10.0	8.9	8.8	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/22/20 05:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/22/20 05:25	200.0	179.0	182.9	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/22/20 05:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/22/20 05:20	10.0	9.3	9.3	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/22/20 05:15	21.0	18.0	18.1	R-A		0.1
	Zero	11/22/20 05:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/23/20 04:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/23/20 04:24	200.0	179.0	180.6	R-A /Span * 100		0.8
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/23/20 04:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/23/20 04:19	10.0	9.3	9.4	R-A /Span * 100		1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/23/20 05:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/23/20 05:25	200.0	181.1	180.0	R-A /Span * 100		0.6
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/23/20 05:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/23/20 05:20	10.0	8.9	8.9	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/23/20 05:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/23/20 05:25	200.0	179.0	182.8	R-A /Span * 100		1.9
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/23/20 05:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/23/20 05:20	10.0	9.3	9.3	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/23/20 05:14	21.0	18.0	18.1	R-A		0.1
	Zero	11/23/20 05:20	21.0	0.0	0.0	R-A		0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:29

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/24/20 04:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/24/20 04:25	200.0	179.0	180.4	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/24/20 04:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/24/20 04:20	10.0	9.3	9.4	R-A /Span * 100		1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/24/20 05:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/24/20 05:25	200.0	181.1	180.4	R-A /Span * 100		0.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/24/20 05:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/24/20 05:20	10.0	8.9	8.9	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/24/20 05:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/24/20 05:25	200.0	179.0	183.2	R-A /Span * 100		2.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/24/20 05:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/24/20 05:20	10.0	9.3	9.3	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/24/20 05:15	21.0	18.0	18.1	R-A		0.1
	Zero	11/24/20 05:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/25/20 04:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/25/20 04:25	200.0	179.0	180.1	R-A /Span * 100		0.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/25/20 04:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/25/20 04:19	10.0	9.3	9.4	R-A /Span * 100		1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/25/20 05:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/25/20 05:25	200.0	181.1	179.9	R-A /Span * 100		0.6
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/25/20 05:14	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	11/25/20 05:20	10.0	8.9	8.9	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/25/20 05:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/25/20 05:25	200.0	179.0	182.7	R-A /Span * 100		1.9

Daily Calibration Results

CT1 and CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:29

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/25/20 05:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/25/20 05:20	10.0	9.3		R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/25/20 05:14	21.0	18.0		R-A	0.1
	Zero	11/25/20 05:20	21.0	0.0		R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/22/20 16:41	200.0	0.1		R-A /Span * 100	0.1
	High	12/22/20 16:52	200.0	181.9		R-A /Span * 100	0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/22/20 16:41	10.0	0.1		R-A /Span * 100	1.0
	High	12/22/20 16:46	10.0	8.9		R-A /Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/22/20 16:41	200.0	0.0		R-A /Span * 100	0.0
	High	12/22/20 16:52	200.0	180.0		R-A /Span * 100	0.7
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/22/20 16:41	10.0	0.0		R-A /Span * 100	0.0
	High	12/22/20 16:46	10.0	9.2		R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/22/20 16:41	21.0	18.0		R-A	0.0
	Zero	12/22/20 16:46	21.0	0.0		R-A	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/22/20 18:38	200.0	0.0		R-A /Span * 100	0.0
	High	12/22/20 18:49	200.0	180.2		R-A /Span * 100	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/22/20 18:38	10.0	0.0		R-A /Span * 100	0.0
	High	12/22/20 18:43	10.0	9.1		R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/22/20 18:38	200.0	0.0		R-A /Span * 100	0.0
	High	12/22/20 18:49	200.0	180.5		R-A /Span * 100	2.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/22/20 18:38	10.0	0.0		R-A /Span * 100	0.0
	High	12/22/20 18:43	10.0	9.0		R-A /Span * 100	2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/22/20 18:38	21.0	18.2		R-A	0.1
	Zero	12/22/20 18:43	21.0	0.0		R-A	0.0

Monthly Summary Report

Units CT1 and CT2



From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/05/2021 16:23 **Location:** Roseville, CA

Date	Unit CT1 OperatingTime, Hr		Unit CT1 DBOn, Hr		Unit CT2 OperatingTime, Hr		Unit CT2 DBOn, Hr	
	1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)	
	Sum	Running Sum	Sum	Running Sum	Sum	Running Sum	Sum	Running Sum
Oct 20	485.61	485.61	157.79	157.79	678.52	678.52	254.65	254.65
Nov 20	0.00	485.61	0.00	157.79	600.07	1,278.59	166.71	421.36
Dec 20	2.72	488.33	0.00	157.79	2.85	1,281.44	0.00	421.36
Sum/Avg	488.33		157.79		1,281.44		421.36	

Tons 12 Month Rolling Summary

CT1 and CT2 Combined



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:17 Location: Roseville, CA

* = Excess Emission

Date	Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2	
	CO, Ton		NOx, Ton		PM10, Ton		SO2, Ton		VOC, Ton	
	1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)	
	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum
Oct 2020	0.4702	2.7037	1.4695	8.2453	0.2805	1.5473	0.1402	0.7736	0.4673	2.5777
Nov 2020	0.3189	2.4722	0.7256	7.9558	0.1387	1.5036	0.0696	0.7521	0.2316	2.5050
Dec 2020	0.0524	2.4405	0.0197	7.7366	0.0012	1.4593	0.0006	0.7300	0.0020	2.4312
Sum/Avg	2.4405		7.7366		1.4593		0.7300		2.4312	
Limit Value										

AQ34 3HR AVG LOAD

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/01/20 0:00	1			52			52											
10/01/20 1:00	1			45			48											
10/01/20 2:00	1			40			46											
10/01/20 3:00	1			37			46											
10/01/20 4:00	1			36			46											
10/01/20 5:00	1			36			43											
10/01/20 6:00	1			37			39											
10/01/20 7:00	1			38			38											
10/01/20 8:00	1			41			42											
10/01/20 9:00	1			46			48											
10/01/20 10:00	1			54			55											
10/01/20 11:00	1			62			62											
10/01/20 12:00	1			68			67											
10/01/20 13:00	1			72			71											
10/01/20 14:00	1			74			73											
10/01/20 15:00	1			74			73											
10/01/20 16:00	1			74			73											
10/01/20 17:00	1			74			73											
10/01/20 18:00	1			70			69											
10/01/20 19:00	1			65			64											
10/01/20 20:00	1			60			59											
10/01/20 21:00	1			63			62											
10/01/20 22:00	1			61			60											
10/01/20 23:00	1			56			57											
10/02/20 0:00	1			48			51											
10/02/20 1:00	1			42			47											
10/02/20 2:00	1			38			44											
10/02/20 3:00	1			37			42											
10/02/20 4:00	1			37			41											
10/02/20 5:00	1			37			40											
10/02/20 6:00	1			37			38											
10/02/20 7:00	1			37			36											
10/02/20 8:00	1			37			36											
10/02/20 9:00	1			38			37											
10/02/20 10:00	1			39			40											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/02/20 11:00	1			44			45											
10/02/20 12:00	1			51			51											
10/02/20 13:00	1			57			56											
10/02/20 14:00	1			61			60											
10/02/20 15:00	1			61			60											
10/02/20 16:00	1			64			63											
10/02/20 17:00	1			64			63											
10/02/20 18:00	1			62			61											
10/02/20 19:00	1			59			59											
10/02/20 20:00	1			52			52											
10/02/20 21:00	1			54			54											
10/02/20 22:00	1			52			52											
10/02/20 23:00	1			54			54											
10/03/20 0:00	1			47			50											
10/03/20 1:00	1			42			46											
10/03/20 2:00	1			38			41											
10/03/20 3:00	1			37			38											
10/03/20 4:00	1			37			36											
10/03/20 5:00	1			37			36											
10/03/20 6:00	1			37			36											
10/03/20 7:00	1			37			36											
10/03/20 8:00	1			38			37											
10/03/20 9:00	1			42			42											
10/03/20 10:00	1			46			47											
10/03/20 11:00	1			50			53											
10/03/20 12:00	1			50			55											
10/03/20 13:00	1			54			57											
10/03/20 14:00	1			59			60											
10/03/20 15:00	1			62			61											
10/03/20 16:00	1			61			60											
10/03/20 17:00	1			57			57											
10/03/20 18:00	1			62			61											
10/03/20 19:00	1			63			63											
10/03/20 20:00	1			64			63											
10/03/20 21:00	1			60			59											
10/03/20 22:00	1			57			57											
10/03/20 23:00	1			54			56											
10/04/20 0:00	1			47			51											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/04/20 1:00	1			42			49											
10/04/20 2:00	1			38			44											
10/04/20 3:00	1			37			41											
10/04/20 4:00	1			37			38											
10/04/20 5:00	1			38			37											
10/04/20 6:00	1			38			39											
10/04/20 7:00	1			39			43											
10/04/20 8:00	1			42			47											
10/04/20 9:00	1			48			52											
10/04/20 10:00	1			54			56											
10/04/20 11:00	1			60			60											
10/04/20 12:00	1			66			64											
10/04/20 13:00	1			71			69											
10/04/20 14:00	1			74			73											
10/04/20 15:00	1			76			74											
10/04/20 16:00	1			75			74											
10/04/20 17:00	1			73			72											
10/04/20 18:00	1			71			70											
10/04/20 19:00	1			66			65											
10/04/20 20:00	1			62			61											
10/04/20 21:00	1			57			57											
10/04/20 22:00	1			54			54											
10/04/20 23:00	1			48			50											
10/05/20 0:00	1			41			45											
10/05/20 1:00	1			38			40											
10/05/20 2:00	1			37			37											
10/05/20 3:00	1			37			36											
10/05/20 4:00	1			38			38											
10/05/20 5:00	1			39			41											
10/05/20 6:00	1			41			44											
10/05/20 7:00	1			43			48											
10/05/20 8:00	1			46			52											
10/05/20 9:00	1			51			56											
10/05/20 10:00	1			57			58											
10/05/20 11:00	1			62			61											
10/05/20 12:00	1			64			63											
10/05/20 13:00	1			69			68											
10/05/20 14:00	1			72			71											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/05/20 15:00	1			76			75											
10/05/20 16:00	1			77			76											
10/05/20 17:00	1			76			75											
10/05/20 18:00	1			74			73											
10/05/20 19:00	1			72			71											
10/05/20 20:00	1			68			67											
10/05/20 21:00	1			64			63											
10/05/20 22:00	1			57			57											
10/05/20 23:00	1			50			51											
10/06/20 0:00	1			43			45											
10/06/20 1:00	1			39			41											
10/06/20 2:00	1			37			38											
10/06/20 3:00	1			37			36											
10/06/20 4:00	1			37			36											
10/06/20 5:00	1			39			39											
10/06/20 6:00	1			41			42											
10/06/20 7:00	1			45			46											
10/06/20 8:00	1			48			50											
10/06/20 9:00	1			53			54											
10/06/20 10:00	1			56			58											
10/06/20 11:00	1			60			61											
10/06/20 12:00	1			62			61											
10/06/20 13:00	1			66			64											
10/06/20 14:00	1			68			66											
10/06/20 15:00	1			73			71											
10/06/20 16:00	1			75			73											
10/06/20 17:00	1			74			74											
10/06/20 18:00	1			72			71											
10/06/20 19:00	1			70			69											
10/06/20 20:00	1			69			68											
10/06/20 21:00	1			67			66											
10/06/20 22:00	1			60			59											
10/06/20 23:00	1			50			51											
10/07/20 0:00	1			43			47											
10/07/20 1:00	1			38			43											
10/07/20 2:00	1			37			40											
10/07/20 3:00	1			37			37											
10/07/20 4:00	1			37			37											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/07/20 5:00	1			45			45											
10/07/20 6:00	1			53			53											
10/07/20 7:00	1			57			56											
10/07/20 8:00	1			53			54											
10/07/20 9:00	1			51			52											
10/07/20 10:00	1			55			56											
10/07/20 11:00	1			59			59											
10/07/20 12:00	1			63			62											
10/07/20 13:00	1			65			65											
10/07/20 14:00	1			70			69											
10/07/20 15:00	1			74			73											
10/07/20 16:00	1			72			71											
10/07/20 17:00	1			67			66											
10/07/20 18:00	1			62			61											
10/07/20 19:00	1			60			60											
10/07/20 20:00	1			61			61											
10/07/20 21:00	1			58			58											
10/07/20 22:00	1			52			54											
10/07/20 23:00	1			43			48											
10/08/20 0:00	1			38			43											
10/08/20 1:00	1			37			39											
10/08/20 2:00	1			37			37											
10/08/20 3:00	1			37			36											
10/08/20 4:00	1			37			36											
10/08/20 5:00	1			25			40											
10/08/20 6:00	1			13			44											
10/08/20 7:00	1			1			50											
10/08/20 8:00	1			0			53											
10/08/20 9:00	1			0			58											
10/08/20 10:00	1			0			62											
10/08/20 11:00	1			0			64											
10/08/20 12:00	1			0			65											
10/08/20 13:00	1			0			66											
10/08/20 14:00	1			0			66											
10/08/20 15:00	1			0			59											
10/08/20 16:00	1			0			52											
10/08/20 17:00	1			0			46											
10/08/20 18:00	1			0			47											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/08/20 19:00	1			0			57											
10/08/20 20:00	1			0			62											
10/08/20 21:00	1			0			70											
10/08/20 22:00	1			0			71											
10/08/20 23:00	1			0			68											
10/09/20 0:00	1			0			58											
10/09/20 1:00	1			0			46											
10/09/20 2:00	1			0			43											
10/09/20 3:00	1			0			42											
10/09/20 4:00	1			0			44											
10/09/20 5:00	1			0			47											
10/09/20 6:00	1			0			52											
10/09/20 7:00	1			0			55											
10/09/20 8:00	1			0			59											
10/09/20 9:00	1			0			62											
10/09/20 10:00	1			0			65											
10/09/20 11:00	1			0			68											
10/09/20 12:00	1			0			70											
10/09/20 13:00	1			0			69											
10/09/20 14:00	1			0			69											
10/09/20 15:00	1			0			65											
10/09/20 16:00	1			0			62											
10/09/20 17:00	1			0			59											
10/09/20 18:00	1			0			60											
10/09/20 19:00	1			0			61											
10/09/20 20:00	1			0			58											
10/09/20 21:00	1			0			54											
10/09/20 22:00	1			0			52											
10/09/20 23:00	1			0			50											
10/10/20 0:00	1			0			46											
10/10/20 1:00	1			0			41											
10/10/20 2:00	1			0			39											
10/10/20 3:00	1			0			37											
10/10/20 4:00	1			0			36											
10/10/20 5:00	1			0			38											
10/10/20 6:00	1			0			40											
10/10/20 7:00	1			0			45											
10/10/20 8:00	1			0			48											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/10/20 9:00	1			0			54											
10/10/20 10:00	1			0			60											
10/10/20 11:00	1			0			64											
10/10/20 12:00	1			0			65											
10/10/20 13:00	1			0			61											
10/10/20 14:00	1			0			39											
10/10/20 15:00	1			6			18											
10/10/20 16:00	1			18			0											
10/10/20 17:00	1			35			0											
10/10/20 18:00	1			45			0											
10/10/20 19:00	1			46			0											
10/10/20 20:00	1			46			0											
10/10/20 21:00	1			49			0											
10/10/20 22:00	1			53			0											
10/10/20 23:00	1			53			0											
10/11/20 0:00	1			50			0											
10/11/20 1:00	1			47			0											
10/11/20 2:00	1			42			0											
10/11/20 3:00	1			39			0											
10/11/20 4:00	1			39			0											
10/11/20 5:00	1			43			0											
10/11/20 6:00	1			48			0											
10/11/20 7:00	1			51			0											
10/11/20 8:00	1			51			0											
10/11/20 9:00	1			51			0											
10/11/20 10:00	1			52			0											
10/11/20 11:00	1			50			0											
10/11/20 12:00	1			46			0											
10/11/20 13:00	1			47			0											
10/11/20 14:00	1			57			0											
10/11/20 15:00	1			65			0											
10/11/20 16:00	1			64			0											
10/11/20 17:00	1			55			0											
10/11/20 18:00	1			46			0											
10/11/20 19:00	1			41			0											
10/11/20 20:00	1			43			0											
10/11/20 21:00	1			49			0											
10/11/20 22:00	1			53			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/11/20 23:00	1			50			0											
10/12/20 0:00	1			45			0											
10/12/20 1:00	1			41			0											
10/12/20 2:00	1			39			0											
10/12/20 3:00	1			38			0											
10/12/20 4:00	1			40			0											
10/12/20 5:00	1			47			0											
10/12/20 6:00	1			55			0											
10/12/20 7:00	1			61			0											
10/12/20 8:00	1			62			0											
10/12/20 9:00	1			61			0											
10/12/20 10:00	1			60			0											
10/12/20 11:00	1			57			0											
10/12/20 12:00	1			56			0											
10/12/20 13:00	1			59			0											
10/12/20 14:00	1			67			0											
10/12/20 15:00	1			74			0											
10/12/20 16:00	1			68			0											
10/12/20 17:00	1			60			0											
10/12/20 18:00	1			51			0											
10/12/20 19:00	1			47			0											
10/12/20 20:00	1			47			0											
10/12/20 21:00	1			45			0											
10/12/20 22:00	1			49			0											
10/12/20 23:00	1			52			0											
10/13/20 0:00	1			56			0											
10/13/20 1:00	1			56			0											
10/13/20 2:00	1			56			0											
10/13/20 3:00	1			57			0											
10/13/20 4:00	1			57			0											
10/13/20 5:00	1			64			0											
10/13/20 6:00	1			71			0											
10/13/20 7:00	1			78			0											
10/13/20 8:00	1			68			11											
10/13/20 9:00	1			55			24											
10/13/20 10:00	1			49			44											
10/13/20 11:00	1			56			54											
10/13/20 12:00	1			66			62											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/13/20 13:00	1			69			63											
10/13/20 14:00	1			68			63											
10/13/20 15:00	1			67			63											
10/13/20 16:00	1			65			64											
10/13/20 17:00	1			64			64											
10/13/20 18:00	1			64			64											
10/13/20 19:00	1			61			61											
10/13/20 20:00	1			61			61											
10/13/20 21:00	1			59			59											
10/13/20 22:00	1			56			57											
10/13/20 23:00	1			48			51											
10/14/20 0:00	1			42			46											
10/14/20 1:00	1			38			42											
10/14/20 2:00	1			37			39											
10/14/20 3:00	1			37			37											
10/14/20 4:00	1			37			37											
10/14/20 5:00	1			39			40											
10/14/20 6:00	1			41			45											
10/14/20 7:00	1			42			49											
10/14/20 8:00	1			44			53											
10/14/20 9:00	1			48			55											
10/14/20 10:00	1			53			57											
10/14/20 11:00	1			58			59											
10/14/20 12:00	1			61			61											
10/14/20 13:00	1			64			64											
10/14/20 14:00	1			69			69											
10/14/20 15:00	1			73			73											
10/14/20 16:00	1			75			75											
10/14/20 17:00	1			74			74											
10/14/20 18:00	1			71			71											
10/14/20 19:00	1			64			65											
10/14/20 20:00	1			61			62											
10/14/20 21:00	1			56			57											
10/14/20 22:00	1			56			56											
10/14/20 23:00	1			49			52											
10/15/20 0:00	1			43			48											
10/15/20 1:00	1			39			44											
10/15/20 2:00	1			37			40											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/15/20 3:00	1			37			38											
10/15/20 4:00	1			37			38											
10/15/20 5:00	1			38			40											
10/15/20 6:00	1			42			45											
10/15/20 7:00	1			46			50											
10/15/20 8:00	1			40			60											
10/15/20 9:00	1			25			69											
10/15/20 10:00	1			8			75											
10/15/20 11:00	1			0			75											
10/15/20 12:00	1			0			74											
10/15/20 13:00	1			0			73											
10/15/20 14:00	1			0			71											
10/15/20 15:00	1			9			65											
10/15/20 16:00	1			33			65											
10/15/20 17:00	1			57			66											
10/15/20 18:00	1			70			70											
10/15/20 19:00	1			65			66											
10/15/20 20:00	1			63			63											
10/15/20 21:00	1			58			60											
10/15/20 22:00	1			53			57											
10/15/20 23:00	1			45			53											
10/16/20 0:00	1			40			49											
10/16/20 1:00	1			38			46											
10/16/20 2:00	1			37			42											
10/16/20 3:00	1			37			41											
10/16/20 4:00	1			38			42											
10/16/20 5:00	1			39			44											
10/16/20 6:00	1			40			48											
10/16/20 7:00	1			41			51											
10/16/20 8:00	1			43			54											
10/16/20 9:00	1			46			55											
10/16/20 10:00	1			49			56											
10/16/20 11:00	1			50			55											
10/16/20 12:00	1			54			56											
10/16/20 13:00	1			59			60											
10/16/20 14:00	1			66			66											
10/16/20 15:00	1			71			71											
10/16/20 16:00	1			74			74											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/16/20 17:00	1			75			75											
10/16/20 18:00	1			73			73											
10/16/20 19:00	1			70			71											
10/16/20 20:00	1			67			67											
10/16/20 21:00	1			63			63											
10/16/20 22:00	1			56			57											
10/16/20 23:00	1			49			52											
10/17/20 0:00	1			44			48											
10/17/20 1:00	1			40			43											
10/17/20 2:00	1			37			39											
10/17/20 3:00	1			37			36											
10/17/20 4:00	1			37			36											
10/17/20 5:00	1			38			38											
10/17/20 6:00	1			38			40											
10/17/20 7:00	1			40			44											
10/17/20 8:00	1			43			49											
10/17/20 9:00	1			47			53											
10/17/20 10:00	1			52			57											
10/17/20 11:00	1			54			58											
10/17/20 12:00	1			55			58											
10/17/20 13:00	1			58			59											
10/17/20 14:00	1			63			65											
10/17/20 15:00	1			66			70											
10/17/20 16:00	1			68			73											
10/17/20 17:00	1			66			70											
10/17/20 18:00	1			65			66											
10/17/20 19:00	1			66			66											
10/17/20 20:00	1			65			65											
10/17/20 21:00	1			64			64											
10/17/20 22:00	1			57			57											
10/17/20 23:00	1			49			52											
10/18/20 0:00	1			44			48											
10/18/20 1:00	1			40			44											
10/18/20 2:00	1			38			42											
10/18/20 3:00	1			37			40											
10/18/20 4:00	1			37			40											
10/18/20 5:00	1			37			41											
10/18/20 6:00	1			38			43											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/18/20 7:00	1			40			46											
10/18/20 8:00	1			42			50											
10/18/20 9:00	1			47			54											
10/18/20 10:00	1			54			57											
10/18/20 11:00	1			59			59											
10/18/20 12:00	1			61			60											
10/18/20 13:00	1			62			61											
10/18/20 14:00	1			64			63											
10/18/20 15:00	1			68			68											
10/18/20 16:00	1			68			68											
10/18/20 17:00	1			65			65											
10/18/20 18:00	1			58			59											
10/18/20 19:00	1			55			56											
10/18/20 20:00	1			56			57											
10/18/20 21:00	1			57			58											
10/18/20 22:00	1			54			56											
10/18/20 23:00	1			46			51											
10/19/20 0:00	1			40			47											
10/19/20 1:00	1			38			44											
10/19/20 2:00	1			37			40											
10/19/20 3:00	1			37			38											
10/19/20 4:00	1			38			38											
10/19/20 5:00	1			40			42											
10/19/20 6:00	1			42			47											
10/19/20 7:00	1			45			52											
10/19/20 8:00	1			48			55											
10/19/20 9:00	1			53			58											
10/19/20 10:00	1			57			59											
10/19/20 11:00	1			62			61											
10/19/20 12:00	1			64			63											
10/19/20 13:00	1			65			65											
10/19/20 14:00	1			67			67											
10/19/20 15:00	1			71			70											
10/19/20 16:00	1			73			72											
10/19/20 17:00	1			73			72											
10/19/20 18:00	1			69			68											
10/19/20 19:00	1			62			62											
10/19/20 20:00	1			60			60											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/19/20 21:00	1			56			57											
10/19/20 22:00	1			54			55											
10/19/20 23:00	1			46			49											
10/20/20 0:00	1			41			46											
10/20/20 1:00	1			38			43											
10/20/20 2:00	1			37			40											
10/20/20 3:00	1			37			37											
10/20/20 4:00	1			38			37											
10/20/20 5:00	1			39			40											
10/20/20 6:00	1			41			45											
10/20/20 7:00	1			42			49											
10/20/20 8:00	1			44			52											
10/20/20 9:00	1			48			55											
10/20/20 10:00	1			54			58											
10/20/20 11:00	1			61			61											
10/20/20 12:00	1			66			65											
10/20/20 13:00	1			70			70											
10/20/20 14:00	1			73			73											
10/20/20 15:00	1			76			75											
10/20/20 16:00	1			72			72											
10/20/20 17:00	1			67			67											
10/20/20 18:00	1			61			61											
10/20/20 19:00	1			61			61											
10/20/20 20:00	1			61			60											
10/20/20 21:00	1			58			58											
10/20/20 22:00	1			50			51											
10/20/20 23:00	1			43			46											
10/21/20 0:00	1			39			42											
10/21/20 1:00	1			37			39											
10/21/20 2:00	1			37			36											
10/21/20 3:00	1			37			36											
10/21/20 4:00	1			37			36											
10/21/20 5:00	1			41			41											
10/21/20 6:00	1			45			46											
10/21/20 7:00	1			46			47											
10/21/20 8:00	1			43			44											
10/21/20 9:00	1			40			42											
10/21/20 10:00	1			43			46											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/21/20 11:00	1			47			51											
10/21/20 12:00	1			52			55											
10/21/20 13:00	1			56			58											
10/21/20 14:00	1			60			61											
10/21/20 15:00	1			60			60											
10/21/20 16:00	1			57			58											
10/21/20 17:00	1			53			55											
10/21/20 18:00	1			50			52											
10/21/20 19:00	1			44			47											
10/21/20 20:00	1			40			42											
10/21/20 21:00	1			41			43											
10/21/20 22:00	1			42			46											
10/21/20 23:00	1			41			48											
10/22/20 0:00	1			38			43											
10/22/20 1:00	1			37			39											
10/22/20 2:00	1			37			36											
10/22/20 3:00	1			37			36											
10/22/20 4:00	1			37			37											
10/22/20 5:00	1			45			44											
10/22/20 6:00	1			53			52											
10/22/20 7:00	1			56			55											
10/22/20 8:00	1			52			53											
10/22/20 9:00	1			50			53											
10/22/20 10:00	1			53			56											
10/22/20 11:00	1			55			57											
10/22/20 12:00	1			57			57											
10/22/20 13:00	1			58			58											
10/22/20 14:00	1			60			60											
10/22/20 15:00	1			57			58											
10/22/20 16:00	1			58			58											
10/22/20 17:00	1			58			58											
10/22/20 18:00	1			59			59											
10/22/20 19:00	1			57			58											
10/22/20 20:00	1			54			56											
10/22/20 21:00	1			50			52											
10/22/20 22:00	1			45			45											
10/22/20 23:00	1			39			39											
10/23/20 0:00	1			37			36											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/23/20 1:00	1			37			36											
10/23/20 2:00	1			37			36											
10/23/20 3:00	1			37			36											
10/23/20 4:00	1			37			36											
10/23/20 5:00	1			38			38											
10/23/20 6:00	1			40			42											
10/23/20 7:00	1			42			46											
10/23/20 8:00	1			44			50											
10/23/20 9:00	1			45			53											
10/23/20 10:00	1			45			56											
10/23/20 11:00	1			47			57											
10/23/20 12:00	1			50			57											
10/23/20 13:00	1			56			58											
10/23/20 14:00	1			59			59											
10/23/20 15:00	1			62			60											
10/23/20 16:00	1			58			55											
10/23/20 17:00	1			59			56											
10/23/20 18:00	1			54			52											
10/23/20 19:00	1			50			52											
10/23/20 20:00	1			46			50											
10/23/20 21:00	1			45			52											
10/23/20 22:00	1			44			53											
10/23/20 23:00	1			28			49											
10/24/20 0:00	1			13			46											
10/24/20 1:00	1			1			41											
10/24/20 2:00	1			0			38											
10/24/20 3:00	1			0			36											
10/24/20 4:00	1			0			36											
10/24/20 5:00	1			0			37											
10/24/20 6:00	1			0			40											
10/24/20 7:00	1			0			44											
10/24/20 8:00	1			0			50											
10/24/20 9:00	1			0			54											
10/24/20 10:00	1			0			58											
10/24/20 11:00	1			0			59											
10/24/20 12:00	1			0			59											
10/24/20 13:00	1			0			61											
10/24/20 14:00	1			0			65											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/24/20 15:00	1			0			63											
10/24/20 16:00	1			0			54											
10/24/20 17:00	1			0			44											
10/24/20 18:00	1			0			42											
10/24/20 19:00	1			0			53											
10/24/20 20:00	1			0			61											
10/24/20 21:00	1			0			66											
10/24/20 22:00	1			0			60											
10/24/20 23:00	1			0			53											
10/25/20 0:00	1			0			47											
10/25/20 1:00	1			0			42											
10/25/20 2:00	1			0			39											
10/25/20 3:00	1			0			38											
10/25/20 4:00	1			0			39											
10/25/20 5:00	1			0			42											
10/25/20 6:00	1			0			46											
10/25/20 7:00	1			0			51											
10/25/20 8:00	1			0			55											
10/25/20 9:00	1			0			59											
10/25/20 10:00	1			0			63											
10/25/20 11:00	1			0			65											
10/25/20 12:00	1			0			66											
10/25/20 13:00	1			0			67											
10/25/20 14:00	1			0			69											
10/25/20 15:00	1			0			70											
10/25/20 16:00	1			0			67											
10/25/20 17:00	1			0			64											
10/25/20 18:00	1			0			61											
10/25/20 19:00	1			0			62											
10/25/20 20:00	1			0			59											
10/25/20 21:00	1			0			56											
10/25/20 22:00	1			0			52											
10/25/20 23:00	1			0			49											
10/26/20 0:00	1			0			43											
10/26/20 1:00	1			0			39											
10/26/20 2:00	1			0			38											
10/26/20 3:00	1			0			38											
10/26/20 4:00	1			0			41											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/26/20 5:00	1			0			46											
10/26/20 6:00	1			0			50											
10/26/20 7:00	1			0			56											
10/26/20 8:00	1			0			60											
10/26/20 9:00	1			0			65											
10/26/20 10:00	1			0			69											
10/26/20 11:00	1			0			72											
10/26/20 12:00	1			0			74											
10/26/20 13:00	1			0			75											
10/26/20 14:00	1			0			75											
10/26/20 15:00	1			0			74											
10/26/20 16:00	1			0			69											
10/26/20 17:00	1			0			66											
10/26/20 18:00	1			0			68											
10/26/20 19:00	1			0			73											
10/26/20 20:00	1			0			76											
10/26/20 21:00	1			0			71											
10/26/20 22:00	1			0			63											
10/26/20 23:00	1			0			54											
10/27/20 0:00	1			0			47											
10/27/20 1:00	1			0			42											
10/27/20 2:00	1			0			39											
10/27/20 3:00	1			0			37											
10/27/20 4:00	1			0			38											
10/27/20 5:00	1			0			45											
10/27/20 6:00	1			0			51											
10/27/20 7:00	1			0			57											
10/27/20 8:00	1			0			57											
10/27/20 9:00	1			0			60											
10/27/20 10:00	1			0			63											
10/27/20 11:00	1			0			65											
10/27/20 12:00	1			0			62											
10/27/20 13:00	1			0			58											
10/27/20 14:00	1			0			54											
10/27/20 15:00	1			0			55											
10/27/20 16:00	1			0			57											
10/27/20 17:00	1			0			59											
10/27/20 18:00	1			0			59											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/27/20 19:00	1			0			56											
10/27/20 20:00	1			0			56											
10/27/20 21:00	1			0			56											
10/27/20 22:00	1			0			55											
10/27/20 23:00	1			0			49											
10/28/20 0:00	1			0			43											
10/28/20 1:00	1			0			41											
10/28/20 2:00	1			0			40											
10/28/20 3:00	1			0			40											
10/28/20 4:00	1			0			43											
10/28/20 5:00	1			0			50											
10/28/20 6:00	1			0			56											
10/28/20 7:00	1			0			60											
10/28/20 8:00	1			0			59											
10/28/20 9:00	1			0			58											
10/28/20 10:00	1			0			57											
10/28/20 11:00	1			0			57											
10/28/20 12:00	1			0			58											
10/28/20 13:00	1			0			59											
10/28/20 14:00	1			0			60											
10/28/20 15:00	1			0			58											
10/28/20 16:00	1			0			56											
10/28/20 17:00	1			0			56											
10/28/20 18:00	1			0			57											
10/28/20 19:00	1			0			55											
10/28/20 20:00	1			0			52											
10/28/20 21:00	1			0			51											
10/28/20 22:00	1			0			52											
10/28/20 23:00	1			0			50											
10/29/20 0:00	1			0			45											
10/29/20 1:00	1			0			41											
10/29/20 2:00	1			0			39											
10/29/20 3:00	1			0			39											
10/29/20 4:00	1			0			41											
10/29/20 5:00	1			0			48											
10/29/20 6:00	1			0			53											
10/29/20 7:00	1			0			57											
10/29/20 8:00	1			0			60											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/29/20 9:00	1			0			63											
10/29/20 10:00	1			0			66											
10/29/20 11:00	1			0			66											
10/29/20 12:00	1			0			66											
10/29/20 13:00	1			0			64											
10/29/20 14:00	1			0			63											
10/29/20 15:00	1			0			60											
10/29/20 16:00	1			0			59											
10/29/20 17:00	1			0			58											
10/29/20 18:00	1			0			59											
10/29/20 19:00	1			0			61											
10/29/20 20:00	1			0			58											
10/29/20 21:00	1			0			50											
10/29/20 22:00	1			0			45											
10/29/20 23:00	1			0			43											
10/30/20 0:00	1			0			45											
10/30/20 1:00	1			0			43											
10/30/20 2:00	1			0			41											
10/30/20 3:00	1			0			40											
10/30/20 4:00	1			0			43											
10/30/20 5:00	1			0			49											
10/30/20 6:00	1			0			55											
10/30/20 7:00	1			0			58											
10/30/20 8:00	1			0			58											
10/30/20 9:00	1			0			59											
10/30/20 10:00	1			0			62											
10/30/20 11:00	1			0			65											
10/30/20 12:00	1			0			67											
10/30/20 13:00	1			0			70											
10/30/20 14:00	1			0			72											
10/30/20 15:00	1			0			69											
10/30/20 16:00	1			0			62											
10/30/20 17:00	1			0			54											
10/30/20 18:00	1			0			52											
10/30/20 19:00	1			0			55											
10/30/20 20:00	1			0			56											
10/30/20 21:00	1			0			56											
10/30/20 22:00	1			0			53											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/30/20 23:00	1			0			51											
10/31/20 0:00	1			0			49											
10/31/20 1:00	1			0			45											
10/31/20 2:00	1			0			42											
10/31/20 3:00	1			0			40											
10/31/20 4:00	1			0			41											
10/31/20 5:00	1			0			44											
10/31/20 6:00	1			0			49											
10/31/20 7:00	1			0			54											
10/31/20 8:00	1			0			59											
10/31/20 9:00	1			0			62											
10/31/20 10:00	1			0			64											
10/31/20 11:00	1			0			65											
10/31/20 12:00	1			0			61											
10/31/20 13:00	1			0			59											
10/31/20 14:00	1			0			62											
10/31/20 15:00	1			0			62											
10/31/20 16:00	1			0			56											
10/31/20 17:00	1			0			50											
10/31/20 18:00	1			0			49											
10/31/20 19:00	1			0			53											
10/31/20 20:00	1			0			50											
10/31/20 21:00	1			0			50											
10/31/20 22:00	1			0			51											
10/31/20 23:00	1			0			50											
11/01/20 0:00	1			0			44											
11/01/20 1:00	1			0			38											
11/01/20 2:00	1			0			36											
11/01/20 3:00	1			0			36											
11/01/20 4:00	1			0			36											
11/01/20 5:00	1			0			36											
11/01/20 6:00	1			0			37											
11/01/20 7:00	1			0			40											
11/01/20 8:00	1			0			44											
11/01/20 9:00	1			0			48											
11/01/20 10:00	1			0			52											
11/01/20 11:00	1			0			57											
11/01/20 12:00	1			0			62											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/01/20 13:00	1			0			67											
11/01/20 14:00	1			0			70											
11/01/20 15:00	1			0			73											
11/01/20 16:00	1			0			74											
11/01/20 17:00	1			0			68											
11/01/20 18:00	1			0			60											
11/01/20 19:00	1			0			51											
11/01/20 20:00	1			0			45											
11/01/20 21:00	1			0			47											
11/01/20 22:00	1			0			48											
11/01/20 23:00	1			0			48											
11/02/20 0:00	1			0			40											
11/02/20 1:00	1			0			35											
11/02/20 2:00	1			0			34											
11/02/20 3:00	1			0			35											
11/02/20 4:00	1			0			38											
11/02/20 5:00	1			0			42											
11/02/20 6:00	1			0			48											
11/02/20 7:00	1			0			53											
11/02/20 8:00	1			0			57											
11/02/20 9:00	1			0			58											
11/02/20 10:00	1			0			58											
11/02/20 11:00	1			0			61											
11/02/20 12:00	1			0			67											
11/02/20 13:00	1			0			73											
11/02/20 14:00	1			0			77											
11/02/20 15:00	1			0			77											
11/02/20 16:00	1			0			77											
11/02/20 17:00	1			0			77											
11/02/20 18:00	1			0			77											
11/02/20 19:00	1			0			75											
11/02/20 20:00	1			0			66											
11/02/20 21:00	1			0			62											
11/02/20 22:00	1			0			57											
11/02/20 23:00	1			0			54											
11/03/20 0:00	1			0			46											
11/03/20 1:00	1			0			40											
11/03/20 2:00	1			0			37											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/03/20 3:00	1			0			37											
11/03/20 4:00	1			0			37											
11/03/20 5:00	1			0			40											
11/03/20 6:00	1			0			46											
11/03/20 7:00	1			0			51											
11/03/20 8:00	1			0			57											
11/03/20 9:00	1			0			62											
11/03/20 10:00	1			0			68											
11/03/20 11:00	1			0			72											
11/03/20 12:00	1			0			72											
11/03/20 13:00	1			0			72											
11/03/20 14:00	1			0			72											
11/03/20 15:00	1			0			74											
11/03/20 16:00	1			0			75											
11/03/20 17:00	1			0			76											
11/03/20 18:00	1			0			73											
11/03/20 19:00	1			0			67											
11/03/20 20:00	1			0			63											
11/03/20 21:00	1			0			63											
11/03/20 22:00	1			0			64											
11/03/20 23:00	1			0			59											
11/04/20 0:00	1			0			51											
11/04/20 1:00	1			0			42											
11/04/20 2:00	1			0			38											
11/04/20 3:00	1			0			36											
11/04/20 4:00	1			0			36											
11/04/20 5:00	1			0			38											
11/04/20 6:00	1			0			39											
11/04/20 7:00	1			0			43											
11/04/20 8:00	1			0			45											
11/04/20 9:00	1			0			51											
11/04/20 10:00	1			0			55											
11/04/20 11:00	1			0			59											
11/04/20 12:00	1			0			59											
11/04/20 13:00	1			0			62											
11/04/20 14:00	1			0			65											
11/04/20 15:00	1			0			68											
11/04/20 16:00	1			0			66											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/04/20 17:00	1			0			62											
11/04/20 18:00	1			0			55											
11/04/20 19:00	1			0			51											
11/04/20 20:00	1			0			51											
11/04/20 21:00	1			0			54											
11/04/20 22:00	1			0			57											
11/04/20 23:00	1			0			56											
11/05/20 0:00	1			0			50											
11/05/20 1:00	1			0			44											
11/05/20 2:00	1			0			40											
11/05/20 3:00	1			0			40											
11/05/20 4:00	1			0			40											
11/05/20 5:00	1			0			39											
11/05/20 6:00	1			0			41											
11/05/20 7:00	1			0			45											
11/05/20 8:00	1			0			50											
11/05/20 9:00	1			0			53											
11/05/20 10:00	1			0			55											
11/05/20 11:00	1			0			57											
11/05/20 12:00	1			0			58											
11/05/20 13:00	1			0			61											
11/05/20 14:00	1			0			65											
11/05/20 15:00	1			0			68											
11/05/20 16:00	1			0			69											
11/05/20 17:00	1			0			64											
11/05/20 18:00	1			0			57											
11/05/20 19:00	1			0			51											
11/05/20 20:00	1			0			52											
11/05/20 21:00	1			0			57											
11/05/20 22:00	1			0			58											
11/05/20 23:00	1			0			55											
11/06/20 0:00	1			0			47											
11/06/20 1:00	1			0			41											
11/06/20 2:00	1			0			36											
11/06/20 3:00	1			0			36											
11/06/20 4:00	1			0			36											
11/06/20 5:00	1			0			37											
11/06/20 6:00	1			0			39											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/06/20 7:00	1			0			43											
11/06/20 8:00	1			0			47											
11/06/20 9:00	1			0			50											
11/06/20 10:00	1			0			52											
11/06/20 11:00	1			0			52											
11/06/20 12:00	1			0			53											
11/06/20 13:00	1			0			54											
11/06/20 14:00	1			0			56											
11/06/20 15:00	1			0			56											
11/06/20 16:00	1			0			52											
11/06/20 17:00	1			0			53											
11/06/20 18:00	1			0			49											
11/06/20 19:00	1			0			53											
11/06/20 20:00	1			0			52											
11/06/20 21:00	1			0			55											
11/06/20 22:00	1			0			54											
11/06/20 23:00	1			0			52											
11/07/20 0:00	1			0			49											
11/07/20 1:00	1			0			44											
11/07/20 2:00	1			0			40											
11/07/20 3:00	1			0			37											
11/07/20 4:00	1			0			36											
11/07/20 5:00	1			0			36											
11/07/20 6:00	1			0			36											
11/07/20 7:00	1			0			39											
11/07/20 8:00	1			0			44											
11/07/20 9:00	1			0			51											
11/07/20 10:00	1			0			56											
11/07/20 11:00	1			0			58											
11/07/20 12:00	1			0			56											
11/07/20 13:00	1			0			53											
11/07/20 14:00	1			0			51											
11/07/20 15:00	1			0			50											
11/07/20 16:00	1			0			48											
11/07/20 17:00	1			0			48											
11/07/20 18:00	1			0			49											
11/07/20 19:00	1			0			53											
11/07/20 20:00	1			0			54											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/07/20 21:00	1			0			54											
11/07/20 22:00	1			0			53											
11/07/20 23:00	1			0			50											
11/08/20 0:00	1			0			48											
11/08/20 1:00	1			0			44											
11/08/20 2:00	1			0			40											
11/08/20 3:00	1			0			38											
11/08/20 4:00	1			0			37											
11/08/20 5:00	1			0			38											
11/08/20 6:00	1			0			41											
11/08/20 7:00	1			0			45											
11/08/20 8:00	1			0			50											
11/08/20 9:00	1			0			47											
11/08/20 10:00	1			0			43											
11/08/20 11:00	1			0			39											
11/08/20 12:00	1			0			40											
11/08/20 13:00	1			0			42											
11/08/20 14:00	1			0			47											
11/08/20 15:00	1			0			53											
11/08/20 16:00	1			0			57											
11/08/20 17:00	1			0			57											
11/08/20 18:00	1			0			56											
11/08/20 19:00	1			0			56											
11/08/20 20:00	1			0			55											
11/08/20 21:00	1			0			54											
11/08/20 22:00	1			0			51											
11/08/20 23:00	1			0			49											
11/09/20 0:00	1			0			46											
11/09/20 1:00	1			0			43											
11/09/20 2:00	1			0			41											
11/09/20 3:00	1			0			42											
11/09/20 4:00	1			0			44											
11/09/20 5:00	1			0			47											
11/09/20 6:00	1			0			50											
11/09/20 7:00	1			0			54											
11/09/20 8:00	1			0			56											
11/09/20 9:00	1			0			59											
11/09/20 10:00	1			0			60											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/09/20 11:00	1			0			60											
11/09/20 12:00	1			0			60											
11/09/20 13:00	1			0			60											
11/09/20 14:00	1			0			60											
11/09/20 15:00	1			0			56											
11/09/20 16:00	1			0			53											
11/09/20 17:00	1			0			49											
11/09/20 18:00	1			0			48											
11/09/20 19:00	1			0			48											
11/09/20 20:00	1			0			49											
11/09/20 21:00	1			0			49											
11/09/20 22:00	1			0			50											
11/09/20 23:00	1			0			52											
11/10/20 0:00	1			0			50											
11/10/20 1:00	1			0			48											
11/10/20 2:00	1			0			44											
11/10/20 3:00	1			0			46											
11/10/20 4:00	1			0			47											
11/10/20 5:00	1			0			51											
11/10/20 6:00	1			0			54											
11/10/20 7:00	1			0			57											
11/10/20 8:00	1			0			60											
11/10/20 9:00	1			0			63											
11/10/20 10:00	1			0			61											
11/10/20 11:00	1			0			56											
11/10/20 12:00	1			0			52											
11/10/20 13:00	1			0			54											
11/10/20 14:00	1			0			53											
11/10/20 15:00	1			0			54											
11/10/20 16:00	1			0			53											
11/10/20 17:00	1			0			54											
11/10/20 18:00	1			0			53											
11/10/20 19:00	1			0			54											
11/10/20 20:00	1			0			54											
11/10/20 21:00	1			0			56											
11/10/20 22:00	1			0			56											
11/10/20 23:00	1			0			52											
11/11/20 0:00	1			0			45											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/11/20 1:00	1			0			38											
11/11/20 2:00	1			0			35											
11/11/20 3:00	1			0			34											
11/11/20 4:00	1			0			34											
11/11/20 5:00	1			0			37											
11/11/20 6:00	1			0			42											
11/11/20 7:00	1			0			48											
11/11/20 8:00	1			0			52											
11/11/20 9:00	1			0			56											
11/11/20 10:00	1			0			57											
11/11/20 11:00	1			0			55											
11/11/20 12:00	1			0			53											
11/11/20 13:00	1			0			51											
11/11/20 14:00	1			0			51											
11/11/20 15:00	1			0			55											
11/11/20 16:00	1			0			57											
11/11/20 17:00	1			0			56											
11/11/20 18:00	1			0			53											
11/11/20 19:00	1			0			49											
11/11/20 20:00	1			0			50											
11/11/20 21:00	1			0			51											
11/11/20 22:00	1			0			52											
11/11/20 23:00	1			0			47											
11/12/20 0:00	1			0			41											
11/12/20 1:00	1			0			36											
11/12/20 2:00	1			0			35											
11/12/20 3:00	1			0			34											
11/12/20 4:00	1			0			36											
11/12/20 5:00	1			0			39											
11/12/20 6:00	1			0			45											
11/12/20 7:00	1			0			52											
11/12/20 8:00	1			0			57											
11/12/20 9:00	1			0			59											
11/12/20 10:00	1			0			56											
11/12/20 11:00	1			0			50											
11/12/20 12:00	1			0			42											
11/12/20 13:00	1			0			38											
11/12/20 14:00	1			0			36											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/12/20 15:00	1			0			42											
11/12/20 16:00	1			0			48											
11/12/20 17:00	1			0			54											
11/12/20 18:00	1			0			54											
11/12/20 19:00	1			0			55											
11/12/20 20:00	1			0			56											
11/12/20 21:00	1			0			56											
11/12/20 22:00	1			0			53											
11/12/20 23:00	1			0			48											
11/13/20 0:00	1			0			42											
11/13/20 1:00	1			0			38											
11/13/20 2:00	1			0			35											
11/13/20 3:00	1			0			34											
11/13/20 4:00	1			0			34											
11/13/20 5:00	1			0			36											
11/13/20 6:00	1			0			42											
11/13/20 7:00	1			0			50											
11/13/20 8:00	1			0			56											
11/13/20 9:00	1			0			59											
11/13/20 10:00	1			0			60											
11/13/20 11:00	1			0			61											
11/13/20 12:00	1			0			61											
11/13/20 13:00	1			0			62											
11/13/20 14:00	1			0			61											
11/13/20 15:00	1			0			61											
11/13/20 16:00	1			0			58											
11/13/20 17:00	1			0			55											
11/13/20 18:00	1			0			52											
11/13/20 19:00	1			0			48											
11/13/20 20:00	1			0			49											
11/13/20 21:00	1			0			50											
11/13/20 22:00	1			0			52											
11/13/20 23:00	1			0			48											
11/14/20 0:00	1			0			44											
11/14/20 1:00	1			0			38											
11/14/20 2:00	1			0			36											
11/14/20 3:00	1			0			34											
11/14/20 4:00	1			0			34											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/14/20 5:00	1			0			34											
11/14/20 6:00	1			0			36											
11/14/20 7:00	1			0			41											
11/14/20 8:00	1			0			47											
11/14/20 9:00	1			0			54											
11/14/20 10:00	1			0			54											
11/14/20 11:00	1			0			50											
11/14/20 12:00	1			0			45											
11/14/20 13:00	1			0			48											
11/14/20 14:00	1			0			53											
11/14/20 15:00	1			0			56											
11/14/20 16:00	1			0			56											
11/14/20 17:00	1			0			55											
11/14/20 18:00	1			0			55											
11/14/20 19:00	1			0			53											
11/14/20 20:00	1			0			55											
11/14/20 21:00	1			0			56											
11/14/20 22:00	1			0			60											
11/14/20 23:00	1			0			57											
11/15/20 0:00	1			0			50											
11/15/20 1:00	1			0			40											
11/15/20 2:00	1			0			39											
11/15/20 3:00	1			0			42											
11/15/20 4:00	1			0			42											
11/15/20 5:00	1			0			41											
11/15/20 6:00	1			0			41											
11/15/20 7:00	1			0			44											
11/15/20 8:00	1			0			48											
11/15/20 9:00	1			0			50											
11/15/20 10:00	1			0			53											
11/15/20 11:00	1			0			55											
11/15/20 12:00	1			0			57											
11/15/20 13:00	1			0			58											
11/15/20 14:00	1			0			59											
11/15/20 15:00	1			0			60											
11/15/20 16:00	1			0			61											
11/15/20 17:00	1			0			60											
11/15/20 18:00	1			0			58											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/15/20 19:00	1			0			58											
11/15/20 20:00	1			0			59											
11/15/20 21:00	1			0			59											
11/15/20 22:00	1			0			54											
11/15/20 23:00	1			0			47											
11/16/20 0:00	1			0			41											
11/16/20 1:00	1			0			37											
11/16/20 2:00	1			0			35											
11/16/20 3:00	1			0			35											
11/16/20 4:00	1			0			35											
11/16/20 5:00	1			0			38											
11/16/20 6:00	1			0			45											
11/16/20 7:00	1			0			53											
11/16/20 8:00	1			0			59											
11/16/20 9:00	1			0			60											
11/16/20 10:00	1			0			59											
11/16/20 11:00	1			0			59											
11/16/20 12:00	1			0			59											
11/16/20 13:00	1			0			59											
11/16/20 14:00	1			0			59											
11/16/20 15:00	1			0			58											
11/16/20 16:00	1			0			54											
11/16/20 17:00	1			0			52											
11/16/20 18:00	1			0			51											
11/16/20 19:00	1			0			54											
11/16/20 20:00	1			0			56											
11/16/20 21:00	1			0			58											
11/16/20 22:00	1			0			54											
11/16/20 23:00	1			0			48											
11/17/20 0:00	1			0			41											
11/17/20 1:00	1			0			37											
11/17/20 2:00	1			0			36											
11/17/20 3:00	1			0			35											
11/17/20 4:00	1			0			35											
11/17/20 5:00	1			0			37											
11/17/20 6:00	1			0			40											
11/17/20 7:00	1			0			45											
11/17/20 8:00	1			0			50											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/17/20 9:00	1			0			55											
11/17/20 10:00	1			0			58											
11/17/20 11:00	1			0			59											
11/17/20 12:00	1			0			59											
11/17/20 13:00	1			0			59											
11/17/20 14:00	1			0			58											
11/17/20 15:00	1			0			57											
11/17/20 16:00	1			0			56											
11/17/20 17:00	1			0			55											
11/17/20 18:00	1			0			55											
11/17/20 19:00	1			0			53											
11/17/20 20:00	1			0			51											
11/17/20 21:00	1			0			49											
11/17/20 22:00	1			0			48											
11/17/20 23:00	1			0			44											
11/18/20 0:00	1			0			40											
11/18/20 1:00	1			0			36											
11/18/20 2:00	1			0			35											
11/18/20 3:00	1			0			34											
11/18/20 4:00	1			0			34											
11/18/20 5:00	1			0			36											
11/18/20 6:00	1			0			40											
11/18/20 7:00	1			0			46											
11/18/20 8:00	1			0			53											
11/18/20 9:00	1			0			57											
11/18/20 10:00	1			0			59											
11/18/20 11:00	1			0			59											
11/18/20 12:00	1			0			59											
11/18/20 13:00	1			0			58											
11/18/20 14:00	1			0			57											
11/18/20 15:00	1			0			55											
11/18/20 16:00	1			0			55											
11/18/20 17:00	1			0			55											
11/18/20 18:00	1			0			55											
11/18/20 19:00	1			0			54											
11/18/20 20:00	1			0			55											
11/18/20 21:00	1			0			52											
11/18/20 22:00	1			0			51											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/18/20 23:00	1			0			45											
11/19/20 0:00	1			0			41											
11/19/20 1:00	1			0			37											
11/19/20 2:00	1			0			35											
11/19/20 3:00	1			0			34											
11/19/20 4:00	1			0			34											
11/19/20 5:00	1			0			37											
11/19/20 6:00	1			0			42											
11/19/20 7:00	1			0			49											
11/19/20 8:00	1			0			54											
11/19/20 9:00	1			0			58											
11/19/20 10:00	1			0			58											
11/19/20 11:00	1			0			56											
11/19/20 12:00	1			0			54											
11/19/20 13:00	1			0			53											
11/19/20 14:00	1			0			54											
11/19/20 15:00	1			0			54											
11/19/20 16:00	1			0			53											
11/19/20 17:00	1			0			53											
11/19/20 18:00	1			0			55											
11/19/20 19:00	1			0			54											
11/19/20 20:00	1			0			52											
11/19/20 21:00	1			0			49											
11/19/20 22:00	1			0			49											
11/19/20 23:00	1			0			47											
11/20/20 0:00	1			0			43											
11/20/20 1:00	1			0			38											
11/20/20 2:00	1			0			35											
11/20/20 3:00	1			0			34											
11/20/20 4:00	1			0			36											
11/20/20 5:00	1			0			40											
11/20/20 6:00	1			0			48											
11/20/20 7:00	1			0			55											
11/20/20 8:00	1			0			61											
11/20/20 9:00	1			0			63											
11/20/20 10:00	1			0			64											
11/20/20 11:00	1			0			64											
11/20/20 12:00	1			0			60											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/20/20 13:00	1			0			56											
11/20/20 14:00	1			0			53											
11/20/20 15:00	1			0			52											
11/20/20 16:00	1			0			52											
11/20/20 17:00	1			0			55											
11/20/20 18:00	1			0			56											
11/20/20 19:00	1			0			58											
11/20/20 20:00	1			0			58											
11/20/20 21:00	1			0			58											
11/20/20 22:00	1			0			57											
11/20/20 23:00	1			0			53											
11/21/20 0:00	1			0			51											
11/21/20 1:00	1			0			49											
11/21/20 2:00	1			0			48											
11/21/20 3:00	1			0			46											
11/21/20 4:00	1			0			45											
11/21/20 5:00	1			0			45											
11/21/20 6:00	1			0			44											
11/21/20 7:00	1			0			46											
11/21/20 8:00	1			0			50											
11/21/20 9:00	1			0			54											
11/21/20 10:00	1			0			55											
11/21/20 11:00	1			0			55											
11/21/20 12:00	1			0			54											
11/21/20 13:00	1			0			52											
11/21/20 14:00	1			0			52											
11/21/20 15:00	1			0			53											
11/21/20 16:00	1			0			53											
11/21/20 17:00	1			0			52											
11/21/20 18:00	1			0			53											
11/21/20 19:00	1			0			54											
11/21/20 20:00	1			0			56											
11/21/20 21:00	1			0			57											
11/21/20 22:00	1			0			59											
11/21/20 23:00	1			0			57											
11/22/20 0:00	1			0			51											
11/22/20 1:00	1			0			43											
11/22/20 2:00	1			0			38											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/22/20 3:00	1			0			37											
11/22/20 4:00	1			0			37											
11/22/20 5:00	1			0			37											
11/22/20 6:00	1			0			39											
11/22/20 7:00	1			0			44											
11/22/20 8:00	1			0			51											
11/22/20 9:00	1			0			57											
11/22/20 10:00	1			0			60											
11/22/20 11:00	1			0			60											
11/22/20 12:00	1			0			59											
11/22/20 13:00	1			0			58											
11/22/20 14:00	1			0			57											
11/22/20 15:00	1			0			58											
11/22/20 16:00	1			0			61											
11/22/20 17:00	1			0			64											
11/22/20 18:00	1			0			65											
11/22/20 19:00	1			0			63											
11/22/20 20:00	1			0			61											
11/22/20 21:00	1			0			59											
11/22/20 22:00	1			0			56											
11/22/20 23:00	1			0			50											
11/23/20 0:00	1			0			43											
11/23/20 1:00	1			0			38											
11/23/20 2:00	1			0			36											
11/23/20 3:00	1			0			36											
11/23/20 4:00	1			0			36											
11/23/20 5:00	1			0			39											
11/23/20 6:00	1			0			45											
11/23/20 7:00	1			0			50											
11/23/20 8:00	1			0			54											
11/23/20 9:00	1			0			56											
11/23/20 10:00	1			0			57											
11/23/20 11:00	1			0			58											
11/23/20 12:00	1			0			58											
11/23/20 13:00	1			0			57											
11/23/20 14:00	1			0			57											
11/23/20 15:00	1			0			57											
11/23/20 16:00	1			0			57											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/23/20 17:00	1			0			56											
11/23/20 18:00	1			0			56											
11/23/20 19:00	1			0			55											
11/23/20 20:00	1			0			54											
11/23/20 21:00	1			0			52											
11/23/20 22:00	1			0			52											
11/23/20 23:00	1			0			49											
11/24/20 0:00	1			0			44											
11/24/20 1:00	1			0			39											
11/24/20 2:00	1			0			36											
11/24/20 3:00	1			0			36											
11/24/20 4:00	1			0			36											
11/24/20 5:00	1			0			39											
11/24/20 6:00	1			0			47											
11/24/20 7:00	1			0			54											
11/24/20 8:00	1			0			59											
11/24/20 9:00	1			0			58											
11/24/20 10:00	1			0			58											
11/24/20 11:00	1			0			57											
11/24/20 12:00	1			0			57											
11/24/20 13:00	1			0			57											
11/24/20 14:00	1			0			57											
11/24/20 15:00	1			0			56											
11/24/20 16:00	1			0			56											
11/24/20 17:00	1			0			57											
11/24/20 18:00	1			0			56											
11/24/20 19:00	1			0			54											
11/24/20 20:00	1			0			54											
11/24/20 21:00	1			0			54											
11/24/20 22:00	1			0			54											
11/24/20 23:00	1			0			50											
11/25/20 0:00	1			0			46											
11/25/20 1:00	1			0			40											
11/25/20 2:00	1			0			38											
11/25/20 3:00	1			0			38											
11/25/20 4:00	1			0			40											
11/25/20 5:00	1			0			43											
11/25/20 6:00	1			0			48											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/25/20 7:00	1			0			52											
11/25/20 8:00	1			0			55											
11/25/20 9:00	1			0			54											
11/25/20 10:00	1			0			56											
11/25/20 11:00	1			0			57											
11/25/20 12:00	1			0			57											
11/25/20 13:00	1			0			54											
11/25/20 14:00	1			0			53											
11/25/20 15:00	1			0			53											
11/25/20 16:00	1			0			54											
11/25/20 17:00	1			0			54											
11/25/20 18:00	1			0			53											
11/25/20 19:00	1			0			52											
11/25/20 20:00	1			0			53											
11/25/20 21:00	1			0			55											
11/25/20 22:00	1			0			55											
11/25/20 23:00	1			0			51											
11/26/20 0:00	1			0			33											
11/26/20 1:00	0			0			15											
11/26/20 2:00	0			0			1											
11/26/20 3:00	0			0			0											
11/26/20 4:00	0			0			0											
11/26/20 5:00	0			0			0											
11/26/20 6:00	0			0			0											
11/26/20 7:00	0			0			0											
11/26/20 8:00	0			0			0											
11/26/20 9:00	0			0			0											
11/26/20 10:00	0			0			0											
11/26/20 11:00	0			0			0											
11/26/20 12:00	0			0			0											
11/26/20 13:00	0			0			0											
11/26/20 14:00	0			0			0											
11/26/20 15:00	0			0			0											
11/26/20 16:00	0			0			0											
11/26/20 17:00	0			0			0											
11/26/20 18:00	0			0			0											
11/26/20 19:00	0			0			0											
11/26/20 20:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/26/20 21:00	0			0			0											
11/26/20 22:00	0			0			0											
11/26/20 23:00	0			0			0											
11/27/20 0:00	0			0			0											
11/27/20 1:00	0			0			0											
11/27/20 2:00	0			0			0											
11/27/20 3:00	0			0			0											
11/27/20 4:00	0			0			0											
11/27/20 5:00	0			0			0											
11/27/20 6:00	0			0			0											
11/27/20 7:00	0			0			0											
11/27/20 8:00	0			0			0											
11/27/20 9:00	0			0			0											
11/27/20 10:00	0			0			0											
11/27/20 11:00	0			0			0											
11/27/20 12:00	0			0			0											
11/27/20 13:00	0			0			0											
11/27/20 14:00	0			0			0											
11/27/20 15:00	0			0			0											
11/27/20 16:00	0			0			0											
11/27/20 17:00	0			0			0											
11/27/20 18:00	0			0			0											
11/27/20 19:00	0			0			0											
11/27/20 20:00	0			0			0											
11/27/20 21:00	0			0			0											
11/27/20 22:00	0			0			0											
11/27/20 23:00	0			0			0											
11/28/20 0:00	0			0			0											
11/28/20 1:00	0			0			0											
11/28/20 2:00	0			0			0											
11/28/20 3:00	0			0			0											
11/28/20 4:00	0			0			0											
11/28/20 5:00	0			0			0											
11/28/20 6:00	0			0			0											
11/28/20 7:00	0			0			0											
11/28/20 8:00	0			0			0											
11/28/20 9:00	0			0			0											
11/28/20 10:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/28/20 11:00	0			0			0											
11/28/20 12:00	0			0			0											
11/28/20 13:00	0			0			0											
11/28/20 14:00	0			0			0											
11/28/20 15:00	0			0			0											
11/28/20 16:00	0			0			0											
11/28/20 17:00	0			0			0											
11/28/20 18:00	0			0			0											
11/28/20 19:00	0			0			0											
11/28/20 20:00	0			0			0											
11/28/20 21:00	0			0			0											
11/28/20 22:00	0			0			0											
11/28/20 23:00	0			0			0											
11/29/20 0:00	0			0			0											
11/29/20 1:00	0			0			0											
11/29/20 2:00	0			0			0											
11/29/20 3:00	0			0			0											
11/29/20 4:00	0			0			0											
11/29/20 5:00	0			0			0											
11/29/20 6:00	0			0			0											
11/29/20 7:00	0			0			0											
11/29/20 8:00	0			0			0											
11/29/20 9:00	0			0			0											
11/29/20 10:00	0			0			0											
11/29/20 11:00	0			0			0											
11/29/20 12:00	0			0			0											
11/29/20 13:00	0			0			0											
11/29/20 14:00	0			0			0											
11/29/20 15:00	0			0			0											
11/29/20 16:00	0			0			0											
11/29/20 17:00	0			0			0											
11/29/20 18:00	0			0			0											
11/29/20 19:00	0			0			0											
11/29/20 20:00	0			0			0											
11/29/20 21:00	0			0			0											
11/29/20 22:00	0			0			0											
11/29/20 23:00	0			0			0											
11/30/20 0:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/30/20 1:00	0			0			0											
11/30/20 2:00	0			0			0											
11/30/20 3:00	0			0			0											
11/30/20 4:00	0			0			0											
11/30/20 5:00	0			0			0											
11/30/20 6:00	0			0			0											
11/30/20 7:00	0			0			0											
11/30/20 8:00	0			0			0											
11/30/20 9:00	0			0			0											
11/30/20 10:00	0			0			0											
11/30/20 11:00	0			0			0											
11/30/20 12:00	0			0			0											
11/30/20 13:00	0			0			0											
11/30/20 14:00	0			0			0											
11/30/20 15:00	0			0			0											
11/30/20 16:00	0			0			0											
11/30/20 17:00	0			0			0											
11/30/20 18:00	0			0			0											
11/30/20 19:00	0			0			0											
11/30/20 20:00	0			0			0											
11/30/20 21:00	0			0			0											
11/30/20 22:00	0			0			0											
11/30/20 23:00	0			0			0											
12/01/20 0:00	0			0			0											
12/01/20 1:00	0			0			0											
12/01/20 2:00	0			0			0											
12/01/20 3:00	0			0			0											
12/01/20 4:00	0			0			0											
12/01/20 5:00	0			0			0											
12/01/20 6:00	0			0			0											
12/01/20 7:00	0			0			0											
12/01/20 8:00	0			0			0											
12/01/20 9:00	0			0			0											
12/01/20 10:00	0			0			0											
12/01/20 11:00	0			0			0											
12/01/20 12:00	0			0			0											
12/01/20 13:00	0			0			0											
12/01/20 14:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/01/20 15:00	0			0			0											
12/01/20 16:00	0			0			0											
12/01/20 17:00	0			0			0											
12/01/20 18:00	0			0			0											
12/01/20 19:00	0			0			0											
12/01/20 20:00	0			0			0											
12/01/20 21:00	0			0			0											
12/01/20 22:00	0			0			0											
12/01/20 23:00	0			0			0											
12/02/20 0:00	0			0			0											
12/02/20 1:00	0			0			0											
12/02/20 2:00	0			0			0											
12/02/20 3:00	0			0			0											
12/02/20 4:00	0			0			0											
12/02/20 5:00	0			0			0											
12/02/20 6:00	0			0			0											
12/02/20 7:00	0			0			0											
12/02/20 8:00	0			0			0											
12/02/20 9:00	0			0			0											
12/02/20 10:00	0			0			0											
12/02/20 11:00	0			0			0											
12/02/20 12:00	0			0			0											
12/02/20 13:00	0			0			0											
12/02/20 14:00	0			0			0											
12/02/20 15:00	0			0			0											
12/02/20 16:00	0			0			0											
12/02/20 17:00	0			0			0											
12/02/20 18:00	0			0			0											
12/02/20 19:00	0			0			0											
12/02/20 20:00	0			0			0											
12/02/20 21:00	0			0			0											
12/02/20 22:00	0			0			0											
12/02/20 23:00	0			0			0											
12/03/20 0:00	0			0			0											
12/03/20 1:00	0			0			0											
12/03/20 2:00	0			0			0											
12/03/20 3:00	0			0			0											
12/03/20 4:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/03/20 5:00	0			0			0											
12/03/20 6:00	0			0			0											
12/03/20 7:00	0			0			0											
12/03/20 8:00	0			0			0											
12/03/20 9:00	0			0			0											
12/03/20 10:00	0			0			0											
12/03/20 11:00	0			0			0											
12/03/20 12:00	0			0			0											
12/03/20 13:00	0			0			0											
12/03/20 14:00	0			0			0											
12/03/20 15:00	0			0			0											
12/03/20 16:00	0			0			0											
12/03/20 17:00	0			0			0											
12/03/20 18:00	0			0			0											
12/03/20 19:00	0			0			0											
12/03/20 20:00	0			0			0											
12/03/20 21:00	0			0			0											
12/03/20 22:00	0			0			0											
12/03/20 23:00	0			0			0											
12/04/20 0:00	0			0			0											
12/04/20 1:00	0			0			0											
12/04/20 2:00	0			0			0											
12/04/20 3:00	0			0			0											
12/04/20 4:00	0			0			0											
12/04/20 5:00	0			0			0											
12/04/20 6:00	0			0			0											
12/04/20 7:00	0			0			0											
12/04/20 8:00	0			0			0											
12/04/20 9:00	0			0			0											
12/04/20 10:00	0			0			0											
12/04/20 11:00	0			0			0											
12/04/20 12:00	0			0			0											
12/04/20 13:00	0			0			0											
12/04/20 14:00	0			0			0											
12/04/20 15:00	0			0			0											
12/04/20 16:00	0			0			0											
12/04/20 17:00	0			0			0											
12/04/20 18:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/04/20 19:00	0			0			0											
12/04/20 20:00	0			0			0											
12/04/20 21:00	0			0			0											
12/04/20 22:00	0			0			0											
12/04/20 23:00	0			0			0											
12/05/20 0:00	0			0			0											
12/05/20 1:00	0			0			0											
12/05/20 2:00	0			0			0											
12/05/20 3:00	0			0			0											
12/05/20 4:00	0			0			0											
12/05/20 5:00	0			0			0											
12/05/20 6:00	0			0			0											
12/05/20 7:00	0			0			0											
12/05/20 8:00	0			0			0											
12/05/20 9:00	0			0			0											
12/05/20 10:00	0			0			0											
12/05/20 11:00	0			0			0											
12/05/20 12:00	0			0			0											
12/05/20 13:00	0			0			0											
12/05/20 14:00	0			0			0											
12/05/20 15:00	0			0			0											
12/05/20 16:00	0			0			0											
12/05/20 17:00	0			0			0											
12/05/20 18:00	0			0			0											
12/05/20 19:00	0			0			0											
12/05/20 20:00	0			0			0											
12/05/20 21:00	0			0			0											
12/05/20 22:00	0			0			0											
12/05/20 23:00	0			0			0											
12/06/20 0:00	0			0			0											
12/06/20 1:00	0			0			0											
12/06/20 2:00	0			0			0											
12/06/20 3:00	0			0			0											
12/06/20 4:00	0			0			0											
12/06/20 5:00	0			0			0											
12/06/20 6:00	0			0			0											
12/06/20 7:00	0			0			0											
12/06/20 8:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/06/20 9:00	0			0			0											
12/06/20 10:00	0			0			0											
12/06/20 11:00	0			0			0											
12/06/20 12:00	0			0			0											
12/06/20 13:00	0			0			0											
12/06/20 14:00	0			0			0											
12/06/20 15:00	0			0			0											
12/06/20 16:00	0			0			0											
12/06/20 17:00	0			0			0											
12/06/20 18:00	0			0			0											
12/06/20 19:00	0			0			0											
12/06/20 20:00	0			0			0											
12/06/20 21:00	0			0			0											
12/06/20 22:00	0			0			0											
12/06/20 23:00	0			0			0											
12/07/20 0:00	0			0			0											
12/07/20 1:00	0			0			0											
12/07/20 2:00	0			0			0											
12/07/20 3:00	0			0			0											
12/07/20 4:00	0			0			0											
12/07/20 5:00	0			0			0											
12/07/20 6:00	0			0			0											
12/07/20 7:00	0			0			0											
12/07/20 8:00	0			0			0											
12/07/20 9:00	0			0			0											
12/07/20 10:00	0			0			0											
12/07/20 11:00	0			0			0											
12/07/20 12:00	0			0			0											
12/07/20 13:00	0			0			0											
12/07/20 14:00	0			0			0											
12/07/20 15:00	0			0			0											
12/07/20 16:00	0			0			0											
12/07/20 17:00	0			0			0											
12/07/20 18:00	0			0			0											
12/07/20 19:00	0			0			0											
12/07/20 20:00	0			0			0											
12/07/20 21:00	0			0			0											
12/07/20 22:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/07/20 23:00	0			0			0											
12/08/20 0:00	0			0			0											
12/08/20 1:00	0			0			0											
12/08/20 2:00	0			0			0											
12/08/20 3:00	0			0			0											
12/08/20 4:00	0			0			0											
12/08/20 5:00	0			0			0											
12/08/20 6:00	0			0			0											
12/08/20 7:00	0			0			0											
12/08/20 8:00	0			0			0											
12/08/20 9:00	0			0			0											
12/08/20 10:00	0			0			0											
12/08/20 11:00	0			0			0											
12/08/20 12:00	0			0			0											
12/08/20 13:00	0			0			0											
12/08/20 14:00	0			0			0											
12/08/20 15:00	0			0			0											
12/08/20 16:00	0			0			0											
12/08/20 17:00	0			0			0											
12/08/20 18:00	0			0			0											
12/08/20 19:00	0			0			0											
12/08/20 20:00	0			0			0											
12/08/20 21:00	0			0			0											
12/08/20 22:00	0			0			0											
12/08/20 23:00	0			0			0											
12/09/20 0:00	0			0			0											
12/09/20 1:00	0			0			0											
12/09/20 2:00	0			0			0											
12/09/20 3:00	0			0			0											
12/09/20 4:00	0			0			0											
12/09/20 5:00	0			0			0											
12/09/20 6:00	0			0			0											
12/09/20 7:00	0			0			0											
12/09/20 8:00	0			0			0											
12/09/20 9:00	0			0			0											
12/09/20 10:00	0			0			0											
12/09/20 11:00	0			0			0											
12/09/20 12:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/09/20 13:00	0			0			0											
12/09/20 14:00	0			0			0											
12/09/20 15:00	0			0			0											
12/09/20 16:00	0			0			0											
12/09/20 17:00	0			0			0											
12/09/20 18:00	0			0			0											
12/09/20 19:00	0			0			0											
12/09/20 20:00	0			0			0											
12/09/20 21:00	0			0			0											
12/09/20 22:00	0			0			0											
12/09/20 23:00	0			0			0											
12/10/20 0:00	0			0			0											
12/10/20 1:00	0			0			0											
12/10/20 2:00	0			0			0											
12/10/20 3:00	0			0			0											
12/10/20 4:00	0			0			0											
12/10/20 5:00	0			0			0											
12/10/20 6:00	0			0			0											
12/10/20 7:00	0			0			0											
12/10/20 8:00	0			0			0											
12/10/20 9:00	0			0			0											
12/10/20 10:00	0			0			0											
12/10/20 11:00	0			0			0											
12/10/20 12:00	0			0			0											
12/10/20 13:00	0			0			0											
12/10/20 14:00	0			0			0											
12/10/20 15:00	0			0			0											
12/10/20 16:00	0			0			0											
12/10/20 17:00	0			0			0											
12/10/20 18:00	0			0			0											
12/10/20 19:00	0			0			0											
12/10/20 20:00	0			0			0											
12/10/20 21:00	0			0			0											
12/10/20 22:00	0			0			0											
12/10/20 23:00	0			0			0											
12/11/20 0:00	0			0			0											
12/11/20 1:00	0			0			0											
12/11/20 2:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/11/20 3:00	0			0			0											
12/11/20 4:00	0			0			0											
12/11/20 5:00	0			0			0											
12/11/20 6:00	0			0			0											
12/11/20 7:00	0			0			0											
12/11/20 8:00	0			0			0											
12/11/20 9:00	0			0			0											
12/11/20 10:00	0			0			0											
12/11/20 11:00	0			0			0											
12/11/20 12:00	0			0			0											
12/11/20 13:00	0			0			0											
12/11/20 14:00	0			0			0											
12/11/20 15:00	0			0			0											
12/11/20 16:00	0			0			0											
12/11/20 17:00	0			0			0											
12/11/20 18:00	0			0			0											
12/11/20 19:00	0			0			0											
12/11/20 20:00	0			0			0											
12/11/20 21:00	0			0			0											
12/11/20 22:00	0			0			0											
12/11/20 23:00	0			0			0											
12/12/20 0:00	0			0			0											
12/12/20 1:00	0			0			0											
12/12/20 2:00	0			0			0											
12/12/20 3:00	0			0			0											
12/12/20 4:00	0			0			0											
12/12/20 5:00	0			0			0											
12/12/20 6:00	0			0			0											
12/12/20 7:00	0			0			0											
12/12/20 8:00	0			0			0											
12/12/20 9:00	0			0			0											
12/12/20 10:00	0			0			0											
12/12/20 11:00	0			0			0											
12/12/20 12:00	0			0			0											
12/12/20 13:00	0			0			0											
12/12/20 14:00	0			0			0											
12/12/20 15:00	0			0			0											
12/12/20 16:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/12/20 17:00	0			0			0											
12/12/20 18:00	0			0			0											
12/12/20 19:00	0			0			0											
12/12/20 20:00	0			0			0											
12/12/20 21:00	0			0			0											
12/12/20 22:00	0			0			0											
12/12/20 23:00	0			0			0											
12/13/20 0:00	0			0			0											
12/13/20 1:00	0			0			0											
12/13/20 2:00	0			0			0											
12/13/20 3:00	0			0			0											
12/13/20 4:00	0			0			0											
12/13/20 5:00	0			0			0											
12/13/20 6:00	0			0			0											
12/13/20 7:00	0			0			0											
12/13/20 8:00	0			0			0											
12/13/20 9:00	0			0			0											
12/13/20 10:00	0			0			0											
12/13/20 11:00	0			0			0											
12/13/20 12:00	0			0			0											
12/13/20 13:00	0			0			0											
12/13/20 14:00	0			0			0											
12/13/20 15:00	0			0			0											
12/13/20 16:00	0			0			0											
12/13/20 17:00	0			0			0											
12/13/20 18:00	0			0			0											
12/13/20 19:00	0			0			0											
12/13/20 20:00	0			0			0											
12/13/20 21:00	0			0			0											
12/13/20 22:00	0			0			0											
12/13/20 23:00	0			0			0											
12/14/20 0:00	0			0			0											
12/14/20 1:00	0			0			0											
12/14/20 2:00	0			0			0											
12/14/20 3:00	0			0			0											
12/14/20 4:00	0			0			0											
12/14/20 5:00	0			0			0											
12/14/20 6:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/14/20 7:00	0			0			0											
12/14/20 8:00	0			0			0											
12/14/20 9:00	0			0			0											
12/14/20 10:00	0			0			0											
12/14/20 11:00	0			0			0											
12/14/20 12:00	0			0			0											
12/14/20 13:00	0			0			0											
12/14/20 14:00	0			0			0											
12/14/20 15:00	0			0			0											
12/14/20 16:00	0			0			0											
12/14/20 17:00	0			0			0											
12/14/20 18:00	0			0			0											
12/14/20 19:00	0			0			0											
12/14/20 20:00	0			0			0											
12/14/20 21:00	0			0			0											
12/14/20 22:00	0			0			0											
12/14/20 23:00	0			0			0											
12/15/20 0:00	0			0			0											
12/15/20 1:00	0			0			0											
12/15/20 2:00	0			0			0											
12/15/20 3:00	0			0			0											
12/15/20 4:00	0			0			0											
12/15/20 5:00	0			0			0											
12/15/20 6:00	0			0			0											
12/15/20 7:00	0			0			0											
12/15/20 8:00	0			0			0											
12/15/20 9:00	0			0			0											
12/15/20 10:00	0			0			0											
12/15/20 11:00	0			0			0											
12/15/20 12:00	0			0			0											
12/15/20 13:00	0			0			0											
12/15/20 14:00	0			0			0											
12/15/20 15:00	0			0			0											
12/15/20 16:00	0			0			0											
12/15/20 17:00	0			0			0											
12/15/20 18:00	0			0			0											
12/15/20 19:00	0			0			0											
12/15/20 20:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/15/20 21:00	0			0			0											
12/15/20 22:00	0			0			0											
12/15/20 23:00	0			0			0											
12/16/20 0:00	0			0			0											
12/16/20 1:00	0			0			0											
12/16/20 2:00	0			0			0											
12/16/20 3:00	0			0			0											
12/16/20 4:00	0			0			0											
12/16/20 5:00	0			0			0											
12/16/20 6:00	0			0			0											
12/16/20 7:00	0			0			0											
12/16/20 8:00	0			0			0											
12/16/20 9:00	0			0			0											
12/16/20 10:00	0			0			0											
12/16/20 11:00	0			0			0											
12/16/20 12:00	0			0			0											
12/16/20 13:00	0			0			0											
12/16/20 14:00	0			0			0											
12/16/20 15:00	0			0			0											
12/16/20 16:00	0			0			0											
12/16/20 17:00	0			0			0											
12/16/20 18:00	0			0			0											
12/16/20 19:00	0			0			0											
12/16/20 20:00	0			0			0											
12/16/20 21:00	0			0			0											
12/16/20 22:00	0			0			0											
12/16/20 23:00	0			0			0											
12/17/20 0:00	0			0			0											
12/17/20 1:00	0			0			0											
12/17/20 2:00	0			0			0											
12/17/20 3:00	0			0			0											
12/17/20 4:00	0			0			0											
12/17/20 5:00	0			0			0											
12/17/20 6:00	0			0			0											
12/17/20 7:00	0			0			0											
12/17/20 8:00	0			0			0											
12/17/20 9:00	0			0			0											
12/17/20 10:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/17/20 11:00	0			0			0											
12/17/20 12:00	0			0			0											
12/17/20 13:00	0			0			0											
12/17/20 14:00	0			0			0											
12/17/20 15:00	0			0			0											
12/17/20 16:00	0			0			0											
12/17/20 17:00	0			0			0											
12/17/20 18:00	0			0			0											
12/17/20 19:00	0			0			0											
12/17/20 20:00	0			0			0											
12/17/20 21:00	0			0			0											
12/17/20 22:00	0			0			0											
12/17/20 23:00	0			0			0											
12/18/20 0:00	0			0			0											
12/18/20 1:00	0			0			0											
12/18/20 2:00	0			0			0											
12/18/20 3:00	0			0			0											
12/18/20 4:00	0			0			0											
12/18/20 5:00	0			0			0											
12/18/20 6:00	0			0			0											
12/18/20 7:00	0			0			0											
12/18/20 8:00	0			0			0											
12/18/20 9:00	0			0			0											
12/18/20 10:00	0			0			0											
12/18/20 11:00	0			0			0											
12/18/20 12:00	0			0			0											
12/18/20 13:00	0			0			0											
12/18/20 14:00	0			0			0											
12/18/20 15:00	0			0			0											
12/18/20 16:00	0			0			0											
12/18/20 17:00	0			0			0											
12/18/20 18:00	0			0			0											
12/18/20 19:00	0			0			0											
12/18/20 20:00	0			0			0											
12/18/20 21:00	0			0			0											
12/18/20 22:00	0			0			0											
12/18/20 23:00	0			0			0											
12/19/20 0:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/19/20 1:00	0			0			0											
12/19/20 2:00	0			0			0											
12/19/20 3:00	0			0			0											
12/19/20 4:00	0			0			0											
12/19/20 5:00	0			0			0											
12/19/20 6:00	0			0			0											
12/19/20 7:00	0			0			0											
12/19/20 8:00	0			0			0											
12/19/20 9:00	0			0			0											
12/19/20 10:00	0			0			0											
12/19/20 11:00	0			0			0											
12/19/20 12:00	0			0			0											
12/19/20 13:00	0			0			0											
12/19/20 14:00	0			0			0											
12/19/20 15:00	0			0			0											
12/19/20 16:00	0			0			0											
12/19/20 17:00	0			0			0											
12/19/20 18:00	0			0			0											
12/19/20 19:00	0			0			0											
12/19/20 20:00	0			0			0											
12/19/20 21:00	0			0			0											
12/19/20 22:00	0			0			0											
12/19/20 23:00	0			0			0											
12/20/20 0:00	0			0			0											
12/20/20 1:00	0			0			0											
12/20/20 2:00	0			0			0											
12/20/20 3:00	0			0			0											
12/20/20 4:00	0			0			0											
12/20/20 5:00	0			0			0											
12/20/20 6:00	0			0			0											
12/20/20 7:00	0			0			0											
12/20/20 8:00	0			0			0											
12/20/20 9:00	0			0			0											
12/20/20 10:00	0			0			0											
12/20/20 11:00	0			0			0											
12/20/20 12:00	0			0			0											
12/20/20 13:00	0			0			0											
12/20/20 14:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/20/20 15:00	0			0			0											
12/20/20 16:00	0			0			0											
12/20/20 17:00	0			0			0											
12/20/20 18:00	0			0			0											
12/20/20 19:00	0			0			0											
12/20/20 20:00	0			0			0											
12/20/20 21:00	0			0			0											
12/20/20 22:00	0			0			0											
12/20/20 23:00	0			0			0											
12/21/20 0:00	0			0			0											
12/21/20 1:00	0			0			0											
12/21/20 2:00	0			0			0											
12/21/20 3:00	0			0			0											
12/21/20 4:00	0			0			0											
12/21/20 5:00	0			0			0											
12/21/20 6:00	0			0			0											
12/21/20 7:00	0			0			0											
12/21/20 8:00	0			0			0											
12/21/20 9:00	0			0			0											
12/21/20 10:00	0			0			0											
12/21/20 11:00	0			0			0											
12/21/20 12:00	0			0			0											
12/21/20 13:00	0			0			0											
12/21/20 14:00	0			0			0											
12/21/20 15:00	0			0			0											
12/21/20 16:00	0			0			0											
12/21/20 17:00	0			0			0											
12/21/20 18:00	0			0			0											
12/21/20 19:00	0			0			0											
12/21/20 20:00	0			0			0											
12/21/20 21:00	0			0			0											
12/21/20 22:00	0			0			0											
12/21/20 23:00	0			0			0											
12/22/20 0:00	0			0			0											
12/22/20 1:00	0			0			0											
12/22/20 2:00	0			0			0											
12/22/20 3:00	0			0			0											
12/22/20 4:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/22/20 5:00	0			0			0											
12/22/20 6:00	0			0			0											
12/22/20 7:00	0			0			0											
12/22/20 8:00	0			0			0											
12/22/20 9:00	0			0			0											
12/22/20 10:00	0			0			0											
12/22/20 11:00	0			0			0											
12/22/20 12:00	0			0			0											
12/22/20 13:00	0			0			0											
12/22/20 14:00	0			0			0											
12/22/20 15:00	1			0			3											
12/22/20 16:00	1			0			16											
12/22/20 17:00	1			5			28											
12/22/20 18:00	1			17			32											
12/22/20 19:00	1			30			18											
12/22/20 20:00	1			29			6											
12/22/20 21:00	0			17			0											
12/22/20 22:00	0			4			0											
12/22/20 23:00	0			0			0											
12/23/20 0:00	0			0			0											
12/23/20 1:00	0			0			0											
12/23/20 2:00	0			0			0											
12/23/20 3:00	0			0			0											
12/23/20 4:00	0			0			0											
12/23/20 5:00	0			0			0											
12/23/20 6:00	0			0			0											
12/23/20 7:00	0			0			0											
12/23/20 8:00	0			0			0											
12/23/20 9:00	0			0			0											
12/23/20 10:00	0			0			0											
12/23/20 11:00	0			0			0											
12/23/20 12:00	0			0			0											
12/23/20 13:00	0			0			0											
12/23/20 14:00	0			0			0											
12/23/20 15:00	0			0			0											
12/23/20 16:00	0			0			0											
12/23/20 17:00	0			0			0											
12/23/20 18:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/23/20 19:00	0			0			0											
12/23/20 20:00	0			0			0											
12/23/20 21:00	0			0			0											
12/23/20 22:00	0			0			0											
12/23/20 23:00	0			0			0											
12/24/20 0:00	0			0			0											
12/24/20 1:00	0			0			0											
12/24/20 2:00	0			0			0											
12/24/20 3:00	0			0			0											
12/24/20 4:00	0			0			0											
12/24/20 5:00	0			0			0											
12/24/20 6:00	0			0			0											
12/24/20 7:00	0			0			0											
12/24/20 8:00	0			0			0											
12/24/20 9:00	0			0			0											
12/24/20 10:00	0			0			0											
12/24/20 11:00	0			0			0											
12/24/20 12:00	0			0			0											
12/24/20 13:00	0			0			0											
12/24/20 14:00	0			0			0											
12/24/20 15:00	0			0			0											
12/24/20 16:00	0			0			0											
12/24/20 17:00	0			0			0											
12/24/20 18:00	0			0			0											
12/24/20 19:00	0			0			0											
12/24/20 20:00	0			0			0											
12/24/20 21:00	0			0			0											
12/24/20 22:00	0			0			0											
12/24/20 23:00	0			0			0											
12/25/20 0:00	0			0			0											
12/25/20 1:00	0			0			0											
12/25/20 2:00	0			0			0											
12/25/20 3:00	0			0			0											
12/25/20 4:00	0			0			0											
12/25/20 5:00	0			0			0											
12/25/20 6:00	0			0			0											
12/25/20 7:00	0			0			0											
12/25/20 8:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/25/20 9:00	0			0			0											
12/25/20 10:00	0			0			0											
12/25/20 11:00	0			0			0											
12/25/20 12:00	0			0			0											
12/25/20 13:00	0			0			0											
12/25/20 14:00	0			0			0											
12/25/20 15:00	0			0			0											
12/25/20 16:00	0			0			0											
12/25/20 17:00	0			0			0											
12/25/20 18:00	0			0			0											
12/25/20 19:00	0			0			0											
12/25/20 20:00	0			0			0											
12/25/20 21:00	0			0			0											
12/25/20 22:00	0			0			0											
12/25/20 23:00	0			0			0											
12/26/20 0:00	0			0			0											
12/26/20 1:00	0			0			0											
12/26/20 2:00	0			0			0											
12/26/20 3:00	0			0			0											
12/26/20 4:00	0			0			0											
12/26/20 5:00	0			0			0											
12/26/20 6:00	0			0			0											
12/26/20 7:00	0			0			0											
12/26/20 8:00	0			0			0											
12/26/20 9:00	0			0			0											
12/26/20 10:00	0			0			0											
12/26/20 11:00	0			0			0											
12/26/20 12:00	0			0			0											
12/26/20 13:00	0			0			0											
12/26/20 14:00	0			0			0											
12/26/20 15:00	0			0			0											
12/26/20 16:00	0			0			0											
12/26/20 17:00	0			0			0											
12/26/20 18:00	0			0			0											
12/26/20 19:00	0			0			0											
12/26/20 20:00	0			0			0											
12/26/20 21:00	0			0			0											
12/26/20 22:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/26/20 23:00	0			0			0											
12/27/20 0:00	0			0			0											
12/27/20 1:00	0			0			0											
12/27/20 2:00	0			0			0											
12/27/20 3:00	0			0			0											
12/27/20 4:00	0			0			0											
12/27/20 5:00	0			0			0											
12/27/20 6:00	0			0			0											
12/27/20 7:00	0			0			0											
12/27/20 8:00	0			0			0											
12/27/20 9:00	0			0			0											
12/27/20 10:00	0			0			0											
12/27/20 11:00	0			0			0											
12/27/20 12:00	0			0			0											
12/27/20 13:00	0			0			0											
12/27/20 14:00	0			0			0											
12/27/20 15:00	0			0			0											
12/27/20 16:00	0			0			0											
12/27/20 17:00	0			0			0											
12/27/20 18:00	0			0			0											
12/27/20 19:00	0			0			0											
12/27/20 20:00	0			0			0											
12/27/20 21:00	0			0			0											
12/27/20 22:00	0			0			0											
12/27/20 23:00	0			0			0											
12/28/20 0:00	0			0			0											
12/28/20 1:00	0			0			0											
12/28/20 2:00	0			0			0											
12/28/20 3:00	0			0			0											
12/28/20 4:00	0			0			0											
12/28/20 5:00	0			0			0											
12/28/20 6:00	0			0			0											
12/28/20 7:00	0			0			0											
12/28/20 8:00	0			0			0											
12/28/20 9:00	0			0			0											
12/28/20 10:00	0			0			0											
12/28/20 11:00	0			0			0											
12/28/20 12:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/28/20 13:00	0			0			0											
12/28/20 14:00	0			0			0											
12/28/20 15:00	0			0			0											
12/28/20 16:00	0			0			0											
12/28/20 17:00	0			0			0											
12/28/20 18:00	0			0			0											
12/28/20 19:00	0			0			0											
12/28/20 20:00	0			0			0											
12/28/20 21:00	0			0			0											
12/28/20 22:00	0			0			0											
12/28/20 23:00	0			0			0											
12/29/20 0:00	0			0			0											
12/29/20 1:00	0			0			0											
12/29/20 2:00	0			0			0											
12/29/20 3:00	0			0			0											
12/29/20 4:00	0			0			0											
12/29/20 5:00	0			0			0											
12/29/20 6:00	0			0			0											
12/29/20 7:00	0			0			0											
12/29/20 8:00	0			0			0											
12/29/20 9:00	0			0			0											
12/29/20 10:00	0			0			0											
12/29/20 11:00	0			0			0											
12/29/20 12:00	0			0			0											
12/29/20 13:00	0			0			0											
12/29/20 14:00	0			0			0											
12/29/20 15:00	0			0			0											
12/29/20 16:00	0			0			0											
12/29/20 17:00	0			0			0											
12/29/20 18:00	0			0			0											
12/29/20 19:00	0			0			0											
12/29/20 20:00	0			0			0											
12/29/20 21:00	0			0			0											
12/29/20 22:00	0			0			0											
12/29/20 23:00	0			0			0											
12/30/20 0:00	0			0			0											
12/30/20 1:00	0			0			0											
12/30/20 2:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/30/20 3:00	0			0			0											
12/30/20 4:00	0			0			0											
12/30/20 5:00	0			0			0											
12/30/20 6:00	0			0			0											
12/30/20 7:00	0			0			0											
12/30/20 8:00	0			0			0											
12/30/20 9:00	0			0			0											
12/30/20 10:00	0			0			0											
12/30/20 11:00	0			0			0											
12/30/20 12:00	0			0			0											
12/30/20 13:00	0			0			0											
12/30/20 14:00	0			0			0											
12/30/20 15:00	0			0			0											
12/30/20 16:00	0			0			0											
12/30/20 17:00	0			0			0											
12/30/20 18:00	0			0			0											
12/30/20 19:00	0			0			0											
12/30/20 20:00	0			0			0											
12/30/20 21:00	0			0			0											
12/30/20 22:00	0			0			0											
12/30/20 23:00	0			0			0											
12/31/20 0:00	0			0			0											
12/31/20 1:00	0			0			0											
12/31/20 2:00	0			0			0											
12/31/20 3:00	0			0			0											
12/31/20 4:00	0			0			0											
12/31/20 5:00	0			0			0											
12/31/20 6:00	0			0			0											
12/31/20 7:00	0			0			0											
12/31/20 8:00	0			0			0											
12/31/20 9:00	0			0			0											
12/31/20 10:00	0			0			0											
12/31/20 11:00	0			0			0											
12/31/20 12:00	0			0			0											
12/31/20 13:00	0			0			0											
12/31/20 14:00	0			0			0											
12/31/20 15:00	0			0			0											
12/31/20 16:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/31/20 17:00	0			0			0											
12/31/20 18:00	0			0			0											
12/31/20 19:00	0			0			0											
12/31/20 20:00	0			0			0											
12/31/20 21:00	0			0			0											
12/31/20 22:00	0			0			0											
12/31/20 23:00	0			0			0											

CEMs Log

Date/Time	Operator	Description
12/22/20	Administrator (VRL)	Performed cal error check on CT2 Stack
12/22/20	Administrator (VRL)	Performed cal error check on CT1 Stack
12/22/20	Administrator (BRB)	Spanned Gasses for HRSG and SCR on unit 2
12/22/20 8:28	Administrator (brb)	Spanned Gases gor HRSG and SCR on unit 1
12/12/20	Operator (DWN)	DAHS LOST POWER DURING THE PLANNED DCS UPGRADE. POWER OFF 12/10/20 14:19 POWER ON 12/11/20 13:27
12/08/20	Administrator (DWN)	UPDATED GCV VALUE FOR EACH UNIT FOR DECEMBER TO 104800
11/28/20	Administrator (JB)	CHANGED OUT UNIT2 LOW NOX/CO CYLINDER # EB0025109 NOX - 9.191PPM, CO 8.892PPM
11/28/20	Administrator (JB)	CHANGED OUT UNIT2 HIGH NOX/CO CYLINDER # EB0062569 NOX - 180.0PPM, CO 181.9PPM
11/22/20	Operator (LH)	CHANGED OUT HIGH NOX BOTTLE FOR UNIT-2 NEW VALUES - NO-179.0 / CO-181.1 ID#EB0019044
11/22/20	Operator (LH)	CHANGED 02 BOTTLE FOR UNIT-2 NEW VALUES 18.04 ID#EB0038989
11/22/20	Operator (BRB)	Spanned UNIT 2 INLET NOX low and high.
11/20/20	Operator (BRB)	Changed out Unit 2 SCR Inlet vacuum pump.
11/10/20	Operator (DWN)	UPDATED GCV VALUE FOR EACH UNIT TO 105,100 FOR NOVEMBER
11/01/20 5:56	Operator (DWN)	ADJUSTED CEMS CONFIGURATION UTILITY FOR DAILY SAVINGS TIME ADJUSTMENT -60 ENTERED
10/27/20 7:27	Operator (BRB)	Spanned Inlet Low and High NOX as well as Stack low NOX, found the daily cal sheet to be accurate to instrumentation, and the Span should help Calibrations to be more accurate.
10/23/20	Operator (RC)	CT-1 HIGH NOX BOTTLE CHANGE OUT - ID#EB0015622 NEW VALUES: NO-180.5 / CO-180.2
10/23/20	Administrator (VRL)	updated Nox bias numbers from RATA for unit 1 and 2. Also NH3 correction factors.
10/23/20 0:50	Operator (RC)	CHANGED UNIT 2 LO NOX/CO, BOTTLE # EB0050004, NEW VALUE NO 9.291, CO 8.882
10/23/20 0:49	Operator (RC)	CHANGED UNIT 1 O2, BOTTLE # EB0023835, NEW VALUE 18.16%
10/20/20 6:45	Operator (VRL)	CT2 SCR Nox failed cal. Verified correct lineup, initiated another calibration and analyzer passed.

Date/Time	Operator	Description
10/20/20 5:47	Operator (JB)	CHANGED OUT UNIT2 HIGH NOX/CO CYLINDER # EB0100806 NOX - 179.0PPM, CO 180.9PPM ENTERED CYLINDER CHANGED OUT INFORMATION AFTER UNIT CALIBRATION DUE TO KEYBOARD FAILURE
10/17/20	Administrator (LH)	CHANGED OUT UNIT 1 LOW NOX/CO BOTTLE. CYLINDER# EB0018110 NEW VALUE CO 9.05 NOX 8.991
10/17/20	Administrator (LH)	CHANGED OUT UNIT 2 O2 BOTTLE CYLINDER #EB0068264 NEW VALUE 18.04
10/14/20 6:08	Administrator (DWN)	UPDATED GCV VALUE FOR OCTOBER: 104,000
10/02/20	Administrator (VRL)	Performed CT2 CO low CGA @ 13:30
10/02/20	Administrator (VRL)	Performed CT2 O2 Linearity @ 10:35 start

Cylinder Gas Audit

01/05/2021

Page 1

Facility: ROSEVILLE ENERGY
Unit/Stack: CT1
Parameter/Scale: CO / High

Test Date: 10/01/2020
Test Result: **Pass**

Instrument Name: CT1_CODualRg_P_Instrume
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
10/01/2020	08:26	L	200	50.300	49.700	25.2 %
10/01/2020	08:31	M	200	112.800	114.000	56.4 %
10/01/2020	08:44	L	200	50.300	49.700	25.2 %
10/01/2020	08:49	M	200	112.800	114.000	56.4 %
10/01/2020	09:01	L	200	50.300	49.700	25.2 %
10/01/2020	09:06	M	200	112.800	113.900	56.4 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	50.300	49.700	Std	1.2
M	112.800	113.967	Std	1.0

Cylinder Gas Audit

01/05/2021

Page 2

Facility: ROSEVILLE ENERGY
Unit/Stack: CT1
Parameter/Scale: CO / Low

Test Date: 10/01/2020
Test Result: **Pass**

Instrument Name: CT1_CODualRg_P_Instrume
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
10/01/2020	10:38	L	10	2.400	2.300	24.0 %
10/01/2020	10:43	M	10	5.700	5.600	57.0 %
10/01/2020	10:50	L	10	2.400	2.200	24.0 %
10/01/2020	10:55	M	10	5.700	5.600	57.0 %
10/01/2020	11:02	L	10	2.400	2.200	24.0 %
10/01/2020	11:07	M	10	5.700	5.600	57.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	2.400	2.233	Std	6.9
M	5.700	5.600	Std	1.8

Cylinder Gas Audit

01/05/2021

Page 3

Facility: ROSEVILLE ENERGY
Unit/Stack: CT2
Parameter/Scale: CO / High

Test Date: 10/01/2020
Test Result: **Pass**

Instrument Name: CT2_CODualRg_P_Instrume
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
10/01/2020	11:38	L	200	49.400	49.900	24.7 %
10/01/2020	11:43	M	200	112.700	115.800	56.4 %
10/01/2020	11:55	L	200	49.400	50.000	24.7 %
10/01/2020	12:00	M	200	112.700	116.000	56.4 %
10/01/2020	12:12	L	200	49.400	49.700	24.7 %
10/01/2020	12:17	M	200	112.700	115.700	56.4 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	49.400	49.867	Std	0.9
M	112.700	115.833	Std	2.8

Cylinder Gas Audit

01/05/2021

Page 4

Facility: ROSEVILLE ENERGY
Unit/Stack: CT2
Parameter/Scale: CO / Low

Test Date: 10/02/2020
Test Result: **Pass**

Instrument Name: CT2_CODualRg_P_Instrume
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
10/02/2020	12:30	L	10	2.400	2.300	24.0 %
10/02/2020	12:34	M	10	5.700	5.700	57.0 %
10/02/2020	12:42	L	10	2.400	2.300	24.0 %
10/02/2020	12:47	M	10	5.700	5.700	57.0 %
10/02/2020	12:54	L	10	2.400	2.300	24.0 %
10/02/2020	12:59	M	10	5.700	5.600	57.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	2.400	2.300	Std	4.2
M	5.700	5.667	Std	0.6

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/01/2020 00:00	3,313.6	0.0	3,313.6	104,000.0	344.6	0.41	0.2	0.7
10/01/2020 01:00	2,937.5	0.0	2,937.5	104,000.0	305.5	0.37	0.2	0.6
10/01/2020 02:00	2,879.7	0.0	2,879.7	104,000.0	299.5	0.36	0.2	0.6
10/01/2020 03:00	2,869.1	0.0	2,869.1	104,000.0	298.4	0.36	0.2	0.6
10/01/2020 04:00	2,868.7	0.0	2,868.7	104,000.0	298.3	0.36	0.2	0.6
10/01/2020 05:00	2,866.6	0.0	2,866.6	104,000.0	298.1	0.36	0.2	0.6
10/01/2020 06:00	2,877.0	0.0	2,877.0	104,000.0	299.2	0.36	0.2	0.6
10/01/2020 07:00	3,052.7	0.0	3,052.7	104,000.0	317.5	0.38	0.2	0.6
10/01/2020 08:00	3,345.7	0.0	3,345.7	104,000.0	348.0	0.42	0.2	0.7
10/01/2020 09:00	3,744.7	0.0	3,744.7	104,000.0	389.4	0.47	0.2	0.8
10/01/2020 10:00	4,120.9	415.5	4,494.9	104,000.0	467.5	0.56	0.3	0.9
10/01/2020 11:00	4,095.7	1,235.5	5,331.2	104,000.0	554.4	0.67	0.3	1.1
10/01/2020 12:00	4,070.4	1,492.1	5,562.5	104,000.0	578.5	0.70	0.3	1.2
10/01/2020 13:00	4,053.1	1,757.1	5,810.2	104,000.0	604.3	0.73	0.4	1.2
10/01/2020 14:00	4,035.9	1,901.4	5,937.3	104,000.0	617.5	0.74	0.4	1.2
10/01/2020 15:00	4,020.6	1,381.4	5,402.0	104,000.0	561.8	0.67	0.3	1.1
10/01/2020 16:00	4,026.2	1,912.0	5,938.2	104,000.0	617.6	0.74	0.4	1.2
10/01/2020 17:00	4,028.7	1,707.0	5,735.7	104,000.0	596.5	0.71	0.4	1.2
10/01/2020 18:00	4,014.6	66.0	4,023.2	104,000.0	418.4	0.51	0.3	0.9
10/01/2020 19:00	4,058.0	308.5	4,314.1	104,000.0	448.7	0.54	0.3	0.9
10/01/2020 20:00	4,077.8	399.8	4,417.6	104,000.0	459.4	0.56	0.3	0.9
10/01/2020 21:00	4,080.0	738.2	4,818.2	104,000.0	501.1	0.60	0.3	1.0
10/01/2020 22:00	3,855.7	22.8	3,857.3	104,000.0	401.2	0.48	0.2	0.8
10/01/2020 23:00	3,518.2	0.0	3,518.2	104,000.0	365.9	0.44	0.2	0.7
Average/Sum#:	3,617.1	555.7	4,163.2	104,000.0	433.0	0.52	0.3	0.9
Minimum:	2,866.6	0.0	2,866.6	104,000.0	298.1	0.36	0.2	0.6
Maximum:	4,120.9	1,912.0	5,938.2	104,000.0	617.6	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/02/2020 00:00	3,104.4	0.0	3,104.4	104,000.0	322.9	0.39	0.2	0.6
10/02/2020 01:00	2,883.6	0.0	2,883.6	104,000.0	299.9	0.36	0.2	0.6
10/02/2020 02:00	2,876.1	0.0	2,876.1	104,000.0	299.1	0.36	0.2	0.6
10/02/2020 03:00	2,893.1	0.0	2,893.1	104,000.0	300.9	0.36	0.2	0.6
10/02/2020 04:00	2,972.8	0.0	2,972.8	104,000.0	309.2	0.37	0.2	0.6
10/02/2020 05:00	2,870.8	0.0	2,870.8	104,000.0	298.6	0.36	0.2	0.6
10/02/2020 06:00	2,866.9	0.0	2,866.9	104,000.0	298.2	0.36	0.2	0.6
10/02/2020 07:00	2,868.7	0.0	2,868.7	104,000.0	298.3	0.36	0.2	0.6
10/02/2020 08:00	2,877.4	0.0	2,877.4	104,000.0	299.2	0.36	0.2	0.6
10/02/2020 09:00	2,989.8	0.0	2,989.8	104,000.0	310.9	0.37	0.2	0.6
10/02/2020 10:00	3,171.2	0.0	3,171.2	104,000.0	329.8	0.40	0.2	0.7
10/02/2020 11:00	3,710.6	0.0	3,710.6	104,000.0	385.9	0.46	0.2	0.8
10/02/2020 12:00	4,047.3	161.9	4,173.6	104,000.0	434.1	0.52	0.3	0.9
10/02/2020 13:00	4,051.1	337.9	4,389.0	104,000.0	456.5	0.55	0.3	0.9
10/02/2020 14:00	4,041.2	705.7	4,746.9	104,000.0	493.7	0.59	0.3	1.0
10/02/2020 15:00	4,023.5	64.8	4,041.0	104,000.0	420.3	0.51	0.3	0.9
10/02/2020 16:00	4,023.4	1,264.0	5,287.4	104,000.0	549.9	0.66	0.3	1.1
10/02/2020 17:00	4,039.8	895.7	4,935.5	104,000.0	513.3	0.62	0.3	1.0
10/02/2020 18:00	3,606.7	75.2	3,615.7	104,000.0	376.0	0.46	0.2	0.8
10/02/2020 19:00	4,054.6	281.2	4,251.4	104,000.0	442.1	0.54	0.3	0.9
10/02/2020 20:00	3,329.9	0.0	3,329.9	104,000.0	346.3	0.42	0.2	0.7
10/02/2020 21:00	3,928.1	261.2	4,131.8	104,000.0	429.7	0.52	0.3	0.9
10/02/2020 22:00	3,829.6	0.0	3,829.6	104,000.0	398.3	0.48	0.2	0.8
10/02/2020 23:00	3,510.4	0.0	3,510.4	104,000.0	365.1	0.44	0.2	0.7
Average/Sum#:	3,440.5	168.7	3,597.0	104,000.0	374.1	0.45	0.2	0.8
Minimum:	2,866.9	0.0	2,866.9	104,000.0	298.2	0.36	0.2	0.6
Maximum:	4,054.6	1,264.0	5,287.4	104,000.0	549.9	0.66	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/03/2020 00:00	2,987.1	0.0	2,987.1	104,000.0	310.7	0.37	0.2	0.6
10/03/2020 01:00	2,862.1	0.0	2,862.1	104,000.0	297.7	0.36	0.2	0.6
10/03/2020 02:00	2,868.8	0.0	2,868.8	104,000.0	298.4	0.36	0.2	0.6
10/03/2020 03:00	2,872.8	0.0	2,872.8	104,000.0	298.8	0.36	0.2	0.6
10/03/2020 04:00	2,865.8	0.0	2,865.8	104,000.0	298.0	0.36	0.2	0.6
10/03/2020 05:00	2,866.4	0.0	2,866.4	104,000.0	298.1	0.36	0.2	0.6
10/03/2020 06:00	2,872.2	0.0	2,872.2	104,000.0	298.7	0.36	0.2	0.6
10/03/2020 07:00	2,871.2	0.0	2,871.2	104,000.0	298.6	0.36	0.2	0.6
10/03/2020 08:00	3,072.9	0.0	3,072.9	104,000.0	319.6	0.39	0.2	0.6
10/03/2020 09:00	3,467.7	0.0	3,467.7	104,000.0	360.6	0.43	0.2	0.7
10/03/2020 10:00	3,574.1	0.0	3,574.1	104,000.0	371.7	0.44	0.2	0.7
10/03/2020 11:00	3,731.1	0.0	3,731.1	104,000.0	388.0	0.47	0.2	0.8
10/03/2020 12:00	3,610.8	0.0	3,610.8	104,000.0	375.5	0.45	0.2	0.8
10/03/2020 13:00	4,041.8	270.0	4,292.9	104,000.0	446.5	0.54	0.3	0.9
10/03/2020 14:00	4,022.4	1,012.3	5,034.7	104,000.0	523.6	0.63	0.3	1.0
10/03/2020 15:00	4,008.4	113.5	4,034.5	104,000.0	419.6	0.51	0.3	0.9
10/03/2020 16:00	4,007.2	247.9	4,237.7	104,000.0	440.7	0.53	0.3	0.9
10/03/2020 17:00	3,933.0	5.6	3,933.2	104,000.0	409.1	0.49	0.2	0.8
10/03/2020 18:00	4,038.0	1,452.8	5,490.8	104,000.0	571.0	0.69	0.3	1.1
10/03/2020 19:00	4,058.1	693.6	4,696.2	104,000.0	488.4	0.60	0.3	1.0
10/03/2020 20:00	4,071.1	0.0	4,071.1	104,000.0	423.4	0.51	0.3	0.8
10/03/2020 21:00	4,058.2	318.0	4,322.1	104,000.0	449.5	0.55	0.3	0.9
10/03/2020 22:00	3,794.6	0.0	3,794.6	104,000.0	394.6	0.47	0.2	0.8
10/03/2020 23:00	3,522.8	0.0	3,522.8	104,000.0	366.4	0.44	0.2	0.7
Average/Sum#:	3,503.3	171.4	3,664.7	104,000.0	381.1	0.46	0.2	0.8
Minimum:	2,862.1	0.0	2,862.1	104,000.0	297.7	0.36	0.2	0.6
Maximum:	4,071.1	1,452.8	5,490.8	104,000.0	571.0	0.69	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/04/2020 00:00	2,944.8	0.0	2,944.8	104,000.0	306.3	0.37	0.2	0.6
10/04/2020 01:00	2,939.0	0.0	2,939.0	104,000.0	305.7	0.37	0.2	0.6
10/04/2020 02:00	2,867.3	0.0	2,867.3	104,000.0	298.2	0.36	0.2	0.6
10/04/2020 03:00	2,870.4	0.0	2,870.4	104,000.0	298.5	0.36	0.2	0.6
10/04/2020 04:00	2,908.4	0.0	2,908.4	104,000.0	302.5	0.36	0.2	0.6
10/04/2020 05:00	2,949.7	0.0	2,949.7	104,000.0	306.8	0.37	0.2	0.6
10/04/2020 06:00	2,895.6	0.0	2,895.6	104,000.0	301.1	0.36	0.2	0.6
10/04/2020 07:00	3,211.4	0.0	3,211.4	104,000.0	334.0	0.40	0.2	0.7
10/04/2020 08:00	3,408.0	0.0	3,408.0	104,000.0	354.4	0.43	0.2	0.7
10/04/2020 09:00	3,923.7	0.0	3,923.7	104,000.0	408.1	0.49	0.2	0.8
10/04/2020 10:00	4,109.5	127.1	4,221.3	104,000.0	439.0	0.53	0.3	0.9
10/04/2020 11:00	4,105.0	698.2	4,803.2	104,000.0	499.5	0.60	0.3	1.0
10/04/2020 12:00	4,072.7	1,408.3	5,481.0	104,000.0	570.0	0.68	0.3	1.1
10/04/2020 13:00	4,037.8	1,803.3	5,841.1	104,000.0	607.5	0.73	0.4	1.2
10/04/2020 14:00	4,033.1	1,846.7	5,879.8	104,000.0	611.5	0.73	0.4	1.2
10/04/2020 15:00	4,032.3	1,835.2	5,867.5	104,000.0	610.2	0.73	0.4	1.2
10/04/2020 16:00	4,038.2	1,611.5	5,649.7	104,000.0	587.6	0.70	0.4	1.2
10/04/2020 17:00	4,038.8	1,273.8	5,312.6	104,000.0	552.5	0.66	0.3	1.1
10/04/2020 18:00	4,040.0	1,049.8	5,016.3	104,000.0	521.7	0.63	0.3	1.1
10/04/2020 19:00	4,063.5	97.3	4,131.6	104,000.0	429.7	0.52	0.3	0.9
10/04/2020 20:00	4,001.1	0.0	4,001.1	104,000.0	416.1	0.50	0.2	0.8
10/04/2020 21:00	3,991.2	0.0	3,991.2	104,000.0	415.1	0.50	0.2	0.8
10/04/2020 22:00	3,483.6	0.0	3,483.6	104,000.0	362.3	0.43	0.2	0.7
10/04/2020 23:00	3,005.2	0.0	3,005.2	104,000.0	312.5	0.38	0.2	0.6
Average/Sum#:	3,582.1	489.6	4,066.8	104,000.0	423.0	0.51	0.3	0.8
Minimum:	2,867.3	0.0	2,867.3	104,000.0	298.2	0.36	0.2	0.6
Maximum:	4,109.5	1,846.7	5,879.8	104,000.0	611.5	0.73	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/05/2020 00:00	2,867.2	0.0	2,867.2	104,000.0	298.2	0.36	0.2	0.6
10/05/2020 01:00	2,865.7	0.0	2,865.7	104,000.0	298.0	0.36	0.2	0.6
10/05/2020 02:00	2,863.6	0.0	2,863.6	104,000.0	297.8	0.36	0.2	0.6
10/05/2020 03:00	2,876.3	0.0	2,876.3	104,000.0	299.1	0.36	0.2	0.6
10/05/2020 04:00	2,948.7	0.0	2,948.7	104,000.0	306.7	0.37	0.2	0.6
10/05/2020 05:00	3,160.4	0.0	3,160.4	104,000.0	328.7	0.39	0.2	0.7
10/05/2020 06:00	3,199.2	0.0	3,199.2	104,000.0	332.7	0.40	0.2	0.7
10/05/2020 07:00	3,340.1	0.0	3,340.1	104,000.0	347.4	0.42	0.2	0.7
10/05/2020 08:00	3,593.2	0.0	3,593.2	104,000.0	373.7	0.45	0.2	0.7
10/05/2020 09:00	4,161.6	18.0	4,163.4	104,000.0	433.0	0.52	0.3	0.9
10/05/2020 10:00	4,132.1	221.2	4,353.3	104,000.0	452.7	0.54	0.3	0.9
10/05/2020 11:00	4,098.0	865.7	4,963.7	104,000.0	516.2	0.62	0.3	1.0
10/05/2020 12:00	4,069.9	699.2	4,769.1	104,000.0	496.0	0.60	0.3	1.0
10/05/2020 13:00	4,040.0	1,723.9	5,763.9	104,000.0	599.4	0.72	0.4	1.2
10/05/2020 14:00	4,025.6	1,942.8	5,968.4	104,000.0	620.7	0.74	0.4	1.2
10/05/2020 15:00	4,012.6	1,941.1	5,953.7	104,000.0	619.2	0.74	0.4	1.2
10/05/2020 16:00	4,017.1	1,942.0	5,959.1	104,000.0	619.7	0.74	0.4	1.2
10/05/2020 17:00	4,035.0	1,613.8	5,648.8	104,000.0	587.5	0.71	0.4	1.2
10/05/2020 18:00	4,052.0	1,256.9	5,308.9	104,000.0	552.1	0.66	0.3	1.1
10/05/2020 19:00	4,073.5	1,068.5	5,142.0	104,000.0	534.8	0.64	0.3	1.1
10/05/2020 20:00	4,091.7	497.7	4,549.6	104,000.0	473.2	0.57	0.3	1.0
10/05/2020 21:00	4,087.8	0.0	4,087.8	104,000.0	425.1	0.51	0.3	0.9
10/05/2020 22:00	3,603.2	0.0	3,603.2	104,000.0	374.7	0.45	0.2	0.7
10/05/2020 23:00	3,186.8	0.0	3,186.8	104,000.0	331.4	0.40	0.2	0.7
Average/Sum#:	3,641.7	574.6	4,214.0	104,000.0	438.3	0.53	0.3	0.9
Minimum:	2,863.6	0.0	2,863.6	104,000.0	297.8	0.36	0.2	0.6
Maximum:	4,161.6	1,942.8	5,968.4	104,000.0	620.7	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/06/2020 00:00	2,861.1	0.0	2,861.1	104,000.0	297.6	0.36	0.2	0.6
10/06/2020 01:00	2,853.0	0.0	2,853.0	104,000.0	296.7	0.36	0.2	0.6
10/06/2020 02:00	2,859.2	0.0	2,859.2	104,000.0	297.4	0.36	0.2	0.6
10/06/2020 03:00	2,861.6	0.0	2,861.6	104,000.0	297.6	0.36	0.2	0.6
10/06/2020 04:00	2,859.4	0.0	2,859.4	104,000.0	297.4	0.36	0.2	0.6
10/06/2020 05:00	3,204.0	0.0	3,204.0	104,000.0	333.2	0.40	0.2	0.7
10/06/2020 06:00	3,239.6	0.0	3,239.6	104,000.0	336.9	0.40	0.2	0.7
10/06/2020 07:00	3,452.7	0.0	3,452.7	104,000.0	359.1	0.43	0.2	0.7
10/06/2020 08:00	3,733.1	0.0	3,733.1	104,000.0	388.2	0.47	0.2	0.8
10/06/2020 09:00	3,997.4	0.3	3,997.4	104,000.0	415.7	0.50	0.2	0.8
10/06/2020 10:00	3,910.7	241.3	4,152.0	104,000.0	431.8	0.52	0.3	0.9
10/06/2020 11:00	4,080.7	723.8	4,804.5	104,000.0	499.7	0.60	0.3	1.0
10/06/2020 12:00	4,042.2	212.7	4,208.1	104,000.0	437.6	0.53	0.3	0.9
10/06/2020 13:00	4,021.2	1,211.4	5,232.6	104,000.0	544.2	0.65	0.3	1.1
10/06/2020 14:00	4,004.7	1,383.9	5,388.6	104,000.0	560.4	0.67	0.3	1.1
10/06/2020 15:00	3,997.4	1,793.3	5,790.7	104,000.0	602.2	0.72	0.4	1.2
10/06/2020 16:00	3,995.5	1,789.3	5,784.8	104,000.0	601.6	0.72	0.4	1.2
10/06/2020 17:00	4,002.2	1,338.7	5,340.9	104,000.0	555.5	0.67	0.3	1.1
10/06/2020 18:00	4,016.1	988.3	5,004.4	104,000.0	520.5	0.62	0.3	1.0
10/06/2020 19:00	4,027.4	1,189.1	5,216.5	104,000.0	542.5	0.65	0.3	1.1
10/06/2020 20:00	4,030.6	1,148.1	5,178.7	104,000.0	538.6	0.65	0.3	1.1
10/06/2020 21:00	4,035.6	163.4	4,182.7	104,000.0	435.0	0.52	0.3	0.9
10/06/2020 22:00	3,565.1	0.0	3,565.1	104,000.0	370.8	0.44	0.2	0.7
10/06/2020 23:00	3,087.4	0.0	3,087.4	104,000.0	321.1	0.39	0.2	0.6
Average/Sum#:	3,614.1	507.7	4,119.1	104,000.0	428.4	0.51	0.3	0.9
Minimum:	2,853.0	0.0	2,853.0	104,000.0	296.7	0.36	0.2	0.6
Maximum:	4,080.7	1,793.3	5,790.7	104,000.0	602.2	0.72	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/07/2020 00:00	2,853.8	0.0	2,853.8	104,000.0	296.8	0.36	0.2	0.6
10/07/2020 01:00	2,843.0	0.0	2,843.0	104,000.0	295.7	0.35	0.2	0.6
10/07/2020 02:00	2,841.0	0.0	2,841.0	104,000.0	295.5	0.35	0.2	0.6
10/07/2020 03:00	2,842.8	0.0	2,842.8	104,000.0	295.7	0.35	0.2	0.6
10/07/2020 04:00	2,918.3	0.0	2,918.3	104,000.0	303.5	0.36	0.2	0.6
10/07/2020 05:00	4,087.9	159.9	4,227.0	104,000.0	439.6	0.53	0.3	0.9
10/07/2020 06:00	4,069.3	175.1	4,239.1	104,000.0	440.9	0.53	0.3	0.9
10/07/2020 07:00	3,468.9	0.0	3,468.9	104,000.0	360.8	0.43	0.2	0.7
10/07/2020 08:00	3,651.9	0.0	3,651.9	104,000.0	379.8	0.46	0.2	0.8
10/07/2020 09:00	3,831.8	0.0	3,831.8	104,000.0	398.5	0.48	0.2	0.8
10/07/2020 10:00	4,095.3	160.3	4,231.6	104,000.0	440.1	0.53	0.3	0.9
10/07/2020 11:00	4,059.3	408.9	4,468.2	104,000.0	464.7	0.56	0.3	0.9
10/07/2020 12:00	4,053.0	669.0	4,722.0	104,000.0	491.1	0.59	0.3	1.0
10/07/2020 13:00	4,043.1	1,057.1	5,100.2	104,000.0	530.4	0.64	0.3	1.1
10/07/2020 14:00	4,026.5	1,849.2	5,875.7	104,000.0	611.1	0.73	0.4	1.2
10/07/2020 15:00	4,027.3	1,786.6	5,813.9	104,000.0	604.6	0.73	0.4	1.2
10/07/2020 16:00	4,030.6	578.1	4,608.7	104,000.0	479.3	0.57	0.3	1.0
10/07/2020 17:00	4,048.8	228.7	4,277.5	104,000.0	444.9	0.53	0.3	0.9
10/07/2020 18:00	4,046.6	142.1	4,188.7	104,000.0	435.6	0.52	0.3	0.9
10/07/2020 19:00	4,078.2	145.1	4,223.3	104,000.0	439.2	0.53	0.3	0.9
10/07/2020 20:00	4,073.7	485.1	4,544.2	104,000.0	472.6	0.57	0.3	0.9
10/07/2020 21:00	3,588.3	0.0	3,588.3	104,000.0	373.2	0.45	0.2	0.7
10/07/2020 22:00	3,083.1	0.0	3,083.1	104,000.0	320.6	0.39	0.2	0.6
10/07/2020 23:00	2,849.1	0.0	2,849.1	104,000.0	296.3	0.36	0.2	0.6
Average/Sum#:	3,646.3	326.9	3,970.5	104,000.0	412.9	0.50	0.3	0.8
Minimum:	2,841.0	0.0	2,841.0	104,000.0	295.5	0.35	0.2	0.6
Maximum:	4,095.3	1,849.2	5,875.7	104,000.0	611.1	0.73	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/08/2020 00:00	2,847.9	0.0	2,847.9	104,000.0	296.2	0.36	0.2	0.6
10/08/2020 01:00	2,843.9	0.0	2,843.9	104,000.0	295.8	0.35	0.2	0.6
10/08/2020 02:00	2,844.9	0.0	2,844.9	104,000.0	295.9	0.35	0.2	0.6
10/08/2020 03:00	2,847.7	0.0	2,847.7	104,000.0	296.2	0.36	0.2	0.6
10/08/2020 04:00	2,795.5	0.0	2,795.5	104,000.0	290.7	0.36	0.2	0.6
10/08/2020 05:00	1,086.7	0.0	1,086.7	104,000.0	113.0	0.00	0.0	0.0
10/08/2020 06:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/08/2020 07:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/08/2020 08:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/08/2020 09:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/08/2020 10:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/08/2020 11:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/08/2020 12:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/08/2020 13:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/08/2020 14:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/08/2020 15:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/08/2020 16:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/08/2020 17:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/08/2020 18:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/08/2020 19:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/08/2020 20:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/08/2020 21:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/08/2020 22:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/08/2020 23:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	2,544.4	0.0	2,544.4	104,000.0	264.6	0.36	0.2	0.6
Minimum:	1,086.7	0.0	1,086.7	104,000.0	113.0	0.35	0.2	0.6
Maximum:	2,847.9	0.0	2,847.9	104,000.0	296.2	0.36	0.2	0.6
%SI	75.00	75.00	75.00	0.00	75.00	79.17	79.17	79.17

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/09/2020 00:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/09/2020 01:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/09/2020 02:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/09/2020 03:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/09/2020 04:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/09/2020 05:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/09/2020 06:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/09/2020 07:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/09/2020 08:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/09/2020 09:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/09/2020 10:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/09/2020 11:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/09/2020 12:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/09/2020 13:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/09/2020 14:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/09/2020 15:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/09/2020 16:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/09/2020 17:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/09/2020 18:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/09/2020 19:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/09/2020 20:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/09/2020 21:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/09/2020 22:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/09/2020 23:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/10/2020 00:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/10/2020 01:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/10/2020 02:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/10/2020 03:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/10/2020 04:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/10/2020 05:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/10/2020 06:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/10/2020 07:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/10/2020 08:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/10/2020 09:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/10/2020 10:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/10/2020 11:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/10/2020 12:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/10/2020 13:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/10/2020 14:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/10/2020 15:00	2,581.0	0.0	2,581.0	104,000.0	268.4	0.00	0.0	0.0
10/10/2020 16:00	3,275.2	0.0	3,275.2	104,000.0	340.6	0.41	0.2	0.7
10/10/2020 17:00	3,965.0	0.0	3,965.0	104,000.0	412.4	0.50	0.2	0.8
10/10/2020 18:00	3,687.3	0.0	3,687.3	104,000.0	383.5	0.46	0.2	0.8
10/10/2020 19:00	3,061.7	0.0	3,061.7	104,000.0	318.4	0.38	0.2	0.6
10/10/2020 20:00	3,921.0	0.0	3,921.0	104,000.0	407.8	0.49	0.2	0.8
10/10/2020 21:00	4,060.0	107.1	4,105.0	104,000.0	426.9	0.52	0.3	0.9
10/10/2020 22:00	3,899.5	0.0	3,899.5	104,000.0	405.5	0.49	0.2	0.8
10/10/2020 23:00	3,859.8	0.0	3,859.8	104,000.0	401.4	0.48	0.2	0.8
Average/Sum#:	3,590.1	11.9	3,595.1	104,000.0	373.9	0.47	0.2	0.8
Minimum:	2,581.0	0.0	2,581.0	104,000.0	268.4	0.38	0.2	0.6
Maximum:	4,060.0	107.1	4,105.0	104,000.0	426.9	0.52	0.3	0.9
%SI	62.50	62.50	62.50	0.00	62.50	66.67	66.67	66.67

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/11/2020 00:00	3,577.8	0.0	3,577.8	104,000.0	372.1	0.45	0.2	0.7
10/11/2020 01:00	3,241.6	0.0	3,241.6	104,000.0	337.1	0.41	0.2	0.7
10/11/2020 02:00	3,122.5	0.0	3,122.5	104,000.0	324.7	0.39	0.2	0.7
10/11/2020 03:00	3,086.5	0.0	3,086.5	104,000.0	321.0	0.39	0.2	0.6
10/11/2020 04:00	3,201.0	0.0	3,201.0	104,000.0	332.9	0.40	0.2	0.7
10/11/2020 05:00	3,840.3	0.0	3,840.3	104,000.0	399.4	0.48	0.2	0.8
10/11/2020 06:00	3,971.8	0.0	3,971.8	104,000.0	413.1	0.50	0.2	0.8
10/11/2020 07:00	3,637.3	0.0	3,637.3	104,000.0	378.3	0.45	0.2	0.8
10/11/2020 08:00	3,850.4	0.0	3,850.4	104,000.0	400.4	0.48	0.2	0.8
10/11/2020 09:00	3,977.2	0.0	3,977.2	104,000.0	413.6	0.50	0.2	0.8
10/11/2020 10:00	3,945.0	0.0	3,945.0	104,000.0	410.3	0.49	0.2	0.8
10/11/2020 11:00	3,361.7	0.0	3,361.7	104,000.0	349.6	0.42	0.2	0.7
10/11/2020 12:00	3,284.7	0.0	3,284.7	104,000.0	341.6	0.41	0.2	0.7
10/11/2020 13:00	4,066.2	80.0	4,083.8	104,000.0	424.7	0.52	0.3	0.9
10/11/2020 14:00	4,106.6	1,760.7	5,867.3	104,000.0	610.2	0.73	0.4	1.2
10/11/2020 15:00	4,126.5	1,107.5	5,234.0	104,000.0	544.3	0.65	0.3	1.1
10/11/2020 16:00	3,923.4	14.2	3,924.5	104,000.0	408.1	0.49	0.2	0.8
10/11/2020 17:00	3,457.8	0.0	3,457.8	104,000.0	359.6	0.43	0.2	0.7
10/11/2020 18:00	3,224.4	0.0	3,224.4	104,000.0	335.3	0.40	0.2	0.7
10/11/2020 19:00	3,016.8	0.0	3,016.8	104,000.0	313.7	0.38	0.2	0.6
10/11/2020 20:00	3,883.7	0.0	3,883.7	104,000.0	403.9	0.48	0.2	0.8
10/11/2020 21:00	4,143.6	38.6	4,154.0	104,000.0	432.0	0.52	0.3	0.9
10/11/2020 22:00	3,787.4	0.0	3,787.4	104,000.0	393.9	0.48	0.2	0.8
10/11/2020 23:00	3,396.1	0.0	3,396.1	104,000.0	353.2	0.42	0.2	0.7
Average/Sum#:	3,634.6	125.0	3,755.3	104,000.0	390.5	0.47	0.2	0.8
Minimum:	3,016.8	0.0	3,016.8	104,000.0	313.7	0.38	0.2	0.6
Maximum:	4,143.6	1,760.7	5,867.3	104,000.0	610.2	0.73	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/12/2020 00:00	3,200.8	0.0	3,200.8	104,000.0	332.9	0.40	0.2	0.7
10/12/2020 01:00	3,085.0	0.0	3,085.0	104,000.0	320.8	0.39	0.2	0.6
10/12/2020 02:00	2,976.2	0.0	2,976.2	104,000.0	309.5	0.37	0.2	0.6
10/12/2020 03:00	3,019.8	0.0	3,019.8	104,000.0	314.1	0.38	0.2	0.6
10/12/2020 04:00	3,467.8	0.0	3,467.8	104,000.0	360.7	0.44	0.2	0.7
10/12/2020 05:00	4,092.1	180.0	4,214.5	104,000.0	438.3	0.53	0.3	0.9
10/12/2020 06:00	4,135.7	516.6	4,652.3	104,000.0	483.8	0.58	0.3	1.0
10/12/2020 07:00	4,141.6	511.2	4,652.8	104,000.0	483.9	0.58	0.3	1.0
10/12/2020 08:00	4,140.8	422.5	4,563.3	104,000.0	474.6	0.57	0.3	0.9
10/12/2020 09:00	4,066.5	439.5	4,506.0	104,000.0	468.6	0.56	0.3	0.9
10/12/2020 10:00	4,031.1	540.5	4,571.6	104,000.0	475.4	0.57	0.3	1.0
10/12/2020 11:00	3,925.6	26.3	3,929.5	104,000.0	408.7	0.49	0.2	0.8
10/12/2020 12:00	4,094.1	3.7	4,094.2	104,000.0	425.8	0.51	0.3	0.9
10/12/2020 13:00	4,085.2	1,451.1	5,536.3	104,000.0	575.8	0.69	0.3	1.2
10/12/2020 14:00	4,072.6	1,938.1	6,010.7	104,000.0	625.1	0.75	0.4	1.3
10/12/2020 15:00	4,065.1	1,914.2	5,979.3	104,000.0	621.8	0.75	0.4	1.2
10/12/2020 16:00	3,873.5	116.0	3,896.7	104,000.0	405.3	0.50	0.2	0.8
10/12/2020 17:00	3,785.1	0.0	3,785.1	104,000.0	393.7	0.47	0.2	0.8
10/12/2020 18:00	3,704.4	0.0	3,704.4	104,000.0	385.3	0.46	0.2	0.8
10/12/2020 19:00	3,314.6	0.0	3,314.6	104,000.0	344.7	0.41	0.2	0.7
10/12/2020 20:00	3,642.9	0.0	3,642.9	104,000.0	378.9	0.45	0.2	0.8
10/12/2020 21:00	3,354.2	0.0	3,354.2	104,000.0	348.8	0.42	0.2	0.7
10/12/2020 22:00	3,986.3	2.5	3,986.4	104,000.0	414.6	0.50	0.2	0.8
10/12/2020 23:00	4,212.6	64.6	4,241.7	104,000.0	441.1	0.53	0.3	0.9
Average/Sum#:	3,769.7	338.6	4,099.4	104,000.0	426.3	0.51	0.3	0.9
Minimum:	2,976.2	0.0	2,976.2	104,000.0	309.5	0.37	0.2	0.6
Maximum:	4,212.6	1,938.1	6,010.7	104,000.0	625.1	0.75	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/13/2020 00:00	4,060.3	0.0	4,060.3	104,000.0	422.3	0.51	0.3	0.8
10/13/2020 01:00	4,096.4	0.0	4,096.4	104,000.0	426.0	0.51	0.3	0.9
10/13/2020 02:00	4,157.8	0.0	4,157.8	104,000.0	432.4	0.52	0.3	0.9
10/13/2020 03:00	4,244.6	0.0	4,244.6	104,000.0	441.4	0.53	0.3	0.9
10/13/2020 04:00	4,089.5	50.0	4,093.5	104,000.0	425.7	0.52	0.3	0.9
10/13/2020 05:00	4,250.2	1,970.1	6,220.3	104,000.0	646.9	0.78	0.4	1.3
10/13/2020 06:00	4,267.7	2,047.7	6,315.4	104,000.0	656.8	0.79	0.4	1.3
10/13/2020 07:00	4,175.9	1,986.2	6,162.1	104,000.0	640.9	0.77	0.4	1.3
10/13/2020 08:00	3,671.3	510.1	3,860.0	104,000.0	401.4	0.52	0.3	0.9
10/13/2020 09:00	2,966.9	0.0	2,966.9	104,000.0	308.6	0.37	0.2	0.6
10/13/2020 10:00	4,098.2	240.4	4,295.3	104,000.0	446.7	0.54	0.3	0.9
10/13/2020 11:00	4,113.4	936.9	5,050.3	104,000.0	525.2	0.63	0.3	1.1
10/13/2020 12:00	4,072.9	1,040.7	5,113.6	104,000.0	531.8	0.64	0.3	1.1
10/13/2020 13:00	4,045.4	1,093.0	5,138.4	104,000.0	534.4	0.64	0.3	1.1
10/13/2020 14:00	4,020.1	768.9	4,789.0	104,000.0	498.1	0.60	0.3	1.0
10/13/2020 15:00	4,011.2	591.0	4,602.2	104,000.0	478.6	0.57	0.3	1.0
10/13/2020 16:00	4,009.0	734.7	4,743.7	104,000.0	493.3	0.59	0.3	1.0
10/13/2020 17:00	4,030.4	571.8	4,602.2	104,000.0	478.6	0.57	0.3	1.0
10/13/2020 18:00	4,059.9	315.2	4,343.6	104,000.0	451.7	0.55	0.3	0.9
10/13/2020 19:00	3,927.5	0.0	3,927.5	104,000.0	408.5	0.49	0.2	0.8
10/13/2020 20:00	4,086.1	478.8	4,564.9	104,000.0	474.7	0.57	0.3	0.9
10/13/2020 21:00	3,933.8	8.0	3,934.4	104,000.0	409.2	0.49	0.2	0.8
10/13/2020 22:00	3,509.2	0.0	3,509.2	104,000.0	365.0	0.44	0.2	0.7
10/13/2020 23:00	2,952.9	0.0	2,952.9	104,000.0	307.1	0.37	0.2	0.6
Average/Sum#:	3,952.1	556.0	4,489.4	104,000.0	466.9	0.56	0.3	0.9
Minimum:	2,952.9	0.0	2,952.9	104,000.0	307.1	0.37	0.2	0.6
Maximum:	4,267.7	2,047.7	6,315.4	104,000.0	656.8	0.79	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/14/2020 00:00	2,858.1	0.0	2,858.1	104,000.0	297.2	0.36	0.2	0.6
10/14/2020 01:00	2,862.3	0.0	2,862.3	104,000.0	297.7	0.36	0.2	0.6
10/14/2020 02:00	2,853.7	0.0	2,853.7	104,000.0	296.8	0.36	0.2	0.6
10/14/2020 03:00	2,859.6	0.0	2,859.6	104,000.0	297.4	0.36	0.2	0.6
10/14/2020 04:00	2,916.9	0.0	2,916.9	104,000.0	303.4	0.36	0.2	0.6
10/14/2020 05:00	3,159.4	0.0	3,159.4	104,000.0	328.6	0.39	0.2	0.7
10/14/2020 06:00	3,160.0	0.0	3,160.0	104,000.0	328.6	0.39	0.2	0.7
10/14/2020 07:00	3,205.6	0.0	3,205.6	104,000.0	333.4	0.40	0.2	0.7
10/14/2020 08:00	3,406.5	0.0	3,406.5	104,000.0	354.3	0.42	0.2	0.7
10/14/2020 09:00	3,842.1	0.0	3,842.1	104,000.0	399.6	0.48	0.2	0.8
10/14/2020 10:00	4,075.3	29.7	4,080.3	104,000.0	424.4	0.51	0.3	0.9
10/14/2020 11:00	4,046.1	276.1	4,322.2	104,000.0	449.5	0.54	0.3	0.9
10/14/2020 12:00	4,029.1	596.2	4,625.3	104,000.0	481.0	0.58	0.3	1.0
10/14/2020 13:00	4,016.7	1,069.7	5,086.4	104,000.0	529.0	0.64	0.3	1.1
10/14/2020 14:00	4,013.1	1,860.5	5,873.6	104,000.0	610.9	0.73	0.4	1.2
10/14/2020 15:00	4,008.4	1,865.8	5,874.2	104,000.0	610.9	0.74	0.4	1.2
10/14/2020 16:00	4,020.2	1,603.2	5,623.4	104,000.0	584.8	0.70	0.4	1.2
10/14/2020 17:00	4,058.6	1,182.5	5,241.1	104,000.0	545.1	0.65	0.3	1.1
10/14/2020 18:00	4,086.3	986.9	5,073.2	104,000.0	527.6	0.63	0.3	1.1
10/14/2020 19:00	3,657.9	0.0	3,657.9	104,000.0	380.4	0.46	0.2	0.8
10/14/2020 20:00	4,108.1	292.4	4,350.8	104,000.0	452.5	0.55	0.3	0.9
10/14/2020 21:00	3,936.6	0.0	3,936.6	104,000.0	409.4	0.49	0.2	0.8
10/14/2020 22:00	3,516.4	0.0	3,516.4	104,000.0	365.7	0.44	0.2	0.7
10/14/2020 23:00	3,174.1	0.0	3,174.1	104,000.0	330.1	0.40	0.2	0.7
Average/Sum#:	3,578.0	406.8	3,981.7	104,000.0	414.1	0.50	0.3	0.8
Minimum:	2,853.7	0.0	2,853.7	104,000.0	296.8	0.36	0.2	0.6
Maximum:	4,108.1	1,865.8	5,874.2	104,000.0	610.9	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/15/2020 00:00	2,858.2	0.0	2,858.2	104,000.0	297.3	0.36	0.2	0.6
10/15/2020 01:00	2,845.5	0.0	2,845.5	104,000.0	295.9	0.36	0.2	0.6
10/15/2020 02:00	2,851.7	0.0	2,851.7	104,000.0	296.6	0.36	0.2	0.6
10/15/2020 03:00	2,858.1	0.0	2,858.1	104,000.0	297.2	0.36	0.2	0.6
10/15/2020 04:00	2,875.0	0.0	2,875.0	104,000.0	299.0	0.36	0.2	0.6
10/15/2020 05:00	3,051.9	0.0	3,051.9	104,000.0	317.4	0.38	0.2	0.6
10/15/2020 06:00	3,427.1	0.0	3,427.1	104,000.0	356.4	0.43	0.2	0.7
10/15/2020 07:00	3,612.7	0.0	3,612.7	104,000.0	375.7	0.45	0.2	0.8
10/15/2020 08:00	2,594.4	0.0	2,594.4	104,000.0	269.8	0.46	0.2	0.8
10/15/2020 09:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/15/2020 10:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/15/2020 11:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/15/2020 12:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/15/2020 13:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/15/2020 14:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/15/2020 15:00	2,550.7	0.0	2,550.7	104,000.0	265.3	0.50	0.3	0.8
10/15/2020 16:00	4,025.0	1,513.3	5,462.6	104,000.0	568.1	0.69	0.3	1.2
10/15/2020 17:00	4,041.3	1,328.1	5,369.4	104,000.0	558.4	0.67	0.3	1.1
10/15/2020 18:00	4,068.5	954.4	5,022.9	104,000.0	522.4	0.63	0.3	1.0
10/15/2020 19:00	3,995.8	87.9	4,015.1	104,000.0	417.6	0.51	0.3	0.9
10/15/2020 20:00	4,115.0	473.1	4,555.0	104,000.0	473.7	0.57	0.3	1.0
10/15/2020 21:00	3,715.9	0.0	3,715.9	104,000.0	386.5	0.46	0.2	0.8
10/15/2020 22:00	3,217.7	0.0	3,217.7	104,000.0	334.6	0.40	0.2	0.7
10/15/2020 23:00	3,044.0	0.0	3,044.0	104,000.0	316.6	0.38	0.2	0.6
Average/Sum#:	3,319.4	242.0	3,551.6	104,000.0	369.4	0.46	0.2	0.8
Minimum:	2,550.7	0.0	2,550.7	104,000.0	265.3	0.36	0.2	0.6
Maximum:	4,115.0	1,513.3	5,462.6	104,000.0	568.1	0.69	0.3	1.2
%SI	25.00	25.00	25.00	0.00	25.00	25.00	25.00	25.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/16/2020 00:00	2,850.8	0.0	2,850.8	104,000.0	296.5	0.36	0.2	0.6
10/16/2020 01:00	2,845.8	0.0	2,845.8	104,000.0	296.0	0.36	0.2	0.6
10/16/2020 02:00	2,842.9	0.0	2,842.9	104,000.0	295.7	0.35	0.2	0.6
10/16/2020 03:00	2,844.3	0.0	2,844.3	104,000.0	295.8	0.36	0.2	0.6
10/16/2020 04:00	2,957.8	0.0	2,957.8	104,000.0	307.6	0.37	0.2	0.6
10/16/2020 05:00	3,072.6	0.0	3,072.6	104,000.0	319.6	0.38	0.2	0.6
10/16/2020 06:00	3,105.7	0.0	3,105.7	104,000.0	323.0	0.39	0.2	0.6
10/16/2020 07:00	3,087.5	0.0	3,087.5	104,000.0	321.1	0.38	0.2	0.6
10/16/2020 08:00	3,360.5	0.0	3,360.5	104,000.0	349.5	0.42	0.2	0.7
10/16/2020 09:00	3,628.4	0.0	3,628.4	104,000.0	377.4	0.45	0.2	0.8
10/16/2020 10:00	3,629.3	0.0	3,629.3	104,000.0	377.4	0.45	0.2	0.8
10/16/2020 11:00	3,540.0	0.0	3,540.0	104,000.0	368.2	0.44	0.2	0.7
10/16/2020 12:00	4,068.0	310.9	4,357.1	104,000.0	453.1	0.55	0.3	0.9
10/16/2020 13:00	4,031.0	878.5	4,909.5	104,000.0	510.6	0.61	0.3	1.0
10/16/2020 14:00	4,011.6	1,320.4	5,332.0	104,000.0	554.5	0.67	0.3	1.1
10/16/2020 15:00	4,001.7	1,803.3	5,805.0	104,000.0	603.7	0.72	0.4	1.2
10/16/2020 16:00	4,004.3	1,805.3	5,809.6	104,000.0	604.2	0.73	0.4	1.2
10/16/2020 17:00	4,008.9	1,540.1	5,549.0	104,000.0	577.1	0.69	0.3	1.2
10/16/2020 18:00	4,027.9	1,060.8	5,088.7	104,000.0	529.2	0.63	0.3	1.1
10/16/2020 19:00	4,047.3	1,035.2	5,082.5	104,000.0	528.6	0.63	0.3	1.1
10/16/2020 20:00	4,090.0	502.3	4,557.1	104,000.0	473.9	0.57	0.3	1.0
10/16/2020 21:00	3,897.1	0.0	3,897.1	104,000.0	405.3	0.49	0.2	0.8
10/16/2020 22:00	3,477.2	0.0	3,477.2	104,000.0	361.6	0.44	0.2	0.7
10/16/2020 23:00	3,284.7	0.0	3,284.7	104,000.0	341.6	0.41	0.2	0.7
Average/Sum#:	3,529.8	427.4	3,954.8	104,000.0	411.3	0.49	0.2	0.8
Minimum:	2,842.9	0.0	2,842.9	104,000.0	295.7	0.35	0.2	0.6
Maximum:	4,090.0	1,805.3	5,809.6	104,000.0	604.2	0.73	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/17/2020 00:00	2,891.6	0.0	2,891.6	104,000.0	300.7	0.36	0.2	0.6
10/17/2020 01:00	2,842.1	0.0	2,842.1	104,000.0	295.6	0.35	0.2	0.6
10/17/2020 02:00	2,855.9	0.0	2,855.9	104,000.0	297.0	0.36	0.2	0.6
10/17/2020 03:00	2,857.2	0.0	2,857.2	104,000.0	297.1	0.36	0.2	0.6
10/17/2020 04:00	2,857.6	0.0	2,857.6	104,000.0	297.2	0.36	0.2	0.6
10/17/2020 05:00	3,005.4	0.0	3,005.4	104,000.0	312.6	0.38	0.2	0.6
10/17/2020 06:00	2,942.9	0.0	2,942.9	104,000.0	306.1	0.37	0.2	0.6
10/17/2020 07:00	3,161.1	0.0	3,161.1	104,000.0	328.8	0.40	0.2	0.7
10/17/2020 08:00	3,492.1	0.0	3,492.1	104,000.0	363.2	0.44	0.2	0.7
10/17/2020 09:00	3,741.3	0.0	3,741.3	104,000.0	389.1	0.47	0.2	0.8
10/17/2020 10:00	3,877.0	0.0	3,877.0	104,000.0	403.2	0.48	0.2	0.8
10/17/2020 11:00	3,868.8	0.0	3,868.8	104,000.0	402.4	0.48	0.2	0.8
10/17/2020 12:00	3,977.1	2.3	3,977.1	104,000.0	413.6	0.50	0.2	0.8
10/17/2020 13:00	4,025.7	417.8	4,443.5	104,000.0	462.1	0.55	0.3	0.9
10/17/2020 14:00	3,836.1	1,702.1	5,538.2	104,000.0	576.0	0.69	0.3	1.2
10/17/2020 15:00	3,600.1	1,402.0	5,002.1	104,000.0	520.2	0.62	0.3	1.0
10/17/2020 16:00	3,730.1	1,347.6	5,077.7	104,000.0	528.1	0.63	0.3	1.1
10/17/2020 17:00	4,043.0	794.1	4,837.1	104,000.0	503.1	0.60	0.3	1.0
10/17/2020 18:00	4,056.1	179.8	4,187.4	104,000.0	435.5	0.53	0.3	0.9
10/17/2020 19:00	4,078.8	1,260.0	5,338.8	104,000.0	555.2	0.67	0.3	1.1
10/17/2020 20:00	4,108.4	549.3	4,602.8	104,000.0	478.7	0.58	0.3	1.0
10/17/2020 21:00	3,938.1	0.0	3,938.1	104,000.0	409.6	0.49	0.2	0.8
10/17/2020 22:00	3,509.4	0.0	3,509.4	104,000.0	365.0	0.44	0.2	0.7
10/17/2020 23:00	3,186.8	0.0	3,186.8	104,000.0	331.4	0.40	0.2	0.7
Average/Sum#:	3,520.1	319.0	3,834.7	104,000.0	398.8	0.48	0.2	0.8
Minimum:	2,842.1	0.0	2,842.1	104,000.0	295.6	0.35	0.2	0.6
Maximum:	4,108.4	1,702.1	5,538.2	104,000.0	576.0	0.69	0.3	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/18/2020 00:00	3,054.5	0.0	3,054.5	104,000.0	317.7	0.38	0.2	0.6
10/18/2020 01:00	2,844.1	0.0	2,844.1	104,000.0	295.8	0.35	0.2	0.6
10/18/2020 02:00	2,861.5	0.0	2,861.5	104,000.0	297.6	0.36	0.2	0.6
10/18/2020 03:00	2,848.6	0.0	2,848.6	104,000.0	296.3	0.36	0.2	0.6
10/18/2020 04:00	2,879.7	0.0	2,879.7	104,000.0	299.5	0.36	0.2	0.6
10/18/2020 05:00	2,937.7	0.0	2,937.7	104,000.0	305.5	0.37	0.2	0.6
10/18/2020 06:00	2,950.1	0.0	2,950.1	104,000.0	306.8	0.37	0.2	0.6
10/18/2020 07:00	3,124.2	0.0	3,124.2	104,000.0	324.9	0.39	0.2	0.6
10/18/2020 08:00	3,371.0	0.0	3,371.0	104,000.0	350.6	0.42	0.2	0.7
10/18/2020 09:00	3,781.3	3.1	3,781.4	104,000.0	393.3	0.47	0.2	0.8
10/18/2020 10:00	4,123.6	168.1	4,291.7	104,000.0	446.3	0.53	0.3	0.9
10/18/2020 11:00	4,101.3	239.2	4,340.5	104,000.0	451.4	0.54	0.3	0.9
10/18/2020 12:00	4,074.6	184.4	4,259.0	104,000.0	442.9	0.53	0.3	0.9
10/18/2020 13:00	4,054.4	460.0	4,514.4	104,000.0	469.5	0.56	0.3	0.9
10/18/2020 14:00	4,034.0	1,025.3	5,059.3	104,000.0	526.2	0.63	0.3	1.1
10/18/2020 15:00	4,022.2	1,492.1	5,514.3	104,000.0	573.5	0.69	0.3	1.1
10/18/2020 16:00	4,021.0	620.6	4,641.6	104,000.0	482.7	0.58	0.3	1.0
10/18/2020 17:00	4,032.5	95.5	4,051.6	104,000.0	421.4	0.52	0.3	0.9
10/18/2020 18:00	3,709.6	0.0	3,709.6	104,000.0	385.8	0.46	0.2	0.8
10/18/2020 19:00	3,721.8	2.2	3,721.8	104,000.0	387.1	0.47	0.2	0.8
10/18/2020 20:00	4,078.5	405.6	4,435.4	104,000.0	461.3	0.56	0.3	0.9
10/18/2020 21:00	3,824.9	0.0	3,824.9	104,000.0	397.8	0.48	0.2	0.8
10/18/2020 22:00	3,313.6	0.0	3,313.6	104,000.0	344.6	0.41	0.2	0.7
10/18/2020 23:00	3,005.8	0.0	3,005.8	104,000.0	312.6	0.38	0.2	0.6
Average/Sum#:	3,532.1	195.7	3,722.3	104,000.0	387.1	0.47	0.2	0.8
Minimum:	2,844.1	0.0	2,844.1	104,000.0	295.8	0.35	0.2	0.6
Maximum:	4,123.6	1,492.1	5,514.3	104,000.0	573.5	0.69	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/19/2020 00:00	2,864.0	0.0	2,864.0	104,000.0	297.9	0.36	0.2	0.6
10/19/2020 01:00	2,895.8	0.0	2,895.8	104,000.0	301.2	0.36	0.2	0.6
10/19/2020 02:00	2,857.6	0.0	2,857.6	104,000.0	297.2	0.36	0.2	0.6
10/19/2020 03:00	2,873.8	0.0	2,873.8	104,000.0	298.9	0.36	0.2	0.6
10/19/2020 04:00	2,972.6	0.0	2,972.6	104,000.0	309.2	0.37	0.2	0.6
10/19/2020 05:00	3,224.9	0.0	3,224.9	104,000.0	335.4	0.40	0.2	0.7
10/19/2020 06:00	3,278.7	0.0	3,278.7	104,000.0	341.0	0.41	0.2	0.7
10/19/2020 07:00	3,465.9	0.0	3,465.9	104,000.0	360.5	0.43	0.2	0.7
10/19/2020 08:00	3,630.9	0.0	3,630.9	104,000.0	377.6	0.45	0.2	0.8
10/19/2020 09:00	4,081.1	11.6	4,082.0	104,000.0	424.5	0.51	0.3	0.9
10/19/2020 10:00	4,134.8	232.0	4,366.8	104,000.0	454.1	0.55	0.3	0.9
10/19/2020 11:00	4,102.1	525.0	4,627.1	104,000.0	481.2	0.58	0.3	1.0
10/19/2020 12:00	4,077.4	638.8	4,716.2	104,000.0	490.5	0.59	0.3	1.0
10/19/2020 13:00	4,061.8	864.8	4,926.6	104,000.0	512.4	0.61	0.3	1.0
10/19/2020 14:00	4,046.2	1,193.3	5,239.5	104,000.0	544.9	0.66	0.3	1.1
10/19/2020 15:00	4,038.2	1,802.7	5,840.9	104,000.0	607.5	0.73	0.4	1.2
10/19/2020 16:00	4,042.2	1,519.5	5,561.7	104,000.0	578.4	0.69	0.3	1.2
10/19/2020 17:00	4,072.2	1,035.7	5,107.9	104,000.0	531.2	0.64	0.3	1.1
10/19/2020 18:00	4,073.3	521.0	4,594.3	104,000.0	477.8	0.57	0.3	1.0
10/19/2020 19:00	3,777.3	4.6	3,777.4	104,000.0	392.8	0.47	0.2	0.8
10/19/2020 20:00	4,098.9	335.6	4,377.4	104,000.0	455.2	0.55	0.3	0.9
10/19/2020 21:00	3,820.9	0.0	3,820.9	104,000.0	397.4	0.48	0.2	0.8
10/19/2020 22:00	3,279.1	0.0	3,279.1	104,000.0	341.0	0.41	0.2	0.7
10/19/2020 23:00	3,049.0	0.0	3,049.0	104,000.0	317.1	0.38	0.2	0.6
Average/Sum#:	3,617.4	361.9	3,976.3	104,000.0	413.5	0.50	0.3	0.8
Minimum:	2,857.6	0.0	2,857.6	104,000.0	297.2	0.36	0.2	0.6
Maximum:	4,134.8	1,802.7	5,840.9	104,000.0	607.5	0.73	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/20/2020 00:00	2,873.7	0.0	2,873.7	104,000.0	298.9	0.36	0.2	0.6
10/20/2020 01:00	2,855.2	0.0	2,855.2	104,000.0	296.9	0.36	0.2	0.6
10/20/2020 02:00	2,847.5	0.0	2,847.5	104,000.0	296.1	0.36	0.2	0.6
10/20/2020 03:00	2,858.7	0.0	2,858.7	104,000.0	297.3	0.36	0.2	0.6
10/20/2020 04:00	2,951.1	0.0	2,951.1	104,000.0	306.9	0.37	0.2	0.6
10/20/2020 05:00	3,163.1	0.0	3,163.1	104,000.0	329.0	0.40	0.2	0.7
10/20/2020 06:00	3,161.6	0.0	3,161.6	104,000.0	328.8	0.40	0.2	0.7
10/20/2020 07:00	3,140.6	0.0	3,140.6	104,000.0	326.6	0.39	0.2	0.7
10/20/2020 08:00	3,401.1	0.0	3,401.1	104,000.0	353.7	0.42	0.2	0.7
10/20/2020 09:00	3,924.9	0.0	3,924.9	104,000.0	408.2	0.49	0.2	0.8
10/20/2020 10:00	4,086.1	287.9	4,296.3	104,000.0	446.8	0.55	0.3	0.9
10/20/2020 11:00	4,100.9	892.5	4,993.4	104,000.0	519.3	0.62	0.3	1.0
10/20/2020 12:00	4,077.0	993.0	5,070.0	104,000.0	527.3	0.63	0.3	1.1
10/20/2020 13:00	4,067.7	1,713.2	5,780.9	104,000.0	601.2	0.72	0.4	1.2
10/20/2020 14:00	4,052.4	1,795.6	5,848.0	104,000.0	608.2	0.73	0.4	1.2
10/20/2020 15:00	4,039.1	1,715.1	5,754.2	104,000.0	598.4	0.72	0.4	1.2
10/20/2020 16:00	4,036.3	672.6	4,708.9	104,000.0	489.7	0.59	0.3	1.0
10/20/2020 17:00	4,049.6	242.6	4,183.0	104,000.0	435.0	0.54	0.3	0.9
10/20/2020 18:00	4,037.6	0.0	4,037.6	104,000.0	419.9	0.51	0.3	0.8
10/20/2020 19:00	4,084.3	608.4	4,650.1	104,000.0	483.6	0.59	0.3	1.0
10/20/2020 20:00	4,080.7	16.3	4,082.3	104,000.0	424.6	0.51	0.3	0.9
10/20/2020 21:00	3,543.4	0.0	3,543.4	104,000.0	368.5	0.44	0.2	0.7
10/20/2020 22:00	3,131.1	0.0	3,131.1	104,000.0	325.6	0.39	0.2	0.7
10/20/2020 23:00	2,859.9	0.0	2,859.9	104,000.0	297.4	0.36	0.2	0.6
Average/Sum#:	3,559.3	372.4	3,921.5	104,000.0	407.8	0.49	0.3	0.8
Minimum:	2,847.5	0.0	2,847.5	104,000.0	296.1	0.36	0.2	0.6
Maximum:	4,100.9	1,795.6	5,848.0	104,000.0	608.2	0.73	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/21/2020 00:00	2,842.5	0.0	2,842.5	104,000.0	295.6	0.35	0.2	0.6
10/21/2020 01:00	2,849.7	0.0	2,849.7	104,000.0	296.4	0.36	0.2	0.6
10/21/2020 02:00	2,854.0	0.0	2,854.0	104,000.0	296.8	0.36	0.2	0.6
10/21/2020 03:00	2,851.5	0.0	2,851.5	104,000.0	296.6	0.36	0.2	0.6
10/21/2020 04:00	2,875.5	0.0	2,875.5	104,000.0	299.1	0.36	0.2	0.6
10/21/2020 05:00	3,540.6	0.0	3,540.6	104,000.0	368.2	0.44	0.2	0.7
10/21/2020 06:00	3,570.9	0.0	3,570.9	104,000.0	371.4	0.45	0.2	0.7
10/21/2020 07:00	2,875.8	0.0	2,875.8	104,000.0	299.1	0.36	0.2	0.6
10/21/2020 08:00	2,986.4	0.0	2,986.4	104,000.0	310.6	0.37	0.2	0.6
10/21/2020 09:00	3,176.8	0.0	3,176.8	104,000.0	330.4	0.40	0.2	0.7
10/21/2020 10:00	3,365.2	0.0	3,365.2	104,000.0	350.0	0.42	0.2	0.7
10/21/2020 11:00	3,764.2	0.0	3,764.2	104,000.0	391.5	0.47	0.2	0.8
10/21/2020 12:00	3,941.6	11.5	3,942.8	104,000.0	410.1	0.49	0.2	0.8
10/21/2020 13:00	4,046.3	234.5	4,280.8	104,000.0	445.2	0.53	0.3	0.9
10/21/2020 14:00	4,039.6	737.3	4,776.9	104,000.0	496.8	0.60	0.3	1.0
10/21/2020 15:00	3,832.1	9.1	3,832.7	104,000.0	398.6	0.48	0.2	0.8
10/21/2020 16:00	3,748.9	0.0	3,748.9	104,000.0	389.9	0.47	0.2	0.8
10/21/2020 17:00	3,675.6	0.0	3,675.6	104,000.0	382.3	0.46	0.2	0.8
10/21/2020 18:00	3,284.1	0.0	3,284.1	104,000.0	341.5	0.41	0.2	0.7
10/21/2020 19:00	2,868.3	0.0	2,868.3	104,000.0	298.3	0.36	0.2	0.6
10/21/2020 20:00	2,932.8	0.0	2,932.8	104,000.0	305.0	0.37	0.2	0.6
10/21/2020 21:00	3,407.1	0.0	3,407.1	104,000.0	354.3	0.43	0.2	0.7
10/21/2020 22:00	2,991.2	0.0	2,991.2	104,000.0	311.1	0.37	0.2	0.6
10/21/2020 23:00	2,869.5	0.0	2,869.5	104,000.0	298.4	0.36	0.2	0.6
Average/Sum#:	3,299.6	41.4	3,340.2	104,000.0	347.4	0.42	0.2	0.7
Minimum:	2,842.5	0.0	2,842.5	104,000.0	295.6	0.35	0.2	0.6
Maximum:	4,046.3	737.3	4,776.9	104,000.0	496.8	0.60	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/22/2020 00:00	2,855.6	0.0	2,855.6	104,000.0	297.0	0.36	0.2	0.6
10/22/2020 01:00	2,846.5	0.0	2,846.5	104,000.0	296.0	0.36	0.2	0.6
10/22/2020 02:00	2,850.9	0.0	2,850.9	104,000.0	296.5	0.36	0.2	0.6
10/22/2020 03:00	2,851.5	0.0	2,851.5	104,000.0	296.6	0.36	0.2	0.6
10/22/2020 04:00	2,936.2	0.0	2,936.2	104,000.0	305.4	0.37	0.2	0.6
10/22/2020 05:00	4,187.0	0.0	4,187.0	104,000.0	435.4	0.52	0.3	0.9
10/22/2020 06:00	4,163.3	0.0	4,163.3	104,000.0	433.0	0.52	0.3	0.9
10/22/2020 07:00	3,421.2	0.0	3,421.2	104,000.0	355.8	0.43	0.2	0.7
10/22/2020 08:00	3,567.6	0.0	3,567.6	104,000.0	371.0	0.44	0.2	0.7
10/22/2020 09:00	3,893.1	0.0	3,893.1	104,000.0	404.9	0.49	0.2	0.8
10/22/2020 10:00	3,846.3	0.0	3,846.3	104,000.0	400.0	0.48	0.2	0.8
10/22/2020 11:00	3,939.8	0.0	3,939.8	104,000.0	409.7	0.49	0.2	0.8
10/22/2020 12:00	4,169.2	0.0	4,169.2	104,000.0	433.6	0.52	0.3	0.9
10/22/2020 13:00	4,169.9	0.0	4,169.9	104,000.0	433.7	0.52	0.3	0.9
10/22/2020 14:00	4,161.6	164.6	4,260.4	104,000.0	443.1	0.54	0.3	0.9
10/22/2020 15:00	3,740.7	0.0	3,740.7	104,000.0	389.0	0.47	0.2	0.8
10/22/2020 16:00	4,115.3	74.4	4,154.0	104,000.0	432.0	0.52	0.3	0.9
10/22/2020 17:00	4,200.6	190.3	4,375.7	104,000.0	455.1	0.55	0.3	0.9
10/22/2020 18:00	3,864.3	0.0	3,864.3	104,000.0	401.9	0.48	0.2	0.8
10/22/2020 19:00	3,842.3	0.0	3,842.3	104,000.0	399.6	0.48	0.2	0.8
10/22/2020 20:00	3,864.2	0.0	3,864.2	104,000.0	401.9	0.48	0.2	0.8
10/22/2020 21:00	3,131.6	0.0	3,131.6	104,000.0	325.7	0.39	0.2	0.7
10/22/2020 22:00	2,858.3	0.0	2,858.3	104,000.0	297.3	0.36	0.2	0.6
10/22/2020 23:00	2,855.2	0.0	2,855.2	104,000.0	296.9	0.36	0.2	0.6
Average/Sum#:	3,597.2	17.9	3,610.2	104,000.0	375.5	0.45	0.2	0.8
Minimum:	2,846.5	0.0	2,846.5	104,000.0	296.0	0.36	0.2	0.6
Maximum:	4,200.6	190.3	4,375.7	104,000.0	455.1	0.55	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/23/2020 00:00	2,847.1	0.0	2,847.1	104,000.0	296.1	0.36	0.2	0.6
10/23/2020 01:00	2,852.9	0.0	2,852.9	104,000.0	296.7	0.36	0.2	0.6
10/23/2020 02:00	2,856.2	0.0	2,856.2	104,000.0	297.0	0.36	0.2	0.6
10/23/2020 03:00	2,853.1	0.0	2,853.1	104,000.0	296.7	0.36	0.2	0.6
10/23/2020 04:00	2,867.1	0.0	2,867.1	104,000.0	298.2	0.36	0.2	0.6
10/23/2020 05:00	3,028.7	0.0	3,028.7	104,000.0	315.0	0.38	0.2	0.6
10/23/2020 06:00	3,124.4	0.0	3,124.4	104,000.0	324.9	0.39	0.2	0.6
10/23/2020 07:00	3,216.9	0.0	3,216.9	104,000.0	334.6	0.40	0.2	0.7
10/23/2020 08:00	3,387.1	0.0	3,387.1	104,000.0	352.3	0.42	0.2	0.7
10/23/2020 09:00	3,379.9	0.0	3,379.9	104,000.0	351.5	0.42	0.2	0.7
10/23/2020 10:00	3,266.6	0.0	3,266.6	104,000.0	339.7	0.41	0.2	0.7
10/23/2020 11:00	3,743.6	0.0	3,743.6	104,000.0	389.3	0.47	0.2	0.8
10/23/2020 12:00	3,892.4	0.0	3,892.4	104,000.0	404.8	0.49	0.2	0.8
10/23/2020 13:00	4,123.2	165.1	4,255.3	104,000.0	442.6	0.54	0.3	0.9
10/23/2020 14:00	4,172.2	140.7	4,312.9	104,000.0	448.5	0.54	0.3	0.9
10/23/2020 15:00	4,155.5	134.8	4,286.3	104,000.0	445.8	0.54	0.3	0.9
10/23/2020 16:00	3,623.1	0.0	3,623.1	104,000.0	376.8	0.45	0.2	0.8
10/23/2020 17:00	4,141.6	390.4	4,481.2	104,000.0	466.0	0.57	0.3	0.9
10/23/2020 18:00	3,333.0	0.0	3,333.0	104,000.0	346.6	0.42	0.2	0.7
10/23/2020 19:00	3,054.8	0.0	3,054.8	104,000.0	317.7	0.38	0.2	0.6
10/23/2020 20:00	3,653.9	0.0	3,653.9	104,000.0	380.0	0.46	0.2	0.8
10/23/2020 21:00	3,279.0	0.0	3,279.0	104,000.0	341.0	0.41	0.2	0.7
10/23/2020 22:00	2,840.9	0.0	2,840.9	104,000.0	295.5	0.36	0.2	0.6
10/23/2020 23:00	1,193.7	0.0	1,193.7	104,000.0	124.1	0.00	0.0	0.0
Average/Sum#:	3,287.0	34.6	3,317.9	104,000.0	345.1	0.43	0.2	0.7
Minimum:	1,193.7	0.0	1,193.7	104,000.0	124.1	0.36	0.2	0.6
Maximum:	4,172.2	390.4	4,481.2	104,000.0	466.0	0.57	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	4.17	4.17	4.17

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/24/2020 00:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/24/2020 01:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/24/2020 02:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/24/2020 03:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/24/2020 04:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/24/2020 05:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/24/2020 06:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/24/2020 07:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/24/2020 08:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/24/2020 09:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/24/2020 10:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/24/2020 11:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/24/2020 12:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/24/2020 13:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/24/2020 14:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/24/2020 15:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/24/2020 16:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/24/2020 17:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/24/2020 18:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/24/2020 19:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/24/2020 20:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/24/2020 21:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/24/2020 22:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/24/2020 23:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/25/2020 00:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/25/2020 01:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/25/2020 02:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/25/2020 03:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/25/2020 04:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/25/2020 05:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/25/2020 06:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/25/2020 07:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/25/2020 08:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/25/2020 09:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/25/2020 10:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/25/2020 11:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/25/2020 12:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/25/2020 13:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/25/2020 14:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/25/2020 15:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/25/2020 16:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/25/2020 17:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/25/2020 18:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/25/2020 19:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/25/2020 20:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/25/2020 21:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/25/2020 22:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/25/2020 23:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/26/2020 00:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/26/2020 01:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/26/2020 02:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/26/2020 03:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/26/2020 04:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/26/2020 05:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/26/2020 06:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/26/2020 07:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/26/2020 08:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/26/2020 09:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/26/2020 10:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/26/2020 11:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/26/2020 12:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/26/2020 13:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/26/2020 14:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/26/2020 15:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/26/2020 16:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/26/2020 17:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/26/2020 18:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/26/2020 19:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/26/2020 20:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/26/2020 21:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/26/2020 22:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/26/2020 23:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/27/2020 00:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/27/2020 01:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/27/2020 02:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/27/2020 03:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/27/2020 04:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/27/2020 05:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/27/2020 06:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/27/2020 07:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/27/2020 08:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/27/2020 09:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/27/2020 10:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/27/2020 11:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/27/2020 12:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/27/2020 13:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/27/2020 14:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/27/2020 15:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/27/2020 16:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/27/2020 17:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/27/2020 18:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/27/2020 19:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/27/2020 20:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/27/2020 21:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/27/2020 22:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/27/2020 23:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/28/2020 00:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/28/2020 01:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/28/2020 02:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/28/2020 03:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/28/2020 04:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/28/2020 05:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/28/2020 06:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/28/2020 07:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/28/2020 08:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/28/2020 09:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/28/2020 10:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/28/2020 11:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/28/2020 12:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/28/2020 13:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/28/2020 14:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/28/2020 15:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/28/2020 16:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/28/2020 17:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/28/2020 18:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/28/2020 19:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/28/2020 20:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/28/2020 21:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/28/2020 22:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/28/2020 23:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/29/2020 00:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/29/2020 01:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/29/2020 02:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/29/2020 03:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/29/2020 04:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/29/2020 05:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/29/2020 06:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/29/2020 07:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/29/2020 08:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/29/2020 09:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/29/2020 10:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/29/2020 11:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/29/2020 12:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/29/2020 13:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/29/2020 14:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/29/2020 15:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/29/2020 16:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/29/2020 17:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/29/2020 18:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/29/2020 19:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/29/2020 20:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/29/2020 21:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/29/2020 22:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/29/2020 23:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/30/2020 00:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/30/2020 01:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/30/2020 02:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/30/2020 03:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/30/2020 04:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/30/2020 05:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/30/2020 06:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/30/2020 07:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/30/2020 08:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/30/2020 09:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/30/2020 10:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/30/2020 11:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/30/2020 12:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/30/2020 13:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/30/2020 14:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/30/2020 15:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/30/2020 16:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/30/2020 17:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/30/2020 18:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/30/2020 19:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/30/2020 20:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/30/2020 21:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/30/2020 22:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/30/2020 23:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/31/2020 00:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/31/2020 01:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/31/2020 02:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/31/2020 03:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/31/2020 04:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/31/2020 05:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/31/2020 06:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/31/2020 07:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/31/2020 08:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/31/2020 09:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/31/2020 10:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/31/2020 11:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/31/2020 12:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/31/2020 13:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/31/2020 14:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/31/2020 15:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/31/2020 16:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/31/2020 17:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/31/2020 18:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/31/2020 19:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/31/2020 20:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/31/2020 21:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/31/2020 22:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
10/31/2020 23:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/01/2020 00:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/01/2020 01:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/01/2020 02:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/01/2020 03:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/01/2020 04:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/01/2020 05:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/01/2020 06:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/01/2020 07:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/01/2020 08:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/01/2020 09:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/01/2020 10:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/01/2020 11:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/01/2020 12:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/01/2020 13:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/01/2020 14:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/01/2020 15:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/01/2020 16:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/01/2020 17:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/01/2020 18:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/01/2020 19:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/01/2020 20:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/01/2020 21:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/01/2020 22:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/01/2020 23:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/02/2020 00:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/02/2020 01:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/02/2020 02:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/02/2020 03:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/02/2020 04:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/02/2020 05:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/02/2020 06:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/02/2020 07:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/02/2020 08:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/02/2020 09:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/02/2020 10:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/02/2020 11:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/02/2020 12:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/02/2020 13:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/02/2020 14:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/02/2020 15:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/02/2020 16:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/02/2020 17:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/02/2020 18:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/02/2020 19:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/02/2020 20:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/02/2020 21:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/02/2020 22:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/02/2020 23:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/03/2020 00:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/03/2020 01:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/03/2020 02:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/03/2020 03:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/03/2020 04:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/03/2020 05:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/03/2020 06:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/03/2020 07:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/03/2020 08:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/03/2020 09:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/03/2020 10:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/03/2020 11:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/03/2020 12:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/03/2020 13:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/03/2020 14:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/03/2020 15:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/03/2020 16:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/03/2020 17:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/03/2020 18:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/03/2020 19:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/03/2020 20:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/03/2020 21:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/03/2020 22:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/03/2020 23:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/04/2020 00:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/04/2020 01:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/04/2020 02:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/04/2020 03:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/04/2020 04:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/04/2020 05:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/04/2020 06:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/04/2020 07:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/04/2020 08:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/04/2020 09:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/04/2020 10:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/04/2020 11:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/04/2020 12:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/04/2020 13:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/04/2020 14:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/04/2020 15:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/04/2020 16:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/04/2020 17:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/04/2020 18:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/04/2020 19:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/04/2020 20:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/04/2020 21:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/04/2020 22:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/04/2020 23:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/05/2020 00:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/05/2020 01:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/05/2020 02:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/05/2020 03:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/05/2020 04:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/05/2020 05:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/05/2020 06:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/05/2020 07:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/05/2020 08:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/05/2020 09:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/05/2020 10:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/05/2020 11:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/05/2020 12:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/05/2020 13:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/05/2020 14:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/05/2020 15:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/05/2020 16:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/05/2020 17:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/05/2020 18:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/05/2020 19:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/05/2020 20:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/05/2020 21:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/05/2020 22:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/05/2020 23:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/06/2020 00:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/06/2020 01:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/06/2020 02:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/06/2020 03:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/06/2020 04:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/06/2020 05:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/06/2020 06:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/06/2020 07:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/06/2020 08:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/06/2020 09:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/06/2020 10:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/06/2020 11:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/06/2020 12:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/06/2020 13:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/06/2020 14:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/06/2020 15:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/06/2020 16:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/06/2020 17:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/06/2020 18:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/06/2020 19:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/06/2020 20:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/06/2020 21:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/06/2020 22:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/06/2020 23:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/07/2020 00:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/07/2020 01:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/07/2020 02:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/07/2020 03:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/07/2020 04:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/07/2020 05:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/07/2020 06:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/07/2020 07:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/07/2020 08:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/07/2020 09:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/07/2020 10:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/07/2020 11:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/07/2020 12:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/07/2020 13:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/07/2020 14:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/07/2020 15:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/07/2020 16:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/07/2020 17:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/07/2020 18:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/07/2020 19:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/07/2020 20:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/07/2020 21:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/07/2020 22:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/07/2020 23:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/08/2020 00:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/08/2020 01:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/08/2020 02:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/08/2020 03:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/08/2020 04:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/08/2020 05:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/08/2020 06:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/08/2020 07:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/08/2020 08:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/08/2020 09:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/08/2020 10:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/08/2020 11:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/08/2020 12:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/08/2020 13:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/08/2020 14:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/08/2020 15:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/08/2020 16:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/08/2020 17:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/08/2020 18:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/08/2020 19:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/08/2020 20:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/08/2020 21:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/08/2020 22:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/08/2020 23:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/09/2020 00:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/09/2020 01:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/09/2020 02:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/09/2020 03:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/09/2020 04:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/09/2020 05:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/09/2020 06:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/09/2020 07:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/09/2020 08:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/09/2020 09:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/09/2020 10:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/09/2020 11:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/09/2020 12:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/09/2020 13:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/09/2020 14:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/09/2020 15:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/09/2020 16:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/09/2020 17:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/09/2020 18:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/09/2020 19:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/09/2020 20:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/09/2020 21:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/09/2020 22:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/09/2020 23:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/10/2020 00:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/10/2020 01:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/10/2020 02:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/10/2020 03:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/10/2020 04:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/10/2020 05:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/10/2020 06:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/10/2020 07:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/10/2020 08:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/10/2020 09:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/10/2020 10:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/10/2020 11:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/10/2020 12:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/10/2020 13:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/10/2020 14:00	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
11/10/2020 15:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/10/2020 16:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/10/2020 17:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/10/2020 18:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/10/2020 19:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/10/2020 20:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/10/2020 21:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/10/2020 22:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/10/2020 23:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,412.5	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,000.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/11/2020 00:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/11/2020 01:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/11/2020 02:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/11/2020 03:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/11/2020 04:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/11/2020 05:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/11/2020 06:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/11/2020 07:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/11/2020 08:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/11/2020 09:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/11/2020 10:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/11/2020 11:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/11/2020 12:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/11/2020 13:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/11/2020 14:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/11/2020 15:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/11/2020 16:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/11/2020 17:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/11/2020 18:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/11/2020 19:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/11/2020 20:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/11/2020 21:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/11/2020 22:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/11/2020 23:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/12/2020 00:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/12/2020 01:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/12/2020 02:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/12/2020 03:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/12/2020 04:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/12/2020 05:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/12/2020 06:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/12/2020 07:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/12/2020 08:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/12/2020 09:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/12/2020 10:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/12/2020 11:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/12/2020 12:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/12/2020 13:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/12/2020 14:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/12/2020 15:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/12/2020 16:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/12/2020 17:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/12/2020 18:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/12/2020 19:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/12/2020 20:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/12/2020 21:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/12/2020 22:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/12/2020 23:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/13/2020 00:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/13/2020 01:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/13/2020 02:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/13/2020 03:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/13/2020 04:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/13/2020 05:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/13/2020 06:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/13/2020 07:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/13/2020 08:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/13/2020 09:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/13/2020 10:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/13/2020 11:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/13/2020 12:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/13/2020 13:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/13/2020 14:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/13/2020 15:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/13/2020 16:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/13/2020 17:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/13/2020 18:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/13/2020 19:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/13/2020 20:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/13/2020 21:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/13/2020 22:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/13/2020 23:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/14/2020 00:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/14/2020 01:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/14/2020 02:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/14/2020 03:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/14/2020 04:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/14/2020 05:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/14/2020 06:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/14/2020 07:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/14/2020 08:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/14/2020 09:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/14/2020 10:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/14/2020 11:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/14/2020 12:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/14/2020 13:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/14/2020 14:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/14/2020 15:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/14/2020 16:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/14/2020 17:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/14/2020 18:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/14/2020 19:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/14/2020 20:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/14/2020 21:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/14/2020 22:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/14/2020 23:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/15/2020 00:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/15/2020 01:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/15/2020 02:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/15/2020 03:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/15/2020 04:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/15/2020 05:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/15/2020 06:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/15/2020 07:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/15/2020 08:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/15/2020 09:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/15/2020 10:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/15/2020 11:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/15/2020 12:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/15/2020 13:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/15/2020 14:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/15/2020 15:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/15/2020 16:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/15/2020 17:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/15/2020 18:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/15/2020 19:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/15/2020 20:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/15/2020 21:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/15/2020 22:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/15/2020 23:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/16/2020 00:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/16/2020 01:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/16/2020 02:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/16/2020 03:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/16/2020 04:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/16/2020 05:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/16/2020 06:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/16/2020 07:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/16/2020 08:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/16/2020 09:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/16/2020 10:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/16/2020 11:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/16/2020 12:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/16/2020 13:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/16/2020 14:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/16/2020 15:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/16/2020 16:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/16/2020 17:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/16/2020 18:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/16/2020 19:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/16/2020 20:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/16/2020 21:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/16/2020 22:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/16/2020 23:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/17/2020 00:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/17/2020 01:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/17/2020 02:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/17/2020 03:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/17/2020 04:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/17/2020 05:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/17/2020 06:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/17/2020 07:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/17/2020 08:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/17/2020 09:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/17/2020 10:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/17/2020 11:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/17/2020 12:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/17/2020 13:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/17/2020 14:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/17/2020 15:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/17/2020 16:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/17/2020 17:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/17/2020 18:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/17/2020 19:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/17/2020 20:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/17/2020 21:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/17/2020 22:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/17/2020 23:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/18/2020 00:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/18/2020 01:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/18/2020 02:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/18/2020 03:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/18/2020 04:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/18/2020 05:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/18/2020 06:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/18/2020 07:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/18/2020 08:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/18/2020 09:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/18/2020 10:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/18/2020 11:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/18/2020 12:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/18/2020 13:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/18/2020 14:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/18/2020 15:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/18/2020 16:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/18/2020 17:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/18/2020 18:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/18/2020 19:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/18/2020 20:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/18/2020 21:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/18/2020 22:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/18/2020 23:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/19/2020 00:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/19/2020 01:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/19/2020 02:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/19/2020 03:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/19/2020 04:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/19/2020 05:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/19/2020 06:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/19/2020 07:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/19/2020 08:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/19/2020 09:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/19/2020 10:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/19/2020 11:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/19/2020 12:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/19/2020 13:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/19/2020 14:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/19/2020 15:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/19/2020 16:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/19/2020 17:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/19/2020 18:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/19/2020 19:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/19/2020 20:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/19/2020 21:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/19/2020 22:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/19/2020 23:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/20/2020 00:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/20/2020 01:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/20/2020 02:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/20/2020 03:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/20/2020 04:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/20/2020 05:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/20/2020 06:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/20/2020 07:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/20/2020 08:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/20/2020 09:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/20/2020 10:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/20/2020 11:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/20/2020 12:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/20/2020 13:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/20/2020 14:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/20/2020 15:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/20/2020 16:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/20/2020 17:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/20/2020 18:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/20/2020 19:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/20/2020 20:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/20/2020 21:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/20/2020 22:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/20/2020 23:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/21/2020 00:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/21/2020 01:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/21/2020 02:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/21/2020 03:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/21/2020 04:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/21/2020 05:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/21/2020 06:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/21/2020 07:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/21/2020 08:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/21/2020 09:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/21/2020 10:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/21/2020 11:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/21/2020 12:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/21/2020 13:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/21/2020 14:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/21/2020 15:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/21/2020 16:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/21/2020 17:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/21/2020 18:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/21/2020 19:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/21/2020 20:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/21/2020 21:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/21/2020 22:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/21/2020 23:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/22/2020 00:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/22/2020 01:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/22/2020 02:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/22/2020 03:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/22/2020 04:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/22/2020 05:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/22/2020 06:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/22/2020 07:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/22/2020 08:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/22/2020 09:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/22/2020 10:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/22/2020 11:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/22/2020 12:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/22/2020 13:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/22/2020 14:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/22/2020 15:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/22/2020 16:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/22/2020 17:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/22/2020 18:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/22/2020 19:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/22/2020 20:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/22/2020 21:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/22/2020 22:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/22/2020 23:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/23/2020 00:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/23/2020 01:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/23/2020 02:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/23/2020 03:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/23/2020 04:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/23/2020 05:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/23/2020 06:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/23/2020 07:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/23/2020 08:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/23/2020 09:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/23/2020 10:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/23/2020 11:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/23/2020 12:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/23/2020 13:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/23/2020 14:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/23/2020 15:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/23/2020 16:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/23/2020 17:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/23/2020 18:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/23/2020 19:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/23/2020 20:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/23/2020 21:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/23/2020 22:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/23/2020 23:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/24/2020 00:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/24/2020 01:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/24/2020 02:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/24/2020 03:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/24/2020 04:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/24/2020 05:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/24/2020 06:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/24/2020 07:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/24/2020 08:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/24/2020 09:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/24/2020 10:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/24/2020 11:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/24/2020 12:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/24/2020 13:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/24/2020 14:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/24/2020 15:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/24/2020 16:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/24/2020 17:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/24/2020 18:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/24/2020 19:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/24/2020 20:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/24/2020 21:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/24/2020 22:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/24/2020 23:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/25/2020 00:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/25/2020 01:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/25/2020 02:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/25/2020 03:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/25/2020 04:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/25/2020 05:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/25/2020 06:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/25/2020 07:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/25/2020 08:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/25/2020 09:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/25/2020 10:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/25/2020 11:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/25/2020 12:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/25/2020 13:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/25/2020 14:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/25/2020 15:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/25/2020 16:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/25/2020 17:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/25/2020 18:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/25/2020 19:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/25/2020 20:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/25/2020 21:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/25/2020 22:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/25/2020 23:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/26/2020 00:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/26/2020 01:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/26/2020 02:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/26/2020 03:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/26/2020 04:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/26/2020 05:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/26/2020 06:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/26/2020 07:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/26/2020 08:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/26/2020 09:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/26/2020 10:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/26/2020 11:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/26/2020 12:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/26/2020 13:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/26/2020 14:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/26/2020 15:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/26/2020 16:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/26/2020 17:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/26/2020 18:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/26/2020 19:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/26/2020 20:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/26/2020 21:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/26/2020 22:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/26/2020 23:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/27/2020 00:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/27/2020 01:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/27/2020 02:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/27/2020 03:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/27/2020 04:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/27/2020 05:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/27/2020 06:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/27/2020 07:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/27/2020 08:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/27/2020 09:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/27/2020 10:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/27/2020 11:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/27/2020 12:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/27/2020 13:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/27/2020 14:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/27/2020 15:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/27/2020 16:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/27/2020 17:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/27/2020 18:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/27/2020 19:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/27/2020 20:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/27/2020 21:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/27/2020 22:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/27/2020 23:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/28/2020 00:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/28/2020 01:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/28/2020 02:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/28/2020 03:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/28/2020 04:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/28/2020 05:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/28/2020 06:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/28/2020 07:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/28/2020 08:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/28/2020 09:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/28/2020 10:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/28/2020 11:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/28/2020 12:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/28/2020 13:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/28/2020 14:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/28/2020 15:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/28/2020 16:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/28/2020 17:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/28/2020 18:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/28/2020 19:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/28/2020 20:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/28/2020 21:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/28/2020 22:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/28/2020 23:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/29/2020 00:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/29/2020 01:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/29/2020 02:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/29/2020 03:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/29/2020 04:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/29/2020 05:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/29/2020 06:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/29/2020 07:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/29/2020 08:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/29/2020 09:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/29/2020 10:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/29/2020 11:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/29/2020 12:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/29/2020 13:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/29/2020 14:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/29/2020 15:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/29/2020 16:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/29/2020 17:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/29/2020 18:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/29/2020 19:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/29/2020 20:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/29/2020 21:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/29/2020 22:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/29/2020 23:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/30/2020 00:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/30/2020 01:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/30/2020 02:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/30/2020 03:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/30/2020 04:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/30/2020 05:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/30/2020 06:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/30/2020 07:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/30/2020 08:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/30/2020 09:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/30/2020 10:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/30/2020 11:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/30/2020 12:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/30/2020 13:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/30/2020 14:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/30/2020 15:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/30/2020 16:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/30/2020 17:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/30/2020 18:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/30/2020 19:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/30/2020 20:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/30/2020 21:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/30/2020 22:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
11/30/2020 23:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/01/2020 00:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/01/2020 01:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/01/2020 02:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/01/2020 03:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/01/2020 04:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/01/2020 05:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/01/2020 06:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/01/2020 07:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/01/2020 08:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/01/2020 09:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/01/2020 10:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/01/2020 11:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/01/2020 12:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/01/2020 13:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/01/2020 14:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/01/2020 15:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/01/2020 16:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/01/2020 17:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/01/2020 18:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/01/2020 19:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/01/2020 20:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/01/2020 21:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/01/2020 22:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/01/2020 23:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:30 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/02/2020 00:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/02/2020 01:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/02/2020 02:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/02/2020 03:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/02/2020 04:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/02/2020 05:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/02/2020 06:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/02/2020 07:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/02/2020 08:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/02/2020 09:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/02/2020 10:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/02/2020 11:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/02/2020 12:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/02/2020 13:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/02/2020 14:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/02/2020 15:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/02/2020 16:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/02/2020 17:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/02/2020 18:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/02/2020 19:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/02/2020 20:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/02/2020 21:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/02/2020 22:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/02/2020 23:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:31 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/03/2020 00:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/03/2020 01:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/03/2020 02:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/03/2020 03:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/03/2020 04:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/03/2020 05:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/03/2020 06:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/03/2020 07:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/03/2020 08:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/03/2020 09:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/03/2020 10:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/03/2020 11:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/03/2020 12:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/03/2020 13:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/03/2020 14:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/03/2020 15:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/03/2020 16:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/03/2020 17:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/03/2020 18:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/03/2020 19:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/03/2020 20:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/03/2020 21:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/03/2020 22:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/03/2020 23:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:31 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/04/2020 00:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/04/2020 01:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/04/2020 02:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/04/2020 03:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/04/2020 04:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/04/2020 05:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/04/2020 06:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/04/2020 07:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/04/2020 08:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/04/2020 09:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/04/2020 10:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/04/2020 11:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/04/2020 12:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/04/2020 13:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/04/2020 14:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/04/2020 15:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/04/2020 16:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/04/2020 17:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/04/2020 18:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/04/2020 19:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/04/2020 20:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/04/2020 21:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/04/2020 22:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/04/2020 23:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:31 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/05/2020 00:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/05/2020 01:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/05/2020 02:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/05/2020 03:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/05/2020 04:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/05/2020 05:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/05/2020 06:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/05/2020 07:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/05/2020 08:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/05/2020 09:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/05/2020 10:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/05/2020 11:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/05/2020 12:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/05/2020 13:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/05/2020 14:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/05/2020 15:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/05/2020 16:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/05/2020 17:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/05/2020 18:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/05/2020 19:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/05/2020 20:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/05/2020 21:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/05/2020 22:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/05/2020 23:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:31 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/06/2020 00:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/06/2020 01:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/06/2020 02:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/06/2020 03:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/06/2020 04:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/06/2020 05:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/06/2020 06:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/06/2020 07:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/06/2020 08:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/06/2020 09:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/06/2020 10:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/06/2020 11:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/06/2020 12:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/06/2020 13:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/06/2020 14:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/06/2020 15:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/06/2020 16:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/06/2020 17:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/06/2020 18:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/06/2020 19:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/06/2020 20:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/06/2020 21:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/06/2020 22:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/06/2020 23:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:31 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/07/2020 00:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/07/2020 01:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/07/2020 02:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/07/2020 03:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/07/2020 04:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/07/2020 05:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/07/2020 06:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/07/2020 07:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/07/2020 08:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/07/2020 09:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/07/2020 10:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/07/2020 11:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/07/2020 12:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/07/2020 13:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/07/2020 14:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/07/2020 15:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/07/2020 16:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/07/2020 17:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/07/2020 18:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/07/2020 19:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/07/2020 20:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/07/2020 21:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/07/2020 22:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/07/2020 23:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:31 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/08/2020 00:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/08/2020 01:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/08/2020 02:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/08/2020 03:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/08/2020 04:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/08/2020 05:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/08/2020 06:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/08/2020 07:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/08/2020 08:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/08/2020 09:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/08/2020 10:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/08/2020 11:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/08/2020 12:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/08/2020 13:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/08/2020 14:00	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
12/08/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/08/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/08/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/08/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/08/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/08/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/08/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/08/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/08/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,987.5	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,100.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:31 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/09/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/09/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/09/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/09/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/09/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/09/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/09/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/09/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/09/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/09/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/09/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/09/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/09/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/09/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/09/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/09/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/09/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/09/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/09/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/09/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/09/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/09/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/09/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/09/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:31 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/10/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/10/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/10/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/10/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/10/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/10/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/10/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/10/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/10/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/10/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/10/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/10/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/10/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/10/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/10/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/10/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/10/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/10/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/10/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/10/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/10/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/10/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/10/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/10/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:31 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/11/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/11/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/11/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/11/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/11/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/11/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/11/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/11/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/11/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/11/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/11/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/11/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/11/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/11/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/11/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/11/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/11/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/11/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/11/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/11/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/11/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/11/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/11/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/11/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:31 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/12/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/12/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/12/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/12/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/12/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/12/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/12/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/12/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/12/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/12/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/12/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/12/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/12/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/12/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/12/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/12/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/12/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/12/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/12/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/12/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/12/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/12/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/12/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/12/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:31 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/13/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/13/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/13/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/13/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/13/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/13/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/13/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/13/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/13/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/13/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/13/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/13/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/13/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/13/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/13/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/13/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/13/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/13/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/13/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/13/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/13/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/13/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/13/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/13/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:31 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/14/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/14/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/14/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/14/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/14/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/14/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/14/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/14/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/14/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/14/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/14/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/14/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/14/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/14/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/14/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/14/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/14/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/14/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/14/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/14/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/14/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/14/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/14/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/14/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:31 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/15/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/15/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/15/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/15/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/15/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/15/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/15/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/15/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/15/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/15/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/15/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/15/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/15/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/15/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/15/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/15/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/15/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/15/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/15/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/15/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/15/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/15/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/15/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/15/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:31 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/16/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/16/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/16/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/16/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/16/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/16/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/16/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/16/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/16/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/16/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/16/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/16/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/16/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/16/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/16/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/16/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/16/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/16/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/16/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/16/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/16/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/16/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/16/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/16/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:31 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/17/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/17/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/17/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/17/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/17/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/17/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/17/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/17/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/17/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/17/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/17/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/17/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/17/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/17/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/17/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/17/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/17/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/17/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/17/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/17/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/17/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/17/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/17/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/17/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:31 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/18/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/18/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/18/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/18/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/18/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/18/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/18/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/18/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/18/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/18/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/18/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/18/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/18/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/18/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/18/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/18/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/18/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/18/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/18/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/18/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/18/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/18/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/18/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/18/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:31 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/19/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/19/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/19/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/19/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/19/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/19/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/19/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/19/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/19/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/19/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/19/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/19/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/19/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/19/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/19/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/19/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/19/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/19/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/19/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/19/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/19/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/19/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/19/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/19/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:31 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/20/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/20/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/20/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/20/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/20/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/20/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/20/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/20/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/20/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/20/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/20/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/20/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/20/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/20/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/20/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/20/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/20/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/20/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/20/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/20/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/20/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/20/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/20/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/20/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:31 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/21/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/21/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/21/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/21/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/21/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/21/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/21/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/21/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/21/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/21/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/21/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/21/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/21/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/21/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/21/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/21/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/21/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/21/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/21/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/21/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/21/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/21/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/21/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/21/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:31 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/22/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/22/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/22/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/22/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/22/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/22/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/22/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/22/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/22/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/22/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/22/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/22/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/22/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/22/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/22/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/22/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/22/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/22/2020 17:00	2,308.7	0.0	2,308.7	104,800.0	242.0	0.00	0.0	0.0
12/22/2020 18:00	3,786.0	0.0	3,786.0	104,800.0	396.8	0.55	0.3	0.9
12/22/2020 19:00	4,245.5	0.0	4,245.5	104,800.0	444.9	0.53	0.3	0.9
12/22/2020 20:00	1,873.2	0.0	1,873.2	104,800.0	196.3	0.00	0.0	0.0
12/22/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/22/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/22/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	3,053.4	0.0	3,053.4	104,800.0	320.0	0.54	0.3	0.9
Minimum:	1,873.2	0.0	1,873.2	104,800.0	196.3	0.53	0.3	0.9
Maximum:	4,245.5	0.0	4,245.5	104,800.0	444.9	0.55	0.3	0.9
%SI	83.33	83.33	83.33	0.00	83.33	91.67	91.67	91.67

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:31 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/23/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/23/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/23/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/23/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/23/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/23/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/23/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/23/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/23/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/23/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/23/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/23/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/23/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/23/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/23/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/23/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/23/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/23/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/23/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/23/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/23/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/23/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/23/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/23/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:31 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/24/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/24/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/24/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/24/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/24/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/24/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/24/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/24/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/24/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/24/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/24/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/24/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/24/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/24/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/24/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/24/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/24/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/24/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/24/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/24/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/24/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/24/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/24/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/24/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:31 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/25/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/25/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/25/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/25/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/25/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/25/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/25/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/25/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/25/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/25/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/25/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/25/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/25/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/25/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/25/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/25/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/25/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/25/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/25/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/25/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/25/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/25/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/25/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/25/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:31 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/26/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/26/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/26/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/26/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/26/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/26/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/26/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/26/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/26/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/26/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/26/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/26/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/26/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/26/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/26/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/26/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/26/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/26/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/26/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/26/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/26/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/26/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/26/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/26/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:31 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/27/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/27/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/27/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/27/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/27/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/27/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/27/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/27/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/27/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/27/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/27/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/27/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/27/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/27/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/27/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/27/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/27/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/27/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/27/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/27/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/27/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/27/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/27/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/27/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:31 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/28/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/28/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/28/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/28/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/28/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/28/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/28/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/28/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/28/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/28/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/28/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/28/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/28/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/28/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/28/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/28/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/28/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/28/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/28/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/28/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/28/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/28/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/28/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/28/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:31 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/29/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/29/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/29/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/29/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/29/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/29/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/29/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/29/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/29/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/29/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/29/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/29/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/29/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/29/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/29/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/29/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/29/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/29/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/29/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/29/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/29/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/29/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/29/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/29/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:31 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/30/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/30/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/30/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/30/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/30/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/30/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/30/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/30/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/30/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/30/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/30/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/30/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/30/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/30/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/30/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/30/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/30/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/30/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/30/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/30/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/30/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/30/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/30/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/30/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:31 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/31/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/31/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/31/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/31/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/31/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/31/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/31/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/31/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/31/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/31/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/31/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/31/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/31/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/31/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/31/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/31/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/31/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/31/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/31/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/31/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/31/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/31/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/31/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
12/31/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/01/2020 00:00	3,314.5	0.0	3,314.5	104,000.0	344.7	0.4	0.2	0.7
10/01/2020 01:00	3,143.8	0.0	3,143.8	104,000.0	327.0	0.4	0.2	0.7
10/01/2020 02:00	3,215.7	0.0	3,215.7	104,000.0	334.4	0.4	0.2	0.7
10/01/2020 03:00	3,245.5	0.0	3,245.5	104,000.0	337.5	0.4	0.2	0.7
10/01/2020 04:00	3,213.7	0.0	3,213.7	104,000.0	334.2	0.4	0.2	0.7
10/01/2020 05:00	2,713.3	0.0	2,713.3	104,000.0	282.2	0.3	0.2	0.6
10/01/2020 06:00	2,719.2	0.0	2,719.2	104,000.0	282.8	0.3	0.2	0.6
10/01/2020 07:00	2,959.6	0.0	2,959.6	104,000.0	307.8	0.4	0.2	0.6
10/01/2020 08:00	3,348.2	0.0	3,348.2	104,000.0	348.2	0.4	0.2	0.7
10/01/2020 09:00	3,706.1	0.2	3,706.1	104,000.0	385.4	0.5	0.2	0.8
10/01/2020 10:00	3,880.2	488.8	4,369.0	104,000.0	454.4	0.5	0.3	0.9
10/01/2020 11:00	3,861.0	1,223.7	5,084.7	104,000.0	528.8	0.6	0.3	1.1
10/01/2020 12:00	3,833.7	1,478.3	5,312.0	104,000.0	552.4	0.7	0.3	1.1
10/01/2020 13:00	3,821.2	1,738.2	5,559.4	104,000.0	578.2	0.7	0.3	1.2
10/01/2020 14:00	3,814.4	1,873.8	5,688.2	104,000.0	591.6	0.7	0.4	1.2
10/01/2020 15:00	3,800.3	1,369.4	5,169.7	104,000.0	537.6	0.6	0.3	1.1
10/01/2020 16:00	3,808.4	1,891.2	5,699.6	104,000.0	592.8	0.7	0.4	1.2
10/01/2020 17:00	3,809.5	1,690.7	5,500.2	104,000.0	572.0	0.7	0.3	1.1
10/01/2020 18:00	3,835.8	68.5	3,844.7	104,000.0	399.8	0.5	0.2	0.8
10/01/2020 19:00	3,843.0	334.6	4,144.1	104,000.0	431.0	0.5	0.3	0.9
10/01/2020 20:00	3,858.3	387.1	4,187.3	104,000.0	435.5	0.5	0.3	0.9
10/01/2020 21:00	3,859.8	731.0	4,590.8	104,000.0	477.4	0.6	0.3	1.0
10/01/2020 22:00	3,768.3	26.2	3,770.4	104,000.0	392.1	0.5	0.2	0.8
10/01/2020 23:00	3,474.4	0.0	3,474.4	104,000.0	361.3	0.4	0.2	0.7
Average/Sum#:	3,535.3	554.2	4,082.3	104,000.0	424.5	0.5	0.3	0.9
Minimum:	2,713.3	0.0	2,713.3	104,000.0	282.2	0.3	0.2	0.6
Maximum:	3,880.2	1,891.2	5,699.6	104,000.0	592.8	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/02/2020 00:00	3,234.6	0.0	3,234.6	104,000.0	336.4	0.4	0.2	0.7
10/02/2020 01:00	3,162.7	0.0	3,162.7	104,000.0	328.9	0.4	0.2	0.7
10/02/2020 02:00	2,918.6	0.0	2,918.6	104,000.0	303.5	0.4	0.2	0.6
10/02/2020 03:00	2,901.2	0.0	2,901.2	104,000.0	301.7	0.4	0.2	0.6
10/02/2020 04:00	3,064.2	0.0	3,064.2	104,000.0	318.7	0.4	0.2	0.6
10/02/2020 05:00	2,719.1	0.0	2,719.1	104,000.0	282.8	0.3	0.2	0.6
10/02/2020 06:00	2,719.3	0.0	2,719.3	104,000.0	282.8	0.3	0.2	0.6
10/02/2020 07:00	2,718.7	0.0	2,718.7	104,000.0	282.7	0.3	0.2	0.6
10/02/2020 08:00	2,713.4	0.0	2,713.4	104,000.0	282.2	0.3	0.2	0.6
10/02/2020 09:00	2,848.9	0.0	2,848.9	104,000.0	296.3	0.4	0.2	0.6
10/02/2020 10:00	3,133.0	0.0	3,133.0	104,000.0	325.8	0.4	0.2	0.7
10/02/2020 11:00	3,520.7	0.0	3,520.7	104,000.0	366.2	0.4	0.2	0.7
10/02/2020 12:00	3,817.3	152.9	3,944.2	104,000.0	410.2	0.5	0.2	0.8
10/02/2020 13:00	3,813.4	333.4	4,146.8	104,000.0	431.3	0.5	0.3	0.9
10/02/2020 14:00	3,809.6	699.8	4,509.4	104,000.0	469.0	0.6	0.3	0.9
10/02/2020 15:00	3,801.5	73.8	3,825.9	104,000.0	397.9	0.5	0.2	0.8
10/02/2020 16:00	3,808.0	1,247.0	5,055.0	104,000.0	525.7	0.6	0.3	1.1
10/02/2020 17:00	3,821.8	888.2	4,710.0	104,000.0	489.8	0.6	0.3	1.0
10/02/2020 18:00	3,449.6	75.8	3,458.7	104,000.0	359.7	0.4	0.2	0.7
10/02/2020 19:00	3,839.8	359.6	4,145.5	104,000.0	431.1	0.5	0.3	0.9
10/02/2020 20:00	3,186.5	0.0	3,186.5	104,000.0	331.4	0.4	0.2	0.7
10/02/2020 21:00	3,713.1	296.1	3,964.8	104,000.0	412.3	0.5	0.3	0.8
10/02/2020 22:00	3,704.5	0.0	3,704.5	104,000.0	385.3	0.5	0.2	0.8
10/02/2020 23:00	3,501.6	0.0	3,501.6	104,000.0	364.2	0.4	0.2	0.7
Average/Sum#:	3,330.0	171.9	3,492.0	104,000.0	363.2	0.4	0.2	0.7
Minimum:	2,713.4	0.0	2,713.4	104,000.0	282.2	0.3	0.2	0.6
Maximum:	3,839.8	1,247.0	5,055.0	104,000.0	525.7	0.6	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/03/2020 00:00	3,173.3	0.0	3,173.3	104,000.0	330.0	0.4	0.2	0.7
10/03/2020 01:00	2,937.6	0.0	2,937.6	104,000.0	305.5	0.4	0.2	0.6
10/03/2020 02:00	2,713.4	0.0	2,713.4	104,000.0	282.2	0.3	0.2	0.6
10/03/2020 03:00	2,718.4	0.0	2,718.4	104,000.0	282.7	0.3	0.2	0.6
10/03/2020 04:00	2,718.5	0.0	2,718.5	104,000.0	282.7	0.3	0.2	0.6
10/03/2020 05:00	2,718.5	0.0	2,718.5	104,000.0	282.7	0.3	0.2	0.6
10/03/2020 06:00	2,717.8	0.0	2,717.8	104,000.0	282.7	0.3	0.2	0.6
10/03/2020 07:00	2,719.0	0.0	2,719.0	104,000.0	282.8	0.3	0.2	0.6
10/03/2020 08:00	2,937.1	0.0	2,937.1	104,000.0	305.5	0.4	0.2	0.6
10/03/2020 09:00	3,424.7	0.0	3,424.7	104,000.0	356.2	0.4	0.2	0.7
10/03/2020 10:00	3,630.4	0.0	3,630.4	104,000.0	377.6	0.5	0.2	0.8
10/03/2020 11:00	3,837.4	0.0	3,837.4	104,000.0	399.1	0.5	0.2	0.8
10/03/2020 12:00	3,734.9	0.0	3,734.9	104,000.0	388.4	0.5	0.2	0.8
10/03/2020 13:00	3,822.4	268.7	4,091.1	104,000.0	425.5	0.5	0.3	0.9
10/03/2020 14:00	3,808.9	1,002.4	4,811.3	104,000.0	500.4	0.6	0.3	1.0
10/03/2020 15:00	3,801.5	111.0	3,827.0	104,000.0	398.0	0.5	0.2	0.8
10/03/2020 16:00	3,799.0	243.5	4,025.5	104,000.0	418.7	0.5	0.3	0.8
10/03/2020 17:00	3,801.5	5.2	3,801.8	104,000.0	395.4	0.5	0.2	0.8
10/03/2020 18:00	3,830.0	1,437.2	5,267.2	104,000.0	547.8	0.7	0.3	1.1
10/03/2020 19:00	3,842.2	691.4	4,485.2	104,000.0	466.5	0.6	0.3	0.9
10/03/2020 20:00	3,854.1	0.6	3,854.1	104,000.0	400.8	0.5	0.2	0.8
10/03/2020 21:00	3,861.1	389.8	4,204.1	104,000.0	437.2	0.5	0.3	0.9
10/03/2020 22:00	3,744.2	0.0	3,744.2	104,000.0	389.4	0.5	0.2	0.8
10/03/2020 23:00	3,612.8	0.0	3,612.8	104,000.0	375.7	0.4	0.2	0.8
Average/Sum#:	3,406.6	172.9	3,571.1	104,000.0	371.4	0.4	0.2	0.8
Minimum:	2,713.4	0.0	2,713.4	104,000.0	282.2	0.3	0.2	0.6
Maximum:	3,861.1	1,437.2	5,267.2	104,000.0	547.8	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/04/2020 00:00	3,214.9	0.0	3,214.9	104,000.0	334.3	0.4	0.2	0.7
10/04/2020 01:00	3,272.4	0.0	3,272.4	104,000.0	340.3	0.4	0.2	0.7
10/04/2020 02:00	2,899.1	0.0	2,899.1	104,000.0	301.5	0.4	0.2	0.6
10/04/2020 03:00	2,715.5	0.0	2,715.5	104,000.0	282.4	0.3	0.2	0.6
10/04/2020 04:00	2,757.4	0.0	2,757.4	104,000.0	286.8	0.3	0.2	0.6
10/04/2020 05:00	2,879.0	0.0	2,879.0	104,000.0	299.4	0.4	0.2	0.6
10/04/2020 06:00	2,955.3	0.0	2,955.3	104,000.0	307.4	0.4	0.2	0.6
10/04/2020 07:00	3,329.0	0.0	3,329.0	104,000.0	346.2	0.4	0.2	0.7
10/04/2020 08:00	3,607.2	0.0	3,607.2	104,000.0	375.1	0.4	0.2	0.8
10/04/2020 09:00	3,782.2	0.0	3,782.2	104,000.0	393.3	0.5	0.2	0.8
10/04/2020 10:00	3,882.3	45.8	3,922.6	104,000.0	408.0	0.5	0.2	0.8
10/04/2020 11:00	3,863.7	689.5	4,553.2	104,000.0	473.5	0.6	0.3	0.9
10/04/2020 12:00	3,839.4	1,393.2	5,232.6	104,000.0	544.2	0.7	0.3	1.1
10/04/2020 13:00	3,818.0	1,787.2	5,605.2	104,000.0	582.9	0.7	0.3	1.2
10/04/2020 14:00	3,814.0	1,830.4	5,644.4	104,000.0	587.0	0.7	0.4	1.2
10/04/2020 15:00	3,818.4	1,818.9	5,637.3	104,000.0	586.3	0.7	0.4	1.2
10/04/2020 16:00	3,825.9	1,597.3	5,423.2	104,000.0	564.0	0.7	0.3	1.1
10/04/2020 17:00	3,825.3	1,262.1	5,087.4	104,000.0	529.1	0.6	0.3	1.1
10/04/2020 18:00	3,834.4	1,045.4	4,806.6	104,000.0	499.9	0.6	0.3	1.0
10/04/2020 19:00	3,840.5	65.0	3,890.6	104,000.0	404.6	0.5	0.2	0.8
10/04/2020 20:00	3,823.4	0.0	3,823.4	104,000.0	397.6	0.5	0.2	0.8
10/04/2020 21:00	3,847.2	0.0	3,847.2	104,000.0	400.1	0.5	0.2	0.8
10/04/2020 22:00	3,437.9	0.0	3,437.9	104,000.0	357.5	0.4	0.2	0.7
10/04/2020 23:00	3,121.7	0.0	3,121.7	104,000.0	324.7	0.4	0.2	0.6
Average/Sum#:	3,500.2	480.6	3,976.9	104,000.0	413.6	0.5	0.2	0.8
Minimum:	2,715.5	0.0	2,715.5	104,000.0	282.4	0.3	0.2	0.6
Maximum:	3,882.3	1,830.4	5,644.4	104,000.0	587.0	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/05/2020 00:00	2,885.4	0.0	2,885.4	104,000.0	300.1	0.4	0.2	0.6
10/05/2020 01:00	2,709.4	0.0	2,709.4	104,000.0	281.8	0.3	0.2	0.6
10/05/2020 02:00	2,714.0	0.0	2,714.0	104,000.0	282.3	0.3	0.2	0.6
10/05/2020 03:00	2,730.1	0.0	2,730.1	104,000.0	283.9	0.3	0.2	0.6
10/05/2020 04:00	2,884.0	0.0	2,884.0	104,000.0	299.9	0.4	0.2	0.6
10/05/2020 05:00	3,188.7	0.0	3,188.7	104,000.0	331.6	0.4	0.2	0.7
10/05/2020 06:00	3,349.3	0.0	3,349.3	104,000.0	348.3	0.4	0.2	0.7
10/05/2020 07:00	3,578.6	0.0	3,578.6	104,000.0	372.2	0.4	0.2	0.7
10/05/2020 08:00	3,858.4	0.0	3,858.4	104,000.0	401.3	0.5	0.2	0.8
10/05/2020 09:00	3,945.6	2.8	3,945.7	104,000.0	410.4	0.5	0.2	0.8
10/05/2020 10:00	3,909.2	222.1	4,131.3	104,000.0	429.7	0.5	0.3	0.9
10/05/2020 11:00	3,874.8	856.8	4,731.6	104,000.0	492.1	0.6	0.3	1.0
10/05/2020 12:00	3,853.5	692.1	4,545.6	104,000.0	472.7	0.6	0.3	0.9
10/05/2020 13:00	3,837.4	1,700.1	5,537.5	104,000.0	575.9	0.7	0.3	1.2
10/05/2020 14:00	3,825.3	1,903.4	5,728.7	104,000.0	595.8	0.7	0.4	1.2
10/05/2020 15:00	3,818.8	1,903.3	5,722.1	104,000.0	595.1	0.7	0.4	1.2
10/05/2020 16:00	3,823.7	1,903.4	5,727.1	104,000.0	595.6	0.7	0.4	1.2
10/05/2020 17:00	3,834.5	1,598.5	5,433.0	104,000.0	565.0	0.7	0.3	1.1
10/05/2020 18:00	3,842.8	1,245.8	5,088.6	104,000.0	529.2	0.6	0.3	1.1
10/05/2020 19:00	3,867.2	1,060.1	4,927.3	104,000.0	512.4	0.6	0.3	1.0
10/05/2020 20:00	3,887.2	496.3	4,343.8	104,000.0	451.8	0.5	0.3	0.9
10/05/2020 21:00	3,881.2	0.0	3,881.2	104,000.0	403.6	0.5	0.2	0.8
10/05/2020 22:00	3,466.7	0.0	3,466.7	104,000.0	360.5	0.4	0.2	0.7
10/05/2020 23:00	3,190.9	0.0	3,190.9	104,000.0	331.9	0.4	0.2	0.7
Average/Sum#:	3,531.5	566.0	4,095.8	104,000.0	426.0	0.5	0.3	0.9
Minimum:	2,709.4	0.0	2,709.4	104,000.0	281.8	0.3	0.2	0.6
Maximum:	3,945.6	1,903.4	5,728.7	104,000.0	595.8	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/06/2020 00:00	2,902.4	0.0	2,902.4	104,000.0	301.8	0.4	0.2	0.6
10/06/2020 01:00	2,735.7	0.0	2,735.7	104,000.0	284.5	0.3	0.2	0.6
10/06/2020 02:00	2,706.0	0.0	2,706.0	104,000.0	281.4	0.3	0.2	0.6
10/06/2020 03:00	2,708.5	0.0	2,708.5	104,000.0	281.7	0.3	0.2	0.6
10/06/2020 04:00	2,709.5	0.0	2,709.5	104,000.0	281.8	0.3	0.2	0.6
10/06/2020 05:00	3,115.8	0.0	3,115.8	104,000.0	324.0	0.4	0.2	0.6
10/06/2020 06:00	3,193.1	0.0	3,193.1	104,000.0	332.1	0.4	0.2	0.7
10/06/2020 07:00	3,364.7	0.0	3,364.7	104,000.0	349.9	0.4	0.2	0.7
10/06/2020 08:00	3,730.4	0.0	3,730.4	104,000.0	388.0	0.5	0.2	0.8
10/06/2020 09:00	3,877.2	0.3	3,877.2	104,000.0	403.2	0.5	0.2	0.8
10/06/2020 10:00	3,876.2	234.3	4,110.5	104,000.0	427.5	0.5	0.3	0.9
10/06/2020 11:00	3,844.7	716.0	4,560.7	104,000.0	474.3	0.6	0.3	0.9
10/06/2020 12:00	3,794.7	162.4	3,856.4	104,000.0	401.1	0.5	0.2	0.8
10/06/2020 13:00	3,799.9	1,166.8	4,850.0	104,000.0	504.4	0.6	0.3	1.0
10/06/2020 14:00	3,790.1	1,370.8	5,160.9	104,000.0	536.7	0.6	0.3	1.1
10/06/2020 15:00	3,787.0	1,776.1	5,563.1	104,000.0	578.6	0.7	0.3	1.2
10/06/2020 16:00	3,787.2	1,773.5	5,560.7	104,000.0	578.3	0.7	0.3	1.2
10/06/2020 17:00	3,800.4	1,327.3	5,127.7	104,000.0	533.3	0.6	0.3	1.1
10/06/2020 18:00	3,812.0	979.3	4,791.3	104,000.0	498.3	0.6	0.3	1.0
10/06/2020 19:00	3,827.0	1,177.9	5,004.9	104,000.0	520.5	0.6	0.3	1.0
10/06/2020 20:00	3,835.8	1,140.1	4,975.9	104,000.0	517.5	0.6	0.3	1.0
10/06/2020 21:00	3,828.5	83.8	3,903.9	104,000.0	406.0	0.5	0.2	0.8
10/06/2020 22:00	3,445.8	0.0	3,445.8	104,000.0	358.4	0.4	0.2	0.7
10/06/2020 23:00	3,151.9	0.0	3,151.9	104,000.0	327.8	0.4	0.2	0.7
Average/Sum#:	3,476.0	496.2	3,962.8	104,000.0	412.1	0.5	0.2	0.8
Minimum:	2,706.0	0.0	2,706.0	104,000.0	281.4	0.3	0.2	0.6
Maximum:	3,877.2	1,776.1	5,563.1	104,000.0	578.6	0.7	0.3	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/07/2020 00:00	3,102.6	0.0	3,102.6	104,000.0	322.7	0.4	0.2	0.6
10/07/2020 01:00	2,845.7	0.0	2,845.7	104,000.0	296.0	0.4	0.2	0.6
10/07/2020 02:00	2,686.6	0.0	2,686.6	104,000.0	279.4	0.3	0.2	0.6
10/07/2020 03:00	2,695.8	0.0	2,695.8	104,000.0	280.4	0.3	0.2	0.6
10/07/2020 04:00	2,834.2	0.0	2,834.2	104,000.0	294.8	0.4	0.2	0.6
10/07/2020 05:00	3,836.4	158.1	3,975.5	104,000.0	413.5	0.5	0.2	0.8
10/07/2020 06:00	3,842.1	170.0	4,007.0	104,000.0	416.7	0.5	0.3	0.8
10/07/2020 07:00	3,286.7	0.0	3,286.7	104,000.0	341.8	0.4	0.2	0.7
10/07/2020 08:00	3,586.1	0.0	3,586.1	104,000.0	373.0	0.4	0.2	0.7
10/07/2020 09:00	3,772.0	0.0	3,772.0	104,000.0	392.3	0.5	0.2	0.8
10/07/2020 10:00	3,875.4	160.3	4,014.9	104,000.0	417.5	0.5	0.3	0.8
10/07/2020 11:00	3,848.0	405.2	4,253.2	104,000.0	442.3	0.5	0.3	0.9
10/07/2020 12:00	3,834.1	662.0	4,496.1	104,000.0	467.6	0.6	0.3	0.9
10/07/2020 13:00	3,826.5	1,045.7	4,872.2	104,000.0	506.7	0.6	0.3	1.0
10/07/2020 14:00	3,812.7	1,831.5	5,644.2	104,000.0	587.0	0.7	0.4	1.2
10/07/2020 15:00	3,818.1	1,769.9	5,588.0	104,000.0	581.2	0.7	0.3	1.2
10/07/2020 16:00	3,818.6	578.9	4,397.5	104,000.0	457.3	0.5	0.3	0.9
10/07/2020 17:00	3,848.9	221.0	4,069.9	104,000.0	423.3	0.5	0.3	0.8
10/07/2020 18:00	3,871.3	27.7	3,899.0	104,000.0	405.5	0.5	0.2	0.8
10/07/2020 19:00	3,885.3	129.3	4,014.6	104,000.0	417.5	0.5	0.3	0.8
10/07/2020 20:00	3,884.7	494.7	4,369.5	104,000.0	454.4	0.5	0.3	0.9
10/07/2020 21:00	3,549.4	0.0	3,549.4	104,000.0	369.1	0.4	0.2	0.7
10/07/2020 22:00	3,248.6	0.0	3,248.6	104,000.0	337.9	0.4	0.2	0.7
10/07/2020 23:00	3,064.5	0.0	3,064.5	104,000.0	318.7	0.4	0.2	0.6
Average/Sum#:	3,528.1	318.9	3,844.7	104,000.0	399.9	0.5	0.3	0.8
Minimum:	2,686.6	0.0	2,686.6	104,000.0	279.4	0.3	0.2	0.6
Maximum:	3,885.3	1,831.5	5,644.2	104,000.0	587.0	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/08/2020 00:00	2,776.0	0.0	2,776.0	104,000.0	288.7	0.3	0.2	0.6
10/08/2020 01:00	2,695.9	0.0	2,695.9	104,000.0	280.4	0.3	0.2	0.6
10/08/2020 02:00	2,696.6	0.0	2,696.6	104,000.0	280.4	0.3	0.2	0.6
10/08/2020 03:00	2,698.3	0.0	2,698.3	104,000.0	280.6	0.3	0.2	0.6
10/08/2020 04:00	2,706.4	0.0	2,706.4	104,000.0	281.5	0.3	0.2	0.6
10/08/2020 05:00	3,417.4	0.0	3,417.4	104,000.0	355.4	0.4	0.2	0.7
10/08/2020 06:00	3,462.2	0.0	3,462.2	104,000.0	360.1	0.4	0.2	0.7
10/08/2020 07:00	3,724.8	0.0	3,724.8	104,000.0	387.4	0.5	0.2	0.8
10/08/2020 08:00	3,885.1	40.4	3,892.4	104,000.0	404.8	0.5	0.2	0.8
10/08/2020 09:00	3,871.1	664.8	4,535.9	104,000.0	471.7	0.6	0.3	0.9
10/08/2020 10:00	3,846.8	1,098.4	4,945.2	104,000.0	514.3	0.6	0.3	1.0
10/08/2020 11:00	3,817.3	956.9	4,774.2	104,000.0	496.5	0.6	0.3	1.0
10/08/2020 12:00	3,790.3	1,205.0	4,995.3	104,000.0	519.5	0.6	0.3	1.0
10/08/2020 13:00	3,766.8	1,270.5	5,037.3	104,000.0	523.9	0.6	0.3	1.0
10/08/2020 14:00	3,742.5	932.7	4,675.2	104,000.0	486.2	0.6	0.3	1.0
10/08/2020 15:00	3,295.6	17.3	3,296.5	104,000.0	342.8	0.4	0.2	0.7
10/08/2020 16:00	3,265.7	0.0	3,265.7	104,000.0	339.6	0.4	0.2	0.7
10/08/2020 17:00	3,284.9	0.0	3,284.9	104,000.0	341.6	0.4	0.2	0.7
10/08/2020 18:00	3,553.6	0.0	3,553.6	104,000.0	369.6	0.4	0.2	0.7
10/08/2020 19:00	3,901.0	1,702.0	5,603.0	104,000.0	582.7	0.7	0.3	1.2
10/08/2020 20:00	3,917.6	495.9	4,413.5	104,000.0	459.0	0.6	0.3	0.9
10/08/2020 21:00	3,936.4	1,628.9	5,565.3	104,000.0	578.8	0.7	0.3	1.2
10/08/2020 22:00	3,946.1	1,862.7	5,808.8	104,000.0	604.1	0.7	0.4	1.2
10/08/2020 23:00	3,619.7	23.7	3,621.6	104,000.0	376.6	0.5	0.2	0.8
Average/Sum#:	3,484.1	495.8	3,976.9	104,000.0	413.6	0.5	0.2	0.8
Minimum:	2,695.9	0.0	2,695.9	104,000.0	280.4	0.3	0.2	0.6
Maximum:	3,946.1	1,862.7	5,808.8	104,000.0	604.1	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/09/2020 00:00	3,298.5	0.0	3,298.5	104,000.0	343.0	0.4	0.2	0.7
10/09/2020 01:00	3,107.6	0.0	3,107.6	104,000.0	323.2	0.4	0.2	0.6
10/09/2020 02:00	3,122.6	0.0	3,122.6	104,000.0	324.8	0.4	0.2	0.7
10/09/2020 03:00	3,139.0	0.0	3,139.0	104,000.0	326.5	0.4	0.2	0.7
10/09/2020 04:00	3,403.7	0.0	3,403.7	104,000.0	354.0	0.4	0.2	0.7
10/09/2020 05:00	3,709.0	0.0	3,709.0	104,000.0	385.7	0.5	0.2	0.8
10/09/2020 06:00	3,883.7	1.0	3,883.8	104,000.0	403.9	0.5	0.2	0.8
10/09/2020 07:00	3,920.7	6.4	3,927.1	104,000.0	408.4	0.5	0.2	0.8
10/09/2020 08:00	3,908.4	503.4	4,411.8	104,000.0	458.8	0.6	0.3	0.9
10/09/2020 09:00	3,883.5	1,001.7	4,885.2	104,000.0	508.1	0.6	0.3	1.0
10/09/2020 10:00	3,847.5	1,203.6	5,051.1	104,000.0	525.3	0.6	0.3	1.1
10/09/2020 11:00	3,825.4	1,437.3	5,262.7	104,000.0	547.3	0.7	0.3	1.1
10/09/2020 12:00	3,848.3	1,506.5	5,354.8	104,000.0	556.9	0.7	0.3	1.1
10/09/2020 13:00	3,873.4	1,080.4	4,953.8	104,000.0	515.2	0.6	0.3	1.0
10/09/2020 14:00	3,861.6	1,300.9	5,162.5	104,000.0	536.9	0.6	0.3	1.1
10/09/2020 15:00	3,853.6	461.8	4,315.4	104,000.0	448.8	0.5	0.3	0.9
10/09/2020 16:00	3,854.5	50.6	3,868.2	104,000.0	402.3	0.5	0.2	0.8
10/09/2020 17:00	3,876.3	494.0	4,370.3	104,000.0	454.5	0.5	0.3	0.9
10/09/2020 18:00	3,888.6	618.0	4,506.6	104,000.0	468.7	0.6	0.3	0.9
10/09/2020 19:00	3,853.0	356.2	4,077.4	104,000.0	424.0	0.5	0.3	0.9
10/09/2020 20:00	3,622.8	0.0	3,622.8	104,000.0	376.8	0.5	0.2	0.8
10/09/2020 21:00	3,680.1	0.0	3,680.1	104,000.0	382.7	0.5	0.2	0.8
10/09/2020 22:00	3,761.8	0.0	3,761.8	104,000.0	391.2	0.5	0.2	0.8
10/09/2020 23:00	3,305.0	0.0	3,305.0	104,000.0	343.7	0.4	0.2	0.7
Average/Sum#:	3,680.4	417.6	4,090.9	104,000.0	425.4	0.5	0.2	0.9
Minimum:	3,107.6	0.0	3,107.6	104,000.0	323.2	0.4	0.2	0.6
Maximum:	3,920.7	1,506.5	5,354.8	104,000.0	556.9	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/10/2020 00:00	3,086.1	0.0	3,086.1	104,000.0	321.0	0.4	0.2	0.6
10/10/2020 01:00	2,918.3	0.0	2,918.3	104,000.0	303.5	0.4	0.2	0.6
10/10/2020 02:00	2,829.4	0.0	2,829.4	104,000.0	294.3	0.4	0.2	0.6
10/10/2020 03:00	2,822.0	0.0	2,822.0	104,000.0	293.5	0.4	0.2	0.6
10/10/2020 04:00	2,827.5	0.0	2,827.5	104,000.0	294.1	0.4	0.2	0.6
10/10/2020 05:00	3,090.2	0.0	3,090.2	104,000.0	321.4	0.4	0.2	0.6
10/10/2020 06:00	3,160.7	0.0	3,160.7	104,000.0	328.7	0.4	0.2	0.7
10/10/2020 07:00	3,519.1	0.0	3,519.1	104,000.0	366.0	0.4	0.2	0.7
10/10/2020 08:00	3,680.0	14.7	3,681.0	104,000.0	382.8	0.5	0.2	0.8
10/10/2020 09:00	3,855.3	663.7	4,519.0	104,000.0	470.0	0.6	0.3	0.9
10/10/2020 10:00	3,831.5	922.7	4,754.2	104,000.0	494.4	0.6	0.3	1.0
10/10/2020 11:00	3,849.5	971.5	4,821.0	104,000.0	501.4	0.6	0.3	1.0
10/10/2020 12:00	3,832.9	870.6	4,703.5	104,000.0	489.2	0.6	0.3	1.0
10/10/2020 13:00	3,700.3	43.7	3,722.6	104,000.0	387.2	0.5	0.2	0.8
10/10/2020 14:00	236.2	0.0	236.2	104,000.0	24.6	0.0	0.0	0.0
10/10/2020 15:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/10/2020 16:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/10/2020 17:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/10/2020 18:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/10/2020 19:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/10/2020 20:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/10/2020 21:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/10/2020 22:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/10/2020 23:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,149.3	232.5	3,379.4	104,000.0	351.5	0.5	0.2	0.8
Minimum:	236.2	0.0	236.2	104,000.0	24.6	0.4	0.2	0.6
Maximum:	3,855.3	971.5	4,821.0	104,000.0	501.4	0.6	0.3	1.0
%SI	37.50	37.50	37.50	0.00	37.50	41.67	41.67	41.67

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/11/2020 00:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/11/2020 01:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/11/2020 02:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/11/2020 03:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/11/2020 04:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/11/2020 05:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/11/2020 06:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/11/2020 07:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/11/2020 08:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/11/2020 09:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/11/2020 10:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/11/2020 11:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/11/2020 12:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/11/2020 13:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/11/2020 14:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/11/2020 15:00	44.7	0.0	44.7	104,000.0	4.6	0.0	0.0	0.0
10/11/2020 16:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/11/2020 17:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/11/2020 18:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/11/2020 19:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/11/2020 20:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/11/2020 21:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/11/2020 22:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/11/2020 23:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
Average/Sum#:	44.7	0.0	44.7	104,000.0	4.6	0.0	0.0	0.0
Minimum:	44.7	0.0	44.7	104,000.0	4.6	0.0	0.0	0.0
Maximum:	44.7	0.0	44.7	104,000.0	4.6	0.0	0.0	0.0
%SI	95.83	95.83	95.83	0.00	95.83	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/12/2020 00:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/12/2020 01:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/12/2020 02:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/12/2020 03:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/12/2020 04:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/12/2020 05:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/12/2020 06:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/12/2020 07:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/12/2020 08:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/12/2020 09:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/12/2020 10:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/12/2020 11:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/12/2020 12:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/12/2020 13:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/12/2020 14:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/12/2020 15:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/12/2020 16:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/12/2020 17:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/12/2020 18:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/12/2020 19:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/12/2020 20:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/12/2020 21:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/12/2020 22:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/12/2020 23:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/13/2020 00:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/13/2020 01:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/13/2020 02:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/13/2020 03:00	0.0	0.0	0.0	104,000.0	0.0	0.0	0.0	0.0
10/13/2020 04:00	530.3	0.0	530.3	104,000.0	55.2	0.0	0.0	0.0
10/13/2020 05:00	531.0	0.0	531.0	104,000.0	55.2	0.0	0.0	0.0
10/13/2020 06:00	565.5	0.0	565.5	104,000.0	58.8	0.0	0.0	0.0
10/13/2020 07:00	663.9	0.0	663.9	104,000.0	69.0	0.0	0.0	0.0
10/13/2020 08:00	2,640.7	0.0	2,640.7	104,000.0	274.6	0.0	0.0	0.0
10/13/2020 09:00	2,861.3	0.0	2,861.3	104,000.0	297.6	0.4	0.2	0.6
10/13/2020 10:00	3,847.1	248.2	4,063.0	104,000.0	422.6	0.5	0.3	0.9
10/13/2020 11:00	3,687.6	928.0	4,615.6	104,000.0	480.0	0.6	0.3	1.0
10/13/2020 12:00	3,592.4	1,031.6	4,624.0	104,000.0	480.9	0.6	0.3	1.0
10/13/2020 13:00	3,516.1	1,084.9	4,601.0	104,000.0	478.5	0.6	0.3	1.0
10/13/2020 14:00	3,619.8	763.5	4,383.3	104,000.0	455.9	0.5	0.3	0.9
10/13/2020 15:00	3,843.1	586.1	4,429.2	104,000.0	460.6	0.6	0.3	0.9
10/13/2020 16:00	3,843.6	728.0	4,571.6	104,000.0	475.4	0.6	0.3	1.0
10/13/2020 17:00	3,855.5	568.1	4,423.6	104,000.0	460.1	0.6	0.3	0.9
10/13/2020 18:00	3,868.5	313.7	4,150.8	104,000.0	431.7	0.5	0.3	0.9
10/13/2020 19:00	3,809.7	0.9	3,809.7	104,000.0	396.2	0.5	0.2	0.8
10/13/2020 20:00	3,904.5	483.2	4,387.7	104,000.0	456.3	0.5	0.3	0.9
10/13/2020 21:00	3,762.0	2.0	3,762.1	104,000.0	391.3	0.5	0.2	0.8
10/13/2020 22:00	3,474.1	0.0	3,474.1	104,000.0	361.3	0.4	0.2	0.7
10/13/2020 23:00	3,134.4	0.0	3,134.4	104,000.0	326.0	0.4	0.2	0.7
Average/Sum#:	2,977.6	336.9	3,311.1	104,000.0	344.4	0.5	0.3	0.9
Minimum:	530.3	0.0	530.3	104,000.0	55.2	0.4	0.2	0.6
Maximum:	3,904.5	1,084.9	4,624.0	104,000.0	480.9	0.6	0.3	1.0
%SI	16.67	16.67	16.67	0.00	16.67	37.50	37.50	37.50

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/14/2020 00:00	3,006.3	0.0	3,006.3	104,000.0	312.7	0.4	0.2	0.6
10/14/2020 01:00	2,766.1	0.0	2,766.1	104,000.0	287.7	0.3	0.2	0.6
10/14/2020 02:00	2,697.9	0.0	2,697.9	104,000.0	280.6	0.3	0.2	0.6
10/14/2020 03:00	2,708.6	0.0	2,708.6	104,000.0	281.7	0.3	0.2	0.6
10/14/2020 04:00	2,860.2	0.0	2,860.2	104,000.0	297.5	0.4	0.2	0.6
10/14/2020 05:00	3,225.9	0.0	3,225.9	104,000.0	335.5	0.4	0.2	0.7
10/14/2020 06:00	3,373.8	0.0	3,373.8	104,000.0	350.9	0.4	0.2	0.7
10/14/2020 07:00	3,532.6	0.0	3,532.6	104,000.0	367.4	0.4	0.2	0.7
10/14/2020 08:00	3,791.1	0.0	3,791.1	104,000.0	394.3	0.5	0.2	0.8
10/14/2020 09:00	3,800.4	0.0	3,800.4	104,000.0	395.2	0.5	0.2	0.8
10/14/2020 10:00	3,891.4	23.4	3,895.4	104,000.0	405.1	0.5	0.2	0.8
10/14/2020 11:00	3,871.1	270.3	4,141.4	104,000.0	430.7	0.5	0.3	0.9
10/14/2020 12:00	3,858.9	590.2	4,449.1	104,000.0	462.7	0.6	0.3	0.9
10/14/2020 13:00	3,851.4	1,058.4	4,909.8	104,000.0	510.6	0.6	0.3	1.0
10/14/2020 14:00	3,855.5	1,844.0	5,699.5	104,000.0	592.7	0.7	0.4	1.2
10/14/2020 15:00	3,853.6	1,850.5	5,704.1	104,000.0	593.2	0.7	0.4	1.2
10/14/2020 16:00	3,866.4	1,589.6	5,456.0	104,000.0	567.4	0.7	0.3	1.1
10/14/2020 17:00	3,893.9	1,173.0	5,066.9	104,000.0	527.0	0.6	0.3	1.1
10/14/2020 18:00	3,911.9	982.2	4,894.1	104,000.0	509.0	0.6	0.3	1.0
10/14/2020 19:00	3,622.4	1.4	3,622.4	104,000.0	376.7	0.5	0.2	0.8
10/14/2020 20:00	3,924.3	282.8	4,159.0	104,000.0	432.5	0.5	0.3	0.9
10/14/2020 21:00	3,780.7	0.0	3,780.7	104,000.0	393.2	0.5	0.2	0.8
10/14/2020 22:00	3,484.7	0.0	3,484.7	104,000.0	362.4	0.4	0.2	0.7
10/14/2020 23:00	3,327.8	0.0	3,327.8	104,000.0	346.1	0.4	0.2	0.7
Average/Sum#:	3,531.5	402.7	3,931.4	104,000.0	408.9	0.5	0.2	0.8
Minimum:	2,697.9	0.0	2,697.9	104,000.0	280.6	0.3	0.2	0.6
Maximum:	3,924.3	1,850.5	5,704.1	104,000.0	593.2	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/15/2020 00:00	3,109.0	0.0	3,109.0	104,000.0	323.3	0.4	0.2	0.6
10/15/2020 01:00	2,863.2	0.0	2,863.2	104,000.0	297.8	0.4	0.2	0.6
10/15/2020 02:00	2,743.6	0.0	2,743.6	104,000.0	285.3	0.3	0.2	0.6
10/15/2020 03:00	2,800.2	0.0	2,800.2	104,000.0	291.2	0.4	0.2	0.6
10/15/2020 04:00	2,823.8	0.0	2,823.8	104,000.0	293.7	0.4	0.2	0.6
10/15/2020 05:00	3,054.6	0.0	3,054.6	104,000.0	317.7	0.4	0.2	0.6
10/15/2020 06:00	3,503.0	0.0	3,503.0	104,000.0	364.3	0.4	0.2	0.7
10/15/2020 07:00	3,777.6	0.0	3,777.6	104,000.0	392.9	0.5	0.2	0.8
10/15/2020 08:00	3,980.9	1,494.5	5,296.1	104,000.0	550.8	0.7	0.3	1.1
10/15/2020 09:00	3,971.6	1,884.4	5,856.0	104,000.0	609.0	0.7	0.4	1.2
10/15/2020 10:00	3,937.8	1,623.1	5,560.9	104,000.0	578.3	0.7	0.3	1.2
10/15/2020 11:00	3,906.0	1,781.0	5,687.0	104,000.0	591.4	0.7	0.4	1.2
10/15/2020 12:00	3,891.5	1,601.8	5,493.3	104,000.0	571.3	0.7	0.3	1.1
10/15/2020 13:00	3,871.5	1,400.1	5,271.6	104,000.0	548.2	0.7	0.3	1.1
10/15/2020 14:00	3,861.5	1,410.5	5,272.0	104,000.0	548.3	0.7	0.3	1.1
10/15/2020 15:00	3,563.7	802.4	4,021.1	104,000.0	418.2	0.5	0.3	0.9
10/15/2020 16:00	3,844.2	1,486.9	5,256.8	104,000.0	546.7	0.7	0.3	1.1
10/15/2020 17:00	3,860.0	1,318.7	5,178.7	104,000.0	538.6	0.6	0.3	1.1
10/15/2020 18:00	3,882.6	948.9	4,831.5	104,000.0	502.5	0.6	0.3	1.0
10/15/2020 19:00	3,856.4	88.0	3,876.6	104,000.0	403.2	0.5	0.2	0.8
10/15/2020 20:00	3,922.5	483.3	4,405.8	104,000.0	458.2	0.6	0.3	0.9
10/15/2020 21:00	3,807.1	1.8	3,807.1	104,000.0	395.9	0.5	0.2	0.8
10/15/2020 22:00	3,478.2	0.0	3,478.2	104,000.0	361.7	0.4	0.2	0.7
10/15/2020 23:00	3,437.1	0.0	3,437.1	104,000.0	357.5	0.4	0.2	0.7
Average/Sum#:	3,572.8	680.2	4,225.2	104,000.0	439.4	0.5	0.3	0.9
Minimum:	2,743.6	0.0	2,743.6	104,000.0	285.3	0.3	0.2	0.6
Maximum:	3,980.9	1,884.4	5,856.0	104,000.0	609.0	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/16/2020 00:00	3,048.7	0.0	3,048.7	104,000.0	317.1	0.4	0.2	0.6
10/16/2020 01:00	2,961.2	0.0	2,961.2	104,000.0	308.0	0.4	0.2	0.6
10/16/2020 02:00	2,919.1	0.0	2,919.1	104,000.0	303.6	0.4	0.2	0.6
10/16/2020 03:00	2,919.8	0.0	2,919.8	104,000.0	303.7	0.4	0.2	0.6
10/16/2020 04:00	3,080.5	0.0	3,080.5	104,000.0	320.4	0.4	0.2	0.6
10/16/2020 05:00	3,303.4	0.0	3,303.4	104,000.0	343.6	0.4	0.2	0.7
10/16/2020 06:00	3,468.6	0.0	3,468.6	104,000.0	360.7	0.4	0.2	0.7
10/16/2020 07:00	3,579.3	0.0	3,579.3	104,000.0	372.2	0.4	0.2	0.7
10/16/2020 08:00	3,827.5	0.0	3,827.5	104,000.0	398.1	0.5	0.2	0.8
10/16/2020 09:00	3,781.0	0.0	3,781.0	104,000.0	393.2	0.5	0.2	0.8
10/16/2020 10:00	3,679.1	0.0	3,679.1	104,000.0	382.6	0.5	0.2	0.8
10/16/2020 11:00	3,594.4	0.0	3,594.4	104,000.0	373.8	0.4	0.2	0.7
10/16/2020 12:00	3,866.7	297.6	4,143.5	104,000.0	430.9	0.5	0.3	0.9
10/16/2020 13:00	3,852.6	870.0	4,722.6	104,000.0	491.2	0.6	0.3	1.0
10/16/2020 14:00	3,842.8	1,307.7	5,150.5	104,000.0	535.7	0.6	0.3	1.1
10/16/2020 15:00	3,838.5	1,787.4	5,625.9	104,000.0	585.1	0.7	0.4	1.2
10/16/2020 16:00	3,841.1	1,789.6	5,630.7	104,000.0	585.6	0.7	0.4	1.2
10/16/2020 17:00	3,849.9	1,527.9	5,377.8	104,000.0	559.3	0.7	0.3	1.1
10/16/2020 18:00	3,871.2	1,051.3	4,922.5	104,000.0	511.9	0.6	0.3	1.0
10/16/2020 19:00	3,877.0	1,026.7	4,903.7	104,000.0	510.0	0.6	0.3	1.0
10/16/2020 20:00	3,898.3	501.7	4,364.9	104,000.0	453.9	0.5	0.3	0.9
10/16/2020 21:00	3,758.5	0.0	3,758.5	104,000.0	390.9	0.5	0.2	0.8
10/16/2020 22:00	3,431.0	0.0	3,431.0	104,000.0	356.8	0.4	0.2	0.7
10/16/2020 23:00	3,371.3	0.0	3,371.3	104,000.0	350.6	0.4	0.2	0.7
Average/Sum#:	3,560.9	423.3	3,981.9	104,000.0	414.1	0.5	0.2	0.8
Minimum:	2,919.1	0.0	2,919.1	104,000.0	303.6	0.4	0.2	0.6
Maximum:	3,898.3	1,789.6	5,630.7	104,000.0	585.6	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/17/2020 00:00	3,140.9	0.0	3,140.9	104,000.0	326.7	0.4	0.2	0.7
10/17/2020 01:00	2,698.2	0.0	2,698.2	104,000.0	280.6	0.3	0.2	0.6
10/17/2020 02:00	2,697.6	0.0	2,697.6	104,000.0	280.6	0.3	0.2	0.6
10/17/2020 03:00	2,704.6	0.0	2,704.6	104,000.0	281.3	0.3	0.2	0.6
10/17/2020 04:00	2,711.7	0.0	2,711.7	104,000.0	282.0	0.3	0.2	0.6
10/17/2020 05:00	2,945.0	0.0	2,945.0	104,000.0	306.3	0.4	0.2	0.6
10/17/2020 06:00	3,038.2	0.0	3,038.2	104,000.0	316.0	0.4	0.2	0.6
10/17/2020 07:00	3,328.1	0.0	3,328.1	104,000.0	346.1	0.4	0.2	0.7
10/17/2020 08:00	3,688.6	0.0	3,688.6	104,000.0	383.6	0.5	0.2	0.8
10/17/2020 09:00	3,766.7	0.0	3,766.7	104,000.0	391.7	0.5	0.2	0.8
10/17/2020 10:00	3,921.4	0.0	3,921.4	104,000.0	407.8	0.5	0.2	0.8
10/17/2020 11:00	3,887.0	0.0	3,887.0	104,000.0	404.2	0.5	0.2	0.8
10/17/2020 12:00	3,862.9	0.0	3,862.9	104,000.0	401.7	0.5	0.2	0.8
10/17/2020 13:00	3,850.6	326.2	4,039.8	104,000.0	420.1	0.5	0.3	0.9
10/17/2020 14:00	3,842.9	1,746.1	5,589.0	104,000.0	581.3	0.7	0.3	1.2
10/17/2020 15:00	3,833.4	1,391.4	5,224.8	104,000.0	543.4	0.7	0.3	1.1
10/17/2020 16:00	3,831.2	1,336.5	5,167.7	104,000.0	537.4	0.6	0.3	1.1
10/17/2020 17:00	3,850.9	791.2	4,642.1	104,000.0	482.8	0.6	0.3	1.0
10/17/2020 18:00	3,875.0	164.2	3,994.9	104,000.0	415.5	0.5	0.3	0.8
10/17/2020 19:00	3,883.9	1,249.4	5,133.3	104,000.0	533.9	0.6	0.3	1.1
10/17/2020 20:00	3,887.5	547.6	4,391.3	104,000.0	456.7	0.6	0.3	0.9
10/17/2020 21:00	3,769.3	0.0	3,769.3	104,000.0	392.0	0.5	0.2	0.8
10/17/2020 22:00	3,469.9	0.0	3,469.9	104,000.0	360.9	0.4	0.2	0.7
10/17/2020 23:00	3,324.1	0.0	3,324.1	104,000.0	345.7	0.4	0.2	0.7
Average/Sum#:	3,492.1	314.7	3,797.4	104,000.0	394.9	0.5	0.2	0.8
Minimum:	2,697.6	0.0	2,697.6	104,000.0	280.6	0.3	0.2	0.6
Maximum:	3,921.4	1,746.1	5,589.0	104,000.0	581.3	0.7	0.3	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/18/2020 00:00	3,003.4	0.0	3,003.4	104,000.0	312.4	0.4	0.2	0.6
10/18/2020 01:00	2,925.2	0.0	2,925.2	104,000.0	304.2	0.4	0.2	0.6
10/18/2020 02:00	2,936.9	0.0	2,936.9	104,000.0	305.4	0.4	0.2	0.6
10/18/2020 03:00	2,867.5	0.0	2,867.5	104,000.0	298.2	0.4	0.2	0.6
10/18/2020 04:00	2,914.7	0.0	2,914.7	104,000.0	303.1	0.4	0.2	0.6
10/18/2020 05:00	3,048.3	0.0	3,048.3	104,000.0	317.0	0.4	0.2	0.6
10/18/2020 06:00	3,174.8	0.0	3,174.8	104,000.0	330.2	0.4	0.2	0.7
10/18/2020 07:00	3,428.0	0.0	3,428.0	104,000.0	356.5	0.4	0.2	0.7
10/18/2020 08:00	3,700.7	0.0	3,700.7	104,000.0	384.9	0.5	0.2	0.8
10/18/2020 09:00	3,769.2	2.3	3,769.3	104,000.0	392.0	0.5	0.2	0.8
10/18/2020 10:00	3,913.1	164.4	4,077.5	104,000.0	424.1	0.5	0.3	0.8
10/18/2020 11:00	3,892.8	223.4	4,116.2	104,000.0	428.1	0.5	0.3	0.9
10/18/2020 12:00	3,856.5	15.8	3,871.2	104,000.0	402.6	0.5	0.2	0.8
10/18/2020 13:00	3,859.7	445.0	4,304.7	104,000.0	447.7	0.5	0.3	0.9
10/18/2020 14:00	3,847.2	1,014.6	4,861.8	104,000.0	505.6	0.6	0.3	1.0
10/18/2020 15:00	3,842.0	1,482.7	5,324.7	104,000.0	553.8	0.7	0.3	1.1
10/18/2020 16:00	3,839.3	615.0	4,454.3	104,000.0	463.2	0.6	0.3	0.9
10/18/2020 17:00	3,840.2	96.0	3,859.4	104,000.0	401.4	0.5	0.2	0.8
10/18/2020 18:00	3,577.8	0.0	3,577.8	104,000.0	372.1	0.4	0.2	0.7
10/18/2020 19:00	3,694.8	10.9	3,695.3	104,000.0	384.3	0.5	0.2	0.8
10/18/2020 20:00	3,891.6	409.6	4,260.2	104,000.0	443.1	0.5	0.3	0.9
10/18/2020 21:00	3,785.8	0.0	3,785.8	104,000.0	393.7	0.5	0.2	0.8
10/18/2020 22:00	3,422.4	0.0	3,422.4	104,000.0	355.9	0.4	0.2	0.7
10/18/2020 23:00	3,290.8	0.0	3,290.8	104,000.0	342.2	0.4	0.2	0.7
Average/Sum#:	3,513.4	186.7	3,694.6	104,000.0	384.2	0.5	0.2	0.8
Minimum:	2,867.5	0.0	2,867.5	104,000.0	298.2	0.4	0.2	0.6
Maximum:	3,913.1	1,482.7	5,324.7	104,000.0	553.8	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/19/2020 00:00	3,084.9	0.0	3,084.9	104,000.0	320.8	0.4	0.2	0.6
10/19/2020 01:00	2,824.3	0.0	2,824.3	104,000.0	293.7	0.4	0.2	0.6
10/19/2020 02:00	2,731.7	0.0	2,731.7	104,000.0	284.1	0.3	0.2	0.6
10/19/2020 03:00	2,746.4	0.0	2,746.4	104,000.0	285.6	0.3	0.2	0.6
10/19/2020 04:00	2,943.0	0.0	2,943.0	104,000.0	306.1	0.4	0.2	0.6
10/19/2020 05:00	3,300.3	0.0	3,300.3	104,000.0	343.2	0.4	0.2	0.7
10/19/2020 06:00	3,469.2	0.0	3,469.2	104,000.0	360.8	0.4	0.2	0.7
10/19/2020 07:00	3,749.5	0.0	3,749.5	104,000.0	389.9	0.5	0.2	0.8
10/19/2020 08:00	3,883.3	0.0	3,883.3	104,000.0	403.9	0.5	0.2	0.8
10/19/2020 09:00	3,954.2	4.7	3,954.6	104,000.0	411.3	0.5	0.2	0.8
10/19/2020 10:00	3,927.8	226.6	4,154.4	104,000.0	432.1	0.5	0.3	0.9
10/19/2020 11:00	3,906.0	517.8	4,423.8	104,000.0	460.1	0.6	0.3	0.9
10/19/2020 12:00	3,883.5	632.3	4,515.8	104,000.0	469.6	0.6	0.3	0.9
10/19/2020 13:00	3,869.0	857.2	4,726.2	104,000.0	491.5	0.6	0.3	1.0
10/19/2020 14:00	3,859.6	1,180.3	5,039.9	104,000.0	524.1	0.6	0.3	1.0
10/19/2020 15:00	3,851.7	1,787.0	5,638.7	104,000.0	586.4	0.7	0.4	1.2
10/19/2020 16:00	3,857.2	1,506.8	5,364.0	104,000.0	557.9	0.7	0.3	1.1
10/19/2020 17:00	3,867.5	1,029.2	4,896.7	104,000.0	509.3	0.6	0.3	1.0
10/19/2020 18:00	3,887.5	518.5	4,406.0	104,000.0	458.2	0.6	0.3	0.9
10/19/2020 19:00	3,648.3	4.1	3,648.4	104,000.0	379.4	0.5	0.2	0.8
10/19/2020 20:00	3,911.9	323.7	4,196.8	104,000.0	436.5	0.5	0.3	0.9
10/19/2020 21:00	3,670.3	0.0	3,670.3	104,000.0	381.7	0.5	0.2	0.8
10/19/2020 22:00	3,281.6	0.0	3,281.6	104,000.0	341.3	0.4	0.2	0.7
10/19/2020 23:00	3,206.8	0.0	3,206.8	104,000.0	333.5	0.4	0.2	0.7
Average/Sum#:	3,554.8	357.8	3,910.7	104,000.0	406.7	0.5	0.2	0.8
Minimum:	2,731.7	0.0	2,731.7	104,000.0	284.1	0.3	0.2	0.6
Maximum:	3,954.2	1,787.0	5,638.7	104,000.0	586.4	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/20/2020 00:00	3,096.7	0.0	3,096.7	104,000.0	322.1	0.4	0.2	0.6
10/20/2020 01:00	2,823.1	0.0	2,823.1	104,000.0	293.6	0.4	0.2	0.6
10/20/2020 02:00	2,701.5	0.0	2,701.5	104,000.0	281.0	0.3	0.2	0.6
10/20/2020 03:00	2,705.3	0.0	2,705.3	104,000.0	281.4	0.3	0.2	0.6
10/20/2020 04:00	2,863.6	0.0	2,863.6	104,000.0	297.8	0.4	0.2	0.6
10/20/2020 05:00	3,205.9	0.0	3,205.9	104,000.0	333.4	0.4	0.2	0.7
10/20/2020 06:00	3,355.4	0.0	3,355.4	104,000.0	349.0	0.4	0.2	0.7
10/20/2020 07:00	3,463.0	0.0	3,463.0	104,000.0	360.2	0.4	0.2	0.7
10/20/2020 08:00	3,785.0	0.0	3,785.0	104,000.0	393.6	0.5	0.2	0.8
10/20/2020 09:00	3,792.2	0.0	3,792.2	104,000.0	394.4	0.5	0.2	0.8
10/20/2020 10:00	3,879.9	326.0	4,140.7	104,000.0	430.6	0.5	0.3	0.9
10/20/2020 11:00	3,889.8	884.5	4,774.3	104,000.0	496.5	0.6	0.3	1.0
10/20/2020 12:00	3,872.2	983.5	4,855.7	104,000.0	505.0	0.6	0.3	1.0
10/20/2020 13:00	3,870.7	1,696.8	5,567.5	104,000.0	579.0	0.7	0.3	1.2
10/20/2020 14:00	3,858.5	1,780.0	5,638.5	104,000.0	586.4	0.7	0.4	1.2
10/20/2020 15:00	3,853.1	1,701.4	5,554.5	104,000.0	577.7	0.7	0.3	1.2
10/20/2020 16:00	3,857.4	668.8	4,526.2	104,000.0	470.7	0.6	0.3	0.9
10/20/2020 17:00	3,868.7	242.7	4,002.2	104,000.0	416.2	0.5	0.3	0.9
10/20/2020 18:00	3,863.5	0.1	3,863.5	104,000.0	401.8	0.5	0.2	0.8
10/20/2020 19:00	3,899.7	643.8	4,543.5	104,000.0	472.5	0.6	0.3	0.9
10/20/2020 20:00	3,883.2	15.3	3,884.7	104,000.0	404.0	0.5	0.2	0.8
10/20/2020 21:00	3,428.0	0.0	3,428.0	104,000.0	356.5	0.4	0.2	0.7
10/20/2020 22:00	3,186.7	0.0	3,186.7	104,000.0	331.4	0.4	0.2	0.7
10/20/2020 23:00	3,009.1	0.0	3,009.1	104,000.0	312.9	0.4	0.2	0.6
Average/Sum#:	3,500.5	372.6	3,865.3	104,000.0	402.0	0.5	0.2	0.8
Minimum:	2,701.5	0.0	2,701.5	104,000.0	281.0	0.3	0.2	0.6
Maximum:	3,899.7	1,780.0	5,638.5	104,000.0	586.4	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/21/2020 00:00	2,702.4	0.0	2,702.4	104,000.0	281.0	0.3	0.2	0.6
10/21/2020 01:00	2,694.8	0.0	2,694.8	104,000.0	280.3	0.3	0.2	0.6
10/21/2020 02:00	2,701.1	0.0	2,701.1	104,000.0	280.9	0.3	0.2	0.6
10/21/2020 03:00	2,699.7	0.0	2,699.7	104,000.0	280.8	0.3	0.2	0.6
10/21/2020 04:00	2,732.2	0.0	2,732.2	104,000.0	284.1	0.3	0.2	0.6
10/21/2020 05:00	3,439.5	0.0	3,439.5	104,000.0	357.7	0.4	0.2	0.7
10/21/2020 06:00	3,561.0	0.0	3,561.0	104,000.0	370.3	0.4	0.2	0.7
10/21/2020 07:00	2,760.4	0.0	2,760.4	104,000.0	287.1	0.3	0.2	0.6
10/21/2020 08:00	2,907.7	0.0	2,907.7	104,000.0	302.4	0.4	0.2	0.6
10/21/2020 09:00	3,194.4	0.0	3,194.4	104,000.0	332.2	0.4	0.2	0.7
10/21/2020 10:00	3,476.9	0.0	3,476.9	104,000.0	361.6	0.4	0.2	0.7
10/21/2020 11:00	3,732.3	0.0	3,732.3	104,000.0	388.2	0.5	0.2	0.8
10/21/2020 12:00	3,879.2	7.2	3,879.9	104,000.0	403.5	0.5	0.2	0.8
10/21/2020 13:00	3,858.3	237.9	4,096.2	104,000.0	426.0	0.5	0.3	0.9
10/21/2020 14:00	3,855.5	733.0	4,588.5	104,000.0	477.2	0.6	0.3	1.0
10/21/2020 15:00	3,696.9	8.4	3,697.5	104,000.0	384.5	0.5	0.2	0.8
10/21/2020 16:00	3,727.3	0.0	3,727.3	104,000.0	387.6	0.5	0.2	0.8
10/21/2020 17:00	3,757.6	0.0	3,757.6	104,000.0	390.8	0.5	0.2	0.8
10/21/2020 18:00	3,178.7	0.0	3,178.7	104,000.0	330.6	0.4	0.2	0.7
10/21/2020 19:00	2,777.7	0.0	2,777.7	104,000.0	288.9	0.3	0.2	0.6
10/21/2020 20:00	2,909.4	0.0	2,909.4	104,000.0	302.6	0.4	0.2	0.6
10/21/2020 21:00	3,460.3	0.0	3,460.3	104,000.0	359.9	0.4	0.2	0.7
10/21/2020 22:00	3,255.6	0.0	3,255.6	104,000.0	338.6	0.4	0.2	0.7
10/21/2020 23:00	3,144.5	0.0	3,144.5	104,000.0	327.0	0.4	0.2	0.7
Average/Sum#:	3,254.3	41.1	3,294.8	104,000.0	342.7	0.4	0.2	0.7
Minimum:	2,694.8	0.0	2,694.8	104,000.0	280.3	0.3	0.2	0.6
Maximum:	3,879.2	733.0	4,588.5	104,000.0	477.2	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/22/2020 00:00	2,717.1	0.0	2,717.1	104,000.0	282.6	0.3	0.2	0.6
10/22/2020 01:00	2,701.9	0.0	2,701.9	104,000.0	281.0	0.3	0.2	0.6
10/22/2020 02:00	2,703.5	0.0	2,703.5	104,000.0	281.2	0.3	0.2	0.6
10/22/2020 03:00	2,706.0	0.0	2,706.0	104,000.0	281.4	0.3	0.2	0.6
10/22/2020 04:00	2,789.5	0.0	2,789.5	104,000.0	290.1	0.3	0.2	0.6
10/22/2020 05:00	3,976.3	0.0	3,976.3	104,000.0	413.5	0.5	0.2	0.8
10/22/2020 06:00	3,962.3	0.0	3,962.3	104,000.0	412.1	0.5	0.2	0.8
10/22/2020 07:00	3,352.7	0.0	3,352.7	104,000.0	348.7	0.4	0.2	0.7
10/22/2020 08:00	3,634.2	0.0	3,634.2	104,000.0	378.0	0.5	0.2	0.8
10/22/2020 09:00	3,883.7	0.0	3,883.7	104,000.0	403.9	0.5	0.2	0.8
10/22/2020 10:00	3,828.2	0.0	3,828.2	104,000.0	398.1	0.5	0.2	0.8
10/22/2020 11:00	3,802.5	0.0	3,802.5	104,000.0	395.5	0.5	0.2	0.8
10/22/2020 12:00	3,967.1	0.0	3,967.1	104,000.0	412.6	0.5	0.2	0.8
10/22/2020 13:00	3,962.9	0.0	3,962.9	104,000.0	412.1	0.5	0.2	0.8
10/22/2020 14:00	3,959.4	159.3	4,058.2	104,000.0	422.1	0.5	0.3	0.9
10/22/2020 15:00	3,604.1	0.0	3,604.1	104,000.0	374.8	0.5	0.2	0.7
10/22/2020 16:00	3,963.0	33.2	3,979.6	104,000.0	413.9	0.5	0.2	0.8
10/22/2020 17:00	3,994.9	183.1	4,163.4	104,000.0	433.0	0.5	0.3	0.9
10/22/2020 18:00	3,737.9	0.0	3,737.9	104,000.0	388.7	0.5	0.2	0.8
10/22/2020 19:00	3,851.6	0.0	3,851.6	104,000.0	400.6	0.5	0.2	0.8
10/22/2020 20:00	3,755.3	0.0	3,755.3	104,000.0	390.6	0.5	0.2	0.8
10/22/2020 21:00	3,061.3	0.0	3,061.3	104,000.0	318.4	0.4	0.2	0.6
10/22/2020 22:00	2,740.0	0.0	2,740.0	104,000.0	285.0	0.3	0.2	0.6
10/22/2020 23:00	2,708.1	0.0	2,708.1	104,000.0	281.6	0.3	0.2	0.6
Average/Sum#:	3,473.5	15.7	3,485.3	104,000.0	362.5	0.4	0.2	0.7
Minimum:	2,701.9	0.0	2,701.9	104,000.0	281.0	0.3	0.2	0.6
Maximum:	3,994.9	183.1	4,163.4	104,000.0	433.0	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/23/2020 00:00	2,709.4	0.0	2,709.4	104,000.0	281.8	0.3	0.2	0.6
10/23/2020 01:00	2,713.1	0.0	2,713.1	104,000.0	282.2	0.3	0.2	0.6
10/23/2020 02:00	2,713.9	0.0	2,713.9	104,000.0	282.2	0.3	0.2	0.6
10/23/2020 03:00	2,712.9	0.0	2,712.9	104,000.0	282.1	0.3	0.2	0.6
10/23/2020 04:00	2,728.5	0.0	2,728.5	104,000.0	283.8	0.3	0.2	0.6
10/23/2020 05:00	2,981.9	0.0	2,981.9	104,000.0	310.1	0.4	0.2	0.6
10/23/2020 06:00	3,200.7	0.0	3,200.7	104,000.0	332.9	0.4	0.2	0.7
10/23/2020 07:00	3,412.7	0.0	3,412.7	104,000.0	354.9	0.4	0.2	0.7
10/23/2020 08:00	3,658.2	0.0	3,658.2	104,000.0	380.5	0.5	0.2	0.8
10/23/2020 09:00	3,781.1	0.0	3,781.1	104,000.0	393.2	0.5	0.2	0.8
10/23/2020 10:00	3,801.6	0.0	3,801.6	104,000.0	395.4	0.5	0.2	0.8
10/23/2020 11:00	3,831.8	0.0	3,831.8	104,000.0	398.5	0.5	0.2	0.8
10/23/2020 12:00	3,794.3	0.0	3,794.3	104,000.0	394.6	0.5	0.2	0.8
10/23/2020 13:00	3,925.9	203.1	4,102.6	104,000.0	426.7	0.5	0.3	0.9
10/23/2020 14:00	3,966.5	70.9	4,037.4	104,000.0	419.9	0.5	0.3	0.8
10/23/2020 15:00	3,799.5	12.1	3,811.2	104,000.0	396.4	0.5	0.2	0.8
10/23/2020 16:00	3,198.0	0.0	3,198.0	104,000.0	332.6	0.4	0.2	0.7
10/23/2020 17:00	3,938.4	367.3	4,250.6	104,000.0	442.1	0.5	0.3	0.9
10/23/2020 18:00	3,239.7	0.0	3,239.7	104,000.0	336.9	0.4	0.2	0.7
10/23/2020 19:00	3,132.7	0.0	3,132.7	104,000.0	325.8	0.4	0.2	0.7
10/23/2020 20:00	3,813.3	0.0	3,813.3	104,000.0	396.6	0.5	0.2	0.8
10/23/2020 21:00	3,581.7	0.0	3,581.7	104,000.0	372.5	0.4	0.2	0.7
10/23/2020 22:00	3,424.0	0.0	3,424.0	104,000.0	356.1	0.4	0.2	0.7
10/23/2020 23:00	3,146.9	0.0	3,146.9	104,000.0	327.3	0.4	0.2	0.7
Average/Sum#:	3,383.6	27.2	3,407.4	104,000.0	354.4	0.4	0.2	0.7
Minimum:	2,709.4	0.0	2,709.4	104,000.0	281.8	0.3	0.2	0.6
Maximum:	3,966.5	367.3	4,250.6	104,000.0	442.1	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/24/2020 00:00	3,210.6	0.0	3,210.6	104,000.0	333.9	0.4	0.2	0.7
10/24/2020 01:00	2,738.9	0.0	2,738.9	104,000.0	284.8	0.3	0.2	0.6
10/24/2020 02:00	2,807.4	0.0	2,807.4	104,000.0	292.0	0.4	0.2	0.6
10/24/2020 03:00	2,808.2	0.0	2,808.2	104,000.0	292.1	0.4	0.2	0.6
10/24/2020 04:00	2,826.4	0.0	2,826.4	104,000.0	293.9	0.4	0.2	0.6
10/24/2020 05:00	3,027.6	0.0	3,027.6	104,000.0	314.9	0.4	0.2	0.6
10/24/2020 06:00	3,150.0	0.0	3,150.0	104,000.0	327.6	0.4	0.2	0.7
10/24/2020 07:00	3,593.5	0.0	3,593.5	104,000.0	373.7	0.4	0.2	0.7
10/24/2020 08:00	3,919.1	0.0	3,919.1	104,000.0	407.6	0.5	0.2	0.8
10/24/2020 09:00	3,986.0	0.0	3,986.0	104,000.0	414.5	0.5	0.2	0.8
10/24/2020 10:00	3,965.3	408.1	4,361.2	104,000.0	453.6	0.5	0.3	0.9
10/24/2020 11:00	3,949.5	57.7	3,976.6	104,000.0	413.6	0.5	0.3	0.8
10/24/2020 12:00	3,947.5	34.6	3,950.3	104,000.0	410.8	0.5	0.2	0.8
10/24/2020 13:00	3,938.4	1,045.6	4,984.0	104,000.0	518.3	0.6	0.3	1.0
10/24/2020 14:00	3,936.4	1,334.7	5,271.1	104,000.0	548.2	0.7	0.3	1.1
10/24/2020 15:00	3,457.8	182.1	3,497.9	104,000.0	363.8	0.5	0.2	0.8
10/24/2020 16:00	2,925.5	0.0	2,925.5	104,000.0	304.3	0.4	0.2	0.6
10/24/2020 17:00	3,127.3	0.0	3,127.3	104,000.0	325.2	0.4	0.2	0.7
10/24/2020 18:00	3,198.1	0.0	3,198.1	104,000.0	332.6	0.4	0.2	0.7
10/24/2020 19:00	3,908.4	1,499.7	5,378.1	104,000.0	559.3	0.7	0.3	1.1
10/24/2020 20:00	3,931.3	1,064.7	4,996.0	104,000.0	519.6	0.6	0.3	1.0
10/24/2020 21:00	3,937.6	424.2	4,319.4	104,000.0	449.2	0.5	0.3	0.9
10/24/2020 22:00	3,724.9	0.0	3,724.9	104,000.0	387.4	0.5	0.2	0.8
10/24/2020 23:00	3,353.6	0.0	3,353.6	104,000.0	348.8	0.4	0.2	0.7
Average/Sum#:	3,473.7	252.1	3,713.8	104,000.0	386.2	0.5	0.2	0.8
Minimum:	2,738.9	0.0	2,738.9	104,000.0	284.8	0.3	0.2	0.6
Maximum:	3,986.0	1,499.7	5,378.1	104,000.0	559.3	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/25/2020 00:00	3,145.1	0.0	3,145.1	104,000.0	327.1	0.4	0.2	0.7
10/25/2020 01:00	2,900.0	0.0	2,900.0	104,000.0	301.6	0.4	0.2	0.6
10/25/2020 02:00	2,898.4	0.0	2,898.4	104,000.0	301.4	0.4	0.2	0.6
10/25/2020 03:00	2,933.9	0.0	2,933.9	104,000.0	305.1	0.4	0.2	0.6
10/25/2020 04:00	3,090.5	0.0	3,090.5	104,000.0	321.4	0.4	0.2	0.6
10/25/2020 05:00	3,337.5	0.0	3,337.5	104,000.0	347.1	0.4	0.2	0.7
10/25/2020 06:00	3,683.6	0.0	3,683.6	104,000.0	383.1	0.5	0.2	0.8
10/25/2020 07:00	3,822.9	0.0	3,822.9	104,000.0	397.6	0.5	0.2	0.8
10/25/2020 08:00	3,943.7	47.7	3,964.2	104,000.0	412.3	0.5	0.2	0.8
10/25/2020 09:00	4,030.6	534.9	4,565.5	104,000.0	474.8	0.6	0.3	0.9
10/25/2020 10:00	3,999.8	747.7	4,747.5	104,000.0	493.7	0.6	0.3	1.0
10/25/2020 11:00	3,994.7	763.4	4,758.1	104,000.0	494.8	0.6	0.3	1.0
10/25/2020 12:00	3,996.0	918.8	4,914.8	104,000.0	511.1	0.6	0.3	1.0
10/25/2020 13:00	4,029.7	900.6	4,930.3	104,000.0	512.8	0.6	0.3	1.0
10/25/2020 14:00	4,031.2	1,225.6	5,256.8	104,000.0	546.7	0.7	0.3	1.1
10/25/2020 15:00	4,038.0	1,196.3	5,234.3	104,000.0	544.4	0.7	0.3	1.1
10/25/2020 16:00	4,015.7	35.2	4,021.0	104,000.0	418.2	0.5	0.3	0.8
10/25/2020 17:00	4,070.1	535.5	4,605.6	104,000.0	479.0	0.6	0.3	1.0
10/25/2020 18:00	4,087.1	294.8	4,381.9	104,000.0	455.7	0.5	0.3	0.9
10/25/2020 19:00	4,084.4	257.0	4,315.7	104,000.0	448.8	0.5	0.3	0.9
10/25/2020 20:00	3,819.9	0.0	3,819.9	104,000.0	397.3	0.5	0.2	0.8
10/25/2020 21:00	3,792.2	0.0	3,792.2	104,000.0	394.4	0.5	0.2	0.8
10/25/2020 22:00	3,583.8	0.0	3,583.8	104,000.0	372.7	0.4	0.2	0.7
10/25/2020 23:00	3,213.7	0.0	3,213.7	104,000.0	334.2	0.4	0.2	0.7
Average/Sum#:	3,689.3	310.7	3,996.6	104,000.0	415.6	0.5	0.2	0.8
Minimum:	2,898.4	0.0	2,898.4	104,000.0	301.4	0.4	0.2	0.6
Maximum:	4,087.1	1,225.6	5,256.8	104,000.0	546.7	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/26/2020 00:00	2,882.5	0.0	2,882.5	104,000.0	299.8	0.4	0.2	0.6
10/26/2020 01:00	2,881.0	0.0	2,881.0	104,000.0	299.6	0.4	0.2	0.6
10/26/2020 02:00	2,869.2	0.0	2,869.2	104,000.0	298.4	0.4	0.2	0.6
10/26/2020 03:00	2,930.8	0.0	2,930.8	104,000.0	304.8	0.4	0.2	0.6
10/26/2020 04:00	3,267.5	0.0	3,267.5	104,000.0	339.8	0.4	0.2	0.7
10/26/2020 05:00	3,748.8	0.0	3,748.8	104,000.0	389.9	0.5	0.2	0.8
10/26/2020 06:00	3,724.5	0.0	3,724.5	104,000.0	387.3	0.5	0.2	0.8
10/26/2020 07:00	4,002.6	359.9	4,247.3	104,000.0	441.7	0.5	0.3	0.9
10/26/2020 08:00	4,059.5	715.3	4,774.8	104,000.0	496.6	0.6	0.3	1.0
10/26/2020 09:00	4,017.8	915.5	4,933.3	104,000.0	513.1	0.6	0.3	1.0
10/26/2020 10:00	3,953.4	1,564.9	5,518.3	104,000.0	573.9	0.7	0.3	1.1
10/26/2020 11:00	3,908.2	1,785.1	5,693.3	104,000.0	592.1	0.7	0.4	1.2
10/26/2020 12:00	3,872.4	1,824.9	5,697.3	104,000.0	592.5	0.7	0.4	1.2
10/26/2020 13:00	3,888.6	1,728.9	5,617.5	104,000.0	584.2	0.7	0.4	1.2
10/26/2020 14:00	4,044.7	1,757.7	5,802.4	104,000.0	603.4	0.7	0.4	1.2
10/26/2020 15:00	4,039.3	1,244.9	5,284.2	104,000.0	549.6	0.7	0.3	1.1
10/26/2020 16:00	4,006.7	100.8	4,095.4	104,000.0	425.9	0.5	0.3	0.9
10/26/2020 17:00	4,081.1	832.5	4,913.6	104,000.0	511.0	0.6	0.3	1.0
10/26/2020 18:00	4,094.7	1,776.7	5,871.4	104,000.0	610.6	0.7	0.4	1.2
10/26/2020 19:00	4,099.9	1,730.7	5,830.6	104,000.0	606.4	0.7	0.4	1.2
10/26/2020 20:00	4,119.5	1,445.1	5,564.6	104,000.0	578.7	0.7	0.3	1.2
10/26/2020 21:00	4,105.7	244.5	4,342.9	104,000.0	451.7	0.5	0.3	0.9
10/26/2020 22:00	3,797.4	0.0	3,797.4	104,000.0	394.9	0.5	0.2	0.8
10/26/2020 23:00	3,328.3	0.0	3,328.3	104,000.0	346.1	0.4	0.2	0.7
Average/Sum#:	3,738.5	751.1	4,484.0	104,000.0	466.3	0.6	0.3	0.9
Minimum:	2,869.2	0.0	2,869.2	104,000.0	298.4	0.4	0.2	0.6
Maximum:	4,119.5	1,824.9	5,871.4	104,000.0	610.6	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/27/2020 00:00	3,159.8	0.0	3,159.8	104,000.0	328.6	0.4	0.2	0.7
10/27/2020 01:00	2,997.6	0.0	2,997.6	104,000.0	311.8	0.4	0.2	0.6
10/27/2020 02:00	2,880.1	0.0	2,880.1	104,000.0	299.5	0.4	0.2	0.6
10/27/2020 03:00	2,902.7	0.0	2,902.7	104,000.0	301.9	0.4	0.2	0.6
10/27/2020 04:00	3,176.1	0.0	3,176.1	104,000.0	330.3	0.4	0.2	0.7
10/27/2020 05:00	3,966.3	0.0	3,966.3	104,000.0	412.5	0.5	0.2	0.8
10/27/2020 06:00	3,899.9	0.0	3,899.9	104,000.0	405.6	0.5	0.2	0.8
10/27/2020 07:00	4,049.3	0.2	4,049.3	104,000.0	421.1	0.5	0.3	0.8
10/27/2020 08:00	4,022.4	64.9	4,030.8	104,000.0	419.2	0.5	0.3	0.9
10/27/2020 09:00	3,981.9	872.3	4,854.2	104,000.0	504.8	0.6	0.3	1.0
10/27/2020 10:00	3,943.3	983.9	4,927.2	104,000.0	512.4	0.6	0.3	1.0
10/27/2020 11:00	3,896.9	1,045.7	4,942.6	104,000.0	514.0	0.6	0.3	1.0
10/27/2020 12:00	3,780.9	77.4	3,794.8	104,000.0	394.7	0.5	0.2	0.8
10/27/2020 13:00	3,763.1	0.0	3,763.1	104,000.0	391.4	0.5	0.2	0.8
10/27/2020 14:00	3,796.5	0.1	3,796.5	104,000.0	394.8	0.5	0.2	0.8
10/27/2020 15:00	3,976.2	6.8	3,983.0	104,000.0	414.2	0.5	0.2	0.8
10/27/2020 16:00	3,983.1	5.7	3,988.8	104,000.0	414.8	0.5	0.2	0.8
10/27/2020 17:00	3,992.1	5.8	3,997.9	104,000.0	415.8	0.5	0.2	0.8
10/27/2020 18:00	3,961.4	5.2	3,966.0	104,000.0	412.5	0.5	0.2	0.8
10/27/2020 19:00	3,684.8	0.0	3,684.8	104,000.0	383.2	0.5	0.2	0.8
10/27/2020 20:00	3,922.0	209.9	4,127.7	104,000.0	429.3	0.5	0.3	0.9
10/27/2020 21:00	3,925.9	155.3	4,061.0	104,000.0	422.3	0.5	0.3	0.8
10/27/2020 22:00	3,484.5	0.0	3,484.5	104,000.0	362.4	0.4	0.2	0.7
10/27/2020 23:00	3,095.8	0.0	3,095.8	104,000.0	322.0	0.4	0.2	0.6
Average/Sum#:	3,676.8	143.1	3,813.8	104,000.0	396.6	0.5	0.2	0.8
Minimum:	2,880.1	0.0	2,880.1	104,000.0	299.5	0.4	0.2	0.6
Maximum:	4,049.3	1,045.7	4,942.6	104,000.0	514.0	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/28/2020 00:00	3,096.4	0.0	3,096.4	104,000.0	322.0	0.4	0.2	0.6
10/28/2020 01:00	3,083.6	0.0	3,083.6	104,000.0	320.7	0.4	0.2	0.6
10/28/2020 02:00	3,011.4	0.0	3,011.4	104,000.0	313.2	0.4	0.2	0.6
10/28/2020 03:00	3,111.4	0.0	3,111.4	104,000.0	323.6	0.4	0.2	0.6
10/28/2020 04:00	3,495.5	0.0	3,495.5	104,000.0	363.5	0.4	0.2	0.7
10/28/2020 05:00	4,079.2	131.8	4,207.0	104,000.0	437.5	0.5	0.3	0.9
10/28/2020 06:00	4,080.9	5.5	4,086.3	104,000.0	425.0	0.5	0.3	0.8
10/28/2020 07:00	4,028.3	2.9	4,029.2	104,000.0	419.0	0.5	0.3	0.8
10/28/2020 08:00	4,040.9	4.7	4,043.8	104,000.0	420.6	0.5	0.3	0.8
10/28/2020 09:00	3,992.8	0.0	3,992.8	104,000.0	415.3	0.5	0.2	0.8
10/28/2020 10:00	3,920.7	0.0	3,920.7	104,000.0	407.8	0.5	0.2	0.8
10/28/2020 11:00	3,864.6	249.7	4,034.4	104,000.0	419.6	0.5	0.3	0.9
10/28/2020 12:00	3,823.0	465.9	4,288.9	104,000.0	446.0	0.5	0.3	0.9
10/28/2020 13:00	3,791.8	437.5	4,229.3	104,000.0	439.8	0.5	0.3	0.9
10/28/2020 14:00	3,773.6	476.9	4,250.5	104,000.0	442.1	0.5	0.3	0.9
10/28/2020 15:00	3,722.1	32.6	3,726.3	104,000.0	387.5	0.5	0.2	0.8
10/28/2020 16:00	3,756.6	7.1	3,757.2	104,000.0	390.7	0.5	0.2	0.8
10/28/2020 17:00	4,010.0	95.4	4,105.4	104,000.0	427.0	0.5	0.3	0.9
10/28/2020 18:00	3,982.6	4.2	3,986.3	104,000.0	414.6	0.5	0.2	0.8
10/28/2020 19:00	3,428.3	0.0	3,428.3	104,000.0	356.5	0.4	0.2	0.7
10/28/2020 20:00	3,593.2	0.0	3,593.2	104,000.0	373.7	0.4	0.2	0.7
10/28/2020 21:00	3,931.1	0.0	3,931.1	104,000.0	408.8	0.5	0.2	0.8
10/28/2020 22:00	3,582.6	0.0	3,582.6	104,000.0	372.6	0.4	0.2	0.7
10/28/2020 23:00	3,259.6	0.0	3,259.6	104,000.0	339.0	0.4	0.2	0.7
Average/Sum#:	3,685.8	79.8	3,760.5	104,000.0	391.1	0.5	0.2	0.8
Minimum:	3,011.4	0.0	3,011.4	104,000.0	313.2	0.4	0.2	0.6
Maximum:	4,080.9	476.9	4,288.9	104,000.0	446.0	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/29/2020 00:00	3,070.7	0.0	3,070.7	104,000.0	319.4	0.4	0.2	0.6
10/29/2020 01:00	3,018.4	0.0	3,018.4	104,000.0	313.9	0.4	0.2	0.6
10/29/2020 02:00	2,965.8	0.0	2,965.8	104,000.0	308.4	0.4	0.2	0.6
10/29/2020 03:00	3,038.6	0.0	3,038.6	104,000.0	316.0	0.4	0.2	0.6
10/29/2020 04:00	3,397.4	0.0	3,397.4	104,000.0	353.3	0.4	0.2	0.7
10/29/2020 05:00	3,967.9	1.0	3,968.0	104,000.0	412.7	0.5	0.2	0.8
10/29/2020 06:00	3,974.9	0.0	3,974.9	104,000.0	413.4	0.5	0.2	0.8
10/29/2020 07:00	4,065.4	0.1	4,065.4	104,000.0	422.8	0.5	0.3	0.8
10/29/2020 08:00	4,055.8	792.4	4,848.2	104,000.0	504.2	0.6	0.3	1.0
10/29/2020 09:00	3,982.5	912.1	4,894.6	104,000.0	509.0	0.6	0.3	1.0
10/29/2020 10:00	3,919.5	909.5	4,829.0	104,000.0	502.2	0.6	0.3	1.0
10/29/2020 11:00	4,011.7	822.4	4,834.1	104,000.0	502.7	0.6	0.3	1.0
10/29/2020 12:00	4,000.3	956.2	4,956.5	104,000.0	515.5	0.6	0.3	1.0
10/29/2020 13:00	3,985.7	155.5	4,029.2	104,000.0	419.0	0.5	0.3	0.9
10/29/2020 14:00	3,970.9	495.6	4,466.5	104,000.0	464.5	0.6	0.3	0.9
10/29/2020 15:00	3,942.8	5.5	3,948.3	104,000.0	410.6	0.5	0.2	0.8
10/29/2020 16:00	3,913.5	18.2	3,922.2	104,000.0	407.9	0.5	0.2	0.8
10/29/2020 17:00	3,980.0	304.6	4,284.6	104,000.0	445.6	0.5	0.3	0.9
10/29/2020 18:00	4,009.2	250.7	4,259.9	104,000.0	443.0	0.5	0.3	0.9
10/29/2020 19:00	3,996.6	397.9	4,366.6	104,000.0	454.1	0.6	0.3	0.9
10/29/2020 20:00	3,681.7	0.0	3,681.7	104,000.0	382.9	0.5	0.2	0.8
10/29/2020 21:00	2,864.1	0.0	2,864.1	104,000.0	297.9	0.4	0.2	0.6
10/29/2020 22:00	3,377.5	0.0	3,377.5	104,000.0	351.3	0.4	0.2	0.7
10/29/2020 23:00	3,403.3	0.0	3,403.3	104,000.0	353.9	0.4	0.2	0.7
Average/Sum#:	3,691.4	250.9	3,936.1	104,000.0	409.3	0.5	0.2	0.8
Minimum:	2,864.1	0.0	2,864.1	104,000.0	297.9	0.4	0.2	0.6
Maximum:	4,065.4	956.2	4,956.5	104,000.0	515.5	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/30/2020 00:00	3,150.0	0.0	3,150.0	104,000.0	327.6	0.4	0.2	0.7
10/30/2020 01:00	3,077.5	0.0	3,077.5	104,000.0	320.1	0.4	0.2	0.6
10/30/2020 02:00	3,070.1	0.0	3,070.1	104,000.0	319.3	0.4	0.2	0.6
10/30/2020 03:00	3,098.1	0.0	3,098.1	104,000.0	322.2	0.4	0.2	0.6
10/30/2020 04:00	3,460.0	0.0	3,460.0	104,000.0	359.8	0.4	0.2	0.7
10/30/2020 05:00	3,996.3	3.2	3,997.5	104,000.0	415.7	0.5	0.2	0.8
10/30/2020 06:00	3,962.5	2.3	3,963.1	104,000.0	412.2	0.5	0.2	0.8
10/30/2020 07:00	3,855.7	5.9	3,861.6	104,000.0	401.6	0.5	0.2	0.8
10/30/2020 08:00	3,905.0	212.8	4,117.8	104,000.0	428.3	0.5	0.3	0.9
10/30/2020 09:00	3,955.1	523.4	4,478.5	104,000.0	465.8	0.6	0.3	0.9
10/30/2020 10:00	4,043.2	805.1	4,848.3	104,000.0	504.2	0.6	0.3	1.0
10/30/2020 11:00	4,011.3	876.3	4,887.6	104,000.0	508.3	0.6	0.3	1.0
10/30/2020 12:00	3,985.7	1,019.0	5,004.7	104,000.0	520.5	0.6	0.3	1.0
10/30/2020 13:00	3,967.5	1,711.6	5,679.1	104,000.0	590.6	0.7	0.4	1.2
10/30/2020 14:00	3,957.6	1,657.3	5,614.9	104,000.0	583.9	0.7	0.4	1.2
10/30/2020 15:00	3,909.8	57.4	3,967.2	104,000.0	412.6	0.5	0.2	0.8
10/30/2020 16:00	3,707.2	0.3	3,707.2	104,000.0	385.5	0.5	0.2	0.8
10/30/2020 17:00	3,642.6	0.0	3,642.6	104,000.0	378.8	0.5	0.2	0.8
10/30/2020 18:00	3,689.1	0.0	3,689.1	104,000.0	383.7	0.5	0.2	0.8
10/30/2020 19:00	3,868.6	445.6	4,269.6	104,000.0	444.0	0.5	0.3	0.9
10/30/2020 20:00	3,892.9	80.5	3,969.4	104,000.0	412.8	0.5	0.2	0.8
10/30/2020 21:00	3,667.8	0.0	3,667.8	104,000.0	381.5	0.5	0.2	0.8
10/30/2020 22:00	3,701.9	0.0	3,701.9	104,000.0	385.0	0.5	0.2	0.8
10/30/2020 23:00	3,508.8	0.0	3,508.8	104,000.0	364.9	0.4	0.2	0.7
Average/Sum#:	3,711.8	308.4	4,018.0	104,000.0	417.9	0.5	0.2	0.8
Minimum:	3,070.1	0.0	3,070.1	104,000.0	319.3	0.4	0.2	0.6
Maximum:	4,043.2	1,711.6	5,679.1	104,000.0	590.6	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/31/2020 00:00	3,306.6	0.0	3,306.6	104,000.0	343.9	0.4	0.2	0.7
10/31/2020 01:00	3,134.4	0.0	3,134.4	104,000.0	326.0	0.4	0.2	0.7
10/31/2020 02:00	3,013.0	0.0	3,013.0	104,000.0	313.4	0.4	0.2	0.6
10/31/2020 03:00	3,058.7	0.0	3,058.7	104,000.0	318.1	0.4	0.2	0.6
10/31/2020 04:00	3,201.6	0.0	3,201.6	104,000.0	333.0	0.4	0.2	0.7
10/31/2020 05:00	3,638.1	0.0	3,638.1	104,000.0	378.4	0.5	0.2	0.8
10/31/2020 06:00	3,887.8	0.0	3,887.8	104,000.0	404.3	0.5	0.2	0.8
10/31/2020 07:00	3,984.6	2.9	3,985.6	104,000.0	414.5	0.5	0.2	0.8
10/31/2020 08:00	4,013.4	472.6	4,476.5	104,000.0	465.6	0.6	0.3	0.9
10/31/2020 09:00	3,956.1	841.9	4,798.0	104,000.0	499.0	0.6	0.3	1.0
10/31/2020 10:00	3,886.2	836.4	4,722.6	104,000.0	491.2	0.6	0.3	1.0
10/31/2020 11:00	3,829.3	866.1	4,695.4	104,000.0	488.3	0.6	0.3	1.0
10/31/2020 12:00	3,829.0	58.4	3,837.8	104,000.0	399.1	0.5	0.2	0.8
10/31/2020 13:00	3,950.7	60.5	4,000.9	104,000.0	416.1	0.5	0.3	0.8
10/31/2020 14:00	3,960.0	1,605.3	5,565.3	104,000.0	578.8	0.7	0.3	1.2
10/31/2020 15:00	3,729.3	74.5	3,746.4	104,000.0	389.6	0.5	0.2	0.8
10/31/2020 16:00	3,059.3	0.0	3,059.3	104,000.0	318.2	0.4	0.2	0.6
10/31/2020 17:00	3,856.0	0.0	3,856.0	104,000.0	401.0	0.5	0.2	0.8
10/31/2020 18:00	3,695.8	0.0	3,695.8	104,000.0	384.4	0.5	0.2	0.8
10/31/2020 19:00	3,621.6	0.0	3,621.6	104,000.0	376.6	0.5	0.2	0.8
10/31/2020 20:00	3,420.2	0.0	3,420.2	104,000.0	355.7	0.4	0.2	0.7
10/31/2020 21:00	3,725.5	0.0	3,725.5	104,000.0	387.5	0.5	0.2	0.8
10/31/2020 22:00	3,790.9	0.0	3,790.9	104,000.0	394.3	0.5	0.2	0.8
10/31/2020 23:00	3,164.0	0.0	3,164.0	104,000.0	329.1	0.4	0.2	0.7
Average/Sum#:	3,613.0	200.8	3,808.4	104,000.0	396.1	0.5	0.2	0.8
Minimum:	3,013.0	0.0	3,013.0	104,000.0	313.4	0.4	0.2	0.6
Maximum:	4,013.4	1,605.3	5,565.3	104,000.0	578.8	0.7	0.3	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/01/2020 00:00	2,833.8	0.0	2,833.8	104,000.0	294.7	0.4	0.2	0.6
11/01/2020 01:00	2,830.1	0.0	2,830.1	104,000.0	294.3	0.4	0.2	0.6
11/01/2020 02:00	2,828.4	0.0	2,828.4	104,000.0	294.2	0.4	0.2	0.6
11/01/2020 03:00	2,827.5	0.0	2,827.5	104,000.0	294.1	0.4	0.2	0.6
11/01/2020 04:00	2,833.6	0.0	2,833.6	104,000.0	294.7	0.4	0.2	0.6
11/01/2020 05:00	2,857.9	0.0	2,857.9	104,000.0	297.2	0.4	0.2	0.6
11/01/2020 06:00	2,987.5	0.0	2,987.5	104,000.0	310.7	0.4	0.2	0.6
11/01/2020 07:00	3,219.1	0.0	3,219.1	104,000.0	334.8	0.4	0.2	0.7
11/01/2020 08:00	3,473.9	0.0	3,473.9	104,000.0	361.3	0.4	0.2	0.7
11/01/2020 09:00	3,652.2	0.0	3,652.2	104,000.0	379.8	0.5	0.2	0.8
11/01/2020 10:00	3,891.2	82.3	3,948.8	104,000.0	410.7	0.5	0.2	0.8
11/01/2020 11:00	3,853.8	856.8	4,710.6	104,000.0	489.9	0.6	0.3	1.0
11/01/2020 12:00	3,989.1	817.6	4,806.7	104,000.0	499.9	0.6	0.3	1.0
11/01/2020 13:00	3,968.4	1,271.4	5,239.8	104,000.0	544.9	0.7	0.3	1.1
11/01/2020 14:00	3,959.9	1,672.1	5,632.0	104,000.0	585.7	0.7	0.4	1.2
11/01/2020 15:00	3,956.7	1,680.1	5,636.8	104,000.0	586.2	0.7	0.4	1.2
11/01/2020 16:00	3,962.5	1,671.6	5,634.1	104,000.0	585.9	0.7	0.4	1.2
11/01/2020 17:00	3,756.1	233.0	3,826.0	104,000.0	397.9	0.5	0.2	0.8
11/01/2020 18:00	3,615.5	0.0	3,615.5	104,000.0	376.0	0.4	0.2	0.8
11/01/2020 19:00	3,405.6	0.0	3,405.6	104,000.0	354.2	0.4	0.2	0.7
11/01/2020 20:00	2,853.8	0.0	2,853.8	104,000.0	296.8	0.4	0.2	0.6
11/01/2020 21:00	3,913.5	186.2	4,056.9	104,000.0	421.9	0.5	0.3	0.9
11/01/2020 22:00	3,508.2	0.0	3,508.2	104,000.0	364.9	0.4	0.2	0.7
11/01/2020 23:00	2,933.8	0.0	2,933.8	104,000.0	305.1	0.4	0.2	0.6
Average/Sum#:	3,413.0	353.0	3,756.4	104,000.0	390.7	0.5	0.2	0.8
Minimum:	2,827.5	0.0	2,827.5	104,000.0	294.1	0.4	0.2	0.6
Maximum:	3,989.1	1,680.1	5,636.8	104,000.0	586.2	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/02/2020 00:00	2,734.7	0.0	2,734.7	104,000.0	284.4	0.3	0.2	0.6
11/02/2020 01:00	2,743.3	0.0	2,743.3	104,000.0	285.3	0.3	0.2	0.6
11/02/2020 02:00	2,778.4	0.0	2,778.4	104,000.0	289.0	0.3	0.2	0.6
11/02/2020 03:00	2,920.1	0.0	2,920.1	104,000.0	303.7	0.4	0.2	0.6
11/02/2020 04:00	3,258.2	0.0	3,258.2	104,000.0	338.9	0.4	0.2	0.7
11/02/2020 05:00	3,349.2	0.0	3,349.2	104,000.0	348.3	0.4	0.2	0.7
11/02/2020 06:00	3,963.9	0.0	3,963.9	104,000.0	412.2	0.5	0.2	0.8
11/02/2020 07:00	3,975.8	2.5	3,976.7	104,000.0	413.6	0.5	0.2	0.8
11/02/2020 08:00	3,929.3	29.0	3,945.8	104,000.0	410.4	0.5	0.2	0.8
11/02/2020 09:00	3,921.7	219.4	4,141.1	104,000.0	430.7	0.5	0.3	0.9
11/02/2020 10:00	3,865.4	320.6	4,186.0	104,000.0	435.3	0.5	0.3	0.9
11/02/2020 11:00	3,794.2	1,119.4	4,913.6	104,000.0	511.0	0.6	0.3	1.0
11/02/2020 12:00	3,960.1	1,853.2	5,813.3	104,000.0	604.6	0.7	0.4	1.2
11/02/2020 13:00	3,946.0	1,916.8	5,862.8	104,000.0	609.7	0.7	0.4	1.2
11/02/2020 14:00	3,934.3	1,928.4	5,862.7	104,000.0	609.7	0.7	0.4	1.2
11/02/2020 15:00	3,927.7	1,926.1	5,853.8	104,000.0	608.8	0.7	0.4	1.2
11/02/2020 16:00	3,931.1	1,929.9	5,861.0	104,000.0	609.5	0.7	0.4	1.2
11/02/2020 17:00	3,946.2	1,871.2	5,817.4	104,000.0	605.0	0.7	0.4	1.2
11/02/2020 18:00	3,966.1	1,851.1	5,817.2	104,000.0	605.0	0.7	0.4	1.2
11/02/2020 19:00	3,988.9	1,240.6	5,229.5	104,000.0	543.9	0.7	0.3	1.1
11/02/2020 20:00	3,600.9	37.8	3,604.7	104,000.0	374.9	0.5	0.2	0.8
11/02/2020 21:00	3,963.2	870.4	4,676.9	104,000.0	486.4	0.6	0.3	1.0
11/02/2020 22:00	3,894.1	7.2	3,894.3	104,000.0	405.0	0.5	0.2	0.8
11/02/2020 23:00	3,188.0	0.0	3,188.0	104,000.0	331.6	0.4	0.2	0.7
Average/Sum#:	3,645.0	713.5	4,349.7	104,000.0	452.4	0.5	0.3	0.9
Minimum:	2,734.7	0.0	2,734.7	104,000.0	284.4	0.3	0.2	0.6
Maximum:	3,988.9	1,929.9	5,862.8	104,000.0	609.7	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/03/2020 00:00	2,983.5	0.0	2,983.5	104,000.0	310.3	0.4	0.2	0.6
11/03/2020 01:00	2,875.7	0.0	2,875.7	104,000.0	299.1	0.4	0.2	0.6
11/03/2020 02:00	2,835.7	0.0	2,835.7	104,000.0	294.9	0.4	0.2	0.6
11/03/2020 03:00	2,881.6	0.0	2,881.6	104,000.0	299.7	0.4	0.2	0.6
11/03/2020 04:00	2,954.0	0.0	2,954.0	104,000.0	307.2	0.4	0.2	0.6
11/03/2020 05:00	3,351.8	0.0	3,351.8	104,000.0	348.6	0.4	0.2	0.7
11/03/2020 06:00	3,884.8	1.1	3,885.1	104,000.0	404.1	0.5	0.2	0.8
11/03/2020 07:00	3,723.8	0.0	3,723.8	104,000.0	387.3	0.5	0.2	0.8
11/03/2020 08:00	3,984.1	383.7	4,329.4	104,000.0	450.3	0.5	0.3	0.9
11/03/2020 09:00	3,961.2	1,357.7	5,318.9	104,000.0	553.2	0.7	0.3	1.1
11/03/2020 10:00	3,873.9	1,557.3	5,431.2	104,000.0	564.8	0.7	0.3	1.1
11/03/2020 11:00	3,804.2	1,644.0	5,448.2	104,000.0	566.6	0.7	0.3	1.1
11/03/2020 12:00	3,828.3	1,601.0	5,429.3	104,000.0	564.6	0.7	0.3	1.1
11/03/2020 13:00	3,948.7	1,409.9	5,358.6	104,000.0	557.3	0.7	0.3	1.1
11/03/2020 14:00	3,943.8	1,457.5	5,401.3	104,000.0	561.7	0.7	0.3	1.1
11/03/2020 15:00	3,934.9	1,943.1	5,878.0	104,000.0	611.3	0.7	0.4	1.2
11/03/2020 16:00	3,949.8	1,894.8	5,844.6	104,000.0	607.8	0.7	0.4	1.2
11/03/2020 17:00	3,968.1	1,440.1	5,408.2	104,000.0	562.5	0.7	0.3	1.1
11/03/2020 18:00	3,982.1	931.2	4,913.3	104,000.0	511.0	0.6	0.3	1.0
11/03/2020 19:00	3,989.0	210.4	4,199.4	104,000.0	436.7	0.5	0.3	0.9
11/03/2020 20:00	4,015.7	419.0	4,434.7	104,000.0	461.2	0.6	0.3	0.9
11/03/2020 21:00	4,028.6	842.2	4,870.8	104,000.0	506.6	0.6	0.3	1.0
11/03/2020 22:00	4,014.6	543.8	4,330.0	104,000.0	450.3	0.6	0.3	0.9
11/03/2020 23:00	3,510.1	0.0	3,510.1	104,000.0	365.1	0.4	0.2	0.7
Average/Sum#:	3,676.2	734.9	4,399.9	104,000.0	457.6	0.6	0.3	0.9
Minimum:	2,835.7	0.0	2,835.7	104,000.0	294.9	0.4	0.2	0.6
Maximum:	4,028.6	1,943.1	5,878.0	104,000.0	611.3	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/04/2020 00:00	3,067.6	0.0	3,067.6	104,000.0	319.0	0.4	0.2	0.6
11/04/2020 01:00	2,879.2	0.0	2,879.2	104,000.0	299.4	0.4	0.2	0.6
11/04/2020 02:00	2,855.5	0.0	2,855.5	104,000.0	297.0	0.4	0.2	0.6
11/04/2020 03:00	2,874.0	0.0	2,874.0	104,000.0	298.9	0.4	0.2	0.6
11/04/2020 04:00	2,873.2	0.0	2,873.2	104,000.0	298.8	0.4	0.2	0.6
11/04/2020 05:00	3,208.7	0.0	3,208.7	104,000.0	333.7	0.4	0.2	0.7
11/04/2020 06:00	2,962.4	0.0	2,962.4	104,000.0	308.1	0.4	0.2	0.6
11/04/2020 07:00	3,401.1	0.0	3,401.1	104,000.0	353.7	0.4	0.2	0.7
11/04/2020 08:00	3,453.6	0.0	3,453.6	104,000.0	359.2	0.4	0.2	0.7
11/04/2020 09:00	3,949.5	158.4	4,079.4	104,000.0	424.3	0.5	0.3	0.9
11/04/2020 10:00	3,906.3	300.9	4,207.2	104,000.0	437.5	0.5	0.3	0.9
11/04/2020 11:00	3,860.1	386.2	4,246.3	104,000.0	441.6	0.5	0.3	0.9
11/04/2020 12:00	3,807.3	469.4	4,276.7	104,000.0	444.8	0.5	0.3	0.9
11/04/2020 13:00	3,774.5	1,141.8	4,916.3	104,000.0	511.3	0.6	0.3	1.0
11/04/2020 14:00	3,759.7	1,397.4	5,157.1	104,000.0	536.3	0.6	0.3	1.1
11/04/2020 15:00	3,750.2	1,409.6	5,159.8	104,000.0	536.6	0.6	0.3	1.1
11/04/2020 16:00	3,761.9	659.7	4,421.6	104,000.0	459.8	0.6	0.3	0.9
11/04/2020 17:00	3,757.8	9.6	3,766.7	104,000.0	391.7	0.5	0.2	0.8
11/04/2020 18:00	3,436.5	0.0	3,436.5	104,000.0	357.4	0.4	0.2	0.7
11/04/2020 19:00	3,637.4	0.0	3,637.4	104,000.0	378.3	0.5	0.2	0.8
11/04/2020 20:00	3,704.5	0.0	3,704.5	104,000.0	385.3	0.5	0.2	0.8
11/04/2020 21:00	3,922.7	202.7	4,090.9	104,000.0	425.5	0.5	0.3	0.9
11/04/2020 22:00	3,914.3	133.2	4,034.2	104,000.0	419.6	0.5	0.3	0.8
11/04/2020 23:00	3,602.6	0.0	3,602.6	104,000.0	374.7	0.5	0.2	0.7
Average/Sum#:	3,505.0	261.2	3,763.0	104,000.0	391.4	0.5	0.2	0.8
Minimum:	2,855.5	0.0	2,855.5	104,000.0	297.0	0.4	0.2	0.6
Maximum:	3,949.5	1,409.6	5,159.8	104,000.0	536.6	0.6	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/05/2020 00:00	3,002.5	0.0	3,002.5	104,000.0	312.3	0.4	0.2	0.6
11/05/2020 01:00	2,995.8	0.0	2,995.8	104,000.0	311.6	0.4	0.2	0.6
11/05/2020 02:00	2,997.1	0.0	2,997.1	104,000.0	311.7	0.4	0.2	0.6
11/05/2020 03:00	2,987.7	0.0	2,987.7	104,000.0	310.7	0.4	0.2	0.6
11/05/2020 04:00	2,981.4	0.0	2,981.4	104,000.0	310.1	0.4	0.2	0.6
11/05/2020 05:00	2,956.3	0.0	2,956.3	104,000.0	307.5	0.4	0.2	0.6
11/05/2020 06:00	3,368.6	0.0	3,368.6	104,000.0	350.3	0.4	0.2	0.7
11/05/2020 07:00	3,659.9	0.0	3,659.9	104,000.0	380.6	0.5	0.2	0.8
11/05/2020 08:00	3,774.7	0.0	3,774.7	104,000.0	392.6	0.5	0.2	0.8
11/05/2020 09:00	3,771.7	0.0	3,771.7	104,000.0	392.3	0.5	0.2	0.8
11/05/2020 10:00	3,850.4	262.2	4,112.6	104,000.0	427.7	0.5	0.3	0.9
11/05/2020 11:00	3,810.5	368.5	4,179.0	104,000.0	434.6	0.5	0.3	0.9
11/05/2020 12:00	3,773.6	396.6	4,170.2	104,000.0	433.7	0.5	0.3	0.9
11/05/2020 13:00	3,740.9	1,214.0	4,954.9	104,000.0	515.3	0.6	0.3	1.0
11/05/2020 14:00	3,708.8	1,745.6	5,454.4	104,000.0	567.3	0.7	0.3	1.1
11/05/2020 15:00	3,697.5	1,422.9	5,120.4	104,000.0	532.5	0.6	0.3	1.1
11/05/2020 16:00	3,722.9	1,351.6	5,074.5	104,000.0	527.7	0.6	0.3	1.1
11/05/2020 17:00	3,727.9	171.4	3,774.2	104,000.0	392.5	0.5	0.2	0.8
11/05/2020 18:00	3,450.1	0.0	3,450.1	104,000.0	358.8	0.4	0.2	0.7
11/05/2020 19:00	3,483.5	0.0	3,483.5	104,000.0	362.3	0.4	0.2	0.7
11/05/2020 20:00	3,867.8	450.2	4,318.0	104,000.0	449.1	0.5	0.3	0.9
11/05/2020 21:00	3,966.0	397.3	4,363.3	104,000.0	453.8	0.5	0.3	0.9
11/05/2020 22:00	3,670.6	37.2	3,675.4	104,000.0	382.2	0.5	0.2	0.8
11/05/2020 23:00	3,586.0	0.0	3,586.0	104,000.0	372.9	0.4	0.2	0.7
Average/Sum#:	3,523.0	325.7	3,842.2	104,000.0	399.6	0.5	0.2	0.8
Minimum:	2,956.3	0.0	2,956.3	104,000.0	307.5	0.4	0.2	0.6
Maximum:	3,966.0	1,745.6	5,454.4	104,000.0	567.3	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/06/2020 00:00	2,851.3	0.0	2,851.3	104,000.0	296.5	0.4	0.2	0.6
11/06/2020 01:00	2,824.4	0.0	2,824.4	104,000.0	293.7	0.4	0.2	0.6
11/06/2020 02:00	2,830.1	0.0	2,830.1	104,000.0	294.3	0.4	0.2	0.6
11/06/2020 03:00	2,856.7	0.0	2,856.7	104,000.0	297.1	0.4	0.2	0.6
11/06/2020 04:00	2,878.7	0.0	2,878.7	104,000.0	299.4	0.4	0.2	0.6
11/06/2020 05:00	3,017.5	0.0	3,017.5	104,000.0	313.8	0.4	0.2	0.6
11/06/2020 06:00	3,108.8	0.0	3,108.8	104,000.0	323.3	0.4	0.2	0.6
11/06/2020 07:00	3,373.3	0.0	3,373.3	104,000.0	350.8	0.4	0.2	0.7
11/06/2020 08:00	3,732.5	0.0	3,732.5	104,000.0	388.2	0.5	0.2	0.8
11/06/2020 09:00	3,653.0	0.0	3,653.0	104,000.0	379.9	0.5	0.2	0.8
11/06/2020 10:00	3,766.4	0.0	3,766.4	104,000.0	391.7	0.5	0.2	0.8
11/06/2020 11:00	3,755.2	0.0	3,755.2	104,000.0	390.5	0.5	0.2	0.8
11/06/2020 12:00	3,724.8	0.0	3,724.8	104,000.0	387.4	0.5	0.2	0.8
11/06/2020 13:00	3,852.9	104.4	3,931.2	104,000.0	408.8	0.5	0.2	0.8
11/06/2020 14:00	3,876.0	175.4	4,051.4	104,000.0	421.3	0.5	0.3	0.8
11/06/2020 15:00	3,731.3	16.6	3,733.5	104,000.0	388.3	0.5	0.2	0.8
11/06/2020 16:00	3,281.4	0.0	3,281.4	104,000.0	341.3	0.4	0.2	0.7
11/06/2020 17:00	3,745.0	536.6	4,002.6	104,000.0	416.3	0.5	0.3	0.9
11/06/2020 18:00	3,132.6	1.0	3,132.6	104,000.0	325.8	0.4	0.2	0.7
11/06/2020 19:00	3,892.0	149.6	3,941.4	104,000.0	409.9	0.5	0.3	0.8
11/06/2020 20:00	3,810.7	66.9	3,825.4	104,000.0	397.8	0.5	0.2	0.8
11/06/2020 21:00	3,763.8	0.0	3,763.8	104,000.0	391.4	0.5	0.2	0.8
11/06/2020 22:00	3,768.5	0.0	3,768.5	104,000.0	391.9	0.5	0.2	0.8
11/06/2020 23:00	3,520.4	0.0	3,520.4	104,000.0	366.1	0.4	0.2	0.7
Average/Sum#:	3,447.8	43.8	3,471.9	104,000.0	361.1	0.5	0.2	0.7
Minimum:	2,824.4	0.0	2,824.4	104,000.0	293.7	0.4	0.2	0.6
Maximum:	3,892.0	536.6	4,051.4	104,000.0	421.3	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/07/2020 00:00	3,307.3	0.0	3,307.3	104,000.0	344.0	0.4	0.2	0.7
11/07/2020 01:00	2,955.5	0.0	2,955.5	104,000.0	307.4	0.4	0.2	0.6
11/07/2020 02:00	2,826.5	0.0	2,826.5	104,000.0	294.0	0.4	0.2	0.6
11/07/2020 03:00	2,825.5	0.0	2,825.5	104,000.0	293.9	0.4	0.2	0.6
11/07/2020 04:00	2,834.1	0.0	2,834.1	104,000.0	294.7	0.4	0.2	0.6
11/07/2020 05:00	2,868.7	0.0	2,868.7	104,000.0	298.3	0.4	0.2	0.6
11/07/2020 06:00	2,888.3	0.0	2,888.3	104,000.0	300.4	0.4	0.2	0.6
11/07/2020 07:00	3,230.9	0.0	3,230.9	104,000.0	336.0	0.4	0.2	0.7
11/07/2020 08:00	3,731.0	3.0	3,731.2	104,000.0	388.0	0.5	0.2	0.8
11/07/2020 09:00	3,993.4	13.7	4,007.1	104,000.0	416.7	0.5	0.3	0.8
11/07/2020 10:00	3,974.1	32.7	4,006.8	104,000.0	416.7	0.5	0.3	0.8
11/07/2020 11:00	3,937.3	28.0	3,965.3	104,000.0	412.4	0.5	0.2	0.8
11/07/2020 12:00	3,770.0	0.0	3,770.0	104,000.0	392.1	0.5	0.2	0.8
11/07/2020 13:00	3,457.9	0.0	3,457.9	104,000.0	359.6	0.4	0.2	0.7
11/07/2020 14:00	3,611.1	0.0	3,611.1	104,000.0	375.6	0.5	0.2	0.8
11/07/2020 15:00	3,633.7	0.0	3,633.7	104,000.0	377.9	0.5	0.2	0.8
11/07/2020 16:00	3,175.2	0.0	3,175.2	104,000.0	330.2	0.4	0.2	0.7
11/07/2020 17:00	3,514.6	0.0	3,514.6	104,000.0	365.5	0.4	0.2	0.7
11/07/2020 18:00	3,830.3	0.0	3,830.3	104,000.0	398.4	0.5	0.2	0.8
11/07/2020 19:00	3,885.0	0.0	3,885.0	104,000.0	404.0	0.5	0.2	0.8
11/07/2020 20:00	3,802.2	0.0	3,802.2	104,000.0	395.4	0.5	0.2	0.8
11/07/2020 21:00	3,668.5	0.0	3,668.5	104,000.0	381.5	0.5	0.2	0.8
11/07/2020 22:00	3,705.7	0.0	3,705.7	104,000.0	385.4	0.5	0.2	0.8
11/07/2020 23:00	3,443.1	0.0	3,443.1	104,000.0	358.1	0.4	0.2	0.7
Average/Sum#:	3,452.9	3.2	3,456.0	104,000.0	359.4	0.5	0.2	0.7
Minimum:	2,825.5	0.0	2,825.5	104,000.0	293.9	0.4	0.2	0.6
Maximum:	3,993.4	32.7	4,007.1	104,000.0	416.7	0.5	0.3	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/08/2020 00:00	3,280.5	0.0	3,280.5	104,000.0	341.2	0.4	0.2	0.7
11/08/2020 01:00	3,039.1	0.0	3,039.1	104,000.0	316.1	0.4	0.2	0.6
11/08/2020 02:00	2,921.2	0.0	2,921.2	104,000.0	303.8	0.4	0.2	0.6
11/08/2020 03:00	2,925.2	0.0	2,925.2	104,000.0	304.2	0.4	0.2	0.6
11/08/2020 04:00	2,955.4	0.0	2,955.4	104,000.0	307.4	0.4	0.2	0.6
11/08/2020 05:00	3,016.1	0.0	3,016.1	104,000.0	313.7	0.4	0.2	0.6
11/08/2020 06:00	3,390.6	0.0	3,390.6	104,000.0	352.6	0.4	0.2	0.7
11/08/2020 07:00	3,540.4	0.0	3,540.4	104,000.0	368.2	0.4	0.2	0.7
11/08/2020 08:00	3,870.4	0.0	3,870.4	104,000.0	402.5	0.5	0.2	0.8
11/08/2020 09:00	2,944.2	0.0	2,944.2	104,000.0	306.2	0.4	0.2	0.6
11/08/2020 10:00	2,922.2	0.0	2,922.2	104,000.0	303.9	0.4	0.2	0.6
11/08/2020 11:00	3,102.2	0.0	3,102.2	104,000.0	322.6	0.4	0.2	0.6
11/08/2020 12:00	3,098.6	0.0	3,098.6	104,000.0	322.3	0.4	0.2	0.6
11/08/2020 13:00	3,239.4	0.0	3,239.4	104,000.0	336.9	0.4	0.2	0.7
11/08/2020 14:00	3,923.8	107.4	4,006.5	104,000.0	416.7	0.5	0.3	0.8
11/08/2020 15:00	3,952.3	92.3	4,044.6	104,000.0	420.6	0.5	0.3	0.8
11/08/2020 16:00	3,869.6	2.5	3,870.7	104,000.0	402.6	0.5	0.2	0.8
11/08/2020 17:00	3,792.7	0.0	3,792.7	104,000.0	394.4	0.5	0.2	0.8
11/08/2020 18:00	3,881.3	0.8	3,881.4	104,000.0	403.7	0.5	0.2	0.8
11/08/2020 19:00	3,952.3	3.0	3,953.2	104,000.0	411.1	0.5	0.2	0.8
11/08/2020 20:00	3,801.0	0.0	3,801.0	104,000.0	395.3	0.5	0.2	0.8
11/08/2020 21:00	3,718.6	0.0	3,718.6	104,000.0	386.7	0.5	0.2	0.8
11/08/2020 22:00	3,544.6	0.0	3,544.6	104,000.0	368.6	0.4	0.2	0.7
11/08/2020 23:00	3,431.9	0.0	3,431.9	104,000.0	356.9	0.4	0.2	0.7
Average/Sum#:	3,421.4	8.6	3,428.8	104,000.0	356.6	0.4	0.2	0.7
Minimum:	2,921.2	0.0	2,921.2	104,000.0	303.8	0.4	0.2	0.6
Maximum:	3,952.3	107.4	4,044.6	104,000.0	420.6	0.5	0.3	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/09/2020 00:00	3,095.0	0.0	3,095.0	104,000.0	321.9	0.4	0.2	0.6
11/09/2020 01:00	3,167.8	0.0	3,167.8	104,000.0	329.5	0.4	0.2	0.7
11/09/2020 02:00	3,105.8	0.0	3,105.8	104,000.0	323.0	0.4	0.2	0.6
11/09/2020 03:00	3,214.9	0.0	3,214.9	104,000.0	334.3	0.4	0.2	0.7
11/09/2020 04:00	3,399.7	0.0	3,399.7	104,000.0	353.6	0.4	0.2	0.7
11/09/2020 05:00	3,712.6	0.0	3,712.6	104,000.0	386.1	0.5	0.2	0.8
11/09/2020 06:00	3,727.4	0.0	3,727.4	104,000.0	387.6	0.5	0.2	0.8
11/09/2020 07:00	4,015.3	0.0	4,015.3	104,000.0	417.6	0.5	0.3	0.8
11/09/2020 08:00	4,051.1	4.3	4,052.7	104,000.0	421.5	0.5	0.3	0.8
11/09/2020 09:00	4,107.7	11.8	4,119.5	104,000.0	428.4	0.5	0.3	0.9
11/09/2020 10:00	4,089.0	4.1	4,093.1	104,000.0	425.7	0.5	0.3	0.9
11/09/2020 11:00	4,066.2	42.1	4,108.3	104,000.0	427.3	0.5	0.3	0.9
11/09/2020 12:00	4,035.3	6.1	4,041.3	104,000.0	420.3	0.5	0.3	0.8
11/09/2020 13:00	4,030.9	6.1	4,037.0	104,000.0	419.8	0.5	0.3	0.8
11/09/2020 14:00	4,014.9	132.3	4,143.2	104,000.0	430.9	0.5	0.3	0.9
11/09/2020 15:00	3,542.8	0.0	3,542.8	104,000.0	368.5	0.4	0.2	0.7
11/09/2020 16:00	3,466.6	0.0	3,466.6	104,000.0	360.5	0.4	0.2	0.7
11/09/2020 17:00	3,467.0	0.0	3,467.0	104,000.0	360.6	0.4	0.2	0.7
11/09/2020 18:00	3,493.4	0.0	3,493.4	104,000.0	363.3	0.4	0.2	0.7
11/09/2020 19:00	3,508.0	0.0	3,508.0	104,000.0	364.8	0.4	0.2	0.7
11/09/2020 20:00	3,541.6	0.0	3,541.6	104,000.0	368.3	0.4	0.2	0.7
11/09/2020 21:00	3,576.3	0.0	3,576.3	104,000.0	371.9	0.4	0.2	0.7
11/09/2020 22:00	3,716.1	0.0	3,716.1	104,000.0	386.5	0.5	0.2	0.8
11/09/2020 23:00	3,912.5	0.0	3,912.5	104,000.0	406.9	0.5	0.2	0.8
Average/Sum#:	3,669.1	8.6	3,677.4	104,000.0	382.5	0.5	0.2	0.8
Minimum:	3,095.0	0.0	3,095.0	104,000.0	321.9	0.4	0.2	0.6
Maximum:	4,107.7	132.3	4,143.2	104,000.0	430.9	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/10/2020 00:00	3,143.2	0.0	3,143.2	104,000.0	326.9	0.4	0.2	0.7
11/10/2020 01:00	3,352.6	0.0	3,352.6	104,000.0	348.7	0.4	0.2	0.7
11/10/2020 02:00	3,324.5	0.0	3,324.5	104,000.0	345.7	0.4	0.2	0.7
11/10/2020 03:00	3,421.5	0.0	3,421.5	104,000.0	355.8	0.4	0.2	0.7
11/10/2020 04:00	3,627.6	0.0	3,627.6	104,000.0	377.3	0.5	0.2	0.8
11/10/2020 05:00	3,968.3	0.0	3,968.3	104,000.0	412.7	0.5	0.2	0.8
11/10/2020 06:00	3,906.9	0.0	3,906.9	104,000.0	406.3	0.5	0.2	0.8
11/10/2020 07:00	4,122.1	72.6	4,158.4	104,000.0	432.5	0.5	0.3	0.9
11/10/2020 08:00	4,156.1	653.9	4,810.0	104,000.0	500.2	0.6	0.3	1.0
11/10/2020 09:00	4,104.8	467.8	4,572.6	104,000.0	475.6	0.6	0.3	1.0
11/10/2020 10:00	3,675.7	0.0	3,675.7	104,000.0	382.3	0.5	0.2	0.8
11/10/2020 11:00	3,696.6	0.0	3,696.6	104,000.0	384.4	0.5	0.2	0.8
11/10/2020 12:00	3,738.6	2.9	3,738.7	104,000.0	388.8	0.5	0.2	0.8
11/10/2020 13:00	3,972.5	102.3	4,074.8	104,000.0	423.8	0.5	0.3	0.8
11/10/2020 14:00	3,522.5	19.0	3,525.7	104,000.0	366.7	0.4	0.2	0.7
11/10/2020 15:00	3,928.0	0.0	3,928.0	105,100.0	412.8	0.5	0.2	0.8
11/10/2020 16:00	3,787.0	0.0	3,787.0	105,100.0	398.0	0.5	0.2	0.8
11/10/2020 17:00	3,750.9	0.0	3,750.9	105,100.0	394.2	0.5	0.2	0.8
11/10/2020 18:00	3,660.7	0.0	3,660.7	105,100.0	384.7	0.5	0.2	0.8
11/10/2020 19:00	3,984.8	0.0	3,984.8	105,100.0	418.8	0.5	0.3	0.8
11/10/2020 20:00	3,864.7	0.0	3,864.7	105,100.0	406.2	0.5	0.2	0.8
11/10/2020 21:00	3,982.1	0.0	3,982.1	105,100.0	418.5	0.5	0.3	0.8
11/10/2020 22:00	3,845.1	0.0	3,845.1	105,100.0	404.1	0.5	0.2	0.8
11/10/2020 23:00	3,329.9	0.0	3,329.9	105,100.0	350.0	0.4	0.2	0.7
Average/Sum#:	3,744.4	54.9	3,797.1	104,412.5	396.5	0.5	0.2	0.8
Minimum:	3,143.2	0.0	3,143.2	104,000.0	326.9	0.4	0.2	0.7
Maximum:	4,156.1	653.9	4,810.0	105,100.0	500.2	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/11/2020 00:00	2,831.7	0.0	2,831.7	105,100.0	297.6	0.4	0.2	0.6
11/11/2020 01:00	2,766.1	0.0	2,766.1	105,100.0	290.7	0.4	0.2	0.6
11/11/2020 02:00	2,764.7	0.0	2,764.7	105,100.0	290.6	0.3	0.2	0.6
11/11/2020 03:00	2,763.2	0.0	2,763.2	105,100.0	290.4	0.4	0.2	0.6
11/11/2020 04:00	2,793.2	0.0	2,793.2	105,100.0	293.6	0.4	0.2	0.6
11/11/2020 05:00	3,192.9	0.0	3,192.9	105,100.0	335.6	0.4	0.2	0.7
11/11/2020 06:00	3,511.5	0.0	3,511.5	105,100.0	369.1	0.4	0.2	0.7
11/11/2020 07:00	3,805.6	0.0	3,805.6	105,100.0	400.0	0.5	0.2	0.8
11/11/2020 08:00	3,930.8	0.1	3,930.8	105,100.0	413.1	0.5	0.2	0.8
11/11/2020 09:00	3,956.7	2.2	3,957.4	105,100.0	415.9	0.5	0.2	0.8
11/11/2020 10:00	3,892.2	2.3	3,893.0	105,100.0	409.2	0.5	0.2	0.8
11/11/2020 11:00	3,650.3	0.0	3,650.3	105,100.0	383.6	0.5	0.2	0.8
11/11/2020 12:00	3,649.4	0.0	3,649.4	105,100.0	383.6	0.5	0.2	0.8
11/11/2020 13:00	3,650.5	0.0	3,650.5	105,100.0	383.7	0.5	0.2	0.8
11/11/2020 14:00	3,697.4	0.0	3,697.4	105,100.0	388.6	0.5	0.2	0.8
11/11/2020 15:00	3,964.8	352.1	4,288.7	105,100.0	450.7	0.5	0.3	0.9
11/11/2020 16:00	3,863.2	177.9	3,948.6	105,100.0	415.0	0.5	0.3	0.8
11/11/2020 17:00	3,559.3	0.0	3,559.3	105,100.0	374.1	0.5	0.2	0.7
11/11/2020 18:00	3,624.5	0.0	3,624.5	105,100.0	380.9	0.5	0.2	0.8
11/11/2020 19:00	3,415.7	0.0	3,415.7	105,100.0	359.0	0.4	0.2	0.7
11/11/2020 20:00	3,731.6	0.0	3,731.6	105,100.0	392.2	0.5	0.2	0.8
11/11/2020 21:00	3,882.6	0.0	3,882.6	105,100.0	408.1	0.5	0.2	0.8
11/11/2020 22:00	3,466.9	0.0	3,466.9	105,100.0	364.4	0.4	0.2	0.7
11/11/2020 23:00	3,014.6	0.0	3,014.6	105,100.0	316.8	0.4	0.2	0.6
Average/Sum#:	3,474.1	22.3	3,491.3	105,100.0	366.9	0.5	0.2	0.7
Minimum:	2,763.2	0.0	2,763.2	105,100.0	290.4	0.3	0.2	0.6
Maximum:	3,964.8	352.1	4,288.7	105,100.0	450.7	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/12/2020 00:00	2,863.0	0.0	2,863.0	105,100.0	300.9	0.4	0.2	0.6
11/12/2020 01:00	2,755.2	0.0	2,755.2	105,100.0	289.6	0.4	0.2	0.6
11/12/2020 02:00	2,758.6	0.0	2,758.6	105,100.0	289.9	0.4	0.2	0.6
11/12/2020 03:00	2,778.9	0.0	2,778.9	105,100.0	292.1	0.4	0.2	0.6
11/12/2020 04:00	2,953.0	0.0	2,953.0	105,100.0	310.4	0.4	0.2	0.6
11/12/2020 05:00	3,301.5	0.0	3,301.5	105,100.0	347.0	0.4	0.2	0.7
11/12/2020 06:00	3,791.9	0.0	3,791.9	105,100.0	398.5	0.5	0.2	0.8
11/12/2020 07:00	4,028.5	0.2	4,028.5	105,100.0	423.4	0.5	0.3	0.8
11/12/2020 08:00	4,070.5	4.1	4,072.8	105,100.0	428.1	0.5	0.3	0.9
11/12/2020 09:00	4,049.7	21.9	4,070.5	105,100.0	427.8	0.5	0.3	0.9
11/12/2020 10:00	3,572.7	0.0	3,572.7	105,100.0	375.5	0.5	0.2	0.8
11/12/2020 11:00	3,088.4	0.0	3,088.4	105,100.0	324.6	0.4	0.2	0.6
11/12/2020 12:00	2,869.2	0.0	2,869.2	105,100.0	301.6	0.4	0.2	0.6
11/12/2020 13:00	2,872.1	0.0	2,872.1	105,100.0	301.9	0.4	0.2	0.6
11/12/2020 14:00	2,887.4	0.0	2,887.4	105,100.0	303.5	0.4	0.2	0.6
11/12/2020 15:00	3,808.2	0.0	3,808.2	105,100.0	400.2	0.5	0.2	0.8
11/12/2020 16:00	3,777.5	0.0	3,777.5	105,100.0	397.0	0.5	0.2	0.8
11/12/2020 17:00	3,835.7	0.0	3,835.7	105,100.0	403.1	0.5	0.2	0.8
11/12/2020 18:00	3,850.0	0.0	3,850.0	105,100.0	404.6	0.5	0.2	0.8
11/12/2020 19:00	3,954.3	0.0	3,954.3	105,100.0	415.6	0.5	0.2	0.8
11/12/2020 20:00	3,952.5	0.0	3,952.5	105,100.0	415.4	0.5	0.2	0.8
11/12/2020 21:00	3,871.9	0.0	3,871.9	105,100.0	406.9	0.5	0.2	0.8
11/12/2020 22:00	3,419.2	0.0	3,419.2	105,100.0	359.4	0.4	0.2	0.7
11/12/2020 23:00	3,135.9	0.0	3,135.9	105,100.0	329.6	0.4	0.2	0.7
Average/Sum#:	3,426.9	1.1	3,427.9	105,100.0	360.3	0.5	0.2	0.7
Minimum:	2,755.2	0.0	2,755.2	105,100.0	289.6	0.4	0.2	0.6
Maximum:	4,070.5	21.9	4,072.8	105,100.0	428.1	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/13/2020 00:00	2,891.2	0.0	2,891.2	105,100.0	303.9	0.4	0.2	0.6
11/13/2020 01:00	2,762.7	0.0	2,762.7	105,100.0	290.4	0.4	0.2	0.6
11/13/2020 02:00	2,766.3	0.0	2,766.3	105,100.0	290.7	0.4	0.2	0.6
11/13/2020 03:00	2,769.8	0.0	2,769.8	105,100.0	291.1	0.4	0.2	0.6
11/13/2020 04:00	2,765.5	0.0	2,765.5	105,100.0	290.7	0.4	0.2	0.6
11/13/2020 05:00	3,116.2	0.0	3,116.2	105,100.0	327.5	0.4	0.2	0.7
11/13/2020 06:00	3,670.9	0.0	3,670.9	105,100.0	385.8	0.5	0.2	0.8
11/13/2020 07:00	3,973.7	4.4	3,975.0	105,100.0	417.8	0.5	0.3	0.8
11/13/2020 08:00	4,040.5	4.3	4,044.1	105,100.0	425.0	0.5	0.3	0.9
11/13/2020 09:00	4,033.7	7.3	4,041.0	105,100.0	424.7	0.5	0.3	0.9
11/13/2020 10:00	4,036.0	61.0	4,097.0	105,100.0	430.6	0.5	0.3	0.9
11/13/2020 11:00	4,007.7	450.2	4,457.9	105,100.0	468.5	0.6	0.3	0.9
11/13/2020 12:00	4,001.0	299.6	4,300.6	105,100.0	452.0	0.5	0.3	0.9
11/13/2020 13:00	4,018.0	509.1	4,527.1	105,100.0	475.8	0.6	0.3	1.0
11/13/2020 14:00	4,026.2	187.1	4,213.3	105,100.0	442.8	0.5	0.3	0.9
11/13/2020 15:00	3,987.0	5.6	3,992.6	105,100.0	419.6	0.5	0.3	0.8
11/13/2020 16:00	3,917.2	1.2	3,917.3	105,100.0	411.7	0.5	0.2	0.8
11/13/2020 17:00	3,522.9	0.0	3,522.9	105,100.0	370.3	0.4	0.2	0.7
11/13/2020 18:00	3,605.6	0.0	3,605.6	105,100.0	378.9	0.5	0.2	0.8
11/13/2020 19:00	3,381.0	0.0	3,381.0	105,100.0	355.3	0.4	0.2	0.7
11/13/2020 20:00	3,751.7	0.0	3,751.7	105,100.0	394.3	0.5	0.2	0.8
11/13/2020 21:00	3,783.7	0.0	3,783.7	105,100.0	397.7	0.5	0.2	0.8
11/13/2020 22:00	3,590.1	0.0	3,590.1	105,100.0	377.3	0.5	0.2	0.8
11/13/2020 23:00	3,099.4	0.0	3,099.4	105,100.0	325.7	0.4	0.2	0.7
Average/Sum#:	3,563.3	63.7	3,626.8	105,100.0	381.2	0.5	0.2	0.8
Minimum:	2,762.7	0.0	2,762.7	105,100.0	290.4	0.4	0.2	0.6
Maximum:	4,040.5	509.1	4,527.1	105,100.0	475.8	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/14/2020 00:00	2,953.0	0.0	2,953.0	105,100.0	310.4	0.4	0.2	0.6
11/14/2020 01:00	2,749.2	0.0	2,749.2	105,100.0	288.9	0.3	0.2	0.6
11/14/2020 02:00	2,770.2	0.0	2,770.2	105,100.0	291.1	0.4	0.2	0.6
11/14/2020 03:00	2,771.2	0.0	2,771.2	105,100.0	291.3	0.4	0.2	0.6
11/14/2020 04:00	2,770.1	0.0	2,770.1	105,100.0	291.1	0.4	0.2	0.6
11/14/2020 05:00	2,786.5	0.0	2,786.5	105,100.0	292.9	0.4	0.2	0.6
11/14/2020 06:00	3,015.8	0.0	3,015.8	105,100.0	317.0	0.4	0.2	0.6
11/14/2020 07:00	3,487.9	0.0	3,487.9	105,100.0	366.6	0.4	0.2	0.7
11/14/2020 08:00	3,816.6	6.5	3,817.1	105,100.0	401.2	0.5	0.2	0.8
11/14/2020 09:00	4,075.8	152.4	4,213.0	105,100.0	442.8	0.5	0.3	0.9
11/14/2020 10:00	3,447.4	0.0	3,447.4	105,100.0	362.3	0.4	0.2	0.7
11/14/2020 11:00	3,165.8	0.0	3,165.8	105,100.0	332.7	0.4	0.2	0.7
11/14/2020 12:00	3,272.9	0.0	3,272.9	105,100.0	344.0	0.4	0.2	0.7
11/14/2020 13:00	3,930.2	41.5	3,943.5	105,100.0	414.5	0.5	0.3	0.8
11/14/2020 14:00	3,894.5	9.7	3,895.8	105,100.0	409.4	0.5	0.2	0.8
11/14/2020 15:00	3,802.3	14.6	3,803.3	105,100.0	399.7	0.5	0.2	0.8
11/14/2020 16:00	3,929.4	275.0	4,163.2	105,100.0	437.6	0.5	0.3	0.9
11/14/2020 17:00	3,720.3	0.0	3,720.3	105,100.0	391.0	0.5	0.2	0.8
11/14/2020 18:00	3,787.4	0.0	3,787.4	105,100.0	398.1	0.5	0.2	0.8
11/14/2020 19:00	3,721.2	0.0	3,721.2	105,100.0	391.1	0.5	0.2	0.8
11/14/2020 20:00	4,024.2	0.0	4,024.2	105,100.0	422.9	0.5	0.3	0.8
11/14/2020 21:00	4,016.5	67.6	4,034.8	105,100.0	424.1	0.5	0.3	0.9
11/14/2020 22:00	4,083.0	468.6	4,504.7	105,100.0	473.4	0.6	0.3	1.0
11/14/2020 23:00	3,481.6	0.0	3,481.6	105,100.0	365.9	0.4	0.2	0.7
Average/Sum#:	3,478.0	43.2	3,512.5	105,100.0	369.2	0.5	0.2	0.7
Minimum:	2,749.2	0.0	2,749.2	105,100.0	288.9	0.3	0.2	0.6
Maximum:	4,083.0	468.6	4,504.7	105,100.0	473.4	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/15/2020 00:00	2,889.0	0.0	2,889.0	105,100.0	303.6	0.4	0.2	0.6
11/15/2020 01:00	2,857.3	0.0	2,857.3	105,100.0	300.3	0.4	0.2	0.6
11/15/2020 02:00	3,306.5	0.0	3,306.5	105,100.0	347.5	0.4	0.2	0.7
11/15/2020 03:00	3,315.9	0.0	3,315.9	105,100.0	348.5	0.4	0.2	0.7
11/15/2020 04:00	2,829.3	0.0	2,829.3	105,100.0	297.4	0.4	0.2	0.6
11/15/2020 05:00	3,069.2	0.0	3,069.2	105,100.0	322.6	0.4	0.2	0.6
11/15/2020 06:00	3,390.2	0.0	3,390.2	105,100.0	356.3	0.4	0.2	0.7
11/15/2020 07:00	3,377.1	0.0	3,377.1	105,100.0	354.9	0.4	0.2	0.7
11/15/2020 08:00	3,649.2	0.0	3,649.2	105,100.0	383.5	0.5	0.2	0.8
11/15/2020 09:00	3,735.5	0.0	3,735.5	105,100.0	392.6	0.5	0.2	0.8
11/15/2020 10:00	3,850.6	0.6	3,850.6	105,100.0	404.7	0.5	0.2	0.8
11/15/2020 11:00	3,946.3	77.7	4,024.0	105,100.0	422.9	0.5	0.3	0.8
11/15/2020 12:00	3,890.1	3.0	3,893.1	105,100.0	409.2	0.5	0.2	0.8
11/15/2020 13:00	3,881.3	69.8	3,951.1	105,100.0	415.3	0.5	0.2	0.8
11/15/2020 14:00	3,864.8	387.2	4,252.0	105,100.0	446.9	0.5	0.3	0.9
11/15/2020 15:00	3,855.5	662.1	4,517.6	105,100.0	474.8	0.6	0.3	0.9
11/15/2020 16:00	3,851.5	466.7	4,318.2	105,100.0	453.8	0.5	0.3	0.9
11/15/2020 17:00	3,875.3	202.8	4,078.1	105,100.0	428.6	0.5	0.3	0.9
11/15/2020 18:00	3,906.9	23.4	3,930.3	105,100.0	413.1	0.5	0.2	0.8
11/15/2020 19:00	3,952.7	336.1	4,288.8	105,100.0	450.8	0.5	0.3	0.9
11/15/2020 20:00	3,982.9	321.1	4,304.0	105,100.0	452.4	0.5	0.3	0.9
11/15/2020 21:00	3,849.2	4.8	3,853.9	105,100.0	405.0	0.5	0.2	0.8
11/15/2020 22:00	3,339.3	0.0	3,339.3	105,100.0	351.0	0.4	0.2	0.7
11/15/2020 23:00	3,085.8	0.0	3,085.8	105,100.0	324.3	0.4	0.2	0.6
Average/Sum#:	3,564.6	106.5	3,671.1	105,100.0	385.8	0.5	0.2	0.8
Minimum:	2,829.3	0.0	2,829.3	105,100.0	297.4	0.4	0.2	0.6
Maximum:	3,982.9	662.1	4,517.6	105,100.0	474.8	0.6	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/16/2020 00:00	2,842.3	0.0	2,842.3	105,100.0	298.7	0.4	0.2	0.6
11/16/2020 01:00	2,822.6	0.0	2,822.6	105,100.0	296.7	0.4	0.2	0.6
11/16/2020 02:00	2,787.0	0.0	2,787.0	105,100.0	292.9	0.4	0.2	0.6
11/16/2020 03:00	2,813.5	0.0	2,813.5	105,100.0	295.7	0.4	0.2	0.6
11/16/2020 04:00	2,833.9	0.0	2,833.9	105,100.0	297.8	0.4	0.2	0.6
11/16/2020 05:00	3,146.5	0.0	3,146.5	105,100.0	330.7	0.4	0.2	0.7
11/16/2020 06:00	4,005.7	0.2	4,005.7	105,100.0	421.0	0.5	0.3	0.8
11/16/2020 07:00	4,100.2	4.2	4,104.0	105,100.0	431.3	0.5	0.3	0.9
11/16/2020 08:00	4,085.2	54.4	4,139.6	105,100.0	435.1	0.5	0.3	0.9
11/16/2020 09:00	4,043.5	155.0	4,198.5	105,100.0	441.3	0.5	0.3	0.9
11/16/2020 10:00	3,987.1	149.5	4,136.6	105,100.0	434.8	0.5	0.3	0.9
11/16/2020 11:00	3,941.2	294.6	4,235.8	105,100.0	445.2	0.5	0.3	0.9
11/16/2020 12:00	3,907.4	362.6	4,270.0	105,100.0	448.8	0.5	0.3	0.9
11/16/2020 13:00	3,879.2	418.0	4,297.2	105,100.0	451.6	0.5	0.3	0.9
11/16/2020 14:00	3,852.0	239.8	4,091.8	105,100.0	430.0	0.5	0.3	0.9
11/16/2020 15:00	3,840.4	8.6	3,849.0	105,100.0	404.5	0.5	0.2	0.8
11/16/2020 16:00	3,344.0	1.1	3,344.2	105,100.0	351.5	0.4	0.2	0.7
11/16/2020 17:00	3,774.9	0.0	3,774.9	105,100.0	396.7	0.5	0.2	0.8
11/16/2020 18:00	3,760.6	0.0	3,760.6	105,100.0	395.2	0.5	0.2	0.8
11/16/2020 19:00	3,929.8	75.5	3,986.4	105,100.0	419.0	0.5	0.3	0.8
11/16/2020 20:00	3,976.1	63.8	4,039.9	105,100.0	424.6	0.5	0.3	0.8
11/16/2020 21:00	3,948.0	186.3	4,115.7	105,100.0	432.6	0.5	0.3	0.9
11/16/2020 22:00	3,353.8	0.0	3,353.8	105,100.0	352.5	0.4	0.2	0.7
11/16/2020 23:00	2,976.0	0.0	2,976.0	105,100.0	312.8	0.4	0.2	0.6
Average/Sum#:	3,581.3	83.9	3,663.6	105,100.0	385.0	0.5	0.3	0.8
Minimum:	2,787.0	0.0	2,787.0	105,100.0	292.9	0.4	0.2	0.6
Maximum:	4,100.2	418.0	4,297.2	105,100.0	451.6	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/17/2020 00:00	2,877.5	0.0	2,877.5	105,100.0	302.4	0.4	0.2	0.6
11/17/2020 01:00	2,800.3	0.0	2,800.3	105,100.0	294.3	0.4	0.2	0.6
11/17/2020 02:00	2,763.4	0.0	2,763.4	105,100.0	290.4	0.4	0.2	0.6
11/17/2020 03:00	2,768.6	0.0	2,768.6	105,100.0	291.0	0.3	0.2	0.6
11/17/2020 04:00	2,781.8	0.0	2,781.8	105,100.0	292.4	0.4	0.2	0.6
11/17/2020 05:00	3,075.5	0.0	3,075.5	105,100.0	323.2	0.4	0.2	0.6
11/17/2020 06:00	3,319.3	0.0	3,319.3	105,100.0	348.9	0.4	0.2	0.7
11/17/2020 07:00	3,517.1	0.0	3,517.1	105,100.0	369.6	0.4	0.2	0.7
11/17/2020 08:00	3,890.6	19.5	3,899.0	105,100.0	409.8	0.5	0.2	0.8
11/17/2020 09:00	3,947.4	196.3	4,143.7	105,100.0	435.5	0.5	0.3	0.9
11/17/2020 10:00	3,930.0	232.1	4,162.1	105,100.0	437.4	0.5	0.3	0.9
11/17/2020 11:00	3,903.0	278.7	4,181.7	105,100.0	439.5	0.5	0.3	0.9
11/17/2020 12:00	3,900.9	300.8	4,201.7	105,100.0	441.6	0.5	0.3	0.9
11/17/2020 13:00	3,918.5	262.5	4,181.0	105,100.0	439.4	0.5	0.3	0.9
11/17/2020 14:00	3,906.6	4.4	3,911.0	105,100.0	411.0	0.5	0.2	0.8
11/17/2020 15:00	3,756.8	5.3	3,762.1	105,100.0	395.4	0.5	0.2	0.8
11/17/2020 16:00	3,751.5	6.0	3,757.5	105,100.0	394.9	0.5	0.2	0.8
11/17/2020 17:00	3,752.3	7.4	3,759.7	105,100.0	395.1	0.5	0.2	0.8
11/17/2020 18:00	3,767.6	4.8	3,771.1	105,100.0	396.3	0.5	0.2	0.8
11/17/2020 19:00	3,436.7	0.0	3,436.7	105,100.0	361.2	0.4	0.2	0.7
11/17/2020 20:00	3,603.0	0.0	3,603.0	105,100.0	378.7	0.5	0.2	0.8
11/17/2020 21:00	3,454.6	0.0	3,454.6	105,100.0	363.1	0.4	0.2	0.7
11/17/2020 22:00	3,311.6	0.0	3,311.6	105,100.0	348.0	0.4	0.2	0.7
11/17/2020 23:00	2,917.6	0.0	2,917.6	105,100.0	306.6	0.4	0.2	0.6
Average/Sum#:	3,460.5	54.9	3,514.9	105,100.0	369.4	0.4	0.2	0.7
Minimum:	2,763.4	0.0	2,763.4	105,100.0	290.4	0.3	0.2	0.6
Maximum:	3,947.4	300.8	4,201.7	105,100.0	441.6	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/18/2020 00:00	2,853.6	0.0	2,853.6	105,100.0	299.9	0.4	0.2	0.6
11/18/2020 01:00	2,737.6	0.0	2,737.6	105,100.0	287.7	0.3	0.2	0.6
11/18/2020 02:00	2,740.0	0.0	2,740.0	105,100.0	288.0	0.3	0.2	0.6
11/18/2020 03:00	2,740.9	0.0	2,740.9	105,100.0	288.1	0.3	0.2	0.6
11/18/2020 04:00	2,745.1	0.0	2,745.1	105,100.0	288.5	0.3	0.2	0.6
11/18/2020 05:00	2,938.6	0.0	2,938.6	105,100.0	308.8	0.4	0.2	0.6
11/18/2020 06:00	3,310.0	0.0	3,310.0	105,100.0	347.9	0.4	0.2	0.7
11/18/2020 07:00	3,795.6	0.2	3,795.6	105,100.0	398.9	0.5	0.2	0.8
11/18/2020 08:00	3,982.3	166.6	4,148.9	105,100.0	436.0	0.5	0.3	0.9
11/18/2020 09:00	3,967.8	185.9	4,153.7	105,100.0	436.6	0.5	0.3	0.9
11/18/2020 10:00	3,946.6	239.2	4,185.8	105,100.0	439.9	0.5	0.3	0.9
11/18/2020 11:00	3,943.4	259.5	4,202.9	105,100.0	441.7	0.5	0.3	0.9
11/18/2020 12:00	3,930.0	304.6	4,234.6	105,100.0	445.1	0.5	0.3	0.9
11/18/2020 13:00	3,901.7	14.2	3,902.8	105,100.0	410.2	0.5	0.2	0.8
11/18/2020 14:00	3,892.0	0.0	3,892.0	105,100.0	409.0	0.5	0.2	0.8
11/18/2020 15:00	3,893.5	0.0	3,893.5	105,100.0	409.2	0.5	0.2	0.8
11/18/2020 16:00	3,890.4	0.0	3,890.4	105,100.0	408.9	0.5	0.2	0.8
11/18/2020 17:00	3,891.2	0.0	3,891.2	105,100.0	409.0	0.5	0.2	0.8
11/18/2020 18:00	3,839.5	0.0	3,839.5	105,100.0	403.5	0.5	0.2	0.8
11/18/2020 19:00	3,608.9	0.0	3,608.9	105,100.0	379.3	0.5	0.2	0.8
11/18/2020 20:00	3,946.5	3.4	3,949.1	105,100.0	415.1	0.5	0.2	0.8
11/18/2020 21:00	3,443.0	0.0	3,443.0	105,100.0	361.9	0.4	0.2	0.7
11/18/2020 22:00	3,372.1	0.0	3,372.1	105,100.0	354.4	0.4	0.2	0.7
11/18/2020 23:00	3,026.5	0.0	3,026.5	105,100.0	318.1	0.4	0.2	0.6
Average/Sum#:	3,514.0	48.9	3,562.3	105,100.0	374.4	0.4	0.2	0.8
Minimum:	2,737.6	0.0	2,737.6	105,100.0	287.7	0.3	0.2	0.6
Maximum:	3,982.3	304.6	4,234.6	105,100.0	445.1	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/19/2020 00:00	2,868.8	0.0	2,868.8	105,100.0	301.5	0.4	0.2	0.6
11/19/2020 01:00	2,745.5	0.0	2,745.5	105,100.0	288.6	0.3	0.2	0.6
11/19/2020 02:00	2,744.0	0.0	2,744.0	105,100.0	288.4	0.3	0.2	0.6
11/19/2020 03:00	2,743.2	0.0	2,743.2	105,100.0	288.3	0.3	0.2	0.6
11/19/2020 04:00	2,770.1	0.0	2,770.1	105,100.0	291.1	0.4	0.2	0.6
11/19/2020 05:00	3,118.7	0.0	3,118.7	105,100.0	327.8	0.4	0.2	0.7
11/19/2020 06:00	3,494.5	0.0	3,494.5	105,100.0	367.3	0.4	0.2	0.7
11/19/2020 07:00	3,936.8	0.2	3,936.8	105,100.0	413.8	0.5	0.2	0.8
11/19/2020 08:00	4,117.5	0.0	4,117.5	105,100.0	432.7	0.5	0.3	0.9
11/19/2020 09:00	4,074.9	204.6	4,234.5	105,100.0	445.0	0.5	0.3	0.9
11/19/2020 10:00	3,812.1	0.8	3,812.1	105,100.0	400.7	0.5	0.2	0.8
11/19/2020 11:00	3,799.7	0.0	3,799.7	105,100.0	399.3	0.5	0.2	0.8
11/19/2020 12:00	3,803.1	0.0	3,803.1	105,100.0	399.7	0.5	0.2	0.8
11/19/2020 13:00	3,790.3	0.0	3,790.3	105,100.0	398.4	0.5	0.2	0.8
11/19/2020 14:00	3,909.0	0.0	3,909.0	105,100.0	410.8	0.5	0.2	0.8
11/19/2020 15:00	3,792.9	0.0	3,792.9	105,100.0	398.6	0.5	0.2	0.8
11/19/2020 16:00	3,697.4	0.0	3,697.4	105,100.0	388.6	0.5	0.2	0.8
11/19/2020 17:00	3,829.1	0.4	3,829.1	105,100.0	402.4	0.5	0.2	0.8
11/19/2020 18:00	3,910.9	177.6	4,029.9	105,100.0	423.5	0.5	0.3	0.9
11/19/2020 19:00	3,499.8	0.0	3,499.8	105,100.0	367.8	0.4	0.2	0.7
11/19/2020 20:00	3,559.2	0.0	3,559.2	105,100.0	374.1	0.5	0.2	0.8
11/19/2020 21:00	3,615.2	0.0	3,615.2	105,100.0	380.0	0.5	0.2	0.8
11/19/2020 22:00	3,550.1	0.0	3,550.1	105,100.0	373.1	0.4	0.2	0.7
11/19/2020 23:00	3,178.4	0.0	3,178.4	105,100.0	334.0	0.4	0.2	0.7
Average/Sum#:	3,515.1	16.0	3,526.7	105,100.0	370.6	0.4	0.2	0.8
Minimum:	2,743.2	0.0	2,743.2	105,100.0	288.3	0.3	0.2	0.6
Maximum:	4,117.5	204.6	4,234.5	105,100.0	445.0	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/20/2020 00:00	2,897.7	0.0	2,897.7	105,100.0	304.5	0.4	0.2	0.6
11/20/2020 01:00	2,776.0	0.0	2,776.0	105,100.0	291.8	0.4	0.2	0.6
11/20/2020 02:00	2,770.9	0.0	2,770.9	105,100.0	291.2	0.4	0.2	0.6
11/20/2020 03:00	2,778.2	0.0	2,778.2	105,100.0	292.0	0.4	0.2	0.6
11/20/2020 04:00	2,979.9	0.0	2,979.9	105,100.0	313.2	0.4	0.2	0.6
11/20/2020 05:00	3,349.7	0.0	3,349.7	105,100.0	352.1	0.4	0.2	0.7
11/20/2020 06:00	4,127.4	2.7	4,128.8	105,100.0	433.9	0.5	0.3	0.9
11/20/2020 07:00	4,148.2	4.2	4,151.6	105,100.0	436.3	0.5	0.3	0.9
11/20/2020 08:00	4,135.6	5.0	4,140.6	105,100.0	435.2	0.5	0.3	0.9
11/20/2020 09:00	4,124.8	710.7	4,835.5	105,100.0	508.2	0.6	0.3	1.0
11/20/2020 10:00	4,088.4	557.7	4,646.1	105,100.0	488.3	0.6	0.3	1.0
11/20/2020 11:00	4,053.0	252.7	4,305.7	105,100.0	452.5	0.5	0.3	0.9
11/20/2020 12:00	3,841.8	1.6	3,842.0	105,100.0	403.8	0.5	0.2	0.8
11/20/2020 13:00	3,724.5	0.0	3,724.5	105,100.0	391.4	0.5	0.2	0.8
11/20/2020 14:00	3,669.4	0.0	3,669.4	105,100.0	385.7	0.5	0.2	0.8
11/20/2020 15:00	3,705.6	0.0	3,705.6	105,100.0	389.5	0.5	0.2	0.8
11/20/2020 16:00	3,761.4	0.0	3,761.4	105,100.0	395.3	0.5	0.2	0.8
11/20/2020 17:00	3,992.0	122.5	4,092.5	105,100.0	430.1	0.5	0.3	0.9
11/20/2020 18:00	3,898.5	1.8	3,898.9	105,100.0	409.8	0.5	0.2	0.8
11/20/2020 19:00	3,853.5	8.6	3,861.8	105,100.0	405.9	0.5	0.2	0.8
11/20/2020 20:00	3,959.1	2.7	3,960.0	105,100.0	416.2	0.5	0.2	0.8
11/20/2020 21:00	4,005.7	3.8	4,007.1	105,100.0	421.1	0.5	0.3	0.8
11/20/2020 22:00	3,745.6	0.0	3,745.6	105,100.0	393.7	0.5	0.2	0.8
11/20/2020 23:00	3,513.5	0.0	3,513.5	105,100.0	369.3	0.4	0.2	0.7
Average/Sum#:	3,662.5	69.8	3,731.0	105,100.0	392.1	0.5	0.2	0.8
Minimum:	2,770.9	0.0	2,770.9	105,100.0	291.2	0.4	0.2	0.6
Maximum:	4,148.2	710.7	4,835.5	105,100.0	508.2	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/21/2020 00:00	3,654.0	0.0	3,654.0	105,100.0	384.0	0.5	0.2	0.8
11/21/2020 01:00	3,462.5	0.0	3,462.5	105,100.0	363.9	0.4	0.2	0.7
11/21/2020 02:00	3,307.4	0.0	3,307.4	105,100.0	347.6	0.4	0.2	0.7
11/21/2020 03:00	3,250.2	0.0	3,250.2	105,100.0	341.6	0.4	0.2	0.7
11/21/2020 04:00	3,451.9	0.0	3,451.9	105,100.0	362.8	0.4	0.2	0.7
11/21/2020 05:00	3,191.5	0.0	3,191.5	105,100.0	335.4	0.4	0.2	0.7
11/21/2020 06:00	3,184.5	0.0	3,184.5	105,100.0	334.7	0.4	0.2	0.7
11/21/2020 07:00	3,723.0	0.0	3,723.0	105,100.0	391.3	0.5	0.2	0.8
11/21/2020 08:00	3,845.7	0.0	3,845.7	105,100.0	404.2	0.5	0.2	0.8
11/21/2020 09:00	3,962.5	0.0	3,962.5	105,100.0	416.5	0.5	0.2	0.8
11/21/2020 10:00	3,931.8	0.0	3,931.8	105,100.0	413.2	0.5	0.2	0.8
11/21/2020 11:00	3,773.1	0.0	3,773.1	105,100.0	396.6	0.5	0.2	0.8
11/21/2020 12:00	3,690.9	0.0	3,690.9	105,100.0	387.9	0.5	0.2	0.8
11/21/2020 13:00	3,672.2	0.0	3,672.2	105,100.0	385.9	0.5	0.2	0.8
11/21/2020 14:00	3,773.5	0.0	3,773.5	105,100.0	396.6	0.5	0.2	0.8
11/21/2020 15:00	3,778.2	0.0	3,778.2	105,100.0	397.1	0.5	0.2	0.8
11/21/2020 16:00	3,767.1	0.0	3,767.1	105,100.0	395.9	0.5	0.2	0.8
11/21/2020 17:00	3,673.5	0.0	3,673.5	105,100.0	386.1	0.5	0.2	0.8
11/21/2020 18:00	3,855.3	0.0	3,855.3	105,100.0	405.2	0.5	0.2	0.8
11/21/2020 19:00	4,022.5	0.0	4,022.5	105,100.0	422.8	0.5	0.3	0.8
11/21/2020 20:00	4,030.1	0.1	4,030.1	105,100.0	423.6	0.5	0.3	0.8
11/21/2020 21:00	4,001.7	30.4	4,023.6	105,100.0	422.9	0.5	0.3	0.8
11/21/2020 22:00	4,060.9	295.3	4,332.6	105,100.0	455.4	0.5	0.3	0.9
11/21/2020 23:00	3,809.0	0.0	3,809.0	105,100.0	400.3	0.5	0.2	0.8
Average/Sum#:	3,703.0	13.6	3,715.3	105,100.0	390.5	0.5	0.2	0.8
Minimum:	3,184.5	0.0	3,184.5	105,100.0	334.7	0.4	0.2	0.7
Maximum:	4,060.9	295.3	4,332.6	105,100.0	455.4	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/22/2020 00:00	3,007.6	0.0	3,007.6	105,100.0	316.1	0.4	0.2	0.6
11/22/2020 01:00	2,924.3	0.0	2,924.3	105,100.0	307.3	0.4	0.2	0.6
11/22/2020 02:00	2,917.4	0.0	2,917.4	105,100.0	306.6	0.4	0.2	0.6
11/22/2020 03:00	2,918.1	0.0	2,918.1	105,100.0	306.7	0.4	0.2	0.6
11/22/2020 04:00	2,919.4	0.0	2,919.4	105,100.0	306.8	0.4	0.2	0.6
11/22/2020 05:00	2,954.8	0.0	2,954.8	105,100.0	310.5	0.4	0.2	0.6
11/22/2020 06:00	3,227.4	0.0	3,227.4	105,100.0	339.2	0.4	0.2	0.7
11/22/2020 07:00	3,735.4	0.0	3,735.4	105,100.0	392.6	0.5	0.2	0.8
11/22/2020 08:00	4,037.0	2.4	4,037.7	105,100.0	424.4	0.5	0.3	0.8
11/22/2020 09:00	4,076.6	275.9	4,302.8	105,100.0	452.2	0.5	0.3	0.9
11/22/2020 10:00	4,050.7	408.4	4,459.1	105,100.0	468.7	0.6	0.3	0.9
11/22/2020 11:00	4,001.3	6.2	4,007.5	105,100.0	421.2	0.5	0.3	0.8
11/22/2020 12:00	3,955.9	31.6	3,987.5	105,100.0	419.1	0.5	0.3	0.8
11/22/2020 13:00	3,927.1	134.9	4,062.0	105,100.0	426.9	0.5	0.3	0.9
11/22/2020 14:00	3,854.1	6.8	3,856.7	105,100.0	405.3	0.5	0.2	0.8
11/22/2020 15:00	3,908.0	509.5	4,417.5	105,100.0	464.3	0.6	0.3	0.9
11/22/2020 16:00	3,932.0	1,150.7	5,082.7	105,100.0	534.2	0.6	0.3	1.1
11/22/2020 17:00	3,960.3	741.6	4,701.9	105,100.0	494.2	0.6	0.3	1.0
11/22/2020 18:00	3,972.2	684.9	4,657.1	105,100.0	489.5	0.6	0.3	1.0
11/22/2020 19:00	3,993.9	150.2	4,144.1	105,100.0	435.5	0.5	0.3	0.9
11/22/2020 20:00	4,000.5	186.6	4,187.1	105,100.0	440.1	0.5	0.3	0.9
11/22/2020 21:00	3,995.5	174.8	4,170.3	105,100.0	438.3	0.5	0.3	0.9
11/22/2020 22:00	3,607.8	0.6	3,607.9	105,100.0	379.2	0.5	0.2	0.8
11/22/2020 23:00	3,122.1	0.0	3,122.1	105,100.0	328.1	0.4	0.2	0.7
Average/Sum#:	3,625.0	186.0	3,808.7	105,100.0	400.3	0.5	0.3	0.8
Minimum:	2,917.4	0.0	2,917.4	105,100.0	306.6	0.4	0.2	0.6
Maximum:	4,076.6	1,150.7	5,082.7	105,100.0	534.2	0.6	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/23/2020 00:00	2,869.6	0.0	2,869.6	105,100.0	301.6	0.4	0.2	0.6
11/23/2020 01:00	2,870.7	0.0	2,870.7	105,100.0	301.7	0.4	0.2	0.6
11/23/2020 02:00	2,873.1	0.0	2,873.1	105,100.0	302.0	0.4	0.2	0.6
11/23/2020 03:00	2,869.5	0.0	2,869.5	105,100.0	301.6	0.4	0.2	0.6
11/23/2020 04:00	2,877.4	0.0	2,877.4	105,100.0	302.4	0.4	0.2	0.6
11/23/2020 05:00	3,252.3	0.0	3,252.3	105,100.0	341.8	0.4	0.2	0.7
11/23/2020 06:00	3,769.1	0.0	3,769.1	105,100.0	396.1	0.5	0.2	0.8
11/23/2020 07:00	3,793.3	0.0	3,793.3	105,100.0	398.7	0.5	0.2	0.8
11/23/2020 08:00	3,968.6	1.1	3,968.9	105,100.0	417.1	0.5	0.3	0.8
11/23/2020 09:00	3,982.7	1.2	3,982.9	105,100.0	418.6	0.5	0.3	0.8
11/23/2020 10:00	3,944.5	3.3	3,945.9	105,100.0	414.7	0.5	0.2	0.8
11/23/2020 11:00	3,957.1	5.6	3,962.1	105,100.0	416.4	0.5	0.2	0.8
11/23/2020 12:00	3,918.2	5.3	3,922.0	105,100.0	412.2	0.5	0.2	0.8
11/23/2020 13:00	3,882.1	4.6	3,885.6	105,100.0	408.4	0.5	0.2	0.8
11/23/2020 14:00	3,854.5	2.5	3,855.4	105,100.0	405.2	0.5	0.2	0.8
11/23/2020 15:00	3,878.2	65.7	3,938.6	105,100.0	413.9	0.5	0.2	0.8
11/23/2020 16:00	3,905.0	249.2	4,154.2	105,100.0	436.6	0.5	0.3	0.9
11/23/2020 17:00	3,784.9	9.0	3,791.0	105,100.0	398.4	0.5	0.2	0.8
11/23/2020 18:00	3,934.1	5.9	3,938.6	105,100.0	413.9	0.5	0.2	0.8
11/23/2020 19:00	3,755.6	0.7	3,755.7	105,100.0	394.7	0.5	0.2	0.8
11/23/2020 20:00	3,726.1	0.0	3,726.1	105,100.0	391.6	0.5	0.2	0.8
11/23/2020 21:00	3,718.0	0.0	3,718.0	105,100.0	390.8	0.5	0.2	0.8
11/23/2020 22:00	3,617.2	0.0	3,617.2	105,100.0	380.2	0.5	0.2	0.8
11/23/2020 23:00	3,246.7	0.0	3,246.7	105,100.0	341.2	0.4	0.2	0.7
Average/Sum#:	3,593.7	14.8	3,607.7	105,100.0	379.2	0.5	0.2	0.8
Minimum:	2,869.5	0.0	2,869.5	105,100.0	301.6	0.4	0.2	0.6
Maximum:	3,982.7	249.2	4,154.2	105,100.0	436.6	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/24/2020 00:00	2,861.8	0.0	2,861.8	105,100.0	300.8	0.4	0.2	0.6
11/24/2020 01:00	2,855.6	0.0	2,855.6	105,100.0	300.1	0.4	0.2	0.6
11/24/2020 02:00	2,866.5	0.0	2,866.5	105,100.0	301.3	0.4	0.2	0.6
11/24/2020 03:00	2,861.4	0.0	2,861.4	105,100.0	300.7	0.4	0.2	0.6
11/24/2020 04:00	2,877.6	0.0	2,877.6	105,100.0	302.4	0.4	0.2	0.6
11/24/2020 05:00	3,271.3	0.0	3,271.3	105,100.0	343.8	0.4	0.2	0.7
11/24/2020 06:00	4,044.7	1.4	4,045.0	105,100.0	425.1	0.5	0.3	0.8
11/24/2020 07:00	4,021.1	0.0	4,021.1	105,100.0	422.6	0.5	0.3	0.8
11/24/2020 08:00	4,056.5	3.5	4,059.2	105,100.0	426.6	0.5	0.3	0.9
11/24/2020 09:00	3,996.3	2.6	3,997.0	105,100.0	420.1	0.5	0.3	0.8
11/24/2020 10:00	3,933.1	1.1	3,933.3	105,100.0	413.4	0.5	0.2	0.8
11/24/2020 11:00	3,839.9	12.5	3,852.4	105,100.0	404.9	0.5	0.2	0.8
11/24/2020 12:00	3,927.4	113.6	4,004.6	105,100.0	420.9	0.5	0.3	0.8
11/24/2020 13:00	3,889.6	2.3	3,890.3	105,100.0	408.9	0.5	0.2	0.8
11/24/2020 14:00	3,860.1	1.7	3,860.7	105,100.0	405.8	0.5	0.2	0.8
11/24/2020 15:00	3,807.4	6.7	3,813.8	105,100.0	400.8	0.5	0.2	0.8
11/24/2020 16:00	3,866.7	6.5	3,873.2	105,100.0	407.1	0.5	0.2	0.8
11/24/2020 17:00	3,901.2	7.2	3,908.4	105,100.0	410.8	0.5	0.2	0.8
11/24/2020 18:00	3,787.1	0.1	3,787.1	105,100.0	398.0	0.5	0.2	0.8
11/24/2020 19:00	3,683.7	0.0	3,683.7	105,100.0	387.2	0.5	0.2	0.8
11/24/2020 20:00	3,985.2	0.0	3,985.2	105,100.0	418.8	0.5	0.3	0.8
11/24/2020 21:00	3,939.8	0.0	3,939.8	105,100.0	414.1	0.5	0.2	0.8
11/24/2020 22:00	3,745.9	0.0	3,745.9	105,100.0	393.7	0.5	0.2	0.8
11/24/2020 23:00	3,249.4	0.0	3,249.4	105,100.0	341.5	0.4	0.2	0.7
Average/Sum#:	3,630.4	6.6	3,635.2	105,100.0	382.1	0.5	0.2	0.8
Minimum:	2,855.6	0.0	2,855.6	105,100.0	300.1	0.4	0.2	0.6
Maximum:	4,056.5	113.6	4,059.2	105,100.0	426.6	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/25/2020 00:00	3,090.8	0.0	3,090.8	105,100.0	324.8	0.4	0.2	0.7
11/25/2020 01:00	2,877.3	0.0	2,877.3	105,100.0	302.4	0.4	0.2	0.6
11/25/2020 02:00	2,884.4	0.0	2,884.4	105,100.0	303.2	0.4	0.2	0.6
11/25/2020 03:00	3,131.9	0.0	3,131.9	105,100.0	329.2	0.4	0.2	0.7
11/25/2020 04:00	3,152.4	0.0	3,152.4	105,100.0	331.3	0.4	0.2	0.7
11/25/2020 05:00	3,361.7	0.0	3,361.7	105,100.0	353.3	0.4	0.2	0.7
11/25/2020 06:00	4,008.1	1.4	4,008.4	105,100.0	421.3	0.5	0.3	0.8
11/25/2020 07:00	3,770.7	0.0	3,770.7	105,100.0	396.3	0.5	0.2	0.8
11/25/2020 08:00	3,842.1	0.0	3,842.1	105,100.0	403.8	0.5	0.2	0.8
11/25/2020 09:00	3,963.3	0.0	3,963.3	105,100.0	416.5	0.5	0.2	0.8
11/25/2020 10:00	4,075.2	0.0	4,075.2	105,100.0	428.3	0.5	0.3	0.9
11/25/2020 11:00	4,040.6	0.0	4,040.6	105,100.0	424.7	0.5	0.3	0.8
11/25/2020 12:00	3,984.9	0.0	3,984.9	105,100.0	418.8	0.5	0.3	0.8
11/25/2020 13:00	3,568.4	0.0	3,568.4	105,100.0	375.0	0.5	0.2	0.8
11/25/2020 14:00	3,683.0	0.0	3,683.0	105,100.0	387.1	0.5	0.2	0.8
11/25/2020 15:00	3,927.8	0.0	3,927.8	105,100.0	412.8	0.5	0.2	0.8
11/25/2020 16:00	3,874.4	0.0	3,874.4	105,100.0	407.2	0.5	0.2	0.8
11/25/2020 17:00	3,683.5	0.0	3,683.5	105,100.0	387.1	0.5	0.2	0.8
11/25/2020 18:00	3,794.2	0.0	3,794.2	105,100.0	398.8	0.5	0.2	0.8
11/25/2020 19:00	3,798.5	0.0	3,798.5	105,100.0	399.2	0.5	0.2	0.8
11/25/2020 20:00	3,799.2	0.0	3,799.2	105,100.0	399.3	0.5	0.2	0.8
11/25/2020 21:00	3,946.8	3.4	3,948.4	105,100.0	415.0	0.5	0.2	0.8
11/25/2020 22:00	3,833.9	0.0	3,833.9	105,100.0	402.9	0.5	0.2	0.8
11/25/2020 23:00	3,199.4	0.0	3,199.4	105,100.0	336.3	0.4	0.2	0.7
Average/Sum#:	3,637.2	0.2	3,637.3	105,100.0	382.3	0.5	0.2	0.8
Minimum:	2,877.3	0.0	2,877.3	105,100.0	302.4	0.4	0.2	0.6
Maximum:	4,075.2	3.4	4,075.2	105,100.0	428.3	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/26/2020 00:00	1,074.4	0.0	1,074.4	105,100.0	112.9	0.0	0.0	0.0
11/26/2020 01:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/26/2020 02:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/26/2020 03:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/26/2020 04:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/26/2020 05:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/26/2020 06:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/26/2020 07:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/26/2020 08:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/26/2020 09:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/26/2020 10:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/26/2020 11:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/26/2020 12:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/26/2020 13:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/26/2020 14:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/26/2020 15:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/26/2020 16:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/26/2020 17:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/26/2020 18:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/26/2020 19:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/26/2020 20:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/26/2020 21:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/26/2020 22:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/26/2020 23:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
Average/Sum#:	1,074.4	0.0	1,074.4	105,100.0	112.9	0.0	0.0	0.0
Minimum:	1,074.4	0.0	1,074.4	105,100.0	112.9	0.0	0.0	0.0
Maximum:	1,074.4	0.0	1,074.4	105,100.0	112.9	0.0	0.0	0.0
%SI	95.83	95.83	95.83	0.00	95.83	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/27/2020 00:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/27/2020 01:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/27/2020 02:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/27/2020 03:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/27/2020 04:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/27/2020 05:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/27/2020 06:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/27/2020 07:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/27/2020 08:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/27/2020 09:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/27/2020 10:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/27/2020 11:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/27/2020 12:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/27/2020 13:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/27/2020 14:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/27/2020 15:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/27/2020 16:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/27/2020 17:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/27/2020 18:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/27/2020 19:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/27/2020 20:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/27/2020 21:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/27/2020 22:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/27/2020 23:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/28/2020 00:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/28/2020 01:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/28/2020 02:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/28/2020 03:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/28/2020 04:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/28/2020 05:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/28/2020 06:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/28/2020 07:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/28/2020 08:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/28/2020 09:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/28/2020 10:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/28/2020 11:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/28/2020 12:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/28/2020 13:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/28/2020 14:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/28/2020 15:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/28/2020 16:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/28/2020 17:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/28/2020 18:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/28/2020 19:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/28/2020 20:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/28/2020 21:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/28/2020 22:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/28/2020 23:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/29/2020 00:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/29/2020 01:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/29/2020 02:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/29/2020 03:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/29/2020 04:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/29/2020 05:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/29/2020 06:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/29/2020 07:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/29/2020 08:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/29/2020 09:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/29/2020 10:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/29/2020 11:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/29/2020 12:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/29/2020 13:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/29/2020 14:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/29/2020 15:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/29/2020 16:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/29/2020 17:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/29/2020 18:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/29/2020 19:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/29/2020 20:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/29/2020 21:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/29/2020 22:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/29/2020 23:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/30/2020 00:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/30/2020 01:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/30/2020 02:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/30/2020 03:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/30/2020 04:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/30/2020 05:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/30/2020 06:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/30/2020 07:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/30/2020 08:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/30/2020 09:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/30/2020 10:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/30/2020 11:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/30/2020 12:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/30/2020 13:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/30/2020 14:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/30/2020 15:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/30/2020 16:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/30/2020 17:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/30/2020 18:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/30/2020 19:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/30/2020 20:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/30/2020 21:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/30/2020 22:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
11/30/2020 23:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/01/2020 00:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/01/2020 01:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/01/2020 02:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/01/2020 03:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/01/2020 04:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/01/2020 05:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/01/2020 06:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/01/2020 07:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/01/2020 08:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/01/2020 09:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/01/2020 10:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/01/2020 11:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/01/2020 12:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/01/2020 13:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/01/2020 14:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/01/2020 15:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/01/2020 16:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/01/2020 17:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/01/2020 18:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/01/2020 19:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/01/2020 20:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/01/2020 21:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/01/2020 22:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/01/2020 23:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/02/2020 00:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/02/2020 01:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/02/2020 02:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/02/2020 03:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/02/2020 04:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/02/2020 05:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/02/2020 06:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/02/2020 07:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/02/2020 08:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/02/2020 09:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/02/2020 10:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/02/2020 11:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/02/2020 12:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/02/2020 13:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/02/2020 14:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/02/2020 15:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/02/2020 16:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/02/2020 17:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/02/2020 18:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/02/2020 19:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/02/2020 20:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/02/2020 21:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/02/2020 22:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/02/2020 23:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/03/2020 00:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/03/2020 01:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/03/2020 02:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/03/2020 03:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/03/2020 04:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/03/2020 05:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/03/2020 06:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/03/2020 07:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/03/2020 08:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/03/2020 09:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/03/2020 10:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/03/2020 11:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/03/2020 12:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/03/2020 13:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/03/2020 14:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/03/2020 15:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/03/2020 16:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/03/2020 17:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/03/2020 18:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/03/2020 19:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/03/2020 20:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/03/2020 21:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/03/2020 22:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/03/2020 23:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/04/2020 00:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/04/2020 01:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/04/2020 02:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/04/2020 03:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/04/2020 04:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/04/2020 05:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/04/2020 06:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/04/2020 07:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/04/2020 08:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/04/2020 09:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/04/2020 10:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/04/2020 11:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/04/2020 12:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/04/2020 13:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/04/2020 14:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/04/2020 15:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/04/2020 16:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/04/2020 17:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/04/2020 18:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/04/2020 19:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/04/2020 20:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/04/2020 21:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/04/2020 22:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/04/2020 23:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/05/2020 00:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/05/2020 01:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/05/2020 02:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/05/2020 03:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/05/2020 04:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/05/2020 05:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/05/2020 06:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/05/2020 07:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/05/2020 08:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/05/2020 09:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/05/2020 10:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/05/2020 11:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/05/2020 12:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/05/2020 13:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/05/2020 14:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/05/2020 15:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/05/2020 16:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/05/2020 17:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/05/2020 18:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/05/2020 19:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/05/2020 20:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/05/2020 21:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/05/2020 22:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/05/2020 23:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/06/2020 00:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/06/2020 01:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/06/2020 02:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/06/2020 03:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/06/2020 04:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/06/2020 05:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/06/2020 06:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/06/2020 07:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/06/2020 08:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/06/2020 09:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/06/2020 10:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/06/2020 11:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/06/2020 12:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/06/2020 13:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/06/2020 14:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/06/2020 15:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/06/2020 16:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/06/2020 17:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/06/2020 18:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/06/2020 19:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/06/2020 20:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/06/2020 21:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/06/2020 22:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/06/2020 23:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/07/2020 00:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/07/2020 01:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/07/2020 02:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/07/2020 03:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/07/2020 04:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/07/2020 05:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/07/2020 06:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/07/2020 07:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/07/2020 08:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/07/2020 09:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/07/2020 10:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/07/2020 11:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/07/2020 12:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/07/2020 13:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/07/2020 14:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/07/2020 15:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/07/2020 16:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/07/2020 17:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/07/2020 18:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/07/2020 19:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/07/2020 20:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/07/2020 21:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/07/2020 22:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/07/2020 23:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/08/2020 00:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/08/2020 01:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/08/2020 02:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/08/2020 03:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/08/2020 04:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/08/2020 05:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/08/2020 06:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/08/2020 07:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/08/2020 08:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/08/2020 09:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/08/2020 10:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/08/2020 11:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/08/2020 12:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/08/2020 13:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/08/2020 14:00	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
12/08/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/08/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/08/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/08/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/08/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/08/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/08/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/08/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/08/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,987.5	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,100.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/09/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/09/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/09/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/09/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/09/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/09/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/09/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/09/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/09/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/09/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/09/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/09/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/09/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/09/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/09/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/09/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/09/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/09/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/09/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/09/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/09/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/09/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/09/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/09/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/10/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/10/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/10/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/10/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/10/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/10/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/10/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/10/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/10/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/10/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/10/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/10/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/10/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/10/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/10/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/10/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/10/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/10/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/10/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/10/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/10/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/10/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/10/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/10/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/11/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/11/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/11/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/11/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/11/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/11/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/11/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/11/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/11/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/11/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/11/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/11/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/11/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/11/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/11/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/11/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/11/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/11/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/11/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/11/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/11/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/11/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/11/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/11/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/12/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/12/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/12/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/12/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/12/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/12/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/12/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/12/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/12/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/12/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/12/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/12/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/12/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/12/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/12/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/12/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/12/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/12/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/12/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/12/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/12/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/12/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/12/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/12/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/13/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/13/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/13/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/13/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/13/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/13/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/13/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/13/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/13/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/13/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/13/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/13/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/13/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/13/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/13/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/13/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/13/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/13/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/13/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/13/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/13/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/13/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/13/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/13/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/14/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/14/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/14/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/14/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/14/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/14/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/14/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/14/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/14/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/14/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/14/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/14/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/14/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/14/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/14/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/14/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/14/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/14/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/14/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/14/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/14/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/14/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/14/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/14/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/15/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/15/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/15/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/15/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/15/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/15/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/15/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/15/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/15/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/15/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/15/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/15/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/15/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/15/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/15/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/15/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/15/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/15/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/15/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/15/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/15/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/15/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/15/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/15/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/16/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/16/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/16/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/16/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/16/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/16/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/16/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/16/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/16/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/16/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/16/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/16/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/16/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/16/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/16/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/16/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/16/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/16/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/16/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/16/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/16/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/16/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/16/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/16/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/17/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/17/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/17/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/17/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/17/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/17/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/17/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/17/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/17/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/17/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/17/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/17/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/17/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/17/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/17/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/17/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/17/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/17/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/17/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/17/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/17/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/17/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/17/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/17/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/18/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/18/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/18/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/18/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/18/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/18/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/18/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/18/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/18/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/18/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/18/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/18/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/18/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/18/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/18/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/18/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/18/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/18/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/18/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/18/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/18/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/18/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/18/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/18/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/19/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/19/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/19/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/19/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/19/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/19/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/19/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/19/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/19/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/19/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/19/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/19/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/19/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/19/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/19/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/19/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/19/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/19/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/19/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/19/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/19/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/19/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/19/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/19/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/20/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/20/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/20/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/20/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/20/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/20/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/20/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/20/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/20/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/20/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/20/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/20/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/20/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/20/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/20/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/20/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/20/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/20/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/20/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/20/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/20/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/20/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/20/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/20/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/21/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/21/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/21/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/21/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/21/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/21/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/21/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/21/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/21/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/21/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/21/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/21/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/21/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/21/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/21/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/21/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/21/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/21/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/21/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/21/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/21/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/21/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/21/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/21/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/22/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/22/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/22/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/22/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/22/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/22/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/22/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/22/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/22/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/22/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/22/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/22/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/22/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/22/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/22/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/22/2020 15:00	1,569.7	0.0	1,569.7	104,800.0	164.5	0.0	0.0	0.0
12/22/2020 16:00	4,067.5	0.0	4,067.5	104,800.0	426.3	0.5	0.3	0.9
12/22/2020 17:00	3,622.1	0.0	3,622.1	104,800.0	379.6	0.5	0.2	0.8
12/22/2020 18:00	2,474.0	0.0	2,474.0	104,800.0	259.3	0.3	0.2	0.6
12/22/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/22/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/22/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/22/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/22/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Average/Sum#:	2,933.3	0.0	2,933.3	104,800.0	307.4	0.4	0.2	0.8
Minimum:	1,569.7	0.0	1,569.7	104,800.0	164.5	0.3	0.2	0.6
Maximum:	4,067.5	0.0	4,067.5	104,800.0	426.3	0.5	0.3	0.9
%SI	83.33	83.33	83.33	0.00	83.33	87.50	87.50	87.50

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/23/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/23/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/23/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/23/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/23/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/23/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/23/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/23/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/23/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/23/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/23/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/23/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/23/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/23/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/23/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/23/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/23/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/23/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/23/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/23/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/23/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/23/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/23/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/23/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/24/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/24/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/24/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/24/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/24/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/24/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/24/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/24/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/24/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/24/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/24/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/24/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/24/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/24/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/24/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/24/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/24/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/24/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/24/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/24/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/24/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/24/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/24/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/24/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/25/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/25/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/25/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/25/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/25/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/25/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/25/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/25/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/25/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/25/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/25/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/25/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/25/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/25/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/25/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/25/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/25/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/25/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/25/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/25/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/25/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/25/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/25/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/25/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/26/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/26/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/26/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/26/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/26/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/26/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/26/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/26/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/26/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/26/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/26/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/26/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/26/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/26/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/26/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/26/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/26/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/26/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/26/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/26/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/26/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/26/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/26/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/26/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/27/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/27/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/27/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/27/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/27/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/27/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/27/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/27/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/27/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/27/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/27/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/27/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/27/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/27/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/27/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/27/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/27/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/27/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/27/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/27/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/27/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/27/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/27/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/27/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/28/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/28/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/28/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/28/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/28/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/28/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/28/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/28/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/28/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/28/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/28/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/28/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/28/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/28/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/28/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/28/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/28/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/28/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/28/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/28/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/28/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/28/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/28/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/28/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/29/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/29/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/29/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/29/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/29/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/29/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/29/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/29/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/29/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/29/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/29/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/29/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/29/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/29/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/29/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/29/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/29/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/29/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/29/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/29/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/29/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/29/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/29/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/29/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/30/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/30/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/30/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/30/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/30/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/30/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/30/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/30/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/30/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/30/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/30/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/30/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/30/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/30/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/30/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/30/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/30/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/30/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/30/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/30/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/30/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/30/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/30/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/30/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:32 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/31/2020 00:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/31/2020 01:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/31/2020 02:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/31/2020 03:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/31/2020 04:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/31/2020 05:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/31/2020 06:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/31/2020 07:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/31/2020 08:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/31/2020 09:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/31/2020 10:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/31/2020 11:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/31/2020 12:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/31/2020 13:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/31/2020 14:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/31/2020 15:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/31/2020 16:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/31/2020 17:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/31/2020 18:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/31/2020 19:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/31/2020 20:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/31/2020 21:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/31/2020 22:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
12/31/2020 23:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Linearity Report

01/05/2021

Page 1

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY	ReasonForTest:	QA
EDR Site ID:	CT001	Component ID:	A15	Grace Period:	0
		Component Type:	NOXA	Scale:	High
Instrument Name:	CT1_NOXDualRg_P_Instrume	Test End Date/Time:	10/01/2020	Highest Error:	3.1
Performance Spec:	5 %	Test No.:	104		
		Status (Pass/Fail):	Passed		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
10/01/2020	0826	L	200.0	47.6	48.5		23.8 %
10/01/2020	0831	M	200.0	105.0	108.3		52.5 %
10/01/2020	0837	H	200.0	180.0	180.0		90.0 %
10/01/2020	0844	L	200.0	47.6	49.2		23.8 %
10/01/2020	0849	M	200.0	105.0	108.3		52.5 %
10/01/2020	0854	H	200.0	180.0	180.0		90.0 %
10/01/2020	0901	L	200.0	47.6	49.1		23.8 %
10/01/2020	0906	M	200.0	105.0	108.1		52.5 %
10/01/2020	0911	H	200.0	180.0	179.6		90.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	47.600	48.933	No	2.8
M	105.000	108.233	No	3.1
H	180.000	179.867	No	0.1

Linearity Report

01/05/2021

Page 2

ORIS Code: 56298

EDR Site ID: CT001

Facility Name: ROSEVILLE ENERGY

Component ID: A16

Component Type: O2D

ReasonForTest: QA

Grace Period: 0

Instrument Name: CT1_O2D_P_Instrument

Performance Spec: 5 %

Test End Date/Time: 10/01/2020

Test No.: 105

Status (Pass/Fail): **Passed**

Scale: High

Highest Error: 3.6

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
10/01/2020	1234	L	21.0	5.5	5.3		26.2 %
10/01/2020	1238	M	21.0	11.1	10.9		52.9 %
10/01/2020	1244	H	21.0	18.0	18.0		85.7 %
10/01/2020	1251	L	21.0	5.5	5.3		26.2 %
10/01/2020	1256	M	21.0	11.1	10.9		52.9 %
10/01/2020	1301	H	21.0	18.0	18.0		85.7 %
10/01/2020	1308	L	21.0	5.5	5.3		26.2 %
10/01/2020	1313	M	21.0	11.1	10.9		52.9 %
10/01/2020	1318	H	21.0	18.0	18.0		85.7 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.500	5.300	No	3.6
M	11.100	10.900	No	1.8
H	18.000	18.000	No	0.0

Linearity Report

01/05/2021

Page 3

ORIS Code: 56298

EDR Site ID: CT002

Facility Name: ROSEVILLE ENERGY

Component ID: A21

Component Type: NOXA

ReasonForTest: QA

Grace Period: 0

Instrument Name: CT2_NOXDualRg_P_Instrume Test End Date/Time: 10/01/2020

Scale: High

Performance Spec: 5 %

Test No.: 104

Highest Error: 2.6

Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
10/01/2020	1138	L	200.0	48.2	48.8		24.1 %
10/01/2020	1143	M	200.0	106.0	108.5		53.0 %
10/01/2020	1148	H	200.0	180.0	180.3		90.0 %
10/01/2020	1155	L	200.0	48.2	49.3		24.1 %
10/01/2020	1200	M	200.0	106.0	108.9		53.0 %
10/01/2020	1205	H	200.0	180.0	180.3		90.0 %
10/01/2020	1212	L	200.0	48.2	49.3		24.1 %
10/01/2020	1217	M	200.0	106.0	108.9		53.0 %
10/01/2020	1222	H	200.0	180.0	180.2		90.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	48.200	49.133	No	1.9
M	106.000	108.767	No	2.6
H	180.000	180.267	No	0.1

Linearity Report

01/05/2021

Page 4

ORIS Code: 56298

EDR Site ID: CT002

Facility Name: ROSEVILLE ENERGY

Component ID: A22

Component Type: O2D

ReasonForTest: QA

Grace Period: 0

Instrument Name: CT2_O2D_P_Instrument

Performance Spec: 5 %

Test End Date/Time: 10/02/2020

Test No.: 105

Status (Pass/Fail): **Passed**

Scale: High

Highest Error: 0.9

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
10/02/2020	0942	L	21.0	5.5	5.6		26.2 %
10/02/2020	0948	M	21.0	11.2	11.3		53.3 %
10/02/2020	0953	H	21.0	18.1	18.1		86.2 %
10/02/2020	1000	L	21.0	5.5	5.5		26.2 %
10/02/2020	1005	M	21.0	11.2	11.3		53.3 %
10/02/2020	1010	H	21.0	18.1	18.1		86.2 %
10/02/2020	1017	L	21.0	5.5	5.5		26.2 %
10/02/2020	1022	M	21.0	11.2	11.3		53.3 %
10/02/2020	1027	H	21.0	18.1	18.1		86.2 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.500	5.533	No	0.6
M	11.200	11.300	No	0.9
H	18.100	18.100	No	0.0

Roseville Energy Park Revision History

RegPerfect® by Teledyne Monitor Labs, Inc.

Teledyne Monitor Labs, Inc.

35 Inverness Drive East

Englewood, CO 80112-5189

Telephone: (800) 846-6062

<http://www.teledyne-ml.com/>

<http://www.regperfect.com/>

©1998-2005 Teledyne Monitor Labs, Inc. All rights reserved.

RegPerfect® is a registered trademark of Teledyne Monitor Labs, Inc.

NOTE: This server's C drive is only 20 GB in size!! Do not place large files on this drive.

10/28/20 Taylor Sullivan

Q3 EDR

CO Ppmvdc EDS/CMS Summary Report

CT1



From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/05/2021 16:38 **Location:** Roseville, CA
Description: Electric Utility

CMS Data from: CT1_CO_Ppmvdc_1H
EDS Data from: CT1_CO_Ppmvdc_3H
Emission Limitation: 4
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 04/09/2006 14:00
Process Unit(s) Description:
Operating time for EDS: 493.00 Hour(s)
Operating time for CMS: 493.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

NOx Ppmvdc EDS/CMS Summary Report

CT1



From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/05/2021 16:38 **Location:** Roseville, CA
Description: Electric Utility

CMS Data from: CT1_NOx_Ppmvdc_1H
EDS Data from: CT1_NOx_Ppmvdc_1H
Emission Limitation: 2.0
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-02
Date of Latest CMS Certification or Audit: 04/09/2006 14:00
Process Unit(s) Description:
Operating time for EDS: 493.00 Hour(s)
Operating time for CMS: 493.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

CO Ppmvdc EDS/CMS Summary Report

CT2



From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/05/2021 16:39 **Location:** Roseville, CA
Description: Electric Utility

CMS Data from: CT2_CO_Ppmvdc_1H
EDS Data from: CT2_CO_Ppmvdc_3H
Emission Limitation: 4
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 04/10/2006 07:00
Process Unit(s) Description:
Operating time for EDS: 1,289.00 Hour(s)
Operating time for CMS: 1,289.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	5
2. Total CMS Downtime	5
3. Total Downtime as a percentage of operating time	0.39
4. Total Availability as a percentage of operating time	99.61

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

NOx Ppmvdc EDS/CMS Summary Report

CT2



From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/05/2021 16:40 **Location:** Roseville, CA
Description: Electric Utility

CMS Data from: CT2_NOx_Ppmvdc_1H
EDS Data from: CT2_NOx_Ppmvdc_1H
Emission Limitation: 2.0
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-02
Date of Latest CMS Certification or Audit: 04/10/2006 07:00
Process Unit(s) Description:
Operating time for EDS: 1,289.00 Hour(s)
Operating time for CMS: 1,289.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	5
2. Total CMS Downtime	5
3. Total Downtime as a percentage of operating time	0.39
4. Total Availability as a percentage of operating time	99.61

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

CO Invalid Data

CT1

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:41 Location: Roseville, CA



Tag Name: CT1_CO_Ppm_1H
Total Operating Time: 493.00 Hour(s)
Non-Operating Time: 1,715.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	493.00 Hour(s)
Total Monitor Downtime (Online only):	0.00 Hour(s)
Percent Monitor Availability:	100.00 %
Percent Monitor Downtime:	0.00 %

NOx Invalid Data

CT1

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:41 Location: Roseville, CA



Tag Name: CT1_NOx_Ppm_1H
Total Operating Time: 493.00 Hour(s)
Non-Operating Time: 1,715.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	493.00 Hour(s)
Total Monitor Downtime (Online only):	0.00 Hour(s)
Percent Monitor Availability:	100.00 %
Percent Monitor Downtime:	0.00 %

NOx SCR Invalid Data



CT1

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:42 Location: Roseville, CA

Tag Name: CT1_NOx_SCR_Ppm_1H
Total Operating Time: 493.00 Hour(s)
Non-Operating Time: 1,715.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	493.00 Hour(s)
Total Monitor Downtime (Online only):	0.00 Hour(s)
Percent Monitor Availability:	100.00 %
Percent Monitor Downtime:	0.00 %

O2 Invalid Data

CT1

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:42 Location: Roseville, CA



Tag Name: CT1_O2Dry_Pct_1H
Total Operating Time: 493.00 Hour(s)
Non-Operating Time: 1,715.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	493.00 Hour(s)
Total Monitor Downtime (Online only):	0.00 Hour(s)
Percent Monitor Availability:	100.00 %
Percent Monitor Downtime:	0.00 %

CO Invalid Data

CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:43 Location: Roseville, CA



Tag Name: CT2_CO_Ppm_1H
Total Operating Time: 1,289.00 Hour(s)
Non-Operating Time: 919.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	1,289.00 Hour(s)
Total Monitor Downtime (Online only):	0.00 Hour(s)
Percent Monitor Availability:	100.00 %
Percent Monitor Downtime:	0.00 %

NOx Invalid Data

CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59
Generated: 01/05/2021 16:43

Facility Name: ROSEVILLE ENERGY
Location: Roseville, CA



Tag Name: CT2_NOx_Ppm_1H

Total Operating Time: 1,289.00 Hour(s)

Non-Operating Time: 919.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	10/13/2020 04:00	10/13/2020 04:59	1		
2	10/13/2020 05:00	10/13/2020 05:59	1		
3	10/13/2020 06:00	10/13/2020 06:59	1		
4	10/13/2020 07:00	10/13/2020 07:59	1		
5	10/13/2020 08:00	10/13/2020 08:59	1		

Total Operating Time:	1,289.00 Hour(s)
Total Monitor Downtime (Online only):	5.00 Hour(s)
Percent Monitor Availability:	99.61 %
Percent Monitor Downtime:	0.39 %

NOx SCR Invalid Data

CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:44 Location: Roseville, CA



Tag Name: CT2_NOx_SCR_Ppm_1H

Total Operating Time: 1,289.00 Hour(s)

Non-Operating Time: 919.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	10/19/2020 04:00	10/19/2020 04:59	1	3 - Quality assurance calibration	
2	10/19/2020 05:00	10/19/2020 05:59	1		
3	10/19/2020 06:00	10/19/2020 06:59	1		
4	10/19/2020 07:00	10/19/2020 07:59	1		
5	10/19/2020 08:00	10/19/2020 08:59	1		
6	10/19/2020 09:00	10/19/2020 09:59	1		
7	10/19/2020 10:00	10/19/2020 10:59	1		
8	10/19/2020 11:00	10/19/2020 11:59	1		
9	10/19/2020 12:00	10/19/2020 12:59	1		
10	10/19/2020 13:00	10/19/2020 13:59	1		
11	10/19/2020 14:00	10/19/2020 14:59	1		
12	10/19/2020 15:00	10/19/2020 15:59	1		
13	10/19/2020 16:00	10/19/2020 16:59	1		
14	10/19/2020 17:00	10/19/2020 17:59	1		
15	10/19/2020 18:00	10/19/2020 18:59	1		
16	10/19/2020 19:00	10/19/2020 19:59	1		
17	10/19/2020 20:00	10/19/2020 20:59	1		
18	10/19/2020 21:00	10/19/2020 21:59	1		
19	10/19/2020 22:00	10/19/2020 22:59	1		
20	10/19/2020 23:00	10/19/2020 23:59	1		
21	10/20/2020 00:00	10/20/2020 00:59	1		
22	10/20/2020 01:00	10/20/2020 01:59	1		
23	10/20/2020 02:00	10/20/2020 02:59	1		
24	10/20/2020 03:00	10/20/2020 03:59	1		
25	10/20/2020 04:00	10/20/2020 04:59	1	3 - Quality assurance calibration	
26	10/20/2020 05:00	10/20/2020 05:59	1		

NOx SCR Invalid Data



CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:44 Location: Roseville, CA

Tag Name: CT2_NOx_SCR_Ppm_1H
Total Operating Time: 1,289.00 Hour(s)
Non-Operating Time: 919.00 Hour(s) Report Time: 2,208.00 Hour(s)

Total Operating Time:	1,289.00 Hour(s)
Total Monitor Downtime (Online only):	26.00 Hour(s)
Percent Monitor Availability:	97.98 %
Percent Monitor Downtime:	2.02 %

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Quality assurance calibration	2	7.69

02 Invalid Data

CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:45 Location: Roseville, CA



Tag Name: CT2_O2Dry_Pct_1H
Total Operating Time: 1,289.00 Hour(s)
Non-Operating Time: 919.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	10/13/2020 04:00	10/13/2020 04:59	1		
2	10/13/2020 05:00	10/13/2020 05:59	1		
3	10/13/2020 06:00	10/13/2020 06:59	1		
4	10/13/2020 07:00	10/13/2020 07:59	1		
5	10/13/2020 08:00	10/13/2020 08:59	1		

Total Operating Time:	1,289.00 Hour(s)
Total Monitor Downtime (Online only):	5.00 Hour(s)
Percent Monitor Availability:	99.61 %
Percent Monitor Downtime:	0.39 %

AQ-36

AQ-36: The project owner shall notify the _PCAPCD of any breakdown condition as soon as reasonably possible, but no later than two PCAPCD business hours after its detection.

Verification: The Project owner shall include the identification of all breakdowns, PCAPCD notification, resulting excess emission (if any) and corrective actions taken (if any) as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6



MEMORANDUM

TO: Hearing Board Members, Placer County Air Pollution Control District

FROM: Erik C. White, Air Pollution Control Officer

DATE: November 13, 2020

SUBJECT: Short Term Variance #20-03

Please find enclosed a copy of the Short Term Variance #20-03 granted to Roseville Energy Park.

Ms. Julie Manfredi
Roseville Energy Park – Roseville Electric Utility
5120 Phillip Road
Roseville, CA 95747

Ms. Vanessa Faune
District Support Division
California Air Resources Board
P.O. Box 2815
Sacramento, CA 95812

Ms. Roshni Brahmhatt
U.S. Environmental Protection Agency
Region IX, Compliance Division
75 Hawthorne Street
San Francisco, CA 94105

**PLACER COUNTY AIR POLLUTION CONTROL DISTRICT
HEARING BOARD ORDER
SHORT TERM VARIANCE NO. 20-03**

THE MATTER of the application for a Short Term Variance, a variance of not more than 90 days in duration, by Roseville Energy Park – Roseville Electric Utility, was heard on November 13, 2020. Notice of the hearing was provided on October 30, 2020, in conformance with the requirements of the California Health and Safety Code Sections 40823 and 40825, and District Rules and Regulations. All persons interested in the application having been heard and the matter having been taken under submission for decision by the following member(s) of the Placer County Air Pollution Control District Hearing Board:

- ☒ Mr. Donald Gronstal, Chairman
- ☐ Ms. Diane Przepiorski
- ☐ Mr. D. Stevens Parks
- ☐ Mr. Tim Woodall (alternate)
- ☐ Mr. Gary Hall
- ☐ Dr. Gabriele Windgasse

NOTE

Pursuant to California Health and Safety Code Sections 40824, 40825, and 42351, in districts with a population of less than 750,000, the chairman of the hearing board or any other member designated by the board may hear an application. This provision applies to Placer County Air Pollution Control District for Emergency Variances, Interim Variances, Short Term Variances, and Interim Authorization & Modification of Increments of Progress.

The Board finds:

Roseville Energy Park - Roseville Electric (REP) operates a power plant with two combustion turbines with a heat recovery steam turbine generator at 5120 Phillip Road, Roseville, California. An ammonia (NH₃) injection system in conjunction with a reduction catalyst is used to reduce nitrogen oxide (NO_x) emissions. An oxidation catalyst is used to reduce carbon monoxide (CO) and volatile organic compound (VOC) emissions.

REP will be going into a planned major maintenance outage which is scheduled to begin on November 30, 2020 and last through December 19, 2020. During the maintenance outage, combustion turbines #1 and #2 (CT1 and CT2) and their associated duct burners and heat recovery steam generators will be cleaned and repaired and will be prepared for the installation of Low Load Turndown (LLT) and Advanced Emissions Tuning (AET) hardware.

Following the major maintenance outage, REP will perform commissioning activities on CT1 and CT2 to ensure that all systems are ready for service. The commissioning activities will include reduced loads, multiple start-ups and shut-downs, equipment tuning, and turbine/generator optimization. The commissioning and optimization activities will not include operation of the LLT and AET hardware as this equipment will be authorized through a standalone Authority to Construct / Permit to Operate application process, expected in late 2020 or early 2021.

The commissioning and optimization activities will involve operating the units at varying loads and ramp rates. These periods of rapid load increases and rapid load decreases will create dynamic emission profiles from the combustion turbines and duct burners under abnormal operating scenarios. The swings in emissions will likely strain or otherwise impede the emission control equipment, which may not be designed to sufficiently control emissions from such aggressive load changes. If any part of the emission control process becomes compromised during the testing or equipment optimization activities, there is a possibility that permitted operating and emission limits may be exceeded. REP has requested this Short Term Variance from Permits to Operate REPR-20-01 and REPR-20-02 for Combustion Turbine #1 and Combustion Turbine #2, for the following conditions:

- Condition 18. Turbine limits on the duration of startup and shutdowns.
- Condition 19. Turbine NOx concentration limits as a function of turbine efficiency.
- Condition 48. Excess ammonia concentration emission limits.
- Condition 49. Turbine NOx, CO, and VOC emission limits during routine operations (excluding startup and shutdown).
- Condition 50. Turbine NOx emission exemption.
- Condition 51. Turbine NOx and CO emissions limits during startup and shutdown.
- Condition 52. Turbine emission limits during routine operation (excluding startup and shutdown) in pound per hour.
- Condition 53. Facility daily emission limits.
- Condition 54. Turbine daily, hourly, and quarterly emission limits.
- Condition 55. Facility quarterly emission limits.

Having considered the additional details and discussion laid out in the accompanying staff report, the Board orders that REP is hereby granted, pursuant to Section 40825 and Sections 40860 et seq. of the California Health and Safety Code, a variance from District Permits to Operate REPR-20-01 and REPR-20-02, Conditions 18, 19, 48, 49, 50, 51, 52, 53, 54, and 55.

The Short Term Variance will take effect on December 20, 2020, and shall end no later than January 31, 2021 under the following conditions:

SHORT TERM VARIANCE # 20-03
CONDITIONS OF APPROVAL

1. This Variance Order does not allow violation of Section 41700 of the California Health and Safety Code, which prohibits discharges to the atmosphere which cause injury, detriment, nuisance, or annoyance to any considerable number of persons or to the public, or which endanger the comfort, repose, health, or safety of any such persons or the public, or which cause, or have a natural tendency to cause injury or damage to business or property.
2. This variance covers District Permits to Operate REPR-20-01 and REPR-20-02, Conditions 18, 19, 48, 49, 50, 51, 52, 53, 54, and 55.
3. This variance is granted during the equipment testing and power optimization activities associated with the commissioning of Roseville Energy Park's Combustion Turbine #1 and #2 and their associated duct burners and heat recovery steam generators. This variance is not valid during routine operation that is after the completion of, or not a part of, the commissioning activities.
4. Roseville Energy Park shall provide written notification to the District when the commissioning activities begin.
5. Roseville Energy Park shall report all noncompliant events to the District using the District Non-Compliance Event forms and procedures.
6. A written final report, including the dates and times of any excess emissions, an estimate of the quantities of pollutants discharged, and the amount of pollutants emitted in excess of permit limitations, shall be submitted to the District by no later than thirty days after the commissioning activities have been completed, and no later than March 1, 2021.
7. Roseville Energy Park shall notify the District upon the completion of the required commissioning activities, at which time Roseville Energy Park shall be in compliance with all conditions listed in Permits to Operate REPR-20-01 and REPR-20-02.
8. This variance is approved to take effect on December 20, 2020. Roseville Energy Park shall be in compliance with all conditions listed in Permits to Operate REPR-20-01 and REPR-20-02 by no later than January 31, 2021.

DATE APPROVED: November 13, 2020

Donald J. Instal

**CHAIRMAN/VICE CHAIRMAN
OF HEARING BOARD**
(Signature)

AQ-37

AQ-37 Any Violation of any emission standard listed in this permit which is indicated by the CEMS shall be reported to the PCAPCD no later than 96 hours after such occurrence as per California Health and Safety Code 42706

Verification: The Project owner shall include all violations of emissions standards and corresponding PCAPCD notifications in the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

All Notices of Non Compliance are included in AQ-41.

AQ-40

AQ-40 The Project owner shall comply with the applicable requirements for quality assurance testing and maintenance of the continuous emission monitor equipment in accordance with the procedures and guidance specified in 40 CFR Part 60, Appendix F.

Verification: The Project owner shall include all CEMS quality assurance test failures that required corrective action as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

Cylinder Gas Audit

01/05/2021

Page 1

Facility: ROSEVILLE ENERGY
Unit/Stack: CT1
Parameter/Scale: CO / High

Test Date: 10/01/2020
Test Result: **Pass**

Instrument Name: CT1_CODualRg_P_Instrume
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
10/01/2020	08:26	L	200	50.300	49.700	25.2 %
10/01/2020	08:31	M	200	112.800	114.000	56.4 %
10/01/2020	08:44	L	200	50.300	49.700	25.2 %
10/01/2020	08:49	M	200	112.800	114.000	56.4 %
10/01/2020	09:01	L	200	50.300	49.700	25.2 %
10/01/2020	09:06	M	200	112.800	113.900	56.4 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	50.300	49.700	Std	1.2
M	112.800	113.967	Std	1.0

Cylinder Gas Audit

01/05/2021

Page 2

Facility: ROSEVILLE ENERGY
Unit/Stack: CT1
Parameter/Scale: CO / Low

Test Date: 10/01/2020
Test Result: **Pass**

Instrument Name: CT1_CODualRg_P_Instrume
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
10/01/2020	10:38	L	10	2.400	2.300	24.0 %
10/01/2020	10:43	M	10	5.700	5.600	57.0 %
10/01/2020	10:50	L	10	2.400	2.200	24.0 %
10/01/2020	10:55	M	10	5.700	5.600	57.0 %
10/01/2020	11:02	L	10	2.400	2.200	24.0 %
10/01/2020	11:07	M	10	5.700	5.600	57.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	2.400	2.233	Std	6.9
M	5.700	5.600	Std	1.8

Cylinder Gas Audit

01/05/2021

Page 3

Facility: ROSEVILLE ENERGY
Unit/Stack: CT2
Parameter/Scale: CO / High

Test Date: 10/01/2020
Test Result: **Pass**

Instrument Name: CT2_CODualRg_P_Instrume
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
10/01/2020	11:38	L	200	49.400	49.900	24.7 %
10/01/2020	11:43	M	200	112.700	115.800	56.4 %
10/01/2020	11:55	L	200	49.400	50.000	24.7 %
10/01/2020	12:00	M	200	112.700	116.000	56.4 %
10/01/2020	12:12	L	200	49.400	49.700	24.7 %
10/01/2020	12:17	M	200	112.700	115.700	56.4 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	49.400	49.867	Std	0.9
M	112.700	115.833	Std	2.8

Cylinder Gas Audit

01/05/2021

Page 4

Facility: ROSEVILLE ENERGY
Unit/Stack: CT2
Parameter/Scale: CO / Low

Test Date: 10/02/2020
Test Result: **Pass**

Instrument Name: CT2_CODualRg_P_Instrume
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
10/02/2020	12:30	L	10	2.400	2.300	24.0 %
10/02/2020	12:34	M	10	5.700	5.700	57.0 %
10/02/2020	12:42	L	10	2.400	2.300	24.0 %
10/02/2020	12:47	M	10	5.700	5.700	57.0 %
10/02/2020	12:54	L	10	2.400	2.300	24.0 %
10/02/2020	12:59	M	10	5.700	5.600	57.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	2.400	2.300	Std	4.2
M	5.700	5.667	Std	0.6

Linearity Report

01/05/2021

Page 1

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY	ReasonForTest:	QA
EDR Site ID:	CT001	Component ID:	A15	Grace Period:	0
		Component Type:	NOXA	Scale:	High
Instrument Name:	CT1_NOXDualRg_P_Instrume	Test End Date/Time:	10/01/2020	Highest Error:	3.1
Performance Spec:	5 %	Test No.:	104		
		Status (Pass/Fail):	Passed		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
10/01/2020	0826	L	200.0	47.6	48.5		23.8 %
10/01/2020	0831	M	200.0	105.0	108.3		52.5 %
10/01/2020	0837	H	200.0	180.0	180.0		90.0 %
10/01/2020	0844	L	200.0	47.6	49.2		23.8 %
10/01/2020	0849	M	200.0	105.0	108.3		52.5 %
10/01/2020	0854	H	200.0	180.0	180.0		90.0 %
10/01/2020	0901	L	200.0	47.6	49.1		23.8 %
10/01/2020	0906	M	200.0	105.0	108.1		52.5 %
10/01/2020	0911	H	200.0	180.0	179.6		90.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	47.600	48.933	No	2.8
M	105.000	108.233	No	3.1
H	180.000	179.867	No	0.1

Linearity Report

01/05/2021

Page 2

ORIS Code: 56298

EDR Site ID: CT001

Facility Name: ROSEVILLE ENERGY

Component ID: A16

Component Type: O2D

ReasonForTest: QA

Grace Period: 0

Instrument Name: CT1_O2D_P_Instrument

Performance Spec: 5 %

Test End Date/Time: 10/01/2020

Test No.: 105

Status (Pass/Fail): **Passed**

Scale: High

Highest Error: 3.6

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
10/01/2020	1234	L	21.0	5.5	5.3		26.2 %
10/01/2020	1238	M	21.0	11.1	10.9		52.9 %
10/01/2020	1244	H	21.0	18.0	18.0		85.7 %
10/01/2020	1251	L	21.0	5.5	5.3		26.2 %
10/01/2020	1256	M	21.0	11.1	10.9		52.9 %
10/01/2020	1301	H	21.0	18.0	18.0		85.7 %
10/01/2020	1308	L	21.0	5.5	5.3		26.2 %
10/01/2020	1313	M	21.0	11.1	10.9		52.9 %
10/01/2020	1318	H	21.0	18.0	18.0		85.7 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.500	5.300	No	3.6
M	11.100	10.900	No	1.8
H	18.000	18.000	No	0.0

Linearity Report

01/05/2021

Page 3

ORIS Code: 56298

EDR Site ID: CT002

Facility Name: ROSEVILLE ENERGY

Component ID: A21

Component Type: NOXA

ReasonForTest: QA

Grace Period: 0

Instrument Name: CT2_NOXDualRg_P_Instrume Test End Date/Time: 10/01/2020

Scale: High

Performance Spec: 5 %

Test No.: 104

Highest Error: 2.6

Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
10/01/2020	1138	L	200.0	48.2	48.8		24.1 %
10/01/2020	1143	M	200.0	106.0	108.5		53.0 %
10/01/2020	1148	H	200.0	180.0	180.3		90.0 %
10/01/2020	1155	L	200.0	48.2	49.3		24.1 %
10/01/2020	1200	M	200.0	106.0	108.9		53.0 %
10/01/2020	1205	H	200.0	180.0	180.3		90.0 %
10/01/2020	1212	L	200.0	48.2	49.3		24.1 %
10/01/2020	1217	M	200.0	106.0	108.9		53.0 %
10/01/2020	1222	H	200.0	180.0	180.2		90.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	48.200	49.133	No	1.9
M	106.000	108.767	No	2.6
H	180.000	180.267	No	0.1

Linearity Report

01/05/2021

Page 4

ORIS Code: 56298

EDR Site ID: CT002

Facility Name: ROSEVILLE ENERGY

Component ID: A22

Component Type: O2D

ReasonForTest: QA

Grace Period: 0

Instrument Name: CT2_O2D_P_Instrument

Performance Spec: 5 %

Test End Date/Time: 10/02/2020

Test No.: 105

Status (Pass/Fail): **Passed**

Scale: High

Highest Error: 0.9

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
10/02/2020	0942	L	21.0	5.5	5.6		26.2 %
10/02/2020	0948	M	21.0	11.2	11.3		53.3 %
10/02/2020	0953	H	21.0	18.1	18.1		86.2 %
10/02/2020	1000	L	21.0	5.5	5.5		26.2 %
10/02/2020	1005	M	21.0	11.2	11.3		53.3 %
10/02/2020	1010	H	21.0	18.1	18.1		86.2 %
10/02/2020	1017	L	21.0	5.5	5.5		26.2 %
10/02/2020	1022	M	21.0	11.2	11.3		53.3 %
10/02/2020	1027	H	21.0	18.1	18.1		86.2 %

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Alt Perf Spec	Results
L	5.500		5.533	No	0.6
M	11.200		11.300	No	0.9
H	18.100		18.100	No	0.0

Roseville Energy Park Revision History

RegPerfect® by Teledyne Monitor Labs, Inc.

Teledyne Monitor Labs, Inc.

35 Inverness Drive East

Englewood, CO 80112-5189

Telephone: (800) 846-6062

<http://www.teledyne-ml.com/>

<http://www.regperfect.com/>

©1998-2005 Teledyne Monitor Labs, Inc. All rights reserved.

RegPerfect® is a registered trademark of Teledyne Monitor Labs, Inc.

NOTE: This server's C drive is only 20 GB in size!! Do not place large files on this drive.

10/28/20 Taylor Sullivan

Q3 EDR

AQ-41

AQ-41The Project owner shall submit a written report to the APCO and the CPM for each calendar quarter, within 30 days of the end of the quarter, including: time intervals, data and magnitude of excess emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; averaging period used for data reporting shall correspond to the averaging period for each respective emission standard; applicable time and date of each period during which the CEMS was inoperative (except for zero and span checks) and the nature of the system repairs and adjustments; and a negative declaration when no excess emission occurred.

Verification: The Project owner shall include the excess emission report as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6

Excess Emission Report



From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/06/2021 11:22 **Location:** Roseville, CA

Tag Name: ALL_CO_Lb_1D
Total Operating Time: 58.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 34.00 Day(s) **Report Time:** 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	58.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/06/2021 11:23 **Location:** Roseville, CA

Tag Name: ALL_NOX_Lb_1D
Total Operating Time: 58.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 34.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	58.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/06/2021 11:23 **Location:** Roseville, CA

Tag Name: ALL_PM10_Lb_1D
Total Operating Time: 58.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 34.00 Day(s) **Report Time:** 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	58.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/06/2021 11:24 **Location:** Roseville, CA

Tag Name: ALL_SO2_Lb_1D
Total Operating Time: 58.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 34.00 Day(s) **Report Time:** 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	58.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/06/2021 11:25 **Location:** Roseville, CA

Tag Name: ALL_VOC_Lb_1D
Total Operating Time: 58.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 34.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	58.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NH3 Slip Ppmvdc 1-Hour Block Excess Emissions



CT1

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/06/2021 11:27 Location: Roseville, CA

Tag Name: CT1_NH3Slip_Ppmvdc_1H
Total Operating Time: 493.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,715.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	493.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx LbPerHr 1-Hour Block Excess Emissions

CT1

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/06/2021 11:28 Location: Roseville, CA



Tag Name: CT1_NOx_Norm_LbPerHr_1H
Total Operating Time: 493.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,715.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	493.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx Ppmvdc 1-Hour Block Excess Emissions

CT1

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/06/2021 11:28 Location: Roseville, CA



Tag Name: CT1_NOx_Ppmvdc_1H
Total Operating Time: 493.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,715.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	493.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx LbPerHr SUSd 1-Hour Block Excess Emissions



CT1

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/06/2021 11:29 Location: Roseville, CA

Tag Name: CT1_NOx_SUSd_LbPerHr_1H
Total Operating Time: 493.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,715.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	493.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

PM10 LbPerHr 1-Hour Block Excess Emissions

CT1

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/06/2021 11:29 Location: Roseville, CA



Tag Name: CT1_PM10_Norm_LbPerHr_1H
Total Operating Time: 493.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,715.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	493.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

S02 LbPerHr 1-Hour Block Excess Emissions



CT1

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/06/2021 11:29 Location: Roseville, CA

Tag Name: CT1_S02_Norm_LbPerHr_1H
Total Operating Time: 493.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,715.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	493.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

VOC LbPerHr 1-Hour Block Excess Emissions



CT1

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/06/2021 11:30 Location: Roseville, CA

Tag Name: CT1_VOC_Norm_LbPerHr_1H
Total Operating Time: 493.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,715.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	493.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO LbPerHr 3-Hour Rolling Excess Emissions

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/06/2021 11:26 Location: Roseville, CA

Tag Name: CT1_CO_3Hr_LbPerHr_1H
Total Operating Time: 493.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,715.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	493.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO Ppmvdc 3-Hour Block Excess Emissions



CT1

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/06/2021 11:26 Location: Roseville, CA

Tag Name: CT1_CO_Ppmvdc_3H
Total Operating Time: 493.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,715.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	493.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO LbPerHr SUSd 1-Hour Block Excess Emissions



CT1

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/06/2021 11:27 Location: Roseville, CA

Tag Name: CT1_CO_SUSD_LbPerHr_1H
Total Operating Time: 493.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,715.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	493.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NH3 Slip Ppmvdc 1-Hour Block Excess Emissions

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/06/2021 11:32 Location: Roseville, CA

Tag Name: CT2_NH3Slip_Ppmvdc_1H
Total Operating Time: 1,289.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 919.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,289.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx LbPerHr 1-Hour Block Excess Emissions

CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/06/2021 11:32 Location: Roseville, CA



Tag Name: CT2_NOx_Norm_LbPerHr_1H
Total Operating Time: 1,289.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 919.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,289.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx Ppmvdc 1-Hour Block Excess Emissions

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/06/2021 11:33 Location: Roseville, CA

Tag Name: CT2_NOx_Ppmvdc_1H
Total Operating Time: 1,289.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 919.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,289.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx LbPerHr SUSd 1-Hour Block Excess Emissions



CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/06/2021 11:33 Location: Roseville, CA

Tag Name: CT2_NOx_SUSd_LbPerHr_1H
Total Operating Time: 1,289.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 919.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,289.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

PM10 LbPerHr 1-Hour Block Excess Emissions

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/06/2021 11:34 Location: Roseville, CA

Tag Name: CT2_PM10_Norm_LbPerHr_1H
Total Operating Time: 1,289.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 919.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,289.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

S02 LbPerHr 1-Hour Block Excess Emissions

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/06/2021 11:34 Location: Roseville, CA

Tag Name: CT2_S02_Norm_LbPerHr_1H
Total Operating Time: 1,289.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 919.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,289.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

VOC LbPerHr 1-Hour Block Excess Emissions

CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/06/2021 11:35 Location: Roseville, CA



Tag Name: CT2_VOC_Norm_LbPerHr_1H
Total Operating Time: 1,289.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 919.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,289.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO LbPerHr 3-Hour Rolling Excess Emissions

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/06/2021 11:31 Location: Roseville, CA

Tag Name: CT2_CO_3Hr_LbPerHr_1H
Total Operating Time: 1,289.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 919.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,289.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO Ppmvdc 3-Hour Block Excess Emissions



CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/06/2021 11:31 Location: Roseville, CA

Tag Name: CT2_CO_Ppmvdc_3H
Total Operating Time: 1,289.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 919.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,289.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO LbPerHr SUSD 1-Hour Block Excess Emissions



CT2

From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/06/2021 11:32 Location: Roseville, CA

Tag Name: CT2_CO_SUSD_LbPerHr_1H
Total Operating Time: 1,289.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 919.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,289.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

AQ-42

AQ-42 The Project owner shall provide the PCAPCD and CPM with a written emission statement showing actual emissions of volatile organic compounds and oxides of nitrogen. Pursuant to PCAPCD Rule 503 the Project owner shall submit this emission statement on a form or in a format specified by the Air Pollution Control Officer. The statement shall contain the following information:

- a) Information contained in the California Air Resources Board's Emission Inventory Turn Around Document as described in Instructions for the Emission Data System Review and Update Report;
- b) Actual emissions of volatile organic compounds and oxides of nitrogen, in tons per year, for the calendar year prior to the preparation of the emission statement;
- c) Information regarding seasonal or diurnal peaks in the emission of affected pollutants; and
- d) Certification by a responsible official of the Project owner that the information contained in the emission statement is accurate to the best knowledge of the individual certifying the emission statement.

Verification: The Project owner shall submit to the CPM the emission statement described herein prior to the beginning of March each year.

12 Month Running Summary Report

AQ42 12 Month Running Summary Report



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/06/2021 11:38 Location: Roseville, CA

Date	Units CT1 & CT2		Units CT1 & CT2	
	NOx, Ton		VOC, Ton	
	1 Day(s)		1 Day(s)	
	Sum	Running Sum	Sum	Running Sum
Oct 20	1.4695	1.4695	0.4673	0.4673
Nov 20	0.7256	2.1951	0.2316	0.6989
Dec 20	0.0197	2.2148	0.0020	0.7009
Sum/Avg	2.2148		0.7009	

Roseville Energy Park Quarterly Emissions Summary

for PCAPCD



From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/06/2021 11:21 **Location:** Roseville, CA

* = Excess Emission

Date	Unit CT1 CO, Ton		Unit CT1 NOx, Ton		Unit CT1 OperatingTime, Hrs		Unit CT2 CO, Ton		Unit CT2 NOx, Ton		Unit CT2 OperatingTime, Hrs	
	1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)	
	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum
Oct 2020	0.1796	1.2994	0.6168	4.0281	485.61	3,026.63	0.2856	1.3948	0.8529	4.2177	678.52	3,247.49
Nov 2020	0.0000	1.0028	0.0000	3.4108	0.00	2,564.71	0.3189	1.4597	0.7256	4.5456	600.07	3,554.39
Dec 2020	0.0256	0.9885	0.0085	3.2963	2.72	2,471.31	0.0268	1.4422	0.0113	4.4410	2.85	3,461.12
Sum/Avg	0.9885		3.2963		2,471.31		1.4422		4.4410		3,461.12	
Limit Value												

AQ-47

AQ-47 No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

In regards to AQ-47 of Roseville Energy Park's 4Q20 QAQR, there were no violations of PCAPCD's Rule 205 for nuisance.

AQ-48

AQ-48 Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited and is in violation of PCAPCD Rule 202, Visible Emissions.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

In regards to AQ-48 of Roseville Energy Park's 4Q20 QAQR, there were no violations of PCAPCD's Rule 202 for opacity.

AQ-51

AQ-51 The ammonia slip shall not exceed 10 ppmv @ 15% O₂ averaged over one hour. The SCR catalyst shall be replaced, repaired or otherwise reconditioned within 24 months of the ammonia slip reaching 7 ppm @ 15% O₂ averaged over 24 hours. The SCR ammonia injection grid replacement, repair or reconditioning scheduled event may be cancelled if the Project owner can demonstrate to the CPM that, subsequent to the initial exceedance, the ammonia slip consistently remains below 7 ppm @ 15% O₂ averaged over 24 hours and that the initial exceedance does not accurately indicate expected future operating conditions.

Compliance with ammonia slip limits shall be demonstrated by using the following calculation procedure:

$$\text{Ammonia slip ppmv @ 15\% O}_2 = ((a - (b \times c / 1,000,000)) \times 1,000,000 / b) \times d,$$

Where

a = ammonia injection rate (lb/hr)/17(lb/lb mol)

b = dry exhaust gas flow rate (lb/hr)/ (29(lb/lb mol)

c = change in measured NOX conc. Ppmv @ 15% O₂ across catalyst, and

d = correction factor

The correction factor shall be derived annually during compliance testing by comparing the measured and calculated ammonia slip.

Verification: The Project owner shall include the ammonia slip concentrations averaged on an hourly and 24 hour basis calculated via the protocol provided as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6. The Project owner shall notify the CPM within 10 days of an exceedance of the 7 ppm ammonia slip limit herein. The Project owner shall notify the CPM no less than 30 days prior to the scheduled date of the SCR catalyst replacement, repair or reconditioning event. If the Project owner finds that the exceedance of the 7 ppm slip limit does not accurately reflect the expected future operations provided for in this condition, the Project owner shall submit all relevant information to the CPM no less than 30 days prior to the scheduled date of the SCR catalyst replacement, repair or reconditioning event in order to cancel the event.

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/01/2020 00:00	3	1.9	13.3	14.4	30.8	726,005.6	0.00	1.00
10/01/2020 01:00	3	1.9	14.5	14.5	31.4	653,686.2	0.00	1.00
10/01/2020 02:00	3	1.8	13.9	14.5	28.0	640,847.8	0.00	1.00
10/01/2020 03:00	3	1.9	13.8	14.5	29.0	638,494.1	0.00	1.00
10/01/2020 04:00	3	1.8	14.0	14.5	28.8	638,280.1	0.00	1.00
10/01/2020 05:00	3	1.8	13.7	14.5	30.2	637,852.2	0.00	1.00
10/01/2020 06:00	3	1.9	13.8	14.5	28.8	640,205.9	0.00	1.00
10/01/2020 07:00	3	1.9	14.5	14.4	33.6	668,911.1	0.00	1.00
10/01/2020 08:00	3	1.8	13.3	14.4	33.3	733,168.7	0.00	1.00
10/01/2020 09:00	2	1.8	12.6	14.6	34.4	846,434.7	0.00	1.00
10/01/2020 10:00	2	1.9	11.8	14.1	30.6	941,479.3	0.00	1.00
10/01/2020 11:00	2	2.3	15.5	12.7	44.8	925,864.5	0.00	1.00
10/01/2020 12:00	3	2.5	16.7	12.4	43.7	932,014.1	0.00	1.00
10/01/2020 13:00	4	2.6	17.4	11.9	48.2	919,492.4	0.00	1.00
10/01/2020 14:00	4	2.6	17.9	11.7	51.3	919,151.7	0.00	1.00
10/01/2020 15:00	3	2.4	16.4	12.5	41.6	915,884.1	0.00	1.00
10/01/2020 16:00	4	2.7	17.9	11.8	50.8	929,402.7	0.00	1.00
10/01/2020 17:00	4	2.6	17.1	12.0	47.5	917,822.1	0.00	1.00
10/01/2020 18:00	2	1.9	10.5	14.5	25.9	895,261.2	0.00	1.00
10/01/2020 19:00	2	1.9	11.3	14.0	29.6	890,522.8	0.00	1.00
10/01/2020 20:00	2	2.0	11.8	13.9	30.9	898,733.7	0.00	1.00
10/01/2020 21:00	2	2.2	12.9	13.4	33.7	914,958.1	0.00	1.00
10/01/2020 22:00	2	1.9	11.6	14.5	31.2	858,457.9	0.00	1.00
10/01/2020 23:00	3	1.9	12.8	14.5	32.5	782,925.6	0.00	1.00
Average/Sum#:	3	2.1	14.1	13.7	35.4	811,077.4	0.00 #	24.00 #
Minimum:	2	1.8	10.5	11.7	25.9	637,852.2	0.00	1.00
Maximum:	4	2.7	17.9	14.6	51.3	941,479.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/02/2020 00:00	3	1.9	14.2	14.4	31.7	680,287.9	0.00	1.00
10/02/2020 01:00	3	1.8	14.0	14.5	28.5	641,703.7	0.00	1.00
10/02/2020 02:00	3	1.9	13.8	14.5	28.5	639,991.9	0.00	1.00
10/02/2020 03:00	3	1.9	13.7	14.5	28.2	643,843.4	0.00	1.00
10/02/2020 04:00	3	1.8	14.6	14.4	31.4	651,424.6	0.00	1.00
10/02/2020 05:00	3	1.9	14.2	14.5	30.7	638,922.1	0.00	1.00
10/02/2020 06:00	3	1.9	14.0	14.5	30.5	638,066.2	0.00	1.00
10/02/2020 07:00	3	1.8	13.8	14.5	30.0	638,280.1	0.00	1.00
10/02/2020 08:00	3	1.8	13.4	14.5	28.5	640,205.9	0.00	1.00
10/02/2020 09:00	3	1.9	14.2	14.4	32.1	655,006.2	0.00	1.00
10/02/2020 10:00	3	1.8	14.1	14.5	33.0	705,681.5	0.00	1.00
10/02/2020 11:00	2	1.8	12.0	14.6	29.6	838,826.8	0.00	1.00
10/02/2020 12:00	2	1.9	10.7	14.3	26.8	900,707.8	0.00	1.00
10/02/2020 13:00	2	2.0	11.4	14.0	28.8	906,003.2	0.00	1.00
10/02/2020 14:00	2	2.1	12.8	13.5	32.2	913,628.1	0.00	1.00
10/02/2020 15:00	2	1.9	10.4	14.4	26.9	885,490.9	0.00	1.00
10/02/2020 16:00	3	2.3	15.9	12.7	41.4	918,349.4	0.00	1.00
10/02/2020 17:00	3	2.2	13.9	13.2	35.5	912,890.3	0.00	1.00
10/02/2020 18:00	2	2.0	12.4	14.3	30.4	780,156.9	0.00	1.00
10/02/2020 19:00	2	1.9	11.6	14.1	29.4	890,327.2	0.00	1.00
10/02/2020 20:00	3	1.9	13.0	14.4	31.0	729,587.2	0.00	1.00
10/02/2020 21:00	2	1.9	12.4	14.2	32.8	878,271.1	0.00	1.00
10/02/2020 22:00	2	1.9	11.9	14.6	32.7	865,780.5	0.00	1.00
10/02/2020 23:00	3	1.9	13.2	14.4	33.4	769,195.1	0.00	1.00
Average/Sum#:	3	1.9	13.2	14.2	31.0	765,109.5	0.00 #	24.00 #
Minimum:	2	1.8	10.4	12.7	26.8	638,066.2	0.00	1.00
Maximum:	3	2.3	15.9	14.6	41.4	918,349.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/03/2020 00:00	3	1.9	14.3	14.4	31.0	654,584.9	0.00	1.00
10/03/2020 01:00	3	1.8	13.9	14.5	28.3	636,996.3	0.00	1.00
10/03/2020 02:00	3	1.9	13.6	14.5	27.7	638,494.1	0.00	1.00
10/03/2020 03:00	3	1.9	13.7	14.5	28.5	639,350.0	0.00	1.00
10/03/2020 04:00	3	1.8	14.1	14.5	28.5	637,638.2	0.00	1.00
10/03/2020 05:00	3	1.9	13.8	14.5	29.1	637,852.2	0.00	1.00
10/03/2020 06:00	3	1.9	13.8	14.5	28.7	639,136.0	0.00	1.00
10/03/2020 07:00	3	1.9	13.7	14.5	28.5	638,922.1	0.00	1.00
10/03/2020 08:00	3	1.9	13.8	14.4	30.9	673,335.4	0.00	1.00
10/03/2020 09:00	3	1.8	13.3	14.5	33.6	771,585.1	0.00	1.00
10/03/2020 10:00	3	1.8	13.3	14.6	35.0	807,960.4	0.00	1.00
10/03/2020 11:00	3	1.9	12.8	14.4	33.4	817,441.0	0.00	1.00
10/03/2020 12:00	2	1.9	12.2	14.4	29.4	791,105.9	0.00	1.00
10/03/2020 13:00	2	1.9	11.1	14.1	28.1	899,188.2	0.00	1.00
10/03/2020 14:00	3	2.2	14.4	13.1	35.8	919,270.0	0.00	1.00
10/03/2020 15:00	2	2.0	10.7	14.3	28.0	870,621.9	0.00	1.00
10/03/2020 16:00	2	1.9	11.2	14.1	29.0	887,507.8	0.00	1.00
10/03/2020 17:00	2	1.9	10.3	14.5	26.7	875,361.7	0.00	1.00
10/03/2020 18:00	3	2.4	16.2	12.4	43.9	919,931.0	0.00	1.00
10/03/2020 19:00	2	2.2	13.0	13.5	33.5	903,820.1	0.00	1.00
10/03/2020 20:00	2	1.9	10.3	14.5	28.2	905,959.8	0.00	1.00
10/03/2020 21:00	2	2.0	12.0	14.0	31.3	892,110.5	0.00	1.00
10/03/2020 22:00	3	1.9	12.9	14.5	36.3	844,335.7	0.00	1.00
10/03/2020 23:00	3	1.9	13.4	14.4	34.0	771,934.0	0.00	1.00
Average/Sum#:	3	1.9	13.0	14.2	31.1	778,101.8	0.00 #	24.00 #
Minimum:	2	1.8	10.3	12.4	26.7	636,996.3	0.00	1.00
Maximum:	3	2.4	16.2	14.6	43.9	919,931.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOX, Ppm	Unit CT1 NOX, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/04/2020 00:00	3	1.9	14.1	14.5	30.0	655,398.0	0.00	1.00
10/04/2020 01:00	3	1.8	14.5	14.4	30.8	644,050.8	0.00	1.00
10/04/2020 02:00	3	1.9	14.0	14.5	28.9	638,066.2	0.00	1.00
10/04/2020 03:00	3	1.9	13.9	14.5	28.7	638,708.1	0.00	1.00
10/04/2020 04:00	3	1.8	14.2	14.5	28.9	647,267.0	0.00	1.00
10/04/2020 05:00	3	1.9	14.4	14.4	31.7	646,368.3	0.00	1.00
10/04/2020 06:00	3	1.9	14.3	14.5	30.6	644,271.4	0.00	1.00
10/04/2020 07:00	3	1.9	13.7	14.4	32.9	703,673.5	0.00	1.00
10/04/2020 08:00	3	1.9	13.2	14.5	33.1	758,318.8	0.00	1.00
10/04/2020 09:00	2	1.8	11.1	14.5	27.7	873,222.0	0.00	1.00
10/04/2020 10:00	2	1.9	10.8	14.3	29.3	910,874.7	0.00	1.00
10/04/2020 11:00	2	2.1	12.8	13.5	34.3	924,361.5	0.00	1.00
10/04/2020 12:00	3	2.4	16.8	12.5	43.2	929,252.3	0.00	1.00
10/04/2020 13:00	4	2.6	17.9	11.9	49.4	924,361.5	0.00	1.00
10/04/2020 14:00	4	2.6	17.8	11.9	50.8	930,447.8	0.00	1.00
10/04/2020 15:00	4	2.6	17.8	11.9	51.2	928,469.7	0.00	1.00
10/04/2020 16:00	4	2.5	17.2	12.2	47.5	924,912.4	0.00	1.00
10/04/2020 17:00	3	2.4	16.0	12.7	41.5	922,691.4	0.00	1.00
10/04/2020 18:00	3	2.3	14.9	13.0	38.4	904,340.1	0.00	1.00
10/04/2020 19:00	2	1.9	11.0	14.3	30.0	891,578.3	0.00	1.00
10/04/2020 20:00	2	1.9	10.4	14.5	29.3	890,339.8	0.00	1.00
10/04/2020 21:00	2	1.9	10.7	14.5	30.2	888,200.1	0.00	1.00
10/04/2020 22:00	3	1.9	13.3	14.4	33.2	763,296.1	0.00	1.00
10/04/2020 23:00	3	1.8	15.1	14.4	33.7	658,377.1	0.00	1.00
Average/Sum#:	3	2.1	14.2	13.8	35.2	801,702.0	0.00 #	24.00 #
Minimum:	2	1.8	10.4	11.9	27.7	638,066.2	0.00	1.00
Maximum:	4	2.6	17.9	14.5	51.2	930,447.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/05/2020 00:00	3	1.9	14.1	14.5	29.2	638,066.2	0.00	1.00
10/05/2020 01:00	3	1.9	14.2	14.5	30.0	637,638.2	0.00	1.00
10/05/2020 02:00	3	1.8	14.5	14.5	31.1	637,210.3	0.00	1.00
10/05/2020 03:00	3	1.9	14.8	14.5	32.6	639,991.9	0.00	1.00
10/05/2020 04:00	3	1.8	14.9	14.5	32.0	656,253.8	0.00	1.00
10/05/2020 05:00	4	1.9	14.9	14.3	36.4	682,014.8	0.00	1.00
10/05/2020 06:00	3	1.9	14.6	14.3	34.6	690,314.4	0.00	1.00
10/05/2020 07:00	3	1.9	13.8	14.3	33.6	720,815.2	0.00	1.00
10/05/2020 08:00	3	1.9	13.3	14.5	35.3	799,615.5	0.00	1.00
10/05/2020 09:00	2	1.8	10.6	14.5	29.0	926,501.2	0.00	1.00
10/05/2020 10:00	2	1.8	11.8	14.1	35.1	911,674.1	0.00	1.00
10/05/2020 11:00	3	2.2	14.2	13.3	37.7	930,127.5	0.00	1.00
10/05/2020 12:00	3	2.1	13.3	13.5	35.5	917,884.5	0.00	1.00
10/05/2020 13:00	4	2.5	18.1	12.1	50.5	932,764.7	0.00	1.00
10/05/2020 14:00	5	2.6	18.7	11.7	54.6	923,914.9	0.00	1.00
10/05/2020 15:00	5	2.6	18.6	11.7	54.7	921,682.2	0.00	1.00
10/05/2020 16:00	5	2.6	18.7	11.7	55.2	922,426.4	0.00	1.00
10/05/2020 17:00	4	2.5	17.8	12.2	49.4	924,755.0	0.00	1.00
10/05/2020 18:00	3	2.4	16.5	12.7	43.8	922,023.4	0.00	1.00
10/05/2020 19:00	3	2.3	15.6	13.0	41.5	927,048.3	0.00	1.00
10/05/2020 20:00	2	2.1	12.7	13.7	34.1	900,016.1	0.00	1.00
10/05/2020 21:00	2	1.9	10.7	14.5	30.6	909,597.4	0.00	1.00
10/05/2020 22:00	3	1.9	13.3	14.4	36.2	789,420.5	0.00	1.00
10/05/2020 23:00	3	1.9	14.2	14.4	34.4	698,195.8	0.00	1.00
Average/Sum#:	3	2.1	14.7	13.6	38.2	814,998.0	0.00 #	24.00 #
Minimum:	2	1.8	10.6	11.7	29.0	637,210.3	0.00	1.00
Maximum:	5	2.6	18.7	14.5	55.2	932,764.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/06/2020 00:00	3	1.8	13.7	14.5	29.1	636,782.3	0.00	1.00
10/06/2020 01:00	3	1.8	14.0	14.5	29.8	634,856.6	0.00	1.00
10/06/2020 02:00	3	1.9	14.5	14.5	31.4	636,354.4	0.00	1.00
10/06/2020 03:00	3	1.9	14.6	14.5	32.0	636,782.3	0.00	1.00
10/06/2020 04:00	3	1.8	15.1	14.5	32.3	636,354.4	0.00	1.00
10/06/2020 05:00	3	1.9	14.2	14.3	33.5	691,351.8	0.00	1.00
10/06/2020 06:00	3	1.9	14.1	14.3	33.0	699,028.9	0.00	1.00
10/06/2020 07:00	3	1.9	13.4	14.4	33.4	756,554.3	0.00	1.00
10/06/2020 08:00	3	1.8	13.5	14.5	38.3	830,641.5	0.00	1.00
10/06/2020 09:00	2	1.9	11.0	14.5	29.5	889,483.9	0.00	1.00
10/06/2020 10:00	3	1.8	12.9	14.3	37.0	895,935.5	0.00	1.00
10/06/2020 11:00	3	2.1	13.6	13.5	35.8	924,731.6	0.00	1.00
10/06/2020 12:00	2	2.1	12.1	14.0	32.5	868,492.9	0.00	1.00
10/06/2020 13:00	4	2.2	17.2	12.5	46.6	887,191.4	0.00	1.00
10/06/2020 14:00	3	2.3	17.2	12.7	46.2	935,884.7	0.00	1.00
10/06/2020 15:00	4	2.6	18.7	12.1	53.6	937,122.0	0.00	1.00
10/06/2020 16:00	4	2.6	18.6	12.1	53.6	936,188.3	0.00	1.00
10/06/2020 17:00	3	2.4	17.1	12.7	45.6	927,701.5	0.00	1.00
10/06/2020 18:00	3	2.2	15.1	13.3	40.6	937,875.5	0.00	1.00
10/06/2020 19:00	3	2.3	16.2	13.0	43.8	940,395.9	0.00	1.00
10/06/2020 20:00	3	2.3	16.0	13.0	42.4	933,635.4	0.00	1.00
10/06/2020 21:00	2	2.0	11.6	14.4	31.4	916,460.9	0.00	1.00
10/06/2020 22:00	3	1.8	13.9	14.7	39.5	819,004.1	0.00	1.00
10/06/2020 23:00	3	1.8	14.9	14.6	34.8	697,971.7	0.00	1.00
Average/Sum#:	3	2.0	14.7	13.8	37.7	816,949.2	0.00 #	24.00 #
Minimum:	2	1.8	11.0	12.1	29.1	634,856.6	0.00	1.00
Maximum:	4	2.6	18.7	14.7	53.6	940,395.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/07/2020 00:00	3	1.8	14.4	14.7	30.1	655,556.7	0.00	1.00
10/07/2020 01:00	3	1.8	14.3	14.7	30.4	653,127.1	0.00	1.00
10/07/2020 02:00	3	1.8	14.1	14.7	29.9	652,685.3	0.00	1.00
10/07/2020 03:00	3	1.8	13.9	14.7	29.9	653,127.1	0.00	1.00
10/07/2020 04:00	3	1.8	14.5	14.7	31.7	670,355.3	0.00	1.00
10/07/2020 05:00	2	1.8	12.3	14.5	35.3	940,623.4	0.00	1.00
10/07/2020 06:00	2	1.9	12.4	14.4	36.0	928,891.1	0.00	1.00
10/07/2020 07:00	3	1.8	13.4	14.6	35.9	784,267.2	0.00	1.00
10/07/2020 08:00	3	1.8	13.5	14.6	38.3	825,567.3	0.00	1.00
10/07/2020 09:00	2	1.8	12.1	14.7	33.9	880,186.5	0.00	1.00
10/07/2020 10:00	2	1.9	11.1	14.4	30.4	927,205.6	0.00	1.00
10/07/2020 11:00	2	2.0	12.1	14.0	32.9	922,277.6	0.00	1.00
10/07/2020 12:00	2	2.1	13.3	13.7	35.1	934,061.5	0.00	1.00
10/07/2020 13:00	3	2.2	15.2	13.2	41.0	943,302.2	0.00	1.00
10/07/2020 14:00	4	2.6	18.7	12.0	53.3	940,286.8	0.00	1.00
10/07/2020 15:00	4	2.6	18.5	12.1	53.0	940,856.8	0.00	1.00
10/07/2020 16:00	2	2.1	13.0	13.8	34.7	924,457.9	0.00	1.00
10/07/2020 17:00	2	1.9	11.9	14.3	33.2	923,116.5	0.00	1.00
10/07/2020 18:00	2	1.9	11.5	14.4	32.6	917,725.0	0.00	1.00
10/07/2020 19:00	2	1.9	11.4	14.4	32.7	925,309.5	0.00	1.00
10/07/2020 20:00	2	2.0	12.8	13.9	34.3	924,557.1	0.00	1.00
10/07/2020 21:00	3	1.9	13.5	14.6	37.4	811,220.9	0.00	1.00
10/07/2020 22:00	3	1.8	13.9	14.5	31.2	685,996.0	0.00	1.00
10/07/2020 23:00	3	1.8	13.5	14.6	27.3	644,064.2	0.00	1.00
Average/Sum#:	3	2.0	13.6	14.2	35.0	833,701.0	0.00 #	24.00 #
Minimum:	2	1.8	11.1	12.0	27.3	644,064.2	0.00	1.00
Maximum:	4	2.6	18.7	14.7	53.3	943,302.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/08/2020 00:00	3	1.8	13.8	14.6	29.1	643,846.8	0.00	1.00
10/08/2020 01:00	3	1.8	13.8	14.6	29.2	642,977.4	0.00	1.00
10/08/2020 02:00	3	1.8	13.8	14.6	29.2	643,194.7	0.00	1.00
10/08/2020 03:00	3	1.8	13.9	14.6	29.7	643,846.8	0.00	1.00
10/08/2020 04:00	3	2.2	17.0	14.6	27.5	631,891.5	0.10	1.00
10/08/2020 05:00	0	11.3	32.9	16.9	0.0	386,862.4	0.05	0.05
10/08/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/08/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	3	3.5	17.5	15.0	24.1	598,769.9	0.15 #	5.05 #
Minimum:	3	1.8	13.8	14.6	0.0	386,862.4	0.00	0.00
Maximum:	3	11.3	32.9	16.9	29.7	643,846.8	0.10	1.00
%SI	79.17	75.00	75.00	75.00	75.00	75.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/09/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/09/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/10/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2020 15:00	0	13.4	20.7	15.5	3.9	680,654.6	0.77	0.77
10/10/2020 16:00	3	1.9	13.7	14.6	32.8	740,358.6	0.20	1.00
10/10/2020 17:00	2	1.8	10.7	14.7	27.3	910,888.1	0.00	1.00
10/10/2020 18:00	2	1.8	12.6	14.6	34.1	833,609.9	0.00	1.00
10/10/2020 19:00	3	1.8	13.4	14.5	29.1	681,288.6	0.00	1.00
10/10/2020 20:00	2	1.8	10.8	14.6	28.6	886,430.6	0.00	1.00
10/10/2020 21:00	2	1.9	10.7	14.5	28.9	913,448.9	0.00	1.00
10/10/2020 22:00	2	1.8	11.2	14.6	32.2	881,431.1	0.00	1.00
10/10/2020 23:00	2	1.8	11.8	14.6	33.1	872,519.0	0.00	1.00
Average/Sum#:	2	3.1	12.8	14.7	27.8	822,292.2	0.97 #	8.77 #
Minimum:	2	1.8	10.7	14.5	3.9	680,654.6	0.00	0.00
Maximum:	3	13.4	20.7	15.5	34.1	913,448.9	0.77	1.00
%SI	66.67	62.50	62.50	62.50	62.50	62.50	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/11/2020 00:00	3	1.8	12.6	14.5	33.1	796,191.9	0.00	1.00
10/11/2020 01:00	3	1.9	12.9	14.4	30.0	710,204.6	0.00	1.00
10/11/2020 02:00	3	1.9	13.6	14.4	31.5	684,080.1	0.00	1.00
10/11/2020 03:00	3	1.9	13.9	14.4	31.9	676,285.0	0.00	1.00
10/11/2020 04:00	3	1.8	13.9	14.4	32.3	701,356.0	0.00	1.00
10/11/2020 05:00	3	1.8	12.8	14.6	37.3	868,171.6	0.00	1.00
10/11/2020 06:00	2	1.8	11.0	14.7	30.6	912,434.2	0.00	1.00
10/11/2020 07:00	3	1.8	12.9	14.6	36.4	822,306.7	0.00	1.00
10/11/2020 08:00	3	1.8	12.9	14.6	38.4	870,345.3	0.00	1.00
10/11/2020 09:00	2	1.8	11.1	14.7	32.5	913,538.6	0.00	1.00
10/11/2020 10:00	2	1.8	11.3	14.8	33.6	921,106.3	0.00	1.00
10/11/2020 11:00	3	1.8	13.6	14.6	35.3	759,921.8	0.00	1.00
10/11/2020 12:00	3	1.8	13.4	14.6	34.2	742,532.3	0.00	1.00
10/11/2020 13:00	2	1.8	10.9	14.6	30.8	923,165.9	0.00	1.00
10/11/2020 14:00	5	2.4	18.6	12.2	56.2	960,485.9	0.00	1.00
10/11/2020 15:00	3	2.3	16.2	13.1	43.4	955,612.4	0.00	1.00
10/11/2020 16:00	2	1.9	12.4	14.7	35.0	901,390.5	0.00	1.00
10/11/2020 17:00	3	1.8	13.3	14.5	33.0	769,445.3	0.00	1.00
10/11/2020 18:00	3	1.9	13.7	14.5	32.8	717,450.0	0.00	1.00
10/11/2020 19:00	3	1.8	13.9	14.5	30.7	671,231.9	0.00	1.00
10/11/2020 20:00	2	1.8	12.1	14.6	33.8	877,953.2	0.00	1.00
10/11/2020 21:00	2	1.8	11.1	14.6	33.0	939,033.9	0.00	1.00
10/11/2020 22:00	3	1.9	13.9	14.5	42.6	842,837.9	0.00	1.00
10/11/2020 23:00	3	1.9	13.8	14.4	35.0	744,124.1	0.00	1.00
Average/Sum#:	3	1.9	13.2	14.4	35.1	820,050.2	0.00 #	24.00 #
Minimum:	2	1.8	10.9	12.2	30.0	671,231.9	0.00	1.00
Maximum:	5	2.4	18.6	14.8	56.2	960,485.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/12/2020 00:00	3	1.9	14.3	14.4	34.4	701,356.0	0.00	1.00
10/12/2020 01:00	3	1.9	14.9	14.4	35.0	675,863.6	0.00	1.00
10/12/2020 02:00	3	1.9	14.4	14.5	32.5	662,245.1	0.00	1.00
10/12/2020 03:00	3	1.8	14.4	14.5	33.2	672,087.8	0.00	1.00
10/12/2020 04:00	3	1.8	13.9	14.5	34.4	771,799.0	0.00	1.00
10/12/2020 05:00	2	1.8	12.4	14.3	38.4	909,422.3	0.00	1.00
10/12/2020 06:00	3	2.0	13.8	13.9	39.6	946,467.9	0.00	1.00
10/12/2020 07:00	3	2.0	13.6	13.9	38.7	946,663.5	0.00	1.00
10/12/2020 08:00	3	2.0	13.4	14.1	39.9	955,777.7	0.00	1.00
10/12/2020 09:00	3	2.0	13.8	14.1	39.8	943,694.5	0.00	1.00
10/12/2020 10:00	3	2.0	13.8	13.9	38.6	930,034.8	0.00	1.00
10/12/2020 11:00	3	1.9	12.2	14.6	34.9	888,386.9	0.00	1.00
10/12/2020 12:00	2	1.8	10.6	14.7	30.2	940,485.3	0.00	1.00
10/12/2020 13:00	4	2.3	17.6	12.7	51.3	961,603.1	0.00	1.00
10/12/2020 14:00	5	2.6	19.9	11.9	58.7	951,141.3	0.00	1.00
10/12/2020 15:00	5	2.6	19.8	11.9	58.5	946,120.1	0.00	1.00
10/12/2020 16:00	2	1.9	13.0	14.4	32.8	853,888.8	0.00	1.00
10/12/2020 17:00	3	1.8	12.9	14.6	35.6	855,781.6	0.00	1.00
10/12/2020 18:00	3	1.8	13.2	14.6	36.3	837,522.6	0.00	1.00
10/12/2020 19:00	3	1.9	12.6	14.5	29.8	737,563.4	0.00	1.00
10/12/2020 20:00	3	1.8	13.3	14.6	38.8	823,611.0	0.00	1.00
10/12/2020 21:00	3	1.8	13.6	14.6	34.0	758,182.9	0.00	1.00
10/12/2020 22:00	2	1.8	11.3	14.7	31.9	915,747.3	0.00	1.00
10/12/2020 23:00	2	1.9	10.8	14.5	32.4	943,833.0	0.00	1.00
Average/Sum#:	3	2.0	13.9	14.1	37.9	855,386.6	0.00 #	24.00 #
Minimum:	2	1.8	10.6	11.9	29.8	662,245.1	0.00	1.00
Maximum:	5	2.6	19.9	14.7	58.7	961,603.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/13/2020 00:00	2	1.8	10.9	14.6	32.4	917,949.1	0.00	1.00
10/13/2020 01:00	2	1.8	11.0	14.6	32.8	925,991.7	0.00	1.00
10/13/2020 02:00	2	1.8	10.9	14.6	32.7	939,903.3	0.00	1.00
10/13/2020 03:00	2	1.8	10.9	14.6	34.0	959,466.5	0.00	1.00
10/13/2020 04:00	2	1.8	12.0	14.6	36.1	925,339.6	0.00	1.00
10/13/2020 05:00	5	2.5	18.5	12.0	66.0	995,371.5	0.00	1.00
10/13/2020 06:00	6	2.6	18.7	11.8	64.5	988,393.3	0.00	1.00
10/13/2020 07:00	6	2.6	20.1	11.9	65.8	975,182.3	0.00	1.00
10/13/2020 08:00	3	2.1	15.7	13.8	39.6	774,207.0	0.00	1.00
10/13/2020 09:00	3	1.8	14.0	14.5	29.5	660,319.3	0.00	1.00
10/13/2020 10:00	2	1.9	11.7	14.3	32.2	926,851.3	0.00	1.00
10/13/2020 11:00	3	2.1	14.8	13.3	40.3	946,344.3	0.00	1.00
10/13/2020 12:00	3	2.2	15.4	13.2	41.7	945,792.1	0.00	1.00
10/13/2020 13:00	3	2.2	15.7	13.1	41.9	938,231.3	0.00	1.00
10/13/2020 14:00	3	2.1	13.9	13.6	36.6	934,397.7	0.00	1.00
10/13/2020 15:00	2	2.0	13.1	13.8	34.4	923,107.8	0.00	1.00
10/13/2020 16:00	2	2.1	13.7	13.6	36.0	925,393.2	0.00	1.00
10/13/2020 17:00	2	2.0	13.0	13.9	34.0	936,295.0	0.00	1.00
10/13/2020 18:00	2	1.9	12.0	14.2	31.9	923,237.3	0.00	1.00
10/13/2020 19:00	2	1.8	11.0	14.7	31.7	902,274.0	0.00	1.00
10/13/2020 20:00	2	1.9	12.6	14.0	33.2	942,124.3	0.00	1.00
10/13/2020 21:00	2	1.9	11.2	14.6	32.5	889,473.7	0.00	1.00
10/13/2020 22:00	3	1.8	12.7	14.5	33.3	780,999.8	0.00	1.00
10/13/2020 23:00	3	1.8	13.5	14.5	29.3	657,109.7	0.00	1.00
Average/Sum#:	3	2.0	13.6	13.8	38.4	901,406.5	0.00 #	24.00 #
Minimum:	2	1.8	10.9	11.8	29.3	657,109.7	0.00	1.00
Maximum:	6	2.6	20.1	14.7	66.0	995,371.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/14/2020 00:00	3	1.8	13.8	14.6	29.8	646,020.5	0.00	1.00
10/14/2020 01:00	3	1.8	13.8	14.6	30.1	647,107.4	0.00	1.00
10/14/2020 02:00	3	1.8	13.9	14.7	30.4	655,556.7	0.00	1.00
10/14/2020 03:00	3	1.8	13.9	14.7	30.5	656,882.0	0.00	1.00
10/14/2020 04:00	3	1.8	14.3	14.6	30.9	659,497.4	0.00	1.00
10/14/2020 05:00	3	1.8	14.2	14.5	34.4	703,113.8	0.00	1.00
10/14/2020 06:00	3	1.9	14.1	14.5	33.0	703,113.8	0.00	1.00
10/14/2020 07:00	3	1.8	13.7	14.5	32.1	713,384.5	0.00	1.00
10/14/2020 08:00	3	1.8	12.9	14.6	32.1	770,138.2	0.00	1.00
10/14/2020 09:00	2	1.8	12.0	14.7	32.8	882,616.1	0.00	1.00
10/14/2020 10:00	2	1.8	10.5	14.6	29.2	922,513.8	0.00	1.00
10/14/2020 11:00	2	1.9	11.4	14.3	31.8	932,661.0	0.00	1.00
10/14/2020 12:00	2	2.0	13.0	13.8	34.4	927,736.8	0.00	1.00
10/14/2020 13:00	3	2.2	15.3	13.2	40.5	940,812.3	0.00	1.00
10/14/2020 14:00	4	2.6	18.9	12.0	53.9	939,979.1	0.00	1.00
10/14/2020 15:00	5	2.6	19.0	11.9	55.1	929,534.8	0.00	1.00
10/14/2020 16:00	4	2.5	18.3	12.4	50.6	942,164.0	0.00	1.00
10/14/2020 17:00	3	2.3	16.6	13.0	44.0	944,902.8	0.00	1.00
10/14/2020 18:00	3	2.2	15.6	13.2	41.5	938,322.5	0.00	1.00
10/14/2020 19:00	3	1.9	13.1	14.6	35.2	826,871.5	0.00	1.00
10/14/2020 20:00	2	1.9	12.0	14.2	32.5	924,872.4	0.00	1.00
10/14/2020 21:00	2	1.8	11.8	14.7	35.0	904,261.8	0.00	1.00
10/14/2020 22:00	3	1.8	13.2	14.6	33.8	794,918.2	0.00	1.00
10/14/2020 23:00	3	1.9	13.7	14.5	32.1	706,323.4	0.00	1.00
Average/Sum#:	3	2.0	14.1	14.0	36.1	817,221.0	0.00 #	24.00 #
Minimum:	2	1.8	10.5	11.9	29.2	646,020.5	0.00	1.00
Maximum:	5	2.6	19.0	14.7	55.1	944,902.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/15/2020 00:00	3	1.8	14.3	14.7	31.1	656,661.1	0.00	1.00
10/15/2020 01:00	3	1.8	14.2	14.7	31.0	653,568.8	0.00	1.00
10/15/2020 02:00	3	1.8	14.4	14.7	31.9	655,115.0	0.00	1.00
10/15/2020 03:00	3	1.8	14.7	14.7	32.8	656,440.2	0.00	1.00
10/15/2020 04:00	3	1.8	15.3	14.7	33.0	660,416.0	0.00	1.00
10/15/2020 05:00	4	1.8	15.7	14.5	38.0	679,148.9	0.00	1.00
10/15/2020 06:00	3	1.8	13.8	14.6	34.4	774,702.9	0.00	1.00
10/15/2020 07:00	3	1.8	13.8	14.6	38.2	816,655.1	0.00	1.00
10/15/2020 08:00	2	1.8	14.1	14.5	24.3	577,298.0	0.02	0.05
10/15/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2020 15:00	3	6.1	22.0	15.8	12.2	712,369.2	0.65	0.67
10/15/2020 16:00	4	2.2	18.4	12.8	48.6	960,456.8	0.00	1.00
10/15/2020 17:00	3	2.4	17.9	12.7	46.7	932,544.6	0.00	1.00
10/15/2020 18:00	3	2.2	16.1	13.3	42.3	941,299.1	0.00	1.00
10/15/2020 19:00	2	1.9	11.5	14.5	31.0	893,549.4	0.00	1.00
10/15/2020 20:00	2	1.9	13.0	14.0	35.0	940,139.6	0.00	1.00
10/15/2020 21:00	3	1.9	13.6	14.6	38.2	840,131.0	0.00	1.00
10/15/2020 22:00	3	1.9	14.0	14.5	32.3	715,952.2	0.00	1.00
10/15/2020 23:00	3	1.8	14.9	14.6	34.0	688,190.1	0.00	1.00
Average/Sum#:	3	2.1	15.1	14.4	34.2	764,146.6	0.67 #	16.72 #
Minimum:	2	1.8	11.5	12.7	12.2	577,298.0	0.00	0.00
Maximum:	4	6.1	22.0	15.8	48.6	960,456.8	0.65	1.00
%SI	25.00	25.00	25.00	25.00	25.00	25.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/16/2020 00:00	3	1.8	14.4	14.7	30.9	654,894.1	0.00	1.00
10/16/2020 01:00	3	1.8	14.4	14.7	31.4	653,789.7	0.00	1.00
10/16/2020 02:00	3	1.8	14.3	14.7	31.6	653,127.1	0.00	1.00
10/16/2020 03:00	3	1.8	14.6	14.7	32.2	653,348.0	0.00	1.00
10/16/2020 04:00	3	1.8	15.6	14.6	34.9	668,626.9	0.00	1.00
10/16/2020 05:00	3	1.9	15.4	14.5	36.7	683,856.3	0.00	1.00
10/16/2020 06:00	3	1.8	15.0	14.5	35.0	691,131.4	0.00	1.00
10/16/2020 07:00	3	1.8	15.2	14.5	36.5	687,065.9	0.00	1.00
10/16/2020 08:00	3	1.8	13.9	14.6	35.0	759,704.5	0.00	1.00
10/16/2020 09:00	3	1.8	14.2	14.7	40.1	833,581.9	0.00	1.00
10/16/2020 10:00	3	1.8	14.2	14.8	40.2	847,247.2	0.00	1.00
10/16/2020 11:00	3	1.7	13.9	14.8	37.9	826,593.5	0.00	1.00
10/16/2020 12:00	2	1.9	11.9	14.3	31.3	940,130.6	0.00	1.00
10/16/2020 13:00	3	2.1	14.4	13.4	38.0	932,304.1	0.00	1.00
10/16/2020 14:00	3	2.3	17.1	12.8	44.6	937,464.0	0.00	1.00
10/16/2020 15:00	4	2.5	19.1	12.1	53.3	939,456.3	0.00	1.00
10/16/2020 16:00	4	2.5	19.0	12.1	53.7	940,234.3	0.00	1.00
10/16/2020 17:00	4	2.4	18.2	12.5	49.1	940,827.2	0.00	1.00
10/16/2020 18:00	3	2.3	15.8	13.2	41.9	941,168.0	0.00	1.00
10/16/2020 19:00	3	2.2	15.6	13.2	40.7	940,100.9	0.00	1.00
10/16/2020 20:00	2	2.1	12.9	13.9	34.6	927,100.3	0.00	1.00
10/16/2020 21:00	2	1.8	11.5	14.8	33.3	909,881.5	0.00	1.00
10/16/2020 22:00	3	1.8	13.8	14.6	35.8	786,006.1	0.00	1.00
10/16/2020 23:00	3	1.8	13.8	14.5	33.7	730,930.3	0.00	1.00
Average/Sum#:	3	2.0	14.9	14.1	38.0	811,607.1	0.00 #	24.00 #
Minimum:	2	1.7	11.5	12.1	30.9	653,127.1	0.00	1.00
Maximum:	4	2.5	19.1	14.8	53.7	941,168.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/17/2020 00:00	3	1.8	14.4	14.7	31.4	664,170.8	0.00	1.00
10/17/2020 01:00	3	1.8	14.3	14.7	30.7	652,906.2	0.00	1.00
10/17/2020 02:00	3	1.8	14.7	14.6	31.9	645,585.8	0.00	1.00
10/17/2020 03:00	3	1.8	14.8	14.6	32.2	645,803.1	0.00	1.00
10/17/2020 04:00	3	1.8	15.0	14.7	31.8	656,440.2	0.00	1.00
10/17/2020 05:00	3	1.8	15.1	14.5	35.0	668,878.2	0.00	1.00
10/17/2020 06:00	3	1.8	14.3	14.6	31.3	665,366.4	0.00	1.00
10/17/2020 07:00	3	1.8	14.7	14.5	34.8	703,541.8	0.00	1.00
10/17/2020 08:00	3	1.8	13.8	14.6	36.3	789,484.0	0.00	1.00
10/17/2020 09:00	3	1.7	13.6	14.8	38.2	873,513.2	0.00	1.00
10/17/2020 10:00	2	1.8	12.1	14.8	34.7	905,167.1	0.00	1.00
10/17/2020 11:00	2	1.8	11.7	14.8	32.4	903,371.1	0.00	1.00
10/17/2020 12:00	2	1.8	10.6	14.7	28.6	913,538.6	0.00	1.00
10/17/2020 13:00	2	1.9	12.4	14.1	35.0	930,604.4	0.00	1.00
10/17/2020 14:00	5	2.5	19.6	12.2	54.0	906,653.4	0.00	1.00
10/17/2020 15:00	4	2.4	19.0	12.6	47.6	858,282.6	0.00	1.00
10/17/2020 16:00	4	2.4	18.0	12.7	45.5	881,942.7	0.00	1.00
10/17/2020 17:00	2	2.2	14.4	13.5	36.9	931,023.5	0.00	1.00
10/17/2020 18:00	2	1.9	11.5	14.4	32.6	917,514.3	0.00	1.00
10/17/2020 19:00	3	2.3	16.9	12.9	43.9	950,380.5	0.00	1.00
10/17/2020 20:00	2	2.1	12.9	13.8	34.9	923,300.6	0.00	1.00
10/17/2020 21:00	2	1.9	11.2	14.7	32.1	904,703.6	0.00	1.00
10/17/2020 22:00	3	1.8	14.1	14.6	37.7	793,396.7	0.00	1.00
10/17/2020 23:00	3	1.8	14.0	14.6	32.8	720,360.7	0.00	1.00
Average/Sum#:	3	1.9	14.3	14.2	35.9	808,580.4	0.00 #	24.00 #
Minimum:	2	1.7	10.6	12.2	28.6	645,585.8	0.00	1.00
Maximum:	5	2.5	19.6	14.8	54.0	950,380.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/18/2020 00:00	3	1.8	14.9	14.6	34.3	690,581.2	0.00	1.00
10/18/2020 01:00	3	1.8	14.5	14.7	30.6	653,348.0	0.00	1.00
10/18/2020 02:00	3	1.8	14.3	14.6	30.8	646,890.0	0.00	1.00
10/18/2020 03:00	3	1.8	14.3	14.6	30.6	644,064.2	0.00	1.00
10/18/2020 04:00	3	1.8	15.0	14.6	32.5	651,020.0	0.00	1.00
10/18/2020 05:00	3	1.8	15.0	14.6	34.8	664,062.1	0.00	1.00
10/18/2020 06:00	3	1.8	14.8	14.6	33.3	666,887.9	0.00	1.00
10/18/2020 07:00	3	1.8	14.8	14.5	34.8	695,196.8	0.00	1.00
10/18/2020 08:00	3	1.8	13.5	14.6	33.9	762,095.5	0.00	1.00
10/18/2020 09:00	2	1.7	13.1	14.8	36.4	882,942.0	0.00	1.00
10/18/2020 10:00	2	1.9	11.3	14.4	30.4	940,267.9	0.00	1.00
10/18/2020 11:00	2	1.9	11.6	14.3	31.8	936,603.3	0.00	1.00
10/18/2020 12:00	2	1.9	11.4	14.4	32.4	933,104.7	0.00	1.00
10/18/2020 13:00	2	1.9	12.6	14.0	33.9	931,804.0	0.00	1.00
10/18/2020 14:00	3	2.2	15.0	13.2	39.4	935,832.6	0.00	1.00
10/18/2020 15:00	3	2.4	17.8	12.5	46.1	934,958.2	0.00	1.00
10/18/2020 16:00	2	2.1	13.0	13.8	34.8	931,015.7	0.00	1.00
10/18/2020 17:00	2	1.9	11.0	14.5	30.2	901,680.4	0.00	1.00
10/18/2020 18:00	3	1.8	13.2	14.6	37.5	838,609.4	0.00	1.00
10/18/2020 19:00	3	1.8	13.1	14.6	35.8	841,435.2	0.00	1.00
10/18/2020 20:00	2	2.0	12.7	14.1	32.9	928,993.3	0.00	1.00
10/18/2020 21:00	3	1.8	12.6	14.6	35.9	864,693.7	0.00	1.00
10/18/2020 22:00	3	1.9	13.1	14.5	30.3	737,349.4	0.00	1.00
10/18/2020 23:00	3	1.8	14.2	14.5	30.9	668,878.2	0.00	1.00
Average/Sum#:	3	1.9	13.6	14.3	33.9	803,429.7	0.00 #	24.00 #
Minimum:	2	1.7	11.0	12.5	30.2	644,064.2	0.00	1.00
Maximum:	3	2.4	17.8	14.8	46.1	940,267.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/19/2020 00:00	3	1.8	13.9	14.6	28.9	647,542.1	0.00	1.00
10/19/2020 01:00	3	1.8	14.3	14.6	30.7	654,715.3	0.00	1.00
10/19/2020 02:00	3	1.8	14.3	14.6	30.8	646,020.5	0.00	1.00
10/19/2020 03:00	3	1.8	14.5	14.6	31.8	649,715.8	0.00	1.00
10/19/2020 04:00	3	1.8	14.5	14.6	31.8	672,104.8	0.00	1.00
10/19/2020 05:00	3	1.8	13.9	14.5	34.8	717,664.0	0.00	1.00
10/19/2020 06:00	3	1.8	14.0	14.5	36.5	729,646.4	0.00	1.00
10/19/2020 07:00	3	1.6	13.9	14.6	35.8	783,615.1	0.00	1.00
10/19/2020 08:00	3	1.6	13.5	14.6	38.2	820,785.2	0.00	1.00
10/19/2020 09:00	2	1.6	10.4	14.6	29.1	922,731.2	0.00	1.00
10/19/2020 10:00	2	1.7	11.3	14.3	33.4	942,205.5	0.00	1.00
10/19/2020 11:00	2	1.7	12.7	13.9	35.3	941,381.4	0.00	1.00
10/19/2020 12:00	2	1.8	13.3	13.8	36.7	946,060.1	0.00	1.00
10/19/2020 13:00	3	1.9	14.1	13.4	38.7	935,590.7	0.00	1.00
10/19/2020 14:00	3	2.0	15.8	13.0	43.9	944,556.1	0.00	1.00
10/19/2020 15:00	4	2.3	18.5	12.0	53.5	934,747.5	0.00	1.00
10/19/2020 16:00	4	2.1	17.7	12.5	48.8	942,946.5	0.00	1.00
10/19/2020 17:00	3	2.1	15.4	13.2	39.3	944,725.0	0.00	1.00
10/19/2020 18:00	2	2.1	12.9	13.9	32.7	934,730.0	0.00	1.00
10/19/2020 19:00	3	1.9	12.7	14.6	35.4	853,825.2	0.00	1.00
10/19/2020 20:00	2	1.9	11.9	14.2	30.2	930,391.0	0.00	1.00
10/19/2020 21:00	3	1.9	12.5	14.7	35.8	877,756.9	0.00	1.00
10/19/2020 22:00	3	1.8	14.2	14.5	33.6	729,646.4	0.00	1.00
10/19/2020 23:00	3	1.8	14.5	14.5	32.9	678,507.0	0.00	1.00
Average/Sum#:	3	1.9	13.9	14.1	35.8	824,233.7	0.00 #	24.00 #
Minimum:	2	1.6	10.4	12.0	28.9	646,020.5	0.00	1.00
Maximum:	4	2.3	18.5	14.7	53.5	946,060.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOX, Ppm	Unit CT1 NOX, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/20/2020 00:00	2	1.8	13.9	14.6	28.2	649,715.8	0.00	1.00
10/20/2020 01:00	3	1.8	13.8	14.6	29.6	645,368.4	0.00	1.00
10/20/2020 02:00	3	1.8	13.7	14.6	29.0	643,629.5	0.00	1.00
10/20/2020 03:00	3	1.8	14.4	14.6	31.3	646,237.9	0.00	1.00
10/20/2020 04:00	3	1.8	14.7	14.6	31.5	667,105.3	0.00	1.00
10/20/2020 05:00	3	1.9	14.1	14.5	33.0	703,969.7	0.00	1.00
10/20/2020 06:00	3	1.9	14.1	14.5	32.1	703,541.8	0.00	1.00
10/20/2020 07:00	3	1.9	14.2	14.5	32.5	698,834.4	0.00	1.00
10/20/2020 08:00	3	1.8	13.2	14.6	32.3	768,834.0	0.00	1.00
10/20/2020 09:00	2	1.8	11.7	14.8	32.1	916,391.9	0.00	1.00
10/20/2020 10:00	2	1.9	11.7	14.3	31.0	927,058.8	0.00	1.00
10/20/2020 11:00	2	2.1	14.2	13.4	36.9	948,189.4	0.00	1.00
10/20/2020 12:00	3	2.2	14.8	13.3	38.6	950,128.3	0.00	1.00
10/20/2020 13:00	4	2.5	18.4	12.2	49.5	946,319.5	0.00	1.00
10/20/2020 14:00	4	2.6	18.7	12.1	51.7	946,459.0	0.00	1.00
10/20/2020 15:00	4	2.5	18.4	12.2	50.5	941,912.1	0.00	1.00
10/20/2020 16:00	2	2.1	13.4	13.7	34.8	931,398.8	0.00	1.00
10/20/2020 17:00	2	2.0	11.7	14.3	30.9	902,575.2	0.00	1.00
10/20/2020 18:00	2	1.8	10.6	14.7	29.3	927,453.7	0.00	1.00
10/20/2020 19:00	2	2.0	13.0	13.8	34.9	932,751.6	0.00	1.00
10/20/2020 20:00	2	1.9	10.5	14.6	28.8	922,948.6	0.00	1.00
10/20/2020 21:00	3	1.9	13.1	14.5	33.4	788,488.9	0.00	1.00
10/20/2020 22:00	3	1.9	13.8	14.4	30.8	685,976.3	0.00	1.00
10/20/2020 23:00	3	1.8	13.6	14.6	27.5	646,455.3	0.00	1.00
Average/Sum#:	3	2.0	13.9	14.1	34.2	810,072.7	0.00 #	24.00 #
Minimum:	2	1.8	10.5	12.1	27.5	643,629.5	0.00	1.00
Maximum:	4	2.6	18.7	14.8	51.7	950,128.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/21/2020 00:00	3	1.8	13.7	14.7	28.4	652,906.2	0.00	1.00
10/21/2020 01:00	3	1.8	13.9	14.6	29.1	644,281.6	0.00	1.00
10/21/2020 02:00	3	1.8	14.3	14.6	30.8	645,151.0	0.00	1.00
10/21/2020 03:00	3	1.8	14.3	14.6	30.8	644,716.3	0.00	1.00
10/21/2020 04:00	3	1.8	14.8	14.6	31.4	650,150.5	0.00	1.00
10/21/2020 05:00	3	1.8	13.8	14.6	35.5	800,352.5	0.00	1.00
10/21/2020 06:00	3	1.8	13.8	14.6	35.7	807,308.3	0.00	1.00
10/21/2020 07:00	3	1.8	14.2	14.6	30.0	650,150.5	0.00	1.00
10/21/2020 08:00	3	1.8	14.8	14.6	33.1	675,148.0	0.00	1.00
10/21/2020 09:00	3	1.8	13.9	14.6	32.2	718,187.0	0.00	1.00
10/21/2020 10:00	3	1.8	13.3	14.7	32.5	773,062.2	0.00	1.00
10/21/2020 11:00	2	1.8	12.4	14.6	32.6	850,999.4	0.00	1.00
10/21/2020 12:00	2	1.8	11.0	14.7	28.5	905,808.0	0.00	1.00
10/21/2020 13:00	2	1.9	11.3	14.3	31.1	923,739.0	0.00	1.00
10/21/2020 14:00	2	2.1	13.4	13.6	33.7	931,959.0	0.00	1.00
10/21/2020 15:00	2	1.9	11.8	14.6	31.9	866,432.6	0.00	1.00
10/21/2020 16:00	2	1.8	12.5	14.6	33.5	847,521.5	0.00	1.00
10/21/2020 17:00	2	1.8	12.9	14.6	34.0	831,001.5	0.00	1.00
10/21/2020 18:00	3	1.8	13.4	14.6	31.8	742,315.0	0.00	1.00
10/21/2020 19:00	3	1.8	14.0	14.7	30.2	658,869.8	0.00	1.00
10/21/2020 20:00	3	1.8	14.4	14.6	31.5	662,975.3	0.00	1.00
10/21/2020 21:00	2	1.8	13.2	14.6	31.6	770,138.2	0.00	1.00
10/21/2020 22:00	3	1.8	14.5	14.6	32.1	676,234.8	0.00	1.00
10/21/2020 23:00	3	1.8	14.1	14.6	29.2	648,628.9	0.00	1.00
Average/Sum#:	3	1.8	13.5	14.6	31.7	749,084.9	0.00 #	24.00 #
Minimum:	2	1.8	11.0	13.6	28.4	644,281.6	0.00	1.00
Maximum:	3	2.1	14.8	14.7	35.7	931,959.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOX, Ppm	Unit CT1 NOX, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/22/2020 00:00	3	1.8	14.0	14.6	29.2	645,585.8	0.00	1.00
10/22/2020 01:00	3	1.8	14.0	14.6	29.6	643,412.1	0.00	1.00
10/22/2020 02:00	3	1.8	14.3	14.6	31.0	644,498.9	0.00	1.00
10/22/2020 03:00	3	1.8	14.3	14.6	30.6	644,716.3	0.00	1.00
10/22/2020 04:00	3	1.8	14.6	14.6	31.3	663,844.8	0.00	1.00
10/22/2020 05:00	2	1.8	11.1	14.6	30.9	946,424.4	0.00	1.00
10/22/2020 06:00	2	1.9	11.5	14.6	33.4	941,207.6	0.00	1.00
10/22/2020 07:00	3	1.8	13.9	14.5	35.7	761,314.4	0.00	1.00
10/22/2020 08:00	3	1.8	14.1	14.6	39.2	806,438.8	0.00	1.00
10/22/2020 09:00	2	1.7	12.5	14.8	36.5	908,983.5	0.00	1.00
10/22/2020 10:00	3	1.7	13.1	14.8	39.0	897,983.2	0.00	1.00
10/22/2020 11:00	2	1.7	12.1	14.8	35.6	919,759.3	0.00	1.00
10/22/2020 12:00	2	1.7	10.7	14.7	30.6	957,713.6	0.00	1.00
10/22/2020 13:00	2	1.7	10.7	14.7	31.2	957,934.4	0.00	1.00
10/22/2020 14:00	2	1.8	11.3	14.4	32.5	933,526.1	0.00	1.00
10/22/2020 15:00	3	1.8	13.2	14.6	37.4	845,565.2	0.00	1.00
10/22/2020 16:00	2	1.8	11.2	14.5	31.2	924,361.5	0.00	1.00
10/22/2020 17:00	2	1.9	11.5	14.3	32.8	944,280.4	0.00	1.00
10/22/2020 18:00	3	1.8	13.2	14.6	38.8	873,605.8	0.00	1.00
10/22/2020 19:00	3	1.8	13.7	14.6	39.3	868,606.3	0.00	1.00
10/22/2020 20:00	3	1.8	13.4	14.7	38.8	887,696.2	0.00	1.00
10/22/2020 21:00	3	1.8	15.5	14.5	36.6	696,908.6	0.00	1.00
10/22/2020 22:00	3	1.8	15.3	14.7	32.9	656,661.1	0.00	1.00
10/22/2020 23:00	3	1.8	15.5	14.7	34.3	655,777.6	0.00	1.00
Average/Sum#:	3	1.8	13.1	14.6	34.1	817,783.6	0.00 #	24.00 #
Minimum:	2	1.7	10.7	14.3	29.2	643,412.1	0.00	1.00
Maximum:	3	1.9	15.5	14.8	39.3	957,934.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/23/2020 00:00	3	1.8	15.7	14.7	34.8	654,010.6	0.00	1.00
10/23/2020 01:00	3	1.8	15.5	14.7	34.4	655,335.8	0.00	1.00
10/23/2020 02:00	3	1.8	15.7	14.7	35.1	655,998.5	0.00	1.00
10/23/2020 03:00	3	1.8	15.8	14.7	35.3	655,335.8	0.00	1.00
10/23/2020 04:00	3	1.7	16.4	14.6	36.3	648,194.2	0.00	1.00
10/23/2020 05:00	3	1.9	15.7	14.5	36.4	674,013.6	0.00	1.00
10/23/2020 06:00	3	1.9	15.5	14.5	36.0	695,196.8	0.00	1.00
10/23/2020 07:00	3	1.8	14.7	14.5	34.7	715,952.2	0.00	1.00
10/23/2020 08:00	3	1.8	14.1	14.5	35.0	753,825.3	0.00	1.00
10/23/2020 09:00	3	1.8	14.1	14.6	35.9	764,051.9	0.00	1.00
10/23/2020 10:00	3	1.8	14.0	14.6	34.5	738,402.3	0.00	1.00
10/23/2020 11:00	2	1.8	13.1	14.8	36.2	873,962.2	0.00	1.00
10/23/2020 12:00	2	1.8	12.0	14.8	33.8	908,759.0	0.00	1.00
10/23/2020 13:00	2	1.8	11.5	14.4	31.6	932,472.7	0.00	1.00
10/23/2020 14:00	2	1.9	11.3	14.4	32.5	944,902.8	0.00	1.00
10/23/2020 15:00	2	1.9	11.4	14.4	32.7	939,214.4	0.00	1.00
10/23/2020 16:00	3	1.8	13.5	14.6	36.4	819,046.2	0.00	1.00
10/23/2020 17:00	2	1.9	12.6	14.1	33.7	938,458.5	0.00	1.00
10/23/2020 18:00	3	1.9	13.5	14.5	33.0	741,628.9	0.00	1.00
10/23/2020 19:00	3	1.8	14.1	14.5	30.9	679,790.8	0.00	1.00
10/23/2020 20:00	3	1.8	12.9	14.6	33.6	826,002.0	0.00	1.00
10/23/2020 21:00	3	1.9	13.0	14.4	29.3	718,421.1	0.00	1.00
10/23/2020 22:00	3	2.0	14.9	14.6	26.3	642,325.2	0.08	1.00
10/23/2020 23:00	0	11.6	34.5	16.7	0.0	404,632.3	0.07	0.07
Average/Sum#:	3	2.2	14.8	14.6	32.4	749,163.9	0.15 #	23.07 #
Minimum:	2	1.7	11.3	14.1	0.0	404,632.3	0.00	0.07
Maximum:	3	11.6	34.5	16.7	36.4	944,902.8	0.08	1.00
%SI	4.17	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/24/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/24/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/24/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/24/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/24/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/24/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/24/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/24/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/24/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/24/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/24/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/24/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/24/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/24/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/24/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/24/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/24/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/24/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/24/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/24/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/24/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/24/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/24/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/24/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/25/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/25/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/25/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/25/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/25/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/25/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/25/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/25/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/25/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/25/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/25/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/25/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/25/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/25/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/25/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/25/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/25/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/25/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/25/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/25/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/25/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/25/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/25/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/25/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/26/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/26/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/27/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/27/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/28/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/28/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/29/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/29/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/29/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/29/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/29/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/29/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/29/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/29/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/29/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/29/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/29/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/29/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/29/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/29/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/29/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/29/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/29/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/29/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/29/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/29/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/29/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/29/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/29/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/29/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/30/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/30/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/30/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/30/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/30/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/30/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/30/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/30/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/30/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/30/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/30/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/30/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/30/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/30/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/30/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/30/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/30/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/30/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/30/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/30/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/30/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/30/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/30/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/30/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/31/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/31/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/01/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/01/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/02/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/02/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/03/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/03/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/04/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/04/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/05/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/05/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/05/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/05/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/05/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/05/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/05/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/05/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/05/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/05/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/05/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/05/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/05/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/05/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/05/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/05/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/05/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/05/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/05/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/05/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/05/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/05/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/05/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/05/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/06/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/06/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/06/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/06/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/06/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/06/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/06/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/06/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/06/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/06/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/06/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/06/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/06/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/06/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/06/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/06/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/06/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/06/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/06/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/06/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/06/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/06/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/06/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/06/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/07/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/07/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/07/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/07/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/07/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/07/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/07/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/07/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/07/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/07/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/07/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/07/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/07/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/07/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/07/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/07/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/07/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/07/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/07/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/07/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/07/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/07/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/07/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/07/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/08/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/08/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/09/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/09/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/10/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/10/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/11/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/11/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/12/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/12/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/13/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/13/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/13/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/13/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/13/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/13/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/13/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/13/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/13/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/13/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/13/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/13/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/13/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/13/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/13/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/13/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/13/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/13/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/13/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/13/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/13/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/13/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/13/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/13/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/14/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/14/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/14/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/14/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/14/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/14/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/14/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/14/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/14/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/14/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/14/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/14/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/14/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/14/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/14/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/14/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/14/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/14/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/14/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/14/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/14/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/14/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/14/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/14/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/15/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/15/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/16/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/16/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/17/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/17/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/18/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/18/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/19/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/20/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/20/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/21/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/21/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/21/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/21/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/21/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/21/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/21/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/21/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/21/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/21/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/21/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/21/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/21/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/21/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/21/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/21/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/21/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/21/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/21/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/21/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/21/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/21/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/21/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/21/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/22/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/22/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/22/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/22/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/22/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/22/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/22/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/22/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/22/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/22/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/22/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/22/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/22/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/22/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/22/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/22/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/22/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/22/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/22/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/22/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/22/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/22/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/22/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/22/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/23/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/23/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/24/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/24/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/25/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/25/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/26/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/27/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/28/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/29/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/30/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/01/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/02/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/03/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/04/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/05/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/06/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/07/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/08/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/09/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/10/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/11/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/12/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/13/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/14/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/15/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/16/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/17/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/18/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/19/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/20/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/21/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/22/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2020 17:00	0	15.2	22.3	15.8	0.0	649,805.3	0.57	0.57
12/22/2020 18:00	3	3.1	12.9	14.4	33.9	835,980.9	0.42	1.00
12/22/2020 19:00	2	1.8	12.7	14.5	34.1	951,963.9	0.00	1.00
12/22/2020 20:00	0	9.5	38.6	15.6	2.0	507,203.8	0.15	0.15
12/22/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	3	7.4	21.6	15.1	17.5	736,238.5	1.14 #	2.72 #
Minimum:	2	1.8	12.7	14.4	0.0	507,203.8	0.00	0.00
Maximum:	3	15.2	38.6	15.8	34.1	951,963.9	0.57	1.00
%SI	91.67	83.33	83.33	83.33	83.33	83.33	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/23/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/24/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/25/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/26/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/27/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/28/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/29/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/30/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:35 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/31/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/01/2020 00:00	1	1.8	15.1	14.6	26.9	749,270.8	0.00	1.00
10/01/2020 01:00	1	1.8	15.4	14.6	25.6	710,796.5	0.00	1.00
10/01/2020 02:00	1	1.8	15.0	14.6	26.0	726,881.8	0.00	1.00
10/01/2020 03:00	1	1.8	15.1	14.6	26.6	733,620.2	0.00	1.00
10/01/2020 04:00	1	1.8	15.7	14.6	26.7	726,447.0	0.00	1.00
10/01/2020 05:00	1	1.8	16.4	14.6	26.6	613,415.2	0.00	1.00
10/01/2020 06:00	1	1.8	16.6	14.6	26.5	614,719.4	0.00	1.00
10/01/2020 07:00	2	1.8	17.2	14.5	28.7	658,607.5	0.00	1.00
10/01/2020 08:00	1	1.8	15.2	14.6	27.7	756,878.7	0.00	1.00
10/01/2020 09:00	1	1.8	16.9	14.7	35.9	851,251.9	0.00	1.00
10/01/2020 10:00	2	2.0	17.2	13.9	36.6	888,952.1	0.00	1.00
10/01/2020 11:00	2	2.2	20.1	12.9	44.8	905,189.5	0.00	1.00
10/01/2020 12:00	2	2.4	20.9	12.5	48.2	900,559.6	0.00	1.00
10/01/2020 13:00	3	2.5	21.4	12.3	52.3	920,699.0	0.00	1.00
10/01/2020 14:00	3	2.6	21.4	12.0	52.9	910,282.5	0.00	1.00
10/01/2020 15:00	2	2.4	20.2	12.7	44.5	897,808.0	0.00	1.00
10/01/2020 16:00	3	2.6	21.3	12.0	51.4	912,129.0	0.00	1.00
10/01/2020 17:00	3	2.5	20.6	12.2	49.1	900,357.2	0.00	1.00
10/01/2020 18:00	1	1.9	15.7	14.5	34.8	855,462.3	0.00	1.00
10/01/2020 19:00	1	1.9	16.5	14.1	34.6	867,973.4	0.00	1.00
10/01/2020 20:00	2	2.0	16.6	14.0	36.1	864,325.1	0.00	1.00
10/01/2020 21:00	2	2.1	17.5	13.5	37.9	883,463.8	0.00	1.00
10/01/2020 22:00	1	1.9	15.8	14.6	34.9	852,303.7	0.00	1.00
10/01/2020 23:00	1	1.8	15.5	14.6	29.3	785,354.0	0.00	1.00
Average/Sum#:	2	2.0	17.5	13.8	36.0	811,947.8	0.00 #	24.00 #
Minimum:	1	1.8	15.0	12.0	25.6	613,415.2	0.00	1.00
Maximum:	3	2.6	21.4	14.7	52.9	920,699.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/02/2020 00:00	1	1.8	14.8	14.6	25.3	731,229.1	0.00	1.00
10/02/2020 01:00	1	1.8	15.1	14.6	25.7	714,926.5	0.00	1.00
10/02/2020 02:00	2	1.8	17.1	14.5	28.7	649,406.7	0.00	1.00
10/02/2020 03:00	2	1.8	17.1	14.5	28.1	645,555.2	0.00	1.00
10/02/2020 04:00	1	1.9	16.5	14.4	25.4	671,439.3	0.00	1.00
10/02/2020 05:00	1	1.8	17.0	14.6	27.8	614,719.4	0.00	1.00
10/02/2020 06:00	2	1.8	16.9	14.6	27.8	614,719.4	0.00	1.00
10/02/2020 07:00	2	1.8	16.7	14.6	27.2	614,502.0	0.00	1.00
10/02/2020 08:00	1	1.8	15.9	14.7	25.4	623,309.0	0.00	1.00
10/02/2020 09:00	2	1.8	16.5	14.6	28.3	644,064.2	0.00	1.00
10/02/2020 10:00	0	1.8	15.3	14.7	25.9	719,610.4	0.00	1.00
10/02/2020 11:00	1	1.8	15.3	14.7	29.5	808,843.9	0.00	1.00
10/02/2020 12:00	1	1.8	15.9	14.5	35.5	877,715.4	0.00	1.00
10/02/2020 13:00	1	2.0	16.4	14.1	35.2	868,577.6	0.00	1.00
10/02/2020 14:00	2	2.1	17.5	13.6	36.7	879,808.3	0.00	1.00
10/02/2020 15:00	1	1.9	15.4	14.5	33.5	851,396.8	0.00	1.00
10/02/2020 16:00	2	2.3	19.8	12.8	42.0	888,773.3	0.00	1.00
10/02/2020 17:00	2	2.2	18.4	13.3	39.8	882,558.0	0.00	1.00
10/02/2020 18:00	1	1.9	14.4	14.4	26.1	757,818.4	0.00	1.00
10/02/2020 19:00	2	1.9	16.5	14.1	36.2	868,174.8	0.00	1.00
10/02/2020 20:00	1	1.9	14.6	14.5	23.8	709,105.1	0.00	1.00
10/02/2020 21:00	2	1.9	17.3	14.2	37.6	842,707.0	0.00	1.00
10/02/2020 22:00	1	1.8	15.8	14.7	33.5	851,031.0	0.00	1.00
10/02/2020 23:00	1	1.8	15.3	14.6	29.3	791,657.7	0.00	1.00
Average/Sum#:	1	1.9	16.3	14.4	30.6	755,068.7	0.00 #	24.00 #
Minimum:	0	1.8	14.4	12.8	23.8	614,502.0	0.00	1.00
Maximum:	2	2.3	19.8	14.7	42.0	888,773.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/03/2020 00:00	1	1.8	15.3	14.5	25.3	706,109.4	0.00	1.00
10/03/2020 01:00	1	1.9	16.9	14.5	27.6	653,686.2	0.00	1.00
10/03/2020 02:00	1	1.8	15.9	14.6	24.8	613,415.2	0.00	1.00
10/03/2020 03:00	2	1.8	16.6	14.6	27.0	614,502.0	0.00	1.00
10/03/2020 04:00	1	1.8	17.0	14.6	26.6	614,502.0	0.00	1.00
10/03/2020 05:00	1	1.8	16.7	14.6	26.5	614,502.0	0.00	1.00
10/03/2020 06:00	2	1.8	16.6	14.6	26.8	614,502.0	0.00	1.00
10/03/2020 07:00	1	1.8	16.9	14.6	26.6	614,719.4	0.00	1.00
10/03/2020 08:00	1	1.8	16.3	14.5	26.0	653,686.2	0.00	1.00
10/03/2020 09:00	1	1.8	15.3	14.7	28.9	786,756.4	0.00	1.00
10/03/2020 10:00	1	1.8	15.9	14.8	32.8	847,696.1	0.00	1.00
10/03/2020 11:00	1	1.8	15.5	14.6	32.8	867,519.5	0.00	1.00
10/03/2020 12:00	1	1.8	14.9	14.6	30.1	844,261.0	0.00	1.00
10/03/2020 13:00	2	1.9	16.1	14.2	35.0	869,686.7	0.00	1.00
10/03/2020 14:00	2	2.2	18.8	13.2	38.4	889,948.0	0.00	1.00
10/03/2020 15:00	1	1.9	15.7	14.4	34.6	838,509.1	0.00	1.00
10/03/2020 16:00	1	1.9	16.2	14.2	34.3	855,788.0	0.00	1.00
10/03/2020 17:00	1	1.8	14.9	14.6	32.2	859,476.8	0.00	1.00
10/03/2020 18:00	2	2.4	20.2	12.6	43.8	903,820.1	0.00	1.00
10/03/2020 19:00	2	2.1	17.6	13.6	37.6	875,118.5	0.00	1.00
10/03/2020 20:00	1	1.8	15.5	14.6	34.7	871,214.8	0.00	1.00
10/03/2020 21:00	2	2.0	16.8	14.0	35.9	867,699.0	0.00	1.00
10/03/2020 22:00	1	1.8	15.6	14.7	34.4	860,086.9	0.00	1.00
10/03/2020 23:00	1	1.8	16.0	14.7	31.6	829,827.0	0.00	1.00
Average/Sum#:	1	1.9	16.4	14.4	31.4	773,626.3	0.00 #	24.00 #
Minimum:	1	1.8	14.9	12.6	24.8	613,415.2	0.00	1.00
Maximum:	2	2.4	20.2	14.8	43.8	903,820.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/04/2020 00:00	1	1.8	15.0	14.5	25.6	715,310.3	0.00	1.00
10/04/2020 01:00	1	1.8	15.3	14.6	27.5	739,706.5	0.00	1.00
10/04/2020 02:00	1	1.8	17.2	14.5	28.3	645,127.3	0.00	1.00
10/04/2020 03:00	1	1.8	16.0	14.7	25.0	623,750.7	0.00	1.00
10/04/2020 04:00	1	1.8	16.8	14.6	26.3	623,414.1	0.00	1.00
10/04/2020 05:00	2	1.9	17.5	14.5	29.1	640,633.8	0.00	1.00
10/04/2020 06:00	2	1.8	17.5	14.5	28.8	657,751.6	0.00	1.00
10/04/2020 07:00	1	1.9	15.1	14.6	27.1	752,531.3	0.00	1.00
10/04/2020 08:00	1	1.8	15.8	14.7	33.0	828,501.8	0.00	1.00
10/04/2020 09:00	1	1.8	16.0	14.6	34.0	854,912.1	0.00	1.00
10/04/2020 10:00	1	1.9	16.2	14.4	35.5	859,577.2	0.00	1.00
10/04/2020 11:00	2	2.1	17.9	13.6	38.0	888,249.9	0.00	1.00
10/04/2020 12:00	2	2.4	20.7	12.7	44.6	908,830.2	0.00	1.00
10/04/2020 13:00	3	2.6	21.5	12.1	49.9	907,088.0	0.00	1.00
10/04/2020 14:00	3	2.6	21.5	12.0	51.5	903,204.6	0.00	1.00
10/04/2020 15:00	3	2.6	21.6	12.0	51.8	902,127.5	0.00	1.00
10/04/2020 16:00	3	2.5	21.4	12.3	49.2	898,087.6	0.00	1.00
10/04/2020 17:00	2	2.3	20.0	12.8	44.2	894,521.5	0.00	1.00
10/04/2020 18:00	2	2.3	19.5	13.1	41.7	877,660.6	0.00	1.00
10/04/2020 19:00	2	1.9	16.0	14.4	36.5	852,414.0	0.00	1.00
10/04/2020 20:00	1	1.9	15.2	14.6	33.8	864,258.9	0.00	1.00
10/04/2020 21:00	1	1.8	16.1	14.6	35.6	869,693.2	0.00	1.00
10/04/2020 22:00	1	1.9	14.6	14.5	26.4	764,951.9	0.00	1.00
10/04/2020 23:00	1	1.9	15.6	14.5	26.3	694,768.9	0.00	1.00
Average/Sum#:	2	2.0	17.5	13.9	35.4	798,628.1	0.00 #	24.00 #
Minimum:	1	1.8	14.6	12.0	25.0	623,414.1	0.00	1.00
Maximum:	3	2.6	21.6	14.7	51.8	908,830.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/05/2020 00:00	2	1.8	17.5	14.5	29.1	642,131.7	0.00	1.00
10/05/2020 01:00	2	1.8	16.8	14.7	27.4	622,425.5	0.00	1.00
10/05/2020 02:00	2	1.8	17.3	14.6	28.8	613,632.5	0.00	1.00
10/05/2020 03:00	2	1.8	17.6	14.6	29.8	617,110.4	0.00	1.00
10/05/2020 04:00	1	1.8	17.9	14.5	29.9	641,703.7	0.00	1.00
10/05/2020 05:00	1	1.9	15.9	14.5	26.5	709,533.0	0.00	1.00
10/05/2020 06:00	1	1.9	15.4	14.5	28.3	745,266.4	0.00	1.00
10/05/2020 07:00	1	1.8	15.5	14.6	32.1	809,047.2	0.00	1.00
10/05/2020 08:00	1	1.8	17.1	14.7	38.8	886,371.0	0.00	1.00
10/05/2020 09:00	1	1.8	16.6	14.6	37.2	892,082.2	0.00	1.00
10/05/2020 10:00	2	1.9	16.8	14.2	37.9	878,271.1	0.00	1.00
10/05/2020 11:00	2	2.1	18.5	13.5	41.8	910,667.2	0.00	1.00
10/05/2020 12:00	2	2.0	19.7	13.6	40.2	886,749.2	0.00	1.00
10/05/2020 13:00	3	2.5	23.2	12.3	49.7	917,036.6	0.00	1.00
10/05/2020 14:00	3	2.6	23.4	12.0	54.0	916,745.0	0.00	1.00
10/05/2020 15:00	3	2.6	23.1	12.0	54.2	915,667.9	0.00	1.00
10/05/2020 16:00	3	2.6	22.9	12.0	54.5	916,437.3	0.00	1.00
10/05/2020 17:00	3	2.5	22.2	12.4	50.7	910,264.4	0.00	1.00
10/05/2020 18:00	2	2.3	21.0	12.9	46.3	905,874.2	0.00	1.00
10/05/2020 19:00	2	2.3	20.3	13.2	44.6	911,289.7	0.00	1.00
10/05/2020 20:00	2	2.0	18.1	13.9	40.2	883,865.6	0.00	1.00
10/05/2020 21:00	1	1.8	16.6	14.7	37.6	891,451.1	0.00	1.00
10/05/2020 22:00	1	1.8	15.5	14.6	28.5	783,615.1	0.00	1.00
10/05/2020 23:00	1	1.8	15.7	14.6	27.3	721,447.5	0.00	1.00
Average/Sum#:	2	2.0	18.5	13.8	38.1	813,695.2	0.00 #	24.00 #
Minimum:	1	1.8	15.4	12.0	26.5	613,632.5	0.00	1.00
Maximum:	3	2.6	23.4	14.7	54.5	917,036.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/06/2020 00:00	2	1.9	17.6	14.6	30.3	656,019.5	0.00	1.00
10/06/2020 01:00	2	1.8	17.4	14.7	28.5	628,389.1	0.00	1.00
10/06/2020 02:00	2	1.8	18.3	14.7	30.8	621,542.0	0.00	1.00
10/06/2020 03:00	2	1.8	18.6	14.7	31.0	622,204.6	0.00	1.00
10/06/2020 04:00	2	1.8	19.2	14.7	31.4	622,425.5	0.00	1.00
10/06/2020 05:00	1	1.8	16.6	14.5	26.7	693,271.1	0.00	1.00
10/06/2020 06:00	1	1.9	16.0	14.5	27.1	710,602.9	0.00	1.00
10/06/2020 07:00	1	1.8	15.3	14.6	28.1	760,574.0	0.00	1.00
10/06/2020 08:00	1	1.8	16.9	14.8	37.4	871,043.7	0.00	1.00
10/06/2020 09:00	1	1.8	16.7	14.7	36.3	890,567.6	0.00	1.00
10/06/2020 10:00	2	1.9	17.5	14.3	38.8	887,013.5	0.00	1.00
10/06/2020 11:00	2	2.1	18.6	13.7	40.4	902,108.3	0.00	1.00
10/06/2020 12:00	2	2.0	16.5	14.3	36.6	832,236.5	0.00	1.00
10/06/2020 13:00	2	2.0	20.4	13.0	46.1	874,351.5	0.00	1.00
10/06/2020 14:00	2	2.3	21.4	12.7	47.2	896,305.0	0.00	1.00
10/06/2020 15:00	3	2.5	22.9	12.1	52.6	900,396.5	0.00	1.00
10/06/2020 16:00	3	2.5	22.7	12.2	53.0	910,273.7	0.00	1.00
10/06/2020 17:00	2	2.3	21.2	12.8	47.3	901,622.3	0.00	1.00
10/06/2020 18:00	2	2.2	19.8	13.3	43.4	897,873.9	0.00	1.00
10/06/2020 19:00	2	2.3	20.8	13.0	45.3	902,260.0	0.00	1.00
10/06/2020 20:00	2	2.3	20.8	13.0	44.8	897,059.6	0.00	1.00
10/06/2020 21:00	2	1.9	16.8	14.4	37.7	855,363.5	0.00	1.00
10/06/2020 22:00	1	1.8	15.5	14.7	29.9	791,615.6	0.00	1.00
10/06/2020 23:00	1	1.8	15.9	14.6	26.6	712,535.4	0.00	1.00
Average/Sum#:	2	2.0	18.5	13.9	37.4	801,569.0	0.00 #	24.00 #
Minimum:	1	1.8	15.3	12.1	26.6	621,542.0	0.00	1.00
Maximum:	3	2.5	22.9	14.8	53.0	910,273.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOX, Ppm	Unit CT2 NOX, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/07/2020 00:00	1	1.8	15.9	14.6	26.6	701,449.6	0.00	1.00
10/07/2020 01:00	1	1.8	17.1	14.7	28.6	653,789.7	0.00	1.00
10/07/2020 02:00	1	1.8	16.3	14.7	25.6	617,124.5	0.00	1.00
10/07/2020 03:00	1	1.8	16.6	14.7	26.9	619,333.2	0.00	1.00
10/07/2020 04:00	1	1.7	17.5	14.6	28.9	640,803.7	0.00	1.00
10/07/2020 05:00	1	1.9	18.5	14.5	41.9	884,776.5	0.00	1.00
10/07/2020 06:00	2	1.9	18.7	14.4	41.7	877,906.4	0.00	1.00
10/07/2020 07:00	1	1.8	15.7	14.6	26.4	742,967.1	0.00	1.00
10/07/2020 08:00	1	1.8	15.9	14.7	33.1	823,863.4	0.00	1.00
10/07/2020 09:00	1	1.8	17.3	14.8	38.5	880,697.0	0.00	1.00
10/07/2020 10:00	1	1.9	16.9	14.4	37.2	879,591.8	0.00	1.00
10/07/2020 11:00	2	2.0	17.6	14.1	38.1	890,730.0	0.00	1.00
10/07/2020 12:00	2	2.1	18.0	13.7	39.1	889,365.1	0.00	1.00
10/07/2020 13:00	2	2.2	19.9	13.2	43.0	901,152.4	0.00	1.00
10/07/2020 14:00	3	2.6	22.8	12.1	52.8	913,468.3	0.00	1.00
10/07/2020 15:00	3	2.5	22.9	12.2	53.2	914,838.5	0.00	1.00
10/07/2020 16:00	2	2.1	18.2	13.8	40.4	882,025.0	0.00	1.00
10/07/2020 17:00	2	1.9	17.0	14.3	39.3	878,299.0	0.00	1.00
10/07/2020 18:00	2	1.9	17.0	14.5	38.9	867,658.7	0.00	1.00
10/07/2020 19:00	2	1.9	17.0	14.4	39.0	879,591.8	0.00	1.00
10/07/2020 20:00	2	2.0	17.9	13.9	39.9	888,952.1	0.00	1.00
10/07/2020 21:00	1	1.8	15.4	14.6	31.0	802,308.8	0.00	1.00
10/07/2020 22:00	1	1.8	15.1	14.6	25.7	734,489.7	0.00	1.00
10/07/2020 23:00	1	1.9	15.7	14.5	26.0	681,930.5	0.00	1.00
Average/Sum#:	2	1.9	17.5	14.2	35.9	810,296.4	0.00 #	24.00 #
Minimum:	1	1.7	15.1	12.1	25.6	617,124.5	0.00	1.00
Maximum:	3	2.6	22.9	14.8	53.2	914,838.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/08/2020 00:00	2	1.8	17.0	14.6	27.9	627,544.2	0.00	1.00
10/08/2020 01:00	2	1.8	17.2	14.7	27.8	619,333.2	0.00	1.00
10/08/2020 02:00	2	1.8	17.5	14.7	28.4	619,333.2	0.00	1.00
10/08/2020 03:00	2	1.8	17.6	14.7	28.7	619,775.0	0.00	1.00
10/08/2020 04:00	2	1.8	18.3	14.6	29.2	611,893.6	0.00	1.00
10/08/2020 05:00	1	1.8	15.1	14.6	26.3	772,529.2	0.00	1.00
10/08/2020 06:00	1	1.9	15.3	14.6	28.8	782,745.6	0.00	1.00
10/08/2020 07:00	1	1.8	16.1	14.7	33.7	855,669.4	0.00	1.00
10/08/2020 08:00	2	1.8	17.6	14.5	40.0	866,160.9	0.00	1.00
10/08/2020 09:00	2	2.0	19.4	13.7	43.3	897,163.2	0.00	1.00
10/08/2020 10:00	2	2.2	21.6	13.1	47.6	902,942.3	0.00	1.00
10/08/2020 11:00	2	2.2	21.1	13.3	45.6	894,630.5	0.00	1.00
10/08/2020 12:00	2	2.3	22.5	13.0	48.7	900,526.5	0.00	1.00
10/08/2020 13:00	2	2.3	23.0	12.9	49.0	896,801.8	0.00	1.00
10/08/2020 14:00	2	2.2	21.4	13.4	44.7	887,752.2	0.00	1.00
10/08/2020 15:00	1	1.9	16.0	14.6	25.9	745,140.8	0.00	1.00
10/08/2020 16:00	1	1.8	15.3	14.6	26.7	738,185.0	0.00	1.00
10/08/2020 17:00	1	1.8	15.4	14.6	27.3	742,532.3	0.00	1.00
10/08/2020 18:00	1	1.8	15.9	14.7	31.9	816,353.6	0.00	1.00
10/08/2020 19:00	3	2.4	22.8	12.3	54.5	927,864.6	0.00	1.00
10/08/2020 20:00	2	2.1	18.7	13.9	39.8	897,951.1	0.00	1.00
10/08/2020 21:00	3	2.4	22.8	12.4	54.6	932,497.5	0.00	1.00
10/08/2020 22:00	3	2.6	24.3	12.0	57.7	929,516.0	0.00	1.00
10/08/2020 23:00	1	1.9	16.3	14.5	28.9	805,820.7	0.00	1.00
Average/Sum#:	2	2.0	18.7	13.9	37.4	803,777.6	0.00 #	24.00 #
Minimum:	1	1.8	15.1	12.0	25.9	611,893.6	0.00	1.00
Maximum:	3	2.6	24.3	14.7	57.7	932,497.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/09/2020 00:00	1	1.8	15.7	14.5	26.6	733,925.9	0.00	1.00
10/09/2020 01:00	1	1.9	16.1	14.5	26.0	691,559.3	0.00	1.00
10/09/2020 02:00	1	1.9	16.0	14.5	26.2	694,982.9	0.00	1.00
10/09/2020 03:00	1	1.9	16.0	14.5	26.2	698,620.4	0.00	1.00
10/09/2020 04:00	1	1.8	15.5	14.5	28.1	757,462.9	0.00	1.00
10/09/2020 05:00	1	1.8	16.3	14.6	34.6	838,392.0	0.00	1.00
10/09/2020 06:00	1	1.8	17.3	14.6	38.2	877,953.2	0.00	1.00
10/09/2020 07:00	2	1.9	17.9	14.5	39.7	873,863.9	0.00	1.00
10/09/2020 08:00	2	2.0	19.0	13.9	42.8	897,559.9	0.00	1.00
10/09/2020 09:00	2	2.2	21.0	13.3	46.7	915,532.3	0.00	1.00
10/09/2020 10:00	2	2.3	22.2	13.0	48.7	910,580.5	0.00	1.00
10/09/2020 11:00	3	2.4	23.4	12.7	51.3	914,007.3	0.00	1.00
10/09/2020 12:00	3	2.4	23.4	12.5	51.1	907,895.8	0.00	1.00
10/09/2020 13:00	2	2.3	21.1	13.1	44.7	904,522.4	0.00	1.00
10/09/2020 14:00	2	2.3	22.1	12.8	47.0	907,708.6	0.00	1.00
10/09/2020 15:00	1	2.0	18.2	14.0	37.9	890,721.3	0.00	1.00
10/09/2020 16:00	1	1.8	16.7	14.6	35.9	874,475.3	0.00	1.00
10/09/2020 17:00	2	2.0	18.3	13.9	39.8	889,147.7	0.00	1.00
10/09/2020 18:00	2	2.1	18.5	13.8	41.3	904,013.0	0.00	1.00
10/09/2020 19:00	2	2.0	17.5	14.1	37.4	853,876.4	0.00	1.00
10/09/2020 20:00	1	1.8	15.9	14.7	32.4	832,256.6	0.00	1.00
10/09/2020 21:00	1	1.8	16.1	14.7	33.8	845,288.2	0.00	1.00
10/09/2020 22:00	1	1.8	16.6	14.7	35.6	864,062.6	0.00	1.00
10/09/2020 23:00	1	1.8	15.2	14.6	25.5	747,097.1	0.00	1.00
Average/Sum#:	2	2.0	18.2	14.0	37.4	842,729.4	0.00 #	24.00 #
Minimum:	1	1.8	15.2	12.5	25.5	691,559.3	0.00	1.00
Maximum:	3	2.4	23.4	14.7	51.3	915,532.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/10/2020 00:00	1	1.9	15.5	14.5	24.9	686,851.9	0.00	1.00
10/10/2020 01:00	2	1.9	17.4	14.5	29.1	649,406.7	0.00	1.00
10/10/2020 02:00	1	1.8	17.1	14.6	27.5	639,716.8	0.00	1.00
10/10/2020 03:00	2	1.8	17.0	14.5	27.8	628,009.5	0.00	1.00
10/10/2020 04:00	1	1.8	17.2	14.6	27.2	639,282.1	0.00	1.00
10/10/2020 05:00	1	1.8	16.2	14.5	25.6	687,707.8	0.00	1.00
10/10/2020 06:00	1	1.9	15.7	14.5	25.7	703,327.8	0.00	1.00
10/10/2020 07:00	1	1.8	15.2	14.6	29.4	795,570.4	0.00	1.00
10/10/2020 08:00	1	1.8	15.8	14.7	33.4	845,509.1	0.00	1.00
10/10/2020 09:00	2	2.0	18.7	13.7	41.0	893,929.8	0.00	1.00
10/10/2020 10:00	2	2.2	19.9	13.4	42.5	902,724.6	0.00	1.00
10/10/2020 11:00	2	2.2	20.0	13.3	42.3	903,459.7	0.00	1.00
10/10/2020 12:00	2	2.2	19.6	13.4	40.5	893,229.9	0.00	1.00
10/10/2020 13:00	1	1.9	16.2	14.5	32.9	828,501.8	0.02	0.88
10/10/2020 14:00	0	0.2	5.8	20.2	0.0	481,254.9	0.15	0.15
10/10/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/10/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	1	1.8	16.5	14.6	30.0	745,232.2	0.17 #	14.03 #
Minimum:	1	0.2	5.8	13.3	0.0	481,254.9	0.00	0.00
Maximum:	2	2.2	20.0	20.2	42.5	903,459.7	0.15	1.00
%SI	41.67	37.50	37.50	37.50	37.50	37.50	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/11/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2020 15:00	0	0.0	0.0	21.1	0.0	0.0	0.03	0.03
10/11/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/11/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	21.1	0.0	0.0	0.03 #	0.03 #
Minimum:	0	0.0	0.0	21.1	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	21.1	0.0	0.0	0.03	0.03
%SI	100.00	95.83	95.83	95.83	95.83	95.83	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/12/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/12/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/13/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/13/2020 04:00	0	0.0	12.9	0.0	0.0	36,168.5	0.13	0.13
10/13/2020 05:00	0	0.0	14.0	0.0	0.0	36,168.5	0.13	0.13
10/13/2020 06:00	0	0.0	11.5	0.0	0.0	38,527.3	0.13	0.13
10/13/2020 07:00	0	0.0	15.5	0.0	0.0	45,210.7	0.10	0.10
10/13/2020 08:00	0	0.0	20.6	0.0	11.1	179,925.3	0.97	0.97
10/13/2020 09:00	1	1.1	16.5	14.7	30.2	657,323.7	0.07	1.00
10/13/2020 10:00	1	1.8	16.1	14.4	30.1	890,336.5	0.00	1.00
10/13/2020 11:00	1	2.1	19.6	13.5	37.7	888,275.3	0.00	1.00
10/13/2020 12:00	2	2.2	19.7	13.3	38.2	866,521.3	0.00	1.00
10/13/2020 13:00	2	2.2	19.5	13.1	37.9	840,089.2	0.00	1.00
10/13/2020 14:00	1	2.1	17.1	13.6	33.2	855,233.7	0.00	1.00
10/13/2020 15:00	1	2.1	15.6	13.8	32.2	888,390.0	0.00	1.00
10/13/2020 16:00	1	2.1	15.9	13.6	33.3	891,814.2	0.00	1.00
10/13/2020 17:00	1	2.1	15.3	13.9	32.4	900,103.1	0.00	1.00
10/13/2020 18:00	1	2.0	14.4	14.2	30.4	882,359.0	0.00	1.00
10/13/2020 19:00	1	1.8	12.9	14.7	27.2	875,106.4	0.00	1.00
10/13/2020 20:00	1	2.0	15.1	14.0	32.1	905,606.3	0.00	1.00
10/13/2020 21:00	1	1.8	12.8	14.6	26.0	850,564.7	0.00	1.00
10/13/2020 22:00	1	1.8	12.3	14.6	22.0	785,354.0	0.00	1.00
10/13/2020 23:00	1	1.9	13.1	14.5	20.6	697,550.5	0.00	1.00
Average/Sum#:	1	1.9	15.5	14.0	23.7	844,975.2	1.53 #	16.46 #
Minimum:	1	1.1	11.5	13.1	0.0	657,323.7	0.00	0.00
Maximum:	2	2.2	20.6	14.7	38.2	905,606.3	0.97	1.00
%SI	37.50	37.50	16.67	37.50	16.67	37.50	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/14/2020 00:00	1	1.9	14.4	14.5	22.5	669,092.2	0.00	1.00
10/14/2020 01:00	1	1.8	14.5	14.6	23.6	625,370.5	0.00	1.00
10/14/2020 02:00	1	1.8	15.1	14.7	23.9	619,775.0	0.00	1.00
10/14/2020 03:00	1	1.8	15.0	14.7	23.9	622,204.6	0.00	1.00
10/14/2020 04:00	1	1.8	15.2	14.6	23.6	646,672.6	0.00	1.00
10/14/2020 05:00	1	1.8	13.0	14.6	20.1	729,272.8	0.00	1.00
10/14/2020 06:00	1	1.9	12.8	14.6	22.4	762,747.6	0.00	1.00
10/14/2020 07:00	1	1.8	12.9	14.6	24.3	798,613.5	0.00	1.00
10/14/2020 08:00	1	1.8	13.8	14.8	29.1	885,186.9	0.00	1.00
10/14/2020 09:00	1	1.8	14.0	14.7	28.3	872,897.6	0.00	1.00
10/14/2020 10:00	1	1.8	13.7	14.6	29.0	880,561.6	0.00	1.00
10/14/2020 11:00	1	1.9	14.2	14.2	30.1	880,315.0	0.00	1.00
10/14/2020 12:00	1	2.0	15.2	13.8	31.6	892,440.4	0.00	1.00
10/14/2020 13:00	2	2.2	17.0	13.2	35.9	908,088.4	0.00	1.00
10/14/2020 14:00	3	2.6	19.7	12.1	46.8	922,338.4	0.00	1.00
10/14/2020 15:00	3	2.6	19.8	12.1	47.9	923,116.5	0.00	1.00
10/14/2020 16:00	2	2.4	19.7	12.4	44.7	914,131.1	0.00	1.00
10/14/2020 17:00	2	2.3	18.3	13.0	39.6	913,527.4	0.00	1.00
10/14/2020 18:00	2	2.2	17.6	13.3	37.5	917,154.0	0.00	1.00
10/14/2020 19:00	1	1.9	12.9	14.6	24.9	818,828.8	0.00	1.00
10/14/2020 20:00	1	1.9	15.0	14.2	32.6	883,994.1	0.00	1.00
10/14/2020 21:00	1	1.8	13.4	14.6	27.6	854,694.7	0.00	1.00
10/14/2020 22:00	1	1.8	12.7	14.6	22.6	787,745.1	0.00	1.00
10/14/2020 23:00	1	1.9	12.5	14.5	21.5	740,559.0	0.00	1.00
Average/Sum#:	1	2.0	15.1	14.1	29.8	811,222.0	0.00 #	24.00 #
Minimum:	1	1.8	12.5	12.1	20.1	619,775.0	0.00	1.00
Maximum:	3	2.6	19.8	14.8	47.9	923,116.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/15/2020 00:00	1	1.9	13.7	14.6	22.8	702,753.8	0.00	1.00
10/15/2020 01:00	1	1.8	15.5	14.6	25.9	647,324.7	0.00	1.00
10/15/2020 02:00	1	1.8	15.0	14.7	24.2	630,156.1	0.00	1.00
10/15/2020 03:00	1	1.8	15.7	14.7	26.3	643,187.7	0.00	1.00
10/15/2020 04:00	1	1.8	16.1	14.6	25.8	638,412.6	0.00	1.00
10/15/2020 05:00	1	1.8	15.2	14.5	23.4	679,790.8	0.00	1.00
10/15/2020 06:00	1	1.8	13.5	14.7	25.5	804,647.3	0.00	1.00
10/15/2020 07:00	1	1.8	14.4	14.8	30.5	882,044.0	0.00	1.00
10/15/2020 08:00	3	2.3	19.3	12.7	47.0	919,852.4	0.00	1.00
10/15/2020 09:00	3	2.5	20.8	12.1	51.4	947,703.9	0.00	1.00
10/15/2020 10:00	2	2.4	20.5	12.4	46.6	931,691.9	0.00	1.00
10/15/2020 11:00	3	2.5	20.7	12.2	48.3	930,893.8	0.00	1.00
10/15/2020 12:00	2	2.4	20.4	12.4	45.7	920,414.3	0.00	1.00
10/15/2020 13:00	2	2.4	19.7	12.7	42.6	915,510.3	0.00	1.00
10/15/2020 14:00	2	2.4	19.6	12.7	42.8	915,677.3	0.00	1.00
10/15/2020 15:00	1	2.2	17.3	13.5	31.6	773,909.8	0.00	1.00
10/15/2020 16:00	2	2.1	19.2	12.6	45.3	902,005.2	0.00	1.00
10/15/2020 17:00	2	2.3	19.0	12.8	41.4	910,582.7	0.00	1.00
10/15/2020 18:00	2	2.2	17.4	13.3	37.3	905,441.8	0.00	1.00
10/15/2020 19:00	1	1.9	13.6	14.5	29.0	862,737.4	0.00	1.00
10/15/2020 20:00	1	2.0	15.3	14.0	33.1	909,377.2	0.00	1.00
10/15/2020 21:00	1	1.8	13.1	14.7	27.7	874,443.7	0.00	1.00
10/15/2020 22:00	1	1.8	12.6	14.6	22.9	786,223.5	0.00	1.00
10/15/2020 23:00	1	1.8	13.3	14.7	25.3	789,627.8	0.00	1.00
Average/Sum#:	2	2.1	16.7	13.7	34.3	826,017.1	0.00 #	24.00 #
Minimum:	1	1.8	12.6	12.1	22.8	630,156.1	0.00	1.00
Maximum:	3	2.5	20.8	14.8	51.4	947,703.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/16/2020 00:00	1	1.9	14.4	14.6	23.1	689,276.9	0.00	1.00
10/16/2020 01:00	1	1.8	15.3	14.5	25.0	659,035.5	0.00	1.00
10/16/2020 02:00	1	1.8	15.5	14.6	25.9	659,932.1	0.00	1.00
10/16/2020 03:00	1	1.8	15.7	14.5	26.0	649,834.7	0.00	1.00
10/16/2020 04:00	1	1.7	15.0	14.6	23.6	696,450.1	0.00	1.00
10/16/2020 05:00	1	1.8	13.5	14.6	23.9	746,879.7	0.00	1.00
10/16/2020 06:00	1	1.8	13.5	14.7	25.6	796,695.8	0.00	1.00
10/16/2020 07:00	1	1.8	13.8	14.7	28.5	822,096.4	0.00	1.00
10/16/2020 08:00	1	1.7	15.4	14.8	34.1	893,717.8	0.00	1.00
10/16/2020 09:00	1	1.8	15.3	14.8	33.0	882,717.5	0.00	1.00
10/16/2020 10:00	1	1.7	14.6	14.9	30.4	873,236.3	0.00	1.00
10/16/2020 11:00	1	1.7	14.2	14.8	28.2	839,165.3	0.00	1.00
10/16/2020 12:00	1	1.9	14.7	14.3	31.9	894,068.1	0.00	1.00
10/16/2020 13:00	2	2.1	16.7	13.5	34.7	909,001.7	0.00	1.00
10/16/2020 14:00	2	2.3	18.7	12.8	39.8	905,679.8	0.00	1.00
10/16/2020 15:00	3	2.5	19.9	12.2	46.6	920,977.2	0.00	1.00
10/16/2020 16:00	3	2.5	19.8	12.2	47.3	921,764.3	0.00	1.00
10/16/2020 17:00	2	2.4	19.5	12.5	43.6	911,808.4	0.00	1.00
10/16/2020 18:00	2	2.2	17.7	13.2	38.1	910,400.4	0.00	1.00
10/16/2020 19:00	2	2.2	17.6	13.2	37.0	907,021.3	0.00	1.00
10/16/2020 20:00	1	2.0	15.5	13.9	33.0	887,973.9	0.00	1.00
10/16/2020 21:00	1	1.8	14.4	14.8	31.4	877,554.1	0.00	1.00
10/16/2020 22:00	1	1.8	13.5	14.7	24.1	788,081.6	0.00	1.00
10/16/2020 23:00	1	1.8	13.1	14.6	23.7	762,095.5	0.00	1.00
Average/Sum#:	1	2.0	15.7	14.1	31.6	825,227.7	0.00 #	24.00 #
Minimum:	1	1.7	13.1	12.2	23.1	649,834.7	0.00	1.00
Maximum:	3	2.5	19.9	14.9	47.3	921,764.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/17/2020 00:00	1	1.8	13.5	14.6	22.6	710,144.4	0.00	1.00
10/17/2020 01:00	1	1.8	14.8	14.7	23.5	619,775.0	0.00	1.00
10/17/2020 02:00	2	1.8	16.0	14.7	26.7	619,775.0	0.00	1.00
10/17/2020 03:00	2	1.8	16.5	14.7	26.9	621,321.1	0.00	1.00
10/17/2020 04:00	1	1.7	16.6	14.7	26.4	622,867.2	0.00	1.00
10/17/2020 05:00	1	1.9	16.1	14.5	25.7	655,398.0	0.00	1.00
10/17/2020 06:00	1	1.8	15.3	14.5	24.0	676,153.3	0.00	1.00
10/17/2020 07:00	1	1.9	13.1	14.6	22.7	752,313.9	0.00	1.00
10/17/2020 08:00	1	1.8	14.1	14.8	29.1	861,165.9	0.00	1.00
10/17/2020 09:00	1	1.7	15.0	14.8	31.4	879,350.1	0.00	1.00
10/17/2020 10:00	1	1.8	14.0	14.7	29.4	900,727.8	0.00	1.00
10/17/2020 11:00	1	1.8	13.9	14.7	29.5	892,776.3	0.00	1.00
10/17/2020 12:00	1	1.8	13.8	14.7	29.1	887,254.5	0.00	1.00
10/17/2020 13:00	1	1.9	14.7	14.3	31.5	871,659.4	0.00	1.00
10/17/2020 14:00	3	2.5	19.6	12.2	44.9	914,995.9	0.00	1.00
10/17/2020 15:00	2	2.4	18.9	12.7	41.6	907,494.2	0.00	1.00
10/17/2020 16:00	2	2.3	18.7	12.8	40.9	908,553.9	0.00	1.00
10/17/2020 17:00	2	2.2	16.6	13.5	35.0	893,456.9	0.00	1.00
10/17/2020 18:00	1	1.9	14.3	14.4	32.1	875,378.2	0.00	1.00
10/17/2020 19:00	2	2.3	18.4	12.9	38.6	913,919.6	0.00	1.00
10/17/2020 20:00	1	2.1	15.4	13.9	33.3	893,451.6	0.00	1.00
10/17/2020 21:00	1	1.8	13.1	14.7	27.3	865,829.6	0.00	1.00
10/17/2020 22:00	1	1.8	13.1	14.7	24.6	797,137.5	0.00	1.00
10/17/2020 23:00	1	1.8	13.1	14.7	23.4	763,564.5	0.00	1.00
Average/Sum#:	1	1.9	15.4	14.2	30.0	804,352.7	0.00 #	24.00 #
Minimum:	1	1.7	13.1	12.2	22.6	619,775.0	0.00	1.00
Maximum:	3	2.5	19.6	14.8	44.9	914,995.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/18/2020 00:00	1	1.8	14.4	14.6	22.8	679,060.6	0.00	1.00
10/18/2020 01:00	1	1.8	15.4	14.6	24.9	661,236.3	0.00	1.00
10/18/2020 02:00	1	1.8	15.5	14.5	25.0	653,472.2	0.00	1.00
10/18/2020 03:00	1	1.8	15.2	14.6	25.1	648,194.2	0.00	1.00
10/18/2020 04:00	1	1.8	15.7	14.5	24.9	648,550.8	0.00	1.00
10/18/2020 05:00	1	1.9	14.8	14.5	22.8	678,293.0	0.00	1.00
10/18/2020 06:00	1	1.8	13.7	14.6	22.5	717,752.3	0.00	1.00
10/18/2020 07:00	1	1.8	13.1	14.7	24.9	787,419.0	0.00	1.00
10/18/2020 08:00	1	1.8	14.0	14.8	29.5	864,084.3	0.00	1.00
10/18/2020 09:00	1	1.7	14.9	14.8	31.3	880,023.5	0.00	1.00
10/18/2020 10:00	1	1.9	14.4	14.4	30.8	893,496.7	0.00	1.00
10/18/2020 11:00	1	1.9	14.5	14.3	30.8	888,258.5	0.00	1.00
10/18/2020 12:00	1	1.9	13.8	14.5	29.6	861,453.5	0.00	1.00
10/18/2020 13:00	1	1.9	14.9	14.1	32.0	901,604.8	0.00	1.00
10/18/2020 14:00	2	2.2	16.8	13.3	36.1	911,027.6	0.00	1.00
10/18/2020 15:00	2	2.4	19.1	12.5	41.4	902,841.9	0.00	1.00
10/18/2020 16:00	2	2.1	15.3	13.8	33.6	893,404.8	0.00	1.00
10/18/2020 17:00	1	1.9	13.7	14.5	29.8	858,885.9	0.00	1.00
10/18/2020 18:00	1	1.8	12.4	14.6	23.5	808,829.9	0.00	1.00
10/18/2020 19:00	1	1.8	12.8	14.7	26.5	848,822.2	0.00	1.00
10/18/2020 20:00	1	1.9	14.9	14.1	31.4	892,341.1	0.00	1.00
10/18/2020 21:00	1	1.8	12.9	14.7	26.7	869,584.5	0.00	1.00
10/18/2020 22:00	1	1.9	12.3	14.6	21.4	773,616.1	0.00	1.00
10/18/2020 23:00	1	1.8	12.5	14.5	20.7	732,214.1	0.00	1.00
Average/Sum#:	1	1.9	14.5	14.4	27.8	802,269.5	0.00 #	24.00 #
Minimum:	1	1.7	12.3	12.5	20.7	648,194.2	0.00	1.00
Maximum:	2	2.4	19.1	14.8	41.4	911,027.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/19/2020 00:00	1	1.8	13.8	14.5	21.9	686,424.0	0.00	1.00
10/19/2020 01:00	1	1.8	15.0	14.6	24.4	638,412.6	0.00	1.00
10/19/2020 02:00	1	1.8	14.3	14.7	22.4	627,505.6	0.00	1.00
10/19/2020 03:00	1	1.8	14.8	14.7	24.1	630,818.7	0.00	1.00
10/19/2020 04:00	0	1.8	0.0	14.5	23.9	654,970.0	0.00	1.00
10/19/2020 05:00	0	1.9	0.0	14.6	22.9	746,010.2	0.00	1.00
10/19/2020 06:00	0	1.8	0.0	14.6	24.5	784,267.2	0.00	1.00
10/19/2020 07:00	0	1.8	0.0	14.7	28.6	861,191.2	0.00	1.00
10/19/2020 08:00	0	1.7	0.0	14.8	31.9	906,738.5	0.00	1.00
10/19/2020 09:00	0	1.8	0.0	14.6	30.1	894,038.5	0.00	1.00
10/19/2020 10:00	0	1.9	0.0	14.3	31.3	896,558.0	0.00	1.00
10/19/2020 11:00	0	2.0	0.0	14.0	31.7	913,148.1	0.00	1.00
10/19/2020 12:00	0	2.1	0.0	13.8	33.1	905,748.9	0.00	1.00
10/19/2020 13:00	0	2.2	0.0	13.5	34.2	909,556.9	0.00	1.00
10/19/2020 14:00	0	2.3	0.0	13.0	37.8	908,500.4	0.00	1.00
10/19/2020 15:00	0	2.5	0.0	12.1	45.4	912,534.6	0.00	1.00
10/19/2020 16:00	0	2.4	0.0	12.5	42.3	909,526.0	0.00	1.00
10/19/2020 17:00	0	2.2	0.0	13.2	36.5	905,776.4	0.00	1.00
10/19/2020 18:00	0	2.0	0.0	13.9	33.0	896,386.1	0.00	1.00
10/19/2020 19:00	0	1.8	0.0	14.6	24.2	824,697.8	0.00	1.00
10/19/2020 20:00	0	1.9	0.0	14.2	31.7	892,169.8	0.00	1.00
10/19/2020 21:00	0	1.8	0.0	14.7	26.7	843,079.5	0.00	1.00
10/19/2020 22:00	0	1.8	0.0	14.6	21.9	741,880.2	0.00	1.00
10/19/2020 23:00	0	1.8	0.0	14.6	21.0	724,925.4	0.00	1.00
Average/Sum#:	1	1.9	14.5	14.1	29.4	817,286.0	0.00 #	24.00 #
Minimum:	1	1.7	13.8	12.1	21.0	627,505.6	0.00	1.00
Maximum:	1	2.5	15.0	14.8	45.4	913,148.1	0.00	1.00
%SI	83.33	0.00	83.33	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/20/2020 00:00	0	1.9	0.0	14.6	22.0	700,145.4	0.00	1.00
10/20/2020 01:00	0	1.8	0.0	14.6	24.9	638,195.2	0.00	1.00
10/20/2020 02:00	0	1.8	0.0	14.7	24.0	620,658.5	0.00	1.00
10/20/2020 03:00	0	1.8	0.0	14.7	27.1	621,542.0	0.00	1.00
10/20/2020 04:00	0	1.8	0.0	14.6	24.1	647,324.7	0.00	1.00
10/20/2020 05:00	0	1.8	0.0	14.5	20.3	713,384.5	0.00	1.00
10/20/2020 06:00	0	1.8	13.4	14.6	22.8	758,617.6	0.00	1.00
10/20/2020 07:00	1	1.8	13.2	14.6	24.2	782,963.0	0.00	1.00
10/20/2020 08:00	1	1.8	14.3	14.8	30.3	883,615.5	0.00	1.00
10/20/2020 09:00	1	1.8	14.9	14.8	31.2	885,411.4	0.00	1.00
10/20/2020 10:00	1	1.9	14.9	14.2	31.0	880,110.7	0.00	1.00
10/20/2020 11:00	1	2.2	16.8	13.4	34.6	906,558.9	0.00	1.00
10/20/2020 12:00	2	2.2	17.1	13.3	36.0	909,946.5	0.00	1.00
10/20/2020 13:00	2	2.5	19.7	12.3	44.3	921,972.9	0.00	1.00
10/20/2020 14:00	3	2.5	19.9	12.2	46.5	923,023.5	0.00	1.00
10/20/2020 15:00	3	2.5	19.7	12.2	45.7	909,329.3	0.00	1.00
10/20/2020 16:00	2	2.1	15.9	13.7	34.0	895,261.2	0.00	1.00
10/20/2020 17:00	1	1.9	14.3	14.3	31.0	863,567.3	0.00	1.00
10/20/2020 18:00	1	1.8	13.5	14.7	28.5	887,475.4	0.00	1.00
10/20/2020 19:00	1	2.0	15.7	13.8	33.7	911,342.3	0.00	1.00
10/20/2020 20:00	1	1.8	13.4	14.6	28.7	878,170.6	0.00	1.00
10/20/2020 21:00	1	1.8	12.4	14.6	21.4	774,920.3	0.00	1.00
10/20/2020 22:00	1	1.9	12.5	14.5	19.6	709,105.1	0.00	1.00
10/20/2020 23:00	1	1.9	14.1	14.5	22.4	669,520.1	0.00	1.00
Average/Sum#:	1	2.0	15.3	14.1	29.5	803,840.1	0.00 #	24.00 #
Minimum:	0	1.8	12.4	12.2	19.6	620,658.5	0.00	1.00
Maximum:	3	2.5	19.9	14.8	46.5	923,023.5	0.00	1.00
%SI	25.00	0.00	25.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOX, Ppm	Unit CT2 NOX, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/21/2020 00:00	1	1.8	14.0	14.7	21.7	620,658.5	0.00	1.00
10/21/2020 01:00	1	1.8	14.7	14.7	23.5	619,112.3	0.00	1.00
10/21/2020 02:00	2	1.8	16.0	14.7	26.2	620,437.6	0.00	1.00
10/21/2020 03:00	1	1.8	15.7	14.7	25.4	620,216.7	0.00	1.00
10/21/2020 04:00	1	1.8	16.1	14.7	25.6	627,505.6	0.00	1.00
10/21/2020 05:00	1	1.8	13.1	14.6	21.9	777,528.7	0.00	1.00
10/21/2020 06:00	1	1.8	13.6	14.7	26.1	817,899.8	0.00	1.00
10/21/2020 07:00	1	1.8	15.2	14.7	23.9	634,131.8	0.00	1.00
10/21/2020 08:00	1	1.8	15.1	14.6	24.2	657,323.7	0.00	1.00
10/21/2020 09:00	1	1.8	12.9	14.7	21.0	733,746.4	0.00	1.00
10/21/2020 10:00	1	1.8	13.3	14.8	25.7	811,776.8	0.00	1.00
10/21/2020 11:00	1	1.8	13.0	14.7	25.2	857,436.4	0.00	1.00
10/21/2020 12:00	1	1.8	13.8	14.7	29.2	891,230.2	0.00	1.00
10/21/2020 13:00	1	1.9	14.3	14.3	30.9	883,901.2	0.00	1.00
10/21/2020 14:00	1	2.1	15.9	13.6	31.9	895,190.8	0.00	1.00
10/21/2020 15:00	1	1.8	12.6	14.7	25.1	849,264.0	0.00	1.00
10/21/2020 16:00	1	1.8	12.5	14.7	25.4	856,111.1	0.00	1.00
10/21/2020 17:00	1	1.8	12.7	14.7	25.8	863,179.1	0.00	1.00
10/21/2020 18:00	1	1.8	12.8	14.6	21.0	718,621.7	0.00	1.00
10/21/2020 19:00	1	1.8	14.3	14.7	23.2	638,107.6	0.00	1.00
10/21/2020 20:00	1	1.8	14.5	14.6	23.1	657,758.4	0.00	1.00
10/21/2020 21:00	1	1.8	12.7	14.7	23.0	794,928.8	0.00	1.00
10/21/2020 22:00	1	1.8	12.9	14.6	21.6	736,011.3	0.00	1.00
10/21/2020 23:00	1	1.9	13.6	14.6	22.8	710,796.5	0.00	1.00
Average/Sum#:	1	1.8	14.0	14.6	24.7	745,536.5	0.00 #	24.00 #
Minimum:	1	1.8	12.5	13.6	21.0	619,112.3	0.00	1.00
Maximum:	2	2.1	16.1	14.8	31.9	895,190.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOX, Ppm	Unit CT2 NOX, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/22/2020 00:00	1	1.8	15.0	14.7	23.6	624,192.5	0.00	1.00
10/22/2020 01:00	1	1.8	15.2	14.7	24.5	620,658.5	0.00	1.00
10/22/2020 02:00	1	1.8	15.8	14.7	25.4	621,100.2	0.00	1.00
10/22/2020 03:00	1	1.8	15.9	14.7	25.8	621,542.0	0.00	1.00
10/22/2020 04:00	1	1.7	15.7	14.6	24.8	630,587.3	0.00	1.00
10/22/2020 05:00	1	1.8	14.5	14.6	31.4	898,820.6	0.00	1.00
10/22/2020 06:00	1	1.8	14.7	14.6	31.0	895,777.4	0.00	1.00
10/22/2020 07:00	1	1.8	13.4	14.6	22.9	757,965.5	0.00	1.00
10/22/2020 08:00	1	1.8	14.0	14.7	29.2	834,907.1	0.00	1.00
10/22/2020 09:00	1	1.8	15.7	14.7	34.9	892,113.7	0.00	1.00
10/22/2020 10:00	1	1.8	15.2	14.8	33.1	893,717.8	0.00	1.00
10/22/2020 11:00	1	1.8	15.4	14.8	33.6	887,880.9	0.00	1.00
10/22/2020 12:00	1	1.8	14.4	14.7	31.1	911,329.8	0.00	1.00
10/22/2020 13:00	1	1.8	14.4	14.7	31.1	910,225.5	0.00	1.00
10/22/2020 14:00	1	1.9	14.8	14.4	31.8	889,283.1	0.00	1.00
10/22/2020 15:00	1	1.8	13.0	14.6	24.3	814,698.8	0.00	1.00
10/22/2020 16:00	1	1.8	14.4	14.6	32.4	899,690.1	0.00	1.00
10/22/2020 17:00	1	1.9	15.1	14.3	33.5	898,425.4	0.00	1.00
10/22/2020 18:00	1	1.8	13.6	14.6	26.9	844,913.1	0.00	1.00
10/22/2020 19:00	1	1.8	13.7	14.6	29.0	870,780.0	0.00	1.00
10/22/2020 20:00	1	1.8	14.6	14.7	30.6	862,737.4	0.00	1.00
10/22/2020 21:00	1	1.8	15.4	14.5	24.1	681,288.6	0.00	1.00
10/22/2020 22:00	2	1.8	16.7	14.7	27.9	629,493.5	0.00	1.00
10/22/2020 23:00	2	1.8	17.2	14.7	28.6	621,983.7	0.00	1.00
Average/Sum#:	1	1.8	14.9	14.6	28.8	792,254.7	0.00 #	24.00 #
Minimum:	1	1.7	13.0	14.3	22.9	620,658.5	0.00	1.00
Maximum:	2	1.9	17.2	14.8	34.9	911,329.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOX, Ppm	Unit CT2 NOX, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/23/2020 00:00	2	1.8	17.3	14.7	28.9	622,425.5	0.00	1.00
10/23/2020 01:00	2	1.8	17.6	14.7	29.3	623,309.0	0.00	1.00
10/23/2020 02:00	2	1.8	18.2	14.7	30.7	623,309.0	0.00	1.00
10/23/2020 03:00	2	1.8	18.7	14.7	32.0	623,088.1	0.00	1.00
10/23/2020 04:00	1	1.7	18.9	14.7	31.2	626,843.0	0.00	1.00
10/23/2020 05:00	1	1.8	16.7	14.4	26.3	653,320.8	0.00	1.00
10/23/2020 06:00	1	1.9	17.4	14.5	31.1	712,314.7	0.00	1.00
10/23/2020 07:00	1	1.8	17.2	14.6	33.5	771,442.4	0.00	1.00
10/23/2020 08:00	2	1.8	18.1	14.7	39.1	840,429.0	0.00	1.00
10/23/2020 09:00	2	1.8	18.7	14.7	42.1	868,480.1	0.00	1.00
10/23/2020 10:00	2	1.8	18.7	14.8	42.5	887,656.4	0.00	1.00
10/23/2020 11:00	2	1.8	19.6	14.8	46.1	894,615.8	0.00	1.00
10/23/2020 12:00	1	1.8	19.6	14.8	45.3	885,860.4	0.00	1.00
10/23/2020 13:00	1	1.9	19.0	14.4	43.1	898,974.4	0.00	1.00
10/23/2020 14:00	1	1.9	18.4	14.4	43.3	884,648.2	0.00	1.00
10/23/2020 15:00	1	1.9	17.4	14.4	37.6	835,138.2	0.00	1.00
10/23/2020 16:00	1	1.8	15.9	14.5	25.9	711,672.7	0.00	1.00
10/23/2020 17:00	1	1.9	18.8	14.2	44.0	903,615.7	0.00	1.00
10/23/2020 18:00	1	1.8	16.7	14.5	28.9	720,873.6	0.00	1.00
10/23/2020 19:00	1	1.9	16.3	14.5	26.7	697,122.6	0.00	1.00
10/23/2020 20:00	1	1.8	16.4	14.7	36.6	875,989.9	0.00	1.00
10/23/2020 21:00	1	1.8	16.3	14.5	31.6	797,047.8	0.00	1.00
10/23/2020 22:00	1	1.9	16.0	14.5	29.8	761,956.3	0.00	1.00
10/23/2020 23:00	1	1.9	17.0	14.5	28.7	700,332.2	0.00	1.00
Average/Sum#:	1	1.8	17.7	14.6	34.8	767,519.4	0.00 #	24.00 #
Minimum:	1	1.7	15.9	14.2	25.9	622,425.5	0.00	1.00
Maximum:	2	1.9	19.6	14.8	46.1	903,615.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/24/2020 00:00	1	1.8	16.3	14.5	28.5	714,454.4	0.00	1.00
10/24/2020 01:00	1	1.8	19.5	14.6	33.2	619,066.8	0.00	1.00
10/24/2020 02:00	1	1.8	17.7	14.6	28.7	634,717.3	0.00	1.00
10/24/2020 03:00	1	1.8	17.7	14.6	29.3	634,934.7	0.00	1.00
10/24/2020 04:00	1	1.8	18.4	14.6	30.1	638,847.3	0.00	1.00
10/24/2020 05:00	1	1.9	19.4	14.4	32.6	663,433.4	0.00	1.00
10/24/2020 06:00	1	1.9	18.0	14.5	30.0	700,974.1	0.00	1.00
10/24/2020 07:00	1	1.8	16.8	14.6	34.3	812,307.8	0.00	1.00
10/24/2020 08:00	1	1.8	17.7	14.7	40.1	900,286.1	0.00	1.00
10/24/2020 09:00	1	1.8	18.0	14.6	40.7	900,994.3	0.00	1.00
10/24/2020 10:00	1	2.0	18.8	14.0	42.5	900,247.7	0.00	1.00
10/24/2020 11:00	1	1.9	17.6	14.5	40.1	884,990.5	0.00	1.00
10/24/2020 12:00	1	1.8	17.4	14.6	40.3	892,951.6	0.00	1.00
10/24/2020 13:00	1	2.2	21.3	13.2	48.0	921,782.7	0.00	1.00
10/24/2020 14:00	2	2.3	22.8	12.8	50.9	926,812.9	0.00	1.00
10/24/2020 15:00	1	2.0	17.2	14.3	30.1	754,843.3	0.00	1.00
10/24/2020 16:00	1	1.8	17.7	14.6	29.3	661,453.7	0.00	1.00
10/24/2020 17:00	1	1.8	16.4	14.6	27.0	706,883.8	0.00	1.00
10/24/2020 18:00	1	1.9	16.3	14.6	28.3	722,969.1	0.00	1.00
10/24/2020 19:00	2	2.3	24.0	12.6	57.1	922,794.0	0.00	1.00
10/24/2020 20:00	1	2.2	23.0	13.2	50.4	924,094.7	0.00	1.00
10/24/2020 21:00	1	2.0	19.9	14.0	44.5	891,515.1	0.00	1.00
10/24/2020 22:00	1	1.8	17.1	14.6	36.0	842,087.3	0.00	1.00
10/24/2020 23:00	1	1.9	16.0	14.5	28.3	746,336.3	0.00	1.00
Average/Sum#:	1	1.9	18.5	14.2	36.7	788,324.1	0.00 #	24.00 #
Minimum:	1	1.8	16.0	12.6	27.0	619,066.8	0.00	1.00
Maximum:	2	2.3	24.0	14.7	57.1	926,812.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/25/2020 00:00	1	1.9	16.4	14.5	27.1	699,904.2	0.00	1.00
10/25/2020 01:00	1	1.9	18.0	14.5	30.6	645,341.2	0.00	1.00
10/25/2020 02:00	1	1.9	18.0	14.5	30.1	644,913.3	0.00	1.00
10/25/2020 03:00	1	1.9	18.0	14.5	30.0	652,830.3	0.00	1.00
10/25/2020 04:00	1	1.8	17.8	14.4	28.8	677,127.7	0.00	1.00
10/25/2020 05:00	1	1.9	16.0	14.5	29.0	742,698.8	0.00	1.00
10/25/2020 06:00	1	1.8	16.7	14.6	35.2	832,740.4	0.00	1.00
10/25/2020 07:00	1	1.8	17.0	14.6	37.2	864,258.9	0.00	1.00
10/25/2020 08:00	1	1.9	17.4	14.5	40.8	882,208.9	0.00	1.00
10/25/2020 09:00	1	2.0	19.3	13.9	45.8	928,861.0	0.00	1.00
10/25/2020 10:00	1	2.1	19.8	13.6	47.0	926,143.6	0.00	1.00
10/25/2020 11:00	1	2.1	19.9	13.6	47.0	928,207.1	0.00	1.00
10/25/2020 12:00	1	2.2	20.8	13.4	49.2	933,217.1	0.00	1.00
10/25/2020 13:00	2	2.2	21.4	13.4	51.6	936,321.1	0.00	1.00
10/25/2020 14:00	2	2.3	23.1	13.0	55.4	947,676.3	0.00	1.00
10/25/2020 15:00	2	2.3	23.5	13.0	55.2	943,689.4	0.00	1.00
10/25/2020 16:00	1	1.9	18.5	14.6	43.6	909,036.9	0.00	1.00
10/25/2020 17:00	1	2.0	20.5	13.9	50.7	937,077.5	0.00	1.00
10/25/2020 18:00	1	1.9	19.9	14.2	49.9	931,413.0	0.00	1.00
10/25/2020 19:00	1	1.9	19.8	14.2	49.0	917,309.9	0.00	1.00
10/25/2020 20:00	1	1.9	17.7	14.6	38.9	863,606.8	0.00	1.00
10/25/2020 21:00	1	1.8	17.7	14.6	38.7	857,303.1	0.00	1.00
10/25/2020 22:00	1	1.8	18.1	14.6	37.9	810,134.1	0.00	1.00
10/25/2020 23:00	1	1.9	18.0	14.5	32.7	715,096.3	0.00	1.00
Average/Sum#:	1	2.0	18.9	14.2	40.9	838,629.9	0.00 #	24.00 #
Minimum:	1	1.8	16.0	13.0	27.1	644,913.3	0.00	1.00
Maximum:	2	2.3	23.5	14.6	55.4	947,676.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/26/2020 00:00	1	1.8	19.6	14.6	34.6	651,672.1	0.00	1.00
10/26/2020 01:00	1	1.8	19.6	14.6	34.9	651,237.4	0.00	1.00
10/26/2020 02:00	1	1.8	19.7	14.6	35.1	648,628.9	0.00	1.00
10/26/2020 03:00	1	1.8	19.5	14.6	35.0	662,540.6	0.00	1.00
10/26/2020 04:00	1	1.9	18.8	14.5	33.2	727,078.8	0.00	1.00
10/26/2020 05:00	1	1.8	19.0	14.6	43.1	847,521.5	0.00	1.00
10/26/2020 06:00	1	1.8	18.8	14.6	41.0	841,869.9	0.00	1.00
10/26/2020 07:00	1	1.9	21.0	14.2	53.0	902,798.1	0.00	1.00
10/26/2020 08:00	2	2.1	22.8	13.7	57.2	944,522.4	0.00	1.00
10/26/2020 09:00	2	2.1	23.6	13.5	59.4	949,529.3	0.00	1.00
10/26/2020 10:00	2	2.4	27.1	12.7	66.4	958,430.1	0.00	1.00
10/26/2020 11:00	2	2.5	28.4	12.3	69.6	942,832.8	0.00	1.00
10/26/2020 12:00	2	2.5	28.5	12.3	70.1	943,469.7	0.00	1.00
10/26/2020 13:00	2	2.5	27.4	12.4	66.3	941,197.3	0.00	1.00
10/26/2020 14:00	2	2.5	25.3	12.3	63.5	960,826.4	0.00	1.00
10/26/2020 15:00	2	2.3	23.8	13.0	55.6	952,703.3	0.00	1.00
10/26/2020 16:00	1	2.0	19.0	14.4	44.6	897,289.0	0.00	1.00
10/26/2020 17:00	2	2.1	21.3	13.6	53.2	958,597.1	0.00	1.00
10/26/2020 18:00	2	2.5	25.4	12.3	64.6	972,291.3	0.00	1.00
10/26/2020 19:00	2	2.5	25.8	12.3	64.3	965,603.4	0.00	1.00
10/26/2020 20:00	2	2.4	25.0	12.7	61.1	966,446.2	0.00	1.00
10/26/2020 21:00	1	2.0	20.1	14.3	49.2	937,225.7	0.00	1.00
10/26/2020 22:00	1	1.8	18.8	14.7	43.9	872,235.0	0.00	1.00
10/26/2020 23:00	1	1.8	17.8	14.7	33.1	764,448.0	0.00	1.00
Average/Sum#:	2	2.1	22.3	13.6	51.3	869,208.1	0.00 #	24.00 #
Minimum:	1	1.8	17.8	12.3	33.1	648,628.9	0.00	1.00
Maximum:	2	2.5	28.5	14.7	70.1	972,291.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/27/2020 00:00	1	1.8	18.2	14.6	32.6	714,274.4	0.00	1.00
10/27/2020 01:00	1	1.8	19.4	14.6	34.6	677,756.4	0.00	1.00
10/27/2020 02:00	1	1.8	19.5	14.6	34.9	651,020.0	0.00	1.00
10/27/2020 03:00	1	1.8	19.4	14.6	34.6	656,236.9	0.00	1.00
10/27/2020 04:00	1	1.9	18.9	14.5	31.8	706,751.4	0.00	1.00
10/27/2020 05:00	1	1.8	19.1	14.7	46.4	911,109.0	0.00	1.00
10/27/2020 06:00	1	1.8	18.7	14.7	44.3	895,868.6	0.00	1.00
10/27/2020 07:00	1	1.8	19.9	14.7	48.8	930,104.2	0.00	1.00
10/27/2020 08:00	1	1.8	19.5	14.6	49.1	911,210.6	0.00	1.00
10/27/2020 09:00	2	2.1	22.0	13.5	54.0	934,169.5	0.00	1.00
10/27/2020 10:00	2	2.2	22.7	13.4	55.3	935,590.7	0.00	1.00
10/27/2020 11:00	2	2.2	23.1	13.3	55.3	926,163.3	0.00	1.00
10/27/2020 12:00	1	1.9	17.2	14.5	37.1	844,549.7	0.00	1.00
10/27/2020 13:00	1	1.8	16.0	14.6	35.8	850,782.1	0.00	1.00
10/27/2020 14:00	1	1.8	16.2	14.6	36.9	858,172.6	0.00	1.00
10/27/2020 15:00	1	1.9	17.6	14.4	42.8	872,639.4	0.00	1.00
10/27/2020 16:00	1	1.9	17.7	14.4	42.9	873,903.4	0.00	1.00
10/27/2020 17:00	1	1.9	17.6	14.5	42.6	889,697.9	0.00	1.00
10/27/2020 18:00	1	1.8	17.5	14.5	41.7	882,636.8	0.00	1.00
10/27/2020 19:00	1	1.8	16.9	14.7	38.2	846,392.6	0.00	1.00
10/27/2020 20:00	1	1.9	19.2	14.4	48.1	904,452.1	0.00	1.00
10/27/2020 21:00	1	1.9	18.9	14.4	45.7	889,704.5	0.00	1.00
10/27/2020 22:00	1	1.8	16.6	14.6	33.0	787,745.1	0.00	1.00
10/27/2020 23:00	1	1.8	17.5	14.5	30.0	688,991.6	0.00	1.00
Average/Sum#:	1	1.9	18.7	14.4	41.5	834,996.8	0.00 #	24.00 #
Minimum:	1	1.8	16.0	13.3	30.0	651,020.0	0.00	1.00
Maximum:	2	2.2	23.1	14.7	55.3	935,590.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/28/2020 00:00	1	1.9	17.6	14.5	30.6	688,991.6	0.00	1.00
10/28/2020 01:00	1	1.9	18.0	14.5	31.6	686,210.0	0.00	1.00
10/28/2020 02:00	1	1.8	19.0	14.4	34.3	659,851.9	0.00	1.00
10/28/2020 03:00	1	1.9	18.4	14.4	32.3	681,762.7	0.00	1.00
10/28/2020 04:00	1	1.9	16.6	14.5	32.8	777,790.3	0.00	1.00
10/28/2020 05:00	1	1.9	19.8	14.4	51.5	921,728.0	0.00	1.00
10/28/2020 06:00	1	1.9	19.2	14.4	47.5	895,392.9	0.00	1.00
10/28/2020 07:00	1	1.9	18.3	14.4	45.4	882,752.0	0.00	1.00
10/28/2020 08:00	1	1.9	18.7	14.5	48.1	899,968.6	0.00	1.00
10/28/2020 09:00	1	1.8	18.6	14.7	46.5	917,293.5	0.00	1.00
10/28/2020 10:00	1	1.8	18.7	14.7	46.4	900,727.8	0.00	1.00
10/28/2020 11:00	1	1.9	19.4	14.4	47.3	884,016.1	0.00	1.00
10/28/2020 12:00	1	2.0	20.0	14.1	48.4	898,181.3	0.00	1.00
10/28/2020 13:00	1	2.0	19.8	14.1	48.3	885,695.4	0.00	1.00
10/28/2020 14:00	1	2.0	19.9	14.1	48.1	890,327.2	0.00	1.00
10/28/2020 15:00	1	1.8	17.9	14.8	42.1	869,921.2	0.00	1.00
10/28/2020 16:00	1	1.8	17.6	14.9	42.5	891,723.5	0.00	1.00
10/28/2020 17:00	1	1.9	18.0	14.4	44.0	899,606.5	0.00	1.00
10/28/2020 18:00	1	1.9	17.8	14.4	42.9	873,482.1	0.00	1.00
10/28/2020 19:00	1	1.8	16.1	14.6	32.4	774,920.3	0.00	1.00
10/28/2020 20:00	1	1.8	16.7	14.7	37.0	825,409.5	0.00	1.00
10/28/2020 21:00	1	1.7	18.6	14.7	45.6	902,936.6	0.00	1.00
10/28/2020 22:00	1	1.8	17.0	14.6	34.9	809,916.7	0.00	1.00
10/28/2020 23:00	1	1.8	16.6	14.5	30.1	725,367.0	0.00	1.00
Average/Sum#:	1	1.9	18.3	14.5	41.3	835,165.5	0.00 #	24.00 #
Minimum:	1	1.7	16.1	14.1	30.1	659,851.9	0.00	1.00
Maximum:	1	2.0	20.0	14.9	51.5	921,728.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/29/2020 00:00	1	1.9	18.3	14.5	31.8	683,428.4	0.00	1.00
10/29/2020 01:00	1	1.9	19.0	14.4	34.1	661,326.6	0.00	1.00
10/29/2020 02:00	1	1.9	18.9	14.5	34.4	659,891.4	0.00	1.00
10/29/2020 03:00	1	1.9	18.9	14.4	34.1	665,750.9	0.00	1.00
10/29/2020 04:00	1	1.9	16.6	14.5	30.5	755,965.1	0.00	1.00
10/29/2020 05:00	1	1.9	18.1	14.6	45.2	897,081.7	0.00	1.00
10/29/2020 06:00	1	1.8	18.0	14.6	43.6	898,603.2	0.00	1.00
10/29/2020 07:00	1	1.8	18.6	14.6	47.5	919,035.9	0.00	1.00
10/29/2020 08:00	2	2.1	21.3	13.6	53.9	945,840.8	0.00	1.00
10/29/2020 09:00	2	2.1	21.9	13.5	54.0	941,941.9	0.00	1.00
10/29/2020 10:00	2	2.1	22.0	13.5	53.4	929,358.0	0.00	1.00
10/29/2020 11:00	1	2.1	20.2	13.5	49.0	930,283.3	0.00	1.00
10/29/2020 12:00	2	2.2	20.7	13.4	49.7	941,251.0	0.00	1.00
10/29/2020 13:00	1	1.9	17.7	14.5	43.2	896,545.0	0.00	1.00
10/29/2020 14:00	1	2.0	18.4	14.0	44.7	921,880.6	0.00	1.00
10/29/2020 15:00	1	1.9	16.9	14.5	41.3	878,571.3	0.00	1.00
10/29/2020 16:00	1	1.8	16.3	14.6	39.9	886,647.9	0.00	1.00
10/29/2020 17:00	1	1.9	17.9	14.2	44.5	910,769.4	0.00	1.00
10/29/2020 18:00	1	1.9	18.0	14.3	44.8	919,174.2	0.00	1.00
10/29/2020 19:00	1	2.0	18.5	14.1	45.0	914,493.5	0.00	1.00
10/29/2020 20:00	1	1.8	16.6	14.7	37.0	845,730.0	0.00	1.00
10/29/2020 21:00	1	1.8	17.7	14.6	30.0	647,542.1	0.00	1.00
10/29/2020 22:00	1	1.8	15.9	14.6	30.8	763,617.1	0.00	1.00
10/29/2020 23:00	1	1.8	16.2	14.6	32.4	769,268.7	0.00	1.00
Average/Sum#:	1	1.9	18.4	14.3	41.5	840,999.9	0.00 #	24.00 #
Minimum:	1	1.8	15.9	13.4	30.0	647,542.1	0.00	1.00
Maximum:	2	2.2	22.0	14.7	54.0	945,840.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/30/2020 00:00	1	1.9	17.1	14.5	30.8	700,974.1	0.00	1.00
10/30/2020 01:00	1	1.9	18.2	14.5	32.1	684,926.2	0.00	1.00
10/30/2020 02:00	1	1.9	18.5	14.4	32.7	672,703.4	0.00	1.00
10/30/2020 03:00	1	1.9	18.2	14.4	32.5	678,813.1	0.00	1.00
10/30/2020 04:00	1	1.9	16.3	14.5	32.0	769,873.3	0.00	1.00
10/30/2020 05:00	1	1.9	18.2	14.5	45.7	889,483.9	0.00	1.00
10/30/2020 06:00	1	1.9	18.1	14.5	44.2	881,994.9	0.00	1.00
10/30/2020 07:00	1	1.9	17.9	14.4	41.5	846,093.6	0.00	1.00
10/30/2020 08:00	1	1.9	18.7	14.3	45.8	888,673.4	0.00	1.00
10/30/2020 09:00	2	2.0	19.9	14.0	50.2	924,460.7	0.00	1.00
10/30/2020 10:00	2	2.1	19.8	13.5	49.9	933,059.2	0.00	1.00
10/30/2020 11:00	2	2.2	20.0	13.5	49.6	940,646.5	0.00	1.00
10/30/2020 12:00	2	2.2	20.5	13.3	50.6	937,875.5	0.00	1.00
10/30/2020 13:00	2	2.5	23.7	12.3	57.4	940,444.2	0.00	1.00
10/30/2020 14:00	2	2.5	23.8	12.4	57.1	940,714.0	0.00	1.00
10/30/2020 15:00	1	1.9	17.3	14.4	39.0	869,268.5	0.00	1.00
10/30/2020 16:00	1	1.8	16.7	14.8	39.1	865,431.3	0.00	1.00
10/30/2020 17:00	1	1.8	17.1	14.8	39.2	850,390.1	0.00	1.00
10/30/2020 18:00	1	1.8	17.1	14.8	39.8	861,390.4	0.00	1.00
10/30/2020 19:00	1	1.9	19.5	14.1	48.2	894,153.6	0.00	1.00
10/30/2020 20:00	1	1.9	18.5	14.5	45.2	883,278.7	0.00	1.00
10/30/2020 21:00	1	1.8	16.8	14.7	37.1	842,637.7	0.00	1.00
10/30/2020 22:00	1	1.8	16.9	14.7	38.5	850,368.4	0.00	1.00
10/30/2020 23:00	1	1.8	16.3	14.7	33.6	805,972.5	0.00	1.00
Average/Sum#:	1	2.0	18.5	14.2	42.2	848,067.8	0.00 #	24.00 #
Minimum:	1	1.8	16.3	12.3	30.8	672,703.4	0.00	1.00
Maximum:	2	2.5	23.8	14.8	57.4	940,714.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/31/2020 00:00	1	1.8	16.2	14.6	30.5	747,531.8	0.00	1.00
10/31/2020 01:00	1	1.9	17.4	14.5	31.5	697,550.5	0.00	1.00
10/31/2020 02:00	1	1.8	18.7	14.4	34.1	660,273.2	0.00	1.00
10/31/2020 03:00	1	1.9	18.3	14.5	32.7	680,646.7	0.00	1.00
10/31/2020 04:00	1	1.9	17.3	14.5	30.4	712,528.6	0.00	1.00
10/31/2020 05:00	1	1.9	16.5	14.6	36.3	822,524.1	0.00	1.00
10/31/2020 06:00	1	1.8	17.2	14.6	41.5	878,822.7	0.00	1.00
10/31/2020 07:00	1	1.9	17.9	14.5	44.3	886,916.3	0.00	1.00
10/31/2020 08:00	2	1.9	19.7	14.0	51.6	924,063.8	0.00	1.00
10/31/2020 09:00	2	2.1	21.1	13.6	53.1	936,086.0	0.00	1.00
10/31/2020 10:00	2	2.1	21.1	13.6	52.2	921,453.8	0.00	1.00
10/31/2020 11:00	2	2.1	21.3	13.5	51.6	903,635.0	0.00	1.00
10/31/2020 12:00	1	1.7	16.7	14.6	39.9	867,519.5	0.00	1.00
10/31/2020 13:00	1	1.7	17.1	14.5	44.3	890,339.8	0.00	1.00
10/31/2020 14:00	2	2.1	22.8	12.5	57.7	943,598.6	0.00	1.00
10/31/2020 15:00	1	1.7	16.8	14.6	38.9	846,869.4	0.00	1.00
10/31/2020 16:00	1	1.8	17.0	14.6	27.4	691,668.0	0.00	1.00
10/31/2020 17:00	1	1.8	16.0	14.7	38.0	885,708.4	0.00	1.00
10/31/2020 18:00	1	1.8	15.7	14.6	34.2	835,566.2	0.00	1.00
10/31/2020 19:00	1	1.8	15.5	14.6	32.6	818,611.5	0.00	1.00
10/31/2020 20:00	1	1.8	15.5	14.6	31.0	773,181.4	0.00	1.00
10/31/2020 21:00	1	1.8	16.8	14.7	38.9	855,890.2	0.00	1.00
10/31/2020 22:00	1	1.8	17.2	14.7	39.8	870,909.7	0.00	1.00
10/31/2020 23:00	1	1.9	16.5	14.6	28.8	715,361.2	0.00	1.00
Average/Sum#:	1	1.9	17.8	14.3	39.2	823,635.7	0.00 #	24.00 #
Minimum:	1	1.7	15.5	12.5	27.4	660,273.2	0.00	1.00
Maximum:	2	2.1	22.8	14.7	57.7	943,598.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/01/2020 00:00	1	1.8	17.7	14.6	31.4	640,586.3	0.00	1.00
11/01/2020 01:00	1	1.8	17.6	14.6	30.9	639,716.8	0.00	1.00
11/01/2020 02:00	1	1.8	17.4	14.6	30.7	639,499.5	0.00	1.00
11/01/2020 03:00	1	1.8	17.3	14.6	30.9	639,282.1	0.00	1.00
11/01/2020 04:00	1	1.8	17.6	14.6	30.4	640,586.3	0.00	1.00
11/01/2020 05:00	1	1.9	17.5	14.5	31.6	635,926.4	0.00	1.00
11/01/2020 06:00	1	1.8	18.6	14.4	34.0	654,584.9	0.00	1.00
11/01/2020 07:00	1	1.8	16.7	14.5	29.6	716,380.1	0.00	1.00
11/01/2020 08:00	1	1.8	15.9	14.6	33.1	785,354.0	0.00	1.00
11/01/2020 09:00	1	1.8	16.7	14.7	38.2	838,882.9	0.00	1.00
11/01/2020 10:00	1	1.8	18.7	14.6	47.2	892,734.3	0.00	1.00
11/01/2020 11:00	1	2.0	21.1	13.6	50.0	919,015.1	0.00	1.00
11/01/2020 12:00	1	2.2	19.6	13.5	47.5	925,101.7	0.00	1.00
11/01/2020 13:00	2	2.3	21.8	12.9	51.4	932,749.2	0.00	1.00
11/01/2020 14:00	2	2.5	23.4	12.4	56.5	943,614.0	0.00	1.00
11/01/2020 15:00	2	2.5	23.6	12.3	57.0	933,437.9	0.00	1.00
11/01/2020 16:00	2	2.5	23.6	12.4	56.8	943,936.2	0.00	1.00
11/01/2020 17:00	1	2.0	17.3	14.3	36.0	825,596.9	0.00	1.00
11/01/2020 18:00	1	1.8	16.6	14.8	37.5	844,104.2	0.00	1.00
11/01/2020 19:00	1	1.8	16.1	14.7	32.7	782,338.9	0.00	1.00
11/01/2020 20:00	1	1.8	17.0	14.7	30.0	655,556.7	0.00	1.00
11/01/2020 21:00	1	1.9	18.1	14.4	44.7	888,861.8	0.00	1.00
11/01/2020 22:00	1	1.8	16.3	14.6	33.3	793,179.3	0.00	1.00
11/01/2020 23:00	1	1.9	17.6	14.6	31.6	663,192.7	0.00	1.00
Average/Sum#:	1	2.0	18.5	14.1	38.9	782,259.1	0.00 #	24.00 #
Minimum:	1	1.8	15.9	12.3	29.6	635,926.4	0.00	1.00
Maximum:	2	2.5	23.6	14.8	57.0	943,936.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/02/2020 00:00	1	1.8	19.0	14.7	34.4	628,168.2	0.00	1.00
11/02/2020 01:00	1	1.8	19.7	14.7	35.4	630,156.1	0.00	1.00
11/02/2020 02:00	1	1.8	18.8	14.6	33.5	628,196.3	0.00	1.00
11/02/2020 03:00	1	1.8	17.4	14.5	31.0	649,834.7	0.00	1.00
11/02/2020 04:00	1	1.9	17.0	14.5	30.0	725,153.0	0.00	1.00
11/02/2020 05:00	1	1.9	16.9	14.5	32.8	745,266.4	0.00	1.00
11/02/2020 06:00	1	1.8	17.2	14.7	42.5	910,446.3	0.00	1.00
11/02/2020 07:00	1	1.9	17.8	14.5	43.7	884,990.5	0.00	1.00
11/02/2020 08:00	1	1.8	18.0	14.5	45.8	878,143.4	0.00	1.00
11/02/2020 09:00	1	1.9	18.9	14.4	47.3	907,401.7	0.00	1.00
11/02/2020 10:00	1	1.9	19.2	14.3	47.0	903,197.6	0.00	1.00
11/02/2020 11:00	2	2.2	22.5	13.2	54.5	908,799.8	0.00	1.00
11/02/2020 12:00	2	2.5	23.9	12.1	58.1	940,856.8	0.00	1.00
11/02/2020 13:00	2	2.6	24.1	12.0	59.8	938,132.6	0.00	1.00
11/02/2020 14:00	2	2.6	24.1	12.0	60.0	938,132.6	0.00	1.00
11/02/2020 15:00	2	2.6	24.1	12.0	59.9	936,747.8	0.00	1.00
11/02/2020 16:00	2	2.6	24.2	12.0	60.3	937,824.9	0.00	1.00
11/02/2020 17:00	2	2.5	24.3	12.1	59.4	941,479.3	0.00	1.00
11/02/2020 18:00	2	2.5	24.3	12.1	59.5	941,479.3	0.00	1.00
11/02/2020 19:00	2	2.3	22.1	12.9	52.2	931,037.4	0.00	1.00
11/02/2020 20:00	1	1.9	15.9	14.5	30.3	802,183.1	0.00	1.00
11/02/2020 21:00	2	2.1	20.1	13.5	49.9	900,118.9	0.00	1.00
11/02/2020 22:00	1	1.9	16.5	14.6	38.0	880,344.2	0.00	1.00
11/02/2020 23:00	1	1.9	16.5	14.5	27.8	709,533.0	0.00	1.00
Average/Sum#:	1	2.1	20.1	13.6	45.5	841,567.7	0.00 #	24.00 #
Minimum:	1	1.8	15.9	12.0	27.8	628,168.2	0.00	1.00
Maximum:	2	2.6	24.3	14.7	60.3	941,479.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/03/2020 00:00	1	1.9	18.0	14.4	32.2	653,742.1	0.00	1.00
11/03/2020 01:00	1	1.8	18.2	14.6	32.7	650,150.5	0.00	1.00
11/03/2020 02:00	1	1.8	17.4	14.6	31.0	641,021.0	0.00	1.00
11/03/2020 03:00	1	1.8	17.8	14.5	32.3	641,275.8	0.00	1.00
11/03/2020 04:00	1	1.8	18.7	14.5	33.8	657,323.7	0.00	1.00
11/03/2020 05:00	1	1.8	16.1	14.6	30.2	757,748.2	0.00	1.00
11/03/2020 06:00	1	1.9	17.8	14.5	43.0	864,663.1	0.00	1.00
11/03/2020 07:00	1	1.8	16.9	14.6	38.4	841,869.9	0.00	1.00
11/03/2020 08:00	2	1.9	19.5	14.2	51.0	920,375.8	0.00	1.00
11/03/2020 09:00	2	2.3	23.5	12.9	58.0	946,957.0	0.00	1.00
11/03/2020 10:00	2	2.4	24.7	12.6	59.7	931,868.5	0.00	1.00
11/03/2020 11:00	2	2.4	25.3	12.5	60.6	923,709.4	0.00	1.00
11/03/2020 12:00	2	2.4	24.6	12.5	57.8	920,448.8	0.00	1.00
11/03/2020 13:00	2	2.4	22.7	12.7	53.0	930,707.6	0.00	1.00
11/03/2020 14:00	2	2.4	22.7	12.7	53.4	938,055.7	0.00	1.00
11/03/2020 15:00	2	2.6	24.3	12.0	59.7	940,594.5	0.00	1.00
11/03/2020 16:00	2	2.6	24.4	12.0	59.9	935,209.1	0.00	1.00
11/03/2020 17:00	2	2.4	22.8	12.7	53.9	939,391.7	0.00	1.00
11/03/2020 18:00	1	2.2	21.0	13.3	48.2	920,757.7	0.00	1.00
11/03/2020 19:00	1	1.9	17.9	14.3	43.0	906,102.5	0.00	1.00
11/03/2020 20:00	1	2.0	18.3	14.1	45.5	928,791.9	0.00	1.00
11/03/2020 21:00	2	2.1	19.9	13.5	49.6	937,500.5	0.00	1.00
11/03/2020 22:00	1	2.1	19.1	13.9	45.8	880,931.1	0.00	1.00
11/03/2020 23:00	1	1.8	15.8	14.5	30.5	781,213.8	0.00	1.00
Average/Sum#:	1	2.1	20.3	13.6	46.0	849,600.4	0.00 #	24.00 #
Minimum:	1	1.8	15.8	12.0	30.2	641,021.0	0.00	1.00
Maximum:	2	2.6	25.3	14.6	60.6	946,957.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/04/2020 00:00	1	1.9	17.5	14.4	30.7	672,071.4	0.00	1.00
11/04/2020 01:00	1	1.8	16.6	14.5	28.5	640,633.8	0.00	1.00
11/04/2020 02:00	1	1.8	16.8	14.5	30.0	635,498.5	0.00	1.00
11/04/2020 03:00	1	1.8	17.4	14.5	31.3	639,564.0	0.00	1.00
11/04/2020 04:00	1	1.8	18.1	14.5	31.9	639,350.0	0.00	1.00
11/04/2020 05:00	1	1.9	16.9	14.5	31.5	714,026.4	0.00	1.00
11/04/2020 06:00	1	1.9	17.9	14.5	32.9	659,249.5	0.00	1.00
11/04/2020 07:00	1	1.8	15.9	14.6	31.2	768,834.0	0.00	1.00
11/04/2020 08:00	1	1.8	16.0	14.6	33.6	780,789.3	0.00	1.00
11/04/2020 09:00	1	1.8	18.8	14.5	48.5	907,885.6	0.00	1.00
11/04/2020 10:00	1	1.9	19.1	14.3	47.7	907,762.4	0.00	1.00
11/04/2020 11:00	1	1.9	19.2	14.2	47.0	902,593.7	0.00	1.00
11/04/2020 12:00	1	2.0	19.6	14.1	48.0	895,764.7	0.00	1.00
11/04/2020 13:00	2	2.2	22.4	13.2	54.2	909,333.4	0.00	1.00
11/04/2020 14:00	2	2.3	24.1	12.8	57.2	906,694.2	0.00	1.00
11/04/2020 15:00	2	2.3	24.4	12.8	57.3	907,201.4	0.00	1.00
11/04/2020 16:00	1	2.1	21.1	13.8	48.3	886,846.9	0.00	1.00
11/04/2020 17:00	1	1.9	17.7	14.6	41.3	851,434.2	0.00	1.00
11/04/2020 18:00	1	1.8	15.8	14.7	32.3	789,406.9	0.00	1.00
11/04/2020 19:00	1	1.8	16.4	14.7	37.5	835,569.7	0.00	1.00
11/04/2020 20:00	1	1.8	16.4	14.7	38.4	851,031.0	0.00	1.00
11/04/2020 21:00	1	1.9	18.5	14.4	46.7	896,446.3	0.00	1.00
11/04/2020 22:00	1	1.9	18.4	14.4	45.1	884,016.1	0.00	1.00
11/04/2020 23:00	1	1.8	16.4	14.7	35.1	827,618.3	0.00	1.00
Average/Sum#:	1	1.9	18.4	14.3	40.3	804,567.6	0.00 #	24.00 #
Minimum:	1	1.8	15.8	12.8	28.5	635,498.5	0.00	1.00
Maximum:	2	2.3	24.4	14.7	57.3	909,333.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/05/2020 00:00	1	1.9	18.1	14.5	32.0	668,236.3	0.00	1.00
11/05/2020 01:00	1	1.9	18.3	14.5	32.7	666,738.5	0.00	1.00
11/05/2020 02:00	1	1.9	18.4	14.5	33.3	666,952.5	0.00	1.00
11/05/2020 03:00	1	1.9	18.7	14.5	33.8	664,812.7	0.00	1.00
11/05/2020 04:00	1	1.8	19.2	14.5	34.1	663,528.9	0.00	1.00
11/05/2020 05:00	1	1.8	18.7	14.5	34.0	657,965.6	0.00	1.00
11/05/2020 06:00	1	1.8	16.2	14.6	31.8	761,443.4	0.00	1.00
11/05/2020 07:00	1	1.7	16.8	14.6	38.3	827,306.2	0.00	1.00
11/05/2020 08:00	1	1.7	17.2	14.7	41.0	867,154.9	0.00	1.00
11/05/2020 09:00	1	1.7	17.3	14.7	41.5	866,492.2	0.00	1.00
11/05/2020 10:00	1	1.8	19.0	14.3	47.6	887,428.5	0.00	1.00
11/05/2020 11:00	1	1.8	19.4	14.2	47.1	888,286.3	0.00	1.00
11/05/2020 12:00	1	1.8	19.4	14.2	46.7	886,446.8	0.00	1.00
11/05/2020 13:00	2	2.1	22.6	13.1	55.1	904,697.9	0.00	1.00
11/05/2020 14:00	2	2.3	25.6	12.3	61.3	903,342.4	0.00	1.00
11/05/2020 15:00	2	2.2	24.2	12.8	56.8	900,269.7	0.00	1.00
11/05/2020 16:00	2	2.2	23.9	12.8	55.9	892,154.6	0.00	1.00
11/05/2020 17:00	1	1.8	18.4	14.5	41.1	839,842.3	0.00	1.00
11/05/2020 18:00	1	1.7	16.1	14.7	33.0	792,499.1	0.00	1.00
11/05/2020 19:00	1	1.7	15.9	14.7	34.0	800,229.8	0.00	1.00
11/05/2020 20:00	1	1.8	18.9	14.0	46.5	891,316.7	0.00	1.00
11/05/2020 21:00	1	1.9	18.5	14.1	45.6	913,889.4	0.00	1.00
11/05/2020 22:00	1	1.8	16.0	14.5	34.4	817,803.1	0.00	1.00
11/05/2020 23:00	1	1.7	15.6	14.6	33.6	810,568.8	0.00	1.00
Average/Sum#:	1	1.9	18.9	14.2	41.3	809,975.3	0.00 #	24.00 #
Minimum:	1	1.7	15.6	12.3	31.8	657,965.6	0.00	1.00
Maximum:	2	2.3	25.6	14.7	61.3	913,889.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/06/2020 00:00	1	1.8	16.6	14.5	28.1	634,428.6	0.00	1.00
11/06/2020 01:00	1	1.8	16.5	14.5	28.7	628,437.4	0.00	1.00
11/06/2020 02:00	1	1.7	16.5	14.5	29.0	629,721.2	0.00	1.00
11/06/2020 03:00	1	1.7	16.7	14.5	29.2	635,712.5	0.00	1.00
11/06/2020 04:00	1	1.7	17.4	14.5	29.8	640,633.8	0.00	1.00
11/06/2020 05:00	1	1.8	17.0	14.4	29.0	661,116.0	0.00	1.00
11/06/2020 06:00	1	1.8	16.5	14.4	28.4	681,130.6	0.00	1.00
11/06/2020 07:00	1	1.9	15.6	14.5	30.4	750,615.7	0.00	1.00
11/06/2020 08:00	1	1.8	17.2	14.6	40.1	843,826.3	0.00	1.00
11/06/2020 09:00	1	1.8	17.2	14.6	38.4	825,784.6	0.00	1.00
11/06/2020 10:00	1	1.8	17.4	14.7	41.0	865,167.0	0.00	1.00
11/06/2020 11:00	1	1.8	17.5	14.7	40.6	862,516.5	0.00	1.00
11/06/2020 12:00	1	1.8	17.4	14.7	40.3	855,669.4	0.00	1.00
11/06/2020 13:00	1	1.8	18.7	14.5	46.2	874,719.8	0.00	1.00
11/06/2020 14:00	1	1.9	19.2	14.4	47.7	887,597.7	0.00	1.00
11/06/2020 15:00	1	1.8	17.6	14.7	40.6	857,657.2	0.00	1.00
11/06/2020 16:00	1	1.8	16.6	14.6	30.8	741,880.2	0.00	1.00
11/06/2020 17:00	1	1.9	19.4	13.9	46.4	814,416.2	0.00	1.00
11/06/2020 18:00	1	1.9	17.4	14.5	29.8	697,122.6	0.00	1.00
11/06/2020 19:00	1	1.8	18.2	14.5	46.0	877,073.5	0.00	1.00
11/06/2020 20:00	1	1.9	17.4	14.5	40.1	851,182.8	0.00	1.00
11/06/2020 21:00	1	1.8	16.9	14.6	38.8	850,782.1	0.00	1.00
11/06/2020 22:00	1	1.8	16.9	14.6	38.5	851,868.9	0.00	1.00
11/06/2020 23:00	1	1.8	16.3	14.5	32.9	783,353.5	0.00	1.00
Average/Sum#:	1	1.8	17.3	14.5	36.3	775,100.6	0.00 #	24.00 #
Minimum:	1	1.7	15.6	13.9	28.1	628,437.4	0.00	1.00
Maximum:	1	1.9	19.4	14.7	47.7	887,597.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/07/2020 00:00	1	1.8	15.8	14.5	29.5	736,065.6	0.00	1.00
11/07/2020 01:00	1	1.9	17.7	14.4	31.7	647,632.4	0.00	1.00
11/07/2020 02:00	1	1.9	16.9	14.5	28.8	629,079.3	0.00	1.00
11/07/2020 03:00	1	1.8	17.1	14.5	29.8	628,865.4	0.00	1.00
11/07/2020 04:00	1	1.8	17.6	14.5	29.8	630,577.1	0.00	1.00
11/07/2020 05:00	1	1.9	17.9	14.5	31.6	638,280.1	0.00	1.00
11/07/2020 06:00	1	1.9	17.9	14.5	31.4	642,773.6	0.00	1.00
11/07/2020 07:00	1	1.9	16.1	14.4	28.7	707,887.1	0.00	1.00
11/07/2020 08:00	1	1.9	16.6	14.6	38.1	843,391.5	0.00	1.00
11/07/2020 09:00	1	1.9	18.6	14.4	45.7	877,906.4	0.00	1.00
11/07/2020 10:00	1	1.9	18.7	14.4	46.4	877,906.4	0.00	1.00
11/07/2020 11:00	1	1.9	18.5	14.5	45.5	882,422.8	0.00	1.00
11/07/2020 12:00	1	1.8	16.9	14.7	38.9	866,050.5	0.00	1.00
11/07/2020 13:00	1	1.8	16.2	14.6	32.8	781,658.7	0.00	1.00
11/07/2020 14:00	1	1.8	16.7	14.7	37.4	829,606.1	0.00	1.00
11/07/2020 15:00	1	1.8	17.1	14.7	37.8	834,686.2	0.00	1.00
11/07/2020 16:00	1	1.9	16.6	14.5	29.6	706,537.4	0.00	1.00
11/07/2020 17:00	1	1.8	16.3	14.6	35.5	794,483.5	0.00	1.00
11/07/2020 18:00	1	1.8	17.6	14.7	42.3	879,965.6	0.00	1.00
11/07/2020 19:00	1	1.8	17.7	14.7	42.7	892,334.6	0.00	1.00
11/07/2020 20:00	1	1.8	17.4	14.6	39.7	859,476.8	0.00	1.00
11/07/2020 21:00	1	1.8	16.8	14.6	36.4	829,262.5	0.00	1.00
11/07/2020 22:00	1	1.8	16.8	14.6	37.5	837,739.9	0.00	1.00
11/07/2020 23:00	1	1.8	16.2	14.5	31.5	766,235.7	0.00	1.00
Average/Sum#:	1	1.8	17.2	14.6	35.8	775,867.7	0.00 #	24.00 #
Minimum:	1	1.8	15.8	14.4	28.7	628,865.4	0.00	1.00
Maximum:	1	1.9	18.7	14.7	46.4	892,334.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/08/2020 00:00	1	1.9	16.4	14.5	30.8	730,074.4	0.00	1.00
11/08/2020 01:00	1	1.9	18.1	14.4	31.2	665,961.6	0.00	1.00
11/08/2020 02:00	1	1.9	18.4	14.4	32.3	640,047.9	0.00	1.00
11/08/2020 03:00	1	1.9	18.4	14.4	32.4	640,890.6	0.00	1.00
11/08/2020 04:00	1	1.8	19.3	14.4	33.2	647,632.4	0.00	1.00
11/08/2020 05:00	1	1.8	18.5	14.4	31.8	660,905.3	0.00	1.00
11/08/2020 06:00	1	1.9	15.9	14.5	30.1	754,467.2	0.00	1.00
11/08/2020 07:00	1	1.8	16.1	14.5	33.5	787,847.0	0.00	1.00
11/08/2020 08:00	1	1.8	17.5	14.6	42.4	874,910.0	0.00	1.00
11/08/2020 09:00	1	1.9	19.0	14.5	32.5	655,184.0	0.00	1.00
11/08/2020 10:00	1	1.8	19.0	14.5	34.2	650,262.6	0.00	1.00
11/08/2020 11:00	1	1.8	17.9	14.5	31.0	690,275.5	0.00	1.00
11/08/2020 12:00	1	1.8	18.0	14.5	32.1	689,633.6	0.00	1.00
11/08/2020 13:00	1	1.8	16.7	14.6	31.4	732,316.0	0.00	1.00
11/08/2020 14:00	1	1.8	19.0	14.5	48.2	891,623.7	0.00	1.00
11/08/2020 15:00	1	1.9	19.8	14.5	49.9	899,968.6	0.00	1.00
11/08/2020 16:00	1	1.9	18.5	14.5	44.5	861,453.5	0.00	1.00
11/08/2020 17:00	1	1.8	17.9	14.6	42.0	857,303.1	0.00	1.00
11/08/2020 18:00	1	1.8	18.1	14.6	44.0	877,518.5	0.00	1.00
11/08/2020 19:00	1	1.9	18.6	14.5	45.8	879,641.2	0.00	1.00
11/08/2020 20:00	1	1.8	17.6	14.6	40.9	859,259.5	0.00	1.00
11/08/2020 21:00	1	1.8	17.4	14.6	38.8	840,565.7	0.00	1.00
11/08/2020 22:00	1	1.8	16.5	14.5	34.3	788,702.9	0.00	1.00
11/08/2020 23:00	1	1.9	16.4	14.5	32.5	763,668.1	0.00	1.00
Average/Sum#:	1	1.8	17.9	14.5	36.7	764,171.4	0.00 #	24.00 #
Minimum:	1	1.8	15.9	14.4	30.1	640,047.9	0.00	1.00
Maximum:	1	1.9	19.8	14.6	49.9	899,968.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/09/2020 00:00	1	1.9	19.0	14.4	33.9	678,181.1	0.00	1.00
11/09/2020 01:00	1	1.9	17.6	14.4	31.4	694,192.8	0.00	1.00
11/09/2020 02:00	1	1.9	19.3	14.4	35.0	680,498.6	0.00	1.00
11/09/2020 03:00	1	1.9	17.4	14.4	31.0	704,305.5	0.00	1.00
11/09/2020 04:00	1	1.8	16.9	14.5	32.3	756,607.0	0.00	1.00
11/09/2020 05:00	1	1.9	17.6	14.5	39.5	826,148.1	0.00	1.00
11/09/2020 06:00	1	1.8	17.6	14.5	39.0	829,357.6	0.00	1.00
11/09/2020 07:00	1	1.8	18.2	14.6	45.0	907,732.7	0.00	1.00
11/09/2020 08:00	1	1.9	18.5	14.5	46.2	901,894.3	0.00	1.00
11/09/2020 09:00	2	1.9	19.6	14.4	51.4	902,556.0	0.00	1.00
11/09/2020 10:00	1	1.9	19.5	14.5	50.7	910,881.2	0.00	1.00
11/09/2020 11:00	1	1.9	19.5	14.5	50.3	914,304.7	0.00	1.00
11/09/2020 12:00	1	1.9	19.2	14.5	49.9	899,326.7	0.00	1.00
11/09/2020 13:00	2	1.9	19.6	14.5	51.2	898,256.8	0.00	1.00
11/09/2020 14:00	1	1.9	19.8	14.4	51.1	907,823.0	0.00	1.00
11/09/2020 15:00	1	1.8	17.0	14.6	35.2	801,004.6	0.00	1.00
11/09/2020 16:00	1	1.8	16.7	14.6	35.0	783,615.1	0.00	1.00
11/09/2020 17:00	1	1.8	16.7	14.6	35.1	783,832.4	0.00	1.00
11/09/2020 18:00	1	1.8	16.6	14.6	35.4	789,701.4	0.00	1.00
11/09/2020 19:00	1	1.8	16.6	14.6	35.1	792,961.9	0.00	1.00
11/09/2020 20:00	1	1.8	16.5	14.6	35.4	800,569.8	0.00	1.00
11/09/2020 21:00	1	1.8	16.4	14.5	35.9	795,764.0	0.00	1.00
11/09/2020 22:00	1	1.8	17.1	14.5	38.6	827,003.9	0.00	1.00
11/09/2020 23:00	1	1.8	17.6	14.6	42.8	884,474.3	0.00	1.00
Average/Sum#:	1	1.9	17.9	14.5	40.3	819,624.7	0.00 #	24.00 #
Minimum:	1	1.8	16.4	14.4	31.0	678,181.1	0.00	1.00
Maximum:	2	1.9	19.8	14.6	51.4	914,304.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/10/2020 00:00	1	1.9	18.9	14.4	33.1	688,715.1	0.00	1.00
11/10/2020 01:00	1	1.9	16.4	14.5	31.3	746,122.3	0.00	1.00
11/10/2020 02:00	1	1.9	16.3	14.5	31.1	739,703.1	0.00	1.00
11/10/2020 03:00	1	1.9	16.3	14.5	32.1	761,314.4	0.00	1.00
11/10/2020 04:00	1	1.9	17.1	14.5	35.5	807,318.5	0.00	1.00
11/10/2020 05:00	1	1.8	18.0	14.6	44.0	897,081.7	0.00	1.00
11/10/2020 06:00	1	1.8	17.8	14.5	41.4	869,370.5	0.00	1.00
11/10/2020 07:00	1	1.9	18.6	14.4	48.9	911,193.9	0.00	1.00
11/10/2020 08:00	2	2.0	21.1	13.7	54.5	951,369.6	0.00	1.00
11/10/2020 09:00	2	2.0	20.6	14.0	53.5	943,910.5	0.00	1.00
11/10/2020 10:00	1	1.8	17.2	14.6	37.0	831,001.5	0.00	1.00
11/10/2020 11:00	1	1.8	17.4	14.6	39.8	835,566.2	0.00	1.00
11/10/2020 12:00	1	1.8	17.7	14.7	41.9	858,761.6	0.00	1.00
11/10/2020 13:00	1	1.8	19.6	14.5	50.1	906,815.7	0.00	1.00
11/10/2020 14:00	1	1.8	17.3	14.6	36.1	797,091.9	0.00	1.00
11/10/2020 15:00	1	1.7	19.1	14.8	48.9	926,718.7	0.00	1.00
11/10/2020 16:00	1	1.8	17.9	14.7	41.4	879,082.1	0.00	1.00
11/10/2020 17:00	1	1.8	18.1	14.7	42.3	870,688.9	0.00	1.00
11/10/2020 18:00	1	1.8	17.6	14.7	38.6	849,705.7	0.00	1.00
11/10/2020 19:00	1	1.8	18.9	14.7	48.3	925,024.1	0.00	1.00
11/10/2020 20:00	1	1.8	18.0	14.7	42.4	897,193.8	0.00	1.00
11/10/2020 21:00	1	1.8	18.4	14.7	46.0	924,361.5	0.00	1.00
11/10/2020 22:00	1	1.8	18.1	14.6	42.0	878,387.9	0.00	1.00
11/10/2020 23:00	1	1.8	17.0	14.5	31.0	748,904.0	0.00	1.00
Average/Sum#:	1	1.8	18.1	14.5	41.3	851,891.8	0.00 #	24.00 #
Minimum:	1	1.7	16.3	13.7	31.0	688,715.1	0.00	1.00
Maximum:	2	2.0	21.1	14.8	54.5	951,369.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/11/2020 00:00	1	1.8	18.5	14.6	32.7	646,890.0	0.00	1.00
11/11/2020 01:00	2	1.8	20.8	14.6	38.4	631,891.5	0.00	1.00
11/11/2020 02:00	2	1.8	21.3	14.6	38.9	631,674.2	0.00	1.00
11/11/2020 03:00	2	1.8	21.2	14.6	38.6	631,239.4	0.00	1.00
11/11/2020 04:00	1	1.7	21.4	14.6	37.9	638,195.2	0.00	1.00
11/11/2020 05:00	1	1.9	17.4	14.4	29.0	707,044.3	0.00	1.00
11/11/2020 06:00	1	1.9	16.3	14.5	33.5	789,772.7	0.00	1.00
11/11/2020 07:00	1	1.8	17.3	14.6	40.6	869,475.8	0.00	1.00
11/11/2020 08:00	1	1.8	17.7	14.6	43.0	897,951.1	0.00	1.00
11/11/2020 09:00	1	1.9	18.1	14.5	44.4	889,911.9	0.00	1.00
11/11/2020 10:00	1	1.8	18.2	14.5	44.7	875,575.7	0.00	1.00
11/11/2020 11:00	1	1.8	17.0	14.6	37.5	833,827.3	0.00	1.00
11/11/2020 12:00	1	1.8	16.8	14.6	37.3	833,827.3	0.00	1.00
11/11/2020 13:00	1	1.8	16.7	14.6	37.2	834,044.7	0.00	1.00
11/11/2020 14:00	1	1.8	17.0	14.6	38.5	844,695.7	0.00	1.00
11/11/2020 15:00	1	1.9	19.3	14.2	48.9	921,193.4	0.00	1.00
11/11/2020 16:00	1	1.9	17.9	14.4	43.2	874,324.8	0.00	1.00
11/11/2020 17:00	1	1.8	16.0	14.6	33.5	813,177.2	0.00	1.00
11/11/2020 18:00	1	1.8	16.5	14.6	36.5	827,958.3	0.00	1.00
11/11/2020 19:00	1	1.9	16.0	14.5	31.7	768,161.5	0.00	1.00
11/11/2020 20:00	1	1.8	16.9	14.6	39.3	852,521.0	0.00	1.00
11/11/2020 21:00	1	1.8	17.3	14.6	41.2	887,082.7	0.00	1.00
11/11/2020 22:00	1	1.9	16.1	14.5	31.4	779,716.0	0.00	1.00
11/11/2020 23:00	1	1.9	18.6	14.4	34.2	667,436.4	0.00	1.00
Average/Sum#:	1	1.8	17.9	14.5	38.0	789,482.8	0.00 #	24.00 #
Minimum:	1	1.7	16.0	14.2	29.0	631,239.4	0.00	1.00
Maximum:	2	1.9	21.4	14.6	48.9	921,193.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/12/2020 00:00	2	1.9	20.3	14.5	37.9	643,843.4	0.00	1.00
11/12/2020 01:00	2	1.8	23.0	14.6	42.5	629,500.5	0.00	1.00
11/12/2020 02:00	2	1.8	22.5	14.6	41.1	630,152.6	0.00	1.00
11/12/2020 03:00	2	1.8	22.1	14.6	39.7	634,934.7	0.00	1.00
11/12/2020 04:00	1	2.0	18.3	14.5	29.5	664,170.8	0.00	1.00
11/12/2020 05:00	1	1.9	16.9	14.4	31.1	731,061.9	0.00	1.00
11/12/2020 06:00	1	1.9	17.6	14.5	39.6	852,680.7	0.00	1.00
11/12/2020 07:00	1	1.8	18.2	14.6	44.9	920,340.1	0.00	1.00
11/12/2020 08:00	1	1.9	18.7	14.5	46.7	916,016.5	0.00	1.00
11/12/2020 09:00	1	1.8	19.1	14.5	49.6	915,374.6	0.00	1.00
11/12/2020 10:00	1	1.8	16.6	14.6	34.1	816,220.4	0.00	1.00
11/12/2020 11:00	1	1.9	17.6	14.5	31.3	694,554.9	0.00	1.00
11/12/2020 12:00	1	1.8	18.3	14.6	33.7	655,584.8	0.00	1.00
11/12/2020 13:00	1	1.8	18.4	14.6	33.4	656,236.9	0.00	1.00
11/12/2020 14:00	1	1.8	18.3	14.6	33.5	659,714.8	0.00	1.00
11/12/2020 15:00	1	1.8	17.3	14.8	41.2	898,432.2	0.00	1.00
11/12/2020 16:00	1	1.8	17.6	14.7	41.1	876,873.4	0.00	1.00
11/12/2020 17:00	1	1.8	17.7	14.7	42.2	890,346.7	0.00	1.00
11/12/2020 18:00	1	1.8	17.6	14.7	42.3	893,659.8	0.00	1.00
11/12/2020 19:00	1	1.8	18.0	14.7	44.3	917,956.1	0.00	1.00
11/12/2020 20:00	1	1.8	17.9	14.7	43.5	917,514.3	0.00	1.00
11/12/2020 21:00	1	1.8	17.6	14.7	41.5	898,740.0	0.00	1.00
11/12/2020 22:00	1	1.8	16.6	14.5	31.4	769,017.4	0.00	1.00
11/12/2020 23:00	1	1.9	18.2	14.4	33.1	694,403.5	0.00	1.00
Average/Sum#:	1	1.8	18.5	14.6	38.7	782,388.8	0.00 #	24.00 #
Minimum:	1	1.8	16.6	14.4	29.5	629,500.5	0.00	1.00
Maximum:	2	2.0	23.0	14.8	49.6	920,340.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/13/2020 00:00	1	1.9	18.2	14.5	32.0	650,262.6	0.00	1.00
11/13/2020 01:00	1	1.8	19.9	14.6	36.4	631,239.4	0.00	1.00
11/13/2020 02:00	1	1.8	19.5	14.6	34.7	631,891.5	0.00	1.00
11/13/2020 03:00	1	1.8	19.3	14.6	34.6	632,761.0	0.00	1.00
11/13/2020 04:00	1	1.8	20.0	14.6	34.9	631,891.5	0.00	1.00
11/13/2020 05:00	1	1.8	17.8	14.5	30.7	700,760.1	0.00	1.00
11/13/2020 06:00	1	1.9	16.6	14.6	36.6	838,609.4	0.00	1.00
11/13/2020 07:00	1	1.8	18.2	14.5	44.6	893,977.4	0.00	1.00
11/13/2020 08:00	1	1.8	19.0	14.5	47.9	909,383.4	0.00	1.00
11/13/2020 09:00	1	1.9	18.8	14.5	47.7	908,741.5	0.00	1.00
11/13/2020 10:00	1	1.9	18.7	14.4	48.4	907,191.0	0.00	1.00
11/13/2020 11:00	1	2.0	19.8	14.0	49.4	929,819.3	0.00	1.00
11/13/2020 12:00	1	1.9	19.1	14.2	49.2	923,850.5	0.00	1.00
11/13/2020 13:00	1	2.0	19.4	14.0	48.8	944,307.4	0.00	1.00
11/13/2020 14:00	1	1.9	18.5	14.3	47.3	918,759.3	0.00	1.00
11/13/2020 15:00	1	1.9	17.5	14.4	42.9	884,016.1	0.00	1.00
11/13/2020 16:00	1	1.8	16.4	14.6	39.6	894,908.0	0.00	1.00
11/13/2020 17:00	1	1.8	15.3	14.6	30.3	804,917.2	0.00	1.00
11/13/2020 18:00	1	1.8	15.5	14.6	33.0	823,611.0	0.00	1.00
11/13/2020 19:00	1	1.8	15.2	14.5	28.6	760,244.5	0.00	1.00
11/13/2020 20:00	1	1.8	15.7	14.6	36.2	857,085.8	0.00	1.00
11/13/2020 21:00	1	1.8	16.0	14.6	36.7	864,476.3	0.00	1.00
11/13/2020 22:00	1	1.8	16.0	14.6	33.4	820,133.0	0.00	1.00
11/13/2020 23:00	1	1.9	16.9	14.5	29.3	696,908.6	0.00	1.00
Average/Sum#:	1	1.9	17.8	14.5	38.9	810,822.7	0.00 #	24.00 #
Minimum:	1	1.8	15.2	14.0	28.6	631,239.4	0.00	1.00
Maximum:	1	2.0	20.0	14.6	49.4	944,307.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/14/2020 00:00	1	1.9	17.1	14.5	30.3	664,170.8	0.00	1.00
11/14/2020 01:00	1	1.8	19.4	14.6	35.1	627,978.9	0.00	1.00
11/14/2020 02:00	1	1.8	19.0	14.6	33.9	632,761.0	0.00	1.00
11/14/2020 03:00	1	1.8	19.0	14.6	34.1	633,195.8	0.00	1.00
11/14/2020 04:00	1	1.8	19.8	14.6	34.6	632,761.0	0.00	1.00
11/14/2020 05:00	1	1.8	19.1	14.6	34.0	636,673.7	0.00	1.00
11/14/2020 06:00	1	1.9	17.6	14.5	30.9	678,293.0	0.00	1.00
11/14/2020 07:00	1	1.9	15.2	14.5	29.4	784,423.4	0.00	1.00
11/14/2020 08:00	1	1.8	16.5	14.6	38.9	872,084.2	0.00	1.00
11/14/2020 09:00	1	1.9	18.4	14.3	45.9	918,759.3	0.00	1.00
11/14/2020 10:00	1	1.9	15.5	14.5	29.4	775,222.6	0.00	1.00
11/14/2020 11:00	1	1.8	16.9	14.5	31.8	711,886.7	0.00	1.00
11/14/2020 12:00	1	1.8	15.8	14.6	30.1	747,749.2	0.00	1.00
11/14/2020 13:00	1	1.8	17.3	14.6	44.3	900,994.3	0.00	1.00
11/14/2020 14:00	1	1.8	17.3	14.7	41.9	904,261.8	0.00	1.00
11/14/2020 15:00	1	1.8	17.1	14.7	40.8	882,837.0	0.00	1.00
11/14/2020 16:00	1	1.9	19.0	14.2	46.4	894,418.1	0.00	1.00
11/14/2020 17:00	1	1.8	16.4	14.7	37.7	863,620.9	0.00	1.00
11/14/2020 18:00	1	1.8	16.9	14.6	39.1	865,345.8	0.00	1.00
11/14/2020 19:00	1	1.8	16.7	14.6	37.6	850,130.0	0.00	1.00
11/14/2020 20:00	1	1.8	18.2	14.7	46.3	934,080.0	0.00	1.00
11/14/2020 21:00	1	1.9	18.0	14.5	44.3	907,457.6	0.00	1.00
11/14/2020 22:00	1	2.0	19.5	14.0	49.2	939,544.2	0.00	1.00
11/14/2020 23:00	1	1.9	16.1	14.5	30.6	782,925.6	0.00	1.00
Average/Sum#:	1	1.8	17.6	14.5	37.4	793,399.0	0.00 #	24.00 #
Minimum:	1	1.8	15.2	14.0	29.4	627,978.9	0.00	1.00
Maximum:	1	2.0	19.8	14.7	49.2	939,544.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/15/2020 00:00	1	1.8	18.5	14.6	32.8	659,932.1	0.00	1.00
11/15/2020 01:00	1	1.8	18.1	14.5	32.0	642,559.6	0.00	1.00
11/15/2020 02:00	1	1.9	16.0	14.5	28.5	743,554.6	0.00	1.00
11/15/2020 03:00	1	1.9	16.1	14.5	30.3	745,694.4	0.00	1.00
11/15/2020 04:00	1	1.8	18.8	14.5	33.3	636,354.4	0.00	1.00
11/15/2020 05:00	1	1.9	18.8	14.4	33.8	679,655.9	0.00	1.00
11/15/2020 06:00	1	1.9	16.0	14.5	29.9	762,384.2	0.00	1.00
11/15/2020 07:00	1	1.9	16.1	14.5	30.9	759,388.6	0.00	1.00
11/15/2020 08:00	1	1.8	16.5	14.6	36.3	833,609.9	0.00	1.00
11/15/2020 09:00	1	1.8	16.7	14.6	37.7	853,390.5	0.00	1.00
11/15/2020 10:00	1	1.8	17.1	14.7	41.0	893,880.7	0.00	1.00
11/15/2020 11:00	1	1.9	18.9	14.5	46.6	904,890.0	0.00	1.00
11/15/2020 12:00	1	1.9	18.6	14.5	45.6	875,575.7	0.00	1.00
11/15/2020 13:00	1	1.8	19.3	14.5	48.4	888,628.0	0.00	1.00
11/15/2020 14:00	1	1.9	20.1	14.2	49.6	913,426.5	0.00	1.00
11/15/2020 15:00	2	2.0	20.9	13.8	51.2	915,778.4	0.00	1.00
11/15/2020 16:00	2	2.0	20.2	14.1	50.6	913,889.4	0.00	1.00
11/15/2020 17:00	1	1.9	19.5	14.4	49.2	902,977.4	0.00	1.00
11/15/2020 18:00	1	1.9	18.8	14.5	47.5	883,920.6	0.00	1.00
11/15/2020 19:00	2	1.9	19.2	14.2	50.2	921,397.8	0.00	1.00
11/15/2020 20:00	1	2.0	19.0	14.2	49.7	924,668.0	0.00	1.00
11/15/2020 21:00	1	1.9	17.7	14.4	41.9	853,256.7	0.00	1.00
11/15/2020 22:00	1	1.8	16.2	14.5	30.5	751,043.7	0.00	1.00
11/15/2020 23:00	1	1.9	17.9	14.4	32.0	683,237.4	0.00	1.00
Average/Sum#:	1	1.9	18.1	14.4	40.0	814,295.6	0.00 #	24.00 #
Minimum:	1	1.8	16.0	13.8	28.5	636,354.4	0.00	1.00
Maximum:	2	2.0	20.9	14.7	51.2	924,668.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOX, Ppm	Unit CT2 NOX, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/16/2020 00:00	1	1.9	17.0	14.5	29.5	639,136.0	0.00	1.00
11/16/2020 01:00	1	1.9	17.5	14.6	31.0	644,933.7	0.00	1.00
11/16/2020 02:00	1	1.8	19.5	14.6	35.2	636,673.7	0.00	1.00
11/16/2020 03:00	1	1.9	18.6	14.5	32.6	632,716.9	0.00	1.00
11/16/2020 04:00	1	1.8	18.6	14.5	31.9	637,210.3	0.00	1.00
11/16/2020 05:00	1	1.8	17.9	14.4	31.4	696,721.0	0.00	1.00
11/16/2020 06:00	1	1.9	17.4	14.6	42.4	915,123.3	0.00	1.00
11/16/2020 07:00	1	1.9	18.7	14.4	46.7	908,665.7	0.00	1.00
11/16/2020 08:00	1	1.9	19.1	14.4	48.3	916,671.6	0.00	1.00
11/16/2020 09:00	1	1.9	19.1	14.4	47.8	929,733.8	0.00	1.00
11/16/2020 10:00	1	1.9	19.1	14.4	48.1	916,039.6	0.00	1.00
11/16/2020 11:00	1	1.9	19.4	14.3	47.7	923,739.0	0.00	1.00
11/16/2020 12:00	1	1.9	19.7	14.2	47.5	917,309.9	0.00	1.00
11/16/2020 13:00	1	2.0	19.8	14.1	47.6	909,458.9	0.00	1.00
11/16/2020 14:00	1	2.0	19.0	14.3	46.2	892,200.7	0.00	1.00
11/16/2020 15:00	1	1.8	18.5	14.5	45.2	865,519.0	0.00	1.00
11/16/2020 16:00	1	1.8	16.6	14.6	31.0	764,051.9	0.00	1.00
11/16/2020 17:00	1	1.8	16.9	14.7	40.6	876,210.7	0.00	1.00
11/16/2020 18:00	1	1.8	16.9	14.7	39.5	872,897.6	0.00	1.00
11/16/2020 19:00	1	1.9	18.4	14.5	46.0	896,545.0	0.00	1.00
11/16/2020 20:00	1	1.9	18.8	14.4	47.2	894,550.1	0.00	1.00
11/16/2020 21:00	1	1.9	18.9	14.3	45.3	897,595.4	0.00	1.00
11/16/2020 22:00	1	1.9	15.9	14.5	28.8	754,253.3	0.00	1.00
11/16/2020 23:00	1	1.9	18.7	14.4	33.2	659,009.1	0.00	1.00
Average/Sum#:	1	1.9	18.3	14.5	40.4	816,540.3	0.00 #	24.00 #
Minimum:	1	1.8	15.9	14.1	28.8	632,716.9	0.00	1.00
Maximum:	1	2.0	19.8	14.7	48.3	929,733.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/17/2020 00:00	1	1.9	17.9	14.5	30.9	647,053.0	0.00	1.00
11/17/2020 01:00	1	1.8	17.2	14.6	28.8	639,716.8	0.00	1.00
11/17/2020 02:00	1	1.8	17.9	14.6	31.3	631,239.4	0.00	1.00
11/17/2020 03:00	1	1.8	17.7	14.6	29.9	632,543.6	0.00	1.00
11/17/2020 04:00	1	1.8	17.5	14.6	28.9	635,586.8	0.00	1.00
11/17/2020 05:00	1	1.8	17.6	14.5	30.2	691,559.3	0.00	1.00
11/17/2020 06:00	1	1.8	15.9	14.5	29.3	746,550.3	0.00	1.00
11/17/2020 07:00	1	1.8	16.5	14.6	34.3	803,395.6	0.00	1.00
11/17/2020 08:00	1	1.9	17.9	14.5	41.9	876,859.6	0.00	1.00
11/17/2020 09:00	1	1.9	19.0	14.3	45.1	903,612.6	0.00	1.00
11/17/2020 10:00	1	1.9	18.9	14.3	46.8	907,554.9	0.00	1.00
11/17/2020 11:00	1	1.9	19.2	14.3	45.2	911,912.1	0.00	1.00
11/17/2020 12:00	1	1.9	19.3	14.2	45.9	902,593.7	0.00	1.00
11/17/2020 13:00	1	1.9	19.0	14.2	43.8	898,097.1	0.00	1.00
11/17/2020 14:00	1	1.9	17.4	14.5	40.0	879,427.2	0.00	1.00
11/17/2020 15:00	1	1.9	16.5	14.4	35.8	833,031.4	0.00	1.00
11/17/2020 16:00	1	1.9	16.3	14.4	35.9	831,978.0	0.00	1.00
11/17/2020 17:00	1	1.9	16.2	14.4	35.8	832,399.3	0.00	1.00
11/17/2020 18:00	1	1.9	16.0	14.4	36.2	834,927.5	0.00	1.00
11/17/2020 19:00	1	1.8	15.1	14.5	28.3	772,868.9	0.00	1.00
11/17/2020 20:00	1	1.8	15.4	14.6	32.9	823,176.2	0.00	1.00
11/17/2020 21:00	1	1.8	15.1	14.5	29.4	776,934.4	0.00	1.00
11/17/2020 22:00	1	1.8	15.1	14.5	27.3	744,624.5	0.00	1.00
11/17/2020 23:00	1	1.9	16.9	14.5	29.4	656,039.9	0.00	1.00
Average/Sum#:	1	1.9	17.1	14.5	35.1	783,903.4	0.00 #	24.00 #
Minimum:	1	1.8	15.1	14.2	27.3	631,239.4	0.00	1.00
Maximum:	1	1.9	19.3	14.6	46.8	911,912.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/18/2020 00:00	1	1.9	16.8	14.5	27.9	641,703.7	0.00	1.00
11/18/2020 01:00	1	1.8	17.3	14.6	29.3	625,370.5	0.00	1.00
11/18/2020 02:00	1	1.8	17.4	14.6	29.1	626,022.6	0.00	1.00
11/18/2020 03:00	1	1.8	17.4	14.6	29.1	626,239.9	0.00	1.00
11/18/2020 04:00	1	1.8	18.1	14.6	29.8	627,109.4	0.00	1.00
11/18/2020 05:00	1	1.9	17.6	14.4	29.8	650,581.9	0.00	1.00
11/18/2020 06:00	1	1.8	15.1	14.5	26.2	744,410.5	0.00	1.00
11/18/2020 07:00	1	1.8	16.0	14.6	36.3	867,084.7	0.00	1.00
11/18/2020 08:00	1	1.9	18.0	14.3	42.8	904,650.0	0.00	1.00
11/18/2020 09:00	1	1.9	17.9	14.3	42.5	905,895.0	0.00	1.00
11/18/2020 10:00	1	1.9	17.9	14.3	42.7	912,742.1	0.00	1.00
11/18/2020 11:00	1	1.9	17.9	14.3	42.8	916,476.9	0.00	1.00
11/18/2020 12:00	1	1.9	18.1	14.2	43.7	909,747.5	0.00	1.00
11/18/2020 13:00	1	1.8	16.8	14.7	40.0	906,028.8	0.00	1.00
11/18/2020 14:00	1	1.8	16.7	14.7	39.6	903,378.3	0.00	1.00
11/18/2020 15:00	1	1.8	16.8	14.7	39.8	903,820.1	0.00	1.00
11/18/2020 16:00	1	1.8	16.9	14.7	39.8	903,157.5	0.00	1.00
11/18/2020 17:00	1	1.8	16.9	14.7	39.7	903,378.3	0.00	1.00
11/18/2020 18:00	1	1.8	16.9	14.7	38.3	891,230.2	0.00	1.00
11/18/2020 19:00	1	1.9	15.9	14.6	32.8	824,480.4	0.00	1.00
11/18/2020 20:00	1	1.8	17.5	14.5	42.2	888,200.1	0.00	1.00
11/18/2020 21:00	1	1.8	15.8	14.5	29.5	774,366.7	0.00	1.00
11/18/2020 22:00	1	1.8	15.8	14.5	29.5	758,318.8	0.00	1.00
11/18/2020 23:00	1	1.9	18.2	14.4	32.0	670,175.2	0.00	1.00
Average/Sum#:	1	1.8	17.1	14.5	35.6	803,523.7	0.00 #	24.00 #
Minimum:	1	1.8	15.1	14.2	26.2	625,370.5	0.00	1.00
Maximum:	1	1.9	18.2	14.7	43.7	916,476.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/19/2020 00:00	1	1.9	18.9	14.5	33.7	645,127.3	0.00	1.00
11/19/2020 01:00	1	1.8	20.7	14.6	35.9	627,326.8	0.00	1.00
11/19/2020 02:00	1	1.8	20.9	14.6	36.4	626,892.1	0.00	1.00
11/19/2020 03:00	1	1.8	21.0	14.6	36.6	626,674.7	0.00	1.00
11/19/2020 04:00	1	1.8	21.4	14.6	36.4	632,761.0	0.00	1.00
11/19/2020 05:00	1	1.9	18.4	14.4	30.2	690,611.3	0.00	1.00
11/19/2020 06:00	1	1.9	15.8	14.5	29.7	785,921.2	0.00	1.00
11/19/2020 07:00	1	1.8	17.7	14.6	42.4	899,472.7	0.00	1.00
11/19/2020 08:00	1	1.8	18.8	14.6	46.0	940,555.4	0.00	1.00
11/19/2020 09:00	1	1.9	19.1	14.3	46.3	923,324.0	0.00	1.00
11/19/2020 10:00	1	1.8	17.0	14.6	37.2	870,997.4	0.00	1.00
11/19/2020 11:00	1	1.8	16.9	14.7	38.4	881,953.5	0.00	1.00
11/19/2020 12:00	1	1.8	16.9	14.7	38.2	882,837.0	0.00	1.00
11/19/2020 13:00	1	1.8	17.1	14.7	38.9	879,965.6	0.00	1.00
11/19/2020 14:00	1	1.8	17.4	14.7	41.7	907,354.1	0.00	1.00
11/19/2020 15:00	1	1.8	17.2	14.7	38.8	880,407.4	0.00	1.00
11/19/2020 16:00	1	1.8	17.0	14.6	36.3	844,695.7	0.00	1.00
11/19/2020 17:00	1	1.8	17.4	14.7	40.5	888,800.6	0.00	1.00
11/19/2020 18:00	1	1.9	19.0	14.3	43.8	878,714.0	0.00	1.00
11/19/2020 19:00	1	1.9	16.5	14.6	33.3	799,483.0	0.00	1.00
11/19/2020 20:00	1	1.8	16.5	14.6	33.9	813,177.2	0.00	1.00
11/19/2020 21:00	1	1.8	16.5	14.6	34.6	826,002.0	0.00	1.00
11/19/2020 22:00	1	1.8	16.3	14.5	33.1	798,331.6	0.00	1.00
11/19/2020 23:00	1	1.9	17.6	14.4	31.4	703,673.5	0.00	1.00
Average/Sum#:	1	1.8	18.0	14.6	37.2	802,294.1	0.00 #	24.00 #
Minimum:	1	1.8	15.8	14.3	29.7	626,674.7	0.00	1.00
Maximum:	1	1.9	21.4	14.7	46.3	940,555.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/20/2020 00:00	1	1.8	17.8	14.5	30.4	651,546.4	0.00	1.00
11/20/2020 01:00	2	1.9	21.4	14.6	39.7	634,282.6	0.00	1.00
11/20/2020 02:00	2	1.8	22.7	14.6	41.0	632,978.4	0.00	1.00
11/20/2020 03:00	2	1.8	23.8	14.6	43.4	634,717.3	0.00	1.00
11/20/2020 04:00	1	1.9	19.2	14.4	31.3	659,851.9	0.00	1.00
11/20/2020 05:00	1	1.9	17.1	14.4	29.3	741,806.7	0.00	1.00
11/20/2020 06:00	1	1.9	18.7	14.4	45.3	914,143.4	0.00	1.00
11/20/2020 07:00	1	1.9	19.1	14.4	46.6	919,199.8	0.00	1.00
11/20/2020 08:00	1	2.0	18.2	14.4	46.3	916,882.3	0.00	1.00
11/20/2020 09:00	2	2.0	19.4	13.7	53.8	966,585.4	0.00	1.00
11/20/2020 10:00	2	2.1	18.2	13.9	51.5	955,271.3	0.00	1.00
11/20/2020 11:00	2	1.9	17.1	14.3	49.7	938,885.7	0.00	1.00
11/20/2020 12:00	1	1.8	15.4	14.7	41.5	891,892.8	0.00	1.00
11/20/2020 13:00	1	1.8	15.2	14.7	39.8	864,504.4	0.00	1.00
11/20/2020 14:00	1	1.8	15.2	14.7	38.9	851,914.5	0.00	1.00
11/20/2020 15:00	1	1.8	15.1	14.7	39.7	860,307.7	0.00	1.00
11/20/2020 16:00	1	1.8	15.2	14.7	41.3	873,118.5	0.00	1.00
11/20/2020 17:00	2	1.8	16.7	14.5	48.8	920,296.0	0.00	1.00
11/20/2020 18:00	1	1.9	15.7	14.5	43.1	876,859.6	0.00	1.00
11/20/2020 19:00	2	1.9	15.5	14.4	42.1	855,152.9	0.00	1.00
11/20/2020 20:00	2	1.9	15.6	14.5	44.0	890,553.8	0.00	1.00
11/20/2020 21:00	2	1.9	15.6	14.4	44.5	887,176.3	0.00	1.00
11/20/2020 22:00	1	1.8	14.6	14.6	37.1	855,781.6	0.00	1.00
11/20/2020 23:00	1	1.8	14.0	14.5	31.9	790,200.7	0.00	1.00
Average/Sum#:	1	1.9	17.4	14.5	41.7	832,662.9	0.00 #	24.00 #
Minimum:	1	1.8	14.0	13.7	29.3	632,978.4	0.00	1.00
Maximum:	2	2.1	23.8	14.7	53.8	966,585.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/21/2020 00:00	1	1.9	14.1	14.5	35.3	821,654.6	0.00	1.00
11/21/2020 01:00	1	1.8	13.9	14.5	31.6	778,646.1	0.00	1.00
11/21/2020 02:00	1	1.9	14.2	14.4	30.7	732,326.0	0.00	1.00
11/21/2020 03:00	1	1.9	14.5	14.4	30.3	719,685.2	0.00	1.00
11/21/2020 04:00	1	1.8	14.2	14.5	31.9	776,292.4	0.00	1.00
11/21/2020 05:00	1	1.9	15.7	14.4	32.8	706,623.0	0.00	1.00
11/21/2020 06:00	1	1.9	16.0	14.4	32.8	705,148.2	0.00	1.00
11/21/2020 07:00	1	1.9	14.6	14.5	36.4	837,274.6	0.00	1.00
11/21/2020 08:00	1	1.8	14.9	14.5	39.9	864,877.1	0.00	1.00
11/21/2020 09:00	1	1.8	15.2	14.6	41.9	905,341.7	0.00	1.00
11/21/2020 10:00	1	1.8	15.3	14.7	42.9	912,655.1	0.00	1.00
11/21/2020 11:00	1	1.8	14.9	14.7	39.4	875,989.9	0.00	1.00
11/21/2020 12:00	1	1.8	14.8	14.7	38.5	856,773.7	0.00	1.00
11/21/2020 13:00	1	1.8	14.8	14.7	38.7	852,356.2	0.00	1.00
11/21/2020 14:00	1	1.8	15.1	14.7	41.5	875,989.9	0.00	1.00
11/21/2020 15:00	1	1.8	15.1	14.7	40.6	877,094.2	0.00	1.00
11/21/2020 16:00	1	1.8	15.1	14.7	40.5	874,443.7	0.00	1.00
11/21/2020 17:00	1	1.8	14.9	14.7	38.3	852,798.0	0.00	1.00
11/21/2020 18:00	1	1.8	15.2	14.7	42.0	894,985.1	0.00	1.00
11/21/2020 19:00	1	1.8	16.2	14.7	46.9	933,859.1	0.00	1.00
11/21/2020 20:00	1	1.8	15.7	14.7	44.8	935,626.1	0.00	1.00
11/21/2020 21:00	2	1.9	15.9	14.4	45.1	890,968.6	0.00	1.00
11/21/2020 22:00	2	1.9	16.7	14.2	48.6	930,799.8	0.00	1.00
11/21/2020 23:00	1	1.8	14.8	14.6	38.9	870,127.9	0.00	1.00
Average/Sum#:	1	1.8	15.1	14.6	38.8	845,097.3	0.00 #	24.00 #
Minimum:	1	1.8	13.9	14.2	30.3	705,148.2	0.00	1.00
Maximum:	2	1.9	16.7	14.7	48.6	935,626.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/22/2020 00:00	1	1.9	15.8	14.4	31.4	665,961.6	0.00	1.00
11/22/2020 01:00	1	1.9	15.7	14.5	32.0	657,537.7	0.00	1.00
11/22/2020 02:00	1	1.9	15.6	14.5	31.8	656,039.9	0.00	1.00
11/22/2020 03:00	1	1.9	15.6	14.5	32.0	656,253.8	0.00	1.00
11/22/2020 04:00	1	1.8	16.1	14.5	32.2	656,467.8	0.00	1.00
11/22/2020 05:00	1	1.8	15.6	14.5	32.1	664,384.8	0.00	1.00
11/22/2020 06:00	1	1.9	14.5	14.4	29.1	714,628.8	0.00	1.00
11/22/2020 07:00	1	1.8	14.4	14.6	36.9	853,390.5	0.00	1.00
11/22/2020 08:00	1	1.9	15.3	14.5	43.6	908,099.5	0.00	1.00
11/22/2020 09:00	2	1.9	16.4	14.2	48.6	924,259.3	0.00	1.00
11/22/2020 10:00	2	2.0	16.9	14.0	48.7	930,216.2	0.00	1.00
11/22/2020 11:00	2	2.0	18.2	14.5	45.5	901,252.4	0.00	1.00
11/22/2020 12:00	1	1.8	17.9	14.5	45.8	896,759.0	0.00	1.00
11/22/2020 13:00	1	1.9	18.1	14.4	46.3	899,395.8	0.00	1.00
11/22/2020 14:00	1	1.9	17.2	14.5	43.9	867,230.8	0.00	1.00
11/22/2020 15:00	2	2.0	19.2	14.0	50.6	921,483.7	0.00	1.00
11/22/2020 16:00	2	2.2	22.4	13.1	55.0	937,880.1	0.00	1.00
11/22/2020 17:00	2	2.1	20.3	13.7	50.9	939,957.7	0.00	1.00
11/22/2020 18:00	2	2.1	19.8	13.7	50.4	931,018.4	0.00	1.00
11/22/2020 19:00	1	1.9	17.8	14.4	46.7	917,514.3	0.00	1.00
11/22/2020 20:00	1	1.9	17.9	14.3	48.0	913,157.1	0.00	1.00
11/22/2020 21:00	1	1.9	18.0	14.3	47.0	909,422.3	0.00	1.00
11/22/2020 22:00	1	1.8	15.7	14.6	34.1	824,263.1	0.00	1.00
11/22/2020 23:00	1	1.9	17.0	14.4	30.5	691,243.3	0.00	1.00
Average/Sum#:	1	1.9	17.1	14.3	41.4	826,575.7	0.00 #	24.00 #
Minimum:	1	1.8	14.4	13.1	29.1	656,039.9	0.00	1.00
Maximum:	2	2.2	22.4	14.6	55.0	939,957.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/23/2020 00:00	1	1.8	16.8	14.5	30.1	645,341.2	0.00	1.00
11/23/2020 01:00	1	1.9	16.8	14.5	30.6	645,555.2	0.00	1.00
11/23/2020 02:00	1	1.8	17.0	14.5	30.7	646,197.1	0.00	1.00
11/23/2020 03:00	1	1.9	16.8	14.5	30.2	645,341.2	0.00	1.00
11/23/2020 04:00	1	1.8	17.4	14.5	30.6	647,053.0	0.00	1.00
11/23/2020 05:00	1	1.9	16.4	14.4	30.5	720,106.5	0.00	1.00
11/23/2020 06:00	1	1.8	16.1	14.6	38.3	860,998.4	0.00	1.00
11/23/2020 07:00	1	1.8	16.6	14.5	37.9	853,108.6	0.00	1.00
11/23/2020 08:00	1	1.9	16.8	14.5	42.0	892,479.5	0.00	1.00
11/23/2020 09:00	1	1.8	16.6	14.6	43.1	909,906.4	0.00	1.00
11/23/2020 10:00	1	1.9	16.9	14.5	43.0	887,344.2	0.00	1.00
11/23/2020 11:00	1	1.9	17.3	14.5	44.7	890,981.7	0.00	1.00
11/23/2020 12:00	1	1.8	17.5	14.5	44.7	881,994.9	0.00	1.00
11/23/2020 13:00	1	1.8	17.4	14.5	44.1	873,863.9	0.00	1.00
11/23/2020 14:00	1	1.8	17.2	14.5	43.5	867,016.8	0.00	1.00
11/23/2020 15:00	1	1.8	17.8	14.5	46.4	885,632.4	0.00	1.00
11/23/2020 16:00	1	1.9	18.4	14.3	46.2	905,895.0	0.00	1.00
11/23/2020 17:00	1	1.9	16.8	14.5	41.5	852,466.7	0.00	1.00
11/23/2020 18:00	1	1.8	17.7	14.5	44.6	885,632.4	0.00	1.00
11/23/2020 19:00	1	1.8	16.5	14.6	39.5	857,955.2	0.00	1.00
11/23/2020 20:00	1	1.8	16.3	14.6	37.9	851,216.8	0.00	1.00
11/23/2020 21:00	1	1.8	16.3	14.6	37.4	849,477.9	0.00	1.00
11/23/2020 22:00	1	1.8	15.9	14.6	34.7	826,436.7	0.00	1.00
11/23/2020 23:00	1	1.9	16.0	14.5	29.8	730,074.4	0.00	1.00
Average/Sum#:	1	1.8	16.9	14.5	38.4	813,003.2	0.00 #	24.00 #
Minimum:	1	1.8	15.9	14.3	29.8	645,341.2	0.00	1.00
Maximum:	1	1.9	18.4	14.6	46.4	909,906.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOX, Ppm	Unit CT2 NOX, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/24/2020 00:00	1	1.8	17.6	14.5	31.5	643,629.5	0.00	1.00
11/24/2020 01:00	1	1.8	16.9	14.5	30.1	642,131.7	0.00	1.00
11/24/2020 02:00	1	1.9	16.7	14.5	30.3	644,699.3	0.00	1.00
11/24/2020 03:00	1	1.9	17.1	14.5	30.9	643,415.5	0.00	1.00
11/24/2020 04:00	1	1.8	18.0	14.5	31.8	647,053.0	0.00	1.00
11/24/2020 05:00	1	1.8	16.8	14.5	31.8	735,637.7	0.00	1.00
11/24/2020 06:00	1	1.8	17.3	14.5	44.1	909,597.4	0.00	1.00
11/24/2020 07:00	1	1.9	17.2	14.5	42.7	904,248.0	0.00	1.00
11/24/2020 08:00	1	1.9	17.7	14.4	45.2	898,763.8	0.00	1.00
11/24/2020 09:00	1	1.8	17.1	14.6	43.4	913,167.0	0.00	1.00
11/24/2020 10:00	1	1.8	17.1	14.5	42.6	884,562.6	0.00	1.00
11/24/2020 11:00	1	1.9	17.0	14.4	41.5	853,046.1	0.00	1.00
11/24/2020 12:00	1	1.9	17.8	14.4	45.3	886,755.0	0.00	1.00
11/24/2020 13:00	1	1.8	16.9	14.6	43.4	888,821.6	0.00	1.00
11/24/2020 14:00	1	1.8	17.2	14.5	43.1	868,300.6	0.00	1.00
11/24/2020 15:00	1	1.8	17.1	14.5	41.6	857,602.0	0.00	1.00
11/24/2020 16:00	1	1.8	17.5	14.5	43.6	871,082.3	0.00	1.00
11/24/2020 17:00	1	1.9	17.5	14.5	43.6	878,999.3	0.00	1.00
11/24/2020 18:00	1	1.8	16.6	14.7	40.0	879,082.1	0.00	1.00
11/24/2020 19:00	1	1.8	16.4	14.6	37.2	841,652.6	0.00	1.00
11/24/2020 20:00	1	1.8	17.2	14.7	44.5	925,024.1	0.00	1.00
11/24/2020 21:00	1	1.8	17.2	14.7	42.2	914,643.0	0.00	1.00
11/24/2020 22:00	1	1.8	16.7	14.6	37.8	855,781.6	0.00	1.00
11/24/2020 23:00	1	1.9	16.0	14.5	28.8	730,716.3	0.00	1.00
Average/Sum#:	1	1.8	17.1	14.5	39.0	821,600.5	0.00 #	24.00 #
Minimum:	1	1.8	16.0	14.4	28.8	642,131.7	0.00	1.00
Maximum:	1	1.9	18.0	14.7	45.3	925,024.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/25/2020 00:00	1	1.9	17.3	14.4	31.0	684,290.8	0.00	1.00
11/25/2020 01:00	1	1.8	16.8	14.5	30.0	647,053.0	0.00	1.00
11/25/2020 02:00	1	1.8	16.7	14.5	29.9	648,764.8	0.00	1.00
11/25/2020 03:00	1	1.9	17.2	14.4	30.6	693,560.8	0.00	1.00
11/25/2020 04:00	1	1.8	17.5	14.4	31.0	697,985.1	0.00	1.00
11/25/2020 05:00	1	1.9	15.6	14.5	30.1	755,965.1	0.00	1.00
11/25/2020 06:00	1	1.8	17.0	14.5	43.1	901,466.4	0.00	1.00
11/25/2020 07:00	1	1.8	16.5	14.6	37.5	861,433.1	0.00	1.00
11/25/2020 08:00	1	1.8	16.3	14.6	38.7	877,735.8	0.00	1.00
11/25/2020 09:00	1	1.8	16.7	14.6	42.1	905,341.7	0.00	1.00
11/25/2020 10:00	1	1.8	17.8	14.7	46.3	946,007.2	0.00	1.00
11/25/2020 11:00	1	1.8	17.6	14.7	45.2	938,055.7	0.00	1.00
11/25/2020 12:00	1	1.8	17.2	14.7	43.8	925,024.1	0.00	1.00
11/25/2020 13:00	1	1.8	15.8	14.6	33.0	815,133.6	0.00	1.00
11/25/2020 14:00	1	1.8	16.4	14.7	38.2	855,006.7	0.00	1.00
11/25/2020 15:00	1	1.8	17.4	14.8	45.1	926,718.7	0.00	1.00
11/25/2020 16:00	1	1.8	17.4	14.7	42.9	899,402.6	0.00	1.00
11/25/2020 17:00	1	1.8	17.0	14.6	38.6	841,435.2	0.00	1.00
11/25/2020 18:00	1	1.8	17.2	14.7	41.6	880,849.1	0.00	1.00
11/25/2020 19:00	1	1.8	17.2	14.7	41.3	881,732.6	0.00	1.00
11/25/2020 20:00	1	1.8	17.1	14.6	40.6	867,954.2	0.00	1.00
11/25/2020 21:00	1	1.9	17.5	14.5	44.2	887,986.1	0.00	1.00
11/25/2020 22:00	1	1.8	16.9	14.6	40.5	875,779.5	0.00	1.00
11/25/2020 23:00	1	2.4	18.2	14.5	26.8	719,589.7	0.08	1.00
Average/Sum#:	1	1.8	17.0	14.6	38.0	830,594.7	0.08 #	24.00 #
Minimum:	1	1.8	15.6	14.4	26.8	647,053.0	0.00	1.00
Maximum:	1	2.4	18.2	14.8	46.3	946,007.2	0.08	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/26/2020 00:00	0	13.4	33.4	17.1	0.0	406,863.2	0.07	0.07
11/26/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/26/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	13.4	33.4	17.1	0.0	406,863.2	0.07 #	0.07 #
Minimum:	0	13.4	33.4	17.1	0.0	406,863.2	0.00	0.00
Maximum:	0	13.4	33.4	17.1	0.0	406,863.2	0.07	0.07
%SI	100.00	95.83	95.83	95.83	95.83	95.83	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/27/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/27/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/28/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/28/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/29/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/29/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/30/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/30/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/01/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/01/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/02/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/02/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/03/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/03/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/04/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/04/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/05/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/05/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/06/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/06/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/07/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/07/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/08/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/08/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/09/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/09/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/10/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/10/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/11/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/11/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/12/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/12/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/13/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/13/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/14/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/14/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/15/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/15/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/16/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/16/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/17/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/17/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/18/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/18/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/19/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/19/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/20/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/20/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/21/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/21/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/22/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2020 15:00	0	21.6	27.6	17.6	0.0	682,637.3	0.30	0.30
12/22/2020 16:00	2	7.7	19.9	14.6	45.4	926,643.8	0.53	1.00
12/22/2020 17:00	0	1.8	21.2	14.5	35.9	812,239.8	0.00	1.00
12/22/2020 18:00	1	3.7	27.4	14.9	27.3	591,819.6	0.17	0.55
12/22/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/22/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	1	8.7	24.0	15.4	27.2	753,335.1	1.00 #	2.85 #
Minimum:	0	1.8	19.9	14.5	0.0	591,819.6	0.00	0.00
Maximum:	2	21.6	27.6	17.6	45.4	926,643.8	0.53	1.00
%SI	87.50	83.33	83.33	83.33	83.33	83.33	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/23/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/23/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/24/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/24/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/25/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/25/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/26/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/26/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/27/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/27/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/28/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/28/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/29/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/29/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/30/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/30/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:36 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/31/2020 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
12/31/2020 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

AQ-55

AQ-55 The emissions rates from each gas turbine and heat recovery steam generator exhaust during startup and shutdown shall not exceed the following:

Turbine emissions limitations during Startup and Shutdown		
Pollutant	Max Lbs/ Hr (worst case turbine)	Pounds per Startup or Shutdown (both turbines combined)
NO_x	37.1	122.8
CO	89.5	204.8

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 12:18 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
10/01/2020	32.04	128.83	12.37	24.70	41.20
10/02/2020	37.70	110.80	10.63	21.24	35.40
10/03/2020	37.26	113.45	10.83	21.71	36.17
10/04/2020	31.54	126.61	12.04	24.11	40.18
10/05/2020	29.96	129.77	12.47	24.89	41.48
10/06/2020	29.58	126.33	12.11	24.21	40.36
10/07/2020	36.16	123.04	11.69	23.44	39.02
10/08/2020	26.60	72.18	6.85	13.71	22.80
10/09/2020	18.68	64.29	6.12	12.24	20.43
10/10/2020	37.04	63.33	5.09	10.18	17.03
10/11/2020	14.62	58.73	5.62	11.24	18.76
10/12/2020	18.41	64.20	6.16	12.27	20.48
10/13/2020	37.78	108.80	10.71	21.47	35.71
10/14/2020	28.78	124.11	11.86	23.70	39.52
10/15/2020	41.98	108.68	10.11	20.24	33.73
10/16/2020	29.49	123.57	11.89	23.74	39.62
10/17/2020	31.44	119.97	11.44	22.86	38.07
10/18/2020	37.04	115.83	11.09	22.22	37.04
10/19/2020	37.58	119.41	11.81	23.59	39.37
10/20/2020	33.39	122.46	11.68	23.32	38.87
10/21/2020	33.46	103.89	9.96	19.90	33.10
10/22/2020	35.35	110.14	10.66	21.30	35.41
10/23/2020	45.98	105.28	10.02	20.03	33.31
10/24/2020	19.31	58.09	5.58	11.12	18.57
10/25/2020	22.17	63.02	6.00	11.97	19.95
10/26/2020	18.74	70.73	6.73	13.43	22.38
10/27/2020	25.70	59.82	5.72	11.44	19.03
10/28/2020	29.48	59.42	5.61	11.29	18.79
10/29/2020	28.36	61.90	5.90	11.78	19.69
10/30/2020	28.36	63.68	6.02	12.02	20.07
10/31/2020	26.13	58.71	5.71	11.41	19.04
Monthly Avg/Sum*:	940.11 *	2,939.07 *	280.48 *	560.77 *	934.58 *
Daily Min:	14.62	58.09	5.09	10.18	17.03
Daily Max:	45.98	129.77	12.47	24.89	41.48
Oct 2020 - Oct 2020	940.11	2,939.07	280.48	560.77	934.58
QTD:	940.11 *	2,939.07 *	280.48 *	560.77 *	934.58 *
YTD 2020:	4,136.69 *	13,982.18 *	1,319.05 *	2,638.18 *	4,395.42 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 12:18 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
11/01/2020	22.05	59.02	5.65	11.24	18.74
11/02/2020	25.02	68.39	6.52	13.03	21.72
11/03/2020	22.06	69.00	6.59	13.16	21.95
11/04/2020	25.74	58.94	5.63	11.25	18.79
11/05/2020	23.48	57.64	5.79	11.48	19.19
11/06/2020	22.66	53.49	5.21	10.42	17.32
11/07/2020	24.13	54.36	5.20	10.33	17.25
11/08/2020	25.80	53.58	5.10	10.24	17.12
11/09/2020	30.19	57.78	5.50	11.01	18.36
11/10/2020	27.77	59.60	5.71	11.42	19.04
11/11/2020	26.25	55.03	5.28	10.58	17.63
11/12/2020	26.64	54.55	5.19	10.38	17.29
11/13/2020	29.66	57.27	5.49	10.95	18.30
11/14/2020	26.10	55.72	5.30	10.64	17.73
11/15/2020	29.68	58.41	5.54	11.13	18.54
11/16/2020	33.26	58.52	5.55	11.10	18.49
11/17/2020	24.10	55.50	5.32	10.62	17.72
11/18/2020	19.38	56.27	5.41	10.79	18.00
11/19/2020	16.49	55.86	5.32	10.69	17.82
11/20/2020	26.00	59.46	5.63	11.29	18.82
11/21/2020	21.74	58.98	5.60	11.29	18.75
11/22/2020	23.55	60.68	5.74	11.54	19.21
11/23/2020	25.27	56.90	5.46	10.92	18.17
11/24/2020	26.87	57.33	5.50	11.00	18.33
11/25/2020	18.50	58.11	5.49	11.00	18.35
11/26/2020	15.65	0.61	0.00	0.01	0.02
11/27/2020	0.00	0.00	0.00	0.00	0.00
11/28/2020	0.00	0.00	0.00	0.00	0.00
11/29/2020	0.00	0.00	0.00	0.00	0.00
11/30/2020	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	638.04 *	1,451.00 *	138.72 *	277.51 *	462.65 *
Daily Min:	15.65	0.61	0.00	0.01	0.02
Daily Max:	33.26	69.00	6.59	13.16	21.95
Oct 2020 - Nov 2020	1,578.15	4,390.07	419.20	838.28	1,397.23
QTD:	1,578.15 *	4,390.07 *	419.20 *	838.28 *	1,397.23 *
YTD 2020:	4,774.73 *	15,433.18 *	1,457.77 *	2,915.69 *	4,858.07 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 12:18 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
12/01/2020	0.00	0.00	0.00	0.00	0.00
12/02/2020	0.00	0.00	0.00	0.00	0.00
12/03/2020	0.00	0.00	0.00	0.00	0.00
12/04/2020	0.00	0.00	0.00	0.00	0.00
12/05/2020	0.00	0.00	0.00	0.00	0.00
12/06/2020	0.00	0.00	0.00	0.00	0.00
12/07/2020	0.00	0.00	0.00	0.00	0.00
12/08/2020	0.00	0.00	0.00	0.00	0.00
12/09/2020	0.00	0.00	0.00	0.00	0.00
12/10/2020	0.00	0.00	0.00	0.00	0.00
12/11/2020	0.00	0.00	0.00	0.00	0.00
12/12/2020	0.00	0.00	0.00	0.00	0.00
12/13/2020	0.00	0.00	0.00	0.00	0.00
12/14/2020	0.00	0.00	0.00	0.00	0.00
12/15/2020	0.00	0.00	0.00	0.00	0.00
12/16/2020	0.00	0.00	0.00	0.00	0.00
12/17/2020	0.00	0.00	0.00	0.00	0.00
12/18/2020	0.00	0.00	0.00	0.00	0.00
12/19/2020	0.00	0.00	0.00	0.00	0.00
12/20/2020	0.00	0.00	0.00	0.00	0.00
12/21/2020	0.00	0.00	0.00	0.00	0.00
12/22/2020	104.87	39.49	1.21	2.42	4.01
12/23/2020	0.00	0.00	0.00	0.00	0.00
12/24/2020	0.00	0.00	0.00	0.00	0.00
12/25/2020	0.00	0.00	0.00	0.00	0.00
12/26/2020	0.00	0.00	0.00	0.00	0.00
12/27/2020	0.00	0.00	0.00	0.00	0.00
12/28/2020	0.00	0.00	0.00	0.00	0.00
12/29/2020	0.00	0.00	0.00	0.00	0.00
12/30/2020	0.00	0.00	0.00	0.00	0.00
12/31/2020	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	104.87 *	39.49 *	1.21 *	2.42 *	4.01 *
Daily Min:	104.87	39.49	1.21	2.42	4.01
Daily Max:	104.87	39.49	1.21	2.42	4.01
Oct 2020 - Dec 2020	1,683.02	4,429.56	420.41	840.70	1,401.24
QTD:	1,683.02 *	4,429.56 *	420.41 *	840.70 *	1,401.24 *
YTD 2020:	4,879.60 *	15,472.67 *	1,458.98 *	2,918.11 *	4,862.08 *

Monthly Summary By Day Report



From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/05/2021 12:19 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr	Unit CT1 NOX_SUSD, LbPerHr	Unit CT2 CO_SUSD, LbPerHr	Unit CT2 NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/01/2020	0.0	0.0	0.0	0.0
10/02/2020	0.0	0.0	0.0	0.0
10/03/2020	0.0	0.0	0.0	0.0
10/04/2020	0.0	0.0	0.0	0.0
10/05/2020	0.0	0.0	0.0	0.0
10/06/2020	0.0	0.0	0.0	0.0
10/07/2020	0.0	0.0	0.0	0.0
10/08/2020	5.1	0.8	0.0	0.0
10/09/2020	0.0	0.0	0.0	0.0
10/10/2020	21.0	11.7	1.1	0.0
10/11/2020	0.0	0.0	0.0	0.0
10/12/2020	0.0	0.0	0.0	0.0
10/13/2020	0.0	0.0	0.0	0.0
10/14/2020	0.0	0.0	0.0	0.0
10/15/2020	18.6	4.3	0.0	0.0
10/16/2020	0.0	0.0	0.0	0.0
10/17/2020	0.0	0.0	0.0	0.0
10/18/2020	0.0	0.0	0.0	0.0
10/19/2020	0.0	0.0	0.0	0.0
10/20/2020	0.0	0.0	0.0	0.0
10/21/2020	0.0	0.0	0.0	0.0
10/22/2020	0.0	0.0	0.0	0.0
10/23/2020	5.4	0.8	0.0	0.0
10/24/2020	0.0	0.0	0.0	0.0
10/25/2020	0.0	0.0	0.0	0.0
10/26/2020	0.0	0.0	0.0	0.0
10/27/2020	0.0	0.0	0.0	0.0
10/28/2020	0.0	0.0	0.0	0.0
10/29/2020	0.0	0.0	0.0	0.0
10/30/2020	0.0	0.0	0.0	0.0
10/31/2020	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	50.1 *	17.6 *	1.1 *	0.0 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	21.0	11.7	1.1	0.0
Oct 2020 - Oct 2020	50.1	17.6	1.1	0.0
QTD:	50.1 *	17.6 *	1.1 *	0.0 *
YTD 2020:	530.0 *	145.4 *	255.7 *	116.3 *

Monthly Summary By Day Report



From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/05/2021 12:19 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr	Unit CT1 NOX_SUSD, LbPerHr	Unit CT2 CO_SUSD, LbPerHr	Unit CT2 NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/01/2020	0.0	0.0	0.0	0.0
11/02/2020	0.0	0.0	0.0	0.0
11/03/2020	0.0	0.0	0.0	0.0
11/04/2020	0.0	0.0	0.0	0.0
11/05/2020	0.0	0.0	0.0	0.0
11/06/2020	0.0	0.0	0.0	0.0
11/07/2020	0.0	0.0	0.0	0.0
11/08/2020	0.0	0.0	0.0	0.0
11/09/2020	0.0	0.0	0.0	0.0
11/10/2020	0.0	0.0	0.0	0.0
11/11/2020	0.0	0.0	0.0	0.0
11/12/2020	0.0	0.0	0.0	0.0
11/13/2020	0.0	0.0	0.0	0.0
11/14/2020	0.0	0.0	0.0	0.0
11/15/2020	0.0	0.0	0.0	0.0
11/16/2020	0.0	0.0	0.0	0.0
11/17/2020	0.0	0.0	0.0	0.0
11/18/2020	0.0	0.0	0.0	0.0
11/19/2020	0.0	0.0	0.0	0.0
11/20/2020	0.0	0.0	0.0	0.0
11/21/2020	0.0	0.0	0.0	0.0
11/22/2020	0.0	0.0	0.0	0.0
11/23/2020	0.0	0.0	0.0	0.0
11/24/2020	0.0	0.0	0.0	0.0
11/25/2020	0.0	0.0	0.0	0.6
11/26/2020	0.0	0.0	10.2	0.6
11/27/2020	0.0	0.0	0.0	0.0
11/28/2020	0.0	0.0	0.0	0.0
11/29/2020	0.0	0.0	0.0	0.0
11/30/2020	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	- *	- *	10.2 *	1.2 *
Daily Min:	-	-	0.0	0.0
Daily Max:	-	-	10.2	0.6
Oct 2020 - Nov 2020	50.1	17.6	11.3	1.2
QTD:	50.1 *	17.6 *	11.3 *	1.2 *
YTD 2020:	530.0 *	145.4 *	265.9 *	117.5 *

Monthly Summary By Day Report



From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/05/2021 12:19 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr	Unit CT1 NOX_SUSD, LbPerHr	Unit CT2 CO_SUSD, LbPerHr	Unit CT2 NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/01/2020	0.0	0.0	0.0	0.0
12/02/2020	0.0	0.0	0.0	0.0
12/03/2020	0.0	0.0	0.0	0.0
12/04/2020	0.0	0.0	0.0	0.0
12/05/2020	0.0	0.0	0.0	0.0
12/06/2020	0.0	0.0	0.0	0.0
12/07/2020	0.0	0.0	0.0	0.0
12/08/2020	0.0	0.0	0.0	0.0
12/09/2020	0.0	0.0	0.0	0.0
12/10/2020	0.0	0.0	0.0	0.0
12/11/2020	0.0	0.0	0.0	0.0
12/12/2020	0.0	0.0	0.0	0.0
12/13/2020	0.0	0.0	0.0	0.0
12/14/2020	0.0	0.0	0.0	0.0
12/15/2020	0.0	0.0	0.0	0.0
12/16/2020	0.0	0.0	0.0	0.0
12/17/2020	0.0	0.0	0.0	0.0
12/18/2020	0.0	0.0	0.0	0.0
12/19/2020	0.0	0.0	0.0	0.0
12/20/2020	0.0	0.0	0.0	0.0
12/21/2020	0.0	0.0	0.0	0.0
12/22/2020	44.1	12.0	39.6	14.7
12/23/2020	0.0	0.0	0.0	0.0
12/24/2020	0.0	0.0	0.0	0.0
12/25/2020	0.0	0.0	0.0	0.0
12/26/2020	0.0	0.0	0.0	0.0
12/27/2020	0.0	0.0	0.0	0.0
12/28/2020	0.0	0.0	0.0	0.0
12/29/2020	0.0	0.0	0.0	0.0
12/30/2020	0.0	0.0	0.0	0.0
12/31/2020	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	44.1 *	12.0 *	39.6 *	14.7 *
Daily Min:	44.1	12.0	39.6	14.7
Daily Max:	44.1	12.0	39.6	14.7
Oct 2020 - Dec 2020	94.2	29.6	50.9	15.9
QTD:	94.2 *	29.6 *	50.9 *	15.9 *
YTD 2020:	574.1 *	157.4 *	305.5 *	132.2 *

Startup / Shutdown Events

CT1



From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/05/2021 12:14 **Location:** Roseville, CA

Unit offline

Tag Name: CT1_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
10/08/2020 06:00	10/10/2020 14:00	57
10/15/2020 09:00	10/15/2020 14:00	6
10/24/2020 00:00	12/22/2020 16:00	1433
12/22/2020 21:00	12/31/2020 23:00	219

Startup / Shutdown Events

CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 12:14 Location: Roseville, CA

Operating Time Summary

Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	1,715.00 Hour(s)
Offline Percentage:	77.67 %
Total Online:	493.00 Hour(s)
Online Percentage:	22.33 %

Startup / Shutdown Events

CT1



From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/05/2021 12:14 **Location:** Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	10/08/2020 04:54	10/08/2020 05:02	Shutdown	9
2	10/10/2020 15:14	10/10/2020 16:11	cold Startup	58
3	10/15/2020 08:02	10/15/2020 08:02	Shutdown	1
4	10/15/2020 15:20	10/15/2020 15:58	cold Startup	39
5	10/23/2020 22:55	10/23/2020 23:03	Shutdown	9
6	12/22/2020 17:26	12/22/2020 18:24	cold Startup	59
7	12/22/2020 20:00	12/22/2020 20:08	Shutdown	9

Startup / Shutdown Events

CT1



From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/05/2021 12:14 **Location:** Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	3	156	0.53
Warm Startup	0		0.00
Shutdown	4	28	0.10
Total Process Events:	7	184	0.63

Total Report Time:	2,207.98 Hour(s)
Total Operating Time:	488.32 Hour(s)
Total Startup Time:	156 Minute(s)
Total Shutdown Time:	28 Minute(s)
Total Startup/Shutdown Time:	184 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	0.63 %

Startup / Shutdown Events

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 12:17 Location: Roseville, CA

Unit offline

Tag Name: CT2_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
10/10/2020 15:00	10/11/2020 14:00	24
10/11/2020 16:00	10/13/2020 03:00	36
11/26/2020 01:00	12/22/2020 14:00	638
12/22/2020 19:00	12/31/2020 23:00	221

Startup / Shutdown Events

CT2



From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/05/2021 12:17 **Location:** Roseville, CA

Operating Time Summary

Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	919.00 Hour(s)
Offline Percentage:	41.62 %
Total Online:	1,289.00 Hour(s)
Online Percentage:	58.38 %

Startup / Shutdown Events

CT2



From: 10/01/2020 00:00 **To:** 12/31/2020 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/05/2021 12:17 **Location:** Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	10/10/2020 13:52	10/10/2020 13:52	Shutdown	1
2	10/10/2020 14:09	10/10/2020 14:13	Warm Startup	5
3	10/10/2020 14:13	10/10/2020 14:13	Shutdown	1
4	10/10/2020 14:29	10/10/2020 14:32	Cold Startup	4
5	10/10/2020 14:32	10/10/2020 14:32	Shutdown	1
6	10/11/2020 15:11	10/11/2020 15:12	Cold Startup	2
7	10/11/2020 15:12	10/11/2020 15:12	Shutdown	1
8	10/13/2020 04:43	10/13/2020 04:50	Cold Startup	8
9	10/13/2020 04:49	10/13/2020 04:50	Shutdown	2
10	10/13/2020 05:18	10/13/2020 05:25	Cold Startup	8
11	10/13/2020 05:24	10/13/2020 05:25	Shutdown	2
12	10/13/2020 06:25	10/13/2020 06:31	Cold Startup	7
13	10/13/2020 06:31	10/13/2020 06:31	Shutdown	1
14	10/13/2020 06:59	10/13/2020 07:05	Cold Startup	7
15	10/13/2020 07:05	10/13/2020 07:05	Shutdown	1
16	10/13/2020 08:02	10/13/2020 09:03	Cold Startup	62
17	11/25/2020 23:55	11/26/2020 00:03	Shutdown	9
18	12/22/2020 15:42	12/22/2020 16:31	Cold Startup	50
19	12/22/2020 18:23	12/22/2020 18:32	Shutdown	10

Startup / Shutdown Events

CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 12:17 Location: Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	8	148	0.19
Warm Startup	1	5	0.01
Shutdown	10	29	0.04
Total Process Events:	19	182	0.24

Total Report Time:	2,207.98 Hour(s)
Total Operating Time:	1,281.45 Hour(s)
Total Startup Time:	153 Minute(s)
Total Shutdown Time:	29 Minute(s)
Total Startup/Shutdown Time:	182 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	0.24 %

CT1 SUSD EVENT 1

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/08/20 4:49	284266			0.7			1.69			0.43			1.84			0		
10/08/20 4:50	284959.1			0.7			1.69			0.43			1.84			0		
10/08/20 4:51	284497			0.7			1.78			0.43			1.94			0		
10/08/20 4:52	284805.1			0.7			1.78			0.43			1.94			0		
10/08/20 4:53	284574			0.7			1.78			0.43			1.94			0		
10/08/20 4:54	284266			0.7			1.78			0.43			1.94			1		
10/08/20 4:55	268785.8			0.7			1.78			0.41			1.83			1		
10/08/20 4:56	245758			0.7			2.9			0.38			2.73			1		
10/08/20 4:57	227197.1			0.6			6.58			0.31			5.73			1		
10/08/20 4:58	201319.8			0.5			9.36			0.24			7.22			1		
10/08/20 4:59	176597.6			0.5			13.96			0.19			9.44			1		
10/08/20 5:00	155187.2			7.3			15.9			2.64			9.46			1		
10/08/20 5:01	135548.1			507.1			16.08			160.05			8.35			1		
10/08/20 5:02	35273.3			1716.6			17.7			141.02			2.39			1		
10/08/20 5:03	0			0			19.54			0			0			0		
10/08/20 5:04	0			0			0.1			0			0			0		
10/08/20 5:05	0			0			0.1			0			0			0		
10/08/20 5:06	0			0			0.1			0			0			0		
10/08/20 5:07	0			0			0.1			0			0			0		

CT1 SUSD EVENT 2

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/10/20 15:09	0			0			0			0			0			0		
10/10/20 15:10	0			0			0			0			0			0		
10/10/20 15:11	0			0			0			0			0			0		
10/10/20 15:12	0			0			0			0			0			0		
10/10/20 15:13	0			0			0			0			0			0		
10/10/20 15:14	0			0			0			0			0			1		
10/10/20 15:15	16327.4			0.2			0			0			0			1		
10/10/20 15:16	36890.7			59			28.52			5.07			4.03			1		
10/10/20 15:17	50599.5			526.7			19.67			62.02			3.81			1		
10/10/20 15:18	71701.9			329.5			26.08			55.02			7.17			1		
10/10/20 15:19	118527.6			156.9			32.45			43.3			14.74			1		
10/10/20 15:20	137165.5			52.4			49.82			16.75			26.19			1		
10/10/20 15:21	151644.5			265.1			58.11			93.6			33.76			1		
10/10/20 15:22	171899.7			1676.1			51.49			670.85			33.92			1		
10/10/20 15:23	195235.5			555.2			63.19			252.3			47.26			1		
10/10/20 15:24	221035.8			56.5			67.85			29.05			57.47			1		
10/10/20 15:25	241830.2			2.7			67.38			1.53			62.43			1		
10/10/20 15:26	270018			1.4			60.14			0.91			62.21			1		
10/10/20 15:27	292352.6			1.4			43.64			0.96			48.88			1		
10/10/20 15:28	309681.2			1.5			23.51			1.1			27.9			1		
10/10/20 15:29	315149.3			1.7			15.02			1.25			18.14			1		
10/10/20 15:30	315072.3			1.7			13.21			1.23			15.95			1		
10/10/20 15:31	314764.3			1.6			10.83			1.16			13.06			1		
10/10/20 15:32	312684.8			1.5			9.83			1.11			11.78			1		
10/10/20 15:33	312222.8			1.4			8.22			1.04			9.84			1		
10/10/20 15:34	311991.7			1.4			7.44			0.99			8.9			1		
10/10/20 15:35	311375.6			1.2			6.99			0.86			8.34			1		
10/10/20 15:36	310990.5			1.1			6.72			0.79			8			1		
10/10/20 15:37	310297.3			1.1			6.17			0.79			7.34			1		
10/10/20 15:38	309912.3			1			6.08			0.72			7.22			1		
10/10/20 15:39	309681.2			1			6.08			0.72			7.22			1		
10/10/20 15:40	308911.1			0.9			5.99			0.65			7.09			1		
10/10/20 15:41	308526			0.9			5.99			0.66			7.08			1		
10/10/20 15:42	308757			0.9			5.9			0.66			6.98			1		
10/10/20 15:43	308757			0.9			5.9			0.66			6.98			1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/10/20 15:44	308371.9			0.8			5.9			0.6			6.97			1		
10/10/20 15:45	308526			0.8			5.81			0.6			6.87			1		
10/10/20 15:46	308294.9			0.8			5.72			0.6			6.75			1		
10/10/20 15:47	307678.8			0.8			5.62			0.59			6.63			1		
10/10/20 15:48	307293.7			0.8			5.62			0.59			6.62			1		
10/10/20 15:49	307909.8			0.7			5.62			0.53			6.63			1		
10/10/20 15:50	307832.8			0.7			5.62			0.53			6.63			1		
10/10/20 15:51	307139.7			0.7			5.72			0.53			6.73			1		
10/10/20 15:52	307062.7			0.7			5.9			0.53			6.94			1		
10/10/20 15:53	306446.6			0.7			5.9			0.53			6.93			1		
10/10/20 15:54	306985.7			0.7			5.99			0.53			7.05			1		
10/10/20 15:55	307216.7			0.7			6.18			0.53			7.27			1		
10/10/20 15:56	306908.7			0.7			5.72			0.53			6.72			1		
10/10/20 15:57	307062.7			0.7			3.41			0.53			4.01			1		
10/10/20 15:58	306754.6			0.7			2.67			0.53			3.14			1		
10/10/20 15:59	306908.7			0.7			2.67			0.53			3.14			1		
10/10/20 16:00	306369.5			0.7			2.67			0.53			3.14			1		
10/10/20 16:01	306908.7			0.7			2.77			0.53			3.25			1		
10/10/20 16:02	306369.5			0.7			2.77			0.53			3.25			1		
10/10/20 16:03	306677.6			0.7			2.77			0.53			3.25			1		
10/10/20 16:04	306292.5			0.7			2.67			0.53			3.14			1		
10/10/20 16:05	306600.6			0.7			2.49			0.53			2.92			1		
10/10/20 16:06	306138.5			0.7			2.4			0.53			2.81			1		
10/10/20 16:07	306138.5			0.7			2.21			0.53			2.6			1		
10/10/20 16:08	306061.5			0.7			2.12			0.53			2.49			1		
10/10/20 16:09	306138.5			0.7			2.03			0.53			2.38			1		
10/10/20 16:10	305830.4			0.7			1.94			0.53			2.27			1		
10/10/20 16:11	305522.4			0.7			1.94			0.52			2.27			1		
10/10/20 16:12	305445.3			0.7			1.84			0.52			2.16			0		
10/10/20 16:13	306446.6			0.7			1.75			0.53			2.06			0		
10/10/20 16:14	306292.5			0.7			1.66			0.53			1.95			0		
10/10/20 16:15	306446.6			0.7			1.66			0.53			1.95			0		
10/10/20 16:16	306446.6			0.7			1.66			0.53			1.95			0		

CT1 SUSD EVENT 3

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/15/20 7:57	393782.7			0.7			1.55			0.62			2.33			0		
10/15/20 7:58	393551.6			0.7			1.43			0.61			2.15			0		
10/15/20 7:59	381460.1			0.7			1.43			0.59			2.09			0		
10/15/20 8:00	368444.4			0.7			1.5			0.56			2.12			0		
10/15/20 8:01	363977.5			0.7			1.66			0.62			2.31			0		
10/15/20 8:02	45901.5			0.7			1.84			0.08			0.32			1		
10/15/20 8:03	0			0			2.95			0			0			0		
10/15/20 8:04	0			0			0			0			0			0		
10/15/20 8:05	0			0			0			0			0			0		
10/15/20 8:06	0			0			0			0			0			0		
10/15/20 8:07	0			0			0			0			0			0		

CT1 SUSD EVENT 4

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/15/20 15:15	0			0			0			0			0			0		
10/15/20 15:16	0			0			0			0			0			0		
10/15/20 15:17	0			0			0			0			0			0		
10/15/20 15:18	0			0			0			0			0			0		
10/15/20 15:19	0			0			0			0			0			0		
10/15/20 15:20	2310.5			-0.1			0			0			0			1		
10/15/20 15:21	23258.8			-0.1			0			0			0			1		
10/15/20 15:22	38122.9			47.2			2.95			4.18			0.43			1		
10/15/20 15:23	52447.9			247.1			2.62			30.15			0.53			1		
10/15/20 15:24	69314.4			153.4			4.35			24.76			1.15			1		
10/15/20 15:25	113136.5			77.8			6.44			20.49			2.79			1		
10/15/20 15:26	136626.3			32.9			12.03			10.47			6.3			1		
10/15/20 15:27	141940.4			12.3			16.45			4.08			8.94			1		
10/15/20 15:28	158652.9			1605.4			16.78			592.93			10.2			1		
10/15/20 15:29	180756.5			840			16.01			353.49			11.09			1		
10/15/20 15:30	204785.5			112.1			21.39			53.45			16.78			1		
10/15/20 15:31	228737.4			5.9			24.73			3.14			21.67			1		
10/15/20 15:32	251842.2			1.3			26			0.77			25.09			1		
10/15/20 15:33	275794.2			1.2			22.6			0.77			23.88			1		
10/15/20 15:34	297435.7			1.1			11.7			0.79			13.34			1		
10/15/20 15:35	307678.8			1.2			7.65			0.86			9.02			1		
10/15/20 15:36	307524.8			1.3			7.26			0.91			8.56			1		
10/15/20 15:37	309065.1			1.2			5.9			0.85			6.99			1		
10/15/20 15:38	313301			1.1			5.81			0.79			6.97			1		
10/15/20 15:39	313069.9			1			5.63			0.72			6.76			1		
10/15/20 15:40	312992.9			1			5.54			0.72			6.65			1		
10/15/20 15:41	308757			0.9			5.45			0.64			6.45			1		
10/15/20 15:42	305753.4			0.9			5.45			0.64			6.39			1		
10/15/20 15:43	305291.3			0.8			5.54			0.58			6.48			1		
10/15/20 15:44	304290.1			0.8			5.54			0.58			6.46			1		
10/15/20 15:45	304367.1			0.8			5.54			0.58			6.46			1		
10/15/20 15:46	303905			0.7			5.54			0.51			6.45			1		
10/15/20 15:47	303982			0.7			3.72			0.51			4.33			1		
10/15/20 15:48	304290.1			0.7			2.77			0.52			3.22			1		
10/15/20 15:49	304059.1			0.7			2.58			0.52			3.01			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/15/20 15:50	303674			0.7			2.58			0.52			3			1		
10/15/20 15:51	301363.5			0.7			2.67			0.52			3.09			1		
10/15/20 15:52	306600.6			0.7			2.77			0.53			3.25			1		
10/15/20 15:53	318769.1			0.7			2.77			0.55			3.38			1		
10/15/20 15:54	329859.4			0.7			2.67			0.57			3.38			1		
10/15/20 15:55	341334.8			0.6			2.03			0.51			2.65			1		
10/15/20 15:56	355274.7			0.7			1.87			0.54			2.55			1		
10/15/20 15:57	369907.7			0.7			1.9			0.57			2.7			1		
10/15/20 15:58	388237.5			0.6			1.93			0.52			2.88			1		
10/15/20 15:59	404487.9			0.6			1.93			0.55			3			0		
10/15/20 16:00	401253.2			0.6			1.93			0.54			2.97			0		
10/15/20 16:01	400945.2			0.6			1.9			0.53			2.92			0		
10/15/20 16:02	400483.1			0.6			1.84			0.54			2.82			0		
10/15/20 16:03	400175			0.6			1.74			0.55			2.69			0		

CT1 SUSD EVENT 5

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/23/20 22:50	285036.1			0.7			1.78			0.5			1.94			0		
10/23/20 22:51	285036.1			0.7			1.78			0.5			1.94			0		
10/23/20 22:52	284959.1			0.7			1.78			0.5			1.94			0		
10/23/20 22:53	284959.1			0.7			1.69			0.5			1.84			0		
10/23/20 22:54	285036.1			0.7			1.69			0.5			1.84			0		
10/23/20 22:55	284343			0.7			1.69			0.5			1.84			1		
10/23/20 22:56	266398.3			0.7			1.69			0.46			1.72			1		
10/23/20 22:57	242754.3			0.8			3.24			0.43			3.01			1		
10/23/20 22:58	222807.2			0.7			7.38			0.36			6.3			1		
10/23/20 22:59	196082.7			0.5			7.76			0.24			5.83			1		
10/23/20 23:00	172977.9			0.9			14.52			0.37			9.63			1		
10/23/20 23:01	151259.4			9.3			16.39			3.28			9.5			1		
10/23/20 23:02	131466.3			746.7			16.64			228.5			8.38			1		
10/23/20 23:03	21795.5			1839.6			17.53			93.48			1.47			1		
10/23/20 23:04	0			0			20.92			0			0			0		
10/23/20 23:05	0			0			0.1			0			0			0		
10/23/20 23:06	0			0			0.1			0			0			0		
10/23/20 23:07	0			0			0.1			0			0			0		
10/23/20 23:08	0			0			0.1			0			0			0		

CT1 SUSD EVENT 6

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/22/20 17:21	0			0			0			0			0			0		
12/22/20 17:22	0			0			0			0			0			0		
12/22/20 17:23	0			0			0			0			0			0		
12/22/20 17:24	0			0			0			0			0			0		
12/22/20 17:25	0			0			0			0			0			0		
12/22/20 17:26	0			0.1			0			0			0			1		
12/22/20 17:27	0			1			0			0			0			1		
12/22/20 17:28	6546.4			6.6			7.21			0.1			0.18			1		
12/22/20 17:29	36582.6			524.2			11.8			44.94			1.66			1		
12/22/20 17:30	69699.5			363.4			18.29			59.39			4.92			1		
12/22/20 17:31	119913.9			220.4			23.87			62.03			11.05			1		
12/22/20 17:32	139475.9			101.4			43.27			33.18			23.3			1		
12/22/20 17:33	147408.6			549.8			45.05			190.13			25.64			1		
12/22/20 17:34	164275.1			1888			37.55			727.75			23.82			1		
12/22/20 17:35	185993.6			1584.2			43.05			691.16			30.91			1		
12/22/20 17:36	211408.8			433.1			52.52			214.86			42.88			1		
12/22/20 17:37	231972.1			47.2			53.73			25.68			48.12			1		
12/22/20 17:38	255076.9			5.8			53.1			3.46			52.29			1		
12/22/20 17:39	282340.6			4.5			51.34			2.95			55.97			1		
12/22/20 17:40	301132.4			4.1			38.9			2.87			45.23			1		
12/22/20 17:41	303982			4			22.3			2.85			26.17			1		
12/22/20 17:42	303828			4.2			16.59			2.99			19.46			1		
12/22/20 17:43	303365.9			4.5			14.11			3.22			16.52			1		
12/22/20 17:44	301902.6			5.4			12.58			3.81			14.66			1		
12/22/20 17:45	300747.4			6.2			11.02			4.35			12.8			1		
12/22/20 17:46	300439.3			14.2			9.77			9.99			11.34			1		
12/22/20 17:47	300670.3			14.8			9.33			10.43			10.84			1		
12/22/20 17:48	300670.3			12.7			8.28			8.94			9.61			1		
12/22/20 17:49	300054.2			8.4			7.49			5.89			8.67			1		
12/22/20 17:50	299438.1			6.7			6.78			4.7			7.84			1		
12/22/20 17:51	298745			6.1			5.9			4.26			6.81			1		
12/22/20 17:52	298205.8			5.2			5.72			3.63			6.59			1		
12/22/20 17:53	298359.9			4.2			5.27			2.94			6.08			1		
12/22/20 17:54	298128.8			3.4			5.1			2.38			5.86			1		
12/22/20 17:55	297897.8			2.9			5.01			2			5.76			1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/22/20 17:56	298282.9			2.4			4.83			1.69			5.56			1		
12/22/20 17:57	297820.8			2.1			4.65			1.5			5.34			1		
12/22/20 17:58	297897.8			2			4.56			1.37			5.24			1		
12/22/20 17:59	297435.7			1.9			4.47			1.31			5.13			1		
12/22/20 18:00	297281.7			1.8			4.47			1.25			5.13			1		
12/22/20 18:01	296896.6			1.7			4.47			1.18			5.12			1		
12/22/20 18:02	296357.5			1.6			4.38			1.12			5.01			1		
12/22/20 18:03	296665.5			1.5			4.54			1.07			5.2			1		
12/22/20 18:04	296280.4			1.4			4.63			0.95			5.3			1		
12/22/20 18:05	296126.4			1.3			4.81			0.88			5.5			1		
12/22/20 18:06	296049.4			1.2			4.9			0.82			5.6			1		
12/22/20 18:07	296126.4			1.1			4.99			0.76			5.71			1		
12/22/20 18:08	295895.4			1			5.08			0.69			5.81			1		
12/22/20 18:09	296126.4			1			5.17			0.69			5.91			1		
12/22/20 18:10	295895.4			0.9			5.17			0.63			5.91			1		
12/22/20 18:11	296126.4			0.9			4.45			0.63			5.08			1		
12/22/20 18:12	296203.4			0.9			3.18			0.63			3.63			1		
12/22/20 18:13	295972.4			0.8			3			0.57			3.42			1		
12/22/20 18:14	295664.3			0.8			2.81			0.57			3.21			1		
12/22/20 18:15	295125.2			0.8			2.63			0.57			3			1		
12/22/20 18:16	295510.3			0.8			2.54			0.57			2.9			1		
12/22/20 18:17	295356.3			0.8			2.45			0.57			2.79			1		
12/22/20 18:18	295356.3			0.8			2.36			0.57			2.69			1		
12/22/20 18:19	295279.3			0.8			2.27			0.57			2.59			1		
12/22/20 18:20	295279.3			0.7			2.18			0.5			2.48			1		
12/22/20 18:21	300901.4			0.7			2.09			0.51			2.42			1		
12/22/20 18:22	320694.5			0.7			2			0.55			2.47			1		
12/22/20 18:23	338562.2			0.7			1.88			0.57			2.45			1		
12/22/20 18:24	354427.5			0.8			1.79			0.67			2.45			1		
12/22/20 18:25	376916.2			0.7			1.72			0.64			2.51			0		
12/22/20 18:26	399558.9			0.7			1.48			0.69			2.28			0		
12/22/20 18:27	428285.8			0.7			1.4			0.66			2.32			0		
12/22/20 18:28	436757.6			0.7			1.5			0.67			2.53			0		
12/22/20 18:29	433908			0.6			1.57			0.66			2.63			0		

CT1 SUSD EVENT 7

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/22/20 19:55	361821			0.7			1.97			0.61			2.75			0		
12/22/20 19:56	339794.5			0.7			1.94			0.56			2.54			0		
12/22/20 19:57	315149.3			0.8			1.91			0.58			2.32			0		
12/22/20 19:58	293738.9			0.9			1.91			0.6			2.16			0		
12/22/20 19:59	285960.3			0.8			1.76			0.53			1.94			0		
12/22/20 20:00	283264.8			0.7			2.27			0.48			2.48			1		
12/22/20 20:01	265782.1			0.6			2.72			0.4			2.79			1		
12/22/20 20:02	241137			0.6			5.62			0.37			5.24			1		
12/22/20 20:03	221112.9			0.6			8.95			0.31			7.64			1		
12/22/20 20:04	195774.6			0.4			14.12			0.19			10.67			1		
12/22/20 20:05	172130.7			3.2			16.64			1.29			11.06			1		
12/22/20 20:06	150643.2			168.2			18.24			59.43			10.61			1		
12/22/20 20:07	132852.5			1067.6			18.46			332.66			9.46			1		
12/22/20 20:08	23181.8			1829			19.61			99.49			1.76			1		
12/22/20 20:09	0			0			21.45			0			0			0		
12/22/20 20:10	0			0			17.7			0			0			0		
12/22/20 20:11	0			0			0.2			0			0			0		
12/22/20 20:12	0			0			0.2			0			0			0		
12/22/20 20:13	0			0			0.2			0			0			0		

CT2 SUSD EVENT 1

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/10/20 13:47	382384.3			1.6			1.72			1.45			2.53			0		
10/10/20 13:48	381537.1			1.6			1.72			1.45			2.52			0		
10/10/20 13:49	380921			1.6			1.72			1.45			2.52			0		
10/10/20 13:50	381075			1.7			1.75			1.47			2.56			0		
10/10/20 13:51	252535.4			1.7			1.75			0.98			1.69			0		
10/10/20 13:52	69468.4			1.9			1.83			0.31			0.49			1		
10/10/20 13:53	0			0			5.02			0			0			0		
10/10/20 13:54	0			0			0.84			0			0			0		
10/10/20 13:55	0			0			0			0			0			0		
10/10/20 13:56	0			0			0			0			0			0		
10/10/20 13:57	0			0			0			0			0			0		

CT2 SUSD EVENT 2

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/10/20 14:04	0			0			0			0			0			0		
10/10/20 14:05	0			0			0			0			0			0		
10/10/20 14:06	0			0			0			0			0			0		
10/10/20 14:07	0			0			0			0			0			0		
10/10/20 14:08	0			0			0			0			0			0		
10/10/20 14:09	1463.3			0.2			0			0			0			1		
10/10/20 14:10	17867.7			0.2			0			0			0			1		
10/10/20 14:11	32962.8			64.9			0			4.98			0			1		
10/10/20 14:12	44361.2			183.2			1.04			18.91			0.18			1		
10/10/20 14:13	4466.9			202.9			1.64			2.09			0.03			1		
10/10/20 14:14	0			0			1.69			0			0			0		
10/10/20 14:15	0			0			0			0			0			0		
10/10/20 14:16	0			0			0			0			0			0		
10/10/20 14:17	0			0			0			0			0			0		
10/10/20 14:18	0			0			0			0			0			0		

CT2 SUSD EVENT 3

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/10/20 14:08	0			0			0			0			0			0		
10/10/20 14:09	1463.3			0.2			0			0			0			1		
10/10/20 14:10	17867.7			0.2			0			0			0			1		
10/10/20 14:11	32962.8			64.9			0			4.98			0			1		
10/10/20 14:12	44361.2			183.2			1.04			18.91			0.18			1		
10/10/20 14:13	4466.9			202.9			1.64			2.09			0.03			1		
10/10/20 14:14	0			0			1.69			0			0			0		
10/10/20 14:15	0			0			0			0			0			0		
10/10/20 14:16	0			0			0			0			0			0		
10/10/20 14:17	0			0			0			0			0			0		
10/10/20 14:18	0			0			0			0			0			0		

CT2 SUSD EVENT 4

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/10/20 14:24	0			0			0			0			0			0		
10/10/20 14:25	0			0			0			0			0			0		
10/10/20 14:26	0			0			0			0			0			0		
10/10/20 14:27	0			0			0			0			0			0		
10/10/20 14:28	0			0			0			0			0			0		
10/10/20 14:29	15865.3			0			0			0			0			1		
10/10/20 14:30	30036.2			1.6			0			0			0			1		
10/10/20 14:31	40972.5			272.3			0.91			25.97			0.14			1		
10/10/20 14:32	24568.1			273			2.48			15.64			0.23			1		
10/10/20 14:33	0			0			3.42			0			0			0		
10/10/20 14:34	0			0			0			0			0			0		
10/10/20 14:35	0			0			0			0			0			0		
10/10/20 14:36	0			0			0			0			0			0		
10/10/20 14:37	0			0			0			0			0			0		

CT2 SUSD EVENT 5

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/10/20 14:24	0			0			0			0			0			0		
10/10/20 14:25	0			0			0			0			0			0		
10/10/20 14:26	0			0			0			0			0			0		
10/10/20 14:27	0			0			0			0			0			0		
10/10/20 14:28	0			0			0			0			0			0		
10/10/20 14:29	15865.3			0			0			0			0			1		
10/10/20 14:30	30036.2			1.6			0			0			0			1		
10/10/20 14:31	40972.5			272.3			0.91			25.97			0.14			1		
10/10/20 14:32	24568.1			273			2.48			15.64			0.23			1		
10/10/20 14:33	0			0			3.42			0			0			0		
10/10/20 14:34	0			0			0			0			0			0		
10/10/20 14:35	0			0			0			0			0			0		
10/10/20 14:36	0			0			0			0			0			0		
10/10/20 14:37	0			0			0			0			0			0		

CT2 SUSD EVENT 6

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/11/20 15:06	0			0			0			0			0			0		
10/11/20 15:07	0			0			0			0			0			0		
10/11/20 15:08	0			0			0			0			0			0		
10/11/20 15:09	0			0			0			0			0			0		
10/11/20 15:10	0			0			0			0			0			0		
10/11/20 15:11	2310.5			0			0			0			0			1		
10/11/20 15:12	6623.4			0			0			0			0			1		
10/11/20 15:13	0			0			0.1			0			0			0		
10/11/20 15:14	0			0			15.17			0			0			0		
10/11/20 15:15	0			0			8.85			0			0			0		
10/11/20 15:16	0			0			23.6			0			0			0		
10/11/20 15:17	0			0			0.6			0			0			0		

CT2 SUSD EVENT 7

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/11/20 15:06	0			0			0			0			0			0		
10/11/20 15:07	0			0			0			0			0			0		
10/11/20 15:08	0			0			0			0			0			0		
10/11/20 15:09	0			0			0			0			0			0		
10/11/20 15:10	0			0			0			0			0			0		
10/11/20 15:11	2310.5			0			0			0			0			1		
10/11/20 15:12	6623.4			0			0			0			0			1		
10/11/20 15:13	0			0			0.1			0			0			0		
10/11/20 15:14	0			0			15.17			0			0			0		
10/11/20 15:15	0			0			8.85			0			0			0		
10/11/20 15:16	0			0			23.6			0			0			0		
10/11/20 15:17	0			0			0.6			0			0			0		

CT2 SUSD EVENT 8

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/13/20 4:38	0			0	X		0	X		0	X		0	X		0		
10/13/20 4:39	0			0	X		0	X		0	X		0	X		0		
10/13/20 4:40	0			0	X		0	X		0	X		0	X		0		
10/13/20 4:41	0			0	X		0	X		0	X		0	X		0		
10/13/20 4:42	0			0	X		0	X		0	X		0	X		0		
10/13/20 4:43	6700.4			0.1	X		0	X		0	X		0	X		1		
10/13/20 4:44	25184.2			0.1	X		0	X		0	X		0	X		1		
10/13/20 4:45	37275.7			37.4	X		39.33	X		3.25	X		5.62	X		1		
10/13/20 4:46	47672.9			523.4	X		19.78	X		58.11	X		3.61	X		1		
10/13/20 4:47	58917.2			380.7	X		24.84	X		52.24	X		5.61	X		1		
10/13/20 4:48	87875.2			234.8	X		28.62	X		48.04	X		9.64	X		1		
10/13/20 4:49	118527.6			119.8	X		44.12	X		33.06	X		20.04	X		1		
10/13/20 4:50	42050.7			265.1	X		53.71	X		25.93	X		8.65	X		1		
10/13/20 4:51	0			0	X		42.34	X		0	X		0	X		0		
10/13/20 4:52	0			0	X		0.9	X		0	X		0	X		0		
10/13/20 4:53	0			0	X		0.6	X		0	X		0	X		0		
10/13/20 4:54	0			0	X		0.7	X		0	X		0	X		0		
10/13/20 4:55	0			0	X		1.2	X		0	X		0	X		0		

CT2 SUSD EVENT 9

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/13/20 4:38	0			0	X		0	X		0	X		0	X		0		
10/13/20 4:39	0			0	X		0	X		0	X		0	X		0		
10/13/20 4:40	0			0	X		0	X		0	X		0	X		0		
10/13/20 4:41	0			0	X		0	X		0	X		0	X		0		
10/13/20 4:42	0			0	X		0	X		0	X		0	X		0		
10/13/20 4:43	6700.4			0.1	X		0	X		0	X		0	X		1		
10/13/20 4:44	25184.2			0.1	X		0	X		0	X		0	X		1		
10/13/20 4:45	37275.7			37.4	X		39.33	X		3.25	X		5.62	X		1		
10/13/20 4:46	47672.9			523.4	X		19.78	X		58.11	X		3.61	X		1		
10/13/20 4:47	58917.2			380.7	X		24.84	X		52.24	X		5.61	X		1		
10/13/20 4:48	87875.2			234.8	X		28.62	X		48.04	X		9.64	X		1		
10/13/20 4:49	118527.6			119.8	X		44.12	X		33.06	X		20.04	X		1		
10/13/20 4:50	42050.7			265.1	X		53.71	X		25.93	X		8.65	X		1		
10/13/20 4:51	0			0	X		42.34	X		0	X		0	X		0		
10/13/20 4:52	0			0	X		0.9	X		0	X		0	X		0		
10/13/20 4:53	0			0	X		0.6	X		0	X		0	X		0		
10/13/20 4:54	0			0	X		0.7	X		0	X		0	X		0		
10/13/20 4:55	0			0	X		1.2	X		0	X		0	X		0		

CT2 SUSD EVENT 10

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/13/20 5:13	0			0	X		0.5	X		0	X		0	X		0		
10/13/20 5:14	0			0	X		0.7	X		0	X		0	X		0		
10/13/20 5:15	0			0	X		0.8	X		0	X		0	X		0		
10/13/20 5:16	0			0	X		1	X		0	X		0	X		0		
10/13/20 5:17	0			0	X		1.1	X		0	X		0	X		0		
10/13/20 5:18	13708.8			0.4	X		1.2	X		0	X		0	X		1		
10/13/20 5:19	30036.2			1.7	X		1.9	X		0	X		0	X		1		
10/13/20 5:20	41049.5			486.4	X		107.51	X		46.49	X		16.91	X		1		
10/13/20 5:21	51908.8			454.3	X		41.3	X		54.91	X		8.22	X		1		
10/13/20 5:22	66849.9			169.1	X		28.32	X		26.31	X		7.25	X		1		
10/13/20 5:23	104125.6			181.2	X		62.37	X		43.93	X		24.88	X		1		
10/13/20 5:24	117141.3			87	X		66.38	X		23.73	X		29.78	X		1		
10/13/20 5:25	0			84.6	X		56.25	X		0	X		0	X		1		
10/13/20 5:26	0			0	X		58.02	X		0	X		0	X		0		
10/13/20 5:27	0			0	X		0.9	X		0	X		0	X		0		
10/13/20 5:28	0			0	X		0.9	X		0	X		0	X		0		
10/13/20 5:29	0			0	X		0.9	X		0	X		0	X		0		
10/13/20 5:30	0			0	X		0.9	X		0	X		0	X		0		

CT2 SUSD EVENT 11

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/13/20 5:13	0			0	X		0.5	X		0	X		0	X		0		
10/13/20 5:14	0			0	X		0.7	X		0	X		0	X		0		
10/13/20 5:15	0			0	X		0.8	X		0	X		0	X		0		
10/13/20 5:16	0			0	X		1	X		0	X		0	X		0		
10/13/20 5:17	0			0	X		1.1	X		0	X		0	X		0		
10/13/20 5:18	13708.8			0.4	X		1.2	X		0	X		0	X		1		
10/13/20 5:19	30036.2			1.7	X		1.9	X		0	X		0	X		1		
10/13/20 5:20	41049.5			486.4	X		107.51	X		46.49	X		16.91	X		1		
10/13/20 5:21	51908.8			454.3	X		41.3	X		54.91	X		8.22	X		1		
10/13/20 5:22	66849.9			169.1	X		28.32	X		26.31	X		7.25	X		1		
10/13/20 5:23	104125.6			181.2	X		62.37	X		43.93	X		24.88	X		1		
10/13/20 5:24	117141.3			87	X		66.38	X		23.73	X		29.78	X		1		
10/13/20 5:25	0			84.6	X		56.25	X		0	X		0	X		1		
10/13/20 5:26	0			0	X		58.02	X		0	X		0	X		0		
10/13/20 5:27	0			0	X		0.9	X		0	X		0	X		0		
10/13/20 5:28	0			0	X		0.9	X		0	X		0	X		0		
10/13/20 5:29	0			0	X		0.9	X		0	X		0	X		0		
10/13/20 5:30	0			0	X		0.9	X		0	X		0	X		0		

CT2 SUSD EVENT 12

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/13/20 6:20	0			0	X		0.1	X		0	X		0	X		0		
10/13/20 6:21	0			0	X		0.1	X		0	X		0	X		0		
10/13/20 6:22	0			0	X		0.1	X		0	X		0	X		0		
10/13/20 6:23	0			0	X		0.1	X		0	X		0	X		0		
10/13/20 6:24	0			0	X		0.1	X		0	X		0	X		0		
10/13/20 6:25	22796.7			0.8	X		0.1	X		0	X		0	X		1		
10/13/20 6:26	34195.1			3.2	X		1.9	X		0	X		0	X		1		
10/13/20 6:27	45670.5			538.6	X		35.4	X		57.27	X		6.19	X		1		
10/13/20 6:28	55990.6			449.7	X		31.47	X		58.59	X		6.75	X		1		
10/13/20 6:29	74782.5			279.4	X		36.58	X		48.65	X		10.48	X		1		
10/13/20 6:30	113906.6			181.8	X		46.64	X		48.22	X		20.36	X		1		
10/13/20 6:31	84486.5			83.7	X		60.97	X		16.47	X		19.74	X		1		
10/13/20 6:32	0			0	X		46.49	X		0	X		0	X		0		
10/13/20 6:33	0			0	X		1	X		0	X		0	X		0		
10/13/20 6:34	0			0	X		0.4	X		0	X		0	X		0		
10/13/20 6:35	0			0	X		0.4	X		0	X		0	X		0		
10/13/20 6:36	0			0	X		0.3	X		0	X		0	X		0		

CT2 SUSD EVENT 13

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/13/20 6:20	0			0	X		0.1	X		0	X		0	X		0		
10/13/20 6:21	0			0	X		0.1	X		0	X		0	X		0		
10/13/20 6:22	0			0	X		0.1	X		0	X		0	X		0		
10/13/20 6:23	0			0	X		0.1	X		0	X		0	X		0		
10/13/20 6:24	0			0	X		0.1	X		0	X		0	X		0		
10/13/20 6:25	22796.7			0.8	X		0.1	X		0	X		0	X		1		
10/13/20 6:26	34195.1			3.2	X		1.9	X		0	X		0	X		1		
10/13/20 6:27	45670.5			538.6	X		35.4	X		57.27	X		6.19	X		1		
10/13/20 6:28	55990.6			449.7	X		31.47	X		58.59	X		6.75	X		1		
10/13/20 6:29	74782.5			279.4	X		36.58	X		48.65	X		10.48	X		1		
10/13/20 6:30	113906.6			181.8	X		46.64	X		48.22	X		20.36	X		1		
10/13/20 6:31	84486.5			83.7	X		60.97	X		16.47	X		19.74	X		1		
10/13/20 6:32	0			0	X		46.49	X		0	X		0	X		0		
10/13/20 6:33	0			0	X		1	X		0	X		0	X		0		
10/13/20 6:34	0			0	X		0.4	X		0	X		0	X		0		
10/13/20 6:35	0			0	X		0.4	X		0	X		0	X		0		
10/13/20 6:36	0			0	X		0.3	X		0	X		0	X		0		

CT2 SUSD EVENT 14

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/13/20 6:54	0			0	X		0.1	X		0	X		0	X		0		
10/13/20 6:55	0			0	X		0.1	X		0	X		0	X		0		
10/13/20 6:56	0			0	X		0.1	X		0	X		0	X		0		
10/13/20 6:57	0			0	X		0.1	X		0	X		0	X		0		
10/13/20 6:58	0			0	X		0.1	X		0	X		0	X		0		
10/13/20 6:59	20563.3			1.4	X		0.1	X		0	X		0	X		1		
10/13/20 7:00	32962.8			3.4	X		1.7	X		0	X		0	X		1		
10/13/20 7:01	44207.2			486.9	X		30.68	X		50.14	X		5.2	X		1		
10/13/20 7:02	54604.3			440.2	X		30.16	X		55.97	X		6.31	X		1		
10/13/20 7:03	76091.8			272	X		36.29	X		48.16	X		10.57	X		1		
10/13/20 7:04	112520.3			183.7	X		44.67	X		48.12	X		19.25	X		1		
10/13/20 7:05	77940.2			81.1	X		60.97	X		14.72	X		18.22	X		1		
10/13/20 7:06	0			0	X		45.23	X		0	X		0	X		0		
10/13/20 7:07	0			0	X		1.2	X		0	X		0	X		0		
10/13/20 7:08	0			0	X		0.4	X		0	X		0	X		0		
10/13/20 7:09	0			0	X		0.3	X		0	X		0	X		0		
10/13/20 7:10	0			0	X		0.3	X		0	X		0	X		0		

CT2 SUSD EVENT 15

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/13/20 6:54	0			0	X		0.1	X		0	X		0	X		0		
10/13/20 6:55	0			0	X		0.1	X		0	X		0	X		0		
10/13/20 6:56	0			0	X		0.1	X		0	X		0	X		0		
10/13/20 6:57	0			0	X		0.1	X		0	X		0	X		0		
10/13/20 6:58	0			0	X		0.1	X		0	X		0	X		0		
10/13/20 6:59	20563.3			1.4	X		0.1	X		0	X		0	X		1		
10/13/20 7:00	32962.8			3.4	X		1.7	X		0	X		0	X		1		
10/13/20 7:01	44207.2			486.9	X		30.68	X		50.14	X		5.2	X		1		
10/13/20 7:02	54604.3			440.2	X		30.16	X		55.97	X		6.31	X		1		
10/13/20 7:03	76091.8			272	X		36.29	X		48.16	X		10.57	X		1		
10/13/20 7:04	112520.3			183.7	X		44.67	X		48.12	X		19.25	X		1		
10/13/20 7:05	77940.2			81.1	X		60.97	X		14.72	X		18.22	X		1		
10/13/20 7:06	0			0	X		45.23	X		0	X		0	X		0		
10/13/20 7:07	0			0	X		1.2	X		0	X		0	X		0		
10/13/20 7:08	0			0	X		0.4	X		0	X		0	X		0		
10/13/20 7:09	0			0	X		0.3	X		0	X		0	X		0		
10/13/20 7:10	0			0	X		0.3	X		0	X		0	X		0		

CT2 SUSD EVENT 16

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/13/20 7:57	0			0	X		0	X		0	X		0	X		0		
10/13/20 7:58	0			0	X		0	X		0	X		0	X		0		
10/13/20 7:59	0			0	X		0	X		0	X		0	X		0		
10/13/20 8:00	0			0	X		0	X		0	X		0	X		0		
10/13/20 8:01	0			0	X		0	X		0	X		0	X		0		
10/13/20 8:02	2695.6			0.8	X		0	X		0	X		0	X		1		
10/13/20 8:03	22719.7			0.7	X		0	X		0	X		0	X		1		
10/13/20 8:04	35350.3			141.6	X		177	X		11.66	X		24	X		1		
10/13/20 8:05	46209.6			473.7	X		28.81	X		51.01	X		5.1	X		1		
10/13/20 8:06	57299.9			377	X		30.12	X		50.29	X		6.61	X		1		
10/13/20 8:07	82176			239	X		39.24	X		45.73	X		12.36	X		1		
10/13/20 8:08	124072.7			127.2	X		49.25	X		36.74	X		23.41	X		1		
10/13/20 8:09	130619.1			45	X		69.58	X		13.67	X		34.81	X		1		
10/13/20 8:10	136087.2			901.4	X		61.4	X		285.51	X		32.01	X		1		
10/13/20 8:11	153338.8			2005	X		59	X		715.87	X		34.67	X		1		
10/13/20 8:12	174210.1			1239.5	X		58.16	X		502.76	X		38.82	X		1		
10/13/20 8:13	195081.5			273.9	X		55.76	X		124.4	X		41.68	X		1		
10/13/20 8:14	215490.7			20	X		54.25	X		10.04	X		44.79	X		1		
10/13/20 8:15	237748.3			3.5	X		48.79	X		1.95	X		44.45	X		1		
10/13/20 8:16	258696.7			2.9	X		44.51	X		1.75	X		44.11	X		1		
10/13/20 8:17	277873.6			2.7	X		31.02	X		1.72	X		33.03	X		1		
10/13/20 8:18	278027.7			2.7	X		15.03	X		1.73	X		16.01	X		1		
10/13/20 8:19	277642.6			2.8	X		11.98	X		1.82	X		12.74	X		1		
10/13/20 8:20	277950.7			2.7	X		10.35	X		1.76	X		11.02	X		1		
10/13/20 8:21	289888.1			2.4	X		9.03	X		1.62	X		10.03	X		1		
10/13/20 8:22	298359.9			2.2	X		7.74	X		1.54	X		8.85	X		1		
10/13/20 8:23	310066.3			2	X		7.35	X		1.44	X		8.74	X		1		
10/13/20 8:24	320386.4			1.9	X		6.08	X		1.42	X		7.47	X		1		
10/13/20 8:25	325777.6			1.9	X		5.44	X		1.47	X		6.79	X		1		
10/13/20 8:26	329936.4			1.8	X		5.44	X		1.42	X		6.87	X		1		
10/13/20 8:27	342182			1.8	X		5.35	X		1.4	X		7.01	X		1		
10/13/20 8:28	345647.7			1.7	X		5.24	X		1.36	X		6.95	X		1		
10/13/20 8:29	344107.4			1.6	X		5.42	X		1.3	X		7.15	X		1		
10/13/20 8:30	346571.9			1.6	X		5.71	X		1.31	X		7.58	X		1		
10/13/20 8:31	346417.8			1.5	X		5.9	X		1.23	X		7.83	X		1		

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/13/20 8:32	345262.6			1.5	X		5.9	X		1.2	X		7.81	X		1		
10/13/20 8:33	345724.7			1.5	X		6.18	X		1.21	X		8.19	X		1		
10/13/20 8:34	344646.5			1.4	X		6.65	X		1.13	X		8.78	X		1		
10/13/20 8:35	343722.3			1.4	X		6.74	X		1.12	X		8.88	X		1		
10/13/20 8:36	342413			1.4	X		7.12	X		1.12	X		9.34	X		1		
10/13/20 8:37	338023.1			1.4	X		7.61	X		1.12	X		9.86	X		1		
10/13/20 8:38	321002.6			1.3	X		6.93	X		0.98	X		8.52	X		1		
10/13/20 8:39	306831.6			1.3	X		4.79	X		0.92	X		5.64	X		1		
10/13/20 8:40	302364.7			1.4	X		4.43	X		0.97	X		5.13	X		1		
10/13/20 8:41	310374.4			1.4	X		4.15	X		1	X		4.93	X		1		
10/13/20 8:42	314148.2			1.3	X		3.6	X		0.94	X		4.33	X		1		
10/13/20 8:43	311914.7			1.3	X		3.28	X		0.95	X		3.92	X		1		
10/13/20 8:44	301440.5			1.3	X		3.13	X		0.91	X		3.62	X		1		
10/13/20 8:45	300747.4			1.3	X		3.23	X		0.9	X		3.72	X		1		
10/13/20 8:46	301209.5			1.3	X		3.32	X		0.91	X		3.83	X		1		
10/13/20 8:47	301748.6			1.3	X		3.23	X		0.91	X		3.73	X		1		
10/13/20 8:48	298513.9			1.3	X		3.04	X		0.9	X		3.48	X		1		
10/13/20 8:49	299900.2			1.3	X		2.95	X		0.9	X		3.39	X		1		
10/13/20 8:50	302518.8			1.3	X		2.86	X		0.91	X		3.31	X		1		
10/13/20 8:51	304367.1			1.3	X		2.67	X		0.91	X		3.12	X		1		
10/13/20 8:52	302210.7			1.3	X		2.49	X		0.91	X		2.88	X		1		
10/13/20 8:53	302056.7			1.2	X		2.4	X		0.84	X		2.77	X		1		
10/13/20 8:54	302056.7			1.2	X		2.4	X		0.84	X		2.77	X		1		
10/13/20 8:55	300978.4			1.2	X		2.4	X		0.84	X		2.76	X		1		
10/13/20 8:56	296819.6			1.2	X		2.3	X		0.83	X		2.62	X		1		
10/13/20 8:57	296896.6			1.1	X		2.3	X		0.76	X		2.62	X		1		
10/13/20 8:58	297820.8			1.2	X		2.4	X		0.83	X		2.73	X		1		
10/13/20 8:59	297666.7			1.2	X		2.4	X		0.83	X		2.73	X		1		
10/13/20 9:00	296973.6			1.1	X		2.12	X		0.76	X		2.41	X		1		
10/13/20 9:01	295972.4			1.1	X		1.84	X		0.76	X		2.09	X		1		
10/13/20 9:02	297589.7			1.1	X		1.57	X		0.77	X		1.79	X		1		
10/13/20 9:03	296588.5			1.1	X		1.29	X		0.76	X		1.47	X		1		
10/13/20 9:04	297050.6			1	X		1.11	X		0.7	X		1.26	X		0		
10/13/20 9:05	294817.2			1	X		0.92	X		0.7	X		1.04	X		0		
10/13/20 9:06	295202.2			1	X		0.83	X		0.7	X		0.94	X		0		
10/13/20 9:07	297743.8			3	X		0.87	X		2.04	X		1	X		0		
10/13/20 9:08	296280.4			5.7	X		0	X		3.92	X		0	X		0		

CT2 SUSD EVENT 17

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/25/20 23:50	328627.2			0.8			1.66			0.64			2.11			0		
11/25/20 23:51	315534.4			0.8			1.75			0.62			2.14			0		
11/25/20 23:52	294432.1			0.9			1.82			0.63			2.07			0		
11/25/20 23:53	277488.6			1			1.91			0.65			2.05			0		
11/25/20 23:54	274176.9			1			2.3			0.65			2.45			0		
11/25/20 23:55	264395.8			0.9			2.9			0.58			2.97			1		
11/25/20 23:56	245603.9			0.9			4.09			0.49			3.89			1		
11/25/20 23:57	229276.5			0.9			7.25			0.47			6.44			1		
11/25/20 23:58	204323.4			0.7			13.33			0.34			10.54			1		
11/25/20 23:59	181372.6			0.6			16.79			0.24			11.79			1		
11/26/20 0:00	159962.2			5.1			18.6			1.93			11.52			1		
11/26/20 0:01	142710.6			486.2			20.8			163.24			11.49			1		
11/26/20 0:02	127076.4			1495.6			21.24			447.26			10.45			1		
11/26/20 0:03	0			2080.9			24.58			0			0			1		
11/26/20 0:04	0			0			44.25			0			0			0		
11/26/20 0:05	0			0			0.1			0			0			0		
11/26/20 0:06	0			0			0.1			0			0			0		
11/26/20 0:07	0			0			0.1			0			0			0		
11/26/20 0:08	0			0			0.1			0			0			0		

CT2 SUSD EVENT 18

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/22/20 15:37	0			0			0			0			0			0		
12/22/20 15:38	0			0			0			0			0			0		
12/22/20 15:39	0			0			0			0			0			0		
12/22/20 15:40	0			0			0			0			0			0		
12/22/20 15:41	1232.3			0			0			0			0			0		
12/22/20 15:42	2387.5			0.2			0			0			0			1		
12/22/20 15:43	20640.3			0.1			0			0			0			1		
12/22/20 15:44	34349.1			47.2			0			3.8			0			1		
12/22/20 15:45	45362.4			559.3			3.93			59.47			0.69			1		
12/22/20 15:46	55836.6			487.2			7.76			63.8			1.67			1		
12/22/20 15:47	76091.8			328.6			14.75			58.63			4.33			1		
12/22/20 15:48	119913.9			196			21.19			55.16			9.81			1		
12/22/20 15:49	133776.8			88.3			38.46			27.71			19.86			1		
12/22/20 15:50	140785.2			365.4			42.04			120.66			22.84			1		
12/22/20 15:51	159423.1			1857.4			33.37			694.75			20.54			1		
12/22/20 15:52	178754.1			1246			45.07			522.42			31.1			1		
12/22/20 15:53	201088.7			296.6			54.4			139.88			42.22			1		
12/22/20 15:54	222499.1			22			55.99			11.47			48.1			1		
12/22/20 15:55	244217.6			5.9			60.48			3.38			57.01			1		
12/22/20 15:56	267091.4			4.8			60.12			3			61.99			1		
12/22/20 15:57	291505.5			4.1			40.01			2.84			45.03			1		
12/22/20 15:58	307370.8			3.9			21.72			2.84			25.78			1		
12/22/20 15:59	324314.3			4.1			20.22			3.1			25.31			1		
12/22/20 16:00	340872.7			4.6			16.75			3.68			22.04			1		
12/22/20 16:01	361667			5.5			13.41			4.7			18.72			1		
12/22/20 16:02	380381.9			13.3			12.44			11.82			18.26			1		
12/22/20 16:03	404410.9			14.8			11.25			13.99			17.56			1		
12/22/20 16:04	411804.4			9.2			11.52			8.87			18.32			1		
12/22/20 16:05	410187.1			6.1			10.88			5.86			17.23			1		
12/22/20 16:06	409031.8			5.3			9.77			5.13			15.43			1		
12/22/20 16:07	410110.1			4.6			9.55			4.41			15.12			1		
12/22/20 16:08	409185.9			3.5			9.18			3.33			14.5			1		
12/22/20 16:09	407645.5			2.7			8.8			2.6			13.85			1		
12/22/20 16:10	407491.5			2.2			9.74			2.06			15.32			1		
12/22/20 16:11	409108.8			1.9			9.83			1.8			15.53			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/22/20 16:12	407491.5			1.7			10.11			1.61			15.91			1		
12/22/20 16:13	408338.7			1.7			10.4			1.61			16.39			1		
12/22/20 16:14	408107.6			1.6			10.58			1.52			16.67			1		
12/22/20 16:15	407491.5			1.5			10.68			1.43			16.79			1		
12/22/20 16:16	407799.6			1.4			11.05			1.34			17.4			1		
12/22/20 16:17	406952.4			1.4			11.52			1.34			18.1			1		
12/22/20 16:18	408415.7			1.3			12.08			1.26			19.05			1		
12/22/20 16:19	408492.7			1.2			12.55			1.17			19.79			1		
12/22/20 16:20	405951.2			1.1			11.89			1.07			18.64			1		
12/22/20 16:21	409648			1			6.74			0.99			10.66			1		
12/22/20 16:22	408646.8			1			4.68			0.99			7.39			1		
12/22/20 16:23	409493.9			0.9			4.03			0.9			6.37			1		
12/22/20 16:24	408184.7			0.9			3.47			0.9			5.46			1		
12/22/20 16:25	409339.9			0.9			3.28			0.9			5.18			1		
12/22/20 16:26	408030.6			0.9			2.9			0.9			4.57			1		
12/22/20 16:27	409108.8			0.8			2.53			0.81			3.99			1		
12/22/20 16:28	409185.9			0.8			2.25			0.81			3.55			1		
12/22/20 16:29	408877.8			0.8			1.97			0.81			3.1			1		
12/22/20 16:30	410495.1			0.8			1.78			0.81			2.82			1		
12/22/20 16:31	408569.7			0.8			1.59			0.81			2.51			1		
12/22/20 16:32	409493.9			0.8			1.5			0.81			2.37			0		
12/22/20 16:33	407645.5			0.8			1.4			0.81			2.21			0		
12/22/20 16:34	409956			0.8			1.4			0.81			2.22			0		
12/22/20 16:35	410264.1			0.8			1.31			0.81			2.08			0		
12/22/20 16:36	407414.5			0.9			1.31			0.9			2.06			0		

CT2 SUSD EVENT 19

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/22/20 18:18	272790.6			0.7			1.97			0.48			2.07			0		
12/22/20 18:19	274099.8			0.7			1.97			0.48			2.08			0		
12/22/20 18:20	272713.6			0.7			1.87			0.48			1.97			0		
12/22/20 18:21	274484.9			0.7			1.87			0.48			1.99			0		
12/22/20 18:22	273021.6			0.7			1.78			0.48			1.88			0		
12/22/20 18:23	273791.8			0.7			1.78			0.48			1.88			1		
12/22/20 18:24	263163.6			0.7			1.69			0.46			1.71			1		
12/22/20 18:25	243293.5			0.7			2.15			0.43			2.02			1		
12/22/20 18:26	222961.2			0.8			5.04			0.4			4.34			1		
12/22/20 18:27	202937.1			0.7			8.75			0.34			6.85			1		
12/22/20 18:28	178215			0.6			12.58			0.23			8.66			1		
12/22/20 18:29	158036.8			7			14.44			2.61			8.81			1		
12/22/20 18:30	140015			433.9			16.69			142.47			9.02			1		
12/22/20 18:31	113598.6			1387			18.19			369.77			7.98			1		
12/22/20 18:32	0			1909.8			22.22			0			0			1		
12/22/20 18:33	0			0			35.4			0			0			0		
12/22/20 18:34	0			0			0.2			0			0			0		
12/22/20 18:35	0			0			0.1			0			0			0		
12/22/20 18:36	0			0			0.1			0			0			0		
12/22/20 18:37	0			0			0.1			0			0			0		

AQ-57

AQ-57 The emissions rates from each gas turbine and heat recovery steam generator exhaust during startup and shutdown or excursions shall not exceed the following:

Combustion Turbine emissions limitations per Turbine excluding Startup and Shutdown	
Pollutant	Pounds/Hour
CO	6.2 3hr rolling
NOX	5.1 1 hour rolling
PM-10	4.7
SOX	1.0
VOC	1.8

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6

AQ-57 If the Alstom GX100 turbines are selected for the Project, emission rates from each gas turbine and heat recovery steam generator exhaust, except during startup and/or shutdown, or excursions shall not exceed the following:

Alstom GTX100 - COMBUSTION TURBINE EMISSION LIMITATIONS PER TURBINE EXCLUDING STARTUP AND SHUTDOWN	
POLLUTANT	POUNDS/HOUR
Carbon Monoxide (CO)	6.2 (three-hour rolling average)
Nitrogen Oxides (NOx)	5.1 (one-hour average)
PM10	4.7
Sulfur Oxides (SOx)	1.0
Volatile Organic Compounds (VOCs)	1.8

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emission limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

AQ57 CT1 HOURLY EMISSIONS

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/01/20 0:00	0.8			1.7			3			0.41			0.20676			0.69		
10/01/20 1:00	0.7			1.7			3			0.37			0.1833			0.61		
10/01/20 2:00	0.7			1.7			3			0.36			0.1797			0.6		
10/01/20 3:00	0.7			1.7			3			0.36			0.17904			0.6		
10/01/20 4:00	1.3			1.7			3			0.36			0.17898			0.6		
10/01/20 5:00	1.3			1.7			3			0.36			0.17886			0.6		
10/01/20 6:00	0.8			1.7			3			0.36			0.17952			0.6		
10/01/20 7:00	1.1			1.7			3			0.38			0.1905			0.64		
10/01/20 8:00	1			1.7			3			0.42			0.2088			0.7		
10/01/20 9:00	0.7			1.7			2			0.47			0.23364			0.78		
10/01/20 10:00	1.2			1.7			2			0.56			0.2805			0.94		
10/01/20 11:00	0.2			1.6			2			0.67			0.33264			1.11		
10/01/20 12:00	0.1			1.7			3			0.69			0.3471			1.16		
10/01/20 13:00	0.1			1.7			4			0.73			0.36258			1.21		
10/01/20 14:00	0.1			1.7			4			0.74			0.3705			1.24		
10/01/20 15:00	0.1			1.7			3			0.67			0.33708			1.12		
10/01/20 16:00	0.1			1.7			4			0.74			0.37056			1.24		
10/01/20 17:00	0.1			1.7			4			0.72			0.3579			1.19		
10/01/20 18:00	0.7			1.8			2			0.5			0.25104			0.84		
10/01/20 19:00	1.2			1.7			2			0.54			0.26922			0.9		
10/01/20 20:00	1.1			1.7			2			0.55			0.27564			0.92		
10/01/20 21:00	0.7			1.7			2			0.6			0.30066			1		
10/01/20 22:00	0.8			1.8			2			0.48			0.24072			0.8		
10/01/20 23:00	0.8			1.7			3			0.44			0.21954			0.73		
10/02/20 0:00	0.9			1.7			3			0.39			0.19374			0.65		
10/02/20 1:00	0.7			1.7			3			0.36			0.17994			0.6		
10/02/20 2:00	0.7			1.7			3			0.36			0.17946			0.6		
10/02/20 3:00	0.8			1.7			3			0.36			0.18054			0.6		
10/02/20 4:00	0.8			1.6			3			0.37			0.18552			0.62		
10/02/20 5:00	0.9			1.7			3			0.36			0.17916			0.6		
10/02/20 6:00	1.1			1.7			3			0.36			0.17892			0.6		
10/02/20 7:00	1			1.7			3			0.36			0.17898			0.6		
10/02/20 8:00	0.9			1.7			3			0.36			0.17952			0.6		
10/02/20 9:00	0.8			1.7			3			0.37			0.18654			0.62		
10/02/20 10:00	0.8			1.7			3			0.4			0.19788			0.66		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/02/20 11:00	0.7			1.7			2			0.46			0.23154			0.77		
10/02/20 12:00	1.1			1.7			2			0.52			0.26046			0.87		
10/02/20 13:00	1			1.7			2			0.55			0.2739			0.91		
10/02/20 14:00	0.7			1.7			2			0.59			0.29622			0.99		
10/02/20 15:00	0.9			1.7			2			0.5			0.25218			0.84		
10/02/20 16:00	0.3			1.6			3			0.66			0.32994			1.1		
10/02/20 17:00	0.5			1.7			3			0.62			0.30798			1.03		
10/02/20 18:00	0.8			1.8			2			0.45			0.2256			0.75		
10/02/20 19:00	1.2			1.7			2			0.53			0.26526			0.88		
10/02/20 20:00	1			1.7			3			0.42			0.20778			0.69		
10/02/20 21:00	1.1			1.7			2			0.52			0.25782			0.86		
10/02/20 22:00	1			1.8			2			0.48			0.23898			0.8		
10/02/20 23:00	1			1.7			3			0.44			0.21906			0.73		
10/03/20 0:00	0.9			1.7			3			0.37			0.18642			0.62		
10/03/20 1:00	0.8			1.7			3			0.36			0.17862			0.6		
10/03/20 2:00	1			1.7			3			0.36			0.17904			0.6		
10/03/20 3:00	1			1.7			3			0.36			0.17928			0.6		
10/03/20 4:00	1			1.7			3			0.36			0.1788			0.6		
10/03/20 5:00	1			1.7			3			0.36			0.17886			0.6		
10/03/20 6:00	0.8			1.7			3			0.36			0.17922			0.6		
10/03/20 7:00	0.9			1.7			3			0.36			0.17916			0.6		
10/03/20 8:00	1			1.7			3			0.38			0.19176			0.64		
10/03/20 9:00	0.9			1.7			3			0.43			0.21636			0.72		
10/03/20 10:00	0.7			1.7			3			0.45			0.22302			0.74		
10/03/20 11:00	0.7			1.7			3			0.47			0.2328			0.78		
10/03/20 12:00	0.7			1.7			2			0.45			0.2253			0.75		
10/03/20 13:00	1.2			1.7			2			0.54			0.2679			0.89		
10/03/20 14:00	0.4			1.7			3			0.63			0.31416			1.05		
10/03/20 15:00	0.8			1.8			2			0.5			0.25176			0.84		
10/03/20 16:00	1.1			1.7			2			0.53			0.26442			0.88		
10/03/20 17:00	0.7			1.7			2			0.49			0.24546			0.82		
10/03/20 18:00	0.3			1.6			3			0.69			0.3426			1.14		
10/03/20 19:00	0.7			1.7			2			0.59			0.29304			0.98		
10/03/20 20:00	0.8			1.8			2			0.51			0.25404			0.85		
10/03/20 21:00	1.1			1.7			2			0.54			0.2697			0.9		
10/03/20 22:00	0.8			1.7			3			0.47			0.23676			0.79		
10/03/20 23:00	0.8			1.7			3			0.44			0.21984			0.73		
10/04/20 0:00	0.8			1.7			3			0.37			0.18378			0.61		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/04/20 1:00	0.8			1.7			3			0.37			0.18342			0.61		
10/04/20 2:00	0.7			1.7			3			0.36			0.17892			0.6		
10/04/20 3:00	0.7			1.7			3			0.36			0.1791			0.6		
10/04/20 4:00	0.7			1.7			3			0.36			0.1815			0.61		
10/04/20 5:00	0.8			1.7			3			0.37			0.18408			0.61		
10/04/20 6:00	0.9			1.7			3			0.36			0.18066			0.6		
10/04/20 7:00	1.3			1.7			3			0.4			0.2004			0.67		
10/04/20 8:00	1.1			1.7			3			0.43			0.21264			0.71		
10/04/20 9:00	0.7			1.7			2			0.49			0.24486			0.82		
10/04/20 10:00	1.2			1.7			2			0.53			0.2634			0.88		
10/04/20 11:00	0.7			1.7			2			0.6			0.2997			1		
10/04/20 12:00	0.2			1.7			3			0.68			0.342			1.14		
10/04/20 13:00	0.1			1.7			4			0.73			0.3645			1.22		
10/04/20 14:00	0.1			1.7			4			0.73			0.3669			1.22		
10/04/20 15:00	0.1			1.7			4			0.73			0.36612			1.22		
10/04/20 16:00	0.1			1.7			4			0.71			0.35256			1.18		
10/04/20 17:00	0.2			1.7			3			0.66			0.3315			1.11		
10/04/20 18:00	0.3			1.7			3			0.63			0.31302			1.04		
10/04/20 19:00	1.1			1.8			2			0.52			0.25782			0.86		
10/04/20 20:00	1.2			1.7			2			0.5			0.24966			0.83		
10/04/20 21:00	0.9			1.7			2			0.5			0.24906			0.83		
10/04/20 22:00	0.8			1.7			3			0.43			0.21738			0.72		
10/04/20 23:00	0.8			1.7			3			0.38			0.1875			0.63		
10/05/20 0:00	0.7			1.7			3			0.36			0.17892			0.6		
10/05/20 1:00	0.7			1.7			3			0.36			0.1788			0.6		
10/05/20 2:00	0.8			1.7			3			0.36			0.17868			0.6		
10/05/20 3:00	0.8			1.7			3			0.36			0.17946			0.6		
10/05/20 4:00	0.7			1.7			3			0.37			0.18402			0.61		
10/05/20 5:00	1			1.7			4			0.39			0.19722			0.66		
10/05/20 6:00	0.9			1.7			3			0.4			0.19962			0.67		
10/05/20 7:00	0.9			1.7			3			0.42			0.20844			0.69		
10/05/20 8:00	0.8			1.7			3			0.45			0.22422			0.75		
10/05/20 9:00	0.7			1.7			2			0.52			0.2598			0.87		
10/05/20 10:00	1			1.6			2			0.54			0.27162			0.91		
10/05/20 11:00	0.5			1.7			3			0.62			0.30972			1.03		
10/05/20 12:00	0.6			1.7			3			0.6			0.2976			0.99		
10/05/20 13:00	0.1			1.7			4			0.72			0.35964			1.2		
10/05/20 14:00	0.1			1.7			5			0.74			0.37242			1.24		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/05/20 15:00	0.1			1.7			5			0.74			0.37152			1.24		
10/05/20 16:00	0.1			1.7			5			0.74			0.37182			1.24		
10/05/20 17:00	0.1			1.7			4			0.71			0.3525			1.18		
10/05/20 18:00	0.2			1.7			3			0.66			0.33126			1.1		
10/05/20 19:00	0.4			1.7			3			0.64			0.32088			1.07		
10/05/20 20:00	0.9			1.7			2			0.57			0.28392			0.95		
10/05/20 21:00	1			1.8			2			0.51			0.25506			0.85		
10/05/20 22:00	1.1			1.7			3			0.45			0.22482			0.75		
10/05/20 23:00	1			1.7			3			0.4			0.19884			0.66		
10/06/20 0:00	1.4			1.7			3			0.36			0.17856			0.6		
10/06/20 1:00	1.1			1.7			3			0.36			0.17802			0.59		
10/06/20 2:00	0.8			1.7			3			0.36			0.17844			0.59		
10/06/20 3:00	0.7			1.7			3			0.36			0.17856			0.6		
10/06/20 4:00	0.7			1.7			3			0.36			0.17844			0.59		
10/06/20 5:00	0.9			1.7			3			0.4			0.19992			0.67		
10/06/20 6:00	0.9			1.7			3			0.4			0.20214			0.67		
10/06/20 7:00	0.9			1.7			3			0.43			0.21546			0.72		
10/06/20 8:00	0.8			1.7			3			0.47			0.23292			0.78		
10/06/20 9:00	0.7			1.7			2			0.5			0.24942			0.83		
10/06/20 10:00	0.9			1.6			3			0.52			0.25908			0.86		
10/06/20 11:00	0.6			1.7			3			0.6			0.29982			1		
10/06/20 12:00	0.7			1.8			2			0.53			0.26256			0.88		
10/06/20 13:00	0.2			1.5			4			0.65			0.32652			1.09		
10/06/20 14:00	0.1			1.7			3			0.67			0.33624			1.12		
10/06/20 15:00	0			1.7			4			0.72			0.36132			1.2		
10/06/20 16:00	0			1.7			4			0.72			0.36096			1.2		
10/06/20 17:00	0.1			1.7			3			0.67			0.3333			1.11		
10/06/20 18:00	0.3			1.7			3			0.62			0.3123			1.04		
10/06/20 19:00	0.2			1.7			3			0.65			0.3255			1.09		
10/06/20 20:00	0.3			1.7			3			0.65			0.32316			1.08		
10/06/20 21:00	1.1			1.8			2			0.52			0.261			0.87		
10/06/20 22:00	0.8			1.7			3			0.44			0.22248			0.74		
10/06/20 23:00	0.8			1.7			3			0.39			0.19266			0.64		
10/07/20 0:00	0.7			1.7			3			0.36			0.17808			0.59		
10/07/20 1:00	0.7			1.7			3			0.35			0.17742			0.59		
10/07/20 2:00	0.7			1.7			3			0.35			0.1773			0.59		
10/07/20 3:00	0.7			1.7			3			0.35			0.17742			0.59		
10/07/20 4:00	0.8			1.7			3			0.36			0.1821			0.61		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/07/20 5:00	1.1			1.7			2			0.53			0.26376			0.88		
10/07/20 6:00	1.1			1.7			2			0.53			0.26454			0.88		
10/07/20 7:00	0.8			1.7			3			0.43			0.21648			0.72		
10/07/20 8:00	0.8			1.7			3			0.46			0.22788			0.76		
10/07/20 9:00	0.8			1.7			2			0.48			0.2391			0.8		
10/07/20 10:00	1.1			1.7			2			0.53			0.26406			0.88		
10/07/20 11:00	1			1.7			2			0.56			0.27882			0.93		
10/07/20 12:00	0.7			1.7			2			0.59			0.29466			0.98		
10/07/20 13:00	0.4			1.7			3			0.64			0.31824			1.06		
10/07/20 14:00	0.1			1.7			4			0.73			0.36666			1.22		
10/07/20 15:00	0.1			1.7			4			0.73			0.36276			1.21		
10/07/20 16:00	0.7			1.7			2			0.58			0.28758			0.96		
10/07/20 17:00	1			1.7			2			0.53			0.26694			0.89		
10/07/20 18:00	1.1			1.7			2			0.52			0.26136			0.87		
10/07/20 19:00	1.1			1.7			2			0.53			0.26352			0.88		
10/07/20 20:00	0.9			1.7			2			0.57			0.28356			0.95		
10/07/20 21:00	0.7			1.8			3			0.45			0.22392			0.75		
10/07/20 22:00	0.8			1.7			3			0.38			0.19236			0.64		
10/07/20 23:00	0.7			1.7			3			0.36			0.17778			0.59		
10/08/20 0:00	0.7			1.7			3			0.36			0.17772			0.59		
10/08/20 1:00	0.7			1.7			3			0.35			0.17748			0.59		
10/08/20 2:00	0.7			1.7			3			0.36			0.17754			0.59		
10/08/20 3:00	0.7			1.7			3			0.36			0.17772			0.59		
10/08/20 4:00	0.7			1.7			3			0.35			0.17442			0.58		
10/08/20 5:00	0			0			0	X		0.14			0.0678			0.23		
10/08/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/08/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/08/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/09/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/10/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/10/20 15:00	0			0			0	X		0.32			0.16104			0.54		
10/10/20 16:00	0.7			1.6			3			0.41			0.20436			0.68		
10/10/20 17:00	0.6			1.7			2			0.49			0.24744			0.82		
10/10/20 18:00	0.7			1.7			2			0.46			0.2301			0.77		
10/10/20 19:00	0.7			1.7			3			0.38			0.19104			0.64		
10/10/20 20:00	0.7			1.7			2			0.49			0.24468			0.82		
10/10/20 21:00	0.9			1.7			2			0.51			0.25614			0.85		
10/10/20 22:00	0.7			1.7			2			0.49			0.2433			0.81		
10/10/20 23:00	0.7			1.7			2			0.48			0.24084			0.8		
10/11/20 0:00	0.7			1.7			3			0.45			0.22326			0.74		
10/11/20 1:00	0.7			1.7			3			0.4			0.20226			0.67		
10/11/20 2:00	0.7			1.7			3			0.39			0.19482			0.65		
10/11/20 3:00	0.8			1.7			3			0.39			0.1926			0.64		
10/11/20 4:00	0.7			1.6			3			0.4			0.19974			0.67		
10/11/20 5:00	0.8			1.7			3			0.48			0.23964			0.8		
10/11/20 6:00	0.7			1.7			2			0.5			0.24786			0.83		
10/11/20 7:00	0.7			1.7			3			0.45			0.22698			0.76		
10/11/20 8:00	0.7			1.7			3			0.48			0.24024			0.8		
10/11/20 9:00	0.7			1.7			2			0.5			0.24816			0.83		
10/11/20 10:00	0.7			1.7			2			0.49			0.24618			0.82		
10/11/20 11:00	0.7			1.7			3			0.42			0.20976			0.7		
10/11/20 12:00	0.7			1.7			3			0.41			0.20496			0.68		
10/11/20 13:00	0.8			1.7			2			0.51			0.25482			0.85		
10/11/20 14:00	0.1			1.6			5			0.73			0.36612			1.22		
10/11/20 15:00	0.3			1.7			3			0.65			0.32658			1.09		
10/11/20 16:00	0.8			1.8			2			0.49			0.24486			0.82		
10/11/20 17:00	0.7			1.7			3			0.43			0.21576			0.72		
10/11/20 18:00	0.7			1.7			3			0.4			0.20118			0.67		
10/11/20 19:00	0.6			1.7			3			0.38			0.18822			0.63		
10/11/20 20:00	0.7			1.7			2			0.48			0.24234			0.81		
10/11/20 21:00	1.3			1.7			2			0.52			0.2592			0.86		
10/11/20 22:00	0.9			1.7			3			0.47			0.23634			0.79		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/11/20 23:00	0.8			1.7			3			0.42			0.21192			0.71		
10/12/20 0:00	0.8			1.7			3			0.4			0.19974			0.67		
10/12/20 1:00	0.9			1.7			3			0.38			0.19248			0.64		
10/12/20 2:00	0.8			1.7			3			0.37			0.1857			0.62		
10/12/20 3:00	0.8			1.7			3			0.38			0.18846			0.63		
10/12/20 4:00	0.9			1.7			3			0.43			0.21642			0.72		
10/12/20 5:00	1.2			1.7			2			0.53			0.26298			0.88		
10/12/20 6:00	1.1			1.7			3			0.58			0.29028			0.97		
10/12/20 7:00	1.5			1.7			3			0.58			0.29034			0.97		
10/12/20 8:00	1.3			1.7			3			0.57			0.28476			0.95		
10/12/20 9:00	1			1.7			3			0.56			0.28116			0.94		
10/12/20 10:00	0.8			1.7			3			0.57			0.28524			0.95		
10/12/20 11:00	0.8			1.8			3			0.49			0.24522			0.82		
10/12/20 12:00	0.7			1.7			2			0.51			0.25548			0.85		
10/12/20 13:00	0.2			1.6			4			0.69			0.34548			1.15		
10/12/20 14:00	0.1			1.7			5			0.75			0.37506			1.25		
10/12/20 15:00	0.1			1.7			5			0.75			0.37308			1.24		
10/12/20 16:00	0.7			1.8			2			0.49			0.24318			0.81		
10/12/20 17:00	0.7			1.7			3			0.47			0.23622			0.79		
10/12/20 18:00	0.7			1.7			3			0.46			0.23118			0.77		
10/12/20 19:00	1.2			1.7			3			0.41			0.20682			0.69		
10/12/20 20:00	0.9			1.7			3			0.45			0.22734			0.76		
10/12/20 21:00	0.9			1.7			3			0.42			0.20928			0.7		
10/12/20 22:00	1			1.7			2			0.5			0.24876			0.83		
10/12/20 23:00	1.3			1.7			2			0.53			0.26466			0.88		
10/13/20 0:00	0.9			1.7			2			0.51			0.25338			0.84		
10/13/20 1:00	0.8			1.7			2			0.51			0.2556			0.85		
10/13/20 2:00	0.7			1.7			2			0.52			0.25944			0.86		
10/13/20 3:00	0.8			1.7			2			0.53			0.26484			0.88		
10/13/20 4:00	0.8			1.7			2			0.51			0.25542			0.85		
10/13/20 5:00	0.2			1.7			5			0.78			0.38814			1.29		
10/13/20 6:00	0.4			1.7			6			0.79			0.39408			1.31		
10/13/20 7:00	0.3			1.7			6			0.77			0.38454			1.28		
10/13/20 8:00	0.9			1.8			3			0.48			0.24084			0.8		
10/13/20 9:00	0.8			1.7			3			0.37			0.18516			0.62		
10/13/20 10:00	1.1			1.7			2			0.54			0.26802			0.89		
10/13/20 11:00	0.4			1.7			3			0.63			0.31512			1.05		
10/13/20 12:00	0.3			1.7			3			0.64			0.31908			1.06		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/13/20 13:00	0.3			1.7			3			0.64			0.32064			1.07		
10/13/20 14:00	0.5			1.7			3			0.6			0.29886			1		
10/13/20 15:00	0.7			1.7			2			0.57			0.28716			0.96		
10/13/20 16:00	0.6			1.7			2			0.59			0.29598			0.99		
10/13/20 17:00	0.8			1.7			2			0.57			0.28716			0.96		
10/13/20 18:00	0.9			1.7			2			0.54			0.27102			0.9		
10/13/20 19:00	0.7			1.8			2			0.49			0.2451			0.82		
10/13/20 20:00	0.9			1.7			2			0.57			0.28482			0.95		
10/13/20 21:00	1			1.8			2			0.49			0.24552			0.82		
10/13/20 22:00	1			1.7			3			0.44			0.219			0.73		
10/13/20 23:00	0.8			1.7			3			0.37			0.18426			0.61		
10/14/20 0:00	0.8			1.7			3			0.36			0.17832			0.59		
10/14/20 1:00	0.7			1.7			3			0.36			0.17862			0.6		
10/14/20 2:00	0.7			1.7			3			0.36			0.17808			0.59		
10/14/20 3:00	0.7			1.7			3			0.36			0.17844			0.59		
10/14/20 4:00	0.7			1.7			3			0.36			0.18204			0.61		
10/14/20 5:00	0.9			1.7			3			0.39			0.19716			0.66		
10/14/20 6:00	0.8			1.7			3			0.39			0.19716			0.66		
10/14/20 7:00	0.8			1.7			3			0.4			0.20004			0.67		
10/14/20 8:00	0.7			1.7			3			0.43			0.21258			0.71		
10/14/20 9:00	0.7			1.7			2			0.48			0.23976			0.8		
10/14/20 10:00	1.2			1.7			2			0.51			0.25464			0.85		
10/14/20 11:00	1			1.7			2			0.54			0.2697			0.9		
10/14/20 12:00	0.8			1.7			2			0.58			0.2886			0.96		
10/14/20 13:00	0.3			1.7			3			0.63			0.3174			1.06		
10/14/20 14:00	0.1			1.7			4			0.73			0.36654			1.22		
10/14/20 15:00	0			1.7			5			0.73			0.36654			1.22		
10/14/20 16:00	0.1			1.7			4			0.7			0.35088			1.17		
10/14/20 17:00	0.2			1.7			3			0.65			0.32706			1.09		
10/14/20 18:00	0.3			1.7			3			0.63			0.31656			1.06		
10/14/20 19:00	0.7			1.8			3			0.46			0.22824			0.76		
10/14/20 20:00	0.9			1.7			2			0.54			0.2715			0.91		
10/14/20 21:00	0.7			1.8			2			0.49			0.24564			0.82		
10/14/20 22:00	0.7			1.7			3			0.44			0.21942			0.73		
10/14/20 23:00	0.7			1.7			3			0.4			0.19806			0.66		
10/15/20 0:00	0.6			1.7			3			0.36			0.17838			0.59		
10/15/20 1:00	0.6			1.7			3			0.36			0.17754			0.59		
10/15/20 2:00	0.6			1.7			3			0.36			0.17796			0.59		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/15/20 3:00	0.7			1.7			3			0.36			0.17832			0.59		
10/15/20 4:00	0.7			1.7			3			0.36			0.1794			0.6		
10/15/20 5:00	0.8			1.7			4			0.38			0.19044			0.63		
10/15/20 6:00	0.7			1.7			3			0.43			0.21384			0.71		
10/15/20 7:00	0.7			1.7			3			0.45			0.22542			0.75		
10/15/20 8:00	0.7			1.6			2			0.32			0.16188			0.54		
10/15/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/20 15:00	0.6			1.9			3			0.32			0.15918			0.53		
10/15/20 16:00	0.3			1.6			4			0.68			0.34086			1.14		
10/15/20 17:00	0.1			1.7			3			0.67			0.33504			1.12		
10/15/20 18:00	0.4			1.7			3			0.63			0.31344			1.04		
10/15/20 19:00	0.7			1.8			2			0.5			0.25056			0.84		
10/15/20 20:00	0.9			1.7			2			0.57			0.28422			0.95		
10/15/20 21:00	0.7			1.8			3			0.46			0.2319			0.77		
10/15/20 22:00	0.9			1.7			3			0.4			0.20076			0.67		
10/15/20 23:00	0.8			1.7			3			0.38			0.18996			0.63		
10/16/20 0:00	0.7			1.7			3			0.36			0.1779			0.59		
10/16/20 1:00	1			1.7			3			0.36			0.1776			0.59		
10/16/20 2:00	0.8			1.7			3			0.35			0.17742			0.59		
10/16/20 3:00	0.7			1.7			3			0.35			0.17748			0.59		
10/16/20 4:00	0.8			1.7			3			0.37			0.18456			0.62		
10/16/20 5:00	0.8			1.7			3			0.38			0.19176			0.64		
10/16/20 6:00	0.8			1.7			3			0.39			0.1938			0.65		
10/16/20 7:00	1			1.7			3			0.39			0.19266			0.64		
10/16/20 8:00	0.7			1.7			3			0.42			0.2097			0.7		
10/16/20 9:00	0.7			1.7			3			0.45			0.22644			0.75		
10/16/20 10:00	0.7			1.7			3			0.45			0.22644			0.75		
10/16/20 11:00	0.7			1.7			3			0.44			0.22092			0.74		
10/16/20 12:00	1			1.7			2			0.54			0.27186			0.91		
10/16/20 13:00	0.4			1.7			3			0.61			0.30636			1.02		
10/16/20 14:00	0.1			1.7			3			0.67			0.3327			1.11		
10/16/20 15:00	0.1			1.7			4			0.72			0.36222			1.21		
10/16/20 16:00	0.1			1.7			4			0.73			0.36252			1.21		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/16/20 17:00	0.1			1.7			4			0.69			0.34626			1.15		
10/16/20 18:00	0.3			1.7			3			0.64			0.31752			1.06		
10/16/20 19:00	0.3			1.7			3			0.63			0.31716			1.06		
10/16/20 20:00	0.8			1.7			2			0.57			0.28434			0.95		
10/16/20 21:00	0.8			1.8			2			0.49			0.24318			0.81		
10/16/20 22:00	0.8			1.7			3			0.43			0.21696			0.72		
10/16/20 23:00	0.8			1.7			3			0.41			0.20496			0.68		
10/17/20 0:00	0.8			1.7			3			0.36			0.18042			0.6		
10/17/20 1:00	0.9			1.7			3			0.35			0.17736			0.59		
10/17/20 2:00	0.8			1.7			3			0.36			0.1782			0.59		
10/17/20 3:00	0.7			1.7			3			0.36			0.17826			0.59		
10/17/20 4:00	0.8			1.7			3			0.36			0.17832			0.59		
10/17/20 5:00	1.1			1.7			3			0.38			0.18756			0.63		
10/17/20 6:00	1			1.7			3			0.37			0.18366			0.61		
10/17/20 7:00	0.9			1.7			3			0.39			0.19728			0.66		
10/17/20 8:00	0.7			1.7			3			0.44			0.21792			0.73		
10/17/20 9:00	0.7			1.7			3			0.47			0.23346			0.78		
10/17/20 10:00	0.7			1.7			2			0.48			0.24192			0.81		
10/17/20 11:00	0.7			1.7			2			0.48			0.24144			0.8		
10/17/20 12:00	0.6			1.7			2			0.5			0.24816			0.83		
10/17/20 13:00	0.9			1.6			2			0.55			0.27726			0.92		
10/17/20 14:00	0.1			1.7			5			0.69			0.3456			1.15		
10/17/20 15:00	0			1.7			4			0.62			0.31212			1.04		
10/17/20 16:00	0.1			1.7			4			0.63			0.31686			1.06		
10/17/20 17:00	0.5			1.7			2			0.6			0.30186			1.01		
10/17/20 18:00	1			1.7			2			0.52			0.2613			0.87		
10/17/20 19:00	0.2			1.7			3			0.67			0.33312			1.11		
10/17/20 20:00	0.8			1.7			2			0.57			0.28722			0.96		
10/17/20 21:00	0.8			1.8			2			0.49			0.24576			0.82		
10/17/20 22:00	0.8			1.7			3			0.44			0.219			0.73		
10/17/20 23:00	0.7			1.7			3			0.4			0.19884			0.66		
10/18/20 0:00	0.7			1.7			3			0.38			0.19062			0.64		
10/18/20 1:00	0.7			1.7			3			0.35			0.17748			0.59		
10/18/20 2:00	0.7			1.7			3			0.36			0.17856			0.6		
10/18/20 3:00	0.7			1.7			3			0.36			0.17778			0.59		
10/18/20 4:00	0.8			1.7			3			0.36			0.1797			0.6		
10/18/20 5:00	0.9			1.7			3			0.37			0.1833			0.61		
10/18/20 6:00	0.9			1.7			3			0.37			0.18408			0.61		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/18/20 7:00	0.9			1.7			3			0.39			0.19494			0.65		
10/18/20 8:00	1			1.7			3			0.42			0.21036			0.7		
10/18/20 9:00	0.8			1.7			2			0.47			0.23598			0.79		
10/18/20 10:00	1.1			1.7			2			0.54			0.26778			0.89		
10/18/20 11:00	0.9			1.7			2			0.54			0.27084			0.9		
10/18/20 12:00	1			1.7			2			0.53			0.26574			0.89		
10/18/20 13:00	0.8			1.7			2			0.56			0.2817			0.94		
10/18/20 14:00	0.4			1.7			3			0.63			0.31572			1.05		
10/18/20 15:00	0.1			1.7			3			0.69			0.3441			1.15		
10/18/20 16:00	0.7			1.8			2			0.58			0.28962			0.97		
10/18/20 17:00	0.7			1.8			2			0.51			0.25284			0.84		
10/18/20 18:00	0.7			1.7			3			0.46			0.23148			0.77		
10/18/20 19:00	0.7			1.7			3			0.46			0.23226			0.77		
10/18/20 20:00	1			1.7			2			0.55			0.27678			0.92		
10/18/20 21:00	0.8			1.7			3			0.48			0.23868			0.8		
10/18/20 22:00	0.8			1.7			3			0.41			0.20676			0.69		
10/18/20 23:00	0.8			1.7			3			0.38			0.18756			0.63		
10/19/20 0:00	0.7			1.7			3			0.36			0.17874			0.6		
10/19/20 1:00	0.7			1.7			3			0.36			0.18072			0.6		
10/19/20 2:00	0.7			1.7			3			0.36			0.17832			0.59		
10/19/20 3:00	0.7			1.7			3			0.36			0.17934			0.6		
10/19/20 4:00	1.7			1.7			3			0.37			0.18552			0.62		
10/19/20 5:00	1.1			1.7			3			0.4			0.20124			0.67		
10/19/20 6:00	0.9			1.7			3			0.41			0.2046			0.68		
10/19/20 7:00	0.8			1.5			3			0.43			0.2163			0.72		
10/19/20 8:00	0.8			1.5			3			0.45			0.22656			0.76		
10/19/20 9:00	1.2			1.5			2			0.51			0.2547			0.85		
10/19/20 10:00	1			1.5			2			0.54			0.27246			0.91		
10/19/20 11:00	0.8			1.5			2			0.58			0.28872			0.96		
10/19/20 12:00	0.7			1.5			2			0.59			0.2943			0.98		
10/19/20 13:00	0.5			1.5			3			0.61			0.30744			1.02		
10/19/20 14:00	0.2			1.5			3			0.65			0.32694			1.09		
10/19/20 15:00	0.1			1.5			4			0.73			0.3645			1.22		
10/19/20 16:00	0.1			1.5			4			0.69			0.34704			1.16		
10/19/20 17:00	0.3			1.6			3			0.64			0.31872			1.06		
10/19/20 18:00	0.8			1.7			2			0.57			0.28668			0.96		
10/19/20 19:00	0.8			1.8			3			0.47			0.23568			0.79		
10/19/20 20:00	1			1.7			2			0.55			0.27312			0.91		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/19/20 21:00	0.8			1.8			3			0.48			0.23844			0.79		
10/19/20 22:00	0.9			1.7			3			0.41			0.2046			0.68		
10/19/20 23:00	1.5			1.7			3			0.38			0.19026			0.63		
10/20/20 0:00	0.9			1.7			2			0.36			0.17934			0.6		
10/20/20 1:00	1.1			1.7			3			0.36			0.17814			0.59		
10/20/20 2:00	1.1			1.7			3			0.36			0.17766			0.59		
10/20/20 3:00	0.8			1.7			3			0.36			0.17838			0.59		
10/20/20 4:00	0.8			1.7			3			0.37			0.18414			0.61		
10/20/20 5:00	1			1.7			3			0.39			0.1974			0.66		
10/20/20 6:00	1			1.7			3			0.39			0.19728			0.66		
10/20/20 7:00	0.9			1.7			3			0.39			0.19596			0.65		
10/20/20 8:00	0.8			1.7			3			0.42			0.21222			0.71		
10/20/20 9:00	0.7			1.7			2			0.49			0.24492			0.82		
10/20/20 10:00	0.9			1.7			2			0.54			0.26808			0.89		
10/20/20 11:00	0.5			1.7			2			0.62			0.31158			1.04		
10/20/20 12:00	0.4			1.7			3			0.63			0.31638			1.05		
10/20/20 13:00	0.1			1.7			4			0.72			0.36072			1.2		
10/20/20 14:00	0.1			1.7			4			0.73			0.36492			1.22		
10/20/20 15:00	0.1			1.7			4			0.72			0.35904			1.2		
10/20/20 16:00	0.6			1.7			2			0.59			0.29382			0.98		
10/20/20 17:00	0.8			1.8			2			0.52			0.261			0.87		
10/20/20 18:00	0.7			1.7			2			0.5			0.25194			0.84		
10/20/20 19:00	0.7			1.7			2			0.58			0.29016			0.97		
10/20/20 20:00	1			1.7			2			0.51			0.25476			0.85		
10/20/20 21:00	0.8			1.7			3			0.44			0.2211			0.74		
10/20/20 22:00	0.8			1.7			3			0.39			0.19536			0.65		
10/20/20 23:00	0.7			1.7			3			0.36			0.17844			0.59		
10/21/20 0:00	0.7			1.7			3			0.35			0.17736			0.59		
10/21/20 1:00	0.7			1.7			3			0.36			0.17784			0.59		
10/21/20 2:00	0.7			1.7			3			0.36			0.17808			0.59		
10/21/20 3:00	0.7			1.7			3			0.36			0.17796			0.59		
10/21/20 4:00	0.8			1.7			3			0.36			0.17946			0.6		
10/21/20 5:00	0.8			1.7			3			0.44			0.22092			0.74		
10/21/20 6:00	0.8			1.7			3			0.45			0.22284			0.74		
10/21/20 7:00	0.8			1.7			3			0.36			0.17946			0.6		
10/21/20 8:00	0.8			1.7			3			0.37			0.18636			0.62		
10/21/20 9:00	0.8			1.7			3			0.4			0.19824			0.66		
10/21/20 10:00	0.8			1.7			3			0.42			0.21			0.7		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/21/20 11:00	0.7			1.7			2			0.47			0.2349			0.78		
10/21/20 12:00	0.8			1.7			2			0.49			0.24606			0.82		
10/21/20 13:00	1.1			1.7			2			0.53			0.26712			0.89		
10/21/20 14:00	0.6			1.7			2			0.6			0.29808			0.99		
10/21/20 15:00	0.8			1.8			2			0.48			0.23916			0.8		
10/21/20 16:00	0.7			1.7			2			0.47			0.23394			0.78		
10/21/20 17:00	0.7			1.7			2			0.46			0.22938			0.76		
10/21/20 18:00	0.7			1.7			3			0.41			0.2049			0.68		
10/21/20 19:00	1.2			1.7			3			0.36			0.17898			0.6		
10/21/20 20:00	0.9			1.7			3			0.37			0.183			0.61		
10/21/20 21:00	0.9			1.7			2			0.43			0.21258			0.71		
10/21/20 22:00	0.8			1.7			3			0.37			0.18666			0.62		
10/21/20 23:00	0.8			1.7			3			0.36			0.17904			0.6		
10/22/20 0:00	0.7			1.7			3			0.36			0.1782			0.59		
10/22/20 1:00	0.7			1.7			3			0.36			0.1776			0.59		
10/22/20 2:00	0.9			1.7			3			0.36			0.1779			0.59		
10/22/20 3:00	0.8			1.7			3			0.36			0.17796			0.59		
10/22/20 4:00	0.8			1.6			3			0.37			0.18324			0.61		
10/22/20 5:00	0.8			1.7			2			0.52			0.26124			0.87		
10/22/20 6:00	0.7			1.7			2			0.52			0.2598			0.87		
10/22/20 7:00	0.7			1.6			3			0.43			0.21348			0.71		
10/22/20 8:00	0.7			1.7			3			0.45			0.2226			0.74		
10/22/20 9:00	0.7			1.6			2			0.49			0.24294			0.81		
10/22/20 10:00	0.7			1.7			3			0.48			0.24			0.8		
10/22/20 11:00	0.7			1.6			2			0.49			0.24582			0.82		
10/22/20 12:00	0.7			1.7			2			0.52			0.26016			0.87		
10/22/20 13:00	0.7			1.7			2			0.52			0.26022			0.87		
10/22/20 14:00	1			1.6			2			0.53			0.26586			0.89		
10/22/20 15:00	0.7			1.7			3			0.47			0.2334			0.78		
10/22/20 16:00	1			1.7			2			0.52			0.2592			0.86		
10/22/20 17:00	1.1			1.7			2			0.55			0.27306			0.91		
10/22/20 18:00	0.7			1.7			3			0.48			0.24114			0.8		
10/22/20 19:00	0.7			1.7			3			0.48			0.23976			0.8		
10/22/20 20:00	0.7			1.7			3			0.48			0.24114			0.8		
10/22/20 21:00	0.7			1.7			3			0.39			0.19542			0.65		
10/22/20 22:00	0.7			1.7			3			0.36			0.17838			0.59		
10/22/20 23:00	0.7			1.7			3			0.36			0.17814			0.59		
10/23/20 0:00	0.7			1.7			3			0.36			0.17766			0.59		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/23/20 1:00	0.8			1.7			3			0.36			0.17802			0.59		
10/23/20 2:00	0.7			1.7			3			0.36			0.1782			0.59		
10/23/20 3:00	0.7			1.7			3			0.36			0.17802			0.59		
10/23/20 4:00	0.7			1.6			3			0.36			0.17892			0.6		
10/23/20 5:00	0.9			1.7			3			0.38			0.189			0.63		
10/23/20 6:00	0.8			1.7			3			0.39			0.19494			0.65		
10/23/20 7:00	0.8			1.7			3			0.4			0.20076			0.67		
10/23/20 8:00	0.8			1.7			3			0.42			0.21138			0.7		
10/23/20 9:00	0.7			1.7			3			0.42			0.2109			0.7		
10/23/20 10:00	0.7			1.7			3			0.41			0.20382			0.68		
10/23/20 11:00	0.7			1.7			2			0.47			0.23358			0.78		
10/23/20 12:00	0.7			1.7			2			0.49			0.24288			0.81		
10/23/20 13:00	1.1			1.7			2			0.53			0.26556			0.89		
10/23/20 14:00	1.1			1.7			2			0.54			0.2691			0.9		
10/23/20 15:00	1.1			1.7			2			0.53			0.26748			0.89		
10/23/20 16:00	0.7			1.7			3			0.45			0.22608			0.75		
10/23/20 17:00	0.9			1.7			2			0.56			0.2796			0.93		
10/23/20 18:00	0.8			1.7			3			0.42			0.20796			0.69		
10/23/20 19:00	0.7			1.7			3			0.38			0.19062			0.64		
10/23/20 20:00	0.7			1.7			3			0.46			0.228			0.76		
10/23/20 21:00	0.8			1.7			3			0.41			0.2046			0.68		
10/23/20 22:00	0.7			1.7			3			0.35			0.1773			0.59		
10/23/20 23:00	0			0			0	X		0.15			0.07446			0.25		
10/24/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/24/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/24/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/24/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/24/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/24/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/24/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/24/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/24/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/24/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/24/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/24/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/24/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/24/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/24/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/24/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/24/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/24/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/24/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/24/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/24/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/24/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/24/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/24/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/25/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/25/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/25/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/25/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/25/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/25/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/25/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/25/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/25/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/25/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/25/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/25/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/25/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/25/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/25/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/25/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/25/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/25/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/25/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/25/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/25/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/25/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/25/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/25/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/26/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/26/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/26/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/26/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/26/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/26/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/26/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/26/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/26/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/26/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/26/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/26/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/26/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/26/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/26/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/26/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/26/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/26/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/26/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/26/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/26/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/26/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/26/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/26/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/27/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/27/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/27/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/27/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/27/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/27/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/27/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/27/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/27/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/27/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/27/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/27/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/27/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/27/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/27/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/27/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/27/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/27/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/27/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/27/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/27/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/27/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/27/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/27/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/28/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/28/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/28/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/28/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/28/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/28/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/28/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/28/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/28/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/28/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/28/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/28/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/28/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/28/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/28/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/28/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/28/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/28/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/28/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/28/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/28/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/28/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/28/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/28/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/29/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/29/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/29/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/29/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/29/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/29/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/29/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/29/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/29/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/29/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/29/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/29/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/29/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/29/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/29/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/29/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/29/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/29/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/29/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/29/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/29/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/29/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/29/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/29/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/30/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/30/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/30/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/30/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/30/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/30/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/30/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/30/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/30/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/30/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/30/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/30/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/30/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/30/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/30/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/30/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/30/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/30/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/30/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/30/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/30/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/30/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/30/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/30/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/31/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/31/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/31/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/31/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/31/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/31/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/31/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/31/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/31/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/31/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/31/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/31/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/31/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/31/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/31/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/31/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/31/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/31/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/31/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/31/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/31/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/31/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/31/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/31/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/01/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/01/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/01/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/01/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/01/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/01/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/01/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/01/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/01/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/01/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/01/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/01/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/01/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/01/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/01/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/01/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/01/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/01/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/01/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/01/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/01/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/01/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/01/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/01/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/02/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/02/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/02/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/02/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/02/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/02/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/02/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/02/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/02/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/02/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/02/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/02/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/02/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/02/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/02/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/02/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/02/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/02/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/02/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/02/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/02/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/02/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/02/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/02/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/03/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/03/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/03/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/03/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/03/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/03/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/03/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/03/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/03/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/03/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/03/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/03/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/03/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/03/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/03/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/03/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/03/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/03/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/03/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/03/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/03/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/03/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/03/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/03/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/04/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/04/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/04/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/04/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/04/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/04/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/04/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/04/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/04/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/04/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/04/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/04/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/04/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/04/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/04/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/04/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/04/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/04/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/04/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/04/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/04/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/04/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/04/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/04/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/05/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/05/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/05/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/05/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/05/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/05/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/05/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/05/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/05/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/05/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/05/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/05/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/05/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/05/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/05/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/05/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/05/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/05/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/05/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/05/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/05/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/05/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/05/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/05/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/06/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/06/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/06/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/06/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/06/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/06/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/06/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/06/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/06/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/06/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/06/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/06/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/06/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/06/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/06/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/06/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/06/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/06/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/06/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/06/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/06/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/06/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/06/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/06/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/07/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/07/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/07/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/07/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/07/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/07/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/07/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/07/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/07/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/07/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/07/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/07/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/07/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/07/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/07/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/07/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/07/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/07/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/07/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/07/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/07/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/07/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/07/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/07/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/08/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/08/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/08/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/08/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/08/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/08/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/08/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/08/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/08/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/08/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/08/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/08/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/08/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/08/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/08/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/08/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/08/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/08/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/08/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/08/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/08/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/08/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/08/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/08/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/09/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/09/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/09/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/09/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/09/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/09/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/09/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/09/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/09/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/09/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/09/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/09/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/09/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/09/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/09/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/09/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/09/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/09/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/09/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/09/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/09/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/09/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/09/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/09/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/10/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/10/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/10/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/10/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/10/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/10/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/10/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/10/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/10/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/10/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/10/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/10/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/10/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/10/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/10/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/10/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/10/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/10/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/10/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/10/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/10/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/10/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/10/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/10/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/11/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/11/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/11/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/11/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/11/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/11/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/11/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/11/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/11/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/11/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/11/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/11/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/11/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/11/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/11/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/11/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/11/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/11/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/11/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/11/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/11/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/11/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/11/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/11/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/12/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/12/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/12/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/12/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/12/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/12/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/12/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/12/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/12/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/12/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/12/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/12/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/12/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/12/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/12/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/12/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/12/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/12/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/12/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/12/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/12/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/12/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/12/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/12/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/13/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/13/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/13/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/13/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/13/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/13/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/13/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/13/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/13/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/13/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/13/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/13/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/13/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/13/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/13/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/13/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/13/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/13/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/13/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/13/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/13/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/13/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/13/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/13/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/14/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/14/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/14/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/14/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/14/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/14/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/14/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/14/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/14/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/14/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/14/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/14/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/14/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/14/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/14/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/14/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/14/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/14/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/14/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/14/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/14/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/14/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/14/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/14/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/15/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/15/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/16/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/17/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/17/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/18/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/18/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/20/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/20/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/21/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/21/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/21/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/21/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/21/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/21/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/21/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/21/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/21/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/21/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/21/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/21/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/21/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/21/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/21/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/21/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/21/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/21/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/21/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/21/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/21/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/21/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/21/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/21/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/22/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/22/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/22/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/22/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/22/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/22/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/22/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/22/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/22/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/22/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/22/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/22/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/22/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/22/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/22/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/22/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/22/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/22/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/22/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/22/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/22/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/22/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/22/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/22/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/23/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/23/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/24/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/25/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/25/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/26/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/28/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/30/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/01/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/03/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/04/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/06/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/07/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/09/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/11/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/12/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/14/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/15/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/17/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/19/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/20/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/22/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/20 17:00	0			0			0	X		0.29			0.1452			0.48		
12/22/20 18:00	0.8			1.6			3			0.48			0.23808			0.79		
12/22/20 19:00	0.7			1.7			2			0.53			0.26694			0.89		
12/22/20 20:00	0			0			0	X		0.24			0.11778			0.39		
12/22/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/23/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/25/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/26/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/28/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/30/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/31/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	

AQ57 CT2 HOURLY EMISSIONS

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/01/20 0:00	1			1			1.7			0.41			0.20682			0.69		
10/01/20 1:00	0.9			1			1.7			0.37			0.1962			0.65		
10/01/20 2:00	1			1			1.7			0.36			0.20064			0.67		
10/01/20 3:00	0.9			1			1.7			0.36			0.2025			0.68		
10/01/20 4:00	1.4			1			1.7			0.36			0.20052			0.67		
10/01/20 5:00	1.5			1			1.7			0.36			0.16932			0.56		
10/01/20 6:00	0.9			1			1.7			0.36			0.16968			0.57		
10/01/20 7:00	1.3			2			1.7			0.38			0.18468			0.62		
10/01/20 8:00	1.1			1			1.7			0.42			0.20892			0.7		
10/01/20 9:00	1			1			1.7			0.47			0.23124			0.77		
10/01/20 10:00	1.2			2			1.7			0.56			0.27264			0.91		
10/01/20 11:00	0.4			2			1.7			0.67			0.31728			1.06		
10/01/20 12:00	0.3			2			1.7			0.69			0.33144			1.1		
10/01/20 13:00	0.3			3			1.7			0.73			0.34692			1.16		
10/01/20 14:00	0.3			3			1.7			0.74			0.35496			1.18		
10/01/20 15:00	0.3			2			1.7			0.67			0.32256			1.08		
10/01/20 16:00	0.3			3			1.7			0.74			0.35568			1.19		
10/01/20 17:00	0.3			3			1.7			0.72			0.3432			1.14		
10/01/20 18:00	0.9			1			1.8			0.5			0.23988			0.8		
10/01/20 19:00	1.3			1			1.7			0.54			0.2586			0.86		
10/01/20 20:00	1.2			2			1.7			0.55			0.2613			0.87		
10/01/20 21:00	0.9			2			1.7			0.6			0.28644			0.95		
10/01/20 22:00	1			1			1.7			0.48			0.23526			0.78		
10/01/20 23:00	1			1			1.7			0.44			0.21678			0.72		
10/02/20 0:00	1			1			1.7			0.39			0.20184			0.67		
10/02/20 1:00	1			1			1.7			0.36			0.19734			0.66		
10/02/20 2:00	1			2			1.7			0.36			0.1821			0.61		
10/02/20 3:00	1.1			2			1.7			0.36			0.18102			0.6		
10/02/20 4:00	1.1			1			1.7			0.37			0.19122			0.64		
10/02/20 5:00	0.9			1			1.7			0.36			0.16968			0.57		
10/02/20 6:00	1.3			2			1.7			0.36			0.16968			0.57		
10/02/20 7:00	1.2			2			1.7			0.36			0.16962			0.57		
10/02/20 8:00	1.1			1			1.7			0.36			0.16932			0.56		
10/02/20 9:00	1			2			1.7			0.37			0.17778			0.59		
10/02/20 10:00	0.9			0			1.7			0.4			0.19548			0.65		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/02/20 11:00	0.9			1			1.7			0.46			0.21972			0.73		
10/02/20 12:00	1.5			1			1.7			0.52			0.24612			0.82		
10/02/20 13:00	1.1			1			1.7			0.55			0.25878			0.86		
10/02/20 14:00	0.8			2			1.7			0.59			0.2814			0.94		
10/02/20 15:00	1.1			1			1.7			0.5			0.23874			0.8		
10/02/20 16:00	0.5			2			1.7			0.66			0.31542			1.05		
10/02/20 17:00	0.6			2			1.7			0.62			0.29388			0.98		
10/02/20 18:00	1			1			1.8			0.45			0.21582			0.72		
10/02/20 19:00	1.3			2			1.7			0.53			0.25866			0.86		
10/02/20 20:00	1.1			1			1.7			0.42			0.19884			0.66		
10/02/20 21:00	1.3			2			1.7			0.52			0.24738			0.82		
10/02/20 22:00	1.2			1			1.7			0.48			0.23118			0.77		
10/02/20 23:00	1.1			1			1.7			0.44			0.21852			0.73		
10/03/20 0:00	1.1			1			1.7			0.37			0.198			0.66		
10/03/20 1:00	1.2			1			1.7			0.36			0.1833			0.61		
10/03/20 2:00	1.2			1			1.7			0.36			0.16932			0.56		
10/03/20 3:00	1.2			2			1.7			0.36			0.16962			0.57		
10/03/20 4:00	1.1			1			1.7			0.36			0.16962			0.57		
10/03/20 5:00	1			1			1.7			0.36			0.16962			0.57		
10/03/20 6:00	0.9			2			1.7			0.36			0.16962			0.57		
10/03/20 7:00	1			1			1.7			0.36			0.16968			0.57		
10/03/20 8:00	1.2			1			1.7			0.38			0.1833			0.61		
10/03/20 9:00	1			1			1.7			0.43			0.21372			0.71		
10/03/20 10:00	1			1			1.7			0.45			0.22656			0.76		
10/03/20 11:00	0.9			1			1.7			0.47			0.23946			0.8		
10/03/20 12:00	0.9			1			1.7			0.45			0.23304			0.78		
10/03/20 13:00	1.5			2			1.7			0.54			0.2553			0.85		
10/03/20 14:00	0.5			2			1.7			0.63			0.30024			1		
10/03/20 15:00	0.9			1			1.7			0.5			0.2388			0.8		
10/03/20 16:00	1.3			1			1.7			0.53			0.25122			0.84		
10/03/20 17:00	0.9			1			1.7			0.49			0.23724			0.79		
10/03/20 18:00	0.5			2			1.7			0.69			0.32868			1.1		
10/03/20 19:00	0.9			2			1.7			0.59			0.2799			0.93		
10/03/20 20:00	1			1			1.7			0.51			0.24048			0.8		
10/03/20 21:00	1.3			2			1.7			0.54			0.26232			0.87		
10/03/20 22:00	1			1			1.7			0.47			0.23364			0.78		
10/03/20 23:00	1			1			1.7			0.44			0.22542			0.75		
10/04/20 0:00	1			1			1.7			0.37			0.20058			0.67		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/04/20 1:00	1			1			1.7			0.37			0.20418			0.68		
10/04/20 2:00	1			1			1.7			0.36			0.1809			0.6		
10/04/20 3:00	0.9			1			1.7			0.36			0.16944			0.56		
10/04/20 4:00	0.9			1			1.7			0.36			0.17208			0.57		
10/04/20 5:00	1			2			1.7			0.37			0.17964			0.6		
10/04/20 6:00	1.2			2			1.7			0.36			0.18444			0.61		
10/04/20 7:00	1.5			1			1.7			0.4			0.20772			0.69		
10/04/20 8:00	1.2			1			1.7			0.43			0.22506			0.75		
10/04/20 9:00	0.9			1			1.7			0.49			0.23598			0.79		
10/04/20 10:00	1.7			1			1.7			0.53			0.2448			0.82		
10/04/20 11:00	0.8			2			1.7			0.6			0.2841			0.95		
10/04/20 12:00	0.3			2			1.7			0.68			0.32652			1.09		
10/04/20 13:00	0.2			3			1.7			0.73			0.34974			1.17		
10/04/20 14:00	0.2			3			1.7			0.73			0.3522			1.17		
10/04/20 15:00	0.2			3			1.7			0.73			0.35178			1.17		
10/04/20 16:00	0.2			3			1.7			0.71			0.3384			1.13		
10/04/20 17:00	0.4			2			1.7			0.66			0.31746			1.06		
10/04/20 18:00	0.5			2			1.7			0.63			0.29994			1		
10/04/20 19:00	1.6			2			1.7			0.52			0.24276			0.81		
10/04/20 20:00	1.4			1			1.7			0.5			0.23856			0.8		
10/04/20 21:00	1			1			1.7			0.5			0.24006			0.8		
10/04/20 22:00	0.9			1			1.7			0.43			0.2145			0.72		
10/04/20 23:00	0.9			1			1.7			0.38			0.19482			0.65		
10/05/20 0:00	0.9			2			1.7			0.36			0.18006			0.6		
10/05/20 1:00	0.9			2			1.7			0.36			0.16908			0.56		
10/05/20 2:00	0.9			2			1.7			0.36			0.16938			0.56		
10/05/20 3:00	0.9			2			1.7			0.36			0.17034			0.57		
10/05/20 4:00	0.9			1			1.6			0.37			0.17994			0.6		
10/05/20 5:00	1			1			1.7			0.39			0.19896			0.66		
10/05/20 6:00	1			1			1.7			0.4			0.20898			0.7		
10/05/20 7:00	1			1			1.7			0.42			0.22332			0.74		
10/05/20 8:00	1			1			1.7			0.45			0.24078			0.8		
10/05/20 9:00	0.9			1			1.7			0.52			0.24624			0.82		
10/05/20 10:00	1.6			2			1.7			0.54			0.25782			0.86		
10/05/20 11:00	0.7			2			1.7			0.62			0.29526			0.98		
10/05/20 12:00	0.7			2			1.6			0.6			0.28362			0.95		
10/05/20 13:00	0.3			3			1.7			0.72			0.34554			1.15		
10/05/20 14:00	0.2			3			1.7			0.74			0.35748			1.19		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/05/20 15:00	0.2			3			1.7			0.74			0.35706			1.19		
10/05/20 16:00	0.2			3			1.7			0.74			0.35736			1.19		
10/05/20 17:00	0.2			3			1.7			0.71			0.339			1.13		
10/05/20 18:00	0.3			2			1.7			0.66			0.31752			1.06		
10/05/20 19:00	0.6			2			1.7			0.64			0.30744			1.02		
10/05/20 20:00	1.1			2			1.7			0.57			0.27108			0.9		
10/05/20 21:00	1.3			1			1.7			0.51			0.24216			0.81		
10/05/20 22:00	1.2			1			1.7			0.45			0.2163			0.72		
10/05/20 23:00	1.2			1			1.7			0.4			0.19914			0.66		
10/06/20 0:00	1.7			2			1.7			0.36			0.18108			0.6		
10/06/20 1:00	1.2			2			1.7			0.36			0.1707			0.57		
10/06/20 2:00	1			2			1.7			0.36			0.16884			0.56		
10/06/20 3:00	0.9			2			1.7			0.36			0.16902			0.56		
10/06/20 4:00	0.9			2			1.7			0.36			0.16908			0.56		
10/06/20 5:00	1			1			1.7			0.4			0.1944			0.65		
10/06/20 6:00	1			1			1.7			0.4			0.19926			0.66		
10/06/20 7:00	1			1			1.7			0.43			0.20994			0.7		
10/06/20 8:00	1			1			1.7			0.47			0.2328			0.78		
10/06/20 9:00	0.9			1			1.7			0.5			0.24192			0.81		
10/06/20 10:00	1.4			2			1.7			0.52			0.2565			0.86		
10/06/20 11:00	0.8			2			1.7			0.6			0.28458			0.95		
10/06/20 12:00	1.3			2			1.8			0.53			0.24066			0.8		
10/06/20 13:00	0.6			2			1.5			0.65			0.30264			1.01		
10/06/20 14:00	0.3			2			1.7			0.67			0.32202			1.07		
10/06/20 15:00	0.2			3			1.7			0.72			0.34716			1.16		
10/06/20 16:00	0.2			3			1.7			0.72			0.34698			1.16		
10/06/20 17:00	0.3			2			1.7			0.67			0.31998			1.07		
10/06/20 18:00	0.5			2			1.7			0.62			0.29898			1		
10/06/20 19:00	0.4			2			1.7			0.65			0.3123			1.04		
10/06/20 20:00	0.4			2			1.7			0.65			0.3105			1.04		
10/06/20 21:00	1.3			2			1.7			0.52			0.2436			0.81		
10/06/20 22:00	1			1			1.7			0.44			0.21504			0.72		
10/06/20 23:00	0.9			1			1.7			0.39			0.19668			0.66		
10/07/20 0:00	0.9			1			1.7			0.36			0.19362			0.65		
10/07/20 1:00	0.9			1			1.7			0.35			0.1776			0.59		
10/07/20 2:00	0.9			1			1.7			0.35			0.16764			0.56		
10/07/20 3:00	0.9			1			1.7			0.35			0.16824			0.56		
10/07/20 4:00	1			1			1.6			0.36			0.17688			0.59		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/07/20 5:00	1.3			1			1.7			0.53			0.2481			0.83		
10/07/20 6:00	1.3			2			1.7			0.53			0.25002			0.83		
10/07/20 7:00	1			1			1.7			0.43			0.20508			0.68		
10/07/20 8:00	1			1			1.7			0.46			0.2238			0.75		
10/07/20 9:00	1			1			1.7			0.48			0.23538			0.78		
10/07/20 10:00	1.5			1			1.7			0.53			0.2505			0.84		
10/07/20 11:00	1.1			2			1.7			0.56			0.26538			0.88		
10/07/20 12:00	0.8			2			1.7			0.59			0.28056			0.94		
10/07/20 13:00	0.5			2			1.7			0.64			0.30402			1.01		
10/07/20 14:00	0.2			3			1.7			0.73			0.3522			1.17		
10/07/20 15:00	0.2			3			1.7			0.73			0.34872			1.16		
10/07/20 16:00	0.8			2			1.7			0.58			0.27438			0.91		
10/07/20 17:00	1.2			2			1.7			0.53			0.25398			0.85		
10/07/20 18:00	1.3			2			1.7			0.52			0.2433			0.81		
10/07/20 19:00	1.3			2			1.7			0.53			0.2505			0.84		
10/07/20 20:00	1			2			1.7			0.57			0.27264			0.91		
10/07/20 21:00	0.9			1			1.7			0.45			0.22146			0.74		
10/07/20 22:00	0.9			1			1.7			0.38			0.20274			0.68		
10/07/20 23:00	0.9			1			1.7			0.36			0.19122			0.64		
10/08/20 0:00	0.8			2			1.7			0.36			0.17322			0.58		
10/08/20 1:00	0.9			2			1.7			0.35			0.16824			0.56		
10/08/20 2:00	0.9			2			1.7			0.36			0.16824			0.56		
10/08/20 3:00	0.8			2			1.7			0.36			0.16836			0.56		
10/08/20 4:00	0.8			2			1.7			0.35			0.1689			0.56		
10/08/20 5:00	0.8			1			1.7			0.14			0.21324			0.71		
10/08/20 6:00	0.8			1			1.7			0	X		0.21606			0.72		
10/08/20 7:00	0.9			1			1.7			0	X		0.23244			0.77		
10/08/20 8:00	1.5			2			1.7			0	X		0.24288			0.81		
10/08/20 9:00	0.9			2			1.7			0	X		0.28302			0.94		
10/08/20 10:00	0.5			2			1.7			0	X		0.30858			1.03		
10/08/20 11:00	0.6			2			1.7			0	X		0.2979			0.99		
10/08/20 12:00	0.4			2			1.7			0	X		0.3117			1.04		
10/08/20 13:00	0.4			2			1.7			0	X		0.31434			1.05		
10/08/20 14:00	0.6			2			1.7			0	X		0.29172			0.97		
10/08/20 15:00	0.9			1			1.7			0	X		0.20568			0.69		
10/08/20 16:00	0.9			1			1.7			0	X		0.20376			0.68		
10/08/20 17:00	0.9			1			1.7			0	X		0.20496			0.68		
10/08/20 18:00	0.9			1			1.7			0	X		0.22176			0.74		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/08/20 19:00	0.5			3			1.7			0	X		0.34962			1.17		
10/08/20 20:00	1			2			1.7			0	X		0.2754			0.92		
10/08/20 21:00	0.5			3			1.7			0	X		0.34728			1.16		
10/08/20 22:00	0.3			3			1.7			0	X		0.36246			1.21		
10/08/20 23:00	0.9			1			1.8			0	X		0.22596			0.75		
10/09/20 0:00	0.9			1			1.7			0	X		0.2058			0.69		
10/09/20 1:00	0.9			1			1.7			0	X		0.19392			0.65		
10/09/20 2:00	1			1			1.7			0	X		0.19488			0.65		
10/09/20 3:00	1			1			1.7			0	X		0.1959			0.65		
10/09/20 4:00	0.9			1			1.7			0	X		0.2124			0.71		
10/09/20 5:00	0.8			1			1.7			0	X		0.23142			0.77		
10/09/20 6:00	1			1			1.7			0	X		0.24234			0.81		
10/09/20 7:00	1.7			2			1.7			0	X		0.24504			0.82		
10/09/20 8:00	1.1			2			1.7			0	X		0.27528			0.92		
10/09/20 9:00	0.6			2			1.7			0	X		0.30486			1.02		
10/09/20 10:00	0.4			2			1.7			0	X		0.31518			1.05		
10/09/20 11:00	0.3			3			1.7			0	X		0.32838			1.09		
10/09/20 12:00	0.3			3			1.7			0	X		0.33414			1.11		
10/09/20 13:00	0.5			2			1.7			0	X		0.30912			1.03		
10/09/20 14:00	0.4			2			1.7			0	X		0.32214			1.07		
10/09/20 15:00	1			1			1.7			0	X		0.26928			0.9		
10/09/20 16:00	1.1			1			1.7			0	X		0.24138			0.8		
10/09/20 17:00	1.1			2			1.7			0	X		0.2727			0.91		
10/09/20 18:00	0.9			2			1.7			0	X		0.28122			0.94		
10/09/20 19:00	1			2			1.7			0	X		0.2544			0.85		
10/09/20 20:00	1			1			1.7			0	X		0.22608			0.75		
10/09/20 21:00	1			1			1.7			0	X		0.22962			0.77		
10/09/20 22:00	0.9			1			1.7			0	X		0.23472			0.78		
10/09/20 23:00	0.9			1			1.7			0	X		0.20622			0.69		
10/10/20 0:00	0.9			1			1.7			0	X		0.1926			0.64		
10/10/20 1:00	0.9			2			1.7			0	X		0.1821			0.61		
10/10/20 2:00	0.8			1			1.7			0	X		0.17658			0.59		
10/10/20 3:00	0.8			2			1.7			0	X		0.1761			0.59		
10/10/20 4:00	0.8			1			1.7			0	X		0.17646			0.59		
10/10/20 5:00	0.9			1			1.7			0	X		0.19284			0.64		
10/10/20 6:00	0.9			1			1.7			0	X		0.19722			0.66		
10/10/20 7:00	0.8			1			1.7			0	X		0.2196			0.73		
10/10/20 8:00	0.9			1			1.7			0	X		0.22968			0.77		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/10/20 9:00	0.8			2			1.7			0	X		0.282			0.94		
10/10/20 10:00	0.5			2			1.7			0	X		0.29664			0.99		
10/10/20 11:00	0.5			2			1.7			0	X		0.30084			1		
10/10/20 12:00	0.6			2			1.7			0	X		0.29352			0.98		
10/10/20 13:00	1.4			1			1.8			0	X		0.23232			0.77		
10/10/20 14:00	0			0	X		0			0	X		0.01476			0.05		
10/10/20 15:00	0	X		0	X		0	X		0.32			0	X		0	X	
10/10/20 16:00	0	X		0	X		0	X		0.41			0	X		0	X	
10/10/20 17:00	0	X		0	X		0	X		0.49			0	X		0	X	
10/10/20 18:00	0	X		0	X		0	X		0.46			0	X		0	X	
10/10/20 19:00	0	X		0	X		0	X		0.38			0	X		0	X	
10/10/20 20:00	0	X		0	X		0	X		0.49			0	X		0	X	
10/10/20 21:00	0	X		0	X		0	X		0.51			0	X		0	X	
10/10/20 22:00	0	X		0	X		0	X		0.49			0	X		0	X	
10/10/20 23:00	0	X		0	X		0	X		0.48			0	X		0	X	
10/11/20 0:00	0	X		0	X		0	X		0.45			0	X		0	X	
10/11/20 1:00	0	X		0	X		0	X		0.4			0	X		0	X	
10/11/20 2:00	0	X		0	X		0	X		0.39			0	X		0	X	
10/11/20 3:00	0	X		0	X		0	X		0.39			0	X		0	X	
10/11/20 4:00	0	X		0	X		0	X		0.4			0	X		0	X	
10/11/20 5:00	0	X		0	X		0	X		0.48			0	X		0	X	
10/11/20 6:00	0	X		0	X		0	X		0.5			0	X		0	X	
10/11/20 7:00	0	X		0	X		0	X		0.45			0	X		0	X	
10/11/20 8:00	0	X		0	X		0	X		0.48			0	X		0	X	
10/11/20 9:00	0	X		0	X		0	X		0.5			0	X		0	X	
10/11/20 10:00	0	X		0	X		0	X		0.49			0	X		0	X	
10/11/20 11:00	0	X		0	X		0	X		0.42			0	X		0	X	
10/11/20 12:00	0	X		0	X		0	X		0.41			0	X		0	X	
10/11/20 13:00	0	X		0	X		0	X		0.51			0	X		0	X	
10/11/20 14:00	0	X		0	X		0	X		0.73			0	X		0	X	
10/11/20 15:00	0			0	X		0			0.65			0.00276			0.01		
10/11/20 16:00	0	X		0	X		0	X		0.49			0	X		0	X	
10/11/20 17:00	0	X		0	X		0	X		0.43			0	X		0	X	
10/11/20 18:00	0	X		0	X		0	X		0.4			0	X		0	X	
10/11/20 19:00	0	X		0	X		0	X		0.38			0	X		0	X	
10/11/20 20:00	0	X		0	X		0	X		0.48			0	X		0	X	
10/11/20 21:00	0	X		0	X		0	X		0.52			0	X		0	X	
10/11/20 22:00	0	X		0	X		0	X		0.47			0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/11/20 23:00	0	X		0	X		0	X		0.42			0	X		0	X	
10/12/20 0:00	0	X		0	X		0	X		0.4			0	X		0	X	
10/12/20 1:00	0	X		0	X		0	X		0.38			0	X		0	X	
10/12/20 2:00	0	X		0	X		0	X		0.37			0	X		0	X	
10/12/20 3:00	0	X		0	X		0	X		0.38			0	X		0	X	
10/12/20 4:00	0	X		0	X		0	X		0.43			0	X		0	X	
10/12/20 5:00	0	X		0	X		0	X		0.53			0	X		0	X	
10/12/20 6:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/12/20 7:00	0	X		0	X		0	X		0.58			0	X		0	X	
10/12/20 8:00	0	X		0	X		0	X		0.57			0	X		0	X	
10/12/20 9:00	0	X		0	X		0	X		0.56			0	X		0	X	
10/12/20 10:00	0	X		0	X		0	X		0.57			0	X		0	X	
10/12/20 11:00	0	X		0	X		0	X		0.49			0	X		0	X	
10/12/20 12:00	0	X		0	X		0	X		0.51			0	X		0	X	
10/12/20 13:00	0	X		0	X		0	X		0.69			0	X		0	X	
10/12/20 14:00	0	X		0	X		0	X		0.75			0	X		0	X	
10/12/20 15:00	0	X		0	X		0	X		0.75			0	X		0	X	
10/12/20 16:00	0	X		0	X		0	X		0.49			0	X		0	X	
10/12/20 17:00	0	X		0	X		0	X		0.47			0	X		0	X	
10/12/20 18:00	0	X		0	X		0	X		0.46			0	X		0	X	
10/12/20 19:00	0	X		0	X		0	X		0.41			0	X		0	X	
10/12/20 20:00	0	X		0	X		0	X		0.45			0	X		0	X	
10/12/20 21:00	0	X		0	X		0	X		0.42			0	X		0	X	
10/12/20 22:00	0	X		0	X		0	X		0.5			0	X		0	X	
10/12/20 23:00	0	X		0	X		0	X		0.53			0	X		0	X	
10/13/20 0:00	0	X		0	X		0	X		0.51			0	X		0	X	
10/13/20 1:00	0	X		0	X		0	X		0.51			0	X		0	X	
10/13/20 2:00	0	X		0	X		0	X		0.52			0	X		0	X	
10/13/20 3:00	0	X		0	X		0	X		0.53			0	X		0	X	
10/13/20 4:00	0	X		0	X		0	X		0.51			0.03312			0.11		
10/13/20 5:00	0	X		0	X		0	X		0.78			0.03312			0.11		
10/13/20 6:00	0	X		0	X		0	X		0.79			0.03528			0.12		
10/13/20 7:00	0	X		0	X		0	X		0.77			0.0414			0.14		
10/13/20 8:00	0	X		0	X		0	X		0.48			0.16476			0.55		
10/13/20 9:00	0.9			1			1.1			0.37			0.17856			0.6		
10/13/20 10:00	1.1			1			1.6			0.54			0.25356			0.85		
10/13/20 11:00	0.6			1			1.7			0.63			0.288			0.96		
10/13/20 12:00	0.4			2			1.7			0.64			0.28854			0.96		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/13/20 13:00	0.3			2			1.7			0.64			0.2871			0.96		
10/13/20 14:00	0.6			1			1.7			0.6			0.27354			0.91		
10/13/20 15:00	0.8			1			1.7			0.57			0.27636			0.92		
10/13/20 16:00	0.7			1			1.7			0.59			0.28524			0.95		
10/13/20 17:00	0.8			1			1.7			0.57			0.27606			0.92		
10/13/20 18:00	1.1			1			1.7			0.54			0.25902			0.86		
10/13/20 19:00	0.8			1			1.7			0.49			0.23772			0.79		
10/13/20 20:00	1			1			1.7			0.57			0.27378			0.91		
10/13/20 21:00	1.2			1			1.7			0.49			0.23478			0.78		
10/13/20 22:00	1.1			1			1.7			0.44			0.21678			0.72		
10/13/20 23:00	1.1			1			1.7			0.37			0.1956			0.65		
10/14/20 0:00	1			1			1.7			0.36			0.18762			0.63		
10/14/20 1:00	0.9			1			1.7			0.36			0.17262			0.58		
10/14/20 2:00	0.9			1			1.7			0.36			0.16836			0.56		
10/14/20 3:00	0.8			1			1.7			0.36			0.16902			0.56		
10/14/20 4:00	0.9			1			1.7			0.36			0.1785			0.6		
10/14/20 5:00	0.9			1			1.7			0.39			0.2013			0.67		
10/14/20 6:00	0.9			1			1.7			0.39			0.21054			0.7		
10/14/20 7:00	0.8			1			1.7			0.4			0.22044			0.73		
10/14/20 8:00	0.8			1			1.7			0.43			0.23658			0.79		
10/14/20 9:00	0.8			1			1.7			0.48			0.23712			0.79		
10/14/20 10:00	1.6			1			1.7			0.51			0.24306			0.81		
10/14/20 11:00	1.1			1			1.7			0.54			0.25842			0.86		
10/14/20 12:00	0.9			1			1.7			0.58			0.27762			0.93		
10/14/20 13:00	0.5			2			1.7			0.63			0.30636			1.02		
10/14/20 14:00	0.2			3			1.7			0.73			0.35562			1.19		
10/14/20 15:00	0.2			3			1.7			0.73			0.35592			1.19		
10/14/20 16:00	0.2			2			1.7			0.7			0.34044			1.13		
10/14/20 17:00	0.4			2			1.7			0.65			0.3162			1.05		
10/14/20 18:00	0.5			2			1.7			0.63			0.3054			1.02		
10/14/20 19:00	0.8			1			1.8			0.46			0.22602			0.75		
10/14/20 20:00	1.1			1			1.7			0.54			0.2595			0.87		
10/14/20 21:00	0.8			1			1.7			0.49			0.23592			0.79		
10/14/20 22:00	0.8			1			1.7			0.44			0.21744			0.72		
10/14/20 23:00	0.8			1			1.7			0.4			0.20766			0.69		
10/15/20 0:00	0.9			1			1.7			0.36			0.19398			0.65		
10/15/20 1:00	0.9			1			1.7			0.36			0.17868			0.6		
10/15/20 2:00	0.8			1			1.7			0.36			0.17118			0.57		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/15/20 3:00	0.9			1			1.7			0.36			0.17472			0.58		
10/15/20 4:00	0.9			1			1.6			0.36			0.17622			0.59		
10/15/20 5:00	0.9			1			1.7			0.38			0.19062			0.64		
10/15/20 6:00	0.9			1			1.7			0.43			0.21858			0.73		
10/15/20 7:00	0.9			1			1.7			0.45			0.23574			0.79		
10/15/20 8:00	0.8			3			1.7			0.32			0.33048			1.1		
10/15/20 9:00	0.3			3			1.7			0		X	0.3654			1.22		
10/15/20 10:00	0.3			2			1.7			0		X	0.34698			1.16		
10/15/20 11:00	0.2			3			1.7			0		X	0.35484			1.18		
10/15/20 12:00	0.3			2			1.7			0		X	0.34278			1.14		
10/15/20 13:00	0.3			2			1.7			0		X	0.32892			1.1		
10/15/20 14:00	0.3			2			1.7			0		X	0.32898			1.1		
10/15/20 15:00	0.6			1			1.7			0.32			0.25092			0.84		
10/15/20 16:00	0.4			2			1.5			0.68			0.32802			1.09		
10/15/20 17:00	0.3			2			1.6			0.67			0.32316			1.08		
10/15/20 18:00	0.6			2			1.7			0.63			0.3015			1.01		
10/15/20 19:00	0.9			1			1.7			0.5			0.24192			0.81		
10/15/20 20:00	1.1			1			1.7			0.57			0.27492			0.92		
10/15/20 21:00	1			1			1.7			0.46			0.23754			0.79		
10/15/20 22:00	1			1			1.7			0.4			0.21702			0.72		
10/15/20 23:00	1			1			1.7			0.38			0.2145			0.72		
10/16/20 0:00	1			1			1.7			0.36			0.19026			0.63		
10/16/20 1:00	1.3			1			1.7			0.36			0.1848			0.62		
10/16/20 2:00	1.1			1			1.7			0.35			0.18216			0.61		
10/16/20 3:00	1			1			1.7			0.35			0.18222			0.61		
10/16/20 4:00	1.1			1			1.6			0.37			0.19224			0.64		
10/16/20 5:00	0.9			1			1.7			0.38			0.20616			0.69		
10/16/20 6:00	1			1			1.7			0.39			0.21642			0.72		
10/16/20 7:00	1.1			1			1.7			0.39			0.22332			0.74		
10/16/20 8:00	0.9			1			1.7			0.42			0.23886			0.8		
10/16/20 9:00	0.9			1			1.7			0.45			0.23592			0.79		
10/16/20 10:00	0.9			1			1.7			0.45			0.22956			0.77		
10/16/20 11:00	0.9			1			1.7			0.44			0.22428			0.75		
10/16/20 12:00	1.2			1			1.7			0.54			0.25854			0.86		
10/16/20 13:00	0.6			2			1.7			0.61			0.29472			0.98		
10/16/20 14:00	0.4			2			1.7			0.67			0.32142			1.07		
10/16/20 15:00	0.2			3			1.7			0.72			0.35106			1.17		
10/16/20 16:00	0.2			3			1.7			0.73			0.35136			1.17		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/16/20 17:00	0.3			2			1.7			0.69			0.33558			1.12		
10/16/20 18:00	0.5			2			1.7			0.64			0.30714			1.02		
10/16/20 19:00	0.5			2			1.7			0.63			0.306			1.02		
10/16/20 20:00	1			1			1.7			0.57			0.27234			0.91		
10/16/20 21:00	1			1			1.7			0.49			0.23454			0.78		
10/16/20 22:00	1			1			1.7			0.43			0.21408			0.71		
10/16/20 23:00	1			1			1.7			0.41			0.21036			0.7		
10/17/20 0:00	1.1			1			1.7			0.36			0.19602			0.65		
10/17/20 1:00	1			1			1.7			0.35			0.16836			0.56		
10/17/20 2:00	1			2			1.7			0.36			0.16836			0.56		
10/17/20 3:00	1			2			1.7			0.36			0.16878			0.56		
10/17/20 4:00	1			1			1.7			0.36			0.1692			0.56		
10/17/20 5:00	1.3			1			1.7			0.38			0.18378			0.61		
10/17/20 6:00	1.4			1			1.7			0.37			0.1896			0.63		
10/17/20 7:00	1.1			1			1.7			0.39			0.20766			0.69		
10/17/20 8:00	1			1			1.7			0.44			0.23016			0.77		
10/17/20 9:00	0.9			1			1.7			0.47			0.23502			0.78		
10/17/20 10:00	0.9			1			1.7			0.48			0.24468			0.82		
10/17/20 11:00	0.9			1			1.7			0.48			0.24252			0.81		
10/17/20 12:00	0.9			1			1.7			0.5			0.24102			0.8		
10/17/20 13:00	1.1			1			1.7			0.55			0.25206			0.84		
10/17/20 14:00	0.3			3			1.7			0.69			0.34878			1.16		
10/17/20 15:00	0.3			2			1.7			0.62			0.32604			1.09		
10/17/20 16:00	0.4			2			1.7			0.63			0.32244			1.07		
10/17/20 17:00	0.7			2			1.7			0.6			0.28968			0.97		
10/17/20 18:00	1.3			1			1.7			0.52			0.2493			0.83		
10/17/20 19:00	0.5			2			1.7			0.67			0.32034			1.07		
10/17/20 20:00	1			1			1.7			0.57			0.27402			0.91		
10/17/20 21:00	1			1			1.7			0.49			0.2352			0.78		
10/17/20 22:00	1			1			1.7			0.44			0.21654			0.72		
10/17/20 23:00	1			1			1.7			0.4			0.20742			0.69		
10/18/20 0:00	1.1			1			1.7			0.38			0.18744			0.62		
10/18/20 1:00	1			1			1.7			0.35			0.18252			0.61		
10/18/20 2:00	1.1			1			1.7			0.36			0.18324			0.61		
10/18/20 3:00	1			1			1.7			0.36			0.17892			0.6		
10/18/20 4:00	1.1			1			1.7			0.36			0.18186			0.61		
10/18/20 5:00	1.2			1			1.7			0.37			0.1902			0.63		
10/18/20 6:00	1.2			1			1.7			0.37			0.19812			0.66		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/18/20 7:00	1.1			1			1.7			0.39			0.2139			0.71		
10/18/20 8:00	1.2			1			1.7			0.42			0.23094			0.77		
10/18/20 9:00	1			1			1.7			0.47			0.2352			0.78		
10/18/20 10:00	1.7			1			1.7			0.54			0.25446			0.85		
10/18/20 11:00	1.3			1			1.7			0.54			0.25686			0.86		
10/18/20 12:00	1.3			1			1.7			0.53			0.24156			0.81		
10/18/20 13:00	1.1			1			1.7			0.56			0.26862			0.9		
10/18/20 14:00	0.6			2			1.7			0.63			0.30336			1.01		
10/18/20 15:00	0.3			2			1.7			0.69			0.33228			1.11		
10/18/20 16:00	0.9			2			1.7			0.58			0.27792			0.93		
10/18/20 17:00	1			1			1.7			0.51			0.24084			0.8		
10/18/20 18:00	0.9			1			1.7			0.46			0.22326			0.74		
10/18/20 19:00	0.9			1			1.7			0.46			0.23058			0.77		
10/18/20 20:00	1.2			1			1.7			0.55			0.26586			0.89		
10/18/20 21:00	1			1			1.7			0.48			0.23622			0.79		
10/18/20 22:00	1			1			1.7			0.41			0.21354			0.71		
10/18/20 23:00	1			1			1.7			0.38			0.20532			0.68		
10/19/20 0:00	1			1			1.7			0.36			0.19248			0.64		
10/19/20 1:00	1			1			1.7			0.36			0.17622			0.59		
10/19/20 2:00	1			1			1.7			0.36			0.17046			0.57		
10/19/20 3:00	1			1			1.7			0.36			0.17136			0.57		
10/19/20 4:00	1.8			0		X	1.6			0.37			0.18366			0.61		
10/19/20 5:00	1.3			0		X	1.7			0.4			0.20592			0.69		
10/19/20 6:00	1			0		X	1.7			0.41			0.21648			0.72		
10/19/20 7:00	1			0		X	1.7			0.43			0.23394			0.78		
10/19/20 8:00	1.1			0		X	1.7			0.45			0.24234			0.81		
10/19/20 9:00	1.8			0		X	1.7			0.51			0.24678			0.82		
10/19/20 10:00	1.3			0		X	1.7			0.54			0.25926			0.86		
10/19/20 11:00	1			0		X	1.7			0.58			0.27606			0.92		
10/19/20 12:00	0.9			0		X	1.7			0.59			0.28176			0.94		
10/19/20 13:00	0.6			0		X	1.7			0.61			0.2949			0.98		
10/19/20 14:00	0.5			0		X	1.7			0.65			0.31446			1.05		
10/19/20 15:00	0.3			0		X	1.7			0.73			0.35184			1.17		
10/19/20 16:00	0.3			0		X	1.7			0.69			0.33474			1.12		
10/19/20 17:00	0.5			0		X	1.7			0.64			0.30558			1.02		
10/19/20 18:00	1.1			0		X	1.7			0.57			0.27492			0.92		
10/19/20 19:00	1			0		X	1.7			0.47			0.22764			0.76		
10/19/20 20:00	1.4			0		X	1.7			0.55			0.2619			0.87		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/19/20 21:00	1			0	X		1.7			0.48			0.22902			0.76		
10/19/20 22:00	1			0	X		1.7			0.41			0.20478			0.68		
10/19/20 23:00	1.7			0	X		1.7			0.38			0.2001			0.67		
10/20/20 0:00	1.1			0	X		1.7			0.36			0.19326			0.64		
10/20/20 1:00	1.5			0	X		1.7			0.36			0.17616			0.59		
10/20/20 2:00	1.3			0	X		1.7			0.36			0.1686			0.56		
10/20/20 3:00	1			0	X		1.7			0.36			0.16884			0.56		
10/20/20 4:00	1			0	X		1.7			0.37			0.17868			0.6		
10/20/20 5:00	1.2			0	X		1.7			0.39			0.20004			0.67		
10/20/20 6:00	1.2			0			1.6			0.39			0.2094			0.7		
10/20/20 7:00	1			1			1.7			0.39			0.21612			0.72		
10/20/20 8:00	1			1			1.7			0.42			0.23616			0.79		
10/20/20 9:00	1			1			1.7			0.49			0.23664			0.79		
10/20/20 10:00	1.2			1			1.7			0.54			0.25836			0.86		
10/20/20 11:00	0.6			1			1.7			0.62			0.2979			0.99		
10/20/20 12:00	0.6			2			1.7			0.63			0.303			1.01		
10/20/20 13:00	0.3			2			1.7			0.72			0.3474			1.16		
10/20/20 14:00	0.3			3			1.7			0.73			0.35184			1.17		
10/20/20 15:00	0.3			3			1.7			0.72			0.34662			1.16		
10/20/20 16:00	0.8			2			1.7			0.59			0.28242			0.94		
10/20/20 17:00	1			1			1.7			0.52			0.24972			0.83		
10/20/20 18:00	0.9			1			1.7			0.5			0.24108			0.8		
10/20/20 19:00	1			1			1.7			0.58			0.2835			0.95		
10/20/20 20:00	1.2			1			1.7			0.51			0.2424			0.81		
10/20/20 21:00	1			1			1.7			0.44			0.2139			0.71		
10/20/20 22:00	1			1			1.7			0.39			0.19884			0.66		
10/20/20 23:00	1.1			1			1.7			0.36			0.18774			0.63		
10/21/20 0:00	1			1			1.7			0.35			0.1686			0.56		
10/21/20 1:00	1			1			1.7			0.36			0.16818			0.56		
10/21/20 2:00	1			2			1.7			0.36			0.16854			0.56		
10/21/20 3:00	1			1			1.7			0.36			0.16848			0.56		
10/21/20 4:00	1			1			1.7			0.36			0.17046			0.57		
10/21/20 5:00	1			1			1.7			0.44			0.21462			0.72		
10/21/20 6:00	1			1			1.7			0.45			0.22218			0.74		
10/21/20 7:00	1			1			1.7			0.36			0.17226			0.57		
10/21/20 8:00	1			1			1.7			0.37			0.18144			0.6		
10/21/20 9:00	1			1			1.7			0.4			0.19932			0.66		
10/21/20 10:00	1			1			1.7			0.42			0.21696			0.72		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/21/20 11:00	0.9			1			1.7			0.47			0.23292			0.78		
10/21/20 12:00	1.1			1			1.7			0.49			0.2421			0.81		
10/21/20 13:00	1.6			1			1.7			0.53			0.2556			0.85		
10/21/20 14:00	0.7			1			1.7			0.6			0.28632			0.95		
10/21/20 15:00	1			1			1.7			0.48			0.2307			0.77		
10/21/20 16:00	0.9			1			1.7			0.47			0.23256			0.78		
10/21/20 17:00	0.9			1			1.7			0.46			0.23448			0.78		
10/21/20 18:00	1			1			1.7			0.41			0.19836			0.66		
10/21/20 19:00	1.3			1			1.7			0.36			0.17334			0.58		
10/21/20 20:00	1.1			1			1.7			0.37			0.18156			0.61		
10/21/20 21:00	1			1			1.7			0.43			0.21594			0.72		
10/21/20 22:00	1			1			1.7			0.37			0.20316			0.68		
10/21/20 23:00	1.1			1			1.7			0.36			0.1962			0.65		
10/22/20 0:00	1			1			1.7			0.36			0.16956			0.57		
10/22/20 1:00	1			1			1.7			0.36			0.1686			0.56		
10/22/20 2:00	1.1			1			1.7			0.36			0.16872			0.56		
10/22/20 3:00	1			1			1.7			0.36			0.16884			0.56		
10/22/20 4:00	1			1			1.6			0.37			0.17406			0.58		
10/22/20 5:00	1			1			1.7			0.52			0.2481			0.83		
10/22/20 6:00	0.9			1			1.7			0.52			0.24726			0.82		
10/22/20 7:00	1			1			1.7			0.43			0.20922			0.7		
10/22/20 8:00	0.9			1			1.7			0.45			0.2268			0.76		
10/22/20 9:00	1			1			1.7			0.49			0.24234			0.81		
10/22/20 10:00	1			1			1.7			0.48			0.23886			0.8		
10/22/20 11:00	1			1			1.7			0.49			0.2373			0.79		
10/22/20 12:00	0.9			1			1.7			0.52			0.24756			0.83		
10/22/20 13:00	0.9			1			1.7			0.52			0.24726			0.82		
10/22/20 14:00	1.2			1			1.7			0.53			0.25326			0.84		
10/22/20 15:00	0.9			1			1.7			0.47			0.22488			0.75		
10/22/20 16:00	1.4			1			1.7			0.52			0.24834			0.83		
10/22/20 17:00	1.3			1			1.7			0.55			0.2598			0.87		
10/22/20 18:00	0.9			1			1.7			0.48			0.23322			0.78		
10/22/20 19:00	0.9			1			1.7			0.48			0.24036			0.8		
10/22/20 20:00	1			1			1.7			0.48			0.23436			0.78		
10/22/20 21:00	1			1			1.7			0.39			0.19104			0.64		
10/22/20 22:00	1			2			1.7			0.36			0.171			0.57		
10/22/20 23:00	1			2			1.7			0.36			0.16896			0.56		
10/23/20 0:00	1			2			1.7			0.36			0.16908			0.56		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/23/20 1:00	1			2			1.7			0.36			0.16932			0.56		
10/23/20 2:00	1			2			1.7			0.36			0.16932			0.56		
10/23/20 3:00	1			2			1.7			0.36			0.16926			0.56		
10/23/20 4:00	1			1			1.6			0.36			0.17028			0.57		
10/23/20 5:00	1.2			1			1.7			0.38			0.18606			0.62		
10/23/20 6:00	1.1			1			1.7			0.39			0.19974			0.67		
10/23/20 7:00	1			1			1.7			0.4			0.21294			0.71		
10/23/20 8:00	1			2			1.7			0.42			0.2283			0.76		
10/23/20 9:00	1			2			1.7			0.42			0.23592			0.79		
10/23/20 10:00	1			2			1.7			0.41			0.23724			0.79		
10/23/20 11:00	1			2			1.7			0.47			0.2391			0.8		
10/23/20 12:00	1			1			1.7			0.49			0.23676			0.79		
10/23/20 13:00	1.3			1			1.7			0.53			0.25602			0.85		
10/23/20 14:00	1.4			1			1.7			0.54			0.25194			0.84		
10/23/20 15:00	1.3			1			1.7			0.53			0.23784			0.79		
10/23/20 16:00	1			1			1.7			0.45			0.19956			0.67		
10/23/20 17:00	1.2			1			1.7			0.56			0.26526			0.88		
10/23/20 18:00	1			1			1.7			0.42			0.20214			0.67		
10/23/20 19:00	1.1			1			1.7			0.38			0.19548			0.65		
10/23/20 20:00	1			1			1.7			0.46			0.23796			0.79		
10/23/20 21:00	1			1			1.7			0.41			0.2235			0.75		
10/23/20 22:00	1			1			1.7			0.35			0.21366			0.71		
10/23/20 23:00	1.1			1			1.7			0.15			0.19638			0.65		
10/24/20 0:00	1			1			1.7			0	X		0.20034			0.67		
10/24/20 1:00	0.9			1			1.7			0	X		0.17088			0.57		
10/24/20 2:00	1			1			1.7			0	X		0.1752			0.58		
10/24/20 3:00	1			1			1.7			0	X		0.17526			0.58		
10/24/20 4:00	1			1			1.7			0	X		0.17634			0.59		
10/24/20 5:00	1.2			1			1.7			0	X		0.18894			0.63		
10/24/20 6:00	1.1			1			1.7			0	X		0.19656			0.66		
10/24/20 7:00	1			1			1.7			0	X		0.22422			0.75		
10/24/20 8:00	1			1			1.7			0	X		0.24456			0.82		
10/24/20 9:00	0.9			1			1.7			0	X		0.2487			0.83		
10/24/20 10:00	1.3			1			1.7			0	X		0.27216			0.91		
10/24/20 11:00	1.2			1			1.7			0	X		0.24816			0.83		
10/24/20 12:00	1			1			1.7			0	X		0.24648			0.82		
10/24/20 13:00	0.6			1			1.7			0	X		0.31098			1.04		
10/24/20 14:00	0.4			2			1.7			0	X		0.32892			1.1		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/24/20 15:00	0.9			1			1.8			0	X		0.21828			0.73		
10/24/20 16:00	1			1			1.7			0	X		0.18258			0.61		
10/24/20 17:00	1			1			1.7			0	X		0.19512			0.65		
10/24/20 18:00	1			1			1.7			0	X		0.19956			0.67		
10/24/20 19:00	0.5			2			1.6			0	X		0.33558			1.12		
10/24/20 20:00	0.6			1			1.7			0	X		0.31176			1.04		
10/24/20 21:00	1.2			1			1.7			0	X		0.26952			0.9		
10/24/20 22:00	0.9			1			1.7			0	X		0.23244			0.77		
10/24/20 23:00	1			1			1.7			0	X		0.20928			0.7		
10/25/20 0:00	1			1			1.7			0	X		0.19626			0.65		
10/25/20 1:00	1			1			1.7			0	X		0.18096			0.6		
10/25/20 2:00	1			1			1.7			0	X		0.18084			0.6		
10/25/20 3:00	1			1			1.7			0	X		0.18306			0.61		
10/25/20 4:00	1.1			1			1.7			0	X		0.19284			0.64		
10/25/20 5:00	1			1			1.7			0	X		0.20826			0.69		
10/25/20 6:00	0.9			1			1.7			0	X		0.22986			0.77		
10/25/20 7:00	0.9			1			1.7			0	X		0.23856			0.8		
10/25/20 8:00	2			1			1.7			0	X		0.24738			0.82		
10/25/20 9:00	1.2			1			1.7			0	X		0.28488			0.95		
10/25/20 10:00	1			1			1.7			0	X		0.29622			0.99		
10/25/20 11:00	0.9			1			1.7			0	X		0.29688			0.99		
10/25/20 12:00	0.7			1			1.7			0	X		0.30666			1.02		
10/25/20 13:00	0.8			2			1.7			0	X		0.30768			1.03		
10/25/20 14:00	0.5			2			1.7			0	X		0.32802			1.09		
10/25/20 15:00	0.5			2			1.7			0	X		0.32664			1.09		
10/25/20 16:00	1			1			1.8			0	X		0.25092			0.84		
10/25/20 17:00	1.2			1			1.7			0	X		0.2874			0.96		
10/25/20 18:00	1.2			1			1.7			0	X		0.27342			0.91		
10/25/20 19:00	1.2			1			1.7			0	X		0.26928			0.9		
10/25/20 20:00	0.9			1			1.7			0	X		0.23838			0.79		
10/25/20 21:00	0.9			1			1.7			0	X		0.23664			0.79		
10/25/20 22:00	1			1			1.7			0	X		0.22362			0.75		
10/25/20 23:00	1			1			1.7			0	X		0.20052			0.67		
10/26/20 0:00	1			1			1.7			0	X		0.17988			0.6		
10/26/20 1:00	1			1			1.7			0	X		0.17976			0.6		
10/26/20 2:00	1			1			1.7			0	X		0.17904			0.6		
10/26/20 3:00	1			1			1.7			0	X		0.18288			0.61		
10/26/20 4:00	1.1			1			1.8			0	X		0.20388			0.68		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/26/20 5:00	1			1			1.7			0	X		0.23394			0.78		
10/26/20 6:00	1			1			1.7			0	X		0.23238			0.77		
10/26/20 7:00	1.2			1			1.7			0	X		0.26502			0.88		
10/26/20 8:00	1			2			1.7			0	X		0.29796			0.99		
10/26/20 9:00	0.9			2			1.7			0	X		0.30786			1.03		
10/26/20 10:00	0.4			2			1.7			0	X		0.34434			1.15		
10/26/20 11:00	0.3			2			1.7			0	X		0.35526			1.18		
10/26/20 12:00	0.3			2			1.7			0	X		0.3555			1.19		
10/26/20 13:00	0.3			2			1.7			0	X		0.35052			1.17		
10/26/20 14:00	0.4			2			1.7			0	X		0.36204			1.21		
10/26/20 15:00	0.5			2			1.7			0	X		0.32976			1.1		
10/26/20 16:00	1.4			1			1.8			0	X		0.25554			0.85		
10/26/20 17:00	0.9			2			1.7			0	X		0.3066			1.02		
10/26/20 18:00	0.3			2			1.7			0	X		0.36636			1.22		
10/26/20 19:00	0.4			2			1.7			0	X		0.36384			1.21		
10/26/20 20:00	0.5			2			1.7			0	X		0.34722			1.16		
10/26/20 21:00	1.3			1			1.8			0	X		0.27102			0.9		
10/26/20 22:00	1.1			1			1.7			0	X		0.23694			0.79		
10/26/20 23:00	1			1			1.7			0	X		0.20766			0.69		
10/27/20 0:00	1			1			1.7			0	X		0.19716			0.66		
10/27/20 1:00	1.1			1			1.7			0	X		0.18708			0.62		
10/27/20 2:00	1.1			1			1.7			0	X		0.1797			0.6		
10/27/20 3:00	1.1			1			1.7			0	X		0.18114			0.6		
10/27/20 4:00	1.2			1			1.7			0	X		0.19818			0.66		
10/27/20 5:00	1			1			1.7			0	X		0.2475			0.83		
10/27/20 6:00	1.1			1			1.7			0	X		0.24336			0.81		
10/27/20 7:00	1.1			1			1.7			0	X		0.25266			0.84		
10/27/20 8:00	1.1			1			1.7			0	X		0.25152			0.84		
10/27/20 9:00	0.9			2			1.7			0	X		0.30288			1.01		
10/27/20 10:00	0.7			2			1.7			0	X		0.30744			1.02		
10/27/20 11:00	0.7			2			1.7			0	X		0.3084			1.03		
10/27/20 12:00	1			1			1.8			0	X		0.23682			0.79		
10/27/20 13:00	1			1			1.7			0	X		0.23484			0.78		
10/27/20 14:00	1			1			1.7			0	X		0.23688			0.79		
10/27/20 15:00	1.8			1			1.7			0	X		0.24852			0.83		
10/27/20 16:00	1.8			1			1.7			0	X		0.24888			0.83		
10/27/20 17:00	1.8			1			1.7			0	X		0.24948			0.83		
10/27/20 18:00	1.8			1			1.7			0	X		0.2475			0.83		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/27/20 19:00	1			1			1.7			0	X		0.22992			0.77		
10/27/20 20:00	1.4			1			1.7			0	X		0.25758			0.86		
10/27/20 21:00	1.5			1			1.7			0	X		0.25338			0.84		
10/27/20 22:00	1.2			1			1.7			0	X		0.21744			0.72		
10/27/20 23:00	1.2			1			1.7			0	X		0.1932			0.64		
10/28/20 0:00	1.3			1			1.7			0	X		0.1932			0.64		
10/28/20 1:00	1.3			1			1.7			0	X		0.19242			0.64		
10/28/20 2:00	1.2			1			1.7			0	X		0.18792			0.63		
10/28/20 3:00	1.2			1			1.7			0	X		0.19416			0.65		
10/28/20 4:00	1.3			1			1.7			0	X		0.2181			0.73		
10/28/20 5:00	2			1			1.7			0	X		0.2625			0.88		
10/28/20 6:00	2.1			1			1.7			0	X		0.255			0.85		
10/28/20 7:00	2.1			1			1.7			0	X		0.2514			0.84		
10/28/20 8:00	1.6			1			1.7			0	X		0.25236			0.84		
10/28/20 9:00	1			1			1.7			0	X		0.24918			0.83		
10/28/20 10:00	1			1			1.7			0	X		0.24468			0.82		
10/28/20 11:00	1.3			1			1.7			0	X		0.25176			0.84		
10/28/20 12:00	1.2			1			1.7			0	X		0.2676			0.89		
10/28/20 13:00	1.2			1			1.7			0	X		0.26388			0.88		
10/28/20 14:00	1.2			1			1.7			0	X		0.26526			0.88		
10/28/20 15:00	1.2			1			1.7			0	X		0.2325			0.78		
10/28/20 16:00	1.1			1			1.7			0	X		0.23442			0.78		
10/28/20 17:00	1.7			1			1.7			0	X		0.2562			0.85		
10/28/20 18:00	2.2			1			1.7			0	X		0.24876			0.83		
10/28/20 19:00	1.3			1			1.7			0	X		0.2139			0.71		
10/28/20 20:00	1.2			1			1.7			0	X		0.22422			0.75		
10/28/20 21:00	1.2			1			1.7			0	X		0.24528			0.82		
10/28/20 22:00	1.2			1			1.7			0	X		0.22356			0.75		
10/28/20 23:00	1.2			1			1.7			0	X		0.2034			0.68		
10/29/20 0:00	1.3			1			1.7			0	X		0.19164			0.64		
10/29/20 1:00	1.4			1			1.7			0	X		0.18834			0.63		
10/29/20 2:00	1.4			1			1.7			0	X		0.18504			0.62		
10/29/20 3:00	1.3			1			1.7			0	X		0.1896			0.63		
10/29/20 4:00	1.3			1			1.8			0	X		0.21198			0.71		
10/29/20 5:00	2.2			1			1.7			0	X		0.24762			0.83		
10/29/20 6:00	2.1			1			1.7			0	X		0.24804			0.83		
10/29/20 7:00	1.6			1			1.7			0	X		0.25368			0.85		
10/29/20 8:00	1.1			2			1.7			0	X		0.30252			1.01		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/29/20 9:00	0.8			2			1.7			0	X		0.3054			1.02		
10/29/20 10:00	0.8			2			1.7			0	X		0.30132			1		
10/29/20 11:00	0.9			1			1.7			0	X		0.30162			1.01		
10/29/20 12:00	0.8			2			1.7			0	X		0.3093			1.03		
10/29/20 13:00	1.1			1			1.7			0	X		0.2514			0.84		
10/29/20 14:00	1.2			1			1.7			0	X		0.2787			0.93		
10/29/20 15:00	1.5			1			1.7			0	X		0.24636			0.82		
10/29/20 16:00	1.4			1			1.7			0	X		0.24474			0.82		
10/29/20 17:00	1.3			1			1.7			0	X		0.26736			0.89		
10/29/20 18:00	1.5			1			1.7			0	X		0.2658			0.89		
10/29/20 19:00	1.5			1			1.7			0	X		0.27246			0.91		
10/29/20 20:00	1.2			1			1.7			0	X		0.22974			0.77		
10/29/20 21:00	1.2			1			1.7			0	X		0.17874			0.6		
10/29/20 22:00	1.2			1			1.7			0	X		0.21078			0.7		
10/29/20 23:00	1.3			1			1.7			0	X		0.21234			0.71		
10/30/20 0:00	1.4			1			1.7			0	X		0.19656			0.66		
10/30/20 1:00	1.4			1			1.7			0	X		0.19206			0.64		
10/30/20 2:00	1.5			1			1.7			0	X		0.19158			0.64		
10/30/20 3:00	1.5			1			1.7			0	X		0.19332			0.64		
10/30/20 4:00	1.2			1			1.7			0	X		0.21588			0.72		
10/30/20 5:00	2.2			1			1.7			0	X		0.24942			0.83		
10/30/20 6:00	2.3			1			1.7			0	X		0.24732			0.82		
10/30/20 7:00	2			1			1.7			0	X		0.24096			0.8		
10/30/20 8:00	1.7			1			1.7			0	X		0.25698			0.86		
10/30/20 9:00	1.3			2			1.7			0	X		0.27948			0.93		
10/30/20 10:00	1			2			1.7			0	X		0.30252			1.01		
10/30/20 11:00	0.9			2			1.7			0	X		0.30498			1.02		
10/30/20 12:00	0.8			2			1.7			0	X		0.3123			1.04		
10/30/20 13:00	0.4			2			1.7			0	X		0.35436			1.18		
10/30/20 14:00	0.4			2			1.7			0	X		0.35034			1.17		
10/30/20 15:00	1.4			1			1.8			0	X		0.24756			0.83		
10/30/20 16:00	1.2			1			1.7			0	X		0.2313			0.77		
10/30/20 17:00	1.1			1			1.7			0	X		0.22728			0.76		
10/30/20 18:00	1.2			1			1.7			0	X		0.23022			0.77		
10/30/20 19:00	1.4			1			1.7			0	X		0.2664			0.89		
10/30/20 20:00	1.7			1			1.7			0	X		0.24768			0.83		
10/30/20 21:00	1.2			1			1.7			0	X		0.2289			0.76		
10/30/20 22:00	1.2			1			1.7			0	X		0.231			0.77		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
10/30/20 23:00	1.2			1			1.7			0	X		0.21894			0.73		
10/31/20 0:00	1.2			1			1.7			0	X		0.20634			0.69		
10/31/20 1:00	1.4			1			1.7			0	X		0.1956			0.65		
10/31/20 2:00	1.6			1			1.7			0	X		0.18804			0.63		
10/31/20 3:00	1.6			1			1.7			0	X		0.19086			0.64		
10/31/20 4:00	1.6			1			1.7			0	X		0.1998			0.67		
10/31/20 5:00	1.2			1			1.7			0	X		0.22704			0.76		
10/31/20 6:00	1.2			1			1.7			0	X		0.24258			0.81		
10/31/20 7:00	2.3			1			1.7			0	X		0.2487			0.83		
10/31/20 8:00	1.5			2			1.7			0	X		0.27936			0.93		
10/31/20 9:00	1			2			1.7			0	X		0.2994			1		
10/31/20 10:00	0.9			2			1.7			0	X		0.29472			0.98		
10/31/20 11:00	0.8			2			1.7			0	X		0.29298			0.98		
10/31/20 12:00	1.1			1			1.6			0	X		0.23946			0.8		
10/31/20 13:00	1.7			1			1.5			0	X		0.24966			0.83		
10/31/20 14:00	0.5			2			1.4			0	X		0.34728			1.16		
10/31/20 15:00	1.1			1			1.6			0	X		0.23376			0.78		
10/31/20 16:00	1.1			1			1.7			0	X		0.19092			0.64		
10/31/20 17:00	1			1			1.7			0	X		0.2406			0.8		
10/31/20 18:00	1.1			1			1.7			0	X		0.23064			0.77		
10/31/20 19:00	1.2			1			1.7			0	X		0.22596			0.75		
10/31/20 20:00	1.2			1			1.7			0	X		0.21342			0.71		
10/31/20 21:00	1.2			1			1.7			0	X		0.2325			0.78		
10/31/20 22:00	1.2			1			1.7			0	X		0.23658			0.79		
10/31/20 23:00	1.2			1			1.7			0	X		0.19746			0.66		
11/01/20 0:00	1.1			1			1.7			0	X		0.17682			0.59		
11/01/20 1:00	1.1			1			1.7			0	X		0.17658			0.59		
11/01/20 2:00	1.2			1			1.7			0	X		0.17652			0.59		
11/01/20 3:00	1.3			1			1.7			0	X		0.17646			0.59		
11/01/20 4:00	1.3			1			1.7			0	X		0.17682			0.59		
11/01/20 5:00	1.2			1			1.7			0	X		0.17832			0.59		
11/01/20 6:00	1.3			1			1.7			0	X		0.18642			0.62		
11/01/20 7:00	1.4			1			1.7			0	X		0.20088			0.67		
11/01/20 8:00	1.2			1			1.7			0	X		0.21678			0.72		
11/01/20 9:00	1.1			1			1.7			0	X		0.22788			0.76		
11/01/20 10:00	1.6			1			1.7			0	X		0.24642			0.82		
11/01/20 11:00	0.9			1			1.6			0	X		0.29394			0.98		
11/01/20 12:00	0.9			1			1.7			0	X		0.29994			1		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/01/20 13:00	0.6			2			1.7			0	X		0.32694			1.09		
11/01/20 14:00	0.4			2			1.7			0	X		0.35142			1.17		
11/01/20 15:00	0.4			2			1.7			0	X		0.35172			1.17		
11/01/20 16:00	0.4			2			1.7			0	X		0.35154			1.17		
11/01/20 17:00	1			1			1.8			0	X		0.23874			0.8		
11/01/20 18:00	1.1			1			1.7			0	X		0.2256			0.75		
11/01/20 19:00	1.2			1			1.7			0	X		0.21252			0.71		
11/01/20 20:00	1.5			1			1.7			0	X		0.17808			0.59		
11/01/20 21:00	1.8			1			1.7			0	X		0.25314			0.84		
11/01/20 22:00	1.4			1			1.7			0	X		0.21894			0.73		
11/01/20 23:00	1.3			1			1.7			0	X		0.18306			0.61		
11/02/20 0:00	1.2			1			1.7			0	X		0.17064			0.57		
11/02/20 1:00	1.7			1			1.7			0	X		0.17118			0.57		
11/02/20 2:00	1.6			1			1.7			0	X		0.1734			0.58		
11/02/20 3:00	1.7			1			1.7			0	X		0.18222			0.61		
11/02/20 4:00	1.8			1			1.7			0	X		0.20334			0.68		
11/02/20 5:00	1.6			1			1.7			0	X		0.20898			0.7		
11/02/20 6:00	1.5			1			1.7			0	X		0.24732			0.82		
11/02/20 7:00	2.7			1			1.7			0	X		0.24816			0.83		
11/02/20 8:00	2.4			1			1.7			0	X		0.24624			0.82		
11/02/20 9:00	1.4			1			1.7			0	X		0.25842			0.86		
11/02/20 10:00	1.3			1			1.7			0	X		0.26118			0.87		
11/02/20 11:00	0.7			2			1.7			0	X		0.3066			1.02		
11/02/20 12:00	0.4			2			1.7			0	X		0.36276			1.21		
11/02/20 13:00	0.4			2			1.7			0	X		0.36582			1.22		
11/02/20 14:00	0.4			2			1.7			0	X		0.36582			1.22		
11/02/20 15:00	0.4			2			1.7			0	X		0.36528			1.22		
11/02/20 16:00	0.4			2			1.7			0	X		0.3657			1.22		
11/02/20 17:00	0.4			2			1.7			0	X		0.363			1.21		
11/02/20 18:00	0.4			2			1.7			0	X		0.363			1.21		
11/02/20 19:00	0.6			2			1.7			0	X		0.32634			1.09		
11/02/20 20:00	1.2			1			1.8			0	X		0.22494			0.75		
11/02/20 21:00	1			2			1.7			0	X		0.29184			0.97		
11/02/20 22:00	1.3			1			1.8			0	X		0.243			0.81		
11/02/20 23:00	1.3			1			1.7			0	X		0.19896			0.66		
11/03/20 0:00	1.3			1			1.7			0	X		0.18618			0.62		
11/03/20 1:00	1.1			1			1.7			0	X		0.17946			0.6		
11/03/20 2:00	1.1			1			1.7			0	X		0.17694			0.59		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/03/20 3:00	1.3			1			1.7			0	X		0.17982			0.6		
11/03/20 4:00	1.3			1			1.6			0	X		0.18432			0.61		
11/03/20 5:00	1.2			1			1.7			0	X		0.20916			0.7		
11/03/20 6:00	1.8			1			1.7			0	X		0.24246			0.81		
11/03/20 7:00	1.2			1			1.7			0	X		0.23238			0.77		
11/03/20 8:00	1.6			2			1.7			0	X		0.27018			0.9		
11/03/20 9:00	0.7			2			1.7			0	X		0.33192			1.11		
11/03/20 10:00	0.5			2			1.7			0	X		0.33888			1.13		
11/03/20 11:00	0.4			2			1.7			0	X		0.33996			1.13		
11/03/20 12:00	0.4			2			1.7			0	X		0.33876			1.13		
11/03/20 13:00	0.5			2			1.7			0	X		0.33438			1.11		
11/03/20 14:00	0.5			2			1.7			0	X		0.33702			1.12		
11/03/20 15:00	0.4			2			1.7			0	X		0.36678			1.22		
11/03/20 16:00	0.4			2			1.7			0	X		0.36468			1.22		
11/03/20 17:00	0.5			2			1.7			0	X		0.3375			1.13		
11/03/20 18:00	1			1			1.8			0	X		0.3066			1.02		
11/03/20 19:00	1.5			1			1.7			0	X		0.26202			0.87		
11/03/20 20:00	1.4			1			1.7			0	X		0.27672			0.92		
11/03/20 21:00	1			2			1.7			0	X		0.30396			1.01		
11/03/20 22:00	1			1			1.8			0	X		0.27018			0.9		
11/03/20 23:00	1.2			1			1.7			0	X		0.21906			0.73		
11/04/20 0:00	1.3			1			1.7			0	X		0.1914			0.64		
11/04/20 1:00	1.2			1			1.7			0	X		0.17964			0.6		
11/04/20 2:00	1.2			1			1.7			0	X		0.1782			0.59		
11/04/20 3:00	1.3			1			1.7			0	X		0.17934			0.6		
11/04/20 4:00	1.3			1			1.7			0	X		0.17928			0.6		
11/04/20 5:00	1.6			1			1.7			0	X		0.20022			0.67		
11/04/20 6:00	1.6			1			1.7			0	X		0.18486			0.62		
11/04/20 7:00	1.6			1			1.7			0	X		0.21222			0.71		
11/04/20 8:00	1.4			1			1.7			0	X		0.21552			0.72		
11/04/20 9:00	1.6			1			1.7			0	X		0.25458			0.85		
11/04/20 10:00	1.3			1			1.7			0	X		0.2625			0.88		
11/04/20 11:00	1.3			1			1.7			0	X		0.26496			0.88		
11/04/20 12:00	1.3			1			1.7			0	X		0.26688			0.89		
11/04/20 13:00	0.7			2			1.7			0	X		0.30678			1.02		
11/04/20 14:00	0.5			2			1.7			0	X		0.32178			1.07		
11/04/20 15:00	0.5			2			1.7			0	X		0.32196			1.07		
11/04/20 16:00	1			1			1.7			0	X		0.27588			0.92		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/04/20 17:00	1.5			1			1.7			0	X		0.23502			0.78		
11/04/20 18:00	1.2			1			1.7			0	X		0.21444			0.71		
11/04/20 19:00	1.1			1			1.7			0	X		0.22698			0.76		
11/04/20 20:00	1.2			1			1.7			0	X		0.23118			0.77		
11/04/20 21:00	1.5			1			1.7			0	X		0.2553			0.85		
11/04/20 22:00	1.5			1			1.7			0	X		0.25176			0.84		
11/04/20 23:00	1.3			1			1.7			0	X		0.22482			0.75		
11/05/20 0:00	1.4			1			1.7			0	X		0.18738			0.62		
11/05/20 1:00	1.3			1			1.7			0	X		0.18696			0.62		
11/05/20 2:00	1.3			1			1.7			0	X		0.18702			0.62		
11/05/20 3:00	1.3			1			1.7			0	X		0.18642			0.62		
11/05/20 4:00	1.3			1			1.7			0	X		0.18606			0.62		
11/05/20 5:00	1.2			1			1.7			0	X		0.1845			0.62		
11/05/20 6:00	1.2			1			1.7			0	X		0.21018			0.7		
11/05/20 7:00	1.1			1			1.6			0	X		0.22836			0.76		
11/05/20 8:00	1.1			1			1.6			0	X		0.23556			0.79		
11/05/20 9:00	1.1			1			1.6			0	X		0.23538			0.78		
11/05/20 10:00	1.4			1			1.6			0	X		0.25662			0.86		
11/05/20 11:00	1.3			1			1.6			0	X		0.26076			0.87		
11/05/20 12:00	1.3			1			1.6			0	X		0.26022			0.87		
11/05/20 13:00	0.7			2			1.6			0	X		0.30918			1.03		
11/05/20 14:00	0.4			2			1.6			0	X		0.34038			1.13		
11/05/20 15:00	0.5			2			1.6			0	X		0.3195			1.07		
11/05/20 16:00	0.5			2			1.6			0	X		0.31662			1.06		
11/05/20 17:00	1.1			1			1.6			0	X		0.2355			0.79		
11/05/20 18:00	1.2			1			1.6			0	X		0.21528			0.72		
11/05/20 19:00	1.2			1			1.6			0	X		0.21738			0.72		
11/05/20 20:00	1.4			1			1.6			0	X		0.26946			0.9		
11/05/20 21:00	1.4			1			1.6			0	X		0.27228			0.91		
11/05/20 22:00	1.2			1			1.6			0	X		0.22932			0.76		
11/05/20 23:00	1.1			1			1.6			0	X		0.22374			0.75		
11/06/20 0:00	1.1			1			1.6			0	X		0.1779			0.59		
11/06/20 1:00	1.1			1			1.6			0	X		0.17622			0.59		
11/06/20 2:00	1.2			1			1.6			0	X		0.17658			0.59		
11/06/20 3:00	1.2			1			1.6			0	X		0.17826			0.59		
11/06/20 4:00	1.2			1			1.6			0	X		0.17964			0.6		
11/06/20 5:00	1.3			1			1.6			0	X		0.18828			0.63		
11/06/20 6:00	1.2			1			1.7			0	X		0.19398			0.65		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/06/20 7:00	1.1			1			1.7			0	X		0.21048			0.7		
11/06/20 8:00	1.1			1			1.7			0	X		0.23292			0.78		
11/06/20 9:00	1.1			1			1.7			0	X		0.22794			0.76		
11/06/20 10:00	1			1			1.7			0	X		0.23502			0.78		
11/06/20 11:00	1			1			1.7			0	X		0.2343			0.78		
11/06/20 12:00	1.1			1			1.7			0	X		0.23244			0.77		
11/06/20 13:00	1.5			1			1.7			0	X		0.24528			0.82		
11/06/20 14:00	1.4			1			1.7			0	X		0.25278			0.84		
11/06/20 15:00	1.2			1			1.7			0	X		0.23298			0.78		
11/06/20 16:00	1.1			1			1.7			0	X		0.20478			0.68		
11/06/20 17:00	1			1			1.7			0	X		0.24978			0.83		
11/06/20 18:00	1.2			1			1.8			0	X		0.19548			0.65		
11/06/20 19:00	1.2			1			1.7			0	X		0.24594			0.82		
11/06/20 20:00	1.2			1			1.7			0	X		0.23868			0.8		
11/06/20 21:00	1.1			1			1.7			0	X		0.23484			0.78		
11/06/20 22:00	1.1			1			1.7			0	X		0.23514			0.78		
11/06/20 23:00	1.1			1			1.7			0	X		0.21966			0.73		
11/07/20 0:00	1.1			1			1.7			0	X		0.2064			0.69		
11/07/20 1:00	1.3			1			1.7			0	X		0.18444			0.61		
11/07/20 2:00	1.2			1			1.7			0	X		0.1764			0.59		
11/07/20 3:00	1.1			1			1.7			0	X		0.17634			0.59		
11/07/20 4:00	1.1			1			1.7			0	X		0.17682			0.59		
11/07/20 5:00	1.2			1			1.7			0	X		0.17898			0.6		
11/07/20 6:00	1.2			1			1.7			0	X		0.18024			0.6		
11/07/20 7:00	1.2			1			1.7			0	X		0.2016			0.67		
11/07/20 8:00	1.2			1			1.7			0	X		0.2328			0.78		
11/07/20 9:00	2			1			1.7			0	X		0.25002			0.83		
11/07/20 10:00	1.8			1			1.7			0	X		0.25002			0.83		
11/07/20 11:00	1.8			1			1.7			0	X		0.24744			0.82		
11/07/20 12:00	1.1			1			1.7			0	X		0.23526			0.78		
11/07/20 13:00	1.1			1			1.7			0	X		0.21576			0.72		
11/07/20 14:00	1.1			1			1.7			0	X		0.22536			0.75		
11/07/20 15:00	1.1			1			1.7			0	X		0.22674			0.76		
11/07/20 16:00	1.1			1			1.7			0	X		0.19812			0.66		
11/07/20 17:00	1.1			1			1.7			0	X		0.2193			0.73		
11/07/20 18:00	1.1			1			1.7			0	X		0.23904			0.8		
11/07/20 19:00	1.1			1			1.7			0	X		0.2424			0.81		
11/07/20 20:00	1.1			1			1.7			0	X		0.23724			0.79		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/07/20 21:00	1.1			1			1.7			0	X		0.2289			0.76		
11/07/20 22:00	1.1			1			1.7			0	X		0.23124			0.77		
11/07/20 23:00	1.1			1			1.7			0	X		0.21486			0.72		
11/08/20 0:00	1.2			1			1.7			0	X		0.20472			0.68		
11/08/20 1:00	1.3			1			1.7			0	X		0.18966			0.63		
11/08/20 2:00	1.2			1			1.7			0	X		0.18228			0.61		
11/08/20 3:00	1.2			1			1.7			0	X		0.18252			0.61		
11/08/20 4:00	1.3			1			1.7			0	X		0.18444			0.61		
11/08/20 5:00	1.3			1			1.7			0	X		0.18822			0.63		
11/08/20 6:00	1.2			1			1.7			0	X		0.21156			0.71		
11/08/20 7:00	1.2			1			1.7			0	X		0.22092			0.74		
11/08/20 8:00	1.1			1			1.7			0	X		0.2415			0.81		
11/08/20 9:00	1.2			1			1.7			0	X		0.18372			0.61		
11/08/20 10:00	1.2			1			1.7			0	X		0.18234			0.61		
11/08/20 11:00	1.2			1			1.7			0	X		0.19356			0.65		
11/08/20 12:00	1.2			1			1.7			0	X		0.19338			0.64		
11/08/20 13:00	1.2			1			1.7			0	X		0.20214			0.67		
11/08/20 14:00	1.6			1			1.7			0	X		0.25002			0.83		
11/08/20 15:00	1.6			1			1.7			0	X		0.25236			0.84		
11/08/20 16:00	1.7			1			1.7			0	X		0.24156			0.81		
11/08/20 17:00	1.9			1			1.7			0	X		0.23664			0.79		
11/08/20 18:00	1.7			1			1.7			0	X		0.24222			0.81		
11/08/20 19:00	1.9			1			1.7			0	X		0.24666			0.82		
11/08/20 20:00	1.1			1			1.7			0	X		0.23718			0.79		
11/08/20 21:00	1.2			1			1.7			0	X		0.23202			0.77		
11/08/20 22:00	1.2			1			1.7			0	X		0.22116			0.74		
11/08/20 23:00	1.2			1			1.7			0	X		0.21414			0.71		
11/09/20 0:00	1.3			1			1.7			0	X		0.19314			0.64		
11/09/20 1:00	1.3			1			1.7			0	X		0.1977			0.66		
11/09/20 2:00	1.3			1			1.7			0	X		0.1938			0.65		
11/09/20 3:00	1.3			1			1.7			0	X		0.20058			0.67		
11/09/20 4:00	1.2			1			1.7			0	X		0.21216			0.71		
11/09/20 5:00	1.2			1			1.7			0	X		0.23166			0.77		
11/09/20 6:00	1.2			1			1.7			0	X		0.23256			0.78		
11/09/20 7:00	1.2			1			1.7			0	X		0.25056			0.84		
11/09/20 8:00	2.2			1			1.7			0	X		0.2529			0.84		
11/09/20 9:00	1.9			2			1.7			0	X		0.25704			0.86		
11/09/20 10:00	1.9			1			1.7			0	X		0.25542			0.85		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/09/20 11:00	1.8			1			1.7			0	X		0.25638			0.85		
11/09/20 12:00	1.8			1			1.7			0	X		0.25218			0.84		
11/09/20 13:00	1.8			2			1.7			0	X		0.25188			0.84		
11/09/20 14:00	1.6			1			1.7			0	X		0.25854			0.86		
11/09/20 15:00	1.1			1			1.7			0	X		0.2211			0.74		
11/09/20 16:00	1.1			1			1.7			0	X		0.2163			0.72		
11/09/20 17:00	1.1			1			1.7			0	X		0.21636			0.72		
11/09/20 18:00	1.2			1			1.7			0	X		0.21798			0.73		
11/09/20 19:00	1.3			1			1.7			0	X		0.21888			0.73		
11/09/20 20:00	1.6			1			1.7			0	X		0.22098			0.74		
11/09/20 21:00	1.7			1			1.7			0	X		0.22314			0.74		
11/09/20 22:00	1.3			1			1.7			0	X		0.2319			0.77		
11/09/20 23:00	1.4			1			1.7			0	X		0.24414			0.81		
11/10/20 0:00	1.4			1			1.7			0	X		0.19614			0.65		
11/10/20 1:00	1.3			1			1.7			0	X		0.20922			0.7		
11/10/20 2:00	1.3			1			1.7			0	X		0.20742			0.69		
11/10/20 3:00	1.2			1			1.7			0	X		0.21348			0.71		
11/10/20 4:00	1.2			1			1.7			0	X		0.22638			0.75		
11/10/20 5:00	1.1			1			1.7			0	X		0.24762			0.83		
11/10/20 6:00	1.2			1			1.7			0	X		0.24378			0.81		
11/10/20 7:00	2.2			1			1.7			0	X		0.2595			0.87		
11/10/20 8:00	1.3			2			1.7			0	X		0.30012			1		
11/10/20 9:00	1.2			2			1.7			0	X		0.28536			0.95		
11/10/20 10:00	1.2			1			1.7			0	X		0.22938			0.76		
11/10/20 11:00	1.1			1			1.7			0	X		0.23064			0.77		
11/10/20 12:00	1.1			1			1.7			0	X		0.23328			0.78		
11/10/20 13:00	1.8			1			1.7			0	X		0.25428			0.85		
11/10/20 14:00	1.3			1			1.7			0	X		0.22002			0.73		
11/10/20 15:00	1.2			1			1.7			0	X		0.24768			0.83		
11/10/20 16:00	1.1			1			1.7			0	X		0.2388			0.8		
11/10/20 17:00	1.3			1			1.7			0	X		0.23652			0.79		
11/10/20 18:00	1.2			1			1.7			0	X		0.23082			0.77		
11/10/20 19:00	1.2			1			1.7			0	X		0.25128			0.84		
11/10/20 20:00	1.2			1			1.7			0	X		0.24372			0.81		
11/10/20 21:00	1.2			1			1.7			0	X		0.2511			0.84		
11/10/20 22:00	1.2			1			1.7			0	X		0.24246			0.81		
11/10/20 23:00	1.3			1			1.7			0	X		0.21			0.7		
11/11/20 0:00	1.2			1			1.7			0	X		0.17856			0.6		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/11/20 1:00	1.2			2			1.7			0	X		0.17442			0.58		
11/11/20 2:00	1.2			2			1.7			0	X		0.17436			0.58		
11/11/20 3:00	1.1			2			1.7			0	X		0.17424			0.58		
11/11/20 4:00	1.1			1			1.6			0	X		0.17616			0.59		
11/11/20 5:00	1.3			1			1.7			0	X		0.20136			0.67		
11/11/20 6:00	1.3			1			1.7			0	X		0.22146			0.74		
11/11/20 7:00	1.2			1			1.7			0	X		0.24			0.8		
11/11/20 8:00	1.1			1			1.7			0	X		0.24786			0.83		
11/11/20 9:00	1.9			1			1.7			0	X		0.24954			0.83		
11/11/20 10:00	1.8			1			1.7			0	X		0.24552			0.82		
11/11/20 11:00	1.2			1			1.7			0	X		0.23016			0.77		
11/11/20 12:00	1.1			1			1.7			0	X		0.23016			0.77		
11/11/20 13:00	1.1			1			1.7			0	X		0.23022			0.77		
11/11/20 14:00	1.1			1			1.7			0	X		0.23316			0.78		
11/11/20 15:00	1.4			1			1.7			0	X		0.27042			0.9		
11/11/20 16:00	1.3			1			1.7			0	X		0.249			0.83		
11/11/20 17:00	1.1			1			1.7			0	X		0.22446			0.75		
11/11/20 18:00	1.2			1			1.7			0	X		0.22854			0.76		
11/11/20 19:00	1.3			1			1.7			0	X		0.2154			0.72		
11/11/20 20:00	1.8			1			1.7			0	X		0.23532			0.78		
11/11/20 21:00	1.6			1			1.7			0	X		0.24486			0.82		
11/11/20 22:00	1.3			1			1.7			0	X		0.21864			0.73		
11/11/20 23:00	1.5			1			1.7			0	X		0.19008			0.63		
11/12/20 0:00	1.4			2			1.7			0	X		0.18054			0.6		
11/12/20 1:00	1.4			2			1.7			0	X		0.17376			0.58		
11/12/20 2:00	1.2			2			1.7			0	X		0.17394			0.58		
11/12/20 3:00	1.2			2			1.7			0	X		0.17526			0.58		
11/12/20 4:00	1.3			1			1.8			0	X		0.18624			0.62		
11/12/20 5:00	1.4			1			1.7			0	X		0.2082			0.69		
11/12/20 6:00	1.4			1			1.7			0	X		0.2391			0.8		
11/12/20 7:00	1.4			1			1.7			0	X		0.25404			0.85		
11/12/20 8:00	2.4			1			1.7			0	X		0.25686			0.86		
11/12/20 9:00	2			1			1.7			0	X		0.25668			0.86		
11/12/20 10:00	1.2			1			1.7			0	X		0.2253			0.75		
11/12/20 11:00	1.3			1			1.7			0	X		0.19476			0.65		
11/12/20 12:00	1.2			1			1.7			0	X		0.18096			0.6		
11/12/20 13:00	1.2			1			1.7			0	X		0.18114			0.6		
11/12/20 14:00	1.2			1			1.7			0	X		0.1821			0.61		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/12/20 15:00	1.2			1			1.7			0	X		0.24012			0.8		
11/12/20 16:00	1.1			1			1.7			0	X		0.2382			0.79		
11/12/20 17:00	1.2			1			1.7			0	X		0.24186			0.81		
11/12/20 18:00	1.2			1			1.7			0	X		0.24276			0.81		
11/12/20 19:00	1.3			1			1.7			0	X		0.24936			0.83		
11/12/20 20:00	1.3			1			1.7			0	X		0.24924			0.83		
11/12/20 21:00	1.3			1			1.7			0	X		0.24414			0.81		
11/12/20 22:00	1.3			1			1.7			0	X		0.21564			0.72		
11/12/20 23:00	1.4			1			1.7			0	X		0.19776			0.66		
11/13/20 0:00	1.3			1			1.7			0	X		0.18234			0.61		
11/13/20 1:00	1.1			1			1.7			0	X		0.17424			0.58		
11/13/20 2:00	1.1			1			1.7			0	X		0.17442			0.58		
11/13/20 3:00	1.2			1			1.7			0	X		0.17466			0.58		
11/13/20 4:00	1.1			1			1.7			0	X		0.17442			0.58		
11/13/20 5:00	1.3			1			1.7			0	X		0.1965			0.66		
11/13/20 6:00	1.2			1			1.8			0	X		0.23148			0.77		
11/13/20 7:00	2.1			1			1.7			0	X		0.25068			0.84		
11/13/20 8:00	1.9			1			1.7			0	X		0.255			0.85		
11/13/20 9:00	1.9			1			1.7			0	X		0.25482			0.85		
11/13/20 10:00	1.9			1			1.7			0	X		0.25836			0.86		
11/13/20 11:00	1.5			1			1.7			0	X		0.2811			0.94		
11/13/20 12:00	1.5			1			1.7			0	X		0.2712			0.9		
11/13/20 13:00	1.4			1			1.7			0	X		0.28548			0.95		
11/13/20 14:00	1.5			1			1.7			0	X		0.26568			0.89		
11/13/20 15:00	1.6			1			1.7			0	X		0.25176			0.84		
11/13/20 16:00	1.9			1			1.7			0	X		0.24702			0.82		
11/13/20 17:00	1.2			1			1.7			0	X		0.22218			0.74		
11/13/20 18:00	1.2			1			1.7			0	X		0.22734			0.76		
11/13/20 19:00	1.2			1			1.7			0	X		0.21318			0.71		
11/13/20 20:00	1.1			1			1.7			0	X		0.23658			0.79		
11/13/20 21:00	1.1			1			1.7			0	X		0.23862			0.8		
11/13/20 22:00	1.2			1			1.7			0	X		0.22638			0.75		
11/13/20 23:00	1.3			1			1.7			0	X		0.19542			0.65		
11/14/20 0:00	1.2			1			1.8			0	X		0.18624			0.62		
11/14/20 1:00	1.2			1			1.7			0	X		0.17334			0.58		
11/14/20 2:00	1.3			1			1.7			0	X		0.17466			0.58		
11/14/20 3:00	1.1			1			1.7			0	X		0.17478			0.58		
11/14/20 4:00	1.1			1			1.7			0	X		0.17466			0.58		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/14/20 5:00	1.1			1			1.7			0	X		0.17574			0.59		
11/14/20 6:00	1.3			1			1.7			0	X		0.1902			0.63		
11/14/20 7:00	1.2			1			1.7			0	X		0.21996			0.73		
11/14/20 8:00	1.2			1			1.7			0	X		0.24072			0.8		
11/14/20 9:00	2.1			1			1.7			0	X		0.26568			0.89		
11/14/20 10:00	1.2			1			1.7			0	X		0.21738			0.72		
11/14/20 11:00	1.2			1			1.7			0	X		0.19962			0.67		
11/14/20 12:00	1.2			1			1.7			0	X		0.2064			0.69		
11/14/20 13:00	1.4			1			1.7			0	X		0.2487			0.83		
11/14/20 14:00	1.3			1			1.7			0	X		0.24564			0.82		
11/14/20 15:00	1.2			1			1.7			0	X		0.23982			0.8		
11/14/20 16:00	1.5			1			1.7			0	X		0.26256			0.88		
11/14/20 17:00	1.2			1			1.7			0	X		0.2346			0.78		
11/14/20 18:00	1.1			1			1.7			0	X		0.23886			0.8		
11/14/20 19:00	1.2			1			1.7			0	X		0.23466			0.78		
11/14/20 20:00	1.2			1			1.7			0	X		0.25374			0.85		
11/14/20 21:00	1.5			1			1.7			0	X		0.25446			0.85		
11/14/20 22:00	1.6			1			1.7			0	X		0.28404			0.95		
11/14/20 23:00	1.3			1			1.7			0	X		0.21954			0.73		
11/15/20 0:00	1.2			1			1.7			0	X		0.18216			0.61		
11/15/20 1:00	1.2			1			1.7			0	X		0.18018			0.6		
11/15/20 2:00	1.3			1			1.7			0	X		0.2085			0.7		
11/15/20 3:00	1.2			1			1.7			0	X		0.2091			0.7		
11/15/20 4:00	1.2			1			1.6			0	X		0.17844			0.59		
11/15/20 5:00	1.4			1			1.7			0	X		0.19356			0.65		
11/15/20 6:00	1.2			1			1.7			0	X		0.21378			0.71		
11/15/20 7:00	1.2			1			1.7			0	X		0.21294			0.71		
11/15/20 8:00	1.1			1			1.7			0	X		0.2301			0.77		
11/15/20 9:00	1.1			1			1.7			0	X		0.23556			0.79		
11/15/20 10:00	1.2			1			1.7			0	X		0.24282			0.81		
11/15/20 11:00	1.8			1			1.7			0	X		0.25374			0.85		
11/15/20 12:00	1.8			1			1.7			0	X		0.24552			0.82		
11/15/20 13:00	1.7			1			1.7			0	X		0.24918			0.83		
11/15/20 14:00	1.3			1			1.7			0	X		0.26814			0.89		
11/15/20 15:00	1.1			2			1.7			0	X		0.28488			0.95		
11/15/20 16:00	1.3			2			1.7			0	X		0.27228			0.91		
11/15/20 17:00	1.4			1			1.7			0	X		0.25716			0.86		
11/15/20 18:00	1.8			1			1.7			0	X		0.24786			0.83		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/15/20 19:00	2.2			2			1.7			0	X		0.27048			0.9		
11/15/20 20:00	2.1			1			1.7			0	X		0.27144			0.9		
11/15/20 21:00	1.7			1			1.7			0	X		0.243			0.81		
11/15/20 22:00	1.3			1			1.7			0	X		0.2106			0.7		
11/15/20 23:00	1.4			1			1.7			0	X		0.19458			0.65		
11/16/20 0:00	1.2			1			1.7			0	X		0.17922			0.6		
11/16/20 1:00	1.2			1			1.7			0	X		0.17802			0.59		
11/16/20 2:00	1.2			1			1.7			0	X		0.17574			0.59		
11/16/20 3:00	1.2			1			1.7			0	X		0.17742			0.59		
11/16/20 4:00	1.2			1			1.7			0	X		0.17868			0.6		
11/16/20 5:00	1.5			1			1.7			0	X		0.19842			0.66		
11/16/20 6:00	1.4			1			1.7			0	X		0.2526			0.84		
11/16/20 7:00	2.3			1			1.7			0	X		0.25878			0.86		
11/16/20 8:00	2.1			1			1.7			0	X		0.26106			0.87		
11/16/20 9:00	1.7			1			1.7			0	X		0.26478			0.88		
11/16/20 10:00	1.6			1			1.7			0	X		0.26088			0.87		
11/16/20 11:00	1.4			1			1.7			0	X		0.26712			0.89		
11/16/20 12:00	1.4			1			1.7			0	X		0.26928			0.9		
11/16/20 13:00	1.4			1			1.7			0	X		0.27096			0.9		
11/16/20 14:00	1.5			1			1.7			0	X		0.258			0.86		
11/16/20 15:00	1.6			1			1.7			0	X		0.2427			0.81		
11/16/20 16:00	1.4			1			1.7			0	X		0.2109			0.7		
11/16/20 17:00	1.5			1			1.7			0	X		0.23802			0.79		
11/16/20 18:00	2.3			1			1.7			0	X		0.23712			0.79		
11/16/20 19:00	2			1			1.7			0	X		0.2514			0.84		
11/16/20 20:00	2.2			1			1.7			0	X		0.25476			0.85		
11/16/20 21:00	1.7			1			1.7			0	X		0.25956			0.87		
11/16/20 22:00	1.3			1			1.7			0	X		0.2115			0.71		
11/16/20 23:00	1.5			1			1.7			0	X		0.18768			0.63		
11/17/20 0:00	1.3			1			1.7			0	X		0.18144			0.6		
11/17/20 1:00	1.3			1			1.7			0	X		0.17658			0.59		
11/17/20 2:00	1.2			1			1.7			0	X		0.17424			0.58		
11/17/20 3:00	1.2			1			1.7			0	X		0.1746			0.58		
11/17/20 4:00	1.2			1			1.6			0	X		0.17544			0.58		
11/17/20 5:00	1.3			1			1.7			0	X		0.19392			0.65		
11/17/20 6:00	1.3			1			1.7			0	X		0.20934			0.7		
11/17/20 7:00	1.3			1			1.7			0	X		0.22176			0.74		
11/17/20 8:00	2.2			1			1.7			0	X		0.24588			0.82		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/17/20 9:00	1.6			1			1.7			0	X		0.2613			0.87		
11/17/20 10:00	1.5			1			1.7			0	X		0.26244			0.87		
11/17/20 11:00	1.2			1			1.7			0	X		0.2637			0.88		
11/17/20 12:00	1.1			1			1.7			0	X		0.26496			0.88		
11/17/20 13:00	1.1			1			1.7			0	X		0.26364			0.88		
11/17/20 14:00	1.3			1			1.7			0	X		0.2466			0.82		
11/17/20 15:00	1.2			1			1.7			0	X		0.23724			0.79		
11/17/20 16:00	1.2			1			1.7			0	X		0.23694			0.79		
11/17/20 17:00	1.2			1			1.7			0	X		0.23706			0.79		
11/17/20 18:00	1.1			1			1.7			0	X		0.23778			0.79		
11/17/20 19:00	0.8			1			1.7			0	X		0.21672			0.72		
11/17/20 20:00	0.7			1			1.7			0	X		0.22722			0.76		
11/17/20 21:00	0.8			1			1.7			0	X		0.21786			0.73		
11/17/20 22:00	0.8			1			1.7			0	X		0.2088			0.7		
11/17/20 23:00	0.8			1			1.7			0	X		0.18396			0.61		
11/18/20 0:00	0.8			1			1.7			0	X		0.17994			0.6		
11/18/20 1:00	0.7			1			1.7			0	X		0.17262			0.58		
11/18/20 2:00	0.7			1			1.7			0	X		0.1728			0.58		
11/18/20 3:00	0.7			1			1.7			0	X		0.17286			0.58		
11/18/20 4:00	0.7			1			1.6			0	X		0.1731			0.58		
11/18/20 5:00	0.8			1			1.7			0	X		0.18528			0.62		
11/18/20 6:00	0.8			1			1.7			0	X		0.20874			0.7		
11/18/20 7:00	0.7			1			1.7			0	X		0.23934			0.8		
11/18/20 8:00	1.8			1			1.7			0	X		0.2616			0.87		
11/18/20 9:00	1.5			1			1.7			0	X		0.26196			0.87		
11/18/20 10:00	1.2			1			1.7			0	X		0.26394			0.88		
11/18/20 11:00	1.2			1			1.7			0	X		0.26502			0.88		
11/18/20 12:00	1.1			1			1.7			0	X		0.26706			0.89		
11/18/20 13:00	0.9			1			1.7			0	X		0.24612			0.82		
11/18/20 14:00	0.8			1			1.7			0	X		0.2454			0.82		
11/18/20 15:00	0.8			1			1.7			0	X		0.24552			0.82		
11/18/20 16:00	0.8			1			1.7			0	X		0.24534			0.82		
11/18/20 17:00	0.8			1			1.7			0	X		0.2454			0.82		
11/18/20 18:00	0.8			1			1.7			0	X		0.2421			0.81		
11/18/20 19:00	0.7			1			1.7			0	X		0.22758			0.76		
11/18/20 20:00	1.5			1			1.7			0	X		0.24906			0.83		
11/18/20 21:00	0.8			1			1.7			0	X		0.21714			0.72		
11/18/20 22:00	0.8			1			1.7			0	X		0.21264			0.71		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/18/20 23:00	0.9			1			1.7			0	X		0.19086			0.64		
11/19/20 0:00	0.8			1			1.7			0	X		0.1809			0.6		
11/19/20 1:00	0.7			1			1.7			0	X		0.17316			0.58		
11/19/20 2:00	0.7			1			1.7			0	X		0.17304			0.58		
11/19/20 3:00	0.7			1			1.7			0	X		0.17298			0.58		
11/19/20 4:00	0.7			1			1.6			0	X		0.17466			0.58		
11/19/20 5:00	0.9			1			1.7			0	X		0.19668			0.66		
11/19/20 6:00	0.8			1			1.7			0	X		0.22038			0.73		
11/19/20 7:00	0.9			1			1.7			0	X		0.24828			0.83		
11/19/20 8:00	0.8			1			1.7			0	X		0.25962			0.87		
11/19/20 9:00	1.2			1			1.7			0	X		0.267			0.89		
11/19/20 10:00	0.8			1			1.7			0	X		0.24042			0.8		
11/19/20 11:00	0.8			1			1.7			0	X		0.23958			0.8		
11/19/20 12:00	0.8			1			1.7			0	X		0.23982			0.8		
11/19/20 13:00	0.8			1			1.7			0	X		0.23904			0.8		
11/19/20 14:00	0.8			1			1.7			0	X		0.24648			0.82		
11/19/20 15:00	0.8			1			1.7			0	X		0.23916			0.8		
11/19/20 16:00	0.8			1			1.7			0	X		0.23316			0.78		
11/19/20 17:00	0.8			1			1.7			0	X		0.24144			0.8		
11/19/20 18:00	1.1			1			1.7			0	X		0.2541			0.85		
11/19/20 19:00	0.8			1			1.7			0	X		0.22068			0.74		
11/19/20 20:00	0.7			1			1.7			0	X		0.22446			0.75		
11/19/20 21:00	0.7			1			1.7			0	X		0.228			0.76		
11/19/20 22:00	0.7			1			1.7			0	X		0.22386			0.75		
11/19/20 23:00	0.9			1			1.7			0	X		0.2004			0.67		
11/20/20 0:00	0.8			1			1.7			0	X		0.1827			0.61		
11/20/20 1:00	0.7			2			1.7			0	X		0.17508			0.58		
11/20/20 2:00	0.8			2			1.7			0	X		0.17472			0.58		
11/20/20 3:00	1			2			1.7			0	X		0.1752			0.58		
11/20/20 4:00	1.1			1			1.7			0	X		0.18792			0.63		
11/20/20 5:00	1.1			1			1.7			0	X		0.21126			0.7		
11/20/20 6:00	2			1			1.7			0	X		0.26034			0.87		
11/20/20 7:00	2.2			1			1.7			0	X		0.26178			0.87		
11/20/20 8:00	2.2			1			1.8			0	X		0.26112			0.87		
11/20/20 9:00	0.9			2			1.7			0	X		0.30492			1.02		
11/20/20 10:00	0.9			2			1.7			0	X		0.29298			0.98		
11/20/20 11:00	1.1			2			1.7			0	X		0.2715			0.91		
11/20/20 12:00	1			1			1.7			0	X		0.24228			0.81		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/20/20 13:00	0.8			1			1.7			0	X		0.23484			0.78		
11/20/20 14:00	0.8			1			1.7			0	X		0.23142			0.77		
11/20/20 15:00	0.8			1			1.7			0	X		0.2337			0.78		
11/20/20 16:00	0.9			1			1.7			0	X		0.23718			0.79		
11/20/20 17:00	1.3			2			1.7			0	X		0.25806			0.86		
11/20/20 18:00	1.6			1			1.7			0	X		0.24588			0.82		
11/20/20 19:00	1.5			2			1.7			0	X		0.24354			0.81		
11/20/20 20:00	1.8			2			1.7			0	X		0.24972			0.83		
11/20/20 21:00	1.8			2			1.7			0	X		0.25266			0.84		
11/20/20 22:00	1			1			1.7			0	X		0.23622			0.79		
11/20/20 23:00	1			1			1.7			0	X		0.22158			0.74		
11/21/20 0:00	1			1			1.7			0	X		0.2304			0.77		
11/21/20 1:00	1.5			1			1.7			0	X		0.21834			0.73		
11/21/20 2:00	1.2			1			1.7			0	X		0.20856			0.7		
11/21/20 3:00	1.1			1			1.7			0	X		0.20496			0.68		
11/21/20 4:00	1.2			1			1.7			0	X		0.21768			0.73		
11/21/20 5:00	1.4			1			1.7			0	X		0.20124			0.67		
11/21/20 6:00	1.3			1			1.7			0	X		0.20082			0.67		
11/21/20 7:00	1.1			1			1.7			0	X		0.23478			0.78		
11/21/20 8:00	1			1			1.7			0	X		0.24252			0.81		
11/21/20 9:00	0.9			1			1.7			0	X		0.2499			0.83		
11/21/20 10:00	1			1			1.7			0	X		0.24792			0.83		
11/21/20 11:00	0.8			1			1.7			0	X		0.23796			0.79		
11/21/20 12:00	0.8			1			1.7			0	X		0.23274			0.78		
11/21/20 13:00	0.8			1			1.7			0	X		0.23154			0.77		
11/21/20 14:00	0.8			1			1.7			0	X		0.23796			0.79		
11/21/20 15:00	0.8			1			1.7			0	X		0.23826			0.79		
11/21/20 16:00	0.9			1			1.7			0	X		0.23754			0.79		
11/21/20 17:00	0.9			1			1.7			0	X		0.23166			0.77		
11/21/20 18:00	0.9			1			1.7			0	X		0.24312			0.81		
11/21/20 19:00	1			1			1.7			0	X		0.25368			0.85		
11/21/20 20:00	1			1			1.7			0	X		0.25416			0.85		
11/21/20 21:00	1.8			2			1.7			0	X		0.25374			0.85		
11/21/20 22:00	1.2			2			1.7			0	X		0.27324			0.91		
11/21/20 23:00	0.9			1			1.7			0	X		0.24018			0.8		
11/22/20 0:00	1			1			1.7			0	X		0.18966			0.63		
11/22/20 1:00	1			1			1.7			0	X		0.18438			0.61		
11/22/20 2:00	0.9			1			1.7			0	X		0.18396			0.61		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/22/20 3:00	0.9			1			1.7			0	X		0.18402			0.61		
11/22/20 4:00	0.9			1			1.7			0	X		0.18408			0.61		
11/22/20 5:00	0.9			1			1.7			0	X		0.1863			0.62		
11/22/20 6:00	1.1			1			1.7			0	X		0.20352			0.68		
11/22/20 7:00	0.9			1			1.7			0	X		0.23556			0.79		
11/22/20 8:00	1.7			1			1.7			0	X		0.25464			0.85		
11/22/20 9:00	1.3			2			1.7			0	X		0.27132			0.9		
11/22/20 10:00	1.2			2			1.7			0	X		0.28122			0.94		
11/22/20 11:00	1.3			2			1.9			0	X		0.25272			0.84		
11/22/20 12:00	1.2			1			1.7			0	X		0.25146			0.84		
11/22/20 13:00	1.1			1			1.7			0	X		0.25614			0.85		
11/22/20 14:00	1.6			1			1.7			0	X		0.24318			0.81		
11/22/20 15:00	1			2			1.7			0	X		0.27858			0.93		
11/22/20 16:00	0.5			2			1.7			0	X		0.32052			1.07		
11/22/20 17:00	0.7			2			1.7			0	X		0.29652			0.99		
11/22/20 18:00	0.8			2			1.7			0	X		0.2937			0.98		
11/22/20 19:00	1.6			1			1.8			0	X		0.2613			0.87		
11/22/20 20:00	1.4			1			1.7			0	X		0.26406			0.88		
11/22/20 21:00	1.3			1			1.7			0	X		0.26298			0.88		
11/22/20 22:00	1			1			1.7			0	X		0.22752			0.76		
11/22/20 23:00	1			1			1.7			0	X		0.19686			0.66		
11/23/20 0:00	1			1			1.7			0	X		0.18096			0.6		
11/23/20 1:00	1.2			1			1.7			0	X		0.18102			0.6		
11/23/20 2:00	0.9			1			1.7			0	X		0.1812			0.6		
11/23/20 3:00	1			1			1.7			0	X		0.18096			0.6		
11/23/20 4:00	1			1			1.7			0	X		0.18144			0.6		
11/23/20 5:00	1			1			1.7			0	X		0.20508			0.68		
11/23/20 6:00	0.8			1			1.7			0	X		0.23766			0.79		
11/23/20 7:00	0.9			1			1.7			0	X		0.23922			0.8		
11/23/20 8:00	1.5			1			1.7			0	X		0.25026			0.83		
11/23/20 9:00	1.9			1			1.7			0	X		0.25116			0.84		
11/23/20 10:00	1.7			1			1.7			0	X		0.24882			0.83		
11/23/20 11:00	1.6			1			1.7			0	X		0.24984			0.83		
11/23/20 12:00	1.5			1			1.7			0	X		0.24732			0.82		
11/23/20 13:00	1.5			1			1.7			0	X		0.24504			0.82		
11/23/20 14:00	1.5			1			1.7			0	X		0.24312			0.81		
11/23/20 15:00	1.4			1			1.7			0	X		0.24834			0.83		
11/23/20 16:00	1.1			1			1.7			0	X		0.26196			0.87		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/23/20 17:00	1.1			1			1.7			0	X		0.23904			0.8		
11/23/20 18:00	1.7			1			1.7			0	X		0.24834			0.83		
11/23/20 19:00	1.1			1			1.7			0	X		0.23682			0.79		
11/23/20 20:00	1			1			1.7			0	X		0.23496			0.78		
11/23/20 21:00	0.8			1			1.7			0	X		0.23448			0.78		
11/23/20 22:00	0.9			1			1.7			0	X		0.22812			0.76		
11/23/20 23:00	1.1			1			1.7			0	X		0.20472			0.68		
11/24/20 0:00	1			1			1.7			0	X		0.18048			0.6		
11/24/20 1:00	1.3			1			1.7			0	X		0.18006			0.6		
11/24/20 2:00	1.2			1			1.7			0	X		0.18078			0.6		
11/24/20 3:00	1.1			1			1.7			0	X		0.18042			0.6		
11/24/20 4:00	1			1			1.7			0	X		0.18144			0.6		
11/24/20 5:00	1			1			1.7			0	X		0.20628			0.69		
11/24/20 6:00	1.8			1			1.7			0	X		0.25506			0.85		
11/24/20 7:00	1.8			1			1.7			0	X		0.25356			0.85		
11/24/20 8:00	1.7			1			1.7			0	X		0.25596			0.85		
11/24/20 9:00	1.7			1			1.7			0	X		0.25206			0.84		
11/24/20 10:00	1.7			1			1.7			0	X		0.24804			0.83		
11/24/20 11:00	1.5			1			1.7			0	X		0.24294			0.81		
11/24/20 12:00	1.3			1			1.7			0	X		0.25254			0.84		
11/24/20 13:00	1.7			1			1.7			0	X		0.24534			0.82		
11/24/20 14:00	1.6			1			1.7			0	X		0.24348			0.81		
11/24/20 15:00	1.5			1			1.7			0	X		0.24048			0.8		
11/24/20 16:00	1.5			1			1.7			0	X		0.24426			0.81		
11/24/20 17:00	1.5			1			1.7			0	X		0.24648			0.82		
11/24/20 18:00	1			1			1.7			0	X		0.2388			0.8		
11/24/20 19:00	0.8			1			1.7			0	X		0.23232			0.77		
11/24/20 20:00	0.9			1			1.7			0	X		0.25128			0.84		
11/24/20 21:00	0.9			1			1.7			0	X		0.24846			0.83		
11/24/20 22:00	0.8			1			1.7			0	X		0.23622			0.79		
11/24/20 23:00	0.9			1			1.7			0	X		0.2049			0.68		
11/25/20 0:00	1			1			1.7			0	X		0.19488			0.65		
11/25/20 1:00	0.8			1			1.7			0	X		0.18144			0.6		
11/25/20 2:00	0.8			1			1.7			0	X		0.18192			0.61		
11/25/20 3:00	0.9			1			1.7			0	X		0.19752			0.66		
11/25/20 4:00	0.9			1			1.6			0	X		0.19878			0.66		
11/25/20 5:00	0.9			1			1.8			0	X		0.21198			0.71		
11/25/20 6:00	1.7			1			1.7			0	X		0.25278			0.84		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/25/20 7:00	0.9			1			1.7			0	X		0.23778			0.79		
11/25/20 8:00	0.8			1			1.7			0	X		0.24228			0.81		
11/25/20 9:00	0.8			1			1.7			0	X		0.2499			0.83		
11/25/20 10:00	0.8			1			1.7			0	X		0.25698			0.86		
11/25/20 11:00	0.8			1			1.7			0	X		0.25482			0.85		
11/25/20 12:00	0.8			1			1.7			0	X		0.25128			0.84		
11/25/20 13:00	0.8			1			1.7			0	X		0.225			0.75		
11/25/20 14:00	0.8			1			1.7			0	X		0.23226			0.77		
11/25/20 15:00	0.8			1			1.7			0	X		0.24768			0.83		
11/25/20 16:00	0.8			1			1.7			0	X		0.24432			0.81		
11/25/20 17:00	0.8			1			1.7			0	X		0.23226			0.77		
11/25/20 18:00	0.8			1			1.7			0	X		0.23928			0.8		
11/25/20 19:00	0.8			1			1.7			0	X		0.23952			0.8		
11/25/20 20:00	0.8			1			1.7			0	X		0.23958			0.8		
11/25/20 21:00	1.5			1			1.7			0	X		0.249			0.83		
11/25/20 22:00	0.8			1			1.7			0	X		0.24174			0.81		
11/25/20 23:00	0.9			1			1.7			0	X		0.20178			0.67		
11/26/20 0:00	0			0	X		0			0	X		0.06774			0.23		
11/26/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/26/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/26/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/27/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/28/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/28/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/29/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
11/30/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/30/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/01/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/01/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/02/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/03/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/03/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/04/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/04/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/05/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/06/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/06/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/07/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/07/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/08/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/09/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/09/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/10/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/11/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/11/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/12/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/12/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/13/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/14/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/14/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/15/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/15/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/16/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/17/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/17/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/18/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/19/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/19/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/20/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/20/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/21/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/22/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/20 15:00	0			0	X		0			0	X		0.0987			0.33		
12/22/20 16:00	0.8			2			1.3			0	X		0.25578			0.85		
12/22/20 17:00	0.8			0			1.7			0.29			0.22776			0.76		
12/22/20 18:00	0.7			1			1.8			0.48			0.15558			0.52		
12/22/20 19:00	0	X		0	X		0	X		0.53			0	X		0	X	
12/22/20 20:00	0	X		0	X		0	X		0.24			0	X		0	X	
12/22/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/22/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/23/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/23/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/24/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/25/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/25/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/26/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/26/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/27/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/28/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/28/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/29/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/30/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/30/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 16:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
12/31/20 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
12/31/20 23:00	0	X		0	X		0	X		0	X		0	X		0	X	

AQ-59

AQ-59 The Daily Emissions shall not exceed the following rates:

POLLUTANT	TWO TURBINES	AUX BOILER	COOLING TOWER	EMERGENCY DIESEL GENERATOR	DIESEL FIRE PUMP
NOX	406.0	16.8	-	4.31	1.72
CO	629.5	52.8	-	0.84	0.09
VOC	223.1	7.2	-	0.16	0.05
PM-10	226.8	14.4	16.3	0.14	0.03
SO2	47.1	1.92	-	0.10	0.19

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 12:18 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
10/01/2020	32.04	128.83	12.37	24.70	41.20
10/02/2020	37.70	110.80	10.63	21.24	35.40
10/03/2020	37.26	113.45	10.83	21.71	36.17
10/04/2020	31.54	126.61	12.04	24.11	40.18
10/05/2020	29.96	129.77	12.47	24.89	41.48
10/06/2020	29.58	126.33	12.11	24.21	40.36
10/07/2020	36.16	123.04	11.69	23.44	39.02
10/08/2020	26.60	72.18	6.85	13.71	22.80
10/09/2020	18.68	64.29	6.12	12.24	20.43
10/10/2020	37.04	63.33	5.09	10.18	17.03
10/11/2020	14.62	58.73	5.62	11.24	18.76
10/12/2020	18.41	64.20	6.16	12.27	20.48
10/13/2020	37.78	108.80	10.71	21.47	35.71
10/14/2020	28.78	124.11	11.86	23.70	39.52
10/15/2020	41.98	108.68	10.11	20.24	33.73
10/16/2020	29.49	123.57	11.89	23.74	39.62
10/17/2020	31.44	119.97	11.44	22.86	38.07
10/18/2020	37.04	115.83	11.09	22.22	37.04
10/19/2020	37.58	119.41	11.81	23.59	39.37
10/20/2020	33.39	122.46	11.68	23.32	38.87
10/21/2020	33.46	103.89	9.96	19.90	33.10
10/22/2020	35.35	110.14	10.66	21.30	35.41
10/23/2020	45.98	105.28	10.02	20.03	33.31
10/24/2020	19.31	58.09	5.58	11.12	18.57
10/25/2020	22.17	63.02	6.00	11.97	19.95
10/26/2020	18.74	70.73	6.73	13.43	22.38
10/27/2020	25.70	59.82	5.72	11.44	19.03
10/28/2020	29.48	59.42	5.61	11.29	18.79
10/29/2020	28.36	61.90	5.90	11.78	19.69
10/30/2020	28.36	63.68	6.02	12.02	20.07
10/31/2020	26.13	58.71	5.71	11.41	19.04
Monthly Avg/Sum*:	940.11 *	2,939.07 *	280.48 *	560.77 *	934.58 *
Daily Min:	14.62	58.09	5.09	10.18	17.03
Daily Max:	45.98	129.77	12.47	24.89	41.48
Oct 2020 - Oct 2020	940.11	2,939.07	280.48	560.77	934.58
QTD:	940.11 *	2,939.07 *	280.48 *	560.77 *	934.58 *
YTD 2020:	4,136.69 *	13,982.18 *	1,319.05 *	2,638.18 *	4,395.42 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 12:18 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
11/01/2020	22.05	59.02	5.65	11.24	18.74
11/02/2020	25.02	68.39	6.52	13.03	21.72
11/03/2020	22.06	69.00	6.59	13.16	21.95
11/04/2020	25.74	58.94	5.63	11.25	18.79
11/05/2020	23.48	57.64	5.79	11.48	19.19
11/06/2020	22.66	53.49	5.21	10.42	17.32
11/07/2020	24.13	54.36	5.20	10.33	17.25
11/08/2020	25.80	53.58	5.10	10.24	17.12
11/09/2020	30.19	57.78	5.50	11.01	18.36
11/10/2020	27.77	59.60	5.71	11.42	19.04
11/11/2020	26.25	55.03	5.28	10.58	17.63
11/12/2020	26.64	54.55	5.19	10.38	17.29
11/13/2020	29.66	57.27	5.49	10.95	18.30
11/14/2020	26.10	55.72	5.30	10.64	17.73
11/15/2020	29.68	58.41	5.54	11.13	18.54
11/16/2020	33.26	58.52	5.55	11.10	18.49
11/17/2020	24.10	55.50	5.32	10.62	17.72
11/18/2020	19.38	56.27	5.41	10.79	18.00
11/19/2020	16.49	55.86	5.32	10.69	17.82
11/20/2020	26.00	59.46	5.63	11.29	18.82
11/21/2020	21.74	58.98	5.60	11.29	18.75
11/22/2020	23.55	60.68	5.74	11.54	19.21
11/23/2020	25.27	56.90	5.46	10.92	18.17
11/24/2020	26.87	57.33	5.50	11.00	18.33
11/25/2020	18.50	58.11	5.49	11.00	18.35
11/26/2020	15.65	0.61	0.00	0.01	0.02
11/27/2020	0.00	0.00	0.00	0.00	0.00
11/28/2020	0.00	0.00	0.00	0.00	0.00
11/29/2020	0.00	0.00	0.00	0.00	0.00
11/30/2020	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	638.04 *	1,451.00 *	138.72 *	277.51 *	462.65 *
Daily Min:	15.65	0.61	0.00	0.01	0.02
Daily Max:	33.26	69.00	6.59	13.16	21.95
Oct 2020 - Nov 2020	1,578.15	4,390.07	419.20	838.28	1,397.23
QTD:	1,578.15 *	4,390.07 *	419.20 *	838.28 *	1,397.23 *
YTD 2020:	4,774.73 *	15,433.18 *	1,457.77 *	2,915.69 *	4,858.07 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 12:18 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
12/01/2020	0.00	0.00	0.00	0.00	0.00
12/02/2020	0.00	0.00	0.00	0.00	0.00
12/03/2020	0.00	0.00	0.00	0.00	0.00
12/04/2020	0.00	0.00	0.00	0.00	0.00
12/05/2020	0.00	0.00	0.00	0.00	0.00
12/06/2020	0.00	0.00	0.00	0.00	0.00
12/07/2020	0.00	0.00	0.00	0.00	0.00
12/08/2020	0.00	0.00	0.00	0.00	0.00
12/09/2020	0.00	0.00	0.00	0.00	0.00
12/10/2020	0.00	0.00	0.00	0.00	0.00
12/11/2020	0.00	0.00	0.00	0.00	0.00
12/12/2020	0.00	0.00	0.00	0.00	0.00
12/13/2020	0.00	0.00	0.00	0.00	0.00
12/14/2020	0.00	0.00	0.00	0.00	0.00
12/15/2020	0.00	0.00	0.00	0.00	0.00
12/16/2020	0.00	0.00	0.00	0.00	0.00
12/17/2020	0.00	0.00	0.00	0.00	0.00
12/18/2020	0.00	0.00	0.00	0.00	0.00
12/19/2020	0.00	0.00	0.00	0.00	0.00
12/20/2020	0.00	0.00	0.00	0.00	0.00
12/21/2020	0.00	0.00	0.00	0.00	0.00
12/22/2020	104.87	39.49	1.21	2.42	4.01
12/23/2020	0.00	0.00	0.00	0.00	0.00
12/24/2020	0.00	0.00	0.00	0.00	0.00
12/25/2020	0.00	0.00	0.00	0.00	0.00
12/26/2020	0.00	0.00	0.00	0.00	0.00
12/27/2020	0.00	0.00	0.00	0.00	0.00
12/28/2020	0.00	0.00	0.00	0.00	0.00
12/29/2020	0.00	0.00	0.00	0.00	0.00
12/30/2020	0.00	0.00	0.00	0.00	0.00
12/31/2020	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	104.87 *	39.49 *	1.21 *	2.42 *	4.01 *
Daily Min:	104.87	39.49	1.21	2.42	4.01
Daily Max:	104.87	39.49	1.21	2.42	4.01
Oct 2020 - Dec 2020	1,683.02	4,429.56	420.41	840.70	1,401.24
QTD:	1,683.02 *	4,429.56 *	420.41 *	840.70 *	1,401.24 *
YTD 2020:	4,879.60 *	15,472.67 *	1,458.98 *	2,918.11 *	4,862.08 *

Monthly Summary By Day Report

Unit CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:34 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
10/01/2020	14.27	65.16	6.4	12.48	20.82
10/02/2020	17.29	56.31	5.6	10.79	17.97
10/03/2020	17.03	57.75	5.6	11.00	18.32
10/04/2020	13.90	63.87	6.2	12.20	20.32
10/05/2020	13.31	65.65	6.6	12.63	21.06
10/06/2020	12.72	64.47	6.2	12.35	20.56
10/07/2020	16.45	62.48	6.3	11.90	19.82
10/08/2020	10.65	9.92	1.0	1.79	2.95
10/09/2020	0.00	0.00	0.0	0.00	0.00
10/10/2020	25.53	30.60	1.8	3.96	6.61
10/11/2020	14.62	58.73	5.3	11.24	18.76
10/12/2020	18.41	64.20	6.1	12.27	20.48
10/13/2020	16.38	69.47	6.9	13.45	22.39
10/14/2020	12.76	62.36	6.1	11.92	19.89
10/15/2020	27.55	42.95	3.8	7.58	12.60
10/16/2020	12.31	61.74	5.9	11.84	19.74
10/17/2020	13.37	60.23	5.6	11.48	19.14
10/18/2020	15.80	58.03	5.7	11.15	18.59
10/19/2020	16.29	58.36	6.0	11.90	19.85
10/20/2020	14.34	61.81	6.2	11.74	19.57
10/21/2020	14.84	52.09	5.0	10.03	16.66
10/22/2020	15.49	55.63	5.5	10.85	18.00
10/23/2020	25.75	51.73	5.0	9.82	16.32
10/24/2020	0.00	0.00	0.0	0.00	0.00
10/25/2020	0.00	0.00	0.0	0.00	0.00
10/26/2020	0.00	0.00	0.0	0.00	0.00
10/27/2020	0.00	0.00	0.0	0.00	0.00
10/28/2020	0.00	0.00	0.0	0.00	0.00
10/29/2020	0.00	0.00	0.0	0.00	0.00
10/30/2020	0.00	0.00	0.0	0.00	0.00
10/31/2020	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	359.06 *	1,233.54 *	118.8 *	234.37 *	390.42 *
Daily Min:	10.65	9.92	1.0	1.79	2.95
Daily Max:	27.55	69.47	6.9	13.45	22.39
Oct 2020 - Oct 2020	359.06	1,233.54	118.8	234.37	390.42
QTD:	359.06 *	1,233.54 *	118.8 *	234.37 *	390.42 *
YTD 2020:	1,925.87 *	6,574.43 *	632.0 *	1,240.51 *	2,066.52 *

Monthly Summary By Day Report

Unit CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:34 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
11/01/2020	0.00	0.00	0.0	0.00	0.00
11/02/2020	0.00	0.00	0.0	0.00	0.00
11/03/2020	0.00	0.00	0.0	0.00	0.00
11/04/2020	0.00	0.00	0.0	0.00	0.00
11/05/2020	0.00	0.00	0.0	0.00	0.00
11/06/2020	0.00	0.00	0.0	0.00	0.00
11/07/2020	0.00	0.00	0.0	0.00	0.00
11/08/2020	0.00	0.00	0.0	0.00	0.00
11/09/2020	0.00	0.00	0.0	0.00	0.00
11/10/2020	0.00	0.00	0.0	0.00	0.00
11/11/2020	0.00	0.00	0.0	0.00	0.00
11/12/2020	0.00	0.00	0.0	0.00	0.00
11/13/2020	0.00	0.00	0.0	0.00	0.00
11/14/2020	0.00	0.00	0.0	0.00	0.00
11/15/2020	0.00	0.00	0.0	0.00	0.00
11/16/2020	0.00	0.00	0.0	0.00	0.00
11/17/2020	0.00	0.00	0.0	0.00	0.00
11/18/2020	0.00	0.00	0.0	0.00	0.00
11/19/2020	0.00	0.00	0.0	0.00	0.00
11/20/2020	0.00	0.00	0.0	0.00	0.00
11/21/2020	0.00	0.00	0.0	0.00	0.00
11/22/2020	0.00	0.00	0.0	0.00	0.00
11/23/2020	0.00	0.00	0.0	0.00	0.00
11/24/2020	0.00	0.00	0.0	0.00	0.00
11/25/2020	0.00	0.00	0.0	0.00	0.00
11/26/2020	0.00	0.00	0.0	0.00	0.00
11/27/2020	0.00	0.00	0.0	0.00	0.00
11/28/2020	0.00	0.00	0.0	0.00	0.00
11/29/2020	0.00	0.00	0.0	0.00	0.00
11/30/2020	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	- *	- *	- *	- *	- *
Daily Min:	-	-	-	-	-
Daily Max:	-	-	-	-	-
Oct 2020 - Nov 2020	359.06	1,233.54	118.8	234.37	390.42
QTD:	359.06 *	1,233.54 *	118.8 *	234.37 *	390.42 *
YTD 2020:	1,925.87 *	6,574.43 *	632.0 *	1,240.51 *	2,066.52 *

Monthly Summary By Day Report

Unit CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:34 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
12/01/2020	0.00	0.00	0.0	0.00	0.00
12/02/2020	0.00	0.00	0.0	0.00	0.00
12/03/2020	0.00	0.00	0.0	0.00	0.00
12/04/2020	0.00	0.00	0.0	0.00	0.00
12/05/2020	0.00	0.00	0.0	0.00	0.00
12/06/2020	0.00	0.00	0.0	0.00	0.00
12/07/2020	0.00	0.00	0.0	0.00	0.00
12/08/2020	0.00	0.00	0.0	0.00	0.00
12/09/2020	0.00	0.00	0.0	0.00	0.00
12/10/2020	0.00	0.00	0.0	0.00	0.00
12/11/2020	0.00	0.00	0.0	0.00	0.00
12/12/2020	0.00	0.00	0.0	0.00	0.00
12/13/2020	0.00	0.00	0.0	0.00	0.00
12/14/2020	0.00	0.00	0.0	0.00	0.00
12/15/2020	0.00	0.00	0.0	0.00	0.00
12/16/2020	0.00	0.00	0.0	0.00	0.00
12/17/2020	0.00	0.00	0.0	0.00	0.00
12/18/2020	0.00	0.00	0.0	0.00	0.00
12/19/2020	0.00	0.00	0.0	0.00	0.00
12/20/2020	0.00	0.00	0.0	0.00	0.00
12/21/2020	0.00	0.00	0.0	0.00	0.00
12/22/2020	51.18	16.92	0.6	1.22	2.01
12/23/2020	0.00	0.00	0.0	0.00	0.00
12/24/2020	0.00	0.00	0.0	0.00	0.00
12/25/2020	0.00	0.00	0.0	0.00	0.00
12/26/2020	0.00	0.00	0.0	0.00	0.00
12/27/2020	0.00	0.00	0.0	0.00	0.00
12/28/2020	0.00	0.00	0.0	0.00	0.00
12/29/2020	0.00	0.00	0.0	0.00	0.00
12/30/2020	0.00	0.00	0.0	0.00	0.00
12/31/2020	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	51.18 *	16.92 *	0.6 *	1.22 *	2.01 *
Daily Min:	51.18	16.92	0.6	1.22	2.01
Daily Max:	51.18	16.92	0.6	1.22	2.01
Oct 2020 - Dec 2020	410.24	1,250.46	119.4	235.59	392.43
QTD:	410.24 *	1,250.46 *	119.4 *	235.59 *	392.43 *
YTD 2020:	1,977.05 *	6,591.35 *	632.6 *	1,241.73 *	2,068.53 *

Monthly Summary By Day Report

Unit CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:33 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
10/01/2020	17.77	63.67	6.1	12.22	20.38
10/02/2020	20.41	54.49	5.3	10.45	17.43
10/03/2020	20.23	55.70	5.4	10.71	17.85
10/04/2020	17.64	62.74	5.8	11.91	19.86
10/05/2020	16.65	64.12	6.2	12.26	20.42
10/06/2020	16.86	61.86	5.8	11.86	19.80
10/07/2020	19.71	60.56	6.0	11.54	19.20
10/08/2020	15.95	62.26	5.9	11.92	19.85
10/09/2020	18.68	64.29	5.9	12.24	20.43
10/10/2020	11.51	32.73	3.2	6.22	10.42
10/11/2020	0.00	0.00	0.0	0.00	0.00
10/12/2020	0.00	0.00	0.0	0.00	0.00
10/13/2020	11.62	39.33	4.2	8.02	13.32
10/14/2020	16.02	61.75	5.9	11.78	19.63
10/15/2020	14.43	65.73	6.2	12.66	21.13
10/16/2020	17.18	61.83	5.9	11.90	19.88
10/17/2020	18.07	59.74	5.5	11.38	18.93
10/18/2020	21.24	57.80	5.5	11.07	18.45
10/19/2020	21.29	61.05	5.9	11.69	19.52
10/20/2020	19.05	60.65	5.7	11.58	19.30
10/21/2020	18.62	51.80	5.0	9.87	16.44
10/22/2020	19.86	54.51	5.0	10.45	17.41
10/23/2020	20.23	53.55	5.1	10.21	16.99
10/24/2020	19.31	58.09	5.4	11.12	18.57
10/25/2020	22.17	63.02	5.9	11.97	19.95
10/26/2020	18.74	70.73	6.9	13.43	22.38
10/27/2020	25.70	59.82	5.5	11.44	19.03
10/28/2020	29.48	59.42	5.7	11.29	18.79
10/29/2020	28.36	61.90	5.9	11.78	19.69
10/30/2020	28.36	63.68	5.8	12.02	20.07
10/31/2020	26.13	58.71	5.3	11.41	19.04
Monthly Avg/Sum*:	571.27 *	1,705.53 *	161.9 *	326.40 *	544.16 *
Daily Min:	0.00	0.00	0.0	0.00	0.00
Daily Max:	29.48	70.73	6.9	13.43	22.38
Oct 2020 - Oct 2020	571.27	1,705.53	161.9	326.40	544.16
QTD:	571.27 *	1,705.53 *	161.9 *	326.40 *	544.16 *
YTD 2020:	2,191.28 *	7,406.69 *	707.5 *	1,397.67 *	2,328.90 *

Monthly Summary By Day Report

Unit CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:33 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
11/01/2020	22.05	59.02	5.8	11.24	18.74
11/02/2020	25.02	68.39	6.7	13.03	21.72
11/03/2020	22.06	69.00	6.5	13.16	21.95
11/04/2020	25.74	58.94	5.8	11.25	18.79
11/05/2020	23.48	57.64	5.7	11.48	19.19
11/06/2020	22.66	53.49	4.9	10.42	17.32
11/07/2020	24.13	54.36	5.0	10.33	17.25
11/08/2020	25.80	53.58	5.0	10.24	17.12
11/09/2020	30.19	57.78	5.6	11.01	18.36
11/10/2020	27.77	59.60	5.4	11.42	19.04
11/11/2020	26.25	55.03	4.9	10.58	17.63
11/12/2020	26.64	54.55	5.1	10.38	17.29
11/13/2020	29.66	57.27	5.7	10.95	18.30
11/14/2020	26.10	55.72	5.3	10.64	17.73
11/15/2020	29.68	58.41	5.5	11.13	18.54
11/16/2020	33.26	58.52	6.0	11.10	18.49
11/17/2020	24.10	55.50	5.3	10.62	17.72
11/18/2020	19.38	56.27	5.3	10.79	18.00
11/19/2020	16.49	55.86	5.1	10.69	17.82
11/20/2020	26.00	59.46	5.6	11.29	18.82
11/21/2020	21.74	58.98	5.2	11.29	18.75
11/22/2020	23.55	60.68	6.1	11.54	19.21
11/23/2020	25.27	56.90	5.1	10.92	18.17
11/24/2020	26.87	57.33	5.4	11.00	18.33
11/25/2020	18.50	58.11	5.2	11.00	18.35
11/26/2020	15.65	0.61	0.0	0.01	0.02
11/27/2020	0.00	0.00	0.0	0.00	0.00
11/28/2020	0.00	0.00	0.0	0.00	0.00
11/29/2020	0.00	0.00	0.0	0.00	0.00
11/30/2020	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	638.04 *	1,451.00 *	137.2 *	277.51 *	462.65 *
Daily Min:	15.65	0.61	0.0	0.01	0.02
Daily Max:	33.26	69.00	6.7	13.16	21.95
Oct 2020 - Nov 2020	1,209.31	3,156.53	299.1	603.91	1,006.81
QTD:	1,209.31 *	3,156.53 *	299.1 *	603.91 *	1,006.81 *
YTD 2020:	2,829.32 *	8,857.69 *	844.7 *	1,675.18 *	2,791.55 *

Monthly Summary By Day Report

Unit CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:33 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
12/01/2020	0.00	0.00	0.0	0.00	0.00
12/02/2020	0.00	0.00	0.0	0.00	0.00
12/03/2020	0.00	0.00	0.0	0.00	0.00
12/04/2020	0.00	0.00	0.0	0.00	0.00
12/05/2020	0.00	0.00	0.0	0.00	0.00
12/06/2020	0.00	0.00	0.0	0.00	0.00
12/07/2020	0.00	0.00	0.0	0.00	0.00
12/08/2020	0.00	0.00	0.0	0.00	0.00
12/09/2020	0.00	0.00	0.0	0.00	0.00
12/10/2020	0.00	0.00	0.0	0.00	0.00
12/11/2020	0.00	0.00	0.0	0.00	0.00
12/12/2020	0.00	0.00	0.0	0.00	0.00
12/13/2020	0.00	0.00	0.0	0.00	0.00
12/14/2020	0.00	0.00	0.0	0.00	0.00
12/15/2020	0.00	0.00	0.0	0.00	0.00
12/16/2020	0.00	0.00	0.0	0.00	0.00
12/17/2020	0.00	0.00	0.0	0.00	0.00
12/18/2020	0.00	0.00	0.0	0.00	0.00
12/19/2020	0.00	0.00	0.0	0.00	0.00
12/20/2020	0.00	0.00	0.0	0.00	0.00
12/21/2020	0.00	0.00	0.0	0.00	0.00
12/22/2020	53.69	22.57	0.6	1.20	2.00
12/23/2020	0.00	0.00	0.0	0.00	0.00
12/24/2020	0.00	0.00	0.0	0.00	0.00
12/25/2020	0.00	0.00	0.0	0.00	0.00
12/26/2020	0.00	0.00	0.0	0.00	0.00
12/27/2020	0.00	0.00	0.0	0.00	0.00
12/28/2020	0.00	0.00	0.0	0.00	0.00
12/29/2020	0.00	0.00	0.0	0.00	0.00
12/30/2020	0.00	0.00	0.0	0.00	0.00
12/31/2020	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	53.69 *	22.57 *	0.6 *	1.20 *	2.00 *
Daily Min:	53.69	22.57	0.6	1.20	2.00
Daily Max:	53.69	22.57	0.6	1.20	2.00
Oct 2020 - Dec 2020	1,263.00	3,179.10	299.7	605.11	1,008.81
QTD:	1,263.00 *	3,179.10 *	299.7 *	605.11 *	1,008.81 *
YTD 2020:	2,883.01 *	8,880.26 *	845.3 *	1,676.38 *	2,793.55 *

AQ-60

AQ-60 If the Alstom GTX100 turbine are selected, the quarterly emissions shall not exceed the levels shown below:

Alstom GTX100 Gas Turbines					
Pollutant	Quarter 1 (lbs/quarter) Two turbines	Quarter 2 (lbs/quarter) Two Turbines	Quarter 3 (lbs/quarter) Two turbines	Quarter 4 (lbs/quarter) Two Turbines	Tons/ Year Two Turbines
NOx	15,399	12,965	17,496	15,422	30.64
CO	26,787	32,590	28,175	29,862	58.71
VOCs	5,791	7,306	6,630	6,848	13.29
PM10	16,300	13,692	17,789	17,569	32.67
SOx	3,385	2,843	3,694	3,648	6.78

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emission limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 12:18 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
10/01/2020	32.04	128.83	12.37	24.70	41.20
10/02/2020	37.70	110.80	10.63	21.24	35.40
10/03/2020	37.26	113.45	10.83	21.71	36.17
10/04/2020	31.54	126.61	12.04	24.11	40.18
10/05/2020	29.96	129.77	12.47	24.89	41.48
10/06/2020	29.58	126.33	12.11	24.21	40.36
10/07/2020	36.16	123.04	11.69	23.44	39.02
10/08/2020	26.60	72.18	6.85	13.71	22.80
10/09/2020	18.68	64.29	6.12	12.24	20.43
10/10/2020	37.04	63.33	5.09	10.18	17.03
10/11/2020	14.62	58.73	5.62	11.24	18.76
10/12/2020	18.41	64.20	6.16	12.27	20.48
10/13/2020	37.78	108.80	10.71	21.47	35.71
10/14/2020	28.78	124.11	11.86	23.70	39.52
10/15/2020	41.98	108.68	10.11	20.24	33.73
10/16/2020	29.49	123.57	11.89	23.74	39.62
10/17/2020	31.44	119.97	11.44	22.86	38.07
10/18/2020	37.04	115.83	11.09	22.22	37.04
10/19/2020	37.58	119.41	11.81	23.59	39.37
10/20/2020	33.39	122.46	11.68	23.32	38.87
10/21/2020	33.46	103.89	9.96	19.90	33.10
10/22/2020	35.35	110.14	10.66	21.30	35.41
10/23/2020	45.98	105.28	10.02	20.03	33.31
10/24/2020	19.31	58.09	5.58	11.12	18.57
10/25/2020	22.17	63.02	6.00	11.97	19.95
10/26/2020	18.74	70.73	6.73	13.43	22.38
10/27/2020	25.70	59.82	5.72	11.44	19.03
10/28/2020	29.48	59.42	5.61	11.29	18.79
10/29/2020	28.36	61.90	5.90	11.78	19.69
10/30/2020	28.36	63.68	6.02	12.02	20.07
10/31/2020	26.13	58.71	5.71	11.41	19.04
Monthly Avg/Sum*:	940.11 *	2,939.07 *	280.48 *	560.77 *	934.58 *
Daily Min:	14.62	58.09	5.09	10.18	17.03
Daily Max:	45.98	129.77	12.47	24.89	41.48
Oct 2020 - Oct 2020	940.11	2,939.07	280.48	560.77	934.58
QTD:	940.11 *	2,939.07 *	280.48 *	560.77 *	934.58 *
YTD 2020:	4,136.69 *	13,982.18 *	1,319.05 *	2,638.18 *	4,395.42 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 12:18 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
11/01/2020	22.05	59.02	5.65	11.24	18.74
11/02/2020	25.02	68.39	6.52	13.03	21.72
11/03/2020	22.06	69.00	6.59	13.16	21.95
11/04/2020	25.74	58.94	5.63	11.25	18.79
11/05/2020	23.48	57.64	5.79	11.48	19.19
11/06/2020	22.66	53.49	5.21	10.42	17.32
11/07/2020	24.13	54.36	5.20	10.33	17.25
11/08/2020	25.80	53.58	5.10	10.24	17.12
11/09/2020	30.19	57.78	5.50	11.01	18.36
11/10/2020	27.77	59.60	5.71	11.42	19.04
11/11/2020	26.25	55.03	5.28	10.58	17.63
11/12/2020	26.64	54.55	5.19	10.38	17.29
11/13/2020	29.66	57.27	5.49	10.95	18.30
11/14/2020	26.10	55.72	5.30	10.64	17.73
11/15/2020	29.68	58.41	5.54	11.13	18.54
11/16/2020	33.26	58.52	5.55	11.10	18.49
11/17/2020	24.10	55.50	5.32	10.62	17.72
11/18/2020	19.38	56.27	5.41	10.79	18.00
11/19/2020	16.49	55.86	5.32	10.69	17.82
11/20/2020	26.00	59.46	5.63	11.29	18.82
11/21/2020	21.74	58.98	5.60	11.29	18.75
11/22/2020	23.55	60.68	5.74	11.54	19.21
11/23/2020	25.27	56.90	5.46	10.92	18.17
11/24/2020	26.87	57.33	5.50	11.00	18.33
11/25/2020	18.50	58.11	5.49	11.00	18.35
11/26/2020	15.65	0.61	0.00	0.01	0.02
11/27/2020	0.00	0.00	0.00	0.00	0.00
11/28/2020	0.00	0.00	0.00	0.00	0.00
11/29/2020	0.00	0.00	0.00	0.00	0.00
11/30/2020	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	638.04 *	1,451.00 *	138.72 *	277.51 *	462.65 *
Daily Min:	15.65	0.61	0.00	0.01	0.02
Daily Max:	33.26	69.00	6.59	13.16	21.95
Oct 2020 - Nov 2020	1,578.15	4,390.07	419.20	838.28	1,397.23
QTD:	1,578.15 *	4,390.07 *	419.20 *	838.28 *	1,397.23 *
YTD 2020:	4,774.73 *	15,433.18 *	1,457.77 *	2,915.69 *	4,858.07 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 12:18 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
12/01/2020	0.00	0.00	0.00	0.00	0.00
12/02/2020	0.00	0.00	0.00	0.00	0.00
12/03/2020	0.00	0.00	0.00	0.00	0.00
12/04/2020	0.00	0.00	0.00	0.00	0.00
12/05/2020	0.00	0.00	0.00	0.00	0.00
12/06/2020	0.00	0.00	0.00	0.00	0.00
12/07/2020	0.00	0.00	0.00	0.00	0.00
12/08/2020	0.00	0.00	0.00	0.00	0.00
12/09/2020	0.00	0.00	0.00	0.00	0.00
12/10/2020	0.00	0.00	0.00	0.00	0.00
12/11/2020	0.00	0.00	0.00	0.00	0.00
12/12/2020	0.00	0.00	0.00	0.00	0.00
12/13/2020	0.00	0.00	0.00	0.00	0.00
12/14/2020	0.00	0.00	0.00	0.00	0.00
12/15/2020	0.00	0.00	0.00	0.00	0.00
12/16/2020	0.00	0.00	0.00	0.00	0.00
12/17/2020	0.00	0.00	0.00	0.00	0.00
12/18/2020	0.00	0.00	0.00	0.00	0.00
12/19/2020	0.00	0.00	0.00	0.00	0.00
12/20/2020	0.00	0.00	0.00	0.00	0.00
12/21/2020	0.00	0.00	0.00	0.00	0.00
12/22/2020	104.87	39.49	1.21	2.42	4.01
12/23/2020	0.00	0.00	0.00	0.00	0.00
12/24/2020	0.00	0.00	0.00	0.00	0.00
12/25/2020	0.00	0.00	0.00	0.00	0.00
12/26/2020	0.00	0.00	0.00	0.00	0.00
12/27/2020	0.00	0.00	0.00	0.00	0.00
12/28/2020	0.00	0.00	0.00	0.00	0.00
12/29/2020	0.00	0.00	0.00	0.00	0.00
12/30/2020	0.00	0.00	0.00	0.00	0.00
12/31/2020	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	104.87 *	39.49 *	1.21 *	2.42 *	4.01 *
Daily Min:	104.87	39.49	1.21	2.42	4.01
Daily Max:	104.87	39.49	1.21	2.42	4.01
Oct 2020 - Dec 2020	1,683.02	4,429.56	420.41	840.70	1,401.24
QTD:	1,683.02 *	4,429.56 *	420.41 *	840.70 *	1,401.24 *
YTD 2020:	4,879.60 *	15,472.67 *	1,458.98 *	2,918.11 *	4,862.08 *

Monthly Summary By Day Report

Unit CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:34 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
10/01/2020	14.27	65.16	6.4	12.48	20.82
10/02/2020	17.29	56.31	5.6	10.79	17.97
10/03/2020	17.03	57.75	5.6	11.00	18.32
10/04/2020	13.90	63.87	6.2	12.20	20.32
10/05/2020	13.31	65.65	6.6	12.63	21.06
10/06/2020	12.72	64.47	6.2	12.35	20.56
10/07/2020	16.45	62.48	6.3	11.90	19.82
10/08/2020	10.65	9.92	1.0	1.79	2.95
10/09/2020	0.00	0.00	0.0	0.00	0.00
10/10/2020	25.53	30.60	1.8	3.96	6.61
10/11/2020	14.62	58.73	5.3	11.24	18.76
10/12/2020	18.41	64.20	6.1	12.27	20.48
10/13/2020	16.38	69.47	6.9	13.45	22.39
10/14/2020	12.76	62.36	6.1	11.92	19.89
10/15/2020	27.55	42.95	3.8	7.58	12.60
10/16/2020	12.31	61.74	5.9	11.84	19.74
10/17/2020	13.37	60.23	5.6	11.48	19.14
10/18/2020	15.80	58.03	5.7	11.15	18.59
10/19/2020	16.29	58.36	6.0	11.90	19.85
10/20/2020	14.34	61.81	6.2	11.74	19.57
10/21/2020	14.84	52.09	5.0	10.03	16.66
10/22/2020	15.49	55.63	5.5	10.85	18.00
10/23/2020	25.75	51.73	5.0	9.82	16.32
10/24/2020	0.00	0.00	0.0	0.00	0.00
10/25/2020	0.00	0.00	0.0	0.00	0.00
10/26/2020	0.00	0.00	0.0	0.00	0.00
10/27/2020	0.00	0.00	0.0	0.00	0.00
10/28/2020	0.00	0.00	0.0	0.00	0.00
10/29/2020	0.00	0.00	0.0	0.00	0.00
10/30/2020	0.00	0.00	0.0	0.00	0.00
10/31/2020	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	359.06 *	1,233.54 *	118.8 *	234.37 *	390.42 *
Daily Min:	10.65	9.92	1.0	1.79	2.95
Daily Max:	27.55	69.47	6.9	13.45	22.39
Oct 2020 - Oct 2020	359.06	1,233.54	118.8	234.37	390.42
QTD:	359.06 *	1,233.54 *	118.8 *	234.37 *	390.42 *
YTD 2020:	1,925.87 *	6,574.43 *	632.0 *	1,240.51 *	2,066.52 *

Monthly Summary By Day Report

Unit CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:34 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
11/01/2020	0.00	0.00	0.0	0.00	0.00
11/02/2020	0.00	0.00	0.0	0.00	0.00
11/03/2020	0.00	0.00	0.0	0.00	0.00
11/04/2020	0.00	0.00	0.0	0.00	0.00
11/05/2020	0.00	0.00	0.0	0.00	0.00
11/06/2020	0.00	0.00	0.0	0.00	0.00
11/07/2020	0.00	0.00	0.0	0.00	0.00
11/08/2020	0.00	0.00	0.0	0.00	0.00
11/09/2020	0.00	0.00	0.0	0.00	0.00
11/10/2020	0.00	0.00	0.0	0.00	0.00
11/11/2020	0.00	0.00	0.0	0.00	0.00
11/12/2020	0.00	0.00	0.0	0.00	0.00
11/13/2020	0.00	0.00	0.0	0.00	0.00
11/14/2020	0.00	0.00	0.0	0.00	0.00
11/15/2020	0.00	0.00	0.0	0.00	0.00
11/16/2020	0.00	0.00	0.0	0.00	0.00
11/17/2020	0.00	0.00	0.0	0.00	0.00
11/18/2020	0.00	0.00	0.0	0.00	0.00
11/19/2020	0.00	0.00	0.0	0.00	0.00
11/20/2020	0.00	0.00	0.0	0.00	0.00
11/21/2020	0.00	0.00	0.0	0.00	0.00
11/22/2020	0.00	0.00	0.0	0.00	0.00
11/23/2020	0.00	0.00	0.0	0.00	0.00
11/24/2020	0.00	0.00	0.0	0.00	0.00
11/25/2020	0.00	0.00	0.0	0.00	0.00
11/26/2020	0.00	0.00	0.0	0.00	0.00
11/27/2020	0.00	0.00	0.0	0.00	0.00
11/28/2020	0.00	0.00	0.0	0.00	0.00
11/29/2020	0.00	0.00	0.0	0.00	0.00
11/30/2020	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	- *	- *	- *	- *	- *
Daily Min:	-	-	-	-	-
Daily Max:	-	-	-	-	-
Oct 2020 - Nov 2020	359.06	1,233.54	118.8	234.37	390.42
QTD:	359.06 *	1,233.54 *	118.8 *	234.37 *	390.42 *
YTD 2020:	1,925.87 *	6,574.43 *	632.0 *	1,240.51 *	2,066.52 *

Monthly Summary By Day Report

Unit CT1



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:34 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
12/01/2020	0.00	0.00	0.0	0.00	0.00
12/02/2020	0.00	0.00	0.0	0.00	0.00
12/03/2020	0.00	0.00	0.0	0.00	0.00
12/04/2020	0.00	0.00	0.0	0.00	0.00
12/05/2020	0.00	0.00	0.0	0.00	0.00
12/06/2020	0.00	0.00	0.0	0.00	0.00
12/07/2020	0.00	0.00	0.0	0.00	0.00
12/08/2020	0.00	0.00	0.0	0.00	0.00
12/09/2020	0.00	0.00	0.0	0.00	0.00
12/10/2020	0.00	0.00	0.0	0.00	0.00
12/11/2020	0.00	0.00	0.0	0.00	0.00
12/12/2020	0.00	0.00	0.0	0.00	0.00
12/13/2020	0.00	0.00	0.0	0.00	0.00
12/14/2020	0.00	0.00	0.0	0.00	0.00
12/15/2020	0.00	0.00	0.0	0.00	0.00
12/16/2020	0.00	0.00	0.0	0.00	0.00
12/17/2020	0.00	0.00	0.0	0.00	0.00
12/18/2020	0.00	0.00	0.0	0.00	0.00
12/19/2020	0.00	0.00	0.0	0.00	0.00
12/20/2020	0.00	0.00	0.0	0.00	0.00
12/21/2020	0.00	0.00	0.0	0.00	0.00
12/22/2020	51.18	16.92	0.6	1.22	2.01
12/23/2020	0.00	0.00	0.0	0.00	0.00
12/24/2020	0.00	0.00	0.0	0.00	0.00
12/25/2020	0.00	0.00	0.0	0.00	0.00
12/26/2020	0.00	0.00	0.0	0.00	0.00
12/27/2020	0.00	0.00	0.0	0.00	0.00
12/28/2020	0.00	0.00	0.0	0.00	0.00
12/29/2020	0.00	0.00	0.0	0.00	0.00
12/30/2020	0.00	0.00	0.0	0.00	0.00
12/31/2020	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	51.18 *	16.92 *	0.6 *	1.22 *	2.01 *
Daily Min:	51.18	16.92	0.6	1.22	2.01
Daily Max:	51.18	16.92	0.6	1.22	2.01
Oct 2020 - Dec 2020	410.24	1,250.46	119.4	235.59	392.43
QTD:	410.24 *	1,250.46 *	119.4 *	235.59 *	392.43 *
YTD 2020:	1,977.05 *	6,591.35 *	632.6 *	1,241.73 *	2,068.53 *

Monthly Summary By Day Report

Unit CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:33 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
10/01/2020	17.77	63.67	6.1	12.22	20.38
10/02/2020	20.41	54.49	5.3	10.45	17.43
10/03/2020	20.23	55.70	5.4	10.71	17.85
10/04/2020	17.64	62.74	5.8	11.91	19.86
10/05/2020	16.65	64.12	6.2	12.26	20.42
10/06/2020	16.86	61.86	5.8	11.86	19.80
10/07/2020	19.71	60.56	6.0	11.54	19.20
10/08/2020	15.95	62.26	5.9	11.92	19.85
10/09/2020	18.68	64.29	5.9	12.24	20.43
10/10/2020	11.51	32.73	3.2	6.22	10.42
10/11/2020	0.00	0.00	0.0	0.00	0.00
10/12/2020	0.00	0.00	0.0	0.00	0.00
10/13/2020	11.62	39.33	4.2	8.02	13.32
10/14/2020	16.02	61.75	5.9	11.78	19.63
10/15/2020	14.43	65.73	6.2	12.66	21.13
10/16/2020	17.18	61.83	5.9	11.90	19.88
10/17/2020	18.07	59.74	5.5	11.38	18.93
10/18/2020	21.24	57.80	5.5	11.07	18.45
10/19/2020	21.29	61.05	5.9	11.69	19.52
10/20/2020	19.05	60.65	5.7	11.58	19.30
10/21/2020	18.62	51.80	5.0	9.87	16.44
10/22/2020	19.86	54.51	5.0	10.45	17.41
10/23/2020	20.23	53.55	5.1	10.21	16.99
10/24/2020	19.31	58.09	5.4	11.12	18.57
10/25/2020	22.17	63.02	5.9	11.97	19.95
10/26/2020	18.74	70.73	6.9	13.43	22.38
10/27/2020	25.70	59.82	5.5	11.44	19.03
10/28/2020	29.48	59.42	5.7	11.29	18.79
10/29/2020	28.36	61.90	5.9	11.78	19.69
10/30/2020	28.36	63.68	5.8	12.02	20.07
10/31/2020	26.13	58.71	5.3	11.41	19.04
Monthly Avg/Sum*:	571.27 *	1,705.53 *	161.9 *	326.40 *	544.16 *
Daily Min:	0.00	0.00	0.0	0.00	0.00
Daily Max:	29.48	70.73	6.9	13.43	22.38
Oct 2020 - Oct 2020	571.27	1,705.53	161.9	326.40	544.16
QTD:	571.27 *	1,705.53 *	161.9 *	326.40 *	544.16 *
YTD 2020:	2,191.28 *	7,406.69 *	707.5 *	1,397.67 *	2,328.90 *

Monthly Summary By Day Report

Unit CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:33 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
11/01/2020	22.05	59.02	5.8	11.24	18.74
11/02/2020	25.02	68.39	6.7	13.03	21.72
11/03/2020	22.06	69.00	6.5	13.16	21.95
11/04/2020	25.74	58.94	5.8	11.25	18.79
11/05/2020	23.48	57.64	5.7	11.48	19.19
11/06/2020	22.66	53.49	4.9	10.42	17.32
11/07/2020	24.13	54.36	5.0	10.33	17.25
11/08/2020	25.80	53.58	5.0	10.24	17.12
11/09/2020	30.19	57.78	5.6	11.01	18.36
11/10/2020	27.77	59.60	5.4	11.42	19.04
11/11/2020	26.25	55.03	4.9	10.58	17.63
11/12/2020	26.64	54.55	5.1	10.38	17.29
11/13/2020	29.66	57.27	5.7	10.95	18.30
11/14/2020	26.10	55.72	5.3	10.64	17.73
11/15/2020	29.68	58.41	5.5	11.13	18.54
11/16/2020	33.26	58.52	6.0	11.10	18.49
11/17/2020	24.10	55.50	5.3	10.62	17.72
11/18/2020	19.38	56.27	5.3	10.79	18.00
11/19/2020	16.49	55.86	5.1	10.69	17.82
11/20/2020	26.00	59.46	5.6	11.29	18.82
11/21/2020	21.74	58.98	5.2	11.29	18.75
11/22/2020	23.55	60.68	6.1	11.54	19.21
11/23/2020	25.27	56.90	5.1	10.92	18.17
11/24/2020	26.87	57.33	5.4	11.00	18.33
11/25/2020	18.50	58.11	5.2	11.00	18.35
11/26/2020	15.65	0.61	0.0	0.01	0.02
11/27/2020	0.00	0.00	0.0	0.00	0.00
11/28/2020	0.00	0.00	0.0	0.00	0.00
11/29/2020	0.00	0.00	0.0	0.00	0.00
11/30/2020	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	638.04 *	1,451.00 *	137.2 *	277.51 *	462.65 *
Daily Min:	15.65	0.61	0.0	0.01	0.02
Daily Max:	33.26	69.00	6.7	13.16	21.95
Oct 2020 - Nov 2020	1,209.31	3,156.53	299.1	603.91	1,006.81
QTD:	1,209.31 *	3,156.53 *	299.1 *	603.91 *	1,006.81 *
YTD 2020:	2,829.32 *	8,857.69 *	844.7 *	1,675.18 *	2,791.55 *

Monthly Summary By Day Report

Unit CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:33 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
12/01/2020	0.00	0.00	0.0	0.00	0.00
12/02/2020	0.00	0.00	0.0	0.00	0.00
12/03/2020	0.00	0.00	0.0	0.00	0.00
12/04/2020	0.00	0.00	0.0	0.00	0.00
12/05/2020	0.00	0.00	0.0	0.00	0.00
12/06/2020	0.00	0.00	0.0	0.00	0.00
12/07/2020	0.00	0.00	0.0	0.00	0.00
12/08/2020	0.00	0.00	0.0	0.00	0.00
12/09/2020	0.00	0.00	0.0	0.00	0.00
12/10/2020	0.00	0.00	0.0	0.00	0.00
12/11/2020	0.00	0.00	0.0	0.00	0.00
12/12/2020	0.00	0.00	0.0	0.00	0.00
12/13/2020	0.00	0.00	0.0	0.00	0.00
12/14/2020	0.00	0.00	0.0	0.00	0.00
12/15/2020	0.00	0.00	0.0	0.00	0.00
12/16/2020	0.00	0.00	0.0	0.00	0.00
12/17/2020	0.00	0.00	0.0	0.00	0.00
12/18/2020	0.00	0.00	0.0	0.00	0.00
12/19/2020	0.00	0.00	0.0	0.00	0.00
12/20/2020	0.00	0.00	0.0	0.00	0.00
12/21/2020	0.00	0.00	0.0	0.00	0.00
12/22/2020	53.69	22.57	0.6	1.20	2.00
12/23/2020	0.00	0.00	0.0	0.00	0.00
12/24/2020	0.00	0.00	0.0	0.00	0.00
12/25/2020	0.00	0.00	0.0	0.00	0.00
12/26/2020	0.00	0.00	0.0	0.00	0.00
12/27/2020	0.00	0.00	0.0	0.00	0.00
12/28/2020	0.00	0.00	0.0	0.00	0.00
12/29/2020	0.00	0.00	0.0	0.00	0.00
12/30/2020	0.00	0.00	0.0	0.00	0.00
12/31/2020	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	53.69 *	22.57 *	0.6 *	1.20 *	2.00 *
Daily Min:	53.69	22.57	0.6	1.20	2.00
Daily Max:	53.69	22.57	0.6	1.20	2.00
Oct 2020 - Dec 2020	1,263.00	3,179.10	299.7	605.11	1,008.81
QTD:	1,263.00 *	3,179.10 *	299.7 *	605.11 *	1,008.81 *
YTD 2020:	2,883.01 *	8,880.26 *	845.3 *	1,676.38 *	2,793.55 *

AQ-63

AQ-63 The Total Facility Emissions shall not exceed the following quarterly emissions rates.

POLLUTANT	Q1 (LBS)	Q2 (LBS)	Q3 (LBS)	Q4 (LBS)	TONS/YEAR
NOX	15546	13412	17646	15572	31.09
CO	27121	33872	28515	30202	59.86
VOC	5832	7455	6672	6890	13.42
PM-10	17854	15513	19378	19158	35.95
SO2	3400	2893	3709	3663	6.83

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6

Replace the dates with the ones you need

10/1/2020 0:00
12/31/2020 0:00

1D

TOWER AVG.

519-AIT-9504-1

2963

10/1/20 0:00	3415.8
10/2/20 0:00	3395.2
10/3/20 0:00	3956.8
10/4/20 0:00	2843.8
10/5/20 0:00	3152.5
10/6/20 0:00	3359.1
10/7/20 0:00	4334.7
10/8/20 0:00	4317.0
10/9/20 0:00	3643.3
10/10/20 0:00	4564.3
10/11/20 0:00	4039.4
10/12/20 0:00	3925.1
10/13/20 0:00	4211.7
10/14/20 0:00	3950.6
10/15/20 0:00	4277.8
10/16/20 0:00	4468.9
10/17/20 0:00	4609.0
10/18/20 0:00	4481.9
10/19/20 0:00	4710.0
10/20/20 0:00	5145.4
10/21/20 0:00	4963.4
10/22/20 0:00	4583.3
10/23/20 0:00	4540.0
10/24/20 0:00	4330.9
10/25/20 0:00	4324.9
10/26/20 0:00	4339.2
10/27/20 0:00	4038.0
10/28/20 0:00	4401.5
10/29/20 0:00	3842.5
10/30/20 0:00	4107.8
10/31/20 0:00	3645.7
11/1/20 0:00	4602.0
11/2/20 0:00	4213.1
11/3/20 0:00	4238.0
11/4/20 0:00	3606.8
11/5/20 0:00	3802.6
11/6/20 0:00	3626.7
11/7/20 0:00	3362.5
11/8/20 0:00	3084.0
11/9/20 0:00	2927.6
11/10/20 0:00	2948.7
11/11/20 0:00	3500.9
11/12/20 0:00	3491.0
11/13/20 0:00	3414.4
11/14/20 0:00	3543.9
11/15/20 0:00	3336.2
11/16/20 0:00	3824.7
11/17/20 0:00	3268.1
11/18/20 0:00	3215.4

11/19/20 0:00	3540.2
11/20/20 0:00	3028.7
11/21/20 0:00	3309.5
11/22/20 0:00	3024.8
11/23/20 0:00	3146.2
11/24/20 0:00	3418.3
11/25/20 0:00	3848.2
11/26/20 0:00	3960.0
11/27/20 0:00	2504.8
11/28/20 0:00	2324.4
11/29/20 0:00	2104.4
11/30/20 0:00	1967.3
12/1/20 0:00	1911.8
12/2/20 0:00	1885.6
12/3/20 0:00	1881.0
12/4/20 0:00	1873.4
12/5/20 0:00	1861.3
12/6/20 0:00	1708.2
12/7/20 0:00	1389.2
12/8/20 0:00	I/O Timeout
12/9/20 0:00	I/O Timeout
12/10/20 0:00	Shutdown
12/11/20 0:00	I/O Timeout
12/12/20 0:00	1303.8
12/13/20 0:00	1296.1
12/14/20 0:00	1110.8
12/15/20 0:00	918.5
12/16/20 0:00	813.6
12/17/20 0:00	705.0
12/18/20 0:00	714.4
12/19/20 0:00	697.9
12/20/20 0:00	720.0
12/21/20 0:00	769.4
12/22/20 0:00	635.8
12/23/20 0:00	812.4
12/24/20 0:00	626.9
12/25/20 0:00	613.7
12/26/20 0:00	623.0
12/27/20 0:00	633.2
12/28/20 0:00	623.5
12/29/20 0:00	624.6

Resize to show allsize to show all values

ROSEVILLE ENERGY PARK COOLING TOWER EMISSIONS

POLLUTANT	LBS PER DAY	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4
PM-10	16.3	1471	1487	1504	1504

Whereas compliance with the PM-10 emission limit shall be demonstrated as;
Cooling tower recirculation rate * total dissolved solids of blowdown * design drift rate

<u>Circ pump flow rate</u>	53814	Gallons per minute
	* 8.33	Pounds per gallon
	* 1440	Minutes per day
	64,550,969	Pounds per day

<u>Total dissolved solids</u>	2963	Average daily conductivity umhos
	0.00000064	Conversion to TDS ppm
	0.00189632	

<u>Design drift rate</u>	0.005%
--------------------------	---------------

PM-10 pounds per day	6.12
----------------------	-------------

92	Days in quarter
----	-----------------

PM-10 pounds this quarter	563	4Q20
---------------------------	------------	-------------

fill only these

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 12:18 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
10/01/2020	32.04	128.83	12.37	24.70	41.20
10/02/2020	37.70	110.80	10.63	21.24	35.40
10/03/2020	37.26	113.45	10.83	21.71	36.17
10/04/2020	31.54	126.61	12.04	24.11	40.18
10/05/2020	29.96	129.77	12.47	24.89	41.48
10/06/2020	29.58	126.33	12.11	24.21	40.36
10/07/2020	36.16	123.04	11.69	23.44	39.02
10/08/2020	26.60	72.18	6.85	13.71	22.80
10/09/2020	18.68	64.29	6.12	12.24	20.43
10/10/2020	37.04	63.33	5.09	10.18	17.03
10/11/2020	14.62	58.73	5.62	11.24	18.76
10/12/2020	18.41	64.20	6.16	12.27	20.48
10/13/2020	37.78	108.80	10.71	21.47	35.71
10/14/2020	28.78	124.11	11.86	23.70	39.52
10/15/2020	41.98	108.68	10.11	20.24	33.73
10/16/2020	29.49	123.57	11.89	23.74	39.62
10/17/2020	31.44	119.97	11.44	22.86	38.07
10/18/2020	37.04	115.83	11.09	22.22	37.04
10/19/2020	37.58	119.41	11.81	23.59	39.37
10/20/2020	33.39	122.46	11.68	23.32	38.87
10/21/2020	33.46	103.89	9.96	19.90	33.10
10/22/2020	35.35	110.14	10.66	21.30	35.41
10/23/2020	45.98	105.28	10.02	20.03	33.31
10/24/2020	19.31	58.09	5.58	11.12	18.57
10/25/2020	22.17	63.02	6.00	11.97	19.95
10/26/2020	18.74	70.73	6.73	13.43	22.38
10/27/2020	25.70	59.82	5.72	11.44	19.03
10/28/2020	29.48	59.42	5.61	11.29	18.79
10/29/2020	28.36	61.90	5.90	11.78	19.69
10/30/2020	28.36	63.68	6.02	12.02	20.07
10/31/2020	26.13	58.71	5.71	11.41	19.04
Monthly Avg/Sum*:	940.11 *	2,939.07 *	280.48 *	560.77 *	934.58 *
Daily Min:	14.62	58.09	5.09	10.18	17.03
Daily Max:	45.98	129.77	12.47	24.89	41.48
Oct 2020 - Oct 2020	940.11	2,939.07	280.48	560.77	934.58
QTD:	940.11 *	2,939.07 *	280.48 *	560.77 *	934.58 *
YTD 2020:	4,136.69 *	13,982.18 *	1,319.05 *	2,638.18 *	4,395.42 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 12:18 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
11/01/2020	22.05	59.02	5.65	11.24	18.74
11/02/2020	25.02	68.39	6.52	13.03	21.72
11/03/2020	22.06	69.00	6.59	13.16	21.95
11/04/2020	25.74	58.94	5.63	11.25	18.79
11/05/2020	23.48	57.64	5.79	11.48	19.19
11/06/2020	22.66	53.49	5.21	10.42	17.32
11/07/2020	24.13	54.36	5.20	10.33	17.25
11/08/2020	25.80	53.58	5.10	10.24	17.12
11/09/2020	30.19	57.78	5.50	11.01	18.36
11/10/2020	27.77	59.60	5.71	11.42	19.04
11/11/2020	26.25	55.03	5.28	10.58	17.63
11/12/2020	26.64	54.55	5.19	10.38	17.29
11/13/2020	29.66	57.27	5.49	10.95	18.30
11/14/2020	26.10	55.72	5.30	10.64	17.73
11/15/2020	29.68	58.41	5.54	11.13	18.54
11/16/2020	33.26	58.52	5.55	11.10	18.49
11/17/2020	24.10	55.50	5.32	10.62	17.72
11/18/2020	19.38	56.27	5.41	10.79	18.00
11/19/2020	16.49	55.86	5.32	10.69	17.82
11/20/2020	26.00	59.46	5.63	11.29	18.82
11/21/2020	21.74	58.98	5.60	11.29	18.75
11/22/2020	23.55	60.68	5.74	11.54	19.21
11/23/2020	25.27	56.90	5.46	10.92	18.17
11/24/2020	26.87	57.33	5.50	11.00	18.33
11/25/2020	18.50	58.11	5.49	11.00	18.35
11/26/2020	15.65	0.61	0.00	0.01	0.02
11/27/2020	0.00	0.00	0.00	0.00	0.00
11/28/2020	0.00	0.00	0.00	0.00	0.00
11/29/2020	0.00	0.00	0.00	0.00	0.00
11/30/2020	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	638.04 *	1,451.00 *	138.72 *	277.51 *	462.65 *
Daily Min:	15.65	0.61	0.00	0.01	0.02
Daily Max:	33.26	69.00	6.59	13.16	21.95
Oct 2020 - Nov 2020	1,578.15	4,390.07	419.20	838.28	1,397.23
QTD:	1,578.15 *	4,390.07 *	419.20 *	838.28 *	1,397.23 *
YTD 2020:	4,774.73 *	15,433.18 *	1,457.77 *	2,915.69 *	4,858.07 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 12:18 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
12/01/2020	0.00	0.00	0.00	0.00	0.00
12/02/2020	0.00	0.00	0.00	0.00	0.00
12/03/2020	0.00	0.00	0.00	0.00	0.00
12/04/2020	0.00	0.00	0.00	0.00	0.00
12/05/2020	0.00	0.00	0.00	0.00	0.00
12/06/2020	0.00	0.00	0.00	0.00	0.00
12/07/2020	0.00	0.00	0.00	0.00	0.00
12/08/2020	0.00	0.00	0.00	0.00	0.00
12/09/2020	0.00	0.00	0.00	0.00	0.00
12/10/2020	0.00	0.00	0.00	0.00	0.00
12/11/2020	0.00	0.00	0.00	0.00	0.00
12/12/2020	0.00	0.00	0.00	0.00	0.00
12/13/2020	0.00	0.00	0.00	0.00	0.00
12/14/2020	0.00	0.00	0.00	0.00	0.00
12/15/2020	0.00	0.00	0.00	0.00	0.00
12/16/2020	0.00	0.00	0.00	0.00	0.00
12/17/2020	0.00	0.00	0.00	0.00	0.00
12/18/2020	0.00	0.00	0.00	0.00	0.00
12/19/2020	0.00	0.00	0.00	0.00	0.00
12/20/2020	0.00	0.00	0.00	0.00	0.00
12/21/2020	0.00	0.00	0.00	0.00	0.00
12/22/2020	104.87	39.49	1.21	2.42	4.01
12/23/2020	0.00	0.00	0.00	0.00	0.00
12/24/2020	0.00	0.00	0.00	0.00	0.00
12/25/2020	0.00	0.00	0.00	0.00	0.00
12/26/2020	0.00	0.00	0.00	0.00	0.00
12/27/2020	0.00	0.00	0.00	0.00	0.00
12/28/2020	0.00	0.00	0.00	0.00	0.00
12/29/2020	0.00	0.00	0.00	0.00	0.00
12/30/2020	0.00	0.00	0.00	0.00	0.00
12/31/2020	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	104.87 *	39.49 *	1.21 *	2.42 *	4.01 *
Daily Min:	104.87	39.49	1.21	2.42	4.01
Daily Max:	104.87	39.49	1.21	2.42	4.01
Oct 2020 - Dec 2020	1,683.02	4,429.56	420.41	840.70	1,401.24
QTD:	1,683.02 *	4,429.56 *	420.41 *	840.70 *	1,401.24 *
YTD 2020:	4,879.60 *	15,472.67 *	1,458.98 *	2,918.11 *	4,862.08 *

Tons 12 Month Rolling Summary

CT1 and CT2 Combined



From: 10/01/2020 00:00 To: 12/31/2020 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/05/2021 16:17 Location: Roseville, CA

* = Excess Emission

Date	Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2	
	CO, Ton		NOx, Ton		PM10, Ton		SO2, Ton		VOC, Ton	
	1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)	
	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum
Oct 2020	0.4702	2.7037	1.4695	8.2453	0.2805	1.5473	0.1402	0.7736	0.4673	2.5777
Nov 2020	0.3189	2.4722	0.7256	7.9558	0.1387	1.5036	0.0696	0.7521	0.2316	2.5050
Dec 2020	0.0524	2.4405	0.0197	7.7366	0.0012	1.4593	0.0006	0.7300	0.0020	2.4312
Sum/Avg	2.4405		7.7366		1.4593		0.7300		2.4312	
Limit Value										

AQ68

AQ68 A water sample analysis of cooling tower water shall be performed within 180 days of initial operation and annually thereafter.

Verification: The Project owner shall submit to the CPM and the PCAPCD the initial and annual cooling tower water sample analysis for approval no later than 60 days following the date of test performance.

The Cooling Tower Water Analysis was reported with the 1Q20 QAQR.

AQ-69

AQ-69 No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

In regards to AQ-69 of Roseville Energy Park's 4Q20 QAQR, there were no violations of PCAPCD's Rule 205 for nuisance.

AQ-70

AQ-70 PM-10 emission rates from the cooling tower shall not exceed the following limits

Cooling Tower Emissions Limitations					
Pollutant	Lbs/day	Quarter 1	Quarter 2	Quarter 3	Quarter 4
PM 10	16.3	1471	1487	1504	1504

Verification: the Project owner shall include all the necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly air Quality Report required in condition of Certification AQ-SC6.

Replace the dates with the ones you need

10/1/2020 0:00
12/31/2020 0:00

1D

TOWER AVG.

519-AIT-9504-1

2963

10/1/20 0:00	3415.8
10/2/20 0:00	3395.2
10/3/20 0:00	3956.8
10/4/20 0:00	2843.8
10/5/20 0:00	3152.5
10/6/20 0:00	3359.1
10/7/20 0:00	4334.7
10/8/20 0:00	4317.0
10/9/20 0:00	3643.3
10/10/20 0:00	4564.3
10/11/20 0:00	4039.4
10/12/20 0:00	3925.1
10/13/20 0:00	4211.7
10/14/20 0:00	3950.6
10/15/20 0:00	4277.8
10/16/20 0:00	4468.9
10/17/20 0:00	4609.0
10/18/20 0:00	4481.9
10/19/20 0:00	4710.0
10/20/20 0:00	5145.4
10/21/20 0:00	4963.4
10/22/20 0:00	4583.3
10/23/20 0:00	4540.0
10/24/20 0:00	4330.9
10/25/20 0:00	4324.9
10/26/20 0:00	4339.2
10/27/20 0:00	4038.0
10/28/20 0:00	4401.5
10/29/20 0:00	3842.5
10/30/20 0:00	4107.8
10/31/20 0:00	3645.7
11/1/20 0:00	4602.0
11/2/20 0:00	4213.1
11/3/20 0:00	4238.0
11/4/20 0:00	3606.8
11/5/20 0:00	3802.6
11/6/20 0:00	3626.7
11/7/20 0:00	3362.5
11/8/20 0:00	3084.0
11/9/20 0:00	2927.6
11/10/20 0:00	2948.7
11/11/20 0:00	3500.9
11/12/20 0:00	3491.0
11/13/20 0:00	3414.4
11/14/20 0:00	3543.9
11/15/20 0:00	3336.2
11/16/20 0:00	3824.7
11/17/20 0:00	3268.1
11/18/20 0:00	3215.4

11/19/20 0:00	3540.2
11/20/20 0:00	3028.7
11/21/20 0:00	3309.5
11/22/20 0:00	3024.8
11/23/20 0:00	3146.2
11/24/20 0:00	3418.3
11/25/20 0:00	3848.2
11/26/20 0:00	3960.0
11/27/20 0:00	2504.8
11/28/20 0:00	2324.4
11/29/20 0:00	2104.4
11/30/20 0:00	1967.3
12/1/20 0:00	1911.8
12/2/20 0:00	1885.6
12/3/20 0:00	1881.0
12/4/20 0:00	1873.4
12/5/20 0:00	1861.3
12/6/20 0:00	1708.2
12/7/20 0:00	1389.2
12/8/20 0:00	I/O Timeout
12/9/20 0:00	I/O Timeout
12/10/20 0:00	Shutdown
12/11/20 0:00	I/O Timeout
12/12/20 0:00	1303.8
12/13/20 0:00	1296.1
12/14/20 0:00	1110.8
12/15/20 0:00	918.5
12/16/20 0:00	813.6
12/17/20 0:00	705.0
12/18/20 0:00	714.4
12/19/20 0:00	697.9
12/20/20 0:00	720.0
12/21/20 0:00	769.4
12/22/20 0:00	635.8
12/23/20 0:00	812.4
12/24/20 0:00	626.9
12/25/20 0:00	613.7
12/26/20 0:00	623.0
12/27/20 0:00	633.2
12/28/20 0:00	623.5
12/29/20 0:00	624.6

Resize to show all values

ROSEVILLE ENERGY PARK COOLING TOWER EMISSIONS

POLLUTANT	LBS PER DAY	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4
PM-10	16.3	1471	1487	1504	1504

Whereas compliance with the PM-10 emission limit shall be demonstrated as;
Cooling tower recirculation rate * total dissolved solids of blowdown * design drift rate

<u>Circ pump flow rate</u>	53814	Gallons per minute
	* 8.33	Pounds per gallon
	* 1440	Minutes per day
	64,550,969	Pounds per day

<u>Total dissolved solids</u>	2963	Average daily conductivity umhos
	0.00000064	Conversion to TDS ppm
	0.00189632	

<u>Design drift rate</u>	0.005%
--------------------------	---------------

PM-10 pounds per day	6.12
----------------------	-------------

92	Days in quarter
----	-----------------

PM-10 pounds this quarter	563	4Q20
---------------------------	------------	-------------

fill only these

AQ-71

AQ-71 Compliance with the cooling tower PM-10 emission limit shall be demonstrated as follows: $\text{PM-10} = \text{cooling water recirculation rate} * \text{total dissolved solids concentration in the blow down water} * \text{design drift rate}$.

Verification: the Project owner shall include all the necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly air Quality Report required in condition of Certification AQ-SC6.

Replace the dates with the ones you need

10/1/2020 0:00
12/31/2020 0:00

1D

TOWER AVG.

519-AIT-9504-1

2963

10/1/20 0:00	3415.8
10/2/20 0:00	3395.2
10/3/20 0:00	3956.8
10/4/20 0:00	2843.8
10/5/20 0:00	3152.5
10/6/20 0:00	3359.1
10/7/20 0:00	4334.7
10/8/20 0:00	4317.0
10/9/20 0:00	3643.3
10/10/20 0:00	4564.3
10/11/20 0:00	4039.4
10/12/20 0:00	3925.1
10/13/20 0:00	4211.7
10/14/20 0:00	3950.6
10/15/20 0:00	4277.8
10/16/20 0:00	4468.9
10/17/20 0:00	4609.0
10/18/20 0:00	4481.9
10/19/20 0:00	4710.0
10/20/20 0:00	5145.4
10/21/20 0:00	4963.4
10/22/20 0:00	4583.3
10/23/20 0:00	4540.0
10/24/20 0:00	4330.9
10/25/20 0:00	4324.9
10/26/20 0:00	4339.2
10/27/20 0:00	4038.0
10/28/20 0:00	4401.5
10/29/20 0:00	3842.5
10/30/20 0:00	4107.8
10/31/20 0:00	3645.7
11/1/20 0:00	4602.0
11/2/20 0:00	4213.1
11/3/20 0:00	4238.0
11/4/20 0:00	3606.8
11/5/20 0:00	3802.6
11/6/20 0:00	3626.7
11/7/20 0:00	3362.5
11/8/20 0:00	3084.0
11/9/20 0:00	2927.6
11/10/20 0:00	2948.7
11/11/20 0:00	3500.9
11/12/20 0:00	3491.0
11/13/20 0:00	3414.4
11/14/20 0:00	3543.9
11/15/20 0:00	3336.2
11/16/20 0:00	3824.7
11/17/20 0:00	3268.1
11/18/20 0:00	3215.4

11/19/20 0:00	3540.2
11/20/20 0:00	3028.7
11/21/20 0:00	3309.5
11/22/20 0:00	3024.8
11/23/20 0:00	3146.2
11/24/20 0:00	3418.3
11/25/20 0:00	3848.2
11/26/20 0:00	3960.0
11/27/20 0:00	2504.8
11/28/20 0:00	2324.4
11/29/20 0:00	2104.4
11/30/20 0:00	1967.3
12/1/20 0:00	1911.8
12/2/20 0:00	1885.6
12/3/20 0:00	1881.0
12/4/20 0:00	1873.4
12/5/20 0:00	1861.3
12/6/20 0:00	1708.2
12/7/20 0:00	1389.2
12/8/20 0:00	I/O Timeout
12/9/20 0:00	I/O Timeout
12/10/20 0:00	Shutdown
12/11/20 0:00	I/O Timeout
12/12/20 0:00	1303.8
12/13/20 0:00	1296.1
12/14/20 0:00	1110.8
12/15/20 0:00	918.5
12/16/20 0:00	813.6
12/17/20 0:00	705.0
12/18/20 0:00	714.4
12/19/20 0:00	697.9
12/20/20 0:00	720.0
12/21/20 0:00	769.4
12/22/20 0:00	635.8
12/23/20 0:00	812.4
12/24/20 0:00	626.9
12/25/20 0:00	613.7
12/26/20 0:00	623.0
12/27/20 0:00	633.2
12/28/20 0:00	623.5
12/29/20 0:00	624.6

Resize to show all values

ROSEVILLE ENERGY PARK COOLING TOWER EMISSIONS

POLLUTANT	LBS PER DAY	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4
PM-10	16.3	1471	1487	1504	1504

Whereas compliance with the PM-10 emission limit shall be demonstrated as;
Cooling tower recirculation rate * total dissolved solids of blowdown * design drift rate

<u>Circ pump flow rate</u>	53814	Gallons per minute
	* 8.33	Pounds per gallon
	* 1440	Minutes per day
	64,550,969	Pounds per day

<u>Total dissolved solids</u>	2963	Average daily conductivity umhos
	0.00000064	Conversion to TDS ppm
	0.00189632	

<u>Design drift rate</u>	0.005%
--------------------------	---------------

PM-10 pounds per day	6.12
----------------------	-------------

92	Days in quarter
----	-----------------

PM-10 pounds this quarter	563	4Q20
---------------------------	------------	-------------

fill only these

AQ-86

AQ-86 Operation for maintenance and testing of the emergency diesel engine and generator shall be limited to 50 hours per year.

Verification: The Project owner shall include all necessary operational data to demonstrate compliance with the limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

6

DATE	TECH	TIME START-S/D	RUNTIME TOTAL HRS.	RUNTIME YTD MINUTES
12/24/18	E.O.	13:37 - 14:07 Bi-Weekly Test	97	805
1/6/19	AAB	1241 - 1311 Bi-Weekly Test	97	30
1-20-19	Ry	0825 - 0555 Bi-Weekly Test	98	60
1-29-19	Ry	1013 - 1043 Bi-Weekly Test	98	90
2-17-19	Ry	1035 - 1105 Bi-Weekly Test	99	120
3-11-19	E.O.	0724 - 0730 OUTAGE / BLACK PLANT	99	126
4-29-19	ME	0920 - 0950 TEST / Warm oil for Spring	99	156
4/29/2019	ME	1202 - 1206 Post Maint Priming/TEST	99	160
7-18-19	RL	1311 - 1347 TEST - INTELLIGENT REPLACEMENT	100	195
8-22-19	RL	DIESEL DELIVERY 16.0 GALS		
9-20-19	AB	1026 - 1029 TEST RUN	100	198
9-20-19	AB	1416 - 1421 TEST RUN	100	203
9-20-19	AB	1424 - 1434 TEST RUN	100	213
10-10-19	ME	1100 - 1124 TEST RUN / Trouble Shooting	100	237
10-10-19	ME	1134 - 1144 TEST RUN / Trouble Shooting	101	245
10-10-19	ME	1150 - 1158 TEST RUN / Trouble Shooting	101	253
10-10-19	ME	1206 - 1207 TEST RUN / Trouble Shooting	101	254
10-13-19	AAB	0942 - 0947 WEEKLY TEST RUN	101	259
10-27-19	Ry	Bi-Weekly Test	102	289
11-3-19	BP	Bi-Weekly Test - Failed	102	304
11-10-19	AAB	Bi-Weekly Test FAILED AFTER 5 MINS SHUTDOWN	102	309
11-24-19	ZUR	Bi-Weekly Test Run - Successful	103	339
12-8-19	AAB	Bi-Weekly Test Run	103	369
12-29-19	BP	Bi-Weekly Test 1439 - 1509	104	399
1/04/20	BH	Bi-Weekly Test 14:16 - 14:49	104	33
1/6/20	BH	Trouble shoot with CPO/CAT 13:04 13:29	104	63
1/6/20	AB	1447 - 1453 TEST RUN	105	69
1/6/20	AB	1512 - 1518 TEST RUN	105	75
1/7/20	AB	1110 - 1112 TEST RUN	105	77
1/7/20	AB	1114 - 1127 TEST RUN	105	90
1/7/20	AB	1153 - 1309 TEST RUN	106	166
1/7/20	AB	1317 - 1330 TEST RUN	106	179
01-19-2020	Ry	1355 - 1425 Bi-Weekly Test	107	209
2-9-20	DWN	1038 - 1108 Bi-Weekly Test	107	239
2-11-2020	AAB	1140 - 1142 PLACER COUNTY TEST	107	241
7-25-2020	AAB	1304 - 1334 Bi-Weekly Test	108	271

DATE	TECH	TIME START S/D	RUNTIME TOTAL HRS.	RUNTIME 7 YTD minutes
8-26-2016	KD	01:00 01:30	108	301
4-13-2020	RC	1538 - Bluebeam Test - 1610	109	333
10/4/20	DB	1323 - 1400 - Test Run	109	370
10/22/20	AB	DIESEL DELIVERY 64 GALS		
11/1/2020	KD	13:01 13:31 Bi-Weekly Test	110	400
11/29/20	AB	1444 1514 BI-WEEKLY TEST RUN	110	430
12-20-2020	AAB	1650 - 1720 Bi-Weekly Test Run	111	460

AQ-87

AQ-87 Operation for other than maintenance and testing purposes shall be limited to involuntary interruptions of electrical power. Operation shall not exceed 24 hours without prior authorization by the Air Pollution Control Officer.

Verification: The Project owner shall include all necessary operational data to demonstrate compliance with the limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

Date	Start	Reason	Stop	Initials	Total hrs	YTD
1-26-20	1310	Weekly test	1340	BP	178.1	2.0
2-2-20	1335	Weekly test	1405	MR	178.6	2.5
2-9-20	1133	Weekly test	1203	DWN	179.1	3.0
2-16-20	1508	Weekly test	1538	ZHR	179.6	3.5
2-23-20	1401	Weekly test	1431	BP	180.1	4.0
3-8-20	1545	WEEKLY TEST RUN	1615	AS	180.6	4.5
3-23-20	2319	COMPUTER DEVICE	2322	8	180.6	4.5
4-5-20	1620	WEEKLY TEST RUN	1650	AS	181.1	5.0
4-12-20	1438	WEEKLY TEST RUN	1508	8	181.6	5.5
4-19-20	1514	WEEKLY TEST RUN		KAB	182.1	6.0
4-28-20	1035	WEEKLY TEST RUN	1105	AS	182.6	6.5
5-3-20	1446	WEEKLY TEST RUN	1516	AS	183.1	7.0
5-10-20	1532	WEEKLY TEST RUN	1622	8	183.6	7.5
5-16-20	1505	Weekly test	1535	KAB	184.1	8.0
5-31-20	1516	WEEKLY TEST RUN	1546	AS	184.6	8.5
6-4-20	1309	Weekly Test Run	1339	8	185.1	9.0
6-14-20	1325	Weekly Test Run	1355	BP	185.6	9.5
6-21-20	1500	WEEKLY TEST RUN	1530	RC	186.1	10.0
6-28-20	1215	WEEKLY TEST RUN	135	RC	186.6	10.5
7-1-20	2147	Weekly Test Run	2217	MR	187.1	11.0
7-12-20	1115	weekly test	1145	8	187.6	11.5
7-19-20	1410	WEEKLY TEST RUN	1510	RC	188.1	12.0
7-25-20	1429	WEEKLY TEST RUN	1459	KAB	188.6	12.5
8-3-20	0900	WEEKLY TEST RUN	0930	KAB	189.1	13.0
8-9-20	1330	Weekly Test Run	1420	BP	189.6	13.5
8-23-20	1208	WEEKLY TEST RUN	1238	LH	190.1	14.0
8-30-20	1237	Weekly Test Run	1307	8	190.6	14.5
9-6-20	1230	Weekly Test Run	1300	KAB	191.1	15.0
9-8-20	1310	Post Maint Test Run	1318	MR	191.4	15.3
9-14-20	1421	Weekly Test Run	1451	MR	191.9	15.8
9-20-20	1133	Weekly Test Run	1203	LH	192.4	16.3
9-27-20	1844	Weekly Test Run	1714	ZHR	192.9	16.8
10-4-20	1527	Weekly Test Run	1557	DE	193.3	17.3
10-11-20	2133	Weekly Test Run	2203	DE	193.8	17.8
10-18-20	1628	Weekly Test Run	1658	LH	194.3	18.3
10-22-20		DIESEL DELIVERY	76.0 GALS	8		

DATE	Start	Reason	Stop	Initials	Total Hrs	YTD
10-25-20	1442	Weekly Test Run	1512	ZHR	194.8	18.8
11-1-20	1355	Weekly test run	1425	KAB	195.3	19.3
11-8-20	1125	WEEKLY TEST RUN	1205	RC	196.0	20.0
11-15-20	1545	Weekly Test Run	1615	ZHR	196.5	20.5
11-29-20	1140	WEEKLY TEST RUN	1210	AS	197.0	21.0
12-6-20	1000	WEEKLY TEST RUN	1030	RC	197.8	21.8
12-15-20	1525	WEEKLY TEST RUN	1555	KAB	198.3	22.3
12-20-20	1505	WEEKLY TEST RUN	1535	KAB	198.8	22.8
12-27-20	1340	WEEKLY TEST RUN	1410	DE	199.3	23.3
1-3-2021	1415	WEEKLY TEST RUN	1445	RC	199.8	23.8

AQ-88

AQ-88 The Sulfur content of the Diesel fuel used shall not exceed 15 ppm by weight.

Verification: The Project owner shall include a summary of diesel fuel purchase records showing amounts delivered, date delivered and fuel type with the Quarterly Air Quality Report as required in Condition of Certification AQ-SC6.



P.O. BOX 401
WEST SACRAMENTO, CA 95691-0401

01 Sacramento 916-371-2570 06 Williams 930-473-2811
03 Dixon 707-476-3061 08 Isleton 916-777-5545
04 Fairfield 707-426-5780 11 Marysville 930-743-4847
06 Stockton 209-466-6255 14 Lincoln 916-645-2179
06 Woodland 530-961-1200

REMIT TO: P.O. BOX 401
WEST SACRAMENTO, CA 95691-0401
HAZARDOUS MATERIAL EMERGENCY
CALL 1-800-456-7745

Scan here to sign up for Online Bill Pay →



ACCOUNT: 23464
INVOICE: 75242
WH: 11
DATE: 10-22-20



58.544053.S21

ROSEVILLE ENERGY PARK
CITY OF ROSEVILLE
5120 PHILLIP RD
ROSEVILLE, CA 95747

RAMOS OIL INC.
PO BOX 401
WEST SACRAMENTO, CA 95691-0401



DO NOT ATTACH WITH STAPLE OR PAPERCLIP
PLEASE DETACH AT PERFORATION AND RETURN UPPER PORTION WITH YOUR PAYMENT

CUST. PURCHASE ORDER NUMBER		SALESMAN		TERMS		DEL. ZONE		DUE DATE	
9005475		JOSH GRAVES		Net 30 Days		0		11-21-20	
DELIVERY DATE		DRIVER		TRUCK NUMBER		TERMINAL		B/L NUMBER	
10-22-20		258ROBERT R		25117					
NO. OF PKG'S	BULK OR SIZE	PRODUCT DELIVERED		ORDERED	DELIVERED	TAXES		PRICE	AMOUNT
		NA1993 RED DYED DIESEL COMBUSTIBLE, 3, PG III #2D 15ppm sulfur (maxium) Dyed Diesel fuel non taxable use only, penalty for taxable use.							
	BULK	DSL #2 DYED CARB ULTRA LOW		140	140	T		2.10000	294.00
		REC CA OIL SPILL TAX			140			0.00000	0.00
		L.U.S.T. TAX			140			0.00100	0.14
		FED OIL SPILL TAX			140			0.00214	0.30
		AB 32 DSL IMPLEMENTATION FEE			140			0.00400	0.56
		ENVIRONMENTAL SURCHARGE				T		0.00850	1.19
Ship to:				SALES TAX →				22.95	
ROSEVILLE ENERGY PARK CITY OF ROSEVILLE 5120 PHILLIP RD ROSEVILLE, CA 95747				TOTAL →				319.14	
CUSTOMER AGREES TO PAY FINANCE CHARGE ON PAST DUE BALANCE OF 1.5% PER MONTH OR THE MAXIMUM RATE ALLOWED IN CUSTOMER'S STATE OF RESIDENCE WHICHEVER IS LESS, AND FURTHER AGREES TO PAY REASONABLE ATTORNEY'S FEES AND COSTS IF COLLECTION IS REQUIRED. VENUE FOR PURPOSES OF ENDORSEMENT OF THIS OBLIGATION SHALL BE YOLO COUNTY									
ALL CLAIMS FOR ENVIRONMENTAL DAMAGE DURING DELIVERY OF ANY RAMOS OIL PRODUCT MUST BE MADE WITHIN 15 DAYS FOLLOWING DELIVERY									
ERRORS IN PRICE, EXTENSION AND ADDITION SUBJECT TO CORRECTION.									
DELIVERED BY (SIGNATURE IN FULL) X				RECEIVED IN GOOD ORDER X				TOTAL → 319.14	

AQ-89

AQ-89 Records of operation and maintenance shall be kept by the owner or Operator for a period of five years and shall be made available to the PCAPCD upon request. Information required for reporting to the PCAPCD includes, but is not limited to:

1. The hours of operation the engine was run for maintenance and testing;
2. The hours of operation the engine was run during interruption of electrical power; and
3. Records of the sulfur content of the diesel used.

VERIFICATION: The Project owner shall include these records as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.



P.O. BOX 401
WEST SACRAMENTO, CA 95691-0401

01 Sacramento 916-371-2570 06 Williams 930-473-2811
03 Dixon 707-476-3061 08 Isleton 916-777-5545
04 Fairfield 707-426-5780 11 Marysville 930-743-4847
06 Stockton 209-466-6255 14 Lincoln 916-645-2179
06 Woodland 530-961-1200

REMIT TO: P.O. BOX 401
WEST SACRAMENTO, CA 95691-0401
HAZARDOUS MATERIAL EMERGENCY
CALL 1-800-456-7745

Scan here to sign up for Online Bill Pay →



ACCOUNT: 23464
INVOICE: 75242
WH: 11
DATE: 10-22-20



58.544053.S21

ROSEVILLE ENERGY PARK
CITY OF ROSEVILLE
5120 PHILLIP RD
ROSEVILLE, CA 95747

RAMOS OIL INC.
PO BOX 401
WEST SACRAMENTO, CA 95691-0401



DO NOT ATTACH WITH STAPLE OR PAPERCLIP
PLEASE DETACH AT PERFORATION AND RETURN UPPER PORTION WITH YOUR PAYMENT

CUST. PURCHASE ORDER NUMBER		SALESMAN		TERMS		DEL. ZONE		DUE DATE	
9005475		JOSH GRAVES		Net 30 Days		0		11-21-20	
DELIVERY DATE		DRIVER		TRUCK NUMBER		TERMINAL		B/L NUMBER	
10-22-20		258ROBERT R		25117					
NO. OF PKG'S	BULK OR SIZE	PRODUCT DELIVERED		ORDERED	DELIVERED	TAXES		PRICE	AMOUNT
		NA1993 RED DYED DIESEL COMBUSTIBLE, 3, PG111 #2D 15ppm sulfur (maxium) Dyed Diesel fuel non taxable use only, penalty for taxable use.							
	BULK	DSL #2 DYED CARB ULTRA LOW		140	140	T		2.10000	294.00
		REC CA OIL SPILL TAX			140			0.00000	0.00
		L.U.S.T. TAX			140			0.00100	0.14
		FED OIL SPILL TAX			140			0.00214	0.30
		AB 32 DSL IMPLEMENTATION FEE			140			0.00400	0.56
		ENVIRONMENTAL SURCHARGE				T		0.00850	1.19
Ship to:				SALES TAX →				22.95	
ROSEVILLE ENERGY PARK CITY OF ROSEVILLE 5120 PHILLIP RD ROSEVILLE, CA 95747				TOTAL →				319.14	
CUSTOMER AGREES TO PAY FINANCE CHARGE ON PAST DUE BALANCE OF 1.5% PER MONTH OR THE MAXIMUM RATE ALLOWED IN CUSTOMER'S STATE OF RESIDENCE WHICHEVER IS LESS, AND FURTHER AGREES TO PAY REASONABLE ATTORNEY'S FEES AND COSTS IF COLLECTION IS REQUIRED. VENUE FOR PURPOSES OF ENDORSEMENT OF THIS OBLIGATION SHALL BE YOLO COUNTY									
ALL CLAIMS FOR ENVIRONMENTAL DAMAGE DURING DELIVERY OF ANY RAMOS OIL PRODUCT MUST BE MADE WITHIN 15 DAYS FOLLOWING DELIVERY									
ERRORS IN PRICE, EXTENSION AND ADDITION SUBJECT TO CORRECTION.									
DELIVERED BY (SIGNATURE IN FULL) X				RECEIVED IN GOOD ORDER X				TOTAL → 319.14	

6

DATE	TECH	TIME START-S/D	RUNTIME TOTAL HRS.	RUNTIME YTD MINUTES
12/24/18	E.O.	13:37 - 14:07 Bi-Weekly Test	97	805
1/6/19	AAB	1241 - 1311 Bi-Weekly Test	97	30
1-20-19	Ry	0825 - 0555 Bi-Weekly Test	98	60
1-29-19	Ry	1013 - 1043 Bi-Weekly Test	98	90
2-17-19	Ry	1035 - 1105 Bi-Weekly Test	99	120
3-11-19	E.O.	0724 - 0730 OUTAGE / BLACK PLANT	99	126
4-29-19	ME	0920 - 0950 TEST / Warm oil for Spring	99	156
4/29/2019	ME	1202 - 1206 Post Maint Priming/TEST	99	160
7-18-19	RL	1311 - 1347 TEST - INTELLIGENT REPAIR	100	195
8-22-19	RL	DIESEL DELIVERY 16.0 GALS		
9-20-19	AS	1026 - 1029 TEST RUN	100	198
9-20-19	AS	1416 - 1421 TEST RUN	100	203
9-20-19	AS	1424 - 1434 TEST RUN	100	213
10-10-19	ME	1100 - 1124 TEST RUN / Trouble Shooting	100	237
10-10-19	ME	1134 - 1144 TEST RUN / Trouble Shooting	101	245
10-10-19	ME	1150 - 1158 TEST RUN / Trouble Shooting	101	253
10-10-19	ME	1206 - 1207 TEST RUN / Trouble Shooting	101	254
10-13-19	AAB	0942 - 0947 WEEKLY TEST RUN	101	259
10-27-19	Ry	Bi Weekly Test	102	289
11-3-19	BP	Bi Weekly Test - Failed	102	304
11-10-19	AAB	Bi-Weekly Test FAILED AFTER 5 MINS SHUTDOWN	102	309
11-24-19	ZUR	Bi-Weekly Test Run - Successful	103	339
12-8-19	AAB	Bi-Weekly Test Run	103	369
12-29-19	BP	Bi-Weekly test 1439 - 1509	104	399
1/04/20	BH	Bi-Weekly Test 14:16 - 14:49	104	33
1/6/20	BH	Troubleshooting with CEO/CAT 13:04	104	63
1/6/20	AS	1447 - 1453 TEST RUN	105	69
1/6/20	AS	1512 - 1518 TEST RUN	105	75
1/7/20	AS	1110 - 1112 TEST RUN	105	77
1/7/20	AS	1114 - 1127 TEST RUN	105	90
1/7/20	AS	1153 - 1309 TEST RUN	106	166
1/7/20	AS	1317 - 1330 TEST RUN	106	179
01-19-2020	Ry	1355 - 1425 Bi Weekly Test	107	209
2-9-20	DWN	1038 - 1108 Bi-Weekly Test	107	239
2-11-2020	AAB	1140 - 1142 PLACER COUNTY TEST	107	241
7-25-2020	AAB	1304 - 1334 Bi-Weekly Test	108	271

DATE	TECH	TIME START S/D	RUNTIME TOTAL HRS.	RUNTIME 7 YTD minutes
8-26-2016	KD	01:00 01:30	108	301
4-13-2020	RC	1538 - Bluebeam Test - 1610	109	333
10/4/20	DB	1323 - 1400 - Test Run	109	370
10/22/20	AS	DIESEL DELIVERY 64 GALS		
11/1/2020	KD	13:01 13:31 Bi Weekly test	110	400
11/29/20	AS	1444 1514 BIWEEKLY TEST RUN	110	430
12-20-2020	AAB	1650 - 1720 Bi-Weekly Test Run	111	460

AQ-90

AQ-90 No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6.

In regards to AQ-90 of Roseville Energy Park's 4Q20 QAQR, there were no violations of PCAPCD's Rule 205 for nuisance.

AQ-91

AQ-91 Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited and is in violation of PCAPCD Rule 202, Visible Emissions.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6.

In regards to AQ-91 of Roseville Energy Park's 4Q20 QAQR, there were no violations of PCAPCD's Rule 202 for opacity from the diesel fire pump.

AQ-99

AQ-99 Operation for maintenance and testing of the emergency diesel engine and generator shall be limited to 50 hours per year.

Verification: The Project shall include all necessary operational data to demonstrate compliance with the limits provided as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

6

DATE	TECH	TIME START-S/D	RUNTIME TOTAL HRS.	RUNTIME YTD MINUTES
12/24/18	E.O.	13:37 - 14:07 Bi-Weekly Test	97	805
1/6/19	AAB	1241 - 1311 Bi-Weekly Test	97	30
1-20-19	Ry	0825 - 0555 Bi-Weekly Test	98	60
1-29-19	Ry	1013 - 1043 Bi-Weekly Test	98	90
2-17-19	Ry	1035 - 1105 Bi-Weekly Test	99	120
3-11-19	E.O.	0724 - 0730 OUTAGE / BLACK PLANT	99	126
4-29-19	ME	0920 - 0950 TEST / Warm oil for Spring	99	156
4/29/2019	ME	1202 - 1206 Post Maint Priming/TEST	99	160
7-18-19	RL	1311 - 1347 TEST - INTELLIGENCE REPAIR	100	195
8-22-19	RL	DIESEL DELIVERY 16.0 GALS		
9-20-19	AB	1026 - 1029 TEST RUN	100	198
9-20-19	AB	1416 - 1421 TEST RUN	100	203
9-20-19	AB	1424 - 1434 TEST RUN	100	213
10-10-19	ME	1100 - 1124 TEST RUN / Trouble Shooting	100	237
10-10-19	ME	1134 - 1144 TEST RUN / Trouble Shooting	101	245
10-10-19	ME	1150 - 1158 TEST RUN / Trouble Shooting	101	253
10-10-19	ME	1206 - 1207 TEST RUN / Trouble Shooting	101	254
10-13-19	AAB	0942 - 0947 WEEKLY TEST RUN	101	259
10-27-19	Ry	Bi-Weekly Test	102	289
11-3-19	BP	Bi-Weekly Test - Failed	102	304
11-10-19	AAB	Bi-Weekly Test FAILED AFTER 5 MINS SHUTDOWN	102	309
11-24-19	ZUR	Bi-Weekly Test Run - Successful	103	339
12-8-19	AAB	Bi-Weekly Test Run	103	369
12-29-19	BP	Bi-Weekly Test 1439 - 1509	104	399
1/04/20	BH	Bi-Weekly Test 14:16 - 14:49	104	33
1/6/20	BH	Troubleshooting with CEO/CAT 13:04	104	63
1/6/20	AB	1447 - 1453 TEST RUN	105	69
1/6/20	AB	1512 - 1518 TEST RUN	105	75
1/7/20	AB	1110 - 1112 TEST RUN	105	77
1/7/20	AB	1114 - 1127 TEST RUN	105	90
1/7/20	AB	1153 - 1309 TEST RUN	106	166
1/7/20	AB	1317 - 1330 TEST RUN	106	179
01-19-2020	Ry	1355 - 1425 Bi-Weekly Test	107	209
2-9-20	DWN	1038 - 1108 Bi-Weekly Test	107	239
2-11-2020	AAB	1140 - 1142 PLACER COUNTY TEST	107	241
7-25-2020	AAB	1304 - 1334 Bi-Weekly Test	108	271

DATE	TECH	TIME START S/D	RUNTIME TOTAL HRS.	RUNTIME 7 YTD minutes
8-26-2016	KD	01:00 01:30	108	301
4-13-2020	RC	1538 - Bluebeam Test - 1610	109	333
10/4/20	DB	1323 - 1400 - Test Run	109	370
10/22/20	AB	DIESEL DELIVERY 64 GALS		
11/1/2020	KD	13:01 13:31 Bi-Weekly Test	110	400
11/29/20	AB	1444 1514 BIWEEKLY TEST RUN	110	430
12-20-2020	AAB	1650 - 1720 Bi-Weekly Test Run	111	460

AQ-100

AQ-100 In regards to the Emergency diesel Generator; Operation for other than maintenance and testing purposes shall be limited to involuntary interruptions of electrical power. Operation shall not exceed 24 hours without prior authorization by the Air Pollution Control Officer.

6

DATE	TECH	TIME START-S/D	RUNTIME TOTAL HRS.	RUNTIME YTD MINUTES
12/24/18	E.O.	13:37 - 14:07 Bi-Weekly Test	97	805
1/6/19	LAB	1241 - 1311 Bi-Weekly Test	97	30
1-20-19	Ry	0825 - 0555 Bi-Weekly Test	98	60
1-29-19	Ry	1013 - 1043 Bi-Weekly Test	98	90
2-17-19	Ry	1035 - 1105 Bi-Weekly Test	99	120
3-11-19	E.O.	0724 - 0730 OUTAGE / BLACK PLANT	99	126
4-29-19	ME	0920 - 0950 TEST / Warm oil for Spring	99	156
4/29/2019	ME	1202 - 1206 Post Maint Priming/TEST	99	160
7-18-19	RL	1311 - 1347 TEST-INTelligent REPLACEMENT	100	195
8-22-19	RL	DIESEL DELIVERY 16.0 GALS		
9-20-19	AS	1026 - 1029 TEST RUN	100	198
9-20-19	AS	1416 - 1421 TEST RUN	100	203
9-20-19	AS	1424 - 1434 TEST RUN	100	213
10-10-19	ME	1100 - 1124 TEST RUN / Trouble Shooting	100	237
10-10-19	ME	1134 - 1144 TEST RUN / Trouble Shooting	101	245
10-10-19	ME	1150 - 1158 TEST RUN / Trouble Shooting	101	253
10-10-19	ME	1206 - 1207 TEST RUN / Trouble Shooting	101	254
10-13-19	LAB	0942 - 0947 WEEKLY TEST RUN	101	259
10-27-19	Ry	Bi-Weekly Test	102	289
11-3-19	BP	Bi-Weekly Test - Failed	102	304
11-10-19	LAB	Bi-Weekly Test FAILED AFTER 5 MINS SHUTDOWN	102	309
11-24-19	ZUR	Bi-Weekly Test Run - Successful	103	339
12-8-19	LAB	Bi-Weekly Test Run	103	369
12-29-19	BP	Bi-Weekly test 1439 - 1509	104	399
1/04/20	BH	Bi-Weekly Test 14:16 - 14:49	104	33
1/6/20	BH	Troubleshooting with CEO/CAT 13:04	104	63
1/6/20	AS	1447 - 1453 TEST RUN	105	69
1/6/20	AS	1512 - 1518 TEST RUN	105	75
1/7/20	AS	1110 - 1112 TEST RUN	105	77
1/7/20	AS	1114 - 1127 TEST RUN	105	90
1/7/20	AS	1153 - 1309 TEST RUN	106	166
1/7/20	AS	1317 - 1330 TEST RUN	106	179
01-19-2020	Ry	1355 - 1425 Bi-Weekly Test	107	209
2-9-20	DWN	1038 - 1108 Bi-Weekly Test	107	239
2-11-2020	LAB	1140 - 1142 PLANT CANNY TEST	107	241
7-25-2020	LAB	1304 - 1334 Bi-Weekly Test	108	271

DATE	TECH	TIME START S/D	RUNTIME TOTAL HRS.	RUNTIME 7 YTD minutes
8-26-2016	KD	01:00 01:30	108	301
4-13-2020	RC	1538 - 1610 Bi-Weekly Test	109	333
10/4/20	DB	1323 - 1400 - Test Run	109	370
10/22/20	AS	DIESEL DELIVERY 64 GALS		
11/1/2020	KD	13:01 13:31 Bi-Weekly Test	110	400
11/29/20	AS	1444 1514 BI-WEEKLY TEST RUN	110	430
12-20-2020	LAB	1650 - 1720 Bi-Weekly Test Run	111	460

AQ-101

AQ-101 The sulfur content of the diesel used shall not exceed 15ppm by weight

Verification: The Project owner shall include a summary of diesel fuel purchase records showing amounts delivered, date delivered and fuel type with the Quarterly Air Quality Report in Condition of Certification AQ-SC6



P.O. BOX 401
WEST SACRAMENTO, CA 95691-0401

01 Sacramento 916-371-2570 06 Williams 930-473-2811
03 Dixon 707-476-3061 08 Isleton 916-777-5545
04 Fairfield 707-426-5780 11 Marysville 930-743-4847
06 Stockton 209-466-6255 14 Lincoln 916-645-2179
06 Woodland 530-961-1200

REMIT TO: P.O. BOX 401
WEST SACRAMENTO, CA 95691-0401
HAZARDOUS MATERIAL EMERGENCY
CALL 1-800-456-7745

Scan here to sign up for Online Bill Pay →



ACCOUNT: 23464
INVOICE: 75242
WH: 11
DATE: 10-22-20



58.544053.S21

ROSEVILLE ENERGY PARK
CITY OF ROSEVILLE
5120 PHILLIP RD
ROSEVILLE, CA 95747

RAMOS OIL INC.
PO BOX 401
WEST SACRAMENTO, CA 95691-0401



DO NOT ATTACH WITH STAPLE OR PAPERCLIP
PLEASE DETACH AT PERFORATION AND RETURN UPPER PORTION WITH YOUR PAYMENT

CUST. PURCHASE ORDER NUMBER		SALESMAN		TERMS		DEL. ZONE		DUE DATE	
9005475		JOSH GRAVES		Net 30 Days		0		11-21-20	
DELIVERY DATE		DRIVER		TRUCK NUMBER		TERMINAL		B/L NUMBER	
10-22-20		258ROBERT R		25117					
NO. OF PKG'S	BULK OR SIZE	PRODUCT DELIVERED		ORDERED	DELIVERED	TAXES		PRICE	AMOUNT
		NA1993 RED DYED DIESEL COMBUSTIBLE, 3, PG111 #2D 15ppm sulfur (maxium) Dyed Diesel fuel non taxable use only, penalty for taxable use.							
	BULK	DSL #2 DYED CARB ULTRA LOW		140	140	T		2.10000	294.00
		REC CA OIL SPILL TAX			140			0.00000	0.00
		L.U.S.T. TAX			140			0.00100	0.14
		FED OIL SPILL TAX			140			0.00214	0.30
		AB 32 DSL IMPLEMENTATION FEE			140			0.00400	0.56
		ENVIRONMENTAL SURCHARGE				T		0.00850	1.19
Ship to:				SALES TAX →				22.95	
ROSEVILLE ENERGY PARK CITY OF ROSEVILLE 5120 PHILLIP RD ROSEVILLE, CA 95747				TOTAL →				319.14	
CUSTOMER AGREES TO PAY FINANCE CHARGE ON PAST DUE BALANCE OF 1.5% PER MONTH OR THE MAXIMUM RATE ALLOWED IN CUSTOMER'S STATE OF RESIDENCE WHICHEVER IS LESS, AND FURTHER AGREES TO PAY REASONABLE ATTORNEY'S FEES AND COSTS IF COLLECTION IS REQUIRED. VENUE FOR PURPOSES OF ENDORSEMENT OF THIS OBLIGATION SHALL BE YOLO COUNTY									
ALL CLAIMS FOR ENVIRONMENTAL DAMAGE DURING DELIVERY OF ANY RAMOS OIL PRODUCT MUST BE MADE WITHIN 15 DAYS FOLLOWING DELIVERY									
ERRORS IN PRICE, EXTENSION AND ADDITION SUBJECT TO CORRECTION.									
DELIVERED BY (SIGNATURE IN FULL) X				RECEIVED IN GOOD ORDER X				TOTAL →	
								319.14	

AQ-102

AQ-102 Records of operation and maintenance shall be kept by the owner or operator for a period of five years and shall be made available to the PCAPCD by request. Information required for reporting to the PCAPCD includes, but is not limited to:

- A. Hours of operation the engine was run for maintenance and testing
- B. Hours of operation the engine was run during interruption of electrical power
- C. Records of sulfur content of the diesel fuel used

Verification: The Project owner shall include these records as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6



P.O. BOX 401
WEST SACRAMENTO, CA 95691-0401

01 Sacramento 916-371-2570 06 Williams 930-473-2811
03 Dixon 707-476-3061 08 Isleton 916-777-5545
04 Fairfield 707-426-5780 11 Marysville 930-743-4847
06 Stockton 209-466-6255 14 Lincoln 916-645-2179
06 Woodland 930-961-1200

REMIT TO: P.O. BOX 401
WEST SACRAMENTO, CA 95691-0401
HAZARDOUS MATERIAL EMERGENCY
CALL 1-800-456-7745

Scan here to sign up for Online Bill Pay →



ACCOUNT: 23464
INVOICE: 75242
WH: 11
DATE: 10-22-20



58.544053.S21

ROSEVILLE ENERGY PARK
CITY OF ROSEVILLE
5120 PHILLIP RD
ROSEVILLE, CA 95747

RAMOS OIL INC.
PO BOX 401
WEST SACRAMENTO, CA 95691-0401



DO NOT ATTACH WITH STAPLE OR PAPERCLIP
PLEASE DETACH AT PERFORATION AND RETURN UPPER PORTION WITH YOUR PAYMENT

CUST. PURCHASE ORDER NUMBER		SALESMAN		TERMS		DEL. ZONE		DUE DATE	
9005475		JOSH GRAVES		Net 30 Days		0		11-21-20	
DELIVERY DATE		DRIVER		TRUCK NUMBER		TERMINAL		B/L NUMBER	
10-22-20		258ROBERT R		25117					
NO. OF PKG'S	BULK OR SIZE	PRODUCT DELIVERED		ORDERED	DELIVERED	TAXES		PRICE	AMOUNT
		NA1993 RED DYED DIESEL COMBUSTIBLE, 3, PG111 #2D 15ppm sulfur (maxium) Dyed Diesel fuel non taxable use only, penalty for taxable use.							
	BULK	DSL #2 DYED CARB ULTRA LOW		140	140	T		2.10000	294.00
		REC CA OIL SPILL TAX			140			0.00000	0.00
		L.U.S.T. TAX			140			0.00100	0.14
		FED OIL SPILL TAX			140			0.00214	0.30
		AB 32 DSL IMPLEMENTATION FEE			140			0.00400	0.56
		ENVIRONMENTAL SURCHARGE				T		0.00850	1.19
Ship to: ROSEVILLE ENERGY PARK CITY OF ROSEVILLE 5120 PHILLIP RD ROSEVILLE, CA 95747				SALES TAX →				22.95	
				TOTAL →				319.14	
CUSTOMER AGREES TO PAY FINANCE CHARGE ON PAST DUE BALANCE OF 1.5% PER MONTH OR THE MAXIMUM RATE ALLOWED IN CUSTOMER'S STATE OF RESIDENCE WHICHEVER IS LESS, AND FURTHER AGREES TO PAY REASONABLE ATTORNEY'S FEES AND COSTS IF COLLECTION IS REQUIRED. VENUE FOR PURPOSES OF ENDORSEMENT OF THIS OBLIGATION SHALL BE YOLO COUNTY									
ALL CLAIMS FOR ENVIRONMENTAL DAMAGE DURING DELIVERY OF ANY RAMOS OIL PRODUCT MUST BE MADE WITHIN 15 DAYS FOLLOWING DELIVERY									
ERRORS IN PRICE, EXTENSION AND ADDITION SUBJECT TO CORRECTION.									
DELIVERED BY (SIGNATURE IN FULL)		RECEIVED IN GOOD ORDER		TOTAL →				319.14	
X		X							

6

DATE	TECH	TIME START-S/D	RUNTIME TOTAL HRS.	RUNTIME YTD MINUTES
12/24/18	E.O.	13:37 - 14:07 Bi-Weekly Test	97	805
1/6/19	KAB	1241 - 1311 Bi-Weekly Test	97	30
1-20-19	Ry	0825 - 0555 Bi-Weekly Test	98	60
1-29-19	Ry	1013 - 1043 Bi-Weekly Test	98	90
2-17-19	Ry	1035 - 1105 Bi-Weekly Test	99	120
3-11-19	E.O.	0724 - 0730 OUTAGE / BLACK PLANT	99	126
4-29-19	ME	0920 - 0950 TEST / Warm oil for Spring	99	156
4/29/2019	ME	1202 - 1206 Post Maint Priming/TEST	99	160
7-18-19	RL	1311 - 1347 TEST-INTELLEN REPLAC	100	195
8-22-19	RL	DIESEL DELIVERY 16.0 GALS		
9-20-19	AS	1026 - 1029 TEST RUN	100	198
9-20-19	AS	1416 - 1421 TEST RUN	100	203
9-20-19	AS	1424 - 1434 TEST RUN	100	213
10-10-19	ME	1100 - 1124 TEST RUN / Trouble Shooting	100	237
10-10-19	ME	1134 - 1144 TEST RUN / Trouble Shooting	101	245
10-10-19	ME	1150 - 1158 TEST RUN / Trouble Shooting	101	253
10-10-19	ME	1206 - 1207 TEST RUN / Trouble Shooting	101	254
10-13-19	KAB	0942 - 0947 WEEKLY TEST RUN	101	259
10-27-19	Ry	Bi Weekly Test	102	289
11-3-19	BP	Bi Weekly Test - Failed	102	304
11-10-19	KAB	Bi-Weekly Test FAILED AFTER 5 MINS SHUTDOWN	102	309
11-24-19	ZUR	Bi-Weekly Test Run - Successful	103	339
12-8-19	KAB	Bi-Weekly Test Run	103	369
12-29-19	BP	Bi-Weekly test 1439 - 1509	104	399
1/04/20	BH	Bi-Weekly Test 14:16 - 14:49	104	33
1/6/20	BH	Troubleshooting with CEO/CAT 13:04	104	63
1/6/20	AS	1447 - 1453 TEST RUN	105	69
1/6/20	AS	1512 - 1518 TEST RUN	105	75
1/7/20	AS	1110 - 1112 TEST RUN	105	77
1/7/20	AS	1114 - 1127 TEST RUN	105	90
1/7/20	AS	1153 - 1309 TEST RUN	106	166
1/7/20	AS	1317 - 1330 TEST RUN	106	179
01-19-2020	Ry	1355 - 1425 Bi Weekly Test	107	209
2-9-20	DWN	1038 - 1108 Bi-Weekly Test	107	239
2-11-2020	KAB	1140 - 1142 PLACER COUNTY TEST	107	241
7-25-2020	KAB	1304 - 1334 Bi-Weekly Test	108	271

DATE	TECH	TIME START S/D	RUNTIME TOTAL HRS.	RUNTIME 7 YTD minutes
8-26-2016	KAB	01:00 01:30	108	301
4-13-2020	RC	1538 - Bluebeam Test - 1610	109	333
10/4/20	DB	1323 - 1400 - Test Run	109	370
10/22/20	AS	DIESEL DELIVERY 64 GALS		
11/1/2020	KAB	13:01 13:31 Bi Weekly test	110	400
11/29/20	AS	1444 1514 BIWEEKLY TEST RUN	110	430
12-20-2020	KAB	1650 - 1720 Bi-Weekly Test Run	111	460

AQ-103

AQ-103 No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6.

In regards to AQ-103 of Roseville Energy Park's 4Q20 QAQR, there were no violations of PCAPCD's Rule 205 for nuisance.

AQ-104

AQ-104 Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited and is in violation of PCAPCD Rule 202, Visible Emissions.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite opacity complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

In regards to AQ-104 of Roseville Energy Park's 4Q20 QAQR, there were no violations of PCAPCD's Rule 202 for opacity from stack emissions of the emergency diesel generator.