

<b>DOCKETED</b>	
<b>Docket Number:</b>	19-BSTD-03
<b>Project Title:</b>	2022 Energy Code Pre-Rulemaking
<b>TN #:</b>	237062
<b>Document Title:</b>	Roof Coating Manufacturers Association (RCMA) Comments - ASTM D6083 - Sec 110-8(i)4 and Table 110-8-C
<b>Description:</b>	N/A
<b>Filer:</b>	System
<b>Organization:</b>	Roof Coating Manufacturers Association (RCMA)
<b>Submitter Role:</b>	Public
<b>Submission Date:</b>	3/9/2021 1:00:32 PM
<b>Docketed Date:</b>	3/9/2021

*Comment Received From: Roof Coating Manufacturers Association (RCMA)*  
*Submitted On: 3/9/2021*  
*Docket Number: 19-BSTD-03*

## **ASTM D6083 - Sec 110-8(i)4 and Table 110-8-C**

In the 2013 Building Energy Efficiency Standards for Residential and Nonresidential Buildings, in section 110.8 (Mandatory Requirements for Insulation, Roofing Products and Radiant Barriers), subsection (i), paragraph 4, subparagraph B read "Meet the minimum performance requirements listed in Table 110.8-C or the minimum performance requirements of ASTM C836, D3468, D6083, or D6694, whichever are appropriate to the coating material." Prior to the 2016 Building Energy Efficiency Standards for Residential and Nonresidential Buildings, ASTM D6083 was withdrawn resulting in subparagraph B having the reference to D6083 removed. D6083 was reinstated in 2018, but subparagraph B in the 2019 Building Energy Efficiency Standards for Residential and Nonresidential Buildings was not updated to include D6083 as it was in the 2013 edition. Further, ASTM D6083 was recently revised and published with a 2021 date.

RCMA proposes that for the 2022 edition, section 110.8 (Mandatory Requirements for Insulation, Roofing Products and Radiant Barriers), subsection (i), paragraph 4, subparagraph B be revised to read:

"Meet the minimum performance requirements listed in Table 110.8-C or the minimum performance requirements of ASTM C836, D3468, D6083, or D6694, whichever are appropriate to the coating material."