

DOCKETED

Docket Number:	87-AFC-01C
Project Title:	COMPLIANCE-Luz Solar Electric Generating System Cogeneration AFC (150 MW) Units III-VII.
TN #:	237137-1
Document Title:	Email from Joe Zuccaro to Next Era Energy
Description:	Fire Systems at SEGS III-VIII
Filer:	susan fleming
Organization:	California Energy Commission
Submitter Role:	Commission Staff
Submission Date:	3/11/2021 1:26:19 PM
Docketed Date:	3/11/2021

King, Glen

From: Zuccaro, Joe <JZuccaro@SBCFire.org>
Sent: Tuesday, April 14, 2020 9:33 AM
To: King, Glen
Subject: RE: Fire Systems at SEGS III - VII facility

Caution - External Email (jzuccaro@sbcfire.org)

[Report This Email](#) [Tips](#)

Mr King,

I have reviewed your letter and approve the disconnection of the fire protection systems for the facilities that have been de-energized, provided that all combustibile materials are removed. This would be furniture, boxes, papers, storage, etc. (This does not include removing any combustibile structural components of the bldg.).

I hope that this will help you meet your operational goals. Feel free to contact me if you need any further assistance.

Joe Zuccaro

Fire Prevention Supervisor
San Bernardino County Fire Department
Fire Prevention Supervisor-Desert Division
Phone: 760-995-8190
FAX: 760-995-8205
Inter-Office Mail: 0153
Website: sbcfire.org



From: King, Glen <Glen.King@nexteraenergy.com>
Sent: Tuesday, April 14, 2020 9:26 AM
To: Zuccaro, Joe <JZuccaro@SBCFire.org>
Subject: Fire Systems at SEGS III - VII facility

Please see attached letter.
Thank you.

Glen T. King
NEER Sr. Environmental Specialist
*SEGS III – VII, Adelanto I & II, Mountain View, Shafter,
Silver State, Westside, Whitney Point*

W: 760.762.1505

C: 661.202.5837

