

DOCKETED

| | |
|-------------------------|---|
| Docket Number: | 20-SPPE-01 |
| Project Title: | Great Oaks South Backup Generating Facility Small Power Plant Exemption |
| TN #: | 237152 |
| Document Title: | GOSBGF Revised Air Quality and Public Health Analysis |
| Description: | N/A |
| Filer: | Scott Galati |
| Organization: | DayZenLLC |
| Submitter Role: | Applicant Representative |
| Submission Date: | 3/12/2021 12:09:28 PM |
| Docketed Date: | 3/12/2021 |

Equinix GOS

CEC Submittal

Equinix Great Oaks South Revised Emissions and Modeling Assessment

San Jose, California

Prepared for



Prepared by

Atmospheric Dynamics, Inc.



ATMOSPHERIC DYNAMICS, INC
Meteorological & Air Quality Modeling

March 2021

Revised Analyses for Air Quality and Public Health for Operations and Construction

Based on the recent Bay Area Air Quality Management District (BAAQMD) requirements for emergency diesel generators greater than 1,000 horsepower (hp), Equinix has updated the following analyses to reflect the new BAAQMD requirement which will now utilize Environmental Protection Agency (EPA) Tier 4 engines greater than 1,000 brake horsepower (bhp). The Applicants decision to incorporate Tier 4 diesel emergency generators will result in an annual readiness and maintenance testing schedule per year per engine which would be comprised of 20 hours per year (per engine). While the use of Tier 4 diesel emergency generators will greatly reduce the emissions of oxides of nitrogen (NO_x) and diesel particulate matter (DPM), during the routine testing of the engines, the catalyst used to control NO_x may not be fully controlling the emissions during a short period of time (approximately 15 minutes) after the initial startup of each engine. After the initial 15-minute catalyst warmup period, the catalyst is expected to be at the temperatures needed for full NO_x Tier 4 NO_x control. The diesel particulate filter (DPF) has no warmup requirements and will meet the Tier 4 particulate matter limits during all minutes of each operational period. Additionally, the maintenance and readiness testing (M&R) could occur at loads in the range of 10% to 100%. Based on the range of loads during the M&R testing, it was assumed that the use of EPA Tier 2 D2 cycle emissions would still be the most representative way to quantify emissions during these M&R testing hours with the use of Tier 4 emissions rates for the emergency operation as discussed below. While the project will utilize Tier 4 engines, the continued use of Tier 2 D2 cycle emission factors for the 20 hours of readiness testing would be a conservative estimate of project impacts. For emergency operations, 30 out of the 36 QSK95 engines will be operational with all three (3) of the smaller QSX15 engines. Two emergency scenarios were used for the purposes of implementing BAAQMD policy guidance relating to emission offset screening estimates:

- **Scenario 1 CEC** – QSK95 Engines - Maintenance and readiness testing will be limited to 20 hours/yr and will be based on EPA Tier 2 D2 cycle emissions rates at 100% load, with diesel particulate matter (DPM) limited through the use of diesel particulate filters (DPF) in order to achieve the Tier 4 controls. In accordance with BAAQMD policy guidance emergency emissions offset screening estimates are based on 30 engines with a total runtime of 100 hours/yr, at 100% load, with emergency periods allocated to 3-hour blocks. Each 3-hour period will consist of a 15-minute (0.25 hr) startup or warmup period (Tier 2 D2 cycle) followed by 2.75 hours of steady state operations at the Tier 4 limits. The 1-hour startup period will be evaluated using composite weighted emissions factors based on EPA Tier 2 D2 cycle and Tier 4 limits (with DPFs).

QSK95 Engines – emissions for maintenance and readiness testing and emergency operations will be based on the 20- and 100-hour runtimes using the EPA Tier 2 D2 cycled weighted emissions factors (with DPFs) as previously submitted. These engines are less than 1,000 hp and are not subject to the Tier 4 requirements. However, the engines will utilize DPF to control DPM. There are no changes to the emissions from the previous analyses.

- **Scenario 2 BAAQMD** – QSK95 Engines - Maintenance and readiness testing will be limited to 20 hours/yr and the emissions will be based on EPA Tier 2 D2 cycle emissions rates at 100% load, with DPM limited through the use of DPFs. In accordance with BAAQMD policy guidance emergency emissions offset screening estimates are based on 30 engines with a total runtime of 100 hours/yr at 100% load using Tier 4 emissions factors for all pollutants.

QSX15 Engines – emissions for maintenance and readiness testing and emergency operations will be based on the 20- and 100-hour runtimes using the EPA Tier 2 D2 cycled weighted emissions factors (with DPFs) as previously submitted. There are no changes to the emissions from the previous analyses.

The tables which follow have been revised for the revised emissions factors, support data, and operational hour scenarios. In addition, the emissions, air quality impacts, and HRA results for the construction/operations overlap period are also included in several the following tables.

Attachment 1A includes the emission support data.

| Table 1A Scenario 1 CEC | | | | | | |
|---|--------------------------|------------|------------|-----------------------|---|------------------------|
| Period | NO_x | CO | VOC | SO₂ | PM₁₀/PM_{2.5} | CO₂e |
| QSK95 Engines M&R Testing | | | | | | |
| 1 Engine lbs/hr | 44.92 | 5.10 | 2.35 | 0.05 | 0.15 | - |
| 1 Engine lbs/day | 44.92 | 5.10 | 2.35 | 0.05 | 0.15 | - |
| 1 Engine TPY | 0.446 | 0.051 | 0.023 | 0.001 | 0.002 | 50.3 |
| 6 Engines Lbs/day | 267.7 | 30.6 | 14.1 | 0.31 | 0.92 | - |
| All Engines TPY | 16.06 (5.39)* | 1.84 | 0.85 | 0.02 | 0.06 | 1811 |
| QSK95 Engines Emergency Ops | | | | | | |
| 1 st Hour Lbs/yr | 498.9 | 170.0 | 55.3 | 1.70 | 5.10 | - |
| Remaining Hours lbs/hr | 340.5 | 340.5 | 95.34 | 3.40 | 10.21 | - |
| 1 Engine Total lbs/yr | 839.4 | 510.5 | 150.6 | 5.10 | 15.3 | - |
| 1 Engine Max lbs/3 hr period | 20.1 | 10.2 | 3.1 | 0.10 | 0.31 | - |
| 30 Engines Max lbs/3 hr period | 602.6 | 306.3 | 92.7 | 3.06 | 9.2 | - |
| Emergency Ops TPY | 12.59 | 7.66 | 2.26 | 0.08 | 0.23 | 7547 |
| Total TPY | 28.7 (17.98)* | 9.5 | 3.1 | 0.09 | 0.28 | 9359 |
| Scenario 1 CEC- see description of scenario above. | | | | | | |
| * The 5.39 tpy scenario represents the use of the composite emission factor which allows for 15 minutes of catalyst warmup. | | | | | | |

| Table 1B Scenario 1 BAAQMD | | | | | | |
|---|----------------------------|-------------|-------------|-----------------------|---|------------------------|
| Period | NO_x | CO | VOC | SO₂ | PM₁₀/PM_{2.5} | CO₂e |
| QSK95 Engines M&R Testing | | | | | | |
| 1 Engine lbs/hr | 44.92 | 5.1 | 2.35 | 0.05 | 0.15 | - |
| 1 Engine lbs/day | 44.92 | 5.1 | 2.35 | 0.05 | 0.15 | - |
| 1 Engine TPY | 0.446 | 0.051 | 0.023 | 0.001 | 0.002 | 50.3 |
| 6 Engines Lbs/day | 267.7 | 30.6 | 14.1 | 0.31 | 0.92 | - |
| All Engines TPY | 16.06 (5.39)* | 1.84 | 0.85 | 0.02 | 0.06 | 1811 |
| QSK95 Engines Emergency Ops | | | | | | |
| 1 Engine lbs/hr | 5.10 | 5.10 | 1.43 | 0.05 | 0.15 | - |
| 1 Engine lbs/day | 122.5 | 122.5 | 34.3 | 1.23 | 3.68 | - |
| 1 Engine TPY | 0.255 | 0.255 | 0.071 | 0.003 | 0.008 | 252 |
| 30 Engines lbs/hr | 153.15 | 153.15 | 42.88 | 1.53 | 4.6 | - |
| 30 Engines lbs/day | 3675.5 | 3675.5 | 1029.1 | 36.8 | 110.3 | - |
| 30 Engines TPY | 7.66 | 7.66 | 2.14 | 0.077 | 0.23 | 7547 |
| Total TPY | 23.72 (13.05)** | 9.49 | 2.99 | 0.09 | 0.28 | 9359 |
| Scenario 2 BAAQMD- see description of scenario above. | | | | | | |
| * The 5.39 tpy scenario represents the use of the composite emission factor which allows for 15 minutes of catalyst warmup. | | | | | | |
| ** Total with composite emission factor in place of the Tier 2 D2 cycle weighted emissions factor data | | | | | | |

| Table 2 QSX15 Engine Emissions | | | | | | |
|--------------------------------------|-----------------|--------------|--------------|-----------------|-------------------------------------|-------------------|
| Period | NO _x | CO | VOC | SO ₂ | PM ₁₀ /PM _{2.5} | CO ₂ e |
| QSX15 Engines M&R Testing | | | | | | |
| 1 Engine lbs/hr | 5.98 | 0.645 | 0.306 | 0.008 | 0.024 | - |
| 1 Engine lbs/day | 5.98 | 0.645 | 0.306 | 0.008 | 0.024 | - |
| 1 Engine TPY | 0.06 | 0.006 | 0.003 | 0.0001 | 0.0001 | 7.7 |
| 3 Engines lbs/day | 17.94 | 1.934 | 0.92 | 0.024 | 0.073 | - |
| 3 Engines TPY | 0.18 | 0.02 | 0.009 | 0.0002 | 0.0007 | 23 |
| QSX15 Engines Emergency OPs | | | | | | |
| 1 Engine lbs/hr | 5.98 | 0.645 | 0.306 | 0.008 | 0.024 | - |
| 1 Engine lbs/day | 143.5 | 15.5 | 7.35 | 0.19 | 0.58 | - |
| 1 Engine TPY | 0.299 | 0.032 | 0.015 | 0.0001 | 0.001 | 38.5 |
| 3 Engines lbs/hr | 17.94 | 1.934 | 0.92 | 0.024 | 0.073 | - |
| 3 Engines lbs/day | 430.5 | 46.4 | 22.05 | 0.58 | 1.74 | - |
| 3 Engines TPY | 0.897 | 0.097 | 0.046 | 0.001 | 0.004 | 116 |
| Total TPY | 1.08 | 0.116 | 0.055 | 0.001 | 0.004 | 139 |
| See scenario descriptions above. | | | | | | |

| Table 3 BAAQMD 120 Hour per Year Emissions Summation (tons per year) | | | | | | |
|--|-------------------|-------|-------|-----------------|-------------------------------------|-------------------|
| Engines | NO _x | CO | VOC | SO ₂ | PM ₁₀ /PM _{2.5} | CO ₂ e |
| QSK95 | 23.72 (13.05)* | 9.49 | 2.99 | 0.09 | 0.28 | 9359 |
| QSX15 | 1.08 | 0.116 | 0.055 | 0.001 | 0.004 | 139 |
| Total All Sources | 24.8 (14.13)** | 9.6 | 3.0 | 0.09 | 0.28 | 9498 |
| See BAAQMD scenario description above. These values are NOT the NSR applicability values. * The 5.39 tpy scenario represents the use of the composite emission factor which allows for 15 minutes of catalyst warmup. ** Total with composite emission factor in place of the Tier 2 D2 cycle weighted emissions factor data | | | | | | |

| Table 4 Toxic Air Contaminant (DPM) Emissions from the Proposed Engines (per engine basis) Maintenance and Readiness Testing | |
|---|--------------|
| Scenario | QSK95 |
| Maximum Annual, lbs/yr | 3.06 |
| Maximum Hourly, lbs | 0.153 |
| Scenario | QSK15 |
| Maximum Annual, lbs/yr | 0.48 |
| Maximum Hourly, lbs | 0.024 |
| Notes: DPM is the approved surrogate compound for diesel fuel combustion for purposes of health risk assessment. DPM emission factor based on 0.015 g/bhp-hr | |

| Table 5 Engine Fuel Use Values-Maintenance and Readiness Testing | |
|---|---|
| Scenario | Fuel Use, gallons (per engine basis) |
| QSK95 Maximum Annual, gals/yr | 4440 |
| QSK95 Maximum Hourly, gals/hr | 222 |
| QSK15 Maximum Annual, gals/yr | 680 |
| QSK15 Maximum Hourly, gals/hr | 34 |
| Annual gallons based on 20 hrs/yr at 100% load. | |
| Total Annual Fuel Use (All Engines) | |
| Annual Fuel Use, gals/yr | 161,880 |

Revised Impact Assessment

The following tables summarize the revised modeled concentrations based on the 20 hours per year of operation and the use of DPF, with the exception of the operational HRA where the engines were assumed to operate 50 hours per year (with DPF). The use of the Tier 4 engines will require post combustion controls in the form of Selective Catalytic Reduction (SCR). The use of SCR will increase the stack exit diameter to 34 inches and will increase the stack exit temperature to 872 degrees Fahrenheit. The revised exhaust flow rate is 23,910 cubic feet per minute (cfm). The placement and stack heights of each engine have not been modified.

The new stack parameters were modeled, and the tables below reflect the new operations of the project along with the combined impacts of both construction and operation of two of the completed data centers. The construction emissions presented below have not changed from the previous analysis. Based on the new stack parameters, there is a decrease in the annual modeled impacts. As noted in the summary tables below, the modeling summaries of the M&R testing for NO_x present both the composite emissions to

represent warmup along with the D2 cycle weighted modeling results. Updated background air quality summaries for the years 2017-2019 are provided in Attachment 1B.

| Table 6 Modeled Concentrations and Ambient Air Quality Standards | | | | | | |
|---|--|--|---|------------------------------------|--|--------|
| Pollutant | Averaging Period | Maximum Concentration ($\mu\text{g}/\text{m}^3$) | Background ($\mu\text{g}/\text{m}^3$) | Total ($\mu\text{g}/\text{m}^3$) | Ambient Air Quality Standards ($\mu\text{g}/\text{m}^3$) | |
| | | | | | CAAQS | NAAQS |
| <i>3-/8-/24-Hour Maxima shown for one larger QSK95 engine operating up to 6 hours/day (conservatively represents six engines operating 1 hour/day each) or one smaller QSK15 engine operating up to 3 hours/day (conservative represents three engines operating 1 hour/day each) during the ten hours from 7AM to 5PM.</i> | | | | | | |
| NO ₂ * | 1-hour maximum (CAAQS) | N/A | N/A | 288.9 (251.5) ¹ | 339 | - |
| | 5-yr average of 1-hour yearly 98th % (NAAQS)** | N/A | N/A | 94.6 | - | 188 |
| | Annual maximum | 3.29 | 22.6 | 25.9 | 57 | 100 |
| CO | 1-hour maximum | 87.2 | 2,863 | 2,950.2 | 23,000 | 40,000 |
| | 8-hour maximum | 27.5 | 2,405 | 2,432.5 | 10,000 | 10,000 |
| SO ₂ | 1-hour maximum (CAAQS) | 0.78 | 38 | 18.9 | 655 | - |
| | 5-yr average of 1-hour yearly 99 th % (NAAQS)** | 0.003 | 7 | 7.1 | - | 196 |
| | 3-hour maximum | 0.68 | 38 | 38.7 | - | 1,300 |
| | 24-hour maximum | 0.21 | 4 | 4.2 | 105 | 365 |
| | Annual maximum | 0.004 | 0.5 | 0.5 | - | 80 |
| PM ₁₀ | 24-hour maximum (CAAQS) | 0.34 | 122 | 122.3 | 50 | - |
| | 24-hour 6 th highest over 5 years (NAAQS) | 0.28 | 112 | 112.3 | - | 150 |
| | Annual maximum (CAAQS) | 0.013 | 23 | 23.0 | 20 | - |

| Table 6 Modeled Concentrations and Ambient Air Quality Standards | | | | | | |
|--|---|--|---|------------------------------------|--|-------|
| Pollutant | Averaging Period | Maximum Concentration ($\mu\text{g}/\text{m}^3$) | Background ($\mu\text{g}/\text{m}^3$) | Total ($\mu\text{g}/\text{m}^3$) | Ambient Air Quality Standards ($\mu\text{g}/\text{m}^3$) | |
| | | | | | CAAQS | NAAQS |
| PM _{2.5} | 5-yr average of 24-hour yearly 98 th % (NAAQS) | 0.23 | 43 | 42.2 | - | 35 |
| | Annual maximum (CAAQS) | 0.013 | 12.8 | 12.8 | 12 | - |
| | 5-yr average of annual concentrations (NAAQS) | 0.012 | 10.5 | 10.5 | - | 12.0 |

¹ This concentration represents the use of the composite emission factor for 1-hour.

*1-hour NO₂ impacts are evaluated using the USEPA Plume Volume Molar Ratio Method (PVMRM) and an in-stack NO₂/NO_x ratio of 0.10 (10%), with appropriate maximum seasonal hourly NO₂ background values already added by AERMOD. Annual NO₂ impacts are evaluated with the USEPA Ambient Ratio Method #2 (ARM2) with USEPA-default minimum/maximum NO₂/NO_x ambient ratios of 0.5/0.9.

** Impacts for the 1-hour statistical-based NO₂ and SO₂ NAAQS are based on the annual average emissions per USEPA guidance documents for intermittent sources like emergency generators. Impacts for the 1-hour NO₂ and SO₂ CAAQS are based on the 1-hour emission rate since these CAAQS are "values that are not to be exceeded".

| TABLE 7 Modeled Maximum Construction Impacts | | | | | | |
|--|---------------------|---|---|---|--|--|
| Pollutant | Averaging Time | Maximum Construction Impacts ($\mu\text{g}/\text{m}^3$) | Background ($\mu\text{g}/\text{m}^3$) | Total Impact ($\mu\text{g}/\text{m}^3$) | State Standards ($\mu\text{g}/\text{m}^3$) | Federal Standards ($\mu\text{g}/\text{m}^3$) |
| NO ₂ | 1-hour | 19.97 | 162 | 182 | 339 | - |
| | 1-hour | 14.8 | 102 | 110 | - | 188 |
| | Annual | 1.47 | 22.6 | 25.6 | 57 | 100 |
| SO ₂ | 1-hour | 0.05 | 38 | 18.2 | 655 | 196 |
| | 3-hour | 0.03 | 38 | 18.1 | - | 1300 |
| | 24-hour | 0.01 | 4 | 2.9 | 105 | 365 |
| | Annual | 0.005 | 0.5 | 0.5 | - | 80 |
| CO | 1-hour | 25.7 | 2,863 | 2,889 | 23,000 | 40,000 |
| | 8-hour | 11.1 | 2,405 | 2,416 | 10,000 | 10,000 |
| PM ₁₀ | 24-hour | 3.58 | 122 | 125.6 | 50 | 150 |
| | Annual ^a | 1.3 | 23 | 24.4 | 20 | - |

| | | | | | | |
|--|-----------------------------|-------------|------------|--------------|---------|------------|
| PM2.5 | 24-hour Annual ^a | 1.7 0.59 | 43 12.8 | 43.7 13.4 | - 12 | 35 12.0 |
| Notes: ^a Maximum Annual Arithmetic Mean. | | | | | | |

The health risk impact analyses were not revised from the previous assessments as the use of a diesel particulate filter (DPF) was already incorporated into the risk assessment. The use of DPF satisfies the requirements of the Tier 4 emission limitations. As noted previously, the new annual impacts are smaller than the prior analysis and thus, there would be a reduction in the overall risk. The previous analyses are summarized below.

| Table 8 Operations Residential Risk Results | | | | |
|---|-------------------------|--------------------|-------------------|-----------------|
| Receptor ID | Receptor, UTM | Cancer Risk | Chronic HI | Acute HI |
| PMI | 30, 608154.6, 4121397.9 | 2.61E-5 | 0.00604 | - |
| MEIR | 6493, 608800, 4121050 | 2.98E-6 | 0.00069 | - |
| MEIS | 6588, 608900, 4120900 | 2.21E-6 | 0.00051 | - |
| Assumes each engine is tested for 50 hours per year. Permit limit will be 20 hours per year per engine. DPM is the surrogate compound for equipment diesel exhaust. No acute REL has been established for DPM. FAH=1 for all age groups from 3 rd trimester to 16 years. MEIS – Los Paseos School | | | | |

| Table 9 Operations Worker Results | | | | |
|--|-------------------------|--------------------|-------------------|-----------------|
| Receptor ID | Receptor, UTM | Cancer Risk | Chronic HI | Acute HI |
| PMI | 30, 608154.6, 4121397.9 | 7.85E-6 | 0.00604 | - |
| MEIW | 3572, 608220, 4121360 | 5.06E-6 | 0.00389 | - |
| MEIS | 6588, 608900, 4120900 | 6.65E-7 | 0.00051 | - |
| Assumes each engine is tested for 50 hours per year. Permit limit will be 20 hours per year per engine. DPM is the surrogate compound for equipment diesel exhaust. No acute REL has been established for DPM. FAH not used. MEIS – Los Paseos School | | | | |

| Table 10 Construction Risk Results | | | | |
|---|-------------------------|--------------------|-------------------|-----------------|
| Receptor ID | Receptor, UTM | Cancer Risk | Chronic HI | Acute HI |
| PMI | 30, 608154.6, 4121397.9 | 3.69E-5 | 0.0161 | - |
| MEIR | 6493, 608800, 4121050 | 3.59E-6 | 0.0016 | - |
| MEIW | 3500, 608200, 4121340 | 3.77E-6 | 0.0139 | - |
| MEIS | 6588, 608900, 4120900 | 2.74E-6 | 0.0011 | - |
| DPM is the surrogate compound for construction equipment diesel exhaust. No acute REL has been established for DPM. 4.3 year construction period (HRA used 5 year exposure period.) FAH=1 for all age groups from 3 rd trimester to 16 years, for MEIR and MEIS. FAH not used for MEIW. MEIS – Los Paseos School | | | | |

Construction and Revised Operation Overlap Assessment

From the previous overlap assessment, CalEEMod was run for the periods, including the downtime periods between phases, using the equipment data and use rates as supplied by the applicant. Table 11 presents the previous summary of construction emissions for the project for each pollutant in terms of tons/year for the maximum emissions year by pollutant.

| Table 11 Construction Emissions Tables from CalEEMod 7-1-2020 | | | | | | | |
|---|-----------------------|-----------|------------|-----------------------|----------------------------------|----------------------------------|------------------------|
| Scenario | NO_x | CO | VOC | SO_x | PM10 | PM2.5 | CO₂e |
| Max Const Year by Pollutant | 2021 | 2021 | 2024 | 2021 | 2021/20 | 2021/20 | NA |
| Max Project Emissions, Tons/Yr | 3.93 | 4.41 | 4.26 | 0.0086 | 0.205 exhaust 0.294 fugitives | 0.203 exhaust 0.149 fugitives | 830* |
| Avg. Daily Emissions, Lbs | 29.77 | 33.41 | 32.27 | 0.065 | 1.55 exhaust 2.27 fugitives | 1.54 exhaust 1.14 fugitives | NA |
| BAAQMD Thresholds, Lbs/day | 54 | NA | 54 | NA | 82 | 54 | NA |
| Exceeds Thresholds | No | NA | No | NA | No | No | NA |
| Notes: PM10 and PM2.5 thresholds are exhaust only. Construction schedule is approximately 52 months (3 Phase total), or ~1144 workdays (22 days/month). Max construction year is 12 months at 22 days/month = 264 workdays. *CO ₂ e converted from MT to short tons. Total CO ₂ e for the entire construction period is 3241 mtons (3573 short tons). Source: ADI CalEEMod analysis, January 2020, updated June 2020. | | | | | | | |

The start date for engine operations subsequent to completion of Phase 1 (SV12) will occur at some point during the interim period between the end of Phase 1 and the start of construction of Phase 2 (SV18). The actual start date is unknown, and is materially not relevant, i.e., for purposes of emissions overlap, all of the engines are assumed to be operated under normal maintenance and readiness testing prior to the start of construction of Phase 2. The same situation is expected for the interim period between Phase 2 and Phase 3 (SV19), i.e., all of the engines for SV12 and SV18 are assumed to be operated under normal maintenance and readiness testing prior to the start of construction of Phase 3.

Based on the above, there will be an overlap of emissions during construction of Phase 2 and Phase 3. Table 2 presents a summation of construction emissions for each phase as derived from the revised CalEEMod analysis.

| Table 12 Construction Phase Emissions Summary (tons per period) | | | | | | |
|--|------------|-----------|------------|------------|----------------------------|----------------------------|
| Phase | NOx | CO | VOC | SOx | PM10 | PM2.5 |
| Phase 1 | 6.83 | 6.65 | 4.54 | 0.0137 | Total 0.84 Exhaust 0.32 | Total 0.54 Exhaust 0.31 |
| Phase 2 | 5.04 | 5.98 | 4.41 | 0.012 | Total 0.55 Exhaust 0.27 | Total 0.36 Exhaust 0.27 |
| Phase 3 | 4.94 | 5.87 | 4.40 | 0.011 | Total 0.55 Exhaust 0.27 | Total 0.36 Exhaust 0.27 |

Notes: There is no emissions overlap for Phase 1, and no overlap analysis for Phase 1 is presented herein.

Determination of the Worst-Case Overlap Scenario

Scenario 1 – is defined as the overlap of the emissions from the Phase 1 engines (13 total) and the construction emissions from Phase 2.

Scenario 2 - is defined as the overlap of the emissions from the Phase 1 and 2 engines (26 total) and the construction emissions from Phase 3.

Even though the construction emissions for Phase 2 are just slightly higher than Phase 3, the addition of the engine emissions from Phases 1 and 2 result in higher emissions overall, as compared to the summation of Phase 2 construction and Phase 1 engine emissions. Table 13 presents a recap of Phase 3 construction emissions and emissions from the engines from Phase 1 and 2.

For purposes of an overlap analysis, Scenario 2 as defined above, was chosen as the worst case.

Table 13 Phase 3 Emissions for Overlap Analysis (Worst Case-Scenario 2)

| Phase 3 Construction Emissions (17 Months) | | | | | | | | |
|--|-----------------------|-----------|------------|-----------------------|---------------------|-----------------------|----------------------|------------------------|
| Parameter | NO_x | CO | VOC | SO_x | PM10 Exhaust | PM10 Fugitives | PM2.5 Exhaust | PM2.5 Fugitives |
| Tons/Period | 4.94 | 5.87 | 4.40 | 0.011 | 0.27 | 0.28 | 0.27 | 0.09 |
| Avg Lbs/Month | 581.2 | 690.6 | 517.6 | 1.29 | 31.76 | 32.9 | 31.76 | 10.6 |
| Avg Lbs/day | 26.4 | 31.4 | 23.5 | 0.06 | 1.44 | 1.5 | 1.44 | 0.48 |
| Avg Lbs/hour | 3.30 | 3.94 | 2.94 | 0.0075 | 0.18 | 0.19 | 0.18 | 0.06 |
| Engine Operations Emissions for Phase 1 and 2 During Phase 3 Construction (17 Months) | | | | | | | | |
| Tons/Period | 15.4 | 1.77 | 0.81 | 0.017 | 0.052 | - | 0.052 | - |
| Phase 3 Construction Plus Phase 1 and 2 Engine Emissions for the 17 Month Period | | | | | | | | |
| Tons/Period | 20.3 | 7.6 | 5.2 | 0.03 | 0.32 | 0.28 | 0.32 | 0.09 |
| <p>Table Assumptions from CalEEMod applicant data:</p> <ol style="list-style-type: none"> 1. Construction period is 6-1-26 through 12-1-27, total of 17 months. 2. 22 average work days per month, equals 374 work days. 3. 10 hours per day, 5 days per week. 4. Total CO2e for Phase 3 construction is 1003 metric tons (1103 short tons). 5. Work day is 10 hours, but accounting for lunch and daily breaks, an average work day is approximately 8 hours for purposes of emissions estimates. 6. Operations emissions for Phases 1 and 2 are for the 17-month construction period for Phase 3 based on the BAAQMD Scenario, with only 26 of the engines in operation. | | | | | | | | |

Criteria Pollutant Impacts for Scenario 2

In order to model the worst-case impact for Scenario 2, the emissions in Table 13 for the tons/period, which are based on a 17-month period, were normalized over 12 months by taking the average pounds/month and multiplying by 12 months to calculate the annualized emissions in terms of tons/year. Table 14 presents these emissions which were used in the criteria pollutant analysis as well as the subsequent health risk assessment. Operational testing of the diesel backup generators at SV12 and SV18 were based on the following assumptions:

- 20 hours per year per engine, comprised of 20 hours of full load emissions based on the use of Tier 2 cycle weighted data described earlier.
- Six (6) engines tested per day
- Only one (1) engine tested per hour
-

| Table 14 Normalized Annual Const Emissions for Phase 3 | | | | | | | | |
|---|-----------------------|-----------|------------|-----------------------|---------------------|---------------------|----------------------|----------------------|
| Parameter | NO_x | CO | VOC | SO_x | PM10 Exh | PM10 Fug | PM2.5 Exh | PM2.5 Fug |
| Lbs avg month * | 581.2 | 690.6 | 577.6 | 1.29 | 31.76 | 32.9 | 31.76 | 10.6 |
| Lbs/Yr** | 6974.4 | 8287.2 | 6931.2 | 15.48 | 381.1 | 394.8 | 381.1 | 127.2 |
| Lbs/day | 26.42 | 31.39 | 26.25 | 0.059 | 1.44 | 1.5 | 1.44 | 0.48 |
| Lbs/hr | 3.30 | 3.92 | 3.28 | 0.0074 | 0.18 | 0.188 | 0.18 | 0,06 |
| *based on the 17-month construction period | | | | | | | | |
| **Avg month x 12 months | | | | | | | | |
| Workdays per year = 22 days per month x 12 months = 264 | | | | | | | | |
| Avg work hours per day = 8 | | | | | | | | |

The same background ambient air quality levels and modeling techniques from the modeling analyses of project operating impacts were used in the construction analysis. The applicable background concentrations of NO₂, SO₂, CO, PM2.5, and PM10 from the operational modeling analyses used in the construction impact analysis are shown in the following table. The USEPA-approved model AERMOD (version 19191) was used to estimate ambient impacts from construction activities, consistent with the facility operational impact analyses and the version of AERMET (version 18081) used by BAAQMD to process the meteorological data from the San Jose and Oakland Airports. A detailed discussion of the AERMOD dispersion model and the associated processing programs AERSURFACE, AERMET, and AERMAP is included with the discussion of the modeling analyses of project operating impacts. As with the operational impact analysis, the meteorological data were processed by BAAQMD in accordance with USEPA guidance using the new USEPA default option U*.

The emission sources for the construction site were grouped into two categories: exhaust emissions and dust emissions. Combustion equipment exhaust emissions were modeled as 11 3.048-meter-high point sources (exhaust parameters of 750 Kelvins, 64.681 m/s exit velocity, and 0.1524-meter stack diameter) placed at regular 30-meter intervals around the construction area of SV19. Construction fugitive dust emissions were modeled as an area source covering the construction area with an effective plume height of 0.5 meters. Combustion and fugitive emissions were assumed to occur for 10 hours/day (7 AM to 5 PM) consistent with the expected period of onsite construction activities generating both exhaust emissions and fugitive dust. The construction impacts modeling analysis used the same receptor locations and

meteorological data as used for the project operating impact analysis. A detailed discussion of the receptor locations and meteorological data is included with the discussion of the modeling analyses of project operating impacts.

Modeling Results

Based on the emission rates of operational emissions (SV12 and SV19) plus the construction emissions for SV19 of NO_x, SO₂, CO, PM2.5, and PM10, the modeling options, receptor grids, and meteorological data, AERMOD calculated the short-term and annual ambient impacts for each pollutant. As mentioned above, the modeled 1-hour, 3-hour 8-hour, and 24-hour ambient impacts are based on the worst-case daily emission rates of NO_x, SO₂, CO, PM2.5, and PM10 spread over the estimated daily hours of operation. The annual impacts are based on the annual emission rates of these pollutants. The 1-hour and annual average concentrations of NO₂ were computed using plume volume molar ratio method with a NO₂/NO_x ratio of 0.1.

The modeling analysis results are shown in Table 15 below, including the appropriate background levels and the resulting total ambient impacts. Modeled construction impacts due to facility emissions alone for all pollutants are expected to be below the most stringent state and Federal standards.

| TABLE 15 MODELED MAXIMUM COMBINED OPERATIONS/CONSTRUCTION OVERLAP IMPACTS | | | | | | |
|--|-----------------------|---|--------------------------------------|--|---|---|
| Pollutant | Averaging Time | Maximum Overlap Impacts (µg/m³) | Background (µg/m³) | Total Impact (µg/m³) | State Standards (µg/m³) | Federal Standards (µg/m³) |
| NO ₂ | 1-hour C | 289.1 | - | 389.1 | 339 | - |
| | 1-hour N | 91.8 | - | 91.8 | - | 188 |
| | Annual | 3.55 | 24.5 | 28.1 | 57 | 100 |
| SO ₂ | 1-hour | 0.72 | 18.1 | 18.8 | 655 | 196 |
| | 3-hour | 0.69 | 18.1 | 18.7 | - | 1300 |
| | 24-hour | 0.21 | 2.9 | 3.1 | 105 | 365 |
| | Annual | 0.006 | 0.5 | 0.5 | - | 80 |
| CO | 1-hour | 81.83 | 2,863 | 2,944.9 | 23,000 | 40,000 |
| | 8-hour | 51.87 | 2,405 | 2,456.9 | 10,000 | 10,000 |
| PM10 | 24-hour | 6.0 | 122 | 128.0 | 50 | 150 |
| | Annual ^a | 1.7 | 23.1 | 24.8 | 20 | - |
| PM2.5 | 24-hour | 1.4 | 42 | 43.4 | - | 35 |
| | Annual ^a | 0.6 | 12.8 | 13.4 | 12 | 12.0 |

Notes:
^a Maximum Annual Arithmetic Mean.

HRA Impacts for Scenario 2

Based on the dispersion modeling results presented above and the reduction in the annual impacts, a revised health risk assessment for the emissions overlap period was not performed as there would be a slight decrease in the overall risk results. The prior analyses are presented below.

The HRA was previously performed using HARP (ADMRT Version 19121). The HRA was performed for diesel particulate matter (DPM) only, as DPM is the accepted surrogate compound for whole diesel exhaust. The necessary output files from AERMOD were imported into HARP. Detailed descriptions of the risk assessment methods and support data are contained in the SPPE application document and are not repeated here. Assumptions used in the prior HRA analysis are as follows:

- The standard project receptor file was used. This file contained an extensive cartesian grid of receptors as well as the identified sensitive receptors included in the other project modeling analyses.
- The BAAQMD health tables were used (enabled in HARP)
- Three separate analyses were run as follows:
 - a. Residential run, FAH=defaults, 2-year exposure period (see note below)
 - b. Residential run, FAH=1, 2-year exposure period (see note below)
 - c. Worker run, FAH=off, 2-year exposure period (see note below)

Note: HARP does not allow fractions of years as exposure values, therefore a 2-year period was used to represent the 17-month emissions overlap.
- The PMI, MEIR, MEIW, and MEIS values were derived from the HRA output files.

| Table 16 Construction/Operations Overlap Risk Results | | | | |
|--|-----------------------|--------------------|-------------------|-----------------|
| Receptor ID | Receptor, UTM | Cancer Risk | Chronic HI | Acute HI |
| PMI | 44, 607975.6, 4121426 | 4.86E-5 | 0.0291 | - |
| MEIR | 6493, 608800, 4121050 | 2.31E-6 | 0.0014 | - |
| MEIW | 3292, 608140, 4121300 | 1.02E-6 | 0.0094 | - |
| MEIS | 6588, 608900, 4120900 | 1.91E-6 | 0.0011 | - |

Testing hours for the overlap of construction and operation was set to 20 hours per engine.
 DPM is the surrogate compound for construction equipment diesel exhaust. No acute REL has been established for DPM.
 Phase 3 construction period is 17 months (HRA used 2-year exposure period.)
 FAH=1 for all age groups from 3rd trimester to 16 years, for MEIR and MEIS.
 FAH not used for MEIW.
 MEIS – Los Paseos School

Attachments

Attachment 1A CEC and BAAQMD Tier 4 engine emissions scenarios

Attachment 1B 2017-2019 Background Air Quality Summaries

All modeling input and output files, support files, and HRA files will be supplied in electronic format.

Attachment 1A

Table 1A-1 Emissions Estimates for Emergency Standby Generators

| | | | | | | | | | | | | | | | |
|--|-----------------|-------------|------------|--|------------------|------------------------------|---------------------|---------------------|--------------------|-----------------|-----------------|-----------------------|--|-------------------------|---------------------|
| Engine Mfg: | Cummins | # of Units: | 36 | Max # of Engines Tested per Day: | 6 | Redundant Engines: | 6 | | | | | | | | |
| Model #: | QSK95-G9 | | | <i>(engines are not tested concurrently)</i> | | | | | | | | | | | |
| Fuel: | ULSD | | | Engine OPs Data | | | | | | | | | | | |
| | | | | | | | METRIC UNITS | | | | | | | | |
| | | | | | | | | | | | | | | | |
| Fuel S, %wt: | 0.0015 | BHP | kWe | Load % | RPM | Fuel, gph | Stk Ht, ft | Stk Diam, in | Stk Temp, F | mmbtu/hr | Stk ACFM | Stack Vel, f/s | Stk Diam, m | Stk Temp, Kelvin | Stk Vel, m/s |
| Fuel wt, lb/gal: | 7.05 | 4631 | 3250 | 100 | 1800 | 222 | TBD | 32 | 872 | 30.86 | 23910 | 71.3511 | 0.8128 | 739.82 | 21.7478 |
| Btu/gal: | 139000 | 3501 | 2438 | 75 | 1800 | 171 | TBD | 32 | 735 | 23.77 | 20454 | 61.0379 | 0.8128 | 663.71 | 18.6044 |
| Lbs S/1000 gal: | 0.10575 | 2371 | 1625 | 50 | 1800 | 126 | TBD | 32 | 672 | 17.51 | 16885 | 50.3875 | 0.8128 | 628.71 | 15.3581 |
| Lbs SO2/1000 gal: | 0.2115 | 1240 | 813 | 25 | 1800 | 72 | TBD | 32 | 643 | 10.01 | 10587 | 31.5932 | 0.8128 | 612.59 | 9.6296 |
| EPA Tier: | 4 | 562 | 325 | 10 | 1800 | 42 | TBD | 32 | 541 | 5.84 | 7187 | 21.4471 | 0.8128 | 555.93 | 6.5371 |
| Turbocharged: | Yes | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0.00 | 0 | 0.0000 | 0.0000 | 0 | 0.0000 |
| Aftercooled: | Yes | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | |
| Warm-up Period, mins. | 15 | 0.25 | hrs. | 0.75 | Steady-state hrs | | | | | | | | | | |
| Maintenance and Readiness Testing, hrs/yr: | | | | 20 | | Composite CO2e EF, lb/mmbtu: | | | 163.052 | | | | (40 CFR 98, Subpart C, Tables C-1 and C-2) | | |
| Emergency Runtime, hrs/yr: | | | | 100 | | | | | | | | | (40 CFR 98, Subpart A, Table A-1) | | |

1. Emissions factors for engines without controls are based on D2 Cycle values for the specific engine and size.
2. Emissions factors for engine steady-state periods are based on Tier 4 values for the specific engine and size.
3. Composite warm-up/steady state hour will be based on 0.25 hr warmup (D2) and 0.75 hr steady-state (Tier 4).
4. All scenarios employ DPF (D2 Cycle and Tier 4)

| | Nox | CO | g/bhp-hr | | | |
|---------------------|------------|-----------|-----------------|------------|-----------------|-----------|
| | | | VOC | SOx | PM10/2.5 | |
| D2 Cycle EFs | 4.37 | 0.5 | 0.23 | 0.005 | 0.015 | with DPFs |
| T4 Steady-state EFs | 0.5 | 0.5 | 0.14 | 0.005 | 0.015 | with DPFs |
| Composite Hour EFs | 1.4675 | 0.5 | 0.1625 | 0.005 | 0.015 | with DPFs |

Scenario 1 CEC Emissions Evaluation

1. 20 hrs of maintenance and readiness (M&R) testing at 100% load, using D2 Cycle EFs
2. 100 hrs of emergency ops, in 3 hr blocks (1st hr composite warmup+steady state, remaining 2 hrs at steady state T4), 100% load
3. Redundant engines will not be run during emergency ops
4. Daily M&R-engines will be tested consecutively, i.e., one engine per hour

M&R Testing

| Hrs/engine/yr: | | Nox | CO | VOC | SOx | PM10/2.5 | CO2e |
|----------------|---------|------------|-----------|------------|------------|-----------------|-------------|
| 20 | | | | | | | |
| 1 Engine | lbs/hr | 44.62 | 5.10 | 2.35 | 0.05 | 0.15 | NA |
| 1 Engine | lbs/day | 44.62 | 5.10 | 2.35 | 0.05 | 0.15 | NA |
| 1 Engine | TPY | 0.446 | 0.051 | 0.023 | 0.001 | 0.002 | 50.3 |
| 6 Engines | lbs/day | 267.7 | 30.6 | 14.1 | 0.31 | 0.92 | NA |
| All Engines | TPY | 16.06 | 1.84 | 0.85 | 0.02 | 0.06 | 1811 |

Emergency Ops

| | | | Single Engine | | | | | | |
|-------------------|------|---------------------|---------------|------------|------------|------------|------------|------------|--------|
| Hrs/engine/yr: | | | Nox | CO | VOC | SOx | PM10/2.5 | CO2e | |
| 100 | | | | | | | | | |
| Warmup hrs: | 33.3 | 1st Hr | lbs/yr | 498.92 | 169.99 | 55.25 | 1.70 | 5.10 | 167548 |
| Steady state hrs: | 66.7 | 2 Hrs | lbs/yr | 340.492185 | 340.492185 | 95.3378117 | 3.40492185 | 10.2147655 | 335598 |
| # engines: | 30 | Total | lbs/yr | 839.42 | 510.48 | 150.58 | 5.10 | 15.31 | 503146 |
| | | 1 engine | Max lbs/3hr | 20.09 | 10.21 | 3.09 | 0.10 | 0.31 | NA |
| | | | 30 Engines | | | | | | |
| | | | TPY | Nox | CO | VOC | SOx | PM10/2.5 | CO2e |
| | | | TPY | 12.59 | 7.66 | 2.26 | 0.08 | 0.23 | 7547 |
| | | 30 engines | Max lbs/3hr | 602.63 | 306.29 | 92.65 | 3.06 | 9.19 | NA |
| | | | TPY | Nox | CO | VOC | SOx | PM10/2.5 | CO2e |
| | | M&R + Emergency Ops | TPY | 28.65 | 9.49 | 3.10 | 0.09 | 0.28 | 9359 |

Scenario 2 BAAQMD Emissions Evaluation

1. 20 hrs of maintenance and readiness (M&R) testing at 100% load, using D2 Cycle EFs
2. 100 hrs of emergency ops, 100% load, T4 EFs
3. Redundant engines will not be run during emergency ops
4. Daily M&R-engines will be tested consecutively, i.e., one engine per hour

M&R Testing

| Hrs/engine/yr: | | | Nox | CO | VOC | SOx | PM10/2.5 | CO2e |
|----------------|-------------|---------|-------|-------|-------|-------|----------|------|
| 20 | | | | | | | | |
| | 1 Engine | lbs/hr | 44.62 | 5.10 | 2.35 | 0.05 | 0.15 | NA |
| | 1 Engine | lbs/day | 44.62 | 5.10 | 2.35 | 0.05 | 0.15 | NA |
| | 1 Engine | TPY | 0.446 | 0.051 | 0.023 | 0.001 | 0.002 | 50.3 |
| | 6 Engines | lbs/day | 267.7 | 30.6 | 14.1 | 0.31 | 0.92 | NA |
| | All Engines | TPY | 16.06 | 1.84 | 0.85 | 0.02 | 0.06 | 1811 |

Emergency Ops

| | | | Single Engine | | | | | | |
|-----------------|----|---------------------|---------------|----------|----------|--------|----------|----------|------|
| Hrs/engine/yr: | | | Nox | CO | VOC | SOx | PM10/2.5 | CO2e | |
| 100 | | | | | | | | | |
| Hrs/engine/day: | 24 | | | | | | | | |
| # engines: | 30 | | | | | | | | |
| | | lbs/hr | 5.10 | 5.10 | 1.43 | 0.05 | 0.15 | NA | |
| | | lbs/day | 122.52 | 122.52 | 34.30 | 1.23 | 3.68 | NA | |
| | | TPY | 0.255 | 0.255 | 0.071 | 0.003 | 0.008 | 251.57 | |
| | | | 30 Engines | | | | | | |
| | | | TPY | Nox | CO | VOC | SOx | PM10/2.5 | CO2e |
| | | | TPY | 153.145 | 153.145 | 42.881 | 1.531 | 4.594 | NA |
| | | lbs/day | 3675.478 | 3675.478 | 1029.134 | 36.755 | 110.264 | NA | |
| | | TPY | 7.657 | 7.657 | 2.144 | 0.077 | 0.230 | 7547 | |
| | | M&R + Emergency Ops | TPY | 23.72 | 9.49 | 2.99 | 0.09 | 0.28 | 9359 |

Table 1A-2 Emissions Estimates for Emergency Standby Generators

| | | | | | | | | | | | | | | | | |
|---|---|---|------------|----------------------------------|------------|--------------------|-------------------|---------------------|--------------------|-----------------|-----------------|------------|--------------------|----------------|---------------------|--|
| Engine Mfg: | Cummins | # of Units: | 3 | Max # of Engines Tested per Day: | 3 | Redundant Engines: | 0 | | | | | | | | | |
| Model #: | QSX15-G9 | <i>(engines are not tested concurrently)</i> | | | | | | | | | | | | | | |
| Fuel: | ULSD | Engine OPs Data | | | | | | | | | | | | | | |
| | | METRIC UNITS | | | | | | | | | | | | | | |
| | | Stack Temp, | | | | | | | | | | | | | | |
| | | Stack Vel, | | | | | | | | | | | | | | |
| Fuel S, %wt: | 0.0015 | BHP | kWe | Load % | RPM | Fuel, gph | Stk Ht, ft | Stk Diam, in | Stk Temp, F | mmbtu/hr | Stk ACFM | f/s | Stk Diam, m | Kelvins | Stk Vel, m/s | |
| Fuel wt, lb/gal: | 7.05 | 731 | 500 | 100 | 1800 | 34 | TBD | 12 | 894 | 4.73 | 3442 | 73.0415 | 0.3048 | 752.04 | 22.2631 | |
| Btu/gal: | 139000 | 554 | 375 | 75 | 1800 | 25.3 | TBD | 12 | 852 | 3.52 | 2771 | 58.8025 | 0.3048 | 728.71 | 17.9230 | |
| Lbs S/1000 gal: | 0.10575 | 378 | 250 | 50 | 1800 | 18.4 | TBD | 12 | 828 | 2.56 | 2245 | 47.6404 | 0.3048 | 715.37 | 14.5208 | |
| Lbs SO2/1000 gal: | 0.2115 | 201 | 125 | 25 | 1800 | 10.4 | TBD | 12 | 719 | 1.45 | 1418 | 30.0909 | 0.3048 | 654.82 | 9.1717 | |
| EPA Tier: | 2 | 96 | 50 | 10 | 1800 | 5.9 | TBD | 12 | 541 | 0.82 | 955 | 20.2657 | 0.3048 | 555.93 | 6.1770 | |
| Turbocharged: | Yes | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0.00 | 0 | 0.0000 | 0.0000 | 0 | 0.0000 | |
| Aftercooled: | Yes | Stack Exit Area (sq.ft) = 0.785398 | | | | | | | | | | | | | | |
| Scenarios | | Emissions Factor Scenarios (all values in g/bhp-hr) | | | | | | | CO2e | | | | | | | |
| | | NOx | CO | VOC | SO2 | PM10 | PM2.5 | lb/mmbtu | | | | | | | | |
| Declared Emergency Ops, 100 hrs/yr, D2 Cycle EFs, 100% Load | | 3.71 | 0.40 | 0.19 | 0.005 | 0.080 | 0.080 | 163.052 | | | | | | | | |
| Maint/Readiness Testing, 20 hrs/yr, D2 Cycle EFs, 100% Load | | 3.71 | 0.40 | 0.19 | 0.005 | 0.080 | 0.080 | 163.052 | | | | | | | | |
| | | 0.00 | 0.00 | 0.00 | 0 | 0.000 | 0.000 | 0 | | | | | | | | |
| APC Installed: | Diesel Particulate Filters | | | | | | | | | | | | | | | |
| | | Controlled Emissions Factor Scenarios (all values in g/bhp-hr) | | | | | | | CO2e | | | | | | | |
| | | NOx | CO | VOC | SO2 | PM10 | PM2.5 | lb/mmbtu | | | | | | | | |
| Declared Emergency Ops, 100 hrs/yr, D2 Cycle EFs, 100% Load | | 3.71 | 0.40 | 0.19 | 0.005 | 0.015 | 0.015 | 163.052 | | | | | | | | |
| Maint/Readiness Testing, 20 hrs/yr, D2 Cycle EFs, 100% Load | | 3.71 | 0.40 | 0.19 | 0.005 | 0.015 | 0.015 | 163.052 | | | | | | | | |
| | | 0.00 | 0.00 | 0.00 | 0 | 0.000 | 0.000 | 0 | | | | | | | | |
| Scenario 1: | Declared Emergency Ops, 100 hrs/yr, D2 Cycle EFs, 100% Load | | | | | | | | | | | | | | | |
| Max Hourly Runtime: | 1 | | | | | | | | | | | | | | | |
| Max Daily Runtime: | 24 | | | | | | | | | | | | | | | |
| Max Annual Runtime: | 100 | | | | | | | | | | | | | | | |
| | | Single Engine | | | | | | | | | | | | | | |
| | | NOx | CO | VOC | SO2 | PM10 | PM2.5 | CO2e | | | | | | | | |
| | lbs/hr | 5.979 | 0.645 | 0.306 | 0.008 | 0.024 | 0.024 | na | | | | | | | | |
| | lbs/day | 143.496 | 15.471 | 7.349 | 0.193 | 0.580 | 0.580 | na | | | | | | | | |
| | TPY | 0.299 | 0.032 | 0.015 | 0.000 | 0.001 | 0.001 | 38.5 | | | | | | | | |
| | | All Engines | | | | | | | | | | | | | | |
| | | NOx | CO | VOC | SO2 | PM10 | PM2.5 | CO2e | | | | | | | | |
| | lbs/hr | 17.937 | 1.934 | 0.919 | 0.024 | 0.073 | 0.073 | na | | | | | | | | |
| | lbs/day | 430.487 | 46.414 | 22.047 | 0.580 | 1.741 | 1.741 | na | | | | | | | | |
| | | All Engines | | | | | | | | | | | | | | |
| | TPY | 0.897 | 0.097 | 0.046 | 0.001 | 0.004 | 0.004 | 115.6 | | | | | | | | |

Scenario 2: Maint/Readiness Testing, 20 hrs/yr, D2 Cycle EFs, 100% Load

| | | | | | | | | |
|---------------------|----|------------|-----------|----------------------|------------|-------------|--------------|-------------|
| Max Hourly Runtime: | 1 | | | | | | | |
| Max Daily Runtime: | 1 | | | | | | | |
| Max Annual Runtime: | 20 | | | | | | | |
| | | Nox | CO | Single Engine | SO2 | PM10 | PM2.5 | CO2e |
| | | lbs/hr | 5.979 | VOC | 0.306 | 0.008 | 0.024 | na |
| | | lbs/day | 5.979 | 0.645 | 0.306 | 0.008 | 0.024 | na |
| | | TPY | 0.060 | 0.006 | 0.003 | 0.000 | 0.000 | 7.706 |
| | | | | 3 Engines | | | | |
| | | Nox | CO | VOC | SO2 | PM10 | PM2.5 | CO2e |
| | | lbs/hr | 5.979 | 0.306 | 0.008 | 0.024 | 0.024 | na |
| | | lbs/day | 17.937 | 1.934 | 0.919 | 0.073 | 0.073 | na |
| | | | | All Engines | | | | |
| | | TPY | 0.179 | 0.019 | 0.009 | 0.0002 | 0.0007 | 23.118 |

Scenario 3:

| | | | | | | | | |
|---------------------|---|------------|-----------|----------------------|------------|-------------|--------------|-------------|
| Max Hourly Runtime: | 0 | | | | | | | |
| Max Daily Runtime: | 0 | | | | | | | |
| Max Annual Runtime: | 0 | | | | | | | |
| | | NOx | CO | Single Engine | SO2 | PM10 | PM2.5 | CO2e |
| | | lbs/hr | 0.000 | VOC | 0.000 | 0.000 | 0.000 | na |
| | | lbs/day | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | na |
| | | TPY | 0.00000 | 0.00000 | 0.00000 | 0.00000 | 0.00000 | 0.000 |
| | | | | 3 Engines | | | | |
| | | NOx | CO | VOC | SO2 | PM10 | PM2.5 | CO2e |
| | | lbs/hr | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | na |
| | | lbs/day | 0.000 | 0.000 | 0.000 | 0.000 | 0.000 | na |
| | | | | All Engines | | | | |
| | | TPY | 0.000 | 0.000 | 0.000 | 0.000 | 0.0000 | 0.000 |

BAAQMD M/R Testing + Emergency Emissions Totals, TPY:

| | | | | | | | |
|----------------------|------------|-----------|------------|------------|-------------|--------------|-------------|
| QX-15 Scenario 1 + 2 | Nox | CO | VOC | SO2 | PM10 | PM2.5 | CO2e |
| | 1.076 | 0.116 | 0.055 | 0.001 | 0.004 | 0.004 | 138.705 |

Application & Performance Warranty Data
Project Information

| | |
|---------------------------|---------------------------------|
| Site Location: | USA |
| Project Name: | Equinix San Jose 3250kW - AT-IV |
| Application: | Standby Power |
| Number Of Engines: | 1 |
| Operating Hours per Year: | 200 |

Engine Specifications

| | |
|------------------------------|--------------------------------|
| Engine Manufacturer: | Cummins |
| Model Number: | QSK95-G9 |
| Rated Speed: | 1800 RPM |
| Generator Power: | 3250 ekW |
| Type of Fuel: | Ultra-Low Sulfur Diesel (ULSD) |
| Type of Lube Oil: | 1 wt% sulfated ash or less |
| Lube Oil Consumption: | 0.1 % Fuel Consumption |
| Number of Exhaust Manifolds: | 2 |

Engine Cycle Data

| Load % | Speed | Power <i>bhp</i> | Exhaust Flow <i>acfm (cfm)</i> | Exhaust Temp. <i>F</i> | Fuel Cons. | NO _x <i>g/bhp-hr</i> | CO <i>g/bhp-hr</i> | NMHC <i>g/bhp-hr</i> | NMNEHC <i>g/bhp-hr</i> | PM ₁₀ <i>g/bhp-hr</i> | O ₂ <i>%</i> | H ₂ O <i>%</i> |
|--------|-------|---------------------|-----------------------------------|---------------------------|------------|------------------------------------|-----------------------|-------------------------|---------------------------|-------------------------------------|----------------------------|------------------------------|
| 25 | Rated | 1,276 | 10,812 | 648 | | | | | | | | |
| 100 | Rated | 4,703 | 24,590 | 874 | | 5.7 | 0.5 | 0.06 | 0.06 | 0.11 | 10 | 12 |

Emission Data (100% Load)

| Emission | Raw Engine Emissions | | | | | | Target Outlet Emissions | | | | | | Calculated Reduction |
|-------------------|----------------------|----------------|----------------------------------|--------------|----------------|-----------------|-------------------------|----------------|----------------------------------|--------------|----------------|-----------------|----------------------|
| | <i>g/bhp-hr</i> | <i>tons/yr</i> | <i>ppmvd @ 15% O₂</i> | <i>ppmvd</i> | <i>g/kW-hr</i> | <i>lb/MW-hr</i> | <i>g/bhp-hr</i> | <i>tons/yr</i> | <i>ppmvd @ 15% O₂</i> | <i>ppmvd</i> | <i>g/kW-hr</i> | <i>lb/MW-hr</i> | |
| NO _x * | 5.7 | 5.91 | 521 | 963 | 7.644 | 16.85 | 0.5 | 0.52 | 46 | 84 | 0.671 | 1.48 | 91.2% |
| CO | 0.5 | 0.52 | 75 | 139 | 0.671 | 1.48 | 2.6 | 2.7 | 390 | 721 | 3.487 | 7.69 | |
| NMHC** | 0.06 | 0.06 | 16 | 29 | 0.08 | 0.18 | 0.14 | 0.15 | 37 | 68 | 0.188 | 0.41 | |
| PM ₁₀ | 0.11 | 0.11 | 39 | 71 | 0.148 | 0.33 | 0.02 | 0.02 | 7 | 13 | 0.027 | 0.06 | 81.8% |
| NH ₃ | 0 | 0 | 0 | 0 | 0 | 0 | 0.08 | 0.08 | 20 | 37 | 0.109 | 0.24 | |

 * MW referenced as NO₂

 ** MW referenced as CH₄. Propane in the exhaust shall not exceed 15% by volume of the NMHC compounds in the exhaust, excluding aldehydes. The 15% (vol.) shall be established on a wet basis, reported on a methane molecular weight basis. The measurement of exhaust NMHC composition shall be based upon EPA method 320 (FTIR), and shall exclude formaldehyde.

System Specifications
SCR/DOC/ADPF System Specifications (SP-AT-IV-10-TBD, ACIS-3, Commissioning & Startup)

| | |
|--|---------------------------------------|
| Design Exhaust Flow Rate: | 24,590 acfm (cfm) |
| Design Exhaust Temperature ¹ : | 874°F |
| SCR Catalyst Volume: | 63 cubic feet |
| System Pressure Loss: | 20.0 inches of WC (Clean) (49.8 mBar) |
| Sound Target: | 70 dBA @ 23 feet |
| Exhaust Temperature Limits: | 572 – 977°F (300 – 525°C) |
| Minimum Regeneration Temperature ¹² : | 500°F (260°C) |
| Reactant: | Urea |
| Percent Concentration: | 32.5% |
| System Dosing Capacity: | 115 L/hr |
| Estimated Reactant Consumption: | 16.3 gal/hr (61.6 L/hr) / Per Engine |

Sound Data

| | Octave Band Center Frequency (OBCF) | | | | | | | | | | | Receiver | |
|--|-------------------------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|----------|----------|
| | Hz | 31.5 | 63 | 125 | 250 | 500 | 1000 | 2000 | 4000 | 8000 | dBA | Angle | Distance |
| Raw Engine Exhaust Sound Levels | | | | | | | | | | | | | |
| Sound Power A-Weighted | dBA | 69.9 | 100.5 | 109.4 | 122.7 | 123.7 | 123.0 | 123.2 | 123.4 | 121.3 | 130.8 | | |
| Calculated Sound Power | dB | 109.4 | 126.7 | 125.6 | 131.4 | 126.9 | 123.0 | 122.0 | 122.4 | 122.4 | 130.8 | | |
| Calculated Sound Pressure | dB | 101.4 | 118.7 | 117.5 | 123.3 | 118.9 | 114.9 | 113.9 | 114.4 | 114.4 | 122.7 | 90° | 3.3 feet |
| Requested Sound Target | | | | | | | | | | | | | |
| Overall Sound Pressure | | | | | | | | | | | 70.0 | 90° | 23 feet |
| Calculated Target Overall Sound Pressure | | | | | | | | | | | 86.9 | 90° | 3.3 feet |
| Sound Performance Estimations(System Sound Attenuation) | | | | | | | | | | | | | |
| Estimated Sound Attenuation | dB | 12.0 | 17.5 | 24.5 | 31.8 | 37.5 | 45.3 | 56.5 | 66.8 | 70.3 | 37.3 | | |
| Estimated Sound Power | dB | 97.4 | 109.2 | 101.1 | 99.6 | 89.4 | 77.7 | 65.5 | 55.6 | 52.1 | 93.5 | | |
| Estimated Sound Pressure | dB | 72.5 | 84.3 | 76.2 | 74.6 | 64.5 | 52.8 | 40.6 | 30.7 | 27.2 | 68.5 | 90° | 23 feet |
| Estimated Sound Pressure | dB | 89.4 | 101.2 | 93.0 | 91.5 | 81.4 | 69.6 | 57.4 | 47.6 | 44.1 | 85.4 | 90° | 3.3 feet |
| Warranted Sound Level | | | | | | | | | | | | | |
| Warranted Sound Pressure | | | | | | | | | | | 86.9 | 90° | 3.3 feet |

- WARNING: Warranted Sound Level does not meet requested Sound Target.
- Computed noise levels at each distance and frequency is based on a *free field condition*.
- Site conditions have *not* been taken into account in acoustic predictions.
- The ambient sound level must be at least 10 dBA below the requested sound target.
- MIRATECH does not warrant Sound Performance Estimations.
- Warranted sound level is of the primary silencer only.
- For all distance noise propagation, free field dispersion rule of 6 dB is used every time distance is doubled.

MIRATECH Scope of Supply & Equipment Details

| | Model Number | Quantity |
|--|--|-------------------|
| Selective Catalytic Reduction Housing | SP-AT-IV-10-TBD | 1 / engine |
| SCR Housing | SP-AT-IV-10-TBD-HSG | 1 / engine |
| • Number of Catalyst Layers | 2.0 | |
| • Number of Spare Catalyst Layers | 1.0 | |
| • Number of Catalyst Blocks per Layer | 88 | |
| • Material | Carbon Steel | |
| • Paint | MIRATECH Coating System II - High Temperature Dark Grey - Insulated Surfaces | |
| • Inlet Pipe Size & Connection | 32 inch FF Flange, 150# ANSI standard bolt pattern | |
| • Outlet Pipe Size & Connection | 32 inch FF Flange, 150# ANSI standard bolt pattern | |
| • Dimensions | 82.000" H x 110.250" W x 266" L | |
| • Weight Without Catalyst | 12,500 lbs | |
| • Weight Fully Loaded With Catalyst | 21,525 lbs | |
| • Insulation | None | |
| Tray Set | Tray Set-AT-IV-10-450mm | 2 / engine |
| SCR Catalyst | SCRC-044-150-450 | 176 / engine |
| AT-IV Module | SP-AT-IV-Module | 10 / engine |
| AT-IV Electronics | SP-AT-IV-Electronics | 4 / engine |
| AT-IV Transformer | SP-AT-IV-Transformer | 4 / engine |
| Oxidation Element | MECB-OXZ-SB3213-2421-19020071 | 1 / engine |
| Oxidation Element | MECB-OXZ-SB4488-2421-19020072 | 1 / engine |
| AT-IV Assembly Kit | SP-AT-IV-10 Assembly Kit | 1 / engine |
| | System Sound Attenuation | 1 / engine |
| SCR Control System | ACIS-3 | 1 / engine |
| SCR Controller | OLC-60-HMI | 1 / engine |
| • Overall Dimensions | 31.181 W x 31.535 H x 12.442 D | |
| • Weight | 110 lbs | |
| Dosing Box | SEN115.lab | 1 / engine |
| Reactant Pump | VPN115.lab | 1 / engine |
| Reactant Filter | FILTER115 | 1 / engine |
| Injector | DEN115.600 | 1 / engine |
| Differential Pressure Sensor | PT.040 | 1 / engine |
| Bypass Probe | NP-18 | 2 / engine |
| Temperature Sensor | TT-14-FLEX60-32-1112 | 2 / engine |
| Air Compressor | CA115.lab | 1 / engine |
| NOx Sensor | NOX-24V | 2 / engine |
| Wiring Harness | BLU-WH-NOX-24V-50-SL | 2 / engine |
| Commissioning & Startup | Commissioning & Startup | 1 / engine |



Model Number

Quantity

Analyzer Charges
Expense Charges
Labor Charges

Analyzer Charges
Expense Charges
Labor Charges

1 / engine
1 / engine
1 / engine

Optional Content MIRATECH Scope of Supply & Equipment Details

| | Model Number | Quantity |
|--------------------------------------|---|-------------------|
| Maintenance Pack | ACIS-3 Maintenance Pack | 1 / engine |
| Maintenance Pack | DEX115.XXX Maintenance Pack | 1 / engine |
| Maintenance Pack | CA115 Maintenance Pack | 1 / engine |
| SCR Parts | 2020.025 | 1 / engine |
| SCR Parts | 2020.0249 | 1 / engine |
| SCR Parts | 2020.0251 | 1 / engine |
| Maintenance Pack | SEN115 Maintenance Pack | 1 / engine |
| SCR Parts | 902.0021 | 1 / engine |
| SCR Parts | 2020.0234 | 2 / engine |
| Maintenance Pack | VPN115 Maintenance Pack | 1 / engine |
| SCR Parts | 601.0021 | 1 / engine |
| Spare Parts | ACIS-3 Recommended Spare Parts | 1 / engine |
| Recommended Spare Parts | OLC Recommended Spare Parts | 1 / engine |
| Spare Part | OLC Fuses & Fuse Holders | 1 / engine |
| Recommended Spare Parts | CA115 Recommended Spare Parts | 1 / engine |
| Recommended Spare Parts | SEN115 Recommended Spare Parts | 1 / engine |
| Recommended Spare Parts | VPN115 Recommended Spare Parts | 1 / engine |
| SCR Reactant Tank | SW550.ht.ins | 1 / engine |
| Reactant Tank | SW550.ht.ins | 1 / engine |
| • Material | Cross-Linked Polyethylene | |
| • Tank Dimensions | 50.5 D x 82 H | |
| • Capacity | 500 US Gallons | |
| • Weight | 130 lbs | |
| • Wall Construction | Single | |
| • Insulation | Nominal 2" of Urethane Spray Foam w/ Mastic Coating | |
| • Heat Trace | Included | |
| • Seismic Tie Downs | None | |
| SCR Reactant Tank | DW550.ht.ins | 1 / engine |
| Reactant Tank | DW550.ht.ins | 1 / engine |
| Reactant Tank Level Indicator | TLI | 1 / engine |
| Reactant Tank Level Indicator | TLI | 1 / engine |
| Level Transmitter | LU20 | 1 / engine |
| Level Controller | LI55 | 1 / engine |
| Level Controller Enclosure | LM92 | 1 / engine |
| 304 Stainless Steel Adder | SP-AT-IVS-10-TBD | 1 / engine |
| Insulation | FIELD/FACTORY-INSTALLED | 1 / engine |

Customer Scope Of Supply


- Support Structure
- Attachment to Support Structure (Bolts, Nuts, Levels, etc.)
- Expansion Joints
- Exhaust Piping
- Inlet Pipe Bolts, Nuts, & Gasket
- Outlet Pipe Bolts, Nuts, & Gasket
- Insulation for Exhaust Piping
- Insulation for Housing
- Installation, Fabrication, and Installation of Mounting Frame for Particulate Filters
- Power Input (230 VAC, 60 Hz, Single Phase)
- Component Installation Including External Tubing and Wiring
- Isolated Engine Load Signal to MIRATECH Equipment (4-20 mA)
- Dry Contact (N.O.) for Engine Run Signal to MIRATECH Equipment
- Heat Tracing of Reactant Lines (Required when Ambient Temperatures are Below 40 °F)
- Heat Tracing of Sample Lines (Required when Ambient Temperatures are Below 32 °F)
- Design for Structural Support and Thermal Expansion

Special Notes & Conditions

1. For housings and exhaust components that are insulated, internally or externally, please refer to Section 7.1 of the General Terms and Conditions of Sale to prevent voiding MIRATECH product warranty.
 - **Emission Equipment:**
 - Carbon steel is suitable for temperatures up to 900° F / 482° C continuously, when covered with external insulation or a heat shield. For continuous operation above 900° F / 482° C, where the equipment is externally insulated or has a heat shield, stainless steel should be used.
 - **Silencers, Accessories and Exhaust Piping:**
 - *Aluminized Steel:*
 - Aluminized steel is suitable for temperatures up to 1100° F / 593° C continuously when covered with insulation or a heat shield.
 - *Carbon Steel:*
 - Carbon steel is suitable for temperatures up to 1100° F / 593° C in intermittent use, i.e., less than 500 hours per year, when covered with external insulation or a heat shield.
 - Silencers (plain carbon steel or aluminized) with internal insulation, and without external insulation or heat shield, are suitable for temperatures up to 1100° F / 593° C continuously.
 - *Stainless Steel:*
 - Stainless steel should be used when the exhaust temperature will exceed 1100° F / 593° C continuously and product is internally or externally insulated.
2. Diesel Particulate Filters depend on exhaust temperature to keep soot regenerated and the filter back pressure within acceptable levels. If the engine will be operated consistently at low loads/low exhaust temperatures, the customer should make provisions to add load via facility operations or a load bank. Refer to the included [Guidelines for Successful Operation of LTR™ DPF](#).
 - A packed silencer installed upstream of the MIRATECH catalyst system will void MIRATECH's limited warranty.
 - Final catalyst housings are dependent on engine output and required emission reductions. Changes may be made to optimize the system design at the time of order.
 - Any drawings included with this proposal are preliminary in nature and could change depending on final product selection.
 - Any sound attenuation listed in this proposal is based on housing with catalyst elements installed.
 - MIRATECH Corporation warrants that the emissions reductions requested for this inquiry will be achieved at the design and test load point as outlined in the proposal. Tier 4 is an engine certificate designation, not an actual tons/yr or g/bhp-hr measurement. MIRATECH will utilize the engine manufacturer's emission data at 100% load to provide our warranty. This is the maximum volume potential point for pollutants to be emitted. Permitting is normally done on a mass flow or tons per year basis, therefore the system will be sized accordingly. The MIRATECH design is to achieve the blended Tier 4 emission targets from the D2 test cycle, measured at 100% engine load conditions.
 - Any emission reductions listed in this proposal are based on housing with catalyst elements installed.
 - MIRATECH will confirm shipping location upon placement of order.

NOTES:

- EXHAUST INLET CUSTOMER SUPPLIED EXHAUST PIPE INLET AND EXPANSION JOINTS
- EXHAUST OUTLET CUSTOMER SUPPLIED EXHAUST PIPE OUTLET AND EXPANSION JOINTS




NOT FOR CONSTRUCTION



**CBL ACIS-3 LITE
System Overview Drawing**

| | | | | | | | | |
|-----------------|--|--|------------|---|--------------|---------------------|--|-----|
| PROJECT NAME | | <p>PROPRIETARY AND CONFIDENTIAL</p> <p>THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF MIRATECH GROUP, LLC. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF MIRATECH GROUP, LLC IS PROHIBITED.</p> | | DIMENSIONS ARE APPROXIMATE IN INCHES UNLESS OTHERWISE SPECIFIED | | | | |
| PROPOSAL NUMBER | | | | DO NOT SCALE DRAWING | | | | |
| SALES ORDER NO. | | | | DRAWN | DATE | DRAWING | | REV |
| CUSTOMER P.O. | | | | GFS | 10/18/2017 | CBL-ACIS-3-LITE SOD | | 0 |
| | | REVIEWED BY | DATE | SIZE | NOT TO SCALE | SHEET 1 OF 1 | | |
| | | AJM | 10/20/2017 | A | | | | |



NOTES:


- POWER CONSUMPTION: 300 W MAX
 - VOLTAGE: 208 VAC +/- 10%, SINGLE Φ , 60 HZ
 - CURRENT DRAW: 1.5 A
 - POWER CONSUMPTION OF THE REACTANT BOOSTER PUMP AND DOSING PANEL ARE SUPPLIED USING THE SAME CIRCUIT AS THE OLC; REFERENCE THESE DRAWINGS FOR THEIR ADDED POWER CONSUMPTION
 - OPERATING TEMPERATURE: 32 °F - 122 °F (NON-CONDENSING)
- INSTALLATION INSTRUCTIONS:**
- ENCLOSURE RATED IP66 (NEMA 4 EQUIVALENT)
 - INSTALLATION LOCATION MUST BE VENTILATED AND TEMPERATURE CONTROLLED TO MAINTAIN PROPER OPERATING TEMPERATURE.
 - UNIT MAY BE WALL MOUNTED OR INSTALLED ON A BASE





| | |
|-----------------|--|
| PROJECT NAME | |
| PROPOSAL NUMBER | |
| SALES ORDER NO. | |
| CUSTOMER P.O. | |

PROPRIETARY AND CONFIDENTIAL

THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF MIRATECH GROUP, LLC. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF MIRATECH GROUP, LLC IS PROHIBITED.

| | |
|---|----------------------|
| DIMENSIONS ARE APPROXIMATE IN INCHES UNLESS OTHERWISE SPECIFIED | |
| DIMENSIONAL TOLERANCES UNLESS OTHERWISE SPECIFIED | |
| ANGLES | |
| MACH: $\pm 2^*$ | INCHES: ± 0.125 |
| BEND: $\pm 5^*$ | MILLIMETERS: ± 3 |
| DO NOT SCALE DRAWING | |
| DRAWN | DATE |
| GFS | 10/13/2017 |
| REVIEWED BY | DATE |
| AJM | 10/31/2017 |

| | |
|---|------|
|  | |
| OLC-60-HMI Controller Sales Drawing | |
| DRAWING | |
| OLC-60-HMI SD | |
| REV | 0 |
| SIZE | A |
| SCALE | 1:18 |
| WEIGHT | 76lb |
| SHEET 1 OF 1 | |




NOTES:

- POWER CONSUMPTION: 5.75 W MAX
- POWER: SUPPLIED FROM SNQ CONTROLLER
- OPERATION TEMPERATURE: 40-104°F
14-104°F (WITH .WT OPTION)
- NO DEW DROPS ALLOWED
- OPERATING PRESSURE: REACTANT - 3 BAR (43.50 PSI)
AIR - 1 BAR (14.50 PSI)

INSTALLATION INSTRUCTIONS:


- IF UNIT IS INSTALLED IN AN ENCLOSURE, THE ENCLOSURE MUST BE VENTILATED AND TEMPERATURE CONTROLLED TO MAINTAIN PROPER OPERATION TEMPERATURE.
- UNIT TO BE MOUNTED SO THAT IT IS ACCESSIBLE WHILE ENGINE IS IN OPERATION AND NO MORE THAN 6.5 FEET FROM DOSING INJECTOR.
- UREA LINES SHOULD BE HEAT TRACED IF AMBIENT CONDITIONS FALL BELOW 40°F

| | | | |
|-----------------|---|---|--------------------|
| PROJECT NAME | PROPRIETARY AND CONFIDENTIAL THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF MIRATECH CORPORATION. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF MIRATECH CORPORATION IS PROHIBITED. | DIMENSIONS ARE APPROXIMATE IN INCHES UNLESS OTHERWISE SPECIFIED | |
| PROPOSAL NUMBER | | | |
| SALES ORDER NO. | | DO NOT SCALE DRAWING | |
| CUSTOMER P.O. | | DRAWN JFS | DATE 08/22/2011 |
| | | REVIEWED BY AJM | DATE 08/22/2011 |




**SEN115 Dosing Box
Sales Drawing**



| | | | | |
|------------------|------------|---------------|--------------|-----------------|
| DRAWING | | | SEN115 SD | REV 6 |
| SIZE A | SCALE 1:12 | WEIGHT: 31 lb | SHEET 1 OF 1 | |



FRONT VIEW



RIGHT VIEW



TOP VIEW

NOTES:

- POWER CONSUMPTION: 250 W MAX SUPPLIED BY SNQ CONTROLLER
- OPERATION TEMPERATURE: 40°F - 104°F

INSTALLATION INSTRUCTIONS:





- UNIT TO BE MOUNTED SO THAT THE MAXIMUM SUCTION HEIGHT IS LESS THAN 5 FEET
- UREA LINES SHOULD BE HEAT TRACED IF AMBIENT CONDITIONS FALL BELOW 40°F

| | | | |
|--|-------------------------------------|---|------------|
| PROJECT NAME | PROPRIETARY AND CONFIDENTIAL | DIMENSIONS ARE APPROXIMATE IN INCHES UNLESS OTHERWISE SPECIFIED | |
| PROPOSAL NUMBER | | | |
| SALES ORDER NO. | | | |
| CUSTOMER P.O. | | | |
| THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF MIRATECH CORPORATION. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF MIRATECH CORPORATION IS PROHIBITED. | | DO NOT SCALE DRAWING | |
| | | DRAWN | DATE |
| | | JFS | 08/22/2011 |
| | | REVIEWED BY | DATE |
| AJM | 08/22/2011 | | |



VPN115 Booster Pump Sales Drawing

| | | | |
|-----------|-------|--------|--------|
| DRAWING | | | REV |
| VPN115 SD | | | 6 |
| SIZE | SCALE | WEIGHT | SHEET |
| A | 1:15 | 101 lb | 1 OF 1 |




NOTES:

- POWER CONSUMPTION: 2200 W MAX
- VOLTAGE: 230 VAC +/- 10%, SINGLE Φ , 60 Hz
- CURRENT DRAW: 11.0 A
- OPERATION TEMPERATURE: 32°F - 104°F

INSTALLATION INSTRUCTIONS:

- IF UNIT IS INSTALLED IN AN ENCLOSURE, THE ENCLOSURE MUST BE VENTILATED AND TEMPERATURE CONTROLLED TO MAINTAIN PROPER OPERATION TEMPERATURE

| | | | | | | | |
|-----------------|--|--|--|---|--|---|--|
| PROJECT NAME | | PROPRIETARY AND CONFIDENTIAL | | DIMENSIONS ARE APPROXIMATE IN INCHES UNLESS OTHERWISE SPECIFIED | |  | |
| PROPOSAL NUMBER | | THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF MIRATECH CORPORATION. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF MIRATECH CORPORATION IS PROHIBITED. | | | | | |
| SALES ORDER NO. | | DO NOT SCALE DRAWING | | DRAWN | | DRAWING | |
| CUSTOMER P.O. | | REVIEWED BY | | DATE | | CA115 SD | |
| | | AJM | | 08/22/2011 | | REV 7 | |
| | | SCALE 1:15 | | WEIGHT: 131 lb | | SHEET 1 OF 1 | |

GENERATOR DATA:
 MODEL: C3250 D6e 480V
 DIMS INCHES: 311.3L X 119.25W X 144.2T
 WET WEIGHT Lbs: 67,700
 FUEL CONSUMPTION GPH @ 100% LOAD: 221.0
 COMBUSTION AND COOLING CFM: 120,450
 GEN DRAWING: A049-P688

GENERAL DESCRIPTION:
SUB BASE FUEL SUPPLY TANK
 UL 142 LISTED DOUBLE WALL
 NORMAL VENT EXTENDED 12 FEET ABOVE GRADE
 EMERGENCY VENTS EXTENDED 12 FEET ABOVE GRADE
 LOW LEVEL, HIGH LEVEL, CRITICAL HIGH LEVEL & LEAK
 DETECTION FLOAT SWITCHES
 MECHANICAL OVERFILL PREVENTION VALVE SET @95%
 WITH CUSTOM 7.5 GALLON SPILL CONTAINER
 1" FIRE RATED FUEL LINE SET
 ROCHESTER 6540 FUEL LEVEL GAUGE
 SPARE PORTS FOR CUSTOMER SUPPLIED FUEL POLISHER
 2" BASIN TO PAD AIRSPACE FOR VISUAL INSPECTION

WALK-IN LEVEL 2 SOUND ATTENUATED ENCLOSURE
 ESTIMATED AVERAGE SOUND LEVEL 75 dBA @ 23 FEET
 SEISMIC DESIGN CATEGORY: D, IMPORTANCE FACTOR: 1.25
 RATED 100 MPH WIND LOAD - 120 MPH 3-SECOND GUST
 12 GAUGE GALVANNEAL STEEL CONSTRUCTION
 INTAKE WITH PENTHOUSE EXTENSION, AMCA FIXED VANE
 LOUVERS, SOUND CONTROL SECTIONS & MOTORIZED
 DAMPERS
 DISCHARGE WITH GRAVITY DAMPERS, SOUND
 DIRECTIONAL PLENUM & STACK EXTENSION WITH
 SOUND CONTROL SECTION
 PLENUM STACK EXTENSION CAPABLE OF ACCEPTING UP
 TO (4) ADDITIONAL 8"-3/4" STACK EXTENSIONS
 ACCESS DOOR OPENINGS:
 72" X 36" TYP. SINGLE DOOR
 72" X 72" TYP. DOUBLE DOOR





ELECTRICAL PACKAGE
 GROUND BOND PACKAGE INCLUDING GROUND STRAP ON
 MAJOR COMPONENTS, PAINT PERCING WASHERS
 ON REMOVABLE PANELS & STAINLESS STEEL TAB
 ON ALL (4) CORNERS OF THE BASE FOR
 CONTRACTOR CONNECTION
 SUPPLY & INSTALL CUSTOM FREESTANDING 5000A
 SWITCHBOARD WITH SCHNEIDER MASTERPACT
 NW50H BREAKER & 6.0A TRIP
 3Ø 480V NEMA 3R 125A NF PANELBOARD WITH BOLT-ON
 BRANCH BREAKERS TO 480V LOCK HEATER &
 3ØKVA TRANSFORMER WITH NEMA 3R WEATHER
 SHIELD (480/277 TO 120/208) WITH FEED TO
 3Ø 200A M.L.C. LOAD CENTER WITH 100A M.C.B. (4) GFCI
 DUPLEX OUTLETS, (4) INTERIOR LIGHTS, (2)
 EXTERIOR LIGHTS, DAMPER MOTORS, BATTERY
 CHARGERS, ALT. STRIP HEATER & (2) UNIT
 HEATERS WIRED IN STEEL EMT WITH COMPRESSION
 FITTINGS & LIQUIDTIGHT FLEXIBLE CONDUIT
 (1) EXTERIOR MOUNTED EMERGENCY STOP SWITCH
 (SHIPS LOOSE, INSTALLED ON SITE)
 PNEUMULATOR SYSTEM, TMS2000 & EDT1000 REMOTE
 DISPLAY IN EACH UNIT
 AP-4 TANK STATUS ALARM PANEL

NOTE: NO CONDUIT ON FLOOR OR SUPPORTED BY CEILING
ACCESSORIES
 ROOF MOUNTED MIRATECH T4 SCR WITH DEF TANK,
 FLEX CONNECTIONS, EXHAUST COLLECTOR,
 MIRATECH AIR COMPRESSOR, PUMP & CONTROL
 18" W-BEAM SUBFRAME WITH 6" SUPPORT TUBES, FULL
 NON-SLIP FLOOR, ENGINE FLUID SPILL CONTAINMENT
 & PROVISIONS FOR CP SUPPLIED SEISMIC SPRING
 ISOLATORS
 OIL & COOLANT DRAINS PIPED TO EXTERIOR WITH VALVES
 WALL MOUNTED DOCUMENT HOLDER
 ** INTERIOR & EXTERIOR EQUIPMENT MOUNTING MAY VARY IN
 LOCATION DUE TO MANUFACTURING DESIGN REQUIREMENTS

PAINT COLORS:
 ENCLOSURE COLOR: ANSI 61 - LIGHT GRAY (#42062)
 SUBFRAME COLOR: BLACK
 FUEL TANK COLOR: BLACK

ESTIMATED WEIGHTS: (lbs)
 ENCLOSURE WEIGHT: 67,551
 TOTAL SHIPPING WEIGHT (NOT INCLUDING TANK): 138,000
 TOTAL SYSTEM WEIGHT: 252,433

TANK DATA & NOTES:
 CAPACITY GALLONS: 8,250
 GALLONS PER IN OF DEPTH: 244.0
 RUN TIME @ FULL LOAD Hrs: 36.1
 TANK WEIGHT DRY lbs: 32,000
 TANK WEIGHT WET lbs: 83,933
 CONDUIT STUB AREA: TYPE C (SIDE)
 1. EMERGENCY VENT SIZING BASED ON UL142 TABLE 8.1
 2. PORTS PER UL 142 SECTION 10
 3. NORMAL VENTING PER UL 142 SECTION 8.11, TABLE 8.2
 4. WELDS & JOINTS PER UL SECTION 6 FIGURE 6.1, 6.2



| UL SPEC | DESCRIPTION | CLASS | FILE # |
|---------|--|-------|---------|
| UL 142 | SECONDARY CONTAINMENT DOUBLE WALL TANK | EVFT | MH47836 |
| N/A | | | |
| N/A | | | |



CONCEPTUAL - NOT FOR CONSTRUCTION

| | | | | | | | |
|---|--|-------------------|-------------------|-------------------------|-----------------|--------------------------|--------------|
| THIS DOCUMENT IS CREATED BY AND IS THE PROPERTY OF FREEMAN ENCLOSURE SYSTEMS, L.L.C. ITS USE IS AUTHORIZED ONLY FOR RESPONDING TO A REQUEST FOR QUOTATION OR FOR THE PERFORMANCE OF WORK FOR FREEMAN ENCLOSURE SYSTEMS, L.L.C. DISTRIBUTION IS STRICTLY PROHIBITED WITHOUT WRITTEN CONSENT FROM FREEMAN ENCLOSURE SYSTEMS, L.L.C. APPROVED AS-BUILT / ASSEMBLY DRAWINGS ARE AVAILABLE UPON REQUEST. ALL DIMENSIONS ARE IN INCHES UNLESS SPECIFIED. | | | | EQUINIX SV-11 T4 | | Quote Reference 24709 | Edition 0 |
| Drawing Number S384921 GA | | Designed by AW | Salesperson JD | Date 01/28/20 | Scale N.T.S. | Sheet # 1/1 | |

| AW | BY | DATE |
|----|----|------|
| 0 | | |

| ORIGINAL SUBMISSION RELEASE | DESCRIPTION |
|-----------------------------|-------------|
| 0 | REV |

Attachment 1B

The existing air quality conditions in the project area are summarized in Table Error! No text of specified style in document. and Table Error! No text of specified style in document.1B.2, which provide the background ambient air concentrations of criteria pollutants for the previous three (3) years as measured at certified monitoring stations near the project site. To evaluate the potential for air quality degradation as a result of the project, modeled project air concentrations are combined with the respective background concentrations as presented below and used for comparison to the NAAQS and CAAQS.

| Table Error! No text of specified style in document.: Measured Ambient Air Quality Concentrations by Year | | | | | | | |
|--|--------------|-----------------|---|-------------|-------------|-------------|---------------|
| Pollutant | Units | Avg Time | Basis of Yearly/ Design Concentrations | 2017 | 2018 | 2019 | Design |
| Ozone | ppb | 1-Hr | CAAQS-1 st Highs/3-yr Max | 121 | 78 | 95 | 121 |
| Ozone | ppb | 8-Hr | CAAQS-1 st Highs/3-yr Max | 98 | 61 | 81 | 98 |
| Ozone | ppb | 8-Hr | NAAQS-4 th Highs/3-yr Avg | 75 | 53 | 60 | 63 |
| NO₂ | ppb | 1-Hr | CAAQS-1 st Highs/3-yr Max | 67 | 86 | 59 | 86 |
| NO₂ | ppb | 1-Hr | NAAQS-98 th %s/3-yr Avg | 50 | 59 | 52 | 54 |
| NO₂ | ppb | Annual | CAAQS/NAAQS-AAM/3-yr Max | 12 | 12 | 11 | 12 |
| CO | ppm | 1-Hr | CAAQS-1 st Highs/3-yr Max | 2.1 | 2.5 | 1.7 | 2.5 |
| | | | NAAQS-2 nd Highs/3-yr Max | 2.0 | 2.4 | 1.6 | 2.4 |
| CO | ppm | 8-Hr | CAAQS-1 st Highs/3-yr Max | 1.8 | 2.1 | 1.3 | 2.1 |
| | | | NAAQS-2 nd Highs/3-yr Max | 1.7 | 2.0 | 1.3 | 2 |
| SO₂ | ppb | 1-Hr | CAAQS-1 st Highs/3-yr Max | 3.6 | 6.9 | 14.5 | 14.5 |
| | | | NAAQS-99 th %s/3-yr Avg | 3 | 3 | 2 | 2.7 |
| | | 24-Hr | CAAQS-1 st Highs/3-yr Max | 1.1 | 1.1 | 1.5 | 1.5 |
| | | | NAAQS-2 nd Highs/3-yr Max | 1.0 | 1.1 | 0.6 | 1.1 |
| | | Annual | CAAQS/NAAQS-AAM/3-yr Max | 0.20 | 0.21 | 0.14 | 0.21 |

Notes: Values for 158 East Jackson Street, San Jose, CA, the nearest BAAQMD monitoring site (all applicable pollutants measured)
Data sources: BAAQMD website Air Pollution Summaries for CAAQS and USEPA AIRS Data Reports website for NAAQS.

Table Error! No text of specified style in document.B.2: Background Air Quality Data Summary

| Pollutant and Averaging Time | Background Value ($\mu\text{g}/\text{m}^3$) |
|---|---|
| Ozone – 1-hour Maximum CAAQS | 238 |
| Ozone – 8-hour Maximum CAAQS/ 3-year average 4 th High NAAQS | 192/124 |
| PM ₁₀ – 24-hour Maximum CAAQS/ 24-hour 3-year 4 th High NAAQS | 122/112 |
| PM ₁₀ – Annual Maximum CAAQS | 23 |
| PM _{2.5} – 3-Year Average of Annual 24-hour 98 th Percentiles NAAQS | 43 |
| PM _{2.5} – Annual Maximum CAAQS/ 3-Year Average of Annual Values NAAQS | 12.8/10.5 |
| CO – 1-hour Maximum CAAQS/ 1-hour High, 2 nd High NAAQS | 2863/2748 |
| CO – 8-hour Maximum CAAQS/ 8-hour High, 2 nd High NAAQS | 2405/2290 |
| NO ₂ – 1-hour Maximum CAAQS/ 3-Year Average of Annual 98 th Percentile 1-hour Daily Maxima NAAQS | 162/102 |
| NO ₂ – Annual Maximum CAAQS/NAAQS | 22.6 |
| SO ₂ – 1-hour Maximum CAAQS/ 3-Year Average of Annual 99 th Percentile 1-hour Daily Maxima NAAQS | 38/7 |
| SO ₂ – 3-hour Maximum NAAQS (Not Available - Used 1-hour Maxima) | 38 |
| SO ₂ – 24-hour Maximum CAAQS 24-hour High, 2 nd High NAAQS | 4/3 |
| SO ₂ – Annual Maximum NAAQS | 0.5 |
| Notes: Values for 158 East Jackson Street, San Jose, CA, the nearest BAAQMD monitoring site (all applicable pollutants measured) Conversion of ppm/ppb measurements to $\mu\text{g}/\text{m}^3$ concentrations based on: $\mu\text{g}/\text{m}^3 = \text{ppm} \times 40.9 \times \text{MW}$, where MW = 48 ozone, 28 CO, 46 NO ₂ , and 64 for SO ₂ , respectively. | |