

DOCKETED

Docket Number:	20-RENEW-01
Project Title:	School Energy Efficiency Stimulus Program
TN #:	237312
Document Title:	20-RENEW-01 SEES Program
Description:	N/A
Filer:	Chester Hong
Organization:	California Energy Commission
Submitter Role:	Commission Staff
Submission Date:	3/26/2021 8:34:45 AM
Docketed Date:	3/26/2021

From: [Marc Brogoitti](#)
To: [Energy - Docket Optical System](#)
Cc: [Reese Thompson](#)
Subject: 20-RENEW-01 SEES Program
Date: Friday, March 26, 2021 7:27:28 AM

CAUTION: This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Hello,

A couple of questions:

- 1 What are the deadlines for a LEA to submit applications for AB 841 grants?
- 2 As the requirements for MERV-13 filtration and 4 hours of extra run time for classroom mechanical equipment, namely supply fans will result in extra energy costs, when will these requirements end? MERV-13 filters will also need to be changed more frequently as the pore sizes are smaller therefore trapping more particles. Increased supply fan run times of 50% as well as additional outside air also contribute to the filtration loading. Are the school districts to bear these associated costs in perpetuity?

Regards,



MARC BROGOITTI
Energy Manager

Tel: (805) 937-6356 ext. 4704
Fax: (805) 934-4743
Cell: (805) 345-0851
2560 Skyway Dr. E-mail: mbrogoitti@smjuhsd.org
Santa Maria, CA 93455