

DOCKETED

Docket Number:	20-RENEW-01
Project Title:	School Energy Efficiency Stimulus Program
TN #:	237326
Document Title:	Irella Perez Comments - School Energy Efficiency Stimulus Program, comments Irella Perez
Description:	N/A
Filer:	System
Organization:	Irella Perez
Submitter Role:	Public
Submission Date:	3/26/2021 4:20:41 PM
Docketed Date:	3/26/2021

Comment Received From: Irella Perez
Submitted On: 3/26/2021
Docket Number: 20-RENEW-01

School Energy Efficiency Stimulus Program, comments Irella Perez

1. On Page 3 Keywords/Terms Table 1 it Defines: "MERV Minimum efficiency reporting value" Should also define MERV 16 "It can be a misconception that LEAs must install MERV 13" rather than the minimum without excluding the maximum MERV 16. MERV stand for MERV Minimum efficiency reporting value (13 is the minimum not the exclusive. Filtration goes up to MERV 16)
2. On Page 8 Number 5 Eligible Schools it says: "in addition to the criteria above, a site must have an HVAC system to meet the HVAC Assessment and Maintenance Grant requirements specified in Chapter 2. An HVAC system is defined as any air-handling units, rooftop units, and unitary and single zone equipment in a site's HVAC system or systems, as described in PUC Section 1622." Should it also include: In areas of the buildings where it is not feasible to install a permanent filtration, a Mobil filtration meeting the MERV 13 and up to MERV 16 can be accommodated in acceptance to meet compliance.
3. On Page 10 Section B HVAC Assessment and Maintenance Requirements (number 1. Filtration: B. HVAC Assessment and Maintenance Requirements "1. Filtration The LEA receiving a SRVEVR grant shall install filtration with a minimum efficiency reporting value (MERV) of 13 or better in the HVAC system where feasible." Should specified (MERV) of 13 or better (up to MERV 16)
4. On page 11 Number 2 Ventilation section a. "a. Calculation of the required minimum outside air ventilation rates for each occupied area based on the anticipated occupancy and the minimum required ventilation rate per occupant set forth in Table 120.1-A. " It should read: the minimum and up to the maximum required ventilation

Additional submitted attachment is included below.

1. **On Page 3 Keywords/Terms Table 1 it Defines:**” MERV Minimum efficiency reporting value”
Should also define MERV 16 – It can be a misconception that LEA’s must install MERV 13 – rather than the minimum without excluding the maximum MERV 16. MERV stand for MERV Minimum efficiency reporting value (13 is the minimum not the exclusive. Filtration goes up to MERV 16)
2. **On Page 8 Number 5 Eligible Schools it says:** “in addition to the criteria above, a site must have an HVAC system to meet the HVAC Assessment and Maintenance Grant requirements specified in Chapter 2. An HVAC system is defined as any air-handling units, rooftop units, and unitary and single zone equipment in a site’s HVAC system or systems, as described in PUC Section 1622.”
Should it also include: In areas of the buildings where it is not feasible to install a permanent filtration, a Mobil filtration meeting the MERV 13 and up to MERV 16 can be accommodated in acceptance to meet compliance.
3. **On Page 10 Section B HVAC Assessment and Maintenance Requirements (number 1. Filtration: B. HVAC Assessment and Maintenance Requirements** “1. Filtration The LEA receiving a SRVEVR grant shall install filtration with a minimum efficiency reporting value (MERV) of 13 or better in the HVAC system where feasible.” Should specified (MERV) of 13 or better (up to MERV 16)
4. **On page 11 Number 2 Ventilation section a.** “a. Calculation of the required minimum outside air ventilation rates for each occupied area based on the anticipated occupancy and the minimum required ventilation rate per occupant set forth in Table 120.1-A. C” It should read: the minimum and up to the maximum required ventilation