

**DOCKETED**

<b>Docket Number:</b>	81-AFC-01C
<b>Project Title:</b>	Compliance - Application for Certification of the Occidental Plant # 1
<b>TN #:</b>	237429
<b>Document Title:</b>	CEC Letter to Sharon Peterson, Air Compliance Manager, Calpine Geysers
<b>Description:</b>	Geysers Calistoga (81-AFC-01C) Authorization of Steam Turbine Rotor Replacement
<b>Filer:</b>	susan fleming
<b>Organization:</b>	California Energy Commission
<b>Submitter Role:</b>	Commission Staff
<b>Submission Date:</b>	4/13/2021 9:45:00 AM
<b>Docketed Date:</b>	4/13/2021



April 13, 2021

Sharon Peterson  
Air Compliance Manager  
Calpine Geysers  
10350 Socrates Mine Road  
Middletown, California 95461

**RE: Geysers Calistoga (81-AFC-01C) Authorization of Steam Turbine Rotor Replacement**

Dear Ms. Peterson

On March 4, 2021 the California Energy Commission staff received an inquiry regarding replacement of the steam turbine rotor to account for reduced steam field pressures at the Geysers Calistoga, Unit 19. The proposed activities include fitment of a double flow rotor plus diaphragms and steam seals.

Staff has reviewed the proposed activities and determined that the activities are not subject to Title 20, California Code of Regulations, section 1769, and therefore do not require approval of a post-certification petition. This is because the proposed activities will not change the project design, operation or performance requirements in the Final Commission Decision.

These activities do not require Delegate Chief Building Official (DCBO) oversight for plan review and/or inspections. The project owner is expected to adhere to all applicable Conditions of Certification in the Final Commission Decision, or as amended.

You are hereby authorized to proceed with your activities as outlined above. Should the scope of the above noted activities change, particularly with regard to air quality, please contact us as this may change our decision that the activities do not require approval of a post-certification petition.

If you have any questions or concerns, please contact Eric Veerkamp, Compliance Project Manager, at (916) 661-8458, or via email at [eric.veerkamp@energy.ca.gov](mailto:eric.veerkamp@energy.ca.gov)

Sharon Peterson  
April 13, 2021  
Page 2

Sincerely,

*Elizabeth Huber*

Elizabeth Huber  
Compliance Office Manager  
Siting, Transmission, and Environmental  
Protection Division

cc: Ms. Barbara McBride  
Director of Strategic Origination  
Calpine  
3003 Oak Road, Suite 400  
Walnut Creek, California 94597