

DOCKETED

Docket Number:	03-AFC-01C
Project Title:	Roseville Energy Park Compliance
TN #:	237659
Document Title:	Roseville Energy Park Quarterly Air Quality Report - Q1 2021
Description:	City of Roseville hereby submits the Quarterly Air Quality Report for the first quarter of 2021.
Filer:	Roseville Electric Compliance
Organization:	Roseville Electric
Submitter Role:	Public Agency
Submission Date:	5/4/2021 5:17:22 PM
Docketed Date:	5/4/2021

City of Roseville
Roseville Energy Park
(03-AFC-1)

California Energy Commission
Quarterly Operational Report
First Quarter 2021

List of Attachments

AQ15 - SCR Installed before commissioning in 2007

AQ20 - The gas turbine engine shall be fired exclusively on pipeline quality natural gas with sulfur content no greater than 0.50 grains of sulfur compounds per 100 dry scf of natural gas

AQ21 – Startups and Shutdowns

AQ32 – All hourly, quarter NOx and CO emissions AQ-SC6

AQ33 – All hourly, daily, and quarterly SOx AQ-SC6

AQ34 – Startups and Shutdowns

AQ36 – Breakdown condition

AQ37 – Violations of Emissions

AQ40 – CEMS quality assurance test failures

AQ41 – Excess Emissions

AQ42 – Running 12-month summary

AQ47 – All nuisance violations

AQ48 – Nuisance complaints and stack emission opacity as dark as Ringlemann No. 1 (20% opacity) for periods aggregating more than 3 min.

AQ51 – Ammonia slip exceedances

AQ55 – Emission rates from each gas turbine and heat recovery steam generator exhaust during startup and shutdown – NOx and CO

AQ57 – Emission exceedance rates during startup and shutdown – CO, NOx, PM-10, SOx, and VOC

AQ59 – Emission limit exceedances – NOx, CO, VOC, PM-10, SO₂

AQ60 – Quarterly emission exceedances for Alstom GTX100 turbine – NOx, CO, VOCs, PMO, SOx

AQ63 – Total facility emission exceedances – NOx, CO, VOC, PM-10, SO₂

AQ68 – Annual water sample analysis of cooling tower water

AQ69 – Nuisance complaints

AQ70 – PM-10 quarterly emission rate exceedances from cooling tower

AQ71 – Exceedance of cooling tower PM-10 emission limit – PM-10 = cooling water recirculation rate*total dissolved solids concentration in the blow own water* design drift rate

AQ86 – Limits for operation for maintenance and testing of emergency diesel engine and generator limited to 50 hours per year

AQ87 – Operation for maintenance and testing purposes shall be limited to involuntary interruptions of electrical power. Operation shall not exceed 24 hours

AQ88 – Sulfur content of diesel fuel used shall not exceed 15 ppm by weight

AQ89 – Records of hours of operation engine run for maintenance and testing, during interruption of electrical power, records of sulfur content of diesel used for five years

AQ90 – No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance

AQ91 – Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited and is in violation of PCAPCD Rule 202, Visible Emissions

AQ99 – Operation for maintenance and testing of the emergency diesel engine and generator shall be limited to 50 hours per year.

AQ100 – Emergency diesel Generator; Operation for other than maintenance and testing purposes shall be limited to involuntary interruptions of electrical power

AQ101 - The sulfur content of the diesel used shall not exceed 15ppm by weight

AQ102 – Records of operation and maintenance shall be kept by the owner or operator for a period of five years

AQ103 – No emissions are permitted, from any source, which are a nuisance

AQ104 – Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited

AQ-15

AQ-15 The Project owner shall install a selective catalytic reduction (SCR) system and an oxidation catalyst on the gas turbine. The SCR and oxidation catalyst equipment shall be operated whenever the gas turbine is operated.

Verification: The Project owner shall submit to the CPM a written statement by a California registered Professional Engineer stating that said engineer has reviewed the as built designs or inspected the identified equipment and certifies that it is operational and air tight. The Project owner shall include the operational status of the SCR and oxidation catalyst during all hours of operation as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

This document is on file from the 2007 4Q QAQR.

AQ-20

AQ-20 The gas turbine engine shall be fired exclusively on pipeline quality natural gas with sulfur content no greater than 0.50 grains of sulfur compounds per 100 dry scf of natural gas.

Verification: The Project owner shall submit to the CPM the most recent fuel testing analysis performed as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6



California Gas Transmission

Pipe Ranger

Search

Go

Log in

About CGT

Products

Tools & Services

Operating Data

Reference/Library

Current Pipeline Status

Forecasts

Historical Archives

Gas Quality/Heating Values

Gas System Sulfur Survey Results

Date	Total Sulfur Maximum		Total Sulfur Average all sites	
	PPMv	gr/100 scf	PPMv	gr/100 scf
2021				
First Quarter	4.2	0.26	3.5	0.22

AQ20 ROSEVILLE ENERGY PARK

1Q21

Fuel Quality Analysis BTU values

<http://www.pge.com/pij>

	JAN	FEB	MAR
1	1044.23	1042.54	1031.85
2	1044.56	1042.54	1037.15
3	1042.55	1041.19	1038.39
4	1043.01	1039.89	1038.14
5	1042.33	1040.90	1037.04
6	1042.32	1040.64	1039.50
7	1041.31	1041.39	1036.77
8	1042.42	1040.12	1036.58
9	1042.52	1041.44	1036.75
10	1042.10	1041.60	1036.40
11	1043.18	1041.48	1036.82
12	1042.41	1038.13	1036.99
13	1041.42	1,041.79	1037.26
14	1041.26	1042.71	1038.86
15	1040.74	1044.06	1041.38
16	1040.59	1044.72	1037.94
17	1041.94	1045.03	1036.01
18	1042.47	1042.89	1037.19
19	1042.07	1044.61	1040.22
20	1040.09	1044.40	1044.12
21	1037.76	1044.34	1045.47
22	1042.41	1042.86	1043.65
23	1041.85	1041.25	1039.62
24	1042.56	1039.48	1037.41
25	1043.88	1040.03	1037.44
26	1042.65	1036.14	1034.70
27	1041.73	1035.31	1040.76
28	1041.71	1034.25	1039.91
29	1041.14	N/A	1037.43
30	1040.51	N/A	1037.29
31	1042.54	N/A	1037.86

odeline/operations/gas_quality/p01_2_weeks.shtml

AQ-21

AQ-21 Startup is defined as the period beginning with the turbine light-off until the unit meets the lb/hr and ppmv emission limits in Conditions of Certification AQ-52, -54 and -55. Shutdown is defined as the period beginning with initiation of turbine shutdown sequence and ending with cessation of firing of the gas turbine engine. Startup and shutdown durations shall not exceed 3.0 hours and one hour, respectively, per occurrence.

Verification: The Project owner shall identify and submit to the CPM as part of the Quarterly Air Quality Report all startups and shutdowns for all units including the maximum hourly emission rate, total emissions and duration.

Monthly Summary By Day Report

Units CT1 and CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 11:33 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
01/01/2021	0.00	0.00	0.00	0.00	0.00
01/02/2021	0.00	0.00	0.00	0.00	0.00
01/03/2021	0.00	0.00	0.00	0.00	0.00
01/04/2021	0.00	0.00	0.00	0.00	0.00
01/05/2021	0.00	0.00	0.00	0.00	0.00
01/06/2021	0.00	0.00	0.00	0.00	0.00
01/07/2021	0.00	0.00	0.00	0.00	0.00
01/08/2021	0.00	0.00	0.00	0.00	0.00
01/09/2021	0.00	0.00	0.00	0.00	0.00
01/10/2021	0.00	0.00	0.00	0.00	0.00
01/11/2021	0.00	0.00	0.00	0.00	0.00
01/12/2021	0.00	0.00	0.00	0.00	0.00
01/13/2021	0.00	0.00	0.00	0.00	0.00
01/14/2021	0.00	0.00	0.00	0.00	0.00
01/15/2021	0.00	0.00	0.00	0.00	0.00
01/16/2021	0.00	0.00	0.00	0.00	0.00
01/17/2021	0.00	0.00	0.00	0.00	0.00
01/18/2021	0.00	0.00	0.00	0.00	0.00
01/19/2021	0.00	0.00	0.00	0.00	0.00
01/20/2021	0.00	0.00	0.00	0.00	0.00
01/21/2021	0.00	0.00	0.00	0.00	0.00
01/22/2021	0.00	0.00	0.00	0.00	0.00
01/23/2021	41.43	6.45	0.02	0.05	0.08
01/24/2021	17.66	62.48	5.62	11.22	18.69
01/25/2021	15.90	74.08	7.10	14.24	23.74
01/26/2021	0.01	0.04	0.00	0.01	0.01
01/27/2021	0.00	0.00	0.00	0.00	0.00
01/28/2021	0.00	0.00	0.00	0.00	0.00
01/29/2021	0.00	0.00	0.00	0.00	0.00
01/30/2021	0.00	0.00	0.00	0.00	0.00
01/31/2021	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	75.00 *	143.05 *	12.74 *	25.52 *	42.52 *
Daily Min:	0.01	0.04	0.00	0.01	0.01
Daily Max:	41.43	74.08	7.10	14.24	23.74
Jan 2021 - Jan 2021	75.00	143.05	12.74	25.52	42.52
QTD:	75.00 *	143.05 *	12.74 *	25.52 *	42.52 *
YTD 2021:	75.00 *	143.05 *	12.74 *	25.52 *	42.52 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 11:33 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
02/01/2021	0.00	0.00	0.00	0.00	0.00
02/02/2021	0.00	0.00	0.00	0.00	0.00
02/03/2021	0.00	0.00	0.00	0.00	0.00
02/04/2021	0.00	0.00	0.00	0.00	0.00
02/05/2021	0.00	0.00	0.00	0.00	0.00
02/06/2021	0.00	0.00	0.00	0.00	0.00
02/07/2021	0.00	0.00	0.00	0.00	0.00
02/08/2021	0.00	0.00	0.00	0.00	0.00
02/09/2021	0.00	0.00	0.00	0.00	0.00
02/10/2021	0.00	0.00	0.00	0.00	0.00
02/11/2021	0.00	0.00	0.00	0.00	0.00
02/12/2021	0.00	0.00	0.00	0.00	0.00
02/13/2021	0.00	0.00	0.00	0.00	0.00
02/14/2021	0.00	0.00	0.00	0.00	0.00
02/15/2021	0.00	0.00	0.00	0.00	0.00
02/16/2021	0.00	0.00	0.00	0.00	0.00
02/17/2021	0.00	0.00	0.00	0.00	0.00
02/18/2021	0.00	0.00	0.00	0.00	0.00
02/19/2021	0.00	0.00	0.00	0.00	0.00
02/20/2021	0.00	0.00	0.00	0.00	0.00
02/21/2021	0.00	0.00	0.00	0.00	0.00
02/22/2021	0.00	0.00	0.00	0.00	0.00
02/23/2021	0.00	0.00	0.00	0.00	0.00
02/24/2021	0.00	0.00	0.00	0.00	0.00
02/25/2021	0.00	0.00	0.00	0.00	0.00
02/26/2021	290.84	37.94	1.60	3.19	5.32
02/27/2021	84.73	37.27	2.23	4.44	7.39
02/28/2021	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	375.57 *	75.21 *	3.83 *	7.63 *	12.71 *
Daily Min:	84.73	37.27	1.60	3.19	5.32
Daily Max:	290.84	37.94	2.23	4.44	7.39
Jan 2021 - Feb 2021	450.57	218.26	16.57	33.15	55.23
QTD:	450.57 *	218.26 *	16.57 *	33.15 *	55.23 *
YTD 2021:	450.57 *	218.26 *	16.57 *	33.15 *	55.23 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 11:33 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
03/01/2021	50.79	49.99	2.31	4.66	7.77
03/02/2021	0.00	0.00	0.00	0.00	0.00
03/03/2021	0.00	0.00	0.00	0.00	0.00
03/04/2021	0.00	0.00	0.00	0.00	0.00
03/05/2021	0.00	0.00	0.00	0.00	0.00
03/06/2021	58.31	48.94	2.12	4.26	7.11
03/07/2021	0.00	0.00	0.00	0.00	0.00
03/08/2021	183.31	28.21	1.41	2.89	4.79
03/09/2021	0.00	0.00	0.00	0.00	0.00
03/10/2021	68.19	49.28	1.75	3.48	5.82
03/11/2021	0.00	0.00	0.00	0.00	0.00
03/12/2021	101.50	22.06	0.11	0.23	0.39
03/13/2021	71.12	60.52	6.05	12.12	20.23
03/14/2021	0.00	0.00	0.00	0.00	0.00
03/15/2021	0.00	0.00	0.00	0.00	0.00
03/16/2021	0.00	0.00	0.00	0.00	0.00
03/17/2021	0.00	0.00	0.00	0.00	0.00
03/18/2021	0.00	0.00	0.00	0.00	0.00
03/19/2021	0.00	0.00	0.00	0.00	0.00
03/20/2021	0.00	0.00	0.00	0.00	0.00
03/21/2021	0.00	0.00	0.00	0.00	0.00
03/22/2021	106.86	59.21	4.38	8.75	14.58
03/23/2021	89.72	82.48	6.76	13.47	22.47
03/24/2021	83.72	62.22	4.73	9.53	15.84
03/25/2021	63.73	22.92	1.01	2.05	3.41
03/26/2021	0.00	0.00	0.00	0.00	0.00
03/27/2021	0.00	0.00	0.00	0.00	0.00
03/28/2021	0.00	0.00	0.00	0.00	0.00
03/29/2021	0.00	0.00	0.00	0.00	0.00
03/30/2021	0.00	0.00	0.00	0.00	0.00
03/31/2021	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	877.25 *	485.83 *	30.63 *	61.44 *	102.41 *
Daily Min:	50.79	22.06	0.11	0.23	0.39
Daily Max:	183.31	82.48	6.76	13.47	22.47
Jan 2021 - Mar 2021	1,327.82	704.09	47.20	94.59	157.64
QTD:	1,327.82 *	704.09 *	47.20 *	94.59 *	157.64 *
YTD 2021:	1,327.82 *	704.09 *	47.20 *	94.59 *	157.64 *

Monthly Summary By Day Report



From: 01/01/2021 00:00 **To:** 03/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2021 11:32 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr	Unit CT1 NOX_SUSD, LbPerHr	Unit CT2 CO_SUSD, LbPerHr	Unit CT2 NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/01/2021	0.0	0.0	0.0	0.0
01/02/2021	0.0	0.0	0.0	0.0
01/03/2021	0.0	0.0	0.0	0.0
01/04/2021	0.0	0.0	0.0	0.0
01/05/2021	0.0	0.0	0.0	0.0
01/06/2021	0.0	0.0	0.0	0.0
01/07/2021	0.0	0.0	0.0	0.0
01/08/2021	0.0	0.0	0.0	0.0
01/09/2021	0.0	0.0	0.0	0.0
01/10/2021	0.0	0.0	0.0	0.0
01/11/2021	0.0	0.0	0.0	0.0
01/12/2021	0.0	0.0	0.0	0.0
01/13/2021	0.0	0.0	0.0	0.0
01/14/2021	0.0	0.0	0.0	0.0
01/15/2021	0.0	0.0	0.0	0.0
01/16/2021	0.0	0.0	0.0	0.0
01/17/2021	0.0	0.0	0.0	0.0
01/18/2021	0.0	0.0	0.0	0.0
01/19/2021	0.0	0.0	0.0	0.0
01/20/2021	0.0	0.0	0.0	0.0
01/21/2021	0.0	0.0	0.0	0.0
01/22/2021	0.0	0.0	0.0	0.0
01/23/2021	39.9	6.4	0.0	0.0
01/24/2021	0.6	5.5	0.0	0.0
01/25/2021	0.0	0.1	0.0	0.0
01/26/2021	0.0	0.0	0.0	0.0
01/27/2021	0.0	0.0	0.0	0.0
01/28/2021	0.0	0.0	0.0	0.0
01/29/2021	0.0	0.0	0.0	0.0
01/30/2021	0.0	0.0	0.0	0.0
01/31/2021	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	40.5 *	12.0 *	- *	- *
Daily Min:	0.0	0.0	-	-
Daily Max:	39.9	6.4	-	-
Jan 2021 - Jan 2021	40.5	12.0	-	-
QTD:	40.5 *	12.0 *	0.0 *	0.0 *
YTD 2021:	40.5 *	12.0 *	0.0 *	0.0 *

Monthly Summary By Day Report



From: 01/01/2021 00:00 **To:** 03/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2021 11:32 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr	Unit CT1 NOX_SUSD, LbPerHr	Unit CT2 CO_SUSD, LbPerHr	Unit CT2 NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/01/2021	0.0	0.0	0.0	0.0
02/02/2021	0.0	0.0	0.0	0.0
02/03/2021	0.0	0.0	0.0	0.0
02/04/2021	0.0	0.0	0.0	0.0
02/05/2021	0.0	0.0	0.0	0.0
02/06/2021	0.0	0.0	0.0	0.0
02/07/2021	0.0	0.0	0.0	0.0
02/08/2021	0.0	0.0	0.0	0.0
02/09/2021	0.0	0.0	0.0	0.0
02/10/2021	0.0	0.0	0.0	0.0
02/11/2021	0.0	0.0	0.0	0.0
02/12/2021	0.0	0.0	0.0	0.0
02/13/2021	0.0	0.0	0.0	0.0
02/14/2021	0.0	0.0	0.0	0.0
02/15/2021	0.0	0.0	0.0	0.0
02/16/2021	0.0	0.0	0.0	0.0
02/17/2021	0.0	0.0	0.0	0.0
02/18/2021	0.0	0.0	0.0	0.0
02/19/2021	0.0	0.0	0.0	0.0
02/20/2021	0.0	0.0	0.0	0.0
02/21/2021	0.0	0.0	0.0	0.0
02/22/2021	0.0	0.0	0.0	0.0
02/23/2021	0.0	0.0	0.0	0.0
02/24/2021	0.0	0.0	0.0	0.0
02/25/2021	0.0	0.0	0.0	0.0
02/26/2021	0.0	0.0	277.5	22.9
02/27/2021	0.0	0.0	74.9	15.8
02/28/2021	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	- *	- *	352.4 *	38.7 *
Daily Min:	-	-	74.9	15.8
Daily Max:	-	-	277.5	22.9
Jan 2021 - Feb 2021	40.5	12.0	352.4	38.7
QTD:	40.5 *	12.0 *	352.4 *	38.7 *
YTD 2021:	40.5 *	12.0 *	352.4 *	38.7 *

Monthly Summary By Day Report



From: 01/01/2021 00:00 **To:** 03/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2021 11:32 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr	Unit CT1 NOX_SUSD, LbPerHr	Unit CT2 CO_SUSD, LbPerHr	Unit CT2 NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/01/2021	0.0	0.0	40.6	23.9
03/02/2021	0.0	0.0	0.0	0.0
03/03/2021	0.0	0.0	0.0	0.0
03/04/2021	0.0	0.0	0.0	0.0
03/05/2021	0.0	0.0	0.0	0.0
03/06/2021	0.0	0.0	46.5	27.2
03/07/2021	0.0	0.0	0.0	0.0
03/08/2021	150.0	16.3	0.0	0.0
03/09/2021	0.0	0.0	0.0	0.0
03/10/2021	60.1	33.3	0.0	0.0
03/11/2021	0.0	0.0	0.0	0.0
03/12/2021	68.6	18.4	14.8	0.6
03/13/2021	16.9	1.2	14.2	1.6
03/14/2021	0.0	0.0	0.0	0.0
03/15/2021	0.0	0.0	0.0	0.0
03/16/2021	0.0	0.0	0.0	0.0
03/17/2021	0.0	0.0	0.0	0.0
03/18/2021	0.0	0.0	0.0	0.0
03/19/2021	0.0	0.0	0.0	0.0
03/20/2021	0.0	0.0	0.0	0.0
03/21/2021	0.0	0.0	0.0	0.0
03/22/2021	0.0	0.0	89.5	21.6
03/23/2021	58.1	15.0	15.6	1.6
03/24/2021	25.9	1.4	56.7	15.5
03/25/2021	0.0	0.0	55.1	13.5
03/26/2021	0.0	0.0	0.0	0.0
03/27/2021	0.0	0.0	0.0	0.0
03/28/2021	0.0	0.0	0.0	0.0
03/29/2021	0.0	0.0	0.0	0.0
03/30/2021	0.0	0.0	0.0	0.0
03/31/2021	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	379.6 *	85.6 *	333.0 *	105.5 *
Daily Min:	16.9	1.2	14.2	0.6
Daily Max:	150.0	33.3	89.5	27.2
Jan 2021 - Mar 2021	420.1	97.6	685.4	144.2
QTD:	420.1 *	97.6 *	685.4 *	144.2 *
YTD 2021:	420.1 *	97.6 *	685.4 *	144.2 *

Startup / Shutdown Events

CT1



From: 01/01/2021 00:00 **To:** 03/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2021 11:28 **Location:** Roseville, CA

Unit offline

Tag Name: CT1_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
01/01/2021 00:00	01/23/2021 22:00	551
01/26/2021 01:00	03/08/2021 08:00	992
03/08/2021 11:00	03/08/2021 12:00	2
03/08/2021 21:00	03/10/2021 10:00	38
03/10/2021 20:00	03/12/2021 11:00	40
03/12/2021 15:00	03/13/2021 06:00	16
03/13/2021 19:00	03/23/2021 08:00	230
03/24/2021 13:00	03/31/2021 23:00	179

Startup / Shutdown Events

CT1



From: 01/01/2021 00:00 **To:** 03/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2021 11:28 **Location:** Roseville, CA

Operating Time Summary

Available Data for Report (excludes missing data):	2,160.00 Hour(s)
Total Offline:	2,048.00 Hour(s)
Offline Percentage:	94.81 %
Total Online:	112.00 Hour(s)
Online Percentage:	5.19 %

Startup / Shutdown Events

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 11:28 Location: Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	01/23/2021 23:44	01/24/2021 00:39	Cold Startup	56
2	01/25/2021 23:58	01/26/2021 00:00	Shutdown	3
3	03/08/2021 09:53	03/08/2021 09:58	Cold Startup	6
4	03/08/2021 09:58	03/08/2021 09:58	Shutdown	1
5	03/08/2021 10:29	03/08/2021 10:45	Cold Startup	17
6	03/08/2021 10:45	03/08/2021 10:45	Shutdown	1
7	03/08/2021 10:56	03/08/2021 10:56	Cold Startup	1
8	03/08/2021 10:56	03/08/2021 10:56	Shutdown	1
9	03/08/2021 13:44	03/08/2021 13:49	Cold Startup	6
10	03/08/2021 13:49	03/08/2021 13:49	Shutdown	1
11	03/08/2021 14:44	03/08/2021 15:38	Cold Startup	55
12	03/08/2021 20:01	03/08/2021 20:09	Shutdown	9
13	03/10/2021 11:42	03/10/2021 13:34	Cold Startup	113
14	03/10/2021 19:04	03/10/2021 19:12	Shutdown	9
15	03/12/2021 12:37	03/12/2021 12:40	Cold Startup	4
16	03/12/2021 12:40	03/12/2021 12:40	Shutdown	1
17	03/12/2021 13:03	03/12/2021 13:06	Cold Startup	4
18	03/12/2021 13:06	03/12/2021 13:06	Shutdown	1
19	03/12/2021 13:53	03/12/2021 14:42	Cold Startup	50
20	03/12/2021 14:36	03/12/2021 14:42	Shutdown	7
21	03/13/2021 07:44	03/13/2021 07:47	Cold Startup	4
22	03/13/2021 07:47	03/13/2021 07:47	Shutdown	1

Startup / Shutdown Events

CT1



From: 01/01/2021 00:00 **To:** 03/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2021 11:28 **Location:** Roseville, CA

Number	Start Time	End Time	Event Type	Duration
23	03/13/2021 08:07	03/13/2021 08:10	Cold Startup	4
24	03/13/2021 08:10	03/13/2021 08:10	Shutdown	1
25	03/13/2021 08:31	03/13/2021 10:33	Cold Startup	123
26	03/13/2021 18:01	03/13/2021 18:10	Shutdown	10
27	03/23/2021 09:29	03/23/2021 09:35	Cold Startup	7
28	03/23/2021 09:35	03/23/2021 09:35	Shutdown	1
29	03/23/2021 10:25	03/23/2021 11:27	Cold Startup	63
30	03/24/2021 11:54	03/24/2021 12:01	Shutdown	8

Startup / Shutdown Events

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 11:28 Location: Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	15	513	8.70
Warm Startup	0		0.00
Shutdown	15	55	0.93
Total Process Events:	30	568	9.64

Total Report Time:	2,159.98 Hour(s)
Total Operating Time:	98.23 Hour(s)
Total Startup Time:	513 Minute(s)
Total Shutdown Time:	55 Minute(s)
Total Startup/Shutdown Time:	568 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	9.64 %

Startup / Shutdown Events

CT2



From: 01/01/2021 00:00 **To:** 03/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2021 11:31 **Location:** Roseville, CA

Unit offline

Tag Name: CT2_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
01/01/2021 00:00	02/26/2021 07:00	1352
02/26/2021 15:00	02/27/2021 08:00	18
02/27/2021 19:00	03/01/2021 06:00	36
03/01/2021 18:00	03/06/2021 07:00	110
03/06/2021 18:00	03/12/2021 13:00	140
03/12/2021 16:00	03/12/2021 16:00	1
03/12/2021 18:00	03/13/2021 10:00	17
03/13/2021 23:00	03/22/2021 04:00	198
03/23/2021 15:00	03/24/2021 07:00	17
03/24/2021 17:00	03/25/2021 05:00	13
03/25/2021 12:00	03/31/2021 23:00	156

Startup / Shutdown Events

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 11:31 Location: Roseville, CA

Operating Time Summary

Available Data for Report (excludes missing data):	2,160.00 Hour(s)
Total Offline:	2,058.00 Hour(s)
Offline Percentage:	95.28 %
Total Online:	102.00 Hour(s)
Online Percentage:	4.72 %

Startup / Shutdown Events

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 11:31 Location: Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	02/26/2021 08:17	02/26/2021 09:19	Cold Startup	63
2	02/26/2021 14:11	02/26/2021 14:20	Shutdown	10
3	02/27/2021 09:43	02/27/2021 10:30	Cold Startup	48
4	02/27/2021 17:52	02/27/2021 18:00	Shutdown	9
5	03/01/2021 07:45	03/01/2021 08:34	Cold Startup	50
6	03/01/2021 16:53	03/01/2021 17:02	Shutdown	10
7	03/06/2021 08:05	03/06/2021 09:08	Cold Startup	64
8	03/06/2021 16:57	03/06/2021 17:07	Shutdown	11
9	03/12/2021 14:58	03/12/2021 15:01	Cold Startup	4
10	03/12/2021 15:01	03/12/2021 15:01	Shutdown	1
11	03/12/2021 15:26	03/12/2021 15:29	Cold Startup	4
12	03/12/2021 15:29	03/12/2021 15:29	Shutdown	1
13	03/12/2021 15:51	03/12/2021 15:56	Cold Startup	6
14	03/12/2021 15:56	03/12/2021 15:56	Shutdown	1
15	03/12/2021 17:11	03/12/2021 17:16	Cold Startup	6
16	03/12/2021 17:16	03/12/2021 17:16	Shutdown	1
17	03/13/2021 11:44	03/13/2021 12:45	Cold Startup	62
18	03/13/2021 22:00	03/13/2021 22:09	Shutdown	10
19	03/22/2021 05:39	03/22/2021 06:40	Cold Startup	62
20	03/22/2021 07:51	03/22/2021 07:51	Shutdown	1
21	03/22/2021 08:08	03/22/2021 08:29	Warm Startup	22
22	03/23/2021 13:57	03/23/2021 14:07	Shutdown	11

Startup / Shutdown Events

CT2



From: 01/01/2021 00:00 **To:** 03/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2021 11:31 **Location:** Roseville, CA

Number	Start Time	End Time	Event Type	Duration
23	03/24/2021 08:44	03/24/2021 09:34	Cold Startup	51
24	03/24/2021 15:56	03/24/2021 16:03	Shutdown	8
25	03/25/2021 06:45	03/25/2021 07:25	Cold Startup	41
26	03/25/2021 11:03	03/25/2021 11:11	Shutdown	9

Startup / Shutdown Events

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 11:31 Location: Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	12	461	8.78
Warm Startup	1	22	0.42
Shutdown	13	83	1.58
Total Process Events:	26	566	10.79

Total Report Time:	2,159.98 Hour(s)
Total Operating Time:	87.47 Hour(s)
Total Startup Time:	483 Minute(s)
Total Shutdown Time:	83 Minute(s)
Total Startup/Shutdown Time:	566 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	10.79 %

CT1 SUSD EVENT 1

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/23/21 23:39	0			0			0			0			0			0		
01/23/21 23:40	0			0			0			0			0			0		
01/23/21 23:41	0			0			0			0			0			0		
01/23/21 23:42	0			0			0			0			0			0		
01/23/21 23:43	0			0			0			0			0			0		
01/23/21 23:44	0			0.3			0			0			0			1		
01/23/21 23:45	0			0.3			0			0			0			1		
01/23/21 23:46	0			129.8			23.6			0			0			1		
01/23/21 23:47	18483.8			619.1			12.98			26.75			0.92			1		
01/23/21 23:48	47826.9			501.2			16.77			55.87			3.08			1		
01/23/21 23:49	92034.1			336			23.6			72.13			8.34			1		
01/23/21 23:50	133930.8			189.8			24.88			59.32			12.8			1		
01/23/21 23:51	136934.4			73.2			52.31			23.37			27.5			1		
01/23/21 23:52	148178.7			1357.6			40.75			469.2			23.18			1		
01/23/21 23:53	165661.4			1922			37.55			742.57			23.87			1		
01/23/21 23:54	188304			1607.7			42.1			706.07			30.43			1		
01/23/21 23:55	213565.3			414.8			50.71			206.61			41.57			1		
01/23/21 23:56	235514.8			44.3			55.23			24.34			49.93			1		
01/23/21 23:57	260160			3.8			54.77			2.3			54.7			1		
01/23/21 23:58	285652.3			2.3			54.93			1.56			60.22			1		
01/23/21 23:59	307832.8			2.1			41.02			1.52			48.48			1		
01/24/21 0:00	315919.5			2.1			23.86			1.58			28.93			1		
01/24/21 0:01	330783.6			2.2			15.93			1.69			20.23			1		
01/24/21 0:02	347496.1			2.1			14.08			1.71			18.78			1		
01/24/21 0:03	363823.4			2			10.86			1.67			15.17			1		
01/24/21 0:04	378225.4			1.8			8.28			1.55			12.02			1		
01/24/21 0:05	384540.8			1.5			7.15			1.36			10.56			1		
01/24/21 0:06	399558.9			1.3			6.69			1.23			10.26			1		
01/24/21 0:07	419506			1.3			5.81			1.22			9.36			1		
01/24/21 0:08	430365.3			1.1			5.36			1.09			8.85			1		
01/24/21 0:09	437835.8			1			5.26			1.02			8.85			1		
01/24/21 0:10	439838.2			0.9			5.26			0.93			8.89			1		
01/24/21 0:11	439915.2			0.9			5.17			0.93			8.74			1		
01/24/21 0:12	439607.2			0.9			5.17			0.93			8.73			1		
01/24/21 0:13	439222.1			0.8			5.08			0.84			8.57			1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSDTF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/24/21 0:14	438451.9			0.8			5.16			0.85			8.69			1		
01/24/21 0:15	437835.8			0.8			5.07			0.85			8.52			1		
01/24/21 0:16	436834.6			0.7			5.07			0.75			8.5			1		
01/24/21 0:17	436064.4			0.7			4.98			0.75			8.33			1		
01/24/21 0:18	435756.4			0.7			4.98			0.75			8.33			1		
01/24/21 0:19	435448.3			0.7			5.07			0.75			8.47			1		
01/24/21 0:20	435217.3			0.7			5.16			0.75			8.62			1		
01/24/21 0:21	434986.2			0.7			5.35			0.75			8.93			1		
01/24/21 0:22	434909.2			0.7			5.44			0.75			9.08			1		
01/24/21 0:23	434524.1			0.7			5.53			0.75			9.23			1		
01/24/21 0:24	433985			0.7			5.16			0.75			8.6			1		
01/24/21 0:25	433522.9			0.7			3.32			0.75			5.52			1		
01/24/21 0:26	433754			0.7			2.67			0.75			4.45			1		
01/24/21 0:27	433676.9			0.7			2.49			0.75			4.14			1		
01/24/21 0:28	432906.8			0.7			2.49			0.74			4.14			1		
01/24/21 0:29	432675.7			0.7			2.58			0.74			4.29			1		
01/24/21 0:30	431982.6			0.7			2.58			0.74			4.28			1		
01/24/21 0:31	432444.7			0.7			2.54			0.73			4.22			1		
01/24/21 0:32	432213.6			0.7			2.54			0.73			4.22			1		
01/24/21 0:33	432213.6			0.7			2.36			0.73			3.92			1		
01/24/21 0:34	431905.6			0.7			2.27			0.73			3.76			1		
01/24/21 0:35	431828.6			0.7			2.09			0.73			3.46			1		
01/24/21 0:36	431751.5			0.7			2			0.73			3.31			1		
01/24/21 0:37	431212.4			0.7			1.91			0.73			3.16			1		
01/24/21 0:38	431366.5			0.7			1.82			0.73			3.01			1		
01/24/21 0:39	431520.5			0.7			1.82			0.73			3.01			1		
01/24/21 0:40	431443.5			0.7			1.72			0.73			2.86			0		
01/24/21 0:41	430981.4			0.7			1.72			0.73			2.85			0		
01/24/21 0:42	431366.5			0.7			1.72			0.73			2.86			0		
01/24/21 0:43	431135.4			0.7			1.72			0.73			2.85			0		
01/24/21 0:44	431212.4			0.7			1.63			0.73			2.7			0		

CT1 SUSD EVENT 2

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/25/21 23:53	386389.1			0.7			1.72			0.65			2.56			0		
01/25/21 23:54	382538.3			0.7			1.72			0.65			2.53			0		
01/25/21 23:55	364747.7			0.8			1.7			0.68			2.38			0		
01/25/21 23:56	342413			0.8			1.76			0.63			2.31			0		
01/25/21 23:57	321233.6			0.9			1.82			0.65			2.25			0		
01/25/21 23:58	301286.5			0.9			1.82			0.61			2.11			1		
01/25/21 23:59	278643.8			0.9			1.76			0.57			1.88			1		
01/26/21 0:00	211408.8			0.8			2.41			0.4			1.96			1		
01/26/21 0:01	0			0			6.29			0			0			0		
01/26/21 0:02	0			0			13.77			0			0			0		
01/26/21 0:03	0			0			5.9			0			0			0		
01/26/21 0:04	0			0			0.1			0			0			0		
01/26/21 0:05	0			0			0.1			0			0			0		

CT1 SUSD EVENT 3

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/08/21 9:48	0			0			0			0			0			0		
03/08/21 9:49	0			0			0			0			0			0		
03/08/21 9:50	0			0			0			0			0			0		
03/08/21 9:51	0			0			0			0			0			0		
03/08/21 9:52	2926.6			0			0			0			0			0		
03/08/21 9:53	21333.4			0.3			0			0			0			1		
03/08/21 9:54	32192.7			0.3			0			0			0			1		
03/08/21 9:55	47441.8			46.2			9.83			5.11			1.79			1		
03/08/21 9:56	58994.2			657.4			9.94			90.35			2.25			1		
03/08/21 9:57	71239.8			196.1			16.76			32.57			4.58			1		
03/08/21 9:58	48212			46.1			17.34			5.18			3.21			1		
03/08/21 9:59	0			0			35.11			0			0			0		
03/08/21 10:00	2079.4			0			51.33			0.08			0.42			0		
03/08/21 10:01	0			0			60.97			0			0			0		
03/08/21 10:02	1001.2			0			1.9			0			0			0		
03/08/21 10:03	1078.2			0			1.8			0			0			0		

CT1 SUSD EVENT 4

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/08/21 9:48	0			0			0			0			0			0		
03/08/21 9:49	0			0			0			0			0			0		
03/08/21 9:50	0			0			0			0			0			0		
03/08/21 9:51	0			0			0			0			0			0		
03/08/21 9:52	2926.6			0			0			0			0			0		
03/08/21 9:53	21333.4			0.3			0			0			0			1		
03/08/21 9:54	32192.7			0.3			0			0			0			1		
03/08/21 9:55	47441.8			46.2			9.83			5.11			1.79			1		
03/08/21 9:56	58994.2			657.4			9.94			90.35			2.25			1		
03/08/21 9:57	71239.8			196.1			16.76			32.57			4.58			1		
03/08/21 9:58	48212			46.1			17.34			5.18			3.21			1		
03/08/21 9:59	0			0			35.11			0			0			0		
03/08/21 10:00	2079.4			0			51.33			0.08			0.42			0		
03/08/21 10:01	0			0			60.97			0			0			0		
03/08/21 10:02	1001.2			0			1.9			0			0			0		
03/08/21 10:03	1078.2			0			1.8			0			0			0		

CT1 SUSD EVENT 5

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/08/21 10:24	11783.4			0			0.4			0			0			0		
03/08/21 10:25	10320.1			0			0.3			0			0			0		
03/08/21 10:26	12399.6			0			0.2			0			0			0		
03/08/21 10:27	12784.7			0			0.2			0			0			0		
03/08/21 10:28	11860.5			0			0.2			0			0			0		
03/08/21 10:29	23412.9			0.4			0.2			0			0			1		
03/08/21 10:30	27879.8			0.4			0.2			0			0			1		
03/08/21 10:31	39201.1			59			29.5			5.39			4.43			1		
03/08/21 10:32	51061.6			1134.5			13.49			135.1			2.64			1		
03/08/21 10:33	62768			897.5			19.09			131.39			4.6			1		
03/08/21 10:34	85872.8			543.7			22.72			108.8			7.48			1		
03/08/21 10:35	130311			387.8			24.94			117.8			12.47			1		
03/08/21 10:36	142479.5			253			42.66			84.05			23.32			1		
03/08/21 10:37	139861			719.2			48.53			234.57			26.05			1		
03/08/21 10:38	138551.7			2063.8			45.23			666.63			24.05			1		
03/08/21 10:39	137165.5			2134.8			51.68			682.87			27.2			1		
03/08/21 10:40	136472.3			2135			56.56			679.11			29.61			1		
03/08/21 10:41	136164.2			2210.8			59.84			701.74			31.26			1		
03/08/21 10:42	135163			169.1	X		66.47	X		53.31	X		34.48	X		1		
03/08/21 10:43	135240			97.6	X		56.28	X		30.78	X		29.21	X		1		
03/08/21 10:44	134315.9			97.6	X		62.86	X		30.56	X		32.4	X		1		
03/08/21 10:45	101584.1			90.6	X		58.16	X		21.46	X		22.67	X		1		
03/08/21 10:46	13092.7			0	X		57.03	X		2.86	X		2.86	X		0		
03/08/21 10:47	13015.7			0	X		283.2	X		77.23	X		14.19	X		0		
03/08/21 10:48	12091.5			0			4.2			0			0			0		
03/08/21 10:49	12861.7			0			4.1			0			0			0		
03/08/21 10:50	12553.6			0			3.3			0			0			0		

CT1 SUSD EVENT 6

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/08/21 10:24	11783.4			0			0.4			0			0			0		
03/08/21 10:25	10320.1			0			0.3			0			0			0		
03/08/21 10:26	12399.6			0			0.2			0			0			0		
03/08/21 10:27	12784.7			0			0.2			0			0			0		
03/08/21 10:28	11860.5			0			0.2			0			0			0		
03/08/21 10:29	23412.9			0.4			0.2			0			0			1		
03/08/21 10:30	27879.8			0.4			0.2			0			0			1		
03/08/21 10:31	39201.1			59			29.5			5.39			4.43			1		
03/08/21 10:32	51061.6			1134.5			13.49			135.1			2.64			1		
03/08/21 10:33	62768			897.5			19.09			131.39			4.6			1		
03/08/21 10:34	85872.8			543.7			22.72			108.8			7.48			1		
03/08/21 10:35	130311			387.8			24.94			117.8			12.47			1		
03/08/21 10:36	142479.5			253			42.66			84.05			23.32			1		
03/08/21 10:37	139861			719.2			48.53			234.57			26.05			1		
03/08/21 10:38	138551.7			2063.8			45.23			666.63			24.05			1		
03/08/21 10:39	137165.5			2134.8			51.68			682.87			27.2			1		
03/08/21 10:40	136472.3			2135			56.56			679.11			29.61			1		
03/08/21 10:41	136164.2			2210.8			59.84			701.74			31.26			1		
03/08/21 10:42	135163			169.1	X		66.47	X		53.31	X		34.48	X		1		
03/08/21 10:43	135240			97.6	X		56.28	X		30.78	X		29.21	X		1		
03/08/21 10:44	134315.9			97.6	X		62.86	X		30.56	X		32.4	X		1		
03/08/21 10:45	101584.1			90.6	X		58.16	X		21.46	X		22.67	X		1		
03/08/21 10:46	13092.7			0	X		57.03	X		2.86	X		2.86	X		0		
03/08/21 10:47	13015.7			0	X		283.2	X		77.23	X		14.19	X		0		
03/08/21 10:48	12091.5			0			4.2			0			0			0		
03/08/21 10:49	12861.7			0			4.1			0			0			0		
03/08/21 10:50	12553.6			0			3.3			0			0			0		

CT1 SUSD EVENT 7

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/08/21 10:51	12861.7			0			2.9			0			0			0		
03/08/21 10:52	12861.7			0			2.6			0			0			0		
03/08/21 10:53	14479			0			2.4			0			0			0		
03/08/21 10:54	13631.8			0			2.3			0			0			0		
03/08/21 10:55	14402			0			2			0			0			0		
03/08/21 10:56	15326.2			19.9			1.9			0			0			1		
03/08/21 10:57	14248			0			1.7			0			0			0		
03/08/21 10:58	11629.4			0			47.2			21.33			2.1			0		
03/08/21 10:59	13477.8			0			25.08			15.07			1.29			0		
03/08/21 11:00	15249.2			0			56.05			33.07			3.28			0		
03/08/21 11:01	14556			0			118			61.43			6.61			0		

CT1 SUSD EVENT 8

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/08/21 10:51	12861.7			0			2.9			0			0			0		
03/08/21 10:52	12861.7			0			2.6			0			0			0		
03/08/21 10:53	14479			0			2.4			0			0			0		
03/08/21 10:54	13631.8			0			2.3			0			0			0		
03/08/21 10:55	14402			0			2			0			0			0		
03/08/21 10:56	15326.2			19.9			1.9			0			0			1		
03/08/21 10:57	14248			0			1.7			0			0			0		
03/08/21 10:58	11629.4			0			47.2			21.33			2.1			0		
03/08/21 10:59	13477.8			0			25.08			15.07			1.29			0		
03/08/21 11:00	15249.2			0			56.05			33.07			3.28			0		
03/08/21 11:01	14556			0			118			61.43			6.61			0		

CT1 SUSD EVENT 9

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/08/21 13:39	22334.6			0			0.1			0			0			0		
03/08/21 13:40	21949.6			0			0.1			0			0			0		
03/08/21 13:41	22180.6			0			0.1			0			0			0		
03/08/21 13:42	22411.6			0			0.1			0			0			0		
03/08/21 13:43	23875			0			0.1			0			0			0		
03/08/21 13:44	32885.8			0.9			0.1			0			0			1		
03/08/21 13:45	39586.2			1.3			0.1			0			0			1		
03/08/21 13:46	46209.6			65.6			39.33			7.06			6.97			1		
03/08/21 13:47	56837.8			784.7			23.6			103.99			5.15			1		
03/08/21 13:48	70623.6			697.5			28.84			114.92			7.82			1		
03/08/21 13:49	61458.7			473.8			36.29			67.87			8.56			1		
03/08/21 13:50	21641.5			0			44.25			15.55			3.67			0		
03/08/21 13:51	21641.5			0			8.26			8.86			0.68			0		
03/08/21 13:52	21641.5			0			0.4			0			0			0		
03/08/21 13:53	21410.4			0			0.4			0			0			0		
03/08/21 13:54	21564.5			0			0.4			0			0			0		

CT1 SUSD EVENT 10

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/08/21 13:39	22334.6			0			0.1			0			0			0		
03/08/21 13:40	21949.6			0			0.1			0			0			0		
03/08/21 13:41	22180.6			0			0.1			0			0			0		
03/08/21 13:42	22411.6			0			0.1			0			0			0		
03/08/21 13:43	23875			0			0.1			0			0			0		
03/08/21 13:44	32885.8			0.9			0.1			0			0			1		
03/08/21 13:45	39586.2			1.3			0.1			0			0			1		
03/08/21 13:46	46209.6			65.6			39.33			7.06			6.97			1		
03/08/21 13:47	56837.8			784.7			23.6			103.99			5.15			1		
03/08/21 13:48	70623.6			697.5			28.84			114.92			7.82			1		
03/08/21 13:49	61458.7			473.8			36.29			67.87			8.56			1		
03/08/21 13:50	21641.5			0			44.25			15.55			3.67			0		
03/08/21 13:51	21641.5			0			8.26			8.86			0.68			0		
03/08/21 13:52	21641.5			0			0.4			0			0			0		
03/08/21 13:53	21410.4			0			0.4			0			0			0		
03/08/21 13:54	21564.5			0			0.4			0			0			0		

CT1 SUSD EVENT 11

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/08/21 14:39	20255.2			0			0.3			0			0			0		
03/08/21 14:40	20255.2			0			0.1			0			0			0		
03/08/21 14:41	20409.2			0			0.1			0			0			0		
03/08/21 14:42	20409.2			0			0.1			0			0			0		
03/08/21 14:43	20255.2			0			0.1			0			0			0		
03/08/21 14:44	26031.4			0.8			0.1			0			0			1		
03/08/21 14:45	28649.9			0.8			0.1			0			0			1		
03/08/21 14:46	37737.8			2			0.5			0			0			1		
03/08/21 14:47	48366			1025			25.75			115.64			4.78			1		
03/08/21 14:48	59995.4			921.1			24.64			128.86			5.67			1		
03/08/21 14:49	75629.7			602.4			29.19			106.26			8.47			1		
03/08/21 14:50	116371.1			422.6			37.09			114.64			16.56			1		
03/08/21 14:51	142325.5			262.7			52.16			87.14			28.48			1		
03/08/21 14:52	148871.9			284			63.72			98.53			36.39			1		
03/08/21 14:53	153184.8			1910.5			53.29			682.1			31.31			1		
03/08/21 14:54	167586.8			1939.4			52.73			757.57			33.9			1		
03/08/21 14:55	186917.8			1825.4			51.02			795.54			36.59			1		
03/08/21 14:56	208790.3			1013.7			49.62			493.56			39.76			1		
03/08/21 14:57	231664			170.2			49.88			91.91			44.34			1		
03/08/21 14:58	250070.9			17.8			49.13			10.39			47.13			1		
03/08/21 14:59	278027.7			5.8			45.12			3.75			48.14			1		
03/08/21 15:00	302287.7			5.1			34.32			3.6			39.8			1		
03/08/21 15:01	314379.2			5.1			21.6			3.73			26.06			1		
03/08/21 15:02	314841.3			5.3			11.03			3.89			13.32			1		
03/08/21 15:03	315226.4			5.6			10.09			4.15			12.2			1		
03/08/21 15:04	314764.3			5.6			9.06			4.14			10.95			1		
03/08/21 15:05	313840.1			5.3			8.42			3.87			10.14			1		
03/08/21 15:06	313917.1			4.8			7.38			3.49			8.88			1		
03/08/21 15:07	313994.1			4.2			6.85			3.05			8.26			1		
03/08/21 15:08	313224			3.8			6.07			2.79			7.3			1		
03/08/21 15:09	312453.8			3.6			5.55			2.59			6.66			1		
03/08/21 15:10	311991.7			3.4			5.2			2.5			6.22			1		
03/08/21 15:11	312068.7			3.3			5.02			2.37			6.01			1		
03/08/21 15:12	311914.7			3.2			4.84			2.31			5.8			1		
03/08/21 15:13	311760.7			3			4.58			2.18			5.48			1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSDTF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/08/21 15:14	311837.7			3			4.49			2.18			5.37			1		
03/08/21 15:15	311914.7			2.9			4.31			2.11			5.16			1		
03/08/21 15:16	311529.6			2.8			4.23			2.05			5.05			1		
03/08/21 15:17	311683.6			2.7			4.23			1.98			5.05			1		
03/08/21 15:18	311067.5			2.5			4.31			1.79			5.15			1		
03/08/21 15:19	310605.4			2.2			4.4			1.59			5.25			1		
03/08/21 15:20	310682.4			2.1			4.56			1.49			5.44			1		
03/08/21 15:21	310836.5			1.9			4.56			1.36			5.44			1		
03/08/21 15:22	310605.4			1.7			4.65			1.23			5.54			1		
03/08/21 15:23	311144.5			1.6			4.83			1.17			5.76			1		
03/08/21 15:24	310913.5			1.5			5.01			1.1			5.97			1		
03/08/21 15:25	310682.4			1.5			5.1			1.1			6.07			1		
03/08/21 15:26	310990.5			1.4			4.74			1.04			5.65			1		
03/08/21 15:27	309989.3			1.4			3.13			1.03			3.72			1		
03/08/21 15:28	309835.3			1.3			2.68			0.97			3.19			1		
03/08/21 15:29	309604.2			1.3			2.5			0.97			2.97			1		
03/08/21 15:30	310220.3			1.3			2.32			0.91			2.77			1		
03/08/21 15:31	310143.3			1.3			2.32			0.9			2.77			1		
03/08/21 15:32	309912.3			1.3			2.23			0.9			2.66			1		
03/08/21 15:33	309373.2			1.3			2.23			0.9			2.65			1		
03/08/21 15:34	309989.3			1.3			2.15			0.9			2.55			1		
03/08/21 15:35	309681.2			1.2			2.06			0.84			2.44			1		
03/08/21 15:36	309604.2			1.2			1.97			0.84			2.34			1		
03/08/21 15:37	309604.2			1.2			1.88			0.84			2.23			1		
03/08/21 15:38	309604.2			1.2			1.79			0.84			2.12			1		
03/08/21 15:39	309989.3			1.2			1.7			0.84			2.02			0		
03/08/21 15:40	309758.3			1.2			1.7			0.84			2.02			0		
03/08/21 15:41	309758.3			1.2			1.7			0.84			2.02			0		
03/08/21 15:42	310066.3			1.1			1.61			0.78			1.91			0		
03/08/21 15:43	309835.3			1.1			1.61			0.77			1.91			0		

CT1 SUSD EVENT 12

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/08/21 19:56	325546.5			1.1			2.11			0.83			2.63			0		
03/08/21 19:57	310066.3			1.2			1.54			0.87			1.83			0		
03/08/21 19:58	308217.9			1.1			1.41			0.82			1.67			0		
03/08/21 19:59	307755.8			1			1.23			0.69			1.46			0		
03/08/21 20:00	307832.8			0.9			1.25			0.64			1.48			0		
03/08/21 20:01	300593.3			0.9			1.25			0.63			1.44			1		
03/08/21 20:02	280107.1			0.9			1.79			0.58			1.92			1		
03/08/21 20:03	256001.1			0.9			4.54			0.54			4.46			1		
03/08/21 20:04	237363.2			0.8			7.83			0.43			7.13			1		
03/08/21 20:05	213026.2			0.6			13.52			0.32			11.05			1		
03/08/21 20:06	189690.3			3.2			16.43			1.43			11.96			1		
03/08/21 20:07	169281.1			121.7			19.27			48.02			12.52			1		
03/08/21 20:08	152106.5			887.8			19.47			314.79			11.36			1		
03/08/21 20:09	103971.6			1768.8			21.58			428.81			8.61			1		
03/08/21 20:10	18098.8			0			22.18			90.29			1.54			0		
03/08/21 20:11	18175.8			0			17.7			392.89			1.23			0		
03/08/21 20:12	17944.7			0			0.2			0			0			0		
03/08/21 20:13	17867.7			0			0.2			0			0			0		
03/08/21 20:14	18021.7			0			0.2			0			0			0		

CT1 SUSD EVENT 13

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/10/21 11:37	0			0			0			0			0			0		
03/10/21 11:38	1463.3			0			0			0			0			0		
03/10/21 11:39	0			0			0			0			0			0		
03/10/21 11:40	0			0			0			0			0			0		
03/10/21 11:41	19562.1			0			0			0			0			0		
03/10/21 11:42	25338.3			0.4			0			0			0			1		
03/10/21 11:43	30036.2			0.4			0			0			0			1		
03/10/21 11:44	42512.8			74.3			14.16			7.37			2.31			1		
03/10/21 11:45	53988.2			1121			11.06			141.02			2.29			1		
03/10/21 11:46	67466			826.3			16.39			130.03			4.24			1		
03/10/21 11:47	98272.4			536.6			21.24			122.88			8			1		
03/10/21 11:48	139475.9			370.9			23.09			120.64			12.36			1		
03/10/21 11:49	150951.3			223.6			43.83			78.67			25.38			1		
03/10/21 11:50	168588			1309.8			41.85			514.85			27.08			1		
03/10/21 11:51	188073			1854.2			45.12			813.08			32.56			1		
03/10/21 11:52	202783.1			1131.4			53.4			534.9			41.55			1		
03/10/21 11:53	204785.5			213.6			57.93			101.99			45.52			1		
03/10/21 11:54	204169.3			77.5			56.95			36.87			44.6			1		
03/10/21 11:55	204477.4			68.2			58.74			32.53			46.1			1		
03/10/21 11:56	203630.2			67.9			59.9			32.21			46.8			1		
03/10/21 11:57	207173			68.7			59.13			33.21			47.01			1		
03/10/21 11:58	229969.7			65.2			57.33			34.93			50.59			1		
03/10/21 11:59	238287.4			15.9			53.1			8.83			48.55			1		
03/10/21 12:00	239365.6			1.9			49.09			1.06			45.09			1		
03/10/21 12:01	238980.6			1.4			47.64			0.79			43.68			1		
03/10/21 12:02	238980.6			1.4			45.67			0.79			41.88			1		
03/10/21 12:03	238364.4			1.4			43.7			0.79			39.98			1		
03/10/21 12:04	237363.2			1.4			37.69			0.79			34.33			1		
03/10/21 12:05	237132.2			1.3			33.11			0.72			30.12			1		
03/10/21 12:06	237902.3			1.2			30.16			0.67			27.53			1		
03/10/21 12:07	237594.3			1.1			29.94			0.61			27.29			1		
03/10/21 12:08	238056.4			1			29.72			0.55			27.14			1		
03/10/21 12:09	240674.9			0.9			29.28			0.49			27.04			1		
03/10/21 12:10	240597.9			0.9			34.31			0.49			31.67			1		
03/10/21 12:11	248068.5			0.8			36.38			0.44			34.63			1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/10/21 12:12	250301.9			0.9			36.15			0.5			34.72			1		
03/10/21 12:13	251380.1			0.8			35.19			0.49			33.94			1		
03/10/21 12:14	251919.3			0.8			35.09			0.49			33.92			1		
03/10/21 12:15	252381.3			0.8			34.88			0.49			33.78			1		
03/10/21 12:16	251842.2			0.7			34.78			0.43			33.61			1		
03/10/21 12:17	253151.5			0.8			33.74			0.49			32.78			1		
03/10/21 12:18	252843.4			0.8			28.78			0.49			27.91			1		
03/10/21 12:19	252304.3			0.8			27.53			0.49			26.66			1		
03/10/21 12:20	252227.3			0.8			27.53			0.49			26.65			1		
03/10/21 12:21	250687			0.8			27.84			0.48			26.78			1		
03/10/21 12:22	250378.9			0.8			29.6			0.48			28.44			1		
03/10/21 12:23	250378.9			0.8			32.61			0.48			31.33			1		
03/10/21 12:24	250687			0.7			33.02			0.42			31.76			1		
03/10/21 12:25	250610			0.7			33.74			0.42			32.45			1		
03/10/21 12:26	250841			0.6			34.78			0.36			33.47			1		
03/10/21 12:27	250764			0.6			35.61			0.36			34.26			1		
03/10/21 12:28	250841			0.6			36.44			0.36			35.06			1		
03/10/21 12:29	250610			0.6			37.16			0.36			35.73			1		
03/10/21 12:30	250995			0.5			37.47			0.3			36.08			1		
03/10/21 12:31	250764			0.5			21.84			0.3			21.02			1		
03/10/21 12:32	250764			0.5			13.77			0.3			13.25			1		
03/10/21 12:33	250841			0.5			14.49			0.3			13.94			1		
03/10/21 12:34	250764			0.5			14.8			0.3			14.24			1		
03/10/21 12:35	250455.9			0.5			14.91			0.3			14.33			1		
03/10/21 12:36	250224.9			0.5			14.8			0.3			14.21			1		
03/10/21 12:37	250301.9			0.5			14.49			0.3			13.92			1		
03/10/21 12:38	250301.9			0.5			14.18			0.3			13.62			1		
03/10/21 12:39	250224.9			0.5			13.77			0.3			13.22			1		
03/10/21 12:40	249916.8			0.5			13.56			0.3			13			1		
03/10/21 12:41	250301.9			0.5			13.35			0.3			12.82			1		
03/10/21 12:42	249762.8			0.5			13.04			0.3			12.5			1		
03/10/21 12:43	251688.2			0.5			12.21			0.3			11.79			1		
03/10/21 12:44	251380.1			0.5			9.63			0.3			9.28			1		
03/10/21 12:45	250918			0.5			8.18			0.3			7.87			1		
03/10/21 12:46	250070.9			0.5			7.76			0.3			7.45			1		
03/10/21 12:47	249531.8			0.5			7.04			0.3			6.74			1		
03/10/21 12:48	248530.5			0.4			7.04			0.24			6.71			1		
03/10/21 12:49	249762.8			0.4			6.62			0.24			6.35			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/10/21 12:50	250070.9			0.4			5.8			0.24			5.56			1		
03/10/21 12:51	249146.7			0.4			5.49			0.24			5.24			1		
03/10/21 12:52	248915.6			0.4			4.76			0.24			4.55			1		
03/10/21 12:53	249454.7			0.4			4.55			0.24			4.36			1		
03/10/21 12:54	249839.8			0.4			4.55			0.24			4.37			1		
03/10/21 12:55	249839.8			0.4			4.45			0.24			4.27			1		
03/10/21 12:56	249454.7			0.4			4.24			0.24			4.06			1		
03/10/21 12:57	249685.8			0.4			4.14			0.24			3.97			1		
03/10/21 12:58	249531.8			0.4			4.04			0.24			3.87			1		
03/10/21 12:59	250301.9			0.4			3.93			0.24			3.78			1		
03/10/21 13:00	248453.5			0.4			3.73			0.24			3.55			1		
03/10/21 13:01	248145.5			0.4			4.86			0.24			4.63			1		
03/10/21 13:02	248453.5			0.4			5.79			0.24			5.52			1		
03/10/21 13:03	248915.6			0.4			5.8			0.24			5.54			1		
03/10/21 13:04	249454.7			0.4			5.9			0.24			5.65			1		
03/10/21 13:05	250610			0.4			5.8			0.24			5.57			1		
03/10/21 13:06	250070.9			0.4			6.21			0.24			5.96			1		
03/10/21 13:07	250918			0.4			7.04			0.24			6.78			1		
03/10/21 13:08	258157.5			0.4			7.97			0.25			7.9			1		
03/10/21 13:09	264934.9			0.4			8.24			0.25			8.37			1		
03/10/21 13:10	265782.1			0.5			7.28			0.3			7.42			1		
03/10/21 13:11	265474.1			0.6			6.77			0.36			6.9			1		
03/10/21 13:12	265628.1			0.6			6.77			0.36			6.9			1		
03/10/21 13:13	265320			0.6			6.67			0.36			6.79			1		
03/10/21 13:14	265551.1			0.6			6.58			0.36			6.7			1		
03/10/21 13:15	265397			0.6			6.69			0.37			6.81			1		
03/10/21 13:16	266013.2			0.6			6.49			0.37			6.62			1		
03/10/21 13:17	266706.3			0.6			5.51			0.36			5.64			1		
03/10/21 13:18	265397			0.6			4.55			0.36			4.63			1		
03/10/21 13:19	265320			0.6			3.68			0.36			3.74			1		
03/10/21 13:20	265474.1			0.6			3.39			0.36			3.45			1		
03/10/21 13:21	265320			0.6			3.19			0.36			3.25			1		
03/10/21 13:22	265705.1			0.6			2.9			0.36			2.96			1		
03/10/21 13:23	265243			0.6			2.85			0.36			2.9			1		
03/10/21 13:24	265474.1			0.6			2.75			0.37			2.8			1		
03/10/21 13:25	265397			0.6			2.66			0.37			2.7			1		
03/10/21 13:26	265089			0.6			2.51			0.36			2.56			1		
03/10/21 13:27	265243			0.6			2.46			0.36			2.5			1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/10/21 13:28	264087.8			0.6			2.36			0.36			2.39			1		
03/10/21 13:29	264087.8			0.6			2.26			0.36			2.29			1		
03/10/21 13:30	263856.7			0.6			2.16			0.36			2.19			1		
03/10/21 13:31	264934.9			0.6			1.48			0.36			1.5			1		
03/10/21 13:32	264703.9			0.6			1.38			0.36			1.4			1		
03/10/21 13:33	264395.8			0.6			1.28			0.36			1.3			1		
03/10/21 13:34	265089			0.6			1.28			0.36			1.3			1		
03/10/21 13:35	265089			0.6			1.38			0.36			1.4			0		
03/10/21 13:36	267168.4			0.6			1.38			0.37			1.41			0		
03/10/21 13:37	263394.6			0.6			2.03			0.36			2.05			0		
03/10/21 13:38	263163.6			0.6			3.1			0.36			3.13			0		
03/10/21 13:39	272328.5			0.6			4.72			0.37			4.93			0		

CT1 SUSD EVENT 14

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/10/21 18:59	325084.4			1.1			1.6			0.83			2			0		
03/10/21 19:00	308603			1.1			1.52			0.79			1.8			0		
03/10/21 19:01	306446.6			1.1			1.39			0.81			1.63			0		
03/10/21 19:02	306446.6			1.1			1.23			0.76			1.45			0		
03/10/21 19:03	306446.6			1			1.14			0.69			1.35			0		
03/10/21 19:04	297743.8			1			1.14			0.67			1.31			1		
03/10/21 19:05	276564.3			1			1.94			0.62			2.06			1		
03/10/21 19:06	252381.3			0.9			4.9			0.53			4.75			1		
03/10/21 19:07	232742.3			0.8			8.26			0.43			7.38			1		
03/10/21 19:08	207096			0.6			13.62			0.31			10.83			1		
03/10/21 19:09	185608.5			3.4			15.81			1.48			11.26			1		
03/10/21 19:10	165430.3			169.9			17.83			65.54			11.32			1		
03/10/21 19:11	147100.5			1022.4			18.61			350.6			10.5			1		
03/10/21 19:12	97425.2			1797			18.88			408.28			7.06			1		
03/10/21 19:13	0			0			20.32			0			0			0		
03/10/21 19:14	0			0			17.7			0			0			0		
03/10/21 19:15	0			0			0.2			0			0			0		
03/10/21 19:16	0			0			0.1			0			0			0		
03/10/21 19:17	0			0			0.1			0			0			0		

CT1 SUSD EVENT 15

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/12/21 12:32	19485			0			0			0			0			0		
03/12/21 12:33	19947.1			0			0			0			0			0		
03/12/21 12:34	20409.2			0			0			0			0			0		
03/12/21 12:35	20486.2			0			0			0			0			0		
03/12/21 12:36	26031.4			0			0			0			0			0		
03/12/21 12:37	28727			0.3			0			0			0			1		
03/12/21 12:38	32962.8			0.3			0			0			0			1		
03/12/21 12:39	40972.5			1.5			0.1			0			0			1		
03/12/21 12:40	45747.5			1166.1			11.26			124.24			1.98			1		
03/12/21 12:41	25877.4			0			12.84			55.29			1.28			0		
03/12/21 12:42	25954.4			0			13.41			14.07			1.33			0		
03/12/21 12:43	26108.4			0			11.8			6.51			1.18			0		
03/12/21 12:44	26262.4			0			47.2			11.18			4.75			0		
03/12/21 12:45	26416.5			0			0.6			0			0			0		

CT1 SUSD EVENT 16

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/12/21 12:32	19485			0			0			0			0			0		
03/12/21 12:33	19947.1			0			0			0			0			0		
03/12/21 12:34	20409.2			0			0			0			0			0		
03/12/21 12:35	20486.2			0			0			0			0			0		
03/12/21 12:36	26031.4			0			0			0			0			0		
03/12/21 12:37	28727			0.3			0			0			0			1		
03/12/21 12:38	32962.8			0.3			0			0			0			1		
03/12/21 12:39	40972.5			1.5			0.1			0			0			1		
03/12/21 12:40	45747.5			1166.1			11.26			124.24			1.98			1		
03/12/21 12:41	25877.4			0			12.84			55.29			1.28			0		
03/12/21 12:42	25954.4			0			13.41			14.07			1.33			0		
03/12/21 12:43	26108.4			0			11.8			6.51			1.18			0		
03/12/21 12:44	26262.4			0			47.2			11.18			4.75			0		
03/12/21 12:45	26416.5			0			0.6			0			0			0		

CT1 SUSD EVENT 17

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/12/21 12:58	27879.8			0			0.1			0			0			0		
03/12/21 12:59	27956.8			0			0.1			0			0			0		
03/12/21 13:00	27648.7			0			0			0			0			0		
03/12/21 13:01	27648.7			0			0			0			0			0		
03/12/21 13:02	30498.3			0			0			0			0			0		
03/12/21 13:03	29805.2			0.4			0			0			0			1		
03/12/21 13:04	33887			0.4			0			0			0			1		
03/12/21 13:05	40587.4			1.3			0.2			0			0			1		
03/12/21 13:06	41357.6			1270.9			13.57			122.61			2.15			1		
03/12/21 13:07	27417.7			0			14.75			66.08			1.55			0		
03/12/21 13:08	27109.6			0			14.09			22.02			1.46			0		
03/12/21 13:09	27032.6			0			12.98			10.88			1.35			0		
03/12/21 13:10	26801.6			0			41.3			12.16			4.24			0		
03/12/21 13:11	26647.5			0			0.6			0			0			0		

CT1 SUSD EVENT 18

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/12/21 12:58	27879.8			0			0.1			0			0			0		
03/12/21 12:59	27956.8			0			0.1			0			0			0		
03/12/21 13:00	27648.7			0			0			0			0			0		
03/12/21 13:01	27648.7			0			0			0			0			0		
03/12/21 13:02	30498.3			0			0			0			0			0		
03/12/21 13:03	29805.2			0.4			0			0			0			1		
03/12/21 13:04	33887			0.4			0			0			0			1		
03/12/21 13:05	40587.4			1.3			0.2			0			0			1		
03/12/21 13:06	41357.6			1270.9			13.57			122.61			2.15			1		
03/12/21 13:07	27417.7			0			14.75			66.08			1.55			0		
03/12/21 13:08	27109.6			0			14.09			22.02			1.46			0		
03/12/21 13:09	27032.6			0			12.98			10.88			1.35			0		
03/12/21 13:10	26801.6			0			41.3			12.16			4.24			0		
03/12/21 13:11	26647.5			0			0.6			0			0			0		

CT1 SUSD EVENT 19

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/12/21 13:48	24568.1			0			0.1			0			0			0		
03/12/21 13:49	24491.1			0			0.1			0			0			0		
03/12/21 13:50	24337			0			0			0			0			0		
03/12/21 13:51	25877.4			0			0			0			0			0		
03/12/21 13:52	26108.4			0			0			0			0			0		
03/12/21 13:53	30575.3			0.4			0			0			0			1		
03/12/21 13:54	34118.1			0.6			0			0			0			1		
03/12/21 13:55	42897.9			95.6			21.24			9.56			3.5			1		
03/12/21 13:56	53064			1366.3			14.75			169.13			3			1		
03/12/21 13:57	64539.4			864.9			20.48			130.1			5.07			1		
03/12/21 13:58	85795.8			496.2			24.78			99.3			8.16			1		
03/12/21 13:59	129078.8			328.5			26.55			98.84			13.15			1		
03/12/21 14:00	145252.1			186			46.76			62.98			26.06			1		
03/12/21 14:01	151028.3			667.3			55.68			234.95			32.27			1		
03/12/21 14:02	161348.5			1947			54.39			732.19			33.66			1		
03/12/21 14:03	179601.3			1832.5			58.65			767.47			40.43			1		
03/12/21 14:04	202243.9			1149.2			67.45			541.77			52.33			1		
03/12/21 14:05	224655.6			191.1			62.02			100.12			53.46			1		
03/12/21 14:06	238364.4			16.7			59.86			9.29			54.76			1		
03/12/21 14:07	239981.8			2.8			54.77			1.56			50.42			1		
03/12/21 14:08	240443.9			2.3			52.35			1.26			48.29			1		
03/12/21 14:09	240058.8			2.1			51.06			1.2			47.03			1		
03/12/21 14:10	239981.8			1.8			49.24			1.02			45.33			1		
03/12/21 14:11	239211.6			1.7			44.3			0.96			40.66			1		
03/12/21 14:12	238980.6			1.6			42.69			0.9			39.15			1		
03/12/21 14:13	245989			1.6			41.51			0.92			39.18			1		
03/12/21 14:14	254845.9			1.6			37.33			0.96			36.5			1		
03/12/21 14:15	253921.7			1.5			20.75			0.9			20.22			1		
03/12/21 14:16	253921.7			2.5	X		20.36	X		1.46	X		19.84	X		1		
03/12/21 14:17	253690.6			1.3	X		18.78	X		0.78	X		18.28	X		1		
03/12/21 14:18	253382.5			1	X		18.11	X		0.61	X		17.61	X		1		
03/12/21 14:19	253305.5			1	X		17.6	X		0.6	X		17.1	X		1		
03/12/21 14:20	252458.4			1	X		17.19	X		0.6	X		16.65	X		1		
03/12/21 14:21	252227.3			0.9	X		16.78	X		0.54	X		16.24	X		1		
03/12/21 14:22	251996.3			0.9			16.17			0.54			15.64			1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/12/21 14:23	252073.3			0.8			15.97			0.48			15.44			1		
03/12/21 14:24	251611.2			0.8			15.87			0.48			15.32			1		
03/12/21 14:25	249377.7			0.8			15.77			0.47			15.08			1		
03/12/21 14:26	249993.8			0.8			17.19			0.47			16.49			1		
03/12/21 14:27	250764			0.8			18.22			0.48			17.53			1		
03/12/21 14:28	251072.1			0.8			17.6			0.48			16.95			1		
03/12/21 14:29	250995			0.8			17.09			0.48			16.46			1		
03/12/21 14:30	250533			0.7			16.68			0.42			16.03			1		
03/12/21 14:31	250147.9			0.7			16.68			0.42			16.01			1		
03/12/21 14:32	250841			0.7			17.09			0.42			16.44			1		
03/12/21 14:33	250378.9			0.7			17.6			0.42			16.91			1		
03/12/21 14:34	250610			0.6			18.11			0.36			17.41			1		
03/12/21 14:35	250610			0.6			18.62			0.36			17.9			1		
03/12/21 14:36	244063.6			0.6			19.12			0.35			17.91			1		
03/12/21 14:37	225425.8			0.6			22.25			0.33			19.25			1		
03/12/21 14:38	201011.7			0.5			36.71			0.26			28.32			1		
03/12/21 14:39	177598.8			3.1			41.18			1.3			28.07			1		
03/12/21 14:40	159115			168.2			46.38			62.39			28.31			1		
03/12/21 14:41	140477.1			770.9			47.04			252.45			25.36			1		
03/12/21 14:42	52370.9			1780.9			45.12			217.27			9.06			1		
03/12/21 14:43	26262.4			0			49.47			169.4			4.98			0		
03/12/21 14:44	26185.4			0			0.6			0			0			0		
03/12/21 14:45	26031.4			0			0.5			0			0			0		
03/12/21 14:46	26339.5			0			0.4			0			0			0		
03/12/21 14:47	26185.4			0			0.4			0			0			0		

CT1 SUSD EVENT 20

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/12/21 14:31	250147.9			0.7			16.68			0.42			16.01			1		
03/12/21 14:32	250841			0.7			17.09			0.42			16.44			1		
03/12/21 14:33	250378.9			0.7			17.6			0.42			16.91			1		
03/12/21 14:34	250610			0.6			18.11			0.36			17.41			1		
03/12/21 14:35	250610			0.6			18.62			0.36			17.9			1		
03/12/21 14:36	244063.6			0.6			19.12			0.35			17.91			1		
03/12/21 14:37	225425.8			0.6			22.25			0.33			19.25			1		
03/12/21 14:38	201011.7			0.5			36.71			0.26			28.32			1		
03/12/21 14:39	177598.8			3.1			41.18			1.3			28.07			1		
03/12/21 14:40	159115			168.2			46.38			62.39			28.31			1		
03/12/21 14:41	140477.1			770.9			47.04			252.45			25.36			1		
03/12/21 14:42	52370.9			1780.9			45.12			217.27			9.06			1		
03/12/21 14:43	26262.4			0			49.47			169.4			4.98			0		
03/12/21 14:44	26185.4			0			0.6			0			0			0		
03/12/21 14:45	26031.4			0			0.5			0			0			0		
03/12/21 14:46	26339.5			0			0.4			0			0			0		
03/12/21 14:47	26185.4			0			0.4			0			0			0		

CT1 SUSD EVENT 21

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/13/21 7:39	0			0	X		0	X		0	X		0	X		0		
03/13/21 7:40	0			0	X		0	X		0	X		0	X		0		
03/13/21 7:41	0			0	X		0	X		0	X		0	X		0		
03/13/21 7:42	0			0	X		0	X		0	X		0	X		0		
03/13/21 7:43	0			0	X		0	X		0	X		0	X		0		
03/13/21 7:44	0			0.4	X		0	X		0	X		0	X		1		
03/13/21 7:45	6777.4			0.4	X		0	X		0	X		0	X		1		
03/13/21 7:46	26493.5			118	X		23.6	X		7.29	X		2.4	X		1		
03/13/21 7:47	29266.1			1683.6	X		11.26	X		114.95	X		1.27	X		1		
03/13/21 7:48	0			0	X		14.38	X		0	X		0	X		0		
03/13/21 7:49	0			0	X		11.01	X		0	X		0	X		0		
03/13/21 7:50	0			0	X		20.65	X		0	X		0	X		0		
03/13/21 7:51	0			0	X		0.5	X		0	X		0	X		0		
03/13/21 7:52	0			0	X		0.4	X		0	X		0	X		0		

CT1 SUSD EVENT 22

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/13/21 7:39	0			0	X		0	X		0	X		0	X		0		
03/13/21 7:40	0			0	X		0	X		0	X		0	X		0		
03/13/21 7:41	0			0	X		0	X		0	X		0	X		0		
03/13/21 7:42	0			0	X		0	X		0	X		0	X		0		
03/13/21 7:43	0			0	X		0	X		0	X		0	X		0		
03/13/21 7:44	0			0.4	X		0	X		0	X		0	X		1		
03/13/21 7:45	6777.4			0.4	X		0	X		0	X		0	X		1		
03/13/21 7:46	26493.5			118	X		23.6	X		7.29	X		2.4	X		1		
03/13/21 7:47	29266.1			1683.6	X		11.26	X		114.95	X		1.27	X		1		
03/13/21 7:48	0			0	X		14.38	X		0	X		0	X		0		
03/13/21 7:49	0			0	X		11.01	X		0	X		0	X		0		
03/13/21 7:50	0			0	X		20.65	X		0	X		0	X		0		
03/13/21 7:51	0			0	X		0.5	X		0	X		0	X		0		
03/13/21 7:52	0			0	X		0.4	X		0	X		0	X		0		

CT1 SUSD EVENT 23

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/13/21 8:02	0			0	X		0.1	X		0	X		0	X		0		
03/13/21 8:03	0			0	X		0.1	X		0	X		0	X		0		
03/13/21 8:04	0			0	X		0.1	X		0	X		0	X		0		
03/13/21 8:05	0			0	X		0.1	X		0	X		0	X		0		
03/13/21 8:06	0			0	X		0.1	X		0	X		0	X		0		
03/13/21 8:07	12861.7			0.5	X		0.1	X		0	X		0	X		1		
03/13/21 8:08	20332.2			0.5	X		0	X		0	X		0	X		1		
03/13/21 8:09	31884.6			55.1	X		19.67	X		4.09	X		2.41	X		1		
03/13/21 8:10	24799.1			1745.9	X		13.28	X		100.83	X		1.26	X		1		
03/13/21 8:11	0			0	X		16.59	X		0	X		0	X		0		
03/13/21 8:12	0			0	X		12.25	X		0	X		0	X		0		
03/13/21 8:13	0			0	X		20.65	X		0	X		0	X		0		
03/13/21 8:14	0			0	X		0.6	X		0	X		0	X		0		
03/13/21 8:15	3696.8			0	X		0.5	X		0	X		0	X		0		

CT1 SUSD EVENT 24

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/13/21 8:02	0			0	X		0.1	X		0	X		0	X		0		
03/13/21 8:03	0			0	X		0.1	X		0	X		0	X		0		
03/13/21 8:04	0			0	X		0.1	X		0	X		0	X		0		
03/13/21 8:05	0			0	X		0.1	X		0	X		0	X		0		
03/13/21 8:06	0			0	X		0.1	X		0	X		0	X		0		
03/13/21 8:07	12861.7			0.5	X		0.1	X		0	X		0	X		1		
03/13/21 8:08	20332.2			0.5	X		0	X		0	X		0	X		1		
03/13/21 8:09	31884.6			55.1	X		19.67	X		4.09	X		2.41	X		1		
03/13/21 8:10	24799.1			1745.9	X		13.28	X		100.83	X		1.26	X		1		
03/13/21 8:11	0			0	X		16.59	X		0	X		0	X		0		
03/13/21 8:12	0			0	X		12.25	X		0	X		0	X		0		
03/13/21 8:13	0			0	X		20.65	X		0	X		0	X		0		
03/13/21 8:14	0			0	X		0.6	X		0	X		0	X		0		
03/13/21 8:15	3696.8			0	X		0.5	X		0	X		0	X		0		

CT1 SUSD EVENT 25

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/13/21 8:26	0			0	X		0.1	X		0	X		0	X		0		
03/13/21 8:27	0			0	X		0.1	X		0	X		0	X		0		
03/13/21 8:28	0			0	X		0.1	X		0	X		0	X		0		
03/13/21 8:29	0			0	X		0.1	X		0	X		0	X		0		
03/13/21 8:30	25030.2			0	X		0.1	X		0	X		0	X		0		
03/13/21 8:31	10474.2			0.6	X		0.1	X		0	X		0	X		1		
03/13/21 8:32	24645.1			0.6	X		0.1	X		0	X		0	X		1		
03/13/21 8:33	35504.4			100.3	X		29.5	X		8.31	X		4.02	X		1		
03/13/21 8:34	47056.8			1373.3	X		15.88	X		150.63	X		2.87	X		1		
03/13/21 8:35	59456.3			992.6	X		19.44	X		137.53	X		4.43	X		1		
03/13/21 8:36	78171.2			636.3	X		25.15	X		115.94	X		7.54	X		1		
03/13/21 8:37	120298.9			467.5	X		27.25	X		131.13	X		12.58	X		1		
03/13/21 8:38	146253.3			303.5	X		41.77	X		103.47	X		23.44	X		1		
03/13/21 8:39	154263			411.7	X		54.24	X		148.09	X		32.11	X		1		
03/13/21 8:40	169897.2			1902.4	X		51.99	X		753.74	X		33.9	X		1		
03/13/21 8:41	190691.5			1759.9	X		58.33	X		782.37	X		42.67	X		1		
03/13/21 8:42	203322.2			935.2	X		61.27	X		443.4	X		47.81	X		1		
03/13/21 8:43	204246.4			177.3	X		57.66	X		84.4	X		45.18	X		1		
03/13/21 8:44	203630.2			87.9	X		55.15	X		41.71	X		43.09	X		1		
03/13/21 8:45	203168.1			83.9	X		55.15	X		39.73	X		42.99	X		1		
03/13/21 8:46	203784.3			86.7	X		56.38	X		41.17	X		44.07	X		1		
03/13/21 8:47	203091.1			88.9	X		56.38	X		42.09	X		43.93	X		1		
03/13/21 8:48	201473.8			89.4	X		56.38	X		41.99	X		43.57	X		1		
03/13/21 8:49	200780.6			100	X		56.38	X		46.82	X		43.43	X		1		
03/13/21 8:50	200472.6			109	X		55.46	X		50.92	X		42.66	X		1		
03/13/21 8:51	200318.5			110.5	X		54.94	X		51.61	X		42.22	X		1		
03/13/21 8:52	205786.7			112	X		54.54	X		53.71	X		43.06	X		1		
03/13/21 8:53	227428.2			93.1	X		54.28	X		49.36	X		47.37	X		1		
03/13/21 8:54	244756.8			16.8	X		51.99	X		9.61	X		48.82	X		1		
03/13/21 8:55	252304.3			1.4	X		47.87	X		0.85	X		46.34	X		1		
03/13/21 8:56	255230.9			1.1	X		45.2	X		0.63	X		44.26	X		1		
03/13/21 8:57	253382.5			1	X		36.02	X		0.61	X		35.02	X		1		
03/13/21 8:58	251380.1			0.9	X		36.44	X		0.55	X		35.14	X		1		
03/13/21 8:59	251380.1			0.8	X		39.95	X		0.49	X		38.53	X		1		
03/13/21 9:00	251765.2			0.8	X		39.95	X		0.49	X		38.59	X		1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/13/21 9:01	252150.3			0.8	X		39.85	X		0.49	X		38.55	X		1		
03/13/21 9:02	265089			0.7	X		39.33	X		0.45	X		40.01	X		1		
03/13/21 9:03	286730.5			0.7	X		27.77	X		0.48	X		30.55	X		1		
03/13/21 9:04	298359.9			0.8	X		16.56	X		0.53	X		18.95	X		1		
03/13/21 9:05	299053			0.8	X		15.02	X		0.56	X		17.23	X		1		
03/13/21 9:06	299207.1			1	X		13.12	X		0.68	X		15.06	X		1		
03/13/21 9:07	298822			1.1	X		12.68	X		0.74	X		14.54	X		1		
03/13/21 9:08	298205.8			1.1	X		12.5	X		0.73	X		14.31	X		1		
03/13/21 9:09	298513.9			1	X		12.43	X		0.68	X		14.23	X		1		
03/13/21 9:10	298667.9			1	X		12.16	X		0.68	X		13.93	X		1		
03/13/21 9:11	298282.9			1	X		11.89	X		0.68	X		13.61	X		1		
03/13/21 9:12	298051.8			1	X		11.71	X		0.68	X		13.39	X		1		
03/13/21 9:13	297512.7			1	X		11.53	X		0.68	X		13.17	X		1		
03/13/21 9:14	297666.7			0.9	X		11.44	X		0.62	X		13.07	X		1		
03/13/21 9:15	297666.7			0.9	X		11.44	X		0.62	X		13.07	X		1		
03/13/21 9:16	297589.7			0.9	X		11.44	X		0.62	X		13.06	X		1		
03/13/21 9:17	296819.6			0.9	X		11.35	X		0.62	X		12.93	X		1		
03/13/21 9:18	296973.6			0.9	X		9.83	X		0.62	X		11.2	X		1		
03/13/21 9:19	298436.9			0.9	X		7.42	X		0.62	X		8.5	X		1		
03/13/21 9:20	316612.7			0.8	X		6.62	X		0.59	X		8.03	X		1		
03/13/21 9:21	336713.8			0.9	X		6.26	X		0.7	X		8.08	X		1		
03/13/21 9:22	352733.2			0.9	X		6.16	X		0.71	X		8.34	X		1		
03/13/21 9:23	369907.7			1	X		4.23	X		0.84	X		6	X		1		
03/13/21 9:24	391395.2			1	X		3.31	X		0.9	X		4.97	X		1		
03/13/21 9:25	411804.4			0.9	X		3.22	X		0.86	X		5.08	X		1		
03/13/21 9:26	435294.3			0.9	X		3.18	X		0.92	X		5.31	X		1		
03/13/21 9:27	458399.1			0.9	X		3.13	X		0.99	X		5.51	X		1		
03/13/21 9:28	466177.7			0.8	X		3.36	X		0.89	X		6.01	X		1		
03/13/21 9:29	463251.1			0.9	X		4.29	X		0.97	X		7.63	X		1		
03/13/21 9:30	462634.9			0.9	X		4.2	X		0.96	X		7.46	X		1		
03/13/21 9:31	462943			0.9	X		4.02	X		0.96	X		7.15	X		1		
03/13/21 9:32	462712			0.9	X		3.9	X		0.98	X		6.93	X		1		
03/13/21 9:33	463559.1			0.9	X		3.75	X		0.97	X		6.68	X		1		
03/13/21 9:34	463020			0.9	X		3.75	X		0.96	X		6.67	X		1		
03/13/21 9:35	463251.1			0.9	X		3.75	X		0.97	X		6.67	X		1		
03/13/21 9:36	463636.2			0.9	X		3.84	X		0.97	X		6.84	X		1		
03/13/21 9:37	464021.2			0.9	X		3.84	X		0.97	X		6.84	X		1		
03/13/21 9:38	463790.2			0.9	X		3.84	X		0.97	X		6.84	X		1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/13/21 9:39	463559.1			0.9	X		3.75	X		0.97	X		6.68	X		1		
03/13/21 9:40	463405.1			0.9	X		3.75	X		0.97	X		6.68	X		1		
03/13/21 9:41	463251.1			1	X		3.75	X		1.06	X		6.67	X		1		
03/13/21 9:42	463482.1			0.9	X		3.67	X		0.97	X		6.52	X		1		
03/13/21 9:43	464483.3			0.9	X		3.67	X		0.97	X		6.53	X		1		
03/13/21 9:44	463867.2			0.9	X		3.58	X		0.97	X		6.36	X		1		
03/13/21 9:45	463636.2			0.9	X		3.67	X		0.97	X		6.52	X		1		
03/13/21 9:46	463559.1			0.9	X		3.58	X		0.97	X		6.36	X		1		
03/13/21 9:47	463251.1			0.9	X		3.58	X		0.97	X		6.36	X		1		
03/13/21 9:48	462943			0.9	X		3.58	X		0.96	X		6.35	X		1		
03/13/21 9:49	453624.1			0.9	X		3.49	X		0.95	X		6.07	X		1		
03/13/21 9:50	434293.1			0.9	X		3.4	X		0.91	X		5.66	X		1		
03/13/21 9:51	412343.5			0.9	X		3.35	X		0.85	X		5.29	X		1		
03/13/21 9:52	400868.1			1	X		3.56	X		0.89	X		5.47	X		1		
03/13/21 9:53	397556.4			1	X		3.47	X		0.88	X		5.29	X		1		
03/13/21 9:54	396401.2			1	X		3.43	X		0.9	X		5.22	X		1		
03/13/21 9:55	396478.2			1	X		3.26	X		0.9	X		4.96	X		1		
03/13/21 9:56	396016.1			1	X		3.17	X		0.89	X		4.82	X		1		
03/13/21 9:57	396324.2			1	X		3.17	X		0.9	X		4.82	X		1		
03/13/21 9:58	395091.9			1	X		3.17	X		0.89	X		4.81	X		1		
03/13/21 9:59	395785.1			1	X		3.17	X		0.89	X		4.81	X		1		
03/13/21 10:00	396324.2			1	X		3.17	X		0.9	X		4.82	X		1		
03/13/21 10:01	396709.3			1	X		3.08	X		0.9	X		4.69	X		1		
03/13/21 10:02	396324.2			1	X		2.99	X		0.9	X		4.55	X		1		
03/13/21 10:03	392704.4			1	X		3.08	X		0.89	X		4.64	X		1		
03/13/21 10:04	373989.6			1	X		3.08	X		0.84	X		4.42	X		1		
03/13/21 10:05	355736.8			1	X		3.21	X		0.79	X		4.38	X		1		
03/13/21 10:06	332169.9			1	X		3.42	X		0.79	X		4.36	X		1		
03/13/21 10:07	308140.9			1	X		3.51	X		0.74	X		4.14	X		1		
03/13/21 10:08	286576.4			1	X		3.47	X		0.7	X		3.82	X		1		
03/13/21 10:09	267091.4			1	X		2.68	X		0.61	X		2.75	X		1		
03/13/21 10:10	263548.7			0.8	X		3.56	X		0.52	X		3.6	X		1		
03/13/21 10:11	262932.5			0.7	X		4.62	X		0.42	X		4.66	X		1		
03/13/21 10:12	263394.6			0.6	X		4.43	X		0.36	X		4.47	X		1		
03/13/21 10:13	263548.7			0.5	X		3.74	X		0.3	X		3.78	X		1		
03/13/21 10:14	263317.6			0.5	X		3.64	X		0.3	X		3.68	X		1		
03/13/21 10:15	263471.7			0.6	X		3.44	X		0.36	X		3.48	X		1		
03/13/21 10:16	263394.6			0.6	X		3.15	X		0.36	X		3.18	X		1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/13/21 10:17	263317.6			0.6	X		2.95	X		0.36	X		2.98	X		1		
03/13/21 10:18	261161.2			0.6	X		2.75	X		0.36	X		2.76	X		1		
03/13/21 10:19	242600.3			0.6	X		2.56	X		0.33	X		2.38	X		1		
03/13/21 10:20	234359.6			0.6	X		6	X		0.33	X		5.4	X		1		
03/13/21 10:21	233281.4			0.5	X		10.6	X		0.3	X		9.49	X		1		
03/13/21 10:22	232588.2			0.4	X		10.46	X		0.24	X		9.34	X		1		
03/13/21 10:23	232665.3			0.4	X		10.24	X		0.24	X		9.14	X		1		
03/13/21 10:24	232280.2			0.4	X		10.02	X		0.24	X		8.93	X		1		
03/13/21 10:25	232665.3			0.4	X		9.68	X		0.24	X		8.65	X		1		
03/13/21 10:26	232434.2			0.4	X		9.35	X		0.24	X		8.34	X		1		
03/13/21 10:27	232896.3			0.4	X		9.13	X		0.24	X		8.16	X		1		
03/13/21 10:28	237132.2			0.4	X		8.57	X		0.25	X		7.8	X		1		
03/13/21 10:29	262701.5			0.4	X		7.9	X		0.27	X		7.97	X		1		
03/13/21 10:30	285113.1			0.4	X		4.32	X		0.28	X		4.72	X		1		
03/13/21 10:31	307293.7			0.6	X		1.14	X		0.41	X		1.35	X		1		
03/13/21 10:32	325084.4			0.7	X		0.97	X		0.53	X		1.21	X		1		
03/13/21 10:33	328550.1			0.9	X		0.78	X		0.66	X		0.98	X		1		
03/13/21 10:34	329089.3			1	X		0.69	X		0.8	X		0.88	X		0		
03/13/21 10:35	329089.3			1	X		0.61	X		0.8	X		0.77	X		0		
03/13/21 10:36	329012.2			1	X		0.61	X		0.8	X		0.77	X		0		
03/13/21 10:37	328858.2			1	X		0.61	X		0.8	X		0.77	X		0		
03/13/21 10:38	328242.1			1	X		0.69	X		0.8	X		0.87	X		0		

CT1 SUSD EVENT 26

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/13/21 17:56	323929.2			1			1.71			0.77			2.13			0		
03/13/21 17:57	308449			1			1.65			0.75			1.95			0		
03/13/21 17:58	306677.6			1.1			1.59			0.76			1.87			0		
03/13/21 17:59	306369.5			1			1.52			0.7			1.79			0		
03/13/21 18:00	306138.5			0.9			1.43			0.64			1.68			0		
03/13/21 18:01	304213.1			0.9			1.43			0.63			1.67			1		
03/13/21 18:02	286114.3			0.9			1.52			0.6			1.67			1		
03/13/21 18:03	263856.7			0.9			1.63			0.56			1.65			1		
03/13/21 18:04	240674.9			0.8			2.62			0.47			2.42			1		
03/13/21 18:05	219957.6			0.7			6			0.37			5.07			1		
03/13/21 18:06	195312.5			0.6			16.59			0.25			12.43			1		
03/13/21 18:07	173594			5			19.05			2.04			12.69			1		
03/13/21 18:08	156650.5			428			22.34			156.37			13.43			1		
03/13/21 18:09	138166.7			1466.5			25.35			472.4			13.44			1		
03/13/21 18:10	39971.3			1935.8			26			180.26			3.98			1		
03/13/21 18:11	27186.6			0			27.89			201.79			2.91			0		
03/13/21 18:12	26878.6			0			0.2			0			0			0		
03/13/21 18:13	26724.5			0			0.2			0			0			0		
03/13/21 18:14	26570.5			0			0.2			0			0			0		
03/13/21 18:15	26493.5			0			0.1			0			0			0		

CT1 SUSD EVENT 27

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/23/21 9:24	1001.2			0			0			0			0			0		
03/23/21 9:25	0			0			0			0			0			0		
03/23/21 9:26	0			0			0			0			0			0		
03/23/21 9:27	0			0			0			0			0			0		
03/23/21 9:28	4004.8			0			0			0			0			0		
03/23/21 9:29	6700.4			0.3			0			0			0			1		
03/23/21 9:30	21564.5			0.3			0			0			0			1		
03/23/21 9:31	32962.8			1.5			0.1			0			0			1		
03/23/21 9:32	44207.2			1463.9			9.83			150.73			1.67			1		
03/23/21 9:33	57068.8			1078.2			12.17			143.37			2.66			1		
03/23/21 9:34	69391.4			269.3			17.44			43.59			4.65			1		
03/23/21 9:35	59302.3			48.9			18.27			6.77			4.16			1		
03/23/21 9:36	0			0			30.43			0			0			0		
03/23/21 9:37	0			0			44			0			0			0		
03/23/21 9:38	0			0			64.9			0			0			0		
03/23/21 9:39	0			0			118			0			0			0		
03/23/21 9:40	0			0			1.8			0			0			0		

CT1 SUSD EVENT 28

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/23/21 9:24	1001.2			0			0			0			0			0		
03/23/21 9:25	0			0			0			0			0			0		
03/23/21 9:26	0			0			0			0			0			0		
03/23/21 9:27	0			0			0			0			0			0		
03/23/21 9:28	4004.8			0			0			0			0			0		
03/23/21 9:29	6700.4			0.3			0			0			0			1		
03/23/21 9:30	21564.5			0.3			0			0			0			1		
03/23/21 9:31	32962.8			1.5			0.1			0			0			1		
03/23/21 9:32	44207.2			1463.9			9.83			150.73			1.67			1		
03/23/21 9:33	57068.8			1078.2			12.17			143.37			2.66			1		
03/23/21 9:34	69391.4			269.3			17.44			43.59			4.65			1		
03/23/21 9:35	59302.3			48.9			18.27			6.77			4.16			1		
03/23/21 9:36	0			0			30.43			0			0			0		
03/23/21 9:37	0			0			44			0			0			0		
03/23/21 9:38	0			0			64.9			0			0			0		
03/23/21 9:39	0			0			118			0			0			0		
03/23/21 9:40	0			0			1.8			0			0			0		

CT1 SUSD EVENT 29

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/23/21 10:20	10320.1			0			0.2			0			0			0		
03/23/21 10:21	10012.1			0			0.1			0			0			0		
03/23/21 10:22	9473			0			0.1			0			0			0		
03/23/21 10:23	11398.4			0			0.1			0			0			0		
03/23/21 10:24	10474.2			0			0.1			0			0			0		
03/23/21 10:25	15942.3			0.4			0.1			0			0			1		
03/23/21 10:26	27263.7			0.4			0.1			0			0			1		
03/23/21 10:27	38276.9			23.6			14.75			2.11			2.17			1		
03/23/21 10:28	49675.3			1032.5			13.49			119.49			2.57			1		
03/23/21 10:29	61920.8			886.4			18.05			127.98			4.29			1		
03/23/21 10:30	84563.5			539.6			20.95			106.4			6.8			1		
03/23/21 10:31	127615.5			404.6			24.44			120.36			11.97			1		
03/23/21 10:32	143249.7			232.6			38.8			77.68			21.33			1		
03/23/21 10:33	148332.8			585.8			47.39			202.6			26.97			1		
03/23/21 10:34	159500.1			2011.5			44.35			747.9			27.14			1		
03/23/21 10:35	178446			1889.6			51.49			786.32			35.26			1		
03/23/21 10:36	199856.5			1361.8			59.64			634.66			45.74			1		
03/23/21 10:37	222730.2			296.1			62.79			153.78			53.67			1		
03/23/21 10:38	242831.4			31			59.25			17.55			55.2			1		
03/23/21 10:39	266398.3			4.1			83.51			2.54			85.37			1		
03/23/21 10:40	293199.8			2.6			72.77			1.77			81.87			1		
03/23/21 10:41	311298.6			2.3			31.75			1.7			37.92			1		
03/23/21 10:42	305060.3			2.3			18.48			1.6			21.63			1		
03/23/21 10:43	301440.5			2.4			13.85			1.68			16.02			1		
03/23/21 10:44	300593.3			2.4			12.06			1.7			13.91			1		
03/23/21 10:45	300208.3			2.3			11.18			1.6			12.88			1		
03/23/21 10:46	293970			2.2			10.21			1.51			11.52			1		
03/23/21 10:47	291505.5			2			9.07			1.38			10.14			1		
03/23/21 10:48	285267.2			1.8			9.03			1.19			9.88			1		
03/23/21 10:49	284111.9			1.6			8.94			1.07			9.74			1		
03/23/21 10:50	283341.8			1.5			8.9			0.96			9.67			1		
03/23/21 10:51	283264.8			1.4			8.8			0.9			9.57			1		
03/23/21 10:52	282879.7			1.3			8.62			0.84			9.36			1		
03/23/21 10:53	282494.6			1.2			8.53			0.78			9.25			1		
03/23/21 10:54	282648.6			1.1			8.35			0.72			9.06			1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/23/21 10:55	290042.2			1.1			8.26			0.74			9.19			1		
03/23/21 10:56	307524.8			1.1			7.99			0.78			9.43			1		
03/23/21 10:57	309758.3			1.1			6.88			0.77			8.18			1		
03/23/21 10:58	310528.4			1.1			6.79			0.78			8.09			1		
03/23/21 10:59	310605.4			1.2			6.7			0.84			7.99			1		
03/23/21 11:00	310297.3			1.2			6.62			0.84			7.88			1		
03/23/21 11:01	310528.4			1.2			6.62			0.84			7.88			1		
03/23/21 11:02	309604.2			1.2			6.62			0.84			7.86			1		
03/23/21 11:03	310682.4			1.2			6.7			0.84			7.99			1		
03/23/21 11:04	327317.9			1.1			6.7			0.82			8.42			1		
03/23/21 11:05	344954.5			1.1			7.06			0.86			9.35			1		
03/23/21 11:06	360049.7			1.1			5.55			0.89			7.66			1		
03/23/21 11:07	373758.5			1.1			5.45			0.95			7.81			1		
03/23/21 11:08	391395.2			1			6.44			0.91			9.68			1		
03/23/21 11:09	405874.2			1			5.45			0.94			8.48			1		
03/23/21 11:10	421200.3			0.9			5.25			0.91			8.49			1		
03/23/21 11:11	437527.8			0.9			5.25			0.94			8.82			1		
03/23/21 11:12	442379.8			0.9			5.53			0.95			9.39			1		
03/23/21 11:13	444151.1			0.9			6.18			0.95			10.53			1		
03/23/21 11:14	444536.2			0.9			6.27			0.96			10.69			1		
03/23/21 11:15	445075.3			0.9			5.99			0.96			10.23			1		
03/23/21 11:16	451544.7			0.9			3.32			0.97			5.75			1		
03/23/21 11:17	454240.2			0.9			2.49			0.98			4.34			1		
03/23/21 11:18	454471.3			0.9			2.45			0.96			4.27			1		
03/23/21 11:19	454009.2			0.9			2.63			0.96			4.59			1		
03/23/21 11:20	454009.2			0.9			2.9			0.96			5.06			1		
03/23/21 11:21	453393			0.9			3.09			0.96			5.37			1		
03/23/21 11:22	453855.1			0.9			3			0.96			5.22			1		
03/23/21 11:23	451467.6			0.9			2.81			0.96			4.87			1		
03/23/21 11:24	444844.3			0.9			2.27			0.94			3.87			1		
03/23/21 11:25	443072.9			0.9			1.82			0.94			3.09			1		
03/23/21 11:26	441686.6			0.9			1.72			0.93			2.92			1		
03/23/21 11:27	440608.4			0.9			1.63			0.93			2.76			1		
03/23/21 11:28	440531.4			0.9			1.54			0.93			2.61			0		
03/23/21 11:29	440223.3			0.9			1.54			0.93			2.61			0		
03/23/21 11:30	439915.2			0.9			1.54			0.93			2.6			0		
03/23/21 11:31	440377.3			0.9			1.54			0.93			2.61			0		
03/23/21 11:32	440685.4			0.8			1.54			0.84			2.61			0		

CT1 SUSD EVENT 30

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/24/21 11:49	372449.3			0.9			1.7			0.78			2.43			0		
03/24/21 11:50	359279.5			0.9			1.7			0.75			2.34			0		
03/24/21 11:51	339563.4			1			2.38			0.77			3.1			0		
03/24/21 11:52	316612.7			1			2.52			0.7			3.06			0		
03/24/21 11:53	293276.8			1.1			2.03			0.72			2.28			0		
03/24/21 11:54	275332.1			1			1.88			0.63			1.98			1		
03/24/21 11:55	259158.8			0.9			1.84			0.56			1.83			1		
03/24/21 11:56	235822.9			0.8			3.05			0.42			2.76			1		
03/24/21 11:57	215182.6			0.6			7.35			0.31			6.07			1		
03/24/21 11:58	191538.7			0.6			19.63			0.25			14.43			1		
03/24/21 11:59	169743.2			8.1			22.96			3.2			14.95			1		
03/24/21 12:00	153030.7			577.8			26.99			206.15			15.85			1		
03/24/21 12:01	126999.3			1591.9			29.17			471.42			14.22			1		
03/24/21 12:02	32808.8			0			29.5			154.9			3.72			0		
03/24/21 12:03	32808.8			0			44.25			712.75			5.58			0		
03/24/21 12:04	32500.7			0			0.2			0			0			0		
03/24/21 12:05	32346.7			0			0.2			0			0			0		
03/24/21 12:06	32577.8			0			0.1			0			0			0		

CT2 SUSD EVENT 1

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/26/21 8:12	0			0			0			0			0			0		
02/26/21 8:13	0			0			0			0			0			0		
02/26/21 8:14	0			0			0			0			0			0		
02/26/21 8:15	0			0			0			0			0			0		
02/26/21 8:16	12091.5			0			0			0			0			0		
02/26/21 8:17	10551.2			0.3			0			0			0			1		
02/26/21 8:18	32731.8			1.1			0			0			0			1		
02/26/21 8:19	46748.7			824.5			7.38			89.88			1.32			1		
02/26/21 8:20	59379.3			799.8			9.51			110.82			2.17			1		
02/26/21 8:21	75706.7			692.9			14.75			122.38			4.29			1		
02/26/21 8:22	121916.3			519.2			19.18			147.6			8.97			1		
02/26/21 8:23	154263			373.4			22.13			134.33			13.1			1		
02/26/21 8:24	150104.1			364			37.37			127.45			21.53			1		
02/26/21 8:25	147716.6			1890.8			33.43			651.36			18.96			1		
02/26/21 8:26	145945.3			2161.6			37.03			735.97			20.75			1		
02/26/21 8:27	146099.3			2162.2			40.08			736.67			22.47			1		
02/26/21 8:28	144944.1			2237.6			44.67			756.32			24.85			1		
02/26/21 8:29	145637.2			2237.6			51.2			760.32			28.63			1		
02/26/21 8:30	154494			2237.6			61.32			806.41			36.37			1		
02/26/21 8:31	157959.8			2160.4			70.39			796.01			42.69			1		
02/26/21 8:32	158575.9			2019.9			68.9			746.94			41.93			1		
02/26/21 8:33	156650.5			1957.1			65.82			714.98			39.57			1		
02/26/21 8:34	158421.9			1957.9			64.16			723.57			39.03			1		
02/26/21 8:35	156958.5			1957.9			62.13			717			37.45			1		
02/26/21 8:36	157112.6			2021			62.43			740.58			37.65			1		
02/26/21 8:37	157035.6			2021			60.71			740.13			36.59			1		
02/26/21 8:38	156958.5			2021			59.38			740.13			35.79			1		
02/26/21 8:39	155649.3			2021			58.05			733.79			34.69			1		
02/26/21 8:40	155649.3			2021			56.91			733.79			34			1		
02/26/21 8:41	155726.3			2019.3			55.76			733.62			33.34			1		
02/26/21 8:42	170359.3			2019.3			55			802.33			35.97			1		
02/26/21 8:43	191461.7			1896.9			52.38			847.12			38.5			1		
02/26/21 8:44	215644.7			1202.6			51.19			604.91			42.37			1		
02/26/21 8:45	238210.4			298.5			51.27			165.85			46.88			1		
02/26/21 8:46	262470.4			41.6			51.59			25.44			51.98			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/26/21 8:47	288732.9			10.4			52.65			6.97			58.37			1		
02/26/21 8:48	316227.6			7.3			45.17			5.4			54.83			1		
02/26/21 8:49	335789.6			6.3			29.32			4.91			37.79			1		
02/26/21 8:50	337869.1			5.4			14.35			4.23			18.62			1		
02/26/21 8:51	337021.9			4.8			14.14			3.75			18.3			1		
02/26/21 8:52	333864.3			4.4			12.67			3.45			16.24			1		
02/26/21 8:53	336020.7			4.2			12.42			3.31			16.01			1		
02/26/21 8:54	334942.5			4.1			11.27			3.16			14.49			1		
02/26/21 8:55	335481.6			3.9			10.92			3.03			14.06			1		
02/26/21 8:56	335866.7			3.7			10.39			2.9			13.4			1		
02/26/21 8:57	335096.5			3.5			10.04			2.75			12.91			1		
02/26/21 8:58	335789.6			3.3			9.83			2.59			12.68			1		
02/26/21 8:59	335712.6			3.2			9.48			2.52			12.21			1		
02/26/21 9:00	335019.5			3			9.21			2.38			11.84			1		
02/26/21 9:01	335019.5			3			9.21			2.31			11.84			1		
02/26/21 9:02	334557.4			2.9			9.39			2.23			12.05			1		
02/26/21 9:03	334480.4			2.7			9.65			2.09			12.4			1		
02/26/21 9:04	335404.6			2.4			9.83			1.89			12.66			1		
02/26/21 9:05	334172.3			2.2			10.1			1.74			12.96			1		
02/26/21 9:06	335250.5			2.1			10.37			1.61			13.34			1		
02/26/21 9:07	333941.3			2			10.64			1.53			13.64			1		
02/26/21 9:08	333633.2			1.8			10.82			1.39			13.85			1		
02/26/21 9:09	334711.4			1.6			8.22			1.26			10.57			1		
02/26/21 9:10	334403.3			1.5			4.83			1.19			6.2			1		
02/26/21 9:11	333402.2			1.4			4.02			1.11			5.15			1		
02/26/21 9:12	333864.3			1.3			3.4			1.04			4.35			1		
02/26/21 9:13	334403.3			1.3			3.13			1.05			4.02			1		
02/26/21 9:14	334711.4			1.3			2.68			1.05			3.45			1		
02/26/21 9:15	334172.3			1.3			2.23			0.98			2.87			1		
02/26/21 9:16	335019.5			1.3			2.15			0.98			2.76			1		
02/26/21 9:17	333941.3			1.3			1.97			0.97			2.52			1		
02/26/21 9:18	334249.3			1.2			1.79			0.91			2.29			1		
02/26/21 9:19	333787.2			1.2			1.61			0.9			2.06			1		
02/26/21 9:20	333094.1			1.2			1.52			0.9			1.94			0		
02/26/21 9:21	332400.9			1.1			1.43			0.83			1.83			0		
02/26/21 9:22	333864.3			1.1			1.34			0.84			1.72			0		
02/26/21 9:23	333248.1			1.1			1.36			0.85			1.74			0		
02/26/21 9:24	332709			1.1			1.27			0.85			1.62			0		

CT2 SUSD EVENT 2

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/26/21 14:06	427361.6			0.9			1.61			0.89			2.64			0		
02/26/21 14:07	405489.1			0.9			1.61			0.85			2.5			0		
02/26/21 14:08	386004.1			1			1.59			0.87			2.35			0		
02/26/21 14:09	369522.6			1			1.48			0.82			2.09			0		
02/26/21 14:10	349036.4			1			1.39			0.85			1.86			0		
02/26/21 14:11	331245.7			1.1			1.32			0.82			1.68			1		
02/26/21 14:12	318230			1			1.27			0.74			1.55			1		
02/26/21 14:13	293738.9			0.9			1.57			0.63			1.77			1		
02/26/21 14:14	271250.3			0.8			4.68			0.53			4.87			1		
02/26/21 14:15	251072.1			0.8			8.65			0.46			8.34			1		
02/26/21 14:16	224347.5			0.6			15.7			0.33			13.52			1		
02/26/21 14:17	197160.9			2.6			19.23			1.19			14.55			1		
02/26/21 14:18	173979.1			123.1			21.37			49.96			14.27			1		
02/26/21 14:19	155957.3			845.1			23.3			307.39			13.95			1		
02/26/21 14:20	113675.6			1755.9			25.68			465.78			11.21			1		
02/26/21 14:21	0			0			30.18			0			0			0		
02/26/21 14:22	0			0			0.3			0			0			0		
02/26/21 14:23	0			0			0.2			0			0			0		
02/26/21 14:24	0			0			0.1			0			0			0		
02/26/21 14:25	0			0			0.1			0			0			0		

CT2 SUSD EVENT 3

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/27/21 9:38	0			0			0			0			0			0		
02/27/21 9:39	0			0			0			0			0			0		
02/27/21 9:40	0			0			0			0			0			0		
02/27/21 9:41	0			0			0			0			0			0		
02/27/21 9:42	1232.3			0			0			0			0			0		
02/27/21 9:43	20871.3			0.1			0			0			0			1		
02/27/21 9:44	36890.7			112.1			5.9			9.64			0.83			1		
02/27/21 9:45	49290.2			733.6			15.24			84.4			2.89			1		
02/27/21 9:46	61381.7			770.7			16.15			110.42			3.81			1		
02/27/21 9:47	77016			597.4			21.54			107.38			6.37			1		
02/27/21 9:48	120607			452.7			24.67			127.38			11.43			1		
02/27/21 9:49	155341.2			312.2			37.22			113.16			22.2			1		
02/27/21 9:50	158267.8			283			49.6			104.47			30.13			1		
02/27/21 9:51	163273.9			1760.8			49.78			670.44			31.2			1		
02/27/21 9:52	173131.9			1901.1			52.03			767.68			34.58			1		
02/27/21 9:53	193079			1792.1			50.4			807.12			37.36			1		
02/27/21 9:54	216106.8			1026.3			53.1			517.35			44.05			1		
02/27/21 9:55	239519.7			239.8			51.63			133.96			47.47			1		
02/27/21 9:56	261854.3			26.7			52.98			16.32			53.24			1		
02/27/21 9:57	288501.8			3.8			57.25			2.57			63.4			1		
02/27/21 9:58	315688.5			2.7			53.3			1.99			64.58			1		
02/27/21 9:59	340641.7			2.4			35.94			1.87			47			1		
02/27/21 10:00	358663.4			2.2			18.73			1.86			25.78			1		
02/27/21 10:01	371910.1			2.3			13.25			2			18.92			1		
02/27/21 10:02	380612.9			2.2			12.9			1.95			18.84			1		
02/27/21 10:03	396478.2			2			10.87			1.87			16.55			1		
02/27/21 10:04	409648			1.8			9.54			1.74			15.01			1		
02/27/21 10:05	415732.2			1.6			9.02			1.6			14.4			1		
02/27/21 10:06	429287			1.5			9.2			1.48			15.16			1		
02/27/21 10:07	436218.5			1.3			8.72			1.34			14.6			1		
02/27/21 10:08	442379.8			1.2			8.72			1.27			14.81			1		
02/27/21 10:09	443920.1			1.1			8.81			1.19			15.01			1		
02/27/21 10:10	444151.1			1.1			8.81			1.19			15.01			1		
02/27/21 10:11	449311.2			1.1			8.98	X		1.11			15.49	X		1		
02/27/21 10:12	454779.3			1.1			8.76			1.14			15.29			1		

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/27/21 10:13	458476.1			1.1			8.76			1.15			15.42			1		
02/27/21 10:14	466023.7			1			8.85			1.07			15.83			1		
02/27/21 10:15	472261.9			1			8.85			1.08			16.04			1		
02/27/21 10:16	482351			1			8.99			1.12			16.64			1		
02/27/21 10:17	492286.1			0.9			8.9			1.04			16.81			1		
02/27/21 10:18	497677.2			0.8			8.99			0.95			17.17			1		
02/27/21 10:19	498755.4			0.9			10.1			1.04			19.34			1		
02/27/21 10:20	495982.9			0.9			6.62			1.03			12.59			1		
02/27/21 10:21	495289.7			0.9			3.4			1.03			6.46			1		
02/27/21 10:22	496059.9			0.9			2.95			1.03			5.62			1		
02/27/21 10:23	494673.6			0.9			2.72			1.05			5.17			1		
02/27/21 10:24	495982.9			0.9			2.63			1.05			5.01			1		
02/27/21 10:25	494904.6			0.9			2.45			1.05			4.66			1		
02/27/21 10:26	495828.8			0.9			2.36			1.05			4.49			1		
02/27/21 10:27	495058.7			0.9			2.15			1.03			4.08			1		
02/27/21 10:28	495058.7			0.9			2			1.05			3.8			1		
02/27/21 10:29	496136.9			0.9			1.88			1.03			3.58			1		
02/27/21 10:30	493518.3			0.9			1.7			1.03			3.22			1		
02/27/21 10:31	493903.4			0.8			1.61			0.93			3.05			0		
02/27/21 10:32	494981.7			0.8			1.54			0.94			2.93			0		
02/27/21 10:33	496599			0.8			1.45			0.95			2.77			0		
02/27/21 10:34	495597.8			0.8			1.34			0.93			2.55			0		
02/27/21 10:35	496522			0.8			1.34			0.93			2.56			0		

CT2 SUSD EVENT 4

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/27/21 17:47	315072.3			0.7			1.57			0.54			1.9			0		
02/27/21 17:48	315919.5			0.7			1.66			0.54			2.01			0		
02/27/21 17:49	315457.4			0.7			1.66			0.54			2.01			0		
02/27/21 17:50	315380.4			0.7			1.66			0.54			2.01			0		
02/27/21 17:51	316304.6			0.7			1.75			0.54			2.13			0		
02/27/21 17:52	310913.5			0.7			1.75			0.53			2.09			1		
02/27/21 17:53	286730.5			0.7			2.67			0.49			2.94			1		
02/27/21 17:54	266783.3			0.8			6.85			0.47			7.02			1		
02/27/21 17:55	243755.5			0.7			7.2			0.4			6.74			1		
02/27/21 17:56	214643.5			0.7			16.83			0.33			13.87			1		
02/27/21 17:57	190229.5			4.7			19.05			2.07			13.91			1		
02/27/21 17:58	168433.9			287.2			20.86			112.82			13.48			1		
02/27/21 17:59	150104.1			1214.9			22.96			425.34			13.23			1		
02/27/21 18:00	75552.7			1954.2			25.63			344.26			7.43			1		
02/27/21 18:01	0			0			32.92			0			0			0		
02/27/21 18:02	0			0			0.2			0			0			0		
02/27/21 18:03	0			0			0.2			0			0			0		
02/27/21 18:04	0			0			0.1			0			0			0		
02/27/21 18:05	0			0			0.1			0			0			0		

CT2 SUSD EVENT 5

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/01/21 7:40	0			0			0			0			0			0		
03/01/21 7:41	0			0			0			0			0			0		
03/01/21 7:42	0			0			0			0			0			0		
03/01/21 7:43	0			0			0			0			0			0		
03/01/21 7:44	1925.4			0			0			0			0			0		
03/01/21 7:45	17482.6			0.1			0			0			0			1		
03/01/21 7:46	35119.3			0.8			0			0			0			1		
03/01/21 7:47	47672.9			64.2			13.77			7.15			2.52			1		
03/01/21 7:48	60380.5			776.3			13.66			109.3			3.17			1		
03/01/21 7:49	74474.4			653.4			17.7			113.5			5.06			1		
03/01/21 7:50	113444.5			514.7			22.2			136.18			9.66			1		
03/01/21 7:51	150951.3			393.6			23.85			138.58			13.82			1		
03/01/21 7:52	156881.5			223.1			42.63			81.64			25.68			1		
03/01/21 7:53	166046.4			328.7			48.68			127.31			31.02			1		
03/01/21 7:54	185300.4			737.7			51.89			318.86			36.91			1		
03/01/21 7:55	206248.8			718.8			58.84			345.8			46.58			1		
03/01/21 7:56	229738.6			326.5			65.04			174.98			57.37			1		
03/01/21 7:57	254537.8			69			71.06			40.96			69.42			1		
03/01/21 7:58	278720.8			6.4			77.86			4.14			83.29			1		
03/01/21 7:59	303288.9			1.4			80.32			1.03			93.51			1		
03/01/21 8:00	325161.4			1.3			83.17			1.01			103.81			1		
03/01/21 8:01	340718.7			1.4			86.39			1.12			112.98			1		
03/01/21 8:02	342336			1.7			79.44			1.37			104.39			1		
03/01/21 8:03	342875.1			1.9			64.56			1.48			84.98			1		
03/01/21 8:04	342644.1			1.9			51.73			1.5			68.04			1		
03/01/21 8:05	343414.2			1.8			39.16			1.44			51.62			1		
03/01/21 8:06	343491.3			1.7			29.93			1.37			39.46			1		
03/01/21 8:07	342490			1.5			21.55			1.23			28.33			1		
03/01/21 8:08	339486.4			1.5			11.37			1.15			14.82			1		
03/01/21 8:09	340102.5			1.4			11.97			1.1			15.63			1		
03/01/21 8:10	339794.5			1.3			12.32			1.03			16.07			1		
03/01/21 8:11	338870.3			1.2			12.06			0.96			15.69			1		
03/01/21 8:12	352579.1			1.1			11.8			0.93			15.97			1		
03/01/21 8:13	369676.7			1.1			10.24			0.97			14.53			1		
03/01/21 8:14	386235.1			1.1			9.49			1			14.07			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/01/21 8:15	393089.5			1.1			8.68			1.03			13.09			1		
03/01/21 8:16	399173.8			1.1			8.59			1.05			13.16			1		
03/01/21 8:17	416656.4			1			7.55			1.01			12.07			1		
03/01/21 8:18	429672.1			1.1			7.84			1.06			12.93			1		
03/01/21 8:19	443997.1			1			8.28			1			14.11			1		
03/01/21 8:20	450851.5			1			8.49			1.03			14.7			1		
03/01/21 8:21	463328.1			0.9			8.94			0.97			15.9			1		
03/01/21 8:22	477345			0.9			8.94			1			16.38			1		
03/01/21 8:23	486432.9			0.9			8.94			1.01			16.69			1		
03/01/21 8:24	496599			0.9			9.3			1.04			17.72			1		
03/01/21 8:25	504069.5			0.9			8.53			1.07			16.51			1		
03/01/21 8:26	512079.2			0.8			4.29			0.96			8.43			1		
03/01/21 8:27	511540.1			0.8			3.58			0.96			7.02			1		
03/01/21 8:28	508459.4			0.8			3.31			0.95			6.46			1		
03/01/21 8:29	507997.3			0.9			2.95			1.06			5.75			1		
03/01/21 8:30	507458.3			0.9			2.41			1.06			4.7			1		
03/01/21 8:31	508536.5			0.9			2.15			1.06			4.19			1		
03/01/21 8:32	508767.5			0.9			1.97			1.06			3.84			1		
03/01/21 8:33	508767.5			0.9			1.79			1.06			3.49			1		
03/01/21 8:34	508074.4			0.9			1.7			1.06			3.31			1		
03/01/21 8:35	506072			0.9			1.52			1.06			2.95			0		
03/01/21 8:36	506919.1			0.9			1.43			1.06			2.78			0		
03/01/21 8:37	507612.3			0.9			1.34			1.06			2.61			0		
03/01/21 8:38	506765.1			0.9			1.34			1.06			2.61			0		
03/01/21 8:39	506765.1			0.9			1.25			1.06			2.43			0		

CT2 SUSD EVENT 6

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/01/21 16:48	316150.6			0.7			0.55			0.54			0.67			0		
03/01/21 16:49	317382.8			0.6			0.65			0.48			0.79			0		
03/01/21 16:50	317228.8			0.6			0.65			0.48			0.79			0		
03/01/21 16:51	317536.8			0.6			0.74			0.48			0.9			0		
03/01/21 16:52	317228.8			0.6			0.74			0.48			0.9			0		
03/01/21 16:53	318076			0.6			0.83			0.48			1.01			1		
03/01/21 16:54	303674			0.6			0.92			0.46			1.07			1		
03/01/21 16:55	283880.9			0.6			1.66			0.43			1.81			1		
03/01/21 16:56	261161.2			0.7			4.09			0.41			4.1			1		
03/01/21 16:57	236670.1			0.6			7.4			0.33			6.72			1		
03/01/21 16:58	208251.2			0.4			10.05			0.21			8.04			1		
03/01/21 16:59	182527.9			5.5			11.43			2.35			8.01			1		
03/01/21 17:00	163427.9			399.9			12.64			152.46			7.93			1		
03/01/21 17:01	144327.9			1282.7			13.87			431.84			7.69			1		
03/01/21 17:02	45978.5			1924.7			15.3			206.37			2.7			1		
03/01/21 17:03	0			0			17.16			0			0			0		
03/01/21 17:04	0			0			5.9			0			0			0		
03/01/21 17:05	0			0			5.9			0			0			0		
03/01/21 17:06	0			0			5.9			0			0			0		
03/01/21 17:07	0			0			0			0			0			0		

CT2 SUSD EVENT 7

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/06/21 8:00	0			0			0			0			0			0		
03/06/21 8:01	0			0			0			0			0			0		
03/06/21 8:02	0			0			0			0			0			0		
03/06/21 8:03	0			0			0			0			0			0		
03/06/21 8:04	3157.7			0			0			0.04			0			0		
03/06/21 8:05	23720.9			5.9			0			0.33			0			1		
03/06/21 8:06	40279.4			41.3			5.9			3.88			0.91			1		
03/06/21 8:07	51600.7			664.4			13.16			79.87			2.6			1		
03/06/21 8:08	63538.2			744.6			13.87			110.34			3.38			1		
03/06/21 8:09	82407.1			628.1			16.52			120.62			5.22			1		
03/06/21 8:10	129925.9			473.1			16.63			143.28			8.29			1		
03/06/21 8:11	151875.5			344.5			19.97			121.99			11.64			1		
03/06/21 8:12	159423.1			224.4			29.13			83.38			17.81			1		
03/06/21 8:13	179062.1			391.8			31.16			163.56			21.41			1		
03/06/21 8:14	199779.4			643.6			37.25			299.81			28.56			1		
03/06/21 8:15	215875.8			405			48.68			203.82			40.31			1		
03/06/21 8:16	219572.5			125.1			61.82			64.05			52.08			1		
03/06/21 8:17	221497.9			55.3			64.77			28.55			55.05			1		
03/06/21 8:18	221497.9			48			65.78			24.76			55.9			1		
03/06/21 8:19	220804.8			53.5			61.51			27.53			52.12			1		
03/06/21 8:20	220188.7			56.1			54.98			28.8			46.45			1		
03/06/21 8:21	220188.7			63.3			52.85			32.47			44.64			1		
03/06/21 8:22	220034.6			70.9			49.71			36.39			41.97			1		
03/06/21 8:23	219341.5			73.4			45.57			37.55			38.34			1		
03/06/21 8:24	219110.4			76.1			41.17			38.86			34.61			1		
03/06/21 8:25	217570.1			84.4			38.04			42.79			31.75			1		
03/06/21 8:26	218186.3			89.1			35.27			45.33			29.52			1		
03/06/21 8:27	217878.2			90			34.02			45.71			28.44			1		
03/06/21 8:28	216491.9			93			33.22			46.94			27.6			1		
03/06/21 8:29	217262.1			94.4			32.19			47.82			26.84			1		
03/06/21 8:30	226812			95.8			31.68			50.66			27.57			1		
03/06/21 8:31	248453.5			61.8			31.89			35.78			30.4			1		
03/06/21 8:32	256848.3			6.1			33.43			3.67			32.95			1		
03/06/21 8:33	256925.3			0.9			32.01			0.52			31.56			1		
03/06/21 8:34	258234.6			0.8			31.75			0.45			31.45			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/06/21 8:35	258542.6			0.8			32.4			0.45			32.14			1		
03/06/21 8:36	258388.6			0.6			32.72			0.39			32.44			1		
03/06/21 8:37	258234.6			0.5			32.93			0.32			32.62			1		
03/06/21 8:38	257772.5			0.5			33.25			0.32			32.89			1		
03/06/21 8:39	260545			0.5			33.79			0.33			33.79			1		
03/06/21 8:40	270095			0.5			34.43			0.34			35.68			1		
03/06/21 8:41	272174.4			0.5			34.26			0.33			35.78			1		
03/06/21 8:42	272020.4			0.5			32.96			0.32			34.4			1		
03/06/21 8:43	272174.4			0.5			31.9			0.32			33.32			1		
03/06/21 8:44	271404.3			0.5			32.3			0.32			33.64			1		
03/06/21 8:45	270172			0.5			32.9			0.31			34.11			1		
03/06/21 8:46	272020.4			0.5			33.57			0.32			35.03			1		
03/06/21 8:47	270480.1			0.5			29.1			0.32			30.2			1		
03/06/21 8:48	270865.2			0.5			28.5			0.32			29.62			1		
03/06/21 8:49	270480.1			0.5			26.3			0.32			27.29			1		
03/06/21 8:50	271404.3			0.4			25.3			0.25			26.35			1		
03/06/21 8:51	270557.1			0.4			25.4			0.25			26.37			1		
03/06/21 8:52	271096.2			0.4			25.6			0.25			26.63			1		
03/06/21 8:53	270480.1			0.3			25.8			0.19			26.77			1		
03/06/21 8:54	266706.3			0.3			18.7			0.19			19.14			1		
03/06/21 8:55	276333.3			0.3			16.89			0.2			17.9			1		
03/06/21 8:56	286114.3			0.4			14.3			0.27			15.7			1		
03/06/21 8:57	287654.7			0.4			11.12			0.26			12.28			1		
03/06/21 8:58	294047			0.5			7.04			0.33			7.95			1		
03/06/21 8:59	296819.6			0.5			4.78			0.32			5.44			1		
03/06/21 9:00	296203.4			0.5			3.04			0.32			3.46			1		
03/06/21 9:01	295125.2			0.6			2.77			0.38			3.13			1		
03/06/21 9:02	295125.2			0.6			2.3			0.38			2.61			1		
03/06/21 9:03	294817.2			0.6			2.3			0.38			2.61			1		
03/06/21 9:04	293430.8			0.6			2.21			0.38			2.49			1		
03/06/21 9:05	295356.3			0.6			2.03			0.38			2.3			1		
03/06/21 9:06	295356.3			0.6			1.75			0.38			1.98			1		
03/06/21 9:07	293584.9			0.6			1.57			0.38			1.77			1		
03/06/21 9:08	295356.3			0.6			1.48			0.38			1.67			1		
03/06/21 9:09	294740.1			0.6			1.38			0.38			1.56			0		
03/06/21 9:10	293507.9			0.6			1.38			0.38			1.56			0		
03/06/21 9:11	310759.4			0.6			1.38			0.4			1.65			0		
03/06/21 9:12	317998.9			0.5			1.36			0.4			1.66			0		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/06/21 9:13	318076			0.5			1.07			0.4			1.31			0		

CT2 SUSD EVENT 8

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/06/21 16:52	395477			0.8			1.67			0.73			2.54			0		
03/06/21 16:53	376608.1			0.8			1.74			0.69			2.51			0		
03/06/21 16:54	368521.4			0.9			1.91			0.75			2.7			0		
03/06/21 16:55	366827.1			1			1.91			0.82			2.69			0		
03/06/21 16:56	357970.3			1			1.91			0.8			2.62			0		
03/06/21 16:57	336790.8			0.9			1.91			0.68			2.47			1		
03/06/21 16:58	317151.8			0.8			1.85			0.59			2.25			1		
03/06/21 16:59	292506.7			0.9			1.7			0.61			1.91			1		
03/06/21 17:00	268477.7			0.7			2.21			0.46			2.28			1		
03/06/21 17:01	245681			0.7			5.42			0.39			5.11			1		
03/06/21 17:02	219957.6			0.5			13.8			0.27			11.65			1		
03/06/21 17:03	195466.5			2.1			17.82			0.95			13.36			1		
03/06/21 17:04	173054.9			173.2			20.98			69.86			13.93			1		
03/06/21 17:05	152953.7			801.1			23.9			285.65			14.02			1		
03/06/21 17:06	124765.9			1574.3			26.3			457.77			12.58			1		
03/06/21 17:07	0			0			30.31			0			0			1		
03/06/21 17:08	0			0			17.7			0			0			0		
03/06/21 17:09	0			0			17.7			0			0			0		
03/06/21 17:10	0			0			11.8			0			0			0		
03/06/21 17:11	0			0			11.8			0			0			0		
03/06/21 17:12	0			0			5.9			0			0			0		

CT2 SUSD EVENT 9

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/12/21 14:52	0			0			0			0			0			0		
03/12/21 14:53	0			0			0			0			0			0		
03/12/21 14:54	0			0			0			0			0			0		
03/12/21 14:55	0			0			0			0			0			0		
03/12/21 14:56	6315.3			0			0			0			0			0		
03/12/21 14:57	0			0			0			0			0			0		
03/12/21 14:58	11398.4			0.1			0			0			0			1		
03/12/21 14:59	27340.7			0.3			0			0			0			1		
03/12/21 15:00	40972.5			59.8			6.74			5.72			1.06			1		
03/12/21 15:01	22488.7			1003.9			7.08			52.58			0.61			1		
03/12/21 15:02	0			0			8.96			0			0			0		
03/12/21 15:03	0			0			8.26			0			0			0		
03/12/21 15:04	0			0			8.19			0			0			0		
03/12/21 15:05	0			0			16.52			0			0			0		
03/12/21 15:06	0			0			23.6			0			0			0		

CT2 SUSD EVENT 10

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/12/21 14:52	0			0			0			0			0			0		
03/12/21 14:53	0			0			0			0			0			0		
03/12/21 14:54	0			0			0			0			0			0		
03/12/21 14:55	0			0			0			0			0			0		
03/12/21 14:56	6315.3			0			0			0			0			0		
03/12/21 14:57	0			0			0			0			0			0		
03/12/21 14:58	11398.4			0.1			0			0			0			1		
03/12/21 14:59	27340.7			0.3			0			0			0			1		
03/12/21 15:00	40972.5			59.8			6.74			5.72			1.06			1		
03/12/21 15:01	22488.7			1003.9			7.08			52.58			0.61			1		
03/12/21 15:02	0			0			8.96			0			0			0		
03/12/21 15:03	0			0			8.26			0			0			0		
03/12/21 15:04	0			0			8.19			0			0			0		
03/12/21 15:05	0			0			16.52			0			0			0		
03/12/21 15:06	0			0			23.6			0			0			0		

CT2 SUSD EVENT 11

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/12/21 15:21	0			0			17.7			0			0			0		
03/12/21 15:22	0			0			17.7			0			0			0		
03/12/21 15:23	0			0			11.8			0			0			0		
03/12/21 15:24	0			0			11.8			0			0			0		
03/12/21 15:25	5853.2			0			11.8			0.24			0.27			0		
03/12/21 15:26	0			17.7			11.8			0			0			1		
03/12/21 15:27	17713.7			11.8			5.9			0.49			0.4			1		
03/12/21 15:28	29343.1			82.6			5.9			5.66			0.67			1		
03/12/21 15:29	3388.7			1227.7			9.65			9.62			0.12			1		
03/12/21 15:30	0			0			10.62			0			0			0		
03/12/21 15:31	0			0			9.27			0			0			0		
03/12/21 15:32	0			0			11.8			0			0			0		
03/12/21 15:33	0			0			25.57			0			0			0		
03/12/21 15:34	0			0			29.5			0			0			0		

CT2 SUSD EVENT 12

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/12/21 15:21	0			0			17.7			0			0			0		
03/12/21 15:22	0			0			17.7			0			0			0		
03/12/21 15:23	0			0			11.8			0			0			0		
03/12/21 15:24	0			0			11.8			0			0			0		
03/12/21 15:25	5853.2			0			11.8			0.24			0.27			0		
03/12/21 15:26	0			17.7			11.8			0			0			1		
03/12/21 15:27	17713.7			11.8			5.9			0.49			0.4			1		
03/12/21 15:28	29343.1			82.6			5.9			5.66			0.67			1		
03/12/21 15:29	3388.7			1227.7			9.65			9.62			0.12			1		
03/12/21 15:30	0			0			10.62			0			0			0		
03/12/21 15:31	0			0			9.27			0			0			0		
03/12/21 15:32	0			0			11.8			0			0			0		
03/12/21 15:33	0			0			25.57			0			0			0		
03/12/21 15:34	0			0			29.5			0			0			0		

CT2 SUSD EVENT 13

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/12/21 15:46	0			0			11.8			0			0			0		
03/12/21 15:47	0			0			11.8			0			0			0		
03/12/21 15:48	0			0			5.9			0			0			0		
03/12/21 15:49	5083.1			0			5.9			0.21			0.12			0		
03/12/21 15:50	1232.3			0			5.9			0.05			0.03			0		
03/12/21 15:51	14093.9			11.8			5.9			0.39			0.32			1		
03/12/21 15:52	25492.3			35.4			5.9			2.1			0.58			1		
03/12/21 15:53	39355.2			1230.9			14.01			112.97			2.12			1		
03/12/21 15:54	51061.6			1170.2			15.34			139.35			3.01			1		
03/12/21 15:55	62305.9			714.2			17.39			103.76			4.16			1		
03/12/21 15:56	42897.9			479.3			16.3			47.96			2.68			1		
03/12/21 15:57	0			0			18.5			0			0			0		
03/12/21 15:58	0			0			15.73			0			0			0		
03/12/21 15:59	0			0			47.2			0			0			0		
03/12/21 16:00	0			0			82.6			0			0			0		
03/12/21 16:01	0			0			82.6			0			0			0		

CT2 SUSD EVENT 14

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/12/21 15:46	0			0			11.8			0			0			0		
03/12/21 15:47	0			0			11.8			0			0			0		
03/12/21 15:48	0			0			5.9			0			0			0		
03/12/21 15:49	5083.1			0			5.9			0.21			0.12			0		
03/12/21 15:50	1232.3			0			5.9			0.05			0.03			0		
03/12/21 15:51	14093.9			11.8			5.9			0.39			0.32			1		
03/12/21 15:52	25492.3			35.4			5.9			2.1			0.58			1		
03/12/21 15:53	39355.2			1230.9			14.01			112.97			2.12			1		
03/12/21 15:54	51061.6			1170.2			15.34			139.35			3.01			1		
03/12/21 15:55	62305.9			714.2			17.39			103.76			4.16			1		
03/12/21 15:56	42897.9			479.3			16.3			47.96			2.68			1		
03/12/21 15:57	0			0			18.5			0			0			0		
03/12/21 15:58	0			0			15.73			0			0			0		
03/12/21 15:59	0			0			47.2			0			0			0		
03/12/21 16:00	0			0			82.6			0			0			0		
03/12/21 16:01	0			0			82.6			0			0			0		

CT2 SUSD EVENT 15

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/12/21 17:06	0			0			17.7			0			0			0		
03/12/21 17:07	0			0			17.7			0			0			0		
03/12/21 17:08	0			0			17.7			0			0			0		
03/12/21 17:09	0			0			11.8			0			0			0		
03/12/21 17:10	0			0			11.8			0			0			0		
03/12/21 17:11	13015.7			5.9			11.8			0.18			0.59			1		
03/12/21 17:12	26878.6			88.5			23.6			5.55			2.43			1		
03/12/21 17:13	39663.2			1161.6			20.98			107.39			3.19			1		
03/12/21 17:14	51600.7			1178.4			22.42			141.65			4.44			1		
03/12/21 17:15	63230.1			712.3			23.91			105.08			5.8			1		
03/12/21 17:16	42512.8			484.4			25.85			48.03			4.22			1		
03/12/21 17:17	0			0			26.01			0			0			0		
03/12/21 17:18	0			0			21.83			0			0			0		
03/12/21 17:19	0			0			112.1			0			0			0		
03/12/21 17:20	0			0			106.2			0			0			0		
03/12/21 17:21	0			0			100.3			0			0			0		

CT2 SUSD EVENT 16

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/12/21 17:06	0			0			17.7			0			0			0		
03/12/21 17:07	0			0			17.7			0			0			0		
03/12/21 17:08	0			0			17.7			0			0			0		
03/12/21 17:09	0			0			11.8			0			0			0		
03/12/21 17:10	0			0			11.8			0			0			0		
03/12/21 17:11	13015.7			5.9			11.8			0.18			0.59			1		
03/12/21 17:12	26878.6			88.5			23.6			5.55			2.43			1		
03/12/21 17:13	39663.2			1161.6			20.98			107.39			3.19			1		
03/12/21 17:14	51600.7			1178.4			22.42			141.65			4.44			1		
03/12/21 17:15	63230.1			712.3			23.91			105.08			5.8			1		
03/12/21 17:16	42512.8			484.4			25.85			48.03			4.22			1		
03/12/21 17:17	0			0			26.01			0			0			0		
03/12/21 17:18	0			0			21.83			0			0			0		
03/12/21 17:19	0			0			112.1			0			0			0		
03/12/21 17:20	0			0			106.2			0			0			0		
03/12/21 17:21	0			0			100.3			0			0			0		

CT2 SUSD EVENT 17

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/13/21 11:39	0			0	X		0	X		0	X		0	X		0		
03/13/21 11:40	0			0	X		0	X		0	X		0	X		0		
03/13/21 11:41	0			0	X		0	X		0	X		0	X		0		
03/13/21 11:42	3003.6			0	X		0	X		0.08	X		0	X		0		
03/13/21 11:43	0			0	X		0	X		0	X		0	X		0		
03/13/21 11:44	19639.1			5.9	X		0	X		0.27	X		0	X		1		
03/13/21 11:45	30190.3			70.8	X		5.9	X		4.98	X		0.68	X		1		
03/13/21 11:46	43051.9			1161.1	X		10.03	X		116.44	X		1.66	X		1		
03/13/21 11:47	54604.3			1125.1	X		12.91	X		143.3	X		2.71	X		1		
03/13/21 11:48	66926.9			747.1	X		17.39	X		116.57	X		4.47	X		1		
03/13/21 11:49	96501			517.5	X		21.07	X		116.42	X		7.8	X		1		
03/13/21 11:50	144405			360.9	X		22.37	X		121.5	X		12.4	X		1		
03/13/21 11:51	155726.3			210	X		44.25	X		76.26	X		26.44	X		1		
03/13/21 11:52	161040.4			1037	X		43.27	X		389.27	X		26.73	X		1		
03/13/21 11:53	160886.4			1814.6	X		46.33	X		680.78	X		28.61	X		1		
03/13/21 11:54	169820.2			1832.5	X		51.02	X		725.63	X		33.25	X		1		
03/13/21 11:55	187842			1747.1	X		53.77	X		764.94	X		38.75	X		1		
03/13/21 11:56	212641.1			962.8	X		61.17	X		477.37	X		49.92	X		1		
03/13/21 11:57	237440.3			254.7	X		59	X		140.97	X		53.75	X		1		
03/13/21 11:58	260160			26.7	X		51.78	X		16.22	X		51.69	X		1		
03/13/21 11:59	287115.5			3.5	X		46.98	X		2.34	X		51.75	X		1		
03/13/21 12:00	313224			2.4	X		40.1	X		1.75	X		48.19	X		1		
03/13/21 12:01	336251.8			2.2	X		21.42	X		1.71	X		27.64	X		1		
03/13/21 12:02	357277.1			2.1	X		15.13	X		1.78	X		20.75	X		1		
03/13/21 12:03	376377.1			2.3	X		14.54	X		2.03	X		20.99	X		1		
03/13/21 12:04	394629.8			2.4	X		13.6	X		2.2	X		20.59	X		1		
03/13/21 12:05	417041.5			2.3	X		10.93	X		2.28	X		17.49	X		1		
03/13/21 12:06	440531.4			2.1	X		9.95	X		2.17	X		16.82	X		1		
03/13/21 12:07	463328.1			1.8	X		9.12	X		1.93	X		16.21	X		1		
03/13/21 12:08	491670			1.5	X		8.49	X		1.74	X		16.02	X		1		
03/13/21 12:09	496676			1.5	X		8.35	X		1.68	X		15.91	X		1		
03/13/21 12:10	494211.5			1.3	X		9.48	X		1.54	X		17.97	X		1		
03/13/21 12:11	490360.7			1.3	X		9.21	X		1.43	X		17.32	X		1		
03/13/21 12:12	491824			1.3	X		9.12	X		1.43	X		17.21	X		1		
03/13/21 12:13	491824			1.2	X		8.94	X		1.33	X		16.87	X		1		

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/13/21 12:14	490514.7			1.2	X		8.94	X		1.33	X		16.83	X		1		
03/13/21 12:15	492825.2			1.1	X		9.03	X		1.23	X		17.07	X		1		
03/13/21 12:16	492517.2			1.1	X		9.12	X		1.23	X		17.23	X		1		
03/13/21 12:17	491592.9			1	X		9.3	X		1.13	X		17.54	X		1		
03/13/21 12:18	490129.7			1	X		9.57	X		1.12	X		17.99	X		1		
03/13/21 12:19	490745.8			1	X		9.71	X		1.14	X		18.29	X		1		
03/13/21 12:20	491901			0.9	X		9.62	X		1.04	X		18.16	X		1		
03/13/21 12:21	491592.9			0.9	X		9.8	X		1.04	X		18.49	X		1		
03/13/21 12:22	490822.8			0.9	X		7.15	X		1.02	X		13.47	X		1		
03/13/21 12:23	490437.7			0.9	X		4.83	X		1.02	X		9.08	X		1		
03/13/21 12:24	489359.5			0.9	X		4.47	X		1.02	X		8.39	X		1		
03/13/21 12:25	488050.2			0.8	X		4.27	X		0.93	X		7.99	X		1		
03/13/21 12:26	489667.6			0.8	X		3.99	X		0.93	X		7.5	X		1		
03/13/21 12:27	488666.3			0.8	X		3.63	X		0.93	X		6.81	X		1		
03/13/21 12:28	487973.2			0.8	X		3.4	X		0.92	X		6.36	X		1		
03/13/21 12:29	487819.2			0.8	X		3.31	X		0.92	X		6.19	X		1		
03/13/21 12:30	490437.7			0.8	X		3.09	X		0.93	X		5.81	X		1		
03/13/21 12:31	491515.9			0.8	X		2.9	X		0.94	X		5.48	X		1		
03/13/21 12:32	489744.6			0.8	X		2.77	X		0.92	X		5.21	X		1		
03/13/21 12:33	489590.5			0.8	X		3.18	X		0.93	X		5.97	X		1		
03/13/21 12:34	486586.9			0.8	X		2.72	X		0.93	X		5.08	X		1		
03/13/21 12:35	486818			0.8	X		2.63	X		0.93	X		4.92	X		1		
03/13/21 12:36	488743.4			0.8	X		2.54	X		0.93	X		4.77	X		1		
03/13/21 12:37	488589.3			0.8	X		2.45	X		0.93	X		4.59	X		1		
03/13/21 12:38	485970.8			0.8	X		2.36	X		0.93	X		4.4	X		1		
03/13/21 12:39	488512.3			0.8	X		2.36	X		0.93	X		4.42	X		1		
03/13/21 12:40	489744.6			0.8	X		2.27	X		0.93	X		4.26	X		1		
03/13/21 12:41	489898.6			0.8	X		2.18	X		0.93	X		4.09	X		1		
03/13/21 12:42	487742.2			0.8	X		2.09	X		0.93	X		3.91	X		1		
03/13/21 12:43	489744.6			0.7	X		2.09	X		0.83	X		3.92	X		1		
03/13/21 12:44	490899.8			0.8	X		2.09	X		0.93	X		3.93	X		1		
03/13/21 12:45	489667.6			0.8	X		2.06	X		0.92	X		3.86	X		1		
03/13/21 12:46	486432.9			0.8	X		2.06	X		0.91	X		3.84	X		0		
03/13/21 12:47	486895			0.8	X		2	X		0.93	X		3.73	X		0		
03/13/21 12:48	486740.9			0.8	X		2	X		0.93	X		3.73	X		0		
03/13/21 12:49	486740.9			0.7	X		1.91	X		0.82	X		3.56	X		0		
03/13/21 12:50	486509.9			0.8	X		1.91	X		0.93	X		3.56	X		0		

CT2 SUSD EVENT 18

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/13/21 21:55	412497.6			0.9			1.48			0.83			2.33			0		
03/13/21 21:56	400406			0.9			1.48			0.81			2.27			0		
03/13/21 21:57	382076.3			0.9			1.48			0.77			2.16			0		
03/13/21 21:58	356661			0.9			1.54			0.71			2.11			0		
03/13/21 21:59	336944.9			0.9			1.62			0.74			2.1			0		
03/13/21 22:00	328088			1			1.82			0.73			2.29			1		
03/13/21 22:01	306677.6			0.9			1.85			0.63			2.18			1		
03/13/21 22:02	281955.5			0.8			2.63			0.54			2.85			1		
03/13/21 22:03	258927.7			0.7			5.14			0.4			5.11			1		
03/13/21 22:04	236054			0.5			5.59			0.28			5.06			1		
03/13/21 22:05	209560.5			2.1			22.71			1.03			18.26			1		
03/13/21 22:06	184838.3			2.4			26.49			1.03			18.78			1		
03/13/21 22:07	166816.6			559.4			30.34			217.5			19.42			1		
03/13/21 22:08	146715.4			1347			33.49			460.71			18.85			1		
03/13/21 22:09	38508			1866.8			36.32			167.57			5.37			1		
03/13/21 22:10	0			0			34.33			0			0			0		
03/13/21 22:11	0			0			17.7			0			0			0		
03/13/21 22:12	0			0			11.8			0			0			0		
03/13/21 22:13	0			0			11.8			0			0			0		
03/13/21 22:14	0			0			11.8			0			0			0		

CT2 SUSD EVENT 19

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/22/21 5:34	0			0			0			0			0			0		
03/22/21 5:35	0			0			0			0			0			0		
03/22/21 5:36	0			0			0			0			0			0		
03/22/21 5:37	0			0			0			0			0			0		
03/22/21 5:38	3311.7			0			0			0.04			0			0		
03/22/21 5:39	8471.8			5.9			0			0.12			0			1		
03/22/21 5:40	21564.5			5.9			0			0.3			0			1		
03/22/21 5:41	34118.1			41.3			2.95			3.28			0.39			1		
03/22/21 5:42	47133.8			1227.2			7.87			134.88			1.42			1		
03/22/21 5:43	59225.3			1012.4			13.19			139.82			3			1		
03/22/21 5:44	73396.2			721.7			17.7			123.42			4.98			1		
03/22/21 5:45	111827.2			524.5			20.23			136.79			8.68			1		
03/22/21 5:46	153338.8			377.6			22.37			134.99			13.16			1		
03/22/21 5:47	157343.6			274.6			32.93			100.76			19.88			1		
03/22/21 5:48	166662.6			1527.5			27.84			593.6			17.81			1		
03/22/21 5:49	184145.2			1899.1			31.11			815.35			21.98			1		
03/22/21 5:50	206017.7			1442.9			36.88			693.12			29.15			1		
03/22/21 5:51	228968.5			597.6			44.32			319.06			38.94			1		
03/22/21 5:52	254768.8			104.8			50.79			62.23			49.64			1		
03/22/21 5:53	277180.5			8.5			62.4			5.5			66.37			1		
03/22/21 5:54	289888.1			2.4			79.91			1.61			88.87			1		
03/22/21 5:55	296280.4			2			64.03			1.4			72.79			1		
03/22/21 5:56	296049.4			1.9			30.81			1.29			34.99			1		
03/22/21 5:57	293507.9			1.7			23.41			1.15			26.37			1		
03/22/21 5:58	292352.6			1.6			23.04			1.09			25.84			1		
03/22/21 5:59	292506.7			1.4			22.57			0.96			25.33			1		
03/22/21 6:00	290504.3			1.3			22.2			0.89			24.74			1		
03/22/21 6:01	290812.3			1.2			21.26			0.83			23.72			1		
03/22/21 6:02	291890.5			1.2			20.23			0.83			22.65			1		
03/22/21 6:03	290812.3			1.1			19.48			0.76			21.74			1		
03/22/21 6:04	289040.9			1			18.82			0.69			20.87			1		
03/22/21 6:05	289349			0.9			18.26			0.63			20.28			1		
03/22/21 6:06	288347.8			0.9			18.18			0.58			20.11			1		
03/22/21 6:07	285498.2			0.9			17.89			0.57			19.59			1		
03/22/21 6:08	288039.8			0.8			20.75			0.51			22.93			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/22/21 6:09	291582.5			0.8			19.32			0.52			21.61			1		
03/22/21 6:10	290273.2			0.7			16.76			0.51			18.67			1		
03/22/21 6:11	288963.9			0.7			16.67			0.5			18.48			1		
03/22/21 6:12	289811.1			0.8			17.22			0.51			19.15			1		
03/22/21 6:13	288578.8			0.7			17.7			0.45			19.6			1		
03/22/21 6:14	288424.8			0.7			17.89			0.45			19.8			1		
03/22/21 6:15	288116.8			0.7			18.08			0.45			19.99			1		
03/22/21 6:16	288732.9			0.7			18.18			0.45			20.13			1		
03/22/21 6:17	286961.5			0.6			18.27			0.38			20.12			1		
03/22/21 6:18	287654.7			0.7			18.27			0.45			20.17			1		
03/22/21 6:19	287269.6			0.7			18.37			0.45			20.24			1		
03/22/21 6:20	286114.3			0.6			18.46			0.38			20.27			1		
03/22/21 6:21	287192.6			0.6			18.65			0.38			20.55			1		
03/22/21 6:22	286807.5			0.6			18.84			0.38			20.73			1		
03/22/21 6:23	286345.4			0.6			19.03			0.38			20.91			1		
03/22/21 6:24	287269.6			0.5			19.13			0.32			21.08			1		
03/22/21 6:25	286422.4			0.6			19.22			0.38			21.12			1		
03/22/21 6:26	286730.5			0.6			19.32			0.38			21.25			1		
03/22/21 6:27	286807.5			0.6			13.13			0.38			14.45			1		
03/22/21 6:28	287192.6			0.6			7.42			0.38			8.18			1		
03/22/21 6:29	285883.3			0.6			5.8			0.38			6.37			1		
03/22/21 6:30	287423.6			0.6			4.76			0.38			5.25			1		
03/22/21 6:31	286191.3			0.5			4.19			0.32			4.6			1		
03/22/21 6:32	285421.2			0.5			3.62			0.32			3.96			1		
03/22/21 6:33	285498.2			0.5			3.33			0.32			3.65			1		
03/22/21 6:34	284882.1			0.5			2.95			0.32			3.22			1		
03/22/21 6:35	286191.3			0.5			2.66			0.32			2.93			1		
03/22/21 6:36	285113.1			0.5			2.38			0.32			2.6			1		
03/22/21 6:37	283572.8			0.5			2.19			0.31			2.38			1		
03/22/21 6:38	286191.3			0.5			2			0.32			2.19			1		
03/22/21 6:39	285267.2			0.5			1.81			0.32			1.98			1		
03/22/21 6:40	286114.3			0.5			1.71			0.32			1.88			1		
03/22/21 6:41	284728.1			0.5			1.62			0.32			1.77			0		
03/22/21 6:42	284805.1			0.5			1.52			0.32			1.66			0		
03/22/21 6:43	286268.4			0.5			1.43			0.32			1.57			0		
03/22/21 6:44	285960.3			0.5			1.33			0.32			1.46			0		
03/22/21 6:45	286037.3			0.4			1.33			0.25			1.46			0		

CT2 SUSD EVENT 20

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/22/21 7:46	284420			0.4			1.71			0.25			1.87			0		
03/22/21 7:47	285113.1			0.4			1.81			0.25			1.98			0		
03/22/21 7:48	284959.1			0.5			1.81			0.32			1.98			0		
03/22/21 7:49	284805.1			0.5			1.81			0.32			1.98			0		
03/22/21 7:50	286422.4			0.5			1.81			0.32			1.99			0		
03/22/21 7:51	198547.2			0.5			1.81			0.22			1.38			1		
03/22/21 7:52	0			0			1.57			0			0			0		
03/22/21 7:53	0			0			2.95			0			0			0		
03/22/21 7:54	0			0			5.9			0			0			0		
03/22/21 7:55	0			0			5.9			0			0			0		
03/22/21 7:56	0			0			5.9			0			0			0		

CT2 SUSD EVENT 21

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/22/21 8:03	0			0			5.9			0			0			0		
03/22/21 8:04	0			0			5.9			0			0			0		
03/22/21 8:05	0			0			5.9			0			0			0		
03/22/21 8:06	0			0			5.9			0			0			0		
03/22/21 8:07	0			0			5.9			0			0			0		
03/22/21 8:08	11860.5			0			0			0			0			1		
03/22/21 8:09	26185.4			35.4			0			2.16			0			1		
03/22/21 8:10	40510.4			356.5			0.49			33.67			0.08			1		
03/22/21 8:11	52293.8			476.4			1.11			58.12			0.22			1		
03/22/21 8:12	65155.5			322.2			1.64			48.97			0.41			1		
03/22/21 8:13	100274.8			235.7			2.36			55.08			0.91			1		
03/22/21 8:14	140862.2			185			4.1			60.74			2.22			1		
03/22/21 8:15	155418.2			161.5			6.71			58.54			4			1		
03/22/21 8:16	170513.4			1455.3			9.4			578.54			6.15			1		
03/22/21 8:17	190383.5			1593.5			11.45			707.34			8.37			1		
03/22/21 8:18	213950.4			731.6			12.71			364.87			10.43			1		
03/22/21 8:19	237748.3			169.4			13.28			93.86			12.11			1		
03/22/21 8:20	259389.8			18.7			15.89			11.29			15.82			1		
03/22/21 8:21	286268.4			2.3			17.37			1.53			19.08			1		
03/22/21 8:22	313146.9			1.5			9.8			1.09			11.77			1		
03/22/21 8:23	335019.5			1.3			6.17			0.99			7.93			1		
03/22/21 8:24	357046.1			1.2			3.51			1			4.8			1		
03/22/21 8:25	375837.9			1.3			3.16			1.12			4.56			1		
03/22/21 8:26	396401.2			1.3			2.22			1.19			3.38			1		
03/22/21 8:27	418196.7			1.2			1.74			1.18			2.78			1		
03/22/21 8:28	438297.9			1.1			1.59			1.08			2.67			1		
03/22/21 8:29	457860			1			1.5			1.03			2.63			1		
03/22/21 8:30	460016.4			0.9			1.61			0.96			2.84			0		
03/22/21 8:31	461556.7			0.9			1.67			0.95			2.96			0		
03/22/21 8:32	462866			0.9			1.76			0.95			3.13			0		
03/22/21 8:33	461556.7			0.9			1.85			0.95			3.27			0		
03/22/21 8:34	461787.8			0.9			1.76			0.95			3.12			0		

CT2 SUSD EVENT 22

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/23/21 13:52	480656.7			0.7			1.34			0.8			2.47			0		
03/23/21 13:53	458476.1			0.7			1.34			0.76			2.36			0		
03/23/21 13:54	435217.3			0.8			1.41			0.8			2.35			0		
03/23/21 13:55	411573.3			0.8			1.3			0.75			2.06			0		
03/23/21 13:56	388622.6			0.9			1.28			0.77			1.91			0		
03/23/21 13:57	364285.6			0.9			1.28			0.73			1.79			1		
03/23/21 13:58	341103.8			0.9			1.37			0.75			1.79			1		
03/23/21 13:59	317767.9			0.9			1.45			0.7			1.77			1		
03/23/21 14:00	293815.9			0.9			1.67			0.6			1.89			1		
03/23/21 14:01	268169.6			0.8			2.45			0.51			2.52			1		
03/23/21 14:02	246528.1			0.6			5.9			0.34			5.58			1		
03/23/21 14:03	220188.7			0.5			18.34			0.28			15.5			1		
03/23/21 14:04	195389.5			4.4			22.77			1.99			17.07			1		
03/23/21 14:05	173748			273.1			26.35			110.65			17.57			1		
03/23/21 14:06	154109			1017.2			30.56			365.46			18.07			1		
03/23/21 14:07	114753.8			1696.7			33.04			453.85			14.55			1		
03/23/21 14:08	0			0			38.24			0			0			0		
03/23/21 14:09	0			0			32.45			0			0			0		
03/23/21 14:10	0			0			17.7			0			0			0		
03/23/21 14:11	0			0			17.7			0			0			0		
03/23/21 14:12	0			0			11.8			0			0			0		

CT2 SUSD EVENT 23

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/24/21 8:39	0			0			0			0			0			0		
03/24/21 8:40	0			0			0			0			0			0		
03/24/21 8:41	0			0			0			0			0			0		
03/24/21 8:42	0			0			0			0			0			0		
03/24/21 8:43	0			0			0			0			0			0		
03/24/21 8:44	10782.2			0.1			0			0			0			1		
03/24/21 8:45	25415.3			47.2			0			2.8			0			1		
03/24/21 8:46	38970.1			76.7			17.7			6.97			2.65			1		
03/24/21 8:47	51523.7			1141.7			13.64			137.23			2.7			1		
03/24/21 8:48	63384.1			847.6			21.31			125.23			5.18			1		
03/24/21 8:49	82330.1			584.4			25.96			112.11			8.2			1		
03/24/21 8:50	130619.1			452.7			30.84			137.81			15.45			1		
03/24/21 8:51	155033.2			279.5			44.14			101.04			26.26			1		
03/24/21 8:52	162888.8			565.7			52.18			214.75			32.6			1		
03/24/21 8:53	177444.8			1786.1			51.31			738.85			34.93			1		
03/24/21 8:54	198162.1			1505.7			55.46			695.65			42.17			1		
03/24/21 8:55	223115.3			669.5			53.99			348.29			46.22			1		
03/24/21 8:56	247529.3			143.4			54.67			82.77			51.92			1		
03/24/21 8:57	269941			13.1			58.76			8.24			60.85			1		
03/24/21 8:58	287577.6			2.4			79.76			1.62			88			1		
03/24/21 8:59	294971.2			2.1			63.23			1.42			71.56			1		
03/24/21 9:00	295741.3			2			39.05			1.36			44.31			1		
03/24/21 9:01	308603			2			19.76			1.41			23.4			1		
03/24/21 9:02	331784.8			1.8			17.34			1.4			22.07			1		
03/24/21 9:03	351654.9			1.6			13.28			1.35			17.91			1		
03/24/21 9:04	371987.2			1.6			11.37			1.41			16.23			1		
03/24/21 9:05	387467.3			1.6			11.29			1.47			16.78			1		
03/24/21 9:06	391857.3			1.5			9.8			1.35			14.74			1		
03/24/21 9:07	392473.4			1.4			9.72			1.27			14.63			1		
03/24/21 9:08	392011.3			1.3			9.63			1.19			14.49			1		
03/24/21 9:09	393320.6			1.2			9.46			1.11			14.27			1		
03/24/21 9:10	391472.2			1.2			9.46			1.11			14.2			1		
03/24/21 9:11	390471			1.2			7.81			1.11			11.7			1		
03/24/21 9:12	387544.4			1.1			7.64			1.02			11.35			1		
03/24/21 9:13	386774.2			1.1			8.24			1.02			12.23			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSDTF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/24/21 9:14	387313.3			1			9.2	X		0.94			13.67	X		1		
03/24/21 9:15	385696			1			9.2	X		0.94			13.61	X		1		
03/24/21 9:16	381922.2			1			9.11	X		0.93			13.35	X		1		
03/24/21 9:17	362976.3			1			9.02			0.88			12.57			1		
03/24/21 9:18	349806.5			1			10.26			0.84			13.77			1		
03/24/21 9:19	339948.5			1			10.24			0.83			13.36			1		
03/24/21 9:20	336251.8			1			9.54			0.82			12.31			1		
03/24/21 9:21	336251.8			1			9.16			0.76			11.82			1		
03/24/21 9:22	335558.6			0.9			9.25			0.69			11.91			1		
03/24/21 9:23	335019.5			0.9			7.75			0.69			9.96			1		
03/24/21 9:24	334788.4			0.9			3.87			0.69			4.98			1		
03/24/21 9:25	334865.4			0.9			3.31			0.7			4.25			1		
03/24/21 9:26	333941.3			0.9			3.04			0.7			3.89			1		
03/24/21 9:27	331707.8			0.9			2.82			0.68			3.59			1		
03/24/21 9:28	332015.8			0.8			2.68			0.62			3.42			1		
03/24/21 9:29	330629.6			0.8			2.41			0.62			3.06			1		
03/24/21 9:30	331399.7			0.8			2.23			0.62			2.84			1		
03/24/21 9:31	330783.6			0.8			2.06			0.62			2.61			1		
03/24/21 9:32	331938.8			0.8			1.97			0.62			2.5			1		
03/24/21 9:33	330706.6			0.8			1.79			0.62			2.27			1		
03/24/21 9:34	329628.4			0.8			1.7			0.62			2.15			1		
03/24/21 9:35	331322.7			0.8			1.61			0.62			2.05			0		
03/24/21 9:36	333402.2			0.8			1.52			0.63			1.94			0		
03/24/21 9:37	333171.1			0.8			1.43			0.62			1.83			0		
03/24/21 9:38	334095.3			0.8			1.43			0.63			1.83			0		
03/24/21 9:39	333710.2			0.8			1.34			0.63			1.72			0		

CT2 SUSD EVENT 24

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/24/21 15:51	305984.5			0.6			1.57			0.46			1.84			0		
03/24/21 15:52	302518.8			0.6			1.48			0.46			1.71			0		
03/24/21 15:53	301286.5			0.6			1.48			0.45			1.71			0		
03/24/21 15:54	297589.7			0.7			1.5			0.45			1.71			0		
03/24/21 15:55	284959.1			0.7			1.59			0.44			1.74			0		
03/24/21 15:56	277719.6			0.7			1.87			0.42			2			1		
03/24/21 15:57	258157.5			0.6			2.57			0.34			2.55			1		
03/24/21 15:58	234282.6			0.6			6.1			0.33			5.48			1		
03/24/21 15:59	208482.2			0.5			16.83			0.27			13.46			1		
03/24/21 16:00	182990			4.6			21.19			1.95			14.88			1		
03/24/21 16:01	162041.6			286.1			25.25			108.1			15.7			1		
03/24/21 16:02	143249.7			985.9			29.03			329.28			15.96			1		
03/24/21 16:03	56067.6			1689.4			32.36			220.84			6.96			1		
03/24/21 16:04	0			0			33.93			0			0			0		
03/24/21 16:05	0			0			8.85			0			0			0		
03/24/21 16:06	0			0			11.8			0			0			0		
03/24/21 16:07	0			0			5.9			0			0			0		
03/24/21 16:08	0			0			5.9			0			0			0		

CT2 SUSD EVENT 25

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/25/21 6:40	0			0			0			0			0			0		
03/25/21 6:41	0			0			0			0			0			0		
03/25/21 6:42	0			0			0			0			0			0		
03/25/21 6:43	0			0			0			0			0			0		
03/25/21 6:44	0			0			0			0			0			0		
03/25/21 6:45	19331			5.9			0			0.27			0			1		
03/25/21 6:46	30960.4			56.1			17.7			4.04			2.1			1		
03/25/21 6:47	44900.3			1283.3			13.28			134.43			2.29			1		
03/25/21 6:48	56144.6			1093.2			15.27			143.16			3.29			1		
03/25/21 6:49	68698.3			772.9			21.12			123.88			5.57			1		
03/25/21 6:50	102585.3			547.9			24.72			130.98			9.73			1		
03/25/21 6:51	149873.1			394.3			32.94			137.78			18.94			1		
03/25/21 6:52	156342.4			242.3			47.2			88.3			28.31			1		
03/25/21 6:53	174595.2			1210			44.7			492.43			29.94			1		
03/25/21 6:54	196390.7			1631.4			49.22			746.81			37.08			1		
03/25/21 6:55	219418.5			776.6			49.27			397.22			41.47			1		
03/25/21 6:56	245989			174.5			49.3			100.08			46.53			1		
03/25/21 6:57	269786.9			14			52.29			8.8			54.13			1		
03/25/21 6:58	291120.4			2.5			72.7			1.72			81.2			1		
03/25/21 6:59	322619.9			2			52.23			1.53			64.65			1		
03/25/21 7:00	345570.7			1.8			23.07			1.49			30.59			1		
03/25/21 7:01	362822.3			1.9			13.4			1.57			18.66			1		
03/25/21 7:02	384078.7			1.9			12.22			1.74			18.01			1		
03/25/21 7:03	401407.3			1.9			10.37			1.81			15.97			1		
03/25/21 7:04	403486.7			1.7			8.94			1.63			13.83			1		
03/25/21 7:05	395169			1.5			9.83			1.42			14.91			1		
03/25/21 7:06	404718.9			1.3			9.44			1.27			14.66			1		
03/25/21 7:07	425128.2			1.4			8.16			1.38			13.3			1		
03/25/21 7:08	430596.3			1.2			6.6			1.24			10.91			1		
03/25/21 7:09	433445.9			1.1			6.6			1.16			10.98			1		
03/25/21 7:10	432829.8			1.1			6.6			1.07			10.97			1		
03/25/21 7:11	434755.2			1.1			6.34			1.07			10.58			1		
03/25/21 7:12	435140.3			1.1			6.34			1.07			10.59			1		
03/25/21 7:13	436141.4			1			6.25			0.98			10.46			1		
03/25/21 7:14	431520.5			1			6.52			0.97			10.79			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/25/21 7:15	429056			1			6.43			0.97			10.58			1		
03/25/21 7:16	425667.3			1			6.34			0.96			10.35			1		
03/25/21 7:17	424974.1			0.9			6.34			0.87			10.34			1		
03/25/21 7:18	427515.7			0.9			6.25			0.88			10.26			1		
03/25/21 7:19	427746.7			0.9			6.16			0.88			10.12			1		
03/25/21 7:20	428979			0.9			4.84			0.88			7.97			1		
03/25/21 7:21	428439.8			0.9			2.64			0.88			4.34			1		
03/25/21 7:22	430904.4			0.9			2.11			0.88			3.49			1		
03/25/21 7:23	431674.5			0.9			1.76			0.89			2.92			1		
03/25/21 7:24	428285.8			0.9			1.67			0.88			2.75			1		
03/25/21 7:25	426437.4			0.9			1.59			0.88			2.59			1		
03/25/21 7:26	425436.2			0.9			1.5			0.87			2.44			0		
03/25/21 7:27	420738.3			0.9			1.5			0.86			2.42			0		
03/25/21 7:28	421277.4			0.9			1.41			0.86			2.28			0		
03/25/21 7:29	425744.3			0.9			1.41			0.87			2.3			0		
03/25/21 7:30	426591.5			0.9			1.32			0.88			2.16			0		

CT2 SUSD EVENT 26

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/25/21 10:58	428516.9			0.8			1.27			0.82			2.09			0		
03/25/21 10:59	410495.1			0.8			1.43			0.77			2.25			0		
03/25/21 11:00	388083.5			0.8			1.67			0.72			2.49			0		
03/25/21 11:01	366442			0.9			2.17			0.74			3.05			0		
03/25/21 11:02	340179.6			0.9			2.48			0.75			3.24			0		
03/25/21 11:03	316612.7			1			2.6			0.7			3.16			1		
03/25/21 11:04	293122.8			1			2.15			0.67			2.41			1		
03/25/21 11:05	267707.5			0.8			2.49			0.52			2.56			1		
03/25/21 11:06	244987.8			0.7			5.32			0.39			5			1		
03/25/21 11:07	220804.8			0.5			18.23			0.27			15.44			1		
03/25/21 11:08	194619.4			3.4			24.64			1.52			18.4			1		
03/25/21 11:09	172746.8			207.9			28.58			83.74			18.94			1		
03/25/21 11:10	153800.9			815.8			32.01			292.56			18.89			1		
03/25/21 11:11	103971.6			1570.9			33.55			380.83			13.38			1		
03/25/21 11:12	0			0			38.7			0			0			0		
03/25/21 11:13	0			0			14.75			0			0			0		
03/25/21 11:14	0			0			17.7			0			0			0		
03/25/21 11:15	0			0			11.8			0			0			0		
03/25/21 11:16	0			0			11.8			0			0			0		

AQ-32

AQ-32 The Project owner shall maintain hourly records of NO_x and CO emission concentrations (ppmv @ 15% O₂), and hourly, daily, and quarterly records of NO_x and CO emissions. Ongoing compliance with the CO emission limits during normal operation shall be deemed compliance with the VOC emission limits during normal operation.

Verification: The project owner shall submit to the CPM all concentration, hourly, daily, and quarter NO_x and CO emissions as part of the Quarterly Air Quality Report required by Condition of Certification AQ-SC6

Tons 12 Month Rolling Summary

CT1 and CT2 Combined



From: 01/01/2021 00:00 **To:** 03/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2021 14:44 **Location:** Roseville, CA

* = Excess Emission

Date	Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2	
	CO, Ton		NOx, Ton		PM10, Ton		SO2, Ton		VOC, Ton	
	1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)	
	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum
Jan 2021	0.0375	2.3537	0.0714	7.4988	0.0127	1.4139	0.0064	0.7071	0.0212	2.3550
Feb 2021	0.1878	2.3603	0.0376	7.1818	0.0038	1.3539	0.0019	0.6771	0.0064	2.2550
Mar 2021	0.4389	2.7992	0.2429	7.4247	0.0306	1.3845	0.0155	0.6926	0.0512	2.3062
Sum/Avg	2.7992		7.4247		1.3845		0.6926		2.3062	
Limit Value										

AQ32 DAILY NOX CO

Date/Time	CT1_CO_Lb_1D			CT1_NOx_Lb_1D			CT2_CO_Lb_1D			CT2_NOx_Lb_1D			Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc						
01/01/21 0:00	0			0			0			0								
01/02/21 0:00	0			0			0			0								
01/03/21 0:00	0			0			0			0								
01/04/21 0:00	0			0			0			0								
01/05/21 0:00	0			0			0			0								
01/06/21 0:00	0			0			0			0								
01/07/21 0:00	0			0			0			0								
01/08/21 0:00	0			0			0			0								
01/09/21 0:00	0			0			0			0								
01/10/21 0:00	0			0			0			0								
01/11/21 0:00	0			0			0			0								
01/12/21 0:00	0			0			0			0								
01/13/21 0:00	0			0			0			0								
01/14/21 0:00	0			0			0			0								
01/15/21 0:00	0			0			0			0								
01/16/21 0:00	0			0			0			0								
01/17/21 0:00	0			0			0			0								
01/18/21 0:00	0			0			0			0								
01/19/21 0:00	0			0			0			0								
01/20/21 0:00	0			0			0			0								
01/21/21 0:00	0			0			0			0								
01/22/21 0:00	0			0			0			0								
01/23/21 0:00	41.43			6.45			0			0								
01/24/21 0:00	17.66			62.48			0			0								
01/25/21 0:00	15.9			74.08			0			0								
01/26/21 0:00	0.01			0.04			0			0								
01/27/21 0:00	0			0			0			0								
01/28/21 0:00	0			0			0			0								
01/29/21 0:00	0			0			0			0								
01/30/21 0:00	0			0			0			0								
01/31/21 0:00	0			0			0			0								
02/01/21 0:00	0			0			0			0								
02/02/21 0:00	0			0			0			0								
02/03/21 0:00	0			0			0			0								
02/04/21 0:00	0			0			0			0								

Date/Time	CT1_CO_Lb_1D			CT1_NOx_Lb_1D			CT2_CO_Lb_1D			CT2_NOx_Lb_1D			Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc						
02/05/21 0:00	0			0			0			0								
02/06/21 0:00	0			0			0			0								
02/07/21 0:00	0			0			0			0								
02/08/21 0:00	0			0			0			0								
02/09/21 0:00	0			0			0			0								
02/10/21 0:00	0			0			0			0								
02/11/21 0:00	0			0			0			0								
02/12/21 0:00	0			0			0			0								
02/13/21 0:00	0			0			0			0								
02/14/21 0:00	0			0			0			0								
02/15/21 0:00	0			0			0			0								
02/16/21 0:00	0			0			0			0								
02/17/21 0:00	0			0			0			0								
02/18/21 0:00	0			0			0			0								
02/19/21 0:00	0			0			0			0								
02/20/21 0:00	0			0			0			0								
02/21/21 0:00	0			0			0			0								
02/22/21 0:00	0			0			0			0								
02/23/21 0:00	0			0			0			0								
02/24/21 0:00	0			0			0			0								
02/25/21 0:00	0			0			0			0								
02/26/21 0:00	0			0			290.84			37.94								
02/27/21 0:00	0			0			84.73			37.27								
02/28/21 0:00	0			0			0			0								
03/01/21 0:00	0			0			50.79			49.99								
03/02/21 0:00	0			0			0			0								
03/03/21 0:00	0			0			0			0								
03/04/21 0:00	0			0			0			0								
03/05/21 0:00	0			0			0			0								
03/06/21 0:00	0			0			58.31			48.94								
03/07/21 0:00	0			0			0			0								
03/08/21 0:00	182.97			28.21			0			0								
03/09/21 0:00	0			0			0			0								
03/10/21 0:00	68.19			49.28			0			0								
03/11/21 0:00	0			0			0			0								
03/12/21 0:00	83.56			21.42			17.94			0.64								
03/13/21 0:00	25.05			27.12			27.22			33.4								
03/14/21 0:00	0			0			0			0								

Date/Time	CT1_CO_Lb_1D			CT1_NOx_Lb_1D			CT2_CO_Lb_1D			CT2_NOx_Lb_1D			Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc						
03/15/21 0:00	0			0			0			0								
03/16/21 0:00	0			0			0			0								
03/17/21 0:00	0			0			0			0								
03/18/21 0:00	0			0			0			0								
03/19/21 0:00	0			0			0			0								
03/20/21 0:00	0			0			0			0								
03/21/21 0:00	0			0			0			0								
03/22/21 0:00	0			0			106.86			59.21								
03/23/21 0:00	62.26			46.66			27.46			35.82								
03/24/21 0:00	17.87			27.12			65.85			35.1								
03/25/21 0:00	0			0			63.73			22.92								
03/26/21 0:00	0			0			0			0								
03/27/21 0:00	0			0			0			0								
03/28/21 0:00	0			0			0			0								
03/29/21 0:00	0			0			0			0								
03/30/21 0:00	0			0			0			0								
03/31/21 0:00	0			0			0			0								
04/01/21 0:00	0	X		0	X		0	X		0	X							

AQ32 HOURLY NOX CO

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/01/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/01/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/01/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/01/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/01/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/01/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/01/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/01/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/01/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/01/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/01/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/01/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/01/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/01/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/01/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/01/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/01/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/01/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/01/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/01/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/01/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/01/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/01/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/01/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/02/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/02/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/02/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/02/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/02/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/02/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/02/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/02/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/02/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/02/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/02/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/02/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/02/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/02/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/02/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/02/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/02/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/02/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/02/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/02/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/02/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/02/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/02/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/02/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/03/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/03/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/03/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/03/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/03/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/03/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/03/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/03/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/03/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/03/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/03/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/03/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/03/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/03/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/03/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/03/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/03/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/03/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/03/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/03/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/03/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/03/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/03/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/03/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/04/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/04/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/04/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/04/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/04/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/04/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/04/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/04/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/04/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/04/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/04/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/04/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/04/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/04/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/04/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/04/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/04/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/04/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/04/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/04/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/04/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/04/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/04/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/04/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/05/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/05/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/05/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/05/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/05/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/05/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/05/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/05/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/05/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/05/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/05/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/05/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/05/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/05/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/05/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/05/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/05/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/05/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/05/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/05/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/05/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/05/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/05/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/05/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/06/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/06/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/06/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/06/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/06/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/06/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/06/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/06/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/06/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/06/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/06/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/06/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/06/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/06/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/06/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/06/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/06/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/06/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/06/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/06/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/06/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/06/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/06/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/06/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/07/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/07/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/07/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/07/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/07/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/07/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/07/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/07/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/07/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/07/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/07/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/07/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/07/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/07/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/07/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/07/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/07/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/07/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/07/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/07/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/07/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/07/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/07/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/07/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/08/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/08/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/08/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/08/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/08/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/08/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/08/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/08/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/08/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/08/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/08/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/08/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/08/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/08/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/08/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/08/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/08/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/08/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/08/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/08/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/08/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/08/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/08/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/08/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/09/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/09/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/09/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/09/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/09/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/09/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/09/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/09/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/09/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/09/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/09/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/09/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/09/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/09/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/09/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/09/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/09/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/09/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/09/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/09/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/09/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/09/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/09/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/09/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/10/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/10/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/10/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/10/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/10/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/10/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/10/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/10/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/10/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/10/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/10/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/10/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/10/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/10/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/10/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/10/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/10/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/10/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/10/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/10/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/10/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/10/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/10/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/10/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/11/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/11/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/11/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/11/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/11/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/11/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/11/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/11/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/11/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/11/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/11/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/11/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/11/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/11/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/11/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/11/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/11/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/11/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/11/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/11/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/11/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/11/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/11/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/11/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/12/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/12/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/12/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/12/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/12/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/12/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/12/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/12/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/12/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/12/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/12/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/12/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/12/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/12/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/12/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/12/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/12/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/12/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/12/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/12/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/12/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/12/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/12/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/12/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/13/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/13/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/13/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/13/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/13/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/13/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/13/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/13/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/13/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/13/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/13/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/13/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/13/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/13/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/13/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/13/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/13/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/13/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/13/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/13/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/13/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/13/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/13/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/13/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/14/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/14/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/14/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/14/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/14/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/14/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/14/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/14/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/14/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/14/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/14/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/14/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/14/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/14/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/14/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/14/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/14/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/14/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/14/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/14/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/14/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/14/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/14/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/14/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/15/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/15/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/15/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/15/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/15/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/15/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/15/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/15/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/15/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/15/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/15/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/15/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/15/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/15/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/15/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/15/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/15/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/15/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/15/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/15/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/15/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/15/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/15/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/15/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/16/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/16/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/16/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/16/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/16/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/16/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/16/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/16/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/16/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/16/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/16/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/16/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/16/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/16/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/16/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/16/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/16/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/16/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/16/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/16/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/16/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/16/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/16/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/16/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/17/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/17/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/17/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/17/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/17/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/17/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/17/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/17/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/17/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/17/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/17/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/17/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/17/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/17/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/17/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/17/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/17/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/17/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/17/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/17/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/17/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/17/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/17/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/17/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/18/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/18/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/18/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/18/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/18/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/18/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/18/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/18/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/18/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/18/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/18/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/18/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/18/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/18/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/18/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/18/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/18/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/18/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/18/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/18/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/18/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/18/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/18/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/18/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/19/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/19/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/19/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/19/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/19/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/19/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/19/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/19/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/19/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/19/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/19/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/19/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/19/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/19/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/19/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/19/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/19/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/19/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/19/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/19/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/19/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/19/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/19/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/19/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/20/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/20/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/20/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/20/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/20/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/20/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/20/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/20/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/20/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/20/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/20/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/20/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/20/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/20/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/20/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/20/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/20/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/20/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/20/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/20/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/20/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/20/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/20/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/20/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/21/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/21/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/21/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/21/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/21/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/21/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/21/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/21/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/21/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/21/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/21/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/21/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/21/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/21/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/21/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/21/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/21/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/21/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/21/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/21/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/21/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/21/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/21/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/21/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/22/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/22/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/22/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/22/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/22/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/22/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/22/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/22/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/22/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/22/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/22/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/22/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/22/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/22/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/22/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/22/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/22/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/22/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/22/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/22/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/22/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/22/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/22/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/22/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/23/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/23/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/23/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/23/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/23/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/23/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/23/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/23/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/23/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/23/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/23/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/23/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/23/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/23/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/23/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/23/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/23/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/23/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/23/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/23/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/23/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/23/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/23/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/23/21 23:00	0			0			18		1	0	X		0	X		0	X	1
01/24/21 0:00	0.8			1.6			14.4		1	0	X		0	X		0	X	1
01/24/21 1:00	0.8			1.7			14.4		1	0	X		0	X		0	X	1
01/24/21 2:00	0.9			1.7			14.2		1	0	X		0	X		0	X	1
01/24/21 3:00	0.9			1.7			14.2		1	0	X		0	X		0	X	1
01/24/21 4:00	0.8			1.7			14.2		1	0	X		0	X		0	X	1
01/24/21 5:00	0.8			1.7			14.3		1	0	X		0	X		0	X	1
01/24/21 6:00	0.8			1.7			14.2		1	0	X		0	X		0	X	1
01/24/21 7:00	0.8			1.7			14.2		1	0	X		0	X		0	X	1
01/24/21 8:00	0.8			1.7			14.2		1	0	X		0	X		0	X	1
01/24/21 9:00	0.8			1.7			14.3		1	0	X		0	X		0	X	1
01/24/21 10:00	0.8			1.7			14.3		1	0	X		0	X		0	X	1
01/24/21 11:00	0.8			1.7			14.3		1	0	X		0	X		0	X	1
01/24/21 12:00	0.7			1.7			14.4		1	0	X		0	X		0	X	1
01/24/21 13:00	0.7			1.7			14.4		1	0	X		0	X		0	X	1
01/24/21 14:00	0.7			1.7			14.4		1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/24/21 15:00	0.6			1.7			14.5		1	0	X		0	X		0	X	1
01/24/21 16:00	1			1.7			14		1	0	X		0	X		0	X	1
01/24/21 17:00	1.2			1.7			14.1		1	0	X		0	X		0	X	1
01/24/21 18:00	1.1			1.7			13.8		1	0	X		0	X		0	X	1
01/24/21 19:00	1			1.7			14		1	0	X		0	X		0	X	1
01/24/21 20:00	0.7			1.7			14.4		1	0	X		0	X		0	X	1
01/24/21 21:00	0.7			1.7			14.3		1	0	X		0	X		0	X	1
01/24/21 22:00	0.7			1.7			14.4		1	0	X		0	X		0	X	1
01/24/21 23:00	0.8			1.7			14.2		1	0	X		0	X		0	X	1
01/25/21 0:00	0.8			1.7			14.2		1	0	X		0	X		0	X	1
01/25/21 1:00	0.8			1.7			14.2		1	0	X		0	X		0	X	1
01/25/21 2:00	0.8			1.7			14.2		1	0	X		0	X		0	X	1
01/25/21 3:00	0.9			1.7			14.2		1	0	X		0	X		0	X	1
01/25/21 4:00	0.8			1.7			14.2		1	0	X		0	X		0	X	1
01/25/21 5:00	0.7			1.7			14.4		1	0	X		0	X		0	X	1
01/25/21 6:00	0.8			1.7			14.4		1	0	X		0	X		0	X	1
01/25/21 7:00	0.7			1.7			13.3		1	0	X		0	X		0	X	1
01/25/21 8:00	0.2			1.7			12.4		1	0	X		0	X		0	X	1
01/25/21 9:00	0.1			1.7			12		1	0	X		0	X		0	X	1
01/25/21 10:00	0.4			1.7			12.8		1	0	X		0	X		0	X	1
01/25/21 11:00	0.5			1.7			13.1		1	0	X		0	X		0	X	1
01/25/21 12:00	0.9			1.7			13.6		1	0	X		0	X		0	X	1
01/25/21 13:00	1			1.7			13.9		1	0	X		0	X		0	X	1
01/25/21 14:00	1			1.7			13.9		1	0	X		0	X		0	X	1
01/25/21 15:00	1.1			1.7			14		1	0	X		0	X		0	X	1
01/25/21 16:00	0.5			1.7			13		1	0	X		0	X		0	X	1
01/25/21 17:00	0.9			1.7			13.7		1	0	X		0	X		0	X	1
01/25/21 18:00	0.1			1.7			12		1	0	X		0	X		0	X	1
01/25/21 19:00	0.1			1.7			12		1	0	X		0	X		0	X	1
01/25/21 20:00	0.2			1.7			12.3		1	0	X		0	X		0	X	1
01/25/21 21:00	0.6			1.7			13.3		1	0	X		0	X		0	X	1
01/25/21 22:00	0.8			1.8			14.4		1	0	X		0	X		0	X	1
01/25/21 23:00	0.7			1.7			14.3		1	0	X		0	X		0	X	1
01/26/21 0:00	0			0			14.3		1	0	X		0	X		0	X	1
01/26/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/26/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/26/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/26/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/26/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/26/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/26/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/26/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/26/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/26/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/26/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/26/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/26/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/26/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/26/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/26/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/26/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/26/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/26/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/26/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/26/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/26/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/26/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/27/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/27/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/27/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/27/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/27/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/27/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/27/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/27/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/27/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/27/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/27/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/27/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/27/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/27/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/27/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/27/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/27/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/27/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/27/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/27/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/27/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/27/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/27/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/27/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/28/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/28/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/28/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/28/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/28/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/28/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/28/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/28/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/28/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/28/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/28/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/28/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/28/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/28/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/28/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/28/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/28/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/28/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/28/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/28/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/28/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/28/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/28/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/28/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/29/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/29/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/29/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/29/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/29/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/29/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/29/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/29/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/29/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/29/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/29/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/29/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/29/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/29/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/29/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/29/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/29/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/29/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/29/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/29/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/29/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/29/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/29/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/29/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/30/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/30/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/30/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/30/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/30/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/30/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/30/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/30/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/30/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/30/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/30/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/30/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/30/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/30/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/30/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/30/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/30/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/30/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/30/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/30/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/30/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/30/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/30/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/30/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/31/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/31/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/31/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/31/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/31/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/31/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/31/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/31/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/31/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/31/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/31/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/31/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/31/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/31/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/31/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/31/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/31/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/31/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/31/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/31/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/31/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/31/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/31/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
01/31/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/01/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/01/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/01/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/01/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/01/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/01/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/01/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/01/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/01/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/01/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/01/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/01/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/01/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/01/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/01/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/01/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/01/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/01/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/01/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/01/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/01/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/01/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/01/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/01/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/02/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/02/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/02/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/02/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/02/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/02/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/02/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/02/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/02/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/02/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/02/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/02/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/02/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/02/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/02/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/02/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/02/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/02/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/02/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/02/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/02/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/02/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/02/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/02/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/03/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/03/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/03/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/03/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/03/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/03/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/03/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/03/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/03/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/03/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/03/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/03/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/03/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/03/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/03/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/03/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/03/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/03/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/03/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/03/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/03/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/03/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/03/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/03/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/04/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/04/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/04/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/04/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/04/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/04/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/04/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/04/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/04/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/04/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/04/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/04/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/04/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/04/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/04/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/04/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/04/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/04/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/04/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/04/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/04/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/04/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/04/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/04/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/05/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/05/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/05/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/05/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/05/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/05/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/05/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/05/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/05/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/05/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/05/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/05/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/05/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/05/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/05/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/05/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/05/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/05/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/05/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/05/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/05/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/05/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/05/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/05/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/06/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/06/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/06/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/06/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/06/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/06/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/06/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/06/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/06/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/06/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/06/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/06/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/06/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/06/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/06/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/06/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/06/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/06/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/06/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/06/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/06/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/06/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/06/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/06/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/07/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/07/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/07/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/07/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/07/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/07/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/07/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/07/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/07/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/07/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/07/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/07/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/07/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/07/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/07/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/07/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/07/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/07/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/07/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/07/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/07/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/07/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/07/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/07/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/08/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/08/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/08/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/08/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/08/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/08/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/08/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/08/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/08/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/08/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/08/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/08/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/08/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/08/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/08/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/08/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/08/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/08/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/08/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/08/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/08/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/08/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/08/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/08/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/09/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/09/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/09/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/09/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/09/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/09/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/09/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/09/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/09/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/09/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/09/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/09/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/09/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/09/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/09/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/09/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/09/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/09/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/09/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/09/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/09/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/09/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/09/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/09/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/10/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/10/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/10/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/10/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/10/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/10/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/10/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/10/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/10/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/10/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/10/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/10/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/10/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/10/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/10/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/10/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/10/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/10/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/10/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/10/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/10/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/10/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/10/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/10/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/11/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/11/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/11/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/11/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/11/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/11/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/11/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/11/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/11/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/11/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/11/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/11/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/11/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/11/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/11/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/11/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/11/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/11/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/11/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/11/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/11/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/11/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/11/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/11/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/12/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/12/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/12/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/12/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/12/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/12/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/12/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/12/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/12/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/12/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/12/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/12/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/12/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/12/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/12/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/12/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/12/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/12/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/12/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/12/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/12/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/12/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/12/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/12/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/13/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/13/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/13/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/13/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/13/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/13/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/13/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/13/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/13/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/13/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/13/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/13/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/13/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/13/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/13/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/13/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/13/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/13/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/13/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/13/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/13/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/13/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/13/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/13/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/14/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/14/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/14/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/14/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/14/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/14/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/14/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/14/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/14/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/14/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/14/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/14/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/14/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/14/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/14/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/14/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/14/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/14/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/14/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/14/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/14/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/14/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/14/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/14/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/15/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/15/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/15/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/15/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/15/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/15/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/15/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/15/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/15/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/15/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/15/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/15/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/15/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/15/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/15/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/15/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/15/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/15/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/15/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/15/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/15/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/15/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/15/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/15/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/16/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/16/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/16/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/16/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/16/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/16/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/16/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/16/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/16/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/16/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/16/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/16/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/16/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/16/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/16/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/16/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/16/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/16/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/16/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/16/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/16/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/16/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/16/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/16/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/17/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/17/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/17/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/17/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/17/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/17/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/17/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/17/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/17/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/17/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/17/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/17/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/17/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/17/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/17/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/17/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/17/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/17/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/17/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/17/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/17/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/17/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/17/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/17/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/18/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/18/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/18/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/18/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/18/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/18/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/18/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/18/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/18/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/18/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/18/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/18/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/18/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/18/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/18/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/18/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/18/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/18/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/18/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/18/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/18/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/18/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/18/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/18/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/19/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/19/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/19/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/19/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/19/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/19/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/19/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/19/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/19/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/19/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/19/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/19/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/19/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/19/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/19/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/19/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/19/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/19/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/19/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/19/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/19/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/19/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/19/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/19/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/20/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/20/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/20/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/20/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/20/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/20/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/20/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/20/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/20/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/20/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/20/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/20/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/20/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/20/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/20/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/20/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/20/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/20/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/20/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/20/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/20/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/20/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/20/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/20/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/21/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/21/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/21/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/21/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/21/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/21/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/21/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/21/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/21/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/21/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/21/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/21/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/21/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/21/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/21/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/21/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/21/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/21/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/21/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/21/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/21/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/21/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/21/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/21/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/22/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/22/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/22/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/22/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/22/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/22/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/22/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/22/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/22/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/22/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/22/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/22/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/22/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/22/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/22/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/22/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/22/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/22/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/22/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/22/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/22/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/22/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/22/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/22/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/23/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/23/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/23/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/23/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/23/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/23/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/23/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/23/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/23/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/23/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/23/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/23/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/23/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/23/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/23/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/23/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/23/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/23/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/23/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/23/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/23/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/23/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/23/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/23/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/24/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/24/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/24/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/24/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/24/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/24/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/24/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/24/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/24/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/24/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/24/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/24/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/24/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/24/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/24/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/24/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/24/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/24/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/24/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/24/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/24/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/24/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/24/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/24/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/25/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/25/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/25/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/25/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/25/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/25/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/25/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/25/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/25/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/25/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/25/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/25/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/25/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/25/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/25/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/25/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/25/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/25/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/25/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/25/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/25/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/25/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/25/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/25/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/26/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/26/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/26/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/26/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/26/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/26/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/26/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/26/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/26/21 8:00	0	X		0	X		0	X	1	0			0			17		1
02/26/21 9:00	0	X		0	X		0	X	1	1			1.6			14.3		1
02/26/21 10:00	0	X		0	X		0	X	1	0.9			1.6			14.4		1
02/26/21 11:00	0	X		0	X		0	X	1	0.9			1.7			14.4		1
02/26/21 12:00	0	X		0	X		0	X	1	0.9			1.7			14.4		1
02/26/21 13:00	0	X		0	X		0	X	1	0.9			1.7			14.4		1
02/26/21 14:00	0	X		0	X		0	X	1	0.9			1.6			14.9		1
02/26/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/26/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/26/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/26/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/26/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/26/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/26/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/26/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/26/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/27/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/27/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/27/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/27/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/27/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/27/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/27/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/27/21 7:00	0	X		0	X		0	X	1	0	X		0.5	X		0	X	1
02/27/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/27/21 9:00	0	X		0	X		0	X	1	0			0			17.7		1
02/27/21 10:00	0	X		0	X		0	X	1	0.9			1.6			14.3		1
02/27/21 11:00	0	X		0	X		0	X	1	0.8			1.7			14.3		1
02/27/21 12:00	0	X		0	X		0	X	1	0.8			1.7			14.4		1
02/27/21 13:00	0	X		0	X		0	X	1	0.8			1.4			14.5		1
02/27/21 14:00	0	X		0	X		0	X	1	0.8			1.8			14.5		1
02/27/21 15:00	0	X		0	X		0	X	1	0.9			1.7			14.4		1
02/27/21 16:00	0	X		0	X		0	X	1	0.9			1.8			14.4		1
02/27/21 17:00	0	X		0	X		0	X	1	0.7			1.6			14.6		1
02/27/21 18:00	0	X		0	X		0	X	1	0			0			17.7		1
02/27/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/27/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/27/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/27/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/27/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/28/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/28/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/28/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/28/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/28/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/28/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/28/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/28/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/28/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/28/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/28/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/28/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/28/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/28/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/28/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/28/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/28/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/28/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/28/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/28/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/28/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/28/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/28/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
02/28/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/01/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/01/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/01/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/01/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/01/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/01/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/01/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/01/21 7:00	0	X		0	X		0	X	1	0			0			18.1		1
03/01/21 8:00	0	X		0	X		0	X	1	0.8			1.5			14.2		1
03/01/21 9:00	0	X		0	X		0	X	1	0.8			1.7			14.3		1
03/01/21 10:00	0	X		0	X		0	X	1	0.8			1.7			14.3		1
03/01/21 11:00	0	X		0	X		0	X	1	0.7			1.7			14.4		1
03/01/21 12:00	0	X		0	X		0	X	1	0.8			1.7			14.4		1
03/01/21 13:00	0	X		0	X		0	X	1	0.8			1.7			14.4		1
03/01/21 14:00	0	X		0	X		0	X	1	0.7			2.1			14.6		1
03/01/21 15:00	0	X		0	X		0	X	1	0.5			1.6			14.8		1
03/01/21 16:00	0	X		0	X		0	X	1	0.7			1.2			14.6		1
03/01/21 17:00	0	X		0	X		0	X	1	0			0			17.2		1
03/01/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/01/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/01/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/01/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/01/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/01/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/02/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/02/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/02/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/02/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/02/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/02/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/02/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/02/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/02/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/02/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/02/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/02/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/02/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/02/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/02/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/02/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/02/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/02/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/02/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/02/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/02/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/02/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/02/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/02/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/03/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/03/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/03/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/03/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/03/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/03/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/03/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/03/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/03/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/03/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/03/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/03/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/03/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/03/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/03/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/03/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/03/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/03/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/03/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/03/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/03/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/03/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/03/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/03/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/04/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/04/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/04/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/04/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/04/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/04/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/04/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/04/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/04/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/04/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/04/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/04/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/04/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/04/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/04/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/04/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/04/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/04/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/04/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/04/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/04/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/04/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/04/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/04/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/05/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/05/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/05/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/05/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/05/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/05/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/05/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/05/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/05/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/05/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/05/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/05/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/05/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/05/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/05/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/05/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/05/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/05/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/05/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/05/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/05/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/05/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/05/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/05/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/06/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/06/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/06/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/06/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/06/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/06/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/06/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/06/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/06/21 8:00	0	X		0	X		0	X	1	0			0			16.2		1
03/06/21 9:00	0	X		0	X		0	X	1	0.7			1.6			14.3		1
03/06/21 10:00	0	X		0	X		0	X	1	11.8			3			14.7		1
03/06/21 11:00	0	X		0	X		0	X	1	0.5			1.4			14.7		1
03/06/21 12:00	0	X		0	X		0	X	1	0.8			1.7			14.3		1
03/06/21 13:00	0	X		0	X		0	X	1	0.7			1.7			14.3		1
03/06/21 14:00	0	X		0	X		0	X	1	0.8			1.7			14.3		1
03/06/21 15:00	0	X		0	X		0	X	1	0.8			1.7			14.2		1
03/06/21 16:00	0	X		0	X		0	X	1	0.8			1.7			14.2		1
03/06/21 17:00	0	X		0	X		0	X	1	0			0			15.9		1
03/06/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/06/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/06/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/06/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/06/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/06/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/07/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/07/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/07/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/07/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/07/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/07/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/07/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/07/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/07/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/07/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/07/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/07/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/07/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/07/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/07/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/07/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/07/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/07/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/07/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/07/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/07/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/07/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/07/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/07/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/08/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/08/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/08/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/08/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/08/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/08/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/08/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/08/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/08/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/08/21 9:00	0			0			19.6		1	0	X		0	X		0	X	1
03/08/21 10:00	0			0			19.1		1	0	X		0	X		0	X	1
03/08/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/08/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/08/21 13:00	0			0			19.8		1	0	X		0	X		0	X	1
03/08/21 14:00	0			0			18.4		1	0	X		0	X		0	X	1
03/08/21 15:00	1.1			1.7			14.3		1	0	X		0	X		0	X	1
03/08/21 16:00	1.1			1.7			14.3		1	0	X		0	X		0	X	1
03/08/21 17:00	0	X		0	X		0	X	0	0	X		0	X		0	X	1
03/08/21 18:00	1.1			1.7			14.2		1	0	X		0.1	X		0	X	1
03/08/21 19:00	1			1.7			14.2		1	0	X		0	X		0	X	1
03/08/21 20:00	0.9			1.3			15.4		1	0	X		0	X		0	X	1
03/08/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/08/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/08/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/09/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/09/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/09/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/09/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/09/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/09/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/09/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/09/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/09/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/09/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/09/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/09/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/09/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/09/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/09/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/09/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/09/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/09/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/09/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/09/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/09/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/09/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/09/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/09/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/10/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/10/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/10/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/10/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/10/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/10/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/10/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/10/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/10/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/10/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/10/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/10/21 11:00	0			0			17.9		1	0	X		0	X		0	X	1
03/10/21 12:00	0			0			15.3		1	0	X		0	X		0	X	1
03/10/21 13:00	0.7			2.8			14.8		1	0	X		0	X		0	X	1
03/10/21 14:00	1			1.7			14.2		1	0	X		0	X		0	X	1
03/10/21 15:00	0.9			1.7			14.2		1	0	X		0	X		0	X	1
03/10/21 16:00	0.9			1.7			14.3		1	0	X		0	X		0	X	1
03/10/21 17:00	0.9			1.7			14.2		1	0	X		0	X		0	X	1
03/10/21 18:00	1			1.7			14.2		1	0	X		0	X		0	X	1
03/10/21 19:00	1.1			1.3			15.1		1	0	X		0	X		0	X	1
03/10/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/10/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/10/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/10/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/11/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/11/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/11/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/11/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/11/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/11/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/11/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/11/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/11/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/11/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/11/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/11/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/11/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/11/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/11/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/11/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/11/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/11/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/11/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/11/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/11/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/11/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/11/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/11/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/12/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/12/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/12/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/12/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/12/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/12/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/12/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/12/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/12/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/12/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/12/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/12/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/12/21 12:00	0			0			20.6		1	0	X		0	X		0	X	1
03/12/21 13:00	0			0			20.1		1	0	X		0	X		0	X	1
03/12/21 14:00	0			0			15.8		1	0			0			20.9		1
03/12/21 15:00	0	X		0	X		0	X	1	0			0			20		1
03/12/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/12/21 17:00	0	X		0	X		0	X	1	0			0			19.8		1
03/12/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/12/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/12/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/12/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/12/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/12/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/13/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/13/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/13/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/13/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/13/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/13/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/13/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/13/21 7:00	0	X		0	X		0	X	0	0	X		0	X		0	X	1
03/13/21 8:00	0	X		0	X		0	X	0	0	X		0	X		0	X	1
03/13/21 9:00	0	X		0	X		0	X	0	0	X		0	X		0	X	1
03/13/21 10:00	0	X		0	X		0	X	0	0	X		0	X		0	X	1
03/13/21 11:00	0.9			2.6			14.5		1	0	X		0	X		0	X	0
03/13/21 12:00	0.9			1.7			14.4		1	0	X		0	X		0	X	0
03/13/21 13:00	1			1.7			14.4		1	0.9			1.5			14.3		1
03/13/21 14:00	0.4			1.7			11.9		1	0.4			1.6			11.8		1
03/13/21 15:00	0.3			1.7			11.6		1	0.3			1.7			11.7		1
03/13/21 16:00	0.3			1.7			11.6		1	0.3			1.7			11.7		1
03/13/21 17:00	0.8			1.8			13.7		1	0.7			1.7			13.7		1
03/13/21 18:00	0.9			1.4			15.5		1	0.4			4.4			15.1		1
03/13/21 19:00	0	X		0	X		0	X	1	0.7			1.7			14.4		1
03/13/21 20:00	0	X		0	X		0	X	1	0.8			1.3			14.3		1
03/13/21 21:00	0	X		0	X		0	X	1	0.8			1.8			14.3		1
03/13/21 22:00	0	X		0	X		0	X	1	0			0			15.6		1
03/13/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/14/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/14/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/14/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/14/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/14/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/14/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/14/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/14/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/14/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/14/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/14/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/14/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/14/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/14/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/14/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/14/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/14/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/14/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/14/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/14/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/14/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/14/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/14/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/14/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/15/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/15/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/15/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/15/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/15/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/15/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/15/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/15/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/15/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/15/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/15/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/15/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/15/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/15/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/15/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/15/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/15/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/15/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/15/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/15/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/15/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/15/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/15/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/15/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/16/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/16/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/16/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/16/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/16/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/16/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/16/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/16/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/16/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/16/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/16/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/16/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/16/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/16/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/16/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/16/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/16/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/16/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/16/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/16/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/16/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/16/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/16/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/16/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/17/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/17/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/17/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/17/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/17/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/17/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/17/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/17/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/17/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/17/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/17/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/17/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/17/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/17/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/17/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/17/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/17/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/17/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/17/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/17/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/17/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/17/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/17/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/17/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/18/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/18/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/18/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/18/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/18/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/18/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/18/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/18/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/18/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/18/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/18/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/18/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/18/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/18/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/18/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/18/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/18/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/18/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/18/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/18/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/18/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/18/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/18/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/18/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/19/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/19/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/19/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/19/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/19/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/19/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/19/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/19/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/19/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/19/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/19/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/19/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/19/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/19/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/19/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/19/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/19/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/19/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/19/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/19/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/19/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/19/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/19/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/19/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/20/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/20/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/20/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/20/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/20/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/20/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/20/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/20/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/20/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/20/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/20/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/20/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/20/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/20/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/20/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/20/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/20/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/20/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/20/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/20/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/20/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/20/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/20/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/20/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/21/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/21/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/21/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/21/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/21/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/21/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/21/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/21/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/21/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/21/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/21/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/21/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/21/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/21/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/21/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/21/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/21/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/21/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/21/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/21/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/21/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/21/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/21/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/21/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/22/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/22/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/22/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/22/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/22/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/22/21 5:00	0	X		0	X		0	X	1	0			0			17.4		1
03/22/21 6:00	0	X		0	X		0	X	1	0.5			1.3			14.7		1
03/22/21 7:00	0	X		0	X		0	X	1	0.5			1.8			14.7		1
03/22/21 8:00	0	X		0	X		0	X	1	0.8			1.8			15.3		1
03/22/21 9:00	0	X		0	X		0	X	1	0.7			1.7			14.3		1
03/22/21 10:00	0	X		0	X		0	X	1	0.6			1.7			14.4		1
03/22/21 11:00	0	X		0	X		0	X	1	0.8			1.7			13.4		1
03/22/21 12:00	0	X		0	X		0	X	1	0.4			1.7			12.2		1
03/22/21 13:00	0	X		0	X		0	X	1	1.1			1.8			13.9		1
03/22/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	0

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/22/21 15:00	0	X		0	X		0	X	1	0.8			0.5			14.3		1
03/22/21 16:00	0	X		0	X		0	X	1	0.6			1.7			14.5		1
03/22/21 17:00	0	X		0	X		0	X	1	0.6			1.7			14.6		1
03/22/21 18:00	0	X		0	X		0	X	1	0.6			1.7			14.6		1
03/22/21 19:00	0	X		0	X		0	X	1	0.6			1.7			14.5		1
03/22/21 20:00	0	X		0	X		0	X	1	0.6			1.7			14.5		1
03/22/21 21:00	0	X		0	X		0	X	1	0.6			1.7			14.5		1
03/22/21 22:00	0	X		0	X		0	X	1	0.6			1.7			14.5		1
03/22/21 23:00	0	X		0	X		0	X	1	0.7			1.7			14.5		1
03/23/21 0:00	0	X		0	X		0	X	1	0.6			1.7			14.5		1
03/23/21 1:00	0	X		0	X		0	X	1	0.6			1.7			14.5		1
03/23/21 2:00	0	X		0	X		0	X	1	0.6			1.7			14.5		1
03/23/21 3:00	0	X		0	X		0	X	1	0.6			1.7			14.5		1
03/23/21 4:00	0	X		0	X		0	X	1	0.6			1.7			14.5		1
03/23/21 5:00	0	X		0	X		0	X	1	0.6			1.7			14.5		1
03/23/21 6:00	0	X		0	X		0	X	1	0.6			1.7			14.5		1
03/23/21 7:00	0	X		0	X		0	X	1	0.5			1.6			14.6		1
03/23/21 8:00	0	X		0	X		0	X	1	1.2			1.6			13.9		1
03/23/21 9:00	0			0			19.8		1	0.9			1.7			14.3		1
03/23/21 10:00	0			0			16.1		1	1.7			1.7			14.3		1
03/23/21 11:00	0.9			1.7			14.4		1	1.4			1.8			14		1
03/23/21 12:00	0.6			1.6			12.6		1	0.3			1.3			12.1		1
03/23/21 13:00	1			1.7			14.3		1	0.9			1.3			14.3		1
03/23/21 14:00	0.6			1.7			13		1	0			0			15.7		1
03/23/21 15:00	0.3			1.7			11.8		1	0	X		0	X		0	X	1
03/23/21 16:00	1			1.7			13.5		1	0	X		0	X		0	X	1
03/23/21 17:00	0.8			1.8			14.5		1	0	X		0	X		0	X	1
03/23/21 18:00	0.7			1.7			14.6		1	0	X		0	X		0	X	1
03/23/21 19:00	0.7			1.7			14.6		1	0	X		0	X		0	X	1
03/23/21 20:00	0.7			1.7			14.5		1	0	X		0	X		0	X	1
03/23/21 21:00	0.7			1.7			14.5		1	0	X		0	X		0	X	1
03/23/21 22:00	0.7			1.7			14.5		1	0	X		0	X		0	X	1
03/23/21 23:00	0.7			1.7			14.6		1	0	X		0	X		0	X	1
03/24/21 0:00	0.7			1.7			14.6		1	0	X		0	X		0	X	1
03/24/21 1:00	0.7			1.7			14.6		1	0	X		0	X		0	X	1
03/24/21 2:00	0.7			1.7			14.6		1	0	X		0	X		0	X	1
03/24/21 3:00	0.7			1.7			14.6		1	0	X		0	X		0	X	1
03/24/21 4:00	0.7			1.7			14.6		1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/24/21 5:00	0.8			1.8			14.6		1	0	X		0	X		0	X	1
03/24/21 6:00	0.7			1.7			14.6		1	0	X		0	X		0	X	1
03/24/21 7:00	0.8			1.5			14.4		1	0	X		0	X		0	X	1
03/24/21 8:00	0.9			1			12.9		1	0			0			18		1
03/24/21 9:00	0.9			1.4			14.3		1	0.8			1.4			14.2		1
03/24/21 10:00	0.7			1.9			12.5		1	0.4			1.7			12.1		1
03/24/21 11:00	0.9			1.8			14.4		1	0.8			1.8			14.2		1
03/24/21 12:00	0			0			17.1		1	0.7			1.2			13.5		1
03/24/21 13:00	0	X		0	X		0	X	1	0.8			1.3			14.4		1
03/24/21 14:00	0	X		0	X		0	X	1	0.5			1.6			12.4		1
03/24/21 15:00	0	X		0	X		0	X	1	0.7			1.8			14.5		1
03/24/21 16:00	0	X		0	X		0	X	1	0			0			16.8		1
03/24/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/24/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/24/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/24/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/24/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/24/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/24/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/25/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/25/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/25/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/25/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/25/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/25/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/25/21 6:00	0	X		0	X		0	X	1	0			0			17.9		1
03/25/21 7:00	0	X		0	X		0	X	1	0.9			1.6			14.2		1
03/25/21 8:00	0	X		0	X		0	X	1	0.9			1.7			14.2		1
03/25/21 9:00	0	X		0	X		0	X	1	0.9			1.8			14.2		1
03/25/21 10:00	0	X		0	X		0	X	1	0.9			1.6			14.2		1
03/25/21 11:00	0	X		0	X		0	X	1	0.9			2.1			15.2		1
03/25/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/25/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/25/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/25/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/25/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/25/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/25/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/25/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/25/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/25/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/25/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/25/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/26/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/27/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/27/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/28/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/28/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/29/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/30/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/30/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/21 0:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/21 1:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/21 2:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/21 3:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/21 4:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/21 5:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/21 6:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/21 7:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/21 8:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/21 9:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/21 10:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/21 11:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/21 12:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/21 13:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/21 14:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/21 15:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/21 16:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/21 17:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/21 18:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/21 19:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/21 20:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/21 21:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/21 22:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1
03/31/21 23:00	0	X		0	X		0	X	1	0	X		0	X		0	X	1

AQ-33

AQ-33 The Project owner shall maintain records of Sox lb/hr, lb/day, and lb, quarter emissions. Sox emissions shall be based on fuel use records, natural gas sulfur content, and mass balance calculations.

Verification: The Project owner shall submit to the CPM all hourly, daily, and quarterly Sox emissions as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

Tons 12 Month Rolling Summary

CT1 and CT2 Combined



From: 01/01/2021 00:00 **To:** 03/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2021 14:44 **Location:** Roseville, CA

* = Excess Emission

Date	Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2	
	CO, Ton		NOx, Ton		PM10, Ton		SO2, Ton		VOC, Ton	
	1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)	
	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum
Jan 2021	0.0375	2.3537	0.0714	7.4988	0.0127	1.4139	0.0064	0.7071	0.0212	2.3550
Feb 2021	0.1878	2.3603	0.0376	7.1818	0.0038	1.3539	0.0019	0.6771	0.0064	2.2550
Mar 2021	0.4389	2.7992	0.2429	7.4247	0.0306	1.3845	0.0155	0.6926	0.0512	2.3062
Sum/Avg	2.7992		7.4247		1.3845		0.6926		2.3062	
Limit Value										

AQ33 DAILY SOX

Date/Time	CT1_SO2_Lb_1D			CT2_SO2_Lb_1D														
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/01/21 0:00	0			0														
01/02/21 0:00	0			0														
01/03/21 0:00	0			0														
01/04/21 0:00	0			0														
01/05/21 0:00	0			0														
01/06/21 0:00	0			0														
01/07/21 0:00	0			0														
01/08/21 0:00	0			0														
01/09/21 0:00	0			0														
01/10/21 0:00	0			0														
01/11/21 0:00	0			0														
01/12/21 0:00	0			0														
01/13/21 0:00	0			0														
01/14/21 0:00	0			0														
01/15/21 0:00	0			0														
01/16/21 0:00	0			0														
01/17/21 0:00	0			0														
01/18/21 0:00	0			0														
01/19/21 0:00	0			0														
01/20/21 0:00	0			0														
01/21/21 0:00	0			0														
01/22/21 0:00	0			0														
01/23/21 0:00	0			0														
01/24/21 0:00	5.6			0														
01/25/21 0:00	7.1			0														
01/26/21 0:00	0			0														
01/27/21 0:00	0			0														
01/28/21 0:00	0			0														
01/29/21 0:00	0			0														
01/30/21 0:00	0			0														
01/31/21 0:00	0			0														
02/01/21 0:00	0			0														
02/02/21 0:00	0			0														
02/03/21 0:00	0			0														
02/04/21 0:00	0			0														

Date/Time	CT1_SO2_Lb_1D			CT2_SO2_Lb_1D														
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/05/21 0:00	0			0														
02/06/21 0:00	0			0														
02/07/21 0:00	0			0														
02/08/21 0:00	0			0														
02/09/21 0:00	0			0														
02/10/21 0:00	0			0														
02/11/21 0:00	0			0														
02/12/21 0:00	0			0														
02/13/21 0:00	0			0														
02/14/21 0:00	0			0														
02/15/21 0:00	0			0														
02/16/21 0:00	0			0														
02/17/21 0:00	0			0														
02/18/21 0:00	0			0														
02/19/21 0:00	0			0														
02/20/21 0:00	0			0														
02/21/21 0:00	0			0														
02/22/21 0:00	0			0														
02/23/21 0:00	0			0														
02/24/21 0:00	0			0														
02/25/21 0:00	0			0														
02/26/21 0:00	0			1.6														
02/27/21 0:00	0			2.2														
02/28/21 0:00	0			0														
03/01/21 0:00	0			2.3														
03/02/21 0:00	0			0														
03/03/21 0:00	0			0														
03/04/21 0:00	0			0														
03/05/21 0:00	0			0														
03/06/21 0:00	0			2.2														
03/07/21 0:00	0			0														
03/08/21 0:00	1.4			0														
03/09/21 0:00	0			0														
03/10/21 0:00	1.8			0														
03/11/21 0:00	0			0														
03/12/21 0:00	0.1			0														
03/13/21 0:00	2.8			3														
03/14/21 0:00	0			0														

Date/Time	CT1_SO2_Lb_1D			CT2_SO2_Lb_1D														
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/15/21 0:00	0			0														
03/16/21 0:00	0			0														
03/17/21 0:00	0			0														
03/18/21 0:00	0			0														
03/19/21 0:00	0			0														
03/20/21 0:00	0			0														
03/21/21 0:00	0			0														
03/22/21 0:00	0			4.5														
03/23/21 0:00	3.5			3.5														
03/24/21 0:00	2.8			2.1														
03/25/21 0:00	0			1														
03/26/21 0:00	0			0														
03/27/21 0:00	0			0														
03/28/21 0:00	0			0														
03/29/21 0:00	0			0														
03/30/21 0:00	0			0														
03/31/21 0:00	0			0														
04/01/21 0:00	0	X		0	X													

AQ33 HOURLY SOX

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
01/01/21 0:00	0	X		0	X		0											
01/01/21 1:00	0	X		0	X		0											
01/01/21 2:00	0	X		0	X		0											
01/01/21 3:00	0	X		0	X		0											
01/01/21 4:00	0	X		0	X		0											
01/01/21 5:00	0	X		0	X		0											
01/01/21 6:00	0	X		0	X		0											
01/01/21 7:00	0	X		0	X		0											
01/01/21 8:00	0	X		0	X		0											
01/01/21 9:00	0	X		0	X		0											
01/01/21 10:00	0	X		0	X		0											
01/01/21 11:00	0	X		0	X		0											
01/01/21 12:00	0	X		0	X		0											
01/01/21 13:00	0	X		0	X		0											
01/01/21 14:00	0	X		0	X		0											
01/01/21 15:00	0	X		0	X		0											
01/01/21 16:00	0	X		0	X		0											
01/01/21 17:00	0	X		0	X		0											
01/01/21 18:00	0	X		0	X		0											
01/01/21 19:00	0	X		0	X		0											
01/01/21 20:00	0	X		0	X		0											
01/01/21 21:00	0	X		0	X		0											
01/01/21 22:00	0	X		0	X		0											
01/01/21 23:00	0	X		0	X		0											
01/02/21 0:00	0	X		0	X		0											
01/02/21 1:00	0	X		0	X		0											
01/02/21 2:00	0	X		0	X		0											
01/02/21 3:00	0	X		0	X		0											
01/02/21 4:00	0	X		0	X		0											
01/02/21 5:00	0	X		0	X		0											
01/02/21 6:00	0	X		0	X		0											
01/02/21 7:00	0	X		0	X		0											
01/02/21 8:00	0	X		0	X		0											
01/02/21 9:00	0	X		0	X		0											
01/02/21 10:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/02/21 11:00	0	X		0	X		0											
01/02/21 12:00	0	X		0	X		0											
01/02/21 13:00	0	X		0	X		0											
01/02/21 14:00	0	X		0	X		0											
01/02/21 15:00	0	X		0	X		0											
01/02/21 16:00	0	X		0	X		0											
01/02/21 17:00	0	X		0	X		0											
01/02/21 18:00	0	X		0	X		0											
01/02/21 19:00	0	X		0	X		0											
01/02/21 20:00	0	X		0	X		0											
01/02/21 21:00	0	X		0	X		0											
01/02/21 22:00	0	X		0	X		0											
01/02/21 23:00	0	X		0	X		0											
01/03/21 0:00	0	X		0	X		0											
01/03/21 1:00	0	X		0	X		0											
01/03/21 2:00	0	X		0	X		0											
01/03/21 3:00	0	X		0	X		0											
01/03/21 4:00	0	X		0	X		0											
01/03/21 5:00	0	X		0	X		0											
01/03/21 6:00	0	X		0	X		0											
01/03/21 7:00	0	X		0	X		0											
01/03/21 8:00	0	X		0	X		0											
01/03/21 9:00	0	X		0	X		0											
01/03/21 10:00	0	X		0	X		0											
01/03/21 11:00	0	X		0	X		0											
01/03/21 12:00	0	X		0	X		0											
01/03/21 13:00	0	X		0	X		0											
01/03/21 14:00	0	X		0	X		0											
01/03/21 15:00	0	X		0	X		0											
01/03/21 16:00	0	X		0	X		0											
01/03/21 17:00	0	X		0	X		0											
01/03/21 18:00	0	X		0	X		0											
01/03/21 19:00	0	X		0	X		0											
01/03/21 20:00	0	X		0	X		0											
01/03/21 21:00	0	X		0	X		0											
01/03/21 22:00	0	X		0	X		0											
01/03/21 23:00	0	X		0	X		0											
01/04/21 0:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
01/04/21 1:00	0	X		0	X		0											
01/04/21 2:00	0	X		0	X		0											
01/04/21 3:00	0	X		0	X		0											
01/04/21 4:00	0	X		0	X		0											
01/04/21 5:00	0	X		0	X		0											
01/04/21 6:00	0	X		0	X		0											
01/04/21 7:00	0	X		0	X		0											
01/04/21 8:00	0	X		0	X		0											
01/04/21 9:00	0	X		0	X		0											
01/04/21 10:00	0	X		0	X		0											
01/04/21 11:00	0	X		0	X		0											
01/04/21 12:00	0	X		0	X		0											
01/04/21 13:00	0	X		0	X		0											
01/04/21 14:00	0	X		0	X		0											
01/04/21 15:00	0	X		0	X		0											
01/04/21 16:00	0	X		0	X		0											
01/04/21 17:00	0	X		0	X		0											
01/04/21 18:00	0	X		0	X		0											
01/04/21 19:00	0	X		0	X		0											
01/04/21 20:00	0	X		0	X		0											
01/04/21 21:00	0	X		0	X		0											
01/04/21 22:00	0	X		0	X		0											
01/04/21 23:00	0	X		0	X		0											
01/05/21 0:00	0	X		0	X		0											
01/05/21 1:00	0	X		0	X		0											
01/05/21 2:00	0	X		0	X		0											
01/05/21 3:00	0	X		0	X		0											
01/05/21 4:00	0	X		0	X		0											
01/05/21 5:00	0	X		0	X		0											
01/05/21 6:00	0	X		0	X		0											
01/05/21 7:00	0	X		0	X		0											
01/05/21 8:00	0	X		0	X		0											
01/05/21 9:00	0	X		0	X		0											
01/05/21 10:00	0	X		0	X		0											
01/05/21 11:00	0	X		0	X		0											
01/05/21 12:00	0	X		0	X		0											
01/05/21 13:00	0	X		0	X		0											
01/05/21 14:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/05/21 15:00	0	X		0	X		0											
01/05/21 16:00	0	X		0	X		0											
01/05/21 17:00	0	X		0	X		0											
01/05/21 18:00	0	X		0	X		0											
01/05/21 19:00	0	X		0	X		0											
01/05/21 20:00	0	X		0	X		0											
01/05/21 21:00	0	X		0	X		0											
01/05/21 22:00	0	X		0	X		0											
01/05/21 23:00	0	X		0	X		0											
01/06/21 0:00	0	X		0	X		0											
01/06/21 1:00	0	X		0	X		0											
01/06/21 2:00	0	X		0	X		0											
01/06/21 3:00	0	X		0	X		0											
01/06/21 4:00	0	X		0	X		0											
01/06/21 5:00	0	X		0	X		0											
01/06/21 6:00	0	X		0	X		0											
01/06/21 7:00	0	X		0	X		0											
01/06/21 8:00	0	X		0	X		0											
01/06/21 9:00	0	X		0	X		0											
01/06/21 10:00	0	X		0	X		0											
01/06/21 11:00	0	X		0	X		0											
01/06/21 12:00	0	X		0	X		0											
01/06/21 13:00	0	X		0	X		0											
01/06/21 14:00	0	X		0	X		0											
01/06/21 15:00	0	X		0	X		0											
01/06/21 16:00	0	X		0	X		0											
01/06/21 17:00	0	X		0	X		0											
01/06/21 18:00	0	X		0	X		0											
01/06/21 19:00	0	X		0	X		0											
01/06/21 20:00	0	X		0	X		0											
01/06/21 21:00	0	X		0	X		0											
01/06/21 22:00	0	X		0	X		0											
01/06/21 23:00	0	X		0	X		0											
01/07/21 0:00	0	X		0	X		0											
01/07/21 1:00	0	X		0	X		0											
01/07/21 2:00	0	X		0	X		0											
01/07/21 3:00	0	X		0	X		0											
01/07/21 4:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/07/21 5:00	0	X		0	X		0											
01/07/21 6:00	0	X		0	X		0											
01/07/21 7:00	0	X		0	X		0											
01/07/21 8:00	0	X		0	X		0											
01/07/21 9:00	0	X		0	X		0											
01/07/21 10:00	0	X		0	X		0											
01/07/21 11:00	0	X		0	X		0											
01/07/21 12:00	0	X		0	X		0											
01/07/21 13:00	0	X		0	X		0											
01/07/21 14:00	0	X		0	X		0											
01/07/21 15:00	0	X		0	X		0											
01/07/21 16:00	0	X		0	X		0											
01/07/21 17:00	0	X		0	X		0											
01/07/21 18:00	0	X		0	X		0											
01/07/21 19:00	0	X		0	X		0											
01/07/21 20:00	0	X		0	X		0											
01/07/21 21:00	0	X		0	X		0											
01/07/21 22:00	0	X		0	X		0											
01/07/21 23:00	0	X		0	X		0											
01/08/21 0:00	0	X		0	X		0											
01/08/21 1:00	0	X		0	X		0											
01/08/21 2:00	0	X		0	X		0											
01/08/21 3:00	0	X		0	X		0											
01/08/21 4:00	0	X		0	X		0											
01/08/21 5:00	0	X		0	X		0											
01/08/21 6:00	0	X		0	X		0											
01/08/21 7:00	0	X		0	X		0											
01/08/21 8:00	0	X		0	X		0											
01/08/21 9:00	0	X		0	X		0											
01/08/21 10:00	0	X		0	X		0											
01/08/21 11:00	0	X		0	X		0											
01/08/21 12:00	0	X		0	X		0											
01/08/21 13:00	0	X		0	X		0											
01/08/21 14:00	0	X		0	X		0											
01/08/21 15:00	0	X		0	X		0											
01/08/21 16:00	0	X		0	X		0											
01/08/21 17:00	0	X		0	X		0											
01/08/21 18:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/08/21 19:00	0	X		0	X		0											
01/08/21 20:00	0	X		0	X		0											
01/08/21 21:00	0	X		0	X		0											
01/08/21 22:00	0	X		0	X		0											
01/08/21 23:00	0	X		0	X		0											
01/09/21 0:00	0	X		0	X		0											
01/09/21 1:00	0	X		0	X		0											
01/09/21 2:00	0	X		0	X		0											
01/09/21 3:00	0	X		0	X		0											
01/09/21 4:00	0	X		0	X		0											
01/09/21 5:00	0	X		0	X		0											
01/09/21 6:00	0	X		0	X		0											
01/09/21 7:00	0	X		0	X		0											
01/09/21 8:00	0	X		0	X		0											
01/09/21 9:00	0	X		0	X		0											
01/09/21 10:00	0	X		0	X		0											
01/09/21 11:00	0	X		0	X		0											
01/09/21 12:00	0	X		0	X		0											
01/09/21 13:00	0	X		0	X		0											
01/09/21 14:00	0	X		0	X		0											
01/09/21 15:00	0	X		0	X		0											
01/09/21 16:00	0	X		0	X		0											
01/09/21 17:00	0	X		0	X		0											
01/09/21 18:00	0	X		0	X		0											
01/09/21 19:00	0	X		0	X		0											
01/09/21 20:00	0	X		0	X		0											
01/09/21 21:00	0	X		0	X		0											
01/09/21 22:00	0	X		0	X		0											
01/09/21 23:00	0	X		0	X		0											
01/10/21 0:00	0	X		0	X		0											
01/10/21 1:00	0	X		0	X		0											
01/10/21 2:00	0	X		0	X		0											
01/10/21 3:00	0	X		0	X		0											
01/10/21 4:00	0	X		0	X		0											
01/10/21 5:00	0	X		0	X		0											
01/10/21 6:00	0	X		0	X		0											
01/10/21 7:00	0	X		0	X		0											
01/10/21 8:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/10/21 9:00	0	X		0	X		0											
01/10/21 10:00	0	X		0	X		0											
01/10/21 11:00	0	X		0	X		0											
01/10/21 12:00	0	X		0	X		0											
01/10/21 13:00	0	X		0	X		0											
01/10/21 14:00	0	X		0	X		0											
01/10/21 15:00	0	X		0	X		0											
01/10/21 16:00	0	X		0	X		0											
01/10/21 17:00	0	X		0	X		0											
01/10/21 18:00	0	X		0	X		0											
01/10/21 19:00	0	X		0	X		0											
01/10/21 20:00	0	X		0	X		0											
01/10/21 21:00	0	X		0	X		0											
01/10/21 22:00	0	X		0	X		0											
01/10/21 23:00	0	X		0	X		0											
01/11/21 0:00	0	X		0	X		0											
01/11/21 1:00	0	X		0	X		0											
01/11/21 2:00	0	X		0	X		0											
01/11/21 3:00	0	X		0	X		0											
01/11/21 4:00	0	X		0	X		0											
01/11/21 5:00	0	X		0	X		0											
01/11/21 6:00	0	X		0	X		0											
01/11/21 7:00	0	X		0	X		0											
01/11/21 8:00	0	X		0	X		0											
01/11/21 9:00	0	X		0	X		0											
01/11/21 10:00	0	X		0	X		0											
01/11/21 11:00	0	X		0	X		0											
01/11/21 12:00	0	X		0	X		0											
01/11/21 13:00	0	X		0	X		0											
01/11/21 14:00	0	X		0	X		0											
01/11/21 15:00	0	X		0	X		0											
01/11/21 16:00	0	X		0	X		0											
01/11/21 17:00	0	X		0	X		0											
01/11/21 18:00	0	X		0	X		0											
01/11/21 19:00	0	X		0	X		0											
01/11/21 20:00	0	X		0	X		0											
01/11/21 21:00	0	X		0	X		0											
01/11/21 22:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
01/11/21 23:00	0	X		0	X		0											
01/12/21 0:00	0	X		0	X		0											
01/12/21 1:00	0	X		0	X		0											
01/12/21 2:00	0	X		0	X		0											
01/12/21 3:00	0	X		0	X		0											
01/12/21 4:00	0	X		0	X		0											
01/12/21 5:00	0	X		0	X		0											
01/12/21 6:00	0	X		0	X		0											
01/12/21 7:00	0	X		0	X		0											
01/12/21 8:00	0	X		0	X		0											
01/12/21 9:00	0	X		0	X		0											
01/12/21 10:00	0	X		0	X		0											
01/12/21 11:00	0	X		0	X		0											
01/12/21 12:00	0	X		0	X		0											
01/12/21 13:00	0	X		0	X		0											
01/12/21 14:00	0	X		0	X		0											
01/12/21 15:00	0	X		0	X		0											
01/12/21 16:00	0	X		0	X		0											
01/12/21 17:00	0	X		0	X		0											
01/12/21 18:00	0	X		0	X		0											
01/12/21 19:00	0	X		0	X		0											
01/12/21 20:00	0	X		0	X		0											
01/12/21 21:00	0	X		0	X		0											
01/12/21 22:00	0	X		0	X		0											
01/12/21 23:00	0	X		0	X		0											
01/13/21 0:00	0	X		0	X		0											
01/13/21 1:00	0	X		0	X		0											
01/13/21 2:00	0	X		0	X		0											
01/13/21 3:00	0	X		0	X		0											
01/13/21 4:00	0	X		0	X		0											
01/13/21 5:00	0	X		0	X		0											
01/13/21 6:00	0	X		0	X		0											
01/13/21 7:00	0	X		0	X		0											
01/13/21 8:00	0	X		0	X		0											
01/13/21 9:00	0	X		0	X		0											
01/13/21 10:00	0	X		0	X		0											
01/13/21 11:00	0	X		0	X		0											
01/13/21 12:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
01/13/21 13:00	0	X		0	X		0											
01/13/21 14:00	0	X		0	X		0											
01/13/21 15:00	0	X		0	X		0											
01/13/21 16:00	0	X		0	X		0											
01/13/21 17:00	0	X		0	X		0											
01/13/21 18:00	0	X		0	X		0											
01/13/21 19:00	0	X		0	X		0											
01/13/21 20:00	0	X		0	X		0											
01/13/21 21:00	0	X		0	X		0											
01/13/21 22:00	0	X		0	X		0											
01/13/21 23:00	0	X		0	X		0											
01/14/21 0:00	0	X		0	X		0											
01/14/21 1:00	0	X		0	X		0											
01/14/21 2:00	0	X		0	X		0											
01/14/21 3:00	0	X		0	X		0											
01/14/21 4:00	0	X		0	X		0											
01/14/21 5:00	0	X		0	X		0											
01/14/21 6:00	0	X		0	X		0											
01/14/21 7:00	0	X		0	X		0											
01/14/21 8:00	0	X		0	X		0											
01/14/21 9:00	0	X		0	X		0											
01/14/21 10:00	0	X		0	X		0											
01/14/21 11:00	0	X		0	X		0											
01/14/21 12:00	0	X		0	X		0											
01/14/21 13:00	0	X		0	X		0											
01/14/21 14:00	0	X		0	X		0											
01/14/21 15:00	0	X		0	X		0											
01/14/21 16:00	0	X		0	X		0											
01/14/21 17:00	0	X		0	X		0											
01/14/21 18:00	0	X		0	X		0											
01/14/21 19:00	0	X		0	X		0											
01/14/21 20:00	0	X		0	X		0											
01/14/21 21:00	0	X		0	X		0											
01/14/21 22:00	0	X		0	X		0											
01/14/21 23:00	0	X		0	X		0											
01/15/21 0:00	0	X		0	X		0											
01/15/21 1:00	0	X		0	X		0											
01/15/21 2:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/15/21 3:00	0	X		0	X		0											
01/15/21 4:00	0	X		0	X		0											
01/15/21 5:00	0	X		0	X		0											
01/15/21 6:00	0	X		0	X		0											
01/15/21 7:00	0	X		0	X		0											
01/15/21 8:00	0	X		0	X		0											
01/15/21 9:00	0	X		0	X		0											
01/15/21 10:00	0	X		0	X		0											
01/15/21 11:00	0	X		0	X		0											
01/15/21 12:00	0	X		0	X		0											
01/15/21 13:00	0	X		0	X		0											
01/15/21 14:00	0	X		0	X		0											
01/15/21 15:00	0	X		0	X		0											
01/15/21 16:00	0	X		0	X		0											
01/15/21 17:00	0	X		0	X		0											
01/15/21 18:00	0	X		0	X		0											
01/15/21 19:00	0	X		0	X		0											
01/15/21 20:00	0	X		0	X		0											
01/15/21 21:00	0	X		0	X		0											
01/15/21 22:00	0	X		0	X		0											
01/15/21 23:00	0	X		0	X		0											
01/16/21 0:00	0	X		0	X		0											
01/16/21 1:00	0	X		0	X		0											
01/16/21 2:00	0	X		0	X		0											
01/16/21 3:00	0	X		0	X		0											
01/16/21 4:00	0	X		0	X		0											
01/16/21 5:00	0	X		0	X		0											
01/16/21 6:00	0	X		0	X		0											
01/16/21 7:00	0	X		0	X		0											
01/16/21 8:00	0	X		0	X		0											
01/16/21 9:00	0	X		0	X		0											
01/16/21 10:00	0	X		0	X		0											
01/16/21 11:00	0	X		0	X		0											
01/16/21 12:00	0	X		0	X		0											
01/16/21 13:00	0	X		0	X		0											
01/16/21 14:00	0	X		0	X		0											
01/16/21 15:00	0	X		0	X		0											
01/16/21 16:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/16/21 17:00	0	X		0	X		0											
01/16/21 18:00	0	X		0	X		0											
01/16/21 19:00	0	X		0	X		0											
01/16/21 20:00	0	X		0	X		0											
01/16/21 21:00	0	X		0	X		0											
01/16/21 22:00	0	X		0	X		0											
01/16/21 23:00	0	X		0	X		0											
01/17/21 0:00	0	X		0	X		0											
01/17/21 1:00	0	X		0	X		0											
01/17/21 2:00	0	X		0	X		0											
01/17/21 3:00	0	X		0	X		0											
01/17/21 4:00	0	X		0	X		0											
01/17/21 5:00	0	X		0	X		0											
01/17/21 6:00	0	X		0	X		0											
01/17/21 7:00	0	X		0	X		0											
01/17/21 8:00	0	X		0	X		0											
01/17/21 9:00	0	X		0	X		0											
01/17/21 10:00	0	X		0	X		0											
01/17/21 11:00	0	X		0	X		0											
01/17/21 12:00	0	X		0	X		0											
01/17/21 13:00	0	X		0	X		0											
01/17/21 14:00	0	X		0	X		0											
01/17/21 15:00	0	X		0	X		0											
01/17/21 16:00	0	X		0	X		0											
01/17/21 17:00	0	X		0	X		0											
01/17/21 18:00	0	X		0	X		0											
01/17/21 19:00	0	X		0	X		0											
01/17/21 20:00	0	X		0	X		0											
01/17/21 21:00	0	X		0	X		0											
01/17/21 22:00	0	X		0	X		0											
01/17/21 23:00	0	X		0	X		0											
01/18/21 0:00	0	X		0	X		0											
01/18/21 1:00	0	X		0	X		0											
01/18/21 2:00	0	X		0	X		0											
01/18/21 3:00	0	X		0	X		0											
01/18/21 4:00	0	X		0	X		0											
01/18/21 5:00	0	X		0	X		0											
01/18/21 6:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
01/18/21 7:00	0	X		0	X		0											
01/18/21 8:00	0	X		0	X		0											
01/18/21 9:00	0	X		0	X		0											
01/18/21 10:00	0	X		0	X		0											
01/18/21 11:00	0	X		0	X		0											
01/18/21 12:00	0	X		0	X		0											
01/18/21 13:00	0	X		0	X		0											
01/18/21 14:00	0	X		0	X		0											
01/18/21 15:00	0	X		0	X		0											
01/18/21 16:00	0	X		0	X		0											
01/18/21 17:00	0	X		0	X		0											
01/18/21 18:00	0	X		0	X		0											
01/18/21 19:00	0	X		0	X		0											
01/18/21 20:00	0	X		0	X		0											
01/18/21 21:00	0	X		0	X		0											
01/18/21 22:00	0	X		0	X		0											
01/18/21 23:00	0	X		0	X		0											
01/19/21 0:00	0	X		0	X		0											
01/19/21 1:00	0	X		0	X		0											
01/19/21 2:00	0	X		0	X		0											
01/19/21 3:00	0	X		0	X		0											
01/19/21 4:00	0	X		0	X		0											
01/19/21 5:00	0	X		0	X		0											
01/19/21 6:00	0	X		0	X		0											
01/19/21 7:00	0	X		0	X		0											
01/19/21 8:00	0	X		0	X		0											
01/19/21 9:00	0	X		0	X		0											
01/19/21 10:00	0	X		0	X		0											
01/19/21 11:00	0	X		0	X		0											
01/19/21 12:00	0	X		0	X		0											
01/19/21 13:00	0	X		0	X		0											
01/19/21 14:00	0	X		0	X		0											
01/19/21 15:00	0	X		0	X		0											
01/19/21 16:00	0	X		0	X		0											
01/19/21 17:00	0	X		0	X		0											
01/19/21 18:00	0	X		0	X		0											
01/19/21 19:00	0	X		0	X		0											
01/19/21 20:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/19/21 21:00	0	X		0	X		0											
01/19/21 22:00	0	X		0	X		0											
01/19/21 23:00	0	X		0	X		0											
01/20/21 0:00	0	X		0	X		0											
01/20/21 1:00	0	X		0	X		0											
01/20/21 2:00	0	X		0	X		0											
01/20/21 3:00	0	X		0	X		0											
01/20/21 4:00	0	X		0	X		0											
01/20/21 5:00	0	X		0	X		0											
01/20/21 6:00	0	X		0	X		0											
01/20/21 7:00	0	X		0	X		0											
01/20/21 8:00	0	X		0	X		0											
01/20/21 9:00	0	X		0	X		0											
01/20/21 10:00	0	X		0	X		0											
01/20/21 11:00	0	X		0	X		0											
01/20/21 12:00	0	X		0	X		0											
01/20/21 13:00	0	X		0	X		0											
01/20/21 14:00	0	X		0	X		0											
01/20/21 15:00	0	X		0	X		0											
01/20/21 16:00	0	X		0	X		0											
01/20/21 17:00	0	X		0	X		0											
01/20/21 18:00	0	X		0	X		0											
01/20/21 19:00	0	X		0	X		0											
01/20/21 20:00	0	X		0	X		0											
01/20/21 21:00	0	X		0	X		0											
01/20/21 22:00	0	X		0	X		0											
01/20/21 23:00	0	X		0	X		0											
01/21/21 0:00	0	X		0	X		0											
01/21/21 1:00	0	X		0	X		0											
01/21/21 2:00	0	X		0	X		0											
01/21/21 3:00	0	X		0	X		0											
01/21/21 4:00	0	X		0	X		0											
01/21/21 5:00	0	X		0	X		0											
01/21/21 6:00	0	X		0	X		0											
01/21/21 7:00	0	X		0	X		0											
01/21/21 8:00	0	X		0	X		0											
01/21/21 9:00	0	X		0	X		0											
01/21/21 10:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/21/21 11:00	0	X		0	X		0											
01/21/21 12:00	0	X		0	X		0											
01/21/21 13:00	0	X		0	X		0											
01/21/21 14:00	0	X		0	X		0											
01/21/21 15:00	0	X		0	X		0											
01/21/21 16:00	0	X		0	X		0											
01/21/21 17:00	0	X		0	X		0											
01/21/21 18:00	0	X		0	X		0											
01/21/21 19:00	0	X		0	X		0											
01/21/21 20:00	0	X		0	X		0											
01/21/21 21:00	0	X		0	X		0											
01/21/21 22:00	0	X		0	X		0											
01/21/21 23:00	0	X		0	X		0											
01/22/21 0:00	0	X		0	X		0											
01/22/21 1:00	0	X		0	X		0											
01/22/21 2:00	0	X		0	X		0											
01/22/21 3:00	0	X		0	X		0											
01/22/21 4:00	0	X		0	X		0											
01/22/21 5:00	0	X		0	X		0											
01/22/21 6:00	0	X		0	X		0											
01/22/21 7:00	0	X		0	X		0											
01/22/21 8:00	0	X		0	X		0											
01/22/21 9:00	0	X		0	X		0											
01/22/21 10:00	0	X		0	X		0											
01/22/21 11:00	0	X		0	X		0											
01/22/21 12:00	0	X		0	X		0											
01/22/21 13:00	0	X		0	X		0											
01/22/21 14:00	0	X		0	X		0											
01/22/21 15:00	0	X		0	X		0											
01/22/21 16:00	0	X		0	X		0											
01/22/21 17:00	0	X		0	X		0											
01/22/21 18:00	0	X		0	X		0											
01/22/21 19:00	0	X		0	X		0											
01/22/21 20:00	0	X		0	X		0											
01/22/21 21:00	0	X		0	X		0											
01/22/21 22:00	0	X		0	X		0											
01/22/21 23:00	0	X		0	X		0											
01/23/21 0:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/23/21 1:00	0	X		0	X		0											
01/23/21 2:00	0	X		0	X		0											
01/23/21 3:00	0	X		0	X		0											
01/23/21 4:00	0	X		0	X		0											
01/23/21 5:00	0	X		0	X		0											
01/23/21 6:00	0	X		0	X		0											
01/23/21 7:00	0	X		0	X		0											
01/23/21 8:00	0	X		0	X		0											
01/23/21 9:00	0	X		0	X		0											
01/23/21 10:00	0	X		0	X		0											
01/23/21 11:00	0	X		0	X		0											
01/23/21 12:00	0	X		0	X		0											
01/23/21 13:00	0	X		0	X		0											
01/23/21 14:00	0	X		0	X		0											
01/23/21 15:00	0	X		0	X		0											
01/23/21 16:00	0	X		0	X		0											
01/23/21 17:00	0	X		0	X		0											
01/23/21 18:00	0	X		0	X		0											
01/23/21 19:00	0	X		0	X		0											
01/23/21 20:00	0	X		0	X		0											
01/23/21 21:00	0	X		0	X		0											
01/23/21 22:00	0	X		0	X		0											
01/23/21 23:00	0.0873			0	X		0.02											
01/24/21 0:00	0.2631			0	X		0.26											
01/24/21 1:00	0.25302			0	X		0.25											
01/24/21 2:00	0.21138			0	X		0.21											
01/24/21 3:00	0.20166			0	X		0.2											
01/24/21 4:00	0.20538			0	X		0.21											
01/24/21 5:00	0.21864			0	X		0.22											
01/24/21 6:00	0.1965			0	X		0.2											
01/24/21 7:00	0.19584			0	X		0.2											
01/24/21 8:00	0.1923			0	X		0.19											
01/24/21 9:00	0.20844			0	X		0.21											
01/24/21 10:00	0.2073			0	X		0.21											
01/24/21 11:00	0.2061			0	X		0.21											
01/24/21 12:00	0.23016			0	X		0.23											
01/24/21 13:00	0.22794			0	X		0.23											
01/24/21 14:00	0.24348			0	X		0.24											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H								
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/24/21 15:00	0.25704			0	X		0.26								
01/24/21 16:00	0.2865			0	X		0.29								
01/24/21 17:00	0.28356			0	X		0.28								
01/24/21 18:00	0.29784			0	X		0.3								
01/24/21 19:00	0.28392			0	X		0.28								
01/24/21 20:00	0.255			0	X		0.26								
01/24/21 21:00	0.22596			0	X		0.23								
01/24/21 22:00	0.24444			0	X		0.24								
01/24/21 23:00	0.21312			0	X		0.21								
01/25/21 0:00	0.20502			0	X		0.21								
01/25/21 1:00	0.19968			0	X		0.2								
01/25/21 2:00	0.1995			0	X		0.2								
01/25/21 3:00	0.20388			0	X		0.2								
01/25/21 4:00	0.21846			0	X		0.22								
01/25/21 5:00	0.25086			0	X		0.25								
01/25/21 6:00	0.27414			0	X		0.27								
01/25/21 7:00	0.32682			0	X		0.33								
01/25/21 8:00	0.37056			0	X		0.37								
01/25/21 9:00	0.387			0	X		0.39								
01/25/21 10:00	0.348			0	X		0.35								
01/25/21 11:00	0.33492			0	X		0.33								
01/25/21 12:00	0.30792			0	X		0.31								
01/25/21 13:00	0.294			0	X		0.29								
01/25/21 14:00	0.29376			0	X		0.29								
01/25/21 15:00	0.28722			0	X		0.29								
01/25/21 16:00	0.33648			0	X		0.34								
01/25/21 17:00	0.30408			0	X		0.3								
01/25/21 18:00	0.38328			0	X		0.38								
01/25/21 19:00	0.38484			0	X		0.38								
01/25/21 20:00	0.37242			0	X		0.37								
01/25/21 21:00	0.32382			0	X		0.32								
01/25/21 22:00	0.27024			0	X		0.27								
01/25/21 23:00	0.23898			0	X		0.24								
01/26/21 0:00	0.13218			0	X		0								
01/26/21 1:00	0	X		0	X		0								
01/26/21 2:00	0	X		0	X		0								
01/26/21 3:00	0	X		0	X		0								
01/26/21 4:00	0	X		0	X		0								

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
01/26/21 5:00	0	X		0	X		0											
01/26/21 6:00	0	X		0	X		0											
01/26/21 7:00	0	X		0	X		0											
01/26/21 8:00	0	X		0	X		0											
01/26/21 9:00	0	X		0	X		0											
01/26/21 10:00	0	X		0	X		0											
01/26/21 11:00	0	X		0	X		0											
01/26/21 12:00	0	X		0	X		0											
01/26/21 13:00	0	X		0	X		0											
01/26/21 14:00	0	X		0	X		0											
01/26/21 15:00	0	X		0	X		0											
01/26/21 16:00	0	X		0	X		0											
01/26/21 17:00	0	X		0	X		0											
01/26/21 18:00	0	X		0	X		0											
01/26/21 19:00	0	X		0	X		0											
01/26/21 20:00	0	X		0	X		0											
01/26/21 21:00	0	X		0	X		0											
01/26/21 22:00	0	X		0	X		0											
01/26/21 23:00	0	X		0	X		0											
01/27/21 0:00	0	X		0	X		0											
01/27/21 1:00	0	X		0	X		0											
01/27/21 2:00	0	X		0	X		0											
01/27/21 3:00	0	X		0	X		0											
01/27/21 4:00	0	X		0	X		0											
01/27/21 5:00	0	X		0	X		0											
01/27/21 6:00	0	X		0	X		0											
01/27/21 7:00	0	X		0	X		0											
01/27/21 8:00	0	X		0	X		0											
01/27/21 9:00	0	X		0	X		0											
01/27/21 10:00	0	X		0	X		0											
01/27/21 11:00	0	X		0	X		0											
01/27/21 12:00	0	X		0	X		0											
01/27/21 13:00	0	X		0	X		0											
01/27/21 14:00	0	X		0	X		0											
01/27/21 15:00	0	X		0	X		0											
01/27/21 16:00	0	X		0	X		0											
01/27/21 17:00	0	X		0	X		0											
01/27/21 18:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/27/21 19:00	0	X		0	X		0											
01/27/21 20:00	0	X		0	X		0											
01/27/21 21:00	0	X		0	X		0											
01/27/21 22:00	0	X		0	X		0											
01/27/21 23:00	0	X		0	X		0											
01/28/21 0:00	0	X		0	X		0											
01/28/21 1:00	0	X		0	X		0											
01/28/21 2:00	0	X		0	X		0											
01/28/21 3:00	0	X		0	X		0											
01/28/21 4:00	0	X		0	X		0											
01/28/21 5:00	0	X		0	X		0											
01/28/21 6:00	0	X		0	X		0											
01/28/21 7:00	0	X		0	X		0											
01/28/21 8:00	0	X		0	X		0											
01/28/21 9:00	0	X		0	X		0											
01/28/21 10:00	0	X		0	X		0											
01/28/21 11:00	0	X		0	X		0											
01/28/21 12:00	0	X		0	X		0											
01/28/21 13:00	0	X		0	X		0											
01/28/21 14:00	0	X		0	X		0											
01/28/21 15:00	0	X		0	X		0											
01/28/21 16:00	0	X		0	X		0											
01/28/21 17:00	0	X		0	X		0											
01/28/21 18:00	0	X		0	X		0											
01/28/21 19:00	0	X		0	X		0											
01/28/21 20:00	0	X		0	X		0											
01/28/21 21:00	0	X		0	X		0											
01/28/21 22:00	0	X		0	X		0											
01/28/21 23:00	0	X		0	X		0											
01/29/21 0:00	0	X		0	X		0											
01/29/21 1:00	0	X		0	X		0											
01/29/21 2:00	0	X		0	X		0											
01/29/21 3:00	0	X		0	X		0											
01/29/21 4:00	0	X		0	X		0											
01/29/21 5:00	0	X		0	X		0											
01/29/21 6:00	0	X		0	X		0											
01/29/21 7:00	0	X		0	X		0											
01/29/21 8:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
01/29/21 9:00	0	X		0	X		0											
01/29/21 10:00	0	X		0	X		0											
01/29/21 11:00	0	X		0	X		0											
01/29/21 12:00	0	X		0	X		0											
01/29/21 13:00	0	X		0	X		0											
01/29/21 14:00	0	X		0	X		0											
01/29/21 15:00	0	X		0	X		0											
01/29/21 16:00	0	X		0	X		0											
01/29/21 17:00	0	X		0	X		0											
01/29/21 18:00	0	X		0	X		0											
01/29/21 19:00	0	X		0	X		0											
01/29/21 20:00	0	X		0	X		0											
01/29/21 21:00	0	X		0	X		0											
01/29/21 22:00	0	X		0	X		0											
01/29/21 23:00	0	X		0	X		0											
01/30/21 0:00	0	X		0	X		0											
01/30/21 1:00	0	X		0	X		0											
01/30/21 2:00	0	X		0	X		0											
01/30/21 3:00	0	X		0	X		0											
01/30/21 4:00	0	X		0	X		0											
01/30/21 5:00	0	X		0	X		0											
01/30/21 6:00	0	X		0	X		0											
01/30/21 7:00	0	X		0	X		0											
01/30/21 8:00	0	X		0	X		0											
01/30/21 9:00	0	X		0	X		0											
01/30/21 10:00	0	X		0	X		0											
01/30/21 11:00	0	X		0	X		0											
01/30/21 12:00	0	X		0	X		0											
01/30/21 13:00	0	X		0	X		0											
01/30/21 14:00	0	X		0	X		0											
01/30/21 15:00	0	X		0	X		0											
01/30/21 16:00	0	X		0	X		0											
01/30/21 17:00	0	X		0	X		0											
01/30/21 18:00	0	X		0	X		0											
01/30/21 19:00	0	X		0	X		0											
01/30/21 20:00	0	X		0	X		0											
01/30/21 21:00	0	X		0	X		0											
01/30/21 22:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/30/21 23:00	0	X		0	X		0											
01/31/21 0:00	0	X		0	X		0											
01/31/21 1:00	0	X		0	X		0											
01/31/21 2:00	0	X		0	X		0											
01/31/21 3:00	0	X		0	X		0											
01/31/21 4:00	0	X		0	X		0											
01/31/21 5:00	0	X		0	X		0											
01/31/21 6:00	0	X		0	X		0											
01/31/21 7:00	0	X		0	X		0											
01/31/21 8:00	0	X		0	X		0											
01/31/21 9:00	0	X		0	X		0											
01/31/21 10:00	0	X		0	X		0											
01/31/21 11:00	0	X		0	X		0											
01/31/21 12:00	0	X		0	X		0											
01/31/21 13:00	0	X		0	X		0											
01/31/21 14:00	0	X		0	X		0											
01/31/21 15:00	0	X		0	X		0											
01/31/21 16:00	0	X		0	X		0											
01/31/21 17:00	0	X		0	X		0											
01/31/21 18:00	0	X		0	X		0											
01/31/21 19:00	0	X		0	X		0											
01/31/21 20:00	0	X		0	X		0											
01/31/21 21:00	0	X		0	X		0											
01/31/21 22:00	0	X		0	X		0											
01/31/21 23:00	0	X		0	X		0											
02/01/21 0:00	0	X		0	X		0											
02/01/21 1:00	0	X		0	X		0											
02/01/21 2:00	0	X		0	X		0											
02/01/21 3:00	0	X		0	X		0											
02/01/21 4:00	0	X		0	X		0											
02/01/21 5:00	0	X		0	X		0											
02/01/21 6:00	0	X		0	X		0											
02/01/21 7:00	0	X		0	X		0											
02/01/21 8:00	0	X		0	X		0											
02/01/21 9:00	0	X		0	X		0											
02/01/21 10:00	0	X		0	X		0											
02/01/21 11:00	0	X		0	X		0											
02/01/21 12:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
02/01/21 13:00	0	X		0	X		0											
02/01/21 14:00	0	X		0	X		0											
02/01/21 15:00	0	X		0	X		0											
02/01/21 16:00	0	X		0	X		0											
02/01/21 17:00	0	X		0	X		0											
02/01/21 18:00	0	X		0	X		0											
02/01/21 19:00	0	X		0	X		0											
02/01/21 20:00	0	X		0	X		0											
02/01/21 21:00	0	X		0	X		0											
02/01/21 22:00	0	X		0	X		0											
02/01/21 23:00	0	X		0	X		0											
02/02/21 0:00	0	X		0	X		0											
02/02/21 1:00	0	X		0	X		0											
02/02/21 2:00	0	X		0	X		0											
02/02/21 3:00	0	X		0	X		0											
02/02/21 4:00	0	X		0	X		0											
02/02/21 5:00	0	X		0	X		0											
02/02/21 6:00	0	X		0	X		0											
02/02/21 7:00	0	X		0	X		0											
02/02/21 8:00	0	X		0	X		0											
02/02/21 9:00	0	X		0	X		0											
02/02/21 10:00	0	X		0	X		0											
02/02/21 11:00	0	X		0	X		0											
02/02/21 12:00	0	X		0	X		0											
02/02/21 13:00	0	X		0	X		0											
02/02/21 14:00	0	X		0	X		0											
02/02/21 15:00	0	X		0	X		0											
02/02/21 16:00	0	X		0	X		0											
02/02/21 17:00	0	X		0	X		0											
02/02/21 18:00	0	X		0	X		0											
02/02/21 19:00	0	X		0	X		0											
02/02/21 20:00	0	X		0	X		0											
02/02/21 21:00	0	X		0	X		0											
02/02/21 22:00	0	X		0	X		0											
02/02/21 23:00	0	X		0	X		0											
02/03/21 0:00	0	X		0	X		0											
02/03/21 1:00	0	X		0	X		0											
02/03/21 2:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/03/21 3:00	0	X		0	X		0											
02/03/21 4:00	0	X		0	X		0											
02/03/21 5:00	0	X		0	X		0											
02/03/21 6:00	0	X		0	X		0											
02/03/21 7:00	0	X		0	X		0											
02/03/21 8:00	0	X		0	X		0											
02/03/21 9:00	0	X		0	X		0											
02/03/21 10:00	0	X		0	X		0											
02/03/21 11:00	0	X		0	X		0											
02/03/21 12:00	0	X		0	X		0											
02/03/21 13:00	0	X		0	X		0											
02/03/21 14:00	0	X		0	X		0											
02/03/21 15:00	0	X		0	X		0											
02/03/21 16:00	0	X		0	X		0											
02/03/21 17:00	0	X		0	X		0											
02/03/21 18:00	0	X		0	X		0											
02/03/21 19:00	0	X		0	X		0											
02/03/21 20:00	0	X		0	X		0											
02/03/21 21:00	0	X		0	X		0											
02/03/21 22:00	0	X		0	X		0											
02/03/21 23:00	0	X		0	X		0											
02/04/21 0:00	0	X		0	X		0											
02/04/21 1:00	0	X		0	X		0											
02/04/21 2:00	0	X		0	X		0											
02/04/21 3:00	0	X		0	X		0											
02/04/21 4:00	0	X		0	X		0											
02/04/21 5:00	0	X		0	X		0											
02/04/21 6:00	0	X		0	X		0											
02/04/21 7:00	0	X		0	X		0											
02/04/21 8:00	0	X		0	X		0											
02/04/21 9:00	0	X		0	X		0											
02/04/21 10:00	0	X		0	X		0											
02/04/21 11:00	0	X		0	X		0											
02/04/21 12:00	0	X		0	X		0											
02/04/21 13:00	0	X		0	X		0											
02/04/21 14:00	0	X		0	X		0											
02/04/21 15:00	0	X		0	X		0											
02/04/21 16:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
02/04/21 17:00	0	X		0	X		0											
02/04/21 18:00	0	X		0	X		0											
02/04/21 19:00	0	X		0	X		0											
02/04/21 20:00	0	X		0	X		0											
02/04/21 21:00	0	X		0	X		0											
02/04/21 22:00	0	X		0	X		0											
02/04/21 23:00	0	X		0	X		0											
02/05/21 0:00	0	X		0	X		0											
02/05/21 1:00	0	X		0	X		0											
02/05/21 2:00	0	X		0	X		0											
02/05/21 3:00	0	X		0	X		0											
02/05/21 4:00	0	X		0	X		0											
02/05/21 5:00	0	X		0	X		0											
02/05/21 6:00	0	X		0	X		0											
02/05/21 7:00	0	X		0	X		0											
02/05/21 8:00	0	X		0	X		0											
02/05/21 9:00	0	X		0	X		0											
02/05/21 10:00	0	X		0	X		0											
02/05/21 11:00	0	X		0	X		0											
02/05/21 12:00	0	X		0	X		0											
02/05/21 13:00	0	X		0	X		0											
02/05/21 14:00	0	X		0	X		0											
02/05/21 15:00	0	X		0	X		0											
02/05/21 16:00	0	X		0	X		0											
02/05/21 17:00	0	X		0	X		0											
02/05/21 18:00	0	X		0	X		0											
02/05/21 19:00	0	X		0	X		0											
02/05/21 20:00	0	X		0	X		0											
02/05/21 21:00	0	X		0	X		0											
02/05/21 22:00	0	X		0	X		0											
02/05/21 23:00	0	X		0	X		0											
02/06/21 0:00	0	X		0	X		0											
02/06/21 1:00	0	X		0	X		0											
02/06/21 2:00	0	X		0	X		0											
02/06/21 3:00	0	X		0	X		0											
02/06/21 4:00	0	X		0	X		0											
02/06/21 5:00	0	X		0	X		0											
02/06/21 6:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/06/21 7:00	0	X		0	X		0											
02/06/21 8:00	0	X		0	X		0											
02/06/21 9:00	0	X		0	X		0											
02/06/21 10:00	0	X		0	X		0											
02/06/21 11:00	0	X		0	X		0											
02/06/21 12:00	0	X		0	X		0											
02/06/21 13:00	0	X		0	X		0											
02/06/21 14:00	0	X		0	X		0											
02/06/21 15:00	0	X		0	X		0											
02/06/21 16:00	0	X		0	X		0											
02/06/21 17:00	0	X		0	X		0											
02/06/21 18:00	0	X		0	X		0											
02/06/21 19:00	0	X		0	X		0											
02/06/21 20:00	0	X		0	X		0											
02/06/21 21:00	0	X		0	X		0											
02/06/21 22:00	0	X		0	X		0											
02/06/21 23:00	0	X		0	X		0											
02/07/21 0:00	0	X		0	X		0											
02/07/21 1:00	0	X		0	X		0											
02/07/21 2:00	0	X		0	X		0											
02/07/21 3:00	0	X		0	X		0											
02/07/21 4:00	0	X		0	X		0											
02/07/21 5:00	0	X		0	X		0											
02/07/21 6:00	0	X		0	X		0											
02/07/21 7:00	0	X		0	X		0											
02/07/21 8:00	0	X		0	X		0											
02/07/21 9:00	0	X		0	X		0											
02/07/21 10:00	0	X		0	X		0											
02/07/21 11:00	0	X		0	X		0											
02/07/21 12:00	0	X		0	X		0											
02/07/21 13:00	0	X		0	X		0											
02/07/21 14:00	0	X		0	X		0											
02/07/21 15:00	0	X		0	X		0											
02/07/21 16:00	0	X		0	X		0											
02/07/21 17:00	0	X		0	X		0											
02/07/21 18:00	0	X		0	X		0											
02/07/21 19:00	0	X		0	X		0											
02/07/21 20:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/07/21 21:00	0	X		0	X		0											
02/07/21 22:00	0	X		0	X		0											
02/07/21 23:00	0	X		0	X		0											
02/08/21 0:00	0	X		0	X		0											
02/08/21 1:00	0	X		0	X		0											
02/08/21 2:00	0	X		0	X		0											
02/08/21 3:00	0	X		0	X		0											
02/08/21 4:00	0	X		0	X		0											
02/08/21 5:00	0	X		0	X		0											
02/08/21 6:00	0	X		0	X		0											
02/08/21 7:00	0	X		0	X		0											
02/08/21 8:00	0	X		0	X		0											
02/08/21 9:00	0	X		0	X		0											
02/08/21 10:00	0	X		0	X		0											
02/08/21 11:00	0	X		0	X		0											
02/08/21 12:00	0	X		0	X		0											
02/08/21 13:00	0	X		0	X		0											
02/08/21 14:00	0	X		0	X		0											
02/08/21 15:00	0	X		0	X		0											
02/08/21 16:00	0	X		0	X		0											
02/08/21 17:00	0	X		0	X		0											
02/08/21 18:00	0	X		0	X		0											
02/08/21 19:00	0	X		0	X		0											
02/08/21 20:00	0	X		0	X		0											
02/08/21 21:00	0	X		0	X		0											
02/08/21 22:00	0	X		0	X		0											
02/08/21 23:00	0	X		0	X		0											
02/09/21 0:00	0	X		0	X		0											
02/09/21 1:00	0	X		0	X		0											
02/09/21 2:00	0	X		0	X		0											
02/09/21 3:00	0	X		0	X		0											
02/09/21 4:00	0	X		0	X		0											
02/09/21 5:00	0	X		0	X		0											
02/09/21 6:00	0	X		0	X		0											
02/09/21 7:00	0	X		0	X		0											
02/09/21 8:00	0	X		0	X		0											
02/09/21 9:00	0	X		0	X		0											
02/09/21 10:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/09/21 11:00	0	X		0	X		0											
02/09/21 12:00	0	X		0	X		0											
02/09/21 13:00	0	X		0	X		0											
02/09/21 14:00	0	X		0	X		0											
02/09/21 15:00	0	X		0	X		0											
02/09/21 16:00	0	X		0	X		0											
02/09/21 17:00	0	X		0	X		0											
02/09/21 18:00	0	X		0	X		0											
02/09/21 19:00	0	X		0	X		0											
02/09/21 20:00	0	X		0	X		0											
02/09/21 21:00	0	X		0	X		0											
02/09/21 22:00	0	X		0	X		0											
02/09/21 23:00	0	X		0	X		0											
02/10/21 0:00	0	X		0	X		0											
02/10/21 1:00	0	X		0	X		0											
02/10/21 2:00	0	X		0	X		0											
02/10/21 3:00	0	X		0	X		0											
02/10/21 4:00	0	X		0	X		0											
02/10/21 5:00	0	X		0	X		0											
02/10/21 6:00	0	X		0	X		0											
02/10/21 7:00	0	X		0	X		0											
02/10/21 8:00	0	X		0	X		0											
02/10/21 9:00	0	X		0	X		0											
02/10/21 10:00	0	X		0	X		0											
02/10/21 11:00	0	X		0	X		0											
02/10/21 12:00	0	X		0	X		0											
02/10/21 13:00	0	X		0	X		0											
02/10/21 14:00	0	X		0	X		0											
02/10/21 15:00	0	X		0	X		0											
02/10/21 16:00	0	X		0	X		0											
02/10/21 17:00	0	X		0	X		0											
02/10/21 18:00	0	X		0	X		0											
02/10/21 19:00	0	X		0	X		0											
02/10/21 20:00	0	X		0	X		0											
02/10/21 21:00	0	X		0	X		0											
02/10/21 22:00	0	X		0	X		0											
02/10/21 23:00	0	X		0	X		0											
02/11/21 0:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/11/21 1:00	0	X		0	X		0											
02/11/21 2:00	0	X		0	X		0											
02/11/21 3:00	0	X		0	X		0											
02/11/21 4:00	0	X		0	X		0											
02/11/21 5:00	0	X		0	X		0											
02/11/21 6:00	0	X		0	X		0											
02/11/21 7:00	0	X		0	X		0											
02/11/21 8:00	0	X		0	X		0											
02/11/21 9:00	0	X		0	X		0											
02/11/21 10:00	0	X		0	X		0											
02/11/21 11:00	0	X		0	X		0											
02/11/21 12:00	0	X		0	X		0											
02/11/21 13:00	0	X		0	X		0											
02/11/21 14:00	0	X		0	X		0											
02/11/21 15:00	0	X		0	X		0											
02/11/21 16:00	0	X		0	X		0											
02/11/21 17:00	0	X		0	X		0											
02/11/21 18:00	0	X		0	X		0											
02/11/21 19:00	0	X		0	X		0											
02/11/21 20:00	0	X		0	X		0											
02/11/21 21:00	0	X		0	X		0											
02/11/21 22:00	0	X		0	X		0											
02/11/21 23:00	0	X		0	X		0											
02/12/21 0:00	0	X		0	X		0											
02/12/21 1:00	0	X		0	X		0											
02/12/21 2:00	0	X		0	X		0											
02/12/21 3:00	0	X		0	X		0											
02/12/21 4:00	0	X		0	X		0											
02/12/21 5:00	0	X		0	X		0											
02/12/21 6:00	0	X		0	X		0											
02/12/21 7:00	0	X		0	X		0											
02/12/21 8:00	0	X		0	X		0											
02/12/21 9:00	0	X		0	X		0											
02/12/21 10:00	0	X		0	X		0											
02/12/21 11:00	0	X		0	X		0											
02/12/21 12:00	0	X		0	X		0											
02/12/21 13:00	0	X		0	X		0											
02/12/21 14:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/12/21 15:00	0	X		0	X		0											
02/12/21 16:00	0	X		0	X		0											
02/12/21 17:00	0	X		0	X		0											
02/12/21 18:00	0	X		0	X		0											
02/12/21 19:00	0	X		0	X		0											
02/12/21 20:00	0	X		0	X		0											
02/12/21 21:00	0	X		0	X		0											
02/12/21 22:00	0	X		0	X		0											
02/12/21 23:00	0	X		0	X		0											
02/13/21 0:00	0	X		0	X		0											
02/13/21 1:00	0	X		0	X		0											
02/13/21 2:00	0	X		0	X		0											
02/13/21 3:00	0	X		0	X		0											
02/13/21 4:00	0	X		0	X		0											
02/13/21 5:00	0	X		0	X		0											
02/13/21 6:00	0	X		0	X		0											
02/13/21 7:00	0	X		0	X		0											
02/13/21 8:00	0	X		0	X		0											
02/13/21 9:00	0	X		0	X		0											
02/13/21 10:00	0	X		0	X		0											
02/13/21 11:00	0	X		0	X		0											
02/13/21 12:00	0	X		0	X		0											
02/13/21 13:00	0	X		0	X		0											
02/13/21 14:00	0	X		0	X		0											
02/13/21 15:00	0	X		0	X		0											
02/13/21 16:00	0	X		0	X		0											
02/13/21 17:00	0	X		0	X		0											
02/13/21 18:00	0	X		0	X		0											
02/13/21 19:00	0	X		0	X		0											
02/13/21 20:00	0	X		0	X		0											
02/13/21 21:00	0	X		0	X		0											
02/13/21 22:00	0	X		0	X		0											
02/13/21 23:00	0	X		0	X		0											
02/14/21 0:00	0	X		0	X		0											
02/14/21 1:00	0	X		0	X		0											
02/14/21 2:00	0	X		0	X		0											
02/14/21 3:00	0	X		0	X		0											
02/14/21 4:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/14/21 5:00	0	X		0	X		0											
02/14/21 6:00	0	X		0	X		0											
02/14/21 7:00	0	X		0	X		0											
02/14/21 8:00	0	X		0	X		0											
02/14/21 9:00	0	X		0	X		0											
02/14/21 10:00	0	X		0	X		0											
02/14/21 11:00	0	X		0	X		0											
02/14/21 12:00	0	X		0	X		0											
02/14/21 13:00	0	X		0	X		0											
02/14/21 14:00	0	X		0	X		0											
02/14/21 15:00	0	X		0	X		0											
02/14/21 16:00	0	X		0	X		0											
02/14/21 17:00	0	X		0	X		0											
02/14/21 18:00	0	X		0	X		0											
02/14/21 19:00	0	X		0	X		0											
02/14/21 20:00	0	X		0	X		0											
02/14/21 21:00	0	X		0	X		0											
02/14/21 22:00	0	X		0	X		0											
02/14/21 23:00	0	X		0	X		0											
02/15/21 0:00	0	X		0	X		0											
02/15/21 1:00	0	X		0	X		0											
02/15/21 2:00	0	X		0	X		0											
02/15/21 3:00	0	X		0	X		0											
02/15/21 4:00	0	X		0	X		0											
02/15/21 5:00	0	X		0	X		0											
02/15/21 6:00	0	X		0	X		0											
02/15/21 7:00	0	X		0	X		0											
02/15/21 8:00	0	X		0	X		0											
02/15/21 9:00	0	X		0	X		0											
02/15/21 10:00	0	X		0	X		0											
02/15/21 11:00	0	X		0	X		0											
02/15/21 12:00	0	X		0	X		0											
02/15/21 13:00	0	X		0	X		0											
02/15/21 14:00	0	X		0	X		0											
02/15/21 15:00	0	X		0	X		0											
02/15/21 16:00	0	X		0	X		0											
02/15/21 17:00	0	X		0	X		0											
02/15/21 18:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/15/21 19:00	0	X		0	X		0											
02/15/21 20:00	0	X		0	X		0											
02/15/21 21:00	0	X		0	X		0											
02/15/21 22:00	0	X		0	X		0											
02/15/21 23:00	0	X		0	X		0											
02/16/21 0:00	0	X		0	X		0											
02/16/21 1:00	0	X		0	X		0											
02/16/21 2:00	0	X		0	X		0											
02/16/21 3:00	0	X		0	X		0											
02/16/21 4:00	0	X		0	X		0											
02/16/21 5:00	0	X		0	X		0											
02/16/21 6:00	0	X		0	X		0											
02/16/21 7:00	0	X		0	X		0											
02/16/21 8:00	0	X		0	X		0											
02/16/21 9:00	0	X		0	X		0											
02/16/21 10:00	0	X		0	X		0											
02/16/21 11:00	0	X		0	X		0											
02/16/21 12:00	0	X		0	X		0											
02/16/21 13:00	0	X		0	X		0											
02/16/21 14:00	0	X		0	X		0											
02/16/21 15:00	0	X		0	X		0											
02/16/21 16:00	0	X		0	X		0											
02/16/21 17:00	0	X		0	X		0											
02/16/21 18:00	0	X		0	X		0											
02/16/21 19:00	0	X		0	X		0											
02/16/21 20:00	0	X		0	X		0											
02/16/21 21:00	0	X		0	X		0											
02/16/21 22:00	0	X		0	X		0											
02/16/21 23:00	0	X		0	X		0											
02/17/21 0:00	0	X		0	X		0											
02/17/21 1:00	0	X		0	X		0											
02/17/21 2:00	0	X		0	X		0											
02/17/21 3:00	0	X		0	X		0											
02/17/21 4:00	0	X		0	X		0											
02/17/21 5:00	0	X		0	X		0											
02/17/21 6:00	0	X		0	X		0											
02/17/21 7:00	0	X		0	X		0											
02/17/21 8:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/17/21 9:00	0	X		0	X		0											
02/17/21 10:00	0	X		0	X		0											
02/17/21 11:00	0	X		0	X		0											
02/17/21 12:00	0	X		0	X		0											
02/17/21 13:00	0	X		0	X		0											
02/17/21 14:00	0	X		0	X		0											
02/17/21 15:00	0	X		0	X		0											
02/17/21 16:00	0	X		0	X		0											
02/17/21 17:00	0	X		0	X		0											
02/17/21 18:00	0	X		0	X		0											
02/17/21 19:00	0	X		0	X		0											
02/17/21 20:00	0	X		0	X		0											
02/17/21 21:00	0	X		0	X		0											
02/17/21 22:00	0	X		0	X		0											
02/17/21 23:00	0	X		0	X		0											
02/18/21 0:00	0	X		0	X		0											
02/18/21 1:00	0	X		0	X		0											
02/18/21 2:00	0	X		0	X		0											
02/18/21 3:00	0	X		0	X		0											
02/18/21 4:00	0	X		0	X		0											
02/18/21 5:00	0	X		0	X		0											
02/18/21 6:00	0	X		0	X		0											
02/18/21 7:00	0	X		0	X		0											
02/18/21 8:00	0	X		0	X		0											
02/18/21 9:00	0	X		0	X		0											
02/18/21 10:00	0	X		0	X		0											
02/18/21 11:00	0	X		0	X		0											
02/18/21 12:00	0	X		0	X		0											
02/18/21 13:00	0	X		0	X		0											
02/18/21 14:00	0	X		0	X		0											
02/18/21 15:00	0	X		0	X		0											
02/18/21 16:00	0	X		0	X		0											
02/18/21 17:00	0	X		0	X		0											
02/18/21 18:00	0	X		0	X		0											
02/18/21 19:00	0	X		0	X		0											
02/18/21 20:00	0	X		0	X		0											
02/18/21 21:00	0	X		0	X		0											
02/18/21 22:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/18/21 23:00	0	X		0	X		0											
02/19/21 0:00	0	X		0	X		0											
02/19/21 1:00	0	X		0	X		0											
02/19/21 2:00	0	X		0	X		0											
02/19/21 3:00	0	X		0	X		0											
02/19/21 4:00	0	X		0	X		0											
02/19/21 5:00	0	X		0	X		0											
02/19/21 6:00	0	X		0	X		0											
02/19/21 7:00	0	X		0	X		0											
02/19/21 8:00	0	X		0	X		0											
02/19/21 9:00	0	X		0	X		0											
02/19/21 10:00	0	X		0	X		0											
02/19/21 11:00	0	X		0	X		0											
02/19/21 12:00	0	X		0	X		0											
02/19/21 13:00	0	X		0	X		0											
02/19/21 14:00	0	X		0	X		0											
02/19/21 15:00	0	X		0	X		0											
02/19/21 16:00	0	X		0	X		0											
02/19/21 17:00	0	X		0	X		0											
02/19/21 18:00	0	X		0	X		0											
02/19/21 19:00	0	X		0	X		0											
02/19/21 20:00	0	X		0	X		0											
02/19/21 21:00	0	X		0	X		0											
02/19/21 22:00	0	X		0	X		0											
02/19/21 23:00	0	X		0	X		0											
02/20/21 0:00	0	X		0	X		0											
02/20/21 1:00	0	X		0	X		0											
02/20/21 2:00	0	X		0	X		0											
02/20/21 3:00	0	X		0	X		0											
02/20/21 4:00	0	X		0	X		0											
02/20/21 5:00	0	X		0	X		0											
02/20/21 6:00	0	X		0	X		0											
02/20/21 7:00	0	X		0	X		0											
02/20/21 8:00	0	X		0	X		0											
02/20/21 9:00	0	X		0	X		0											
02/20/21 10:00	0	X		0	X		0											
02/20/21 11:00	0	X		0	X		0											
02/20/21 12:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/20/21 13:00	0	X		0	X		0											
02/20/21 14:00	0	X		0	X		0											
02/20/21 15:00	0	X		0	X		0											
02/20/21 16:00	0	X		0	X		0											
02/20/21 17:00	0	X		0	X		0											
02/20/21 18:00	0	X		0	X		0											
02/20/21 19:00	0	X		0	X		0											
02/20/21 20:00	0	X		0	X		0											
02/20/21 21:00	0	X		0	X		0											
02/20/21 22:00	0	X		0	X		0											
02/20/21 23:00	0	X		0	X		0											
02/21/21 0:00	0	X		0	X		0											
02/21/21 1:00	0	X		0	X		0											
02/21/21 2:00	0	X		0	X		0											
02/21/21 3:00	0	X		0	X		0											
02/21/21 4:00	0	X		0	X		0											
02/21/21 5:00	0	X		0	X		0											
02/21/21 6:00	0	X		0	X		0											
02/21/21 7:00	0	X		0	X		0											
02/21/21 8:00	0	X		0	X		0											
02/21/21 9:00	0	X		0	X		0											
02/21/21 10:00	0	X		0	X		0											
02/21/21 11:00	0	X		0	X		0											
02/21/21 12:00	0	X		0	X		0											
02/21/21 13:00	0	X		0	X		0											
02/21/21 14:00	0	X		0	X		0											
02/21/21 15:00	0	X		0	X		0											
02/21/21 16:00	0	X		0	X		0											
02/21/21 17:00	0	X		0	X		0											
02/21/21 18:00	0	X		0	X		0											
02/21/21 19:00	0	X		0	X		0											
02/21/21 20:00	0	X		0	X		0											
02/21/21 21:00	0	X		0	X		0											
02/21/21 22:00	0	X		0	X		0											
02/21/21 23:00	0	X		0	X		0											
02/22/21 0:00	0	X		0	X		0											
02/22/21 1:00	0	X		0	X		0											
02/22/21 2:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/22/21 3:00	0	X		0	X		0											
02/22/21 4:00	0	X		0	X		0											
02/22/21 5:00	0	X		0	X		0											
02/22/21 6:00	0	X		0	X		0											
02/22/21 7:00	0	X		0	X		0											
02/22/21 8:00	0	X		0	X		0											
02/22/21 9:00	0	X		0	X		0											
02/22/21 10:00	0	X		0	X		0											
02/22/21 11:00	0	X		0	X		0											
02/22/21 12:00	0	X		0	X		0											
02/22/21 13:00	0	X		0	X		0											
02/22/21 14:00	0	X		0	X		0											
02/22/21 15:00	0	X		0	X		0											
02/22/21 16:00	0	X		0	X		0											
02/22/21 17:00	0	X		0	X		0											
02/22/21 18:00	0	X		0	X		0											
02/22/21 19:00	0	X		0	X		0											
02/22/21 20:00	0	X		0	X		0											
02/22/21 21:00	0	X		0	X		0											
02/22/21 22:00	0	X		0	X		0											
02/22/21 23:00	0	X		0	X		0											
02/23/21 0:00	0	X		0	X		0											
02/23/21 1:00	0	X		0	X		0											
02/23/21 2:00	0	X		0	X		0											
02/23/21 3:00	0	X		0	X		0											
02/23/21 4:00	0	X		0	X		0											
02/23/21 5:00	0	X		0	X		0											
02/23/21 6:00	0	X		0	X		0											
02/23/21 7:00	0	X		0	X		0											
02/23/21 8:00	0	X		0	X		0											
02/23/21 9:00	0	X		0	X		0											
02/23/21 10:00	0	X		0	X		0											
02/23/21 11:00	0	X		0	X		0											
02/23/21 12:00	0	X		0	X		0											
02/23/21 13:00	0	X		0	X		0											
02/23/21 14:00	0	X		0	X		0											
02/23/21 15:00	0	X		0	X		0											
02/23/21 16:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/23/21 17:00	0	X		0	X		0											
02/23/21 18:00	0	X		0	X		0											
02/23/21 19:00	0	X		0	X		0											
02/23/21 20:00	0	X		0	X		0											
02/23/21 21:00	0	X		0	X		0											
02/23/21 22:00	0	X		0	X		0											
02/23/21 23:00	0	X		0	X		0											
02/24/21 0:00	0	X		0	X		0											
02/24/21 1:00	0	X		0	X		0											
02/24/21 2:00	0	X		0	X		0											
02/24/21 3:00	0	X		0	X		0											
02/24/21 4:00	0	X		0	X		0											
02/24/21 5:00	0	X		0	X		0											
02/24/21 6:00	0	X		0	X		0											
02/24/21 7:00	0	X		0	X		0											
02/24/21 8:00	0	X		0	X		0											
02/24/21 9:00	0	X		0	X		0											
02/24/21 10:00	0	X		0	X		0											
02/24/21 11:00	0	X		0	X		0											
02/24/21 12:00	0	X		0	X		0											
02/24/21 13:00	0	X		0	X		0											
02/24/21 14:00	0	X		0	X		0											
02/24/21 15:00	0	X		0	X		0											
02/24/21 16:00	0	X		0	X		0											
02/24/21 17:00	0	X		0	X		0											
02/24/21 18:00	0	X		0	X		0											
02/24/21 19:00	0	X		0	X		0											
02/24/21 20:00	0	X		0	X		0											
02/24/21 21:00	0	X		0	X		0											
02/24/21 22:00	0	X		0	X		0											
02/24/21 23:00	0	X		0	X		0											
02/25/21 0:00	0	X		0	X		0											
02/25/21 1:00	0	X		0	X		0											
02/25/21 2:00	0	X		0	X		0											
02/25/21 3:00	0	X		0	X		0											
02/25/21 4:00	0	X		0	X		0											
02/25/21 5:00	0	X		0	X		0											
02/25/21 6:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
02/25/21 7:00	0	X		0	X		0											
02/25/21 8:00	0	X		0	X		0											
02/25/21 9:00	0	X		0	X		0											
02/25/21 10:00	0	X		0	X		0											
02/25/21 11:00	0	X		0	X		0											
02/25/21 12:00	0	X		0	X		0											
02/25/21 13:00	0	X		0	X		0											
02/25/21 14:00	0	X		0	X		0											
02/25/21 15:00	0	X		0	X		0											
02/25/21 16:00	0	X		0	X		0											
02/25/21 17:00	0	X		0	X		0											
02/25/21 18:00	0	X		0	X		0											
02/25/21 19:00	0	X		0	X		0											
02/25/21 20:00	0	X		0	X		0											
02/25/21 21:00	0	X		0	X		0											
02/25/21 22:00	0	X		0	X		0											
02/25/21 23:00	0	X		0	X		0											
02/26/21 0:00	0	X		0	X		0											
02/26/21 1:00	0	X		0	X		0											
02/26/21 2:00	0	X		0	X		0											
02/26/21 3:00	0	X		0	X		0											
02/26/21 4:00	0	X		0	X		0											
02/26/21 5:00	0	X		0	X		0											
02/26/21 6:00	0	X		0	X		0											
02/26/21 7:00	0	X		0	X		0											
02/26/21 8:00	0	X		0.12564			0.09											
02/26/21 9:00	0	X		0.21042			0.21											
02/26/21 10:00	0	X		0.29622			0.3											
02/26/21 11:00	0	X		0.31014			0.31											
02/26/21 12:00	0	X		0.30876			0.31											
02/26/21 13:00	0	X		0.30738			0.31											
02/26/21 14:00	0	X		0.21228			0.07											
02/26/21 15:00	0	X		0	X		0											
02/26/21 16:00	0	X		0	X		0											
02/26/21 17:00	0	X		0	X		0											
02/26/21 18:00	0	X		0	X		0											
02/26/21 19:00	0	X		0	X		0											
02/26/21 20:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/26/21 21:00	0	X		0	X		0											
02/26/21 22:00	0	X		0	X		0											
02/26/21 23:00	0	X		0	X		0											
02/27/21 0:00	0	X		0	X		0											
02/27/21 1:00	0	X		0	X		0											
02/27/21 2:00	0	X		0	X		0											
02/27/21 3:00	0	X		0	X		0											
02/27/21 4:00	0	X		0	X		0											
02/27/21 5:00	0	X		0	X		0											
02/27/21 6:00	0	X		0	X		0											
02/27/21 7:00	0	X		0	X		0											
02/27/21 8:00	0	X		0	X		0											
02/27/21 9:00	0	X		0.1056			0.03											
02/27/21 10:00	0	X		0.2982			0.3											
02/27/21 11:00	0	X		0.30864			0.31											
02/27/21 12:00	0	X		0.30738			0.31											
02/27/21 13:00	0	X		0.3063			0.31											
02/27/21 14:00	0	X		0.30294			0.3											
02/27/21 15:00	0	X		0.26208			0.26											
02/27/21 16:00	0	X		0.21516			0.22											
02/27/21 17:00	0	X		0.19014			0.19											
02/27/21 18:00	0	X		0.04722			0											
02/27/21 19:00	0	X		0	X		0											
02/27/21 20:00	0	X		0	X		0											
02/27/21 21:00	0	X		0	X		0											
02/27/21 22:00	0	X		0	X		0											
02/27/21 23:00	0	X		0	X		0											
02/28/21 0:00	0	X		0	X		0											
02/28/21 1:00	0	X		0	X		0											
02/28/21 2:00	0	X		0	X		0											
02/28/21 3:00	0	X		0	X		0											
02/28/21 4:00	0	X		0	X		0											
02/28/21 5:00	0	X		0	X		0											
02/28/21 6:00	0	X		0	X		0											
02/28/21 7:00	0	X		0	X		0											
02/28/21 8:00	0	X		0	X		0											
02/28/21 9:00	0	X		0	X		0											
02/28/21 10:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
02/28/21 11:00	0	X		0	X		0											
02/28/21 12:00	0	X		0	X		0											
02/28/21 13:00	0	X		0	X		0											
02/28/21 14:00	0	X		0	X		0											
02/28/21 15:00	0	X		0	X		0											
02/28/21 16:00	0	X		0	X		0											
02/28/21 17:00	0	X		0	X		0											
02/28/21 18:00	0	X		0	X		0											
02/28/21 19:00	0	X		0	X		0											
02/28/21 20:00	0	X		0	X		0											
02/28/21 21:00	0	X		0	X		0											
02/28/21 22:00	0	X		0	X		0											
02/28/21 23:00	0	X		0	X		0											
03/01/21 0:00	0	X		0	X		0											
03/01/21 1:00	0	X		0	X		0											
03/01/21 2:00	0	X		0	X		0											
03/01/21 3:00	0	X		0	X		0											
03/01/21 4:00	0	X		0	X		0											
03/01/21 5:00	0	X		0	X		0											
03/01/21 6:00	0	X		0	X		0											
03/01/21 7:00	0	X		0.09504			0.02											
03/01/21 8:00	0	X		0.28548			0.29											
03/01/21 9:00	0	X		0.31422			0.31											
03/01/21 10:00	0	X		0.31092			0.31											
03/01/21 11:00	0	X		0.30678			0.31											
03/01/21 12:00	0	X		0.30468			0.3											
03/01/21 13:00	0	X		0.21216			0.21											
03/01/21 14:00	0	X		0.1926			0.19											
03/01/21 15:00	0	X		0.17934			0.18											
03/01/21 16:00	0	X		0.1941			0.19											
03/01/21 17:00	0	X		0.07374			0											
03/01/21 18:00	0	X		0	X		0											
03/01/21 19:00	0	X		0	X		0											
03/01/21 20:00	0	X		0	X		0											
03/01/21 21:00	0	X		0	X		0											
03/01/21 22:00	0	X		0	X		0											
03/01/21 23:00	0	X		0	X		0											
03/02/21 0:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/02/21 1:00	0	X		0	X		0											
03/02/21 2:00	0	X		0	X		0											
03/02/21 3:00	0	X		0	X		0											
03/02/21 4:00	0	X		0	X		0											
03/02/21 5:00	0	X		0	X		0											
03/02/21 6:00	0	X		0	X		0											
03/02/21 7:00	0	X		0	X		0											
03/02/21 8:00	0	X		0	X		0											
03/02/21 9:00	0	X		0	X		0											
03/02/21 10:00	0	X		0	X		0											
03/02/21 11:00	0	X		0	X		0											
03/02/21 12:00	0	X		0	X		0											
03/02/21 13:00	0	X		0	X		0											
03/02/21 14:00	0	X		0	X		0											
03/02/21 15:00	0	X		0	X		0											
03/02/21 16:00	0	X		0	X		0											
03/02/21 17:00	0	X		0	X		0											
03/02/21 18:00	0	X		0	X		0											
03/02/21 19:00	0	X		0	X		0											
03/02/21 20:00	0	X		0	X		0											
03/02/21 21:00	0	X		0	X		0											
03/02/21 22:00	0	X		0	X		0											
03/02/21 23:00	0	X		0	X		0											
03/03/21 0:00	0	X		0	X		0											
03/03/21 1:00	0	X		0	X		0											
03/03/21 2:00	0	X		0	X		0											
03/03/21 3:00	0	X		0	X		0											
03/03/21 4:00	0	X		0	X		0											
03/03/21 5:00	0	X		0	X		0											
03/03/21 6:00	0	X		0	X		0											
03/03/21 7:00	0	X		0	X		0											
03/03/21 8:00	0	X		0	X		0											
03/03/21 9:00	0	X		0	X		0											
03/03/21 10:00	0	X		0	X		0											
03/03/21 11:00	0	X		0	X		0											
03/03/21 12:00	0	X		0	X		0											
03/03/21 13:00	0	X		0	X		0											
03/03/21 14:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
03/03/21 15:00	0	X		0	X		0											
03/03/21 16:00	0	X		0	X		0											
03/03/21 17:00	0	X		0	X		0											
03/03/21 18:00	0	X		0	X		0											
03/03/21 19:00	0	X		0	X		0											
03/03/21 20:00	0	X		0	X		0											
03/03/21 21:00	0	X		0	X		0											
03/03/21 22:00	0	X		0	X		0											
03/03/21 23:00	0	X		0	X		0											
03/04/21 0:00	0	X		0	X		0											
03/04/21 1:00	0	X		0	X		0											
03/04/21 2:00	0	X		0	X		0											
03/04/21 3:00	0	X		0	X		0											
03/04/21 4:00	0	X		0	X		0											
03/04/21 5:00	0	X		0	X		0											
03/04/21 6:00	0	X		0	X		0											
03/04/21 7:00	0	X		0	X		0											
03/04/21 8:00	0	X		0	X		0											
03/04/21 9:00	0	X		0	X		0											
03/04/21 10:00	0	X		0	X		0											
03/04/21 11:00	0	X		0	X		0											
03/04/21 12:00	0	X		0	X		0											
03/04/21 13:00	0	X		0	X		0											
03/04/21 14:00	0	X		0	X		0											
03/04/21 15:00	0	X		0	X		0											
03/04/21 16:00	0	X		0	X		0											
03/04/21 17:00	0	X		0	X		0											
03/04/21 18:00	0	X		0	X		0											
03/04/21 19:00	0	X		0	X		0											
03/04/21 20:00	0	X		0	X		0											
03/04/21 21:00	0	X		0	X		0											
03/04/21 22:00	0	X		0	X		0											
03/04/21 23:00	0	X		0	X		0											
03/05/21 0:00	0	X		0	X		0											
03/05/21 1:00	0	X		0	X		0											
03/05/21 2:00	0	X		0	X		0											
03/05/21 3:00	0	X		0	X		0											
03/05/21 4:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
03/05/21 5:00	0	X		0	X		0											
03/05/21 6:00	0	X		0	X		0											
03/05/21 7:00	0	X		0	X		0											
03/05/21 8:00	0	X		0	X		0											
03/05/21 9:00	0	X		0	X		0											
03/05/21 10:00	0	X		0	X		0											
03/05/21 11:00	0	X		0	X		0											
03/05/21 12:00	0	X		0	X		0											
03/05/21 13:00	0	X		0	X		0											
03/05/21 14:00	0	X		0	X		0											
03/05/21 15:00	0	X		0	X		0											
03/05/21 16:00	0	X		0	X		0											
03/05/21 17:00	0	X		0	X		0											
03/05/21 18:00	0	X		0	X		0											
03/05/21 19:00	0	X		0	X		0											
03/05/21 20:00	0	X		0	X		0											
03/05/21 21:00	0	X		0	X		0											
03/05/21 22:00	0	X		0	X		0											
03/05/21 23:00	0	X		0	X		0											
03/06/21 0:00	0	X		0	X		0											
03/06/21 1:00	0	X		0	X		0											
03/06/21 2:00	0	X		0	X		0											
03/06/21 3:00	0	X		0	X		0											
03/06/21 4:00	0	X		0	X		0											
03/06/21 5:00	0	X		0	X		0											
03/06/21 6:00	0	X		0	X		0											
03/06/21 7:00	0	X		0	X		0											
03/06/21 8:00	0	X		0.141			0.13											
03/06/21 9:00	0	X		0.20172			0.2											
03/06/21 10:00	0	X		0.18492			0.18											
03/06/21 11:00	0	X		0.18426			0.18											
03/06/21 12:00	0	X		0.30414			0.3											
03/06/21 13:00	0	X		0.30642			0.31											
03/06/21 14:00	0	X		0.30078			0.3											
03/06/21 15:00	0	X		0.2565			0.26											
03/06/21 16:00	0	X		0.2517			0.25											
03/06/21 17:00	0	X		0.12324			0.01											
03/06/21 18:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/06/21 19:00	0	X		0	X		0											
03/06/21 20:00	0	X		0	X		0											
03/06/21 21:00	0	X		0	X		0											
03/06/21 22:00	0	X		0	X		0											
03/06/21 23:00	0	X		0	X		0											
03/07/21 0:00	0	X		0	X		0											
03/07/21 1:00	0	X		0	X		0											
03/07/21 2:00	0	X		0	X		0											
03/07/21 3:00	0	X		0	X		0											
03/07/21 4:00	0	X		0	X		0											
03/07/21 5:00	0	X		0	X		0											
03/07/21 6:00	0	X		0	X		0											
03/07/21 7:00	0	X		0	X		0											
03/07/21 8:00	0	X		0	X		0											
03/07/21 9:00	0	X		0	X		0											
03/07/21 10:00	0	X		0	X		0											
03/07/21 11:00	0	X		0	X		0											
03/07/21 12:00	0	X		0	X		0											
03/07/21 13:00	0	X		0	X		0											
03/07/21 14:00	0	X		0	X		0											
03/07/21 15:00	0	X		0	X		0											
03/07/21 16:00	0	X		0	X		0											
03/07/21 17:00	0	X		0	X		0											
03/07/21 18:00	0	X		0	X		0											
03/07/21 19:00	0	X		0	X		0											
03/07/21 20:00	0	X		0	X		0											
03/07/21 21:00	0	X		0	X		0											
03/07/21 22:00	0	X		0	X		0											
03/07/21 23:00	0	X		0	X		0											
03/08/21 0:00	0	X		0	X		0											
03/08/21 1:00	0	X		0	X		0											
03/08/21 2:00	0	X		0	X		0											
03/08/21 3:00	0	X		0	X		0											
03/08/21 4:00	0	X		0	X		0											
03/08/21 5:00	0	X		0	X		0											
03/08/21 6:00	0	X		0	X		0											
03/08/21 7:00	0	X		0	X		0											
03/08/21 8:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/08/21 9:00	0.0291			0	X		0											
03/08/21 10:00	0.06156			0	X		0.02											
03/08/21 11:00	0	X		0	X		0											
03/08/21 12:00	0	X		0	X		0											
03/08/21 13:00	0.03204			0	X		0											
03/08/21 14:00	0.08436			0	X		0.02											
03/08/21 15:00	0.20082			0	X		0.2											
03/08/21 16:00	0.29196			0	X		0.29											
03/08/21 17:00	0.29376			0	X		0.29											
03/08/21 18:00	0.29442			0	X		0.29											
03/08/21 19:00	0.2841			0	X		0.28											
03/08/21 20:00	0.13812			0	X		0.02											
03/08/21 21:00	0	X		0	X		0											
03/08/21 22:00	0	X		0	X		0											
03/08/21 23:00	0	X		0	X		0											
03/09/21 0:00	0	X		0	X		0											
03/09/21 1:00	0	X		0	X		0											
03/09/21 2:00	0	X		0	X		0											
03/09/21 3:00	0	X		0	X		0											
03/09/21 4:00	0	X		0	X		0											
03/09/21 5:00	0	X		0	X		0											
03/09/21 6:00	0	X		0	X		0											
03/09/21 7:00	0	X		0	X		0											
03/09/21 8:00	0	X		0	X		0											
03/09/21 9:00	0	X		0	X		0											
03/09/21 10:00	0	X		0	X		0											
03/09/21 11:00	0	X		0	X		0											
03/09/21 12:00	0	X		0	X		0											
03/09/21 13:00	0	X		0	X		0											
03/09/21 14:00	0	X		0	X		0											
03/09/21 15:00	0	X		0	X		0											
03/09/21 16:00	0	X		0	X		0											
03/09/21 17:00	0	X		0	X		0											
03/09/21 18:00	0	X		0	X		0											
03/09/21 19:00	0	X		0	X		0											
03/09/21 20:00	0	X		0	X		0											
03/09/21 21:00	0	X		0	X		0											
03/09/21 22:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
03/09/21 23:00	0	X		0	X		0											
03/10/21 0:00	0	X		0	X		0											
03/10/21 1:00	0	X		0	X		0											
03/10/21 2:00	0	X		0	X		0											
03/10/21 3:00	0	X		0	X		0											
03/10/21 4:00	0	X		0	X		0											
03/10/21 5:00	0	X		0	X		0											
03/10/21 6:00	0	X		0	X		0											
03/10/21 7:00	0	X		0	X		0											
03/10/21 8:00	0	X		0	X		0											
03/10/21 9:00	0	X		0	X		0											
03/10/21 10:00	0	X		0	X		0											
03/10/21 11:00	0.09234			0	X		0.03											
03/10/21 12:00	0.15522			0	X		0.16											
03/10/21 13:00	0.16704			0	X		0.17											
03/10/21 14:00	0.20706			0	X		0.21											
03/10/21 15:00	0.28038			0	X		0.28											
03/10/21 16:00	0.29304			0	X		0.29											
03/10/21 17:00	0.29322			0	X		0.29											
03/10/21 18:00	0.2868			0	X		0.29											
03/10/21 19:00	0.14856			0	X		0.03											
03/10/21 20:00	0	X		0	X		0											
03/10/21 21:00	0	X		0	X		0											
03/10/21 22:00	0	X		0	X		0											
03/10/21 23:00	0	X		0	X		0											
03/11/21 0:00	0	X		0	X		0											
03/11/21 1:00	0	X		0	X		0											
03/11/21 2:00	0	X		0	X		0											
03/11/21 3:00	0	X		0	X		0											
03/11/21 4:00	0	X		0	X		0											
03/11/21 5:00	0	X		0	X		0											
03/11/21 6:00	0	X		0	X		0											
03/11/21 7:00	0	X		0	X		0											
03/11/21 8:00	0	X		0	X		0											
03/11/21 9:00	0	X		0	X		0											
03/11/21 10:00	0	X		0	X		0											
03/11/21 11:00	0	X		0	X		0											
03/11/21 12:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
03/11/21 13:00	0	X		0	X		0											
03/11/21 14:00	0	X		0	X		0											
03/11/21 15:00	0	X		0	X		0											
03/11/21 16:00	0	X		0	X		0											
03/11/21 17:00	0	X		0	X		0											
03/11/21 18:00	0	X		0	X		0											
03/11/21 19:00	0	X		0	X		0											
03/11/21 20:00	0	X		0	X		0											
03/11/21 21:00	0	X		0	X		0											
03/11/21 22:00	0	X		0	X		0											
03/11/21 23:00	0	X		0	X		0											
03/12/21 0:00	0	X		0	X		0											
03/12/21 1:00	0	X		0	X		0											
03/12/21 2:00	0	X		0	X		0											
03/12/21 3:00	0	X		0	X		0											
03/12/21 4:00	0	X		0	X		0											
03/12/21 5:00	0	X		0	X		0											
03/12/21 6:00	0	X		0	X		0											
03/12/21 7:00	0	X		0	X		0											
03/12/21 8:00	0	X		0	X		0											
03/12/21 9:00	0	X		0	X		0											
03/12/21 10:00	0	X		0	X		0											
03/12/21 11:00	0	X		0	X		0											
03/12/21 12:00	0.02316			0	X		0											
03/12/21 13:00	0.0333			0	X		0.01											
03/12/21 14:00	0.14136			0.01212			0.1											
03/12/21 15:00	0	X		0.01818			0											
03/12/21 16:00	0	X		0	X		0											
03/12/21 17:00	0	X		0.02466			0											
03/12/21 18:00	0	X		0	X		0											
03/12/21 19:00	0	X		0	X		0											
03/12/21 20:00	0	X		0	X		0											
03/12/21 21:00	0	X		0	X		0											
03/12/21 22:00	0	X		0	X		0											
03/12/21 23:00	0	X		0	X		0											
03/13/21 0:00	0	X		0	X		0											
03/13/21 1:00	0	X		0	X		0											
03/13/21 2:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
03/13/21 3:00	0	X		0	X		0											
03/13/21 4:00	0	X		0	X		0											
03/13/21 5:00	0	X		0	X		0											
03/13/21 6:00	0	X		0	X		0											
03/13/21 7:00	0.00978			0	X		0											
03/13/21 8:00	0.09642			0	X		0.05											
03/13/21 9:00	0.24066			0	X		0.24											
03/13/21 10:00	0.20718			0	X		0.21											
03/13/21 11:00	0.24234			0.08934			0.27											
03/13/21 12:00	0.28524			0.2973			0.58											
03/13/21 13:00	0.28368			0.30378			0.59											
03/13/21 14:00	0.40542			0.43038			0.84											
03/13/21 15:00	0.41316			0.43122			0.84											
03/13/21 16:00	0.41358			0.43128			0.84											
03/13/21 17:00	0.2838			0.30312			0.59											
03/13/21 18:00	0.13206			0.16986			0.19											
03/13/21 19:00	0	X		0.24222			0.24											
03/13/21 20:00	0	X		0.24882			0.25											
03/13/21 21:00	0	X		0.3045			0.3											
03/13/21 22:00	0	X		0.13488			0.02											
03/13/21 23:00	0	X		0	X		0											
03/14/21 0:00	0	X		0	X		0											
03/14/21 1:00	0	X		0	X		0											
03/14/21 2:00	0	X		0	X		0											
03/14/21 3:00	0	X		0	X		0											
03/14/21 4:00	0	X		0	X		0											
03/14/21 5:00	0	X		0	X		0											
03/14/21 6:00	0	X		0	X		0											
03/14/21 7:00	0	X		0	X		0											
03/14/21 8:00	0	X		0	X		0											
03/14/21 9:00	0	X		0	X		0											
03/14/21 10:00	0	X		0	X		0											
03/14/21 11:00	0	X		0	X		0											
03/14/21 12:00	0	X		0	X		0											
03/14/21 13:00	0	X		0	X		0											
03/14/21 14:00	0	X		0	X		0											
03/14/21 15:00	0	X		0	X		0											
03/14/21 16:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/14/21 17:00	0	X		0	X		0											
03/14/21 18:00	0	X		0	X		0											
03/14/21 19:00	0	X		0	X		0											
03/14/21 20:00	0	X		0	X		0											
03/14/21 21:00	0	X		0	X		0											
03/14/21 22:00	0	X		0	X		0											
03/14/21 23:00	0	X		0	X		0											
03/15/21 0:00	0	X		0	X		0											
03/15/21 1:00	0	X		0	X		0											
03/15/21 2:00	0	X		0	X		0											
03/15/21 3:00	0	X		0	X		0											
03/15/21 4:00	0	X		0	X		0											
03/15/21 5:00	0	X		0	X		0											
03/15/21 6:00	0	X		0	X		0											
03/15/21 7:00	0	X		0	X		0											
03/15/21 8:00	0	X		0	X		0											
03/15/21 9:00	0	X		0	X		0											
03/15/21 10:00	0	X		0	X		0											
03/15/21 11:00	0	X		0	X		0											
03/15/21 12:00	0	X		0	X		0											
03/15/21 13:00	0	X		0	X		0											
03/15/21 14:00	0	X		0	X		0											
03/15/21 15:00	0	X		0	X		0											
03/15/21 16:00	0	X		0	X		0											
03/15/21 17:00	0	X		0	X		0											
03/15/21 18:00	0	X		0	X		0											
03/15/21 19:00	0	X		0	X		0											
03/15/21 20:00	0	X		0	X		0											
03/15/21 21:00	0	X		0	X		0											
03/15/21 22:00	0	X		0	X		0											
03/15/21 23:00	0	X		0	X		0											
03/16/21 0:00	0	X		0	X		0											
03/16/21 1:00	0	X		0	X		0											
03/16/21 2:00	0	X		0	X		0											
03/16/21 3:00	0	X		0	X		0											
03/16/21 4:00	0	X		0	X		0											
03/16/21 5:00	0	X		0	X		0											
03/16/21 6:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/16/21 7:00	0	X		0	X		0											
03/16/21 8:00	0	X		0	X		0											
03/16/21 9:00	0	X		0	X		0											
03/16/21 10:00	0	X		0	X		0											
03/16/21 11:00	0	X		0	X		0											
03/16/21 12:00	0	X		0	X		0											
03/16/21 13:00	0	X		0	X		0											
03/16/21 14:00	0	X		0	X		0											
03/16/21 15:00	0	X		0	X		0											
03/16/21 16:00	0	X		0	X		0											
03/16/21 17:00	0	X		0	X		0											
03/16/21 18:00	0	X		0	X		0											
03/16/21 19:00	0	X		0	X		0											
03/16/21 20:00	0	X		0	X		0											
03/16/21 21:00	0	X		0	X		0											
03/16/21 22:00	0	X		0	X		0											
03/16/21 23:00	0	X		0	X		0											
03/17/21 0:00	0	X		0	X		0											
03/17/21 1:00	0	X		0	X		0											
03/17/21 2:00	0	X		0	X		0											
03/17/21 3:00	0	X		0	X		0											
03/17/21 4:00	0	X		0	X		0											
03/17/21 5:00	0	X		0	X		0											
03/17/21 6:00	0	X		0	X		0											
03/17/21 7:00	0	X		0	X		0											
03/17/21 8:00	0	X		0	X		0											
03/17/21 9:00	0	X		0	X		0											
03/17/21 10:00	0	X		0	X		0											
03/17/21 11:00	0	X		0	X		0											
03/17/21 12:00	0	X		0	X		0											
03/17/21 13:00	0	X		0	X		0											
03/17/21 14:00	0	X		0	X		0											
03/17/21 15:00	0	X		0	X		0											
03/17/21 16:00	0	X		0	X		0											
03/17/21 17:00	0	X		0	X		0											
03/17/21 18:00	0	X		0	X		0											
03/17/21 19:00	0	X		0	X		0											
03/17/21 20:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/17/21 21:00	0	X		0	X		0											
03/17/21 22:00	0	X		0	X		0											
03/17/21 23:00	0	X		0	X		0											
03/18/21 0:00	0	X		0	X		0											
03/18/21 1:00	0	X		0	X		0											
03/18/21 2:00	0	X		0	X		0											
03/18/21 3:00	0	X		0	X		0											
03/18/21 4:00	0	X		0	X		0											
03/18/21 5:00	0	X		0	X		0											
03/18/21 6:00	0	X		0	X		0											
03/18/21 7:00	0	X		0	X		0											
03/18/21 8:00	0	X		0	X		0											
03/18/21 9:00	0	X		0	X		0											
03/18/21 10:00	0	X		0	X		0											
03/18/21 11:00	0	X		0	X		0											
03/18/21 12:00	0	X		0	X		0											
03/18/21 13:00	0	X		0	X		0											
03/18/21 14:00	0	X		0	X		0											
03/18/21 15:00	0	X		0	X		0											
03/18/21 16:00	0	X		0	X		0											
03/18/21 17:00	0	X		0	X		0											
03/18/21 18:00	0	X		0	X		0											
03/18/21 19:00	0	X		0	X		0											
03/18/21 20:00	0	X		0	X		0											
03/18/21 21:00	0	X		0	X		0											
03/18/21 22:00	0	X		0	X		0											
03/18/21 23:00	0	X		0	X		0											
03/19/21 0:00	0	X		0	X		0											
03/19/21 1:00	0	X		0	X		0											
03/19/21 2:00	0	X		0	X		0											
03/19/21 3:00	0	X		0	X		0											
03/19/21 4:00	0	X		0	X		0											
03/19/21 5:00	0	X		0	X		0											
03/19/21 6:00	0	X		0	X		0											
03/19/21 7:00	0	X		0	X		0											
03/19/21 8:00	0	X		0	X		0											
03/19/21 9:00	0	X		0	X		0											
03/19/21 10:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/19/21 11:00	0	X		0	X		0											
03/19/21 12:00	0	X		0	X		0											
03/19/21 13:00	0	X		0	X		0											
03/19/21 14:00	0	X		0	X		0											
03/19/21 15:00	0	X		0	X		0											
03/19/21 16:00	0	X		0	X		0											
03/19/21 17:00	0	X		0	X		0											
03/19/21 18:00	0	X		0	X		0											
03/19/21 19:00	0	X		0	X		0											
03/19/21 20:00	0	X		0	X		0											
03/19/21 21:00	0	X		0	X		0											
03/19/21 22:00	0	X		0	X		0											
03/19/21 23:00	0	X		0	X		0											
03/20/21 0:00	0	X		0	X		0											
03/20/21 1:00	0	X		0	X		0											
03/20/21 2:00	0	X		0	X		0											
03/20/21 3:00	0	X		0	X		0											
03/20/21 4:00	0	X		0	X		0											
03/20/21 5:00	0	X		0	X		0											
03/20/21 6:00	0	X		0	X		0											
03/20/21 7:00	0	X		0	X		0											
03/20/21 8:00	0	X		0	X		0											
03/20/21 9:00	0	X		0	X		0											
03/20/21 10:00	0	X		0	X		0											
03/20/21 11:00	0	X		0	X		0											
03/20/21 12:00	0	X		0	X		0											
03/20/21 13:00	0	X		0	X		0											
03/20/21 14:00	0	X		0	X		0											
03/20/21 15:00	0	X		0	X		0											
03/20/21 16:00	0	X		0	X		0											
03/20/21 17:00	0	X		0	X		0											
03/20/21 18:00	0	X		0	X		0											
03/20/21 19:00	0	X		0	X		0											
03/20/21 20:00	0	X		0	X		0											
03/20/21 21:00	0	X		0	X		0											
03/20/21 22:00	0	X		0	X		0											
03/20/21 23:00	0	X		0	X		0											
03/21/21 0:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/21/21 1:00	0	X		0	X		0											
03/21/21 2:00	0	X		0	X		0											
03/21/21 3:00	0	X		0	X		0											
03/21/21 4:00	0	X		0	X		0											
03/21/21 5:00	0	X		0	X		0											
03/21/21 6:00	0	X		0	X		0											
03/21/21 7:00	0	X		0	X		0											
03/21/21 8:00	0	X		0	X		0											
03/21/21 9:00	0	X		0	X		0											
03/21/21 10:00	0	X		0	X		0											
03/21/21 11:00	0	X		0	X		0											
03/21/21 12:00	0	X		0	X		0											
03/21/21 13:00	0	X		0	X		0											
03/21/21 14:00	0	X		0	X		0											
03/21/21 15:00	0	X		0	X		0											
03/21/21 16:00	0	X		0	X		0											
03/21/21 17:00	0	X		0	X		0											
03/21/21 18:00	0	X		0	X		0											
03/21/21 19:00	0	X		0	X		0											
03/21/21 20:00	0	X		0	X		0											
03/21/21 21:00	0	X		0	X		0											
03/21/21 22:00	0	X		0	X		0											
03/21/21 23:00	0	X		0	X		0											
03/22/21 0:00	0	X		0	X		0											
03/22/21 1:00	0	X		0	X		0											
03/22/21 2:00	0	X		0	X		0											
03/22/21 3:00	0	X		0	X		0											
03/22/21 4:00	0	X		0	X		0											
03/22/21 5:00	0	X		0.11142			0.04											
03/22/21 6:00	0	X		0.17928			0.18											
03/22/21 7:00	0	X		0.17694			0.15											
03/22/21 8:00	0	X		0.23292			0.2											
03/22/21 9:00	0	X		0.30954			0.31											
03/22/21 10:00	0	X		0.20514			0.21											
03/22/21 11:00	0	X		0.3534			0.35											
03/22/21 12:00	0	X		0.4197			0.42											
03/22/21 13:00	0	X		0.33414			0.33											
03/22/21 14:00	0	X		0.43074			0.43											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
03/22/21 15:00	0	X		0.26226			0.26											
03/22/21 16:00	0	X		0.18678			0.19											
03/22/21 17:00	0	X		0.183			0.18											
03/22/21 18:00	0	X		0.1827			0.18											
03/22/21 19:00	0	X		0.18522			0.19											
03/22/21 20:00	0	X		0.18642			0.19											
03/22/21 21:00	0	X		0.18744			0.19											
03/22/21 22:00	0	X		0.18774			0.19											
03/22/21 23:00	0	X		0.1872			0.19											
03/23/21 0:00	0	X		0.18732			0.19											
03/23/21 1:00	0	X		0.18738			0.19											
03/23/21 2:00	0	X		0.1872			0.19											
03/23/21 3:00	0	X		0.18726			0.19											
03/23/21 4:00	0	X		0.18726			0.19											
03/23/21 5:00	0	X		0.18654			0.19											
03/23/21 6:00	0	X		0.18522			0.19											
03/23/21 7:00	0	X		0.18846			0.19											
03/23/21 8:00	0	X		0.31434			0.31											
03/23/21 9:00	0.02598			0.30744			0.31											
03/23/21 10:00	0.14064			0.3003			0.38											
03/23/21 11:00	0.2685			0.30828			0.58											
03/23/21 12:00	0.35424			0.42234			0.78											
03/23/21 13:00	0.27882			0.29826			0.58											
03/23/21 14:00	0.33462			0.1302			0.35											
03/23/21 15:00	0.40368			0	X		0.4											
03/23/21 16:00	0.31968			0	X		0.32											
03/23/21 17:00	0.189			0	X		0.19											
03/23/21 18:00	0.17208			0	X		0.17											
03/23/21 19:00	0.17454			0	X		0.17											
03/23/21 20:00	0.17658			0	X		0.18											
03/23/21 21:00	0.1752			0	X		0.18											
03/23/21 22:00	0.1749			0	X		0.17											
03/23/21 23:00	0.17424			0	X		0.17											
03/24/21 0:00	0.1737			0	X		0.17											
03/24/21 1:00	0.17418			0	X		0.17											
03/24/21 2:00	0.17454			0	X		0.17											
03/24/21 3:00	0.1746			0	X		0.17											
03/24/21 4:00	0.17436			0	X		0.17											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/24/21 5:00	0.17448			0	X		0.17											
03/24/21 6:00	0.1743			0	X		0.17											
03/24/21 7:00	0.18684			0	X		0.19											
03/24/21 8:00	0.37824			0.0945			0.4											
03/24/21 9:00	0.21342			0.22698			0.44											
03/24/21 10:00	0.39648			0.41808			0.81											
03/24/21 11:00	0.22782			0.25494			0.48											
03/24/21 12:00	0.08748			0.3462			0.35											
03/24/21 13:00	0	X		0.26814			0.27											
03/24/21 14:00	0	X		0.39606			0.4											
03/24/21 15:00	0	X		0.18786			0.19											
03/24/21 16:00	0	X		0.08502			0.01											
03/24/21 17:00	0	X		0	X		0											
03/24/21 18:00	0	X		0	X		0											
03/24/21 19:00	0	X		0	X		0											
03/24/21 20:00	0	X		0	X		0											
03/24/21 21:00	0	X		0	X		0											
03/24/21 22:00	0	X		0	X		0											
03/24/21 23:00	0	X		0	X		0											
03/25/21 0:00	0	X		0	X		0											
03/25/21 1:00	0	X		0	X		0											
03/25/21 2:00	0	X		0	X		0											
03/25/21 3:00	0	X		0	X		0											
03/25/21 4:00	0	X		0	X		0											
03/25/21 5:00	0	X		0	X		0											
03/25/21 6:00	0	X		0.09786			0.02											
03/25/21 7:00	0	X		0.26352			0.26											
03/25/21 8:00	0	X		0.26298			0.26											
03/25/21 9:00	0	X		0.21672			0.22											
03/25/21 10:00	0	X		0.22338			0.22											
03/25/21 11:00	0	X		0.15954			0.03											
03/25/21 12:00	0	X		0	X		0											
03/25/21 13:00	0	X		0	X		0											
03/25/21 14:00	0	X		0	X		0											
03/25/21 15:00	0	X		0	X		0											
03/25/21 16:00	0	X		0	X		0											
03/25/21 17:00	0	X		0	X		0											
03/25/21 18:00	0	X		0	X		0											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc									
03/25/21 19:00	0	X		0	X		0											
03/25/21 20:00	0	X		0	X		0											
03/25/21 21:00	0	X		0	X		0											
03/25/21 22:00	0	X		0	X		0											
03/25/21 23:00	0	X		0	X		0											
03/26/21 0:00	0	X		0	X		0											
03/26/21 1:00	0	X		0	X		0											
03/26/21 2:00	0	X		0	X		0											
03/26/21 3:00	0	X		0	X		0											
03/26/21 4:00	0	X		0	X		0											
03/26/21 5:00	0	X		0	X		0											
03/26/21 6:00	0	X		0	X		0											
03/26/21 7:00	0	X		0	X		0											
03/26/21 8:00	0	X		0	X		0											
03/26/21 9:00	0	X		0	X		0											
03/26/21 10:00	0	X		0	X		0											
03/26/21 11:00	0	X		0	X		0											
03/26/21 12:00	0	X		0	X		0											
03/26/21 13:00	0	X		0	X		0											
03/26/21 14:00	0	X		0	X		0											
03/26/21 15:00	0	X		0	X		0											
03/26/21 16:00	0	X		0	X		0											
03/26/21 17:00	0	X		0	X		0											
03/26/21 18:00	0	X		0	X		0											
03/26/21 19:00	0	X		0	X		0											
03/26/21 20:00	0	X		0	X		0											
03/26/21 21:00	0	X		0	X		0											
03/26/21 22:00	0	X		0	X		0											
03/26/21 23:00	0	X		0	X		0											
03/27/21 0:00	0	X		0	X		0											
03/27/21 1:00	0	X		0	X		0											
03/27/21 2:00	0	X		0	X		0											
03/27/21 3:00	0	X		0	X		0											
03/27/21 4:00	0	X		0	X		0											
03/27/21 5:00	0	X		0	X		0											
03/27/21 6:00	0	X		0	X		0											
03/27/21 7:00	0	X		0	X		0											
03/27/21 8:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/27/21 9:00	0	X		0	X		0											
03/27/21 10:00	0	X		0	X		0											
03/27/21 11:00	0	X		0	X		0											
03/27/21 12:00	0	X		0	X		0											
03/27/21 13:00	0	X		0	X		0											
03/27/21 14:00	0	X		0	X		0											
03/27/21 15:00	0	X		0	X		0											
03/27/21 16:00	0	X		0	X		0											
03/27/21 17:00	0	X		0	X		0											
03/27/21 18:00	0	X		0	X		0											
03/27/21 19:00	0	X		0	X		0											
03/27/21 20:00	0	X		0	X		0											
03/27/21 21:00	0	X		0	X		0											
03/27/21 22:00	0	X		0	X		0											
03/27/21 23:00	0	X		0	X		0											
03/28/21 0:00	0	X		0	X		0											
03/28/21 1:00	0	X		0	X		0											
03/28/21 2:00	0	X		0	X		0											
03/28/21 3:00	0	X		0	X		0											
03/28/21 4:00	0	X		0	X		0											
03/28/21 5:00	0	X		0	X		0											
03/28/21 6:00	0	X		0	X		0											
03/28/21 7:00	0	X		0	X		0											
03/28/21 8:00	0	X		0	X		0											
03/28/21 9:00	0	X		0	X		0											
03/28/21 10:00	0	X		0	X		0											
03/28/21 11:00	0	X		0	X		0											
03/28/21 12:00	0	X		0	X		0											
03/28/21 13:00	0	X		0	X		0											
03/28/21 14:00	0	X		0	X		0											
03/28/21 15:00	0	X		0	X		0											
03/28/21 16:00	0	X		0	X		0											
03/28/21 17:00	0	X		0	X		0											
03/28/21 18:00	0	X		0	X		0											
03/28/21 19:00	0	X		0	X		0											
03/28/21 20:00	0	X		0	X		0											
03/28/21 21:00	0	X		0	X		0											
03/28/21 22:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/28/21 23:00	0	X		0	X		0											
03/29/21 0:00	0	X		0	X		0											
03/29/21 1:00	0	X		0	X		0											
03/29/21 2:00	0	X		0	X		0											
03/29/21 3:00	0	X		0	X		0											
03/29/21 4:00	0	X		0	X		0											
03/29/21 5:00	0	X		0	X		0											
03/29/21 6:00	0	X		0	X		0											
03/29/21 7:00	0	X		0	X		0											
03/29/21 8:00	0	X		0	X		0											
03/29/21 9:00	0	X		0	X		0											
03/29/21 10:00	0	X		0	X		0											
03/29/21 11:00	0	X		0	X		0											
03/29/21 12:00	0	X		0	X		0											
03/29/21 13:00	0	X		0	X		0											
03/29/21 14:00	0	X		0	X		0											
03/29/21 15:00	0	X		0	X		0											
03/29/21 16:00	0	X		0	X		0											
03/29/21 17:00	0	X		0	X		0											
03/29/21 18:00	0	X		0	X		0											
03/29/21 19:00	0	X		0	X		0											
03/29/21 20:00	0	X		0	X		0											
03/29/21 21:00	0	X		0	X		0											
03/29/21 22:00	0	X		0	X		0											
03/29/21 23:00	0	X		0	X		0											
03/30/21 0:00	0	X		0	X		0											
03/30/21 1:00	0	X		0	X		0											
03/30/21 2:00	0	X		0	X		0											
03/30/21 3:00	0	X		0	X		0											
03/30/21 4:00	0	X		0	X		0											
03/30/21 5:00	0	X		0	X		0											
03/30/21 6:00	0	X		0	X		0											
03/30/21 7:00	0	X		0	X		0											
03/30/21 8:00	0	X		0	X		0											
03/30/21 9:00	0	X		0	X		0											
03/30/21 10:00	0	X		0	X		0											
03/30/21 11:00	0	X		0	X		0											
03/30/21 12:00	0	X		0	X		0											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/30/21 13:00	0	X		0	X		0											
03/30/21 14:00	0	X		0	X		0											
03/30/21 15:00	0	X		0	X		0											
03/30/21 16:00	0	X		0	X		0											
03/30/21 17:00	0	X		0	X		0											
03/30/21 18:00	0	X		0	X		0											
03/30/21 19:00	0	X		0	X		0											
03/30/21 20:00	0	X		0	X		0											
03/30/21 21:00	0	X		0	X		0											
03/30/21 22:00	0	X		0	X		0											
03/30/21 23:00	0	X		0	X		0											
03/31/21 0:00	0	X		0	X		0											
03/31/21 1:00	0	X		0	X		0											
03/31/21 2:00	0	X		0	X		0											
03/31/21 3:00	0	X		0	X		0											
03/31/21 4:00	0	X		0	X		0											
03/31/21 5:00	0	X		0	X		0											
03/31/21 6:00	0	X		0	X		0											
03/31/21 7:00	0	X		0	X		0											
03/31/21 8:00	0	X		0	X		0											
03/31/21 9:00	0	X		0	X		0											
03/31/21 10:00	0	X		0	X		0											
03/31/21 11:00	0	X		0	X		0											
03/31/21 12:00	0	X		0	X		0											
03/31/21 13:00	0	X		0	X		0											
03/31/21 14:00	0	X		0	X		0											
03/31/21 15:00	0	X		0	X		0											
03/31/21 16:00	0	X		0	X		0											
03/31/21 17:00	0	X		0	X		0											
03/31/21 18:00	0	X		0	X		0											
03/31/21 19:00	0	X		0	X		0											
03/31/21 20:00	0	X		0	X		0											
03/31/21 21:00	0	X		0	X		0											
03/31/21 22:00	0	X		0	X		0											
03/31/21 23:00	0	X		0	X		0											

AQ-34

AQ-34 the Project owner shall maintain the following records: occurrence, duration, and type of any startup, shutdown, or malfunction: performance testing, evaluations, calibrations, check, adjustments, any period during which a continuous monitoring system or monitoring device was inoperative, maintenance of any continuous emission monitor; emission measurements, total daily and rolling twelve month averages hours of operation, hourly quantity of fuel used and gross three hour average operating load.

Verification; The Project owner shall submit to the CPM all data identified in this condition as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

Daily Calibration Results

CT1 and CT2

From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2021 14:49

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/24/21 03:18	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	01/24/21 03:28	200.0	180.2	181.5	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/24/21 03:18	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	01/24/21 03:24	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/24/21 03:18	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/24/21 03:28	200.0	180.5	179.9	R-A /Span * 100		0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/24/21 03:18	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/24/21 03:24	10.0	9.0	8.8	R-A /Span * 100		2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	01/24/21 03:18	21.0	18.2	18.1	R-A		0.1
	Zero	01/24/21 03:24	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/24/21 04:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	01/24/21 04:24	200.0	180.5	185.0	R-A /Span * 100		2.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/24/21 04:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	01/24/21 04:20	10.0	9.0	8.5	>1x Alert R-A /Span * 100		5.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/25/21 03:33	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	01/25/21 03:42	200.0	180.2	182.4	R-A /Span * 100		1.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/25/21 03:33	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	01/25/21 03:38	10.0	9.1	9.2	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/25/21 03:33	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/25/21 03:42	200.0	180.5	179.7	R-A /Span * 100		0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	01/25/21 03:33	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	01/25/21 03:38	10.0	9.0	8.8	R-A /Span * 100		2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	01/25/21 03:33	21.0	18.2	18.1	R-A		0.1
	Zero	01/25/21 03:38	21.0	0.0	0.0	R-A		0.0

Daily Calibration Results

CT1 and CT2

From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2021 14:49

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	01/25/21 04:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	01/25/21 04:25	200.0	180.5	183.3	R-A /Span * 100		1.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Warning	
	Zero	01/25/21 04:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	01/25/21 04:20	10.0	9.0	8.3	>2x R-A /Span * 100		7.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/26/21 11:52	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	02/26/21 12:02	200.0	181.9	183.2	R-A /Span * 100		0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/26/21 11:52	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	02/26/21 11:57	10.0	8.9	9.0	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/26/21 11:52	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/26/21 12:02	200.0	180.0	174.9	>1x Alert R-A /Span * 100		2.6
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/26/21 11:52	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/26/21 11:57	10.0	9.2	9.1	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	02/26/21 11:52	21.0	18.0	18.0	R-A		0.0
	Zero	02/26/21 11:57	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/27/21 13:17	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/27/21 13:26	200.0	180.0	180.3	R-A /Span * 100		0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/27/21 13:17	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/27/21 13:21	10.0	9.2	9.2	R-A /Span * 100		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/27/21 13:17	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	02/27/21 13:28	200.0	181.9	183.8	R-A /Span * 100		1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/27/21 13:17	10.0	0.0	0.2	R-A /Span * 100		2.0
	High	02/27/21 13:22	10.0	8.9	9.0	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/27/21 13:17	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/27/21 13:28	200.0	180.0	180.3	R-A /Span * 100		0.2

Daily Calibration Results

CT1 and CT2

From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2021 14:49

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/27/21 13:17	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	02/27/21 13:22	10.0	9.2	9.2	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	02/27/21 13:17	21.0	18.0	17.9	R-A		0.1
	Zero	02/27/21 13:22	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	02/27/21 13:34	200.0	0.0	0.2	R-A /Span * 100		0.1
	High	02/27/21 13:43	200.0	180.0	180.4	R-A /Span * 100		0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	02/27/21 13:34	10.0	0.0	0.2	R-A /Span * 100		2.0
	High	02/27/21 13:39	10.0	9.2	9.2	R-A /Span * 100		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/01/21 11:20	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	03/01/21 11:30	200.0	181.9	181.8	R-A /Span * 100		0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/01/21 11:20	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	03/01/21 11:25	10.0	8.9	8.8	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/01/21 11:20	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/01/21 11:30	200.0	180.0	175.8	R-A /Span * 100		2.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/01/21 11:20	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/01/21 11:25	10.0	9.2	9.1	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	03/01/21 11:20	21.0	18.0	17.9	R-A		0.1
	Zero	03/01/21 11:25	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/06/21 11:40	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	03/06/21 11:49	200.0	181.9	182.1	R-A /Span * 100		0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/06/21 11:40	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	03/06/21 11:44	10.0	8.9	8.8	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/06/21 11:40	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/06/21 11:49	200.0	180.0	175.6	R-A /Span * 100		2.2

Daily Calibration Results

CT1 and CT2

From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2021 14:49

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/06/21 11:40	10.0	0.0	R-A /Span * 100		0.0
	High	03/06/21 11:44	10.0	9.2	R-A /Span * 100		2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	03/06/21 11:40	21.0	18.0	R-A		0.1
	Zero	03/06/21 11:44	21.0	0.0	R-A		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/08/21 18:17	200.0	0.0	R-A /Span * 100		0.2
	High	03/08/21 18:27	200.0	180.2	R-A /Span * 100		0.8
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/08/21 18:17	10.0	0.0	R-A /Span * 100		3.0
	High	03/08/21 18:22	10.0	9.1	R-A /Span * 100		2.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/08/21 18:17	200.0	0.0	R-A /Span * 100		0.0
	High	03/08/21 18:27	200.0	180.5	R-A /Span * 100		0.8
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/08/21 18:17	10.0	0.0	R-A /Span * 100		0.0
	High	03/08/21 18:22	10.0	9.0	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	03/08/21 18:17	21.0	18.2	R-A		0.1
	Zero	03/08/21 18:22	21.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Offline	Pass	
	Zero	03/08/21 18:18	200.0	0.0	R-A /Span * 100		0.0
	High	03/08/21 18:28	200.0	181.9	R-A /Span * 100		0.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Offline	Pass	
	Zero	03/08/21 18:18	10.0	0.0	R-A /Span * 100		1.0
	High	03/08/21 18:23	10.0	8.9	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Offline	Offline	
	Zero	03/08/21 18:18	200.0	0.0	off R-A /Span * 100		0.0
	High	03/08/21 18:28	200.0	180.0	off R-A /Span * 100		0.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Offline	Offline	
	Zero	03/08/21 18:18	10.0	0.0	off R-A /Span * 100		0.0
	High	03/08/21 18:23	10.0	9.2	off R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Offline	Offline	
	High	03/08/21 18:18	21.0	18.0	off R-A		0.0
	Zero	03/08/21 18:23	21.0	0.0	off R-A		0.0

Daily Calibration Results

CT1 and CT2

From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2021 14:49

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/10/21 14:07	200.0	0.0	0.3	R-A /Span * 100		0.2
	High	03/10/21 14:17	200.0	180.2	182.5	R-A /Span * 100		1.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/10/21 14:07	10.0	0.0	0.3	R-A /Span * 100		3.0
	High	03/10/21 14:12	10.0	9.1	9.3	R-A /Span * 100		2.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/10/21 14:07	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/10/21 14:17	200.0	180.5	182.0	R-A /Span * 100		0.8
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/10/21 14:07	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/10/21 14:12	10.0	9.0	8.9	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	03/10/21 14:07	21.0	18.2	18.1	R-A		0.1
	Zero	03/10/21 14:12	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/13/21 10:50	200.0	0.0	0.3	R-A /Span * 100		0.2
	High	03/13/21 11:00	200.0	180.2	181.0	R-A /Span * 100		0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/13/21 10:50	10.0	0.0	0.3	R-A /Span * 100		3.0
	High	03/13/21 10:55	10.0	9.1	9.3	R-A /Span * 100		2.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/13/21 10:50	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/13/21 11:00	200.0	180.5	180.2	R-A /Span * 100		0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/13/21 10:50	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/13/21 10:55	10.0	9.0	8.8	R-A /Span * 100		2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	03/13/21 10:50	21.0	18.2	18.1	R-A		0.1
	Zero	03/13/21 10:55	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/13/21 12:58	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	03/13/21 13:08	200.0	181.9	182.2	R-A /Span * 100		0.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/13/21 12:58	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	03/13/21 13:03	10.0	8.9	8.9	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2021 14:49

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/13/21 12:58	200.0	0.0		R-A /Span * 100	0.0
	High	03/13/21 13:08	200.0	180.0		R-A /Span * 100	2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/13/21 12:58	10.0	0.0		R-A /Span * 100	0.0
	High	03/13/21 13:03	10.0	9.2		R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	03/13/21 12:58	21.0	18.0		R-A	0.1
	Zero	03/13/21 13:03	21.0	0.0		R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/13/21 13:47	200.0	0.0		R-A /Span * 100	0.0
	High	03/13/21 13:57	200.0	180.3		R-A /Span * 100	0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/13/21 13:47	10.0	0.0		R-A /Span * 100	0.0
	High	03/13/21 13:52	10.0	9.2		R-A /Span * 100	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/22/21 12:30	200.0	0.0		R-A /Span * 100	0.1
	High	03/22/21 12:40	200.0	181.9		R-A /Span * 100	0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/22/21 12:30	10.0	0.0		R-A /Span * 100	1.0
	High	03/22/21 12:35	10.0	8.9		R-A /Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/22/21 12:30	200.0	0.0		R-A /Span * 100	0.0
	High	03/22/21 12:40	200.0	180.0		R-A /Span * 100	2.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/22/21 12:30	10.0	0.0		R-A /Span * 100	0.0
	High	03/22/21 12:35	10.0	9.2		R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	03/22/21 12:30	21.0	18.0		R-A	0.1
	Zero	03/22/21 12:35	21.0	0.0		R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	03/23/21 04:14	200.0	0.0		R-A /Span * 100	0.0
	High	03/23/21 04:25	200.0	180.0		R-A /Span * 100	1.9
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	03/23/21 04:14	10.0	0.0		R-A /Span * 100	0.0
	High	03/23/21 04:19	10.0	9.2	8.8 >1x Alert	R-A /Span * 100	4.0

Daily Calibration Results

CT1 and CT2

From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2021 14:49

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/23/21 05:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/23/21 05:25	200.0	181.9	182.8	R-A /Span * 100		0.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/23/21 05:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/23/21 05:20	10.0	8.9	8.8	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/23/21 05:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/23/21 05:25	200.0	180.0	175.3	R-A /Span * 100		2.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/23/21 05:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/23/21 05:20	10.0	9.2	9.1	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	03/23/21 05:15	21.0	18.0	17.9	R-A		0.1
	Zero	03/23/21 05:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/23/21 13:12	200.0	0.0	0.3	R-A /Span * 100		0.2
	High	03/23/21 13:22	200.0	180.2	182.1	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/23/21 13:12	10.0	0.0	0.3	R-A /Span * 100		3.0
	High	03/23/21 13:17	10.0	9.1	9.4	R-A /Span * 100		3.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/23/21 13:12	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/23/21 13:22	200.0	180.5	181.6	R-A /Span * 100		0.6
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/23/21 13:12	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/23/21 13:17	10.0	9.0	8.9	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	03/23/21 13:12	21.0	18.2	18.1	R-A		0.1
	Zero	03/23/21 13:17	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Warning	
	Zero	03/24/21 04:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	03/24/21 04:25	200.0	180.5	168.4	>2x R-A /Span * 100		6.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Warning	
	Zero	03/24/21 04:15	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	03/24/21 04:20	10.0	9.0	8.1	>2x R-A /Span * 100		9.0

Daily Calibration Results

CT1 and CT2

From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2021 14:49

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/24/21 05:15	200.0	0.0	0.3	R-A /Span * 100		0.2
	High	03/24/21 05:25	200.0	180.2	182.4	R-A /Span * 100		1.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/24/21 05:15	10.0	0.0	0.3	R-A /Span * 100		3.0
	High	03/24/21 05:20	10.0	9.1	9.3	R-A /Span * 100		2.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/24/21 05:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/24/21 05:25	200.0	180.5	180.9	R-A /Span * 100		0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/24/21 05:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/24/21 05:20	10.0	9.0	8.8	R-A /Span * 100		2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	03/24/21 05:15	21.0	18.2	18.1	R-A		0.1
	Zero	03/24/21 05:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/24/21 08:10	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/24/21 08:21	200.0	180.5	180.8	R-A /Span * 100		0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/24/21 08:10	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/24/21 08:15	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/24/21 12:19	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	03/24/21 12:29	200.0	181.9	182.6	R-A /Span * 100		0.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/24/21 12:19	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	03/24/21 12:24	10.0	8.9	8.9	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/24/21 12:19	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/24/21 12:29	200.0	180.0	175.3	R-A /Span * 100		2.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/24/21 12:19	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/24/21 12:24	10.0	9.2	9.1	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	03/24/21 12:19	21.0	18.0	17.9	R-A		0.1
	Zero	03/24/21 12:24	21.0	0.0	0.0	R-A		0.0

Monthly Summary Report

Units CT1 and CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:49 Location: Roseville, CA

Date	Unit CT1 OperatingTime, Hr		Unit CT1 DBOn, Hr		Unit CT2 OperatingTime, Hr		Unit CT2 DBOn, Hr	
	1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)	
	Sum	Running Sum	Sum	Running Sum	Sum	Running Sum	Sum	Running Sum
Jan 21	48.29	48.29	19.00	19.00	0.00	0.00	0.00	0.00
Feb 21	0.00	48.29	0.00	19.00	14.37	14.37	0.00	0.00
Mar 21	49.96	98.25	9.11	28.11	73.12	87.49	13.80	13.80
Sum/Avg	98.25		28.11		87.49		13.80	

Tons 12 Month Rolling Summary

CT1 and CT2 Combined



From: 01/01/2021 00:00 **To:** 03/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2021 14:44 **Location:** Roseville, CA

* = Excess Emission

Date	Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2	
	CO, Ton		NOx, Ton		PM10, Ton		SO2, Ton		VOC, Ton	
	1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)	
	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum
Jan 2021	0.0375	2.3537	0.0714	7.4988	0.0127	1.4139	0.0064	0.7071	0.0212	2.3550
Feb 2021	0.1878	2.3603	0.0376	7.1818	0.0038	1.3539	0.0019	0.6771	0.0064	2.2550
Mar 2021	0.4389	2.7992	0.2429	7.4247	0.0306	1.3845	0.0155	0.6926	0.0512	2.3062
Sum/Avg	2.7992		7.4247		1.3845		0.6926		2.3062	
Limit Value										

AQ34 3HR AVG LOAD

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/01/21 0:00	0			0			0											
01/01/21 1:00	0			0			0											
01/01/21 2:00	0			0			0											
01/01/21 3:00	0			0			0											
01/01/21 4:00	0			0			0											
01/01/21 5:00	0			0			0											
01/01/21 6:00	0			0			0											
01/01/21 7:00	0			0			0											
01/01/21 8:00	0			0			0											
01/01/21 9:00	0			0			0											
01/01/21 10:00	0			0			0											
01/01/21 11:00	0			0			0											
01/01/21 12:00	0			0			0											
01/01/21 13:00	0			0			0											
01/01/21 14:00	0			0			0											
01/01/21 15:00	0			0			0											
01/01/21 16:00	0			0			0											
01/01/21 17:00	0			0			0											
01/01/21 18:00	0			0			0											
01/01/21 19:00	0			0			0											
01/01/21 20:00	0			0			0											
01/01/21 21:00	0			0			0											
01/01/21 22:00	0			0			0											
01/01/21 23:00	0			0			0											
01/02/21 0:00	0			0			0											
01/02/21 1:00	0			0			0											
01/02/21 2:00	0			0			0											
01/02/21 3:00	0			0			0											
01/02/21 4:00	0			0			0											
01/02/21 5:00	0			0			0											
01/02/21 6:00	0			0			0											
01/02/21 7:00	0			0			0											
01/02/21 8:00	0			0			0											
01/02/21 9:00	0			0			0											
01/02/21 10:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/02/21 11:00	0			0			0											
01/02/21 12:00	0			0			0											
01/02/21 13:00	0			0			0											
01/02/21 14:00	0			0			0											
01/02/21 15:00	0			0			0											
01/02/21 16:00	0			0			0											
01/02/21 17:00	0			0			0											
01/02/21 18:00	0			0			0											
01/02/21 19:00	0			0			0											
01/02/21 20:00	0			0			0											
01/02/21 21:00	0			0			0											
01/02/21 22:00	0			0			0											
01/02/21 23:00	0			0			0											
01/03/21 0:00	0			0			0											
01/03/21 1:00	0			0			0											
01/03/21 2:00	0			0			0											
01/03/21 3:00	0			0			0											
01/03/21 4:00	0			0			0											
01/03/21 5:00	0			0			0											
01/03/21 6:00	0			0			0											
01/03/21 7:00	0			0			0											
01/03/21 8:00	0			0			0											
01/03/21 9:00	0			0			0											
01/03/21 10:00	0			0			0											
01/03/21 11:00	0			0			0											
01/03/21 12:00	0			0			0											
01/03/21 13:00	0			0			0											
01/03/21 14:00	0			0			0											
01/03/21 15:00	0			0			0											
01/03/21 16:00	0			0			0											
01/03/21 17:00	0			0			0											
01/03/21 18:00	0			0			0											
01/03/21 19:00	0			0			0											
01/03/21 20:00	0			0			0											
01/03/21 21:00	0			0			0											
01/03/21 22:00	0			0			0											
01/03/21 23:00	0			0			0											
01/04/21 0:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/04/21 1:00	0			0			0											
01/04/21 2:00	0			0			0											
01/04/21 3:00	0			0			0											
01/04/21 4:00	0			0			0											
01/04/21 5:00	0			0			0											
01/04/21 6:00	0			0			0											
01/04/21 7:00	0			0			0											
01/04/21 8:00	0			0			0											
01/04/21 9:00	0			0			0											
01/04/21 10:00	0			0			0											
01/04/21 11:00	0			0			0											
01/04/21 12:00	0			0			0											
01/04/21 13:00	0			0			0											
01/04/21 14:00	0			0			0											
01/04/21 15:00	0			0			0											
01/04/21 16:00	0			0			0											
01/04/21 17:00	0			0			0											
01/04/21 18:00	0			0			0											
01/04/21 19:00	0			0			0											
01/04/21 20:00	0			0			0											
01/04/21 21:00	0			0			0											
01/04/21 22:00	0			0			0											
01/04/21 23:00	0			0			0											
01/05/21 0:00	0			0			0											
01/05/21 1:00	0			0			0											
01/05/21 2:00	0			0			0											
01/05/21 3:00	0			0			0											
01/05/21 4:00	0			0			0											
01/05/21 5:00	0			0			0											
01/05/21 6:00	0			0			0											
01/05/21 7:00	0			0			0											
01/05/21 8:00	0			0			0											
01/05/21 9:00	0			0			0											
01/05/21 10:00	0			0			0											
01/05/21 11:00	0			0			0											
01/05/21 12:00	0			0			0											
01/05/21 13:00	0			0			0											
01/05/21 14:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/05/21 15:00	0			0			0											
01/05/21 16:00	0			0			0											
01/05/21 17:00	0			0			0											
01/05/21 18:00	0			0			0											
01/05/21 19:00	0			0			0											
01/05/21 20:00	0			0			0											
01/05/21 21:00	0			0			0											
01/05/21 22:00	0			0			0											
01/05/21 23:00	0			0			0											
01/06/21 0:00	0			0			0											
01/06/21 1:00	0			0			0											
01/06/21 2:00	0			0			0											
01/06/21 3:00	0			0			0											
01/06/21 4:00	0			0			0											
01/06/21 5:00	0			0			0											
01/06/21 6:00	0			0			0											
01/06/21 7:00	0			0			0											
01/06/21 8:00	0			0			0											
01/06/21 9:00	0			0			0											
01/06/21 10:00	0			0			0											
01/06/21 11:00	0			0			0											
01/06/21 12:00	0			0			0											
01/06/21 13:00	0			0			0											
01/06/21 14:00	0			0			0											
01/06/21 15:00	0			0			0											
01/06/21 16:00	0			0			0											
01/06/21 17:00	0			0			0											
01/06/21 18:00	0			0			0											
01/06/21 19:00	0			0			0											
01/06/21 20:00	0			0			0											
01/06/21 21:00	0			0			0											
01/06/21 22:00	0			0			0											
01/06/21 23:00	0			0			0											
01/07/21 0:00	0			0			0											
01/07/21 1:00	0			0			0											
01/07/21 2:00	0			0			0											
01/07/21 3:00	0			0			0											
01/07/21 4:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/07/21 5:00	0			0			0											
01/07/21 6:00	0			0			0											
01/07/21 7:00	0			0			0											
01/07/21 8:00	0			0			0											
01/07/21 9:00	0			0			0											
01/07/21 10:00	0			0			0											
01/07/21 11:00	0			0			0											
01/07/21 12:00	0			0			0											
01/07/21 13:00	0			0			0											
01/07/21 14:00	0			0			0											
01/07/21 15:00	0			0			0											
01/07/21 16:00	0			0			0											
01/07/21 17:00	0			0			0											
01/07/21 18:00	0			0			0											
01/07/21 19:00	0			0			0											
01/07/21 20:00	0			0			0											
01/07/21 21:00	0			0			0											
01/07/21 22:00	0			0			0											
01/07/21 23:00	0			0			0											
01/08/21 0:00	0			0			0											
01/08/21 1:00	0			0			0											
01/08/21 2:00	0			0			0											
01/08/21 3:00	0			0			0											
01/08/21 4:00	0			0			0											
01/08/21 5:00	0			0			0											
01/08/21 6:00	0			0			0											
01/08/21 7:00	0			0			0											
01/08/21 8:00	0			0			0											
01/08/21 9:00	0			0			0											
01/08/21 10:00	0			0			0											
01/08/21 11:00	0			0			0											
01/08/21 12:00	0			0			0											
01/08/21 13:00	0			0			0											
01/08/21 14:00	0			0			0											
01/08/21 15:00	0			0			0											
01/08/21 16:00	0			0			0											
01/08/21 17:00	0			0			0											
01/08/21 18:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/08/21 19:00	0			0			0											
01/08/21 20:00	0			0			0											
01/08/21 21:00	0			0			0											
01/08/21 22:00	0			0			0											
01/08/21 23:00	0			0			0											
01/09/21 0:00	0			0			0											
01/09/21 1:00	0			0			0											
01/09/21 2:00	0			0			0											
01/09/21 3:00	0			0			0											
01/09/21 4:00	0			0			0											
01/09/21 5:00	0			0			0											
01/09/21 6:00	0			0			0											
01/09/21 7:00	0			0			0											
01/09/21 8:00	0			0			0											
01/09/21 9:00	0			0			0											
01/09/21 10:00	0			0			0											
01/09/21 11:00	0			0			0											
01/09/21 12:00	0			0			0											
01/09/21 13:00	0			0			0											
01/09/21 14:00	0			0			0											
01/09/21 15:00	0			0			0											
01/09/21 16:00	0			0			0											
01/09/21 17:00	0			0			0											
01/09/21 18:00	0			0			0											
01/09/21 19:00	0			0			0											
01/09/21 20:00	0			0			0											
01/09/21 21:00	0			0			0											
01/09/21 22:00	0			0			0											
01/09/21 23:00	0			0			0											
01/10/21 0:00	0			0			0											
01/10/21 1:00	0			0			0											
01/10/21 2:00	0			0			0											
01/10/21 3:00	0			0			0											
01/10/21 4:00	0			0			0											
01/10/21 5:00	0			0			0											
01/10/21 6:00	0			0			0											
01/10/21 7:00	0			0			0											
01/10/21 8:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/10/21 9:00	0			0			0											
01/10/21 10:00	0			0			0											
01/10/21 11:00	0			0			0											
01/10/21 12:00	0			0			0											
01/10/21 13:00	0			0			0											
01/10/21 14:00	0			0			0											
01/10/21 15:00	0			0			0											
01/10/21 16:00	0			0			0											
01/10/21 17:00	0			0			0											
01/10/21 18:00	0			0			0											
01/10/21 19:00	0			0			0											
01/10/21 20:00	0			0			0											
01/10/21 21:00	0			0			0											
01/10/21 22:00	0			0			0											
01/10/21 23:00	0			0			0											
01/11/21 0:00	0			0			0											
01/11/21 1:00	0			0			0											
01/11/21 2:00	0			0			0											
01/11/21 3:00	0			0			0											
01/11/21 4:00	0			0			0											
01/11/21 5:00	0			0			0											
01/11/21 6:00	0			0			0											
01/11/21 7:00	0			0			0											
01/11/21 8:00	0			0			0											
01/11/21 9:00	0			0			0											
01/11/21 10:00	0			0			0											
01/11/21 11:00	0			0			0											
01/11/21 12:00	0			0			0											
01/11/21 13:00	0			0			0											
01/11/21 14:00	0			0			0											
01/11/21 15:00	0			0			0											
01/11/21 16:00	0			0			0											
01/11/21 17:00	0			0			0											
01/11/21 18:00	0			0			0											
01/11/21 19:00	0			0			0											
01/11/21 20:00	0			0			0											
01/11/21 21:00	0			0			0											
01/11/21 22:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/11/21 23:00	0			0			0											
01/12/21 0:00	0			0			0											
01/12/21 1:00	0			0			0											
01/12/21 2:00	0			0			0											
01/12/21 3:00	0			0			0											
01/12/21 4:00	0			0			0											
01/12/21 5:00	0			0			0											
01/12/21 6:00	0			0			0											
01/12/21 7:00	0			0			0											
01/12/21 8:00	0			0			0											
01/12/21 9:00	0			0			0											
01/12/21 10:00	0			0			0											
01/12/21 11:00	0			0			0											
01/12/21 12:00	0			0			0											
01/12/21 13:00	0			0			0											
01/12/21 14:00	0			0			0											
01/12/21 15:00	0			0			0											
01/12/21 16:00	0			0			0											
01/12/21 17:00	0			0			0											
01/12/21 18:00	0			0			0											
01/12/21 19:00	0			0			0											
01/12/21 20:00	0			0			0											
01/12/21 21:00	0			0			0											
01/12/21 22:00	0			0			0											
01/12/21 23:00	0			0			0											
01/13/21 0:00	0			0			0											
01/13/21 1:00	0			0			0											
01/13/21 2:00	0			0			0											
01/13/21 3:00	0			0			0											
01/13/21 4:00	0			0			0											
01/13/21 5:00	0			0			0											
01/13/21 6:00	0			0			0											
01/13/21 7:00	0			0			0											
01/13/21 8:00	0			0			0											
01/13/21 9:00	0			0			0											
01/13/21 10:00	0			0			0											
01/13/21 11:00	0			0			0											
01/13/21 12:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/13/21 13:00	0			0			0											
01/13/21 14:00	0			0			0											
01/13/21 15:00	0			0			0											
01/13/21 16:00	0			0			0											
01/13/21 17:00	0			0			0											
01/13/21 18:00	0			0			0											
01/13/21 19:00	0			0			0											
01/13/21 20:00	0			0			0											
01/13/21 21:00	0			0			0											
01/13/21 22:00	0			0			0											
01/13/21 23:00	0			0			0											
01/14/21 0:00	0			0			0											
01/14/21 1:00	0			0			0											
01/14/21 2:00	0			0			0											
01/14/21 3:00	0			0			0											
01/14/21 4:00	0			0			0											
01/14/21 5:00	0			0			0											
01/14/21 6:00	0			0			0											
01/14/21 7:00	0			0			0											
01/14/21 8:00	0			0			0											
01/14/21 9:00	0			0			0											
01/14/21 10:00	0			0			0											
01/14/21 11:00	0			0			0											
01/14/21 12:00	0			0			0											
01/14/21 13:00	0			0			0											
01/14/21 14:00	0			0			0											
01/14/21 15:00	0			0			0											
01/14/21 16:00	0			0			0											
01/14/21 17:00	0			0			0											
01/14/21 18:00	0			0			0											
01/14/21 19:00	0			0			0											
01/14/21 20:00	0			0			0											
01/14/21 21:00	0			0			0											
01/14/21 22:00	0			0			0											
01/14/21 23:00	0			0			0											
01/15/21 0:00	0			0			0											
01/15/21 1:00	0			0			0											
01/15/21 2:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/15/21 3:00	0			0			0											
01/15/21 4:00	0			0			0											
01/15/21 5:00	0			0			0											
01/15/21 6:00	0			0			0											
01/15/21 7:00	0			0			0											
01/15/21 8:00	0			0			0											
01/15/21 9:00	0			0			0											
01/15/21 10:00	0			0			0											
01/15/21 11:00	0			0			0											
01/15/21 12:00	0			0			0											
01/15/21 13:00	0			0			0											
01/15/21 14:00	0			0			0											
01/15/21 15:00	0			0			0											
01/15/21 16:00	0			0			0											
01/15/21 17:00	0			0			0											
01/15/21 18:00	0			0			0											
01/15/21 19:00	0			0			0											
01/15/21 20:00	0			0			0											
01/15/21 21:00	0			0			0											
01/15/21 22:00	0			0			0											
01/15/21 23:00	0			0			0											
01/16/21 0:00	0			0			0											
01/16/21 1:00	0			0			0											
01/16/21 2:00	0			0			0											
01/16/21 3:00	0			0			0											
01/16/21 4:00	0			0			0											
01/16/21 5:00	0			0			0											
01/16/21 6:00	0			0			0											
01/16/21 7:00	0			0			0											
01/16/21 8:00	0			0			0											
01/16/21 9:00	0			0			0											
01/16/21 10:00	0			0			0											
01/16/21 11:00	0			0			0											
01/16/21 12:00	0			0			0											
01/16/21 13:00	0			0			0											
01/16/21 14:00	0			0			0											
01/16/21 15:00	0			0			0											
01/16/21 16:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/16/21 17:00	0			0			0											
01/16/21 18:00	0			0			0											
01/16/21 19:00	0			0			0											
01/16/21 20:00	0			0			0											
01/16/21 21:00	0			0			0											
01/16/21 22:00	0			0			0											
01/16/21 23:00	0			0			0											
01/17/21 0:00	0			0			0											
01/17/21 1:00	0			0			0											
01/17/21 2:00	0			0			0											
01/17/21 3:00	0			0			0											
01/17/21 4:00	0			0			0											
01/17/21 5:00	0			0			0											
01/17/21 6:00	0			0			0											
01/17/21 7:00	0			0			0											
01/17/21 8:00	0			0			0											
01/17/21 9:00	0			0			0											
01/17/21 10:00	0			0			0											
01/17/21 11:00	0			0			0											
01/17/21 12:00	0			0			0											
01/17/21 13:00	0			0			0											
01/17/21 14:00	0			0			0											
01/17/21 15:00	0			0			0											
01/17/21 16:00	0			0			0											
01/17/21 17:00	0			0			0											
01/17/21 18:00	0			0			0											
01/17/21 19:00	0			0			0											
01/17/21 20:00	0			0			0											
01/17/21 21:00	0			0			0											
01/17/21 22:00	0			0			0											
01/17/21 23:00	0			0			0											
01/18/21 0:00	0			0			0											
01/18/21 1:00	0			0			0											
01/18/21 2:00	0			0			0											
01/18/21 3:00	0			0			0											
01/18/21 4:00	0			0			0											
01/18/21 5:00	0			0			0											
01/18/21 6:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/18/21 7:00	0			0			0											
01/18/21 8:00	0			0			0											
01/18/21 9:00	0			0			0											
01/18/21 10:00	0			0			0											
01/18/21 11:00	0			0			0											
01/18/21 12:00	0			0			0											
01/18/21 13:00	0			0			0											
01/18/21 14:00	0			0			0											
01/18/21 15:00	0			0			0											
01/18/21 16:00	0			0			0											
01/18/21 17:00	0			0			0											
01/18/21 18:00	0			0			0											
01/18/21 19:00	0			0			0											
01/18/21 20:00	0			0			0											
01/18/21 21:00	0			0			0											
01/18/21 22:00	0			0			0											
01/18/21 23:00	0			0			0											
01/19/21 0:00	0			0			0											
01/19/21 1:00	0			0			0											
01/19/21 2:00	0			0			0											
01/19/21 3:00	0			0			0											
01/19/21 4:00	0			0			0											
01/19/21 5:00	0			0			0											
01/19/21 6:00	0			0			0											
01/19/21 7:00	0			0			0											
01/19/21 8:00	0			0			0											
01/19/21 9:00	0			0			0											
01/19/21 10:00	0			0			0											
01/19/21 11:00	0			0			0											
01/19/21 12:00	0			0			0											
01/19/21 13:00	0			0			0											
01/19/21 14:00	0			0			0											
01/19/21 15:00	0			0			0											
01/19/21 16:00	0			0			0											
01/19/21 17:00	0			0			0											
01/19/21 18:00	0			0			0											
01/19/21 19:00	0			0			0											
01/19/21 20:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/19/21 21:00	0			0			0											
01/19/21 22:00	0			0			0											
01/19/21 23:00	0			0			0											
01/20/21 0:00	0			0			0											
01/20/21 1:00	0			0			0											
01/20/21 2:00	0			0			0											
01/20/21 3:00	0			0			0											
01/20/21 4:00	0			0			0											
01/20/21 5:00	0			0			0											
01/20/21 6:00	0			0			0											
01/20/21 7:00	0			0			0											
01/20/21 8:00	0			0			0											
01/20/21 9:00	0			0			0											
01/20/21 10:00	0			0			0											
01/20/21 11:00	0			0			0											
01/20/21 12:00	0			0			0											
01/20/21 13:00	0			0			0											
01/20/21 14:00	0			0			0											
01/20/21 15:00	0			0			0											
01/20/21 16:00	0			0			0											
01/20/21 17:00	0			0			0											
01/20/21 18:00	0			0			0											
01/20/21 19:00	0			0			0											
01/20/21 20:00	0			0			0											
01/20/21 21:00	0			0			0											
01/20/21 22:00	0			0			0											
01/20/21 23:00	0			0			0											
01/21/21 0:00	0			0			0											
01/21/21 1:00	0			0			0											
01/21/21 2:00	0			0			0											
01/21/21 3:00	0			0			0											
01/21/21 4:00	0			0			0											
01/21/21 5:00	0			0			0											
01/21/21 6:00	0			0			0											
01/21/21 7:00	0			0			0											
01/21/21 8:00	0			0			0											
01/21/21 9:00	0			0			0											
01/21/21 10:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/21/21 11:00	0			0			0											
01/21/21 12:00	0			0			0											
01/21/21 13:00	0			0			0											
01/21/21 14:00	0			0			0											
01/21/21 15:00	0			0			0											
01/21/21 16:00	0			0			0											
01/21/21 17:00	0			0			0											
01/21/21 18:00	0			0			0											
01/21/21 19:00	0			0			0											
01/21/21 20:00	0			0			0											
01/21/21 21:00	0			0			0											
01/21/21 22:00	0			0			0											
01/21/21 23:00	0			0			0											
01/22/21 0:00	0			0			0											
01/22/21 1:00	0			0			0											
01/22/21 2:00	0			0			0											
01/22/21 3:00	0			0			0											
01/22/21 4:00	0			0			0											
01/22/21 5:00	0			0			0											
01/22/21 6:00	0			0			0											
01/22/21 7:00	0			0			0											
01/22/21 8:00	0			0			0											
01/22/21 9:00	0			0			0											
01/22/21 10:00	0			0			0											
01/22/21 11:00	0			0			0											
01/22/21 12:00	0			0			0											
01/22/21 13:00	0			0			0											
01/22/21 14:00	0			0			0											
01/22/21 15:00	0			0			0											
01/22/21 16:00	0			0			0											
01/22/21 17:00	0			0			0											
01/22/21 18:00	0			0			0											
01/22/21 19:00	0			0			0											
01/22/21 20:00	0			0			0											
01/22/21 21:00	0			0			0											
01/22/21 22:00	0			0			0											
01/22/21 23:00	0			0			0											
01/23/21 0:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/23/21 1:00	0			0			0											
01/23/21 2:00	0			0			0											
01/23/21 3:00	0			0			0											
01/23/21 4:00	0			0			0											
01/23/21 5:00	0			0			0											
01/23/21 6:00	0			0			0											
01/23/21 7:00	0			0			0											
01/23/21 8:00	0			0			0											
01/23/21 9:00	0			0			0											
01/23/21 10:00	0			0			0											
01/23/21 11:00	0			0			0											
01/23/21 12:00	0			0			0											
01/23/21 13:00	0			0			0											
01/23/21 14:00	0			0			0											
01/23/21 15:00	0			0			0											
01/23/21 16:00	0			0			0											
01/23/21 17:00	0			0			0											
01/23/21 18:00	0			0			0											
01/23/21 19:00	0			0			0											
01/23/21 20:00	0			0			0											
01/23/21 21:00	0			0			0											
01/23/21 22:00	0			0			0											
01/23/21 23:00	1			2			0											
01/24/21 0:00	1			16			0											
01/24/21 1:00	1			29			0											
01/24/21 2:00	1			40			0											
01/24/21 3:00	1			39			0											
01/24/21 4:00	1			40			0											
01/24/21 5:00	1			42			0											
01/24/21 6:00	1			42			0											
01/24/21 7:00	1			41			0											
01/24/21 8:00	1			39			0											
01/24/21 9:00	1			40			0											
01/24/21 10:00	1			41			0											
01/24/21 11:00	1			42			0											
01/24/21 12:00	1			44			0											
01/24/21 13:00	1			45			0											
01/24/21 14:00	1			49			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/24/21 15:00	1			51			0											
01/24/21 16:00	1			55			0											
01/24/21 17:00	1			59			0											
01/24/21 18:00	1			62			0											
01/24/21 19:00	1			62			0											
01/24/21 20:00	1			60			0											
01/24/21 21:00	1			54			0											
01/24/21 22:00	1			51			0											
01/24/21 23:00	1			47			0											
01/25/21 0:00	1			45			0											
01/25/21 1:00	1			41			0											
01/25/21 2:00	1			40			0											
01/25/21 3:00	1			40			0											
01/25/21 4:00	1			42			0											
01/25/21 5:00	1			46			0											
01/25/21 6:00	1			53			0											
01/25/21 7:00	1			60			0											
01/25/21 8:00	1			68			0											
01/25/21 9:00	1			74			0											
01/25/21 10:00	1			75			0											
01/25/21 11:00	1			73			0											
01/25/21 12:00	1			68			0											
01/25/21 13:00	1			65			0											
01/25/21 14:00	1			63			0											
01/25/21 15:00	1			62			0											
01/25/21 16:00	1			64			0											
01/25/21 17:00	1			65			0											
01/25/21 18:00	1			70			0											
01/25/21 19:00	1			73			0											
01/25/21 20:00	1			77			0											
01/25/21 21:00	1			74			0											
01/25/21 22:00	1			67			0											
01/25/21 23:00	1			59			0											
01/26/21 0:00	1			41			0											
01/26/21 1:00	0			22			0											
01/26/21 2:00	0			5			0											
01/26/21 3:00	0			0			0											
01/26/21 4:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/26/21 5:00	0			0			0											
01/26/21 6:00	0			0			0											
01/26/21 7:00	0			0			0											
01/26/21 8:00	0			0			0											
01/26/21 9:00	0			0			0											
01/26/21 10:00	0			0			0											
01/26/21 11:00	0			0			0											
01/26/21 12:00	0			0			0											
01/26/21 13:00	0			0			0											
01/26/21 14:00	0			0			0											
01/26/21 15:00	0			0			0											
01/26/21 16:00	0			0			0											
01/26/21 17:00	0			0			0											
01/26/21 18:00	0			0			0											
01/26/21 19:00	0			0			0											
01/26/21 20:00	0			0			0											
01/26/21 21:00	0			0			0											
01/26/21 22:00	0			0			0											
01/26/21 23:00	0			0			0											
01/27/21 0:00	0			0			0											
01/27/21 1:00	0			0			0											
01/27/21 2:00	0			0			0											
01/27/21 3:00	0			0			0											
01/27/21 4:00	0			0			0											
01/27/21 5:00	0			0			0											
01/27/21 6:00	0			0			0											
01/27/21 7:00	0			0			0											
01/27/21 8:00	0			0			0											
01/27/21 9:00	0			0			0											
01/27/21 10:00	0			0			0											
01/27/21 11:00	0			0			0											
01/27/21 12:00	0			0			0											
01/27/21 13:00	0			0			0											
01/27/21 14:00	0			0			0											
01/27/21 15:00	0			0			0											
01/27/21 16:00	0			0			0											
01/27/21 17:00	0			0			0											
01/27/21 18:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/27/21 19:00	0			0			0											
01/27/21 20:00	0			0			0											
01/27/21 21:00	0			0			0											
01/27/21 22:00	0			0			0											
01/27/21 23:00	0			0			0											
01/28/21 0:00	0			0			0											
01/28/21 1:00	0			0			0											
01/28/21 2:00	0			0			0											
01/28/21 3:00	0			0			0											
01/28/21 4:00	0			0			0											
01/28/21 5:00	0			0			0											
01/28/21 6:00	0			0			0											
01/28/21 7:00	0			0			0											
01/28/21 8:00	0			0			0											
01/28/21 9:00	0			0			0											
01/28/21 10:00	0			0			0											
01/28/21 11:00	0			0			0											
01/28/21 12:00	0			0			0											
01/28/21 13:00	0			0			0											
01/28/21 14:00	0			0			0											
01/28/21 15:00	0			0			0											
01/28/21 16:00	0			0			0											
01/28/21 17:00	0			0			0											
01/28/21 18:00	0			0			0											
01/28/21 19:00	0			0			0											
01/28/21 20:00	0			0			0											
01/28/21 21:00	0			0			0											
01/28/21 22:00	0			0			0											
01/28/21 23:00	0			0			0											
01/29/21 0:00	0			0			0											
01/29/21 1:00	0			0			0											
01/29/21 2:00	0			0			0											
01/29/21 3:00	0			0			0											
01/29/21 4:00	0			0			0											
01/29/21 5:00	0			0			0											
01/29/21 6:00	0			0			0											
01/29/21 7:00	0			0			0											
01/29/21 8:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/29/21 9:00	0			0			0											
01/29/21 10:00	0			0			0											
01/29/21 11:00	0			0			0											
01/29/21 12:00	0			0			0											
01/29/21 13:00	0			0			0											
01/29/21 14:00	0			0			0											
01/29/21 15:00	0			0			0											
01/29/21 16:00	0			0			0											
01/29/21 17:00	0			0			0											
01/29/21 18:00	0			0			0											
01/29/21 19:00	0			0			0											
01/29/21 20:00	0			0			0											
01/29/21 21:00	0			0			0											
01/29/21 22:00	0			0			0											
01/29/21 23:00	0			0			0											
01/30/21 0:00	0			0			0											
01/30/21 1:00	0			0			0											
01/30/21 2:00	0			0			0											
01/30/21 3:00	0			0			0											
01/30/21 4:00	0			0			0											
01/30/21 5:00	0			0			0											
01/30/21 6:00	0			0			0											
01/30/21 7:00	0			0			0											
01/30/21 8:00	0			0			0											
01/30/21 9:00	0			0			0											
01/30/21 10:00	0			0			0											
01/30/21 11:00	0			0			0											
01/30/21 12:00	0			0			0											
01/30/21 13:00	0			0			0											
01/30/21 14:00	0			0			0											
01/30/21 15:00	0			0			0											
01/30/21 16:00	0			0			0											
01/30/21 17:00	0			0			0											
01/30/21 18:00	0			0			0											
01/30/21 19:00	0			0			0											
01/30/21 20:00	0			0			0											
01/30/21 21:00	0			0			0											
01/30/21 22:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/30/21 23:00	0			0			0											
01/31/21 0:00	0			0			0											
01/31/21 1:00	0			0			0											
01/31/21 2:00	0			0			0											
01/31/21 3:00	0			0			0											
01/31/21 4:00	0			0			0											
01/31/21 5:00	0			0			0											
01/31/21 6:00	0			0			0											
01/31/21 7:00	0			0			0											
01/31/21 8:00	0			0			0											
01/31/21 9:00	0			0			0											
01/31/21 10:00	0			0			0											
01/31/21 11:00	0			0			0											
01/31/21 12:00	0			0			0											
01/31/21 13:00	0			0			0											
01/31/21 14:00	0			0			0											
01/31/21 15:00	0			0			0											
01/31/21 16:00	0			0			0											
01/31/21 17:00	0			0			0											
01/31/21 18:00	0			0			0											
01/31/21 19:00	0			0			0											
01/31/21 20:00	0			0			0											
01/31/21 21:00	0			0			0											
01/31/21 22:00	0			0			0											
01/31/21 23:00	0			0			0											
02/01/21 0:00	0			0			0											
02/01/21 1:00	0			0			0											
02/01/21 2:00	0			0			0											
02/01/21 3:00	0			0			0											
02/01/21 4:00	0			0			0											
02/01/21 5:00	0			0			0											
02/01/21 6:00	0			0			0											
02/01/21 7:00	0			0			0											
02/01/21 8:00	0			0			0											
02/01/21 9:00	0			0			0											
02/01/21 10:00	0			0			0											
02/01/21 11:00	0			0			0											
02/01/21 12:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/01/21 13:00	0			0			0											
02/01/21 14:00	0			0			0											
02/01/21 15:00	0			0			0											
02/01/21 16:00	0			0			0											
02/01/21 17:00	0			0			0											
02/01/21 18:00	0			0			0											
02/01/21 19:00	0			0			0											
02/01/21 20:00	0			0			0											
02/01/21 21:00	0			0			0											
02/01/21 22:00	0			0			0											
02/01/21 23:00	0			0			0											
02/02/21 0:00	0			0			0											
02/02/21 1:00	0			0			0											
02/02/21 2:00	0			0			0											
02/02/21 3:00	0			0			0											
02/02/21 4:00	0			0			0											
02/02/21 5:00	0			0			0											
02/02/21 6:00	0			0			0											
02/02/21 7:00	0			0			0											
02/02/21 8:00	0			0			0											
02/02/21 9:00	0			0			0											
02/02/21 10:00	0			0			0											
02/02/21 11:00	0			0			0											
02/02/21 12:00	0			0			0											
02/02/21 13:00	0			0			0											
02/02/21 14:00	0			0			0											
02/02/21 15:00	0			0			0											
02/02/21 16:00	0			0			0											
02/02/21 17:00	0			0			0											
02/02/21 18:00	0			0			0											
02/02/21 19:00	0			0			0											
02/02/21 20:00	0			0			0											
02/02/21 21:00	0			0			0											
02/02/21 22:00	0			0			0											
02/02/21 23:00	0			0			0											
02/03/21 0:00	0			0			0											
02/03/21 1:00	0			0			0											
02/03/21 2:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/03/21 3:00	0			0			0											
02/03/21 4:00	0			0			0											
02/03/21 5:00	0			0			0											
02/03/21 6:00	0			0			0											
02/03/21 7:00	0			0			0											
02/03/21 8:00	0			0			0											
02/03/21 9:00	0			0			0											
02/03/21 10:00	0			0			0											
02/03/21 11:00	0			0			0											
02/03/21 12:00	0			0			0											
02/03/21 13:00	0			0			0											
02/03/21 14:00	0			0			0											
02/03/21 15:00	0			0			0											
02/03/21 16:00	0			0			0											
02/03/21 17:00	0			0			0											
02/03/21 18:00	0			0			0											
02/03/21 19:00	0			0			0											
02/03/21 20:00	0			0			0											
02/03/21 21:00	0			0			0											
02/03/21 22:00	0			0			0											
02/03/21 23:00	0			0			0											
02/04/21 0:00	0			0			0											
02/04/21 1:00	0			0			0											
02/04/21 2:00	0			0			0											
02/04/21 3:00	0			0			0											
02/04/21 4:00	0			0			0											
02/04/21 5:00	0			0			0											
02/04/21 6:00	0			0			0											
02/04/21 7:00	0			0			0											
02/04/21 8:00	0			0			0											
02/04/21 9:00	0			0			0											
02/04/21 10:00	0			0			0											
02/04/21 11:00	0			0			0											
02/04/21 12:00	0			0			0											
02/04/21 13:00	0			0			0											
02/04/21 14:00	0			0			0											
02/04/21 15:00	0			0			0											
02/04/21 16:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/04/21 17:00	0			0			0											
02/04/21 18:00	0			0			0											
02/04/21 19:00	0			0			0											
02/04/21 20:00	0			0			0											
02/04/21 21:00	0			0			0											
02/04/21 22:00	0			0			0											
02/04/21 23:00	0			0			0											
02/05/21 0:00	0			0			0											
02/05/21 1:00	0			0			0											
02/05/21 2:00	0			0			0											
02/05/21 3:00	0			0			0											
02/05/21 4:00	0			0			0											
02/05/21 5:00	0			0			0											
02/05/21 6:00	0			0			0											
02/05/21 7:00	0			0			0											
02/05/21 8:00	0			0			0											
02/05/21 9:00	0			0			0											
02/05/21 10:00	0			0			0											
02/05/21 11:00	0			0			0											
02/05/21 12:00	0			0			0											
02/05/21 13:00	0			0			0											
02/05/21 14:00	0			0			0											
02/05/21 15:00	0			0			0											
02/05/21 16:00	0			0			0											
02/05/21 17:00	0			0			0											
02/05/21 18:00	0			0			0											
02/05/21 19:00	0			0			0											
02/05/21 20:00	0			0			0											
02/05/21 21:00	0			0			0											
02/05/21 22:00	0			0			0											
02/05/21 23:00	0			0			0											
02/06/21 0:00	0			0			0											
02/06/21 1:00	0			0			0											
02/06/21 2:00	0			0			0											
02/06/21 3:00	0			0			0											
02/06/21 4:00	0			0			0											
02/06/21 5:00	0			0			0											
02/06/21 6:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/06/21 7:00	0			0			0											
02/06/21 8:00	0			0			0											
02/06/21 9:00	0			0			0											
02/06/21 10:00	0			0			0											
02/06/21 11:00	0			0			0											
02/06/21 12:00	0			0			0											
02/06/21 13:00	0			0			0											
02/06/21 14:00	0			0			0											
02/06/21 15:00	0			0			0											
02/06/21 16:00	0			0			0											
02/06/21 17:00	0			0			0											
02/06/21 18:00	0			0			0											
02/06/21 19:00	0			0			0											
02/06/21 20:00	0			0			0											
02/06/21 21:00	0			0			0											
02/06/21 22:00	0			0			0											
02/06/21 23:00	0			0			0											
02/07/21 0:00	0			0			0											
02/07/21 1:00	0			0			0											
02/07/21 2:00	0			0			0											
02/07/21 3:00	0			0			0											
02/07/21 4:00	0			0			0											
02/07/21 5:00	0			0			0											
02/07/21 6:00	0			0			0											
02/07/21 7:00	0			0			0											
02/07/21 8:00	0			0			0											
02/07/21 9:00	0			0			0											
02/07/21 10:00	0			0			0											
02/07/21 11:00	0			0			0											
02/07/21 12:00	0			0			0											
02/07/21 13:00	0			0			0											
02/07/21 14:00	0			0			0											
02/07/21 15:00	0			0			0											
02/07/21 16:00	0			0			0											
02/07/21 17:00	0			0			0											
02/07/21 18:00	0			0			0											
02/07/21 19:00	0			0			0											
02/07/21 20:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/07/21 21:00	0			0			0											
02/07/21 22:00	0			0			0											
02/07/21 23:00	0			0			0											
02/08/21 0:00	0			0			0											
02/08/21 1:00	0			0			0											
02/08/21 2:00	0			0			0											
02/08/21 3:00	0			0			0											
02/08/21 4:00	0			0			0											
02/08/21 5:00	0			0			0											
02/08/21 6:00	0			0			0											
02/08/21 7:00	0			0			0											
02/08/21 8:00	0			0			0											
02/08/21 9:00	0			0			0											
02/08/21 10:00	0			0			0											
02/08/21 11:00	0			0			0											
02/08/21 12:00	0			0			0											
02/08/21 13:00	0			0			0											
02/08/21 14:00	0			0			0											
02/08/21 15:00	0			0			0											
02/08/21 16:00	0			0			0											
02/08/21 17:00	0			0			0											
02/08/21 18:00	0			0			0											
02/08/21 19:00	0			0			0											
02/08/21 20:00	0			0			0											
02/08/21 21:00	0			0			0											
02/08/21 22:00	0			0			0											
02/08/21 23:00	0			0			0											
02/09/21 0:00	0			0			0											
02/09/21 1:00	0			0			0											
02/09/21 2:00	0			0			0											
02/09/21 3:00	0			0			0											
02/09/21 4:00	0			0			0											
02/09/21 5:00	0			0			0											
02/09/21 6:00	0			0			0											
02/09/21 7:00	0			0			0											
02/09/21 8:00	0			0			0											
02/09/21 9:00	0			0			0											
02/09/21 10:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/09/21 11:00	0			0			0											
02/09/21 12:00	0			0			0											
02/09/21 13:00	0			0			0											
02/09/21 14:00	0			0			0											
02/09/21 15:00	0			0			0											
02/09/21 16:00	0			0			0											
02/09/21 17:00	0			0			0											
02/09/21 18:00	0			0			0											
02/09/21 19:00	0			0			0											
02/09/21 20:00	0			0			0											
02/09/21 21:00	0			0			0											
02/09/21 22:00	0			0			0											
02/09/21 23:00	0			0			0											
02/10/21 0:00	0			0			0											
02/10/21 1:00	0			0			0											
02/10/21 2:00	0			0			0											
02/10/21 3:00	0			0			0											
02/10/21 4:00	0			0			0											
02/10/21 5:00	0			0			0											
02/10/21 6:00	0			0			0											
02/10/21 7:00	0			0			0											
02/10/21 8:00	0			0			0											
02/10/21 9:00	0			0			0											
02/10/21 10:00	0			0			0											
02/10/21 11:00	0			0			0											
02/10/21 12:00	0			0			0											
02/10/21 13:00	0			0			0											
02/10/21 14:00	0			0			0											
02/10/21 15:00	0			0			0											
02/10/21 16:00	0			0			0											
02/10/21 17:00	0			0			0											
02/10/21 18:00	0			0			0											
02/10/21 19:00	0			0			0											
02/10/21 20:00	0			0			0											
02/10/21 21:00	0			0			0											
02/10/21 22:00	0			0			0											
02/10/21 23:00	0			0			0											
02/11/21 0:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/11/21 1:00	0			0			0											
02/11/21 2:00	0			0			0											
02/11/21 3:00	0			0			0											
02/11/21 4:00	0			0			0											
02/11/21 5:00	0			0			0											
02/11/21 6:00	0			0			0											
02/11/21 7:00	0			0			0											
02/11/21 8:00	0			0			0											
02/11/21 9:00	0			0			0											
02/11/21 10:00	0			0			0											
02/11/21 11:00	0			0			0											
02/11/21 12:00	0			0			0											
02/11/21 13:00	0			0			0											
02/11/21 14:00	0			0			0											
02/11/21 15:00	0			0			0											
02/11/21 16:00	0			0			0											
02/11/21 17:00	0			0			0											
02/11/21 18:00	0			0			0											
02/11/21 19:00	0			0			0											
02/11/21 20:00	0			0			0											
02/11/21 21:00	0			0			0											
02/11/21 22:00	0			0			0											
02/11/21 23:00	0			0			0											
02/12/21 0:00	0			0			0											
02/12/21 1:00	0			0			0											
02/12/21 2:00	0			0			0											
02/12/21 3:00	0			0			0											
02/12/21 4:00	0			0			0											
02/12/21 5:00	0			0			0											
02/12/21 6:00	0			0			0											
02/12/21 7:00	0			0			0											
02/12/21 8:00	0			0			0											
02/12/21 9:00	0			0			0											
02/12/21 10:00	0			0			0											
02/12/21 11:00	0			0			0											
02/12/21 12:00	0			0			0											
02/12/21 13:00	0			0			0											
02/12/21 14:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/12/21 15:00	0			0			0											
02/12/21 16:00	0			0			0											
02/12/21 17:00	0			0			0											
02/12/21 18:00	0			0			0											
02/12/21 19:00	0			0			0											
02/12/21 20:00	0			0			0											
02/12/21 21:00	0			0			0											
02/12/21 22:00	0			0			0											
02/12/21 23:00	0			0			0											
02/13/21 0:00	0			0			0											
02/13/21 1:00	0			0			0											
02/13/21 2:00	0			0			0											
02/13/21 3:00	0			0			0											
02/13/21 4:00	0			0			0											
02/13/21 5:00	0			0			0											
02/13/21 6:00	0			0			0											
02/13/21 7:00	0			0			0											
02/13/21 8:00	0			0			0											
02/13/21 9:00	0			0			0											
02/13/21 10:00	0			0			0											
02/13/21 11:00	0			0			0											
02/13/21 12:00	0			0			0											
02/13/21 13:00	0			0			0											
02/13/21 14:00	0			0			0											
02/13/21 15:00	0			0			0											
02/13/21 16:00	0			0			0											
02/13/21 17:00	0			0			0											
02/13/21 18:00	0			0			0											
02/13/21 19:00	0			0			0											
02/13/21 20:00	0			0			0											
02/13/21 21:00	0			0			0											
02/13/21 22:00	0			0			0											
02/13/21 23:00	0			0			0											
02/14/21 0:00	0			0			0											
02/14/21 1:00	0			0			0											
02/14/21 2:00	0			0			0											
02/14/21 3:00	0			0			0											
02/14/21 4:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/14/21 5:00	0			0			0											
02/14/21 6:00	0			0			0											
02/14/21 7:00	0			0			0											
02/14/21 8:00	0			0			0											
02/14/21 9:00	0			0			0											
02/14/21 10:00	0			0			0											
02/14/21 11:00	0			0			0											
02/14/21 12:00	0			0			0											
02/14/21 13:00	0			0			0											
02/14/21 14:00	0			0			0											
02/14/21 15:00	0			0			0											
02/14/21 16:00	0			0			0											
02/14/21 17:00	0			0			0											
02/14/21 18:00	0			0			0											
02/14/21 19:00	0			0			0											
02/14/21 20:00	0			0			0											
02/14/21 21:00	0			0			0											
02/14/21 22:00	0			0			0											
02/14/21 23:00	0			0			0											
02/15/21 0:00	0			0			0											
02/15/21 1:00	0			0			0											
02/15/21 2:00	0			0			0											
02/15/21 3:00	0			0			0											
02/15/21 4:00	0			0			0											
02/15/21 5:00	0			0			0											
02/15/21 6:00	0			0			0											
02/15/21 7:00	0			0			0											
02/15/21 8:00	0			0			0											
02/15/21 9:00	0			0			0											
02/15/21 10:00	0			0			0											
02/15/21 11:00	0			0			0											
02/15/21 12:00	0			0			0											
02/15/21 13:00	0			0			0											
02/15/21 14:00	0			0			0											
02/15/21 15:00	0			0			0											
02/15/21 16:00	0			0			0											
02/15/21 17:00	0			0			0											
02/15/21 18:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/15/21 19:00	0			0			0											
02/15/21 20:00	0			0			0											
02/15/21 21:00	0			0			0											
02/15/21 22:00	0			0			0											
02/15/21 23:00	0			0			0											
02/16/21 0:00	0			0			0											
02/16/21 1:00	0			0			0											
02/16/21 2:00	0			0			0											
02/16/21 3:00	0			0			0											
02/16/21 4:00	0			0			0											
02/16/21 5:00	0			0			0											
02/16/21 6:00	0			0			0											
02/16/21 7:00	0			0			0											
02/16/21 8:00	0			0			0											
02/16/21 9:00	0			0			0											
02/16/21 10:00	0			0			0											
02/16/21 11:00	0			0			0											
02/16/21 12:00	0			0			0											
02/16/21 13:00	0			0			0											
02/16/21 14:00	0			0			0											
02/16/21 15:00	0			0			0											
02/16/21 16:00	0			0			0											
02/16/21 17:00	0			0			0											
02/16/21 18:00	0			0			0											
02/16/21 19:00	0			0			0											
02/16/21 20:00	0			0			0											
02/16/21 21:00	0			0			0											
02/16/21 22:00	0			0			0											
02/16/21 23:00	0			0			0											
02/17/21 0:00	0			0			0											
02/17/21 1:00	0			0			0											
02/17/21 2:00	0			0			0											
02/17/21 3:00	0			0			0											
02/17/21 4:00	0			0			0											
02/17/21 5:00	0			0			0											
02/17/21 6:00	0			0			0											
02/17/21 7:00	0			0			0											
02/17/21 8:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/17/21 9:00	0			0			0											
02/17/21 10:00	0			0			0											
02/17/21 11:00	0			0			0											
02/17/21 12:00	0			0			0											
02/17/21 13:00	0			0			0											
02/17/21 14:00	0			0			0											
02/17/21 15:00	0			0			0											
02/17/21 16:00	0			0			0											
02/17/21 17:00	0			0			0											
02/17/21 18:00	0			0			0											
02/17/21 19:00	0			0			0											
02/17/21 20:00	0			0			0											
02/17/21 21:00	0			0			0											
02/17/21 22:00	0			0			0											
02/18/21 0:00	0			0			0											
02/18/21 1:00	0			0			0											
02/18/21 2:00	0			0			0											
02/18/21 3:00	0			0			0											
02/18/21 4:00	0			0			0											
02/18/21 5:00	0			0			0											
02/18/21 6:00	0			0			0											
02/18/21 7:00	0			0			0											
02/18/21 8:00	0			0			0											
02/18/21 9:00	0			0			0											
02/18/21 10:00	0			0			0											
02/18/21 11:00	0			0			0											
02/18/21 12:00	0			0			0											
02/18/21 13:00	0			0			0											
02/18/21 14:00	0			0			0											
02/18/21 15:00	0			0			0											
02/18/21 16:00	0			0			0											
02/18/21 17:00	0			0			0											
02/18/21 18:00	0			0			0											
02/18/21 19:00	0			0			0											
02/18/21 20:00	0			0			0											
02/18/21 21:00	0			0			0											
02/18/21 22:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/18/21 23:00	0			0			0											
02/19/21 0:00	0			0			0											
02/19/21 1:00	0			0			0											
02/19/21 2:00	0			0			0											
02/19/21 3:00	0			0			0											
02/19/21 4:00	0			0			0											
02/19/21 5:00	0			0			0											
02/19/21 6:00	0			0			0											
02/19/21 7:00	0			0			0											
02/19/21 8:00	0			0			0											
02/19/21 9:00	0			0			0											
02/19/21 10:00	0			0			0											
02/19/21 11:00	0			0			0											
02/19/21 12:00	0			0			0											
02/19/21 13:00	0			0			0											
02/19/21 14:00	0			0			0											
02/19/21 15:00	0			0			0											
02/19/21 16:00	0			0			0											
02/19/21 17:00	0			0			0											
02/19/21 18:00	0			0			0											
02/19/21 19:00	0			0			0											
02/19/21 20:00	0			0			0											
02/19/21 21:00	0			0			0											
02/19/21 22:00	0			0			0											
02/19/21 23:00	0			0			0											
02/20/21 0:00	0			0			0											
02/20/21 1:00	0			0			0											
02/20/21 2:00	0			0			0											
02/20/21 3:00	0			0			0											
02/20/21 4:00	0			0			0											
02/20/21 5:00	0			0			0											
02/20/21 6:00	0			0			0											
02/20/21 7:00	0			0			0											
02/20/21 8:00	0			0			0											
02/20/21 9:00	0			0			0											
02/20/21 10:00	0			0			0											
02/20/21 11:00	0			0			0											
02/20/21 12:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/20/21 13:00	0			0			0											
02/20/21 14:00	0			0			0											
02/20/21 15:00	0			0			0											
02/20/21 16:00	0			0			0											
02/20/21 17:00	0			0			0											
02/20/21 18:00	0			0			0											
02/20/21 19:00	0			0			0											
02/20/21 20:00	0			0			0											
02/20/21 21:00	0			0			0											
02/20/21 22:00	0			0			0											
02/20/21 23:00	0			0			0											
02/21/21 0:00	0			0			0											
02/21/21 1:00	0			0			0											
02/21/21 2:00	0			0			0											
02/21/21 3:00	0			0			0											
02/21/21 4:00	0			0			0											
02/21/21 5:00	0			0			0											
02/21/21 6:00	0			0			0											
02/21/21 7:00	0			0			0											
02/21/21 8:00	0			0			0											
02/21/21 9:00	0			0			0											
02/21/21 10:00	0			0			0											
02/21/21 11:00	0			0			0											
02/21/21 12:00	0			0			0											
02/21/21 13:00	0			0			0											
02/21/21 14:00	0			0			0											
02/21/21 15:00	0			0			0											
02/21/21 16:00	0			0			0											
02/21/21 17:00	0			0			0											
02/21/21 18:00	0			0			0											
02/21/21 19:00	0			0			0											
02/21/21 20:00	0			0			0											
02/21/21 21:00	0			0			0											
02/21/21 22:00	0			0			0											
02/21/21 23:00	0			0			0											
02/22/21 0:00	0			0			0											
02/22/21 1:00	0			0			0											
02/22/21 2:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/22/21 3:00	0			0			0											
02/22/21 4:00	0			0			0											
02/22/21 5:00	0			0			0											
02/22/21 6:00	0			0			0											
02/22/21 7:00	0			0			0											
02/22/21 8:00	0			0			0											
02/22/21 9:00	0			0			0											
02/22/21 10:00	0			0			0											
02/22/21 11:00	0			0			0											
02/22/21 12:00	0			0			0											
02/22/21 13:00	0			0			0											
02/22/21 14:00	0			0			0											
02/22/21 15:00	0			0			0											
02/22/21 16:00	0			0			0											
02/22/21 17:00	0			0			0											
02/22/21 18:00	0			0			0											
02/22/21 19:00	0			0			0											
02/22/21 20:00	0			0			0											
02/22/21 21:00	0			0			0											
02/22/21 22:00	0			0			0											
02/22/21 23:00	0			0			0											
02/23/21 0:00	0			0			0											
02/23/21 1:00	0			0			0											
02/23/21 2:00	0			0			0											
02/23/21 3:00	0			0			0											
02/23/21 4:00	0			0			0											
02/23/21 5:00	0			0			0											
02/23/21 6:00	0			0			0											
02/23/21 7:00	0			0			0											
02/23/21 8:00	0			0			0											
02/23/21 9:00	0			0			0											
02/23/21 10:00	0			0			0											
02/23/21 11:00	0			0			0											
02/23/21 12:00	0			0			0											
02/23/21 13:00	0			0			0											
02/23/21 14:00	0			0			0											
02/23/21 15:00	0			0			0											
02/23/21 16:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/23/21 17:00	0			0			0											
02/23/21 18:00	0			0			0											
02/23/21 19:00	0			0			0											
02/23/21 20:00	0			0			0											
02/23/21 21:00	0			0			0											
02/23/21 22:00	0			0			0											
02/23/21 23:00	0			0			0											
02/24/21 0:00	0			0			0											
02/24/21 1:00	0			0			0											
02/24/21 2:00	0			0			0											
02/24/21 3:00	0			0			0											
02/24/21 4:00	0			0			0											
02/24/21 5:00	0			0			0											
02/24/21 6:00	0			0			0											
02/24/21 7:00	0			0			0											
02/24/21 8:00	0			0			0											
02/24/21 9:00	0			0			0											
02/24/21 10:00	0			0			0											
02/24/21 11:00	0			0			0											
02/24/21 12:00	0			0			0											
02/24/21 13:00	0			0			0											
02/24/21 14:00	0			0			0											
02/24/21 15:00	0			0			0											
02/24/21 16:00	0			0			0											
02/24/21 17:00	0			0			0											
02/24/21 18:00	0			0			0											
02/24/21 19:00	0			0			0											
02/24/21 20:00	0			0			0											
02/24/21 21:00	0			0			0											
02/24/21 22:00	0			0			0											
02/24/21 23:00	0			0			0											
02/25/21 0:00	0			0			0											
02/25/21 1:00	0			0			0											
02/25/21 2:00	0			0			0											
02/25/21 3:00	0			0			0											
02/25/21 4:00	0			0			0											
02/25/21 5:00	0			0			0											
02/25/21 6:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/25/21 7:00	0			0			0											
02/25/21 8:00	0			0			0											
02/25/21 9:00	0			0			0											
02/25/21 10:00	0			0			0											
02/25/21 11:00	0			0			0											
02/25/21 12:00	0			0			0											
02/25/21 13:00	0			0			0											
02/25/21 14:00	0			0			0											
02/25/21 15:00	0			0			0											
02/25/21 16:00	0			0			0											
02/25/21 17:00	0			0			0											
02/25/21 18:00	0			0			0											
02/25/21 19:00	0			0			0											
02/25/21 20:00	0			0			0											
02/25/21 21:00	0			0			0											
02/25/21 22:00	0			0			0											
02/25/21 23:00	0			0			0											
02/26/21 0:00	0			0			0											
02/26/21 1:00	0			0			0											
02/26/21 2:00	0			0			0											
02/26/21 3:00	0			0			0											
02/26/21 4:00	0			0			0											
02/26/21 5:00	0			0			0											
02/26/21 6:00	0			0			0											
02/26/21 7:00	0			0			0											
02/26/21 8:00	1			0			3											
02/26/21 9:00	1			0			11											
02/26/21 10:00	1			0			26											
02/26/21 11:00	1			0			38											
02/26/21 12:00	1			0			45											
02/26/21 13:00	1			0			46											
02/26/21 14:00	1			0			40											
02/26/21 15:00	0			0			24											
02/26/21 16:00	0			0			9											
02/26/21 17:00	0			0			0											
02/26/21 18:00	0			0			0											
02/26/21 19:00	0			0			0											
02/26/21 20:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/26/21 21:00	0			0			0											
02/26/21 22:00	0			0			0											
02/26/21 23:00	0			0			0											
02/27/21 0:00	0			0			0											
02/27/21 1:00	0			0			0											
02/27/21 2:00	0			0			0											
02/27/21 3:00	0			0			0											
02/27/21 4:00	0			0			0											
02/27/21 5:00	0			0			0											
02/27/21 6:00	0			0			0											
02/27/21 7:00	0			0			0											
02/27/21 8:00	0			0			0											
02/27/21 9:00	1			0			2											
02/27/21 10:00	1			0			17											
02/27/21 11:00	1			0			32											
02/27/21 12:00	1			0			45											
02/27/21 13:00	1			0			46											
02/27/21 14:00	1			0			45											
02/27/21 15:00	1			0			42											
02/27/21 16:00	1			0			36											
02/27/21 17:00	1			0			29											
02/27/21 18:00	1			0			16											
02/27/21 19:00	0			0			7											
02/27/21 20:00	0			0			0											
02/27/21 21:00	0			0			0											
02/27/21 22:00	0			0			0											
02/27/21 23:00	0			0			0											
02/28/21 0:00	0			0			0											
02/28/21 1:00	0			0			0											
02/28/21 2:00	0			0			0											
02/28/21 3:00	0			0			0											
02/28/21 4:00	0			0			0											
02/28/21 5:00	0			0			0											
02/28/21 6:00	0			0			0											
02/28/21 7:00	0			0			0											
02/28/21 8:00	0			0			0											
02/28/21 9:00	0			0			0											
02/28/21 10:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/28/21 11:00	0			0			0											
02/28/21 12:00	0			0			0											
02/28/21 13:00	0			0			0											
02/28/21 14:00	0			0			0											
02/28/21 15:00	0			0			0											
02/28/21 16:00	0			0			0											
02/28/21 17:00	0			0			0											
02/28/21 18:00	0			0			0											
02/28/21 19:00	0			0			0											
02/28/21 20:00	0			0			0											
02/28/21 21:00	0			0			0											
02/28/21 22:00	0			0			0											
02/28/21 23:00	0			0			0											
03/01/21 0:00	0			0			0											
03/01/21 1:00	0			0			0											
03/01/21 2:00	0			0			0											
03/01/21 3:00	0			0			0											
03/01/21 4:00	0			0			0											
03/01/21 5:00	0			0			0											
03/01/21 6:00	0			0			0											
03/01/21 7:00	1			0			2											
03/01/21 8:00	1			0			15											
03/01/21 9:00	1			0			30											
03/01/21 10:00	1			0			44											
03/01/21 11:00	1			0			46											
03/01/21 12:00	1			0			45											
03/01/21 13:00	1			0			39											
03/01/21 14:00	1			0			31											
03/01/21 15:00	1			0			22											
03/01/21 16:00	1			0			21											
03/01/21 17:00	1			0			14											
03/01/21 18:00	0			0			8											
03/01/21 19:00	0			0			1											
03/01/21 20:00	0			0			0											
03/01/21 21:00	0			0			0											
03/01/21 22:00	0			0			0											
03/01/21 23:00	0			0			0											
03/02/21 0:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/02/21 1:00	0			0			0											
03/02/21 2:00	0			0			0											
03/02/21 3:00	0			0			0											
03/02/21 4:00	0			0			0											
03/02/21 5:00	0			0			0											
03/02/21 6:00	0			0			0											
03/02/21 7:00	0			0			0											
03/02/21 8:00	0			0			0											
03/02/21 9:00	0			0			0											
03/02/21 10:00	0			0			0											
03/02/21 11:00	0			0			0											
03/02/21 12:00	0			0			0											
03/02/21 13:00	0			0			0											
03/02/21 14:00	0			0			0											
03/02/21 15:00	0			0			0											
03/02/21 16:00	0			0			0											
03/02/21 17:00	0			0			0											
03/02/21 18:00	0			0			0											
03/02/21 19:00	0			0			0											
03/02/21 20:00	0			0			0											
03/02/21 21:00	0			0			0											
03/02/21 22:00	0			0			0											
03/02/21 23:00	0			0			0											
03/03/21 0:00	0			0			0											
03/03/21 1:00	0			0			0											
03/03/21 2:00	0			0			0											
03/03/21 3:00	0			0			0											
03/03/21 4:00	0			0			0											
03/03/21 5:00	0			0			0											
03/03/21 6:00	0			0			0											
03/03/21 7:00	0			0			0											
03/03/21 8:00	0			0			0											
03/03/21 9:00	0			0			0											
03/03/21 10:00	0			0			0											
03/03/21 11:00	0			0			0											
03/03/21 12:00	0			0			0											
03/03/21 13:00	0			0			0											
03/03/21 14:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/03/21 15:00	0			0			0											
03/03/21 16:00	0			0			0											
03/03/21 17:00	0			0			0											
03/03/21 18:00	0			0			0											
03/03/21 19:00	0			0			0											
03/03/21 20:00	0			0			0											
03/03/21 21:00	0			0			0											
03/03/21 22:00	0			0			0											
03/03/21 23:00	0			0			0											
03/04/21 0:00	0			0			0											
03/04/21 1:00	0			0			0											
03/04/21 2:00	0			0			0											
03/04/21 3:00	0			0			0											
03/04/21 4:00	0			0			0											
03/04/21 5:00	0			0			0											
03/04/21 6:00	0			0			0											
03/04/21 7:00	0			0			0											
03/04/21 8:00	0			0			0											
03/04/21 9:00	0			0			0											
03/04/21 10:00	0			0			0											
03/04/21 11:00	0			0			0											
03/04/21 12:00	0			0			0											
03/04/21 13:00	0			0			0											
03/04/21 14:00	0			0			0											
03/04/21 15:00	0			0			0											
03/04/21 16:00	0			0			0											
03/04/21 17:00	0			0			0											
03/04/21 18:00	0			0			0											
03/04/21 19:00	0			0			0											
03/04/21 20:00	0			0			0											
03/04/21 21:00	0			0			0											
03/04/21 22:00	0			0			0											
03/04/21 23:00	0			0			0											
03/05/21 0:00	0			0			0											
03/05/21 1:00	0			0			0											
03/05/21 2:00	0			0			0											
03/05/21 3:00	0			0			0											
03/05/21 4:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/05/21 5:00	0			0			0											
03/05/21 6:00	0			0			0											
03/05/21 7:00	0			0			0											
03/05/21 8:00	0			0			0											
03/05/21 9:00	0			0			0											
03/05/21 10:00	0			0			0											
03/05/21 11:00	0			0			0											
03/05/21 12:00	0			0			0											
03/05/21 13:00	0			0			0											
03/05/21 14:00	0			0			0											
03/05/21 15:00	0			0			0											
03/05/21 16:00	0			0			0											
03/05/21 17:00	0			0			0											
03/05/21 18:00	0			0			0											
03/05/21 19:00	0			0			0											
03/05/21 20:00	0			0			0											
03/05/21 21:00	0			0			0											
03/05/21 22:00	0			0			0											
03/05/21 23:00	0			0			0											
03/06/21 0:00	0			0			0											
03/06/21 1:00	0			0			0											
03/06/21 2:00	0			0			0											
03/06/21 3:00	0			0			0											
03/06/21 4:00	0			0			0											
03/06/21 5:00	0			0			0											
03/06/21 6:00	0			0			0											
03/06/21 7:00	0			0			0											
03/06/21 8:00	1			0			4											
03/06/21 9:00	1			0			12											
03/06/21 10:00	1			0			19											
03/06/21 11:00	1			0			22											
03/06/21 12:00	1			0			29											
03/06/21 13:00	1			0			37											
03/06/21 14:00	1			0			45											
03/06/21 15:00	1			0			42											
03/06/21 16:00	1			0			39											
03/06/21 17:00	1			0			27											
03/06/21 18:00	0			0			15											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/06/21 19:00	0			0			3											
03/06/21 20:00	0			0			0											
03/06/21 21:00	0			0			0											
03/06/21 22:00	0			0			0											
03/06/21 23:00	0			0			0											
03/07/21 0:00	0			0			0											
03/07/21 1:00	0			0			0											
03/07/21 2:00	0			0			0											
03/07/21 3:00	0			0			0											
03/07/21 4:00	0			0			0											
03/07/21 5:00	0			0			0											
03/07/21 6:00	0			0			0											
03/07/21 7:00	0			0			0											
03/07/21 8:00	0			0			0											
03/07/21 9:00	0			0			0											
03/07/21 10:00	0			0			0											
03/07/21 11:00	0			0			0											
03/07/21 12:00	0			0			0											
03/07/21 13:00	0			0			0											
03/07/21 14:00	0			0			0											
03/07/21 15:00	0			0			0											
03/07/21 16:00	0			0			0											
03/07/21 17:00	0			0			0											
03/07/21 18:00	0			0			0											
03/07/21 19:00	0			0			0											
03/07/21 20:00	0			0			0											
03/07/21 21:00	0			0			0											
03/07/21 22:00	0			0			0											
03/07/21 23:00	0			0			0											
03/08/21 0:00	0			0			0											
03/08/21 1:00	0			0			0											
03/08/21 2:00	0			0			0											
03/08/21 3:00	0			0			0											
03/08/21 4:00	0			0			0											
03/08/21 5:00	0			0			0											
03/08/21 6:00	0			0			0											
03/08/21 7:00	0			0			0											
03/08/21 8:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/08/21 9:00	1			0			0											
03/08/21 10:00	1			0			0											
03/08/21 11:00	0			0			0											
03/08/21 12:00	0			0			0											
03/08/21 13:00	1			0			0											
03/08/21 14:00	1			2			0											
03/08/21 15:00	1			11			0											
03/08/21 16:00	1			26			0											
03/08/21 17:00	1			40			0											
03/08/21 18:00	1			47			0											
03/08/21 19:00	1			49			0											
03/08/21 20:00	1			38			0											
03/08/21 21:00	0			22			0											
03/08/21 22:00	0			5			0											
03/08/21 23:00	0			0			0											
03/09/21 0:00	0			0			0											
03/09/21 1:00	0			0			0											
03/09/21 2:00	0			0			0											
03/09/21 3:00	0			0			0											
03/09/21 4:00	0			0			0											
03/09/21 5:00	0			0			0											
03/09/21 6:00	0			0			0											
03/09/21 7:00	0			0			0											
03/09/21 8:00	0			0			0											
03/09/21 9:00	0			0			0											
03/09/21 10:00	0			0			0											
03/09/21 11:00	0			0			0											
03/09/21 12:00	0			0			0											
03/09/21 13:00	0			0			0											
03/09/21 14:00	0			0			0											
03/09/21 15:00	0			0			0											
03/09/21 16:00	0			0			0											
03/09/21 17:00	0			0			0											
03/09/21 18:00	0			0			0											
03/09/21 19:00	0			0			0											
03/09/21 20:00	0			0			0											
03/09/21 21:00	0			0			0											
03/09/21 22:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/09/21 23:00	0			0			0											
03/10/21 0:00	0			0			0											
03/10/21 1:00	0			0			0											
03/10/21 2:00	0			0			0											
03/10/21 3:00	0			0			0											
03/10/21 4:00	0			0			0											
03/10/21 5:00	0			0			0											
03/10/21 6:00	0			0			0											
03/10/21 7:00	0			0			0											
03/10/21 8:00	0			0			0											
03/10/21 9:00	0			0			0											
03/10/21 10:00	0			0			0											
03/10/21 11:00	1			2			0											
03/10/21 12:00	1			8			0											
03/10/21 13:00	1			14			0											
03/10/21 14:00	1			21			0											
03/10/21 15:00	1			31			0											
03/10/21 16:00	1			40			0											
03/10/21 17:00	1			46			0											
03/10/21 18:00	1			47			0											
03/10/21 19:00	1			36			0											
03/10/21 20:00	0			21			0											
03/10/21 21:00	0			5			0											
03/10/21 22:00	0			0			0											
03/10/21 23:00	0			0			0											
03/11/21 0:00	0			0			0											
03/11/21 1:00	0			0			0											
03/11/21 2:00	0			0			0											
03/11/21 3:00	0			0			0											
03/11/21 4:00	0			0			0											
03/11/21 5:00	0			0			0											
03/11/21 6:00	0			0			0											
03/11/21 7:00	0			0			0											
03/11/21 8:00	0			0			0											
03/11/21 9:00	0			0			0											
03/11/21 10:00	0			0			0											
03/11/21 11:00	0			0			0											
03/11/21 12:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/11/21 13:00	0			0			0											
03/11/21 14:00	0			0			0											
03/11/21 15:00	0			0			0											
03/11/21 16:00	0			0			0											
03/11/21 17:00	0			0			0											
03/11/21 18:00	0			0			0											
03/11/21 19:00	0			0			0											
03/11/21 20:00	0			0			0											
03/11/21 21:00	0			0			0											
03/11/21 22:00	0			0			0											
03/11/21 23:00	0			0			0											
03/12/21 0:00	0			0			0											
03/12/21 1:00	0			0			0											
03/12/21 2:00	0			0			0											
03/12/21 3:00	0			0			0											
03/12/21 4:00	0			0			0											
03/12/21 5:00	0			0			0											
03/12/21 6:00	0			0			0											
03/12/21 7:00	0			0			0											
03/12/21 8:00	0			0			0											
03/12/21 9:00	0			0			0											
03/12/21 10:00	0			0			0											
03/12/21 11:00	0			0			0											
03/12/21 12:00	1			0			0											
03/12/21 13:00	1			0			0											
03/12/21 14:00	1			5			0											
03/12/21 15:00	1			5			0											
03/12/21 16:00	0			5			0											
03/12/21 17:00	1			0			0											
03/12/21 18:00	0			0			0											
03/12/21 19:00	0			0			0											
03/12/21 20:00	0			0			0											
03/12/21 21:00	0			0			0											
03/12/21 22:00	0			0			0											
03/12/21 23:00	0			0			0											
03/13/21 0:00	0			0			0											
03/13/21 1:00	0			0			0											
03/13/21 2:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/13/21 3:00	0			0			0											
03/13/21 4:00	0			0			0											
03/13/21 5:00	0			0			0											
03/13/21 6:00	0			0			0											
03/13/21 7:00	1			0			0											
03/13/21 8:00	1			2			0											
03/13/21 9:00	1			14			0											
03/13/21 10:00	1			24			0											
03/13/21 11:00	1			38			2											
03/13/21 12:00	1			45			20											
03/13/21 13:00	1			55			41											
03/13/21 14:00	1			67			67											
03/13/21 15:00	1			76			78											
03/13/21 16:00	1			84			86											
03/13/21 17:00	1			79			81											
03/13/21 18:00	1			55			58											
03/13/21 19:00	1			27			40											
03/13/21 20:00	1			5			29											
03/13/21 21:00	1			0			37											
03/13/21 22:00	1			0			30											
03/13/21 23:00	0			0			19											
03/14/21 0:00	0			0			4											
03/14/21 1:00	0			0			0											
03/14/21 2:00	0			0			0											
03/14/21 3:00	0			0			0											
03/14/21 4:00	0			0			0											
03/14/21 5:00	0			0			0											
03/14/21 6:00	0			0			0											
03/14/21 7:00	0			0			0											
03/14/21 8:00	0			0			0											
03/14/21 9:00	0			0			0											
03/14/21 10:00	0			0			0											
03/14/21 11:00	0			0			0											
03/14/21 12:00	0			0			0											
03/14/21 13:00	0			0			0											
03/14/21 14:00	0			0			0											
03/14/21 15:00	0			0			0											
03/14/21 16:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/14/21 17:00	0			0			0											
03/14/21 18:00	0			0			0											
03/14/21 19:00	0			0			0											
03/14/21 20:00	0			0			0											
03/14/21 21:00	0			0			0											
03/14/21 22:00	0			0			0											
03/14/21 23:00	0			0			0											
03/15/21 0:00	0			0			0											
03/15/21 1:00	0			0			0											
03/15/21 2:00	0			0			0											
03/15/21 3:00	0			0			0											
03/15/21 4:00	0			0			0											
03/15/21 5:00	0			0			0											
03/15/21 6:00	0			0			0											
03/15/21 7:00	0			0			0											
03/15/21 8:00	0			0			0											
03/15/21 9:00	0			0			0											
03/15/21 10:00	0			0			0											
03/15/21 11:00	0			0			0											
03/15/21 12:00	0			0			0											
03/15/21 13:00	0			0			0											
03/15/21 14:00	0			0			0											
03/15/21 15:00	0			0			0											
03/15/21 16:00	0			0			0											
03/15/21 17:00	0			0			0											
03/15/21 18:00	0			0			0											
03/15/21 19:00	0			0			0											
03/15/21 20:00	0			0			0											
03/15/21 21:00	0			0			0											
03/15/21 22:00	0			0			0											
03/15/21 23:00	0			0			0											
03/16/21 0:00	0			0			0											
03/16/21 1:00	0			0			0											
03/16/21 2:00	0			0			0											
03/16/21 3:00	0			0			0											
03/16/21 4:00	0			0			0											
03/16/21 5:00	0			0			0											
03/16/21 6:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/16/21 7:00	0			0			0											
03/16/21 8:00	0			0			0											
03/16/21 9:00	0			0			0											
03/16/21 10:00	0			0			0											
03/16/21 11:00	0			0			0											
03/16/21 12:00	0			0			0											
03/16/21 13:00	0			0			0											
03/16/21 14:00	0			0			0											
03/16/21 15:00	0			0			0											
03/16/21 16:00	0			0			0											
03/16/21 17:00	0			0			0											
03/16/21 18:00	0			0			0											
03/16/21 19:00	0			0			0											
03/16/21 20:00	0			0			0											
03/16/21 21:00	0			0			0											
03/16/21 22:00	0			0			0											
03/16/21 23:00	0			0			0											
03/17/21 0:00	0			0			0											
03/17/21 1:00	0			0			0											
03/17/21 2:00	0			0			0											
03/17/21 3:00	0			0			0											
03/17/21 4:00	0			0			0											
03/17/21 5:00	0			0			0											
03/17/21 6:00	0			0			0											
03/17/21 7:00	0			0			0											
03/17/21 8:00	0			0			0											
03/17/21 9:00	0			0			0											
03/17/21 10:00	0			0			0											
03/17/21 11:00	0			0			0											
03/17/21 12:00	0			0			0											
03/17/21 13:00	0			0			0											
03/17/21 14:00	0			0			0											
03/17/21 15:00	0			0			0											
03/17/21 16:00	0			0			0											
03/17/21 17:00	0			0			0											
03/17/21 18:00	0			0			0											
03/17/21 19:00	0			0			0											
03/17/21 20:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/17/21 21:00	0			0			0											
03/17/21 22:00	0			0			0											
03/17/21 23:00	0			0			0											
03/18/21 0:00	0			0			0											
03/18/21 1:00	0			0			0											
03/18/21 2:00	0			0			0											
03/18/21 3:00	0			0			0											
03/18/21 4:00	0			0			0											
03/18/21 5:00	0			0			0											
03/18/21 6:00	0			0			0											
03/18/21 7:00	0			0			0											
03/18/21 8:00	0			0			0											
03/18/21 9:00	0			0			0											
03/18/21 10:00	0			0			0											
03/18/21 11:00	0			0			0											
03/18/21 12:00	0			0			0											
03/18/21 13:00	0			0			0											
03/18/21 14:00	0			0			0											
03/18/21 15:00	0			0			0											
03/18/21 16:00	0			0			0											
03/18/21 17:00	0			0			0											
03/18/21 18:00	0			0			0											
03/18/21 19:00	0			0			0											
03/18/21 20:00	0			0			0											
03/18/21 21:00	0			0			0											
03/18/21 22:00	0			0			0											
03/18/21 23:00	0			0			0											
03/19/21 0:00	0			0			0											
03/19/21 1:00	0			0			0											
03/19/21 2:00	0			0			0											
03/19/21 3:00	0			0			0											
03/19/21 4:00	0			0			0											
03/19/21 5:00	0			0			0											
03/19/21 6:00	0			0			0											
03/19/21 7:00	0			0			0											
03/19/21 8:00	0			0			0											
03/19/21 9:00	0			0			0											
03/19/21 10:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/19/21 11:00	0			0			0											
03/19/21 12:00	0			0			0											
03/19/21 13:00	0			0			0											
03/19/21 14:00	0			0			0											
03/19/21 15:00	0			0			0											
03/19/21 16:00	0			0			0											
03/19/21 17:00	0			0			0											
03/19/21 18:00	0			0			0											
03/19/21 19:00	0			0			0											
03/19/21 20:00	0			0			0											
03/19/21 21:00	0			0			0											
03/19/21 22:00	0			0			0											
03/19/21 23:00	0			0			0											
03/20/21 0:00	0			0			0											
03/20/21 1:00	0			0			0											
03/20/21 2:00	0			0			0											
03/20/21 3:00	0			0			0											
03/20/21 4:00	0			0			0											
03/20/21 5:00	0			0			0											
03/20/21 6:00	0			0			0											
03/20/21 7:00	0			0			0											
03/20/21 8:00	0			0			0											
03/20/21 9:00	0			0			0											
03/20/21 10:00	0			0			0											
03/20/21 11:00	0			0			0											
03/20/21 12:00	0			0			0											
03/20/21 13:00	0			0			0											
03/20/21 14:00	0			0			0											
03/20/21 15:00	0			0			0											
03/20/21 16:00	0			0			0											
03/20/21 17:00	0			0			0											
03/20/21 18:00	0			0			0											
03/20/21 19:00	0			0			0											
03/20/21 20:00	0			0			0											
03/20/21 21:00	0			0			0											
03/20/21 22:00	0			0			0											
03/20/21 23:00	0			0			0											
03/21/21 0:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/21/21 1:00	0			0			0											
03/21/21 2:00	0			0			0											
03/21/21 3:00	0			0			0											
03/21/21 4:00	0			0			0											
03/21/21 5:00	0			0			0											
03/21/21 6:00	0			0			0											
03/21/21 7:00	0			0			0											
03/21/21 8:00	0			0			0											
03/21/21 9:00	0			0			0											
03/21/21 10:00	0			0			0											
03/21/21 11:00	0			0			0											
03/21/21 12:00	0			0			0											
03/21/21 13:00	0			0			0											
03/21/21 14:00	0			0			0											
03/21/21 15:00	0			0			0											
03/21/21 16:00	0			0			0											
03/21/21 17:00	0			0			0											
03/21/21 18:00	0			0			0											
03/21/21 19:00	0			0			0											
03/21/21 20:00	0			0			0											
03/21/21 21:00	0			0			0											
03/21/21 22:00	0			0			0											
03/21/21 23:00	0			0			0											
03/22/21 0:00	0			0			0											
03/22/21 1:00	0			0			0											
03/22/21 2:00	0			0			0											
03/22/21 3:00	0			0			0											
03/22/21 4:00	0			0			0											
03/22/21 5:00	1			0			3											
03/22/21 6:00	1			0			9											
03/22/21 7:00	1			0			15											
03/22/21 8:00	1			0			23											
03/22/21 9:00	1			0			35											
03/22/21 10:00	1			0			40											
03/22/21 11:00	1			0			53											
03/22/21 12:00	1			0			62											
03/22/21 13:00	1			0			73											
03/22/21 14:00	1			0			78											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/22/21 15:00	1			0			68											
03/22/21 16:00	1			0			56											
03/22/21 17:00	1			0			39											
03/22/21 18:00	1			0			31											
03/22/21 19:00	1			0			31											
03/22/21 20:00	1			0			31											
03/22/21 21:00	1			0			31											
03/22/21 22:00	1			0			31											
03/22/21 23:00	1			0			31											
03/23/21 0:00	1			0			31											
03/23/21 1:00	1			0			31											
03/23/21 2:00	1			0			31											
03/23/21 3:00	1			0			31											
03/23/21 4:00	1			0			31											
03/23/21 5:00	1			0			31											
03/23/21 6:00	1			0			31											
03/23/21 7:00	1			0			31											
03/23/21 8:00	1			0			43											
03/23/21 9:00	1			0			53											
03/23/21 10:00	1			6			62											
03/23/21 11:00	1			26			61											
03/23/21 12:00	1			52			68											
03/23/21 13:00	1			66			70											
03/23/21 14:00	1			71			53											
03/23/21 15:00	1			73			25											
03/23/21 16:00	1			74			4											
03/23/21 17:00	1			62			0											
03/23/21 18:00	1			45			0											
03/23/21 19:00	1			33			0											
03/23/21 20:00	1			31			0											
03/23/21 21:00	1			31			0											
03/23/21 22:00	1			31			0											
03/23/21 23:00	1			31			0											
03/24/21 0:00	1			31			0											
03/24/21 1:00	1			31			0											
03/24/21 2:00	1			31			0											
03/24/21 3:00	1			32			0											
03/24/21 4:00	1			32			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/24/21 5:00	1			32			0											
03/24/21 6:00	1			31			0											
03/24/21 7:00	1			33			0											
03/24/21 8:00	1			48			2											
03/24/21 9:00	1			52			16											
03/24/21 10:00	1			67			44											
03/24/21 11:00	1			58			60											
03/24/21 12:00	1			44			69											
03/24/21 13:00	1			17			59											
03/24/21 14:00	1			1			68											
03/24/21 15:00	1			0			52											
03/24/21 16:00	1			0			35											
03/24/21 17:00	0			0			9											
03/24/21 18:00	0			0			1											
03/24/21 19:00	0			0			0											
03/24/21 20:00	0			0			0											
03/24/21 21:00	0			0			0											
03/24/21 22:00	0			0			0											
03/24/21 23:00	0			0			0											
03/25/21 0:00	0			0			0											
03/25/21 1:00	0			0			0											
03/25/21 2:00	0			0			0											
03/25/21 3:00	0			0			0											
03/25/21 4:00	0			0			0											
03/25/21 5:00	0			0			0											
03/25/21 6:00	1			0			2											
03/25/21 7:00	1			0			14											
03/25/21 8:00	1			0			27											
03/25/21 9:00	1			0			37											
03/25/21 10:00	1			0			38											
03/25/21 11:00	1			0			31											
03/25/21 12:00	0			0			19											
03/25/21 13:00	0			0			5											
03/25/21 14:00	0			0			0											
03/25/21 15:00	0			0			0											
03/25/21 16:00	0			0			0											
03/25/21 17:00	0			0			0											
03/25/21 18:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/25/21 19:00	0			0			0											
03/25/21 20:00	0			0			0											
03/25/21 21:00	0			0			0											
03/25/21 22:00	0			0			0											
03/25/21 23:00	0			0			0											
03/26/21 0:00	0			0			0											
03/26/21 1:00	0			0			0											
03/26/21 2:00	0			0			0											
03/26/21 3:00	0			0			0											
03/26/21 4:00	0			0			0											
03/26/21 5:00	0			0			0											
03/26/21 6:00	0			0			0											
03/26/21 7:00	0			0			0											
03/26/21 8:00	0			0			0											
03/26/21 9:00	0			0			0											
03/26/21 10:00	0			0			0											
03/26/21 11:00	0			0			0											
03/26/21 12:00	0			0			0											
03/26/21 13:00	0			0			0											
03/26/21 14:00	0			0			0											
03/26/21 15:00	0			0			0											
03/26/21 16:00	0			0			0											
03/26/21 17:00	0			0			0											
03/26/21 18:00	0			0			0											
03/26/21 19:00	0			0			0											
03/26/21 20:00	0			0			0											
03/26/21 21:00	0			0			0											
03/26/21 22:00	0			0			0											
03/26/21 23:00	0			0			0											
03/27/21 0:00	0			0			0											
03/27/21 1:00	0			0			0											
03/27/21 2:00	0			0			0											
03/27/21 3:00	0			0			0											
03/27/21 4:00	0			0			0											
03/27/21 5:00	0			0			0											
03/27/21 6:00	0			0			0											
03/27/21 7:00	0			0			0											
03/27/21 8:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/27/21 9:00	0			0			0											
03/27/21 10:00	0			0			0											
03/27/21 11:00	0			0			0											
03/27/21 12:00	0			0			0											
03/27/21 13:00	0			0			0											
03/27/21 14:00	0			0			0											
03/27/21 15:00	0			0			0											
03/27/21 16:00	0			0			0											
03/27/21 17:00	0			0			0											
03/27/21 18:00	0			0			0											
03/27/21 19:00	0			0			0											
03/27/21 20:00	0			0			0											
03/27/21 21:00	0			0			0											
03/27/21 22:00	0			0			0											
03/28/21 0:00	0			0			0											
03/28/21 1:00	0			0			0											
03/28/21 2:00	0			0			0											
03/28/21 3:00	0			0			0											
03/28/21 4:00	0			0			0											
03/28/21 5:00	0			0			0											
03/28/21 6:00	0			0			0											
03/28/21 7:00	0			0			0											
03/28/21 8:00	0			0			0											
03/28/21 9:00	0			0			0											
03/28/21 10:00	0			0			0											
03/28/21 11:00	0			0			0											
03/28/21 12:00	0			0			0											
03/28/21 13:00	0			0			0											
03/28/21 14:00	0			0			0											
03/28/21 15:00	0			0			0											
03/28/21 16:00	0			0			0											
03/28/21 17:00	0			0			0											
03/28/21 18:00	0			0			0											
03/28/21 19:00	0			0			0											
03/28/21 20:00	0			0			0											
03/28/21 21:00	0			0			0											
03/28/21 22:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/28/21 23:00	0			0			0											
03/29/21 0:00	0			0			0											
03/29/21 1:00	0			0			0											
03/29/21 2:00	0			0			0											
03/29/21 3:00	0			0			0											
03/29/21 4:00	0			0			0											
03/29/21 5:00	0			0			0											
03/29/21 6:00	0			0			0											
03/29/21 7:00	0			0			0											
03/29/21 8:00	0			0			0											
03/29/21 9:00	0			0			0											
03/29/21 10:00	0			0			0											
03/29/21 11:00	0			0			0											
03/29/21 12:00	0			0			0											
03/29/21 13:00	0			0			0											
03/29/21 14:00	0			0			0											
03/29/21 15:00	0			0			0											
03/29/21 16:00	0			0			0											
03/29/21 17:00	0			0			0											
03/29/21 18:00	0			0			0											
03/29/21 19:00	0			0			0											
03/29/21 20:00	0			0			0											
03/29/21 21:00	0			0			0											
03/29/21 22:00	0			0			0											
03/29/21 23:00	0			0			0											
03/30/21 0:00	0			0			0											
03/30/21 1:00	0			0			0											
03/30/21 2:00	0			0			0											
03/30/21 3:00	0			0			0											
03/30/21 4:00	0			0			0											
03/30/21 5:00	0			0			0											
03/30/21 6:00	0			0			0											
03/30/21 7:00	0			0			0											
03/30/21 8:00	0			0			0											
03/30/21 9:00	0			0			0											
03/30/21 10:00	0			0			0											
03/30/21 11:00	0			0			0											
03/30/21 12:00	0			0			0											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/30/21 13:00	0			0			0											
03/30/21 14:00	0			0			0											
03/30/21 15:00	0			0			0											
03/30/21 16:00	0			0			0											
03/30/21 17:00	0			0			0											
03/30/21 18:00	0			0			0											
03/30/21 19:00	0			0			0											
03/30/21 20:00	0			0			0											
03/30/21 21:00	0			0			0											
03/30/21 22:00	0			0			0											
03/30/21 23:00	0			0			0											
03/31/21 0:00	0			0			0											
03/31/21 1:00	0			0			0											
03/31/21 2:00	0			0			0											
03/31/21 3:00	0			0			0											
03/31/21 4:00	0			0			0											
03/31/21 5:00	0			0			0											
03/31/21 6:00	0			0			0											
03/31/21 7:00	0			0			0											
03/31/21 8:00	0			0			0											
03/31/21 9:00	0			0			0											
03/31/21 10:00	0			0			0											
03/31/21 11:00	0			0			0											
03/31/21 12:00	0			0			0											
03/31/21 13:00	0			0			0											
03/31/21 14:00	0			0			0											
03/31/21 15:00	0			0			0											
03/31/21 16:00	0			0			0											
03/31/21 17:00	0			0			0											
03/31/21 18:00	0			0			0											
03/31/21 19:00	0			0			0											
03/31/21 20:00	0			0			0											
03/31/21 21:00	0			0			0											
03/31/21 22:00	0			0			0											
03/31/21 23:00	0			0			0											

CEMs Log

Date/Time	Operator	Description
03/24/21	Administrator (BrB)	Performed passing Linearitys (NOX &O2) and CGAs (High and LOW) on unit 1. All SAT
03/23/21	Administrator (BRB)	Performed Nox and O2 Linearities and CO CGAs on unit 2, yesterday had an abort for the O2 Linearity due to Bottle issue.
03/22/21	Administrator (BRB)	Performed NOX linearitys on unit 2 and CGAs on unit 2
03/17/21	Administrator (VRL)	Per TML instruction modified PLC code to keep having both high and low load range data invalidated at same time.
03/17/21 4:37	Operator (DWN)	CHANGED DAYLIGHT SAVINGS BIAS TO -120 FROM -60.
03/13/21	Operator (vrl)	CT2 Reaction cell cleaned and o rings replaced by RG. Performed cal error check.
03/05/21	Operator (DWN)	GCV UPDATED FOR EACH UNIT TO 104,150 FOR MARCH
03/01/21 8:54	Administrator (BRB)	Replaced unit 2 Nox Vacuum pump and manual spanned stack Nox/CO and O2
02/27/21	Administrator (VRL)	Ct2 stack >1 error. Adjust high low 0 span . Run error check. Adjust O2 span. Ct2 Nox inlet adjust zero and span and run error check
02/03/21	Administrator (DWN)	UPDATED GCV VALUE FOR EACH UNIT TO 104,200 FOR FEBRUARY
01/08/21	Administrator (DWN)	GCV UPDATED FOR EACH UNIT FOR JANUARY TO 104,200
01/07/21	Administrator (VRL)	Performed DB maintenance on server and defrag drive.
01/07/21	Administrator (VRL)	Rony performed monthly maint. on CT2
01/07/21	Administrator (VRL)	Rony performed monthly maint. on CT1

Cylinder Gas Audit

04/01/2021

Page 1

Facility: ROSEVILLE ENERGY
Unit/Stack: CT2
Parameter/Scale: CO / High

Test Date: 03/23/2021
Test Result: **Pass**

Instrument Name: CT2_CODualRg_P_Instrume
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
03/23/2021	07:28	L	200	49.400	50.100	24.7 %
03/23/2021	07:34	M	200	112.700	116.800	56.4 %
03/23/2021	07:46	L	200	49.400	50.300	24.7 %
03/23/2021	07:51	M	200	112.700	116.900	56.4 %
03/23/2021	08:03	L	200	49.400	50.100	24.7 %
03/23/2021	08:08	M	200	112.700	116.900	56.4 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	49.400	50.167	Std	1.6
M	112.700	116.867	Std	3.7

Cylinder Gas Audit

04/01/2021

Page 2

Facility: ROSEVILLE ENERGY
Unit/Stack: CT2
Parameter/Scale: CO / High

Test Date: 03/23/2021
Test Result: **Pass**

Instrument Name: CT2_CODualRg_P_Instrume
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
03/23/2021	07:28	L	200	49.400	50.100	24.7 %
03/23/2021	07:34	M	200	112.700	116.800	56.4 %
03/23/2021	07:46	L	200	49.400	50.300	24.7 %
03/23/2021	07:51	M	200	112.700	116.900	56.4 %
03/23/2021	08:03	L	200	49.400	50.100	24.7 %
03/23/2021	08:08	M	200	112.700	116.900	56.4 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	49.400	50.167	Std	1.6
M	112.700	116.867	Std	3.7

Cylinder Gas Audit

04/01/2021

Page 3

Facility: ROSEVILLE ENERGY
Unit/Stack: CT2
Parameter/Scale: CO / Low

Test Date: 03/23/2021
Test Result: **Pass**

Instrument Name: CT2_CODualRg_P_Instrume
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
03/23/2021	12:25	L	10	2.400	2.300	24.0 %
03/23/2021	12:31	M	10	5.700	5.600	57.0 %
03/23/2021	12:38	L	10	2.400	2.300	24.0 %
03/23/2021	12:43	M	10	5.700	5.600	57.0 %
03/23/2021	12:50	L	10	2.400	2.300	24.0 %
03/23/2021	12:55	M	10	5.700	5.600	57.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	2.400	2.300	Std	4.2
M	5.700	5.600	Std	1.8

Cylinder Gas Audit

04/01/2021

Page 4

Facility: ROSEVILLE ENERGY
Unit/Stack: CT1
Parameter/Scale: CO / High

Test Date: 03/24/2021
Test Result: **Pass**

Instrument Name: CT1_CODualRg_P_Instrume
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
03/24/2021	06:28	L	200	50.300	50.800	25.2 %
03/24/2021	06:34	M	200	112.800	116.400	56.4 %
03/24/2021	06:46	L	200	50.300	50.800	25.2 %
03/24/2021	06:51	M	200	112.800	116.400	56.4 %
03/24/2021	07:03	L	200	50.300	50.700	25.2 %
03/24/2021	07:08	M	200	112.800	116.300	56.4 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	50.300	50.767	Std	0.9
M	112.800	116.367	Std	3.2

Cylinder Gas Audit

04/01/2021

Page 5

Facility: ROSEVILLE ENERGY
Unit/Stack: CT1
Parameter/Scale: CO / Low

Test Date: 03/24/2021
Test Result: **Pass**

Instrument Name: CT1_CODualRg_P_Instrume
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
03/24/2021	10:30	L	10	2.400	2.500	24.0 %
03/24/2021	10:35	M	10	5.700	5.900	57.0 %
03/24/2021	10:43	L	10	2.400	2.500	24.0 %
03/24/2021	10:48	M	10	5.700	5.900	57.0 %
03/24/2021	10:55	L	10	2.400	2.500	24.0 %
03/24/2021	11:00	M	10	5.700	5.900	57.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	2.400	2.500	Std	4.2
M	5.700	5.900	Std	3.5

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/01/2021 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/01/2021 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/01/2021 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/01/2021 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/01/2021 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/01/2021 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/01/2021 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/01/2021 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/01/2021 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/01/2021 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/01/2021 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/01/2021 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/01/2021 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/01/2021 13:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/01/2021 14:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/01/2021 15:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/01/2021 16:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/01/2021 17:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/01/2021 18:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/01/2021 19:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/01/2021 20:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/01/2021 21:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/01/2021 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/01/2021 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/02/2021 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/02/2021 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/02/2021 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/02/2021 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/02/2021 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/02/2021 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/02/2021 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/02/2021 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/02/2021 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/02/2021 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/02/2021 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/02/2021 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/02/2021 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/02/2021 13:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/02/2021 14:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/02/2021 15:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/02/2021 16:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/02/2021 17:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/02/2021 18:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/02/2021 19:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/02/2021 20:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/02/2021 21:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/02/2021 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/02/2021 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/03/2021 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/03/2021 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/03/2021 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/03/2021 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/03/2021 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/03/2021 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/03/2021 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/03/2021 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/03/2021 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/03/2021 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/03/2021 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/03/2021 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/03/2021 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/03/2021 13:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/03/2021 14:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/03/2021 15:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/03/2021 16:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/03/2021 17:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/03/2021 18:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/03/2021 19:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/03/2021 20:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/03/2021 21:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/03/2021 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/03/2021 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/04/2021 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/04/2021 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/04/2021 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/04/2021 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/04/2021 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/04/2021 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/04/2021 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/04/2021 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/04/2021 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/04/2021 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/04/2021 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/04/2021 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/04/2021 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/04/2021 13:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/04/2021 14:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/04/2021 15:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/04/2021 16:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/04/2021 17:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/04/2021 18:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/04/2021 19:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/04/2021 20:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/04/2021 21:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/04/2021 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/04/2021 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/05/2021 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/05/2021 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/05/2021 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/05/2021 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/05/2021 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/05/2021 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/05/2021 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/05/2021 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/05/2021 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/05/2021 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/05/2021 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/05/2021 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/05/2021 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/05/2021 13:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/05/2021 14:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/05/2021 15:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/05/2021 16:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/05/2021 17:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/05/2021 18:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/05/2021 19:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/05/2021 20:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/05/2021 21:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/05/2021 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/05/2021 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/06/2021 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/06/2021 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/06/2021 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/06/2021 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/06/2021 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/06/2021 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/06/2021 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/06/2021 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/06/2021 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/06/2021 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/06/2021 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/06/2021 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/06/2021 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/06/2021 13:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/06/2021 14:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/06/2021 15:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/06/2021 16:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/06/2021 17:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/06/2021 18:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/06/2021 19:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/06/2021 20:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/06/2021 21:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/06/2021 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/06/2021 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/07/2021 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/07/2021 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/07/2021 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/07/2021 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/07/2021 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/07/2021 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/07/2021 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/07/2021 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/07/2021 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/07/2021 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/07/2021 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/07/2021 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/07/2021 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/07/2021 13:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/07/2021 14:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/07/2021 15:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/07/2021 16:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/07/2021 17:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/07/2021 18:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/07/2021 19:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/07/2021 20:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/07/2021 21:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/07/2021 22:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/07/2021 23:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/08/2021 00:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/08/2021 01:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/08/2021 02:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/08/2021 03:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/08/2021 04:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/08/2021 05:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/08/2021 06:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/08/2021 07:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/08/2021 08:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/08/2021 09:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/08/2021 10:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/08/2021 11:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/08/2021 12:00	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
01/08/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/08/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/08/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/08/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/08/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/08/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/08/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/08/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/08/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/08/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/08/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,525.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/09/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/09/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/09/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/09/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/09/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/09/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/09/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/09/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/09/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/09/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/09/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/09/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/09/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/09/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/09/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/09/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/09/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/09/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/09/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/09/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/09/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/09/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/09/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/09/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/10/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/10/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/10/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/10/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/10/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/10/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/10/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/10/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/10/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/10/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/10/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/10/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/10/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/10/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/10/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/10/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/10/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/10/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/10/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/10/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/10/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/10/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/10/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/10/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/11/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/11/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/11/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/11/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/11/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/11/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/11/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/11/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/11/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/11/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/11/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/11/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/11/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/11/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/11/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/11/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/11/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/11/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/11/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/11/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/11/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/11/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/11/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/11/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/12/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/12/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/12/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/12/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/12/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/12/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/12/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/12/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/12/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/12/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/12/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/12/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/12/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/12/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/12/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/12/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/12/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/12/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/12/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/12/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/12/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/12/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/12/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/12/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/13/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/13/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/13/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/13/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/13/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/13/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/13/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/13/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/13/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/13/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/13/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/13/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/13/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/13/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/13/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/13/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/13/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/13/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/13/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/13/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/13/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/13/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/13/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/13/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/14/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/14/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/14/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/14/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/14/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/14/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/14/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/14/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/14/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/14/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/14/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/14/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/14/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/14/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/14/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/14/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/14/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/14/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/14/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/14/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/14/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/14/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/14/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/14/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/15/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/15/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/15/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/15/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/15/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/15/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/15/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/15/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/15/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/15/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/15/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/15/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/15/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/15/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/15/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/15/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/15/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/15/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/15/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/15/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/15/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/15/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/15/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/15/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/16/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/16/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/16/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/16/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/16/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/16/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/16/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/16/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/16/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/16/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/16/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/16/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/16/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/16/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/16/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/16/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/16/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/16/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/16/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/16/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/16/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/16/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/16/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/16/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/17/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/17/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/17/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/17/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/17/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/17/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/17/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/17/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/17/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/17/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/17/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/17/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/17/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/17/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/17/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/17/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/17/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/17/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/17/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/17/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/17/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/17/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/17/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/17/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/18/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/18/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/18/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/18/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/18/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/18/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/18/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/18/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/18/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/18/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/18/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/18/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/18/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/18/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/18/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/18/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/18/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/18/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/18/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/18/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/18/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/18/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/18/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/18/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/19/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/19/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/19/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/19/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/19/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/19/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/19/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/19/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/19/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/19/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/19/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/19/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/19/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/19/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/19/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/19/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/19/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/19/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/19/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/19/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/19/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/19/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/19/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/19/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/20/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/20/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/20/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/20/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/20/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/20/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/20/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/20/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/20/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/20/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/20/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/20/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/20/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/20/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/20/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/20/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/20/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/20/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/20/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/20/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/20/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/20/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/20/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/20/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/21/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/21/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/21/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/21/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/21/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/21/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/21/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/21/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/21/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/21/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/21/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/21/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/21/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/21/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/21/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/21/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/21/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/21/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/21/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/21/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/21/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/21/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/21/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/21/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/22/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/22/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/22/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/22/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/22/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/22/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/22/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/22/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/22/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/22/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/22/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/22/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/22/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/22/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/22/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/22/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/22/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/22/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/22/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/22/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/22/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/22/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/22/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/22/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/23/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/23/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/23/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/23/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/23/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/23/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/23/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/23/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/23/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/23/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/23/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/23/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/23/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/23/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/23/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/23/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/23/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/23/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/23/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/23/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/23/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/23/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/23/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/23/2021 23:00	1,396.3	0.0	1,396.3	104,200.0	145.5	0.00	0.0	0.0
Average/Sum#:	1,396.3	0.0	1,396.3	104,200.0	145.5	0.00	0.0	0.0
Minimum:	1,396.3	0.0	1,396.3	104,200.0	145.5	0.00	0.0	0.0
Maximum:	1,396.3	0.0	1,396.3	104,200.0	145.5	0.00	0.0	0.0
%SI	95.83	95.83	95.83	0.00	95.83	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/24/2021 00:00	4,208.4	0.0	4,208.4	104,200.0	438.5	0.53	0.3	0.9
01/24/2021 01:00	4,046.6	0.0	4,046.6	104,200.0	421.7	0.51	0.3	0.8
01/24/2021 02:00	3,381.3	0.0	3,381.3	104,200.0	352.3	0.43	0.2	0.7
01/24/2021 03:00	3,225.7	0.0	3,225.7	104,200.0	336.1	0.40	0.2	0.7
01/24/2021 04:00	3,285.3	0.0	3,285.3	104,200.0	342.3	0.41	0.2	0.7
01/24/2021 05:00	3,497.2	0.0	3,497.2	104,200.0	364.4	0.44	0.2	0.7
01/24/2021 06:00	3,143.3	0.0	3,143.3	104,200.0	327.5	0.39	0.2	0.7
01/24/2021 07:00	3,132.7	0.0	3,132.7	104,200.0	326.4	0.39	0.2	0.7
01/24/2021 08:00	3,075.6	0.0	3,075.6	104,200.0	320.5	0.38	0.2	0.6
01/24/2021 09:00	3,333.7	0.0	3,333.7	104,200.0	347.4	0.42	0.2	0.7
01/24/2021 10:00	3,315.6	0.0	3,315.6	104,200.0	345.5	0.42	0.2	0.7
01/24/2021 11:00	3,296.3	0.0	3,296.3	104,200.0	343.5	0.41	0.2	0.7
01/24/2021 12:00	3,681.2	0.0	3,681.2	104,200.0	383.6	0.46	0.2	0.8
01/24/2021 13:00	3,646.1	0.0	3,646.1	104,200.0	379.9	0.46	0.2	0.8
01/24/2021 14:00	3,894.2	0.0	3,894.2	104,200.0	405.8	0.49	0.2	0.8
01/24/2021 15:00	4,111.1	0.0	4,111.1	104,200.0	428.4	0.51	0.3	0.9
01/24/2021 16:00	4,309.1	279.1	4,582.6	104,200.0	477.5	0.58	0.3	1.0
01/24/2021 17:00	4,323.3	212.4	4,535.7	104,200.0	472.6	0.57	0.3	0.9
01/24/2021 18:00	4,335.5	428.7	4,764.2	104,200.0	496.4	0.60	0.3	1.0
01/24/2021 19:00	4,334.0	243.9	4,541.3	104,200.0	473.2	0.57	0.3	1.0
01/24/2021 20:00	4,078.8	0.0	4,078.8	104,200.0	425.0	0.51	0.3	0.8
01/24/2021 21:00	3,614.0	0.0	3,614.0	104,200.0	376.6	0.45	0.2	0.8
01/24/2021 22:00	3,909.8	0.0	3,909.8	104,200.0	407.4	0.49	0.2	0.8
01/24/2021 23:00	3,408.6	0.0	3,408.6	104,200.0	355.2	0.43	0.2	0.7
Average/Sum#:	3,691.1	48.5	3,737.9	104,200.0	389.5	0.47	0.2	0.8
Minimum:	3,075.6	0.0	3,075.6	104,200.0	320.5	0.38	0.2	0.6
Maximum:	4,335.5	428.7	4,764.2	104,200.0	496.4	0.60	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 **To:** 03/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/25/2021 00:00	3,279.6	0.0	3,279.6	104,200.0	341.7	0.41	0.2	0.7
01/25/2021 01:00	3,193.4	0.0	3,193.4	104,200.0	332.8	0.40	0.2	0.7
01/25/2021 02:00	3,191.3	0.0	3,191.3	104,200.0	332.5	0.40	0.2	0.7
01/25/2021 03:00	3,261.0	0.0	3,261.0	104,200.0	339.8	0.41	0.2	0.7
01/25/2021 04:00	3,494.3	0.0	3,494.3	104,200.0	364.1	0.44	0.2	0.7
01/25/2021 05:00	4,012.7	0.0	4,012.7	104,200.0	418.1	0.50	0.3	0.8
01/25/2021 06:00	4,383.5	21.7	4,385.0	104,200.0	456.9	0.55	0.3	0.9
01/25/2021 07:00	4,379.5	847.5	5,227.0	104,200.0	544.7	0.65	0.3	1.1
01/25/2021 08:00	4,375.7	1,551.6	5,927.3	104,200.0	617.6	0.74	0.4	1.2
01/25/2021 09:00	4,360.1	1,830.2	6,190.3	104,200.0	645.0	0.77	0.4	1.3
01/25/2021 10:00	4,343.8	1,222.1	5,565.9	104,200.0	580.0	0.70	0.3	1.2
01/25/2021 11:00	4,324.3	1,032.9	5,357.2	104,200.0	558.2	0.67	0.3	1.1
01/25/2021 12:00	4,312.1	613.5	4,925.6	104,200.0	513.2	0.62	0.3	1.0
01/25/2021 13:00	4,298.1	404.5	4,702.6	104,200.0	490.0	0.59	0.3	1.0
01/25/2021 14:00	4,285.6	413.0	4,698.6	104,200.0	489.6	0.59	0.3	1.0
01/25/2021 15:00	4,285.6	308.1	4,593.7	104,200.0	478.7	0.57	0.3	1.0
01/25/2021 16:00	4,286.1	1,096.2	5,382.3	104,200.0	560.8	0.67	0.3	1.1
01/25/2021 17:00	4,295.7	567.9	4,863.6	104,200.0	506.8	0.61	0.3	1.0
01/25/2021 18:00	4,326.7	1,803.5	6,130.2	104,200.0	638.8	0.77	0.4	1.3
01/25/2021 19:00	4,337.6	1,817.6	6,155.2	104,200.0	641.4	0.77	0.4	1.3
01/25/2021 20:00	4,346.5	1,609.9	5,956.4	104,200.0	620.7	0.74	0.4	1.2
01/25/2021 21:00	4,385.1	794.4	5,179.5	104,200.0	539.7	0.65	0.3	1.1
01/25/2021 22:00	4,320.4	19.8	4,322.4	104,200.0	450.4	0.54	0.3	0.9
01/25/2021 23:00	3,822.6	0.0	3,822.6	104,200.0	398.3	0.48	0.2	0.8
Average/Sum#:	4,079.2	664.8	4,742.4	104,200.0	494.2	0.59	0.3	1.0
Minimum:	3,191.3	0.0	3,191.3	104,200.0	332.5	0.40	0.2	0.7
Maximum:	4,385.1	1,830.2	6,190.3	104,200.0	645.0	0.77	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/26/2021 00:00	2,114.1	0.0	2,114.1	104,200.0	220.3	0.00	0.0	0.0
01/26/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/26/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/26/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/26/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/26/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/26/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/26/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/26/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/26/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/26/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/26/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/26/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/26/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/26/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/26/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/26/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/26/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/26/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/26/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/26/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/26/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/26/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/26/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	2,114.1	0.0	2,114.1	104,200.0	220.3	0.00	0.0	0.0
Minimum:	2,114.1	0.0	2,114.1	104,200.0	220.3	0.00	0.0	0.0
Maximum:	2,114.1	0.0	2,114.1	104,200.0	220.3	0.00	0.0	0.0
%SI	95.83	95.83	95.83	0.00	95.83	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/27/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/27/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/27/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/27/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/27/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/27/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/27/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/27/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/27/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/27/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/27/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/27/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/27/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/27/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/27/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/27/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/27/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/27/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/27/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/27/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/27/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/27/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/27/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/27/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/28/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/28/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/28/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/28/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/28/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/28/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/28/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/28/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/28/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/28/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/28/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/28/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/28/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/28/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/28/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/28/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/28/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/28/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/28/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/28/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/28/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/28/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/28/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/28/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/29/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/29/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/29/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/29/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/29/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/29/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/29/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/29/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/29/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/29/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/29/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/29/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/29/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/29/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/29/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/29/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/29/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/29/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/29/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/29/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/29/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/29/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/29/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/29/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/30/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/30/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/30/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/30/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/30/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/30/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/30/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/30/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/30/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/30/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/30/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/30/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/30/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/30/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/30/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/30/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/30/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/30/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/30/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/30/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/30/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/30/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/30/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/30/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/31/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/31/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/31/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/31/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/31/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/31/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/31/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/31/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/31/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/31/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/31/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/31/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/31/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/31/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/31/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/31/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/31/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/31/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/31/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/31/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/31/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/31/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/31/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
01/31/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/01/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/01/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/01/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/01/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/01/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/01/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/01/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/01/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/01/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/01/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/01/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/01/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/01/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/01/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/01/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/01/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/01/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/01/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/01/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/01/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/01/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/01/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/01/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/01/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/02/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/02/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/02/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/02/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/02/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/02/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/02/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/02/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/02/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/02/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/02/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/02/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/02/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/02/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/02/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/02/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/02/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/02/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/02/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/02/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/02/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/02/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/02/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/02/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/03/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/03/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/03/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/03/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/03/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/03/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/03/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/03/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/03/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/03/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/03/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/03/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/03/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/03/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/03/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/03/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/03/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/03/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/03/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/03/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/03/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/03/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/03/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/03/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/04/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/04/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/04/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/04/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/04/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/04/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/04/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/04/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/04/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/04/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/04/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/04/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/04/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/04/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/04/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/04/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/04/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/04/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/04/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/04/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/04/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/04/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/04/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/04/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/05/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/05/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/05/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/05/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/05/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/05/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/05/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/05/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/05/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/05/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/05/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/05/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/05/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/05/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/05/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/05/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/05/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/05/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/05/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/05/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/05/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/05/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/05/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/05/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/06/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/06/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/06/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/06/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/06/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/06/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/06/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/06/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/06/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/06/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/06/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/06/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/06/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/06/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/06/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/06/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/06/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/06/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/06/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/06/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/06/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/06/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/06/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/06/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/07/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/07/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/07/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/07/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/07/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/07/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/07/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/07/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/07/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/07/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/07/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/07/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/07/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/07/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/07/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/07/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/07/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/07/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/07/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/07/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/07/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/07/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/07/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/07/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/08/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/08/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/08/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/08/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/08/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/08/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/08/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/08/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/08/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/08/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/08/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/08/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/08/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/08/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/08/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/08/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/08/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/08/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/08/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/08/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/08/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/08/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/08/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/08/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/09/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/09/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/09/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/09/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/09/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/09/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/09/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/09/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/09/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/09/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/09/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/09/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/09/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/09/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/09/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/09/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/09/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/09/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/09/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/09/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/09/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/09/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/09/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/09/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/10/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/10/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/10/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/10/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/10/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/10/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/10/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/10/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/10/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/10/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/10/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/10/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/10/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/10/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/10/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/10/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/10/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/10/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/10/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/10/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/10/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/10/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/10/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/10/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/11/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/11/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/11/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/11/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/11/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/11/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/11/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/11/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/11/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/11/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/11/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/11/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/11/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/11/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/11/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/11/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/11/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/11/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/11/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/11/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/11/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/11/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/11/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/11/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/12/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/12/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/12/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/12/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/12/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/12/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/12/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/12/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/12/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/12/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/12/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/12/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/12/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/12/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/12/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/12/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/12/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/12/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/12/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/12/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/12/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/12/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/12/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/12/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/13/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/13/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/13/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/13/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/13/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/13/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/13/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/13/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/13/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/13/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/13/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/13/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/13/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/13/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/13/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/13/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/13/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/13/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/13/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/13/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/13/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/13/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/13/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/13/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/14/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/14/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/14/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/14/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/14/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/14/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/14/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/14/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/14/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/14/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/14/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/14/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/14/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/14/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/14/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/14/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/14/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/14/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/14/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/14/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/14/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/14/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/14/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/14/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 **To:** 03/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/15/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/15/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/15/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/15/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/15/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/15/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/15/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/15/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/15/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/15/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/15/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/15/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/15/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/15/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/15/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/15/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/15/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/15/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/15/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/15/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/15/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/15/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/15/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/15/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/16/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/16/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/16/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/16/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/16/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/16/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/16/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/16/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/16/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/16/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/16/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/16/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/16/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/16/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/16/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/16/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/16/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/16/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/16/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/16/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/16/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/16/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/16/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/16/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/17/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/17/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/17/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/17/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/17/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/17/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/17/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/17/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/17/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/17/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/17/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/17/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/17/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/17/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/17/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/17/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/17/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/17/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/17/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/17/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/17/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/17/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/17/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/17/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/18/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/18/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/18/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/18/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/18/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/18/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/18/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/18/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/18/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/18/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/18/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/18/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/18/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/18/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/18/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/18/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/18/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/18/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/18/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/18/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/18/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/18/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/18/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/18/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/19/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/19/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/19/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/19/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/19/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/19/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/19/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/19/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/19/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/19/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/19/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/19/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/19/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/19/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/19/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/19/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/19/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/19/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/19/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/19/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/19/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/19/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/19/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/19/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/20/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/20/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/20/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/20/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/20/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/20/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/20/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/20/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/20/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/20/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/20/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/20/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/20/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/20/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/20/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/20/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/20/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/20/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/20/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/20/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/20/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/20/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/20/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/20/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/21/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/21/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/21/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/21/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/21/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/21/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/21/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/21/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/21/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/21/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/21/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/21/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/21/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/21/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/21/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/21/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/21/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/21/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/21/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/21/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/21/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/21/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/21/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/21/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/22/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/22/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/22/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/22/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/22/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/22/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/22/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/22/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/22/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/22/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/22/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/22/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/22/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/22/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/22/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/22/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/22/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/22/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/22/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/22/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/22/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/22/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/22/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/22/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/23/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/23/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/23/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/23/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/23/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/23/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/23/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/23/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/23/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/23/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/23/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/23/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/23/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/23/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/23/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/23/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/23/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/23/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/23/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/23/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/23/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/23/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/23/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/23/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/24/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/24/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/24/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/24/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/24/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/24/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/24/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/24/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/24/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/24/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/24/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/24/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/24/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/24/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/24/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/24/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/24/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/24/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/24/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/24/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/24/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/24/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/24/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/24/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/25/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/25/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/25/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/25/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/25/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/25/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/25/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/25/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/25/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/25/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/25/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/25/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/25/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/25/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/25/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/25/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/25/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/25/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/25/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/25/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/25/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/25/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/25/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/25/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/26/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/26/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/26/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/26/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/26/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/26/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/26/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/26/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/26/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/26/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/26/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/26/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/26/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/26/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/26/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/26/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/26/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/26/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/26/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/26/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/26/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/26/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/26/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/26/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/27/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/27/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/27/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/27/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/27/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/27/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/27/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/27/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/27/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/27/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/27/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/27/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/27/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/27/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/27/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/27/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/27/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/27/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/27/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/27/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/27/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/27/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/27/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/27/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/28/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/28/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/28/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/28/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/28/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/28/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/28/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/28/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/28/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/28/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/28/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/28/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/28/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/28/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/28/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/28/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/28/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/28/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/28/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/28/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/28/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/28/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/28/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
02/28/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/01/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/01/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/01/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/01/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/01/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/01/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/01/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/01/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/01/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/01/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/01/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/01/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/01/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/01/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/01/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/01/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/01/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/01/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/01/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/01/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/01/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/01/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/01/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/01/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/02/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/02/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/02/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/02/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/02/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/02/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/02/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/02/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/02/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/02/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/02/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/02/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/02/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/02/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/02/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/02/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/02/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/02/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/02/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/02/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/02/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/02/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/02/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/02/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/03/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/03/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/03/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/03/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/03/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/03/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/03/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/03/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/03/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/03/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/03/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/03/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/03/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/03/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/03/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/03/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/03/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/03/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/03/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/03/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/03/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/03/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/03/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/03/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/04/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/04/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/04/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/04/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/04/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/04/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/04/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/04/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/04/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/04/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/04/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/04/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/04/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/04/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/04/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/04/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/04/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/04/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/04/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/04/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/04/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/04/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/04/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/04/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/05/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/05/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/05/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/05/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/05/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/05/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/05/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/05/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/05/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/05/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/05/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/05/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/05/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/05/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
03/05/2021 14:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/05/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/05/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/05/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/05/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/05/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/05/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/05/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/05/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/05/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,179.2	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/06/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/06/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/06/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/06/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/06/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/06/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/06/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/06/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/06/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/06/2021 09:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/06/2021 10:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/06/2021 11:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/06/2021 12:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/06/2021 13:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/06/2021 14:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/06/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/06/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/06/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/06/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/06/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/06/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/06/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/06/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/06/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/07/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/07/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/07/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/07/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/07/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/07/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/07/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/07/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/07/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/07/2021 09:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/07/2021 10:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/07/2021 11:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/07/2021 12:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/07/2021 13:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/07/2021 14:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/07/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/07/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/07/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/07/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/07/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/07/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/07/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/07/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/07/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/08/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/08/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/08/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/08/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/08/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/08/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/08/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/08/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/08/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/08/2021 09:00	465.7	0.0	465.7	104,150.0	48.5	0.00	0.0	0.0
03/08/2021 10:00	984.9	0.0	984.9	104,150.0	102.6	0.00	0.0	0.0
03/08/2021 11:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/08/2021 12:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/08/2021 13:00	512.7	0.0	512.7	104,150.0	53.4	0.00	0.0	0.0
03/08/2021 14:00	1,350.1	0.0	1,350.1	104,150.0	140.6	0.00	0.0	0.0
03/08/2021 15:00	3,213.2	0.0	3,213.2	104,150.0	334.7	0.43	0.2	0.7
03/08/2021 16:00	4,672.3	0.0	4,672.3	104,150.0	486.6	0.58	0.3	1.0
03/08/2021 17:00	4,701.2	0.0	4,701.2	104,150.0	489.6	0.59	0.3	1.0
03/08/2021 18:00	4,711.5	0.0	4,711.5	104,150.0	490.7	0.59	0.3	1.0
03/08/2021 19:00	4,546.1	0.0	4,546.1	104,150.0	473.5	0.57	0.3	0.9
03/08/2021 20:00	2,210.0	0.0	2,210.0	104,150.0	230.2	0.38	0.2	0.6
03/08/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/08/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/08/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Average/Sum#:	2,736.8	0.0	2,736.8	104,150.0	285.0	0.52	0.3	0.9
Minimum:	465.7	0.0	465.7	104,150.0	48.5	0.38	0.2	0.6
Maximum:	4,711.5	0.0	4,711.5	104,150.0	490.7	0.59	0.3	1.0
%SI	58.33	58.33	58.33	0.00	58.33	75.00	75.00	75.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/09/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/09/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/09/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/09/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/09/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/09/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/09/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/09/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/09/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/09/2021 09:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/09/2021 10:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/09/2021 11:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/09/2021 12:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/09/2021 13:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/09/2021 14:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/09/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/09/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/09/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/09/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/09/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/09/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/09/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/09/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/09/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/10/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/10/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/10/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/10/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/10/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/10/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/10/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/10/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/10/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/10/2021 09:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/10/2021 10:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/10/2021 11:00	1,477.8	0.0	1,477.8	104,150.0	153.9	0.00	0.0	0.0
03/10/2021 12:00	2,483.5	0.0	2,483.5	104,150.0	258.7	0.00	0.0	0.0
03/10/2021 13:00	2,673.2	0.0	2,673.2	104,150.0	278.4	0.34	0.2	0.6
03/10/2021 14:00	3,313.8	0.0	3,313.8	104,150.0	345.1	0.41	0.2	0.7
03/10/2021 15:00	4,487.1	0.0	4,487.1	104,150.0	467.3	0.56	0.3	0.9
03/10/2021 16:00	4,689.1	0.0	4,689.1	104,150.0	488.4	0.59	0.3	1.0
03/10/2021 17:00	4,691.8	0.0	4,691.8	104,150.0	488.7	0.59	0.3	1.0
03/10/2021 18:00	4,590.0	0.0	4,590.0	104,150.0	478.0	0.57	0.3	1.0
03/10/2021 19:00	2,377.0	0.0	2,377.0	104,150.0	247.6	0.38	0.2	0.6
03/10/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/10/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/10/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/10/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Average/Sum#:	3,420.4	0.0	3,420.4	104,150.0	356.2	0.49	0.3	0.8
Minimum:	1,477.8	0.0	1,477.8	104,150.0	153.9	0.34	0.2	0.6
Maximum:	4,691.8	0.0	4,691.8	104,150.0	488.7	0.59	0.3	1.0
%SI	62.50	62.50	62.50	0.00	62.50	70.83	70.83	70.83

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/11/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/11/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/11/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/11/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/11/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/11/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/11/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/11/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/11/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/11/2021 09:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/11/2021 10:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/11/2021 11:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/11/2021 12:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/11/2021 13:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/11/2021 14:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/11/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/11/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/11/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/11/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/11/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/11/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/11/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/11/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/11/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/12/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/12/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/12/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/12/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/12/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/12/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/12/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/12/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/12/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/12/2021 09:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/12/2021 10:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/12/2021 11:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/12/2021 12:00	371.0	0.0	371.0	104,150.0	38.6	0.00	0.0	0.0
03/12/2021 13:00	532.5	0.0	532.5	104,150.0	55.5	0.00	0.0	0.0
03/12/2021 14:00	2,261.9	0.0	2,261.9	104,150.0	235.6	0.00	0.0	0.0
03/12/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/12/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/12/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/12/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/12/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/12/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/12/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/12/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/12/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Average/Sum#:	1,055.1	0.0	1,055.1	104,150.0	109.9	0.00	0.0	0.0
Minimum:	371.0	0.0	371.0	104,150.0	38.6	0.00	0.0	0.0
Maximum:	2,261.9	0.0	2,261.9	104,150.0	235.6	0.00	0.0	0.0
%SI	87.50	87.50	87.50	0.00	87.50	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/13/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/13/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/13/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/13/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/13/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/13/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/13/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/13/2021 07:00	156.3	0.0	156.3	104,150.0	16.3	0.00	0.0	0.0
03/13/2021 08:00	1,543.2	0.0	1,543.2	104,150.0	160.7	0.00	0.0	0.0
03/13/2021 09:00	3,851.3	0.0	3,851.3	104,150.0	401.1	0.00	0.0	0.0
03/13/2021 10:00	3,315.2	0.0	3,315.2	104,150.0	345.3	0.49	0.2	0.8
03/13/2021 11:00	3,878.0	0.0	3,878.0	104,150.0	403.9	0.48	0.2	0.8
03/13/2021 12:00	4,564.5	0.0	4,564.5	104,150.0	475.4	0.57	0.3	0.9
03/13/2021 13:00	4,534.8	46.6	4,539.5	104,150.0	472.8	0.57	0.3	1.0
03/13/2021 14:00	4,524.4	1,963.5	6,487.9	104,150.0	675.7	0.81	0.4	1.4
03/13/2021 15:00	4,512.5	2,098.9	6,611.4	104,150.0	688.6	0.83	0.4	1.4
03/13/2021 16:00	4,515.7	2,102.9	6,618.6	104,150.0	689.3	0.83	0.4	1.4
03/13/2021 17:00	4,382.4	483.7	4,542.0	104,150.0	473.0	0.61	0.3	1.0
03/13/2021 18:00	2,113.3	0.0	2,113.3	104,150.0	220.1	0.38	0.2	0.6
03/13/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/13/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/13/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/13/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/13/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Average/Sum#:	3,491.0	558.0	4,018.4	104,150.0	418.5	0.62	0.3	1.0
Minimum:	156.3	0.0	156.3	104,150.0	16.3	0.38	0.2	0.6
Maximum:	4,564.5	2,102.9	6,618.6	104,150.0	689.3	0.83	0.4	1.4
%SI	50.00	50.00	50.00	0.00	50.00	62.50	62.50	62.50

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/14/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/14/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/14/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/14/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/14/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/14/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/14/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/14/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/14/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/14/2021 09:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/14/2021 10:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/14/2021 11:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/14/2021 12:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/14/2021 13:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/14/2021 14:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/14/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/14/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/14/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/14/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/14/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/14/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/14/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/14/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/14/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/15/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/15/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/15/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/15/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/15/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/15/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/15/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/15/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/15/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/15/2021 09:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/15/2021 10:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/15/2021 11:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/15/2021 12:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/15/2021 13:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/15/2021 14:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/15/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/15/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/15/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/15/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/15/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/15/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/15/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/15/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/15/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/16/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/16/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/16/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/16/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/16/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/16/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/16/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/16/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/16/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/16/2021 09:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/16/2021 10:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/16/2021 11:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/16/2021 12:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/16/2021 13:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/16/2021 14:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/16/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/16/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/16/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/16/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/16/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/16/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/16/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/16/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/16/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/17/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/17/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/17/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/17/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/17/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/17/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/17/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/17/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/17/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/17/2021 09:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/17/2021 10:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/17/2021 11:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/17/2021 12:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/17/2021 13:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/17/2021 14:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/17/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/17/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/17/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/17/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/17/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/17/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/17/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/17/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/17/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/18/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/18/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/18/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/18/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/18/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/18/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/18/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/18/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/18/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/18/2021 09:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/18/2021 10:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/18/2021 11:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/18/2021 12:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/18/2021 13:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/18/2021 14:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/18/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/18/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/18/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/18/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/18/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/18/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/18/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/18/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/18/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/19/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/19/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/19/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/19/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/19/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/19/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/19/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/19/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/19/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/19/2021 09:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/19/2021 10:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/19/2021 11:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/19/2021 12:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/19/2021 13:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/19/2021 14:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/19/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/19/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/19/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/19/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/19/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/19/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/19/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/19/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/19/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/20/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/20/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/20/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/20/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/20/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/20/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/20/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/20/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/20/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/20/2021 09:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/20/2021 10:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/20/2021 11:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/20/2021 12:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/20/2021 13:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/20/2021 14:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/20/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/20/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/20/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/20/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/20/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/20/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/20/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/20/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/20/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/21/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/21/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/21/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/21/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/21/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/21/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/21/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/21/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/21/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/21/2021 09:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/21/2021 10:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/21/2021 11:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/21/2021 12:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/21/2021 13:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/21/2021 14:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/21/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/21/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/21/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/21/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/21/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/21/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/21/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/21/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/21/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/22/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/22/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/22/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/22/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/22/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/22/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/22/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/22/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/22/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/22/2021 09:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/22/2021 10:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/22/2021 11:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/22/2021 12:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/22/2021 13:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/22/2021 14:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/22/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/22/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/22/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/22/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/22/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/22/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/22/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/22/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/22/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/23/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/23/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/23/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/23/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/23/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/23/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/23/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/23/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/23/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/23/2021 09:00	416.0	0.0	416.0	104,150.0	43.3	0.00	0.0	0.0
03/23/2021 10:00	2,250.4	0.0	2,250.4	104,150.0	234.4	0.00	0.0	0.0
03/23/2021 11:00	4,296.5	0.0	4,296.5	104,150.0	447.5	0.56	0.3	0.9
03/23/2021 12:00	4,559.5	1,387.0	5,669.1	104,150.0	590.4	0.74	0.4	1.2
03/23/2021 13:00	4,460.0	26.9	4,462.2	104,150.0	464.7	0.56	0.3	0.9
03/23/2021 14:00	4,457.3	1,122.2	5,355.1	104,150.0	557.7	0.70	0.3	1.2
03/23/2021 15:00	4,465.6	1,994.3	6,459.9	104,150.0	672.8	0.81	0.4	1.3
03/23/2021 16:00	4,469.4	646.3	5,115.7	104,150.0	532.8	0.64	0.3	1.1
03/23/2021 17:00	3,024.8	0.0	3,024.8	104,150.0	315.0	0.38	0.2	0.6
03/23/2021 18:00	2,753.8	0.0	2,753.8	104,150.0	286.8	0.34	0.2	0.6
03/23/2021 19:00	2,793.5	0.0	2,793.5	104,150.0	290.9	0.35	0.2	0.6
03/23/2021 20:00	2,825.8	0.0	2,825.8	104,150.0	294.3	0.35	0.2	0.6
03/23/2021 21:00	2,803.5	0.0	2,803.5	104,150.0	292.0	0.35	0.2	0.6
03/23/2021 22:00	2,798.4	0.0	2,798.4	104,150.0	291.5	0.35	0.2	0.6
03/23/2021 23:00	2,788.1	0.0	2,788.1	104,150.0	290.4	0.35	0.2	0.6
Average/Sum#:	3,277.5	345.1	3,587.5	104,150.0	373.6	0.50	0.3	0.8
Minimum:	416.0	0.0	416.0	104,150.0	43.3	0.34	0.2	0.6
Maximum:	4,559.5	1,994.3	6,459.9	104,150.0	672.8	0.81	0.4	1.3
%SI	37.50	37.50	37.50	0.00	37.50	45.83	45.83	45.83

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/24/2021 00:00	2,779.6	0.0	2,779.6	104,150.0	289.5	0.35	0.2	0.6
03/24/2021 01:00	2,787.8	0.0	2,787.8	104,150.0	290.3	0.35	0.2	0.6
03/24/2021 02:00	2,793.4	0.0	2,793.4	104,150.0	290.9	0.35	0.2	0.6
03/24/2021 03:00	2,794.0	0.0	2,794.0	104,150.0	291.0	0.35	0.2	0.6
03/24/2021 04:00	2,790.4	0.0	2,790.4	104,150.0	290.6	0.35	0.2	0.6
03/24/2021 05:00	2,792.1	0.0	2,792.1	104,150.0	290.8	0.35	0.2	0.6
03/24/2021 06:00	2,789.0	0.0	2,789.0	104,150.0	290.5	0.35	0.2	0.6
03/24/2021 07:00	2,989.5	0.0	2,989.5	104,150.0	311.4	0.37	0.2	0.6
03/24/2021 08:00	4,626.7	1,550.4	6,053.1	104,150.0	630.4	0.77	0.4	1.3
03/24/2021 09:00	3,415.4	0.0	3,415.4	104,150.0	355.7	0.43	0.2	0.7
03/24/2021 10:00	4,549.5	1,795.1	6,344.6	104,150.0	660.8	0.79	0.4	1.3
03/24/2021 11:00	3,644.1	24.1	3,646.0	104,150.0	379.7	0.48	0.2	0.8
03/24/2021 12:00	1,400.2	0.0	1,400.2	104,150.0	145.8	0.00	0.0	0.0
03/24/2021 13:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/24/2021 14:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/24/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/24/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/24/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/24/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/24/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/24/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/24/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/24/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/24/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Average/Sum#:	3,088.6	259.2	3,336.5	104,150.0	347.5	0.44	0.2	0.7
Minimum:	1,400.2	0.0	1,400.2	104,150.0	145.8	0.35	0.2	0.6
Maximum:	4,626.7	1,795.1	6,344.6	104,150.0	660.8	0.79	0.4	1.3
%SI	45.83	45.83	45.83	0.00	45.83	50.00	50.00	50.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:50 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/25/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/25/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/25/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/25/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/25/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/25/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/25/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/25/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/25/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/25/2021 09:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/25/2021 10:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/25/2021 11:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/25/2021 12:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/25/2021 13:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/25/2021 14:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/25/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/25/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/25/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/25/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/25/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/25/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/25/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/25/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/25/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:51 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/26/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/26/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/26/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/26/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/26/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/26/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/26/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/26/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/26/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/26/2021 09:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/26/2021 10:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/26/2021 11:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/26/2021 12:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/26/2021 13:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/26/2021 14:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/26/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/26/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/26/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/26/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/26/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/26/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/26/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/26/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/26/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:51 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/27/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/27/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/27/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/27/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/27/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/27/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/27/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/27/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/27/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/27/2021 09:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/27/2021 10:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/27/2021 11:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/27/2021 12:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/27/2021 13:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/27/2021 14:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/27/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/27/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/27/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/27/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/27/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/27/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/27/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/27/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/27/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:51 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/28/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/28/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/28/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/28/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/28/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/28/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/28/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/28/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/28/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/28/2021 09:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/28/2021 10:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/28/2021 11:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/28/2021 12:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/28/2021 13:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/28/2021 14:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/28/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/28/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/28/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/28/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/28/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/28/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/28/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/28/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/28/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:51 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/29/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/29/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/29/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/29/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/29/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/29/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/29/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/29/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/29/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/29/2021 09:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/29/2021 10:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/29/2021 11:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/29/2021 12:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/29/2021 13:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/29/2021 14:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/29/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/29/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/29/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/29/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/29/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/29/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/29/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/29/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/29/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:51 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/30/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/30/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/30/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/30/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/30/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/30/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/30/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/30/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/30/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/30/2021 09:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/30/2021 10:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/30/2021 11:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/30/2021 12:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/30/2021 13:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/30/2021 14:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/30/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/30/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/30/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/30/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/30/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/30/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/30/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/30/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/30/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:51 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/31/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/31/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/31/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/31/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/31/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/31/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/31/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/31/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/31/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/31/2021 09:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/31/2021 10:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/31/2021 11:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/31/2021 12:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/31/2021 13:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/31/2021 14:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/31/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/31/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/31/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/31/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/31/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/31/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/31/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/31/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
03/31/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,150.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/01/2021 00:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/01/2021 01:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/01/2021 02:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/01/2021 03:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/01/2021 04:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/01/2021 05:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/01/2021 06:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/01/2021 07:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/01/2021 08:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/01/2021 09:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/01/2021 10:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/01/2021 11:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/01/2021 12:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/01/2021 13:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/01/2021 14:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/01/2021 15:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/01/2021 16:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/01/2021 17:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/01/2021 18:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/01/2021 19:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/01/2021 20:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/01/2021 21:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/01/2021 22:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/01/2021 23:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/02/2021 00:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/02/2021 01:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/02/2021 02:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/02/2021 03:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/02/2021 04:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/02/2021 05:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/02/2021 06:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/02/2021 07:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/02/2021 08:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/02/2021 09:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/02/2021 10:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/02/2021 11:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/02/2021 12:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/02/2021 13:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/02/2021 14:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/02/2021 15:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/02/2021 16:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/02/2021 17:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/02/2021 18:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/02/2021 19:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/02/2021 20:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/02/2021 21:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/02/2021 22:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/02/2021 23:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/03/2021 00:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/03/2021 01:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/03/2021 02:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/03/2021 03:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/03/2021 04:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/03/2021 05:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/03/2021 06:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/03/2021 07:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/03/2021 08:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/03/2021 09:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/03/2021 10:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/03/2021 11:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/03/2021 12:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/03/2021 13:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/03/2021 14:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/03/2021 15:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/03/2021 16:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/03/2021 17:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/03/2021 18:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/03/2021 19:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/03/2021 20:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/03/2021 21:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/03/2021 22:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/03/2021 23:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/04/2021 00:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/04/2021 01:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/04/2021 02:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/04/2021 03:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/04/2021 04:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/04/2021 05:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/04/2021 06:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/04/2021 07:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/04/2021 08:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/04/2021 09:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/04/2021 10:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/04/2021 11:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/04/2021 12:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/04/2021 13:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/04/2021 14:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/04/2021 15:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/04/2021 16:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/04/2021 17:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/04/2021 18:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/04/2021 19:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/04/2021 20:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/04/2021 21:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/04/2021 22:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/04/2021 23:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/05/2021 00:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/05/2021 01:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/05/2021 02:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/05/2021 03:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/05/2021 04:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/05/2021 05:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/05/2021 06:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/05/2021 07:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/05/2021 08:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/05/2021 09:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/05/2021 10:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/05/2021 11:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/05/2021 12:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/05/2021 13:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/05/2021 14:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/05/2021 15:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/05/2021 16:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/05/2021 17:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/05/2021 18:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/05/2021 19:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/05/2021 20:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/05/2021 21:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/05/2021 22:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/05/2021 23:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/06/2021 00:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/06/2021 01:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/06/2021 02:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/06/2021 03:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/06/2021 04:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/06/2021 05:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/06/2021 06:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/06/2021 07:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/06/2021 08:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/06/2021 09:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/06/2021 10:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/06/2021 11:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/06/2021 12:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/06/2021 13:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/06/2021 14:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/06/2021 15:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/06/2021 16:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/06/2021 17:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/06/2021 18:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/06/2021 19:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/06/2021 20:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/06/2021 21:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/06/2021 22:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/06/2021 23:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/07/2021 00:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/07/2021 01:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/07/2021 02:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/07/2021 03:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/07/2021 04:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/07/2021 05:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/07/2021 06:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/07/2021 07:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/07/2021 08:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/07/2021 09:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/07/2021 10:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/07/2021 11:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/07/2021 12:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/07/2021 13:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/07/2021 14:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/07/2021 15:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/07/2021 16:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/07/2021 17:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/07/2021 18:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/07/2021 19:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/07/2021 20:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/07/2021 21:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/07/2021 22:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/07/2021 23:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/08/2021 00:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/08/2021 01:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/08/2021 02:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/08/2021 03:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/08/2021 04:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/08/2021 05:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/08/2021 06:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/08/2021 07:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/08/2021 08:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/08/2021 09:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/08/2021 10:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/08/2021 11:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/08/2021 12:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
01/08/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/08/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/08/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/08/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/08/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/08/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/08/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/08/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/08/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/08/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/08/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,525.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/09/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/09/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/09/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/09/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/09/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/09/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/09/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/09/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/09/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/09/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/09/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/09/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/09/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/09/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/09/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/09/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/09/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/09/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/09/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/09/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/09/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/09/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/09/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/09/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/10/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/10/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/10/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/10/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/10/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/10/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/10/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/10/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/10/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/10/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/10/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/10/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/10/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/10/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/10/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/10/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/10/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/10/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/10/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/10/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/10/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/10/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/10/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/10/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/11/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/11/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/11/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/11/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/11/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/11/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/11/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/11/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/11/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/11/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/11/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/11/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/11/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/11/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/11/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/11/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/11/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/11/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/11/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/11/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/11/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/11/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/11/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/11/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 **To:** 03/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/12/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/12/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/12/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/12/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/12/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/12/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/12/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/12/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/12/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/12/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/12/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/12/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/12/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/12/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/12/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/12/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/12/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/12/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/12/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/12/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/12/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/12/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/12/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/12/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/13/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/13/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/13/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/13/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/13/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/13/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/13/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/13/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/13/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/13/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/13/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/13/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/13/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/13/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/13/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/13/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/13/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/13/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/13/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/13/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/13/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/13/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/13/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/13/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/14/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/14/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/14/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/14/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/14/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/14/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/14/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/14/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/14/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/14/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/14/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/14/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/14/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/14/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/14/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/14/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/14/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/14/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/14/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/14/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/14/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/14/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/14/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/14/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/15/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/15/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/15/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/15/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/15/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/15/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/15/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/15/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/15/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/15/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/15/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/15/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/15/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/15/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/15/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/15/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/15/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/15/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/15/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/15/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/15/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/15/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/15/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/15/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/16/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/16/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/16/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/16/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/16/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/16/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/16/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/16/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/16/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/16/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/16/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/16/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/16/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/16/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/16/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/16/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/16/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/16/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/16/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/16/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/16/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/16/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/16/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/16/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/17/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/17/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/17/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/17/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/17/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/17/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/17/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/17/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/17/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/17/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/17/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/17/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/17/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/17/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/17/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/17/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/17/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/17/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/17/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/17/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/17/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/17/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/17/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/17/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/18/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/18/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/18/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/18/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/18/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/18/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/18/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/18/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/18/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/18/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/18/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/18/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/18/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/18/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/18/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/18/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/18/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/18/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/18/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/18/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/18/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/18/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/18/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/18/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/19/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/19/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/19/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/19/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/19/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/19/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/19/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/19/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/19/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/19/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/19/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/19/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/19/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/19/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/19/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/19/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/19/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/19/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/19/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/19/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/19/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/19/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/19/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/19/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/20/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/20/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/20/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/20/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/20/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/20/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/20/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/20/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/20/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/20/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/20/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/20/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/20/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/20/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/20/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/20/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/20/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/20/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/20/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/20/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/20/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/20/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/20/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/20/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/21/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/21/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/21/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/21/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/21/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/21/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/21/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/21/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/21/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/21/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/21/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/21/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/21/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/21/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/21/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/21/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/21/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/21/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/21/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/21/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/21/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/21/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/21/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/21/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/22/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/22/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/22/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/22/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/22/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/22/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/22/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/22/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/22/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/22/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/22/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/22/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/22/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/22/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/22/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/22/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/22/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/22/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/22/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/22/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/22/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/22/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/22/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/22/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/23/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/23/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/23/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/23/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/23/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/23/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/23/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/23/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/23/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/23/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/23/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/23/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/23/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/23/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/23/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/23/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/23/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/23/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/23/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/23/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/23/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/23/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/23/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/23/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/24/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/24/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/24/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/24/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/24/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/24/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/24/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/24/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/24/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/24/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/24/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/24/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/24/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/24/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/24/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/24/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/24/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/24/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/24/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/24/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/24/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/24/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/24/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/24/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/25/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/25/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/25/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/25/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/25/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/25/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/25/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/25/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/25/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/25/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/25/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/25/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/25/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/25/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/25/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/25/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/25/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/25/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/25/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/25/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/25/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/25/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/25/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/25/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/26/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/26/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/26/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/26/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/26/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/26/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/26/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/26/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/26/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/26/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/26/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/26/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/26/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/26/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/26/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/26/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/26/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/26/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/26/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/26/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/26/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/26/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/26/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/26/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/27/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/27/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/27/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/27/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/27/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/27/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/27/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/27/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/27/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/27/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/27/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/27/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/27/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/27/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/27/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/27/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/27/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/27/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/27/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/27/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/27/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/27/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/27/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/27/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/28/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/28/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/28/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/28/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/28/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/28/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/28/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/28/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/28/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/28/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/28/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/28/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/28/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/28/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/28/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/28/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/28/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/28/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/28/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/28/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/28/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/28/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/28/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/28/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/29/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/29/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/29/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/29/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/29/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/29/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/29/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/29/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/29/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/29/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/29/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/29/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/29/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/29/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/29/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/29/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/29/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/29/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/29/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/29/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/29/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/29/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/29/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/29/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/30/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/30/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/30/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/30/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/30/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/30/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/30/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/30/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/30/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/30/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/30/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/30/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/30/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/30/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/30/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/30/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/30/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/30/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/30/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/30/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/30/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/30/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/30/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/30/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/31/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/31/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/31/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/31/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/31/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/31/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/31/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/31/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/31/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/31/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/31/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/31/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/31/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/31/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/31/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/31/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/31/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/31/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/31/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/31/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/31/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/31/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/31/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
01/31/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/01/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/01/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/01/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/01/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/01/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/01/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/01/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/01/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/01/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/01/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/01/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/01/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/01/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/01/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/01/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/01/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/01/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/01/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/01/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/01/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/01/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/01/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/01/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/01/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/02/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/02/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/02/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/02/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/02/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/02/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/02/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/02/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/02/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/02/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/02/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/02/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/02/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/02/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/02/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/02/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/02/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/02/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/02/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/02/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/02/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/02/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/02/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/02/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/03/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/03/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/03/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/03/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/03/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/03/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/03/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/03/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/03/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/03/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/03/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/03/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/03/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/03/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/03/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/03/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/03/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/03/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/03/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/03/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/03/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/03/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/03/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/03/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/04/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/04/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/04/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/04/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/04/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/04/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/04/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/04/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/04/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/04/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/04/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/04/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/04/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/04/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/04/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/04/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/04/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/04/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/04/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/04/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/04/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/04/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/04/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/04/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/05/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/05/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/05/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/05/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/05/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/05/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/05/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/05/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/05/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/05/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/05/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/05/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/05/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/05/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/05/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/05/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/05/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/05/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/05/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/05/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/05/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/05/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/05/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/05/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/06/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/06/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/06/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/06/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/06/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/06/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/06/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/06/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/06/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/06/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/06/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/06/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/06/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/06/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/06/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/06/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/06/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/06/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/06/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/06/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/06/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/06/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/06/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/06/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/07/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/07/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/07/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/07/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/07/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/07/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/07/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/07/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/07/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/07/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/07/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/07/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/07/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/07/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/07/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/07/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/07/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/07/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/07/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/07/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/07/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/07/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/07/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/07/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/08/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/08/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/08/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/08/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/08/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/08/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/08/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/08/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/08/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/08/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/08/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/08/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/08/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/08/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/08/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/08/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/08/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/08/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/08/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/08/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/08/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/08/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/08/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/08/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/09/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/09/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/09/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/09/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/09/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/09/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/09/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/09/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/09/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/09/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/09/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/09/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/09/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/09/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/09/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/09/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/09/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/09/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/09/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/09/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/09/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/09/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/09/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/09/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/10/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/10/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/10/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/10/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/10/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/10/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/10/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/10/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/10/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/10/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/10/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/10/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/10/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/10/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/10/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/10/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/10/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/10/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/10/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/10/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/10/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/10/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/10/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/10/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/11/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/11/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/11/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/11/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/11/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/11/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/11/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/11/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/11/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/11/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/11/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/11/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/11/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/11/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/11/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/11/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/11/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/11/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/11/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/11/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/11/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/11/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/11/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/11/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/12/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/12/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/12/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/12/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/12/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/12/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/12/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/12/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/12/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/12/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/12/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/12/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/12/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/12/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/12/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/12/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/12/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/12/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/12/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/12/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/12/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/12/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/12/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/12/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/13/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/13/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/13/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/13/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/13/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/13/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/13/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/13/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/13/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/13/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/13/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/13/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/13/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/13/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/13/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/13/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/13/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/13/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/13/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/13/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/13/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/13/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/13/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/13/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/14/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/14/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/14/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/14/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/14/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/14/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/14/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/14/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/14/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/14/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/14/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/14/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/14/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/14/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/14/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/14/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/14/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/14/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/14/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/14/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/14/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/14/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/14/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/14/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/15/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/15/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/15/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/15/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/15/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/15/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/15/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/15/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/15/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/15/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/15/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/15/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/15/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/15/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/15/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/15/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/15/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/15/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/15/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/15/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/15/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/15/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/15/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/15/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/16/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/16/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/16/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/16/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/16/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/16/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/16/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/16/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/16/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/16/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/16/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/16/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/16/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/16/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/16/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/16/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/16/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/16/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/16/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/16/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/16/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/16/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/16/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/16/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/17/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/17/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/17/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/17/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/17/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/17/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/17/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/17/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/17/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/17/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/17/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/17/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/17/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/17/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/17/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/17/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/17/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/17/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/17/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/17/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/17/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/17/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/17/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/17/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/18/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/18/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/18/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/18/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/18/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/18/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/18/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/18/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/18/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/18/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/18/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/18/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/18/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/18/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/18/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/18/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/18/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/18/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/18/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/18/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/18/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/18/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/18/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/18/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/19/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/19/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/19/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/19/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/19/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/19/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/19/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/19/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/19/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/19/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/19/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/19/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/19/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/19/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/19/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/19/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/19/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/19/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/19/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/19/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/19/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/19/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/19/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/19/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/20/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/20/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/20/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/20/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/20/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/20/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/20/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/20/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/20/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/20/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/20/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/20/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/20/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/20/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/20/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/20/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/20/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/20/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/20/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/20/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/20/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/20/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/20/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/20/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/21/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/21/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/21/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/21/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/21/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/21/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/21/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/21/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/21/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/21/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/21/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/21/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/21/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/21/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/21/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/21/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/21/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/21/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/21/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/21/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/21/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/21/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/21/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/21/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/22/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/22/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/22/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/22/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/22/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/22/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/22/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/22/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/22/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/22/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/22/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/22/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/22/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/22/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/22/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/22/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/22/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/22/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/22/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/22/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/22/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/22/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/22/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/22/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/23/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/23/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/23/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/23/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/23/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/23/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/23/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/23/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/23/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/23/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/23/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/23/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/23/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/23/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/23/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/23/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/23/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/23/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/23/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/23/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/23/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/23/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/23/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/23/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/24/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/24/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/24/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/24/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/24/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/24/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/24/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/24/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/24/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/24/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/24/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/24/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/24/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/24/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/24/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/24/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/24/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/24/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/24/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/24/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/24/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/24/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/24/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/24/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/25/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/25/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/25/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/25/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/25/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/25/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/25/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/25/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/25/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/25/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/25/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/25/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/25/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/25/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/25/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/25/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/25/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/25/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/25/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/25/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/25/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/25/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/25/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/25/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/26/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/26/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/26/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/26/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/26/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/26/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/26/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/26/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/26/2021 08:00	2,009.2	0.0	2,009.2	104,200.0	209.4	0.0	0.0	0.0
02/26/2021 09:00	3,365.4	0.0	3,365.4	104,200.0	350.7	0.4	0.2	0.7
02/26/2021 10:00	4,738.3	0.0	4,738.3	104,200.0	493.7	0.6	0.3	1.0
02/26/2021 11:00	4,960.4	0.0	4,960.4	104,200.0	516.9	0.6	0.3	1.0
02/26/2021 12:00	4,938.4	0.0	4,938.4	104,200.0	514.6	0.6	0.3	1.0
02/26/2021 13:00	4,916.6	0.0	4,916.6	104,200.0	512.3	0.6	0.3	1.0
02/26/2021 14:00	3,395.3	0.0	3,395.3	104,200.0	353.8	0.5	0.3	0.9
02/26/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/26/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/26/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/26/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/26/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/26/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/26/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/26/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/26/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	4,046.2	0.0	4,046.2	104,200.0	421.6	0.6	0.3	0.9
Minimum:	2,009.2	0.0	2,009.2	104,200.0	209.4	0.4	0.2	0.7
Maximum:	4,960.4	0.0	4,960.4	104,200.0	516.9	0.6	0.3	1.0
%SI	70.83	70.83	70.83	0.00	70.83	75.00	75.00	75.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/27/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/27/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/27/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/27/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/27/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/27/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/27/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/27/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/27/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/27/2021 09:00	1,689.1	0.0	1,689.1	104,200.0	176.0	0.0	0.0	0.0
02/27/2021 10:00	4,769.3	0.0	4,769.3	104,200.0	497.0	0.6	0.3	1.0
02/27/2021 11:00	4,937.1	0.0	4,937.1	104,200.0	514.4	0.6	0.3	1.0
02/27/2021 12:00	4,916.9	0.0	4,916.9	104,200.0	512.3	0.6	0.3	1.0
02/27/2021 13:00	4,899.1	0.0	4,899.1	104,200.0	510.5	0.6	0.3	1.0
02/27/2021 14:00	4,845.7	0.0	4,845.7	104,200.0	504.9	0.6	0.3	1.0
02/27/2021 15:00	4,192.2	0.0	4,192.2	104,200.0	436.8	0.5	0.3	0.9
02/27/2021 16:00	3,441.8	0.0	3,441.8	104,200.0	358.6	0.4	0.2	0.7
02/27/2021 17:00	3,041.3	0.0	3,041.3	104,200.0	316.9	0.4	0.2	0.7
02/27/2021 18:00	755.5	0.0	755.5	104,200.0	78.7	0.0	0.0	0.0
02/27/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/27/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/27/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/27/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/27/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,748.8	0.0	3,748.8	104,200.0	390.6	0.5	0.3	0.9
Minimum:	755.5	0.0	755.5	104,200.0	78.7	0.4	0.2	0.7
Maximum:	4,937.1	0.0	4,937.1	104,200.0	514.4	0.6	0.3	1.0
%SI	58.33	58.33	58.33	0.00	58.33	66.67	66.67	66.67

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/28/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/28/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/28/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/28/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/28/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/28/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/28/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/28/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/28/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/28/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/28/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/28/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/28/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/28/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/28/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/28/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/28/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/28/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/28/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/28/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/28/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/28/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/28/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
02/28/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/01/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/01/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/01/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/01/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/01/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/01/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/01/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/01/2021 07:00	1,520.2	0.0	1,520.2	104,200.0	158.4	0.0	0.0	0.0
03/01/2021 08:00	4,566.0	0.0	4,566.0	104,200.0	475.8	0.6	0.3	1.1
03/01/2021 09:00	5,026.1	0.0	5,026.1	104,200.0	523.7	0.6	0.3	1.0
03/01/2021 10:00	4,973.5	0.0	4,973.5	104,200.0	518.2	0.6	0.3	1.0
03/01/2021 11:00	4,907.0	0.0	4,907.0	104,200.0	511.3	0.6	0.3	1.0
03/01/2021 12:00	4,873.3	0.0	4,873.3	104,200.0	507.8	0.6	0.3	1.0
03/01/2021 13:00	3,393.6	0.0	3,393.6	104,200.0	353.6	0.4	0.2	0.7
03/01/2021 14:00	3,080.9	0.0	3,080.9	104,200.0	321.0	0.4	0.2	0.6
03/01/2021 15:00	2,868.2	0.0	2,868.2	104,200.0	298.9	0.4	0.2	0.6
03/01/2021 16:00	3,104.6	0.0	3,104.6	104,200.0	323.5	0.4	0.2	0.7
03/01/2021 17:00	1,179.1	0.0	1,179.1	104,200.0	122.9	0.0	0.0	0.0
03/01/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/01/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/01/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/01/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/01/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/01/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,590.2	0.0	3,590.2	104,200.0	374.1	0.5	0.3	0.9
Minimum:	1,179.1	0.0	1,179.1	104,200.0	122.9	0.4	0.2	0.6
Maximum:	5,026.1	0.0	5,026.1	104,200.0	523.7	0.6	0.3	1.1
%SI	54.17	54.17	54.17	0.00	54.17	62.50	62.50	62.50

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/02/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/02/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/02/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/02/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/02/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/02/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/02/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/02/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/02/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/02/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/02/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/02/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/02/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/02/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/02/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/02/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/02/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/02/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/02/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/02/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/02/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/02/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/02/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/02/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/03/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/03/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/03/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/03/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/03/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/03/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/03/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/03/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/03/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/03/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/03/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/03/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/03/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/03/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/03/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/03/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/03/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/03/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/03/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/03/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/03/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/03/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/03/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/03/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/04/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/04/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/04/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/04/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/04/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/04/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/04/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/04/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/04/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/04/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/04/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/04/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/04/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/04/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/04/2021 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/04/2021 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/04/2021 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/04/2021 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/04/2021 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/04/2021 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/04/2021 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/04/2021 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/04/2021 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/04/2021 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/05/2021 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/05/2021 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/05/2021 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/05/2021 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/05/2021 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/05/2021 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/05/2021 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/05/2021 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/05/2021 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/05/2021 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/05/2021 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/05/2021 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/05/2021 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/05/2021 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
03/05/2021 14:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/05/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/05/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/05/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/05/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/05/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/05/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/05/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/05/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/05/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,179.2	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/06/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/06/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/06/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/06/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/06/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/06/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/06/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/06/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/06/2021 08:00	2,256.5	0.0	2,256.5	104,150.0	235.0	0.0	0.0	0.0
03/06/2021 09:00	3,228.5	0.0	3,228.5	104,150.0	336.2	0.4	0.2	0.7
03/06/2021 10:00	2,958.9	0.0	2,958.9	104,150.0	308.2	0.4	0.2	0.6
03/06/2021 11:00	2,949.0	0.0	2,949.0	104,150.0	307.1	0.4	0.2	0.6
03/06/2021 12:00	4,866.8	0.0	4,866.8	104,150.0	506.9	0.6	0.3	1.0
03/06/2021 13:00	4,903.7	0.0	4,903.7	104,150.0	510.7	0.6	0.3	1.0
03/06/2021 14:00	4,813.7	0.0	4,813.7	104,150.0	501.3	0.6	0.3	1.0
03/06/2021 15:00	4,104.5	0.0	4,104.5	104,150.0	427.5	0.5	0.3	0.9
03/06/2021 16:00	4,027.7	0.0	4,027.7	104,150.0	419.5	0.5	0.3	0.8
03/06/2021 17:00	1,971.9	0.0	1,971.9	104,150.0	205.4	0.0	0.0	0.0
03/06/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/06/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/06/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/06/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/06/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/06/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,608.1	0.0	3,608.1	104,150.0	375.8	0.5	0.3	0.8
Minimum:	1,971.9	0.0	1,971.9	104,150.0	205.4	0.4	0.2	0.6
Maximum:	4,903.7	0.0	4,903.7	104,150.0	510.7	0.6	0.3	1.0
%SI	58.33	58.33	58.33	0.00	58.33	66.67	66.67	66.67

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/07/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/07/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/07/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/07/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/07/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/07/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/07/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/07/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/07/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/07/2021 09:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/07/2021 10:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/07/2021 11:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/07/2021 12:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/07/2021 13:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/07/2021 14:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/07/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/07/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/07/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/07/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/07/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/07/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/07/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/07/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/07/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/08/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/08/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/08/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/08/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/08/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/08/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/08/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/08/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/08/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/08/2021 09:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/08/2021 10:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/08/2021 11:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/08/2021 12:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/08/2021 13:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/08/2021 14:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/08/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/08/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/08/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/08/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/08/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/08/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/08/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/08/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/08/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/09/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/09/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/09/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/09/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/09/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/09/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/09/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/09/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/09/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/09/2021 09:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/09/2021 10:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/09/2021 11:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/09/2021 12:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/09/2021 13:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/09/2021 14:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/09/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/09/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/09/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/09/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/09/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/09/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/09/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/09/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/09/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/10/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/10/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/10/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/10/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/10/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/10/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/10/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/10/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/10/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/10/2021 09:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/10/2021 10:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/10/2021 11:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/10/2021 12:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/10/2021 13:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/10/2021 14:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/10/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/10/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/10/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/10/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/10/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/10/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/10/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/10/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/10/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/11/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/11/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/11/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/11/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/11/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/11/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/11/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/11/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/11/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/11/2021 09:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/11/2021 10:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/11/2021 11:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/11/2021 12:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/11/2021 13:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/11/2021 14:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/11/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/11/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/11/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/11/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/11/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/11/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/11/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/11/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/11/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/12/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/12/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/12/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/12/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/12/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/12/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/12/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/12/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/12/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/12/2021 09:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/12/2021 10:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/12/2021 11:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/12/2021 12:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/12/2021 13:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/12/2021 14:00	193.7	0.0	193.7	104,150.0	20.2	0.0	0.0	0.0
03/12/2021 15:00	290.9	0.0	290.9	104,150.0	30.3	0.0	0.0	0.0
03/12/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/12/2021 17:00	394.8	0.0	394.8	104,150.0	41.1	0.0	0.0	0.0
03/12/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/12/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/12/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/12/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/12/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/12/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Average/Sum#:	293.1	0.0	293.1	104,150.0	30.5	0.0	0.0	0.0
Minimum:	193.7	0.0	193.7	104,150.0	20.2	0.0	0.0	0.0
Maximum:	394.8	0.0	394.8	104,150.0	41.1	0.0	0.0	0.0
%SI	87.50	87.50	87.50	0.00	87.50	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	> 4.73 Unit CT2 PM10_Norm, LbPerHr	> 1 Unit CT2 SO2_Norm, LbPerHr	> 1.8 Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/13/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/13/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/13/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/13/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/13/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/13/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/13/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/13/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/13/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/13/2021 09:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/13/2021 10:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/13/2021 11:00	1,430.0	0.0	1,430.0	104,150.0	148.9	0.0	0.0	0.0
03/13/2021 12:00	4,757.1	0.0	4,757.1	104,150.0	495.5	0.6	0.3	1.0
03/13/2021 13:00	4,856.8	40.2	4,860.8	104,150.0	506.3	0.6	0.3	1.0
03/13/2021 14:00	4,943.5	1,943.5	6,887.0	104,150.0	717.3	0.9	0.4	1.4
03/13/2021 15:00	4,816.3	2,084.7	6,901.0	104,150.0	718.7	0.9	0.4	1.4
03/13/2021 16:00	4,819.4	2,081.8	6,901.2	104,150.0	718.8	0.9	0.4	1.4
03/13/2021 17:00	4,692.5	478.1	4,850.3	104,150.0	505.2	0.6	0.3	1.1
03/13/2021 18:00	2,718.5	0.0	2,718.5	104,150.0	283.1	0.3	0.2	0.6
03/13/2021 19:00	3,875.9	0.0	3,875.9	104,150.0	403.7	0.5	0.2	0.8
03/13/2021 20:00	3,982.1	0.0	3,982.1	104,150.0	414.7	0.5	0.2	0.8
03/13/2021 21:00	4,872.9	0.0	4,872.9	104,150.0	507.5	0.6	0.3	1.0
03/13/2021 22:00	2,158.1	0.0	2,158.1	104,150.0	224.8	0.0	0.0	0.0
03/13/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,993.6	552.4	4,516.2	104,150.0	470.4	0.6	0.3	1.1
Minimum:	1,430.0	0.0	1,430.0	104,150.0	148.9	0.3	0.2	0.6
Maximum:	4,943.5	2,084.7	6,901.2	104,150.0	718.8	0.9	0.4	1.4
%SI	50.00	50.00	50.00	0.00	50.00	58.33	58.33	58.33

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/14/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/14/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/14/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/14/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/14/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/14/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/14/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/14/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/14/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/14/2021 09:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/14/2021 10:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/14/2021 11:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/14/2021 12:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/14/2021 13:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/14/2021 14:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/14/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/14/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/14/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/14/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/14/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/14/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/14/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/14/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/14/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/15/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/15/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/15/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/15/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/15/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/15/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/15/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/15/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/15/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/15/2021 09:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/15/2021 10:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/15/2021 11:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/15/2021 12:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/15/2021 13:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/15/2021 14:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/15/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/15/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/15/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/15/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/15/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/15/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/15/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/15/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/15/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/16/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/16/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/16/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/16/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/16/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/16/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/16/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/16/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/16/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/16/2021 09:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/16/2021 10:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/16/2021 11:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/16/2021 12:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/16/2021 13:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/16/2021 14:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/16/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/16/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/16/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/16/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/16/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/16/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/16/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/16/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/16/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/17/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/17/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/17/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/17/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/17/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/17/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/17/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/17/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/17/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/17/2021 09:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/17/2021 10:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/17/2021 11:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/17/2021 12:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/17/2021 13:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/17/2021 14:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/17/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/17/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/17/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/17/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/17/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/17/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/17/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/17/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/17/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/18/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/18/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/18/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/18/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/18/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/18/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/18/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/18/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/18/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/18/2021 09:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/18/2021 10:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/18/2021 11:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/18/2021 12:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/18/2021 13:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/18/2021 14:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/18/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/18/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/18/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/18/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/18/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/18/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/18/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/18/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/18/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/19/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/19/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/19/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/19/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/19/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/19/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/19/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/19/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/19/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/19/2021 09:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/19/2021 10:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/19/2021 11:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/19/2021 12:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/19/2021 13:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/19/2021 14:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/19/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/19/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/19/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/19/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/19/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/19/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/19/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/19/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/19/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/20/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/20/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/20/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/20/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/20/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/20/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/20/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/20/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/20/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/20/2021 09:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/20/2021 10:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/20/2021 11:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/20/2021 12:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/20/2021 13:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/20/2021 14:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/20/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/20/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/20/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/20/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/20/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/20/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/20/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/20/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/20/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/21/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/21/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/21/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/21/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/21/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/21/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/21/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/21/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/21/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/21/2021 09:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/21/2021 10:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/21/2021 11:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/21/2021 12:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/21/2021 13:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/21/2021 14:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/21/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/21/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/21/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/21/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/21/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/21/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/21/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/21/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/21/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/22/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/22/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/22/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/22/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/22/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/22/2021 05:00	1,783.2	0.0	1,783.2	104,150.0	185.7	0.0	0.0	0.0
03/22/2021 06:00	2,868.7	0.0	2,868.7	104,150.0	298.8	0.4	0.2	0.6
03/22/2021 07:00	2,831.7	0.0	2,831.7	104,150.0	294.9	0.4	0.2	0.6
03/22/2021 08:00	3,727.7	0.0	3,727.7	104,150.0	388.2	0.6	0.3	1.0
03/22/2021 09:00	4,953.4	0.0	4,953.4	104,150.0	515.9	0.6	0.3	1.0
03/22/2021 10:00	3,283.0	0.0	3,283.0	104,150.0	341.9	0.4	0.2	0.7
03/22/2021 11:00	4,907.7	830.8	5,655.4	104,150.0	589.0	0.7	0.4	1.2
03/22/2021 12:00	4,903.6	1,812.7	6,716.3	104,150.0	699.5	0.8	0.4	1.4
03/22/2021 13:00	4,948.0	399.4	5,347.4	104,150.0	556.9	0.7	0.3	1.1
03/22/2021 14:00	4,903.7	1,989.2	6,892.9	104,150.0	717.9	0.9	0.4	1.4
03/22/2021 15:00	4,193.6	34.4	4,197.0	104,150.0	437.1	0.5	0.3	0.9
03/22/2021 16:00	2,989.1	0.0	2,989.1	104,150.0	311.3	0.4	0.2	0.6
03/22/2021 17:00	2,928.3	0.0	2,928.3	104,150.0	305.0	0.4	0.2	0.6
03/22/2021 18:00	2,923.9	0.0	2,923.9	104,150.0	304.5	0.4	0.2	0.6
03/22/2021 19:00	2,963.6	0.0	2,963.6	104,150.0	308.7	0.4	0.2	0.6
03/22/2021 20:00	2,982.8	0.0	2,982.8	104,150.0	310.7	0.4	0.2	0.6
03/22/2021 21:00	2,999.5	0.0	2,999.5	104,150.0	312.4	0.4	0.2	0.6
03/22/2021 22:00	3,004.3	0.0	3,004.3	104,150.0	312.9	0.4	0.2	0.6
03/22/2021 23:00	2,996.0	0.0	2,996.0	104,150.0	312.0	0.4	0.2	0.6
Average/Sum#:	3,531.1	266.7	3,791.8	104,150.0	394.9	0.5	0.3	0.8
Minimum:	1,783.2	0.0	1,783.2	104,150.0	185.7	0.4	0.2	0.6
Maximum:	4,953.4	1,989.2	6,892.9	104,150.0	717.9	0.9	0.4	1.4
%SI	20.83	20.83	20.83	0.00	20.83	25.00	25.00	25.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/23/2021 00:00	2,997.5	0.0	2,997.5	104,150.0	312.2	0.4	0.2	0.6
03/23/2021 01:00	2,999.0	0.0	2,999.0	104,150.0	312.3	0.4	0.2	0.6
03/23/2021 02:00	2,995.8	0.0	2,995.8	104,150.0	312.0	0.4	0.2	0.6
03/23/2021 03:00	2,996.6	0.0	2,996.6	104,150.0	312.1	0.4	0.2	0.6
03/23/2021 04:00	2,996.3	0.0	2,996.3	104,150.0	312.1	0.4	0.2	0.6
03/23/2021 05:00	2,984.9	0.0	2,984.9	104,150.0	310.9	0.4	0.2	0.6
03/23/2021 06:00	2,963.8	0.0	2,963.8	104,150.0	308.7	0.4	0.2	0.6
03/23/2021 07:00	3,015.5	0.0	3,015.5	104,150.0	314.1	0.4	0.2	0.6
03/23/2021 08:00	4,837.2	247.2	5,030.0	104,150.0	523.9	0.6	0.3	1.1
03/23/2021 09:00	4,918.5	7.2	4,919.8	104,150.0	512.4	0.6	0.3	1.0
03/23/2021 10:00	4,769.8	85.9	4,805.9	104,150.0	500.5	0.6	0.3	1.0
03/23/2021 11:00	4,792.6	166.0	4,933.7	104,150.0	513.8	0.6	0.3	1.0
03/23/2021 12:00	4,865.0	1,893.9	6,758.9	104,150.0	703.9	0.8	0.4	1.4
03/23/2021 13:00	4,769.2	31.7	4,773.3	104,150.0	497.1	0.6	0.3	1.0
03/23/2021 14:00	2,083.4	0.0	2,083.4	104,150.0	217.0	0.0	0.0	0.0
03/23/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/23/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/23/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/23/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/23/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/23/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/23/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/23/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/23/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,665.7	162.1	3,817.0	104,150.0	397.5	0.5	0.3	0.8
Minimum:	2,083.4	0.0	2,083.4	104,150.0	217.0	0.4	0.2	0.6
Maximum:	4,918.5	1,893.9	6,758.9	104,150.0	703.9	0.8	0.4	1.4
%SI	37.50	37.50	37.50	0.00	37.50	41.67	41.67	41.67

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/24/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/24/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/24/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/24/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/24/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/24/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/24/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/24/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/24/2021 08:00	1,512.3	0.0	1,512.3	104,150.0	157.5	0.0	0.0	0.0
03/24/2021 09:00	3,632.4	0.1	3,632.4	104,150.0	378.3	0.5	0.2	0.8
03/24/2021 10:00	4,888.4	1,802.3	6,690.7	104,150.0	696.8	0.8	0.4	1.4
03/24/2021 11:00	4,077.9	24.0	4,079.8	104,150.0	424.9	0.5	0.3	0.9
03/24/2021 12:00	4,795.8	800.2	5,540.0	104,150.0	577.0	0.7	0.3	1.2
03/24/2021 13:00	4,290.6	6.2	4,290.8	104,150.0	446.9	0.5	0.3	0.9
03/24/2021 14:00	4,894.7	1,519.1	6,337.8	104,150.0	660.1	0.8	0.4	1.3
03/24/2021 15:00	3,006.3	0.0	3,006.3	104,150.0	313.1	0.4	0.2	0.6
03/24/2021 16:00	1,360.9	0.0	1,360.9	104,150.0	141.7	0.0	0.0	0.0
03/24/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/24/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/24/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/24/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/24/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/24/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/24/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,606.6	461.3	4,050.1	104,150.0	421.8	0.6	0.3	1.0
Minimum:	1,360.9	0.0	1,360.9	104,150.0	141.7	0.4	0.2	0.6
Maximum:	4,894.7	1,802.3	6,690.7	104,150.0	696.8	0.8	0.4	1.4
%SI	62.50	62.50	62.50	0.00	62.50	70.83	70.83	70.83

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/25/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/25/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/25/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/25/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/25/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/25/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/25/2021 06:00	1,565.8	0.0	1,565.8	104,150.0	163.1	0.0	0.0	0.0
03/25/2021 07:00	4,216.7	0.0	4,216.7	104,150.0	439.2	0.5	0.3	0.9
03/25/2021 08:00	4,207.9	0.0	4,207.9	104,150.0	438.3	0.5	0.3	0.9
03/25/2021 09:00	3,468.4	0.0	3,468.4	104,150.0	361.2	0.4	0.2	0.7
03/25/2021 10:00	3,574.2	0.0	3,574.2	104,150.0	372.3	0.4	0.2	0.7
03/25/2021 11:00	2,552.6	0.0	2,552.6	104,150.0	265.9	0.5	0.2	0.8
03/25/2021 12:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/25/2021 13:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/25/2021 14:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/25/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/25/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/25/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/25/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/25/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/25/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/25/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/25/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/25/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,264.3	0.0	3,264.3	104,150.0	340.0	0.5	0.2	0.8
Minimum:	1,565.8	0.0	1,565.8	104,150.0	163.1	0.4	0.2	0.7
Maximum:	4,216.7	0.0	4,216.7	104,150.0	439.2	0.5	0.3	0.9
%SI	75.00	75.00	75.00	0.00	75.00	79.17	79.17	79.17

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/26/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/26/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/26/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/26/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/26/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/26/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/26/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/26/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/26/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/26/2021 09:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/26/2021 10:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/26/2021 11:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/26/2021 12:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/26/2021 13:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/26/2021 14:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/26/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/26/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/26/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/26/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/26/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/26/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/26/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/26/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/26/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/27/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/27/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/27/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/27/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/27/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/27/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/27/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/27/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/27/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/27/2021 09:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/27/2021 10:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/27/2021 11:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/27/2021 12:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/27/2021 13:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/27/2021 14:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/27/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/27/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/27/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/27/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/27/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/27/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/27/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/27/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/27/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/28/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/28/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/28/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/28/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/28/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/28/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/28/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/28/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/28/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/28/2021 09:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/28/2021 10:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/28/2021 11:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/28/2021 12:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/28/2021 13:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/28/2021 14:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/28/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/28/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/28/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/28/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/28/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/28/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/28/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/28/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/28/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/29/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/29/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/29/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/29/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/29/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/29/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/29/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/29/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/29/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/29/2021 09:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/29/2021 10:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/29/2021 11:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/29/2021 12:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/29/2021 13:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/29/2021 14:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/29/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/29/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/29/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/29/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/29/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/29/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/29/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/29/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/29/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/30/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/30/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/30/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/30/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/30/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/30/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/30/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/30/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/30/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/30/2021 09:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/30/2021 10:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/30/2021 11:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/30/2021 12:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/30/2021 13:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/30/2021 14:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/30/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/30/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/30/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/30/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/30/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/30/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/30/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/30/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/30/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2021 14:57 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/31/2021 00:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/31/2021 01:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/31/2021 02:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/31/2021 03:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/31/2021 04:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/31/2021 05:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/31/2021 06:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/31/2021 07:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/31/2021 08:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/31/2021 09:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/31/2021 10:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/31/2021 11:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/31/2021 12:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/31/2021 13:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/31/2021 14:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/31/2021 15:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/31/2021 16:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/31/2021 17:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/31/2021 18:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/31/2021 19:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/31/2021 20:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/31/2021 21:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/31/2021 22:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
03/31/2021 23:00	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,150.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Linearity Report

04/01/2021

Page 1

ORIS Code: 56298

EDR Site ID: CT002

Facility Name: ROSEVILLE ENERGY

Component ID: A22

Component Type: O2D

ReasonForTest: QA

Grace Period: 0

Instrument Name: CT2_O2D_P_Instrument

Performance Spec: 5 %

Test End Date/Time: 10/02/2020

Test No.: 105

Status (Pass/Fail): **Passed**

Scale: High

Highest Error: 0.9

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
10/02/2020	0942	L	21.0	5.5	5.6		26.2 %
10/02/2020	0948	M	21.0	11.2	11.3		53.3 %
10/02/2020	0953	H	21.0	18.1	18.1		86.2 %
10/02/2020	1000	L	21.0	5.5	5.5		26.2 %
10/02/2020	1005	M	21.0	11.2	11.3		53.3 %
10/02/2020	1010	H	21.0	18.1	18.1		86.2 %
10/02/2020	1017	L	21.0	5.5	5.5		26.2 %
10/02/2020	1022	M	21.0	11.2	11.3		53.3 %
10/02/2020	1027	H	21.0	18.1	18.1		86.2 %

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Alt Perf Spec	Results
L	5.500		5.533	No	0.6
M	11.200		11.300	No	0.9
H	18.100		18.100	No	0.0

Linearity Report

04/01/2021

Page 2

ORIS Code: 56298

EDR Site ID: CT002

Facility Name: ROSEVILLE ENERGY

Component ID: A22

Component Type: O2D

ReasonForTest: QA

Grace Period: 0

Instrument Name: CT2_O2D_P_Instrument

Performance Spec: 5 %

Test End Date/Time: 03/23/2021

Test No.: 108

Status (Pass/Fail): **Passed**

Scale: High

Highest Error: 0.9

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
03/23/2021	1034	L	21.0	5.5	5.5		26.2 %
03/23/2021	1039	M	21.0	11.2	11.1		53.3 %
03/23/2021	1044	H	21.0	18.0	17.9		85.7 %
03/23/2021	1052	L	21.0	5.5	5.5		26.2 %
03/23/2021	1057	M	21.0	11.2	11.1		53.3 %
03/23/2021	1102	H	21.0	18.0	17.9		85.7 %
03/23/2021	1109	L	21.0	5.5	5.5		26.2 %
03/23/2021	1114	M	21.0	11.2	11.1		53.3 %
03/23/2021	1119	H	21.0	18.0	17.9		85.7 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.500	5.500	No	0.0
M	11.200	11.100	No	0.9
H	18.000	17.900	No	0.6

Linearity Report

04/01/2021

Page 3

ORIS Code: 56298

EDR Site ID: CT002

Facility Name: ROSEVILLE ENERGY

Component ID: A21

Component Type: NOXA

ReasonForTest: QA

Grace Period: 0

Instrument Name: CT2_NOXDualRg_P_Instrume Test End Date/Time: 03/23/2021

Scale: High

Performance Spec: 5 %

Test No.: 109

Highest Error: 2.3

Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
03/23/2021	0728	L	200.0	48.2	47.8		24.1 %
03/23/2021	0734	M	200.0	106.0	105.7		53.0 %
03/23/2021	0739	H	200.0	180.0	176.0		90.0 %
03/23/2021	0746	L	200.0	48.2	47.9		24.1 %
03/23/2021	0751	M	200.0	106.0	106.2		53.0 %
03/23/2021	0756	H	200.0	180.0	175.8		90.0 %
03/23/2021	0803	L	200.0	48.2	48.0		24.1 %
03/23/2021	0808	M	200.0	106.0	106.0		53.0 %
03/23/2021	0813	H	200.0	180.0	175.9		90.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	48.200	47.900	No	0.6
M	106.000	105.967	No	0.0
H	180.000	175.900	No	2.3

Linearity Report

04/01/2021

Page 4

ORIS Code: 56298

EDR Site ID: CT001

Facility Name: ROSEVILLE ENERGY

Component ID: A15

Component Type: NOXA

ReasonForTest: QA

Grace Period: 0

Instrument Name: CT1_NOXDualRg_P_Instrume Test End Date/Time: 03/24/2021

Scale: High

Performance Spec: 5 %

Test No.: 106

Highest Error: 4.4

Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
03/24/2021	0628	L	200.0	47.6	49.1		23.8 %
03/24/2021	0634	M	200.0	105.0	109.0		52.5 %
03/24/2021	0639	H	200.0	180.5	181.4		90.3 %
03/24/2021	0646	L	200.0	47.6	50.0		23.8 %
03/24/2021	0651	M	200.0	105.0	109.4		52.5 %
03/24/2021	0656	H	200.0	180.5	181.4		90.3 %
03/24/2021	0703	L	200.0	47.6	50.0		23.8 %
03/24/2021	0708	M	200.0	105.0	109.7		52.5 %
03/24/2021	0713	H	200.0	180.5	182.0		90.3 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	47.600	49.700	No	4.4
M	105.000	109.367	No	4.2
H	180.500	181.600	No	0.6

Linearity Report

04/01/2021

Page 5

ORIS Code: 56298

EDR Site ID: CT001

Facility Name: ROSEVILLE ENERGY

Component ID: A16

Component Type: O2D

ReasonForTest: QA

Grace Period: 0

Instrument Name: CT1_O2D_P_Instrument

Performance Spec: 5 %

Test End Date/Time: 03/24/2021

Test No.: 107

Status (Pass/Fail): **Passed**

Scale: High

Highest Error: 3.6

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
03/24/2021	0833	L	21.0	5.5	5.3		26.2 %
03/24/2021	0838	M	21.0	11.1	10.9		52.9 %
03/24/2021	0843	H	21.0	18.2	18.1		86.7 %
03/24/2021	0851	L	21.0	5.5	5.3		26.2 %
03/24/2021	0856	M	21.0	11.1	10.9		52.9 %
03/24/2021	0901	H	21.0	18.2	18.1		86.7 %
03/24/2021	0908	L	21.0	5.5	5.3		26.2 %
03/24/2021	0913	M	21.0	11.1	10.9		52.9 %
03/24/2021	0918	H	21.0	18.2	18.1		86.7 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.500	5.300	No	3.6
M	11.100	10.900	No	1.8
H	18.200	18.100	No	0.5

Roseville Energy Park

Revision History

RegPerfect® by Teledyne Monitor Labs, Inc.

Teledyne Monitor Labs, Inc.

35 Inverness Drive East

Englewood, CO 80112-5189

Telephone: (800) 846-6062

<http://www.teledyne-ml.com/>

<http://www.regperfect.com/>

©1998-2005 Teledyne Monitor Labs, Inc. All rights reserved.

RegPerfect® is a registered trademark of Teledyne Monitor Labs, Inc.

NOTE: This server's C drive is only 20 GB in size!! Do not place large files on this drive.

3/23/21 Taylor Sullivan

EDR check

3/09/21 Dennis J Perkins

Looked at the CT2 SCR NOx data to find out why both ranges are invalid during a transition minute. I found that the Low NOx data is slightly higher than the High Range data at the 10 ppm transition point, which makes both ranges go invalid. Manually calibrating the analyzer should fix this problem.

2/18/21 Taylor Sullivan

EDR check

2/2/21 Taylor Sullivan

EDR check

1/21,22/21 Taylor Sullivan

Q4 EDR

CO Ppmvdc EDS/CMS Summary Report

CT1



From: 01/01/2021 00:00 **To:** 03/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2021 15:01 **Location:** Roseville, CA
Description: Electric Utility

CMS Data from: CT1_CO_Ppmvdc_1H
EDS Data from: CT1_CO_Ppmvdc_3H
Emission Limitation: 4
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 04/09/2006 14:00
Process Unit(s) Description:
Operating time for EDS: 112.00 Hour(s)
Operating time for CMS: 112.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	5
2. Total CMS Downtime	5
3. Total Downtime as a percentage of operating time	4.46
4. Total Availability as a percentage of operating time	95.54

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

NOx Ppmvdc EDS/CMS Summary Report

CT1



From: 01/01/2021 00:00 **To:** 03/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2021 15:02 **Location:** Roseville, CA
Description: Electric Utility

CMS Data from: CT1_NOx_Ppmvdc_1H
EDS Data from: CT1_NOx_Ppmvdc_1H
Emission Limitation: 2.0
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-02
Date of Latest CMS Certification or Audit: 04/09/2006 14:00
Process Unit(s) Description:
Operating time for EDS: 112.00 Hour(s)
Operating time for CMS: 112.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
f. Report function is being updated to reflect actual pounds	0
g. TABLE 53.A.1.ii: EQUIPMENT PROTECTION CAUSING RAPID UNLOAD	2
h. EQUIPMENT PROTECTION CAUSING RAPID UNLOAD	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	2
4. Time of Excess Emission as a percentage of operating time	1.79
5. Time in compliance as percentage of operating time	98.21

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	5
2. Total CMS Downtime	5
3. Total Downtime as a percentage of operating time	4.46
4. Total Availability as a percentage of operating time	95.54

CO Ppmvdc EDS/CMS Summary Report

CT2



From: 01/01/2021 00:00 **To:** 03/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2021 15:02 **Location:** Roseville, CA
Description: Electric Utility

CMS Data from: CT2_CO_Ppmvdc_1H
EDS Data from: CT2_CO_Ppmvdc_3H
Emission Limitation: 4
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 04/10/2006 07:00
Process Unit(s) Description:
Operating time for EDS: 102.00 Hour(s)
Operating time for CMS: 102.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	3
2. Total CMS Downtime	3
3. Total Downtime as a percentage of operating time	2.94
4. Total Availability as a percentage of operating time	97.06

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

NOx Ppmvdc EDS/CMS Summary Report

CT2



From: 01/01/2021 00:00 **To:** 03/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2021 15:03 **Location:** Roseville, CA
Description: Electric Utility

CMS Data from: CT2_NOx_Ppmvdc_1H
EDS Data from: CT2_NOx_Ppmvdc_1H
Emission Limitation: 2.0
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-02
Date of Latest CMS Certification or Audit: 04/10/2006 07:00
Process Unit(s) Description:
Operating time for EDS: 102.00 Hour(s)
Operating time for CMS: 102.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	1
e. Unknown causes	0
f. Report function is being updated to reflect actual pounds	0
g. TABLE 53.A.1.ii: EQUIPMENT PROTECTION CAUSING RAPID UNLOAD	3
h. EQUIPMENT PROTECTION CAUSING RAPID UNLOAD	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	4
4. Time of Excess Emission as a percentage of operating time	3.92
5. Time in compliance as percentage of operating time	96.08

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	3
2. Total CMS Downtime	3
3. Total Downtime as a percentage of operating time	2.94
4. Total Availability as a percentage of operating time	97.06

CO Invalid Data

CT1

From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/02/2021 11:21 Location: Roseville, CA



Tag Name: CT1_CO_Ppm_1H
Total Operating Time: 112.00 Hour(s)
Non-Operating Time: 2,048.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	112.00 Hour(s)
Total Monitor Downtime (Online only):	0.00 Hour(s)
Percent Monitor Availability:	100.00 %
Percent Monitor Downtime:	0.00 %

NOx Invalid Data

CT1

From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/02/2021 11:22 Location: Roseville, CA



Tag Name: CT1_NOx_Ppm_1H
Total Operating Time: 112.00 Hour(s)
Non-Operating Time: 2,048.00 Hour(s) Report Time: 2,160.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	03/08/2021 17:00	03/08/2021 17:59	1		
2	03/13/2021 07:00	03/13/2021 07:59	1		
3	03/13/2021 08:00	03/13/2021 08:59	1		
4	03/13/2021 09:00	03/13/2021 09:59	1		
5	03/13/2021 10:00	03/13/2021 10:59	1	3 - Quality assurance calibration	

Total Operating Time:	112.00 Hour(s)
Total Monitor Downtime (Online only):	5.00 Hour(s)
Percent Monitor Availability:	95.54 %
Percent Monitor Downtime:	4.46 %

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Quality assurance calibration	1	20.00

NOx SCR Invalid Data



CT1

From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/02/2021 11:22 Location: Roseville, CA

Tag Name: CT1_NOx_SCR_Ppm_1H
Total Operating Time: 112.00 Hour(s)
Non-Operating Time: 2,048.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	112.00 Hour(s)
Total Monitor Downtime (Online only):	0.00 Hour(s)
Percent Monitor Availability:	100.00 %
Percent Monitor Downtime:	0.00 %

02 Invalid Data

CT1

From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/02/2021 11:23 Location: Roseville, CA



Tag Name: CT1_O2Dry_Pct_1H
Total Operating Time: 112.00 Hour(s)
Non-Operating Time: 2,048.00 Hour(s) Report Time: 2,160.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	03/08/2021 17:00	03/08/2021 17:59	1		
2	03/13/2021 07:00	03/13/2021 07:59	1		
3	03/13/2021 08:00	03/13/2021 08:59	1		
4	03/13/2021 09:00	03/13/2021 09:59	1		
5	03/13/2021 10:00	03/13/2021 10:59	1	3 - Quality assurance calibration	

Total Operating Time:	112.00 Hour(s)
Total Monitor Downtime (Online only):	5.00 Hour(s)
Percent Monitor Availability:	95.54 %
Percent Monitor Downtime:	4.46 %

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Quality assurance calibration	1	20.00

CO Invalid Data

CT2

From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/02/2021 11:23 Location: Roseville, CA



Tag Name: CT2_CO_Ppm_1H
Total Operating Time: 102.00 Hour(s)
Non-Operating Time: 2,058.00 Hour(s) Report Time: 2,160.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	03/22/2021 14:00	03/22/2021 14:59	1	3 - Quality assurance calibration	

Total Operating Time:	102.00 Hour(s)
Total Monitor Downtime (Online only):	1.00 Hour(s)
Percent Monitor Availability:	99.02 %
Percent Monitor Downtime:	0.98 %

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Quality assurance calibration	1	100.00

NOx Invalid Data

CT2

From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/02/2021 11:24 Location: Roseville, CA



Tag Name: CT2_NOx_Ppm_1H

Total Operating Time: 102.00 Hour(s)

Non-Operating Time: 2,058.00 Hour(s) Report Time: 2,160.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	03/13/2021 11:00	03/13/2021 11:59	1		
2	03/13/2021 12:00	03/13/2021 12:59	1	3 - Quality assurance calibration	
3	03/22/2021 14:00	03/22/2021 14:59	1	3 - Quality assurance calibration	

Total Operating Time:	102.00 Hour(s)
Total Monitor Downtime (Online only):	3.00 Hour(s)
Percent Monitor Availability:	97.06 %
Percent Monitor Downtime:	2.94 %

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Quality assurance calibration	2	66.67

NOx SCR Invalid Data

CT2

From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/02/2021 11:24 Location: Roseville, CA



Tag Name: CT2_NOx_SCR_Ppm_1H
Total Operating Time: 102.00 Hour(s)
Non-Operating Time: 2,058.00 Hour(s) Report Time: 2,160.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	03/01/2021 12:00	03/01/2021 12:59	1		

Total Operating Time:	102.00 Hour(s)
Total Monitor Downtime (Online only):	1.00 Hour(s)
Percent Monitor Availability:	99.02 %
Percent Monitor Downtime:	0.98 %

02 Invalid Data

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/02/2021 11:25 Location: Roseville, CA

Tag Name: CT2_O2Dry_Pct_1H
Total Operating Time: 102.00 Hour(s)
Non-Operating Time: 2,058.00 Hour(s) Report Time: 2,160.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	03/13/2021 11:00	03/13/2021 11:59	1		
2	03/13/2021 12:00	03/13/2021 12:59	1	3 - Quality assurance calibration	
3	03/22/2021 14:00	03/22/2021 14:59	1	3 - Quality assurance calibration	

Total Operating Time:	102.00 Hour(s)
Total Monitor Downtime (Online only):	3.00 Hour(s)
Percent Monitor Availability:	97.06 %
Percent Monitor Downtime:	2.94 %

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Quality assurance calibration	2	66.67

AQ-36

AQ-36: The project owner shall notify the _PCAPCD of any breakdown condition as soon as reasonably possible, but no later than two PCAPCD business hours after its detection.

Verification: The Project owner shall include the identification of all breakdowns, PCAPCD notification, resulting excess emission (if any) and corrective actions taken (if any) as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6



Year - Non-Compliance
Event Number 2 0 2 1 0 0 3

110 Maple Street, Auburn, CA 95603 • (530) 745-2330 • Fax (530) 745-2373 • www.placerair.org

Erik C. White, Air Pollution Control Officer

NON-COMPLIANCE EVENT NOTIFICATION FORM – PART I

Submit within 2 business hours after detection of the Non-Compliance Event

1. Company Name	ROSEVILLE ENERGY PARK	5120 PHILLIP ROAD
2. Title V Source Status	Major Yes ☐ No ☐	Synthetic Minor Yes ☐ No ☐
3. For Title V Sources, is the Non-Compliance Event the Result of an Emergency under District Rule 507, Section 402.2(I)	Yes ☐ No ☐	
4. Emission Exceedances	NOx ☐ SOx ☐ PM ☐ VOC ☐ CO ☐ Opacity ☐ None ☐	check all that apply
5. CEMS / COMS / CMS Breakdown	Yes ☐ No ☐	
6. Detection of Non-Compliance Event	Date 3-25-21	Time 12:00 ☐ AM ☐ PM
7. Start of Non-Compliance Event	Date 3-25-21	Time 12:00 ☐ AM ☐ PM ☐ Not known
8. Violation	Permit No. REPR-20-02	Condition No. 49 Rule Section
9. Unit / Equipment Involved	CT2	
10. Description / Cause of Non-Compliance Event	NOx exceedance during shutdown	☐ additional information attached
11. Immediate Corrective Actions	shut down unit ☐ additional information attached	
12. Was the Non-Compliance Event an Emission Violation or Monitoring Equipment Failure or Malfunction	Yes ☐ No ☐	
If yes, do you Request that the Violation, Failure or Malfunction be Shielded from Enforcement Action as an Upset / Breakdown Pursuant to District Rule 404		
Yes ☐ No ☐ Not Able to Determine at this Time ☐ If "Yes", complete and submit the Upset / Breakdown Checklist Form with Part I		
13. Submitted By	Tony Johnson	Telephone (916) 746 - 1656
Signature		Date 3-26-21 Time 11:00 ☒ AM ☐ PM

NON-COMPLIANCE EVENT NOTIFICATION FORM – PART II

Submit within 7 calendar days after end of the Non-Compliance Event

14. End of Non-Compliance Event	Date 3-25-21	Time 1:00	☐ AM ☒ PM
15. Duration of Non-Compliance Event	Hours	Minutes	3
16. Excess Emissions Estimates	NOx 2.1 ppmvdc	SOx	PM
	VOC	CO	Opacity %, for minutes Other
17. Variance in Effect	Yes ☐ Variance # No ☒		
18. Corrective and Preventative Actions Taken	(a) Minimize Emissions (b) Correct Event (c) Prevent Future Events ☒ additional information attached (a) Unit was ramping down to end the hour on its first run in the Energy Imbalance Market (EIM) while the plant was in Automatic Generation Control (AGC) on its way to a shutdown. The ramp downward caused a brief spike in NOx at the top of the hour. The Operator gave the turbine a shutdown command at 2 minutes into the hour and the CEMS averaged the first three minutes as a valid hour with a result of 2.1 ppmvdc. Then unit was offline 8 minutes later.		
19. If Not Able to Determine in Item 12 of Part I, Was the Non-Compliance Event an Emission Violation or Monitoring Equipment Failure or Malfunction	If yes, do you Request that the Violation, Failure or Malfunction be Shielded from Enforcement Action as an Upset / Breakdown Under District Rule 404		
Yes ☐ No ☐ If "Yes", complete and submit the Upset / Breakdown Checklist Form if not previously submitted with Part I			
20. Submitted By	Tony Johnson	Telephone	(916) 746 - 1656
I certify under penalty of law that I am the responsible official for this facility, or his/her duly designated representative, and based on information and belief formed after reasonable inquiry, the statements and information in this document are true, accurate, and complete.			
Signature		Date 3-31-21	Time 12:00 ☐ AM ☒ PM

NOx Ppmvdc 1-Hour Block Excess Emissions

CT2

From: 03/25/2021 00:00 To: 03/25/2021 13:01 Facility Name: ROSEVILLE ENERGY
Generated: 03/25/2021 13:03 Location: Roseville, CA



Tag Name: CT2_NOx_Ppmvdc_1H

Total Operating Time: 6.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 8.00 Hour(s) Report Time: 14.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Tag Value	Limit	Reason Code	Action Code
1	03/25/21 11:00	03/25/21 11:59	1	2.1	2.0		

Total Operating Time:	6.00 Hour(s)
Total Duration (Online only):	1.00 Hour(s)
Time in exceedance as a percentage of operating time:	16.67 %
Time in compliance as a percentage of operating time:	83.33 %

Sample Spreadsheet Listing

	CT2_NOx_Ppmvdc_1M			CT2_Load_CT_MWe_1M			CT2_SUSd_TF_1M			_None								
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/25/21 10:50	1.65			31.8			0											
03/25/21 10:51	1.65			32.5			0											
03/25/21 10:52	1.67			33.4			0											
03/25/21 10:53	1.7			33.5			0											
03/25/21 10:54	1.76			33.3			0											
03/25/21 10:55	1.85			34.8			0											
03/25/21 10:56	1.43			36.5			0											
03/25/21 10:57	1.25			38.2			0											
03/25/21 10:58	1.27			38.4			0											
03/25/21 10:59	1.43			36			0											
03/25/21 11:00	1.67			33.1			0											
03/25/21 11:01	2.17			30			0											
03/25/21 11:02	2.48			26.7			0											
03/25/21 11:03	2.6			23.4			1											
03/25/21 11:04	2.15			20.5			1											
03/25/21 11:05	2.49			17.4			1											
03/25/21 11:06	5.32			14.6			1											
03/25/21 11:07	18.23			11.8			1											
03/25/21 11:08	24.64			8.6			1											
03/25/21 11:09	28.58			5.6			1											
03/25/21 11:10	32.01			2.8			1											
03/25/21 11:11	33.55			0.1			1											
03/25/21 11:12	38.7			0			0											
03/25/21 11:13	14.75			0			0											

← Shut down
command

AQ-37

AQ-37 Any Violation of any emission standard listed in this permit which is indicated by the CEMS shall be reported to the PCAPCD no later than 96 hours after such occurrence as per California Health and Safety Code 42706

Verification: The Project owner shall include all violations of emissions standards and corresponding PCAPCD notifications in the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

All Notices of Non Compliance are included in AQ-41.

AQ-40

AQ-40 The Project owner shall comply with the applicable requirements for quality assurance testing and maintenance of the continuous emission monitor equipment in accordance with the procedures and guidance specified in 40 CFR Part 60, Appendix F.

Verification: The Project owner shall include all CEMS quality assurance test failures that required corrective action as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

Linearity Report

04/01/2021

Page 1

ORIS Code: 56298

EDR Site ID: CT002

Facility Name: ROSEVILLE ENERGY

Component ID: A22

Component Type: O2D

ReasonForTest: QA

Grace Period: 0

Instrument Name: CT2_O2D_P_Instrument

Performance Spec: 5 %

Test End Date/Time: 10/02/2020

Test No.: 105

Status (Pass/Fail): **Passed**

Scale: High

Highest Error: 0.9

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
10/02/2020	0942	L	21.0	5.5	5.6		26.2 %
10/02/2020	0948	M	21.0	11.2	11.3		53.3 %
10/02/2020	0953	H	21.0	18.1	18.1		86.2 %
10/02/2020	1000	L	21.0	5.5	5.5		26.2 %
10/02/2020	1005	M	21.0	11.2	11.3		53.3 %
10/02/2020	1010	H	21.0	18.1	18.1		86.2 %
10/02/2020	1017	L	21.0	5.5	5.5		26.2 %
10/02/2020	1022	M	21.0	11.2	11.3		53.3 %
10/02/2020	1027	H	21.0	18.1	18.1		86.2 %

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Alt Perf Spec	Results
L	5.500		5.533	No	0.6
M	11.200		11.300	No	0.9
H	18.100		18.100	No	0.0

Linearity Report

04/01/2021

Page 2

ORIS Code: 56298

EDR Site ID: CT002

Facility Name: ROSEVILLE ENERGY

Component ID: A22

Component Type: O2D

ReasonForTest: QA

Grace Period: 0

Instrument Name: CT2_O2D_P_Instrument

Performance Spec: 5 %

Test End Date/Time: 03/23/2021

Test No.: 108

Status (Pass/Fail): **Passed**

Scale: High

Highest Error: 0.9

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
03/23/2021	1034	L	21.0	5.5	5.5		26.2 %
03/23/2021	1039	M	21.0	11.2	11.1		53.3 %
03/23/2021	1044	H	21.0	18.0	17.9		85.7 %
03/23/2021	1052	L	21.0	5.5	5.5		26.2 %
03/23/2021	1057	M	21.0	11.2	11.1		53.3 %
03/23/2021	1102	H	21.0	18.0	17.9		85.7 %
03/23/2021	1109	L	21.0	5.5	5.5		26.2 %
03/23/2021	1114	M	21.0	11.2	11.1		53.3 %
03/23/2021	1119	H	21.0	18.0	17.9		85.7 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.500	5.500	No	0.0
M	11.200	11.100	No	0.9
H	18.000	17.900	No	0.6

Linearity Report

04/01/2021

Page 3

ORIS Code: 56298

EDR Site ID: CT002

Facility Name: ROSEVILLE ENERGY

Component ID: A21

Component Type: NOXA

ReasonForTest: QA

Grace Period: 0

Instrument Name: CT2_NOXDualRg_P_Instrume Test End Date/Time: 03/23/2021

Scale: High

Performance Spec: 5 %

Test No.: 109

Highest Error: 2.3

Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
03/23/2021	0728	L	200.0	48.2	47.8		24.1 %
03/23/2021	0734	M	200.0	106.0	105.7		53.0 %
03/23/2021	0739	H	200.0	180.0	176.0		90.0 %
03/23/2021	0746	L	200.0	48.2	47.9		24.1 %
03/23/2021	0751	M	200.0	106.0	106.2		53.0 %
03/23/2021	0756	H	200.0	180.0	175.8		90.0 %
03/23/2021	0803	L	200.0	48.2	48.0		24.1 %
03/23/2021	0808	M	200.0	106.0	106.0		53.0 %
03/23/2021	0813	H	200.0	180.0	175.9		90.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	48.200	47.900	No	0.6
M	106.000	105.967	No	0.0
H	180.000	175.900	No	2.3

Linearity Report

04/01/2021

Page 4

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY	ReasonForTest:	QA
EDR Site ID:	CT001	Component ID:	A15	Grace Period:	0
		Component Type:	NOXA		
Instrument Name:	CT1_NOXDualRg_P_Instrume	Test End Date/Time:	03/24/2021	Scale:	High
Performance Spec:	5 %	Test No.:	106	Highest Error:	4.4
		Status (Pass/Fail):	Passed		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
03/24/2021	0628	L	200.0	47.6	49.1		23.8 %
03/24/2021	0634	M	200.0	105.0	109.0		52.5 %
03/24/2021	0639	H	200.0	180.5	181.4		90.3 %
03/24/2021	0646	L	200.0	47.6	50.0		23.8 %
03/24/2021	0651	M	200.0	105.0	109.4		52.5 %
03/24/2021	0656	H	200.0	180.5	181.4		90.3 %
03/24/2021	0703	L	200.0	47.6	50.0		23.8 %
03/24/2021	0708	M	200.0	105.0	109.7		52.5 %
03/24/2021	0713	H	200.0	180.5	182.0		90.3 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	47.600	49.700	No	4.4
M	105.000	109.367	No	4.2
H	180.500	181.600	No	0.6

Linearity Report

04/01/2021

Page 5

ORIS Code: 56298

EDR Site ID: CT001

Facility Name: ROSEVILLE ENERGY

Component ID: A16

Component Type: O2D

ReasonForTest: QA

Grace Period: 0

Instrument Name: CT1_O2D_P_Instrument

Performance Spec: 5 %

Test End Date/Time: 03/24/2021

Test No.: 107

Status (Pass/Fail): **Passed**

Scale: High

Highest Error: 3.6

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
03/24/2021	0833	L	21.0	5.5	5.3		26.2 %
03/24/2021	0838	M	21.0	11.1	10.9		52.9 %
03/24/2021	0843	H	21.0	18.2	18.1		86.7 %
03/24/2021	0851	L	21.0	5.5	5.3		26.2 %
03/24/2021	0856	M	21.0	11.1	10.9		52.9 %
03/24/2021	0901	H	21.0	18.2	18.1		86.7 %
03/24/2021	0908	L	21.0	5.5	5.3		26.2 %
03/24/2021	0913	M	21.0	11.1	10.9		52.9 %
03/24/2021	0918	H	21.0	18.2	18.1		86.7 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.500	5.300	No	3.6
M	11.100	10.900	No	1.8
H	18.200	18.100	No	0.5

Roseville Energy Park

Revision History

RegPerfect® by Teledyne Monitor Labs, Inc.

Teledyne Monitor Labs, Inc.

35 Inverness Drive East

Englewood, CO 80112-5189

Telephone: (800) 846-6062

<http://www.teledyne-ml.com/>

<http://www.regperfect.com/>

©1998-2005 Teledyne Monitor Labs, Inc. All rights reserved.

RegPerfect® is a registered trademark of Teledyne Monitor Labs, Inc.

NOTE: This server's C drive is only 20 GB in size!! Do not place large files on this drive.

3/23/21 Taylor Sullivan

EDR check

3/09/21 Dennis J Perkins

Looked at the CT2 SCR NOx data to find out why both ranges are invalid during a transition minute. I found that the Low NOx data is slightly higher than the High Range data at the 10 ppm transition point, which makes both ranges go invalid. Manually calibrating the analyzer should fix this problem.

2/18/21 Taylor Sullivan

EDR check

2/2/21 Taylor Sullivan

EDR check

1/21,22/21 Taylor Sullivan

Q4 EDR

Cylinder Gas Audit

04/01/2021

Page 1

Facility: ROSEVILLE ENERGY
Unit/Stack: CT2
Parameter/Scale: CO / High

Test Date: 03/23/2021
Test Result: **Pass**

Instrument Name: CT2_CODualRg_P_Instrume
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
03/23/2021	07:28	L	200	49.400	50.100	24.7 %
03/23/2021	07:34	M	200	112.700	116.800	56.4 %
03/23/2021	07:46	L	200	49.400	50.300	24.7 %
03/23/2021	07:51	M	200	112.700	116.900	56.4 %
03/23/2021	08:03	L	200	49.400	50.100	24.7 %
03/23/2021	08:08	M	200	112.700	116.900	56.4 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	49.400	50.167	Std	1.6
M	112.700	116.867	Std	3.7

Cylinder Gas Audit

04/01/2021

Page 2

Facility: ROSEVILLE ENERGY
Unit/Stack: CT2
Parameter/Scale: CO / High

Test Date: 03/23/2021
Test Result: **Pass**

Instrument Name: CT2_CODualRg_P_Instrume
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
03/23/2021	07:28	L	200	49.400	50.100	24.7 %
03/23/2021	07:34	M	200	112.700	116.800	56.4 %
03/23/2021	07:46	L	200	49.400	50.300	24.7 %
03/23/2021	07:51	M	200	112.700	116.900	56.4 %
03/23/2021	08:03	L	200	49.400	50.100	24.7 %
03/23/2021	08:08	M	200	112.700	116.900	56.4 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	49.400	50.167	Std	1.6
M	112.700	116.867	Std	3.7

Cylinder Gas Audit

04/01/2021

Page 3

Facility: ROSEVILLE ENERGY
Unit/Stack: CT2
Parameter/Scale: CO / Low

Test Date: 03/23/2021
Test Result: **Pass**

Instrument Name: CT2_CODualRg_P_Instrume
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
03/23/2021	12:25	L	10	2.400	2.300	24.0 %
03/23/2021	12:31	M	10	5.700	5.600	57.0 %
03/23/2021	12:38	L	10	2.400	2.300	24.0 %
03/23/2021	12:43	M	10	5.700	5.600	57.0 %
03/23/2021	12:50	L	10	2.400	2.300	24.0 %
03/23/2021	12:55	M	10	5.700	5.600	57.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	2.400	2.300	Std	4.2
M	5.700	5.600	Std	1.8

Cylinder Gas Audit

04/01/2021

Page 4

Facility: ROSEVILLE ENERGY
Unit/Stack: CT1
Parameter/Scale: CO / High

Test Date: 03/24/2021
Test Result: **Pass**

Instrument Name: CT1_CODualRg_P_Instrume
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
03/24/2021	06:28	L	200	50.300	50.800	25.2 %
03/24/2021	06:34	M	200	112.800	116.400	56.4 %
03/24/2021	06:46	L	200	50.300	50.800	25.2 %
03/24/2021	06:51	M	200	112.800	116.400	56.4 %
03/24/2021	07:03	L	200	50.300	50.700	25.2 %
03/24/2021	07:08	M	200	112.800	116.300	56.4 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	50.300	50.767	Std	0.9
M	112.800	116.367	Std	3.2

Cylinder Gas Audit

04/01/2021

Page 5

Facility: ROSEVILLE ENERGY
Unit/Stack: CT1
Parameter/Scale: CO / Low

Test Date: 03/24/2021
Test Result: **Pass**

Instrument Name: CT1_CODualRg_P_Instrume
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
03/24/2021	10:30	L	10	2.400	2.500	24.0 %
03/24/2021	10:35	M	10	5.700	5.900	57.0 %
03/24/2021	10:43	L	10	2.400	2.500	24.0 %
03/24/2021	10:48	M	10	5.700	5.900	57.0 %
03/24/2021	10:55	L	10	2.400	2.500	24.0 %
03/24/2021	11:00	M	10	5.700	5.900	57.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	2.400	2.500	Std	4.2
M	5.700	5.900	Std	3.5

AQ-41

AQ-41 The Project owner shall submit a written report to the APCO and the CPM for each calendar quarter, within 30 days of the end of the quarter, including: time intervals, data and magnitude of excess emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; averaging period used for data reporting shall correspond to the averaging period for each respective emission standard; applicable time and date of each period during which the CEMS was inoperative (except for zero and span checks) and the nature of the system repairs and adjustments; and a negative declaration when no excess emission occurred.

Verification: The Project owner shall include the excess emission report as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6

Excess Emission Report



From: 01/01/2021 00:00 **To:** 03/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/02/2021 11:26 **Location:** Roseville, CA

Tag Name: ALL_CO_Lb_1D
Total Operating Time: 16.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 74.00 Day(s) Report Time: 90.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	16.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



From: 01/01/2021 00:00 **To:** 03/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/02/2021 11:26 **Location:** Roseville, CA

Tag Name: ALL_NOX_Lb_1D
Total Operating Time: 16.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 74.00 Day(s) Report Time: 90.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	16.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



From: 01/01/2021 00:00 **To:** 03/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/02/2021 11:27 **Location:** Roseville, CA

Tag Name: ALL_PM10_Lb_1D
Total Operating Time: 16.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 74.00 Day(s) Report Time: 90.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	16.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



From: 01/01/2021 00:00 **To:** 03/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/02/2021 11:27 **Location:** Roseville, CA

Tag Name: ALL_SO2_Lb_1D
Total Operating Time: 16.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 74.00 Day(s) Report Time: 90.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	16.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



From: 01/01/2021 00:00 **To:** 03/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/02/2021 11:28 **Location:** Roseville, CA

Tag Name: ALL_VOC_Lb_1D
Total Operating Time: 16.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 74.00 Day(s) **Report Time:** 90.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	16.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO LbPerHr 3-Hour Rolling Excess Emissions

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/02/2021 11:29 Location: Roseville, CA

Tag Name: CT1_CO_3Hr_LbPerHr_1H
Total Operating Time: 112.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 2,048.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	112.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO Ppmvdc 3-Hour Block Excess Emissions



CT1

From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/02/2021 11:30 Location: Roseville, CA

Tag Name: CT1_CO_Ppmvdc_3H
Total Operating Time: 112.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 2,048.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	112.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO LbPerHr SUSd 1-Hour Block Excess Emissions



CT1

From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/02/2021 11:30 Location: Roseville, CA

Tag Name: CT1_CO_SUSd_LbPerHr_1H
Total Operating Time: 112.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 2,048.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	112.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NH3 Slip Ppmvdc 1-Hour Block Excess Emissions



CT1

From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/02/2021 11:31 Location: Roseville, CA

Tag Name: CT1_NH3Slip_Ppmvdc_1H
Total Operating Time: 112.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 2,048.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	112.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx LbPerHr 1-Hour Block Excess Emissions



CT1

From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/02/2021 11:31 Location: Roseville, CA

Tag Name: CT1_NOx_Norm_LbPerHr_1H
Total Operating Time: 112.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 2,048.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	112.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx Ppmvdc 1-Hour Block Excess Emissions

CT1

From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/02/2021 11:31 Location: Roseville, CA



Tag Name: CT1_NOx_Ppmvdc_1H

Total Operating Time: 112.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 2,048.00 Hour(s) Report Time: 2,160.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Tag Value	Limit	Reason Code	Action Code
1	03/10/21 13:00	03/10/21 13:59	1	2.8	2.0	19 - COMMISSIONING	15 - NO ACTION NEEDED
2	03/13/21 11:00	03/13/21 11:59	1	2.6	2.0	19 - COMMISSIONING	15 - NO ACTION NEEDED

Total Operating Time:	112.00 Hour(s)
Total Duration (Online only):	2.00 Hour(s)
Time in exceedance as a percentage of operating time:	1.79 %
Time in compliance as a percentage of operating time:	98.21 %

Report Code	Type	Text	Duration	Duration Percent
19	Reason	COMMISSIONING	2	100.00
15	Action	NO ACTION NEEDED	2	100.00

NOx LbPerHr SUSd 1-Hour Block Excess Emissions



CT1

From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/02/2021 11:32 Location: Roseville, CA

Tag Name: CT1_NOx_SUSd_LbPerHr_1H
Total Operating Time: 112.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 2,048.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	112.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

PM10 LbPerHr 1-Hour Block Excess Emissions

CT1

From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/02/2021 11:32 Location: Roseville, CA



Tag Name: CT1_PM10_Norm_LbPerHr_1H
Total Operating Time: 112.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 2,048.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	112.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

S02 LbPerHr 1-Hour Block Excess Emissions



CT1

From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/02/2021 11:33 Location: Roseville, CA

Tag Name: CT1_S02_Norm_LbPerHr_1H
Total Operating Time: 112.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 2,048.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	112.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

VOC LbPerHr 1-Hour Block Excess Emissions

CT1

From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/02/2021 11:33 Location: Roseville, CA



Tag Name: CT1_VOC_Norm_LbPerHr_1H
Total Operating Time: 112.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 2,048.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	112.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO LbPerHr 3-Hour Rolling Excess Emissions

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/02/2021 11:34 Location: Roseville, CA

Tag Name: CT2_CO_3Hr_LbPerHr_1H
Total Operating Time: 102.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 2,058.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	102.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO Ppmvdc 3-Hour Block Excess Emissions

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/02/2021 11:35 Location: Roseville, CA

Tag Name: CT2_CO_Ppmvdc_3H
Total Operating Time: 102.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 2,058.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	102.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO LbPerHr SUSd 1-Hour Block Excess Emissions

CT2

From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/02/2021 11:35 Location: Roseville, CA



Tag Name: CT2_CO_SUSD_LbPerHr_1H

Total Operating Time: 102.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 2,058.00 Hour(s) Report Time: 2,160.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Tag Value	Limit	Reason Code	Action Code
1	02/26/21 08:00	02/26/21 08:59	1	263.2	89.5	1 - Startup/shutdown	

Total Operating Time:	102.00 Hour(s)
Total Duration (Online only):	1.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.98 %
Time in compliance as a percentage of operating time:	99.02 %

Report Code	Type	Text	Duration	Duration Percent
1	Reason	Startup/shutdown	1	100.00

NH3 Slip Ppmvdc 1-Hour Block Excess Emissions

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/02/2021 11:37 Location: Roseville, CA

Tag Name: CT2_NH3Slip_Ppmvdc_1H
Total Operating Time: 102.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 2,058.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	102.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx LbPerHr 1-Hour Block Excess Emissions

CT2

From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/02/2021 11:37 Location: Roseville, CA



Tag Name: CT2_NOx_Norm_LbPerHr_1H
Total Operating Time: 102.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 2,058.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	102.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx Ppmvdc 1-Hour Block Excess Emissions

CT2

From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/02/2021 11:38 Location: Roseville, CA



Tag Name: CT2_NOx_Ppmvdc_1H

Total Operating Time: 102.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 2,058.00 Hour(s) Report Time: 2,160.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Tag Value	Limit	Reason Code	Action Code
1	03/01/21 14:00	03/01/21 14:59	1	2.1	2.0	19 - COMMISSIONING	15 - NO ACTION NEEDED
2	03/06/21 10:00	03/06/21 10:59	1	3.0	2.0	19 - COMMISSIONING	15 - NO ACTION NEEDED
3	03/13/21 18:00	03/13/21 18:59	1	4.4	2.0	19 - COMMISSIONING	15 - NO ACTION NEEDED
4	03/25/21 11:00	03/25/21 11:59	1	2.1	2.0		

Total Operating Time:	102.00 Hour(s)
Total Duration (Online only):	4.00 Hour(s)
Time in exceedance as a percentage of operating time:	3.92 %
Time in compliance as a percentage of operating time:	96.08 %

Report Code	Type	Text	Duration	Duration Percent
19	Reason	COMMISSIONING	3	75.00
15	Action	NO ACTION NEEDED	3	75.00

NOx LbPerHr SUSd 1-Hour Block Excess Emissions



CT2

From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/02/2021 11:39 Location: Roseville, CA

Tag Name: CT2_NOx_SUSd_LbPerHr_1H
Total Operating Time: 102.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 2,058.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	102.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

PM10 LbPerHr 1-Hour Block Excess Emissions

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/02/2021 11:39 Location: Roseville, CA

Tag Name: CT2_PM10_Norm_LbPerHr_1H
Total Operating Time: 102.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 2,058.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	102.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

S02 LbPerHr 1-Hour Block Excess Emissions

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/02/2021 11:40 Location: Roseville, CA

Tag Name: CT2_S02_Norm_LbPerHr_1H
Total Operating Time: 102.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 2,058.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	102.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

VOC LbPerHr 1-Hour Block Excess Emissions

CT2

From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/02/2021 11:40 Location: Roseville, CA



Tag Name: CT2_VOC_Norm_LbPerHr_1H
Total Operating Time: 102.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 2,058.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	102.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

AQ-42

AQ-42 The Project owner shall provide the PCAPCD and CPM with a written emission statement showing actual emissions of volatile organic compounds and oxides of nitrogen. Pursuant to PCAPCD Rule 503 the Project owner shall submit this emission statement on a form or in a format specified by the Air Pollution Control Officer. The statement shall contain the following information:

- a) Information contained in the California Air Resources Board's Emission Inventory Turn Around Document as described in Instructions for the Emission Data System Review and Update Report;
- b) Actual emissions of volatile organic compounds and oxides of nitrogen, in tons per year, for the calendar year prior to the preparation of the emission statement;
- c) Information regarding seasonal or diurnal peaks in the emission of affected pollutants; and
- d) Certification by a responsible official of the Project owner that the information contained in the emission statement is accurate to the best knowledge of the individual certifying the emission statement.

Verification: The Project owner shall submit to the CPM the emission statement described herein prior to the beginning of March each year.

12 Month Running Summary Report

AQ42 12 Month Running Summary Report



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/02/2021 11:17 Location: Roseville, CA

Date	Units CT1 & CT2		Units CT1 & CT2	
	NOx, Ton		VOC, Ton	
	1 Day(s)		1 Day(s)	
	Sum	Running Sum	Sum	Running Sum
Jan 21	0.0714	0.0714	0.0212	0.0212
Feb 21	0.0376	0.1090	0.0064	0.0276
Mar 21	0.2429	0.3519	0.0512	0.0788
Sum/Avg	0.3519		0.0788	

Roseville Energy Park Quarterly Emissions Summary

for PCAPCD



From: 01/01/2021 00:00 **To:** 03/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/02/2021 11:18 **Location:** Roseville, CA

* = Excess Emission

Date	Unit CT1 CO, Ton		Unit CT1 NOx, Ton		Unit CT1 OperatingTime, Hrs		Unit CT2 CO, Ton		Unit CT2 NOx, Ton		Unit CT2 OperatingTime, Hrs	
	1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)	
	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum
Jan 2021	0.0375	0.9489	0.0714	3.2062	48.29	2,406.38	0.0000	1.3998	0.0000	4.2931	0.00	3,345.52
Feb 2021	0.0000	0.8771	0.0000	3.1294	0.00	2,339.96	0.1878	1.4782	0.0376	4.0530	14.37	3,169.12
Mar 2021	0.2199	1.0970	0.0999	3.2293	49.96	2,389.92	0.2091	1.6873	0.1431	4.1961	73.12	3,242.24
Sum/Avg	1.0970		3.2293		2,389.92		1.6873		4.1961		3,242.24	
Limit Value												

AQ-47

AQ-47 No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

In regards to AQ-47 of Roseville Energy Park's 1Q21 QAQR, there were no violations of PCAPCD's Rule 205 for nuisance.

AQ-48

AQ-48 Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited and is in violation of PCAPCD Rule 202, Visible Emissions.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

In regards to AQ-48 of Roseville Energy Park's 1Q21 QAQR, there were no violations of PCAPCD's Rule 202 for opacity.

AQ-51

AQ-51 The ammonia slip shall not exceed 10 ppmv @ 15% O₂ averaged over one hour. The SCR catalyst shall be replaced, repaired or otherwise reconditioned within 24 months of the ammonia slip reaching 7 ppm @ 15% O₂ averaged over 24 hours. The SCR ammonia injection grid replacement, repair or reconditioning scheduled event may be cancelled if the Project owner can demonstrate to the CPM that, subsequent to the initial exceedance, the ammonia slip consistently remains below 7 ppm @ 15% O₂ averaged over 24 hours and that the initial exceedance does not accurately indicate expected future operating conditions.

Compliance with ammonia slip limits shall be demonstrated by using the following calculation procedure:

$$\text{Ammonia slip ppmv @ 15\% O}_2 = ((a - (b \times c / 1,000,000)) \times 1,000,000 / b) \times d,$$

Where

a = ammonia injection rate (lb/hr)/17(lb/lb mol)

b = dry exhaust gas flow rate (lb/hr)/ (29(lb/lb mol)

c = change in measured NOX conc. Ppmv @ 15% O₂ across catalyst, and

d = correction factor

The correction factor shall be derived annually during compliance testing by comparing the measured and calculated ammonia slip.

Verification: The Project owner shall include the ammonia slip concentrations averaged on an hourly and 24 hour basis calculated via the protocol provided as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6. The Project owner shall notify the CPM within 10 days of an exceedance of the 7 ppm ammonia slip limit herein. The Project owner shall notify the CPM no less than 30 days prior to the scheduled date of the SCR catalyst replacement, repair or reconditioning event. If the Project owner finds that the exceedance of the 7 ppm slip limit does not accurately reflect the expected future operations provided for in this condition, the Project owner shall submit all relevant information to the CPM no less than 30 days prior to the scheduled date of the SCR catalyst replacement, repair or reconditioning event in order to cancel the event.

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/01/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/02/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/03/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/04/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/05/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/06/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/07/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/08/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/09/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/10/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/11/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/12/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/13/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/14/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/15/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/16/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/17/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/18/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/19/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/20/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/21/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/22/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/23/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 23:00	0	21.9	27.5	18.0	0.0	687,073.3	0.27	0.27
Average/Sum#:	0	21.9	27.5	18.0	0.0	687,073.3	0.27 #	0.27 #
Minimum:	0	21.9	27.5	18.0	0.0	687,073.3	0.00	0.00
Maximum:	0	21.9	27.5	18.0	0.0	687,073.3	0.27	0.27
%SI	100.00	95.83	95.83	95.83	95.83	95.83	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/24/2021 00:00	3	4.6	12.3	14.4	24.1	923,834.8	0.67	1.00
01/24/2021 01:00	3	1.9	12.2	14.4	34.9	888,440.4	0.00	1.00
01/24/2021 02:00	3	1.9	13.0	14.2	31.7	720,072.0	0.00	1.00
01/24/2021 03:00	4	1.9	13.3	14.2	33.2	686,960.5	0.00	1.00
01/24/2021 04:00	3	1.9	13.0	14.2	30.9	699,632.8	0.00	1.00
01/24/2021 05:00	3	1.9	12.2	14.3	30.2	756,088.3	0.00	1.00
01/24/2021 06:00	4	1.9	13.4	14.2	31.7	669,382.8	0.00	1.00
01/24/2021 07:00	4	1.9	13.3	14.2	30.9	667,134.5	0.00	1.00
01/24/2021 08:00	3	1.9	12.9	14.2	29.3	655,075.4	0.00	1.00
01/24/2021 09:00	3	1.9	11.9	14.3	28.4	720,815.2	0.00	1.00
01/24/2021 10:00	3	1.9	12.0	14.3	28.7	716,872.9	0.00	1.00
01/24/2021 11:00	3	1.9	11.9	14.3	28.0	712,723.1	0.00	1.00
01/24/2021 12:00	2	1.9	11.4	14.4	28.7	808,171.1	0.00	1.00
01/24/2021 13:00	3	1.9	11.5	14.4	28.9	800,375.9	0.00	1.00
01/24/2021 14:00	2	1.9	11.1	14.4	30.3	854,942.2	0.00	1.00
01/24/2021 15:00	2	1.9	9.7	14.5	29.5	916,658.4	0.00	1.00
01/24/2021 16:00	3	1.9	11.6	14.0	34.9	947,681.4	0.00	1.00
01/24/2021 17:00	3	2.0	11.2	14.1	34.1	951,749.9	0.00	1.00
01/24/2021 18:00	3	2.0	12.1	13.8	35.5	957,439.8	0.00	1.00
01/24/2021 19:00	3	2.0	11.2	14.0	33.9	939,147.3	0.00	1.00
01/24/2021 20:00	3	1.9	9.8	14.4	30.3	895,392.9	0.00	1.00
01/24/2021 21:00	3	1.9	11.3	14.3	28.9	781,401.9	0.00	1.00
01/24/2021 22:00	3	1.9	11.6	14.4	32.3	858,313.1	0.00	1.00
01/24/2021 23:00	3	1.9	11.8	14.2	28.3	725,999.3	0.00	1.00
Average/Sum#:	3	2.0	11.9	14.3	30.7	802,262.7	0.67 #	24.00 #
Minimum:	2	1.9	9.7	13.8	24.1	655,075.4	0.00	1.00
Maximum:	4	4.6	13.4	14.5	35.5	957,439.8	0.67	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 **To:** 03/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOX, Ppm	Unit CT1 NOX, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/25/2021 00:00	3	2.0	12.1	14.2	29.1	698,406.4	0.00	1.00
01/25/2021 01:00	3	1.9	12.8	14.2	30.6	680,215.6	0.00	1.00
01/25/2021 02:00	3	1.9	12.8	14.2	30.2	679,602.4	0.00	1.00
01/25/2021 03:00	3	1.9	12.3	14.2	30.6	694,523.0	0.00	1.00
01/25/2021 04:00	3	1.9	12.0	14.2	29.3	744,190.2	0.00	1.00
01/25/2021 05:00	3	1.9	11.7	14.4	33.4	880,855.9	0.00	1.00
01/25/2021 06:00	3	1.9	10.0	14.4	34.6	962,600.0	0.00	1.00
01/25/2021 07:00	4	2.1	14.1	13.3	45.4	981,480.9	0.00	1.00
01/25/2021 08:00	5	2.4	17.7	12.4	54.9	995,007.6	0.00	1.00
01/25/2021 09:00	5	2.6	18.1	12.0	60.5	992,448.0	0.00	1.00
01/25/2021 10:00	4	2.3	16.2	12.8	48.3	980,575.5	0.00	1.00
01/25/2021 11:00	4	2.3	15.2	13.1	46.1	980,016.3	0.00	1.00
01/25/2021 12:00	3	2.1	13.3	13.6	39.3	962,724.1	0.00	1.00
01/25/2021 13:00	3	2.0	12.5	13.9	37.5	958,597.1	0.00	1.00
01/25/2021 14:00	3	2.0	12.6	13.9	37.7	957,814.5	0.00	1.00
01/25/2021 15:00	3	2.0	12.2	14.0	37.0	950,063.0	0.00	1.00
01/25/2021 16:00	4	2.2	15.5	13.0	48.2	972,118.0	0.00	1.00
01/25/2021 17:00	3	2.1	13.3	13.7	39.4	963,922.6	0.00	1.00
01/25/2021 18:00	5	2.5	18.3	12.0	60.6	982,908.2	0.00	1.00
01/25/2021 19:00	5	2.6	18.4	12.0	60.8	986,908.8	0.00	1.00
01/25/2021 20:00	5	2.5	18.2	12.3	56.8	988,374.1	0.00	1.00
01/25/2021 21:00	3	2.2	14.1	13.3	41.6	972,471.5	0.00	1.00
01/25/2021 22:00	3	1.9	10.3	14.4	32.6	948,905.8	0.00	1.00
01/25/2021 23:00	3	1.9	12.4	14.3	34.6	826,426.9	0.03	1.00
Average/Sum#:	4	2.1	14.0	13.5	41.6	905,881.5	0.03 #	24.00 #
Minimum:	3	1.9	10.0	12.0	29.1	679,602.4	0.00	1.00
Maximum:	5	2.6	18.4	14.4	60.8	995,007.6	0.03	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/26/2021 00:00	0	2.7	20.7	14.3	0.0	457,097.3	0.02	0.02
01/26/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	2.7	20.7	14.3	0.0	457,097.3	0.02 #	0.02 #
Minimum:	0	2.7	20.7	14.3	0.0	457,097.3	0.00	0.00
Maximum:	0	2.7	20.7	14.3	0.0	457,097.3	0.02	0.02
%SI	100.00	95.83	95.83	95.83	95.83	95.83	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/27/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/28/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/29/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/30/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/31/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/01/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/02/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/03/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/04/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/05/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/06/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/07/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/08/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/09/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/10/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/11/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/12/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/13/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/14/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/15/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/16/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/17/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/18/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/19/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/20/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/21/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/22/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/23/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/24/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/25/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/26/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/27/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/28/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/01/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/02/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/03/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/04/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/05/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/06/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/07/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/08/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2021 09:00	0	3.5	12.6	19.6	0.0	510,900.6	0.10	0.10
03/08/2021 10:00	0	12.7	17.3	19.1	0.0	780,571.9	0.30	0.30
03/08/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2021 13:00	0	5.7	6.9	19.8	0.0	664,793.3	0.10	0.10
03/08/2021 14:00	0	20.5	24.7	18.4	0.0	770,164.3	0.27	0.27
03/08/2021 15:00	3	4.9	15.5	14.3	18.7	694,464.2	0.65	1.00
03/08/2021 16:00	2	1.9	12.9	14.3	34.2	1,009,639.3	0.00	1.00
03/08/2021 17:00	0	0.0	12.3	0.0	34.3	320,799.1	0.00	1.00
03/08/2021 18:00	3	1.9	12.2	14.2	37.0	1,002,950.1	0.00	1.00
03/08/2021 19:00	3	2.0	12.4	14.2	35.4	967,794.7	0.00	1.00
03/08/2021 20:00	2	8.5	31.6	15.4	3.1	573,166.4	0.15	0.17
03/08/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	3	6.8	15.8	16.6	16.3	774,938.3	1.57 #	5.94 #
Minimum:	2	1.9	6.9	14.2	0.0	510,900.6	0.00	0.00
Maximum:	3	20.5	31.6	19.8	37.0	1,009,639.3	0.65	1.00
%SI	79.17	62.50	58.33	62.50	58.33	62.50	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/09/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/10/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2021 11:00	0	24.7	29.3	17.9	0.0	702,514.7	0.30	0.30
03/10/2021 12:00	0	21.5	39.6	15.3	28.3	632,625.2	1.00	1.00
03/10/2021 13:00	6	3.8	31.4	14.8	66.9	624,996.3	0.58	1.00
03/10/2021 14:00	2	2.0	12.2	14.2	26.6	705,355.8	0.00	1.00
03/10/2021 15:00	3	1.9	10.6	14.2	33.1	955,122.4	0.00	1.00
03/10/2021 16:00	3	1.9	12.3	14.3	42.0	1,013,374.0	0.00	1.00
03/10/2021 17:00	3	1.9	13.3	14.2	43.0	998,862.2	0.00	1.00
03/10/2021 18:00	3	2.0	13.8	14.2	44.4	976,992.3	0.00	1.00
03/10/2021 19:00	3	6.7	27.4	15.1	8.4	584,602.5	0.15	0.22
03/10/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	3	7.4	21.1	14.9	32.5	799,382.8	2.03 #	7.52 #
Minimum:	2	1.9	10.6	14.2	0.0	584,602.5	0.00	0.00
Maximum:	6	24.7	39.6	17.9	66.9	1,013,374.0	1.00	1.00
%SI	70.83	62.50	62.50	62.50	62.50	62.50	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/11/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/12/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2021 12:00	0	0.5	2.1	20.6	0.0	1,761,992.7	0.07	0.07
03/12/2021 13:00	0	2.9	5.6	20.1	0.0	950,038.2	0.18	0.18
03/12/2021 14:00	0	28.4	36.9	15.8	0.0	632,620.4	0.72	0.72
03/12/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	10.6	14.9	18.8	0.0	1,114,883.8	0.97 #	0.97 #
Minimum:	0	0.5	2.1	15.8	0.0	632,620.4	0.00	0.00
Maximum:	0	28.4	36.9	20.6	0.0	1,761,992.7	0.72	0.72
%SI	100.00	87.50	87.50	87.50	87.50	87.50	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/13/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2021 07:00	0	0.0	1.9	0.0	0.0	10,680.2	0.07	0.07
03/13/2021 08:00	0	0.0	29.0	0.0	0.0	105,295.0	0.55	0.55
03/13/2021 09:00	0	0.0	12.6	0.0	16.3	262,811.5	1.00	1.00
03/13/2021 10:00	0	0.0	16.9	0.0	30.3	226,249.9	0.57	1.00
03/13/2021 11:00	2	2.7	11.5	14.5	24.7	864,235.2	0.00	1.00
03/13/2021 12:00	2	1.9	9.1	14.4	27.8	1,001,575.9	0.00	1.00
03/13/2021 13:00	2	1.9	9.2	14.4	28.0	996,098.2	0.00	1.00
03/13/2021 14:00	4	2.6	16.4	11.9	51.4	1,028,133.4	0.00	1.00
03/13/2021 15:00	5	2.7	16.9	11.6	54.3	1,013,963.0	0.00	1.00
03/13/2021 16:00	5	2.7	16.6	11.6	53.0	1,014,993.8	0.00	1.00
03/13/2021 17:00	2	2.2	11.2	13.7	31.3	899,635.7	0.00	1.00
03/13/2021 18:00	2	8.3	22.6	15.5	2.2	558,167.2	0.17	0.18
03/13/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	3	3.1	14.5	13.5	26.6	922,100.3	2.36 #	9.80 #
Minimum:	2	1.9	1.9	11.6	0.0	558,167.2	0.00	0.00
Maximum:	5	8.3	29.0	15.5	54.3	1,028,133.4	1.00	1.00
%SI	66.67	66.67	50.00	66.67	50.00	66.67	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/14/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 **To:** 03/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/15/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/16/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/17/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/18/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/19/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/20/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/21/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/22/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/23/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2021 09:00	0	3.0	9.5	19.8	0.0	539,055.2	0.12	0.12
03/23/2021 10:00	0	17.7	19.7	16.1	0.0	668,735.6	0.58	0.58
03/23/2021 11:00	2	3.5	9.3	14.4	22.7	942,796.0	0.47	1.00
03/23/2021 12:00	3	2.3	13.9	12.6	42.7	974,106.2	0.00	1.00
03/23/2021 13:00	2	1.9	9.0	14.3	24.0	964,199.3	0.00	1.00
03/23/2021 14:00	3	2.2	13.1	13.0	40.4	966,744.3	0.00	1.00
03/23/2021 15:00	5	2.6	15.8	11.8	53.5	1,012,471.1	0.00	1.00
03/23/2021 16:00	2	2.1	10.8	13.5	28.1	985,985.6	0.00	1.00
03/23/2021 17:00	3	1.9	11.5	14.5	25.9	674,013.6	0.00	1.00
03/23/2021 18:00	3	1.8	12.7	14.6	28.4	623,414.1	0.00	1.00
03/23/2021 19:00	3	1.8	12.4	14.6	27.4	632,326.3	0.00	1.00
03/23/2021 20:00	3	1.9	12.0	14.5	26.9	629,721.2	0.00	1.00
03/23/2021 21:00	3	1.8	12.2	14.5	28.0	624,799.9	0.00	1.00
03/23/2021 22:00	4	1.8	12.4	14.5	28.8	623,730.0	0.00	1.00
03/23/2021 23:00	4	1.8	12.2	14.6	29.2	631,239.4	0.00	1.00
Average/Sum#:	3	3.2	12.4	14.5	27.1	766,222.5	1.17 #	13.70 #
Minimum:	2	1.8	9.0	11.8	0.0	539,055.2	0.00	0.00
Maximum:	5	17.7	19.7	19.8	53.5	1,012,471.1	0.58	1.00
%SI	45.83	37.50	37.50	37.50	37.50	37.50	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/24/2021 00:00	4	1.8	12.3	14.6	30.2	629,283.1	0.00	1.00
03/24/2021 01:00	4	1.8	12.2	14.6	29.6	631,022.1	0.00	1.00
03/24/2021 02:00	4	1.8	12.1	14.6	29.4	632,326.3	0.00	1.00
03/24/2021 03:00	4	1.8	12.1	14.6	29.6	632,543.6	0.00	1.00
03/24/2021 04:00	4	1.8	12.4	14.6	29.8	631,674.2	0.00	1.00
03/24/2021 05:00	4	1.9	12.1	14.6	30.5	632,108.9	0.00	1.00
03/24/2021 06:00	4	1.8	12.2	14.6	32.5	631,456.8	0.00	1.00
03/24/2021 07:00	3	1.7	12.1	14.4	30.9	656,059.6	0.00	1.00
03/24/2021 08:00	0	1.4	15.7	12.9	61.5	1,079,106.4	0.00	1.00
03/24/2021 09:00	0	1.5	9.3	14.3	12.3	738,036.7	0.00	1.00
03/24/2021 10:00	3	2.6	14.9	12.5	43.6	1,077,280.5	0.00	1.00
03/24/2021 11:00	2	2.8	10.5	14.4	15.9	799,954.5	0.10	1.00
03/24/2021 12:00	0	18.0	29.3	17.1	0.0	525,426.5	0.03	0.03
03/24/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	3	3.1	13.6	14.4	28.9	715,098.4	0.13 #	12.03 #
Minimum:	0	1.4	9.3	12.5	0.0	525,426.5	0.00	0.00
Maximum:	4	18.0	29.3	17.1	61.5	1,079,106.4	0.10	1.00
%SI	54.17	45.83	45.83	45.83	45.83	45.83	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/25/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/26/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/27/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/28/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/29/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/30/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:45 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/31/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/01/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/02/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/03/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/04/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/05/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/06/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/07/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/08/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/09/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/10/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/11/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/12/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/13/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/14/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/15/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/16/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/17/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/18/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/19/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/20/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/21/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/22/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/23/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/24/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/25/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/26/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/27/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/28/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/29/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/30/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/31/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/01/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/02/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/03/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/04/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/05/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/06/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/07/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/08/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/09/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/10/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/11/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/12/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/13/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/14/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/15/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/16/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/17/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/18/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/19/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/20/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/21/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/22/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/23/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/24/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/25/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/26/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2021 08:00	0	22.2	26.6	17.0	0.0	735,275.6	0.72	0.72
02/26/2021 09:00	1	3.5	16.2	14.3	26.8	727,662.3	0.33	1.00
02/26/2021 10:00	1	1.8	15.0	14.4	35.2	1,040,130.5	0.00	1.00
02/26/2021 11:00	1	1.9	14.6	14.4	35.2	1,089,008.4	0.00	1.00
02/26/2021 12:00	0	1.9	14.3	14.4	33.6	1,084,162.8	0.00	1.00
02/26/2021 13:00	1	1.9	14.3	14.4	34.0	1,079,317.1	0.00	1.00
02/26/2021 14:00	1	5.5	24.3	14.9	17.0	807,503.9	0.17	0.35
02/26/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	1	5.5	17.9	14.8	26.0	937,580.1	1.22 #	6.07 #
Minimum:	0	1.8	14.3	14.3	0.0	727,662.3	0.00	0.00
Maximum:	1	22.2	26.6	17.0	35.2	1,089,008.4	0.72	1.00
%SI	75.00	70.83	70.83	70.83	70.83	70.83	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/27/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2021 09:00	0	24.5	28.9	17.7	0.0	753,183.4	0.28	0.28
02/27/2021 10:00	1	5.1	14.7	14.3	27.2	1,031,218.1	0.52	1.00
02/27/2021 11:00	1	1.9	14.2	14.3	32.5	1,067,321.1	0.00	1.00
02/27/2021 12:00	0	1.9	14.1	14.4	32.6	1,079,317.1	0.00	1.00
02/27/2021 13:00	0	1.5	14.9	14.5	36.2	1,092,329.9	0.00	1.00
02/27/2021 14:00	0	1.9	12.5	14.5	22.7	1,080,347.5	0.00	1.00
02/27/2021 15:00	0	1.9	11.3	14.4	15.2	920,253.2	0.00	1.00
02/27/2021 16:00	0	2.0	13.8	14.4	22.0	755,500.9	0.00	1.00
02/27/2021 17:00	1	2.8	20.3	14.6	24.4	688,842.2	0.13	1.00
02/27/2021 18:00	0	13.9	29.3	17.7	0.0	336,792.8	0.02	0.02
02/27/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	5.7	17.4	15.1	21.3	880,510.6	0.95 #	8.30 #
Minimum:	0	1.5	11.3	14.3	0.0	336,792.8	0.00	0.00
Maximum:	1	24.5	29.3	17.7	36.2	1,092,329.9	0.52	1.00
%SI	66.67	58.33	58.33	58.33	58.33	58.33	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/28/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/01/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2021 07:00	0	26.1	33.1	18.1	0.0	774,702.9	0.25	0.25
03/01/2021 08:00	0	13.2	23.9	14.2	25.0	972,495.7	0.58	1.00
03/01/2021 09:00	0	1.9	10.4	14.3	18.4	1,086,617.5	0.00	1.00
03/01/2021 10:00	0	1.9	10.3	14.3	19.7	1,075,205.6	0.00	1.00
03/01/2021 11:00	0	1.9	10.0	14.4	19.8	1,077,210.3	0.00	1.00
03/01/2021 12:00	0	1.9	0.0	14.4	19.5	1,069,836.5	0.00	1.00
03/01/2021 13:00	0	1.9	9.9	14.4	11.2	744,966.9	0.00	1.00
03/01/2021 14:00	2	2.2	21.1	14.6	41.7	697,754.3	0.00	1.00
03/01/2021 15:00	1	1.6	32.3	14.8	55.4	671,017.9	0.00	1.00
03/01/2021 16:00	0	1.7	20.2	14.6	23.6	703,188.6	0.12	1.00
03/01/2021 17:00	0	8.7	33.2	17.2	0.0	454,871.0	0.05	0.05
03/01/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	5.7	20.4	15.0	21.3	847,987.9	1.00 #	9.30 #
Minimum:	0	1.6	9.9	14.2	0.0	454,871.0	0.00	0.00
Maximum:	2	26.1	33.2	18.1	55.4	1,086,617.5	0.58	1.00
%SI	62.50	54.17	58.33	54.17	54.17	54.17	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/02/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/03/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/04/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/05/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/06/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2021 08:00	0	25.9	39.1	16.2	10.2	684,712.2	0.92	0.92
03/06/2021 09:00	0	1.9	14.4	14.3	18.6	697,576.5	0.15	1.00
03/06/2021 10:00	1	3.0	24.5	14.7	41.9	680,736.4	0.00	1.00
03/06/2021 11:00	0	1.4	20.3	14.7	33.2	678,306.8	0.00	1.00
03/06/2021 12:00	0	1.9	14.2	14.3	30.3	1,051,759.4	0.00	1.00
03/06/2021 13:00	0	2.0	12.9	14.3	28.3	1,059,644.0	0.00	1.00
03/06/2021 14:00	1	1.9	12.9	14.3	30.0	1,040,140.1	0.00	1.00
03/06/2021 15:00	1	1.9	13.2	14.2	25.5	873,774.5	0.00	1.00
03/06/2021 16:00	1	1.9	13.2	14.2	24.0	857,423.2	0.05	1.00
03/06/2021 17:00	0	12.0	35.5	15.9	0.0	562,559.5	0.12	0.12
03/06/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	1	5.4	20.0	14.7	24.2	818,663.3	1.24 #	9.04 #
Minimum:	0	1.4	12.9	14.2	0.0	562,559.5	0.00	0.00
Maximum:	1	25.9	39.1	16.2	41.9	1,059,644.0	0.92	1.00
%SI	66.67	58.33	58.33	58.33	58.33	58.33	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/07/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/08/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/09/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/10/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/11/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/12/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2021 14:00	0	0.0	1.3	20.9	0.0	0.0	0.03	0.03
03/12/2021 15:00	0	1.9	5.0	20.0	0.0	461,039.5	0.20	0.20
03/12/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2021 17:00	0	4.4	6.2	19.8	0.0	511,666.7	0.10	0.10
03/12/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	2.1	4.2	20.2	0.0	324,235.4	0.33 #	0.33 #
Minimum:	0	0.0	1.3	19.8	0.0	0.0	0.00	0.00
Maximum:	0	4.4	6.2	20.9	0.0	511,666.7	0.20	0.20
%SI	100.00	87.50	87.50	87.50	87.50	87.50	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/13/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2021 11:00	0	0.0	25.1	0.0	0.0	97,563.3	0.27	0.27
03/13/2021 12:00	0	0.0	15.2	0.0	22.9	324,665.0	0.77	1.00
03/13/2021 13:00	1	1.6	14.2	14.3	33.9	1,050,514.5	0.00	1.00
03/13/2021 14:00	1	2.5	17.8	11.8	47.0	1,079,437.5	0.00	1.00
03/13/2021 15:00	2	2.7	18.8	11.7	54.1	1,069,788.4	0.00	1.00
03/13/2021 16:00	2	2.7	18.3	11.7	52.5	1,069,937.2	0.00	1.00
03/13/2021 17:00	1	2.1	14.8	13.7	34.3	960,879.4	0.00	1.00
03/13/2021 18:00	2	4.1	36.5	15.1	62.3	668,420.8	0.00	1.00
03/13/2021 19:00	0	1.8	14.4	14.4	15.9	850,517.9	0.00	1.00
03/13/2021 20:00	0	1.5	10.6	14.3	11.3	860,455.0	0.00	1.00
03/13/2021 21:00	0	2.0	9.9	14.3	17.0	1,053,004.4	0.00	1.00
03/13/2021 22:00	0	12.2	28.5	15.6	0.5	580,842.6	0.17	0.17
03/13/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	1	3.3	18.7	13.7	29.3	924,379.8	1.21 #	10.44 #
Minimum:	0	1.5	9.9	11.7	0.0	580,842.6	0.00	0.00
Maximum:	2	12.2	36.5	15.6	62.3	1,079,437.5	0.77	1.00
%SI	62.50	58.33	50.00	58.33	50.00	58.33	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/14/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/15/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/16/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/17/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/18/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/19/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/20/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/21/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/22/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2021 05:00	0	22.6	28.2	17.4	0.0	726,577.5	0.35	0.35
03/22/2021 06:00	1	10.3	23.7	14.7	28.5	659,974.2	0.68	1.00
03/22/2021 07:00	1	1.8	22.5	14.7	36.2	651,360.1	0.02	0.87
03/22/2021 08:00	0	3.0	14.1	15.3	12.1	949,304.5	0.37	0.87
03/22/2021 09:00	0	1.9	9.8	14.3	19.6	1,070,433.4	0.00	1.00
03/22/2021 10:00	1	1.9	12.3	14.4	19.6	720,317.2	0.00	1.00
03/22/2021 11:00	0	2.2	11.5	13.4	26.7	1,075,454.6	0.00	1.00
03/22/2021 12:00	2	2.5	13.8	12.2	38.0	1,101,048.7	0.00	1.00
03/22/2021 13:00	0	2.1	10.2	13.9	20.8	1,089,474.9	0.00	1.00
03/22/2021 14:00	0	0.0	13.9	0.0	66.2	470,387.4	0.00	1.00
03/22/2021 15:00	-1	0.6	9.0	14.3	7.1	906,932.4	0.00	1.00
03/22/2021 16:00	0	1.9	14.0	14.5	17.2	666,096.6	0.00	1.00
03/22/2021 17:00	1	1.8	14.7	14.6	22.8	662,975.3	0.00	1.00
03/22/2021 18:00	1	1.8	14.8	14.6	23.2	661,888.5	0.00	1.00
03/22/2021 19:00	1	1.9	13.9	14.5	21.2	660,533.3	0.00	1.00
03/22/2021 20:00	1	1.8	13.6	14.5	20.9	664,812.7	0.00	1.00
03/22/2021 21:00	1	1.9	13.6	14.5	21.4	668,450.3	0.00	1.00
03/22/2021 22:00	1	1.9	13.7	14.5	21.2	669,520.1	0.00	1.00
03/22/2021 23:00	1	1.9	14.1	14.5	22.3	667,594.4	0.00	1.00
Average/Sum#:	1	3.5	14.8	14.5	23.4	792,930.5	1.42 #	18.09 #
Minimum:	-1	0.6	9.0	12.2	0.0	651,360.1	0.00	0.00
Maximum:	2	22.6	28.2	17.4	66.2	1,101,048.7	0.68	1.00
%SI	29.17	25.00	20.83	25.00	20.83	25.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/23/2021 00:00	1	1.9	14.1	14.5	22.4	668,022.3	0.00	1.00
03/23/2021 01:00	1	1.9	14.5	14.5	23.4	668,236.3	0.00	1.00
03/23/2021 02:00	1	1.9	15.1	14.5	24.9	667,594.4	0.00	1.00
03/23/2021 03:00	1	1.9	15.4	14.5	25.2	667,808.4	0.00	1.00
03/23/2021 04:00	1	1.8	15.9	14.5	25.8	667,808.4	0.00	1.00
03/23/2021 05:00	1	1.9	16.3	14.5	27.4	665,240.7	0.00	1.00
03/23/2021 06:00	1	1.8	16.7	14.5	27.7	660,533.3	0.00	1.00
03/23/2021 07:00	1	1.8	16.3	14.6	27.2	682,755.9	0.00	1.00
03/23/2021 08:00	0	1.9	9.6	13.9	17.4	1,024,916.3	0.00	1.00
03/23/2021 09:00	0	1.9	9.5	14.3	18.3	1,063,171.3	0.00	1.00
03/23/2021 10:00	0	1.9	9.7	14.3	19.8	1,038,480.2	0.00	1.00
03/23/2021 11:00	0	2.0	9.7	14.0	20.5	1,019,725.0	0.00	1.00
03/23/2021 12:00	2	1.9	13.8	12.1	40.8	1,095,383.9	0.00	1.00
03/23/2021 13:00	0	1.5	9.0	14.3	17.5	1,031,425.5	0.05	1.00
03/23/2021 14:00	0	13.4	29.9	15.7	0.0	571,471.3	0.13	0.13
03/23/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	1	2.6	14.4	14.3	22.6	812,838.2	0.18 #	14.13 #
Minimum:	0	1.5	9.0	12.1	0.0	571,471.3	0.00	0.00
Maximum:	2	13.4	29.9	15.7	40.8	1,095,383.9	0.13	1.00
%SI	41.67	37.50	37.50	37.50	37.50	37.50	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/24/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2021 08:00	0	25.7	30.2	18.0	0.0	743,739.1	0.27	0.27
03/24/2021 09:00	0	6.2	13.3	14.2	14.2	773,213.8	0.58	1.00
03/24/2021 10:00	1	2.6	14.4	12.1	38.8	1,084,335.1	0.00	1.00
03/24/2021 11:00	0	2.0	10.6	14.2	16.9	868,460.3	0.00	1.00
03/24/2021 12:00	1	1.5	12.2	13.5	30.5	1,067,780.9	0.00	1.00
03/24/2021 13:00	0	1.5	9.5	14.4	15.1	941,531.9	0.00	1.00
03/24/2021 14:00	1	2.3	13.9	12.4	35.4	1,063,478.9	0.00	1.00
03/24/2021 15:00	0	2.3	14.8	14.5	17.5	669,948.1	0.07	1.00
03/24/2021 16:00	0	18.2	39.6	16.8	0.0	473,286.4	0.07	0.07
03/24/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	6.9	17.6	14.5	18.7	853,974.9	0.99 #	7.34 #
Minimum:	0	1.5	9.5	12.1	0.0	473,286.4	0.00	0.00
Maximum:	1	25.7	39.6	18.0	38.8	1,084,335.1	0.58	1.00
%SI	70.83	62.50	62.50	62.50	62.50	62.50	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/25/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2021 06:00	0	23.6	29.0	17.9	0.0	744,510.4	0.25	0.25
03/25/2021 07:00	0	4.6	10.4	14.2	12.4	897,688.3	0.43	1.00
03/25/2021 08:00	0	1.9	9.1	14.2	14.4	895,848.8	0.00	1.00
03/25/2021 09:00	1	2.0	11.9	14.2	19.2	738,262.8	0.00	1.00
03/25/2021 10:00	0	1.9	11.4	14.2	17.1	760,950.3	0.00	1.00
03/25/2021 11:00	0	10.2	24.5	15.2	3.4	638,824.5	0.15	0.20
03/25/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	7.4	16.1	15.0	11.1	779,347.5	0.83 #	4.45 #
Minimum:	0	1.9	9.1	14.2	0.0	638,824.5	0.00	0.00
Maximum:	1	23.6	29.0	17.9	19.2	897,688.3	0.43	1.00
%SI	79.17	75.00	75.00	75.00	75.00	75.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/26/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/27/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/28/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/29/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/30/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2021 14:46 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/31/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

AQ-55

AQ-55 The emissions rates from each gas turbine and heat recovery steam generator exhaust during startup and shutdown shall not exceed the following:

Turbine emissions limitations during Startup and Shutdown		
Pollutant	Max Lbs/ Hr (worst case turbine)	Pounds per Startup or Shutdown (both turbines combined)
NO_x	37.1	122.8
CO	89.5	204.8

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

Monthly Summary By Day Report

Units CT1 and CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 11:33 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
01/01/2021	0.00	0.00	0.00	0.00	0.00
01/02/2021	0.00	0.00	0.00	0.00	0.00
01/03/2021	0.00	0.00	0.00	0.00	0.00
01/04/2021	0.00	0.00	0.00	0.00	0.00
01/05/2021	0.00	0.00	0.00	0.00	0.00
01/06/2021	0.00	0.00	0.00	0.00	0.00
01/07/2021	0.00	0.00	0.00	0.00	0.00
01/08/2021	0.00	0.00	0.00	0.00	0.00
01/09/2021	0.00	0.00	0.00	0.00	0.00
01/10/2021	0.00	0.00	0.00	0.00	0.00
01/11/2021	0.00	0.00	0.00	0.00	0.00
01/12/2021	0.00	0.00	0.00	0.00	0.00
01/13/2021	0.00	0.00	0.00	0.00	0.00
01/14/2021	0.00	0.00	0.00	0.00	0.00
01/15/2021	0.00	0.00	0.00	0.00	0.00
01/16/2021	0.00	0.00	0.00	0.00	0.00
01/17/2021	0.00	0.00	0.00	0.00	0.00
01/18/2021	0.00	0.00	0.00	0.00	0.00
01/19/2021	0.00	0.00	0.00	0.00	0.00
01/20/2021	0.00	0.00	0.00	0.00	0.00
01/21/2021	0.00	0.00	0.00	0.00	0.00
01/22/2021	0.00	0.00	0.00	0.00	0.00
01/23/2021	41.43	6.45	0.02	0.05	0.08
01/24/2021	17.66	62.48	5.62	11.22	18.69
01/25/2021	15.90	74.08	7.10	14.24	23.74
01/26/2021	0.01	0.04	0.00	0.01	0.01
01/27/2021	0.00	0.00	0.00	0.00	0.00
01/28/2021	0.00	0.00	0.00	0.00	0.00
01/29/2021	0.00	0.00	0.00	0.00	0.00
01/30/2021	0.00	0.00	0.00	0.00	0.00
01/31/2021	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	75.00 *	143.05 *	12.74 *	25.52 *	42.52 *
Daily Min:	0.01	0.04	0.00	0.01	0.01
Daily Max:	41.43	74.08	7.10	14.24	23.74
Jan 2021 - Jan 2021	75.00	143.05	12.74	25.52	42.52
QTD:	75.00 *	143.05 *	12.74 *	25.52 *	42.52 *
YTD 2021:	75.00 *	143.05 *	12.74 *	25.52 *	42.52 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 11:33 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
02/01/2021	0.00	0.00	0.00	0.00	0.00
02/02/2021	0.00	0.00	0.00	0.00	0.00
02/03/2021	0.00	0.00	0.00	0.00	0.00
02/04/2021	0.00	0.00	0.00	0.00	0.00
02/05/2021	0.00	0.00	0.00	0.00	0.00
02/06/2021	0.00	0.00	0.00	0.00	0.00
02/07/2021	0.00	0.00	0.00	0.00	0.00
02/08/2021	0.00	0.00	0.00	0.00	0.00
02/09/2021	0.00	0.00	0.00	0.00	0.00
02/10/2021	0.00	0.00	0.00	0.00	0.00
02/11/2021	0.00	0.00	0.00	0.00	0.00
02/12/2021	0.00	0.00	0.00	0.00	0.00
02/13/2021	0.00	0.00	0.00	0.00	0.00
02/14/2021	0.00	0.00	0.00	0.00	0.00
02/15/2021	0.00	0.00	0.00	0.00	0.00
02/16/2021	0.00	0.00	0.00	0.00	0.00
02/17/2021	0.00	0.00	0.00	0.00	0.00
02/18/2021	0.00	0.00	0.00	0.00	0.00
02/19/2021	0.00	0.00	0.00	0.00	0.00
02/20/2021	0.00	0.00	0.00	0.00	0.00
02/21/2021	0.00	0.00	0.00	0.00	0.00
02/22/2021	0.00	0.00	0.00	0.00	0.00
02/23/2021	0.00	0.00	0.00	0.00	0.00
02/24/2021	0.00	0.00	0.00	0.00	0.00
02/25/2021	0.00	0.00	0.00	0.00	0.00
02/26/2021	290.84	37.94	1.60	3.19	5.32
02/27/2021	84.73	37.27	2.23	4.44	7.39
02/28/2021	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	375.57 *	75.21 *	3.83 *	7.63 *	12.71 *
Daily Min:	84.73	37.27	1.60	3.19	5.32
Daily Max:	290.84	37.94	2.23	4.44	7.39
Jan 2021 - Feb 2021	450.57	218.26	16.57	33.15	55.23
QTD:	450.57 *	218.26 *	16.57 *	33.15 *	55.23 *
YTD 2021:	450.57 *	218.26 *	16.57 *	33.15 *	55.23 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 11:33 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
03/01/2021	50.79	49.99	2.31	4.66	7.77
03/02/2021	0.00	0.00	0.00	0.00	0.00
03/03/2021	0.00	0.00	0.00	0.00	0.00
03/04/2021	0.00	0.00	0.00	0.00	0.00
03/05/2021	0.00	0.00	0.00	0.00	0.00
03/06/2021	58.31	48.94	2.12	4.26	7.11
03/07/2021	0.00	0.00	0.00	0.00	0.00
03/08/2021	183.31	28.21	1.41	2.89	4.79
03/09/2021	0.00	0.00	0.00	0.00	0.00
03/10/2021	68.19	49.28	1.75	3.48	5.82
03/11/2021	0.00	0.00	0.00	0.00	0.00
03/12/2021	101.50	22.06	0.11	0.23	0.39
03/13/2021	71.12	60.52	6.05	12.12	20.23
03/14/2021	0.00	0.00	0.00	0.00	0.00
03/15/2021	0.00	0.00	0.00	0.00	0.00
03/16/2021	0.00	0.00	0.00	0.00	0.00
03/17/2021	0.00	0.00	0.00	0.00	0.00
03/18/2021	0.00	0.00	0.00	0.00	0.00
03/19/2021	0.00	0.00	0.00	0.00	0.00
03/20/2021	0.00	0.00	0.00	0.00	0.00
03/21/2021	0.00	0.00	0.00	0.00	0.00
03/22/2021	106.86	59.21	4.38	8.75	14.58
03/23/2021	89.72	82.48	6.76	13.47	22.47
03/24/2021	83.72	62.22	4.73	9.53	15.84
03/25/2021	63.73	22.92	1.01	2.05	3.41
03/26/2021	0.00	0.00	0.00	0.00	0.00
03/27/2021	0.00	0.00	0.00	0.00	0.00
03/28/2021	0.00	0.00	0.00	0.00	0.00
03/29/2021	0.00	0.00	0.00	0.00	0.00
03/30/2021	0.00	0.00	0.00	0.00	0.00
03/31/2021	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	877.25 *	485.83 *	30.63 *	61.44 *	102.41 *
Daily Min:	50.79	22.06	0.11	0.23	0.39
Daily Max:	183.31	82.48	6.76	13.47	22.47
Jan 2021 - Mar 2021	1,327.82	704.09	47.20	94.59	157.64
QTD:	1,327.82 *	704.09 *	47.20 *	94.59 *	157.64 *
YTD 2021:	1,327.82 *	704.09 *	47.20 *	94.59 *	157.64 *

Monthly Summary By Day Report



From: 01/01/2021 00:00 **To:** 03/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2021 11:32 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr	Unit CT1 NOX_SUSD, LbPerHr	Unit CT2 CO_SUSD, LbPerHr	Unit CT2 NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/01/2021	0.0	0.0	0.0	0.0
01/02/2021	0.0	0.0	0.0	0.0
01/03/2021	0.0	0.0	0.0	0.0
01/04/2021	0.0	0.0	0.0	0.0
01/05/2021	0.0	0.0	0.0	0.0
01/06/2021	0.0	0.0	0.0	0.0
01/07/2021	0.0	0.0	0.0	0.0
01/08/2021	0.0	0.0	0.0	0.0
01/09/2021	0.0	0.0	0.0	0.0
01/10/2021	0.0	0.0	0.0	0.0
01/11/2021	0.0	0.0	0.0	0.0
01/12/2021	0.0	0.0	0.0	0.0
01/13/2021	0.0	0.0	0.0	0.0
01/14/2021	0.0	0.0	0.0	0.0
01/15/2021	0.0	0.0	0.0	0.0
01/16/2021	0.0	0.0	0.0	0.0
01/17/2021	0.0	0.0	0.0	0.0
01/18/2021	0.0	0.0	0.0	0.0
01/19/2021	0.0	0.0	0.0	0.0
01/20/2021	0.0	0.0	0.0	0.0
01/21/2021	0.0	0.0	0.0	0.0
01/22/2021	0.0	0.0	0.0	0.0
01/23/2021	39.9	6.4	0.0	0.0
01/24/2021	0.6	5.5	0.0	0.0
01/25/2021	0.0	0.1	0.0	0.0
01/26/2021	0.0	0.0	0.0	0.0
01/27/2021	0.0	0.0	0.0	0.0
01/28/2021	0.0	0.0	0.0	0.0
01/29/2021	0.0	0.0	0.0	0.0
01/30/2021	0.0	0.0	0.0	0.0
01/31/2021	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	40.5 *	12.0 *	- *	- *
Daily Min:	0.0	0.0	-	-
Daily Max:	39.9	6.4	-	-
Jan 2021 - Jan 2021	40.5	12.0	-	-
QTD:	40.5 *	12.0 *	0.0 *	0.0 *
YTD 2021:	40.5 *	12.0 *	0.0 *	0.0 *

Monthly Summary By Day Report



From: 01/01/2021 00:00 **To:** 03/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2021 11:32 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr	Unit CT1 NOX_SUSD, LbPerHr	Unit CT2 CO_SUSD, LbPerHr	Unit CT2 NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/01/2021	0.0	0.0	0.0	0.0
02/02/2021	0.0	0.0	0.0	0.0
02/03/2021	0.0	0.0	0.0	0.0
02/04/2021	0.0	0.0	0.0	0.0
02/05/2021	0.0	0.0	0.0	0.0
02/06/2021	0.0	0.0	0.0	0.0
02/07/2021	0.0	0.0	0.0	0.0
02/08/2021	0.0	0.0	0.0	0.0
02/09/2021	0.0	0.0	0.0	0.0
02/10/2021	0.0	0.0	0.0	0.0
02/11/2021	0.0	0.0	0.0	0.0
02/12/2021	0.0	0.0	0.0	0.0
02/13/2021	0.0	0.0	0.0	0.0
02/14/2021	0.0	0.0	0.0	0.0
02/15/2021	0.0	0.0	0.0	0.0
02/16/2021	0.0	0.0	0.0	0.0
02/17/2021	0.0	0.0	0.0	0.0
02/18/2021	0.0	0.0	0.0	0.0
02/19/2021	0.0	0.0	0.0	0.0
02/20/2021	0.0	0.0	0.0	0.0
02/21/2021	0.0	0.0	0.0	0.0
02/22/2021	0.0	0.0	0.0	0.0
02/23/2021	0.0	0.0	0.0	0.0
02/24/2021	0.0	0.0	0.0	0.0
02/25/2021	0.0	0.0	0.0	0.0
02/26/2021	0.0	0.0	277.5	22.9
02/27/2021	0.0	0.0	74.9	15.8
02/28/2021	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	- *	- *	352.4 *	38.7 *
Daily Min:	-	-	74.9	15.8
Daily Max:	-	-	277.5	22.9
Jan 2021 - Feb 2021	40.5	12.0	352.4	38.7
QTD:	40.5 *	12.0 *	352.4 *	38.7 *
YTD 2021:	40.5 *	12.0 *	352.4 *	38.7 *

Monthly Summary By Day Report



From: 01/01/2021 00:00 **To:** 03/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2021 11:32 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr	Unit CT1 NOX_SUSD, LbPerHr	Unit CT2 CO_SUSD, LbPerHr	Unit CT2 NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/01/2021	0.0	0.0	40.6	23.9
03/02/2021	0.0	0.0	0.0	0.0
03/03/2021	0.0	0.0	0.0	0.0
03/04/2021	0.0	0.0	0.0	0.0
03/05/2021	0.0	0.0	0.0	0.0
03/06/2021	0.0	0.0	46.5	27.2
03/07/2021	0.0	0.0	0.0	0.0
03/08/2021	150.0	16.3	0.0	0.0
03/09/2021	0.0	0.0	0.0	0.0
03/10/2021	60.1	33.3	0.0	0.0
03/11/2021	0.0	0.0	0.0	0.0
03/12/2021	68.6	18.4	14.8	0.6
03/13/2021	16.9	1.2	14.2	1.6
03/14/2021	0.0	0.0	0.0	0.0
03/15/2021	0.0	0.0	0.0	0.0
03/16/2021	0.0	0.0	0.0	0.0
03/17/2021	0.0	0.0	0.0	0.0
03/18/2021	0.0	0.0	0.0	0.0
03/19/2021	0.0	0.0	0.0	0.0
03/20/2021	0.0	0.0	0.0	0.0
03/21/2021	0.0	0.0	0.0	0.0
03/22/2021	0.0	0.0	89.5	21.6
03/23/2021	58.1	15.0	15.6	1.6
03/24/2021	25.9	1.4	56.7	15.5
03/25/2021	0.0	0.0	55.1	13.5
03/26/2021	0.0	0.0	0.0	0.0
03/27/2021	0.0	0.0	0.0	0.0
03/28/2021	0.0	0.0	0.0	0.0
03/29/2021	0.0	0.0	0.0	0.0
03/30/2021	0.0	0.0	0.0	0.0
03/31/2021	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	379.6 *	85.6 *	333.0 *	105.5 *
Daily Min:	16.9	1.2	14.2	0.6
Daily Max:	150.0	33.3	89.5	27.2
Jan 2021 - Mar 2021	420.1	97.6	685.4	144.2
QTD:	420.1 *	97.6 *	685.4 *	144.2 *
YTD 2021:	420.1 *	97.6 *	685.4 *	144.2 *

Startup / Shutdown Events

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 11:28 Location: Roseville, CA

Unit offline

Tag Name: CT1_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
01/01/2021 00:00	01/23/2021 22:00	551
01/26/2021 01:00	03/08/2021 08:00	992
03/08/2021 11:00	03/08/2021 12:00	2
03/08/2021 21:00	03/10/2021 10:00	38
03/10/2021 20:00	03/12/2021 11:00	40
03/12/2021 15:00	03/13/2021 06:00	16
03/13/2021 19:00	03/23/2021 08:00	230
03/24/2021 13:00	03/31/2021 23:00	179

Startup / Shutdown Events

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 11:28 Location: Roseville, CA

Operating Time Summary

Available Data for Report (excludes missing data):	2,160.00 Hour(s)
Total Offline:	2,048.00 Hour(s)
Offline Percentage:	94.81 %
Total Online:	112.00 Hour(s)
Online Percentage:	5.19 %

Startup / Shutdown Events

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 11:28 Location: Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	01/23/2021 23:44	01/24/2021 00:39	Cold Startup	56
2	01/25/2021 23:58	01/26/2021 00:00	Shutdown	3
3	03/08/2021 09:53	03/08/2021 09:58	Cold Startup	6
4	03/08/2021 09:58	03/08/2021 09:58	Shutdown	1
5	03/08/2021 10:29	03/08/2021 10:45	Cold Startup	17
6	03/08/2021 10:45	03/08/2021 10:45	Shutdown	1
7	03/08/2021 10:56	03/08/2021 10:56	Cold Startup	1
8	03/08/2021 10:56	03/08/2021 10:56	Shutdown	1
9	03/08/2021 13:44	03/08/2021 13:49	Cold Startup	6
10	03/08/2021 13:49	03/08/2021 13:49	Shutdown	1
11	03/08/2021 14:44	03/08/2021 15:38	Cold Startup	55
12	03/08/2021 20:01	03/08/2021 20:09	Shutdown	9
13	03/10/2021 11:42	03/10/2021 13:34	Cold Startup	113
14	03/10/2021 19:04	03/10/2021 19:12	Shutdown	9
15	03/12/2021 12:37	03/12/2021 12:40	Cold Startup	4
16	03/12/2021 12:40	03/12/2021 12:40	Shutdown	1
17	03/12/2021 13:03	03/12/2021 13:06	Cold Startup	4
18	03/12/2021 13:06	03/12/2021 13:06	Shutdown	1
19	03/12/2021 13:53	03/12/2021 14:42	Cold Startup	50
20	03/12/2021 14:36	03/12/2021 14:42	Shutdown	7
21	03/13/2021 07:44	03/13/2021 07:47	Cold Startup	4
22	03/13/2021 07:47	03/13/2021 07:47	Shutdown	1

Startup / Shutdown Events

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 11:28 Location: Roseville, CA

Number	Start Time	End Time	Event Type	Duration
23	03/13/2021 08:07	03/13/2021 08:10	Cold Startup	4
24	03/13/2021 08:10	03/13/2021 08:10	Shutdown	1
25	03/13/2021 08:31	03/13/2021 10:33	Cold Startup	123
26	03/13/2021 18:01	03/13/2021 18:10	Shutdown	10
27	03/23/2021 09:29	03/23/2021 09:35	Cold Startup	7
28	03/23/2021 09:35	03/23/2021 09:35	Shutdown	1
29	03/23/2021 10:25	03/23/2021 11:27	Cold Startup	63
30	03/24/2021 11:54	03/24/2021 12:01	Shutdown	8

Startup / Shutdown Events

CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 11:28 Location: Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	15	513	8.70
Warm Startup	0		0.00
Shutdown	15	55	0.93
Total Process Events:	30	568	9.64

Total Report Time:	2,159.98 Hour(s)
Total Operating Time:	98.23 Hour(s)
Total Startup Time:	513 Minute(s)
Total Shutdown Time:	55 Minute(s)
Total Startup/Shutdown Time:	568 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	9.64 %

Startup / Shutdown Events

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 11:31 Location: Roseville, CA

Unit offline

Tag Name: CT2_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
01/01/2021 00:00	02/26/2021 07:00	1352
02/26/2021 15:00	02/27/2021 08:00	18
02/27/2021 19:00	03/01/2021 06:00	36
03/01/2021 18:00	03/06/2021 07:00	110
03/06/2021 18:00	03/12/2021 13:00	140
03/12/2021 16:00	03/12/2021 16:00	1
03/12/2021 18:00	03/13/2021 10:00	17
03/13/2021 23:00	03/22/2021 04:00	198
03/23/2021 15:00	03/24/2021 07:00	17
03/24/2021 17:00	03/25/2021 05:00	13
03/25/2021 12:00	03/31/2021 23:00	156

Startup / Shutdown Events

CT2



From: 01/01/2021 00:00 **To:** 03/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2021 11:31 **Location:** Roseville, CA

Operating Time Summary

Available Data for Report (excludes missing data):	2,160.00 Hour(s)
Total Offline:	2,058.00 Hour(s)
Offline Percentage:	95.28 %
Total Online:	102.00 Hour(s)
Online Percentage:	4.72 %

Startup / Shutdown Events

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 11:31 Location: Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	02/26/2021 08:17	02/26/2021 09:19	Cold Startup	63
2	02/26/2021 14:11	02/26/2021 14:20	Shutdown	10
3	02/27/2021 09:43	02/27/2021 10:30	Cold Startup	48
4	02/27/2021 17:52	02/27/2021 18:00	Shutdown	9
5	03/01/2021 07:45	03/01/2021 08:34	Cold Startup	50
6	03/01/2021 16:53	03/01/2021 17:02	Shutdown	10
7	03/06/2021 08:05	03/06/2021 09:08	Cold Startup	64
8	03/06/2021 16:57	03/06/2021 17:07	Shutdown	11
9	03/12/2021 14:58	03/12/2021 15:01	Cold Startup	4
10	03/12/2021 15:01	03/12/2021 15:01	Shutdown	1
11	03/12/2021 15:26	03/12/2021 15:29	Cold Startup	4
12	03/12/2021 15:29	03/12/2021 15:29	Shutdown	1
13	03/12/2021 15:51	03/12/2021 15:56	Cold Startup	6
14	03/12/2021 15:56	03/12/2021 15:56	Shutdown	1
15	03/12/2021 17:11	03/12/2021 17:16	Cold Startup	6
16	03/12/2021 17:16	03/12/2021 17:16	Shutdown	1
17	03/13/2021 11:44	03/13/2021 12:45	Cold Startup	62
18	03/13/2021 22:00	03/13/2021 22:09	Shutdown	10
19	03/22/2021 05:39	03/22/2021 06:40	Cold Startup	62
20	03/22/2021 07:51	03/22/2021 07:51	Shutdown	1
21	03/22/2021 08:08	03/22/2021 08:29	Warm Startup	22
22	03/23/2021 13:57	03/23/2021 14:07	Shutdown	11

Startup / Shutdown Events

CT2



From: 01/01/2021 00:00 **To:** 03/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2021 11:31 **Location:** Roseville, CA

Number	Start Time	End Time	Event Type	Duration
23	03/24/2021 08:44	03/24/2021 09:34	Cold Startup	51
24	03/24/2021 15:56	03/24/2021 16:03	Shutdown	8
25	03/25/2021 06:45	03/25/2021 07:25	Cold Startup	41
26	03/25/2021 11:03	03/25/2021 11:11	Shutdown	9

Startup / Shutdown Events

CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 11:31 Location: Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	12	461	8.78
Warm Startup	1	22	0.42
Shutdown	13	83	1.58
Total Process Events:	26	566	10.79

Total Report Time:	2,159.98 Hour(s)
Total Operating Time:	87.47 Hour(s)
Total Startup Time:	483 Minute(s)
Total Shutdown Time:	83 Minute(s)
Total Startup/Shutdown Time:	566 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	10.79 %

CT1 SUSD EVENT 1

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/23/21 23:39	0			0			0			0			0			0		
01/23/21 23:40	0			0			0			0			0			0		
01/23/21 23:41	0			0			0			0			0			0		
01/23/21 23:42	0			0			0			0			0			0		
01/23/21 23:43	0			0			0			0			0			0		
01/23/21 23:44	0			0.3			0			0			0			1		
01/23/21 23:45	0			0.3			0			0			0			1		
01/23/21 23:46	0			129.8			23.6			0			0			1		
01/23/21 23:47	18483.8			619.1			12.98			26.75			0.92			1		
01/23/21 23:48	47826.9			501.2			16.77			55.87			3.08			1		
01/23/21 23:49	92034.1			336			23.6			72.13			8.34			1		
01/23/21 23:50	133930.8			189.8			24.88			59.32			12.8			1		
01/23/21 23:51	136934.4			73.2			52.31			23.37			27.5			1		
01/23/21 23:52	148178.7			1357.6			40.75			469.2			23.18			1		
01/23/21 23:53	165661.4			1922			37.55			742.57			23.87			1		
01/23/21 23:54	188304			1607.7			42.1			706.07			30.43			1		
01/23/21 23:55	213565.3			414.8			50.71			206.61			41.57			1		
01/23/21 23:56	235514.8			44.3			55.23			24.34			49.93			1		
01/23/21 23:57	260160			3.8			54.77			2.3			54.7			1		
01/23/21 23:58	285652.3			2.3			54.93			1.56			60.22			1		
01/23/21 23:59	307832.8			2.1			41.02			1.52			48.48			1		
01/24/21 0:00	315919.5			2.1			23.86			1.58			28.93			1		
01/24/21 0:01	330783.6			2.2			15.93			1.69			20.23			1		
01/24/21 0:02	347496.1			2.1			14.08			1.71			18.78			1		
01/24/21 0:03	363823.4			2			10.86			1.67			15.17			1		
01/24/21 0:04	378225.4			1.8			8.28			1.55			12.02			1		
01/24/21 0:05	384540.8			1.5			7.15			1.36			10.56			1		
01/24/21 0:06	399558.9			1.3			6.69			1.23			10.26			1		
01/24/21 0:07	419506			1.3			5.81			1.22			9.36			1		
01/24/21 0:08	430365.3			1.1			5.36			1.09			8.85			1		
01/24/21 0:09	437835.8			1			5.26			1.02			8.85			1		
01/24/21 0:10	439838.2			0.9			5.26			0.93			8.89			1		
01/24/21 0:11	439915.2			0.9			5.17			0.93			8.74			1		
01/24/21 0:12	439607.2			0.9			5.17			0.93			8.73			1		
01/24/21 0:13	439222.1			0.8			5.08			0.84			8.57			1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSDTF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/24/21 0:14	438451.9			0.8			5.16			0.85			8.69			1		
01/24/21 0:15	437835.8			0.8			5.07			0.85			8.52			1		
01/24/21 0:16	436834.6			0.7			5.07			0.75			8.5			1		
01/24/21 0:17	436064.4			0.7			4.98			0.75			8.33			1		
01/24/21 0:18	435756.4			0.7			4.98			0.75			8.33			1		
01/24/21 0:19	435448.3			0.7			5.07			0.75			8.47			1		
01/24/21 0:20	435217.3			0.7			5.16			0.75			8.62			1		
01/24/21 0:21	434986.2			0.7			5.35			0.75			8.93			1		
01/24/21 0:22	434909.2			0.7			5.44			0.75			9.08			1		
01/24/21 0:23	434524.1			0.7			5.53			0.75			9.23			1		
01/24/21 0:24	433985			0.7			5.16			0.75			8.6			1		
01/24/21 0:25	433522.9			0.7			3.32			0.75			5.52			1		
01/24/21 0:26	433754			0.7			2.67			0.75			4.45			1		
01/24/21 0:27	433676.9			0.7			2.49			0.75			4.14			1		
01/24/21 0:28	432906.8			0.7			2.49			0.74			4.14			1		
01/24/21 0:29	432675.7			0.7			2.58			0.74			4.29			1		
01/24/21 0:30	431982.6			0.7			2.58			0.74			4.28			1		
01/24/21 0:31	432444.7			0.7			2.54			0.73			4.22			1		
01/24/21 0:32	432213.6			0.7			2.54			0.73			4.22			1		
01/24/21 0:33	432213.6			0.7			2.36			0.73			3.92			1		
01/24/21 0:34	431905.6			0.7			2.27			0.73			3.76			1		
01/24/21 0:35	431828.6			0.7			2.09			0.73			3.46			1		
01/24/21 0:36	431751.5			0.7			2			0.73			3.31			1		
01/24/21 0:37	431212.4			0.7			1.91			0.73			3.16			1		
01/24/21 0:38	431366.5			0.7			1.82			0.73			3.01			1		
01/24/21 0:39	431520.5			0.7			1.82			0.73			3.01			1		
01/24/21 0:40	431443.5			0.7			1.72			0.73			2.86			0		
01/24/21 0:41	430981.4			0.7			1.72			0.73			2.85			0		
01/24/21 0:42	431366.5			0.7			1.72			0.73			2.86			0		
01/24/21 0:43	431135.4			0.7			1.72			0.73			2.85			0		
01/24/21 0:44	431212.4			0.7			1.63			0.73			2.7			0		

CT1 SUSD EVENT 2

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/25/21 23:53	386389.1			0.7			1.72			0.65			2.56			0		
01/25/21 23:54	382538.3			0.7			1.72			0.65			2.53			0		
01/25/21 23:55	364747.7			0.8			1.7			0.68			2.38			0		
01/25/21 23:56	342413			0.8			1.76			0.63			2.31			0		
01/25/21 23:57	321233.6			0.9			1.82			0.65			2.25			0		
01/25/21 23:58	301286.5			0.9			1.82			0.61			2.11			1		
01/25/21 23:59	278643.8			0.9			1.76			0.57			1.88			1		
01/26/21 0:00	211408.8			0.8			2.41			0.4			1.96			1		
01/26/21 0:01	0			0			6.29			0			0			0		
01/26/21 0:02	0			0			13.77			0			0			0		
01/26/21 0:03	0			0			5.9			0			0			0		
01/26/21 0:04	0			0			0.1			0			0			0		
01/26/21 0:05	0			0			0.1			0			0			0		

CT1 SUSD EVENT 3

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/08/21 9:48	0			0			0			0			0			0		
03/08/21 9:49	0			0			0			0			0			0		
03/08/21 9:50	0			0			0			0			0			0		
03/08/21 9:51	0			0			0			0			0			0		
03/08/21 9:52	2926.6			0			0			0			0			0		
03/08/21 9:53	21333.4			0.3			0			0			0			1		
03/08/21 9:54	32192.7			0.3			0			0			0			1		
03/08/21 9:55	47441.8			46.2			9.83			5.11			1.79			1		
03/08/21 9:56	58994.2			657.4			9.94			90.35			2.25			1		
03/08/21 9:57	71239.8			196.1			16.76			32.57			4.58			1		
03/08/21 9:58	48212			46.1			17.34			5.18			3.21			1		
03/08/21 9:59	0			0			35.11			0			0			0		
03/08/21 10:00	2079.4			0			51.33			0.08			0.42			0		
03/08/21 10:01	0			0			60.97			0			0			0		
03/08/21 10:02	1001.2			0			1.9			0			0			0		
03/08/21 10:03	1078.2			0			1.8			0			0			0		

CT1 SUSD EVENT 4

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/08/21 9:48	0			0			0			0			0			0		
03/08/21 9:49	0			0			0			0			0			0		
03/08/21 9:50	0			0			0			0			0			0		
03/08/21 9:51	0			0			0			0			0			0		
03/08/21 9:52	2926.6			0			0			0			0			0		
03/08/21 9:53	21333.4			0.3			0			0			0			1		
03/08/21 9:54	32192.7			0.3			0			0			0			1		
03/08/21 9:55	47441.8			46.2			9.83			5.11			1.79			1		
03/08/21 9:56	58994.2			657.4			9.94			90.35			2.25			1		
03/08/21 9:57	71239.8			196.1			16.76			32.57			4.58			1		
03/08/21 9:58	48212			46.1			17.34			5.18			3.21			1		
03/08/21 9:59	0			0			35.11			0			0			0		
03/08/21 10:00	2079.4			0			51.33			0.08			0.42			0		
03/08/21 10:01	0			0			60.97			0			0			0		
03/08/21 10:02	1001.2			0			1.9			0			0			0		
03/08/21 10:03	1078.2			0			1.8			0			0			0		

CT1 SUSD EVENT 5

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/08/21 10:24	11783.4			0			0.4			0			0			0		
03/08/21 10:25	10320.1			0			0.3			0			0			0		
03/08/21 10:26	12399.6			0			0.2			0			0			0		
03/08/21 10:27	12784.7			0			0.2			0			0			0		
03/08/21 10:28	11860.5			0			0.2			0			0			0		
03/08/21 10:29	23412.9			0.4			0.2			0			0			1		
03/08/21 10:30	27879.8			0.4			0.2			0			0			1		
03/08/21 10:31	39201.1			59			29.5			5.39			4.43			1		
03/08/21 10:32	51061.6			1134.5			13.49			135.1			2.64			1		
03/08/21 10:33	62768			897.5			19.09			131.39			4.6			1		
03/08/21 10:34	85872.8			543.7			22.72			108.8			7.48			1		
03/08/21 10:35	130311			387.8			24.94			117.8			12.47			1		
03/08/21 10:36	142479.5			253			42.66			84.05			23.32			1		
03/08/21 10:37	139861			719.2			48.53			234.57			26.05			1		
03/08/21 10:38	138551.7			2063.8			45.23			666.63			24.05			1		
03/08/21 10:39	137165.5			2134.8			51.68			682.87			27.2			1		
03/08/21 10:40	136472.3			2135			56.56			679.11			29.61			1		
03/08/21 10:41	136164.2			2210.8			59.84			701.74			31.26			1		
03/08/21 10:42	135163			169.1	X		66.47	X		53.31	X		34.48	X		1		
03/08/21 10:43	135240			97.6	X		56.28	X		30.78	X		29.21	X		1		
03/08/21 10:44	134315.9			97.6	X		62.86	X		30.56	X		32.4	X		1		
03/08/21 10:45	101584.1			90.6	X		58.16	X		21.46	X		22.67	X		1		
03/08/21 10:46	13092.7			0	X		57.03	X		2.86	X		2.86	X		0		
03/08/21 10:47	13015.7			0	X		283.2	X		77.23	X		14.19	X		0		
03/08/21 10:48	12091.5			0			4.2			0			0			0		
03/08/21 10:49	12861.7			0			4.1			0			0			0		
03/08/21 10:50	12553.6			0			3.3			0			0			0		

CT1 SUSD EVENT 6

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/08/21 10:24	11783.4			0			0.4			0			0			0		
03/08/21 10:25	10320.1			0			0.3			0			0			0		
03/08/21 10:26	12399.6			0			0.2			0			0			0		
03/08/21 10:27	12784.7			0			0.2			0			0			0		
03/08/21 10:28	11860.5			0			0.2			0			0			0		
03/08/21 10:29	23412.9			0.4			0.2			0			0			1		
03/08/21 10:30	27879.8			0.4			0.2			0			0			1		
03/08/21 10:31	39201.1			59			29.5			5.39			4.43			1		
03/08/21 10:32	51061.6			1134.5			13.49			135.1			2.64			1		
03/08/21 10:33	62768			897.5			19.09			131.39			4.6			1		
03/08/21 10:34	85872.8			543.7			22.72			108.8			7.48			1		
03/08/21 10:35	130311			387.8			24.94			117.8			12.47			1		
03/08/21 10:36	142479.5			253			42.66			84.05			23.32			1		
03/08/21 10:37	139861			719.2			48.53			234.57			26.05			1		
03/08/21 10:38	138551.7			2063.8			45.23			666.63			24.05			1		
03/08/21 10:39	137165.5			2134.8			51.68			682.87			27.2			1		
03/08/21 10:40	136472.3			2135			56.56			679.11			29.61			1		
03/08/21 10:41	136164.2			2210.8			59.84			701.74			31.26			1		
03/08/21 10:42	135163			169.1	X		66.47	X		53.31	X		34.48	X		1		
03/08/21 10:43	135240			97.6	X		56.28	X		30.78	X		29.21	X		1		
03/08/21 10:44	134315.9			97.6	X		62.86	X		30.56	X		32.4	X		1		
03/08/21 10:45	101584.1			90.6	X		58.16	X		21.46	X		22.67	X		1		
03/08/21 10:46	13092.7			0	X		57.03	X		2.86	X		2.86	X		0		
03/08/21 10:47	13015.7			0	X		283.2	X		77.23	X		14.19	X		0		
03/08/21 10:48	12091.5			0			4.2			0			0			0		
03/08/21 10:49	12861.7			0			4.1			0			0			0		
03/08/21 10:50	12553.6			0			3.3			0			0			0		

CT1 SUSD EVENT 7

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/08/21 10:51	12861.7			0			2.9			0			0			0		
03/08/21 10:52	12861.7			0			2.6			0			0			0		
03/08/21 10:53	14479			0			2.4			0			0			0		
03/08/21 10:54	13631.8			0			2.3			0			0			0		
03/08/21 10:55	14402			0			2			0			0			0		
03/08/21 10:56	15326.2			19.9			1.9			0			0			1		
03/08/21 10:57	14248			0			1.7			0			0			0		
03/08/21 10:58	11629.4			0			47.2			21.33			2.1			0		
03/08/21 10:59	13477.8			0			25.08			15.07			1.29			0		
03/08/21 11:00	15249.2			0			56.05			33.07			3.28			0		
03/08/21 11:01	14556			0			118			61.43			6.61			0		

CT1 SUSD EVENT 8

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/08/21 10:51	12861.7			0			2.9			0			0			0		
03/08/21 10:52	12861.7			0			2.6			0			0			0		
03/08/21 10:53	14479			0			2.4			0			0			0		
03/08/21 10:54	13631.8			0			2.3			0			0			0		
03/08/21 10:55	14402			0			2			0			0			0		
03/08/21 10:56	15326.2			19.9			1.9			0			0			1		
03/08/21 10:57	14248			0			1.7			0			0			0		
03/08/21 10:58	11629.4			0			47.2			21.33			2.1			0		
03/08/21 10:59	13477.8			0			25.08			15.07			1.29			0		
03/08/21 11:00	15249.2			0			56.05			33.07			3.28			0		
03/08/21 11:01	14556			0			118			61.43			6.61			0		

CT1 SUSD EVENT 9

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/08/21 13:39	22334.6			0			0.1			0			0			0		
03/08/21 13:40	21949.6			0			0.1			0			0			0		
03/08/21 13:41	22180.6			0			0.1			0			0			0		
03/08/21 13:42	22411.6			0			0.1			0			0			0		
03/08/21 13:43	23875			0			0.1			0			0			0		
03/08/21 13:44	32885.8			0.9			0.1			0			0			1		
03/08/21 13:45	39586.2			1.3			0.1			0			0			1		
03/08/21 13:46	46209.6			65.6			39.33			7.06			6.97			1		
03/08/21 13:47	56837.8			784.7			23.6			103.99			5.15			1		
03/08/21 13:48	70623.6			697.5			28.84			114.92			7.82			1		
03/08/21 13:49	61458.7			473.8			36.29			67.87			8.56			1		
03/08/21 13:50	21641.5			0			44.25			15.55			3.67			0		
03/08/21 13:51	21641.5			0			8.26			8.86			0.68			0		
03/08/21 13:52	21641.5			0			0.4			0			0			0		
03/08/21 13:53	21410.4			0			0.4			0			0			0		
03/08/21 13:54	21564.5			0			0.4			0			0			0		

CT1 SUSD EVENT 10

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/08/21 13:39	22334.6			0			0.1			0			0			0		
03/08/21 13:40	21949.6			0			0.1			0			0			0		
03/08/21 13:41	22180.6			0			0.1			0			0			0		
03/08/21 13:42	22411.6			0			0.1			0			0			0		
03/08/21 13:43	23875			0			0.1			0			0			0		
03/08/21 13:44	32885.8			0.9			0.1			0			0			1		
03/08/21 13:45	39586.2			1.3			0.1			0			0			1		
03/08/21 13:46	46209.6			65.6			39.33			7.06			6.97			1		
03/08/21 13:47	56837.8			784.7			23.6			103.99			5.15			1		
03/08/21 13:48	70623.6			697.5			28.84			114.92			7.82			1		
03/08/21 13:49	61458.7			473.8			36.29			67.87			8.56			1		
03/08/21 13:50	21641.5			0			44.25			15.55			3.67			0		
03/08/21 13:51	21641.5			0			8.26			8.86			0.68			0		
03/08/21 13:52	21641.5			0			0.4			0			0			0		
03/08/21 13:53	21410.4			0			0.4			0			0			0		
03/08/21 13:54	21564.5			0			0.4			0			0			0		

CT1 SUSD EVENT 11

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/08/21 14:39	20255.2			0			0.3			0			0			0		
03/08/21 14:40	20255.2			0			0.1			0			0			0		
03/08/21 14:41	20409.2			0			0.1			0			0			0		
03/08/21 14:42	20409.2			0			0.1			0			0			0		
03/08/21 14:43	20255.2			0			0.1			0			0			0		
03/08/21 14:44	26031.4			0.8			0.1			0			0			1		
03/08/21 14:45	28649.9			0.8			0.1			0			0			1		
03/08/21 14:46	37737.8			2			0.5			0			0			1		
03/08/21 14:47	48366			1025			25.75			115.64			4.78			1		
03/08/21 14:48	59995.4			921.1			24.64			128.86			5.67			1		
03/08/21 14:49	75629.7			602.4			29.19			106.26			8.47			1		
03/08/21 14:50	116371.1			422.6			37.09			114.64			16.56			1		
03/08/21 14:51	142325.5			262.7			52.16			87.14			28.48			1		
03/08/21 14:52	148871.9			284			63.72			98.53			36.39			1		
03/08/21 14:53	153184.8			1910.5			53.29			682.1			31.31			1		
03/08/21 14:54	167586.8			1939.4			52.73			757.57			33.9			1		
03/08/21 14:55	186917.8			1825.4			51.02			795.54			36.59			1		
03/08/21 14:56	208790.3			1013.7			49.62			493.56			39.76			1		
03/08/21 14:57	231664			170.2			49.88			91.91			44.34			1		
03/08/21 14:58	250070.9			17.8			49.13			10.39			47.13			1		
03/08/21 14:59	278027.7			5.8			45.12			3.75			48.14			1		
03/08/21 15:00	302287.7			5.1			34.32			3.6			39.8			1		
03/08/21 15:01	314379.2			5.1			21.6			3.73			26.06			1		
03/08/21 15:02	314841.3			5.3			11.03			3.89			13.32			1		
03/08/21 15:03	315226.4			5.6			10.09			4.15			12.2			1		
03/08/21 15:04	314764.3			5.6			9.06			4.14			10.95			1		
03/08/21 15:05	313840.1			5.3			8.42			3.87			10.14			1		
03/08/21 15:06	313917.1			4.8			7.38			3.49			8.88			1		
03/08/21 15:07	313994.1			4.2			6.85			3.05			8.26			1		
03/08/21 15:08	313224			3.8			6.07			2.79			7.3			1		
03/08/21 15:09	312453.8			3.6			5.55			2.59			6.66			1		
03/08/21 15:10	311991.7			3.4			5.2			2.5			6.22			1		
03/08/21 15:11	312068.7			3.3			5.02			2.37			6.01			1		
03/08/21 15:12	311914.7			3.2			4.84			2.31			5.8			1		
03/08/21 15:13	311760.7			3			4.58			2.18			5.48			1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSDTF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/08/21 15:14	311837.7			3			4.49			2.18			5.37			1		
03/08/21 15:15	311914.7			2.9			4.31			2.11			5.16			1		
03/08/21 15:16	311529.6			2.8			4.23			2.05			5.05			1		
03/08/21 15:17	311683.6			2.7			4.23			1.98			5.05			1		
03/08/21 15:18	311067.5			2.5			4.31			1.79			5.15			1		
03/08/21 15:19	310605.4			2.2			4.4			1.59			5.25			1		
03/08/21 15:20	310682.4			2.1			4.56			1.49			5.44			1		
03/08/21 15:21	310836.5			1.9			4.56			1.36			5.44			1		
03/08/21 15:22	310605.4			1.7			4.65			1.23			5.54			1		
03/08/21 15:23	311144.5			1.6			4.83			1.17			5.76			1		
03/08/21 15:24	310913.5			1.5			5.01			1.1			5.97			1		
03/08/21 15:25	310682.4			1.5			5.1			1.1			6.07			1		
03/08/21 15:26	310990.5			1.4			4.74			1.04			5.65			1		
03/08/21 15:27	309989.3			1.4			3.13			1.03			3.72			1		
03/08/21 15:28	309835.3			1.3			2.68			0.97			3.19			1		
03/08/21 15:29	309604.2			1.3			2.5			0.97			2.97			1		
03/08/21 15:30	310220.3			1.3			2.32			0.91			2.77			1		
03/08/21 15:31	310143.3			1.3			2.32			0.9			2.77			1		
03/08/21 15:32	309912.3			1.3			2.23			0.9			2.66			1		
03/08/21 15:33	309373.2			1.3			2.23			0.9			2.65			1		
03/08/21 15:34	309989.3			1.3			2.15			0.9			2.55			1		
03/08/21 15:35	309681.2			1.2			2.06			0.84			2.44			1		
03/08/21 15:36	309604.2			1.2			1.97			0.84			2.34			1		
03/08/21 15:37	309604.2			1.2			1.88			0.84			2.23			1		
03/08/21 15:38	309604.2			1.2			1.79			0.84			2.12			1		
03/08/21 15:39	309989.3			1.2			1.7			0.84			2.02			0		
03/08/21 15:40	309758.3			1.2			1.7			0.84			2.02			0		
03/08/21 15:41	309758.3			1.2			1.7			0.84			2.02			0		
03/08/21 15:42	310066.3			1.1			1.61			0.78			1.91			0		
03/08/21 15:43	309835.3			1.1			1.61			0.77			1.91			0		

CT1 SUSD EVENT 12

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/08/21 19:56	325546.5			1.1			2.11			0.83			2.63			0		
03/08/21 19:57	310066.3			1.2			1.54			0.87			1.83			0		
03/08/21 19:58	308217.9			1.1			1.41			0.82			1.67			0		
03/08/21 19:59	307755.8			1			1.23			0.69			1.46			0		
03/08/21 20:00	307832.8			0.9			1.25			0.64			1.48			0		
03/08/21 20:01	300593.3			0.9			1.25			0.63			1.44			1		
03/08/21 20:02	280107.1			0.9			1.79			0.58			1.92			1		
03/08/21 20:03	256001.1			0.9			4.54			0.54			4.46			1		
03/08/21 20:04	237363.2			0.8			7.83			0.43			7.13			1		
03/08/21 20:05	213026.2			0.6			13.52			0.32			11.05			1		
03/08/21 20:06	189690.3			3.2			16.43			1.43			11.96			1		
03/08/21 20:07	169281.1			121.7			19.27			48.02			12.52			1		
03/08/21 20:08	152106.5			887.8			19.47			314.79			11.36			1		
03/08/21 20:09	103971.6			1768.8			21.58			428.81			8.61			1		
03/08/21 20:10	18098.8			0			22.18			90.29			1.54			0		
03/08/21 20:11	18175.8			0			17.7			392.89			1.23			0		
03/08/21 20:12	17944.7			0			0.2			0			0			0		
03/08/21 20:13	17867.7			0			0.2			0			0			0		
03/08/21 20:14	18021.7			0			0.2			0			0			0		

CT1 SUSD EVENT 13

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/10/21 11:37	0			0			0			0			0			0		
03/10/21 11:38	1463.3			0			0			0			0			0		
03/10/21 11:39	0			0			0			0			0			0		
03/10/21 11:40	0			0			0			0			0			0		
03/10/21 11:41	19562.1			0			0			0			0			0		
03/10/21 11:42	25338.3			0.4			0			0			0			1		
03/10/21 11:43	30036.2			0.4			0			0			0			1		
03/10/21 11:44	42512.8			74.3			14.16			7.37			2.31			1		
03/10/21 11:45	53988.2			1121			11.06			141.02			2.29			1		
03/10/21 11:46	67466			826.3			16.39			130.03			4.24			1		
03/10/21 11:47	98272.4			536.6			21.24			122.88			8			1		
03/10/21 11:48	139475.9			370.9			23.09			120.64			12.36			1		
03/10/21 11:49	150951.3			223.6			43.83			78.67			25.38			1		
03/10/21 11:50	168588			1309.8			41.85			514.85			27.08			1		
03/10/21 11:51	188073			1854.2			45.12			813.08			32.56			1		
03/10/21 11:52	202783.1			1131.4			53.4			534.9			41.55			1		
03/10/21 11:53	204785.5			213.6			57.93			101.99			45.52			1		
03/10/21 11:54	204169.3			77.5			56.95			36.87			44.6			1		
03/10/21 11:55	204477.4			68.2			58.74			32.53			46.1			1		
03/10/21 11:56	203630.2			67.9			59.9			32.21			46.8			1		
03/10/21 11:57	207173			68.7			59.13			33.21			47.01			1		
03/10/21 11:58	229969.7			65.2			57.33			34.93			50.59			1		
03/10/21 11:59	238287.4			15.9			53.1			8.83			48.55			1		
03/10/21 12:00	239365.6			1.9			49.09			1.06			45.09			1		
03/10/21 12:01	238980.6			1.4			47.64			0.79			43.68			1		
03/10/21 12:02	238980.6			1.4			45.67			0.79			41.88			1		
03/10/21 12:03	238364.4			1.4			43.7			0.79			39.98			1		
03/10/21 12:04	237363.2			1.4			37.69			0.79			34.33			1		
03/10/21 12:05	237132.2			1.3			33.11			0.72			30.12			1		
03/10/21 12:06	237902.3			1.2			30.16			0.67			27.53			1		
03/10/21 12:07	237594.3			1.1			29.94			0.61			27.29			1		
03/10/21 12:08	238056.4			1			29.72			0.55			27.14			1		
03/10/21 12:09	240674.9			0.9			29.28			0.49			27.04			1		
03/10/21 12:10	240597.9			0.9			34.31			0.49			31.67			1		
03/10/21 12:11	248068.5			0.8			36.38			0.44			34.63			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/10/21 12:12	250301.9			0.9			36.15			0.5			34.72			1		
03/10/21 12:13	251380.1			0.8			35.19			0.49			33.94			1		
03/10/21 12:14	251919.3			0.8			35.09			0.49			33.92			1		
03/10/21 12:15	252381.3			0.8			34.88			0.49			33.78			1		
03/10/21 12:16	251842.2			0.7			34.78			0.43			33.61			1		
03/10/21 12:17	253151.5			0.8			33.74			0.49			32.78			1		
03/10/21 12:18	252843.4			0.8			28.78			0.49			27.91			1		
03/10/21 12:19	252304.3			0.8			27.53			0.49			26.66			1		
03/10/21 12:20	252227.3			0.8			27.53			0.49			26.65			1		
03/10/21 12:21	250687			0.8			27.84			0.48			26.78			1		
03/10/21 12:22	250378.9			0.8			29.6			0.48			28.44			1		
03/10/21 12:23	250378.9			0.8			32.61			0.48			31.33			1		
03/10/21 12:24	250687			0.7			33.02			0.42			31.76			1		
03/10/21 12:25	250610			0.7			33.74			0.42			32.45			1		
03/10/21 12:26	250841			0.6			34.78			0.36			33.47			1		
03/10/21 12:27	250764			0.6			35.61			0.36			34.26			1		
03/10/21 12:28	250841			0.6			36.44			0.36			35.06			1		
03/10/21 12:29	250610			0.6			37.16			0.36			35.73			1		
03/10/21 12:30	250995			0.5			37.47			0.3			36.08			1		
03/10/21 12:31	250764			0.5			21.84			0.3			21.02			1		
03/10/21 12:32	250764			0.5			13.77			0.3			13.25			1		
03/10/21 12:33	250841			0.5			14.49			0.3			13.94			1		
03/10/21 12:34	250764			0.5			14.8			0.3			14.24			1		
03/10/21 12:35	250455.9			0.5			14.91			0.3			14.33			1		
03/10/21 12:36	250224.9			0.5			14.8			0.3			14.21			1		
03/10/21 12:37	250301.9			0.5			14.49			0.3			13.92			1		
03/10/21 12:38	250301.9			0.5			14.18			0.3			13.62			1		
03/10/21 12:39	250224.9			0.5			13.77			0.3			13.22			1		
03/10/21 12:40	249916.8			0.5			13.56			0.3			13			1		
03/10/21 12:41	250301.9			0.5			13.35			0.3			12.82			1		
03/10/21 12:42	249762.8			0.5			13.04			0.3			12.5			1		
03/10/21 12:43	251688.2			0.5			12.21			0.3			11.79			1		
03/10/21 12:44	251380.1			0.5			9.63			0.3			9.28			1		
03/10/21 12:45	250918			0.5			8.18			0.3			7.87			1		
03/10/21 12:46	250070.9			0.5			7.76			0.3			7.45			1		
03/10/21 12:47	249531.8			0.5			7.04			0.3			6.74			1		
03/10/21 12:48	248530.5			0.4			7.04			0.24			6.71			1		
03/10/21 12:49	249762.8			0.4			6.62			0.24			6.35			1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/10/21 12:50	250070.9			0.4			5.8			0.24			5.56			1		
03/10/21 12:51	249146.7			0.4			5.49			0.24			5.24			1		
03/10/21 12:52	248915.6			0.4			4.76			0.24			4.55			1		
03/10/21 12:53	249454.7			0.4			4.55			0.24			4.36			1		
03/10/21 12:54	249839.8			0.4			4.55			0.24			4.37			1		
03/10/21 12:55	249839.8			0.4			4.45			0.24			4.27			1		
03/10/21 12:56	249454.7			0.4			4.24			0.24			4.06			1		
03/10/21 12:57	249685.8			0.4			4.14			0.24			3.97			1		
03/10/21 12:58	249531.8			0.4			4.04			0.24			3.87			1		
03/10/21 12:59	250301.9			0.4			3.93			0.24			3.78			1		
03/10/21 13:00	248453.5			0.4			3.73			0.24			3.55			1		
03/10/21 13:01	248145.5			0.4			4.86			0.24			4.63			1		
03/10/21 13:02	248453.5			0.4			5.79			0.24			5.52			1		
03/10/21 13:03	248915.6			0.4			5.8			0.24			5.54			1		
03/10/21 13:04	249454.7			0.4			5.9			0.24			5.65			1		
03/10/21 13:05	250610			0.4			5.8			0.24			5.57			1		
03/10/21 13:06	250070.9			0.4			6.21			0.24			5.96			1		
03/10/21 13:07	250918			0.4			7.04			0.24			6.78			1		
03/10/21 13:08	258157.5			0.4			7.97			0.25			7.9			1		
03/10/21 13:09	264934.9			0.4			8.24			0.25			8.37			1		
03/10/21 13:10	265782.1			0.5			7.28			0.3			7.42			1		
03/10/21 13:11	265474.1			0.6			6.77			0.36			6.9			1		
03/10/21 13:12	265628.1			0.6			6.77			0.36			6.9			1		
03/10/21 13:13	265320			0.6			6.67			0.36			6.79			1		
03/10/21 13:14	265551.1			0.6			6.58			0.36			6.7			1		
03/10/21 13:15	265397			0.6			6.69			0.37			6.81			1		
03/10/21 13:16	266013.2			0.6			6.49			0.37			6.62			1		
03/10/21 13:17	266706.3			0.6			5.51			0.36			5.64			1		
03/10/21 13:18	265397			0.6			4.55			0.36			4.63			1		
03/10/21 13:19	265320			0.6			3.68			0.36			3.74			1		
03/10/21 13:20	265474.1			0.6			3.39			0.36			3.45			1		
03/10/21 13:21	265320			0.6			3.19			0.36			3.25			1		
03/10/21 13:22	265705.1			0.6			2.9			0.36			2.96			1		
03/10/21 13:23	265243			0.6			2.85			0.36			2.9			1		
03/10/21 13:24	265474.1			0.6			2.75			0.37			2.8			1		
03/10/21 13:25	265397			0.6			2.66			0.37			2.7			1		
03/10/21 13:26	265089			0.6			2.51			0.36			2.56			1		
03/10/21 13:27	265243			0.6			2.46			0.36			2.5			1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/10/21 13:28	264087.8			0.6			2.36			0.36			2.39			1		
03/10/21 13:29	264087.8			0.6			2.26			0.36			2.29			1		
03/10/21 13:30	263856.7			0.6			2.16			0.36			2.19			1		
03/10/21 13:31	264934.9			0.6			1.48			0.36			1.5			1		
03/10/21 13:32	264703.9			0.6			1.38			0.36			1.4			1		
03/10/21 13:33	264395.8			0.6			1.28			0.36			1.3			1		
03/10/21 13:34	265089			0.6			1.28			0.36			1.3			1		
03/10/21 13:35	265089			0.6			1.38			0.36			1.4			0		
03/10/21 13:36	267168.4			0.6			1.38			0.37			1.41			0		
03/10/21 13:37	263394.6			0.6			2.03			0.36			2.05			0		
03/10/21 13:38	263163.6			0.6			3.1			0.36			3.13			0		
03/10/21 13:39	272328.5			0.6			4.72			0.37			4.93			0		

CT1 SUSD EVENT 14

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/10/21 18:59	325084.4			1.1			1.6			0.83			2			0		
03/10/21 19:00	308603			1.1			1.52			0.79			1.8			0		
03/10/21 19:01	306446.6			1.1			1.39			0.81			1.63			0		
03/10/21 19:02	306446.6			1.1			1.23			0.76			1.45			0		
03/10/21 19:03	306446.6			1			1.14			0.69			1.35			0		
03/10/21 19:04	297743.8			1			1.14			0.67			1.31			1		
03/10/21 19:05	276564.3			1			1.94			0.62			2.06			1		
03/10/21 19:06	252381.3			0.9			4.9			0.53			4.75			1		
03/10/21 19:07	232742.3			0.8			8.26			0.43			7.38			1		
03/10/21 19:08	207096			0.6			13.62			0.31			10.83			1		
03/10/21 19:09	185608.5			3.4			15.81			1.48			11.26			1		
03/10/21 19:10	165430.3			169.9			17.83			65.54			11.32			1		
03/10/21 19:11	147100.5			1022.4			18.61			350.6			10.5			1		
03/10/21 19:12	97425.2			1797			18.88			408.28			7.06			1		
03/10/21 19:13	0			0			20.32			0			0			0		
03/10/21 19:14	0			0			17.7			0			0			0		
03/10/21 19:15	0			0			0.2			0			0			0		
03/10/21 19:16	0			0			0.1			0			0			0		
03/10/21 19:17	0			0			0.1			0			0			0		

CT1 SUSD EVENT 15

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/12/21 12:32	19485			0			0			0			0			0		
03/12/21 12:33	19947.1			0			0			0			0			0		
03/12/21 12:34	20409.2			0			0			0			0			0		
03/12/21 12:35	20486.2			0			0			0			0			0		
03/12/21 12:36	26031.4			0			0			0			0			0		
03/12/21 12:37	28727			0.3			0			0			0			1		
03/12/21 12:38	32962.8			0.3			0			0			0			1		
03/12/21 12:39	40972.5			1.5			0.1			0			0			1		
03/12/21 12:40	45747.5			1166.1			11.26			124.24			1.98			1		
03/12/21 12:41	25877.4			0			12.84			55.29			1.28			0		
03/12/21 12:42	25954.4			0			13.41			14.07			1.33			0		
03/12/21 12:43	26108.4			0			11.8			6.51			1.18			0		
03/12/21 12:44	26262.4			0			47.2			11.18			4.75			0		
03/12/21 12:45	26416.5			0			0.6			0			0			0		

CT1 SUSD EVENT 16

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/12/21 12:32	19485			0			0			0			0			0		
03/12/21 12:33	19947.1			0			0			0			0			0		
03/12/21 12:34	20409.2			0			0			0			0			0		
03/12/21 12:35	20486.2			0			0			0			0			0		
03/12/21 12:36	26031.4			0			0			0			0			0		
03/12/21 12:37	28727			0.3			0			0			0			1		
03/12/21 12:38	32962.8			0.3			0			0			0			1		
03/12/21 12:39	40972.5			1.5			0.1			0			0			1		
03/12/21 12:40	45747.5			1166.1			11.26			124.24			1.98			1		
03/12/21 12:41	25877.4			0			12.84			55.29			1.28			0		
03/12/21 12:42	25954.4			0			13.41			14.07			1.33			0		
03/12/21 12:43	26108.4			0			11.8			6.51			1.18			0		
03/12/21 12:44	26262.4			0			47.2			11.18			4.75			0		
03/12/21 12:45	26416.5			0			0.6			0			0			0		

CT1 SUSD EVENT 17

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/12/21 12:58	27879.8			0			0.1			0			0			0		
03/12/21 12:59	27956.8			0			0.1			0			0			0		
03/12/21 13:00	27648.7			0			0			0			0			0		
03/12/21 13:01	27648.7			0			0			0			0			0		
03/12/21 13:02	30498.3			0			0			0			0			0		
03/12/21 13:03	29805.2			0.4			0			0			0			1		
03/12/21 13:04	33887			0.4			0			0			0			1		
03/12/21 13:05	40587.4			1.3			0.2			0			0			1		
03/12/21 13:06	41357.6			1270.9			13.57			122.61			2.15			1		
03/12/21 13:07	27417.7			0			14.75			66.08			1.55			0		
03/12/21 13:08	27109.6			0			14.09			22.02			1.46			0		
03/12/21 13:09	27032.6			0			12.98			10.88			1.35			0		
03/12/21 13:10	26801.6			0			41.3			12.16			4.24			0		
03/12/21 13:11	26647.5			0			0.6			0			0			0		

CT1 SUSD EVENT 18

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/12/21 12:58	27879.8			0			0.1			0			0			0		
03/12/21 12:59	27956.8			0			0.1			0			0			0		
03/12/21 13:00	27648.7			0			0			0			0			0		
03/12/21 13:01	27648.7			0			0			0			0			0		
03/12/21 13:02	30498.3			0			0			0			0			0		
03/12/21 13:03	29805.2			0.4			0			0			0			1		
03/12/21 13:04	33887			0.4			0			0			0			1		
03/12/21 13:05	40587.4			1.3			0.2			0			0			1		
03/12/21 13:06	41357.6			1270.9			13.57			122.61			2.15			1		
03/12/21 13:07	27417.7			0			14.75			66.08			1.55			0		
03/12/21 13:08	27109.6			0			14.09			22.02			1.46			0		
03/12/21 13:09	27032.6			0			12.98			10.88			1.35			0		
03/12/21 13:10	26801.6			0			41.3			12.16			4.24			0		
03/12/21 13:11	26647.5			0			0.6			0			0			0		

CT1 SUSD EVENT 19

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/12/21 13:48	24568.1			0			0.1			0			0			0		
03/12/21 13:49	24491.1			0			0.1			0			0			0		
03/12/21 13:50	24337			0			0			0			0			0		
03/12/21 13:51	25877.4			0			0			0			0			0		
03/12/21 13:52	26108.4			0			0			0			0			0		
03/12/21 13:53	30575.3			0.4			0			0			0			1		
03/12/21 13:54	34118.1			0.6			0			0			0			1		
03/12/21 13:55	42897.9			95.6			21.24			9.56			3.5			1		
03/12/21 13:56	53064			1366.3			14.75			169.13			3			1		
03/12/21 13:57	64539.4			864.9			20.48			130.1			5.07			1		
03/12/21 13:58	85795.8			496.2			24.78			99.3			8.16			1		
03/12/21 13:59	129078.8			328.5			26.55			98.84			13.15			1		
03/12/21 14:00	145252.1			186			46.76			62.98			26.06			1		
03/12/21 14:01	151028.3			667.3			55.68			234.95			32.27			1		
03/12/21 14:02	161348.5			1947			54.39			732.19			33.66			1		
03/12/21 14:03	179601.3			1832.5			58.65			767.47			40.43			1		
03/12/21 14:04	202243.9			1149.2			67.45			541.77			52.33			1		
03/12/21 14:05	224655.6			191.1			62.02			100.12			53.46			1		
03/12/21 14:06	238364.4			16.7			59.86			9.29			54.76			1		
03/12/21 14:07	239981.8			2.8			54.77			1.56			50.42			1		
03/12/21 14:08	240443.9			2.3			52.35			1.26			48.29			1		
03/12/21 14:09	240058.8			2.1			51.06			1.2			47.03			1		
03/12/21 14:10	239981.8			1.8			49.24			1.02			45.33			1		
03/12/21 14:11	239211.6			1.7			44.3			0.96			40.66			1		
03/12/21 14:12	238980.6			1.6			42.69			0.9			39.15			1		
03/12/21 14:13	245989			1.6			41.51			0.92			39.18			1		
03/12/21 14:14	254845.9			1.6			37.33			0.96			36.5			1		
03/12/21 14:15	253921.7			1.5			20.75			0.9			20.22			1		
03/12/21 14:16	253921.7			2.5	X		20.36	X		1.46	X		19.84	X		1		
03/12/21 14:17	253690.6			1.3	X		18.78	X		0.78	X		18.28	X		1		
03/12/21 14:18	253382.5			1	X		18.11	X		0.61	X		17.61	X		1		
03/12/21 14:19	253305.5			1	X		17.6	X		0.6	X		17.1	X		1		
03/12/21 14:20	252458.4			1	X		17.19	X		0.6	X		16.65	X		1		
03/12/21 14:21	252227.3			0.9	X		16.78	X		0.54	X		16.24	X		1		
03/12/21 14:22	251996.3			0.9			16.17			0.54			15.64			1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/12/21 14:23	252073.3			0.8			15.97			0.48			15.44			1		
03/12/21 14:24	251611.2			0.8			15.87			0.48			15.32			1		
03/12/21 14:25	249377.7			0.8			15.77			0.47			15.08			1		
03/12/21 14:26	249993.8			0.8			17.19			0.47			16.49			1		
03/12/21 14:27	250764			0.8			18.22			0.48			17.53			1		
03/12/21 14:28	251072.1			0.8			17.6			0.48			16.95			1		
03/12/21 14:29	250995			0.8			17.09			0.48			16.46			1		
03/12/21 14:30	250533			0.7			16.68			0.42			16.03			1		
03/12/21 14:31	250147.9			0.7			16.68			0.42			16.01			1		
03/12/21 14:32	250841			0.7			17.09			0.42			16.44			1		
03/12/21 14:33	250378.9			0.7			17.6			0.42			16.91			1		
03/12/21 14:34	250610			0.6			18.11			0.36			17.41			1		
03/12/21 14:35	250610			0.6			18.62			0.36			17.9			1		
03/12/21 14:36	244063.6			0.6			19.12			0.35			17.91			1		
03/12/21 14:37	225425.8			0.6			22.25			0.33			19.25			1		
03/12/21 14:38	201011.7			0.5			36.71			0.26			28.32			1		
03/12/21 14:39	177598.8			3.1			41.18			1.3			28.07			1		
03/12/21 14:40	159115			168.2			46.38			62.39			28.31			1		
03/12/21 14:41	140477.1			770.9			47.04			252.45			25.36			1		
03/12/21 14:42	52370.9			1780.9			45.12			217.27			9.06			1		
03/12/21 14:43	26262.4			0			49.47			169.4			4.98			0		
03/12/21 14:44	26185.4			0			0.6			0			0			0		
03/12/21 14:45	26031.4			0			0.5			0			0			0		
03/12/21 14:46	26339.5			0			0.4			0			0			0		
03/12/21 14:47	26185.4			0			0.4			0			0			0		

CT1 SUSD EVENT 20

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/12/21 14:31	250147.9			0.7			16.68			0.42			16.01			1		
03/12/21 14:32	250841			0.7			17.09			0.42			16.44			1		
03/12/21 14:33	250378.9			0.7			17.6			0.42			16.91			1		
03/12/21 14:34	250610			0.6			18.11			0.36			17.41			1		
03/12/21 14:35	250610			0.6			18.62			0.36			17.9			1		
03/12/21 14:36	244063.6			0.6			19.12			0.35			17.91			1		
03/12/21 14:37	225425.8			0.6			22.25			0.33			19.25			1		
03/12/21 14:38	201011.7			0.5			36.71			0.26			28.32			1		
03/12/21 14:39	177598.8			3.1			41.18			1.3			28.07			1		
03/12/21 14:40	159115			168.2			46.38			62.39			28.31			1		
03/12/21 14:41	140477.1			770.9			47.04			252.45			25.36			1		
03/12/21 14:42	52370.9			1780.9			45.12			217.27			9.06			1		
03/12/21 14:43	26262.4			0			49.47			169.4			4.98			0		
03/12/21 14:44	26185.4			0			0.6			0			0			0		
03/12/21 14:45	26031.4			0			0.5			0			0			0		
03/12/21 14:46	26339.5			0			0.4			0			0			0		
03/12/21 14:47	26185.4			0			0.4			0			0			0		

CT1 SUSD EVENT 21

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/13/21 7:39	0			0	X		0	X		0	X		0	X		0		
03/13/21 7:40	0			0	X		0	X		0	X		0	X		0		
03/13/21 7:41	0			0	X		0	X		0	X		0	X		0		
03/13/21 7:42	0			0	X		0	X		0	X		0	X		0		
03/13/21 7:43	0			0	X		0	X		0	X		0	X		0		
03/13/21 7:44	0			0.4	X		0	X		0	X		0	X		1		
03/13/21 7:45	6777.4			0.4	X		0	X		0	X		0	X		1		
03/13/21 7:46	26493.5			118	X		23.6	X		7.29	X		2.4	X		1		
03/13/21 7:47	29266.1			1683.6	X		11.26	X		114.95	X		1.27	X		1		
03/13/21 7:48	0			0	X		14.38	X		0	X		0	X		0		
03/13/21 7:49	0			0	X		11.01	X		0	X		0	X		0		
03/13/21 7:50	0			0	X		20.65	X		0	X		0	X		0		
03/13/21 7:51	0			0	X		0.5	X		0	X		0	X		0		
03/13/21 7:52	0			0	X		0.4	X		0	X		0	X		0		

CT1 SUSD EVENT 22

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/13/21 7:39	0			0	X		0	X		0	X		0	X		0		
03/13/21 7:40	0			0	X		0	X		0	X		0	X		0		
03/13/21 7:41	0			0	X		0	X		0	X		0	X		0		
03/13/21 7:42	0			0	X		0	X		0	X		0	X		0		
03/13/21 7:43	0			0	X		0	X		0	X		0	X		0		
03/13/21 7:44	0			0.4	X		0	X		0	X		0	X		1		
03/13/21 7:45	6777.4			0.4	X		0	X		0	X		0	X		1		
03/13/21 7:46	26493.5			118	X		23.6	X		7.29	X		2.4	X		1		
03/13/21 7:47	29266.1			1683.6	X		11.26	X		114.95	X		1.27	X		1		
03/13/21 7:48	0			0	X		14.38	X		0	X		0	X		0		
03/13/21 7:49	0			0	X		11.01	X		0	X		0	X		0		
03/13/21 7:50	0			0	X		20.65	X		0	X		0	X		0		
03/13/21 7:51	0			0	X		0.5	X		0	X		0	X		0		
03/13/21 7:52	0			0	X		0.4	X		0	X		0	X		0		

CT1 SUSD EVENT 23

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/13/21 8:02	0			0	X		0.1	X		0	X		0	X		0		
03/13/21 8:03	0			0	X		0.1	X		0	X		0	X		0		
03/13/21 8:04	0			0	X		0.1	X		0	X		0	X		0		
03/13/21 8:05	0			0	X		0.1	X		0	X		0	X		0		
03/13/21 8:06	0			0	X		0.1	X		0	X		0	X		0		
03/13/21 8:07	12861.7			0.5	X		0.1	X		0	X		0	X		1		
03/13/21 8:08	20332.2			0.5	X		0	X		0	X		0	X		1		
03/13/21 8:09	31884.6			55.1	X		19.67	X		4.09	X		2.41	X		1		
03/13/21 8:10	24799.1			1745.9	X		13.28	X		100.83	X		1.26	X		1		
03/13/21 8:11	0			0	X		16.59	X		0	X		0	X		0		
03/13/21 8:12	0			0	X		12.25	X		0	X		0	X		0		
03/13/21 8:13	0			0	X		20.65	X		0	X		0	X		0		
03/13/21 8:14	0			0	X		0.6	X		0	X		0	X		0		
03/13/21 8:15	3696.8			0	X		0.5	X		0	X		0	X		0		

CT1 SUSD EVENT 24

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/13/21 8:02	0			0	X		0.1	X		0	X		0	X		0		
03/13/21 8:03	0			0	X		0.1	X		0	X		0	X		0		
03/13/21 8:04	0			0	X		0.1	X		0	X		0	X		0		
03/13/21 8:05	0			0	X		0.1	X		0	X		0	X		0		
03/13/21 8:06	0			0	X		0.1	X		0	X		0	X		0		
03/13/21 8:07	12861.7			0.5	X		0.1	X		0	X		0	X		1		
03/13/21 8:08	20332.2			0.5	X		0	X		0	X		0	X		1		
03/13/21 8:09	31884.6			55.1	X		19.67	X		4.09	X		2.41	X		1		
03/13/21 8:10	24799.1			1745.9	X		13.28	X		100.83	X		1.26	X		1		
03/13/21 8:11	0			0	X		16.59	X		0	X		0	X		0		
03/13/21 8:12	0			0	X		12.25	X		0	X		0	X		0		
03/13/21 8:13	0			0	X		20.65	X		0	X		0	X		0		
03/13/21 8:14	0			0	X		0.6	X		0	X		0	X		0		
03/13/21 8:15	3696.8			0	X		0.5	X		0	X		0	X		0		

CT1 SUSD EVENT 25

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/13/21 8:26	0			0	X		0.1	X		0	X		0	X		0		
03/13/21 8:27	0			0	X		0.1	X		0	X		0	X		0		
03/13/21 8:28	0			0	X		0.1	X		0	X		0	X		0		
03/13/21 8:29	0			0	X		0.1	X		0	X		0	X		0		
03/13/21 8:30	25030.2			0	X		0.1	X		0	X		0	X		0		
03/13/21 8:31	10474.2			0.6	X		0.1	X		0	X		0	X		1		
03/13/21 8:32	24645.1			0.6	X		0.1	X		0	X		0	X		1		
03/13/21 8:33	35504.4			100.3	X		29.5	X		8.31	X		4.02	X		1		
03/13/21 8:34	47056.8			1373.3	X		15.88	X		150.63	X		2.87	X		1		
03/13/21 8:35	59456.3			992.6	X		19.44	X		137.53	X		4.43	X		1		
03/13/21 8:36	78171.2			636.3	X		25.15	X		115.94	X		7.54	X		1		
03/13/21 8:37	120298.9			467.5	X		27.25	X		131.13	X		12.58	X		1		
03/13/21 8:38	146253.3			303.5	X		41.77	X		103.47	X		23.44	X		1		
03/13/21 8:39	154263			411.7	X		54.24	X		148.09	X		32.11	X		1		
03/13/21 8:40	169897.2			1902.4	X		51.99	X		753.74	X		33.9	X		1		
03/13/21 8:41	190691.5			1759.9	X		58.33	X		782.37	X		42.67	X		1		
03/13/21 8:42	203322.2			935.2	X		61.27	X		443.4	X		47.81	X		1		
03/13/21 8:43	204246.4			177.3	X		57.66	X		84.4	X		45.18	X		1		
03/13/21 8:44	203630.2			87.9	X		55.15	X		41.71	X		43.09	X		1		
03/13/21 8:45	203168.1			83.9	X		55.15	X		39.73	X		42.99	X		1		
03/13/21 8:46	203784.3			86.7	X		56.38	X		41.17	X		44.07	X		1		
03/13/21 8:47	203091.1			88.9	X		56.38	X		42.09	X		43.93	X		1		
03/13/21 8:48	201473.8			89.4	X		56.38	X		41.99	X		43.57	X		1		
03/13/21 8:49	200780.6			100	X		56.38	X		46.82	X		43.43	X		1		
03/13/21 8:50	200472.6			109	X		55.46	X		50.92	X		42.66	X		1		
03/13/21 8:51	200318.5			110.5	X		54.94	X		51.61	X		42.22	X		1		
03/13/21 8:52	205786.7			112	X		54.54	X		53.71	X		43.06	X		1		
03/13/21 8:53	227428.2			93.1	X		54.28	X		49.36	X		47.37	X		1		
03/13/21 8:54	244756.8			16.8	X		51.99	X		9.61	X		48.82	X		1		
03/13/21 8:55	252304.3			1.4	X		47.87	X		0.85	X		46.34	X		1		
03/13/21 8:56	255230.9			1.1	X		45.2	X		0.63	X		44.26	X		1		
03/13/21 8:57	253382.5			1	X		36.02	X		0.61	X		35.02	X		1		
03/13/21 8:58	251380.1			0.9	X		36.44	X		0.55	X		35.14	X		1		
03/13/21 8:59	251380.1			0.8	X		39.95	X		0.49	X		38.53	X		1		
03/13/21 9:00	251765.2			0.8	X		39.95	X		0.49	X		38.59	X		1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/13/21 9:01	252150.3			0.8	X		39.85	X		0.49	X		38.55	X		1		
03/13/21 9:02	265089			0.7	X		39.33	X		0.45	X		40.01	X		1		
03/13/21 9:03	286730.5			0.7	X		27.77	X		0.48	X		30.55	X		1		
03/13/21 9:04	298359.9			0.8	X		16.56	X		0.53	X		18.95	X		1		
03/13/21 9:05	299053			0.8	X		15.02	X		0.56	X		17.23	X		1		
03/13/21 9:06	299207.1			1	X		13.12	X		0.68	X		15.06	X		1		
03/13/21 9:07	298822			1.1	X		12.68	X		0.74	X		14.54	X		1		
03/13/21 9:08	298205.8			1.1	X		12.5	X		0.73	X		14.31	X		1		
03/13/21 9:09	298513.9			1	X		12.43	X		0.68	X		14.23	X		1		
03/13/21 9:10	298667.9			1	X		12.16	X		0.68	X		13.93	X		1		
03/13/21 9:11	298282.9			1	X		11.89	X		0.68	X		13.61	X		1		
03/13/21 9:12	298051.8			1	X		11.71	X		0.68	X		13.39	X		1		
03/13/21 9:13	297512.7			1	X		11.53	X		0.68	X		13.17	X		1		
03/13/21 9:14	297666.7			0.9	X		11.44	X		0.62	X		13.07	X		1		
03/13/21 9:15	297666.7			0.9	X		11.44	X		0.62	X		13.07	X		1		
03/13/21 9:16	297589.7			0.9	X		11.44	X		0.62	X		13.06	X		1		
03/13/21 9:17	296819.6			0.9	X		11.35	X		0.62	X		12.93	X		1		
03/13/21 9:18	296973.6			0.9	X		9.83	X		0.62	X		11.2	X		1		
03/13/21 9:19	298436.9			0.9	X		7.42	X		0.62	X		8.5	X		1		
03/13/21 9:20	316612.7			0.8	X		6.62	X		0.59	X		8.03	X		1		
03/13/21 9:21	336713.8			0.9	X		6.26	X		0.7	X		8.08	X		1		
03/13/21 9:22	352733.2			0.9	X		6.16	X		0.71	X		8.34	X		1		
03/13/21 9:23	369907.7			1	X		4.23	X		0.84	X		6	X		1		
03/13/21 9:24	391395.2			1	X		3.31	X		0.9	X		4.97	X		1		
03/13/21 9:25	411804.4			0.9	X		3.22	X		0.86	X		5.08	X		1		
03/13/21 9:26	435294.3			0.9	X		3.18	X		0.92	X		5.31	X		1		
03/13/21 9:27	458399.1			0.9	X		3.13	X		0.99	X		5.51	X		1		
03/13/21 9:28	466177.7			0.8	X		3.36	X		0.89	X		6.01	X		1		
03/13/21 9:29	463251.1			0.9	X		4.29	X		0.97	X		7.63	X		1		
03/13/21 9:30	462634.9			0.9	X		4.2	X		0.96	X		7.46	X		1		
03/13/21 9:31	462943			0.9	X		4.02	X		0.96	X		7.15	X		1		
03/13/21 9:32	462712			0.9	X		3.9	X		0.98	X		6.93	X		1		
03/13/21 9:33	463559.1			0.9	X		3.75	X		0.97	X		6.68	X		1		
03/13/21 9:34	463020			0.9	X		3.75	X		0.96	X		6.67	X		1		
03/13/21 9:35	463251.1			0.9	X		3.75	X		0.97	X		6.67	X		1		
03/13/21 9:36	463636.2			0.9	X		3.84	X		0.97	X		6.84	X		1		
03/13/21 9:37	464021.2			0.9	X		3.84	X		0.97	X		6.84	X		1		
03/13/21 9:38	463790.2			0.9	X		3.84	X		0.97	X		6.84	X		1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/13/21 9:39	463559.1			0.9	X		3.75	X		0.97	X		6.68	X		1		
03/13/21 9:40	463405.1			0.9	X		3.75	X		0.97	X		6.68	X		1		
03/13/21 9:41	463251.1			1	X		3.75	X		1.06	X		6.67	X		1		
03/13/21 9:42	463482.1			0.9	X		3.67	X		0.97	X		6.52	X		1		
03/13/21 9:43	464483.3			0.9	X		3.67	X		0.97	X		6.53	X		1		
03/13/21 9:44	463867.2			0.9	X		3.58	X		0.97	X		6.36	X		1		
03/13/21 9:45	463636.2			0.9	X		3.67	X		0.97	X		6.52	X		1		
03/13/21 9:46	463559.1			0.9	X		3.58	X		0.97	X		6.36	X		1		
03/13/21 9:47	463251.1			0.9	X		3.58	X		0.97	X		6.36	X		1		
03/13/21 9:48	462943			0.9	X		3.58	X		0.96	X		6.35	X		1		
03/13/21 9:49	453624.1			0.9	X		3.49	X		0.95	X		6.07	X		1		
03/13/21 9:50	434293.1			0.9	X		3.4	X		0.91	X		5.66	X		1		
03/13/21 9:51	412343.5			0.9	X		3.35	X		0.85	X		5.29	X		1		
03/13/21 9:52	400868.1			1	X		3.56	X		0.89	X		5.47	X		1		
03/13/21 9:53	397556.4			1	X		3.47	X		0.88	X		5.29	X		1		
03/13/21 9:54	396401.2			1	X		3.43	X		0.9	X		5.22	X		1		
03/13/21 9:55	396478.2			1	X		3.26	X		0.9	X		4.96	X		1		
03/13/21 9:56	396016.1			1	X		3.17	X		0.89	X		4.82	X		1		
03/13/21 9:57	396324.2			1	X		3.17	X		0.9	X		4.82	X		1		
03/13/21 9:58	395091.9			1	X		3.17	X		0.89	X		4.81	X		1		
03/13/21 9:59	395785.1			1	X		3.17	X		0.89	X		4.81	X		1		
03/13/21 10:00	396324.2			1	X		3.17	X		0.9	X		4.82	X		1		
03/13/21 10:01	396709.3			1	X		3.08	X		0.9	X		4.69	X		1		
03/13/21 10:02	396324.2			1	X		2.99	X		0.9	X		4.55	X		1		
03/13/21 10:03	392704.4			1	X		3.08	X		0.89	X		4.64	X		1		
03/13/21 10:04	373989.6			1	X		3.08	X		0.84	X		4.42	X		1		
03/13/21 10:05	355736.8			1	X		3.21	X		0.79	X		4.38	X		1		
03/13/21 10:06	332169.9			1	X		3.42	X		0.79	X		4.36	X		1		
03/13/21 10:07	308140.9			1	X		3.51	X		0.74	X		4.14	X		1		
03/13/21 10:08	286576.4			1	X		3.47	X		0.7	X		3.82	X		1		
03/13/21 10:09	267091.4			1	X		2.68	X		0.61	X		2.75	X		1		
03/13/21 10:10	263548.7			0.8	X		3.56	X		0.52	X		3.6	X		1		
03/13/21 10:11	262932.5			0.7	X		4.62	X		0.42	X		4.66	X		1		
03/13/21 10:12	263394.6			0.6	X		4.43	X		0.36	X		4.47	X		1		
03/13/21 10:13	263548.7			0.5	X		3.74	X		0.3	X		3.78	X		1		
03/13/21 10:14	263317.6			0.5	X		3.64	X		0.3	X		3.68	X		1		
03/13/21 10:15	263471.7			0.6	X		3.44	X		0.36	X		3.48	X		1		
03/13/21 10:16	263394.6			0.6	X		3.15	X		0.36	X		3.18	X		1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/13/21 10:17	263317.6			0.6	X		2.95	X		0.36	X		2.98	X		1		
03/13/21 10:18	261161.2			0.6	X		2.75	X		0.36	X		2.76	X		1		
03/13/21 10:19	242600.3			0.6	X		2.56	X		0.33	X		2.38	X		1		
03/13/21 10:20	234359.6			0.6	X		6	X		0.33	X		5.4	X		1		
03/13/21 10:21	233281.4			0.5	X		10.6	X		0.3	X		9.49	X		1		
03/13/21 10:22	232588.2			0.4	X		10.46	X		0.24	X		9.34	X		1		
03/13/21 10:23	232665.3			0.4	X		10.24	X		0.24	X		9.14	X		1		
03/13/21 10:24	232280.2			0.4	X		10.02	X		0.24	X		8.93	X		1		
03/13/21 10:25	232665.3			0.4	X		9.68	X		0.24	X		8.65	X		1		
03/13/21 10:26	232434.2			0.4	X		9.35	X		0.24	X		8.34	X		1		
03/13/21 10:27	232896.3			0.4	X		9.13	X		0.24	X		8.16	X		1		
03/13/21 10:28	237132.2			0.4	X		8.57	X		0.25	X		7.8	X		1		
03/13/21 10:29	262701.5			0.4	X		7.9	X		0.27	X		7.97	X		1		
03/13/21 10:30	285113.1			0.4	X		4.32	X		0.28	X		4.72	X		1		
03/13/21 10:31	307293.7			0.6	X		1.14	X		0.41	X		1.35	X		1		
03/13/21 10:32	325084.4			0.7	X		0.97	X		0.53	X		1.21	X		1		
03/13/21 10:33	328550.1			0.9	X		0.78	X		0.66	X		0.98	X		1		
03/13/21 10:34	329089.3			1	X		0.69	X		0.8	X		0.88	X		0		
03/13/21 10:35	329089.3			1	X		0.61	X		0.8	X		0.77	X		0		
03/13/21 10:36	329012.2			1	X		0.61	X		0.8	X		0.77	X		0		
03/13/21 10:37	328858.2			1	X		0.61	X		0.8	X		0.77	X		0		
03/13/21 10:38	328242.1			1	X		0.69	X		0.8	X		0.87	X		0		

CT1 SUSD EVENT 26

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/13/21 17:56	323929.2			1			1.71			0.77			2.13			0		
03/13/21 17:57	308449			1			1.65			0.75			1.95			0		
03/13/21 17:58	306677.6			1.1			1.59			0.76			1.87			0		
03/13/21 17:59	306369.5			1			1.52			0.7			1.79			0		
03/13/21 18:00	306138.5			0.9			1.43			0.64			1.68			0		
03/13/21 18:01	304213.1			0.9			1.43			0.63			1.67			1		
03/13/21 18:02	286114.3			0.9			1.52			0.6			1.67			1		
03/13/21 18:03	263856.7			0.9			1.63			0.56			1.65			1		
03/13/21 18:04	240674.9			0.8			2.62			0.47			2.42			1		
03/13/21 18:05	219957.6			0.7			6			0.37			5.07			1		
03/13/21 18:06	195312.5			0.6			16.59			0.25			12.43			1		
03/13/21 18:07	173594			5			19.05			2.04			12.69			1		
03/13/21 18:08	156650.5			428			22.34			156.37			13.43			1		
03/13/21 18:09	138166.7			1466.5			25.35			472.4			13.44			1		
03/13/21 18:10	39971.3			1935.8			26			180.26			3.98			1		
03/13/21 18:11	27186.6			0			27.89			201.79			2.91			0		
03/13/21 18:12	26878.6			0			0.2			0			0			0		
03/13/21 18:13	26724.5			0			0.2			0			0			0		
03/13/21 18:14	26570.5			0			0.2			0			0			0		
03/13/21 18:15	26493.5			0			0.1			0			0			0		

CT1 SUSD EVENT 27

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/23/21 9:24	1001.2			0			0			0			0			0		
03/23/21 9:25	0			0			0			0			0			0		
03/23/21 9:26	0			0			0			0			0			0		
03/23/21 9:27	0			0			0			0			0			0		
03/23/21 9:28	4004.8			0			0			0			0			0		
03/23/21 9:29	6700.4			0.3			0			0			0			1		
03/23/21 9:30	21564.5			0.3			0			0			0			1		
03/23/21 9:31	32962.8			1.5			0.1			0			0			1		
03/23/21 9:32	44207.2			1463.9			9.83			150.73			1.67			1		
03/23/21 9:33	57068.8			1078.2			12.17			143.37			2.66			1		
03/23/21 9:34	69391.4			269.3			17.44			43.59			4.65			1		
03/23/21 9:35	59302.3			48.9			18.27			6.77			4.16			1		
03/23/21 9:36	0			0			30.43			0			0			0		
03/23/21 9:37	0			0			44			0			0			0		
03/23/21 9:38	0			0			64.9			0			0			0		
03/23/21 9:39	0			0			118			0			0			0		
03/23/21 9:40	0			0			1.8			0			0			0		

CT1 SUSD EVENT 28

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/23/21 9:24	1001.2			0			0			0			0			0		
03/23/21 9:25	0			0			0			0			0			0		
03/23/21 9:26	0			0			0			0			0			0		
03/23/21 9:27	0			0			0			0			0			0		
03/23/21 9:28	4004.8			0			0			0			0			0		
03/23/21 9:29	6700.4			0.3			0			0			0			1		
03/23/21 9:30	21564.5			0.3			0			0			0			1		
03/23/21 9:31	32962.8			1.5			0.1			0			0			1		
03/23/21 9:32	44207.2			1463.9			9.83			150.73			1.67			1		
03/23/21 9:33	57068.8			1078.2			12.17			143.37			2.66			1		
03/23/21 9:34	69391.4			269.3			17.44			43.59			4.65			1		
03/23/21 9:35	59302.3			48.9			18.27			6.77			4.16			1		
03/23/21 9:36	0			0			30.43			0			0			0		
03/23/21 9:37	0			0			44			0			0			0		
03/23/21 9:38	0			0			64.9			0			0			0		
03/23/21 9:39	0			0			118			0			0			0		
03/23/21 9:40	0			0			1.8			0			0			0		

CT1 SUSD EVENT 29

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/23/21 10:20	10320.1			0			0.2			0			0			0		
03/23/21 10:21	10012.1			0			0.1			0			0			0		
03/23/21 10:22	9473			0			0.1			0			0			0		
03/23/21 10:23	11398.4			0			0.1			0			0			0		
03/23/21 10:24	10474.2			0			0.1			0			0			0		
03/23/21 10:25	15942.3			0.4			0.1			0			0			1		
03/23/21 10:26	27263.7			0.4			0.1			0			0			1		
03/23/21 10:27	38276.9			23.6			14.75			2.11			2.17			1		
03/23/21 10:28	49675.3			1032.5			13.49			119.49			2.57			1		
03/23/21 10:29	61920.8			886.4			18.05			127.98			4.29			1		
03/23/21 10:30	84563.5			539.6			20.95			106.4			6.8			1		
03/23/21 10:31	127615.5			404.6			24.44			120.36			11.97			1		
03/23/21 10:32	143249.7			232.6			38.8			77.68			21.33			1		
03/23/21 10:33	148332.8			585.8			47.39			202.6			26.97			1		
03/23/21 10:34	159500.1			2011.5			44.35			747.9			27.14			1		
03/23/21 10:35	178446			1889.6			51.49			786.32			35.26			1		
03/23/21 10:36	199856.5			1361.8			59.64			634.66			45.74			1		
03/23/21 10:37	222730.2			296.1			62.79			153.78			53.67			1		
03/23/21 10:38	242831.4			31			59.25			17.55			55.2			1		
03/23/21 10:39	266398.3			4.1			83.51			2.54			85.37			1		
03/23/21 10:40	293199.8			2.6			72.77			1.77			81.87			1		
03/23/21 10:41	311298.6			2.3			31.75			1.7			37.92			1		
03/23/21 10:42	305060.3			2.3			18.48			1.6			21.63			1		
03/23/21 10:43	301440.5			2.4			13.85			1.68			16.02			1		
03/23/21 10:44	300593.3			2.4			12.06			1.7			13.91			1		
03/23/21 10:45	300208.3			2.3			11.18			1.6			12.88			1		
03/23/21 10:46	293970			2.2			10.21			1.51			11.52			1		
03/23/21 10:47	291505.5			2			9.07			1.38			10.14			1		
03/23/21 10:48	285267.2			1.8			9.03			1.19			9.88			1		
03/23/21 10:49	284111.9			1.6			8.94			1.07			9.74			1		
03/23/21 10:50	283341.8			1.5			8.9			0.96			9.67			1		
03/23/21 10:51	283264.8			1.4			8.8			0.9			9.57			1		
03/23/21 10:52	282879.7			1.3			8.62			0.84			9.36			1		
03/23/21 10:53	282494.6			1.2			8.53			0.78			9.25			1		
03/23/21 10:54	282648.6			1.1			8.35			0.72			9.06			1		

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/23/21 10:55	290042.2			1.1			8.26			0.74			9.19			1		
03/23/21 10:56	307524.8			1.1			7.99			0.78			9.43			1		
03/23/21 10:57	309758.3			1.1			6.88			0.77			8.18			1		
03/23/21 10:58	310528.4			1.1			6.79			0.78			8.09			1		
03/23/21 10:59	310605.4			1.2			6.7			0.84			7.99			1		
03/23/21 11:00	310297.3			1.2			6.62			0.84			7.88			1		
03/23/21 11:01	310528.4			1.2			6.62			0.84			7.88			1		
03/23/21 11:02	309604.2			1.2			6.62			0.84			7.86			1		
03/23/21 11:03	310682.4			1.2			6.7			0.84			7.99			1		
03/23/21 11:04	327317.9			1.1			6.7			0.82			8.42			1		
03/23/21 11:05	344954.5			1.1			7.06			0.86			9.35			1		
03/23/21 11:06	360049.7			1.1			5.55			0.89			7.66			1		
03/23/21 11:07	373758.5			1.1			5.45			0.95			7.81			1		
03/23/21 11:08	391395.2			1			6.44			0.91			9.68			1		
03/23/21 11:09	405874.2			1			5.45			0.94			8.48			1		
03/23/21 11:10	421200.3			0.9			5.25			0.91			8.49			1		
03/23/21 11:11	437527.8			0.9			5.25			0.94			8.82			1		
03/23/21 11:12	442379.8			0.9			5.53			0.95			9.39			1		
03/23/21 11:13	444151.1			0.9			6.18			0.95			10.53			1		
03/23/21 11:14	444536.2			0.9			6.27			0.96			10.69			1		
03/23/21 11:15	445075.3			0.9			5.99			0.96			10.23			1		
03/23/21 11:16	451544.7			0.9			3.32			0.97			5.75			1		
03/23/21 11:17	454240.2			0.9			2.49			0.98			4.34			1		
03/23/21 11:18	454471.3			0.9			2.45			0.96			4.27			1		
03/23/21 11:19	454009.2			0.9			2.63			0.96			4.59			1		
03/23/21 11:20	454009.2			0.9			2.9			0.96			5.06			1		
03/23/21 11:21	453393			0.9			3.09			0.96			5.37			1		
03/23/21 11:22	453855.1			0.9			3			0.96			5.22			1		
03/23/21 11:23	451467.6			0.9			2.81			0.96			4.87			1		
03/23/21 11:24	444844.3			0.9			2.27			0.94			3.87			1		
03/23/21 11:25	443072.9			0.9			1.82			0.94			3.09			1		
03/23/21 11:26	441686.6			0.9			1.72			0.93			2.92			1		
03/23/21 11:27	440608.4			0.9			1.63			0.93			2.76			1		
03/23/21 11:28	440531.4			0.9			1.54			0.93			2.61			0		
03/23/21 11:29	440223.3			0.9			1.54			0.93			2.61			0		
03/23/21 11:30	439915.2			0.9			1.54			0.93			2.6			0		
03/23/21 11:31	440377.3			0.9			1.54			0.93			2.61			0		
03/23/21 11:32	440685.4			0.8			1.54			0.84			2.61			0		

CT1 SUSD EVENT 30

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/24/21 11:49	372449.3			0.9			1.7			0.78			2.43			0		
03/24/21 11:50	359279.5			0.9			1.7			0.75			2.34			0		
03/24/21 11:51	339563.4			1			2.38			0.77			3.1			0		
03/24/21 11:52	316612.7			1			2.52			0.7			3.06			0		
03/24/21 11:53	293276.8			1.1			2.03			0.72			2.28			0		
03/24/21 11:54	275332.1			1			1.88			0.63			1.98			1		
03/24/21 11:55	259158.8			0.9			1.84			0.56			1.83			1		
03/24/21 11:56	235822.9			0.8			3.05			0.42			2.76			1		
03/24/21 11:57	215182.6			0.6			7.35			0.31			6.07			1		
03/24/21 11:58	191538.7			0.6			19.63			0.25			14.43			1		
03/24/21 11:59	169743.2			8.1			22.96			3.2			14.95			1		
03/24/21 12:00	153030.7			577.8			26.99			206.15			15.85			1		
03/24/21 12:01	126999.3			1591.9			29.17			471.42			14.22			1		
03/24/21 12:02	32808.8			0			29.5			154.9			3.72			0		
03/24/21 12:03	32808.8			0			44.25			712.75			5.58			0		
03/24/21 12:04	32500.7			0			0.2			0			0			0		
03/24/21 12:05	32346.7			0			0.2			0			0			0		
03/24/21 12:06	32577.8			0			0.1			0			0			0		

CT2 SUSD EVENT 1

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/26/21 8:12	0			0			0			0			0			0		
02/26/21 8:13	0			0			0			0			0			0		
02/26/21 8:14	0			0			0			0			0			0		
02/26/21 8:15	0			0			0			0			0			0		
02/26/21 8:16	12091.5			0			0			0			0			0		
02/26/21 8:17	10551.2			0.3			0			0			0			1		
02/26/21 8:18	32731.8			1.1			0			0			0			1		
02/26/21 8:19	46748.7			824.5			7.38			89.88			1.32			1		
02/26/21 8:20	59379.3			799.8			9.51			110.82			2.17			1		
02/26/21 8:21	75706.7			692.9			14.75			122.38			4.29			1		
02/26/21 8:22	121916.3			519.2			19.18			147.6			8.97			1		
02/26/21 8:23	154263			373.4			22.13			134.33			13.1			1		
02/26/21 8:24	150104.1			364			37.37			127.45			21.53			1		
02/26/21 8:25	147716.6			1890.8			33.43			651.36			18.96			1		
02/26/21 8:26	145945.3			2161.6			37.03			735.97			20.75			1		
02/26/21 8:27	146099.3			2162.2			40.08			736.67			22.47			1		
02/26/21 8:28	144944.1			2237.6			44.67			756.32			24.85			1		
02/26/21 8:29	145637.2			2237.6			51.2			760.32			28.63			1		
02/26/21 8:30	154494			2237.6			61.32			806.41			36.37			1		
02/26/21 8:31	157959.8			2160.4			70.39			796.01			42.69			1		
02/26/21 8:32	158575.9			2019.9			68.9			746.94			41.93			1		
02/26/21 8:33	156650.5			1957.1			65.82			714.98			39.57			1		
02/26/21 8:34	158421.9			1957.9			64.16			723.57			39.03			1		
02/26/21 8:35	156958.5			1957.9			62.13			717			37.45			1		
02/26/21 8:36	157112.6			2021			62.43			740.58			37.65			1		
02/26/21 8:37	157035.6			2021			60.71			740.13			36.59			1		
02/26/21 8:38	156958.5			2021			59.38			740.13			35.79			1		
02/26/21 8:39	155649.3			2021			58.05			733.79			34.69			1		
02/26/21 8:40	155649.3			2021			56.91			733.79			34			1		
02/26/21 8:41	155726.3			2019.3			55.76			733.62			33.34			1		
02/26/21 8:42	170359.3			2019.3			55			802.33			35.97			1		
02/26/21 8:43	191461.7			1896.9			52.38			847.12			38.5			1		
02/26/21 8:44	215644.7			1202.6			51.19			604.91			42.37			1		
02/26/21 8:45	238210.4			298.5			51.27			165.85			46.88			1		
02/26/21 8:46	262470.4			41.6			51.59			25.44			51.98			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/26/21 8:47	288732.9			10.4			52.65			6.97			58.37			1		
02/26/21 8:48	316227.6			7.3			45.17			5.4			54.83			1		
02/26/21 8:49	335789.6			6.3			29.32			4.91			37.79			1		
02/26/21 8:50	337869.1			5.4			14.35			4.23			18.62			1		
02/26/21 8:51	337021.9			4.8			14.14			3.75			18.3			1		
02/26/21 8:52	333864.3			4.4			12.67			3.45			16.24			1		
02/26/21 8:53	336020.7			4.2			12.42			3.31			16.01			1		
02/26/21 8:54	334942.5			4.1			11.27			3.16			14.49			1		
02/26/21 8:55	335481.6			3.9			10.92			3.03			14.06			1		
02/26/21 8:56	335866.7			3.7			10.39			2.9			13.4			1		
02/26/21 8:57	335096.5			3.5			10.04			2.75			12.91			1		
02/26/21 8:58	335789.6			3.3			9.83			2.59			12.68			1		
02/26/21 8:59	335712.6			3.2			9.48			2.52			12.21			1		
02/26/21 9:00	335019.5			3			9.21			2.38			11.84			1		
02/26/21 9:01	335019.5			3			9.21			2.31			11.84			1		
02/26/21 9:02	334557.4			2.9			9.39			2.23			12.05			1		
02/26/21 9:03	334480.4			2.7			9.65			2.09			12.4			1		
02/26/21 9:04	335404.6			2.4			9.83			1.89			12.66			1		
02/26/21 9:05	334172.3			2.2			10.1			1.74			12.96			1		
02/26/21 9:06	335250.5			2.1			10.37			1.61			13.34			1		
02/26/21 9:07	333941.3			2			10.64			1.53			13.64			1		
02/26/21 9:08	333633.2			1.8			10.82			1.39			13.85			1		
02/26/21 9:09	334711.4			1.6			8.22			1.26			10.57			1		
02/26/21 9:10	334403.3			1.5			4.83			1.19			6.2			1		
02/26/21 9:11	333402.2			1.4			4.02			1.11			5.15			1		
02/26/21 9:12	333864.3			1.3			3.4			1.04			4.35			1		
02/26/21 9:13	334403.3			1.3			3.13			1.05			4.02			1		
02/26/21 9:14	334711.4			1.3			2.68			1.05			3.45			1		
02/26/21 9:15	334172.3			1.3			2.23			0.98			2.87			1		
02/26/21 9:16	335019.5			1.3			2.15			0.98			2.76			1		
02/26/21 9:17	333941.3			1.3			1.97			0.97			2.52			1		
02/26/21 9:18	334249.3			1.2			1.79			0.91			2.29			1		
02/26/21 9:19	333787.2			1.2			1.61			0.9			2.06			1		
02/26/21 9:20	333094.1			1.2			1.52			0.9			1.94			0		
02/26/21 9:21	332400.9			1.1			1.43			0.83			1.83			0		
02/26/21 9:22	333864.3			1.1			1.34			0.84			1.72			0		
02/26/21 9:23	333248.1			1.1			1.36			0.85			1.74			0		
02/26/21 9:24	332709			1.1			1.27			0.85			1.62			0		

CT2 SUSD EVENT 2

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/26/21 14:06	427361.6			0.9			1.61			0.89			2.64			0		
02/26/21 14:07	405489.1			0.9			1.61			0.85			2.5			0		
02/26/21 14:08	386004.1			1			1.59			0.87			2.35			0		
02/26/21 14:09	369522.6			1			1.48			0.82			2.09			0		
02/26/21 14:10	349036.4			1			1.39			0.85			1.86			0		
02/26/21 14:11	331245.7			1.1			1.32			0.82			1.68			1		
02/26/21 14:12	318230			1			1.27			0.74			1.55			1		
02/26/21 14:13	293738.9			0.9			1.57			0.63			1.77			1		
02/26/21 14:14	271250.3			0.8			4.68			0.53			4.87			1		
02/26/21 14:15	251072.1			0.8			8.65			0.46			8.34			1		
02/26/21 14:16	224347.5			0.6			15.7			0.33			13.52			1		
02/26/21 14:17	197160.9			2.6			19.23			1.19			14.55			1		
02/26/21 14:18	173979.1			123.1			21.37			49.96			14.27			1		
02/26/21 14:19	155957.3			845.1			23.3			307.39			13.95			1		
02/26/21 14:20	113675.6			1755.9			25.68			465.78			11.21			1		
02/26/21 14:21	0			0			30.18			0			0			0		
02/26/21 14:22	0			0			0.3			0			0			0		
02/26/21 14:23	0			0			0.2			0			0			0		
02/26/21 14:24	0			0			0.1			0			0			0		
02/26/21 14:25	0			0			0.1			0			0			0		

CT2 SUSD EVENT 3

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/27/21 9:38	0			0			0			0			0			0		
02/27/21 9:39	0			0			0			0			0			0		
02/27/21 9:40	0			0			0			0			0			0		
02/27/21 9:41	0			0			0			0			0			0		
02/27/21 9:42	1232.3			0			0			0			0			0		
02/27/21 9:43	20871.3			0.1			0			0			0			1		
02/27/21 9:44	36890.7			112.1			5.9			9.64			0.83			1		
02/27/21 9:45	49290.2			733.6			15.24			84.4			2.89			1		
02/27/21 9:46	61381.7			770.7			16.15			110.42			3.81			1		
02/27/21 9:47	77016			597.4			21.54			107.38			6.37			1		
02/27/21 9:48	120607			452.7			24.67			127.38			11.43			1		
02/27/21 9:49	155341.2			312.2			37.22			113.16			22.2			1		
02/27/21 9:50	158267.8			283			49.6			104.47			30.13			1		
02/27/21 9:51	163273.9			1760.8			49.78			670.44			31.2			1		
02/27/21 9:52	173131.9			1901.1			52.03			767.68			34.58			1		
02/27/21 9:53	193079			1792.1			50.4			807.12			37.36			1		
02/27/21 9:54	216106.8			1026.3			53.1			517.35			44.05			1		
02/27/21 9:55	239519.7			239.8			51.63			133.96			47.47			1		
02/27/21 9:56	261854.3			26.7			52.98			16.32			53.24			1		
02/27/21 9:57	288501.8			3.8			57.25			2.57			63.4			1		
02/27/21 9:58	315688.5			2.7			53.3			1.99			64.58			1		
02/27/21 9:59	340641.7			2.4			35.94			1.87			47			1		
02/27/21 10:00	358663.4			2.2			18.73			1.86			25.78			1		
02/27/21 10:01	371910.1			2.3			13.25			2			18.92			1		
02/27/21 10:02	380612.9			2.2			12.9			1.95			18.84			1		
02/27/21 10:03	396478.2			2			10.87			1.87			16.55			1		
02/27/21 10:04	409648			1.8			9.54			1.74			15.01			1		
02/27/21 10:05	415732.2			1.6			9.02			1.6			14.4			1		
02/27/21 10:06	429287			1.5			9.2			1.48			15.16			1		
02/27/21 10:07	436218.5			1.3			8.72			1.34			14.6			1		
02/27/21 10:08	442379.8			1.2			8.72			1.27			14.81			1		
02/27/21 10:09	443920.1			1.1			8.81			1.19			15.01			1		
02/27/21 10:10	444151.1			1.1			8.81			1.19			15.01			1		
02/27/21 10:11	449311.2			1.1			8.98	X		1.11			15.49	X		1		
02/27/21 10:12	454779.3			1.1			8.76			1.14			15.29			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSDTF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/27/21 10:13	458476.1			1.1			8.76			1.15			15.42			1		
02/27/21 10:14	466023.7			1			8.85			1.07			15.83			1		
02/27/21 10:15	472261.9			1			8.85			1.08			16.04			1		
02/27/21 10:16	482351			1			8.99			1.12			16.64			1		
02/27/21 10:17	492286.1			0.9			8.9			1.04			16.81			1		
02/27/21 10:18	497677.2			0.8			8.99			0.95			17.17			1		
02/27/21 10:19	498755.4			0.9			10.1			1.04			19.34			1		
02/27/21 10:20	495982.9			0.9			6.62			1.03			12.59			1		
02/27/21 10:21	495289.7			0.9			3.4			1.03			6.46			1		
02/27/21 10:22	496059.9			0.9			2.95			1.03			5.62			1		
02/27/21 10:23	494673.6			0.9			2.72			1.05			5.17			1		
02/27/21 10:24	495982.9			0.9			2.63			1.05			5.01			1		
02/27/21 10:25	494904.6			0.9			2.45			1.05			4.66			1		
02/27/21 10:26	495828.8			0.9			2.36			1.05			4.49			1		
02/27/21 10:27	495058.7			0.9			2.15			1.03			4.08			1		
02/27/21 10:28	495058.7			0.9			2			1.05			3.8			1		
02/27/21 10:29	496136.9			0.9			1.88			1.03			3.58			1		
02/27/21 10:30	493518.3			0.9			1.7			1.03			3.22			1		
02/27/21 10:31	493903.4			0.8			1.61			0.93			3.05			0		
02/27/21 10:32	494981.7			0.8			1.54			0.94			2.93			0		
02/27/21 10:33	496599			0.8			1.45			0.95			2.77			0		
02/27/21 10:34	495597.8			0.8			1.34			0.93			2.55			0		
02/27/21 10:35	496522			0.8			1.34			0.93			2.56			0		

CT2 SUSD EVENT 4

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/27/21 17:47	315072.3			0.7			1.57			0.54			1.9			0		
02/27/21 17:48	315919.5			0.7			1.66			0.54			2.01			0		
02/27/21 17:49	315457.4			0.7			1.66			0.54			2.01			0		
02/27/21 17:50	315380.4			0.7			1.66			0.54			2.01			0		
02/27/21 17:51	316304.6			0.7			1.75			0.54			2.13			0		
02/27/21 17:52	310913.5			0.7			1.75			0.53			2.09			1		
02/27/21 17:53	286730.5			0.7			2.67			0.49			2.94			1		
02/27/21 17:54	266783.3			0.8			6.85			0.47			7.02			1		
02/27/21 17:55	243755.5			0.7			7.2			0.4			6.74			1		
02/27/21 17:56	214643.5			0.7			16.83			0.33			13.87			1		
02/27/21 17:57	190229.5			4.7			19.05			2.07			13.91			1		
02/27/21 17:58	168433.9			287.2			20.86			112.82			13.48			1		
02/27/21 17:59	150104.1			1214.9			22.96			425.34			13.23			1		
02/27/21 18:00	75552.7			1954.2			25.63			344.26			7.43			1		
02/27/21 18:01	0			0			32.92			0			0			0		
02/27/21 18:02	0			0			0.2			0			0			0		
02/27/21 18:03	0			0			0.2			0			0			0		
02/27/21 18:04	0			0			0.1			0			0			0		
02/27/21 18:05	0			0			0.1			0			0			0		

CT2 SUSD EVENT 5

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/01/21 7:40	0			0			0			0			0			0		
03/01/21 7:41	0			0			0			0			0			0		
03/01/21 7:42	0			0			0			0			0			0		
03/01/21 7:43	0			0			0			0			0			0		
03/01/21 7:44	1925.4			0			0			0			0			0		
03/01/21 7:45	17482.6			0.1			0			0			0			1		
03/01/21 7:46	35119.3			0.8			0			0			0			1		
03/01/21 7:47	47672.9			64.2			13.77			7.15			2.52			1		
03/01/21 7:48	60380.5			776.3			13.66			109.3			3.17			1		
03/01/21 7:49	74474.4			653.4			17.7			113.5			5.06			1		
03/01/21 7:50	113444.5			514.7			22.2			136.18			9.66			1		
03/01/21 7:51	150951.3			393.6			23.85			138.58			13.82			1		
03/01/21 7:52	156881.5			223.1			42.63			81.64			25.68			1		
03/01/21 7:53	166046.4			328.7			48.68			127.31			31.02			1		
03/01/21 7:54	185300.4			737.7			51.89			318.86			36.91			1		
03/01/21 7:55	206248.8			718.8			58.84			345.8			46.58			1		
03/01/21 7:56	229738.6			326.5			65.04			174.98			57.37			1		
03/01/21 7:57	254537.8			69			71.06			40.96			69.42			1		
03/01/21 7:58	278720.8			6.4			77.86			4.14			83.29			1		
03/01/21 7:59	303288.9			1.4			80.32			1.03			93.51			1		
03/01/21 8:00	325161.4			1.3			83.17			1.01			103.81			1		
03/01/21 8:01	340718.7			1.4			86.39			1.12			112.98			1		
03/01/21 8:02	342336			1.7			79.44			1.37			104.39			1		
03/01/21 8:03	342875.1			1.9			64.56			1.48			84.98			1		
03/01/21 8:04	342644.1			1.9			51.73			1.5			68.04			1		
03/01/21 8:05	343414.2			1.8			39.16			1.44			51.62			1		
03/01/21 8:06	343491.3			1.7			29.93			1.37			39.46			1		
03/01/21 8:07	342490			1.5			21.55			1.23			28.33			1		
03/01/21 8:08	339486.4			1.5			11.37			1.15			14.82			1		
03/01/21 8:09	340102.5			1.4			11.97			1.1			15.63			1		
03/01/21 8:10	339794.5			1.3			12.32			1.03			16.07			1		
03/01/21 8:11	338870.3			1.2			12.06			0.96			15.69			1		
03/01/21 8:12	352579.1			1.1			11.8			0.93			15.97			1		
03/01/21 8:13	369676.7			1.1			10.24			0.97			14.53			1		
03/01/21 8:14	386235.1			1.1			9.49			1			14.07			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/01/21 8:15	393089.5			1.1			8.68			1.03			13.09			1		
03/01/21 8:16	399173.8			1.1			8.59			1.05			13.16			1		
03/01/21 8:17	416656.4			1			7.55			1.01			12.07			1		
03/01/21 8:18	429672.1			1.1			7.84			1.06			12.93			1		
03/01/21 8:19	443997.1			1			8.28			1			14.11			1		
03/01/21 8:20	450851.5			1			8.49			1.03			14.7			1		
03/01/21 8:21	463328.1			0.9			8.94			0.97			15.9			1		
03/01/21 8:22	477345			0.9			8.94			1			16.38			1		
03/01/21 8:23	486432.9			0.9			8.94			1.01			16.69			1		
03/01/21 8:24	496599			0.9			9.3			1.04			17.72			1		
03/01/21 8:25	504069.5			0.9			8.53			1.07			16.51			1		
03/01/21 8:26	512079.2			0.8			4.29			0.96			8.43			1		
03/01/21 8:27	511540.1			0.8			3.58			0.96			7.02			1		
03/01/21 8:28	508459.4			0.8			3.31			0.95			6.46			1		
03/01/21 8:29	507997.3			0.9			2.95			1.06			5.75			1		
03/01/21 8:30	507458.3			0.9			2.41			1.06			4.7			1		
03/01/21 8:31	508536.5			0.9			2.15			1.06			4.19			1		
03/01/21 8:32	508767.5			0.9			1.97			1.06			3.84			1		
03/01/21 8:33	508767.5			0.9			1.79			1.06			3.49			1		
03/01/21 8:34	508074.4			0.9			1.7			1.06			3.31			1		
03/01/21 8:35	506072			0.9			1.52			1.06			2.95			0		
03/01/21 8:36	506919.1			0.9			1.43			1.06			2.78			0		
03/01/21 8:37	507612.3			0.9			1.34			1.06			2.61			0		
03/01/21 8:38	506765.1			0.9			1.34			1.06			2.61			0		
03/01/21 8:39	506765.1			0.9			1.25			1.06			2.43			0		

CT2 SUSD EVENT 6

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/01/21 16:48	316150.6			0.7			0.55			0.54			0.67			0		
03/01/21 16:49	317382.8			0.6			0.65			0.48			0.79			0		
03/01/21 16:50	317228.8			0.6			0.65			0.48			0.79			0		
03/01/21 16:51	317536.8			0.6			0.74			0.48			0.9			0		
03/01/21 16:52	317228.8			0.6			0.74			0.48			0.9			0		
03/01/21 16:53	318076			0.6			0.83			0.48			1.01			1		
03/01/21 16:54	303674			0.6			0.92			0.46			1.07			1		
03/01/21 16:55	283880.9			0.6			1.66			0.43			1.81			1		
03/01/21 16:56	261161.2			0.7			4.09			0.41			4.1			1		
03/01/21 16:57	236670.1			0.6			7.4			0.33			6.72			1		
03/01/21 16:58	208251.2			0.4			10.05			0.21			8.04			1		
03/01/21 16:59	182527.9			5.5			11.43			2.35			8.01			1		
03/01/21 17:00	163427.9			399.9			12.64			152.46			7.93			1		
03/01/21 17:01	144327.9			1282.7			13.87			431.84			7.69			1		
03/01/21 17:02	45978.5			1924.7			15.3			206.37			2.7			1		
03/01/21 17:03	0			0			17.16			0			0			0		
03/01/21 17:04	0			0			5.9			0			0			0		
03/01/21 17:05	0			0			5.9			0			0			0		
03/01/21 17:06	0			0			5.9			0			0			0		
03/01/21 17:07	0			0			0			0			0			0		

CT2 SUSD EVENT 7

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/06/21 8:00	0			0			0			0			0			0		
03/06/21 8:01	0			0			0			0			0			0		
03/06/21 8:02	0			0			0			0			0			0		
03/06/21 8:03	0			0			0			0			0			0		
03/06/21 8:04	3157.7			0			0			0.04			0			0		
03/06/21 8:05	23720.9			5.9			0			0.33			0			1		
03/06/21 8:06	40279.4			41.3			5.9			3.88			0.91			1		
03/06/21 8:07	51600.7			664.4			13.16			79.87			2.6			1		
03/06/21 8:08	63538.2			744.6			13.87			110.34			3.38			1		
03/06/21 8:09	82407.1			628.1			16.52			120.62			5.22			1		
03/06/21 8:10	129925.9			473.1			16.63			143.28			8.29			1		
03/06/21 8:11	151875.5			344.5			19.97			121.99			11.64			1		
03/06/21 8:12	159423.1			224.4			29.13			83.38			17.81			1		
03/06/21 8:13	179062.1			391.8			31.16			163.56			21.41			1		
03/06/21 8:14	199779.4			643.6			37.25			299.81			28.56			1		
03/06/21 8:15	215875.8			405			48.68			203.82			40.31			1		
03/06/21 8:16	219572.5			125.1			61.82			64.05			52.08			1		
03/06/21 8:17	221497.9			55.3			64.77			28.55			55.05			1		
03/06/21 8:18	221497.9			48			65.78			24.76			55.9			1		
03/06/21 8:19	220804.8			53.5			61.51			27.53			52.12			1		
03/06/21 8:20	220188.7			56.1			54.98			28.8			46.45			1		
03/06/21 8:21	220188.7			63.3			52.85			32.47			44.64			1		
03/06/21 8:22	220034.6			70.9			49.71			36.39			41.97			1		
03/06/21 8:23	219341.5			73.4			45.57			37.55			38.34			1		
03/06/21 8:24	219110.4			76.1			41.17			38.86			34.61			1		
03/06/21 8:25	217570.1			84.4			38.04			42.79			31.75			1		
03/06/21 8:26	218186.3			89.1			35.27			45.33			29.52			1		
03/06/21 8:27	217878.2			90			34.02			45.71			28.44			1		
03/06/21 8:28	216491.9			93			33.22			46.94			27.6			1		
03/06/21 8:29	217262.1			94.4			32.19			47.82			26.84			1		
03/06/21 8:30	226812			95.8			31.68			50.66			27.57			1		
03/06/21 8:31	248453.5			61.8			31.89			35.78			30.4			1		
03/06/21 8:32	256848.3			6.1			33.43			3.67			32.95			1		
03/06/21 8:33	256925.3			0.9			32.01			0.52			31.56			1		
03/06/21 8:34	258234.6			0.8			31.75			0.45			31.45			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/06/21 8:35	258542.6			0.8			32.4			0.45			32.14			1		
03/06/21 8:36	258388.6			0.6			32.72			0.39			32.44			1		
03/06/21 8:37	258234.6			0.5			32.93			0.32			32.62			1		
03/06/21 8:38	257772.5			0.5			33.25			0.32			32.89			1		
03/06/21 8:39	260545			0.5			33.79			0.33			33.79			1		
03/06/21 8:40	270095			0.5			34.43			0.34			35.68			1		
03/06/21 8:41	272174.4			0.5			34.26			0.33			35.78			1		
03/06/21 8:42	272020.4			0.5			32.96			0.32			34.4			1		
03/06/21 8:43	272174.4			0.5			31.9			0.32			33.32			1		
03/06/21 8:44	271404.3			0.5			32.3			0.32			33.64			1		
03/06/21 8:45	270172			0.5			32.9			0.31			34.11			1		
03/06/21 8:46	272020.4			0.5			33.57			0.32			35.03			1		
03/06/21 8:47	270480.1			0.5			29.1			0.32			30.2			1		
03/06/21 8:48	270865.2			0.5			28.5			0.32			29.62			1		
03/06/21 8:49	270480.1			0.5			26.3			0.32			27.29			1		
03/06/21 8:50	271404.3			0.4			25.3			0.25			26.35			1		
03/06/21 8:51	270557.1			0.4			25.4			0.25			26.37			1		
03/06/21 8:52	271096.2			0.4			25.6			0.25			26.63			1		
03/06/21 8:53	270480.1			0.3			25.8			0.19			26.77			1		
03/06/21 8:54	266706.3			0.3			18.7			0.19			19.14			1		
03/06/21 8:55	276333.3			0.3			16.89			0.2			17.9			1		
03/06/21 8:56	286114.3			0.4			14.3			0.27			15.7			1		
03/06/21 8:57	287654.7			0.4			11.12			0.26			12.28			1		
03/06/21 8:58	294047			0.5			7.04			0.33			7.95			1		
03/06/21 8:59	296819.6			0.5			4.78			0.32			5.44			1		
03/06/21 9:00	296203.4			0.5			3.04			0.32			3.46			1		
03/06/21 9:01	295125.2			0.6			2.77			0.38			3.13			1		
03/06/21 9:02	295125.2			0.6			2.3			0.38			2.61			1		
03/06/21 9:03	294817.2			0.6			2.3			0.38			2.61			1		
03/06/21 9:04	293430.8			0.6			2.21			0.38			2.49			1		
03/06/21 9:05	295356.3			0.6			2.03			0.38			2.3			1		
03/06/21 9:06	295356.3			0.6			1.75			0.38			1.98			1		
03/06/21 9:07	293584.9			0.6			1.57			0.38			1.77			1		
03/06/21 9:08	295356.3			0.6			1.48			0.38			1.67			1		
03/06/21 9:09	294740.1			0.6			1.38			0.38			1.56			0		
03/06/21 9:10	293507.9			0.6			1.38			0.38			1.56			0		
03/06/21 9:11	310759.4			0.6			1.38			0.4			1.65			0		
03/06/21 9:12	317998.9			0.5			1.36			0.4			1.66			0		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/06/21 9:13	318076			0.5			1.07			0.4			1.31			0		

CT2 SUSD EVENT 8

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/06/21 16:52	395477			0.8			1.67			0.73			2.54			0		
03/06/21 16:53	376608.1			0.8			1.74			0.69			2.51			0		
03/06/21 16:54	368521.4			0.9			1.91			0.75			2.7			0		
03/06/21 16:55	366827.1			1			1.91			0.82			2.69			0		
03/06/21 16:56	357970.3			1			1.91			0.8			2.62			0		
03/06/21 16:57	336790.8			0.9			1.91			0.68			2.47			1		
03/06/21 16:58	317151.8			0.8			1.85			0.59			2.25			1		
03/06/21 16:59	292506.7			0.9			1.7			0.61			1.91			1		
03/06/21 17:00	268477.7			0.7			2.21			0.46			2.28			1		
03/06/21 17:01	245681			0.7			5.42			0.39			5.11			1		
03/06/21 17:02	219957.6			0.5			13.8			0.27			11.65			1		
03/06/21 17:03	195466.5			2.1			17.82			0.95			13.36			1		
03/06/21 17:04	173054.9			173.2			20.98			69.86			13.93			1		
03/06/21 17:05	152953.7			801.1			23.9			285.65			14.02			1		
03/06/21 17:06	124765.9			1574.3			26.3			457.77			12.58			1		
03/06/21 17:07	0			0			30.31			0			0			1		
03/06/21 17:08	0			0			17.7			0			0			0		
03/06/21 17:09	0			0			17.7			0			0			0		
03/06/21 17:10	0			0			11.8			0			0			0		
03/06/21 17:11	0			0			11.8			0			0			0		
03/06/21 17:12	0			0			5.9			0			0			0		

CT2 SUSD EVENT 9

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/12/21 14:52	0			0			0			0			0			0		
03/12/21 14:53	0			0			0			0			0			0		
03/12/21 14:54	0			0			0			0			0			0		
03/12/21 14:55	0			0			0			0			0			0		
03/12/21 14:56	6315.3			0			0			0			0			0		
03/12/21 14:57	0			0			0			0			0			0		
03/12/21 14:58	11398.4			0.1			0			0			0			1		
03/12/21 14:59	27340.7			0.3			0			0			0			1		
03/12/21 15:00	40972.5			59.8			6.74			5.72			1.06			1		
03/12/21 15:01	22488.7			1003.9			7.08			52.58			0.61			1		
03/12/21 15:02	0			0			8.96			0			0			0		
03/12/21 15:03	0			0			8.26			0			0			0		
03/12/21 15:04	0			0			8.19			0			0			0		
03/12/21 15:05	0			0			16.52			0			0			0		
03/12/21 15:06	0			0			23.6			0			0			0		

CT2 SUSD EVENT 10

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/12/21 14:52	0			0			0			0			0			0		
03/12/21 14:53	0			0			0			0			0			0		
03/12/21 14:54	0			0			0			0			0			0		
03/12/21 14:55	0			0			0			0			0			0		
03/12/21 14:56	6315.3			0			0			0			0			0		
03/12/21 14:57	0			0			0			0			0			0		
03/12/21 14:58	11398.4			0.1			0			0			0			1		
03/12/21 14:59	27340.7			0.3			0			0			0			1		
03/12/21 15:00	40972.5			59.8			6.74			5.72			1.06			1		
03/12/21 15:01	22488.7			1003.9			7.08			52.58			0.61			1		
03/12/21 15:02	0			0			8.96			0			0			0		
03/12/21 15:03	0			0			8.26			0			0			0		
03/12/21 15:04	0			0			8.19			0			0			0		
03/12/21 15:05	0			0			16.52			0			0			0		
03/12/21 15:06	0			0			23.6			0			0			0		

CT2 SUSD EVENT 11

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/12/21 15:21	0			0			17.7			0			0			0		
03/12/21 15:22	0			0			17.7			0			0			0		
03/12/21 15:23	0			0			11.8			0			0			0		
03/12/21 15:24	0			0			11.8			0			0			0		
03/12/21 15:25	5853.2			0			11.8			0.24			0.27			0		
03/12/21 15:26	0			17.7			11.8			0			0			1		
03/12/21 15:27	17713.7			11.8			5.9			0.49			0.4			1		
03/12/21 15:28	29343.1			82.6			5.9			5.66			0.67			1		
03/12/21 15:29	3388.7			1227.7			9.65			9.62			0.12			1		
03/12/21 15:30	0			0			10.62			0			0			0		
03/12/21 15:31	0			0			9.27			0			0			0		
03/12/21 15:32	0			0			11.8			0			0			0		
03/12/21 15:33	0			0			25.57			0			0			0		
03/12/21 15:34	0			0			29.5			0			0			0		

CT2 SUSD EVENT 12

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/12/21 15:21	0			0			17.7			0			0			0		
03/12/21 15:22	0			0			17.7			0			0			0		
03/12/21 15:23	0			0			11.8			0			0			0		
03/12/21 15:24	0			0			11.8			0			0			0		
03/12/21 15:25	5853.2			0			11.8			0.24			0.27			0		
03/12/21 15:26	0			17.7			11.8			0			0			1		
03/12/21 15:27	17713.7			11.8			5.9			0.49			0.4			1		
03/12/21 15:28	29343.1			82.6			5.9			5.66			0.67			1		
03/12/21 15:29	3388.7			1227.7			9.65			9.62			0.12			1		
03/12/21 15:30	0			0			10.62			0			0			0		
03/12/21 15:31	0			0			9.27			0			0			0		
03/12/21 15:32	0			0			11.8			0			0			0		
03/12/21 15:33	0			0			25.57			0			0			0		
03/12/21 15:34	0			0			29.5			0			0			0		

CT2 SUSD EVENT 13

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/12/21 15:46	0			0			11.8			0			0			0		
03/12/21 15:47	0			0			11.8			0			0			0		
03/12/21 15:48	0			0			5.9			0			0			0		
03/12/21 15:49	5083.1			0			5.9			0.21			0.12			0		
03/12/21 15:50	1232.3			0			5.9			0.05			0.03			0		
03/12/21 15:51	14093.9			11.8			5.9			0.39			0.32			1		
03/12/21 15:52	25492.3			35.4			5.9			2.1			0.58			1		
03/12/21 15:53	39355.2			1230.9			14.01			112.97			2.12			1		
03/12/21 15:54	51061.6			1170.2			15.34			139.35			3.01			1		
03/12/21 15:55	62305.9			714.2			17.39			103.76			4.16			1		
03/12/21 15:56	42897.9			479.3			16.3			47.96			2.68			1		
03/12/21 15:57	0			0			18.5			0			0			0		
03/12/21 15:58	0			0			15.73			0			0			0		
03/12/21 15:59	0			0			47.2			0			0			0		
03/12/21 16:00	0			0			82.6			0			0			0		
03/12/21 16:01	0			0			82.6			0			0			0		

CT2 SUSD EVENT 14

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/12/21 15:46	0			0			11.8			0			0			0		
03/12/21 15:47	0			0			11.8			0			0			0		
03/12/21 15:48	0			0			5.9			0			0			0		
03/12/21 15:49	5083.1			0			5.9			0.21			0.12			0		
03/12/21 15:50	1232.3			0			5.9			0.05			0.03			0		
03/12/21 15:51	14093.9			11.8			5.9			0.39			0.32			1		
03/12/21 15:52	25492.3			35.4			5.9			2.1			0.58			1		
03/12/21 15:53	39355.2			1230.9			14.01			112.97			2.12			1		
03/12/21 15:54	51061.6			1170.2			15.34			139.35			3.01			1		
03/12/21 15:55	62305.9			714.2			17.39			103.76			4.16			1		
03/12/21 15:56	42897.9			479.3			16.3			47.96			2.68			1		
03/12/21 15:57	0			0			18.5			0			0			0		
03/12/21 15:58	0			0			15.73			0			0			0		
03/12/21 15:59	0			0			47.2			0			0			0		
03/12/21 16:00	0			0			82.6			0			0			0		
03/12/21 16:01	0			0			82.6			0			0			0		

CT2 SUSD EVENT 15

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/12/21 17:06	0			0			17.7			0			0			0		
03/12/21 17:07	0			0			17.7			0			0			0		
03/12/21 17:08	0			0			17.7			0			0			0		
03/12/21 17:09	0			0			11.8			0			0			0		
03/12/21 17:10	0			0			11.8			0			0			0		
03/12/21 17:11	13015.7			5.9			11.8			0.18			0.59			1		
03/12/21 17:12	26878.6			88.5			23.6			5.55			2.43			1		
03/12/21 17:13	39663.2			1161.6			20.98			107.39			3.19			1		
03/12/21 17:14	51600.7			1178.4			22.42			141.65			4.44			1		
03/12/21 17:15	63230.1			712.3			23.91			105.08			5.8			1		
03/12/21 17:16	42512.8			484.4			25.85			48.03			4.22			1		
03/12/21 17:17	0			0			26.01			0			0			0		
03/12/21 17:18	0			0			21.83			0			0			0		
03/12/21 17:19	0			0			112.1			0			0			0		
03/12/21 17:20	0			0			106.2			0			0			0		
03/12/21 17:21	0			0			100.3			0			0			0		

CT2 SUSD EVENT 16

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/12/21 17:06	0			0			17.7			0			0			0		
03/12/21 17:07	0			0			17.7			0			0			0		
03/12/21 17:08	0			0			17.7			0			0			0		
03/12/21 17:09	0			0			11.8			0			0			0		
03/12/21 17:10	0			0			11.8			0			0			0		
03/12/21 17:11	13015.7			5.9			11.8			0.18			0.59			1		
03/12/21 17:12	26878.6			88.5			23.6			5.55			2.43			1		
03/12/21 17:13	39663.2			1161.6			20.98			107.39			3.19			1		
03/12/21 17:14	51600.7			1178.4			22.42			141.65			4.44			1		
03/12/21 17:15	63230.1			712.3			23.91			105.08			5.8			1		
03/12/21 17:16	42512.8			484.4			25.85			48.03			4.22			1		
03/12/21 17:17	0			0			26.01			0			0			0		
03/12/21 17:18	0			0			21.83			0			0			0		
03/12/21 17:19	0			0			112.1			0			0			0		
03/12/21 17:20	0			0			106.2			0			0			0		
03/12/21 17:21	0			0			100.3			0			0			0		

CT2 SUSD EVENT 17

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/13/21 11:39	0			0	X		0	X		0	X		0	X		0		
03/13/21 11:40	0			0	X		0	X		0	X		0	X		0		
03/13/21 11:41	0			0	X		0	X		0	X		0	X		0		
03/13/21 11:42	3003.6			0	X		0	X		0.08	X		0	X		0		
03/13/21 11:43	0			0	X		0	X		0	X		0	X		0		
03/13/21 11:44	19639.1			5.9	X		0	X		0.27	X		0	X		1		
03/13/21 11:45	30190.3			70.8	X		5.9	X		4.98	X		0.68	X		1		
03/13/21 11:46	43051.9			1161.1	X		10.03	X		116.44	X		1.66	X		1		
03/13/21 11:47	54604.3			1125.1	X		12.91	X		143.3	X		2.71	X		1		
03/13/21 11:48	66926.9			747.1	X		17.39	X		116.57	X		4.47	X		1		
03/13/21 11:49	96501			517.5	X		21.07	X		116.42	X		7.8	X		1		
03/13/21 11:50	144405			360.9	X		22.37	X		121.5	X		12.4	X		1		
03/13/21 11:51	155726.3			210	X		44.25	X		76.26	X		26.44	X		1		
03/13/21 11:52	161040.4			1037	X		43.27	X		389.27	X		26.73	X		1		
03/13/21 11:53	160886.4			1814.6	X		46.33	X		680.78	X		28.61	X		1		
03/13/21 11:54	169820.2			1832.5	X		51.02	X		725.63	X		33.25	X		1		
03/13/21 11:55	187842			1747.1	X		53.77	X		764.94	X		38.75	X		1		
03/13/21 11:56	212641.1			962.8	X		61.17	X		477.37	X		49.92	X		1		
03/13/21 11:57	237440.3			254.7	X		59	X		140.97	X		53.75	X		1		
03/13/21 11:58	260160			26.7	X		51.78	X		16.22	X		51.69	X		1		
03/13/21 11:59	287115.5			3.5	X		46.98	X		2.34	X		51.75	X		1		
03/13/21 12:00	313224			2.4	X		40.1	X		1.75	X		48.19	X		1		
03/13/21 12:01	336251.8			2.2	X		21.42	X		1.71	X		27.64	X		1		
03/13/21 12:02	357277.1			2.1	X		15.13	X		1.78	X		20.75	X		1		
03/13/21 12:03	376377.1			2.3	X		14.54	X		2.03	X		20.99	X		1		
03/13/21 12:04	394629.8			2.4	X		13.6	X		2.2	X		20.59	X		1		
03/13/21 12:05	417041.5			2.3	X		10.93	X		2.28	X		17.49	X		1		
03/13/21 12:06	440531.4			2.1	X		9.95	X		2.17	X		16.82	X		1		
03/13/21 12:07	463328.1			1.8	X		9.12	X		1.93	X		16.21	X		1		
03/13/21 12:08	491670			1.5	X		8.49	X		1.74	X		16.02	X		1		
03/13/21 12:09	496676			1.5	X		8.35	X		1.68	X		15.91	X		1		
03/13/21 12:10	494211.5			1.3	X		9.48	X		1.54	X		17.97	X		1		
03/13/21 12:11	490360.7			1.3	X		9.21	X		1.43	X		17.32	X		1		
03/13/21 12:12	491824			1.3	X		9.12	X		1.43	X		17.21	X		1		
03/13/21 12:13	491824			1.2	X		8.94	X		1.33	X		16.87	X		1		

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/13/21 12:14	490514.7			1.2	X		8.94	X		1.33	X		16.83	X		1		
03/13/21 12:15	492825.2			1.1	X		9.03	X		1.23	X		17.07	X		1		
03/13/21 12:16	492517.2			1.1	X		9.12	X		1.23	X		17.23	X		1		
03/13/21 12:17	491592.9			1	X		9.3	X		1.13	X		17.54	X		1		
03/13/21 12:18	490129.7			1	X		9.57	X		1.12	X		17.99	X		1		
03/13/21 12:19	490745.8			1	X		9.71	X		1.14	X		18.29	X		1		
03/13/21 12:20	491901			0.9	X		9.62	X		1.04	X		18.16	X		1		
03/13/21 12:21	491592.9			0.9	X		9.8	X		1.04	X		18.49	X		1		
03/13/21 12:22	490822.8			0.9	X		7.15	X		1.02	X		13.47	X		1		
03/13/21 12:23	490437.7			0.9	X		4.83	X		1.02	X		9.08	X		1		
03/13/21 12:24	489359.5			0.9	X		4.47	X		1.02	X		8.39	X		1		
03/13/21 12:25	488050.2			0.8	X		4.27	X		0.93	X		7.99	X		1		
03/13/21 12:26	489667.6			0.8	X		3.99	X		0.93	X		7.5	X		1		
03/13/21 12:27	488666.3			0.8	X		3.63	X		0.93	X		6.81	X		1		
03/13/21 12:28	487973.2			0.8	X		3.4	X		0.92	X		6.36	X		1		
03/13/21 12:29	487819.2			0.8	X		3.31	X		0.92	X		6.19	X		1		
03/13/21 12:30	490437.7			0.8	X		3.09	X		0.93	X		5.81	X		1		
03/13/21 12:31	491515.9			0.8	X		2.9	X		0.94	X		5.48	X		1		
03/13/21 12:32	489744.6			0.8	X		2.77	X		0.92	X		5.21	X		1		
03/13/21 12:33	489590.5			0.8	X		3.18	X		0.93	X		5.97	X		1		
03/13/21 12:34	486586.9			0.8	X		2.72	X		0.93	X		5.08	X		1		
03/13/21 12:35	486818			0.8	X		2.63	X		0.93	X		4.92	X		1		
03/13/21 12:36	488743.4			0.8	X		2.54	X		0.93	X		4.77	X		1		
03/13/21 12:37	488589.3			0.8	X		2.45	X		0.93	X		4.59	X		1		
03/13/21 12:38	485970.8			0.8	X		2.36	X		0.93	X		4.4	X		1		
03/13/21 12:39	488512.3			0.8	X		2.36	X		0.93	X		4.42	X		1		
03/13/21 12:40	489744.6			0.8	X		2.27	X		0.93	X		4.26	X		1		
03/13/21 12:41	489898.6			0.8	X		2.18	X		0.93	X		4.09	X		1		
03/13/21 12:42	487742.2			0.8	X		2.09	X		0.93	X		3.91	X		1		
03/13/21 12:43	489744.6			0.7	X		2.09	X		0.83	X		3.92	X		1		
03/13/21 12:44	490899.8			0.8	X		2.09	X		0.93	X		3.93	X		1		
03/13/21 12:45	489667.6			0.8	X		2.06	X		0.92	X		3.86	X		1		
03/13/21 12:46	486432.9			0.8	X		2.06	X		0.91	X		3.84	X		0		
03/13/21 12:47	486895			0.8	X		2	X		0.93	X		3.73	X		0		
03/13/21 12:48	486740.9			0.8	X		2	X		0.93	X		3.73	X		0		
03/13/21 12:49	486740.9			0.7	X		1.91	X		0.82	X		3.56	X		0		
03/13/21 12:50	486509.9			0.8	X		1.91	X		0.93	X		3.56	X		0		

CT2 SUSD EVENT 18

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/13/21 21:55	412497.6			0.9			1.48			0.83			2.33			0		
03/13/21 21:56	400406			0.9			1.48			0.81			2.27			0		
03/13/21 21:57	382076.3			0.9			1.48			0.77			2.16			0		
03/13/21 21:58	356661			0.9			1.54			0.71			2.11			0		
03/13/21 21:59	336944.9			0.9			1.62			0.74			2.1			0		
03/13/21 22:00	328088			1			1.82			0.73			2.29			1		
03/13/21 22:01	306677.6			0.9			1.85			0.63			2.18			1		
03/13/21 22:02	281955.5			0.8			2.63			0.54			2.85			1		
03/13/21 22:03	258927.7			0.7			5.14			0.4			5.11			1		
03/13/21 22:04	236054			0.5			5.59			0.28			5.06			1		
03/13/21 22:05	209560.5			2.1			22.71			1.03			18.26			1		
03/13/21 22:06	184838.3			2.4			26.49			1.03			18.78			1		
03/13/21 22:07	166816.6			559.4			30.34			217.5			19.42			1		
03/13/21 22:08	146715.4			1347			33.49			460.71			18.85			1		
03/13/21 22:09	38508			1866.8			36.32			167.57			5.37			1		
03/13/21 22:10	0			0			34.33			0			0			0		
03/13/21 22:11	0			0			17.7			0			0			0		
03/13/21 22:12	0			0			11.8			0			0			0		
03/13/21 22:13	0			0			11.8			0			0			0		
03/13/21 22:14	0			0			11.8			0			0			0		

CT2 SUSD EVENT 19

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/22/21 5:34	0			0			0			0			0			0		
03/22/21 5:35	0			0			0			0			0			0		
03/22/21 5:36	0			0			0			0			0			0		
03/22/21 5:37	0			0			0			0			0			0		
03/22/21 5:38	3311.7			0			0			0.04			0			0		
03/22/21 5:39	8471.8			5.9			0			0.12			0			1		
03/22/21 5:40	21564.5			5.9			0			0.3			0			1		
03/22/21 5:41	34118.1			41.3			2.95			3.28			0.39			1		
03/22/21 5:42	47133.8			1227.2			7.87			134.88			1.42			1		
03/22/21 5:43	59225.3			1012.4			13.19			139.82			3			1		
03/22/21 5:44	73396.2			721.7			17.7			123.42			4.98			1		
03/22/21 5:45	111827.2			524.5			20.23			136.79			8.68			1		
03/22/21 5:46	153338.8			377.6			22.37			134.99			13.16			1		
03/22/21 5:47	157343.6			274.6			32.93			100.76			19.88			1		
03/22/21 5:48	166662.6			1527.5			27.84			593.6			17.81			1		
03/22/21 5:49	184145.2			1899.1			31.11			815.35			21.98			1		
03/22/21 5:50	206017.7			1442.9			36.88			693.12			29.15			1		
03/22/21 5:51	228968.5			597.6			44.32			319.06			38.94			1		
03/22/21 5:52	254768.8			104.8			50.79			62.23			49.64			1		
03/22/21 5:53	277180.5			8.5			62.4			5.5			66.37			1		
03/22/21 5:54	289888.1			2.4			79.91			1.61			88.87			1		
03/22/21 5:55	296280.4			2			64.03			1.4			72.79			1		
03/22/21 5:56	296049.4			1.9			30.81			1.29			34.99			1		
03/22/21 5:57	293507.9			1.7			23.41			1.15			26.37			1		
03/22/21 5:58	292352.6			1.6			23.04			1.09			25.84			1		
03/22/21 5:59	292506.7			1.4			22.57			0.96			25.33			1		
03/22/21 6:00	290504.3			1.3			22.2			0.89			24.74			1		
03/22/21 6:01	290812.3			1.2			21.26			0.83			23.72			1		
03/22/21 6:02	291890.5			1.2			20.23			0.83			22.65			1		
03/22/21 6:03	290812.3			1.1			19.48			0.76			21.74			1		
03/22/21 6:04	289040.9			1			18.82			0.69			20.87			1		
03/22/21 6:05	289349			0.9			18.26			0.63			20.28			1		
03/22/21 6:06	288347.8			0.9			18.18			0.58			20.11			1		
03/22/21 6:07	285498.2			0.9			17.89			0.57			19.59			1		
03/22/21 6:08	288039.8			0.8			20.75			0.51			22.93			1		

CT2_GasFlow_CT_scfh_1M				CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/22/21 6:09	291582.5			0.8			19.32			0.52			21.61			1		
03/22/21 6:10	290273.2			0.7			16.76			0.51			18.67			1		
03/22/21 6:11	288963.9			0.7			16.67			0.5			18.48			1		
03/22/21 6:12	289811.1			0.8			17.22			0.51			19.15			1		
03/22/21 6:13	288578.8			0.7			17.7			0.45			19.6			1		
03/22/21 6:14	288424.8			0.7			17.89			0.45			19.8			1		
03/22/21 6:15	288116.8			0.7			18.08			0.45			19.99			1		
03/22/21 6:16	288732.9			0.7			18.18			0.45			20.13			1		
03/22/21 6:17	286961.5			0.6			18.27			0.38			20.12			1		
03/22/21 6:18	287654.7			0.7			18.27			0.45			20.17			1		
03/22/21 6:19	287269.6			0.7			18.37			0.45			20.24			1		
03/22/21 6:20	286114.3			0.6			18.46			0.38			20.27			1		
03/22/21 6:21	287192.6			0.6			18.65			0.38			20.55			1		
03/22/21 6:22	286807.5			0.6			18.84			0.38			20.73			1		
03/22/21 6:23	286345.4			0.6			19.03			0.38			20.91			1		
03/22/21 6:24	287269.6			0.5			19.13			0.32			21.08			1		
03/22/21 6:25	286422.4			0.6			19.22			0.38			21.12			1		
03/22/21 6:26	286730.5			0.6			19.32			0.38			21.25			1		
03/22/21 6:27	286807.5			0.6			13.13			0.38			14.45			1		
03/22/21 6:28	287192.6			0.6			7.42			0.38			8.18			1		
03/22/21 6:29	285883.3			0.6			5.8			0.38			6.37			1		
03/22/21 6:30	287423.6			0.6			4.76			0.38			5.25			1		
03/22/21 6:31	286191.3			0.5			4.19			0.32			4.6			1		
03/22/21 6:32	285421.2			0.5			3.62			0.32			3.96			1		
03/22/21 6:33	285498.2			0.5			3.33			0.32			3.65			1		
03/22/21 6:34	284882.1			0.5			2.95			0.32			3.22			1		
03/22/21 6:35	286191.3			0.5			2.66			0.32			2.93			1		
03/22/21 6:36	285113.1			0.5			2.38			0.32			2.6			1		
03/22/21 6:37	283572.8			0.5			2.19			0.31			2.38			1		
03/22/21 6:38	286191.3			0.5			2			0.32			2.19			1		
03/22/21 6:39	285267.2			0.5			1.81			0.32			1.98			1		
03/22/21 6:40	286114.3			0.5			1.71			0.32			1.88			1		
03/22/21 6:41	284728.1			0.5			1.62			0.32			1.77			0		
03/22/21 6:42	284805.1			0.5			1.52			0.32			1.66			0		
03/22/21 6:43	286268.4			0.5			1.43			0.32			1.57			0		
03/22/21 6:44	285960.3			0.5			1.33			0.32			1.46			0		
03/22/21 6:45	286037.3			0.4			1.33			0.25			1.46			0		

CT2 SUSD EVENT 20

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/22/21 7:46	284420			0.4			1.71			0.25			1.87			0		
03/22/21 7:47	285113.1			0.4			1.81			0.25			1.98			0		
03/22/21 7:48	284959.1			0.5			1.81			0.32			1.98			0		
03/22/21 7:49	284805.1			0.5			1.81			0.32			1.98			0		
03/22/21 7:50	286422.4			0.5			1.81			0.32			1.99			0		
03/22/21 7:51	198547.2			0.5			1.81			0.22			1.38			1		
03/22/21 7:52	0			0			1.57			0			0			0		
03/22/21 7:53	0			0			2.95			0			0			0		
03/22/21 7:54	0			0			5.9			0			0			0		
03/22/21 7:55	0			0			5.9			0			0			0		
03/22/21 7:56	0			0			5.9			0			0			0		

CT2 SUSD EVENT 21

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/22/21 8:03	0			0			5.9			0			0			0		
03/22/21 8:04	0			0			5.9			0			0			0		
03/22/21 8:05	0			0			5.9			0			0			0		
03/22/21 8:06	0			0			5.9			0			0			0		
03/22/21 8:07	0			0			5.9			0			0			0		
03/22/21 8:08	11860.5			0			0			0			0			1		
03/22/21 8:09	26185.4			35.4			0			2.16			0			1		
03/22/21 8:10	40510.4			356.5			0.49			33.67			0.08			1		
03/22/21 8:11	52293.8			476.4			1.11			58.12			0.22			1		
03/22/21 8:12	65155.5			322.2			1.64			48.97			0.41			1		
03/22/21 8:13	100274.8			235.7			2.36			55.08			0.91			1		
03/22/21 8:14	140862.2			185			4.1			60.74			2.22			1		
03/22/21 8:15	155418.2			161.5			6.71			58.54			4			1		
03/22/21 8:16	170513.4			1455.3			9.4			578.54			6.15			1		
03/22/21 8:17	190383.5			1593.5			11.45			707.34			8.37			1		
03/22/21 8:18	213950.4			731.6			12.71			364.87			10.43			1		
03/22/21 8:19	237748.3			169.4			13.28			93.86			12.11			1		
03/22/21 8:20	259389.8			18.7			15.89			11.29			15.82			1		
03/22/21 8:21	286268.4			2.3			17.37			1.53			19.08			1		
03/22/21 8:22	313146.9			1.5			9.8			1.09			11.77			1		
03/22/21 8:23	335019.5			1.3			6.17			0.99			7.93			1		
03/22/21 8:24	357046.1			1.2			3.51			1			4.8			1		
03/22/21 8:25	375837.9			1.3			3.16			1.12			4.56			1		
03/22/21 8:26	396401.2			1.3			2.22			1.19			3.38			1		
03/22/21 8:27	418196.7			1.2			1.74			1.18			2.78			1		
03/22/21 8:28	438297.9			1.1			1.59			1.08			2.67			1		
03/22/21 8:29	457860			1			1.5			1.03			2.63			1		
03/22/21 8:30	460016.4			0.9			1.61			0.96			2.84			0		
03/22/21 8:31	461556.7			0.9			1.67			0.95			2.96			0		
03/22/21 8:32	462866			0.9			1.76			0.95			3.13			0		
03/22/21 8:33	461556.7			0.9			1.85			0.95			3.27			0		
03/22/21 8:34	461787.8			0.9			1.76			0.95			3.12			0		

CT2 SUSD EVENT 22

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/23/21 13:52	480656.7			0.7			1.34			0.8			2.47			0		
03/23/21 13:53	458476.1			0.7			1.34			0.76			2.36			0		
03/23/21 13:54	435217.3			0.8			1.41			0.8			2.35			0		
03/23/21 13:55	411573.3			0.8			1.3			0.75			2.06			0		
03/23/21 13:56	388622.6			0.9			1.28			0.77			1.91			0		
03/23/21 13:57	364285.6			0.9			1.28			0.73			1.79			1		
03/23/21 13:58	341103.8			0.9			1.37			0.75			1.79			1		
03/23/21 13:59	317767.9			0.9			1.45			0.7			1.77			1		
03/23/21 14:00	293815.9			0.9			1.67			0.6			1.89			1		
03/23/21 14:01	268169.6			0.8			2.45			0.51			2.52			1		
03/23/21 14:02	246528.1			0.6			5.9			0.34			5.58			1		
03/23/21 14:03	220188.7			0.5			18.34			0.28			15.5			1		
03/23/21 14:04	195389.5			4.4			22.77			1.99			17.07			1		
03/23/21 14:05	173748			273.1			26.35			110.65			17.57			1		
03/23/21 14:06	154109			1017.2			30.56			365.46			18.07			1		
03/23/21 14:07	114753.8			1696.7			33.04			453.85			14.55			1		
03/23/21 14:08	0			0			38.24			0			0			0		
03/23/21 14:09	0			0			32.45			0			0			0		
03/23/21 14:10	0			0			17.7			0			0			0		
03/23/21 14:11	0			0			17.7			0			0			0		
03/23/21 14:12	0			0			11.8			0			0			0		

CT2 SUSD EVENT 23

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/24/21 8:39	0			0			0			0			0			0		
03/24/21 8:40	0			0			0			0			0			0		
03/24/21 8:41	0			0			0			0			0			0		
03/24/21 8:42	0			0			0			0			0			0		
03/24/21 8:43	0			0			0			0			0			0		
03/24/21 8:44	10782.2			0.1			0			0			0			1		
03/24/21 8:45	25415.3			47.2			0			2.8			0			1		
03/24/21 8:46	38970.1			76.7			17.7			6.97			2.65			1		
03/24/21 8:47	51523.7			1141.7			13.64			137.23			2.7			1		
03/24/21 8:48	63384.1			847.6			21.31			125.23			5.18			1		
03/24/21 8:49	82330.1			584.4			25.96			112.11			8.2			1		
03/24/21 8:50	130619.1			452.7			30.84			137.81			15.45			1		
03/24/21 8:51	155033.2			279.5			44.14			101.04			26.26			1		
03/24/21 8:52	162888.8			565.7			52.18			214.75			32.6			1		
03/24/21 8:53	177444.8			1786.1			51.31			738.85			34.93			1		
03/24/21 8:54	198162.1			1505.7			55.46			695.65			42.17			1		
03/24/21 8:55	223115.3			669.5			53.99			348.29			46.22			1		
03/24/21 8:56	247529.3			143.4			54.67			82.77			51.92			1		
03/24/21 8:57	269941			13.1			58.76			8.24			60.85			1		
03/24/21 8:58	287577.6			2.4			79.76			1.62			88			1		
03/24/21 8:59	294971.2			2.1			63.23			1.42			71.56			1		
03/24/21 9:00	295741.3			2			39.05			1.36			44.31			1		
03/24/21 9:01	308603			2			19.76			1.41			23.4			1		
03/24/21 9:02	331784.8			1.8			17.34			1.4			22.07			1		
03/24/21 9:03	351654.9			1.6			13.28			1.35			17.91			1		
03/24/21 9:04	371987.2			1.6			11.37			1.41			16.23			1		
03/24/21 9:05	387467.3			1.6			11.29			1.47			16.78			1		
03/24/21 9:06	391857.3			1.5			9.8			1.35			14.74			1		
03/24/21 9:07	392473.4			1.4			9.72			1.27			14.63			1		
03/24/21 9:08	392011.3			1.3			9.63			1.19			14.49			1		
03/24/21 9:09	393320.6			1.2			9.46			1.11			14.27			1		
03/24/21 9:10	391472.2			1.2			9.46			1.11			14.2			1		
03/24/21 9:11	390471			1.2			7.81			1.11			11.7			1		
03/24/21 9:12	387544.4			1.1			7.64			1.02			11.35			1		
03/24/21 9:13	386774.2			1.1			8.24			1.02			12.23			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSDTF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/24/21 9:14	387313.3			1			9.2	X		0.94			13.67	X		1		
03/24/21 9:15	385696			1			9.2	X		0.94			13.61	X		1		
03/24/21 9:16	381922.2			1			9.11	X		0.93			13.35	X		1		
03/24/21 9:17	362976.3			1			9.02			0.88			12.57			1		
03/24/21 9:18	349806.5			1			10.26			0.84			13.77			1		
03/24/21 9:19	339948.5			1			10.24			0.83			13.36			1		
03/24/21 9:20	336251.8			1			9.54			0.82			12.31			1		
03/24/21 9:21	336251.8			1			9.16			0.76			11.82			1		
03/24/21 9:22	335558.6			0.9			9.25			0.69			11.91			1		
03/24/21 9:23	335019.5			0.9			7.75			0.69			9.96			1		
03/24/21 9:24	334788.4			0.9			3.87			0.69			4.98			1		
03/24/21 9:25	334865.4			0.9			3.31			0.7			4.25			1		
03/24/21 9:26	333941.3			0.9			3.04			0.7			3.89			1		
03/24/21 9:27	331707.8			0.9			2.82			0.68			3.59			1		
03/24/21 9:28	332015.8			0.8			2.68			0.62			3.42			1		
03/24/21 9:29	330629.6			0.8			2.41			0.62			3.06			1		
03/24/21 9:30	331399.7			0.8			2.23			0.62			2.84			1		
03/24/21 9:31	330783.6			0.8			2.06			0.62			2.61			1		
03/24/21 9:32	331938.8			0.8			1.97			0.62			2.5			1		
03/24/21 9:33	330706.6			0.8			1.79			0.62			2.27			1		
03/24/21 9:34	329628.4			0.8			1.7			0.62			2.15			1		
03/24/21 9:35	331322.7			0.8			1.61			0.62			2.05			0		
03/24/21 9:36	333402.2			0.8			1.52			0.63			1.94			0		
03/24/21 9:37	333171.1			0.8			1.43			0.62			1.83			0		
03/24/21 9:38	334095.3			0.8			1.43			0.63			1.83			0		
03/24/21 9:39	333710.2			0.8			1.34			0.63			1.72			0		

CT2 SUSD EVENT 24

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/24/21 15:51	305984.5			0.6			1.57			0.46			1.84			0		
03/24/21 15:52	302518.8			0.6			1.48			0.46			1.71			0		
03/24/21 15:53	301286.5			0.6			1.48			0.45			1.71			0		
03/24/21 15:54	297589.7			0.7			1.5			0.45			1.71			0		
03/24/21 15:55	284959.1			0.7			1.59			0.44			1.74			0		
03/24/21 15:56	277719.6			0.7			1.87			0.42			2			1		
03/24/21 15:57	258157.5			0.6			2.57			0.34			2.55			1		
03/24/21 15:58	234282.6			0.6			6.1			0.33			5.48			1		
03/24/21 15:59	208482.2			0.5			16.83			0.27			13.46			1		
03/24/21 16:00	182990			4.6			21.19			1.95			14.88			1		
03/24/21 16:01	162041.6			286.1			25.25			108.1			15.7			1		
03/24/21 16:02	143249.7			985.9			29.03			329.28			15.96			1		
03/24/21 16:03	56067.6			1689.4			32.36			220.84			6.96			1		
03/24/21 16:04	0			0			33.93			0			0			0		
03/24/21 16:05	0			0			8.85			0			0			0		
03/24/21 16:06	0			0			11.8			0			0			0		
03/24/21 16:07	0			0			5.9			0			0			0		
03/24/21 16:08	0			0			5.9			0			0			0		

CT2 SUSD EVENT 25

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/25/21 6:40	0			0			0			0			0			0		
03/25/21 6:41	0			0			0			0			0			0		
03/25/21 6:42	0			0			0			0			0			0		
03/25/21 6:43	0			0			0			0			0			0		
03/25/21 6:44	0			0			0			0			0			0		
03/25/21 6:45	19331			5.9			0			0.27			0			1		
03/25/21 6:46	30960.4			56.1			17.7			4.04			2.1			1		
03/25/21 6:47	44900.3			1283.3			13.28			134.43			2.29			1		
03/25/21 6:48	56144.6			1093.2			15.27			143.16			3.29			1		
03/25/21 6:49	68698.3			772.9			21.12			123.88			5.57			1		
03/25/21 6:50	102585.3			547.9			24.72			130.98			9.73			1		
03/25/21 6:51	149873.1			394.3			32.94			137.78			18.94			1		
03/25/21 6:52	156342.4			242.3			47.2			88.3			28.31			1		
03/25/21 6:53	174595.2			1210			44.7			492.43			29.94			1		
03/25/21 6:54	196390.7			1631.4			49.22			746.81			37.08			1		
03/25/21 6:55	219418.5			776.6			49.27			397.22			41.47			1		
03/25/21 6:56	245989			174.5			49.3			100.08			46.53			1		
03/25/21 6:57	269786.9			14			52.29			8.8			54.13			1		
03/25/21 6:58	291120.4			2.5			72.7			1.72			81.2			1		
03/25/21 6:59	322619.9			2			52.23			1.53			64.65			1		
03/25/21 7:00	345570.7			1.8			23.07			1.49			30.59			1		
03/25/21 7:01	362822.3			1.9			13.4			1.57			18.66			1		
03/25/21 7:02	384078.7			1.9			12.22			1.74			18.01			1		
03/25/21 7:03	401407.3			1.9			10.37			1.81			15.97			1		
03/25/21 7:04	403486.7			1.7			8.94			1.63			13.83			1		
03/25/21 7:05	395169			1.5			9.83			1.42			14.91			1		
03/25/21 7:06	404718.9			1.3			9.44			1.27			14.66			1		
03/25/21 7:07	425128.2			1.4			8.16			1.38			13.3			1		
03/25/21 7:08	430596.3			1.2			6.6			1.24			10.91			1		
03/25/21 7:09	433445.9			1.1			6.6			1.16			10.98			1		
03/25/21 7:10	432829.8			1.1			6.6			1.07			10.97			1		
03/25/21 7:11	434755.2			1.1			6.34			1.07			10.58			1		
03/25/21 7:12	435140.3			1.1			6.34			1.07			10.59			1		
03/25/21 7:13	436141.4			1			6.25			0.98			10.46			1		
03/25/21 7:14	431520.5			1			6.52			0.97			10.79			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/25/21 7:15	429056			1			6.43			0.97			10.58			1		
03/25/21 7:16	425667.3			1			6.34			0.96			10.35			1		
03/25/21 7:17	424974.1			0.9			6.34			0.87			10.34			1		
03/25/21 7:18	427515.7			0.9			6.25			0.88			10.26			1		
03/25/21 7:19	427746.7			0.9			6.16			0.88			10.12			1		
03/25/21 7:20	428979			0.9			4.84			0.88			7.97			1		
03/25/21 7:21	428439.8			0.9			2.64			0.88			4.34			1		
03/25/21 7:22	430904.4			0.9			2.11			0.88			3.49			1		
03/25/21 7:23	431674.5			0.9			1.76			0.89			2.92			1		
03/25/21 7:24	428285.8			0.9			1.67			0.88			2.75			1		
03/25/21 7:25	426437.4			0.9			1.59			0.88			2.59			1		
03/25/21 7:26	425436.2			0.9			1.5			0.87			2.44			0		
03/25/21 7:27	420738.3			0.9			1.5			0.86			2.42			0		
03/25/21 7:28	421277.4			0.9			1.41			0.86			2.28			0		
03/25/21 7:29	425744.3			0.9			1.41			0.87			2.3			0		
03/25/21 7:30	426591.5			0.9			1.32			0.88			2.16			0		

CT2 SUSD EVENT 26

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/25/21 10:58	428516.9			0.8			1.27			0.82			2.09			0		
03/25/21 10:59	410495.1			0.8			1.43			0.77			2.25			0		
03/25/21 11:00	388083.5			0.8			1.67			0.72			2.49			0		
03/25/21 11:01	366442			0.9			2.17			0.74			3.05			0		
03/25/21 11:02	340179.6			0.9			2.48			0.75			3.24			0		
03/25/21 11:03	316612.7			1			2.6			0.7			3.16			1		
03/25/21 11:04	293122.8			1			2.15			0.67			2.41			1		
03/25/21 11:05	267707.5			0.8			2.49			0.52			2.56			1		
03/25/21 11:06	244987.8			0.7			5.32			0.39			5			1		
03/25/21 11:07	220804.8			0.5			18.23			0.27			15.44			1		
03/25/21 11:08	194619.4			3.4			24.64			1.52			18.4			1		
03/25/21 11:09	172746.8			207.9			28.58			83.74			18.94			1		
03/25/21 11:10	153800.9			815.8			32.01			292.56			18.89			1		
03/25/21 11:11	103971.6			1570.9			33.55			380.83			13.38			1		
03/25/21 11:12	0			0			38.7			0			0			0		
03/25/21 11:13	0			0			14.75			0			0			0		
03/25/21 11:14	0			0			17.7			0			0			0		
03/25/21 11:15	0			0			11.8			0			0			0		
03/25/21 11:16	0			0			11.8			0			0			0		

AQ-57

AQ-57 The emissions rates from each gas turbine and heat recovery steam generator exhaust during startup and shutdown or excursions shall not exceed the following:

Combustion Turbine emissions limitations per Turbine excluding Startup and Shutdown	
Pollutant	Pounds/Hour
CO	6.2 3hr rolling
NOX	5.1 1 hour rolling
PM-10	4.7
SOX	1.0
VOC	1.8

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6

AQ-57 If the Alstom GX100 turbines are selected for the Project, emission rates from each gas turbine and heat recovery steam generator exhaust, except during startup and/or shutdown, or excursions shall not exceed the following:

Alstom GTX100 - COMBUSTION TURBINE EMISSION LIMITATIONS PER TURBINE EXCLUDING STARTUP AND SHUTDOWN	
POLLUTANT	POUNDS/HOUR
Carbon Monoxide (CO)	6.2 (three-hour rolling average)
Nitrogen Oxides (NOx)	5.1 (one-hour average)
PM10	4.7
Sulfur Oxides (SOx)	1.0
Volatile Organic Compounds (VOCs)	1.8

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emission limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

AQ57 CT1 HOURLY EMISSIONS

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/01/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/02/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/04/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/05/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/07/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/08/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/10/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/11/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/13/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/15/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/16/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/18/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/19/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/21/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/23/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 23:00	0			0			0	X		0.17			0.0873			0.29		
01/24/21 0:00	0.8			1.6			3			0.53			0.2631			0.88		
01/24/21 1:00	0.8			1.7			3			0.51			0.25302			0.84		
01/24/21 2:00	0.9			1.7			3			0.42			0.21138			0.7		
01/24/21 3:00	0.9			1.7			4			0.4			0.20166			0.67		
01/24/21 4:00	0.8			1.7			3			0.41			0.20538			0.68		
01/24/21 5:00	0.8			1.7			3			0.44			0.21864			0.73		
01/24/21 6:00	0.8			1.7			4			0.39			0.1965			0.66		
01/24/21 7:00	0.8			1.7			4			0.39			0.19584			0.65		
01/24/21 8:00	0.8			1.7			3			0.38			0.1923			0.64		
01/24/21 9:00	0.8			1.7			3			0.42			0.20844			0.69		
01/24/21 10:00	0.8			1.7			3			0.41			0.2073			0.69		
01/24/21 11:00	0.8			1.7			3			0.41			0.2061			0.69		
01/24/21 12:00	0.7			1.7			2			0.46			0.23016			0.77		
01/24/21 13:00	0.7			1.7			3			0.46			0.22794			0.76		
01/24/21 14:00	0.7			1.7			2			0.49			0.24348			0.81		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/24/21 15:00	0.6			1.7			2			0.51			0.25704			0.86		
01/24/21 16:00	1			1.7			3			0.57			0.2865			0.96		
01/24/21 17:00	1.2			1.7			3			0.57			0.28356			0.95		
01/24/21 18:00	1.1			1.7			3			0.6			0.29784			0.99		
01/24/21 19:00	1			1.7			3			0.57			0.28392			0.95		
01/24/21 20:00	0.7			1.7			3			0.51			0.255			0.85		
01/24/21 21:00	0.7			1.7			3			0.45			0.22596			0.75		
01/24/21 22:00	0.7			1.7			3			0.49			0.24444			0.81		
01/24/21 23:00	0.8			1.7			3			0.43			0.21312			0.71		
01/25/21 0:00	0.8			1.7			3			0.41			0.20502			0.68		
01/25/21 1:00	0.8			1.7			3			0.4			0.19968			0.67		
01/25/21 2:00	0.8			1.7			3			0.4			0.1995			0.67		
01/25/21 3:00	0.9			1.7			3			0.41			0.20388			0.68		
01/25/21 4:00	0.8			1.7			3			0.44			0.21846			0.73		
01/25/21 5:00	0.7			1.7			3			0.5			0.25086			0.84		
01/25/21 6:00	0.8			1.7			3			0.55			0.27414			0.91		
01/25/21 7:00	0.7			1.7			4			0.65			0.32682			1.09		
01/25/21 8:00	0.2			1.7			5			0.74			0.37056			1.24		
01/25/21 9:00	0.1			1.7			5			0.77			0.387			1.29		
01/25/21 10:00	0.4			1.7			4			0.7			0.348			1.16		
01/25/21 11:00	0.5			1.7			4			0.67			0.33492			1.12		
01/25/21 12:00	0.9			1.7			3			0.62			0.30792			1.03		
01/25/21 13:00	1			1.7			3			0.59			0.294			0.98		
01/25/21 14:00	1			1.7			3			0.59			0.29376			0.98		
01/25/21 15:00	1.1			1.7			3			0.57			0.28722			0.96		
01/25/21 16:00	0.5			1.7			4			0.67			0.33648			1.12		
01/25/21 17:00	0.9			1.7			3			0.61			0.30408			1.01		
01/25/21 18:00	0.1			1.7			5			0.77			0.38328			1.28		
01/25/21 19:00	0.1			1.7			5			0.77			0.38484			1.28		
01/25/21 20:00	0.2			1.7			5			0.74			0.37242			1.24		
01/25/21 21:00	0.6			1.7			3			0.65			0.32382			1.08		
01/25/21 22:00	0.8			1.8			3			0.54			0.27024			0.9		
01/25/21 23:00	0.7			1.7			3			0.48			0.23898			0.8		
01/26/21 0:00	0			0			0	X		0.26			0.13218			0.44		
01/26/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/26/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/27/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/29/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/30/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/01/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/03/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/04/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/06/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/07/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/09/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/11/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/12/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/14/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/15/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/17/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/18/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/20/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/22/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/23/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/25/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/26/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/26/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/26/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/26/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/26/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/26/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/26/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/26/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/26/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/26/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/26/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/26/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/26/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/26/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/26/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/26/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/26/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/26/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/26/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/26/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/26/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/26/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/26/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/26/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/27/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/27/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/27/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/27/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/27/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/27/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/27/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/27/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/27/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/27/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/27/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/27/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/27/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/27/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/27/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/27/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/27/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/27/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/27/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/27/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/27/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/27/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/27/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/27/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/28/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/01/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/01/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/01/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/01/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/01/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/01/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/01/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/01/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/01/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/01/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/01/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/01/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/01/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/01/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/01/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/01/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/01/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/01/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/01/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/01/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/01/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/01/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/01/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/01/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/02/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/03/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/05/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/06/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/06/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/06/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/06/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/06/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/06/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/06/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/06/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/06/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/06/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/06/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/06/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/06/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/06/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/06/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/06/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/06/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/06/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/06/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/06/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/06/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/06/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/06/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/06/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/08/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/08/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/08/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/08/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/08/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/08/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/08/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/08/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/08/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/08/21 9:00	0			0			0	X		0.06			0.0291			0.1		
03/08/21 10:00	0			0			0	X		0.12			0.06156			0.21		
03/08/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/08/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/08/21 13:00	0			0			0	X		0.06			0.03204			0.11		
03/08/21 14:00	0			0			0	X		0.17			0.08436			0.28		
03/08/21 15:00	1.1			1.7			3			0.4			0.20082			0.67		
03/08/21 16:00	1.1			1.7			2			0.58			0.29196			0.97		
03/08/21 17:00	0	X		0	X		0	X		0.59			0.29376			0.98		
03/08/21 18:00	1.1			1.7			3			0.59			0.29442			0.98		
03/08/21 19:00	1			1.7			3			0.57			0.2841			0.95		
03/08/21 20:00	0.9			1.3			2			0.28			0.13812			0.46		
03/08/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/08/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/08/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/09/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/10/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/10/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/10/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/10/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/10/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/10/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/10/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/10/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/10/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/10/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/10/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/10/21 11:00	0			0			0	X		0.18			0.09234			0.31		
03/10/21 12:00	0			0			0	X		0.31			0.15522			0.52		
03/10/21 13:00	0.7			2.8			6			0.33			0.16704			0.56		
03/10/21 14:00	1			1.7			2			0.41			0.20706			0.69		
03/10/21 15:00	0.9			1.7			3			0.56			0.28038			0.93		
03/10/21 16:00	0.9			1.7			3			0.59			0.29304			0.98		
03/10/21 17:00	0.9			1.7			3			0.59			0.29322			0.98		
03/10/21 18:00	1			1.7			3			0.57			0.2868			0.96		
03/10/21 19:00	1.1			1.3			3			0.3			0.14856			0.5		
03/10/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/10/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/10/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/10/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/11/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/12/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/12/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/12/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/12/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/12/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/12/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/12/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/12/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/12/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/12/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/12/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/12/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/12/21 12:00	0			0			0	X		0.05			0.02316			0.08		
03/12/21 13:00	0			0			0	X		0.07			0.0333			0.11		
03/12/21 14:00	0			0			0	X		0.28			0.14136			0.47		
03/12/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/12/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/12/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/12/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/12/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/12/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/12/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/12/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/12/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/13/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/13/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/13/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/13/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/13/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/13/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/13/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/13/21 7:00	0	X		0	X		0	X		0.02			0.00978			0.03		
03/13/21 8:00	0	X		0	X		0	X		0.19			0.09642			0.32		
03/13/21 9:00	0	X		0	X		0	X		0.48			0.24066			0.8		
03/13/21 10:00	0	X		0	X		0	X		0.41			0.20718			0.69		
03/13/21 11:00	0.9			2.6			2			0.48			0.24234			0.81		
03/13/21 12:00	0.9			1.7			2			0.57			0.28524			0.95		
03/13/21 13:00	1			1.7			2			0.57			0.28368			0.95		
03/13/21 14:00	0.4			1.7			4			0.81			0.40542			1.35		
03/13/21 15:00	0.3			1.7			5			0.83			0.41316			1.38		
03/13/21 16:00	0.3			1.7			5			0.83			0.41358			1.38		
03/13/21 17:00	0.8			1.8			2			0.57			0.2838			0.95		
03/13/21 18:00	0.9			1.4			2			0.26			0.13206			0.44		
03/13/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/13/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/13/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/13/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/13/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/14/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/16/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/17/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/19/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/21/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/22/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/23/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/23/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/23/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/23/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/23/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/23/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/23/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/23/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/23/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/23/21 9:00	0			0			0	X		0.05			0.02598			0.09		
03/23/21 10:00	0			0			0	X		0.28			0.14064			0.47		
03/23/21 11:00	0.9			1.7			2			0.54			0.2685			0.9		
03/23/21 12:00	0.6			1.6			3			0.71			0.35424			1.18		
03/23/21 13:00	1			1.7			2			0.56			0.27882			0.93		
03/23/21 14:00	0.6			1.7			3			0.67			0.33462			1.12		
03/23/21 15:00	0.3			1.7			5			0.81			0.40368			1.35		
03/23/21 16:00	1			1.7			2			0.64			0.31968			1.07		
03/23/21 17:00	0.8			1.8			3			0.38			0.189			0.63		
03/23/21 18:00	0.7			1.7			3			0.34			0.17208			0.57		
03/23/21 19:00	0.7			1.7			3			0.35			0.17454			0.58		
03/23/21 20:00	0.7			1.7			3			0.35			0.17658			0.59		
03/23/21 21:00	0.7			1.7			3			0.35			0.1752			0.58		
03/23/21 22:00	0.7			1.7			4			0.35			0.1749			0.58		
03/23/21 23:00	0.7			1.7			4			0.35			0.17424			0.58		
03/24/21 0:00	0.7			1.7			4			0.35			0.1737			0.58		
03/24/21 1:00	0.7			1.7			4			0.35			0.17418			0.58		
03/24/21 2:00	0.7			1.7			4			0.35			0.17454			0.58		
03/24/21 3:00	0.7			1.7			4			0.35			0.1746			0.58		
03/24/21 4:00	0.7			1.7			4			0.35			0.17436			0.58		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/24/21 5:00	0.8			1.8			4			0.35			0.17448			0.58		
03/24/21 6:00	0.7			1.7			4			0.35			0.1743			0.58		
03/24/21 7:00	0.8			1.5			3			0.37			0.18684			0.62		
03/24/21 8:00	0.9			1			0	X		0.76			0.37824			1.26		
03/24/21 9:00	0.9			1.4			0			0.43			0.21342			0.71		
03/24/21 10:00	0.7			1.9			3			0.79			0.39648			1.32		
03/24/21 11:00	0.9			1.8			2			0.46			0.22782			0.76		
03/24/21 12:00	0			0			0	X		0.17			0.08748			0.29		
03/24/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/24/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/24/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/24/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/24/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/24/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/24/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/24/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/24/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/24/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/24/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/25/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/27/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/28/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/30/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	

AQ57 CT2 HOURLY EMISSIONS

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/01/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/01/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/02/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/02/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/03/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/04/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/04/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/05/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/05/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/06/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/07/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/07/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/08/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/08/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/09/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/10/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/10/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/11/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/11/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/12/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/13/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/13/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/14/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/15/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/15/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/16/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/16/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/17/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/18/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/18/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/19/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/19/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/20/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/21/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/21/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/22/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/23/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/23/21 23:00	0	X		0	X		0	X		0.17			0	X		0	X	
01/24/21 0:00	0	X		0	X		0	X		0.53			0	X		0	X	
01/24/21 1:00	0	X		0	X		0	X		0.51			0	X		0	X	
01/24/21 2:00	0	X		0	X		0	X		0.42			0	X		0	X	
01/24/21 3:00	0	X		0	X		0	X		0.4			0	X		0	X	
01/24/21 4:00	0	X		0	X		0	X		0.41			0	X		0	X	
01/24/21 5:00	0	X		0	X		0	X		0.44			0	X		0	X	
01/24/21 6:00	0	X		0	X		0	X		0.39			0	X		0	X	
01/24/21 7:00	0	X		0	X		0	X		0.39			0	X		0	X	
01/24/21 8:00	0	X		0	X		0	X		0.38			0	X		0	X	
01/24/21 9:00	0	X		0	X		0	X		0.42			0	X		0	X	
01/24/21 10:00	0	X		0	X		0	X		0.41			0	X		0	X	
01/24/21 11:00	0	X		0	X		0	X		0.41			0	X		0	X	
01/24/21 12:00	0	X		0	X		0	X		0.46			0	X		0	X	
01/24/21 13:00	0	X		0	X		0	X		0.46			0	X		0	X	
01/24/21 14:00	0	X		0	X		0	X		0.49			0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/24/21 15:00	0	X		0	X		0	X		0.51			0	X		0	X	
01/24/21 16:00	0	X		0	X		0	X		0.57			0	X		0	X	
01/24/21 17:00	0	X		0	X		0	X		0.57			0	X		0	X	
01/24/21 18:00	0	X		0	X		0	X		0.6			0	X		0	X	
01/24/21 19:00	0	X		0	X		0	X		0.57			0	X		0	X	
01/24/21 20:00	0	X		0	X		0	X		0.51			0	X		0	X	
01/24/21 21:00	0	X		0	X		0	X		0.45			0	X		0	X	
01/24/21 22:00	0	X		0	X		0	X		0.49			0	X		0	X	
01/24/21 23:00	0	X		0	X		0	X		0.43			0	X		0	X	
01/25/21 0:00	0	X		0	X		0	X		0.41			0	X		0	X	
01/25/21 1:00	0	X		0	X		0	X		0.4			0	X		0	X	
01/25/21 2:00	0	X		0	X		0	X		0.4			0	X		0	X	
01/25/21 3:00	0	X		0	X		0	X		0.41			0	X		0	X	
01/25/21 4:00	0	X		0	X		0	X		0.44			0	X		0	X	
01/25/21 5:00	0	X		0	X		0	X		0.5			0	X		0	X	
01/25/21 6:00	0	X		0	X		0	X		0.55			0	X		0	X	
01/25/21 7:00	0	X		0	X		0	X		0.65			0	X		0	X	
01/25/21 8:00	0	X		0	X		0	X		0.74			0	X		0	X	
01/25/21 9:00	0	X		0	X		0	X		0.77			0	X		0	X	
01/25/21 10:00	0	X		0	X		0	X		0.7			0	X		0	X	
01/25/21 11:00	0	X		0	X		0	X		0.67			0	X		0	X	
01/25/21 12:00	0	X		0	X		0	X		0.62			0	X		0	X	
01/25/21 13:00	0	X		0	X		0	X		0.59			0	X		0	X	
01/25/21 14:00	0	X		0	X		0	X		0.59			0	X		0	X	
01/25/21 15:00	0	X		0	X		0	X		0.57			0	X		0	X	
01/25/21 16:00	0	X		0	X		0	X		0.67			0	X		0	X	
01/25/21 17:00	0	X		0	X		0	X		0.61			0	X		0	X	
01/25/21 18:00	0	X		0	X		0	X		0.77			0	X		0	X	
01/25/21 19:00	0	X		0	X		0	X		0.77			0	X		0	X	
01/25/21 20:00	0	X		0	X		0	X		0.74			0	X		0	X	
01/25/21 21:00	0	X		0	X		0	X		0.65			0	X		0	X	
01/25/21 22:00	0	X		0	X		0	X		0.54			0	X		0	X	
01/25/21 23:00	0	X		0	X		0	X		0.48			0	X		0	X	
01/26/21 0:00	0	X		0	X		0	X		0.26			0	X		0	X	
01/26/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/26/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/26/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/27/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/27/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/28/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/29/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/29/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/30/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
01/30/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
01/31/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/01/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/01/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/02/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/03/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/03/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/04/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/04/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/05/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/06/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/06/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/07/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/07/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/08/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/09/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/09/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/10/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/11/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/11/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/12/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/12/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/13/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/14/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/14/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/15/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/15/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/16/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/17/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/17/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/18/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/18/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/19/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/20/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/20/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/21/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/22/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/22/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/23/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/23/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/24/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/25/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/25/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/26/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/26/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/26/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/26/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/26/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/26/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/26/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/26/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/26/21 8:00	0			0	X		0			0	X		0.12564			0.42		
02/26/21 9:00	1			1			1.6			0	X		0.21042			0.7		
02/26/21 10:00	0.9			1			1.6			0	X		0.29622			0.99		
02/26/21 11:00	0.9			1			1.7			0	X		0.31014			1.03		
02/26/21 12:00	0.9			0			1.7			0	X		0.30876			1.03		
02/26/21 13:00	0.9			1			1.7			0	X		0.30738			1.02		
02/26/21 14:00	0.9			1			1.6			0	X		0.21228			0.71		
02/26/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/26/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/26/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/26/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/26/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/26/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/26/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/26/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/26/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/27/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/27/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/27/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/27/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/27/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/27/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/27/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/27/21 7:00	0	X		0	X		0.5	X		0	X		0	X		0	X	
02/27/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/27/21 9:00	0			0	X		0			0	X		0.1056			0.35		
02/27/21 10:00	0.9			1			1.6			0	X		0.2982			0.99		
02/27/21 11:00	0.8			1			1.7			0	X		0.30864			1.03		
02/27/21 12:00	0.8			0			1.7			0	X		0.30738			1.02		
02/27/21 13:00	0.8			0			1.4			0	X		0.3063			1.02		
02/27/21 14:00	0.8			0			1.8			0	X		0.30294			1.01		
02/27/21 15:00	0.9			0			1.7			0	X		0.26208			0.87		
02/27/21 16:00	0.9			0			1.8			0	X		0.21516			0.72		
02/27/21 17:00	0.7			1			1.6			0	X		0.19014			0.63		
02/27/21 18:00	0			0	X		0			0	X		0.04722			0.16		
02/27/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/27/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/27/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/27/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/27/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
02/28/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
02/28/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/01/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/01/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/01/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/01/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/01/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/01/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/01/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/01/21 7:00	0			0	X		0			0	X		0.09504			0.32		
03/01/21 8:00	0.8			0			1.5			0	X		0.28548			0.95		
03/01/21 9:00	0.8			0			1.7			0	X		0.31422			1.05		
03/01/21 10:00	0.8			0			1.7			0	X		0.31092			1.04		
03/01/21 11:00	0.7			0			1.7			0	X		0.30678			1.02		
03/01/21 12:00	0.8			0			1.7			0	X		0.30468			1.02		
03/01/21 13:00	0.8			0			1.7			0	X		0.21216			0.71		
03/01/21 14:00	0.7			2			2.1			0	X		0.1926			0.64		
03/01/21 15:00	0.5			1			1.6			0	X		0.17934			0.6		
03/01/21 16:00	0.7			0			1.2			0	X		0.1941			0.65		
03/01/21 17:00	0			0	X		0			0	X		0.07374			0.25		
03/01/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/01/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/01/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/01/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/01/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/01/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/02/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/02/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/03/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/03/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/04/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/05/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/05/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/06/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/06/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/06/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/06/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/06/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/06/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/06/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/06/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/06/21 8:00	0			0	X		0			0	X		0.141			0.47		
03/06/21 9:00	0.7			0			1.6			0	X		0.20172			0.67		
03/06/21 10:00	11.8			1			3			0	X		0.18492			0.62		
03/06/21 11:00	0.5			0			1.4			0	X		0.18426			0.61		
03/06/21 12:00	0.8			0			1.7			0	X		0.30414			1.01		
03/06/21 13:00	0.7			0			1.7			0	X		0.30642			1.02		
03/06/21 14:00	0.8			1			1.7			0	X		0.30078			1		
03/06/21 15:00	0.8			1			1.7			0	X		0.2565			0.86		
03/06/21 16:00	0.8			1			1.7			0	X		0.2517			0.84		
03/06/21 17:00	0			0	X		0			0	X		0.12324			0.41		
03/06/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/06/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/06/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/06/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/06/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/06/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/07/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/08/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/08/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/08/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/08/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/08/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/08/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/08/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/08/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/08/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/08/21 9:00	0	X		0	X		0	X		0.06			0	X		0	X	
03/08/21 10:00	0	X		0	X		0	X		0.12			0	X		0	X	
03/08/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/08/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/08/21 13:00	0	X		0	X		0	X		0.06			0	X		0	X	
03/08/21 14:00	0	X		0	X		0	X		0.17			0	X		0	X	
03/08/21 15:00	0	X		0	X		0	X		0.4			0	X		0	X	
03/08/21 16:00	0	X		0	X		0	X		0.58			0	X		0	X	
03/08/21 17:00	0	X		0	X		0	X		0.59			0	X		0	X	
03/08/21 18:00	0	X		0	X		0.1	X		0.59			0	X		0	X	
03/08/21 19:00	0	X		0	X		0	X		0.57			0	X		0	X	
03/08/21 20:00	0	X		0	X		0	X		0.28			0	X		0	X	
03/08/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/08/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/08/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/09/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/09/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/10/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/10/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/10/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/10/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/10/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/10/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/10/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/10/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/10/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/10/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/10/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/10/21 11:00	0	X		0	X		0	X		0.18			0	X		0	X	
03/10/21 12:00	0	X		0	X		0	X		0.31			0	X		0	X	
03/10/21 13:00	0	X		0	X		0	X		0.33			0	X		0	X	
03/10/21 14:00	0	X		0	X		0	X		0.41			0	X		0	X	
03/10/21 15:00	0	X		0	X		0	X		0.56			0	X		0	X	
03/10/21 16:00	0	X		0	X		0	X		0.59			0	X		0	X	
03/10/21 17:00	0	X		0	X		0	X		0.59			0	X		0	X	
03/10/21 18:00	0	X		0	X		0	X		0.57			0	X		0	X	
03/10/21 19:00	0	X		0	X		0	X		0.3			0	X		0	X	
03/10/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/10/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/10/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/10/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/11/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/11/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/12/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/12/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/12/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/12/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/12/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/12/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/12/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/12/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/12/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/12/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/12/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/12/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/12/21 12:00	0	X		0	X		0	X		0.05			0	X		0	X	
03/12/21 13:00	0	X		0	X		0	X		0.07			0	X		0	X	
03/12/21 14:00	0			0	X		0			0.28			0.01212			0.04		
03/12/21 15:00	0			0	X		0			0	X		0.01818			0.06		
03/12/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/12/21 17:00	0			0	X		0			0	X		0.02466			0.08		
03/12/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/12/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/12/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/12/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/12/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/12/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/13/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/13/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/13/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/13/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/13/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/13/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/13/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/13/21 7:00	0	X		0	X		0	X		0.02			0	X		0	X	
03/13/21 8:00	0	X		0	X		0	X		0.19			0	X		0	X	
03/13/21 9:00	0	X		0	X		0	X		0.48			0	X		0	X	
03/13/21 10:00	0	X		0	X		0	X		0.41			0	X		0	X	
03/13/21 11:00	0	X		0	X		0	X		0.48			0.08934			0.3		
03/13/21 12:00	0	X		0	X		0	X		0.57			0.2973			0.99		
03/13/21 13:00	0.9			1			1.5			0.57			0.30378			1.01		
03/13/21 14:00	0.4			1			1.6			0.81			0.43038			1.43		
03/13/21 15:00	0.3			2			1.7			0.83			0.43122			1.44		
03/13/21 16:00	0.3			2			1.7			0.83			0.43128			1.44		
03/13/21 17:00	0.7			1			1.7			0.57			0.30312			1.01		
03/13/21 18:00	0.4			2			4.4			0.26			0.16986			0.57		
03/13/21 19:00	0.7			0			1.7			0	X		0.24222			0.81		
03/13/21 20:00	0.8			0			1.3			0	X		0.24882			0.83		
03/13/21 21:00	0.8			0			1.8			0	X		0.3045			1.02		
03/13/21 22:00	0			0	X		0			0	X		0.13488			0.45		
03/13/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/14/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/14/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/15/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/16/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/16/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/17/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/17/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/18/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/19/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/19/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/20/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/21/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/21/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/22/21 5:00	0			0	X		0			0	X		0.11142			0.37		
03/22/21 6:00	0.5			1			1.3			0	X		0.17928			0.6		
03/22/21 7:00	0.5			1			1.8			0	X		0.17694			0.59		
03/22/21 8:00	0.8			0			1.8			0	X		0.23292			0.78		
03/22/21 9:00	0.7			0			1.7			0	X		0.30954			1.03		
03/22/21 10:00	0.6			1			1.7			0	X		0.20514			0.68		
03/22/21 11:00	0.8			0			1.7			0	X		0.3534			1.18		
03/22/21 12:00	0.4			2			1.7			0	X		0.4197			1.4		
03/22/21 13:00	1.1			0			1.8			0	X		0.33414			1.11		
03/22/21 14:00	0	X		0	X		0	X		0	X		0.43074			1.44		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/22/21 15:00	0.8			-1			0.5			0	X		0.26226			0.87		
03/22/21 16:00	0.6			0			1.7			0	X		0.18678			0.62		
03/22/21 17:00	0.6			1			1.7			0	X		0.183			0.61		
03/22/21 18:00	0.6			1			1.7			0	X		0.1827			0.61		
03/22/21 19:00	0.6			1			1.7			0	X		0.18522			0.62		
03/22/21 20:00	0.6			1			1.7			0	X		0.18642			0.62		
03/22/21 21:00	0.6			1			1.7			0	X		0.18744			0.62		
03/22/21 22:00	0.6			1			1.7			0	X		0.18774			0.63		
03/22/21 23:00	0.7			1			1.7			0	X		0.1872			0.62		
03/23/21 0:00	0.6			1			1.7			0	X		0.18732			0.62		
03/23/21 1:00	0.6			1			1.7			0	X		0.18738			0.62		
03/23/21 2:00	0.6			1			1.7			0	X		0.1872			0.62		
03/23/21 3:00	0.6			1			1.7			0	X		0.18726			0.62		
03/23/21 4:00	0.6			1			1.7			0	X		0.18726			0.62		
03/23/21 5:00	0.6			1			1.7			0	X		0.18654			0.62		
03/23/21 6:00	0.6			1			1.7			0	X		0.18522			0.62		
03/23/21 7:00	0.5			1			1.6			0	X		0.18846			0.63		
03/23/21 8:00	1.2			0			1.6			0	X		0.31434			1.05		
03/23/21 9:00	0.9			0			1.7			0.05			0.30744			1.02		
03/23/21 10:00	1.7			0			1.7			0.28			0.3003			1		
03/23/21 11:00	1.4			0			1.8			0.54			0.30828			1.03		
03/23/21 12:00	0.3			2			1.3			0.71			0.42234			1.41		
03/23/21 13:00	0.9			0			1.3			0.56			0.29826			0.99		
03/23/21 14:00	0			0	X		0			0.67			0.1302			0.43		
03/23/21 15:00	0	X		0	X		0	X		0.81			0	X		0	X	
03/23/21 16:00	0	X		0	X		0	X		0.64			0	X		0	X	
03/23/21 17:00	0	X		0	X		0	X		0.38			0	X		0	X	
03/23/21 18:00	0	X		0	X		0	X		0.34			0	X		0	X	
03/23/21 19:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/23/21 20:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/23/21 21:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/23/21 22:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/23/21 23:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/24/21 0:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/24/21 1:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/24/21 2:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/24/21 3:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/24/21 4:00	0	X		0	X		0	X		0.35			0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/24/21 5:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/24/21 6:00	0	X		0	X		0	X		0.35			0	X		0	X	
03/24/21 7:00	0	X		0	X		0	X		0.37			0	X		0	X	
03/24/21 8:00	0			0	X		0			0.76			0.0945			0.32		
03/24/21 9:00	0.8			0			1.4			0.43			0.22698			0.76		
03/24/21 10:00	0.4			1			1.7			0.79			0.41808			1.39		
03/24/21 11:00	0.8			0			1.8			0.46			0.25494			0.85		
03/24/21 12:00	0.7			1			1.2			0.17			0.3462			1.15		
03/24/21 13:00	0.8			0			1.3			0	X		0.26814			0.89		
03/24/21 14:00	0.5			1			1.6			0	X		0.39606			1.32		
03/24/21 15:00	0.7			0			1.8			0	X		0.18786			0.63		
03/24/21 16:00	0			0	X		0			0	X		0.08502			0.28		
03/24/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/24/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/24/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/24/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/24/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/24/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/24/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/21 6:00	0			0	X		0			0	X		0.09786			0.33		
03/25/21 7:00	0.9			0			1.6			0	X		0.26352			0.88		
03/25/21 8:00	0.9			0			1.7			0	X		0.26298			0.88		
03/25/21 9:00	0.9			1			1.8			0	X		0.21672			0.72		
03/25/21 10:00	0.9			0			1.6			0	X		0.22338			0.74		
03/25/21 11:00	0.9			0			2.1			0	X		0.15954			0.53		
03/25/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/25/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/25/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/26/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/27/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/27/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/28/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/28/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/29/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/30/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/30/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
03/31/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	

AQ-59

AQ-59 The Daily Emissions shall not exceed the following rates:

POLLUTANT	TWO TURBINES	AUX BOILER	COOLING TOWER	EMERGENCY DIESEL GENERATOR	DIESEL FIRE PUMP
NOX	406.0	16.8	-	4.31	1.72
CO	629.5	52.8	-	0.84	0.09
VOC	223.1	7.2	-	0.16	0.05
PM-10	226.8	14.4	16.3	0.14	0.03
SO2	47.1	1.92	-	0.10	0.19

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6

Monthly Summary By Day Report

Units CT1 and CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:41 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
01/01/2021	0.00	0.00	0.00	0.00	0.00
01/02/2021	0.00	0.00	0.00	0.00	0.00
01/03/2021	0.00	0.00	0.00	0.00	0.00
01/04/2021	0.00	0.00	0.00	0.00	0.00
01/05/2021	0.00	0.00	0.00	0.00	0.00
01/06/2021	0.00	0.00	0.00	0.00	0.00
01/07/2021	0.00	0.00	0.00	0.00	0.00
01/08/2021	0.00	0.00	0.00	0.00	0.00
01/09/2021	0.00	0.00	0.00	0.00	0.00
01/10/2021	0.00	0.00	0.00	0.00	0.00
01/11/2021	0.00	0.00	0.00	0.00	0.00
01/12/2021	0.00	0.00	0.00	0.00	0.00
01/13/2021	0.00	0.00	0.00	0.00	0.00
01/14/2021	0.00	0.00	0.00	0.00	0.00
01/15/2021	0.00	0.00	0.00	0.00	0.00
01/16/2021	0.00	0.00	0.00	0.00	0.00
01/17/2021	0.00	0.00	0.00	0.00	0.00
01/18/2021	0.00	0.00	0.00	0.00	0.00
01/19/2021	0.00	0.00	0.00	0.00	0.00
01/20/2021	0.00	0.00	0.00	0.00	0.00
01/21/2021	0.00	0.00	0.00	0.00	0.00
01/22/2021	0.00	0.00	0.00	0.00	0.00
01/23/2021	41.43	6.45	0.02	0.05	0.08
01/24/2021	17.66	62.48	5.62	11.22	18.69
01/25/2021	15.90	74.08	7.10	14.24	23.74
01/26/2021	0.01	0.04	0.00	0.01	0.01
01/27/2021	0.00	0.00	0.00	0.00	0.00
01/28/2021	0.00	0.00	0.00	0.00	0.00
01/29/2021	0.00	0.00	0.00	0.00	0.00
01/30/2021	0.00	0.00	0.00	0.00	0.00
01/31/2021	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	75.00 *	143.05 *	12.74 *	25.52 *	42.52 *
Daily Min:	0.01	0.04	0.00	0.01	0.01
Daily Max:	41.43	74.08	7.10	14.24	23.74
Jan 2021 - Jan 2021	75.00	143.05	12.74	25.52	42.52
QTD:	75.00 *	143.05 *	12.74 *	25.52 *	42.52 *
YTD 2021:	75.00 *	143.05 *	12.74 *	25.52 *	42.52 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:41 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
02/01/2021	0.00	0.00	0.00	0.00	0.00
02/02/2021	0.00	0.00	0.00	0.00	0.00
02/03/2021	0.00	0.00	0.00	0.00	0.00
02/04/2021	0.00	0.00	0.00	0.00	0.00
02/05/2021	0.00	0.00	0.00	0.00	0.00
02/06/2021	0.00	0.00	0.00	0.00	0.00
02/07/2021	0.00	0.00	0.00	0.00	0.00
02/08/2021	0.00	0.00	0.00	0.00	0.00
02/09/2021	0.00	0.00	0.00	0.00	0.00
02/10/2021	0.00	0.00	0.00	0.00	0.00
02/11/2021	0.00	0.00	0.00	0.00	0.00
02/12/2021	0.00	0.00	0.00	0.00	0.00
02/13/2021	0.00	0.00	0.00	0.00	0.00
02/14/2021	0.00	0.00	0.00	0.00	0.00
02/15/2021	0.00	0.00	0.00	0.00	0.00
02/16/2021	0.00	0.00	0.00	0.00	0.00
02/17/2021	0.00	0.00	0.00	0.00	0.00
02/18/2021	0.00	0.00	0.00	0.00	0.00
02/19/2021	0.00	0.00	0.00	0.00	0.00
02/20/2021	0.00	0.00	0.00	0.00	0.00
02/21/2021	0.00	0.00	0.00	0.00	0.00
02/22/2021	0.00	0.00	0.00	0.00	0.00
02/23/2021	0.00	0.00	0.00	0.00	0.00
02/24/2021	0.00	0.00	0.00	0.00	0.00
02/25/2021	0.00	0.00	0.00	0.00	0.00
02/26/2021	290.84	37.94	1.60	3.19	5.32
02/27/2021	84.73	37.27	2.23	4.44	7.39
02/28/2021	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	375.57 *	75.21 *	3.83 *	7.63 *	12.71 *
Daily Min:	84.73	37.27	1.60	3.19	5.32
Daily Max:	290.84	37.94	2.23	4.44	7.39
Jan 2021 - Feb 2021	450.57	218.26	16.57	33.15	55.23
QTD:	450.57 *	218.26 *	16.57 *	33.15 *	55.23 *
YTD 2021:	450.57 *	218.26 *	16.57 *	33.15 *	55.23 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:41 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
03/01/2021	50.79	49.99	2.31	4.66	7.77
03/02/2021	0.00	0.00	0.00	0.00	0.00
03/03/2021	0.00	0.00	0.00	0.00	0.00
03/04/2021	0.00	0.00	0.00	0.00	0.00
03/05/2021	0.00	0.00	0.00	0.00	0.00
03/06/2021	58.31	48.94	2.12	4.26	7.11
03/07/2021	0.00	0.00	0.00	0.00	0.00
03/08/2021	183.31	28.21	1.41	2.89	4.79
03/09/2021	0.00	0.00	0.00	0.00	0.00
03/10/2021	68.19	49.28	1.75	3.48	5.82
03/11/2021	0.00	0.00	0.00	0.00	0.00
03/12/2021	101.50	22.06	0.11	0.23	0.39
03/13/2021	71.12	60.52	6.05	12.12	20.23
03/14/2021	0.00	0.00	0.00	0.00	0.00
03/15/2021	0.00	0.00	0.00	0.00	0.00
03/16/2021	0.00	0.00	0.00	0.00	0.00
03/17/2021	0.00	0.00	0.00	0.00	0.00
03/18/2021	0.00	0.00	0.00	0.00	0.00
03/19/2021	0.00	0.00	0.00	0.00	0.00
03/20/2021	0.00	0.00	0.00	0.00	0.00
03/21/2021	0.00	0.00	0.00	0.00	0.00
03/22/2021	106.86	59.21	4.38	8.75	14.58
03/23/2021	89.72	82.48	6.76	13.47	22.47
03/24/2021	83.72	62.22	4.73	9.53	15.84
03/25/2021	63.73	22.92	1.01	2.05	3.41
03/26/2021	0.00	0.00	0.00	0.00	0.00
03/27/2021	0.00	0.00	0.00	0.00	0.00
03/28/2021	0.00	0.00	0.00	0.00	0.00
03/29/2021	0.00	0.00	0.00	0.00	0.00
03/30/2021	0.00	0.00	0.00	0.00	0.00
03/31/2021	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	877.25 *	485.83 *	30.63 *	61.44 *	102.41 *
Daily Min:	50.79	22.06	0.11	0.23	0.39
Daily Max:	183.31	82.48	6.76	13.47	22.47
Jan 2021 - Mar 2021	1,327.82	704.09	47.20	94.59	157.64
QTD:	1,327.82 *	704.09 *	47.20 *	94.59 *	157.64 *
YTD 2021:	1,327.82 *	704.09 *	47.20 *	94.59 *	157.64 *

Monthly Summary By Day Report

Unit CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:43 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
01/01/2021	0.00	0.00	0.0	0.00	0.00
01/02/2021	0.00	0.00	0.0	0.00	0.00
01/03/2021	0.00	0.00	0.0	0.00	0.00
01/04/2021	0.00	0.00	0.0	0.00	0.00
01/05/2021	0.00	0.00	0.0	0.00	0.00
01/06/2021	0.00	0.00	0.0	0.00	0.00
01/07/2021	0.00	0.00	0.0	0.00	0.00
01/08/2021	0.00	0.00	0.0	0.00	0.00
01/09/2021	0.00	0.00	0.0	0.00	0.00
01/10/2021	0.00	0.00	0.0	0.00	0.00
01/11/2021	0.00	0.00	0.0	0.00	0.00
01/12/2021	0.00	0.00	0.0	0.00	0.00
01/13/2021	0.00	0.00	0.0	0.00	0.00
01/14/2021	0.00	0.00	0.0	0.00	0.00
01/15/2021	0.00	0.00	0.0	0.00	0.00
01/16/2021	0.00	0.00	0.0	0.00	0.00
01/17/2021	0.00	0.00	0.0	0.00	0.00
01/18/2021	0.00	0.00	0.0	0.00	0.00
01/19/2021	0.00	0.00	0.0	0.00	0.00
01/20/2021	0.00	0.00	0.0	0.00	0.00
01/21/2021	0.00	0.00	0.0	0.00	0.00
01/22/2021	0.00	0.00	0.0	0.00	0.00
01/23/2021	41.43	6.45	0.0	0.05	0.08
01/24/2021	17.66	62.48	5.6	11.22	18.69
01/25/2021	15.90	74.08	7.1	14.24	23.74
01/26/2021	0.01	0.04	0.0	0.01	0.01
01/27/2021	0.00	0.00	0.0	0.00	0.00
01/28/2021	0.00	0.00	0.0	0.00	0.00
01/29/2021	0.00	0.00	0.0	0.00	0.00
01/30/2021	0.00	0.00	0.0	0.00	0.00
01/31/2021	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	75.00 *	143.05 *	12.7 *	25.52 *	42.52 *
Daily Min:	0.01	0.04	0.0	0.01	0.01
Daily Max:	41.43	74.08	7.1	14.24	23.74
Jan 2021 - Jan 2021	75.00	143.05	12.7	25.52	42.52
QTD:	75.00 *	143.05 *	12.7 *	25.52 *	42.52 *
YTD 2021:	75.00 *	143.05 *	12.7 *	25.52 *	42.52 *

Monthly Summary By Day Report

Unit CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:43 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
02/01/2021	0.00	0.00	0.0	0.00	0.00
02/02/2021	0.00	0.00	0.0	0.00	0.00
02/03/2021	0.00	0.00	0.0	0.00	0.00
02/04/2021	0.00	0.00	0.0	0.00	0.00
02/05/2021	0.00	0.00	0.0	0.00	0.00
02/06/2021	0.00	0.00	0.0	0.00	0.00
02/07/2021	0.00	0.00	0.0	0.00	0.00
02/08/2021	0.00	0.00	0.0	0.00	0.00
02/09/2021	0.00	0.00	0.0	0.00	0.00
02/10/2021	0.00	0.00	0.0	0.00	0.00
02/11/2021	0.00	0.00	0.0	0.00	0.00
02/12/2021	0.00	0.00	0.0	0.00	0.00
02/13/2021	0.00	0.00	0.0	0.00	0.00
02/14/2021	0.00	0.00	0.0	0.00	0.00
02/15/2021	0.00	0.00	0.0	0.00	0.00
02/16/2021	0.00	0.00	0.0	0.00	0.00
02/17/2021	0.00	0.00	0.0	0.00	0.00
02/18/2021	0.00	0.00	0.0	0.00	0.00
02/19/2021	0.00	0.00	0.0	0.00	0.00
02/20/2021	0.00	0.00	0.0	0.00	0.00
02/21/2021	0.00	0.00	0.0	0.00	0.00
02/22/2021	0.00	0.00	0.0	0.00	0.00
02/23/2021	0.00	0.00	0.0	0.00	0.00
02/24/2021	0.00	0.00	0.0	0.00	0.00
02/25/2021	0.00	0.00	0.0	0.00	0.00
02/26/2021	0.00	0.00	0.0	0.00	0.00
02/27/2021	0.00	0.00	0.0	0.00	0.00
02/28/2021	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	- *	- *	- *	- *	- *
Daily Min:	-	-	-	-	-
Daily Max:	-	-	-	-	-
Jan 2021 - Feb 2021	75.00	143.05	12.7	25.52	42.52
QTD:	75.00 *	143.05 *	12.7 *	25.52 *	42.52 *
YTD 2021:	75.00 *	143.05 *	12.7 *	25.52 *	42.52 *

Monthly Summary By Day Report

Unit CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:43 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
03/01/2021	0.00	0.00	0.0	0.00	0.00
03/02/2021	0.00	0.00	0.0	0.00	0.00
03/03/2021	0.00	0.00	0.0	0.00	0.00
03/04/2021	0.00	0.00	0.0	0.00	0.00
03/05/2021	0.00	0.00	0.0	0.00	0.00
03/06/2021	0.00	0.00	0.0	0.00	0.00
03/07/2021	0.00	0.00	0.0	0.00	0.00
03/08/2021	182.97	28.21	1.4	2.89	4.79
03/09/2021	0.00	0.00	0.0	0.00	0.00
03/10/2021	68.19	49.28	1.8	3.48	5.82
03/11/2021	0.00	0.00	0.0	0.00	0.00
03/12/2021	83.56	21.42	0.1	0.21	0.37
03/13/2021	25.05	27.12	2.8	5.70	9.52
03/14/2021	0.00	0.00	0.0	0.00	0.00
03/15/2021	0.00	0.00	0.0	0.00	0.00
03/16/2021	0.00	0.00	0.0	0.00	0.00
03/17/2021	0.00	0.00	0.0	0.00	0.00
03/18/2021	0.00	0.00	0.0	0.00	0.00
03/19/2021	0.00	0.00	0.0	0.00	0.00
03/20/2021	0.00	0.00	0.0	0.00	0.00
03/21/2021	0.00	0.00	0.0	0.00	0.00
03/22/2021	0.00	0.00	0.0	0.00	0.00
03/23/2021	62.26	46.66	3.5	6.57	10.94
03/24/2021	17.87	27.12	2.8	5.27	8.74
03/25/2021	0.00	0.00	0.0	0.00	0.00
03/26/2021	0.00	0.00	0.0	0.00	0.00
03/27/2021	0.00	0.00	0.0	0.00	0.00
03/28/2021	0.00	0.00	0.0	0.00	0.00
03/29/2021	0.00	0.00	0.0	0.00	0.00
03/30/2021	0.00	0.00	0.0	0.00	0.00
03/31/2021	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	439.90 *	199.81 *	12.4 *	24.12 *	40.18 *
Daily Min:	17.87	21.42	0.1	0.21	0.37
Daily Max:	182.97	49.28	3.5	6.57	10.94
Jan 2021 - Mar 2021	514.90	342.86	25.1	49.64	82.70
QTD:	514.90 *	342.86 *	25.1 *	49.64 *	82.70 *
YTD 2021:	514.90 *	342.86 *	25.1 *	49.64 *	82.70 *

Monthly Summary By Day Report

Unit CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:42 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
01/01/2021	0.00	0.00	0.0	0.00	0.00
01/02/2021	0.00	0.00	0.0	0.00	0.00
01/03/2021	0.00	0.00	0.0	0.00	0.00
01/04/2021	0.00	0.00	0.0	0.00	0.00
01/05/2021	0.00	0.00	0.0	0.00	0.00
01/06/2021	0.00	0.00	0.0	0.00	0.00
01/07/2021	0.00	0.00	0.0	0.00	0.00
01/08/2021	0.00	0.00	0.0	0.00	0.00
01/09/2021	0.00	0.00	0.0	0.00	0.00
01/10/2021	0.00	0.00	0.0	0.00	0.00
01/11/2021	0.00	0.00	0.0	0.00	0.00
01/12/2021	0.00	0.00	0.0	0.00	0.00
01/13/2021	0.00	0.00	0.0	0.00	0.00
01/14/2021	0.00	0.00	0.0	0.00	0.00
01/15/2021	0.00	0.00	0.0	0.00	0.00
01/16/2021	0.00	0.00	0.0	0.00	0.00
01/17/2021	0.00	0.00	0.0	0.00	0.00
01/18/2021	0.00	0.00	0.0	0.00	0.00
01/19/2021	0.00	0.00	0.0	0.00	0.00
01/20/2021	0.00	0.00	0.0	0.00	0.00
01/21/2021	0.00	0.00	0.0	0.00	0.00
01/22/2021	0.00	0.00	0.0	0.00	0.00
01/23/2021	0.00	0.00	0.0	0.00	0.00
01/24/2021	0.00	0.00	0.0	0.00	0.00
01/25/2021	0.00	0.00	0.0	0.00	0.00
01/26/2021	0.00	0.00	0.0	0.00	0.00
01/27/2021	0.00	0.00	0.0	0.00	0.00
01/28/2021	0.00	0.00	0.0	0.00	0.00
01/29/2021	0.00	0.00	0.0	0.00	0.00
01/30/2021	0.00	0.00	0.0	0.00	0.00
01/31/2021	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	- *	- *	- *	- *	- *
Daily Min:	-	-	-	-	-
Daily Max:	-	-	-	-	-
Jan 2021 - Jan 2021	-	-	-	-	-
QTD:	0.00 *	0.00 *	0.0 *	0.00 *	0.00 *
YTD 2021:	0.00 *	0.00 *	0.0 *	0.00 *	0.00 *

Monthly Summary By Day Report

Unit CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:42 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
02/01/2021	0.00	0.00	0.0	0.00	0.00
02/02/2021	0.00	0.00	0.0	0.00	0.00
02/03/2021	0.00	0.00	0.0	0.00	0.00
02/04/2021	0.00	0.00	0.0	0.00	0.00
02/05/2021	0.00	0.00	0.0	0.00	0.00
02/06/2021	0.00	0.00	0.0	0.00	0.00
02/07/2021	0.00	0.00	0.0	0.00	0.00
02/08/2021	0.00	0.00	0.0	0.00	0.00
02/09/2021	0.00	0.00	0.0	0.00	0.00
02/10/2021	0.00	0.00	0.0	0.00	0.00
02/11/2021	0.00	0.00	0.0	0.00	0.00
02/12/2021	0.00	0.00	0.0	0.00	0.00
02/13/2021	0.00	0.00	0.0	0.00	0.00
02/14/2021	0.00	0.00	0.0	0.00	0.00
02/15/2021	0.00	0.00	0.0	0.00	0.00
02/16/2021	0.00	0.00	0.0	0.00	0.00
02/17/2021	0.00	0.00	0.0	0.00	0.00
02/18/2021	0.00	0.00	0.0	0.00	0.00
02/19/2021	0.00	0.00	0.0	0.00	0.00
02/20/2021	0.00	0.00	0.0	0.00	0.00
02/21/2021	0.00	0.00	0.0	0.00	0.00
02/22/2021	0.00	0.00	0.0	0.00	0.00
02/23/2021	0.00	0.00	0.0	0.00	0.00
02/24/2021	0.00	0.00	0.0	0.00	0.00
02/25/2021	0.00	0.00	0.0	0.00	0.00
02/26/2021	290.84	37.94	1.6	3.19	5.32
02/27/2021	84.73	37.27	2.2	4.44	7.39
02/28/2021	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	375.57 *	75.21 *	3.8 *	7.63 *	12.71 *
Daily Min:	84.73	37.27	1.6	3.19	5.32
Daily Max:	290.84	37.94	2.2	4.44	7.39
Jan 2021 - Feb 2021	375.57	75.21	3.8	7.63	12.71
QTD:	375.57 *	75.21 *	3.8 *	7.63 *	12.71 *
YTD 2021:	375.57 *	75.21 *	3.8 *	7.63 *	12.71 *

Monthly Summary By Day Report

Unit CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:42 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
03/01/2021	50.79	49.99	2.3	4.66	7.77
03/02/2021	0.00	0.00	0.0	0.00	0.00
03/03/2021	0.00	0.00	0.0	0.00	0.00
03/04/2021	0.00	0.00	0.0	0.00	0.00
03/05/2021	0.00	0.00	0.0	0.00	0.00
03/06/2021	58.31	48.94	2.2	4.26	7.11
03/07/2021	0.00	0.00	0.0	0.00	0.00
03/08/2021	0.00	0.00	0.0	0.00	0.00
03/09/2021	0.00	0.00	0.0	0.00	0.00
03/10/2021	0.00	0.00	0.0	0.00	0.00
03/11/2021	0.00	0.00	0.0	0.00	0.00
03/12/2021	17.94	0.64	0.0	0.02	0.02
03/13/2021	27.22	33.40	3.0	6.42	10.71
03/14/2021	0.00	0.00	0.0	0.00	0.00
03/15/2021	0.00	0.00	0.0	0.00	0.00
03/16/2021	0.00	0.00	0.0	0.00	0.00
03/17/2021	0.00	0.00	0.0	0.00	0.00
03/18/2021	0.00	0.00	0.0	0.00	0.00
03/19/2021	0.00	0.00	0.0	0.00	0.00
03/20/2021	0.00	0.00	0.0	0.00	0.00
03/21/2021	0.00	0.00	0.0	0.00	0.00
03/22/2021	106.86	59.21	4.5	8.75	14.58
03/23/2021	27.46	35.82	3.5	6.90	11.53
03/24/2021	65.85	35.10	2.1	4.26	7.10
03/25/2021	63.73	22.92	1.0	2.05	3.41
03/26/2021	0.00	0.00	0.0	0.00	0.00
03/27/2021	0.00	0.00	0.0	0.00	0.00
03/28/2021	0.00	0.00	0.0	0.00	0.00
03/29/2021	0.00	0.00	0.0	0.00	0.00
03/30/2021	0.00	0.00	0.0	0.00	0.00
03/31/2021	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	418.16 *	286.02 *	18.6 *	37.32 *	62.23 *
Daily Min:	17.94	0.64	0.0	0.02	0.02
Daily Max:	106.86	59.21	4.5	8.75	14.58
Jan 2021 - Mar 2021	793.73	361.23	22.4	44.95	74.94
QTD:	793.73 *	361.23 *	22.4 *	44.95 *	74.94 *
YTD 2021:	793.73 *	361.23 *	22.4 *	44.95 *	74.94 *

AQ-60

AQ-60 If the Alstom GTX100 turbine are selected, the quarterly emissions shall not exceed the levels shown below:

Alstom GTX100 Gas Turbines					
Pollutant	Quarter 1 (lbs/quarter) Two turbines	Quarter 2 (lbs/quarter) Two Turbines	Quarter 3 (lbs/quarter) Two turbines	Quarter 4 (lbs/quarter) Two Turbines	Tons/ Year Two Turbines
NO _x	15,399	12,965	17,496	15,422	30.64
CO	26,787	32,590	28,175	29,862	58.71
VOCs	5,791	7,306	6,630	6,848	13.29
PM ₁₀	16,300	13,692	17,789	17,569	32.67
SO _x	3,385	2,843	3,694	3,648	6.78

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emission limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

Monthly Summary By Day Report

Units CT1 and CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:41 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
01/01/2021	0.00	0.00	0.00	0.00	0.00
01/02/2021	0.00	0.00	0.00	0.00	0.00
01/03/2021	0.00	0.00	0.00	0.00	0.00
01/04/2021	0.00	0.00	0.00	0.00	0.00
01/05/2021	0.00	0.00	0.00	0.00	0.00
01/06/2021	0.00	0.00	0.00	0.00	0.00
01/07/2021	0.00	0.00	0.00	0.00	0.00
01/08/2021	0.00	0.00	0.00	0.00	0.00
01/09/2021	0.00	0.00	0.00	0.00	0.00
01/10/2021	0.00	0.00	0.00	0.00	0.00
01/11/2021	0.00	0.00	0.00	0.00	0.00
01/12/2021	0.00	0.00	0.00	0.00	0.00
01/13/2021	0.00	0.00	0.00	0.00	0.00
01/14/2021	0.00	0.00	0.00	0.00	0.00
01/15/2021	0.00	0.00	0.00	0.00	0.00
01/16/2021	0.00	0.00	0.00	0.00	0.00
01/17/2021	0.00	0.00	0.00	0.00	0.00
01/18/2021	0.00	0.00	0.00	0.00	0.00
01/19/2021	0.00	0.00	0.00	0.00	0.00
01/20/2021	0.00	0.00	0.00	0.00	0.00
01/21/2021	0.00	0.00	0.00	0.00	0.00
01/22/2021	0.00	0.00	0.00	0.00	0.00
01/23/2021	41.43	6.45	0.02	0.05	0.08
01/24/2021	17.66	62.48	5.62	11.22	18.69
01/25/2021	15.90	74.08	7.10	14.24	23.74
01/26/2021	0.01	0.04	0.00	0.01	0.01
01/27/2021	0.00	0.00	0.00	0.00	0.00
01/28/2021	0.00	0.00	0.00	0.00	0.00
01/29/2021	0.00	0.00	0.00	0.00	0.00
01/30/2021	0.00	0.00	0.00	0.00	0.00
01/31/2021	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	75.00 *	143.05 *	12.74 *	25.52 *	42.52 *
Daily Min:	0.01	0.04	0.00	0.01	0.01
Daily Max:	41.43	74.08	7.10	14.24	23.74
Jan 2021 - Jan 2021	75.00	143.05	12.74	25.52	42.52
QTD:	75.00 *	143.05 *	12.74 *	25.52 *	42.52 *
YTD 2021:	75.00 *	143.05 *	12.74 *	25.52 *	42.52 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:41 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
02/01/2021	0.00	0.00	0.00	0.00	0.00
02/02/2021	0.00	0.00	0.00	0.00	0.00
02/03/2021	0.00	0.00	0.00	0.00	0.00
02/04/2021	0.00	0.00	0.00	0.00	0.00
02/05/2021	0.00	0.00	0.00	0.00	0.00
02/06/2021	0.00	0.00	0.00	0.00	0.00
02/07/2021	0.00	0.00	0.00	0.00	0.00
02/08/2021	0.00	0.00	0.00	0.00	0.00
02/09/2021	0.00	0.00	0.00	0.00	0.00
02/10/2021	0.00	0.00	0.00	0.00	0.00
02/11/2021	0.00	0.00	0.00	0.00	0.00
02/12/2021	0.00	0.00	0.00	0.00	0.00
02/13/2021	0.00	0.00	0.00	0.00	0.00
02/14/2021	0.00	0.00	0.00	0.00	0.00
02/15/2021	0.00	0.00	0.00	0.00	0.00
02/16/2021	0.00	0.00	0.00	0.00	0.00
02/17/2021	0.00	0.00	0.00	0.00	0.00
02/18/2021	0.00	0.00	0.00	0.00	0.00
02/19/2021	0.00	0.00	0.00	0.00	0.00
02/20/2021	0.00	0.00	0.00	0.00	0.00
02/21/2021	0.00	0.00	0.00	0.00	0.00
02/22/2021	0.00	0.00	0.00	0.00	0.00
02/23/2021	0.00	0.00	0.00	0.00	0.00
02/24/2021	0.00	0.00	0.00	0.00	0.00
02/25/2021	0.00	0.00	0.00	0.00	0.00
02/26/2021	290.84	37.94	1.60	3.19	5.32
02/27/2021	84.73	37.27	2.23	4.44	7.39
02/28/2021	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	375.57 *	75.21 *	3.83 *	7.63 *	12.71 *
Daily Min:	84.73	37.27	1.60	3.19	5.32
Daily Max:	290.84	37.94	2.23	4.44	7.39
Jan 2021 - Feb 2021	450.57	218.26	16.57	33.15	55.23
QTD:	450.57 *	218.26 *	16.57 *	33.15 *	55.23 *
YTD 2021:	450.57 *	218.26 *	16.57 *	33.15 *	55.23 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:41 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
03/01/2021	50.79	49.99	2.31	4.66	7.77
03/02/2021	0.00	0.00	0.00	0.00	0.00
03/03/2021	0.00	0.00	0.00	0.00	0.00
03/04/2021	0.00	0.00	0.00	0.00	0.00
03/05/2021	0.00	0.00	0.00	0.00	0.00
03/06/2021	58.31	48.94	2.12	4.26	7.11
03/07/2021	0.00	0.00	0.00	0.00	0.00
03/08/2021	183.31	28.21	1.41	2.89	4.79
03/09/2021	0.00	0.00	0.00	0.00	0.00
03/10/2021	68.19	49.28	1.75	3.48	5.82
03/11/2021	0.00	0.00	0.00	0.00	0.00
03/12/2021	101.50	22.06	0.11	0.23	0.39
03/13/2021	71.12	60.52	6.05	12.12	20.23
03/14/2021	0.00	0.00	0.00	0.00	0.00
03/15/2021	0.00	0.00	0.00	0.00	0.00
03/16/2021	0.00	0.00	0.00	0.00	0.00
03/17/2021	0.00	0.00	0.00	0.00	0.00
03/18/2021	0.00	0.00	0.00	0.00	0.00
03/19/2021	0.00	0.00	0.00	0.00	0.00
03/20/2021	0.00	0.00	0.00	0.00	0.00
03/21/2021	0.00	0.00	0.00	0.00	0.00
03/22/2021	106.86	59.21	4.38	8.75	14.58
03/23/2021	89.72	82.48	6.76	13.47	22.47
03/24/2021	83.72	62.22	4.73	9.53	15.84
03/25/2021	63.73	22.92	1.01	2.05	3.41
03/26/2021	0.00	0.00	0.00	0.00	0.00
03/27/2021	0.00	0.00	0.00	0.00	0.00
03/28/2021	0.00	0.00	0.00	0.00	0.00
03/29/2021	0.00	0.00	0.00	0.00	0.00
03/30/2021	0.00	0.00	0.00	0.00	0.00
03/31/2021	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	877.25 *	485.83 *	30.63 *	61.44 *	102.41 *
Daily Min:	50.79	22.06	0.11	0.23	0.39
Daily Max:	183.31	82.48	6.76	13.47	22.47
Jan 2021 - Mar 2021	1,327.82	704.09	47.20	94.59	157.64
QTD:	1,327.82 *	704.09 *	47.20 *	94.59 *	157.64 *
YTD 2021:	1,327.82 *	704.09 *	47.20 *	94.59 *	157.64 *

Monthly Summary By Day Report

Unit CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:43 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
01/01/2021	0.00	0.00	0.0	0.00	0.00
01/02/2021	0.00	0.00	0.0	0.00	0.00
01/03/2021	0.00	0.00	0.0	0.00	0.00
01/04/2021	0.00	0.00	0.0	0.00	0.00
01/05/2021	0.00	0.00	0.0	0.00	0.00
01/06/2021	0.00	0.00	0.0	0.00	0.00
01/07/2021	0.00	0.00	0.0	0.00	0.00
01/08/2021	0.00	0.00	0.0	0.00	0.00
01/09/2021	0.00	0.00	0.0	0.00	0.00
01/10/2021	0.00	0.00	0.0	0.00	0.00
01/11/2021	0.00	0.00	0.0	0.00	0.00
01/12/2021	0.00	0.00	0.0	0.00	0.00
01/13/2021	0.00	0.00	0.0	0.00	0.00
01/14/2021	0.00	0.00	0.0	0.00	0.00
01/15/2021	0.00	0.00	0.0	0.00	0.00
01/16/2021	0.00	0.00	0.0	0.00	0.00
01/17/2021	0.00	0.00	0.0	0.00	0.00
01/18/2021	0.00	0.00	0.0	0.00	0.00
01/19/2021	0.00	0.00	0.0	0.00	0.00
01/20/2021	0.00	0.00	0.0	0.00	0.00
01/21/2021	0.00	0.00	0.0	0.00	0.00
01/22/2021	0.00	0.00	0.0	0.00	0.00
01/23/2021	41.43	6.45	0.0	0.05	0.08
01/24/2021	17.66	62.48	5.6	11.22	18.69
01/25/2021	15.90	74.08	7.1	14.24	23.74
01/26/2021	0.01	0.04	0.0	0.01	0.01
01/27/2021	0.00	0.00	0.0	0.00	0.00
01/28/2021	0.00	0.00	0.0	0.00	0.00
01/29/2021	0.00	0.00	0.0	0.00	0.00
01/30/2021	0.00	0.00	0.0	0.00	0.00
01/31/2021	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	75.00 *	143.05 *	12.7 *	25.52 *	42.52 *
Daily Min:	0.01	0.04	0.0	0.01	0.01
Daily Max:	41.43	74.08	7.1	14.24	23.74
Jan 2021 - Jan 2021	75.00	143.05	12.7	25.52	42.52
QTD:	75.00 *	143.05 *	12.7 *	25.52 *	42.52 *
YTD 2021:	75.00 *	143.05 *	12.7 *	25.52 *	42.52 *

Monthly Summary By Day Report

Unit CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:43 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
02/01/2021	0.00	0.00	0.0	0.00	0.00
02/02/2021	0.00	0.00	0.0	0.00	0.00
02/03/2021	0.00	0.00	0.0	0.00	0.00
02/04/2021	0.00	0.00	0.0	0.00	0.00
02/05/2021	0.00	0.00	0.0	0.00	0.00
02/06/2021	0.00	0.00	0.0	0.00	0.00
02/07/2021	0.00	0.00	0.0	0.00	0.00
02/08/2021	0.00	0.00	0.0	0.00	0.00
02/09/2021	0.00	0.00	0.0	0.00	0.00
02/10/2021	0.00	0.00	0.0	0.00	0.00
02/11/2021	0.00	0.00	0.0	0.00	0.00
02/12/2021	0.00	0.00	0.0	0.00	0.00
02/13/2021	0.00	0.00	0.0	0.00	0.00
02/14/2021	0.00	0.00	0.0	0.00	0.00
02/15/2021	0.00	0.00	0.0	0.00	0.00
02/16/2021	0.00	0.00	0.0	0.00	0.00
02/17/2021	0.00	0.00	0.0	0.00	0.00
02/18/2021	0.00	0.00	0.0	0.00	0.00
02/19/2021	0.00	0.00	0.0	0.00	0.00
02/20/2021	0.00	0.00	0.0	0.00	0.00
02/21/2021	0.00	0.00	0.0	0.00	0.00
02/22/2021	0.00	0.00	0.0	0.00	0.00
02/23/2021	0.00	0.00	0.0	0.00	0.00
02/24/2021	0.00	0.00	0.0	0.00	0.00
02/25/2021	0.00	0.00	0.0	0.00	0.00
02/26/2021	0.00	0.00	0.0	0.00	0.00
02/27/2021	0.00	0.00	0.0	0.00	0.00
02/28/2021	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	- *	- *	- *	- *	- *
Daily Min:	-	-	-	-	-
Daily Max:	-	-	-	-	-
Jan 2021 - Feb 2021	75.00	143.05	12.7	25.52	42.52
QTD:	75.00 *	143.05 *	12.7 *	25.52 *	42.52 *
YTD 2021:	75.00 *	143.05 *	12.7 *	25.52 *	42.52 *

Monthly Summary By Day Report

Unit CT1



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:43 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
03/01/2021	0.00	0.00	0.0	0.00	0.00
03/02/2021	0.00	0.00	0.0	0.00	0.00
03/03/2021	0.00	0.00	0.0	0.00	0.00
03/04/2021	0.00	0.00	0.0	0.00	0.00
03/05/2021	0.00	0.00	0.0	0.00	0.00
03/06/2021	0.00	0.00	0.0	0.00	0.00
03/07/2021	0.00	0.00	0.0	0.00	0.00
03/08/2021	182.97	28.21	1.4	2.89	4.79
03/09/2021	0.00	0.00	0.0	0.00	0.00
03/10/2021	68.19	49.28	1.8	3.48	5.82
03/11/2021	0.00	0.00	0.0	0.00	0.00
03/12/2021	83.56	21.42	0.1	0.21	0.37
03/13/2021	25.05	27.12	2.8	5.70	9.52
03/14/2021	0.00	0.00	0.0	0.00	0.00
03/15/2021	0.00	0.00	0.0	0.00	0.00
03/16/2021	0.00	0.00	0.0	0.00	0.00
03/17/2021	0.00	0.00	0.0	0.00	0.00
03/18/2021	0.00	0.00	0.0	0.00	0.00
03/19/2021	0.00	0.00	0.0	0.00	0.00
03/20/2021	0.00	0.00	0.0	0.00	0.00
03/21/2021	0.00	0.00	0.0	0.00	0.00
03/22/2021	0.00	0.00	0.0	0.00	0.00
03/23/2021	62.26	46.66	3.5	6.57	10.94
03/24/2021	17.87	27.12	2.8	5.27	8.74
03/25/2021	0.00	0.00	0.0	0.00	0.00
03/26/2021	0.00	0.00	0.0	0.00	0.00
03/27/2021	0.00	0.00	0.0	0.00	0.00
03/28/2021	0.00	0.00	0.0	0.00	0.00
03/29/2021	0.00	0.00	0.0	0.00	0.00
03/30/2021	0.00	0.00	0.0	0.00	0.00
03/31/2021	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	439.90 *	199.81 *	12.4 *	24.12 *	40.18 *
Daily Min:	17.87	21.42	0.1	0.21	0.37
Daily Max:	182.97	49.28	3.5	6.57	10.94
Jan 2021 - Mar 2021	514.90	342.86	25.1	49.64	82.70
QTD:	514.90 *	342.86 *	25.1 *	49.64 *	82.70 *
YTD 2021:	514.90 *	342.86 *	25.1 *	49.64 *	82.70 *

Monthly Summary By Day Report

Unit CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:42 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
01/01/2021	0.00	0.00	0.0	0.00	0.00
01/02/2021	0.00	0.00	0.0	0.00	0.00
01/03/2021	0.00	0.00	0.0	0.00	0.00
01/04/2021	0.00	0.00	0.0	0.00	0.00
01/05/2021	0.00	0.00	0.0	0.00	0.00
01/06/2021	0.00	0.00	0.0	0.00	0.00
01/07/2021	0.00	0.00	0.0	0.00	0.00
01/08/2021	0.00	0.00	0.0	0.00	0.00
01/09/2021	0.00	0.00	0.0	0.00	0.00
01/10/2021	0.00	0.00	0.0	0.00	0.00
01/11/2021	0.00	0.00	0.0	0.00	0.00
01/12/2021	0.00	0.00	0.0	0.00	0.00
01/13/2021	0.00	0.00	0.0	0.00	0.00
01/14/2021	0.00	0.00	0.0	0.00	0.00
01/15/2021	0.00	0.00	0.0	0.00	0.00
01/16/2021	0.00	0.00	0.0	0.00	0.00
01/17/2021	0.00	0.00	0.0	0.00	0.00
01/18/2021	0.00	0.00	0.0	0.00	0.00
01/19/2021	0.00	0.00	0.0	0.00	0.00
01/20/2021	0.00	0.00	0.0	0.00	0.00
01/21/2021	0.00	0.00	0.0	0.00	0.00
01/22/2021	0.00	0.00	0.0	0.00	0.00
01/23/2021	0.00	0.00	0.0	0.00	0.00
01/24/2021	0.00	0.00	0.0	0.00	0.00
01/25/2021	0.00	0.00	0.0	0.00	0.00
01/26/2021	0.00	0.00	0.0	0.00	0.00
01/27/2021	0.00	0.00	0.0	0.00	0.00
01/28/2021	0.00	0.00	0.0	0.00	0.00
01/29/2021	0.00	0.00	0.0	0.00	0.00
01/30/2021	0.00	0.00	0.0	0.00	0.00
01/31/2021	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	- *	- *	- *	- *	- *
Daily Min:	-	-	-	-	-
Daily Max:	-	-	-	-	-
Jan 2021 - Jan 2021	-	-	-	-	-
QTD:	0.00 *	0.00 *	0.0 *	0.00 *	0.00 *
YTD 2021:	0.00 *	0.00 *	0.0 *	0.00 *	0.00 *

Monthly Summary By Day Report

Unit CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:42 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
02/01/2021	0.00	0.00	0.0	0.00	0.00
02/02/2021	0.00	0.00	0.0	0.00	0.00
02/03/2021	0.00	0.00	0.0	0.00	0.00
02/04/2021	0.00	0.00	0.0	0.00	0.00
02/05/2021	0.00	0.00	0.0	0.00	0.00
02/06/2021	0.00	0.00	0.0	0.00	0.00
02/07/2021	0.00	0.00	0.0	0.00	0.00
02/08/2021	0.00	0.00	0.0	0.00	0.00
02/09/2021	0.00	0.00	0.0	0.00	0.00
02/10/2021	0.00	0.00	0.0	0.00	0.00
02/11/2021	0.00	0.00	0.0	0.00	0.00
02/12/2021	0.00	0.00	0.0	0.00	0.00
02/13/2021	0.00	0.00	0.0	0.00	0.00
02/14/2021	0.00	0.00	0.0	0.00	0.00
02/15/2021	0.00	0.00	0.0	0.00	0.00
02/16/2021	0.00	0.00	0.0	0.00	0.00
02/17/2021	0.00	0.00	0.0	0.00	0.00
02/18/2021	0.00	0.00	0.0	0.00	0.00
02/19/2021	0.00	0.00	0.0	0.00	0.00
02/20/2021	0.00	0.00	0.0	0.00	0.00
02/21/2021	0.00	0.00	0.0	0.00	0.00
02/22/2021	0.00	0.00	0.0	0.00	0.00
02/23/2021	0.00	0.00	0.0	0.00	0.00
02/24/2021	0.00	0.00	0.0	0.00	0.00
02/25/2021	0.00	0.00	0.0	0.00	0.00
02/26/2021	290.84	37.94	1.6	3.19	5.32
02/27/2021	84.73	37.27	2.2	4.44	7.39
02/28/2021	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	375.57 *	75.21 *	3.8 *	7.63 *	12.71 *
Daily Min:	84.73	37.27	1.6	3.19	5.32
Daily Max:	290.84	37.94	2.2	4.44	7.39
Jan 2021 - Feb 2021	375.57	75.21	3.8	7.63	12.71
QTD:	375.57 *	75.21 *	3.8 *	7.63 *	12.71 *
YTD 2021:	375.57 *	75.21 *	3.8 *	7.63 *	12.71 *

Monthly Summary By Day Report

Unit CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:42 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
03/01/2021	50.79	49.99	2.3	4.66	7.77
03/02/2021	0.00	0.00	0.0	0.00	0.00
03/03/2021	0.00	0.00	0.0	0.00	0.00
03/04/2021	0.00	0.00	0.0	0.00	0.00
03/05/2021	0.00	0.00	0.0	0.00	0.00
03/06/2021	58.31	48.94	2.2	4.26	7.11
03/07/2021	0.00	0.00	0.0	0.00	0.00
03/08/2021	0.00	0.00	0.0	0.00	0.00
03/09/2021	0.00	0.00	0.0	0.00	0.00
03/10/2021	0.00	0.00	0.0	0.00	0.00
03/11/2021	0.00	0.00	0.0	0.00	0.00
03/12/2021	17.94	0.64	0.0	0.02	0.02
03/13/2021	27.22	33.40	3.0	6.42	10.71
03/14/2021	0.00	0.00	0.0	0.00	0.00
03/15/2021	0.00	0.00	0.0	0.00	0.00
03/16/2021	0.00	0.00	0.0	0.00	0.00
03/17/2021	0.00	0.00	0.0	0.00	0.00
03/18/2021	0.00	0.00	0.0	0.00	0.00
03/19/2021	0.00	0.00	0.0	0.00	0.00
03/20/2021	0.00	0.00	0.0	0.00	0.00
03/21/2021	0.00	0.00	0.0	0.00	0.00
03/22/2021	106.86	59.21	4.5	8.75	14.58
03/23/2021	27.46	35.82	3.5	6.90	11.53
03/24/2021	65.85	35.10	2.1	4.26	7.10
03/25/2021	63.73	22.92	1.0	2.05	3.41
03/26/2021	0.00	0.00	0.0	0.00	0.00
03/27/2021	0.00	0.00	0.0	0.00	0.00
03/28/2021	0.00	0.00	0.0	0.00	0.00
03/29/2021	0.00	0.00	0.0	0.00	0.00
03/30/2021	0.00	0.00	0.0	0.00	0.00
03/31/2021	0.00	0.00	0.0	0.00	0.00
Monthly Avg/Sum*:	418.16 *	286.02 *	18.6 *	37.32 *	62.23 *
Daily Min:	17.94	0.64	0.0	0.02	0.02
Daily Max:	106.86	59.21	4.5	8.75	14.58
Jan 2021 - Mar 2021	793.73	361.23	22.4	44.95	74.94
QTD:	793.73 *	361.23 *	22.4 *	44.95 *	74.94 *
YTD 2021:	793.73 *	361.23 *	22.4 *	44.95 *	74.94 *

AQ-63

AQ-63 The Total Facility Emissions shall not exceed the following quarterly emissions rates.

POLLUTANT	Q1 (LBS)	Q2 (LBS)	Q3 (LBS)	Q4 (LBS)	TONS/YEAR
NOX	15546	13412	17646	15572	31.09
CO	27121	33872	28515	30202	59.86
VOC	5832	7455	6672	6890	13.42
PM-10	17854	15513	19378	19158	35.95
SO2	3400	2893	3709	3663	6.83

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6

Monthly Summary By Day Report

Units CT1 and CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:41 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
01/01/2021	0.00	0.00	0.00	0.00	0.00
01/02/2021	0.00	0.00	0.00	0.00	0.00
01/03/2021	0.00	0.00	0.00	0.00	0.00
01/04/2021	0.00	0.00	0.00	0.00	0.00
01/05/2021	0.00	0.00	0.00	0.00	0.00
01/06/2021	0.00	0.00	0.00	0.00	0.00
01/07/2021	0.00	0.00	0.00	0.00	0.00
01/08/2021	0.00	0.00	0.00	0.00	0.00
01/09/2021	0.00	0.00	0.00	0.00	0.00
01/10/2021	0.00	0.00	0.00	0.00	0.00
01/11/2021	0.00	0.00	0.00	0.00	0.00
01/12/2021	0.00	0.00	0.00	0.00	0.00
01/13/2021	0.00	0.00	0.00	0.00	0.00
01/14/2021	0.00	0.00	0.00	0.00	0.00
01/15/2021	0.00	0.00	0.00	0.00	0.00
01/16/2021	0.00	0.00	0.00	0.00	0.00
01/17/2021	0.00	0.00	0.00	0.00	0.00
01/18/2021	0.00	0.00	0.00	0.00	0.00
01/19/2021	0.00	0.00	0.00	0.00	0.00
01/20/2021	0.00	0.00	0.00	0.00	0.00
01/21/2021	0.00	0.00	0.00	0.00	0.00
01/22/2021	0.00	0.00	0.00	0.00	0.00
01/23/2021	41.43	6.45	0.02	0.05	0.08
01/24/2021	17.66	62.48	5.62	11.22	18.69
01/25/2021	15.90	74.08	7.10	14.24	23.74
01/26/2021	0.01	0.04	0.00	0.01	0.01
01/27/2021	0.00	0.00	0.00	0.00	0.00
01/28/2021	0.00	0.00	0.00	0.00	0.00
01/29/2021	0.00	0.00	0.00	0.00	0.00
01/30/2021	0.00	0.00	0.00	0.00	0.00
01/31/2021	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	75.00 *	143.05 *	12.74 *	25.52 *	42.52 *
Daily Min:	0.01	0.04	0.00	0.01	0.01
Daily Max:	41.43	74.08	7.10	14.24	23.74
Jan 2021 - Jan 2021	75.00	143.05	12.74	25.52	42.52
QTD:	75.00 *	143.05 *	12.74 *	25.52 *	42.52 *
YTD 2021:	75.00 *	143.05 *	12.74 *	25.52 *	42.52 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:41 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
02/01/2021	0.00	0.00	0.00	0.00	0.00
02/02/2021	0.00	0.00	0.00	0.00	0.00
02/03/2021	0.00	0.00	0.00	0.00	0.00
02/04/2021	0.00	0.00	0.00	0.00	0.00
02/05/2021	0.00	0.00	0.00	0.00	0.00
02/06/2021	0.00	0.00	0.00	0.00	0.00
02/07/2021	0.00	0.00	0.00	0.00	0.00
02/08/2021	0.00	0.00	0.00	0.00	0.00
02/09/2021	0.00	0.00	0.00	0.00	0.00
02/10/2021	0.00	0.00	0.00	0.00	0.00
02/11/2021	0.00	0.00	0.00	0.00	0.00
02/12/2021	0.00	0.00	0.00	0.00	0.00
02/13/2021	0.00	0.00	0.00	0.00	0.00
02/14/2021	0.00	0.00	0.00	0.00	0.00
02/15/2021	0.00	0.00	0.00	0.00	0.00
02/16/2021	0.00	0.00	0.00	0.00	0.00
02/17/2021	0.00	0.00	0.00	0.00	0.00
02/18/2021	0.00	0.00	0.00	0.00	0.00
02/19/2021	0.00	0.00	0.00	0.00	0.00
02/20/2021	0.00	0.00	0.00	0.00	0.00
02/21/2021	0.00	0.00	0.00	0.00	0.00
02/22/2021	0.00	0.00	0.00	0.00	0.00
02/23/2021	0.00	0.00	0.00	0.00	0.00
02/24/2021	0.00	0.00	0.00	0.00	0.00
02/25/2021	0.00	0.00	0.00	0.00	0.00
02/26/2021	290.84	37.94	1.60	3.19	5.32
02/27/2021	84.73	37.27	2.23	4.44	7.39
02/28/2021	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	375.57 *	75.21 *	3.83 *	7.63 *	12.71 *
Daily Min:	84.73	37.27	1.60	3.19	5.32
Daily Max:	290.84	37.94	2.23	4.44	7.39
Jan 2021 - Feb 2021	450.57	218.26	16.57	33.15	55.23
QTD:	450.57 *	218.26 *	16.57 *	33.15 *	55.23 *
YTD 2021:	450.57 *	218.26 *	16.57 *	33.15 *	55.23 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 01/01/2021 00:00 To: 03/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/01/2021 14:41 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
03/01/2021	50.79	49.99	2.31	4.66	7.77
03/02/2021	0.00	0.00	0.00	0.00	0.00
03/03/2021	0.00	0.00	0.00	0.00	0.00
03/04/2021	0.00	0.00	0.00	0.00	0.00
03/05/2021	0.00	0.00	0.00	0.00	0.00
03/06/2021	58.31	48.94	2.12	4.26	7.11
03/07/2021	0.00	0.00	0.00	0.00	0.00
03/08/2021	183.31	28.21	1.41	2.89	4.79
03/09/2021	0.00	0.00	0.00	0.00	0.00
03/10/2021	68.19	49.28	1.75	3.48	5.82
03/11/2021	0.00	0.00	0.00	0.00	0.00
03/12/2021	101.50	22.06	0.11	0.23	0.39
03/13/2021	71.12	60.52	6.05	12.12	20.23
03/14/2021	0.00	0.00	0.00	0.00	0.00
03/15/2021	0.00	0.00	0.00	0.00	0.00
03/16/2021	0.00	0.00	0.00	0.00	0.00
03/17/2021	0.00	0.00	0.00	0.00	0.00
03/18/2021	0.00	0.00	0.00	0.00	0.00
03/19/2021	0.00	0.00	0.00	0.00	0.00
03/20/2021	0.00	0.00	0.00	0.00	0.00
03/21/2021	0.00	0.00	0.00	0.00	0.00
03/22/2021	106.86	59.21	4.38	8.75	14.58
03/23/2021	89.72	82.48	6.76	13.47	22.47
03/24/2021	83.72	62.22	4.73	9.53	15.84
03/25/2021	63.73	22.92	1.01	2.05	3.41
03/26/2021	0.00	0.00	0.00	0.00	0.00
03/27/2021	0.00	0.00	0.00	0.00	0.00
03/28/2021	0.00	0.00	0.00	0.00	0.00
03/29/2021	0.00	0.00	0.00	0.00	0.00
03/30/2021	0.00	0.00	0.00	0.00	0.00
03/31/2021	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum*:	877.25 *	485.83 *	30.63 *	61.44 *	102.41 *
Daily Min:	50.79	22.06	0.11	0.23	0.39
Daily Max:	183.31	82.48	6.76	13.47	22.47
Jan 2021 - Mar 2021	1,327.82	704.09	47.20	94.59	157.64
QTD:	1,327.82 *	704.09 *	47.20 *	94.59 *	157.64 *
YTD 2021:	1,327.82 *	704.09 *	47.20 *	94.59 *	157.64 *

Tons 12 Month Rolling Summary

CT1 and CT2 Combined



From: 01/01/2021 00:00 **To:** 03/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2021 14:44 **Location:** Roseville, CA

* = Excess Emission

Date	Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2	
	CO, Ton		NOx, Ton		PM10, Ton		SO2, Ton		VOC, Ton	
	1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)	
	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum
Jan 2021	0.0375	2.3537	0.0714	7.4988	0.0127	1.4139	0.0064	0.7071	0.0212	2.3550
Feb 2021	0.1878	2.3603	0.0376	7.1818	0.0038	1.3539	0.0019	0.6771	0.0064	2.2550
Mar 2021	0.4389	2.7992	0.2429	7.4247	0.0306	1.3845	0.0155	0.6926	0.0512	2.3062
Sum/Avg	2.7992		7.4247		1.3845		0.6926		2.3062	
Limit Value										

Replace the dates with the ones you need

1/1/2021 0:00

3/31/2021 0:00

1D

TOWER AVG.

519-AIT-9504-1

1192

1/1/21 0:00	638.2
1/2/21 0:00	876.2
1/3/21 0:00	968.0
1/4/21 0:00	1035.3
1/5/21 0:00	1019.9
1/6/21 0:00	986.3
1/7/21 0:00	975.9
1/8/21 0:00	960.0
1/9/21 0:00	964.9
1/10/21 0:00	945.5
1/11/21 0:00	1040.0
1/12/21 0:00	1042.0
1/13/21 0:00	1056.9
1/14/21 0:00	1087.6
1/15/21 0:00	1073.0
1/16/21 0:00	1093.5
1/17/21 0:00	1110.6
1/18/21 0:00	1109.6
1/19/21 0:00	1072.0
1/20/21 0:00	1039.6
1/21/21 0:00	1045.4
1/22/21 0:00	1067.0
1/23/21 0:00	1062.2
1/24/21 0:00	1086.8
1/25/21 0:00	2706.8
1/26/21 0:00	2311.7
1/27/21 0:00	1162.5
1/28/21 0:00	1151.3
1/29/21 0:00	1092.2
1/30/21 0:00	1065.8
1/31/21 0:00	1306.0
2/1/21 0:00	1329.5
2/2/21 0:00	1557.7
2/3/21 0:00	1505.6
2/4/21 0:00	1430.4
2/5/21 0:00	1410.0
2/6/21 0:00	1227.0
2/7/21 0:00	1214.2
2/8/21 0:00	1196.8
2/9/21 0:00	1216.9
2/10/21 0:00	1271.6
2/11/21 0:00	1294.3
2/12/21 0:00	1247.8
2/13/21 0:00	1256.8
2/14/21 0:00	1247.8
2/15/21 0:00	1211.7
2/16/21 0:00	1247.9
2/17/21 0:00	1216.5
2/18/21 0:00	1170.2

2/19/21 0:00	1353.9
2/20/21 0:00	1350.3
2/21/21 0:00	1313.1
2/22/21 0:00	1328.5
2/23/21 0:00	1378.8
2/24/21 0:00	1355.8
2/25/21 0:00	1373.3
2/26/21 0:00	1134.4
2/27/21 0:00	1054.9
2/28/21 0:00	1178.2
3/1/21 0:00	1004.9
3/2/21 0:00	1365.4
3/3/21 0:00	1196.1
3/4/21 0:00	1091.9
3/5/21 0:00	1086.4
3/6/21 0:00	1057.6
3/7/21 0:00	1167.1
3/8/21 0:00	974.1
3/9/21 0:00	1213.4
3/10/21 0:00	928.4
3/11/21 0:00	1070.8
3/12/21 0:00	897.8
3/13/21 0:00	851.9
3/14/21 0:00	1475.1
3/15/21 0:00	1249.2
3/16/21 0:00	1140.8
3/17/21 0:00	1086.9
3/18/21 0:00	1068.0
3/19/21 0:00	1070.1
3/20/21 0:00	1065.0
3/21/21 0:00	983.5
3/22/21 0:00	964.7
3/23/21 0:00	1839.5
3/24/21 0:00	2146.9
3/25/21 0:00	1671.7
3/26/21 0:00	1467.7
3/27/21 0:00	1157.4
3/28/21 0:00	985.0
3/29/21 0:00	945.6
3/30/21 0:00	878.6
3/31/21 0:00	981.7

ROSEVILLE ENERGY PARK COOLING TOWER EMISSIONS

POLLUTANT	LBS PER DAY	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4
PM-10	16.3	1471	1487	1504	1504

Whereas compliance with the PM-10 emission limit shall be demonstrated as;
Cooling tower recirculation rate * total dissolved solids of blowdown * design drift rate

<u>Circ pump flow rate</u>	53814	Gallons per minute
	* 8.33	Pounds per gallon
	* 1440	Minutes per day
	64,550,969	Pounds per day

<u>Total dissolved solids</u>	1192	Average daily conductivity umhos
	0.00000064	Conversion to TDS ppm
	0.00076288	

<u>Design drift rate</u>	0.005%

PM-10 pounds per day	2.46

90	Days in quarter

PM-10 pounds this quarter	222	1Q21

fill only these

AQ68

AQ68 A water sample analysis of cooling tower water shall be performed within 180 days of initial operation and annually thereafter.

Verification; The Project owner shall submit to the CPM and the PCAPCD the initial and annual cooling tower water sample analysis for approval no later than 60 days following the date of test performance.

The Cooling Tower Water Analysis was reported with the 1Q20 QAQR.

AQ-69

AQ-69 No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

In regards to AQ-69 of Roseville Energy Park's 1Q21 QAQR, there were no violations of PCAPCD's Rule 205 for nuisance.

AQ-70

AQ-70 PM-10 emission rates from the cooling tower shall not exceed the following limits

Cooling Tower Emissions Limitations					
Pollutant	Lbs/day	Quarter 1	Quarter 2	Quarter 3	Quarter 4
PM 10	16.3	1471	1487	1504	1504

Verification: the Project owner shall include all the necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly air Quality Report required in condition of Certification AQ-SC6.

Replace the dates with the ones you need

1/1/2021 0:00

3/31/2021 0:00

1D

TOWER AVG.

519-AIT-9504-1

1192

1/1/21 0:00	638.2
1/2/21 0:00	876.2
1/3/21 0:00	968.0
1/4/21 0:00	1035.3
1/5/21 0:00	1019.9
1/6/21 0:00	986.3
1/7/21 0:00	975.9
1/8/21 0:00	960.0
1/9/21 0:00	964.9
1/10/21 0:00	945.5
1/11/21 0:00	1040.0
1/12/21 0:00	1042.0
1/13/21 0:00	1056.9
1/14/21 0:00	1087.6
1/15/21 0:00	1073.0
1/16/21 0:00	1093.5
1/17/21 0:00	1110.6
1/18/21 0:00	1109.6
1/19/21 0:00	1072.0
1/20/21 0:00	1039.6
1/21/21 0:00	1045.4
1/22/21 0:00	1067.0
1/23/21 0:00	1062.2
1/24/21 0:00	1086.8
1/25/21 0:00	2706.8
1/26/21 0:00	2311.7
1/27/21 0:00	1162.5
1/28/21 0:00	1151.3
1/29/21 0:00	1092.2
1/30/21 0:00	1065.8
1/31/21 0:00	1306.0
2/1/21 0:00	1329.5
2/2/21 0:00	1557.7
2/3/21 0:00	1505.6
2/4/21 0:00	1430.4
2/5/21 0:00	1410.0
2/6/21 0:00	1227.0
2/7/21 0:00	1214.2
2/8/21 0:00	1196.8
2/9/21 0:00	1216.9
2/10/21 0:00	1271.6
2/11/21 0:00	1294.3
2/12/21 0:00	1247.8
2/13/21 0:00	1256.8
2/14/21 0:00	1247.8
2/15/21 0:00	1211.7
2/16/21 0:00	1247.9
2/17/21 0:00	1216.5
2/18/21 0:00	1170.2

2/19/21 0:00	1353.9
2/20/21 0:00	1350.3
2/21/21 0:00	1313.1
2/22/21 0:00	1328.5
2/23/21 0:00	1378.8
2/24/21 0:00	1355.8
2/25/21 0:00	1373.3
2/26/21 0:00	1134.4
2/27/21 0:00	1054.9
2/28/21 0:00	1178.2
3/1/21 0:00	1004.9
3/2/21 0:00	1365.4
3/3/21 0:00	1196.1
3/4/21 0:00	1091.9
3/5/21 0:00	1086.4
3/6/21 0:00	1057.6
3/7/21 0:00	1167.1
3/8/21 0:00	974.1
3/9/21 0:00	1213.4
3/10/21 0:00	928.4
3/11/21 0:00	1070.8
3/12/21 0:00	897.8
3/13/21 0:00	851.9
3/14/21 0:00	1475.1
3/15/21 0:00	1249.2
3/16/21 0:00	1140.8
3/17/21 0:00	1086.9
3/18/21 0:00	1068.0
3/19/21 0:00	1070.1
3/20/21 0:00	1065.0
3/21/21 0:00	983.5
3/22/21 0:00	964.7
3/23/21 0:00	1839.5
3/24/21 0:00	2146.9
3/25/21 0:00	1671.7
3/26/21 0:00	1467.7
3/27/21 0:00	1157.4
3/28/21 0:00	985.0
3/29/21 0:00	945.6
3/30/21 0:00	878.6
3/31/21 0:00	981.7

ROSEVILLE ENERGY PARK COOLING TOWER EMISSIONS

POLLUTANT	LBS PER DAY	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4
PM-10	16.3	1471	1487	1504	1504

Whereas compliance with the PM-10 emission limit shall be demonstrated as;
Cooling tower recirculation rate * total dissolved solids of blowdown * design drift rate

<u>Circ pump flow rate</u>	53814	Gallons per minute
	* 8.33	Pounds per gallon
	* 1440	Minutes per day
	64,550,969	Pounds per day

<u>Total dissolved solids</u>	1192	Average daily conductivity umhos
	0.00000064	Conversion to TDS ppm
	0.00076288	

<u>Design drift rate</u>	0.005%

PM-10 pounds per day	2.46

90	Days in quarter

PM-10 pounds this quarter	222	1Q21

fill only these

AQ-71

AQ-71 Compliance with the cooling tower PM-10 emission limit shall be demonstrated as follows: $\text{PM-10} = \text{cooling water recirculation rate} * \text{total dissolved solids concentration in the blow down water} * \text{design drift rate}$.

Verification: the Project owner shall include all the necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly air Quality Report required in condition of Certification AQ-SC6.

Replace the dates with the ones you need

1/1/2021 0:00

3/31/2021 0:00

1D

TOWER AVG.

519-AIT-9504-1

1192

1/1/21 0:00	638.2
1/2/21 0:00	876.2
1/3/21 0:00	968.0
1/4/21 0:00	1035.3
1/5/21 0:00	1019.9
1/6/21 0:00	986.3
1/7/21 0:00	975.9
1/8/21 0:00	960.0
1/9/21 0:00	964.9
1/10/21 0:00	945.5
1/11/21 0:00	1040.0
1/12/21 0:00	1042.0
1/13/21 0:00	1056.9
1/14/21 0:00	1087.6
1/15/21 0:00	1073.0
1/16/21 0:00	1093.5
1/17/21 0:00	1110.6
1/18/21 0:00	1109.6
1/19/21 0:00	1072.0
1/20/21 0:00	1039.6
1/21/21 0:00	1045.4
1/22/21 0:00	1067.0
1/23/21 0:00	1062.2
1/24/21 0:00	1086.8
1/25/21 0:00	2706.8
1/26/21 0:00	2311.7
1/27/21 0:00	1162.5
1/28/21 0:00	1151.3
1/29/21 0:00	1092.2
1/30/21 0:00	1065.8
1/31/21 0:00	1306.0
2/1/21 0:00	1329.5
2/2/21 0:00	1557.7
2/3/21 0:00	1505.6
2/4/21 0:00	1430.4
2/5/21 0:00	1410.0
2/6/21 0:00	1227.0
2/7/21 0:00	1214.2
2/8/21 0:00	1196.8
2/9/21 0:00	1216.9
2/10/21 0:00	1271.6
2/11/21 0:00	1294.3
2/12/21 0:00	1247.8
2/13/21 0:00	1256.8
2/14/21 0:00	1247.8
2/15/21 0:00	1211.7
2/16/21 0:00	1247.9
2/17/21 0:00	1216.5
2/18/21 0:00	1170.2

2/19/21 0:00	1353.9
2/20/21 0:00	1350.3
2/21/21 0:00	1313.1
2/22/21 0:00	1328.5
2/23/21 0:00	1378.8
2/24/21 0:00	1355.8
2/25/21 0:00	1373.3
2/26/21 0:00	1134.4
2/27/21 0:00	1054.9
2/28/21 0:00	1178.2
3/1/21 0:00	1004.9
3/2/21 0:00	1365.4
3/3/21 0:00	1196.1
3/4/21 0:00	1091.9
3/5/21 0:00	1086.4
3/6/21 0:00	1057.6
3/7/21 0:00	1167.1
3/8/21 0:00	974.1
3/9/21 0:00	1213.4
3/10/21 0:00	928.4
3/11/21 0:00	1070.8
3/12/21 0:00	897.8
3/13/21 0:00	851.9
3/14/21 0:00	1475.1
3/15/21 0:00	1249.2
3/16/21 0:00	1140.8
3/17/21 0:00	1086.9
3/18/21 0:00	1068.0
3/19/21 0:00	1070.1
3/20/21 0:00	1065.0
3/21/21 0:00	983.5
3/22/21 0:00	964.7
3/23/21 0:00	1839.5
3/24/21 0:00	2146.9
3/25/21 0:00	1671.7
3/26/21 0:00	1467.7
3/27/21 0:00	1157.4
3/28/21 0:00	985.0
3/29/21 0:00	945.6
3/30/21 0:00	878.6
3/31/21 0:00	981.7

ROSEVILLE ENERGY PARK COOLING TOWER EMISSIONS

POLLUTANT	LBS PER DAY	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4
PM-10	16.3	1471	1487	1504	1504

Whereas compliance with the PM-10 emission limit shall be demonstrated as;
Cooling tower recirculation rate * total dissolved solids of blowdown * design drift rate

<u>Circ pump flow rate</u>	53814	Gallons per minute
	* 8.33	Pounds per gallon
	* 1440	Minutes per day
	64,550,969	Pounds per day

<u>Total dissolved solids</u>	1192	Average daily conductivity umhos
	0.00000064	Conversion to TDS ppm
	0.00076288	

<u>Design drift rate</u>	0.005%

PM-10 pounds per day	2.46

90	Days in quarter

PM-10 pounds this quarter	222	1Q21

fill only these

AQ-86

AQ-86 Operation for maintenance and testing of the emergency diesel engine and generator shall be limited to 50 hours per year.

Verification: The Project owner shall include all necessary operational data to demonstrate compliance with the limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

6	DATE	TECH	TIME START-S/D	RUNTIME TOTAL HRS.	RUNTIME YTD MINUTES	DATE	TECH	TIME START S/D	Runtimes TOTAL HRS.	RUNTIME 7 YTD minutes
	12/24/19	E.O.	13:37 - 14:07 Bi-Weekly Test	97	805	8-26-2016	KD	01:00 01:30	108	301
	1/6/19	LAB	1241 - 1311 Bi-Weekly Test	97	30	4-13-2020	RC	1538 - Bi-Weekly Test - 1610	109	333
	1-20-19	Ry	0825 - 0555 Bi-Weekly Test	98	60	10/4/20	DB	1323 - 1400 - Test Run	109	370
	1-29-19	Ry	1013 - 1043 Bi-Weekly Test	98	90	10/22/20	AB	DIESEL DELIVERY 64 GALS		
	2-17-19	Ry	1035 - 1105 Bi-Weekly Test	99	120	11/1/2020	KD	13:01 13:31 Bi Weekly test	110	400
	3-11-19	E.O.	0724 - 0730 OUTAGE / BLACK PLANT	99	126	11/29/20	AB	1444 1514 BIWEEKLY TEST RUN	110	430
	4-29-19	ME	0920 - 0950 TEST / Warm oil for Spring	99	156	12-20-2020	LAB	1650 - 1720 Bi-Weekly Test Run	111	460
	4/29/2019	ME	1202 - 1206 Post Maint Prime/TEST	99	160	2021				
	7-18-19	RL	1311 - 1347 TEST - INTELLIGENT REPAIR	100	195	1-9-21	DWN	14:00 - 14:30 Bi-Weekly Test	111	30
	8-22-19	RL	DIESEL DELIVERY 16.0 GALS			2-3-21	L/A	Diesel Filled 35.5 gallons		60 LAB
	9-20-19	AB	1026 - 1029 TEST RUN	100	198	3-28-2021	LAB	1319 - 1349 Bi-Weekly Test Run	112	60
	9-20-19	AB	1416 - 1421 TEST RUN	100	203					
	9-20-19	AB	1424 - 1434 TEST RUN	100	213					
	10-10-19	ME	1100 - 1124 TEST RUN / Troubleshooting	100	237					
	10-10-19	ME	1136 - 1144 TEST RUN / Troubleshooting	101	245					
	10-10-19	ME	1150 - 1158 TEST RUN / Troubleshooting	101	253					
	10-10-19	ME	1206 - 1207 TEST RUN / Troubleshooting	101	254					
	10-13-19	LAB	0942 - 0947 WEEKLY TEST RUN	101	259					
	10-27-19	Ry	Bi Weekly Test	102	289					
	11-3-19	BP	Bi Weekly Test - Failed	102	304					
	11-10-19	LAB	Bi-Weekly Test FAILED AFTER 5 MIN. SHUT DOWN	102	309					
	11-24-19	ZUR	Bi-Weekly Test Run - Successful	103	339					
	12-8-19	LAB	Bi-Weekly Test Run	103	369					
	12-29-19	BP	Bi-Weekly Test 1439 - 1509	104	399					
	1/04/20	BT	Bi-Weekly Test 14:16 - 14:49	104	33					
	1/6/20	BT	Troubleshoot with CEO / CAT 13:04	104	63					
	1/6/20	AB	1447 - 1453 TEST RUN	105	69					
	1/6/20	AB	1512 - 1518 TEST RUN	105	75					
	1/7/20	AB	1110 - 1112 TEST RUN	105	77					
	1/7/20	AB	1114 - 1127 TEST RUN	105	90					
	1/7/20	AB	1153 - 1309 TEST RUN	106	166					
	1/7/20	AB	1317 - 1330 TEST RUN	106	179					
	01-19-2020	Ry	1355 - 1425 Bi-Weekly Test	107	209					
	2-9-20	DWN	1038 - 1108 Bi-Weekly Test	107	239					
	2-11-2020	LAB	1140 - 1142 PLACER COMPANY TEST	107	241					
	7-25-2020	LAB	1304 - 1334 Bi-Weekly Test	108	271					

AQ-87

AQ-87 Operation for other than maintenance and testing purposes shall be limited to involuntary interruptions of electrical power. Operation shall not exceed 24 hours without prior authorization by the Air Pollution Control Officer.

Verification: The Project owner shall include all necessary operational data to demonstrate compliance with the limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

Date	Start	Reason	Stop	Initials	Total hrs	YTD
1-26-20	1310	Weekly test	1340	BP	178.1	2.0
2/2/20	1335	Weekly TEST	1405	ME	178.6	2.5
2-9-20	1133	Weekly Test	1203	DWN	179.1	3.0
2-16-20	1508	Weekly Test	1538	ZHR	179.6	3.5
2-23-20	1401	Weekly test	1431	BP	180.1	4.0
3-8-20	1545	WEEKLY TEST RUN	1615	AS	180.6	4.5
3-23-20	2319	COONING TANK DENOGE	2322	BO	180.6	4.5
4-5-20	1620	WEEKLY TEST RUN	1650	AS	181.1	5.0
4-12-20	1438	WEEKLY TEST RUN	1508	BS	181.6	5.5
4-19-2020	1514	WEEKLY TEST RUN		MB	182.1	6.0
4-28-20	1335	WEEKLY TEST RUN	1105	AS	182.6	6.5
5-3-20	1446	WEEKLY TEST RUN	1516	AS	183.1	7.0
5-10-20	1532	WEEKLY TEST RUN	1622	BS	183.6	7.5
5-16-20	1505	Weekly test	1535	KMS	184.1	8.0
5-31-20	1516	WEEKLY TEST RUN	1546	AS	184.6	8.5
6-4-20	1309	Weekly Test Run	1339	BS	185.1	9.0
6-14-20	1325	Weekly Test Run	1355	BP	185.6	9.5
6-21-20	1500	WEEKLY TEST RUN	1530	RC	186.1	10.0
6-28-20	1215	WEEKLY TEST RUN	135	RC	186.6	10.5
7-1-20	2147	Weekly TEST Run	2217	ME	187.1	11.0
7-12-20	1115	weekly test	1145	AS	187.6	11.5
7-19-20	1410	WEEKLY TEST RUN	1510	RC	188.1	12.0
7-25-2020	1429	WEEKLY TEST RUN	1459	HAB	188.6	12.5
8-3-2020	0900	WEEKLY TEST RUN	0930	KMS	189.1	13.0
8-9-2020	1330	Weekly Test Run	1420	BP	189.6	13.5
8-23-2020	1208	WEEKLY TEST RUN	1238	LH	190.1	14.0
8-30-2020	1237	Weekly Test Run	1307	FS	190.6	14.5
9-6-2020	1230	Weekly Test Run	1300	KMS	191.1	15.0
9-8-2020	1310	Post Maint Test Run	1318	ME	191.4	15.3
9-14-2020	1421	Weekly Test Run	1451	ME	191.9	15.8
9-20-20	1133	Weekly Test Run	1203	LH	192.4	16.3
9-27-20	1844	Weekly Test Run	1714	ZHR	192.9	16.8
10/4/20	1527	Weekly Test Run	1557	DB	193.3	17.3
10/11/20	2133	Weekly Test Run	2203	BE	193.8	17.8
10/18/20	1628	Weekly Test Run	1658	LH	194.3	18.3
10/22/20		DIESEL DELIVERY	76.0 GALS	AS		

DATE	Start	Reason	Stop	Initials	Total Hrs	YTD
10-25-20	1442	Weekly Test Run	1512	ZHR	194.8	18.8
11-1-2020	13:55	Weekly test run	14:25	KB	195.3	19.3
11-8-20	11:25	WEEKLY TEST RUN	1205	RC	196.0	20.0
11-15-20	1545	Weekly Test Run	1615	ZHR	196.5	20.5
11-29-20	11:40	WEEKLY TEST RUN	1210	AS	197.0	21.0
12-6-20	1000	WEEKLY TEST RUN	1038	RC	197.8	21.8
12-15-2020	1525	WEEKLY TEST RUN	1555	HAB	198.3	22.3
12-20-2020	1505	WEEKLY TEST RUN	1535	HAB	198.8	22.8
12/27/20	1340	WEEKLY TEST RUN	1410	DE	199.3	23.3
1-3-2021	1415	WEEKLY TEST RUN	1445	RC	199.8	23.8
1-10-21	13:10	Weekly Test Run	13:40	DWN	200.3	24.3
1-17-2021	1340	WEEKLY TEST RUN	1410	HAB	200.8	24.8
1-24-2021	1510	WEEKLY TEST RUN	1540	ME	201.3	25.3
2-3-21		Diesel added 75 gallons				25.8
2-7-21	1130	Weekly Test Run	1200	DWN	201.8	26.3
2-14-2021	1521	WEEKLY TEST RUN	1551	HAB	202.3	26.8
2-21-2021	1400	WEEKLY TEST RUN	1430	BS	202.8	27.3
3-6-21	1334	Weekly Test Run	1352	KMS	203.1	27.8
3-21-21	1533	WEEKLY Test Run	1603	LH	203.6	28.3
3-28-2021	1356	WEEKLY TEST RUN	1426	HAB	204.1	28.8

AQ-88

AQ-88 The Sulfur content of the Diesel fuel used shall not exceed 15 ppm by weight.

Verification: The Project owner shall include a summary of diesel fuel purchase records showing amounts delivered, date delivered and fuel type with the Quarterly Air Quality Report as required in Condition of Certification AQ-SC6.



01 Sacramento	916-371-2570	10 Rio Vista Shell	707-374-5620
02 Clarksburg	916-744-1012	11 Marysville	530-743-4647
03 Dixon	707-678-2061	14 Lincoln	916-645-2179
04 Fairfield	707-425-5780	24 San Jose	408-321-8242
06 Woodland	530-661-1200	27 Stockton	209-465-6255
08 Williams	530-473-2811		
09 Isleton	916-777-5545		

P.O. BOX 401 • WEST SACRAMENTO, CA 95691 • (916) 371-2570 • FOR FUELS CALL 916-371-6495

REMIT TO: Ramos Oil Co., Inc.
PO Box 401
West Sacramento, CA 95691

HAZARDOUS MATERIAL EMERGENCY
CALL 1-800-456-7745

DEF (Diesel Exhaust Fluid)
NOW AVAILABLE!

TO PAY ONLINE GO TO OUR WEBSITE
www.amosoil.com

SOLD TO:

ROSEVILLE ENERGY PARK
CITY OF ROSEVILLE
5120 PHILLIP RD
ROSEVILLE, CA 95747

SHIP TO:

ROSEVILLE ENERGY PARK
CITY OF ROSEVILLE
5120 PHILLIP RD
ROSEVILLE, CA 95747

wed

CUST. PURCHASE ORDER NUMBER		SALESMAN		TERMS		DEL. ZONE		DUE DATE	
DELIVERY DATE		DRIVER		TRUCK NUMBER		TERMINAL		B / L NUMBER	
NO. OF PKG'S	BULK OR SIZE	PRODUCT DELIVERED		ORDERED	DELIVERED	TAXES		PRICE	AMOUNT
		RED DYED DIESEL COMBUSTIBLE, 3.0% Sulfur #20 15ppm sulfur (maximum) Dyed Diesel fuel non taxable use only, penalty for taxable use.							
		BULK DSL #2 DYED CABD ULTRA LOW RED CA OIL SPILL TAX L.U.S.T. TAX RED OIL SPILL TAX 88-32 DSL IMPLEMENTATION FEE ENVIRONMENTAL SURCHARGE *** DELIVERY MESSAGE *** PO REQUIRED RED DSL FORM ON FILE		250	75				
LOAD		UNLOADING		MISC. CHARGES		TRIP MILES			
ARRIVED		ARRIVED		PUMP		TERMINAL TO CUSTOMER			
BEGAN LOADING		BEGAN UNLOADING		DEM. HRS.					
FINISHED		FINISHED		SPLIT DEL.					
TOTAL TIME		TOTAL TIME		SPLIT LOAD					
				BRIDGE TOLL					
COMMENTS									
PRODUCT		PREMIUM		UNLEADED PLUS		UNLEADED		DIESEL	
GROSS								SALES TAX	
NET								TOTAL	
CUSTOMER AGREES TO PAY FINANCE CHARGE ON PAST DUE BALANCE OF 1.5% PER MONTH OR THE MAXIMUM RATE ALLOWED IN CUSTOMER'S STATE OF RESIDENCE. WHICHEVER IS LESS; AND FURTHER AGREES TO PAY REASONABLE ATTORNEY'S FEES AND COSTS IF COLLECTION IS REQUIRED. VENUE FOR PURPOSES OF ENDORSEMENT OF THIS OBLIGATION SHALL BE YOLO COUNTY.									
ALL CLAIMS FOR ENVIRONMENTAL DAMAGE DURING DELIVERY OF ANY RAMOS OIL PRODUCT MUST BE MADE WITHIN 15 DAYS FOLLOWING DELIVERY.									
DELIVERED BY (SIGNATURE IN FULL)					RECEIVED IN GOOD ORDER				
X					X				

AQ-89

AQ-89 Records of operation and maintenance shall be kept by the owner or Operator for a period of five years and shall be made available to the PCAPCD upon request. Information required for reporting to the PCAPCD includes, but is not limited to:

1. The hours of operation the engine was run for maintenance and testing;
2. The hours of operation the engine was run during interruption of electrical power; and
3. Records of the sulfur content of the diesel used.

VERIFICATION: The Project owner shall include these records as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.



01 Sacramento	916-371-2570	10 Rio Vista Shell	707-374-5620
02 Clarksburg	916-744-1012	11 Marysville	530-743-4647
03 Dixon	707-678-2061	14 Lincoln	916-645-2179
04 Fairfield	707-425-5780	24 San Jose	408-321-8242
06 Woodland	530-661-1200	27 Stockton	209-465-6255
08 Williams	530-473-2811		
09 Isleton	916-777-5545		

P.O. BOX 401 • WEST SACRAMENTO, CA 95691 • (916) 371-2570 • FOR FUELS CALL 916-371-6495

REMIT TO: Ramos Oil Co., Inc.
PO Box 401
West Sacramento, CA 95691

HAZARDOUS MATERIAL EMERGENCY
CALL 1-800-456-7745

DEF (Diesel Exhaust Fluid)
NOW AVAILABLE!

TO PAY ONLINE GO TO OUR WEBSITE
www.ramosoil.com

SOLD TO:

ROSEVILLE ENERGY PARK
CITY OF ROSEVILLE
5120 PHILLIP RD
ROSEVILLE, CA 95747

SHIP TO:

ROSEVILLE ENERGY PARK
CITY OF ROSEVILLE
5120 PHILLIP RD
ROSEVILLE, CA 95747

wed

CUST. PURCHASE ORDER NUMBER		SALESMAN		TERMS		DEL. ZONE		DUE DATE	
DELIVERY DATE		DRIVER		TRUCK NUMBER		TERMINAL		B / L NUMBER	
NO. OF PKG'S	BULK OR SIZE	PRODUCT DELIVERED		ORDERED	DELIVERED	TAXES		PRICE	AMOUNT
		RED DYED DIESEL COMBUSTIBLE, 3.0% Sulfur #20 15ppm sulfur (maximum) Dyed Diesel fuel non taxable use only, penalty for taxable use.							
		BULK DSL #2 DYED CABD ULTRA LOW RED CA OIL SPILL TAX L.U.S.T. TAX RED OIL SPILL TAX 88-32 DSL IMPLEMENTATION FEE ENVIRONMENTAL SURCHARGE *** DELIVERY MESSAGE *** PO REQUIRED RED DSL FORM ON FILE		250	75				
LOAD		UNLOADING		MISC. CHARGES		TRIP MILES			
ARRIVED		ARRIVED		PUMP		TERMINAL TO CUSTOMER			
BEGAN LOADING		BEGAN UNLOADING		DEM. HRS.					
FINISHED		FINISHED		SPLIT DEL.					
TOTAL TIME		TOTAL TIME		SPLIT LOAD					
				BRIDGE TOLL					
COMMENTS									
PRODUCT		PREMIUM		UNLEADED PLUS		UNLEADED		DIESEL	
GROSS								SALES TAX	
NET								TOTAL	
CUSTOMER AGREES TO PAY FINANCE CHARGE ON PAST DUE BALANCE OF 1.5% PER MONTH OR THE MAXIMUM RATE ALLOWED IN CUSTOMER'S STATE OF RESIDENCE. WHICHEVER IS LESS; AND FURTHER AGREES TO PAY REASONABLE ATTORNEY'S FEES AND COSTS IF COLLECTION IS REQUIRED. VENUE FOR PURPOSES OF ENDORSEMENT OF THIS OBLIGATION SHALL BE YOLO COUNTY.									
ALL CLAIMS FOR ENVIRONMENTAL DAMAGE DURING DELIVERY OF ANY RAMOS OIL PRODUCT MUST BE MADE WITHIN 15 DAYS FOLLOWING DELIVERY.									
DELIVERED BY (SIGNATURE IN FULL)					RECEIVED IN GOOD ORDER				
X					X				

6	DATE	TECH	TIME START-S/D	RUNTIME TOTAL HRS.	RUNTIME YTD MINUTES	DATE	TECH	TIME START S/D	Runtimes TOTAL HRS.	RUNTIME 7 YTD minutes
	12/24/19	E.O.	13:37 - 14:07 Bi-Weekly Test	97	805	8-26-2016	KD	01:00 01:30	108	301
	1/6/19	LAB	1241 - 1311 Bi-Weekly Test	97	30	4-13-2020	RC	1538 - Bi-Weekly Test - 1610	109	333
	1-20-19	Ry	0825 - 0555 Bi-Weekly Test	98	60	10/4/20	DB	1323 - 1400 - Test Run	109	370
	1-29-19	Ry	1013 - 1043 Bi-Weekly Test	98	90	10/22/20	AB	DIESEL DELIVERY 64 GALS		
	2-17-19	Ry	1035 - 1105 Bi-Weekly Test	99	120	11/1/2020	KD	13:01 13:31 Bi-Weekly Test	110	400
	3-11-19	E.O.	0724 - 0730 OUTAGE / BLACK PLANT	99	126	11/29/20	AB	1444 1514 BIWEEKLY TEST RUN	110	430
	4-29-19	ME	0920 - 0950 TEST / Warm oil for Spring	99	156	12-20-2020	LAB	1650 - 1720 Bi-Weekly Test Run	111	460
	4/29/2019	ME	1202 - 1206 Post Maint Prime/Test	99	160	2021				
	7-18-19	RL	1311 - 1347 TEST - INTELLIGENT REPAIR	100	195	1-9-21	DWN	14:00 - 14:30 Bi-Weekly Test	111	30
	8-22-19	RL	DIESEL DELIVERY 16.0 GALS			2-3-21	L/A	Diesel Filled 35.5 gallons		60 LAB
	9-20-19	AB	1026 - 1029 TEST RUN	100	198	3-28-2021	LAB	1319 - 1349 Bi-Weekly Test Run	112	60
	9-20-19	AB	1416 - 1421 TEST RUN	100	203					
	9-20-19	AB	1424 - 1434 TEST RUN	100	213					
	10-10-19	ME	1100 - 1124 TEST RUN / Troubleshooting	100	237					
	10-10-19	ME	1136 - 1144 TEST RUN / Troubleshooting	101	245					
	10-10-19	ME	1150 - 1158 TEST RUN / Troubleshooting	101	253					
	10-10-19	ME	1206 - 1207 TEST RUN / Troubleshooting	101	254					
	10-13-19	LAB	0942 - 0947 WEEKLY TEST RUN	101	259					
	10-27-19	Ry	Bi-Weekly Test	102	289					
	11-3-19	BP	Bi-Weekly Test - Failed	102	304					
	11-10-19	LAB	Bi-Weekly Test FAILED AFTER 5 MIN. SHUT DOWN	102	309					
	11-24-19	ZUR	Bi-Weekly Test Run - Successful	103	339					
	12-8-19	LAB	Bi-Weekly Test Run	103	369					
	12-29-19	BP	Bi-Weekly Test 1439 - 1509	104	399					
	1/04/20	BT	Bi-Weekly Test 14:16 - 14:49	104	33					
	1/6/20	BT	Troubleshoot with CEO / CAT 13:04	104	63					
	1/6/20	AB	1447 - 1453 TEST RUN	105	69					
	1/6/20	AB	1512 - 1518 TEST RUN	105	75					
	1/7/20	AB	1110 - 1112 TEST RUN	105	77					
	1/7/20	AB	1114 - 1127 TEST RUN	105	90					
	1/7/20	AB	1153 - 1309 TEST RUN	106	166					
	1/7/20	AB	1317 - 1330 TEST RUN	106	179					
	01-19-2020	Ry	1355 - 1425 Bi-Weekly Test	107	209					
	2-9-20	DWN	1038 - 1108 Bi-Weekly Test	107	239					
	2-11-2020	LAB	1140 - 1142 PLACER CAMPY TEST	107	241					
	7-25-2020	LAB	1304 - 1334 Bi-Weekly Test	108	271					

AQ-90

AQ-90 No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6.

In regards to AQ-90 of Roseville Energy Park's 1Q21 QAQR, there were no violations of PCAPCD's Rule 205 for nuisance.

AQ-91

AQ-91 Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited and is in violation of PCAPCD Rule 202, Visible Emissions.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6.

In regards to AQ-91 of Roseville Energy Park's 1Q21 QAQR, there were no violations of PCAPCD's Rule 202 for opacity from the diesel fire pump.

AQ-99

AQ-99 Operation for maintenance and testing of the emergency diesel engine and generator shall be limited to 50 hours per year.

Verification: The Project shall include all necessary operational data to demonstrate compliance with the limits provided as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

6									7
DATE	TECH	TIME START-S/D	RUNTIME TOTAL HRS.	RUNTIME YTD MINUTES	DATE	TECH	TIME START S/D	Runtimes TOTAL HRS.	RUNTIME YTD minutes
12/24/19	E.O.	13:37 - 14:07 Bi-Weekly Test	97	805	8-26-2016	KD	01:00 01:30	108	301
1/6/19	LAB	1241 - 1311 Bi-Weekly Test	97	30	4-13-2020	RC	1538 - Bi-Weekly Test - 1610	109	333
1-20-19	Ry	0825 - 0555 Bi-Weekly Test	98	60	10/4/20	DB	1323 - 1400 - Test Run	109	370
1-29-19	Ry	1013 - 1043 Bi-Weekly Test	98	90	10/22/20	AB	DIESEL DELIVERY 64 GALS		
2-17-19	Ry	1035 - 1105 Bi-Weekly Test	99	120	11/1/2020	KD	13:01 13:31 Bi Weekly test	110	400
3-11-19	E.O.	0724 - 0730 OUTAGE / BLACK PLANT	99	126	11/29/20	AB	1444 1514 BIWEEKLY TEST RUN	110	430
4-29-19	ME	0920 - 0950 TEST / Warm oil for Spring	99	156	12-20-2020	LAB	1650 - 1720 Bi-Weekly Test Run	111	460
4/29/2019	ME	1202 - 1206 Post Maint Prime/TEST	99	160	2021				
7-18-19	RL	1311 - 1347 TEST - INTELLIGENT REPAIR	100	195	1-9-21	DWN	14:00 - 14:30 Bi-Weekly Test	111	30
8-22-19	RL	DIESEL DELIVERY 16.0 GALS			2-3-21	L/A	Diesel Filled 35.5 gallons		60 LAB
9-20-19	AB	1026 - 1029 TEST RUN	100	198	3-28-2021	LAB	1319 - 1349 Bi-Weekly Test Run	112	60
9-20-19	AB	1416 - 1421 TEST RUN	100	203					
9-20-19	AB	1424 - 1434 TEST RUN	100	213					
10-10-19	ME	1100 - 1124 TEST RUN / Troubleshooting	100	237					
10-10-19	ME	1136 - 1144 TEST RUN / Troubleshooting	101	245					
10-10-19	ME	1150 - 1158 TEST RUN / Troubleshooting	101	253					
10-10-19	ME	1206 - 1207 TEST RUN / Troubleshooting	101	254					
10-13-19	LAB	0942 - 0947 WEEKLY TEST RUN	101	259					
10-27-19	Ry	Bi Weekly Test	102	289					
11-3-19	BP	Bi Weekly Test - Failed	102	304					
11-10-19	LAB	Bi-Weekly Test FAILED AFTER 5 MIN. SHUT DOWN	102	309					
11-24-19	ZUR	Bi-Weekly Test Run - Successful	103	339					
12-8-19	LAB	Bi-Weekly Test Run	103	369					
12-29-19	BP	Bi-Weekly Test 1439 - 1509	104	399					
1/04/20	BT	Bi-Weekly Test 14:16 - 14:49	104	33					
1/6/20	BT	Troubleshoot with CEO / CAT 13:04	104	63					
1/6/20	AB	1447 - 1453 TEST RUN	105	69					
1/6/20	AB	1512 - 1518 TEST RUN	105	75					
1/7/20	AB	1110 - 1112 TEST RUN	105	77					
1/7/20	AB	1114 - 1127 TEST RUN	105	90					
1/7/20	AB	1153 - 1309 TEST RUN	106	166					
1/7/20	AB	1317 - 1330 TEST RUN	106	179					
01-19-2020	Ry	1355 - 1425 Bi-Weekly Test	107	209					
2-9-20	DWN	1038 - 1108 Bi-Weekly Test	107	239					
2-11-2020	LAB	1140 - 1142 PLACER COMPANY TEST	107	241					
7-25-2020	LAB	1304 - 1334 Bi-Weekly Test	108	271					

AQ-100

AQ-100 In regards to the Emergency diesel Generator; Operation for other than maintenance and testing purposes shall be limited to involuntary interruptions of electrical power. Operation shall not exceed 24 hours without prior authorization by the Air Pollution Control Officer.

6									RunTime 7
DATE	TECH	TIME START-S/D	RUNTIME TOTAL HRS.	RUNTIME YTD MINUTES	DATE	TECH	TIME START S/D	RunTime TOTAL HRS.	RunTime YTD minutes
12/24/18	E.O.	13:37 - 14:07 Bi-Weekly Test	97	805	8-26-2018	KD	01:00 01:30	108	301
1/6/19	LAB	1241 - 1311 Bi-Weekly Test	97	30	4-13-2020	RC	1538 - Bi-Weekly Test - 1610	109	333
1-20-19	Ry	0825 - 0555 Bi-Weekly Test	98	60	10/4/20	DB	1323 - 1400 - Test Run	109	370
1-29-19	Ry	1013 - 1043 Bi-Weekly Test	98	90	10/22/20	AS	DIESEL DELIVERY 64 GALS		
2-17-19	Ry	1035 - 1105 Bi-Weekly Test	99	120	11/1/2020	KD	13:01 13:31 Bi Weekly test	110	400
3-11-19	E.O.	0724 - 0730 OUTAGE / BLACK PLANT	99	126	11/29/20	AS	1444 1514 BIWEEKLY TEST RUN	110	430
4-29-19	ME	0920 - 0950 TEST / Warm oil for Spring	99	156	12-20-2020	LAB	1650 - 1720 Bi-Weekly Test Run	111	460
4/29/2019	ME	1202 - 1206 Post Maint Prime/Test	99	160	2021				
7-18-19	RL	1311 - 1347 TEST - INTELLIGENT REPAIR	100	195	1-9-21	DWN	14:00 - 14:30 Bi-Weekly Test	111	30
8-22-19	RL	DIESEL DELIVERY 16.0 GALS			2-3-21	L/A	Diesel Filled 35.5 gallons		60 LAB
9-20-19	AS	1026 - 1029 TEST RUN	100	198	3-28-2021	LAB	1319 - 1349 Bi-Weekly Test Run	112	60
9-20-19	AS	1416 - 1421 TEST RUN	100	203					
9-20-19	AS	1424 - 1434 TEST RUN	100	213					
10-10-19	ME	1100 - 1124 TEST RUN / Trouble Shooting	100	237					
10-10-19	ME	1136 - 1144 TEST RUN / Trouble Shooting	101	245					
10-10-19	ME	1150 - 1158 TEST RUN / Trouble Shooting	101	253					
10-10-19	ME	1206 - 1207 TEST RUN / Trouble Shooting	101	254					
10-13-19	LAB	0942 - 0947 WEEKLY TEST RUN	101	259					
10-27-19	Ry	Bi Weekly Test	102	289					
11-3-19	BP	Bi Weekly Test - Failed	102	304					
11-10-19	LAB	Bi-Weekly Test FAILED AFTER 5 MIN. SHUT DOWN	102	309					
11-24-19	ZUR	Bi-Weekly Test Run - Successful	103	339					
12-8-19	LAB	Bi-Weekly Test Run	103	369					
12-29-19	BP	Bi-Weekly Test 1439 - 1509	104	399					
1/04/20	BT	Bi-Weekly Test 14:16 - 14:49	104	33					
1/6/20	BT	Troubleshooting with CEO / CAT 13:04	104	63					
1/6/20	AS	1447 - 1453 TEST RUN	105	69					
1/6/20	AS	1512 - 1518 TEST RUN	105	75					
1/7/20	AS	1110 - 1112 TEST RUN	105	77					
1/7/20	AS	1114 - 1127 TEST RUN	105	90					
1/7/20	AS	1153 - 1309 TEST RUN	106	166					
1/7/20	AS	1317 - 1330 TEST RUN	106	179					
01-19-2020	Ry	1355 - 1425 Bi-Weekly Test	107	209					
2-9-20	DWN	1038 - 1108 Bi-Weekly Test	107	239					
2-11-2020	LAB	1140 - 1142 PLACER COMPANY TEST	107	241					
7-25-2020	LAB	1304 - 1334 Bi-Weekly Test	108	271					

AQ-101

AQ-101 The sulfur content of the diesel used shall not exceed 15ppm by weight

Verification: The Project owner shall include a summary of diesel fuel purchase records showing amounts delivered, date delivered and fuel type with the Quarterly Air Quality Report in Condition of Certification AQ-SC6



01 Sacramento	916-371-2570	10 Rio Vista Shell	707-374-5620
02 Clarksburg	916-744-1012	11 Marysville	530-743-4647
03 Dixon	707-678-2061	14 Lincoln	916-645-2179
04 Fairfield	707-425-5780	24 San Jose	408-321-8242
06 Woodland	530-661-1200	27 Stockton	209-465-6255
08 Williams	530-473-2811		
09 Isleton	916-777-5545		

P.O. BOX 401 • WEST SACRAMENTO, CA 95691 • (916) 371-2570 • FOR FUELS CALL 916-371-6495

REMIT TO: Ramos Oil Co., Inc.
PO Box 401
West Sacramento, CA 95691

HAZARDOUS MATERIAL EMERGENCY
CALL 1-800-456-7745

DEF (Diesel Exhaust Fluid)
NOW AVAILABLE!

TO PAY ONLINE GO TO OUR WEBSITE
www.ramosoil.com

SOLD TO:

ROSEVILLE ENERGY PARK
CITY OF ROSEVILLE
5120 PHILLIP RD
ROSEVILLE, CA 95747

SHIP TO:

ROSEVILLE ENERGY PARK
CITY OF ROSEVILLE
5120 PHILLIP RD
ROSEVILLE, CA 95747

wed

CUST. PURCHASE ORDER NUMBER		SALESMAN		TERMS		DEL. ZONE		DUE DATE	
DELIVERY DATE		DRIVER		TRUCK NUMBER		TERMINAL		B / L NUMBER	
NO. OF PKG'S	BULK OR SIZE	PRODUCT DELIVERED		ORDERED	DELIVERED	TAXES		PRICE	AMOUNT
		RED DYED DIESEL COMBUSTIBLE, 3.0% Sulfur, #20 15ppm sulfur (maximum) Dyed Diesel fuel non taxable use only, penalty for taxable use.							
		BULK DSL #2 DYED CABD ULTRA LOW SUD CA OIL SPILL TAX L.U.S.T. TAX FED OIL SPILL TAX 88-32 DSL IMPLEMENTATION FEE ENVIRONMENTAL SURCHARGE *** DELIVERY MESSAGE *** PO REQUIRED RED DSL FORM ON FILE		250	75				
LOAD		UNLOADING		MISC. CHARGES		TRIP MILES			
ARRIVED		ARRIVED		PUMP		TERMINAL TO CUSTOMER			
BEGAN LOADING		BEGAN UNLOADING		DEM. HRS.					
FINISHED		FINISHED		SPLIT DEL.					
TOTAL TIME		TOTAL TIME		SPLIT LOAD					
				BRIDGE TOLL					
COMMENTS									
PRODUCT		PREMIUM		UNLEADED PLUS		UNLEADED		DIESEL	
GROSS								SALES TAX	
NET								TOTAL	
CUSTOMER AGREES TO PAY FINANCE CHARGE ON PAST DUE BALANCE OF 1.5% PER MONTH OR THE MAXIMUM RATE ALLOWED IN CUSTOMER'S STATE OF RESIDENCE. WHICHEVER IS LESS; AND FURTHER AGREES TO PAY REASONABLE ATTORNEY'S FEES AND COSTS IF COLLECTION IS REQUIRED. VENUE FOR PURPOSES OF ENDORSEMENT OF THIS OBLIGATION SHALL BE YOLO COUNTY.									
ALL CLAIMS FOR ENVIRONMENTAL DAMAGE DURING DELIVERY OF ANY RAMOS OIL PRODUCT MUST BE MADE WITHIN 15 DAYS FOLLOWING DELIVERY.									
DELIVERED BY (SIGNATURE IN FULL)					RECEIVED IN GOOD ORDER				
<i>X</i>					<i>X</i>				

AQ-102

AQ-102 Records of operation and maintenance shall be kept by the owner or operator for a period of five years and shall be made available to the PCAPCD by request. Information required for reporting to the PCAPCD includes, but is not limited to:

- A. Hours of operation the engine was run for maintenance and testing
- B. Hours of operation the engine was run during interruption of electrical power
- C. Records of sulfur content of the diesel fuel used

Verification: The Project owner shall include these records as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6



01 Sacramento	916-371-2570	10 Rio Vista Shell	707-374-5620
02 Clarksburg	916-744-1012	11 Marysville	530-743-4647
03 Dixon	707-678-2061	14 Lincoln	916-645-2179
04 Fairfield	707-425-5780	24 San Jose	408-321-8242
06 Woodland	530-661-1200	27 Stockton	209-465-6255
08 Williams	530-473-2811		
09 Isleton	916-777-5545		

P.O. BOX 401 • WEST SACRAMENTO, CA 95691 • (916) 371-2570 • FOR FUELS CALL 916-371-6495

REMIT TO: Ramos Oil Co., Inc.
PO Box 401
West Sacramento, CA 95691

HAZARDOUS MATERIAL EMERGENCY
CALL 1-800-456-7745

DEF (Diesel Exhaust Fluid)
NOW AVAILABLE!

TO PAY ONLINE GO TO OUR WEBSITE
www.ramosoil.com

SOLD TO:

ROSEVILLE ENERGY PARK
CITY OF ROSEVILLE
5120 PHILLIP RD
ROSEVILLE, CA 95747

SHIP TO:

ROSEVILLE ENERGY PARK
CITY OF ROSEVILLE
5120 PHILLIP RD
ROSEVILLE, CA 95747

wed

CUST. PURCHASE ORDER NUMBER		SALESMAN		TERMS		DEL. ZONE		DUE DATE	
DELIVERY DATE		DRIVER		TRUCK NUMBER		TERMINAL		B / L NUMBER	
NO. OF PKG'S	BULK OR SIZE	PRODUCT DELIVERED		ORDERED	DELIVERED	TAXES		PRICE	AMOUNT
		RED DYED DIESEL COMBUSTIBLE, 3.0% Sulfur #20 15ppm sulfur (maximum) Dyed Diesel fuel non taxable use only, penalty for taxable use.							
		BULK DSL #2 DYED CABD ULTRA LOW RED CA OIL SPILL TAX L.I.S.T. TAX RED OIL SPILL TAX 88-32 DSL IMPLEMENTATION FEE ENVIRONMENTAL SURCHARGE *** DELIVERY MESSAGE *** PO REQUIRED RED DSL FORM ON FILE		250	75				
LOAD		UNLOADING		MISC. CHARGES		TRIP MILES			
ARRIVED		ARRIVED		PUMP		TERMINAL TO CUSTOMER			
BEGAN LOADING		BEGAN UNLOADING		DEM. HRS.					
FINISHED		FINISHED		SPLIT DEL.					
TOTAL TIME		TOTAL TIME		SPLIT LOAD					
				BRIDGE TOLL					
COMMENTS									
PRODUCT		PREMIUM		UNLEADED PLUS		UNLEADED		DIESEL	
GROSS								SALES TAX	
NET								TOTAL	
CUSTOMER AGREES TO PAY FINANCE CHARGE ON PAST DUE BALANCE OF 1.5% PER MONTH OR THE MAXIMUM RATE ALLOWED IN CUSTOMER'S STATE OF RESIDENCE. WHICHEVER IS LESS; AND FURTHER AGREES TO PAY REASONABLE ATTORNEY'S FEES AND COSTS IF COLLECTION IS REQUIRED. VENUE FOR PURPOSES OF ENDORSEMENT OF THIS OBLIGATION SHALL BE YOLO COUNTY.									
ALL CLAIMS FOR ENVIRONMENTAL DAMAGE DURING DELIVERY OF ANY RAMOS OIL PRODUCT MUST BE MADE WITHIN 15 DAYS FOLLOWING DELIVERY.									
DELIVERED BY (SIGNATURE IN FULL)					RECEIVED IN GOOD ORDER				
<i>X</i>					<i>X</i>				

6	DATE	TECH	TIME START-S/D	RUNTIME TOTAL HRS.	RUNTIME YTD MINUTES	DATE	TECH	TIME START S/D	Runtimes TOTAL HRS.	RUNTIME 7 YTD minutes
	12/24/19	E.O.	13:37 - 14:07 Bi-Weekly Test	97	805	8-26-2016	KD	01:00 01:30	108	301
	1/6/19	LAB	1241 - 1311 Bi-Weekly Test	97	30	4-13-2020	RC	1538 - Bi-Weekly Test - 1610	109	333
	1-20-19	Ry	0825 - 0555 Bi-Weekly Test	98	60	10/4/20	DB	1323 - 1400 - Test Run	109	370
	1-29-19	Ry	1013 - 1043 Bi-Weekly Test	98	90	10/22/20	AB	DIESEL DELIVERY 64 GALS		
	2-17-19	Ry	1035 - 1105 Bi-Weekly Test	99	120	11/1/2020	KD	13:01 13:31 Bi-Weekly Test	110	400
	3-11-19	E.O.	0724 - 0730 OUTAGE / BLACK PLANT	99	126	11/29/20	AB	1444 1514 BIWEEKLY TEST RUN	110	430
	4-29-19	ME	0920 - 0950 TEST / Warm oil for Spring	99	156	12-20-2020	LAB	1650 - 1720 Bi-Weekly Test Run	111	460
	4/29/2019	ME	1202 - 1206 Post Maint Prime/TEST	99	160	2021				
	7-18-19	RL	1311 - 1347 TEST - INTELLIGENT REPAIR	100	195	1-9-21	DWN	14:00 - 14:30 Bi-Weekly Test	111	30
	8-22-19	RL	DIESEL DELIVERY 16.0 GALS			2-3-21	L/A	Diesel Filled 35.5 gallons		60 LAB
	9-20-19	AB	1026 - 1029 TEST RUN	100	198	3-28-2021	LAB	1319 - 1349 Bi-Weekly Test Run	112	60
	9-20-19	AB	1416 - 1421 TEST RUN	100	203					
	9-20-19	AB	1424 - 1434 TEST RUN	100	213					
	10-10-19	ME	1100 - 1124 TEST RUN / Troubleshooting	100	237					
	10-10-19	ME	1136 - 1144 TEST RUN / Troubleshooting	101	245					
	10-10-19	ME	1150 - 1158 TEST RUN / Troubleshooting	101	253					
	10-10-19	ME	1206 - 1207 TEST RUN / Troubleshooting	101	254					
	10-13-19	LAB	0942 - 0947 WEEKLY TEST RUN	101	259					
	10-27-19	Ry	Bi-Weekly Test	102	289					
	11-3-19	BP	Bi-Weekly Test - Failed	102	304					
	11-10-19	LAB	Bi-Weekly Test FAILED AFTER 5 MIN. SHUT DOWN	102	309					
	11-24-19	ZUR	Bi-Weekly Test Run - Successful	103	339					
	12-8-19	LAB	Bi-Weekly Test Run	103	369					
	12-29-19	BP	Bi-Weekly Test 1439 - 1509	104	399					
	1/04/20	BT	Bi-Weekly Test 14:16 - 14:49	104	33					
	1/6/20	BT	Troubleshoot with CEO / CAT 13:04	104	63					
	1/6/20	AB	1447 - 1453 TEST RUN	105	69					
	1/6/20	AB	1512 - 1518 TEST RUN	105	75					
	1/7/20	AB	1110 - 1112 TEST RUN	105	77					
	1/7/20	AB	1114 - 1127 TEST RUN	105	90					
	1/7/20	AB	1153 - 1309 TEST RUN	106	166					
	1/7/20	AB	1317 - 1330 TEST RUN	106	179					
	01-19-2020	Ry	1355 - 1425 Bi-Weekly Test	107	209					
	2-9-20	DWN	1038 - 1108 Bi-Weekly Test	107	239					
	2-11-2020	LAB	1140 - 1142 PLACER CAMPY TEST	107	241					
	7-25-2020	LAB	1304 - 1334 Bi-Weekly Test	108	271					

AQ-103

AQ-103 No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6.

In regards to AQ-103 of Roseville Energy Park's 1Q21 QAQR, there were no violations of PCAPCD's Rule 205 for nuisance.

AQ-104

AQ-104 Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited and is in violation of PCAPCD Rule 202, Visible Emissions.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite opacity complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

In regards to AQ-104 of Roseville Energy Park's 1Q21 QAQR, there were no violations of PCAPCD's Rule 202 for opacity from stack emissions of the emergency diesel generator.