

<b>DOCKETED</b>	
<b>Docket Number:</b>	21-SIT-01
<b>Project Title:</b>	21-SIT-01, SB100 Implementation Planning for SB100 Resource Build
<b>TN #:</b>	238129-1
<b>Document Title:</b>	Presentation - Dependability of CSP Plants
<b>Description:</b>	N/A
<b>Filer:</b>	Patty Paul
<b>Organization:</b>	Vote Solar
<b>Submitter Role:</b>	Public
<b>Submission Date:</b>	6/4/2021 4:15:50 PM
<b>Docketed Date:</b>	6/4/2021

# Dependability of CSP Plants

---

Dr. Fred Morse, Dr. Terry Peterson,  
Dr. Luis Crespo, Dr. David Kearney


January 2021




# Are CSP plants dependable?

- In 2020, there were 99 CSP plants operating globally and a subset of those provided dependability data
- A “dependable” plant or fleet should have over 90% availability and less than 10% variation in annual output
- The Ivanpah and Crescent Dunes CSP plants in the U.S. had first-of-a-kind early operating issues and thus are not representative of CSP plants globally.

# 2020 Global CSP Fleet



**83 Parabolic Trough** plants are operating globally with a total capacity of 5.2 GW



**16 Power Tower** operating globally with a total capacity of 1.3 GW

# Worldwide status of CSP plants\*

- 99 in operation
  - Over 6 GW total
  - 83% are parabolic trough
- 47 include thermal energy storage (TES)
  - Totaling 3.3 GW of capacity and 25 GWh
  - Nearly 8 hours of energy storage on average
  - Largest is 17.5 hours of full-power TES
- 43 use molten-salt TES
  - First commercial plant came online in 2007
  - 3 of 19 US plants include TES
  - Most built in the last 7 years include TES

\*NREL/SolarPACES database <<https://solarpaces.nrel.gov/>>



**50-MW Termosol 1 Plant (Spain)  
with 9 hours of molten-salt TES**

## Sources of CSP-plant dependability data

---

- Spain — 49 plants, 2.3 GW in commercial operation since 2013, 39 plants provided public individual-plant performance data
- U.S. —
  - 9 SEGS plants, totaling 354 MW, completed long-term PPA contracts
  - 64-MW Nevada Solar One plant in commercial operation since 2007
  - 5 CSP plants, 2 with TES, were funded under the DOE Loan Guarantee Program, and were constructed between 2010–2014
  - All provided dependability data via DOE Energy Information Agency


## Spain has a mature 2.3-GW fleet of CSP plants

---

- 49 operating CSP plants
- 44 parabolic-trough (PT) plants, each limited to 50 MW by Spanish regulations
- 17 PT plants include 7 to 9 hours of full-power TES
- First plants began operation in 2007, all have operated since 2013
- Operation since 2014 has been without natural gas auxiliary heating
- January 2020 Spanish Ministry national energy and climate plan\* sees fleet expansion to 7 GW by 2030

\*[https://ec.europa.eu/energy/topics/energy-strategy/national-energy-climate-plans\\_en#final-necps](https://ec.europa.eu/energy/topics/energy-strategy/national-energy-climate-plans_en#final-necps)

# The Spanish 2.3-GW CSP fleet has demonstrated dependability



Data Source: <https://www.ree.es/en/datos/generation/generation-structure>




Since 2014, the Spanish CSP plants have operated fully on solar energy with no natural gas contribution.

Annual production has generally tracked available sunlight. 2018 insolation was 8% below average and 2020 preliminary data indicate that it was also well below average.

In the summer months, these CSP plants often meet 8% of Spain's hourly demand.


# Spanish parabolic trough plants have been dependable with or without thermal energy storage



In the Spanish market and climate, trough plants with no TES are typically designed for about 20% annual capacity factor, while 30% to 35% is the corresponding target capacity factor for plants with 7 to 9 hours of TES.

The available ESIOS data indicate over 96% availability for trough plants, both with and without TES.

# The current U.S. CSP fleet has shown dependable performance for the past 6 years



Current fleet reached 1.6 GW in 2015

It included 11 PT plants and 2 central-receiver plants that total 4 towers

The final SEGS plants retired in 2019 and 2020 reducing total capacity to 1.4 GW


Ongoing learning is evident in the increasing capacity factor

# Gemasolar (Spain)

- 17-MW power tower CSP plant with 15 hours of full-power TES
- Many novel aspects made it a “first of a kind” plant and therefore not “typical”
- Despite its novelty, the plant has achieved over 92% availability in 3 of the last 6 years
- It has run up to 36 days non-stop at nominal power




# Gemasolar stable production through cloud transients




- Continuous output (—) despite intermittent cloudiness (—)

# Gemasolar production following grid operator requirements



- Output matches grid operator setpoints (—), not irradiance (—)
- Curtailed output in early morning and afternoon, but energy not lost

# Gemasolar 24/7 production over many winter days




## 12 days of continuous production in February

- Continuous output despite intermittent cloudiness
- Generation (—) decoupled from irradiance (—)
- In sunnier times of the year, Gemasolar has run up to 36 days non-stop at full nominal power

# Xina (South Africa) – 100 MW with 5.5 hours full load thermal energy storage



# Xina Solar One meeting evening peaks




- Xina is only paid for production between 06:00 and 22:00 daily (yellow- and pink-shaded areas) with substantially more paid after 17:00 (pink-shaded area)
- The plant was designed to maximize post-17:00 “peak” production
- In its first 3 years of operation, it averaged over 93% availability total and over 91% during the “peak” times

Solana (Arizona) – 250 MW with 6 hours full-load thermal energy storage




# Solana Generating Station meeting the evening peaks



## CSP+TES and Resource Adequacy

- Yagi et al.\* modeled CSP towers with 12 hours TES producing 8 hours of nameplate power during peak system loads in 28 SW U.S. locations over 18 years using actual weather and load data
- Example partially sunny day at right: Boulder City, NV on August 1, 2014
- Modeling required 8-hour output 13:00 to 21:00 (shaded area) to bracket balancing authority (—) peak-load period
- Solar energy input (---) spanned only 08:00–14:00, missing most of the load peak
- TES (—X—) charged during morning solar input
- Plant output (---) began at 09:00 and lasted 12 hours

\*Yagi, Sioshansi, Denholm. *Solar Energy*, 191, 2019, 686






# Capabilities of dependable CSP + TES

---

- Long Duration Storage — plants can operate 24 hours a day when needed
- Can be hybridized — with PV, Natural Gas, or Biogas
  - e.g., a hybrid CSP plant with 12 hours TES can provide full-year capacity with 2%–5% of the fuel consumption of a natural gas plant\*
- Synchronous Generation with wide range of grid reliability services
  - e.g., stability and inertia
- Flexible — in design and output to meet any demand profile
- Dispatchable — separates energy collection from electricity generation
- Costs continue to decrease — still high on the learning curve (6 GW globally) — lowest currently 8.2¢/kWh in relatively low DNI


\*Yagi, Sioshansi, Denholm. *Solar Energy*, 191, 2019, 686

# Flexible Designs for an Evolving Grid



SolarDynamics

# Commercial Developers are Optimizing CSP/PV Hybridization



## DEWA IV – Dubai – PV co-located

- Developer: ACWA Power
- PPA signed at \$0.073/kWh
- 950 MW total capacity
  - 200 MW x3 Troughs with 10 hours TES
  - 100 MW Tower with 15 hours TES
  - 250 MW PV

## Midelt 1 – Morocco- PV hybrid

- Developer: EDF/MASDAR/Green of Africa
- PPA signed at \$0.071/kWh
- 400 MW PV (per press release)
- 400 MW Trough with 5 hours TES
- Excess PV electricity will be stored in molten salt TES

## Many CSP roles in the future energy grid

---

- As grids move to 100% carbon-free generation, they need to maintain system inertia and balance, fast ramping capabilities, and adequate resources for contingency reserves
- CSP + TES plants are the least costly renewable choice for complementing PV all night long
- CSP + TES plants can be designed to meet multi-hour evening peaks with minimal non-solar energy
- CSP + TES plants—with zero or little investment—can provide additional services to the grid such as firm strategic reserve for demand peaks whether the previous days were sunny or not
- CSP + TES could also collect curtailed generation from PV and wind for generation when needed.
- With demonstrated dependability, CSP + TES plants could support the ongoing energy transition process

## ...but there is no silver-bullet energy storage technology that fulfills all power system needs

