

| DOCKETED | |
|-------------------------|---|
| Docket Number: | 21-BSTD-01 |
| Project Title: | 2022 Energy Code Update Rulemaking |
| TN #: | 238395 |
| Document Title: | Taylor Engineering Comments - Revise section 1201(c)3 ventilation |
| Description: | N/A |
| Filer: | System |
| Organization: | Taylor Engineering |
| Submitter Role: | Public |
| Submission Date: | 6/21/2021 4:56:03 PM |
| Docketed Date: | 6/21/2021 |

Comment Received From: Taylor Engineering
Submitted On: 6/21/2021
Docket Number: 21-BSTD-01

Revise section 1201(c)3 ventilation

EXCEPTION 1 to Section 120.1(c)3: Designed Occupancy requires that the AHJ allows this option to occur. This is an unnecessary burden to designers. Instead, delete the Exception to Section 1004.5 of the CBC and reinstate the assumption in earlier versions of Title 24 that specifies that the density of occupants shall not be less than half of the exiting density required by CBC Chapter 10.