

**DOCKETED**

<b>Docket Number:</b>	21-BSTD-01
<b>Project Title:</b>	2022 Energy Code Update Rulemaking
<b>TN #:</b>	239021
<b>Document Title:</b>	Dawn Hollingsworth Comments - Outdoor lighting controls
<b>Description:</b>	N/A
<b>Filer:</b>	System
<b>Organization:</b>	Dawn Hollingsworth
<b>Submitter Role:</b>	Public
<b>Submission Date:</b>	7/27/2021 9:08:25 AM
<b>Docketed Date:</b>	7/27/2021

*Comment Received From: Dawn Hollingsworth*  
*Submitted On: 7/27/2021*  
*Docket Number: 21-BSTD-01*

## **Outdoor lighting controls**

Sections 130.2(c)3 and 160.5(c)2C requires exterior motion sensing controls. There have been numerous industry studies proving this technique doesn't work as intended leaving the owner and users with a burden of purchasing technology that doesn't meet functional standards. In many cases the motion sensors do not have the sensitivity to sense a person in proximity to the zone and they are still left in the dark without the security and safety of proper lighting. This is a matter of life safety with technology that doesn't work.