

DOCKETED

Docket Number:	21-BSTD-01
Project Title:	2022 Energy Code Update Rulemaking
TN #:	239058
Document Title:	Jeff Stein Comments - fan power limits
Description:	N/A
Filer:	System
Organization:	Jeff Stein
Submitter Role:	Public
Submission Date:	7/28/2021 12:36:28 PM
Docketed Date:	7/28/2021

Comment Received From: Jeff Stein
Submitted On: 7/28/2021
Docket Number: 21-BSTD-01

fan power limits

We support the changes to the Fan Power Limits in Section 140.4(c). We would have preferred that the fan power allowances been the more stringent values included in the CASE Report. In our experience, when engineers follow good practices in duct design and product selections, those values can be met easily. We had suggested the CASE team propose lower allowances. However, we recognize that even the looser values presented in the 15-day language will provide significant energy savings, mainly due to the scope's expansions to include health care and systems with down to 1 kW input power.