

DOCKETED	
Docket Number:	01-AFC-25C
Project Title:	Malburg Generating Station-Compliance
TN #:	240154
Document Title:	Quarterly Compliance Report Q3 2021
Description:	N/A
Filer:	Kyle McCormack
Organization:	Heorot Power Management
Submitter Role:	Applicant
Submission Date:	10/28/2021 8:18:12 AM
Docketed Date:	10/28/2021



MALBURG GENERATING STATION

4963 Soto Street
Vernon, CA 90058
Telephone: (323) 476-3610
Fax: (323) 476-3640

28 October 2021

Mr. Anwar Ali
Compliance Project Manager
California Energy Commission
Energy Facilities Siting Division
1516 9th Street, MS 2000
Sacramento, CA 95814-5512

Subject: Malburg Generating Station
2021 Q3 Compliance Report

Dear Mr. Ali:

On behalf of the owner of the Malburg Generating Station, Bicent (California) Malburg LLC, Colorado Energy has compiled the attached Quarterly Compliance Report per the California Energy Commission's Decision 01-AFC-25C – Petition to Amend.

Please contact me at (303) 607-5590 or kmccormack@coloradoenergy.com if you have any questions or need additional information.

Sincerely,

Kyle McCormack
Environmental Manager

Attachments:
MGS 2021 Q3 CEC Report



MALBURG GENERATING STATION

4963 Soto Street

Vernon, CA 90058

Telephone: (323) 476-3610

Fax: (323) 476-3640

**QUARTERLY COMPLIANCE REPORT
(Third Quarter 2021)**

**MALBURG GENERATING STATION
4963 SOTO STREET, VERNON, CA 90058**

SUBMITTED TO:

CALIFORNIA ENERGY COMMISSION

1516 9TH STREET, SACRAMENTO, CA 95814



MALBURG GENERATING STATION

4963 Soto Street
Vernon, CA 90058
Telephone: (323) 476-3610
Fax: (323) 476-3640

Contents

LIST OF TABLES.....	iv
LIST OF APPENDICES	iv
SECTION 1 INTRODUCTION	1
1.1 PROJECT LOCATION AND DESCRIPTION	1
1.2 ORGANIZATION OF THE QUARTERLY COMPLIANCE REPORT	1
SECTION 2 COMPLIANCE DETAILS	1
2.1 CONDITION OF CERTIFICATION AQ-C6.....	1
2.2 CONDITION OF CERTIFICATION AQ-C7	1
2.3 CONDITION OF CERTIFICATION AQ-C8.....	1
2.4 CONDITION OF CERTIFICATION AQ-C9.....	2
2.5 CONDITION OF CERTIFICATION AQ-C10.....	2
2.6 CONDITION OF CERTIFICATION AQ-C11	2
2.7 CONDITION OF CERTIFICATION AQ-2.....	2
2.8 CONDITION OF CERTIFICATION AQ-3.....	2
2.9 CONDITION OF CERTIFICATION AQ-5.....	3
2.10 CONDITION OF CERTIFICATION AQ-6.....	3
2.11 CONDITION OF CERTIFICATION AQ-8.....	4
2.12 CONDITION OF CERTIFICATION AQ-9.....	4
2.13 CONDITION OF CERTIFICATION AQ-10.....	4
2.14 CONDITION OF CERTIFICATION AQ-11.....	4
2.15 CONDITION OF CERTIFICATION AQ-12.....	5
2.16 CONDITION OF CERTIFICATION AQ-13.....	5
2.17 CONDITION OF CERTIFICATION AQ-14.....	5
2.18 CONDITION OF CERTIFICATION AQ-15.....	6
2.19 CONDITION OF CERTIFICATION NUMBER AQ-27	6
Appendix A.....	7
Cooling Tower Blowdown Reports	7



MALBURG GENERATING STATION

4963 Soto Street

Vernon, CA 90058

Telephone: (323) 476-3610

Fax: (323) 476-3640

Appendix B..... 8
 Excess Emission Reports..... 8
Appendix C 9
 Diesel Fuel Oil Specifications..... 9
Appendix D 10
 Cooling Tower PM10 Guidance 10



MALBURG GENERATING STATION

4963 Soto Street

Vernon, CA 90058

Telephone: (323) 476-3610

Fax: (323) 476-3640

LIST OF TABLES

- 2-1 Cooling Tower TDS Sampling Results
- 2-2 Cooling Tower Daily PM10 Emissions During July
- 2-3 Cooling Tower Daily PM10 Emissions During August
- 2-4 Cooling Tower Daily PM10 Emissions During September
- 2-5 Diesel Fuel Fired Emergency Firewater Pump Testing Times
- 2-11 Total Monthly Emissions during July
- 2-12 Total Monthly Emissions during August
- 2-13 Total Monthly Emissions during September
- 2-14 Combustion Turbines Startup and Shutdown Events
- 2-15 Combustion Turbines and Duct Burners Gas Usage

LIST OF APPENDICES

- A Cooling Tower Blowdown Reports
- B Excess Emissions Reports
- C Chevron GST Oil Specifications
- D Cooling Tower PM10

SECTION 1 INTRODUCTION

This Quarterly Compliance Report (QCR) has been prepared to meet the California Energy Commission (CEC) requirements for the Malburg Generating Station (MGS). This QCR fulfills various Conditions of Certifications as described in the California Energy Commission's Petition to Amend License, June 20, 2019.

1.1 PROJECT LOCATION AND DESCRIPTION

The Malburg Generating Station is located at 4963 Soto Street on approximately 3.4 acres, in an industrial land use area. MGS is located near the geographic center of metropolitan Los Angeles County. MGS consists of two Alstom GTX-100 frame type natural gas combustion turbine generators (CTGs); two heat recovery steam generators (HRSG); a steam turbine-generator (STG); a cooling tower, a diesel fuel fired emergency firewater pump and support equipment.

The commissioning of MGS was completed in October 2005 and the power plant began Commercial Operation on October 17, 2005.

1.2 ORGANIZATION OF THE QUARTERLY COMPLIANCE REPORT

A summary of each condition of certification and required means of verification are provided in Section 2. Each sub-section also contains a description of the method used by MGS to demonstrate compliance with the verification requirements and references to Appendices, Figures and Tables as appropriate.

SECTION 2 COMPLIANCE DETAILS

The compliance details for various conditions of certification are provided below.

2.1 CONDITION OF CERTIFICATION AQ-C6

As per the Condition of Certification Number AQ-C6, MGS shall determine the Total Dissolved Solids (TDS) levels in the blowdown water by independent laboratory testing prior to initial operation and periodically thereafter.

For verification of the above condition of certification, the CEC requires MGS to submit weekly TDS reports for the blowdown water as part of the quarterly emission report to the Compliance Project Manager (CPM) for approval.

As demonstration of compliance, the weekly TDS results are provided in Table 2-1, and the weekly sample reports during operation are provided in Appendix A.

2.2 CONDITION OF CERTIFICATION AQ-C7

As per the Condition of Certification Number AQ-C7, particulate matter of diameter less than 10 microns (PM₁₀) emissions from the cooling tower shall not exceed 6.2 lb/day.

Compliance with the PM₁₀ daily emission limit shall be demonstrated as follows:

$$PM_{10} \text{ lb/day} = A*B*C*D$$

Where:

- A = circulating water recirculation rate
- B = total dissolved solids concentration in the blowdown water to be updated on a weekly basis
- C = design drift rate
- D = correction factor

For verification of the above condition of certification, the CEC requires the project owner to calculate the daily PM₁₀ emissions from the cooling tower and submit all calculations and results on a quarterly basis in the quarterly emissions reports to the CPM for approval.

As demonstration of compliance, the daily PM₁₀ emissions from the cooling tower are provided in Tables 2-2 through 2-4.

2.3 CONDITION OF CERTIFICATION AQ-C8

As per the Condition of certification Number AQ-C8, the project owner shall refrain from testing the firewater pump during the same hour as either gas fired combustion turbines is in start up or shut down as defined by Condition of Certification AQ-C9.

For verification of the above condition of certification, the CEC requires MGS to submit to the CPM for approval all testing times and results of the diesel fired emergency firewater pump in the quarterly emissions report.

As demonstration of compliance, the testing times for the diesel fired emergency firewater pump are provided in Table 2-5. MGS refrained from testing the diesel fired

emergency firewater pump on the same hour the combustion turbines were either started or shutdown.

2.4 CONDITION OF CERTIFICATION AQ-C9

As per the Condition of certification Number AQ-C9, MGS shall use the provided definitions to determine compliance with startup, shutdown and any related emission or operational limitations.

For verification of the above condition of certification, the CEC requires MGS to submit to the CPM for approval, a record of all startups and shutdowns including duration and date of occurrence on a quarterly basis as part of the quarterly emission report.

As demonstration of compliance, the startup and shutdown details are provided in Table 2-14.

2.5 CONDITION OF CERTIFICATION AQ-C10

The condition of certification number AQ-C10 has been deleted.

2.6 CONDITION OF CERTIFICATION AQ-C11

As per the Condition of Certification Number AQ-C11, MGS shall submit a quarterly emissions report on a quarterly basis to the CPM for approval. The quarterly emissions report shall generally report all ammonia, NO_x, SO_x, CO, PM₁₀ and VOC emissions from the MGS as necessary to demonstrate compliance with all emission limits. The fourth quarter emission report shall include an annual summary of all emissions of ammonia, NO_x, SO_x, CO, PM₁₀ and VOC as necessary to demonstrate compliance with all annual emission limits.

For verification of the above condition of certification, the CEC requires MGS to submit the quarterly emissions report no less than 30 days after the end of each calendar quarter.

2.7 CONDITION OF CERTIFICATION AQ-2

As per the Condition of Certification Number AQ-2, MGS shall not use diesel oil containing sulfur compounds in excess of 15 ppm by weight as supplied by the supplier.

For verification of the above condition of certification, the CEC requires MGS to submit fuel purchase records for approval to the CPM on a quarterly basis in the quarterly emissions report.

Low sulfur diesel fuel was purchased March 29, 2021.

2.8 CONDITION OF CERTIFICATION AQ-3

As per the Condition of Certification Number AQ-3, MGS shall keep records, in a manner approved by the District, for the following parameter(s) or item(s): Purchase records of fuel oil and sulfur content of the fuel.

For verification of the above condition of certification, the CEC requires MGS to submit fuel purchase records for approval to the CPM on a quarterly basis in the quarterly emissions report.

Low sulfur diesel fuel was purchased March 29, 2021.

2.9 CONDITION OF CERTIFICATION AQ-5

As per the condition of certification number AQ-5, MGS shall limit the emissions from both gas-fired combustion turbine-heat recovery steam generator train exhaust stacks as follows:

Contaminant Emissions Limit

- CO 7,633 lbs in any one month
- PM₁₀ 4,876 lbs in any one month
- PM_{2.5} 4,876 lbs in any one month
- VOC 3,236 lbs in any one month
- SO_x 227 lbs in any one month

For verification of the above condition of certification, the CEC requires the MGS to submit all emission calculations, fuel use and a summary demonstrating compliance of all emission limits stated in this condition for approval to the CPM on a quarterly basis in the quarterly emissions report.

As demonstration of compliance, the monthly emissions of CO, PM₁₀, VOC, and SO_x are presented in Tables 2-11 through 2-13. In addition, the fuel usage for the two turbine-duct burner pairs is provided in Table 2-15. MGS calculates the emission limit(s) for CO based on readings from the certified CEMS. In the event the CO CEMS is not operating or the emissions exceed the valid upper range of the analyzer, the emissions are calculated in accordance with the approved CEMS Plan. MGS calculates the emission limit(s) by using the monthly fuel use data and the following emission factors:- PM₁₀, PM_{2.5}: 6.014 lb/mmscf, VOC: 1.54 lb/mmscf & SO_x: 0.28lb/mmscf.

2.10 CONDITION OF CERTIFICATION AQ-6

As per the condition of certification numbers AQ-6; following commissioning, start-ups shall not exceed 120 minutes during a cold start-up without a trip, and 150 minutes during a cold start-up with a trip. Cold start-ups with or without a trip shall not exceed the following limits: NO_x 122.8 lbs, CO 204.8 lbs and VOC 1.75 lbs.

Start-ups shall not exceed 90 minutes during a non-cold start-up without a trip or 120 minutes during a non-cold start-up with a trip. Non-cold start-ups shall not exceed the following limits: NO_x 51.3 lbs, CO 59.9 lbs, and VOC 1.55 lbs.

Shut-downs shall not exceed 30 minutes. Shut-downs shall not exceed the following limits: NO_x 4.5 lbs, CO 10.8 lbs, and VOC 0.71 lbs.

The number of startups shall not exceed two per day per turbine.

For verification of the above condition of certification, the CEC requires the MGS to submit a record of all startups and shutdowns including duration and date of occurrence on a quarterly basis as part of the quarterly emission report.

As demonstration of compliance, the startup and shutdown details are provided in Table 2-14. Additionally, quarterly excess emission reports from the DAHS are provided in Appendix B.

2.11 CONDITION OF CERTIFICATION AQ-8

The Condition of Certification Number AQ-8 has been deleted.

2.12 CONDITION OF CERTIFICATION AQ-9

As per the Condition of Certification Number AQ-9, the 2.0 ppmv oxides of nitrogen (NO_x) emissions limit(s) are averaged over 1 hour at 15 percent oxygen, dry basis, during the normal operation of the MGS combustion turbine generators.

For verification of the above condition of certification, the CEC requires MGS to submit to the CPM for approval all emissions and emission calculations on a quarterly basis as part of the quarterly emissions report.

NO_x emission for MGS Units 1 and 2 are measured using the CEMS. A review of CEMS NO_x emission data indicated that the maximum corrected NO_x emissions concentration for both MGS combustion turbines during normal operations was 1.9 ppmv, which is less than or equal to the emission concentration limit of 2.0 ppmv. All CEMS data for MGS combustion turbines are stored electronically at MGS. As demonstration of compliance, quarterly excess emission reports from the DAHS are provided in Appendix B.

2.13 CONDITION OF CERTIFICATION AQ-10

As per the Condition of Certification Number AQ-10 the 2.0 ppmv carbon monoxide (CO) emissions limit(s) are averaged over 1 hour at 15 percent oxygen, dry basis, during the normal operation of the MGS combustion turbine generators.

For verification of the above condition of certification, the CEC requires MGS to submit to the CPM for approval all emissions and emission calculations on a quarterly basis as part of the quarterly emissions report.

CO emission for MGS Units 1 and 2 are measured using the CEMS. A review of CEMS CO emission data indicated that maximum CO emission concentration for both MGS combustion turbines was 0.8 ppmv, which is lower than or equal to the emission concentration limit of 2.0 ppmv. All CEMS data for MGS combustion turbines are stored electronically at MGS. As demonstration of compliance, quarterly excess emission reports from the DAHS are provided in Appendix B.

2.14 CONDITION OF CERTIFICATION AQ-11

As per the Condition of Certification Number AQ-11, the 2.0 ppmv VOC emission limit(s) are averaged over 1 hour at 15 percent oxygen, dry basis.

For verification of the above condition of certification, the CEC requires MGS to submit to the CPM for approval all emissions and emission calculations on a quarterly basis as part of the quarterly emissions report.

2.15 CONDITION OF CERTIFICATION AQ-12

As per the Condition of Certification Number AQ-12, the 5 ppm ammonia (NH₃) emission limit(s) are averaged over 1 hour at 15 percent oxygen, dry basis. MGS shall calculate and continuously record the ammonia slip concentration using the following:

NH_3 (ppmv) = $[a-(b*c/1,000,000)]*(1,000,000*d/b)$ where

a = ammonia injection rate (lbs/hr)/17 (lbs/lb-mole)

b = dry exhaust gas flow rate (lbs/hr)/29 (lbs/lb-mole)

c = change in measured NO_x across the SCR (ppmv dry basis)

d = correction derived by comparing the measured and calculated NH₃ slip concentrations during annual compliance testing.

For verification of the above condition of certification, the CEC requires MGS to submit to the CPM for approval all emissions and emission calculations on a quarterly basis as part of the quarterly emissions report.

NH₃ emissions are calculated via the CEMS on an hourly basis but compliance with 5 ppm limit is demonstrated from source tests. The last NH₃ compliance source test, performed in March 2021, indicated compliance with the emission limits for both CT1 and for CT2.

2.16 CONDITION OF CERTIFICATION AQ-13

As per the Condition of Certification Number AQ-13, for the purpose of determining compliance with District Rule 475, combustion contaminant emissions may exceed the concentration limit or the mass emission limit listed, but not both emission limits at the same time.

For verification of the above condition of certification, the CEC requires MGS to submit to the CPM for approval all emissions and emission calculations on a quarterly basis as part of the quarterly emissions report.

Rule 475 limits emission of combustion contaminants from electric generating equipment to no more than 5 kilograms (11 pounds) per hour or 23 milligrams per cubic meter (0.01 gr/SCF) calculated at three percent oxygen on a dry basis averaged over 15 consecutive minutes or any other averaging time specified by the Executive Officer.

The results of the last compliance source tests performed in August 2019 indicated compliance with the particulate matter emission limits for both CT1 and CT2.

2.17 CONDITION OF CERTIFICATION AQ-14

As per the Condition of Certification Number AQ-14, MGS shall only use diesel fuel containing the following specified compounds:

Sulfur less than or equal to 15 ppm by weight.

For verification of the above condition of certification, the CEC requires MGS to submit fuel purchase records to the CPM on a quarterly basis as part of the quarterly emissions report.

MGS uses CARB Ultra Low Sulfur Diesel for the diesel fire pump (D48). This is an ash less oil. As demonstration of compliance, detailed specifications of CARB Ultra Low Sulfur Diesel are provided in Appendix C.

2.18 CONDITION OF CERTIFICATION AQ-15

As per the condition of certification number AQ-15, MGS will limit the operating time to no more than 200 hours each in any one year.

Operations for maintenance and testing as defined in Rule 1470 shall not exceed 50 hours in any one calendar year. The total annual operating time includes all operations including maintenance and testing.

For verification of the above condition of certification, the CEC requires MGS to submit to the CPM for approval all testing times and results of the diesel fired emergency firewater pump in the quarterly emissions report.

As demonstration of compliance, the testing times for the diesel fired emergency firewater pump are provided in Table 2-5.

2.19 CONDITION OF CERTIFICATION NUMBER AQ-27

As per the Condition of Certification Number AQ-27, MGS shall limit the fuel usage of each turbine-duct burner pair to no more than 405 MM cubic feet per month.

For verification of the above condition of certification, the CEC requires MGS to submit to the CPM for approval all emissions and emission calculations on a quarterly basis as part of the quarterly emissions report.

As demonstration of compliance, the fuel usage for the two turbine-duct burner pairs is provided in Table 2-15.

Table 2-1

**Malburg Generating Station
Cooling Tower TDS Sampling Results
Quarter 3, 2021**

Starting	Ending	TDS (ppm)
7/4/2021	7/10/2021	4620
7/11/2021	7/17/2021	5100
7/18/2021	7/24/2021	4500
7/25/2021	7/31/2021	4940
8/1/2021	8/7/2021	4680
8/8/2021	8/14/2021	4460
8/15/2021	8/21/2021	5050
8/22/2021	8/28/2021	4700
8/29/2021	9/4/2021	4540
9/5/2021	9/11/2021	4600
9/12/2021	9/18/2021	4720
9/19/2021	9/25/2021	4510
9/26/2021	10/2/2021	4540

Table 2-2

**Malburg Generating Station
Cooling Tower Daily PM10 Emissions During Jul. 2021**

PM₁₀ = A x B x C x D
PM₁₀ Limit is 6.2 lbs/day

A = Circulation Rate
C = Drift Factor

B = TDS
D = Correction Factor

Date	Circulation Rate (gal/day)	TDS (ppm)	PM ₁₀ (lbs/day)
1	38,811,456	4800	1.55
2	38,811,456	4800	1.55
3	38,811,456	4800	1.55
4	38,811,456	4620	1.49
5	38,811,456	4620	1.49
6	38,811,456	4620	1.49
7	38,811,456	4620	1.49
8	38,811,456	4620	1.49
9	38,811,456	4620	1.49
10	38,811,456	4620	1.49
11	38,811,456	5100	1.65
12	38,811,456	5100	1.65
13	38,811,456	5100	1.65
14	38,811,456	5100	1.65
15	38,811,456	5100	1.65
16	38,811,456	5100	1.65

Date	Circulation Rate (gal/day)	TDS (ppm)	PM ₁₀ (lbs/day)
17	38,811,456	5100	1.65
18	38,811,456	4500	1.46
19	38,811,456	4500	1.46
20	38,811,456	4500	1.46
21	38,811,456	4500	1.46
22	38,811,456	4500	1.46
23	38,811,456	4500	1.46
24	38,811,456	4500	1.46
25	38,811,456	4940	1.60
26	38,811,456	4940	1.60
27	38,811,456	4940	1.60
28	38,811,456	4940	1.60
29	38,811,456	4940	1.60
30	38,811,456	4940	1.60
31	38,811,456	4940	1.60

Table 2-3

**Malburg Generating Station
Cooling Tower Daily PM10 Emissions During Aug. 2021**

PM₁₀ = A x B x C x D
PM₁₀ Limit is 6.2 lbs/day

A = Circulation Rate
C = Drift Factor

B = TDS
D = Correction Factor

Date	Circulation Rate (gal/day)	TDS (ppm)	PM ₁₀ (lbs/day)
1	38,811,456	4680	1.51
2	38,811,456	4680	1.51
3	38,811,456	4680	1.51
4	38,811,456	4680	1.51
5	38,811,456	4680	1.51
6	38,811,456	4680	1.51
7	38,811,456	4680	1.51
8	38,811,456	4460	1.44
9	38,811,456	4460	1.44
10	38,811,456	4460	1.44
11	38,811,456	4460	1.44
12	38,811,456	4460	1.44
13	38,811,456	4460	1.44
14	38,811,456	4460	1.44
15	38,811,456	5050	1.63
16	38,811,456	5050	1.63

Date	Circulation Rate (gal/day)	TDS (ppm)	PM ₁₀ (lbs/day)
17	38,811,456	5050	1.63
18	38,811,456	5050	1.63
19	38,811,456	5050	1.63
20	38,811,456	5050	1.63
21	38,811,456	5050	1.63
22	38,811,456	4700	1.52
23	38,811,456	4700	1.52
24	38,811,456	4700	1.52
25	38,811,456	4700	1.52
26	38,811,456	4700	1.52
27	38,811,456	4700	1.52
28	38,811,456	4700	1.52
29	38,811,456	4540	1.47
30	38,811,456	4540	1.47
31	38,811,456	4540	1.47

Table 2-4

Malburg Generating Station Cooling Tower Daily PM10 Emissions During Sep. 2021							
PM₁₀ = A x B x C x D PM₁₀ Limit is 6.2 lbs/day		A = Circulation Rate C = Drift Factor		B = TDS D = Correction Factor			
Date	Circulation Rate (gal/day)	TDS (ppm)	PM ₁₀ (lbs/day)	Date	Circulation Rate (gal/day)	TDS (ppm)	PM ₁₀ (lbs/day)
1	38,811,456	4540	1.47	17	38,811,456	4720	1.53
2	38,811,456	4540	1.47	18	38,811,456	4720	1.53
3	38,811,456	4540	1.47	19	38,811,456	4510	1.46
4	38,811,456	4540	1.47	20	38,811,456	4510	1.46
5	38,811,456	4600	1.49	21	38,811,456	4510	1.46
6	38,811,456	4600	1.49	22	38,811,456	4510	1.46
7	38,811,456	4600	1.49	23	38,811,456	4510	1.46
8	38,811,456	4600	1.49	24	38,811,456	4510	1.46
9	38,811,456	4600	1.49	25	38,811,456	4510	1.46
10	38,811,456	4600	1.49	26	38,811,456	4540	1.47
11	38,811,456	4600	1.49	27	38,811,456	4540	1.47
12	38,811,456	4720	1.53	28	38,811,456	4540	1.47
13	38,811,456	4720	1.53	29	38,811,456	4540	1.47
14	38,811,456	4720	1.53	30	38,811,456	4540	1.47
15	38,811,456	4720	1.53				
16	38,811,456	4720	1.53				

Table 2-5

**Heorot Power Management
Malburg Generating Station
Diesel Fuel Fired Emergency Firewater Pump Testing Times
During Quarter 3, 2021**

Date	Time	Main / Test Emerg.	Hours of Operation	Fuel Used (gals)
Jul. 04, 2021	23:49	Testing	0.5	4.5
Jul. 11, 2021	22:54	Testing	0.5	5.6
Jul. 18, 2021	22:52	Testing	0.6	5.6
Jul. 25, 2021	22:59	Testing	0.5	6.7
Aug. 01, 2021	23:22	Testing	0.5	5.6
Aug. 08, 2021	23:20	Testing	0.5	5.6
Aug. 15, 2021	20:32	Testing	0.5	5.6
Aug. 23, 2021	01:47	Testing	0.5	5.6
Aug. 29, 2021	23:16	Testing	0.5	5.6
Sep. 05, 2021	23:28	Testing	0.5	5.6
Sep. 12, 2021	23:41	Testing	0.5	5.6
Sep. 19, 2021	22:52	Testing	0.5	5.6
Sep. 26, 2021	22:46	Testing	0.5	5.6

Note: Event 'DNR' - Did Not Run

Table 2-11

Malburg Generating Station Total Monthly Emissions Jul-2021	
Contaminant	Gas Turbines (2)
CO lbs	1,030
PM10 lbs	2,936
PM2.5 lbs	2,936
VOC lbs	752
SOx lbs	137

Table 2-12

Malburg Generating Station Total Monthly Emissions Aug-2021	
Contaminant	Gas Turbines (2)
CO lbs	1,025
PM10 lbs	2,789
PM2.5 lbs	2,789
VOC lbs	714
SOx lbs	131

Table 2-13

Malburg Generating Station Total Monthly Emissions Sep-2021	
Contaminant	Gas Turbines (2)
CO lbs	971
PM10 lbs	2,555
PM2.5 lbs	2,555
VOC lbs	655
SOx lbs	120

Table 2-14

**Malburg Generating Station
Combustion Turbines Startup and Shutdown Events
During Quarter 3, 2021**

CT1

Date	Event Type	Event Start	Event End	Duration (hrs:min)
09/18/2021	Shutdown	01:00	01:13	0:13
09/20/2021	Cold Start	15:48	17:12	1:24

CT2

Date	Event Type	Event Start	Event End	Duration (hrs:min)
8/27/2021	Shutdown	21:58	22:05	0:07
8/28/2021	Warm Start	18:35	19:51	1:16
9/2/2021	Shutdown/Trip	10:09	10:22	0:13
9/2/2021	Warm Start	10:22	11:24	1:02

Table 2-15

**Malburg Generating Station
Combustion Turbines and Duct Burner Gas Usage
During Quarter 3,2021**

Month	CT-1 / DB-1 Gas Usage (mmscf)	CT-2 / DB-2 Gas Usage (mmscf)
Jul-21	242.93	245.38
Aug-21	235.16	228.65
Sep-21	199.12	225.69

Appendix A

Cooling Tower Blowdown Reports



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

July 13, 2021

Tom Barnhart
Colorado Energy Management
4963 Soto St.
Vernon, CA 90058

Report No.: 2107036
Project Name: Malburg Generating Station Weekly

Dear Tom Barnhart,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on July 07, 2021.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

Colorado Energy Management
 4963 Soto St.
 Vernon, CA 90058

File #:74548
 Report Date: 07/13/21
 Submitted: 07/07/21
PLS Report No.: 2107036

Attn: Tom Barnhart Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Sample ID: Cooling Tower Blowdown Water (2107036-01) Sampled: 07/07/21 08:40 Received: 07/07/21 08:40										
Total Dissolved Solids	4620		1	mg/L	5.0	SM 2540C	07/08/21	07/09/21	dd	BG10905

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	Limit	RPD	Limit	Qualifier
Batch BG10905										
Blank	Prepared: 07/08/21 Analyzed: 07/09/21									
Total Dissolved Solids	ND	5.0	mg/L							
LCS	Prepared: 07/08/21 Analyzed: 07/09/21									
Total Dissolved Solids	53.0	5.0	mg/L	50.00		106	80-120			
Duplicate	Source: 2107036-01 Prepared: 07/08/21 Analyzed: 07/09/21									
Total Dissolved Solids	4630	5.0	mg/L		4620			0.253	5	
Duplicate	Source: 2107042-11 Prepared: 07/08/21 Analyzed: 07/09/21									
Total Dissolved Solids	1230	5.0	mg/L		1240			0.929	5	

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the detection limit
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

DATE: 7-21 PAGE 1 OF 1

LOG BOOK NO. FILE NO. LAB NO. 2107036

CLIENT NAME: Com Project Name/No. Malibu Coexisting Spins P.O. NO. AIRBILL NO: _____

ADDRESS: ANALYSES REQUESTED: COOLER TEMP: 1.3°C

PROJECT MANAGER: Tom Bernhart PHONE NO: FAX NO: PRESERVATIVE:

SAMPLER NAME: John Bernhart (Printed) (Signature) REMARKS:

TAT (Analytical Turn Around Time): 0 = Same Day; 1 = 1 Day; 2 = 2 Days; 3 = 3 Days; N = Normal (5-7 Working Days)

CONTAINER TYPES: B = Brass, E = Encore, G = Glass, P = Plastic, V = VOA Vial, O = Other:

UST Project: Y N - Global ID# _____

SAMPLE NO.	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		SAMPLE CONDITION/CONTAINER /COMMENTS:
				WATER	SOIL	SLUDGE	OTHER		#	TYPE	
1	7-21	0840	Coexisting Blowdown	X				N	1	P	Y
2											
3											
4											
5											
6											
7											
8											
9											
10											

Relinquished By: (Signature and Printed Name) Tom Bernhart Received By: (Signature and Printed Name) Guadalupe Tanaka Date: 7-21 Time: 1050

Relinquished By: (Signature and Printed Name) Received By: (Signature and Printed Name) Date: Time:

Relinquished By: (Signature and Printed Name) Received By: (Signature and Printed Name) Date: Time:

SAMPLE DISPOSITION:
1. Samples returned to client? YES NO
2. Samples will not be stored over 30 days, unless additional storage time is requested.
3. Storage time requested: _____ days

SPECIAL INSTRUCTIONS: By _____ Date _____



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

July 19, 2021

Tom Barnhart
Colorado Energy Management
4963 Soto St.
Vernon, CA 90058

Report No.: 2107089
Project Name: Malburg Generating Station Weekly

Dear Tom Barnhart,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on July 12, 2021.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

Colorado Energy Management
 4963 Soto St.
 Vernon, CA 90058

File #: 74548
 Report Date: 07/19/21
 Submitted: 07/12/21
PLS Report No.: 2107089

Attn: Tom Barnhart Phone: (323) 476-3626 FAX: (323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2107089-01) Sampled: 07/12/21 08:35 Received: 07/12/21 08:35

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	5100		1	mg/L	5.0	SM 2540C	07/15/21	07/16/21	dd	BG11930

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	RPD	RPD Limit	Qualifier
---------	--------	-----	-------	-------------	---------------	------	-----	-----------	-----------

Batch BG11930

Blank		Prepared: 07/15/21		Analyzed: 07/16/21					
Total Dissolved Solids	ND	5.0	mg/L						
LCS		Prepared: 07/15/21		Analyzed: 07/16/21					
Total Dissolved Solids	50.0	5.0	mg/L	50.00	100	80-120			
Duplicate		Source: 2107089-01		Prepared: 07/15/21		Analyzed: 07/16/21			
Total Dissolved Solids	5110	5.0	mg/L	5100	0.261	5			

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the detection limit
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-3312 FAX (213) 745-8372

DATE: 7-12-21 PAGE 1 OF 1
 LOG BOOK NO. _____ FILE NO. _____ LAB NO. 2107089

CLIENT NAME: CEM Project Name/No. Malibu Generating Station P.O. NO. _____ AIRBILL NO: _____
 ADDRESS: _____ ANALYSES REQUESTED: _____ COOLER TEMP: 0-9°C

PROJECT MANAGER: TOM BANHUT PHONE NO: _____ FAX NO: _____ PRESERVATIVE: _____

SAMPLER NAME: John Banut (Printed) [Signature] (Signature) REMARKS: _____
 TAT (Analytical Turn Around Time): 0 = Same Day; 1 = 1 Day; 2 = 2 Days; 3 = 3 Days; N = Normal (5-7 Working Days)

CONTAINER TYPES: B = Brass, E = Encore, G = Glass, P = Plastic, V = VOA Vial, O = Other: _____

UST Project: Y N - Global ID# _____

SAMPLE NO.	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		SAMPLE CONDITION/CONTAINER/COMMENTS:
				WATER	SOIL	SLUDGE	OTHER		#	TYPE	
1	7/12/21	0835	Coating powder Blandom	X				N	1	P	X
2											
3											
4											
5											
6											
7											
8											
9											
10											

Relinquished By: (Signature and Printed Name) [Signature] Received By: (Signature and Printed Name) Guadalupe Tanaka Date: 7-12-21 Time: 1010
 Relinquished By: (Signature and Printed Name) _____ Received By: (Signature and Printed Name) _____ Date: _____ Time: _____
 Relinquished By: (Signature and Printed Name) _____ Received By: (Signature and Printed Name) _____ Date: _____ Time: _____

SPECIAL INSTRUCTIONS: _____
 By _____ Date _____

SAMPLE DISPOSITION:
 1. Samples returned to client? YES NO
 2. Samples will not be stored over 30 days, unless additional storage time is requested.
 3. Storage time requested: _____ days



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

July 26, 2021

Tom Barnhart
Colorado Energy Management
4963 Soto St.
Vernon, CA 90058

Report No.: 2107157
Project Name: Malburg Generating Station Weekly

Dear Tom Barnhart,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on July 20, 2021.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

Colorado Energy Management
 4963 Soto St.
 Vernon, CA 90058

File #: 74548
 Report Date: 07/26/21
 Submitted: 07/20/21
PLS Report No.: 2107157

Attn: Tom Barnhart Phone: (323) 476-3626 FAX: (323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2107157-01) Sampled: 07/20/21 08:55 Received: 07/20/21 08:55										
Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	4500		1	mg/L	5.0	SM 2540C	07/20/21	07/21/21	dd	8G12222

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	Limit	RPD	Limit	Qualifier
Batch 8G12222 - -										
Blank										
Total Dissolved Solids	ND	5.0	mg/L							
LCS										
Total Dissolved Solids	50.0	5.0	mg/L	50.00		100	80-120			
Duplicate Source: 2107121-01										
Total Dissolved Solids	3660	5.0	mg/L		3580			1.96	5	

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the detection limit
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

DATE: 7/24 PAGE 1 OF 1
LOG BOOK NO. FILE NO. LAB NO. 210757

CLIENT NAME: CUM Project Name/No. No. 101191 (containing 5 extra weekly) P.O. NO. AIRBILL NO:

ADDRESS: ANALYSES REQUESTED: COOLER TEMP: 1.3²⁰

PROJECT MANAGER: Tom Bamber PHONE NO: FAX NO: PRESERVATIVE:

SAMPLER NAME: John Bamber (Printed) [Signature] (Signature) REMARKS:

TAT (Analytical Turn Around Time): 0 = Same Day; 1 = 1 Day; 2 = 2 Days; 3 = 3 Days; N = Normal (5-7 Working Days)

CONTAINER TYPES: B = Brass, E = Encore, G = Glass, P = Plastic, V = VOA Vial, O = Other:

UST Project: Y N - Global ID#

SAMPLE NO.	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		SAMPLE CONDITION/CONTAINER /COMMENTS:
				WATER	SOIL	SLUDGE	OTHER		#	TYPE	
1	7/24	0855	Cooling Tower/Bondan	6				N	1	P	6
2											
3											
4											
5											
6											
7											
8											
9											
10											

Relinquished By: (Signature and Printed Name) [Signature] Received By: (Signature and Printed Name) Guadalupe Tanaka Date: 7/24 Time: 1:30

SAMPLE DISPOSITION:
1. Samples returned to client? YES NO
2. Samples will not be stored over 30 days, unless additional storage time is requested.
3. Storage time requested: _____ days

SPECIAL INSTRUCTIONS: By _____ Date _____



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

July 30, 2021

Tom Barnhart
Colorado Energy Management
4963 Soto St.
Vernon, CA 90058

Report No.: 2107215
Project Name: Malburg Generating Station Weekly

Dear Tom Barnhart,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on July 26, 2021.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

Colorado Energy Management
 4963 Soto St.
 Vernon, CA 90058

File #: 74548
 Report Date: 07/30/21
 Submitted: 07/26/21
PLS Report No.: 2107215

Attn: Tom Barnhart Phone: (323) 476-3626 FAX: (323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2107215-01) Sampled: 07/24/21 08:45 Received: 07/26/21 08:45										
Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	4940		1	mg/L	5.0	SM 2540C	07/27/21	07/28/21	dd	BG12820

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	RPD	Qualifier
Batch BG12820								
Blank	Prepared: 07/27/21 Analyzed: 07/28/21							
Total Dissolved Solids	ND	5.0	mg/L					
LCS	Prepared: 07/27/21 Analyzed: 07/28/21							
Total Dissolved Solids	53.0	5.0	mg/L	50.00	106	80-120		
Duplicate	Source: 2107215-01 Prepared: 07/27/21 Analyzed: 07/28/21							
Total Dissolved Solids	4850	5.0	mg/L	4940	1.77	5		

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the detection limit
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

DATE: 7-26-21 PAGE 1 OF 1
LOG BOOK NO. _____ FILE NO. _____ LAB NO. 40725

CLIENT NAME: CEM Project Name/No. Malibu Generating Station Weekly P.O. NO. _____ AIRBILL NO: _____

ADDRESS: _____ ANALYSES REQUESTED: _____ COOLER TEMP: 0-20c

PROJECT MANAGER: Tom Balhart PHONE NO: _____ FAX NO: _____ PRESERVATIVE: _____

SAMPLER NAME: John Bane (Printed) [Signature] (Signature) REMARKS: _____

TAT (Analytical Turn Around Time): 0 = Same Day; 1 = 1 Day; 2 = 2 Days; 3 = 3 Days; N = Normal (5-7 Working Days)

CONTAINER TYPES: B = Brass, E = Encore, G = Glass, P = Plastic, V = VOA Vial, O = Other:

UST Project: Y N - Global ID# _____

SAMPLE NO.	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		SAMPLE CONDITION/CONTAINER /COMMENTS:
				WATER	SOIL	SLUDGE	OTHER		#	TYPE	
1	<u>7/24/21</u>	<u>0845</u>	<u>Coast Tower Biondum</u>	<u>✓</u>				<u>21</u>	<u>P</u>	<u>4</u>	
2											
3											
4											
5											
6											
7											
8											
9											
10											

Relinquished By: (Signature and Printed Name) [Signature] Received By: (Signature and Printed Name) Guadalupe Tanaka Date: 7-26-21 Time: 4:40

Relinquished By: (Signature and Printed Name) _____ Received By: (Signature and Printed Name) _____ Date: _____ Time: _____

Relinquished By: (Signature and Printed Name) _____ Received By: (Signature and Printed Name) _____ Date: _____ Time: _____

SAMPLE DISPOSITION:
 1. Samples returned to client? YES NO
 2. Samples will not be stored over 30 days, unless additional storage time is requested.
 3. Storage time requested: _____ days
 By _____ Date _____

SPECIAL INSTRUCTIONS: _____



781 East Washington Blvd., Los Angeles, CA 90021
[213] 745-5312 FAX [213] 745-6372

August 09, 2021

Tom Barnhart
Colorado Energy Management
4963 Soto St.
Vernon, CA 90058

Report No.: 2108022
Project Name: Malburg Generating Station Weekly

Dear Tom Barnhart,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on August 03, 2021.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

Colorado Energy Management
 4963 Soto St.
 Vernon, CA 90058

File #:74548
 Report Date: 08/09/21
 Submitted: 08/03/21
PLS Report No.: 2108022

Attn: Tom Barnhart Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Sample ID: Cooling Tower Blowdown Water (2108022-01) Sampled: 08/03/21 09:05 Received: 08/03/21 09:05										
Total Dissolved Solids	4680		1	mg/L	5.0	SM 2540C	08/05/21	08/06/21	dd	BH10616

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
Batch BH10616										
Blank	Prepared: 08/05/21 Analyzed: 08/06/21									
Total Dissolved Solids	ND	5.0	mg/L							
LCS	Prepared: 08/05/21 Analyzed: 08/06/21									
Total Dissolved Solids	46.0	5.0	mg/L	50.00		92.0	80-120			
Duplicate	Source: 2108022-01 Prepared: 08/05/21 Analyzed: 08/06/21									
Total Dissolved Solids	4780	5.0	mg/L		4680			2.11	5	

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the detection limit
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

DATE: 8/31 PAGE 1 OF 1
 LOG BOOK NO. _____ FILE NO. _____ LAB NO. 1108022

CLIENT NAME: Cam Project Name/No. Malibu Generating Station P.O. NO. _____ AIRBILL NO: _____

ADDRESS: _____ ANALYSES REQUESTED: _____ COOLER TEMP: 1.50c

PROJECT MANAGER: Tom Barnett PHONE NO: _____ FAX NO: _____ PRESERVATIVE: _____

SAMPLER NAME: Jen Baker (Printed) J (Signature) REMARKS: _____

TAT (Analytical Turn Around Time): 0 = Same Day; 1 = 1 Day; 2 = 2 Days; 3 = 3 Days; N = Normal (5-7 Working Days)

CONTAINER TYPES: B = Brass, E = Encore, G = Glass, P = Plastic, V = VOA Vial, O = Other:

UST Project: Y N - Global ID# _____

SAMPLE NO.	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		SAMPLE CONDITION/CONTAINER /COMMENTS:
				WATER	SOIL	SLUDGE	OTHER		#	TYPE	
1	8/31	0905	Leakage from window	✓					N1 P		
2											
3											
4											
5											
6											
7											
8											
9											
10											

Relinquished By: (Signature and Printed Name) J. Tanaka Received By: (Signature and Printed Name) Guadalupe Tanaka Date: 8/31 Time: 0945

Relinquished By: (Signature and Printed Name) _____ Received By: (Signature and Printed Name) _____ Date: _____ Time: _____

Relinquished By: (Signature and Printed Name) _____ Received By: (Signature and Printed Name) _____ Date: _____ Time: _____

SPECIAL INSTRUCTIONS: _____

SAMPLE DISPOSITION:
 1. Samples returned to client? YES NO
 2. Samples will not be stored over 30 days, unless additional storage time is requested.
 3. Storage time requested: _____ days
 By _____ Date _____



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

August 16, 2021

Tom Barnhart
Colorado Energy Management
4963 Soto St.
Vernon, CA 90058

Report No.: 2108100
Project Name: Malburg Generating Station Weekly

Dear Tom Barnhart,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on August 09, 2021.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

Colorado Energy Management
 4963 Soto St.
 Vernon, CA 90058

File #: 74548
 Report Date: 08/16/21
 Submitted: 08/09/21
PLS Report No.: 2108100

Attn: Tom Barnhart Phone: (323) 476-3626 FAX: (323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2108100-01) Sampled: 08/09/21 08:50 Received: 08/09/21 08:50

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	4460		1	mg/L	5.0	SM 2540C	08/12/21	08/13/21	dd	BH11309

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	Limits	RPD	RPD Limit	Qualifier
Batch BH11309										
Blank										
Total Dissolved Solids	ND	5.0	mg/L							
LCS										
Total Dissolved Solids	49.0	5.0	mg/L	50.00		98.0	80-120			
Duplicate										
Source: 2108100-01										
Total Dissolved Solids	4380	5.0	mg/L		4460			1.81	5	

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the detection limit
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

DATE: 8/9/21 PAGE: 1 OF 1

FILE NO.: _____ LAB NO.: 210800

CLIENT NAME: COLORADO ENERGY MGMT. PROJECT NAME/NO. Mulliken Generation Station Weekly
~~STORM WATER~~ P.O.NO. AIRBILL NO:

ADDRESS: 2715 E. 50th ST. VERNON CA 90058 ANALYSES REQUESTED COOLER TEMP: _____

PROJECT MANAGER TOM BARNHART PHONE NO: 1-702-413-2525 FAX NO: PRESERVED: 1-1°C

SAMPLER NAME: SIGNATURE: REMARKS: _____

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: _____

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS									SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE										
	<u>8/9/21</u>	<u>0850</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X									

Relinquished by (Signature & Name): <u>[Signature]</u>	Received by (Signature & Name): <u>[Signature]</u> Guadalupe Tanaka	Date: <u>8/9/21</u>	Time: <u>1:30</u>	SAMPLE DISPOSITION 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature & Name): _____	Received by (Signature & Name): _____	Date: _____	Time: _____	
Relinquished by (Signature & Name): _____	Received by (Signature & Name): _____	Date: _____	Time: _____	

SPECIAL INSTRUCTION: _____



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

August 23, 2021

Tom Barnhart
Colorado Energy Management
4963 Soto St.
Vernon, CA 90058

Report No.: 2108195
Project Name: Malburg Generating Station Weekly

Dear Tom Barnhart,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on August 17, 2021.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

Colorado Energy Management
 4963 Soto St.
 Vernon, CA 90058

File #:74548
 Report Date: 08/23/21
 Submitted: 08/17/21
PLS Report No.: 2108195

Attn: Tom Barnhart Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2108195-01) Sampled: 08/17/21 09:25 Received: 08/17/21 09:25

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	5050		1	mg/L	5.0	- SM 2540C	08/19/21	08/20/21	dd	BH12011

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC %REC	RPD RPD	RPD RPD	Limit	Qualifier
Batch BH12011 - -										
Blank										
Total Dissolved Solids	ND	5.0	mg/L							
LCS										
Total Dissolved Solids	49.0	5.0	mg/L	50.00		98.0			80-120	
Duplicate										
Source: 2108195-01										
Total Dissolved Solids	5110	5.0	mg/L		5050				1.25	5
Duplicate										
Source: 2108205-10										
Total Dissolved Solids	9190	5.0	mg/L		9270				0.867	5

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the detection limit
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Pick Owen Paulin

 Authorized Signature(s)



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

August 30, 2021

Tom Barnhart
Colorado Energy Management
4963 Soto St.
Vernon, CA 90058

Report No.: 2108262
Project Name: Malburg Generating Station Weekly

Dear Tom Barnhart,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on August 23, 2021.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

Colorado Energy Management
 4963 Soto St.
 Vernon, CA 90058

File #: 74548
 Report Date: 08/30/21
 Submitted: 08/23/21
PLS Report No.: 2108262

Attn: Tom Barnhart Phone: (323) 476-3626 FAX: (323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2108262-01) Sampled: 08/23/21 08:20 Received: 08/23/21 08:20										
Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	4700		1	mg/L	5.0	-	SM 2540C	08/26/21	08/27/21	dd BH12702

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	RPD	RPD	Limit	Qualifier
Batch BH12702										
Blank										
Total Dissolved Solids	ND	5.0	mg/L							
LCS										
Total Dissolved Solids	53.0	5.0	mg/L	50.00		106			80-120	
Duplicate Source: 2108262-01										
Total Dissolved Solids	4690	5.0	mg/L		4700			0.142	5	

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the detection limit
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Pick Owen Parker

Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

DATE: 8/23/24 PAGE: 1 OF 1

FILE NO.:

LAB NO.: 21082102

CLIENT NAME: COLORADO ENERGY MGMT. PROJECT NAME/NO. MALBURG GENERATING STATION P.O.NO. AIRBILL NO.:

ADDRESS: 2715 E. 50th ST. VERNON CA 90058 ANALYSES REQUESTED COOLER TEMP: 1.1²⁰

PROJECT MANAGER TOM BARNHART PHONE NO: 1-702-413-2525 FAX NO: PRESERVED: _____

SAMPLER NAME: JOHN BARIE SIGNATURE: REMARKS: _____

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: _____

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS								SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE									
	<u>8/23/24</u>	<u>10:30</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X								

Relinquished by (Signature & Name): 	Received by (Signature & Name): 	Date: <u>8/23/24</u>	Time: <u>12:05</u>	SAMPLE DISPOSITION 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION:



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

September 03, 2021

Tom Barnhart
Colorado Energy Management
4963 Soto St.
Vernon, CA 90058

Report No.: 2108331
Project Name: Malburg Generating Station Weekly

Dear Tom Barnhart,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on August 30, 2021.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

Colorado Energy Management
 4963 Soto St.
 Vernon, CA 90058

File #:74548
 Report Date: 09/03/21
 Submitted: 08/30/21
PLS Report No.: 2108331

Attn: Tom Barnhart Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	4540		I	mg/L	5.0	- SM 2540C	09/01/21	09/02/21	dd	BI10221

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	RPD Limits	RPD Limit	Qualifier
Batch BI10221									
Blank									
Total Dissolved Solids	ND	5.0	mg/L						
LCS									
Total Dissolved Solids	54.0	5.0	mg/L	50.00		108	80-120		
Duplicate									
Source: 2108331-01									
Total Dissolved Solids	4510	5.0	mg/L		4540		0.699	5	

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the detection limit
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Rick Owen Parker

 Authorized Signature(s)



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

September 14, 2021

Tom Barnhart
Colorado Energy Management
4963 Soto St.
Vernon, CA 90058

Report No.: 2109084
Project Name: Malburg Generating Station Weekly

Dear Tom Barnhart,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on September 08, 2021.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

Colorado Energy Management
 4963 Soto St.
 Vernon, CA 90058

File #: 74548
 Report Date: 09/14/21
 Submitted: 09/08/21
PLS Report No.: 2109084

Attn: Tom Barnhart Phone: (323) 476-3626 FAX: (323) 476-3640

Project: Malburg Generating Station Weekly

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Sample ID: Cooling Tower Blowdown Water (2109084-01)	Sampled: 09/08/21 08:55 Received: 09/08/21 08:55									
Total Dissolved Solids	4600		1	mg/L	5.0	SM 2540C	09/09/21	09/10/21	dd	BI11319

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
Batch BI11319 - -										
Blank										
Total Dissolved Solids	ND	5.0	mg/L							
LCS										
Total Dissolved Solids	53.0	5.0	mg/L	50.00		106	80-120			
Duplicate Source: 2109084-01										
Total Dissolved Solids	4700	5.0	mg/L		4600			2.04	5	

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the detection limit
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Authorized Signature(s)



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

September 17, 2021

Tom Barnhart
Colorado Energy Management
4963 Soto St.
Vernon, CA 90058

Report No.: 2109134
Project Name: Malburg Generating Station Weekly

Dear Tom Barnhart,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on September 13, 2021.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

Colorado Energy Management
 4963 Soto St.
 Vernon, CA 90058

File #:74548
 Report Date: 09/17/21
 Submitted: 09/13/21
PLS Report No.: 2109134

Attn: Tom Barnhart Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2109134-01) Sampled: 09/13/21 08:45 Received: 09/13/21 08:45

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	4720		1	mg/L	5.0	SM 2540C	09/16/21	09/17/21	dd	BT11713

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	RPD	Qualifier
---------	--------	-----	-------	-------------	---------------	------	-----	-----------

Batch BT11713

Blank	Prepared: 09/16/21 Analyzed: 09/17/21	
Total Dissolved Solids	ND	5.0 mg/L
LCS	Prepared: 09/16/21 Analyzed: 09/17/21	
Total Dissolved Solids	47.0	5.0 mg/L 50.00 94.0 80-120
Duplicate	Source: 2109134-01 Prepared: 09/16/21 Analyzed: 09/17/21	
Total Dissolved Solids	4820	5.0 mg/L 4720 1.99 5

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the detection limit
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Authorized Signature(s)



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

October 01, 2021

Tom Barnhart
Colorado Energy Management
4963 Soto St.
Vernon, CA 90058

Report No.: 2109259
Project Name: Malburg Generating Station Weekly

Dear Tom Barnhart,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on September 24, 2021.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

Colorado Energy Management
 4963 Soto St.
 Vernon, CA 90058

File #: 74548
 Report Date: 10/01/21
 Submitted: 09/24/21
PLS Report No.: 2109259

Attn: Tom Barnhart Phone: (323) 476-3626 FAX: (323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2109259-01) Sampled: 09/24/21 10:05 Received: 09/24/21 10:05

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	4510		1	mg/L	5.0	SM 2540C	09/30/21	10/01/21	dd	BJ10110

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC Limits	RPD	RPD Limit	Qualifier
---------	--------	-----	-------	-------------	---------------	-------------	-----	-----------	-----------

Batch BJ10110

Blank		Prepared: 09/30/21 Analyzed: 10/01/21				
Total Dissolved Solids	ND	5.0	mg/L			
LCS		Prepared: 09/30/21 Analyzed: 10/01/21				
Total Dissolved Solids	52.0	5.0	mg/L	50.00	104	80-120
Duplicate		Source: 2109310-01 Prepared: 09/30/21 Analyzed: 10/01/21				
Total Dissolved Solids	4560	5.0	mg/L	4540	0.329	5

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the detection limit
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

DATE: 9/24/21 PAGE: 1 OF 1

FILE NO.: _____ LAB NO.: W001554

CLIENT NAME: **COLORADO ENERGY MGMT.** PROJECT NAME/NO. _____ MALBURG GENERATING STATION P.O.NO. _____ AIRBILL NO: _____

ADDRESS: **2715 E. 50th ST. VERNON CA 90058** ANALYSES REQUESTED _____ COOLER TEMP: 2.1°C

PROJECT MANAGER **TOM BARNHART** PHONE NO: **1-702-413-2525** FAX NO: _____ PRESERVED: _____

SAMPLER NAME: **JOHN BARIE** SIGNATURE: [Signature] REMARKS: _____

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: **Y N** GLOBAL ID#: _____

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS	ANALYSES REQUESTED	AIRBILL NO.	COOLER TEMP.	PRESERVED	REMARKS	SAMPLE CONDITIONS/CONTAINER/COMMENTS	
				WATER	SOIL	SLUDGE	OTHER		#	TYPE								
	<u>9/24/21</u>	<u>1005</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X							

Relinquished by (Signature & Name): <u>[Signature]</u>	Received by (Signature & Name): <u>[Signature]</u> Guadalupe Tanaka	Date: <u>9/24/21</u>	Time: <u>1035</u>	SAMPLE DISPOSITION 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	3. Storage time requested: _____ days.

Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	By: _____ Date: _____
-------------------------------------	---------------------------------	-------	-------	-----------------------

SPECIAL INSTRUCTION: _____



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

October 04, 2021

Tom Barnhart
Colorado Energy Management
4963 Soto St.
Vernon, CA 90058

Report No.: 2109310
Project Name: Malburg Generating Station Weekly

Dear Tom Barnhart,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on September 28, 2021.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

Colorado Energy Management
 4963 Soto St.
 Vernon, CA 90058

File #:74548
 Report Date: 10/04/21
 Submitted: 09/28/21
PLS Report No.: 2109310

Attn: Tom Barnhart Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2109310-01) Sampled: 09/28/21 09:30 Received: 09/28/21 13:00

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	4540		1	mg/L	5.0	- SM 2540C	09/30/21	10/01/21	dd	B110110

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC Limits	RPD	RPD Limit	Qualifier
---------	--------	-----	-------	-------------	---------------	-------------	-----	-----------	-----------

Batch B110110

Blank		Prepared: 09/30/21 Analyzed: 10/01/21				
Total Dissolved Solids	ND	5.0	mg/L			
LCS		Prepared: 09/30/21 Analyzed: 10/01/21				
Total Dissolved Solids	52.0	5.0	mg/L	50.00	104	80-120
Duplicate		Source: 2109310-01 Prepared: 09/30/21 Analyzed: 10/01/21				
Total Dissolved Solids	4560	5.0	mg/L	4540	0.329	5

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the detection limit
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Rich Owen Parlier

Authorized Signature(s)

Appendix B

Excess Emission Reports

Startup/Shutdown Excess Emissions Report

U1 CO Startup/Shutdown



From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** Malburg Generating Station

Generated: 10/07/2021 11:23 **Location:** Vernon, California

Tag Name: U1_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,144.28 Hours

Non-Operating Time: 63.72 Hours Report Time: 2,208.00 Hours

Unit Operation

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description

No excess emissions were found in the reporting period.

Excess Emission Report

Unit 1 - CO ppmvdc 3-hour Rolling during Normal Operation

From: 07/01/2021 00:00 To: 09/30/2021 23:59 Facility Name: Malburg Generating Station
Generated: 10/07/2021 11:19 Location: Vernon, California



Tag Name: U1_CO_3HrRoll_Ppmvdc_1H

Total Operating Time: 2,146.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 62.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,146.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

Unit 1 - NOx ppmvdc 1-hour during Normal Operation

From: 07/01/2021 00:00 To: 09/30/2021 23:59 Facility Name: Malburg Generating Station
Generated: 10/07/2021 11:20 Location: Vernon, California



Tag Name: U1_NOxNormal_Ppmvdc_1H

Total Operating Time: 2,146.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 62.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,146.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

Unit 1 - VOC ppmvdc 1-hour during Normal Operation

From: 07/01/2021 00:00 To: 09/30/2021 23:59 Facility Name: Malburg Generating Station
Generated: 10/07/2021 11:21 Location: Vernon, California



Tag Name: U1_VOCNormal_Ppmvdc_1H

Total Operating Time: 2,146.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 62.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,146.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Quad K Excess Emissions Report

U1 NOX 4-Hour Events

From: 07/01/2021 00:00 To: 09/30/2021 23:59
Generated: 10/07/2021 11:22

Facility Name: Malburg Generating Station
Location: Vernon, California



Tag Name: U1_NOx4H_Ppmvdc_1H

Total Operating Time: 2,146.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 62.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,146.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Startup/Shutdown Excess Emissions Report

U1 NOx Startup/Shutdown



From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** Malburg Generating Station

Generated: 10/07/2021 11:23 **Location:** Vernon, California

Tag Name: U1_NOXRECLM_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,144.28 Hours

Non-Operating Time: 63.72 Hours Report Time: 2,208.00 Hours

Unit Operation

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description

No excess emissions were found in the reporting period.

Startup/Shutdown Excess Emissions Report

U1 VOC Startup/Shutdown



From: 07/01/2021 00:00 To: 09/30/2021 23:59 Facility Name: Malburg Generating Station

Generated: 10/07/2021 11:24 Location: Vernon, California

Tag Name: U1_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,144.28 Hours

Non-Operating Time: 63.72 Hours Report Time: 2,208.00 Hours

Unit Operation

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description

No excess emissions were found in the reporting period.

Startup/Shutdown Event Report

U2 CO Startup/Shutdown Events



From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** Malburg Generating Station

Generated: 10/07/2021 11:25 **Location:** Vernon, California

Tag Name: U2_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,183.50 Hours

Non-Operating Time: 24.50 Hours Report Time: 2,208.00 Hours

Unit Operation

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description

No excess emissions were found in the reporting period.

Excess Emission Report

Unit 2 - NOx ppmvdc 1-hour during Normal Operation

From: 07/01/2021 00:00 To: 09/30/2021 23:59 Facility Name: Malburg Generating Station
Generated: 10/07/2021 11:25 Location: Vernon, California



Tag Name: U2_NOxNormal_Ppmvdc_1H

Total Operating Time: 2,186.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 22.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,186.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

Unit 2 - VOC ppmvdc 1-hour during Normal Operation

From: 04/01/2021 00:00 To: 06/30/2021 23:59 Facility Name: Malburg Generating Station
Generated: 10/07/2021 11:26 Location: Vernon, California



Tag Name: U2_VOCNormal_Ppmvdc_1H

Total Operating Time: 2,054.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 130.00 Hour(s) Report Time: 2,184.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,054.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

Unit 2 - CO ppmvdc 1-hour during Normal Operation

From: 07/01/2021 00:00 To: 09/30/2021 23:59 Facility Name: Malburg Generating Station
Generated: 10/07/2021 11:26 Location: Vernon, California



Tag Name: U2_CONormal_Ppmvdc_1H

Total Operating Time: 2,186.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 22.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,186.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Quad K Excess Emissions Report

U2 NOX 4-Hour Events

From: 07/01/2021 00:00 To: 09/30/2021 23:59
Generated: 10/07/2021 11:27

Facility Name: Malburg Generating Station
Location: Vernon, California



Tag Name: U2_NOx4H_Ppmvdc_1H

Total Operating Time: 2,186.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 22.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,186.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Startup/Shutdown Excess Emissions Report

U2 NOx Startup/Shutdown



From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** Malburg Generating Station

Generated: 10/07/2021 11:27 **Location:** Vernon, California

Tag Name: U2_NOXRECLM_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,183.50 Hours

Non-Operating Time: 24.50 Hours Report Time: 2,208.00 Hours

Unit Operation

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description

No excess emissions were found in the reporting period.

Startup/Shutdown Event Report

U2 VOC Startup/Shutdown Events



From: 07/01/2021 00:00 **To:** 09/30/2021 23:59 **Facility Name:** Malburg Generating Station

Generated: 10/07/2021 11:28 **Location:** Vernon, California

Tag Name: U2_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,183.50 Hours

Non-Operating Time: 24.50 Hours Report Time: 2,208.00 Hours

Unit Operation

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description

No excess emissions were found in the reporting period.

Appendix C

Diesel Fuel Oil Specifications

Invoice



SC Commercial, LLC, DBA SC Fuels
 1800 West Katella Ave, Suite 400
 P.O. Box 4159, Orange, CA 92863-4159

PLEASE REMIT ALL PAYMENTS TO:
P.O. BOX 14237
ORANGE, CA 92863-1237

Ph: (800) 659-5823 Credit Inquiries: (888) SCFUELS Ext.6017

INVOICE: 1837355-IN

INVOICE DATE: 3/29/2021

DUE DATE: 4/28/2021

SHIP DATE: 3/29/2021

SHIP VIA: 924

ORDER DATE: 3/24/2021

ORDER NUMBER: 1837355

CUSTOMER PO: MGS21780

TERMS: N30

SALEPERSON: Todd Cripps
 714-938-5714

ACCT NO (Bill-to): 01-0001084
 COLORADO ENERGY MANAGEMENT LLC
 ATTN: ACCOUNTS PAYABLE
 4963 S. SOTO STREET
 VERNON, CA 90058
 (323) 476-3622

ACCT NO (Ship-to) 01-0001084 1L
 COLORADO ENERGY MGMT-VERNON
 4963 SOTO STREET
 VERNON, CA 90058

ITEM CODE	ITEM DESCRIPTION	QUANTITY ORDERED	QUANTITY DELIVERED	PACKAGE DESCRIPTION	EXTENDED QTY	UNIT PRICE	EXT PRICE
CH253090981D055	CH GST 2300 ISO 32 253090981	2	2.00	55 G DR	110.00	18.58000	2,043.80
		Whse: 101					
422D055	DYED CARB ULS DIESEL NON TAXABLE USE ONLY - PENALTY FOR TAXABLE USE 15 PPM OR LESS SULFUR - MAY CONTAIN UP TO 5% BIODIESEL	2	2.00	55 G DR	110.00	3.95000	434.50
		Whse: 101					
Federal Lust						0.00100	0.11
Federal Oil Spill						0.00214	0.24
CA - AB 32 - DSL						0.00828	0.91
						3.96142	435.76
DRUMDEPOSITC001	DRUM DEPOSIT FEE	4	4.00	MISC CHRG	4.00	25.00000	100.00
		Whse: 101					
/FUELCHLUBE	FUEL SURCHARGE LUBES						9.92
/RCFLUBE	REG COMPLIANCE FEE LUBES						12.95
MSRTNDRMC001	RETURN DRUM	0	-4.00	MISC CHRG	4.00-	15.00000	60.00-
		Whse: 101					

Save time, pay online! View invoices, make payments and more.
 Sign up for the Customer Portal today. Email: creditinquiries@scfuels.com or Call 888-SCFuels
 Ext. 6017 or login to Customer Portal: <https://customerportal.scfuels.com>
 24-hour Emergency Response Call CHEMTREC: 800-424-9300

Net Invoice: 2,542.43
 Less Discount: 0.00
 Freight: 0.00
 Sales Tax: 256.52
Invoice Total: 2,798.95

- IN THE EVENT THAT THE ABOVE CHARGES ARE NOT PAID WHEN DUE, SC COMMERCIAL, LLC, DBA SC FUELS RESERVES THE RIGHT TO REFUSE FURTHER CHARGES TO THE ACCOUNT. A SERVICE CHARGE OF 1.5% PER MONTH(A.P.R. 18%) WILL APPLY TO ALL PAST DUE INVOICES.
 - ERRORS IN PRICE, EXTENSION, AND ADDITION SUBJECT TO CORRECTION.
 - It is the purchaser's responsibility to verify that all applicable taxes are being charged in accordance with federal and state laws.
 - Prices shown on this invoice reflect discounts received for Payment by Cash, Check, or Electronic Funds Transfer (EFT). Payment by other means is subject to a 3% surcharge.

Parts

PO 21780

partial



SALES ORDER / DELIVERY TICKET

ORDER NUMBER: 1837355

DATE: 3/24/2021

TERMS: N30
SALES REP: Todd Cripps
PHONE: 714-938-5714

SC Commercial, LLC, DBA SC Fuels
1800 West Katella Ave., Suite 400
P.O. Box 14237, Orange, CA 92863-4159

Ph: (800) 659-5823 Credit Inquiries: (888) SCFUELS Ext. 6017

PO#: MGS21780

SHIP DATE: 3/29/2021

PLEASE REMIT ALL PAYMENTS TO:
P.O. BOX 14237
ORANGE, CA 92863-1237

ROM:

SHIP VIA:

WHSE: 101

ACCT NO (Bill-to): 01-0001084

COLORADO ENERGY MANAGEMENT LLC
ATTN: ACCOUNTS PAYABLE
4963 S. SOTO STREET
VERNON, CA 90058
(323) 476-3622

ACCT NO (Ship-to) 01-0001084 1L

COLORADO ENERGY MGMT-VERNON
4963 SOTO STREET
VERNON, CA 90058
(323) 476-3632

HM	ITEM CODE	ITEM DESCRIPTION	QTY ORDERED	QTY DEL	PACKAGE DESC	EXTENDED QTY
	CH253090981D05 5	CH GST 2300 ISO 32 253090981	2.00	2	55 G DR	110.00 GALS
X	NA1993, DIESEL FUEL, 3 PG III / CARGO TANK					
	422D055	DYED CARB ULS DIESEL NON TAXABLE USE ONLY - PENALTY FOR TAXABLE USE 15 PPM OR LESS SULFUR - MAY CONTAIN UP TO 5% BIODIESEL	2.00	2	55 G DR	110.00 GALS
	DRUMDEPOSITC 001	DRUM DEPOSIT FEE	4.00	4	MISC CHRG	4.00 EACH
	/FUELCHLUBE	FUEL SURCHARGE LUBES				
	/RCFLUBE	REG COMPLIANCE FEE LUBES				

4 empty
Drums

Rec'd by

Date

3-29-21

Print Name

Driver's Signature

Received in INFOR

3/29/21
M. Gordon

ARRIVED DESTINATION	10 32 AM	DATE	3/29/21	COMPLETED UNLOADING	AM	DATE	3/29/21
	PM				PM		
				DRUM CREDIT			

TRUCK #	B/L #	FOR COMPANY USE ONLY
021		RT <input type="checkbox"/> TF <input type="checkbox"/> OP <input type="checkbox"/>
D.O.T. HAZARDOUS MATERIALS PLACARD PROVIDED		
BY SHIPPER <input type="checkbox"/>		CARRIER <input type="checkbox"/>
THIS IS TO CERTIFY THAT THE ABOVE NAMED MATERIALS ARE PROPERLY CLASSIFIED, DESCRIBED, PACKAGED, MARKED AND LABELED AND ARE IN PROPER CONDITION FOR TRANSPORTATION ACCORDING TO APPLICABLE REGULATIONS OF THE DEPARTMENT OF TRANSPORTATION.		

Appendix D

Cooling Tower PM10 Guidance

COOLING TOWER DRIFT MASS DISTRIBUTION Excel Drift Eliminators

The following table represents the predicted mass distribution of drift particle size for cooling tower drift dispersed from Marley TU10 and TU12 Excel Drift Eliminators properly installed in a cooling tower.

Mass in Particles (%)		Droplet Size (Microns)
0.2	Larger Than	525
1.0	Larger Than	375
5.0	Larger Than	230
10.0	Larger Than	170
20.0	Larger Than	115
40.0	Larger Than	65
60.0	Larger Than	35
80.0	Larger Than	15
88.0	Larger Than	10

How to read table: Example – 0.2% of the drift will have particle sizes larger than 525 microns.

Marley guarantees the data above for properly installed, undamaged drift eliminators in 'like-new' condition.

NOTE: Biological treatment and control of Legionella and other potentially health-threatening bacteria is essential. Consult a competent water treatment expert or service company.

pH	6.5 to 9.0 (special materials may be required beyond these limits)
Temperature	125° F (51.7° C) typical maximum; higher temperatures possible with special materials
Langelier Saturation Index	0.0 to 1.0 recommended; higher allowed if scale is controllable.
M-Alkalinity	100 to 500 ppm as CaCO ₃
Silica	150 ppm as SiO ₂ maximum (scale formation)
Iron	3 ppm maximum (staining and scale contributor)
Manganese	0.1 ppm maximum (staining and scale contributor)
Sulfides	Greater than 1 ppm can be corrosive to copper alloys, iron, steel, and galvanized steel. See table below for limits with film fill.
Ammonia	50 ppm maximum if copper alloys present; lower limits apply for film fill - see table.
Chlorine / bromine	1 ppm free residual intermittently (shock), or 0.4 ppm continuously maximum. Excess can attack sealants, accelerate corrosion, increase drift, and embrittle PVC.
Organic solvents	These can attack plastics and promote bio-growth. Trace amounts may be acceptable, depending on the solvent.
TDS	Over 5000 ppm may require thermal performance derate.

<u>Individual Ions:</u>	<u>MAXIMUM:</u>
Cations: Calcium	800 ppm as CaCO ₃ preferred, (300 ppm with MX fills in arid climate).
Magnesium	Depends on pH and silica level (for magnesium silicate scale).
Sodium	No limit.
Anions: Chlorides	450 ppm as Cl ⁻ (300 for galvanized towers). upgrades are required for higher chloride levels.
Sulfates	800 ppm as CaCO ₃ preferred if calcium is also high (CaSO ₄ scale).
Nitrates	300 ppm as NO ₃ (bacteria nutrient).
Carbonates/Bicarbonates	300 ppm as CaCO ₃ preferred for wood or galvanized steel tower.

Fouling Contaminant Limits - based on fouling load of 2.5 pounds per cubic foot

**Bacteria counts listed below relate to maintaining fill thermal efficiency only.
Biocidal treatment is required for all cooling tower installations. (see NOTE above).**

<u>Fill Type</u>	<u>Aerobic Bacteria</u> <u>Heterotrophic Plate Count</u>	<u>Total Suspended</u> <u>Solids (TSS)</u>	<u>Oil and</u> <u>Grease</u>	<u>Sulfides</u>	<u>Ammonia</u>
MC75, MC120	10,000 CFU/ml	50 ppm	1 ppm	0.5 ppm	10 ppm
FB20, MX75 and MX625 (crossflow)	100,000 CFU/ml with TSS up to 50 ppm, or 10,000 CFU/ml with TSS up to 150 ppm		1 ppm	1.0 ppm	15 ppm
DF254, MCR16	100,000 CFU/ml	150 ppm	5 ppm	1.5 ppm	25 ppm
DF381 with 1' MC75 overlay	1,000,000 CFU/ml with TSS up to 50 ppm, or 100,000 CFU/ml with TSS up to 150 ppm		5 ppm	1.5 ppm	25 ppm
DF381, MVC20, AAFNCS ('Cleanflow') MCR12, Tricklebloc	1,000,000 CFU/ml	250 ppm	10 ppm	2.0 ppm	25 ppm
Splash bar or grid fill	1,000,000 CFU/ml target	No specific limit	10 ppm	N/A	N/A

Note: Any amount of oil or grease is likely to adversely affect thermal performance. Sulfides and ammonia promote bacterial growth which can cause fill fouling; conformance to the limits above will assist in controlling bacteria to the recommended levels.

Drift Effects:

Certain contaminants or treatment chemicals such as surfactants, glycols, biodispersants and antifoams may increase drift rate. When minimizing drift is vital, the circulating water shall have a surface tension of at least 65 dynes/cm and a total organic carbon (TOC) level below 25 ppm. *Reclaim or re-use waters in particular may contain contaminants which increase drift rate either directly or by necessitating the use of treatment chemicals which increase drift rate.*

Miscellaneous Solids and Nutrients

Avoid high efficiency fill (MC75) with water containing bacteria nutrients such as alcohols, nitrates, ammonia, fats, glycols, phosphates, black liquor, or TOC greater than 50 ppm. Clog-resistant fills may be considered for contaminated water, case by case. For all film fills, avoid fibrous, oily, greasy, fatty, or tarry contaminants, which can plug fill.
In general, do not use film fill in Steel Plants, Pulp & Paper Mills, Food Processing Operations, or similar applications unless leaks and contamination by airborne or waterborne particulates, oil, or fibers are extremely unlikely. If film fill is used, biological-growth control must be stringent and diligent.