

DOCKETED

Docket Number:	20-SPPE-01
Project Title:	Great Oaks South Backup Generating Facility Small Power Plant Exemption
TN #:	240925
Document Title:	Notice of Determination
Description:	Great Oaks South Backup Generating Facility
Filer:	Lisa Worrall
Organization:	California Energy Commission
Submitter Role:	Commission Staff
Submission Date:	12/13/2021 3:29:45 PM
Docketed Date:	12/13/2021

Notice of Determination

Appendix D

To:

Office of Planning and Research
U.S. Mail: _____ *Street Address:* _____
 P.O. Box 3044 1400 Tenth St., Rm 113
 Sacramento, CA 95812-3044 Sacramento, CA 95814

County Clerk
 County of: _____
 Address: _____

From:

Public Agency: _____
 Address: _____

Contact: _____
 Phone: _____

Lead Agency (if different from above): _____
 Address: _____

Contact: _____
 Phone: _____

SUBJECT: Filing of Notice of Determination in compliance with Section 21108 or 21152 of the Public Resources Code.

State Clearinghouse Number (if submitted to State Clearinghouse): _____

Project Title: _____

Project Applicant: _____

Project Location (include county): _____

Project Description:

This is to advise that the _____ has approved the above
 (Lead Agency or Responsible Agency)

described project on _____ and has made the following determinations regarding the above
 (date)
 described project.

1. The project [will will not] have a significant effect on the environment.
2. An Environmental Impact Report was prepared for this project pursuant to the provisions of CEQA.
 A Negative Declaration was prepared for this project pursuant to the provisions of CEQA.
3. Mitigation measures [were were not] made a condition of the approval of the project.
4. A mitigation reporting or monitoring plan [was was not] adopted for this project.
5. A statement of Overriding Considerations [was was not] adopted for this project.
6. Findings [were were not] made pursuant to the provisions of CEQA.

This is to certify that the final EIR with comments and responses and record of project approval, or the negative Declaration, is available to the General Public at:

 Signature (Public Agency): *Shawn Pittard* Title: _____

Date: *December 10, 2021* Date Received for filing at OPR: _____

NOC Attachment A

Project Description:

The California Energy Commission (CEC) has the exclusive authority to certify all thermal power plants (50 megawatts [MW] and greater) and related facilities proposed for construction in California. The SPPE process allows applicants with facilities between 50 and 100 MW to obtain an exemption from CEC's jurisdiction and proceed with local permitting rather than requiring CEC certification. CEC can grant an exemption if it finds that the proposed facility would not create a substantial adverse impact on the environment or energy resources. Public Resources Code section 25519(c) designates CEC as the lead agency, in accordance with the California Environmental Quality Act (CEQA), for all facilities seeking an SPPE.

SV1, LLC, a wholly owned subsidiary of Equinix, LLC (SV1 or applicant) filed an application with the CEC seeking an exemption from the CEC's jurisdiction (Small Power Plant Exemption, or SPPE) for the Great Oaks South Backup Generating Facility (GOSBGF) (20-SPPE-01). The GOSBGF would be part of the Great Oaks South Data Center (GOSDC) to be located in the City of San Jose. The project was approved by the city on February 1, 2017 but was not constructed. Since its approval, SV1, LLC has made project design changes and is now seeking approval of an SPPE for the GOSBGF.

The GOSDC would consist of three 182,350 square foot, two-story data center buildings. The project site is approximately 18-acres in size.

The GOSBGF would consist of 36 3.25-MW diesel-fired generators in six generation yards that would each be separately electrically interconnected to the three data center buildings. The GOSBGF would be used exclusively to provide backup generation and uninterruptible power supply for the GOSDC, and other than for routine maintenance and testing, would only operate in the event of a failure of the electrical service from Pacific Gas and Electric Company (PG&E) to the data center. In addition, the GOSBGF would include three life safety diesel fired generators, each capable of generating 0.50 MW. GOSBGF would have a generating capacity of up to 99.0 MW.

The GOSDC would connect to a new PG&E substation via five new 21 kilovolt (kV) distribution feeders that would extend underground either along Via Del Oro or along Great Oaks Boulevard, or via both routes to the project site. The California Public Utilities Commission has granted PG&E approval to construct the new substation, which is called the "Santa Teresa Substation". Project figures are attached (Regional Map, Aerial Photograph and Surrounding Land Uses, and Site Plan).