

DOCKETED

Docket Number:	21-BSTD-04
Project Title:	2022 Energy Code Compliance Manuals and Forms
TN #:	241155
Document Title:	Architectural Lighting Design Comments - Lighting screw-based vs non-screw-based lamps
Description:	N/A
Filer:	System
Organization:	Architectural Lighting Design
Submitter Role:	Public
Submission Date:	1/12/2022 5:53:48 PM
Docketed Date:	1/12/2022

*Comment Received From: Architectural Lighting Design
Submitted On: 1/12/2022
Docket Number: 21-BSTD-04*

Lighting screw-based vs non-screw-based lamps

In 2022 Standards 150.0k, 1B says "Screw based luminaires shall contain lamps that comply with JA8", but does not say anything about non-screw based luminaires. Table 150.0A appears to include screw-based and non-screw-based lamps. If 150.0A applies to all lamps, why is there a separate paragraph 1B that specifically talks about screw-based lamps? Does this mean that non-screw-based luminaires can use pin-based halogen MR16s? If this is not the intent, then deleting 1B might make it clearer that ALL non-JA8-exempt lamps must meet JA8.