DOCKETED	
Docket Number:	06-AFC-09C
Project Title:	Colusa Generating Station - Compliance
TN #:	241280
Document Title:	2021 4th Quarter Operating Report
Description:	N/A
Filer:	Anthony TJ Gomez
Organization:	Pacific Gas and Electric
Submitter Role:	Applicant
Submission Date:	1/26/2022 7:53:12 AM
Docketed Date:	1/26/2022

ATTACHMENT 1
Complaints
FCD: AQ-5
Title V: #5

During the fourth quarter of 2021, there were no complaints issued from the public for the Colusa Generating Station. The site continues to be available for inspection by representatives of the CCAPCD.

ATTACHMENT 2
Fuel Quality Data

FCD: AQ-10 & 11
Title V: #16

2021 Monthly Sulfur Content - Colusa Generating Station

All Units in Grains of Sulfur per 100 Standard Cubic Foot

Month	Jan-21	Feb-21	Mar-21	Apr-21	May-21	Jun-21	Jul-21	Aug-21	Sep-21	Oct-21	Nov-21	Dec-21	Avg
Gr/100SCF	0.127	0.142	OUTAGE	0.126	0.156	0.118	0.180	0.166	0.212	0.171	0.202	0.164	0.160

Permit Limits:

0.75 Grains/100SCF per Month (PSD Condition X.I.4); 0.3 Grains/100SCF Annual Average (Title V # 16)

Atmospheric Analysis & Consulting, Inc.

CLIENT	: PG&E
PROJECT NAME	: Natural Gas Sampling
AAC PROJECT NO.	: 211823
REPORT DATE	: 10/11/2021

On October 8, 2021, Atmospheric Analysis & Consulting, Inc. received one (1) 1.0-Liter Silonite Canister for Total Reduced Sulfur analysis by ASTM D-5504. Upon receipt, the sample was assigned a unique Laboratory ID number as follows:

Client ID	Lab No.	Return Pressure (mmHg)
CPP-GS-OCT-A	211823-24147	682.1

This analysis is performed in accordance with AAC's Quality Manual. Test results apply to the sample(s) as received. For detailed information pertaining to specific EPA, NCASI, ASTM and SCAQMD accreditations (Methods & Analytes), please visit our website at www.aaclab.com.

I certify that this data is technically accurate, complete, and in compliance with the terms and conditions of the contract. No problems were encountered during receiving, preparation, and/or analysis of this sample.

The Technical Director or his/her designee, as verified by the following signature, has authorized release of the data.

If you have any questions or require further explanation of data results, please contact the undersigned.

Sucha Parmar, Ph.D.
Technical Director

This report consists of 5 pages.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

LABORATORY ANALYSIS REPORT

CLIENT	**: PG&E**	**SAMPLING DATE**	**: 10/06/2021**
PROJECT NO.	**: 211823**	**RECEIVING DATE**	**: 10/08/2021**
MATRIX	**: AIR**	**ANALYSIS DATE**	**: 10/08/2021**
UNITS	**: ppmV**	**REPORT DATE**	**: 10/11/2021**

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	**CPP-GS-OCT-A**
AAC ID	**211823-24147**
Canister Dil. Fac.	**2.2**
Analyte	**Result**
Hydrogen Sulfide	**0.220**
COS / SO2	**0.641**
Methyl Mercaptan	**0.313**
Ethyl Mercaptan	**0.140**
Dimethyl Sulfide	**0.149**
Carbon Disulfide	< 0.112
Isopropyl Mercaptan	< 0.112
tert-Butyl Mercaptan	**0.352**
n-Propyl Mercaptan	< 0.112
Methylethylsulfide	< 0.112
sec-Butyl Mercaptan / Thiophene	< 0.112
iso-Butyl Mercaptan	< 0.112
Diethyl Sulfide	< 0.112
n-Butyl Mercaptan	< 0.112
Dimethyl Disulfide	**0.151**
2-Methylthiophene	< 0.112
3-Methylthiophene	< 0.112
Tetrahydrothiophene	**0.852**
Bromothiophene	< 0.112
Thiophenol	< 0.112
Diethyl Disulfide	< 0.112
Total Unidentified Sulfur	< 0.112
Total Reduced Sulfurs	**2.18**
Total Sulfurs	**2.82**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

LABORATORY ANALYSIS REPORT

CLIENT	**: PG&E**	**SAMPLING DATE**	**: 10/06/2021**
PROJECT NO.	**: 211823**	**RECEIVING DATE**	**: 10/08/2021**
MATRIX	**: AIR**	**ANALYSIS DATE**	**: 10/08/2021**
UNITS	**: grains/100 dscf**	**REPORT DATE**	**: 10/11/2021**

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	**CPP-GS-OCT-A**
AAC ID	**211823-24147**
Canister Dil. Fac.	**2.2**
Analyte	**Result**
Hydrogen Sulfide	**0.01339**
COS / SO2	**0.03904**
Methyl Mercaptan	**0.01904**
Ethyl Mercaptan	**0.00852**
Dimethyl Sulfide	**0.00908**
Carbon Disulfide	< 0.00680
Isopropyl Mercaptan	< 0.00680
tert-Butyl Mercaptan	**0.02141**
n-Propyl Mercaptan	< 0.00680
Methylethylsulfide	< 0.00680
sec-Butyl Mercaptan / Thiophene	< 0.00680
iso-Butyl Mercaptan	< 0.00680
Diethyl Sulfide	< 0.00680
n-Butyl Mercaptan	< 0.00680
Dimethyl Disulfide	**0.00921**
2-Methylthiophene	< 0.00680
3-Methylthiophene	< 0.00680
Tetrahydrothiophene	**0.05192**
Bromothiophene	< 0.00680
Thiophenol	< 0.00680
Diethyl Disulfide	< 0.00680
Total Unidentified Sulfur	< 0.00680
Total Reduced Sulfurs	**0.13258**
Total Sulfurs	**0.17161**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

Quality Control/Quality Assurance Report
ASTM D-5504

Date Analyzed: 10/8/2021
Analyst: DL
Units: ppbV

Instrument ID: SCD#10
Calb. Date: 6/1/2021

Opening Calibration Verification Standard

519.8 ppbV H2S (SS1289)

H_2S	Resp. (area)	Result	% Rec *	% RPD ****
Initial	3578	528	101.7	1.8
Duplicate	3459	511	98.3	1.6
Triplicate	3512	519	99.8	0.1

527.0 ppbV H2S (SS1289)

MeSH	Resp. (area)	Result	% Rec *	% RPD ****
Initial	4334	517	98.1	0.8
Duplicate	4335	517	98.1	0.8
Triplicate	4233	505	95.8	1.6

522.0 ppbV H2S (SS1289)

DMS	Resp. (area)	Result	% Rec *	% RPD ****
Initial	4761	511	97.9	0.1
Duplicate	4728	507	97.2	0.6
Triplicate	4785	514	98.4	0.6

Method Blank

Analyte	Result
H_2S	<PQL
MeSH	<PQL
DMS	<PQL

Duplicate Analysis **Sample ID** 211740-23917

Analyte	Sample Result	Duplicate Result	Mean	% RPD ***
H_2S	<PQL	<PQL	0.0	0.0
MeSH	<PQL	<PQL	0.0	0.0
DMS	<PQL	<PQL	0.0	0.0

Matrix Spike & Duplicate **Sample ID** 211740-23917 x10

Analyte	Sample Conc.	Spike Added	MS Result	MSD Result	MS % Rec **	MSD % Rec **	% RPD ***
H_2S	<PQL	259.9	255.7	253.9	98.4	97.7	0.7
MeSH	<PQL	263.5	246.3	250.5	93.5	95.1	1.7
DMS	<PQL	261.0	254.5	263.2	97.5	100.8	3.3

Closing Calibration Verification Standard

Analyte	Std. Conc.	Result	% Rec **
H_2S	519.8	498.6	95.9
MeSH	527.0	502.2	95.3
DMS	522.0	502.7	96.3

** Must be 95-105%, ** Must be 90-110%, *** Must be < 10%, **** Must be < 5% RPD from Mean result.*

H2S: PQL = 10.5 ppbV, MDL = 1.12 ppbV
MeSH: PQL = 10.5 ppbV, MDL = 1.12 ppbV
DMS: PQL = 11.0 ppbV, MDL = 1.12 ppbV

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

21823

Colusa Fuel Gas Sampling

Client: PG&E Environmental Services		Project Manager: Surinder Sidhu		Date: 10/7/21
Address: 3400 Crow Canyon Road		Telephone Number: 925-866-5245	Email: SKSG@pge.com	Laboratory: AAC Labs
City: San Ramon	State: CA	Zip: 94583	Site Contacat	Laboratory Phone: 805-650-1642
Project Number/Name: Natural Gas Sampling		Sampler: Steve North 925-785-3039		Laboratory Fax
Contract Number, PO Number		Laboratory Contact: Eric Grosjean - 1534 Eastman Ave. Suite A Ventura CA 93003		

PG&E Sample ID	SAM#-ID#	Date	Time	Sample Type	Containers: Volume	Type	No.	Preservative	Condition on Receipt/Comments	Preparation and Analysis: Sulfur ASTM D-5504
CPP-GS- OCT - A	24147	10/6/21	1145	Gas	1 liter	cyl	1	None		X

Special Instruction:

Email results to Surinder Sidhu (SKSG@PGE.COM) , Evan Cavalli (EMCM@PGE.COM), A.J. Gomez (AJGU@PGE.COM)

Turn Around Time Required	QC Level	Project Specific Requirements (Specify)
☑ Normal ☐ Rush ☐ Other	☑ I. ☐ II. ☐ III.	

1. Relinquished By: Steve North (Via GSO)	Date: 10/7/21	Time: 10:30	1. Received By: Hunter Dalton	Date: 10/8/21	Time: 0931
2. Relinquished By	Date	Time	2. Received By	Date	Time
3. Relinquished By	Date	Time	3. Received By	Date	Time

Comments

Sample collected in 3L Tedlar bag and immediately field transferred to evacuated 1L mini-can onsite.

GLS - 1x can

Atmospheric Analysis & Consulting, Inc.

CLIENT	: PG&E Environmental Services
PROJECT NAME	: Natural Gas Sampling
AAC PROJECT NO.	: 212039
REPORT DATE	: 11/16/2021

On November 4th, 2021, Atmospheric Analysis & Consulting, Inc. received one (1) 1.0-Liter Silonite Canister for Total Reduced Sulfur analysis by ASTM D-5504. Upon receipt, the sample was assigned a unique Laboratory ID number as follows:

Client ID	Lab No.	Return Pressure (mmHg)
CPP-GS-NOV-A	212039-25116	710.6

This analysis is performed in accordance with AAC's Quality Manual. Test results apply to the samples as received. For detailed information pertaining to specific EPA, NCASI, ASTM and SCAQMD accreditations (Methods & Analytes), please visit our website at www.aaclab.com.

I certify that this data is technically accurate, complete, and in compliance with the terms and conditions of the contract. No problems were encountered during receiving, preparation, and/or analysis of this sample. The Technical Director or his/her designee, as verified by the following signature, has authorized release of the data.

If you have any questions or require further explanation of data results, please contact the undersigned.

Sucha Parmar, Ph.D.
Technical Director

This report consists of 5 pages.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

LABORATORY ANALYSIS REPORT

CLIENT : PG&E Environmental Services
PROJECT NO. : 212039
MATRIX : AIR
UNITS : ppmV

SAMPLING DATE : 11/02/2021
RECEIVING DATE : 11/04/2021
ANALYSIS DATE : 11/05/2021
REPORT DATE : 11/16/2021

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	**CPP-GS-NOV-A**
AAC ID	**212039-25116**
Canister Dil. Fac.	**2.2**
Analyte	**Result**
Hydrogen Sulfide	**0.705**
COS / SO2	**0.523**
Methyl Mercaptan	**0.173**
Ethyl Mercaptan	< 0.109
Dimethyl Sulfide	< 0.109
Carbon Disulfide	< 0.109
Isopropyl Mercaptan	< 0.109
tert-Butyl Mercaptan	**0.693**
n-Propyl Mercaptan	< 0.109
Methylethylsulfide	< 0.109
sec-Butyl Mercaptan / Thiophene	< 0.109
iso-Butyl Mercaptan	< 0.109
Diethyl Sulfide	< 0.109
n-Butyl Mercaptan	< 0.109
Dimethyl Disulfide	< 0.109
2-Methylthiophene	< 0.109
3-Methylthiophene	< 0.109
Tetrahydrothiophene	**0.876**
Bromothiophene	< 0.109
Thiophenol	< 0.109
Diethyl Disulfide	< 0.109
Total Unidentified Sulfur	**0.342**
Total Reduced Sulfurs	**2.79**
Total Sulfurs	**3.31**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

LABORATORY ANALYSIS REPORT

CLIENT : PG&E Environmental Services
PROJECT NO. : 212039
MATRIX : AIR
UNITS : grains/100 dscf

SAMPLING DATE : 11/02/2021
RECEIVING DATE : 11/04/2021
ANALYSIS DATE : 11/05/2021
REPORT DATE : 11/16/2021

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	**CPP-GS-NOV-A**
AAC ID	**212039-25116**
Canister Dil. Fac.	**2.2**
Analyte	**Result**
Hydrogen Sulfide	**0.0430**
COS / SO2	**0.0318**
Methyl Mercaptan	**0.0106**
Ethyl Mercaptan	< 0.00664
Dimethyl Sulfide	< 0.00664
Carbon Disulfide	< 0.00664
Isopropyl Mercaptan	< 0.00664
tert-Butyl Mercaptan	**0.0422**
n-Propyl Mercaptan	< 0.00664
Methylethylsulfide	< 0.00664
sec-Butyl Mercaptan / Thiophene	< 0.00664
iso-Butyl Mercaptan	< 0.00664
Diethyl Sulfide	< 0.00664
n-Butyl Mercaptan	< 0.00664
Dimethyl Disulfide	< 0.00664
2-Methylthiophene	< 0.00664
3-Methylthiophene	< 0.00664
Tetrahydrothiophene	**0.0534**
Bromothiophene	< 0.00664
Thiophenol	< 0.00664
Diethyl Disulfide	< 0.00664
Total Unidentified Sulfur	**0.0208**
Total Reduced Sulfurs	**0.170**
Total Sulfurs	**0.202**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

Quality Control/Quality Assurance Report
ASTM D-5504

Date Analyzed: 11/5/2021
Analyst: DL
Units: ppbV

Instrument ID: SCD#10
Calb. Date: 6/1/2021

Opening Calibration Verification Standard

519.8 ppbV H2S (SS1289)

H_2S	Resp. (area)	Result	% Rec *	% RPD ****
Initial	3552	525	100.9	0.7
Duplicate	3530	521	100.3	0.1
Triplicate	3498	517	99.4	0.8

527.0 ppbV H2S (SS1289)

MeSH	Resp. (area)	Result	% Rec *	% RPD ****
Initial	4245	506	96.1	0.9
Duplicate	4227	504	95.6	1.3
Triplicate	4377	522	99.0	2.2

522.0 ppbV H2S (SS1289)

DMS	Resp. (area)	Result	% Rec *	% RPD ****
Initial	4693	504	96.5	1.4
Duplicate	4814	517	99.0	1.2
Triplicate	4769	512	98.0	0.2

Method Blank

Analyte	Result
H_2S	<PQL
MeSH	<PQL
DMS	<PQL

Duplicate Analysis Sample ID 211740-23918

Analyte	Sample Result	Duplicate Result	Mean	% RPD ***
H_2S	<PQL	<PQL	0.0	0.0
MeSH	<PQL	<PQL	0.0	0.0
DMS	<PQL	<PQL	0.0	0.0

Matrix Spike & Duplicate Sample ID 211740-23918 x10

Analyte	Sample Conc.	Spike Added	MS Result	MSD Result	MS % Rec **	MSD % Rec **	% RPD ***
H_2S	<PQL	259.9	262.3	272.8	100.9	105.0	3.9
MeSH	<PQL	263.5	250.9	265.5	95.2	100.8	5.7
DMS	<PQL	261.0	261.3	263.6	100.1	101.0	0.9

Closing Calibration Verification Standard

Analyte	Std. Conc.	Result	% Rec **
H_2S	519.8	524.4	100.9
MeSH	527.0	533.7	101.3
DMS	522.0	533.3	102.2

** Must be 95-105%, ** Must be 90-110%, *** Must be < 10%, **** Must be < 5% RPD from Mean result.*

H2S: PQL = 10.5 ppbV, MDL = 1.12 ppbV
MeSH: PQL = 10.5 ppbV, MDL = 1.12 ppbV
DMS: PQL = 11.0 ppbV, MDL = 1.12 ppbV

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com • (805) 650-1642

212039

Colusa Fuel Gas Sampling

Client: PG&E Environmental Services		Project Manager: Surinder Sidhu		Date: 11/2/21
Address: 3400 Crow Canyon Road		Telephone Number: 925-866-5245	Email: SKSG@pge.com	Laboratory: AAC Labs
City: San Ramon	State: CA	Zip: 94583	Site Contacat	Laboratory Phone: 805-650-1642
Project Number/Name: Natural Gas Sampling			Sampler: Steve North 925-785-3039	Laboratory Fax
Contract Number, PO Number		Laboratory Contact: Eric Grosjean - 1534 Eastman Ave. Suite A Ventura CA 93003		

PG&E Sample ID	SAM#-ID#	Date	Time	Sample Type	Containers: Volume	Type	No.	Preservative	Condition on Receipt/Comments	Preparation and Analysis: Sulfur ASTM D-5504
CPP-GS- NOV - A	25116	11/2/21	1240	Gas	1 liter	cyl	1	None		X

Special Instruction:

Email results to Surinder Sidhu (SKSG@PGE.COM) , Evan Cavalli (EMCM@PGE.COM), A.J. Gomez (AJGU@PGE.COM)

Turn Around Time Required	QC Level	Project Specific Requirements (Specify)
☑ Normal ☐ Rush ☐ Other	☑ I. ☐ II. ☐ III.	

1. Relinquished By: Steve North (via WH) (via GSO)	Date: 11/2/21	Time: 1530	1. Received By	Date	Time
2. Relinquished By	Date	Time	2. Received By	Date	Time
3. Relinquished By	Date	Time	3. Received By	Date: 11/4/21	Time: 1541

Comments

Sample collected in 3L Tedlar bag and immediately field transferred to evacuated 1L mini-can onsite.

GLS 1x 1.0L can

Atmospheric Analysis & Consulting, Inc.

CLIENT	: PG&E Environmental Services
PROJECT NAME	: Natural Gas Sampling
AAC PROJECT NO.	: 212336
REPORT DATE	: 12/21/2021

On December 10th, 2021, Atmospheric Analysis & Consulting, Inc. received one (1) 1.0-Liter Silonite Canister for Total Reduced Sulfur analysis by ASTM D-5504. Upon receipt, the sample was assigned a unique Laboratory ID number as follows:

Client ID	Lab No.	Return Pressure (mmHg)
CPP-GS-DEC-A	212336-26388	684.1

This analysis is performed in accordance with AAC's Quality Manual. Test results apply to the samples as received. For detailed information pertaining to specific EPA, NCASI, ASTM and SCAQMD accreditations (Methods & Analytes), please visit our website at www.aaclab.com.

I certify that this data is technically accurate, complete, and in compliance with the terms and conditions of the contract. No problems were encountered during receiving, preparation, and/or analysis of this sample. The Technical Director or his/her designee, as verified by the following signature, has authorized release of the data.

If you have any questions or require further explanation of data results, please contact the undersigned.

Sucha Parmar, Ph.D.
Technical Director

This report consists of 5 pages.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Atmospheric Analysis & Consulting, Inc

LABORATORY ANALYSIS REPORT

CLIENT : PG&E Environmental Services
PROJECT NO. : 212336
MATRIX : AIR
UNITS : ppmV

SAMPLING DATE : 12/07/2021
RECEIVING DATE : 12/10/2021
ANALYSIS DATE : 12/13/2021
REPORT DATE : 12/21/2021

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	CPP-GS-DEC-A
AAC ID	212336-26388
Canister Dil. Fac.	2.2
Analyte	Result
Hydrogen Sulfide	**0.546**
COS / SO2	**0.677**
Methyl Mercaptan	**0.134**
Ethyl Mercaptan	< 0.112
Dimethyl Sulfide	< 0.112
Carbon-Disulfide	< 0.112
Isopropyl Mercaptan	< 0.112
tert-Butyl Mercaptan	**0.569**
n-Propyl Mercaptan	< 0.112
Methylethylsulfide	< 0.112
sec-Butyl Mercaptan / Thiophene	< 0.112
iso-Butyl Mercaptan	< 0.112
Diethyl Sulfide	< 0.112
n-Butyl Mercaptan	< 0.112
Dimethyl Disulfide	< 0.112
2-Methylthiophene	< 0.112
3-Methylthiophene	< 0.112
Tetrahydrothiophene	**0.770**
Bromothiophene	< 0.112
Thiophenol	< 0.112
Diethyl Disulfide	< 0.112
Total Unidentified Sulfur	< 0.112
Total Reduced Sulfurs	**2.02**
Total Sulfurs	**2.70**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Atmospheric Analysis & Consulting, Inc

LABORATORY ANALYSIS REPORT

CLIENT : PG&E Environmental Services
PROJECT NO. : 212336
MATRIX : AIR
UNITS : grains/100 dscf

SAMPLING DATE : 12/07/2021
RECEIVING DATE : 12/10/2021
ANALYSIS DATE : 12/13/2021
REPORT DATE : 12/21/2021

Total Reduced Sulfur Compounds Analysis by ASTM D-5504

Client ID	CPP-GS-DEC-A
AAC ID	212336-26388
Canister Dil. Fac.	2.2
Analyte	Result
Hydrogen Sulfide	**0.0332**
COS / SO2	**0.0412**
Methyl Mercaptan	**0.0082**
Ethyl Mercaptan	< 0.00681
Dimethyl Sulfide	< 0.00681
Carbon Disulfide	< 0.00681
Isopropyl Mercaptan	< 0.00681
tert-Butyl Mercaptan	**0.0346**
n-Propyl Mercaptan	< 0.00681
Methylethylsulfide	< 0.00681
sec-Butyl Mercaptan / Thiophene	< 0.00681
iso-Butyl Mercaptan	< 0.00681
Diethyl Sulfide	< 0.00681
n-Butyl Mercaptan	< 0.00681
Dimethyl Disulfide	< 0.00681
2-Methylthiophene	< 0.00681
3-Methylthiophene	< 0.00681
Tetrahydrothiophene	**0.0469**
Bromothiophene	< 0.00681
Thiophenol	< 0.00681
Diethyl Disulfide	< 0.00681
Total Unidentified Sulfur	< 0.00681
Total Reduced Sulfurs	**0.123**
Total Sulfurs	**0.164**

All unidentified compound's concentrations expressed in terms of H_2S (TRS does not include COS and SO_2)
Sample Reporting Limit (SRL) is equal to Reporting Limit x Canister Dil. Fac. x Analysis Dil. Fac.

2225 Sperry Ave., Ventura, CA 93003 www.aaclab.com (805) 650-1642

Quality Control/Quality Assurance Report
ASTM D-5504

Date Analyzed: 12/13/2021
Analyst: DL
Units: ppbV

Instrument ID: SCD#10
Calb. Date: 12/8/2021

Opening Calibration Verification Standard

519.8 ppbV H2S (SS1289)

H_2S	Resp. (area)	Result	% Rec *	% RPD ****
Initial	2903	509	97.9	0.4
Duplicate	2939	515	99.2	0.9
Triplicate	2900	509	97.8	0.5

527.0 ppbV H2S (SS1289)

MeSH	Resp. (area)	Result	% Rec *	% RPD ****
Initial	3588	543	103.0	3.2
Duplicate	3363	509	96.5	3.3
Triplicate	3479	526	99.9	0.1

522.0 ppbV H2S (SS1289)

DMS	Resp. (area)	Result	% Rec *	% RPD ****
Initial	3977	528	101.1	1.3
Duplicate	3873	514	98.4	1.3
Triplicate	3925	521	99.7	0.0

Method Blank

Analyte	Result
H_2S	<PQL
MeSH	<PQL
DMS	<PQL

Duplicate Analysis **Sample ID** 212124-25443

Analyte	Sample Result	Duplicate Result	Mean	% RPD ***
H_2S	<PQL	<PQL	0.0	0.0
MeSH	<PQL	<PQL	0.0	0.0
DMS	<PQL	<PQL	0.0	0.0

Matrix Spike & Duplicate **Sample ID** 212124-25443 x10

Analyte	Sample Conc.	Spike Added	MS Result	MSD Result	MS % Rec **	MSD % Rec **	% RPD ***
H_2S	<PQL	259.9	245.7	252.5	94.5	97.2	2.7
MeSH	<PQL	263.5	252.5	267.9	95.8	101.7	5.9
DMS	<PQL	261.0	264.0	268.6	101.2	102.9	1.7

Closing Calibration Verification Standard

Analyte	Std. Conc.	Result	% Rec **
H_2S	519.8	518.7	99.8
MeSH	527.0	515.5	97.8
DMS	522.0	516.9	99.0

** Must be 95-105%, ** Must be 90-110%, *** Must be < 10%, **** Must be < 5% RPD from Mean result.*

H2S: PQL = 10.5 ppbV, MDL = 1.12 ppbV
MeSH: PQL = 10.5 ppbV, MDL = 1.12 ppbV
DMS: PQL = 11.0 ppbV, MDL = 1.12 ppbV

2225 Sperry Ave., Ventura, CA 93003
www.aaclab.com
(805) 650-1642

212336

Colusa Fuel Gas Sampling

Client: PG&E Environmental Services		Project Manager: Surinder Sidhu		Date: 12/8/21
Address: 3400 Crow Canyon Road		Telephone Number: 925-866-5245	Email: SKSG@pge.com	Laboratory: AAC Labs
City: San Ramon	State: CA	Zip: 94583	Site Contacat	Laboratory Phone: 805-650-1642
Project Number/Name: Natural Gas Sampling			Sampler: Steve North 925-785-3039	Laboratory Fax
Contract Number, PO Number		Laboratory Contact: Eric Grosjean - 1534 Eastman Ave. Suite A Ventura CA 93003		

PG&E Sample ID	SAM#-ID#	Date	Time	Sample Type	Containers: Volume	Containers: Type	Containers: No.	Preservative	Condition on Receipt/Comments	Preparation and Analysis: Sulfur ASTM D-5504
CPP-GS- DEC - A	26388	12/7/21	1315	Gas	1 liter	cyl	1	None		X

Special Instruction:

Email results to Surinder Sidhu (SKSG@PGE.COM) , Evan Cavalli (EMCM@PGE.COM), A.J. Gomez (AJGU@PGE.COM)

Turn Around Time Required	QC Level	Project Specific Requirements (Specify)
☑ Normal ☐ Rush ☐ Other	☑ I. ☐ II. ☐ III.	

1. Relinquished By: Steve North (via GSO)	Date: 12/8/21	Time: 1200	1. Received By	Date	Time
2. Relinquished By	Date	Time	2. Received By	Date	Time
3. Relinquished By	Date	Time	3. Received By	Date: 12/10/21	Time: 1611

Comments

Sample collected in 3L Tedlar bag and immediately field transferred to evacuated 1L mini-can onsite.

12 1.0L Can

ATTACHMENT 3
40 CFR 60 Section KKKK

FCD: AQ-13
Title V: #8, 9, 25, 25, 30

40 CFR 60 KKKK Emission Limits:

Natural Gas Fired Combustion Turbine > 850 MMBtu

15 ppmvdc @ 15% O_2; 4 Hour Rolling Average

During Normal Operations

96 ppmvdc @ 15% O_2; 4 Hour Rolling Average

Turbines operating at less than 75% of Peak Load (Startup/Shutdown)

KKKK Compliance (Colusa Generating Station)

40 CFR Part 60 Subpart KKKK applies to all stationary gas turbines rated at greater than or equal to 10 MMBtu/hr that commence construction, modification, or reconstruction after February 18, 2005. The gas turbines involved in this project have a rating of 1612 MMBtu/hr and were installed after February 18, 2005, therefore, this subpart applies.

Compliance with the applicable provisions of NSPS KKKK are summarized below. Specific data to support the compliance determinations listed below are included as attachments. The non-applicable portions of KKKK are not listed in the compliance summary:

Section	Requirement	Compliance Status
60.4305	CGS Turbines/HRSGs rated at larger than 10 MMBtu/hr and construction commenced after February 18, 2005. Subpart KKKK applies.	IN COMPLIANCE
60.4310	No exemptions apply.	No exemptions apply.
60.4315	Pollutants regulated under Subpart KKKK: NO_x and SO_2.	IN COMPLIANCE
60.4320	NOx emissions limit: 15 ppmv @15% O_2	IN COMPLIANCE
60.4330	SO_2 emissions limit: 0.90 lbs SO_2/MWh (gross output), or cannot burn any fuel which contains total potential sulfur emissions in excess of 0.060 lbs SO_2/MMBtu (heat input).	IN COMPLIANCE Based on monthly fuel sampling.
60.4333	Operate turbine/HRSG, APC systems, and monitoring equipment to minimize emissions at all times including during startup, shutdown, and malfunction.	IN COMPLIANCE
60.4340(b)(1)	For units with SCR, install a NO_x CEMS per 60.4335(b) or 60.4345. If Part 75 applies, NO_x can be monitored per Appendix E of Part 75. (CGS QAP applies here)	IN COMPLIANCE CT1 and CT2 utilize SCR and NO_x CEMS per 60.4335(b) or 60.4345. Part 75 applies and NO_x is monitored per Appendix E of Part 75.
60.4345	Meet all CEMS Performance Specs and develop a QA Plan for the CEMS. (CGS QAP applies here)	IN COMPLIANCE
60.4350	All CEMS data must be reduced to hourly averages per 60.13(h). (CGS QAP applies here)	IN COMPLIANCE

60.4355	If applicable, develop and insure all parametric monitoring and monitoring plans comply with this section. (CGS QAP applies here)	IN COMPLIANCE
60.4360	Monitor fuel sulfur content, or invoke exemption per 60.4365.	Exemption per 60.4365
60.4365	Exemption for fuel sulfur monitoring if fuel is demonstrated not to exceed potential sulfur emissions of 0.060 lb SO_2/MMBtu. Use PG&E gas quality data to show that exemption applies per 60.4365 (a) or (b).	IN COMPLIANCE Pipeline quality natural gas used with sulfur content less than 0.30 gr/100 SCF (0.0008 lb/MMBtu as SO_2). Annual compliance based on PG&E supplied fuel analysis data. See Attachment 2.
60.4375	Submit excess emissions reports per 60.7(c). Within 30 days following the end of each 6 month period (see 60.4395).	IN COMPLIANCE
60.4380(b)	Determine excess emissions and monitor downtime per (b) (1-3)	IN COMPLIANCE See Attachment 4.
60.4400	Initial and annual NO_X performance tests not required if CEMS used per 60.4340(b)(1)	IN COMPLIANCE NO_x CEMs used per 60.4340(b)(1). NO_x, CO, and VOC tested annually.
60.4415	Perform initial SO_2 performance test per 60.4415 (2) or (3). This test must be conducted even if the 60.4365 exemption is invoked.	IN COMPLIANCE Initial SO_2 source test performed in 2010; results available upon request. Ongoing compliance determined by fuel sampling (60.4415(a)(1)(ii)).

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/01/2021 00:00	1	3
10/01/2021 01:00	1	3
10/01/2021 02:00	1	3
10/01/2021 03:00	1	3
10/01/2021 04:00	0	3
10/01/2021 05:00	1	3
10/01/2021 06:00	1	3
10/01/2021 07:00	1	3
10/01/2021 08:00	1	3
10/01/2021 09:00	1	3
10/01/2021 10:00	1	3
10/01/2021 11:00	1	3
10/01/2021 12:00	1	3
10/01/2021 13:00	1	18
10/01/2021 14:00	1	22
10/01/2021 15:00	1	22
10/01/2021 16:00	1	20
10/01/2021 17:00	1	5
10/01/2021 18:00	1	1
10/01/2021 19:00	1	1
10/01/2021 20:00	1	1
10/01/2021 21:00	1	1
10/01/2021 22:00	1	1
10/01/2021 23:00	1	1
Average/Sum#:	1	6
Minimum:	0	1
Maximum:	1	22
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/02/2021 00:00	0	1
10/02/2021 01:00	0	1
10/02/2021 02:00	0	1
10/02/2021 03:00	0	1
10/02/2021 04:00	0	1
10/02/2021 05:00	0	1
10/02/2021 06:00	0	1
10/02/2021 07:00	0	1
10/02/2021 08:00	0	1
10/02/2021 09:00	1	1
10/02/2021 10:00	1	1
10/02/2021 11:00	1	1
10/02/2021 12:00	1	1
10/02/2021 13:00	1	1
10/02/2021 14:00	1	1
10/02/2021 15:00	1	1
10/02/2021 16:00	1	1
10/02/2021 17:00	1	1
10/02/2021 18:00	1	1
10/02/2021 19:00	1	1
10/02/2021 20:00	1	1
10/02/2021 21:00	1	1
10/02/2021 22:00	1	1
10/02/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	0	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/03/2021 00:00	1	1
10/03/2021 01:00	1	1
10/03/2021 02:00	1	1
10/03/2021 03:00	1	1
10/03/2021 04:00	1	1
10/03/2021 05:00	1	1
10/03/2021 06:00	1	1
10/03/2021 07:00	1	1
10/03/2021 08:00	1	1
10/03/2021 09:00	1	1
10/03/2021 10:00	1	1
10/03/2021 11:00	1	1
10/03/2021 12:00	1	1
10/03/2021 13:00	1	1
10/03/2021 14:00	1	1
10/03/2021 15:00	1	1
10/03/2021 16:00	1	1
10/03/2021 17:00	1	1
10/03/2021 18:00	1	1
10/03/2021 19:00	1	1
10/03/2021 20:00	1	1
10/03/2021 21:00	1	1
10/03/2021 22:00	1	1
10/03/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/04/2021 00:00	1	1
10/04/2021 01:00	1	1
10/04/2021 02:00	1	1
10/04/2021 03:00	1	1
10/04/2021 04:00	1	1
10/04/2021 05:00	1	1
10/04/2021 06:00	1	1
10/04/2021 07:00	1	1
10/04/2021 08:00	1	1
10/04/2021 09:00	1	1
10/04/2021 10:00	1	1
10/04/2021 11:00	1	1
10/04/2021 12:00	1	1
10/04/2021 13:00	1	1
10/04/2021 14:00	1	1
10/04/2021 15:00	1	1
10/04/2021 16:00	1	1
10/04/2021 17:00	1	1
10/04/2021 18:00	1	1
10/04/2021 19:00	1	1
10/04/2021 20:00	1	1
10/04/2021 21:00	1	1
10/04/2021 22:00	1	1
10/04/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/05/2021 00:00	1	1
10/05/2021 01:00	0	1
10/05/2021 02:00	0	1
10/05/2021 03:00	0	1
10/05/2021 04:00	0	1
10/05/2021 05:00	1	1
10/05/2021 06:00	1	1
10/05/2021 07:00	1	1
10/05/2021 08:00	1	1
10/05/2021 09:00	1	1
10/05/2021 10:00	1	1
10/05/2021 11:00	1	1
10/05/2021 12:00	1	1
10/05/2021 13:00	1	1
10/05/2021 14:00	1	1
10/05/2021 15:00	1	1
10/05/2021 16:00	1	1
10/05/2021 17:00	1	1
10/05/2021 18:00	1	1
10/05/2021 19:00	1	1
10/05/2021 20:00	1	1
10/05/2021 21:00	1	1
10/05/2021 22:00	1	1
10/05/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	0	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/06/2021 00:00	1	1
10/06/2021 01:00	1	1
10/06/2021 02:00	1	1
10/06/2021 03:00	1	1
10/06/2021 04:00	1	1
10/06/2021 05:00	1	1
10/06/2021 06:00	1	1
10/06/2021 07:00	1	1
10/06/2021 08:00	1	1
10/06/2021 09:00	1	1
10/06/2021 10:00	1	1
10/06/2021 11:00	1	1
10/06/2021 12:00	1	1
10/06/2021 13:00	1	1
10/06/2021 14:00	1	1
10/06/2021 15:00	1	1
10/06/2021 16:00	1	1
10/06/2021 17:00	1	1
10/06/2021 18:00	1	1
10/06/2021 19:00	1	1
10/06/2021 20:00	1	1
10/06/2021 21:00	1	1
10/06/2021 22:00	1	1
10/06/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/07/2021 00:00	1	1
10/07/2021 01:00	1	1
10/07/2021 02:00	1	1
10/07/2021 03:00	1	1
10/07/2021 04:00	1	1
10/07/2021 05:00	1	1
10/07/2021 06:00	1	1
10/07/2021 07:00	1	1
10/07/2021 08:00	1	1
10/07/2021 09:00	1	1
10/07/2021 10:00	1	1
10/07/2021 11:00	1	1
10/07/2021 12:00	1	1
10/07/2021 13:00	1	1
10/07/2021 14:00	1	1
10/07/2021 15:00	1	1
10/07/2021 16:00	1	1
10/07/2021 17:00	1	1
10/07/2021 18:00	1	1
10/07/2021 19:00	1	1
10/07/2021 20:00	1	1
10/07/2021 21:00	1	1
10/07/2021 22:00	1	1
10/07/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/08/2021 00:00	1	1
10/08/2021 01:00	1	1
10/08/2021 02:00	1	1
10/08/2021 03:00	1	1
10/08/2021 04:00	1	1
10/08/2021 05:00	1	1
10/08/2021 06:00	1	1
10/08/2021 07:00	1	1
10/08/2021 08:00	1	1
10/08/2021 09:00	1	1
10/08/2021 10:00	1	1
10/08/2021 11:00	1	1
10/08/2021 12:00	1	1
10/08/2021 13:00	1	1
10/08/2021 14:00	1	1
10/08/2021 15:00	1	1
10/08/2021 16:00	0	1
10/08/2021 17:00	0	1
10/08/2021 18:00	0	1
10/08/2021 19:00	0	1
10/08/2021 20:00	1	1
10/08/2021 21:00	4	2
10/08/2021 22:00	4	2
10/08/2021 23:00	4	2
Average/Sum#:	1	1
Minimum:	0	1
Maximum:	4	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/09/2021 00:00	4	2
10/09/2021 01:00	4	2
10/09/2021 02:00	4	2
10/09/2021 03:00	4	2
10/09/2021 04:00	4	2
10/09/2021 05:00	4	2
10/09/2021 06:00	4	2
10/09/2021 07:00	4	2
10/09/2021 08:00	4	2
10/09/2021 09:00	4	2
10/09/2021 10:00	4	2
10/09/2021 11:00	4	2
10/09/2021 12:00	4	2
10/09/2021 13:00	4	2
10/09/2021 14:00	4	2
10/09/2021 15:00	4	2
10/09/2021 16:00	4	2
10/09/2021 17:00	4	2
10/09/2021 18:00	4	2
10/09/2021 19:00	4	2
10/09/2021 20:00	4	2
10/09/2021 21:00	4	2
10/09/2021 22:00	4	2
10/09/2021 23:00	4	2
Average/Sum#:	4	2
Minimum:	4	2
Maximum:	4	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/10/2021 00:00	4	2
10/10/2021 01:00	4	2
10/10/2021 02:00	4	2
10/10/2021 03:00	4	2
10/10/2021 04:00	4	2
10/10/2021 05:00	4	2
10/10/2021 06:00	4	2
10/10/2021 07:00	4	2
10/10/2021 08:00	4	2
10/10/2021 09:00	4	2
10/10/2021 10:00	4	2
10/10/2021 11:00	4	2
10/10/2021 12:00	4	2
10/10/2021 13:00	4	2
10/10/2021 14:00	4	2
10/10/2021 15:00	4	2
10/10/2021 16:00	4	2
10/10/2021 17:00	4	2
10/10/2021 18:00	4	2
10/10/2021 19:00	4	2
10/10/2021 20:00	4	2
10/10/2021 21:00	4	2
10/10/2021 22:00	4	2
10/10/2021 23:00	4	2
Average/Sum#:	4	2
Minimum:	4	2
Maximum:	4	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/11/2021 00:00	4	2
10/11/2021 01:00	4	2
10/11/2021 02:00	4	2
10/11/2021 03:00	4	2
10/11/2021 04:00	4	2
10/11/2021 05:00	4	2
10/11/2021 06:00	4	2
10/11/2021 07:00	4	2
10/11/2021 08:00	4	2
10/11/2021 09:00	4	2
10/11/2021 10:00	4	2
10/11/2021 11:00	4	2
10/11/2021 12:00	4	2
10/11/2021 13:00	4	2
10/11/2021 14:00	4	2
10/11/2021 15:00	4	2
10/11/2021 16:00	4	2
10/11/2021 17:00	4	2
10/11/2021 18:00	4	2
10/11/2021 19:00	4	2
10/11/2021 20:00	4	2
10/11/2021 21:00	4	2
10/11/2021 22:00	4	2
10/11/2021 23:00	4	2
Average/Sum#:	4	2
Minimum:	4	2
Maximum:	4	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/12/2021 00:00	4	2
10/12/2021 01:00	4	2
10/12/2021 02:00	4	2
10/12/2021 03:00	4	2
10/12/2021 04:00	4	2
10/12/2021 05:00	4	2
10/12/2021 06:00	4	2
10/12/2021 07:00	4	2
10/12/2021 08:00	4	2
10/12/2021 09:00	4	2
10/12/2021 10:00	4	2
10/12/2021 11:00	4	2
10/12/2021 12:00	4	2
10/12/2021 13:00	4	2
10/12/2021 14:00	4	2
10/12/2021 15:00	4	2
10/12/2021 16:00	4	2
10/12/2021 17:00	4	2
10/12/2021 18:00	4	2
10/12/2021 19:00	4	2
10/12/2021 20:00	4	2
10/12/2021 21:00	4	2
10/12/2021 22:00	4	2
10/12/2021 23:00	4	2
Average/Sum#:	4	2
Minimum:	4	2
Maximum:	4	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/13/2021 00:00	4	2
10/13/2021 01:00	4	2
10/13/2021 02:00	4	2
10/13/2021 03:00	4	2
10/13/2021 04:00	4	2
10/13/2021 05:00	4	2
10/13/2021 06:00	4	2
10/13/2021 07:00	4	2
10/13/2021 08:00	4	2
10/13/2021 09:00	4	2
10/13/2021 10:00	4	2
10/13/2021 11:00	4	2
10/13/2021 12:00	4	2
10/13/2021 13:00	4	2
10/13/2021 14:00	4	2
10/13/2021 15:00	4	2
10/13/2021 16:00	4	2
10/13/2021 17:00	4	2
10/13/2021 18:00	4	2
10/13/2021 19:00	4	2
10/13/2021 20:00	4	2
10/13/2021 21:00	4	2
10/13/2021 22:00	4	2
10/13/2021 23:00	4	2
Average/Sum#:	4	2
Minimum:	4	2
Maximum:	4	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/14/2021 00:00	4	2
10/14/2021 01:00	4	2
10/14/2021 02:00	4	2
10/14/2021 03:00	4	2
10/14/2021 04:00	4	2
10/14/2021 05:00	4	2
10/14/2021 06:00	4	2
10/14/2021 07:00	4	2
10/14/2021 08:00	4	2
10/14/2021 09:00	4	2
10/14/2021 10:00	4	2
10/14/2021 11:00	4	2
10/14/2021 12:00	4	2
10/14/2021 13:00	4	2
10/14/2021 14:00	4	2
10/14/2021 15:00	4	2
10/14/2021 16:00	4	2
10/14/2021 17:00	4	2
10/14/2021 18:00	4	2
10/14/2021 19:00	4	2
10/14/2021 20:00	4	2
10/14/2021 21:00	4	2
10/14/2021 22:00	4	2
10/14/2021 23:00	4	2
Average/Sum#:	4	2
Minimum:	4	2
Maximum:	4	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/15/2021 00:00	4	2
10/15/2021 01:00	4	2
10/15/2021 02:00	4	2
10/15/2021 03:00	4	2
10/15/2021 04:00	4	2
10/15/2021 05:00	4	2
10/15/2021 06:00	4	2
10/15/2021 07:00	4	2
10/15/2021 08:00	4	2
10/15/2021 09:00	4	2
10/15/2021 10:00	4	2
10/15/2021 11:00	4	2
10/15/2021 12:00	4	2
10/15/2021 13:00	4	2
10/15/2021 14:00	4	2
10/15/2021 15:00	4	2
10/15/2021 16:00	4	2
10/15/2021 17:00	4	2
10/15/2021 18:00	4	2
10/15/2021 19:00	4	2
10/15/2021 20:00	4	2
10/15/2021 21:00	4	2
10/15/2021 22:00	4	2
10/15/2021 23:00	4	2
Average/Sum#:	4	2
Minimum:	4	2
Maximum:	4	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/16/2021 00:00	4	2
10/16/2021 01:00	4	2
10/16/2021 02:00	4	2
10/16/2021 03:00	4	2
10/16/2021 04:00	4	2
10/16/2021 05:00	4	2
10/16/2021 06:00	4	2
10/16/2021 07:00	4	2
10/16/2021 08:00	4	2
10/16/2021 09:00	4	2
10/16/2021 10:00	4	2
10/16/2021 11:00	4	2
10/16/2021 12:00	4	2
10/16/2021 13:00	4	2
10/16/2021 14:00	4	2
10/16/2021 15:00	4	2
10/16/2021 16:00	4	2
10/16/2021 17:00	4	2
10/16/2021 18:00	4	2
10/16/2021 19:00	4	2
10/16/2021 20:00	4	2
10/16/2021 21:00	4	2
10/16/2021 22:00	4	2
10/16/2021 23:00	4	2
Average/Sum#:	4	2
Minimum:	4	2
Maximum:	4	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/17/2021 00:00	4	2
10/17/2021 01:00	4	2
10/17/2021 02:00	4	2
10/17/2021 03:00	4	2
10/17/2021 04:00	4	2
10/17/2021 05:00	4	2
10/17/2021 06:00	4	2
10/17/2021 07:00	4	2
10/17/2021 08:00	4	2
10/17/2021 09:00	4	2
10/17/2021 10:00	4	2
10/17/2021 11:00	4	2
10/17/2021 12:00	4	2
10/17/2021 13:00	4	2
10/17/2021 14:00	4	2
10/17/2021 15:00	4	2
10/17/2021 16:00	4	2
10/17/2021 17:00	4	2
10/17/2021 18:00	4	2
10/17/2021 19:00	4	2
10/17/2021 20:00	4	2
10/17/2021 21:00	4	2
10/17/2021 22:00	4	2
10/17/2021 23:00	4	2
Average/Sum#:	4	2
Minimum:	4	2
Maximum:	4	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/18/2021 00:00	4	2
10/18/2021 01:00	4	2
10/18/2021 02:00	4	2
10/18/2021 03:00	4	2
10/18/2021 04:00	4	2
10/18/2021 05:00	4	2
10/18/2021 06:00	4	2
10/18/2021 07:00	4	2
10/18/2021 08:00	4	2
10/18/2021 09:00	4	2
10/18/2021 10:00	4	2
10/18/2021 11:00	4	2
10/18/2021 12:00	4	2
10/18/2021 13:00	4	2
10/18/2021 14:00	4	2
10/18/2021 15:00	4	2
10/18/2021 16:00	4	2
10/18/2021 17:00	4	2
10/18/2021 18:00	4	2
10/18/2021 19:00	4	2
10/18/2021 20:00	4	2
10/18/2021 21:00	4	2
10/18/2021 22:00	4	2
10/18/2021 23:00	4	2
Average/Sum#:	4	2
Minimum:	4	2
Maximum:	4	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/19/2021 00:00	4	2
10/19/2021 01:00	4	2
10/19/2021 02:00	4	2
10/19/2021 03:00	4	2
10/19/2021 04:00	4	2
10/19/2021 05:00	4	2
10/19/2021 06:00	4	2
10/19/2021 07:00	4	2
10/19/2021 08:00	4	2
10/19/2021 09:00	4	2
10/19/2021 10:00	4	2
10/19/2021 11:00	4	2
10/19/2021 12:00	4	2
10/19/2021 13:00	4	2
10/19/2021 14:00	4	2
10/19/2021 15:00	4	2
10/19/2021 16:00	4	2
10/19/2021 17:00	4	2
10/19/2021 18:00	4	2
10/19/2021 19:00	4	2
10/19/2021 20:00	4	2
10/19/2021 21:00	4	2
10/19/2021 22:00	4	2
10/19/2021 23:00	4	2
Average/Sum#:	4	2
Minimum:	4	2
Maximum:	4	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/20/2021 00:00	4	2
10/20/2021 01:00	4	2
10/20/2021 02:00	4	2
10/20/2021 03:00	4	2
10/20/2021 04:00	4	2
10/20/2021 05:00	4	2
10/20/2021 06:00	4	2
10/20/2021 07:00	4	2
10/20/2021 08:00	4	10
10/20/2021 09:00	4	23
10/20/2021 10:00	4	25
10/20/2021 11:00	4	27
10/20/2021 12:00	4	20
10/20/2021 13:00	16	7
10/20/2021 14:00	23	5
10/20/2021 15:00	23	1
10/20/2021 16:00	20	0
10/20/2021 17:00	8	1
10/20/2021 18:00	1	1
10/20/2021 19:00	1	1
10/20/2021 20:00	1	1
10/20/2021 21:00	1	1
10/20/2021 22:00	2	2
10/20/2021 23:00	2	2
Average/Sum#:	6	6
Minimum:	1	0
Maximum:	23	27
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/21/2021 00:00	2	2
10/21/2021 01:00	2	2
10/21/2021 02:00	2	2
10/21/2021 03:00	2	2
10/21/2021 04:00	2	2
10/21/2021 05:00	2	2
10/21/2021 06:00	2	2
10/21/2021 07:00	2	2
10/21/2021 08:00	2	2
10/21/2021 09:00	2	2
10/21/2021 10:00	2	2
10/21/2021 11:00	2	2
10/21/2021 12:00	2	2
10/21/2021 13:00	2	2
10/21/2021 14:00	2	2
10/21/2021 15:00	2	2
10/21/2021 16:00	2	2
10/21/2021 17:00	2	2
10/21/2021 18:00	2	2
10/21/2021 19:00	2	2
10/21/2021 20:00	2	2
10/21/2021 21:00	2	2
10/21/2021 22:00	2	2
10/21/2021 23:00	2	2
Average/Sum#:	2	2
Minimum:	2	2
Maximum:	2	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/22/2021 00:00	2	2
10/22/2021 01:00	2	2
10/22/2021 02:00	2	2
10/22/2021 03:00	2	2
10/22/2021 04:00	2	2
10/22/2021 05:00	2	2
10/22/2021 06:00	2	2
10/22/2021 07:00	2	2
10/22/2021 08:00	2	2
10/22/2021 09:00	2	2
10/22/2021 10:00	2	2
10/22/2021 11:00	2	2
10/22/2021 12:00	2	2
10/22/2021 13:00	2	2
10/22/2021 14:00	2	2
10/22/2021 15:00	2	2
10/22/2021 16:00	2	2
10/22/2021 17:00	2	2
10/22/2021 18:00	2	2
10/22/2021 19:00	2	2
10/22/2021 20:00	2	2
10/22/2021 21:00	2	2
10/22/2021 22:00	2	2
10/22/2021 23:00	2	2
Average/Sum#:	2	2
Minimum:	2	2
Maximum:	2	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/23/2021 00:00	2	2
10/23/2021 01:00	16	2
10/23/2021 02:00	22	2
10/23/2021 03:00	25	2
10/23/2021 04:00	23	2
10/23/2021 05:00	9	8
10/23/2021 06:00	3	18
10/23/2021 07:00	1	19
10/23/2021 08:00	1	18
10/23/2021 09:00	1	11
10/23/2021 10:00	1	1
10/23/2021 11:00	1	0
10/23/2021 12:00	1	0
10/23/2021 13:00	1	0
10/23/2021 14:00	1	0
10/23/2021 15:00	1	0
10/23/2021 16:00	1	0
10/23/2021 17:00	1	1
10/23/2021 18:00	1	1
10/23/2021 19:00	1	1
10/23/2021 20:00	1	1
10/23/2021 21:00	1	1
10/23/2021 22:00	1	1
10/23/2021 23:00	1	1
Average/Sum#:	5	4
Minimum:	1	0
Maximum:	25	19
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/24/2021 00:00	1	1
10/24/2021 01:00	1	1
10/24/2021 02:00	1	1
10/24/2021 03:00	1	1
10/24/2021 04:00	1	3
10/24/2021 05:00	1	3
10/24/2021 06:00	1	3
10/24/2021 07:00	7	2
10/24/2021 08:00	8	0
10/24/2021 09:00	8	0
10/24/2021 10:00	7	0
10/24/2021 11:00	2	0
10/24/2021 12:00	1	0
10/24/2021 13:00	1	0
10/24/2021 14:00	1	0
10/24/2021 15:00	1	0
10/24/2021 16:00	1	0
10/24/2021 17:00	1	1
10/24/2021 18:00	1	1
10/24/2021 19:00	1	1
10/24/2021 20:00	1	1
10/24/2021 21:00	1	1
10/24/2021 22:00	1	1
10/24/2021 23:00	1	1
Average/Sum#:	2	1
Minimum:	1	0
Maximum:	8	3
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/25/2021 00:00	1	1
10/25/2021 01:00	1	1
10/25/2021 02:00	1	1
10/25/2021 03:00	1	1
10/25/2021 04:00	1	1
10/25/2021 05:00	1	3
10/25/2021 06:00	1	4
10/25/2021 07:00	1	4
10/25/2021 08:00	1	4
10/25/2021 09:00	1	1
10/25/2021 10:00	1	1
10/25/2021 11:00	1	1
10/25/2021 12:00	1	1
10/25/2021 13:00	1	1
10/25/2021 14:00	1	1
10/25/2021 15:00	1	1
10/25/2021 16:00	1	1
10/25/2021 17:00	1	1
10/25/2021 18:00	1	1
10/25/2021 19:00	1	1
10/25/2021 20:00	1	1
10/25/2021 21:00	1	1
10/25/2021 22:00	1	1
10/25/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	4
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/26/2021 00:00	1	1
10/26/2021 01:00	1	1
10/26/2021 02:00	1	1
10/26/2021 03:00	1	1
10/26/2021 04:00	1	1
10/26/2021 05:00	1	3
10/26/2021 06:00	1	4
10/26/2021 07:00	1	4
10/26/2021 08:00	1	4
10/26/2021 09:00	0	1
10/26/2021 10:00	0	0
10/26/2021 11:00	0	0
10/26/2021 12:00	1	0
10/26/2021 13:00	1	0
10/26/2021 14:00	1	0
10/26/2021 15:00	1	0
10/26/2021 16:00	1	0
10/26/2021 17:00	1	1
10/26/2021 18:00	1	1
10/26/2021 19:00	1	1
10/26/2021 20:00	1	1
10/26/2021 21:00	1	1
10/26/2021 22:00	1	1
10/26/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	4
%SI	12.50	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/27/2021 00:00	1	1
10/27/2021 01:00	1	1
10/27/2021 02:00	1	0
10/27/2021 03:00	1	0
10/27/2021 04:00	1	0
10/27/2021 05:00	1	0
10/27/2021 06:00	1	0
10/27/2021 07:00	1	0
10/27/2021 08:00	1	1
10/27/2021 09:00	1	1
10/27/2021 10:00	1	1
10/27/2021 11:00	1	0
10/27/2021 12:00	1	0
10/27/2021 13:00	1	0
10/27/2021 14:00	1	0
10/27/2021 15:00	1	0
10/27/2021 16:00	1	1
10/27/2021 17:00	1	1
10/27/2021 18:00	1	1
10/27/2021 19:00	1	1
10/27/2021 20:00	1	1
10/27/2021 21:00	1	1
10/27/2021 22:00	1	1
10/27/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/28/2021 00:00	1	1
10/28/2021 01:00	1	1
10/28/2021 02:00	1	1
10/28/2021 03:00	1	1
10/28/2021 04:00	1	1
10/28/2021 05:00	1	1
10/28/2021 06:00	1	1
10/28/2021 07:00	1	1
10/28/2021 08:00	1	1
10/28/2021 09:00	1	1
10/28/2021 10:00	1	1
10/28/2021 11:00	1	1
10/28/2021 12:00	1	10
10/28/2021 13:00	1	13
10/28/2021 14:00	1	13
10/28/2021 15:00	1	13
10/28/2021 16:00	1	4
10/28/2021 17:00	1	1
10/28/2021 18:00	1	1
10/28/2021 19:00	1	1
10/28/2021 20:00	1	1
10/28/2021 21:00	1	1
10/28/2021 22:00	1	1
10/28/2021 23:00	1	1
Average/Sum#:	1	3
Minimum:	1	1
Maximum:	1	13
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/29/2021 00:00	1	1
10/29/2021 01:00	1	1
10/29/2021 02:00	1	1
10/29/2021 03:00	1	1
10/29/2021 04:00	1	1
10/29/2021 05:00	1	1
10/29/2021 06:00	1	1
10/29/2021 07:00	1	1
10/29/2021 08:00	1	1
10/29/2021 09:00	1	1
10/29/2021 10:00	1	1
10/29/2021 11:00	1	1
10/29/2021 12:00	1	1
10/29/2021 13:00	1	0
10/29/2021 14:00	1	1
10/29/2021 15:00	1	1
10/29/2021 16:00	1	1
10/29/2021 17:00	1	1
10/29/2021 18:00	1	1
10/29/2021 19:00	1	1
10/29/2021 20:00	1	1
10/29/2021 21:00	1	1
10/29/2021 22:00	1	1
10/29/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/30/2021 00:00	1	1
10/30/2021 01:00	1	1
10/30/2021 02:00	1	0
10/30/2021 03:00	1	0
10/30/2021 04:00	1	0
10/30/2021 05:00	1	1
10/30/2021 06:00	1	1
10/30/2021 07:00	1	1
10/30/2021 08:00	1	1
10/30/2021 09:00	1	1
10/30/2021 10:00	1	0
10/30/2021 11:00	1	0
10/30/2021 12:00	1	0
10/30/2021 13:00	1	0
10/30/2021 14:00	1	0
10/30/2021 15:00	1	0
10/30/2021 16:00	1	0
10/30/2021 17:00	1	1
10/30/2021 18:00	1	1
10/30/2021 19:00	1	1
10/30/2021 20:00	1	1
10/30/2021 21:00	1	1
10/30/2021 22:00	1	1
10/30/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
10/31/2021 00:00	1	1
10/31/2021 01:00	1	1
10/31/2021 02:00	1	1
10/31/2021 03:00	1	0
10/31/2021 04:00	1	0
10/31/2021 05:00	1	0
10/31/2021 06:00	1	1
10/31/2021 07:00	1	0
10/31/2021 08:00	1	0
10/31/2021 09:00	1	0
10/31/2021 10:00	1	0
10/31/2021 11:00	1	0
10/31/2021 12:00	1	0
10/31/2021 13:00	1	0
10/31/2021 14:00	1	0
10/31/2021 15:00	1	0
10/31/2021 16:00	1	0
10/31/2021 17:00	1	1
10/31/2021 18:00	1	1
10/31/2021 19:00	1	1
10/31/2021 20:00	1	1
10/31/2021 21:00	1	1
10/31/2021 22:00	1	1
10/31/2021 23:00	1	1
Average/Sum#:	1	0
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/01/2021 00:00	1	1
11/01/2021 01:00	1	1
11/01/2021 02:00	1	1
11/01/2021 03:00	1	1
11/01/2021 04:00	1	1
11/01/2021 05:00	1	1
11/01/2021 06:00	1	1
11/01/2021 07:00	1	1
11/01/2021 08:00	1	1
11/01/2021 09:00	1	1
11/01/2021 10:00	1	1
11/01/2021 11:00	1	1
11/01/2021 12:00	1	1
11/01/2021 13:00	1	1
11/01/2021 14:00	1	1
11/01/2021 15:00	1	1
11/01/2021 16:00	1	1
11/01/2021 17:00	1	1
11/01/2021 18:00	1	1
11/01/2021 19:00	1	1
11/01/2021 20:00	1	1
11/01/2021 21:00	1	1
11/01/2021 22:00	1	1
11/01/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/02/2021 00:00	1	1
11/02/2021 01:00	1	1
11/02/2021 02:00	1	1
11/02/2021 03:00	1	1
11/02/2021 04:00	1	1
11/02/2021 05:00	1	1
11/02/2021 06:00	1	1
11/02/2021 07:00	1	1
11/02/2021 08:00	1	1
11/02/2021 09:00	1	1
11/02/2021 10:00	1	0
11/02/2021 11:00	1	0
11/02/2021 12:00	1	0
11/02/2021 13:00	1	0
11/02/2021 14:00	1	0
11/02/2021 15:00	1	0
11/02/2021 16:00	1	0
11/02/2021 17:00	1	1
11/02/2021 18:00	1	1
11/02/2021 19:00	2	1
11/02/2021 20:00	2	1
11/02/2021 21:00	2	1
11/02/2021 22:00	2	1
11/02/2021 23:00	2	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	2	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/03/2021 00:00	1	1
11/03/2021 01:00	1	1
11/03/2021 02:00	1	1
11/03/2021 03:00	1	1
11/03/2021 04:00	1	1
11/03/2021 05:00	1	1
11/03/2021 06:00	1	1
11/03/2021 07:00	1	1
11/03/2021 08:00	1	1
11/03/2021 09:00	1	1
11/03/2021 10:00	1	0
11/03/2021 11:00	1	0
11/03/2021 12:00	1	0
11/03/2021 13:00	1	0
11/03/2021 14:00	1	0
11/03/2021 15:00	1	0
11/03/2021 16:00	1	0
11/03/2021 17:00	1	1
11/03/2021 18:00	1	1
11/03/2021 19:00	1	1
11/03/2021 20:00	1	1
11/03/2021 21:00	1	1
11/03/2021 22:00	1	1
11/03/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/04/2021 00:00	1	1
11/04/2021 01:00	1	1
11/04/2021 02:00	1	1
11/04/2021 03:00	1	1
11/04/2021 04:00	1	1
11/04/2021 05:00	1	1
11/04/2021 06:00	1	1
11/04/2021 07:00	1	1
11/04/2021 08:00	1	1
11/04/2021 09:00	1	1
11/04/2021 10:00	1	0
11/04/2021 11:00	1	0
11/04/2021 12:00	1	0
11/04/2021 13:00	1	0
11/04/2021 14:00	1	0
11/04/2021 15:00	1	0
11/04/2021 16:00	1	0
11/04/2021 17:00	1	1
11/04/2021 18:00	1	1
11/04/2021 19:00	1	1
11/04/2021 20:00	1	1
11/04/2021 21:00	1	1
11/04/2021 22:00	1	1
11/04/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/05/2021 00:00	1	1
11/05/2021 01:00	1	1
11/05/2021 02:00	1	1
11/05/2021 03:00	1	1
11/05/2021 04:00	1	1
11/05/2021 05:00	1	1
11/05/2021 06:00	1	1
11/05/2021 07:00	1	1
11/05/2021 08:00	1	1
11/05/2021 09:00	1	1
11/05/2021 10:00	1	1
11/05/2021 11:00	0	1
11/05/2021 12:00	0	1
11/05/2021 13:00	0	11
11/05/2021 14:00	1	13
11/05/2021 15:00	1	13
11/05/2021 16:00	1	12
11/05/2021 17:00	1	2
11/05/2021 18:00	1	1
11/05/2021 19:00	1	1
11/05/2021 20:00	1	1
11/05/2021 21:00	1	1
11/05/2021 22:00	1	1
11/05/2021 23:00	1	1
Average/Sum#:	1	3
Minimum:	0	1
Maximum:	1	13
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/06/2021 00:00	1	1
11/06/2021 01:00	1	1
11/06/2021 02:00	1	0
11/06/2021 03:00	1	0
11/06/2021 04:00	1	0
11/06/2021 05:00	1	0
11/06/2021 06:00	1	0
11/06/2021 07:00	1	1
11/06/2021 08:00	1	1
11/06/2021 09:00	1	1
11/06/2021 10:00	1	0
11/06/2021 11:00	1	0
11/06/2021 12:00	1	0
11/06/2021 13:00	1	0
11/06/2021 14:00	1	0
11/06/2021 15:00	1	0
11/06/2021 16:00	1	0
11/06/2021 17:00	1	1
11/06/2021 18:00	1	1
11/06/2021 19:00	1	1
11/06/2021 20:00	1	1
11/06/2021 21:00	1	1
11/06/2021 22:00	1	1
11/06/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/07/2021 00:00	1	1
11/07/2021 01:00	1	1
11/07/2021 02:00	1	1
11/07/2021 03:00	1	1
11/07/2021 04:00	1	1
11/07/2021 05:00	1	1
11/07/2021 06:00	1	1
11/07/2021 07:00	1	1
11/07/2021 08:00	1	1
11/07/2021 09:00	1	1
11/07/2021 10:00	1	1
11/07/2021 11:00	1	1
11/07/2021 12:00	1	1
11/07/2021 13:00	1	1
11/07/2021 14:00	1	1
11/07/2021 15:00	1	1
11/07/2021 16:00	1	1
11/07/2021 17:00	1	1
11/07/2021 18:00	1	1
11/07/2021 19:00	1	1
11/07/2021 20:00	1	1
11/07/2021 21:00	1	1
11/07/2021 22:00	1	1
11/07/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/08/2021 00:00	1	1
11/08/2021 01:00	1	1
11/08/2021 02:00	1	1
11/08/2021 03:00	1	1
11/08/2021 04:00	1	1
11/08/2021 05:00	1	1
11/08/2021 06:00	1	1
11/08/2021 07:00	1	1
11/08/2021 08:00	1	1
11/08/2021 09:00	1	1
11/08/2021 10:00	1	1
11/08/2021 11:00	1	1
11/08/2021 12:00	1	14
11/08/2021 13:00	1	20
11/08/2021 14:00	1	24
11/08/2021 15:00	1	23
11/08/2021 16:00	1	13
11/08/2021 17:00	1	6
11/08/2021 18:00	1	1
11/08/2021 19:00	1	1
11/08/2021 20:00	1	1
11/08/2021 21:00	1	1
11/08/2021 22:00	1	1
11/08/2021 23:00	1	1
Average/Sum#:	1	5
Minimum:	1	1
Maximum:	1	24
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/09/2021 00:00	1	1
11/09/2021 01:00	1	1
11/09/2021 02:00	1	1
11/09/2021 03:00	1	3
11/09/2021 04:00	1	4
11/09/2021 05:00	1	4
11/09/2021 06:00	1	3
11/09/2021 07:00	14	2
11/09/2021 08:00	16	0
11/09/2021 09:00	16	0
11/09/2021 10:00	16	0
11/09/2021 11:00	3	0
11/09/2021 12:00	1	0
11/09/2021 13:00	1	0
11/09/2021 14:00	1	0
11/09/2021 15:00	1	0
11/09/2021 16:00	1	0
11/09/2021 17:00	1	0
11/09/2021 18:00	1	0
11/09/2021 19:00	1	1
11/09/2021 20:00	1	1
11/09/2021 21:00	1	1
11/09/2021 22:00	1	1
11/09/2021 23:00	1	1
Average/Sum#:	4	1
Minimum:	1	0
Maximum:	16	4
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/10/2021 00:00	1	1
11/10/2021 01:00	1	1
11/10/2021 02:00	1	1
11/10/2021 03:00	1	1
11/10/2021 04:00	1	1
11/10/2021 05:00	1	0
11/10/2021 06:00	1	0
11/10/2021 07:00	1	1
11/10/2021 08:00	1	1
11/10/2021 09:00	1	0
11/10/2021 10:00	1	0
11/10/2021 11:00	1	0
11/10/2021 12:00	1	0
11/10/2021 13:00	1	0
11/10/2021 14:00	1	0
11/10/2021 15:00	1	0
11/10/2021 16:00	1	0
11/10/2021 17:00	1	1
11/10/2021 18:00	1	1
11/10/2021 19:00	1	1
11/10/2021 20:00	1	1
11/10/2021 21:00	1	1
11/10/2021 22:00	1	1
11/10/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/11/2021 00:00	1	1
11/11/2021 01:00	2	2
11/11/2021 02:00	2	2
11/11/2021 03:00	2	2
11/11/2021 04:00	2	2
11/11/2021 05:00	2	2
11/11/2021 06:00	2	2
11/11/2021 07:00	2	2
11/11/2021 08:00	2	2
11/11/2021 09:00	12	2
11/11/2021 10:00	16	2
11/11/2021 11:00	16	2
11/11/2021 12:00	15	2
11/11/2021 13:00	5	13
11/11/2021 14:00	1	16
11/11/2021 15:00	1	16
11/11/2021 16:00	1	15
11/11/2021 17:00	1	3
11/11/2021 18:00	1	1
11/11/2021 19:00	1	1
11/11/2021 20:00	1	1
11/11/2021 21:00	1	1
11/11/2021 22:00	1	1
11/11/2021 23:00	1	1
Average/Sum#:	4	4
Minimum:	1	1
Maximum:	16	16
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/12/2021 00:00	1	1
11/12/2021 01:00	1	1
11/12/2021 02:00	1	0
11/12/2021 03:00	1	0
11/12/2021 04:00	1	0
11/12/2021 05:00	1	0
11/12/2021 06:00	1	1
11/12/2021 07:00	1	1
11/12/2021 08:00	1	1
11/12/2021 09:00	1	1
11/12/2021 10:00	1	1
11/12/2021 11:00	1	1
11/12/2021 12:00	1	1
11/12/2021 13:00	1	1
11/12/2021 14:00	1	1
11/12/2021 15:00	1	6
11/12/2021 16:00	1	8
11/12/2021 17:00	1	8
11/12/2021 18:00	1	7
11/12/2021 19:00	1	2
11/12/2021 20:00	1	1
11/12/2021 21:00	1	1
11/12/2021 22:00	1	1
11/12/2021 23:00	1	1
Average/Sum#:	1	2
Minimum:	1	0
Maximum:	1	8
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/13/2021 00:00	1	1
11/13/2021 01:00	1	1
11/13/2021 02:00	1	1
11/13/2021 03:00	1	1
11/13/2021 04:00	1	1
11/13/2021 05:00	1	1
11/13/2021 06:00	1	1
11/13/2021 07:00	1	1
11/13/2021 08:00	9	1
11/13/2021 09:00	11	1
11/13/2021 10:00	11	1
11/13/2021 11:00	11	1
11/13/2021 12:00	3	1
11/13/2021 13:00	1	10
11/13/2021 14:00	1	11
11/13/2021 15:00	1	11
11/13/2021 16:00	1	10
11/13/2021 17:00	1	2
11/13/2021 18:00	1	1
11/13/2021 19:00	1	1
11/13/2021 20:00	1	1
11/13/2021 21:00	1	1
11/13/2021 22:00	1	1
11/13/2021 23:00	1	1
Average/Sum#:	3	3
Minimum:	1	1
Maximum:	11	11
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/14/2021 00:00	1	1
11/14/2021 01:00	1	1
11/14/2021 02:00	1	1
11/14/2021 03:00	1	1
11/14/2021 04:00	1	1
11/14/2021 05:00	1	1
11/14/2021 06:00	1	1
11/14/2021 07:00	1	1
11/14/2021 08:00	1	1
11/14/2021 09:00	8	1
11/14/2021 10:00	15	1
11/14/2021 11:00	16	1
11/14/2021 12:00	16	1
11/14/2021 13:00	9	1
11/14/2021 14:00	2	8
11/14/2021 15:00	1	14
11/14/2021 16:00	1	14
11/14/2021 17:00	1	14
11/14/2021 18:00	1	7
11/14/2021 19:00	1	1
11/14/2021 20:00	1	1
11/14/2021 21:00	1	1
11/14/2021 22:00	1	1
11/14/2021 23:00	1	1
Average/Sum#:	4	3
Minimum:	1	1
Maximum:	16	14
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/15/2021 00:00	1	1
11/15/2021 01:00	1	1
11/15/2021 02:00	1	1
11/15/2021 03:00	1	1
11/15/2021 04:00	1	1
11/15/2021 05:00	1	1
11/15/2021 06:00	1	1
11/15/2021 07:00	1	8
11/15/2021 08:00	1	10
11/15/2021 09:00	1	10
11/15/2021 10:00	1	10
11/15/2021 11:00	1	3
11/15/2021 12:00	1	0
11/15/2021 13:00	1	1
11/15/2021 14:00	1	1
11/15/2021 15:00	1	1
11/15/2021 16:00	1	1
11/15/2021 17:00	1	1
11/15/2021 18:00	1	1
11/15/2021 19:00	1	1
11/15/2021 20:00	1	1
11/15/2021 21:00	1	1
11/15/2021 22:00	1	1
11/15/2021 23:00	1	1
Average/Sum#:	1	2
Minimum:	1	0
Maximum:	1	10
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/16/2021 00:00	2	2
11/16/2021 01:00	2	2
11/16/2021 02:00	2	2
11/16/2021 03:00	2	2
11/16/2021 04:00	2	2
11/16/2021 05:00	2	2
11/16/2021 06:00	2	2
11/16/2021 07:00	2	2
11/16/2021 08:00	11	2
11/16/2021 09:00	14	2
11/16/2021 10:00	14	2
11/16/2021 11:00	14	2
11/16/2021 12:00	4	2
11/16/2021 13:00	1	8
11/16/2021 14:00	1	16
11/16/2021 15:00	1	17
11/16/2021 16:00	1	16
11/16/2021 17:00	1	10
11/16/2021 18:00	1	2
11/16/2021 19:00	1	1
11/16/2021 20:00	1	1
11/16/2021 21:00	1	1
11/16/2021 22:00	1	1
11/16/2021 23:00	1	1
Average/Sum#:	4	4
Minimum:	1	1
Maximum:	14	17
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/17/2021 00:00	1	1
11/17/2021 01:00	1	1
11/17/2021 02:00	1	1
11/17/2021 03:00	1	1
11/17/2021 04:00	1	1
11/17/2021 05:00	1	1
11/17/2021 06:00	1	1
11/17/2021 07:00	1	1
11/17/2021 08:00	1	1
11/17/2021 09:00	1	1
11/17/2021 10:00	1	1
11/17/2021 11:00	1	1
11/17/2021 12:00	1	1
11/17/2021 13:00	1	1
11/17/2021 14:00	1	1
11/17/2021 15:00	1	1
11/17/2021 16:00	1	1
11/17/2021 17:00	1	1
11/17/2021 18:00	1	1
11/17/2021 19:00	1	1
11/17/2021 20:00	1	1
11/17/2021 21:00	1	1
11/17/2021 22:00	1	1
11/17/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/18/2021 00:00	1	1
11/18/2021 01:00	1	1
11/18/2021 02:00	1	1
11/18/2021 03:00	1	1
11/18/2021 04:00	1	1
11/18/2021 05:00	1	1
11/18/2021 06:00	1	1
11/18/2021 07:00	1	1
11/18/2021 08:00	1	1
11/18/2021 09:00	1	1
11/18/2021 10:00	1	1
11/18/2021 11:00	1	1
11/18/2021 12:00	1	1
11/18/2021 13:00	1	1
11/18/2021 14:00	1	1
11/18/2021 15:00	1	1
11/18/2021 16:00	1	1
11/18/2021 17:00	1	1
11/18/2021 18:00	1	1
11/18/2021 19:00	1	1
11/18/2021 20:00	1	1
11/18/2021 21:00	1	1
11/18/2021 22:00	1	1
11/18/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/19/2021 00:00	1	1
11/19/2021 01:00	1	1
11/19/2021 02:00	1	1
11/19/2021 03:00	1	1
11/19/2021 04:00	1	1
11/19/2021 05:00	1	1
11/19/2021 06:00	1	1
11/19/2021 07:00	1	1
11/19/2021 08:00	1	1
11/19/2021 09:00	1	1
11/19/2021 10:00	1	1
11/19/2021 11:00	1	1
11/19/2021 12:00	1	1
11/19/2021 13:00	1	1
11/19/2021 14:00	1	1
11/19/2021 15:00	1	1
11/19/2021 16:00	1	1
11/19/2021 17:00	1	1
11/19/2021 18:00	1	1
11/19/2021 19:00	1	1
11/19/2021 20:00	1	1
11/19/2021 21:00	1	1
11/19/2021 22:00	1	1
11/19/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/20/2021 00:00	1	1
11/20/2021 01:00	1	1
11/20/2021 02:00	1	1
11/20/2021 03:00	1	0
11/20/2021 04:00	1	0
11/20/2021 05:00	1	0
11/20/2021 06:00	1	1
11/20/2021 07:00	1	1
11/20/2021 08:00	1	1
11/20/2021 09:00	1	0
11/20/2021 10:00	1	0
11/20/2021 11:00	1	0
11/20/2021 12:00	1	0
11/20/2021 13:00	1	0
11/20/2021 14:00	1	0
11/20/2021 15:00	1	0
11/20/2021 16:00	1	1
11/20/2021 17:00	1	1
11/20/2021 18:00	1	1
11/20/2021 19:00	1	1
11/20/2021 20:00	1	1
11/20/2021 21:00	1	1
11/20/2021 22:00	1	1
11/20/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/21/2021 00:00	1	1
11/21/2021 01:00	1	1
11/21/2021 02:00	1	1
11/21/2021 03:00	1	1
11/21/2021 04:00	1	1
11/21/2021 05:00	1	1
11/21/2021 06:00	1	1
11/21/2021 07:00	1	1
11/21/2021 08:00	1	1
11/21/2021 09:00	1	1
11/21/2021 10:00	11	1
11/21/2021 11:00	16	1
11/21/2021 12:00	16	1
11/21/2021 13:00	15	1
11/21/2021 14:00	6	14
11/21/2021 15:00	1	18
11/21/2021 16:00	1	18
11/21/2021 17:00	1	18
11/21/2021 18:00	1	5
11/21/2021 19:00	1	1
11/21/2021 20:00	1	1
11/21/2021 21:00	1	1
11/21/2021 22:00	1	1
11/21/2021 23:00	1	1
Average/Sum#:	3	4
Minimum:	1	1
Maximum:	16	18
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/22/2021 00:00	1	1
11/22/2021 01:00	1	1
11/22/2021 02:00	1	1
11/22/2021 03:00	1	1
11/22/2021 04:00	1	1
11/22/2021 05:00	1	1
11/22/2021 06:00	1	1
11/22/2021 07:00	1	1
11/22/2021 08:00	1	1
11/22/2021 09:00	1	1
11/22/2021 10:00	1	1
11/22/2021 11:00	1	1
11/22/2021 12:00	1	11
11/22/2021 13:00	1	13
11/22/2021 14:00	1	13
11/22/2021 15:00	1	13
11/22/2021 16:00	1	3
11/22/2021 17:00	1	1
11/22/2021 18:00	1	1
11/22/2021 19:00	1	1
11/22/2021 20:00	1	1
11/22/2021 21:00	1	1
11/22/2021 22:00	1	1
11/22/2021 23:00	1	1
Average/Sum#:	1	3
Minimum:	1	1
Maximum:	1	13
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/23/2021 00:00	1	1
11/23/2021 01:00	1	1
11/23/2021 02:00	1	1
11/23/2021 03:00	1	1
11/23/2021 04:00	1	0
11/23/2021 05:00	1	1
11/23/2021 06:00	1	1
11/23/2021 07:00	1	1
11/23/2021 08:00	1	1
11/23/2021 09:00	1	1
11/23/2021 10:00	1	1
11/23/2021 11:00	1	0
11/23/2021 12:00	1	0
11/23/2021 13:00	1	0
11/23/2021 14:00	1	0
11/23/2021 15:00	1	0
11/23/2021 16:00	1	1
11/23/2021 17:00	1	1
11/23/2021 18:00	1	1
11/23/2021 19:00	1	1
11/23/2021 20:00	1	1
11/23/2021 21:00	1	1
11/23/2021 22:00	1	1
11/23/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/24/2021 00:00	1	1
11/24/2021 01:00	1	1
11/24/2021 02:00	1	1
11/24/2021 03:00	1	1
11/24/2021 04:00	1	1
11/24/2021 05:00	1	1
11/24/2021 06:00	1	1
11/24/2021 07:00	1	1
11/24/2021 08:00	1	1
11/24/2021 09:00	1	1
11/24/2021 10:00	1	1
11/24/2021 11:00	1	0
11/24/2021 12:00	1	0
11/24/2021 13:00	1	0
11/24/2021 14:00	1	0
11/24/2021 15:00	1	0
11/24/2021 16:00	1	1
11/24/2021 17:00	1	1
11/24/2021 18:00	1	1
11/24/2021 19:00	1	1
11/24/2021 20:00	1	1
11/24/2021 21:00	1	1
11/24/2021 22:00	1	1
11/24/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/25/2021 00:00	2	2
11/25/2021 01:00	2	2
11/25/2021 02:00	2	2
11/25/2021 03:00	2	2
11/25/2021 04:00	2	2
11/25/2021 05:00	2	2
11/25/2021 06:00	2	2
11/25/2021 07:00	2	2
11/25/2021 08:00	2	2
11/25/2021 09:00	2	2
11/25/2021 10:00	2	2
11/25/2021 11:00	2	2
11/25/2021 12:00	2	2
11/25/2021 13:00	2	2
11/25/2021 14:00	2	2
11/25/2021 15:00	2	2
11/25/2021 16:00	2	2
11/25/2021 17:00	2	2
11/25/2021 18:00	2	2
11/25/2021 19:00	2	2
11/25/2021 20:00	2	2
11/25/2021 21:00	2	2
11/25/2021 22:00	2	2
11/25/2021 23:00	2	2
Average/Sum#:	2	2
Minimum:	2	2
Maximum:	2	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/26/2021 00:00	2	2
11/26/2021 01:00	2	2
11/26/2021 02:00	2	2
11/26/2021 03:00	2	2
11/26/2021 04:00	2	2
11/26/2021 05:00	2	2
11/26/2021 06:00	2	2
11/26/2021 07:00	2	2
11/26/2021 08:00	2	2
11/26/2021 09:00	2	2
11/26/2021 10:00	2	2
11/26/2021 11:00	2	2
11/26/2021 12:00	2	2
11/26/2021 13:00	2	2
11/26/2021 14:00	2	2
11/26/2021 15:00	2	2
11/26/2021 16:00	2	2
11/26/2021 17:00	2	2
11/26/2021 18:00	2	2
11/26/2021 19:00	2	2
11/26/2021 20:00	2	2
11/26/2021 21:00	2	2
11/26/2021 22:00	2	2
11/26/2021 23:00	2	2
Average/Sum#:	2	2
Minimum:	2	2
Maximum:	2	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/27/2021 00:00	2	2
11/27/2021 01:00	2	2
11/27/2021 02:00	2	2
11/27/2021 03:00	2	2
11/27/2021 04:00	2	2
11/27/2021 05:00	2	2
11/27/2021 06:00	2	2
11/27/2021 07:00	2	2
11/27/2021 08:00	2	2
11/27/2021 09:00	2	2
11/27/2021 10:00	2	2
11/27/2021 11:00	2	2
11/27/2021 12:00	2	2
11/27/2021 13:00	2	2
11/27/2021 14:00	2	2
11/27/2021 15:00	2	2
11/27/2021 16:00	2	2
11/27/2021 17:00	2	2
11/27/2021 18:00	2	2
11/27/2021 19:00	2	2
11/27/2021 20:00	2	2
11/27/2021 21:00	2	2
11/27/2021 22:00	2	2
11/27/2021 23:00	2	2
Average/Sum#:	2	2
Minimum:	2	2
Maximum:	2	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/28/2021 00:00	2	2
11/28/2021 01:00	2	2
11/28/2021 02:00	2	2
11/28/2021 03:00	2	2
11/28/2021 04:00	2	2
11/28/2021 05:00	2	2
11/28/2021 06:00	2	2
11/28/2021 07:00	2	2
11/28/2021 08:00	2	2
11/28/2021 09:00	2	2
11/28/2021 10:00	2	2
11/28/2021 11:00	2	2
11/28/2021 12:00	2	2
11/28/2021 13:00	2	2
11/28/2021 14:00	2	2
11/28/2021 15:00	2	2
11/28/2021 16:00	2	2
11/28/2021 17:00	2	2
11/28/2021 18:00	2	2
11/28/2021 19:00	2	2
11/28/2021 20:00	2	2
11/28/2021 21:00	2	2
11/28/2021 22:00	2	2
11/28/2021 23:00	2	2
Average/Sum#:	2	2
Minimum:	2	2
Maximum:	2	2
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/29/2021 00:00	2	2
11/29/2021 01:00	2	2
11/29/2021 02:00	2	2
11/29/2021 03:00	2	2
11/29/2021 04:00	2	2
11/29/2021 05:00	2	2
11/29/2021 06:00	2	2
11/29/2021 07:00	9	2
11/29/2021 08:00	21	2
11/29/2021 09:00	23	2
11/29/2021 10:00	24	2
11/29/2021 11:00	19	2
11/29/2021 12:00	7	2
11/29/2021 13:00	6	2
11/29/2021 14:00	3	15
11/29/2021 15:00	1	19
11/29/2021 16:00	1	18
11/29/2021 17:00	1	17
11/29/2021 18:00	1	4
11/29/2021 19:00	1	1
11/29/2021 20:00	1	1
11/29/2021 21:00	1	1
11/29/2021 22:00	1	1
11/29/2021 23:00	1	1
Average/Sum#:	6	4
Minimum:	1	1
Maximum:	24	19
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
11/30/2021 00:00	1	1
11/30/2021 01:00	1	1
11/30/2021 02:00	1	1
11/30/2021 03:00	1	1
11/30/2021 04:00	1	1
11/30/2021 05:00	5	1
11/30/2021 06:00	7	1
11/30/2021 07:00	7	1
11/30/2021 08:00	7	12
11/30/2021 09:00	3	15
11/30/2021 10:00	1	15
11/30/2021 11:00	1	14
11/30/2021 12:00	1	3
11/30/2021 13:00	1	1
11/30/2021 14:00	1	1
11/30/2021 15:00	1	1
11/30/2021 16:00	1	1
11/30/2021 17:00	1	1
11/30/2021 18:00	1	1
11/30/2021 19:00	1	1
11/30/2021 20:00	1	1
11/30/2021 21:00	1	1
11/30/2021 22:00	1	1
11/30/2021 23:00	1	1
Average/Sum#:	2	3
Minimum:	1	1
Maximum:	7	15
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/01/2021 00:00	1	1
12/01/2021 01:00	1	1
12/01/2021 02:00	1	1
12/01/2021 03:00	1	1
12/01/2021 04:00	1	0
12/01/2021 05:00	1	1
12/01/2021 06:00	1	1
12/01/2021 07:00	1	1
12/01/2021 08:00	1	1
12/01/2021 09:00	1	1
12/01/2021 10:00	1	1
12/01/2021 11:00	1	1
12/01/2021 12:00	1	1
12/01/2021 13:00	1	1
12/01/2021 14:00	1	1
12/01/2021 15:00	1	1
12/01/2021 16:00	1	1
12/01/2021 17:00	1	1
12/01/2021 18:00	1	1
12/01/2021 19:00	1	1
12/01/2021 20:00	1	1
12/01/2021 21:00	1	1
12/01/2021 22:00	1	1
12/01/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/02/2021 00:00	1	1
12/02/2021 01:00	1	1
12/02/2021 02:00	1	1
12/02/2021 03:00	1	1
12/02/2021 04:00	1	3
12/02/2021 05:00	1	3
12/02/2021 06:00	4	3
12/02/2021 07:00	5	2
12/02/2021 08:00	5	0
12/02/2021 09:00	5	0
12/02/2021 10:00	2	0
12/02/2021 11:00	1	0
12/02/2021 12:00	2	0
12/02/2021 13:00	2	0
12/02/2021 14:00	1	1
12/02/2021 15:00	1	1
12/02/2021 16:00	1	1
12/02/2021 17:00	1	1
12/02/2021 18:00	1	1
12/02/2021 19:00	1	1
12/02/2021 20:00	1	1
12/02/2021 21:00	1	1
12/02/2021 22:00	1	1
12/02/2021 23:00	1	1
Average/Sum#:	2	1
Minimum:	1	0
Maximum:	5	3
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/03/2021 00:00	1	1
12/03/2021 01:00	1	1
12/03/2021 02:00	1	1
12/03/2021 03:00	1	1
12/03/2021 04:00	1	3
12/03/2021 05:00	1	3
12/03/2021 06:00	1	3
12/03/2021 07:00	1	3
12/03/2021 08:00	1	1
12/03/2021 09:00	1	1
12/03/2021 10:00	1	1
12/03/2021 11:00	1	1
12/03/2021 12:00	1	1
12/03/2021 13:00	1	1
12/03/2021 14:00	1	1
12/03/2021 15:00	1	1
12/03/2021 16:00	1	1
12/03/2021 17:00	1	1
12/03/2021 18:00	1	1
12/03/2021 19:00	1	1
12/03/2021 20:00	1	1
12/03/2021 21:00	1	1
12/03/2021 22:00	1	1
12/03/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	3
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/04/2021 00:00	1	1
12/04/2021 01:00	1	1
12/04/2021 02:00	1	1
12/04/2021 03:00	1	1
12/04/2021 04:00	2	1
12/04/2021 05:00	2	2
12/04/2021 06:00	2	3
12/04/2021 07:00	2	4
12/04/2021 08:00	1	4
12/04/2021 09:00	1	3
12/04/2021 10:00	1	1
12/04/2021 11:00	1	1
12/04/2021 12:00	1	1
12/04/2021 13:00	1	1
12/04/2021 14:00	1	1
12/04/2021 15:00	1	1
12/04/2021 16:00	1	2
12/04/2021 17:00	1	2
12/04/2021 18:00	1	2
12/04/2021 19:00	1	2
12/04/2021 20:00	1	1
12/04/2021 21:00	1	1
12/04/2021 22:00	1	1
12/04/2021 23:00	2	1
Average/Sum#:	1	2
Minimum:	1	1
Maximum:	2	4
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/05/2021 00:00	2	1
12/05/2021 01:00	2	1
12/05/2021 02:00	2	1
12/05/2021 03:00	2	1
12/05/2021 04:00	2	1
12/05/2021 05:00	2	1
12/05/2021 06:00	2	1
12/05/2021 07:00	8	1
12/05/2021 08:00	10	1
12/05/2021 09:00	10	1
12/05/2021 10:00	10	1
12/05/2021 11:00	3	1
12/05/2021 12:00	1	1
12/05/2021 13:00	1	12
12/05/2021 14:00	1	15
12/05/2021 15:00	1	15
12/05/2021 16:00	1	15
12/05/2021 17:00	1	4
12/05/2021 18:00	1	1
12/05/2021 19:00	1	1
12/05/2021 20:00	1	1
12/05/2021 21:00	1	1
12/05/2021 22:00	1	1
12/05/2021 23:00	1	1
Average/Sum#:	3	3
Minimum:	1	1
Maximum:	10	15
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/06/2021 00:00	1	1
12/06/2021 01:00	1	1
12/06/2021 02:00	1	1
12/06/2021 03:00	1	1
12/06/2021 04:00	1	1
12/06/2021 05:00	1	1
12/06/2021 06:00	1	1
12/06/2021 07:00	1	1
12/06/2021 08:00	1	1
12/06/2021 09:00	1	1
12/06/2021 10:00	1	1
12/06/2021 11:00	1	1
12/06/2021 12:00	1	1
12/06/2021 13:00	1	1
12/06/2021 14:00	1	1
12/06/2021 15:00	1	1
12/06/2021 16:00	1	1
12/06/2021 17:00	1	1
12/06/2021 18:00	1	1
12/06/2021 19:00	1	1
12/06/2021 20:00	1	1
12/06/2021 21:00	1	1
12/06/2021 22:00	1	1
12/06/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/07/2021 00:00	1	1
12/07/2021 01:00	1	1
12/07/2021 02:00	1	1
12/07/2021 03:00	1	1
12/07/2021 04:00	1	1
12/07/2021 05:00	1	1
12/07/2021 06:00	1	1
12/07/2021 07:00	1	1
12/07/2021 08:00	1	1
12/07/2021 09:00	1	1
12/07/2021 10:00	1	1
12/07/2021 11:00	1	1
12/07/2021 12:00	1	1
12/07/2021 13:00	1	1
12/07/2021 14:00	1	1
12/07/2021 15:00	1	1
12/07/2021 16:00	1	1
12/07/2021 17:00	1	1
12/07/2021 18:00	1	1
12/07/2021 19:00	1	1
12/07/2021 20:00	1	1
12/07/2021 21:00	1	1
12/07/2021 22:00	1	1
12/07/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/08/2021 00:00	1	1
12/08/2021 01:00	1	1
12/08/2021 02:00	1	1
12/08/2021 03:00	1	1
12/08/2021 04:00	1	1
12/08/2021 05:00	1	1
12/08/2021 06:00	1	1
12/08/2021 07:00	1	1
12/08/2021 08:00	1	1
12/08/2021 09:00	1	1
12/08/2021 10:00	1	1
12/08/2021 11:00	1	1
12/08/2021 12:00	1	1
12/08/2021 13:00	1	1
12/08/2021 14:00	1	1
12/08/2021 15:00	1	1
12/08/2021 16:00	1	1
12/08/2021 17:00	1	1
12/08/2021 18:00	1	1
12/08/2021 19:00	1	1
12/08/2021 20:00	1	1
12/08/2021 21:00	1	1
12/08/2021 22:00	1	1
12/08/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/09/2021 00:00	1	1
12/09/2021 01:00	1	1
12/09/2021 02:00	1	1
12/09/2021 03:00	1	1
12/09/2021 04:00	1	1
12/09/2021 05:00	1	1
12/09/2021 06:00	1	1
12/09/2021 07:00	1	1
12/09/2021 08:00	1	1
12/09/2021 09:00	1	1
12/09/2021 10:00	1	1
12/09/2021 11:00	1	1
12/09/2021 12:00	1	1
12/09/2021 13:00	1	1
12/09/2021 14:00	1	1
12/09/2021 15:00	1	1
12/09/2021 16:00	1	1
12/09/2021 17:00	1	1
12/09/2021 18:00	1	1
12/09/2021 19:00	1	1
12/09/2021 20:00	1	1
12/09/2021 21:00	1	1
12/09/2021 22:00	1	1
12/09/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/10/2021 00:00	1	1
12/10/2021 01:00	1	1
12/10/2021 02:00	1	1
12/10/2021 03:00	1	1
12/10/2021 04:00	1	1
12/10/2021 05:00	1	1
12/10/2021 06:00	1	1
12/10/2021 07:00	1	1
12/10/2021 08:00	1	1
12/10/2021 09:00	1	1
12/10/2021 10:00	1	1
12/10/2021 11:00	1	1
12/10/2021 12:00	1	1
12/10/2021 13:00	1	1
12/10/2021 14:00	1	1
12/10/2021 15:00	1	1
12/10/2021 16:00	1	1
12/10/2021 17:00	1	1
12/10/2021 18:00	1	1
12/10/2021 19:00	1	1
12/10/2021 20:00	1	1
12/10/2021 21:00	1	1
12/10/2021 22:00	1	1
12/10/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/11/2021 00:00	1	1
12/11/2021 01:00	1	1
12/11/2021 02:00	1	1
12/11/2021 03:00	1	1
12/11/2021 04:00	1	1
12/11/2021 05:00	1	1
12/11/2021 06:00	1	1
12/11/2021 07:00	1	1
12/11/2021 08:00	1	1
12/11/2021 09:00	1	1
12/11/2021 10:00	1	1
12/11/2021 11:00	1	1
12/11/2021 12:00	1	1
12/11/2021 13:00	1	1
12/11/2021 14:00	1	1
12/11/2021 15:00	1	1
12/11/2021 16:00	1	1
12/11/2021 17:00	1	1
12/11/2021 18:00	1	1
12/11/2021 19:00	1	1
12/11/2021 20:00	1	1
12/11/2021 21:00	1	1
12/11/2021 22:00	1	1
12/11/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/12/2021 00:00	1	1
12/12/2021 01:00	1	1
12/12/2021 02:00	1	1
12/12/2021 03:00	1	1
12/12/2021 04:00	1	1
12/12/2021 05:00	1	1
12/12/2021 06:00	1	1
12/12/2021 07:00	1	1
12/12/2021 08:00	1	1
12/12/2021 09:00	1	1
12/12/2021 10:00	1	1
12/12/2021 11:00	1	1
12/12/2021 12:00	1	1
12/12/2021 13:00	1	1
12/12/2021 14:00	1	1
12/12/2021 15:00	1	1
12/12/2021 16:00	1	1
12/12/2021 17:00	1	1
12/12/2021 18:00	1	1
12/12/2021 19:00	1	1
12/12/2021 20:00	1	1
12/12/2021 21:00	1	1
12/12/2021 22:00	1	1
12/12/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/13/2021 00:00	1	1
12/13/2021 01:00	1	1
12/13/2021 02:00	1	1
12/13/2021 03:00	1	1
12/13/2021 04:00	1	1
12/13/2021 05:00	1	1
12/13/2021 06:00	1	1
12/13/2021 07:00	1	1
12/13/2021 08:00	1	1
12/13/2021 09:00	1	1
12/13/2021 10:00	1	1
12/13/2021 11:00	1	1
12/13/2021 12:00	1	1
12/13/2021 13:00	1	1
12/13/2021 14:00	1	1
12/13/2021 15:00	1	1
12/13/2021 16:00	1	1
12/13/2021 17:00	1	1
12/13/2021 18:00	1	1
12/13/2021 19:00	1	1
12/13/2021 20:00	1	1
12/13/2021 21:00	1	1
12/13/2021 22:00	1	1
12/13/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/14/2021 00:00	1	1
12/14/2021 01:00	1	1
12/14/2021 02:00	1	1
12/14/2021 03:00	1	1
12/14/2021 04:00	1	1
12/14/2021 05:00	1	1
12/14/2021 06:00	1	1
12/14/2021 07:00	1	1
12/14/2021 08:00	1	1
12/14/2021 09:00	1	1
12/14/2021 10:00	1	1
12/14/2021 11:00	1	1
12/14/2021 12:00	1	1
12/14/2021 13:00	1	1
12/14/2021 14:00	1	1
12/14/2021 15:00	1	1
12/14/2021 16:00	1	1
12/14/2021 17:00	1	1
12/14/2021 18:00	1	1
12/14/2021 19:00	1	1
12/14/2021 20:00	1	1
12/14/2021 21:00	1	1
12/14/2021 22:00	1	1
12/14/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/15/2021 00:00	1	1
12/15/2021 01:00	1	1
12/15/2021 02:00	1	1
12/15/2021 03:00	1	1
12/15/2021 04:00	1	1
12/15/2021 05:00	1	1
12/15/2021 06:00	1	1
12/15/2021 07:00	1	1
12/15/2021 08:00	1	1
12/15/2021 09:00	1	1
12/15/2021 10:00	1	1
12/15/2021 11:00	1	1
12/15/2021 12:00	1	1
12/15/2021 13:00	1	1
12/15/2021 14:00	1	1
12/15/2021 15:00	1	1
12/15/2021 16:00	1	1
12/15/2021 17:00	1	1
12/15/2021 18:00	1	1
12/15/2021 19:00	1	1
12/15/2021 20:00	1	1
12/15/2021 21:00	1	1
12/15/2021 22:00	1	1
12/15/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/16/2021 00:00	1	1
12/16/2021 01:00	1	1
12/16/2021 02:00	1	1
12/16/2021 03:00	1	1
12/16/2021 04:00	1	1
12/16/2021 05:00	1	1
12/16/2021 06:00	1	1
12/16/2021 07:00	1	1
12/16/2021 08:00	1	1
12/16/2021 09:00	1	1
12/16/2021 10:00	1	1
12/16/2021 11:00	1	1
12/16/2021 12:00	1	1
12/16/2021 13:00	1	1
12/16/2021 14:00	1	1
12/16/2021 15:00	1	1
12/16/2021 16:00	1	1
12/16/2021 17:00	1	1
12/16/2021 18:00	1	1
12/16/2021 19:00	1	1
12/16/2021 20:00	1	1
12/16/2021 21:00	1	1
12/16/2021 22:00	1	1
12/16/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/17/2021 00:00	1	1
12/17/2021 01:00	1	1
12/17/2021 02:00	1	1
12/17/2021 03:00	1	1
12/17/2021 04:00	1	1
12/17/2021 05:00	1	1
12/17/2021 06:00	1	1
12/17/2021 07:00	1	1
12/17/2021 08:00	1	1
12/17/2021 09:00	1	1
12/17/2021 10:00	1	1
12/17/2021 11:00	1	1
12/17/2021 12:00	1	1
12/17/2021 13:00	1	1
12/17/2021 14:00	1	1
12/17/2021 15:00	1	1
12/17/2021 16:00	1	1
12/17/2021 17:00	1	1
12/17/2021 18:00	1	1
12/17/2021 19:00	1	1
12/17/2021 20:00	1	1
12/17/2021 21:00	1	1
12/17/2021 22:00	1	1
12/17/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/18/2021 00:00	1	1
12/18/2021 01:00	1	1
12/18/2021 02:00	1	1
12/18/2021 03:00	1	1
12/18/2021 04:00	1	1
12/18/2021 05:00	1	1
12/18/2021 06:00	1	1
12/18/2021 07:00	1	1
12/18/2021 08:00	1	1
12/18/2021 09:00	1	1
12/18/2021 10:00	1	1
12/18/2021 11:00	1	1
12/18/2021 12:00	1	1
12/18/2021 13:00	1	1
12/18/2021 14:00	1	1
12/18/2021 15:00	1	1
12/18/2021 16:00	1	1
12/18/2021 17:00	1	1
12/18/2021 18:00	1	1
12/18/2021 19:00	1	1
12/18/2021 20:00	1	1
12/18/2021 21:00	1	1
12/18/2021 22:00	1	1
12/18/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/19/2021 00:00	1	1
12/19/2021 01:00	1	1
12/19/2021 02:00	1	1
12/19/2021 03:00	1	1
12/19/2021 04:00	1	1
12/19/2021 05:00	1	1
12/19/2021 06:00	1	1
12/19/2021 07:00	1	1
12/19/2021 08:00	1	1
12/19/2021 09:00	1	1
12/19/2021 10:00	1	1
12/19/2021 11:00	1	1
12/19/2021 12:00	1	1
12/19/2021 13:00	1	1
12/19/2021 14:00	1	1
12/19/2021 15:00	1	1
12/19/2021 16:00	1	1
12/19/2021 17:00	1	1
12/19/2021 18:00	1	1
12/19/2021 19:00	1	1
12/19/2021 20:00	1	1
12/19/2021 21:00	1	1
12/19/2021 22:00	1	1
12/19/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/20/2021 00:00	1	1
12/20/2021 01:00	1	1
12/20/2021 02:00	1	1
12/20/2021 03:00	1	1
12/20/2021 04:00	1	1
12/20/2021 05:00	1	1
12/20/2021 06:00	1	1
12/20/2021 07:00	1	1
12/20/2021 08:00	1	1
12/20/2021 09:00	1	1
12/20/2021 10:00	1	1
12/20/2021 11:00	1	1
12/20/2021 12:00	1	1
12/20/2021 13:00	1	1
12/20/2021 14:00	1	1
12/20/2021 15:00	1	1
12/20/2021 16:00	1	1
12/20/2021 17:00	1	1
12/20/2021 18:00	1	1
12/20/2021 19:00	1	1
12/20/2021 20:00	1	1
12/20/2021 21:00	1	1
12/20/2021 22:00	1	1
12/20/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/21/2021 00:00	1	1
12/21/2021 01:00	1	1
12/21/2021 02:00	1	1
12/21/2021 03:00	1	1
12/21/2021 04:00	1	1
12/21/2021 05:00	1	1
12/21/2021 06:00	1	1
12/21/2021 07:00	1	1
12/21/2021 08:00	1	1
12/21/2021 09:00	1	1
12/21/2021 10:00	1	1
12/21/2021 11:00	1	1
12/21/2021 12:00	1	1
12/21/2021 13:00	1	1
12/21/2021 14:00	1	1
12/21/2021 15:00	1	1
12/21/2021 16:00	1	1
12/21/2021 17:00	1	1
12/21/2021 18:00	1	1
12/21/2021 19:00	1	1
12/21/2021 20:00	1	1
12/21/2021 21:00	1	1
12/21/2021 22:00	1	1
12/21/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/22/2021 00:00	1	1
12/22/2021 01:00	1	1
12/22/2021 02:00	1	1
12/22/2021 03:00	1	1
12/22/2021 04:00	1	1
12/22/2021 05:00	1	1
12/22/2021 06:00	1	1
12/22/2021 07:00	1	1
12/22/2021 08:00	1	1
12/22/2021 09:00	1	1
12/22/2021 10:00	1	1
12/22/2021 11:00	1	1
12/22/2021 12:00	1	1
12/22/2021 13:00	1	1
12/22/2021 14:00	1	1
12/22/2021 15:00	1	1
12/22/2021 16:00	1	1
12/22/2021 17:00	1	1
12/22/2021 18:00	1	1
12/22/2021 19:00	1	1
12/22/2021 20:00	1	1
12/22/2021 21:00	1	1
12/22/2021 22:00	1	1
12/22/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/23/2021 00:00	1	1
12/23/2021 01:00	1	1
12/23/2021 02:00	1	1
12/23/2021 03:00	1	1
12/23/2021 04:00	1	1
12/23/2021 05:00	1	1
12/23/2021 06:00	1	1
12/23/2021 07:00	1	1
12/23/2021 08:00	1	1
12/23/2021 09:00	1	1
12/23/2021 10:00	1	1
12/23/2021 11:00	1	1
12/23/2021 12:00	1	1
12/23/2021 13:00	1	1
12/23/2021 14:00	1	1
12/23/2021 15:00	1	1
12/23/2021 16:00	1	1
12/23/2021 17:00	1	1
12/23/2021 18:00	1	1
12/23/2021 19:00	1	1
12/23/2021 20:00	1	1
12/23/2021 21:00	1	1
12/23/2021 22:00	1	1
12/23/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/24/2021 00:00	1	1
12/24/2021 01:00	1	1
12/24/2021 02:00	1	1
12/24/2021 03:00	1	1
12/24/2021 04:00	1	1
12/24/2021 05:00	1	1
12/24/2021 06:00	1	1
12/24/2021 07:00	1	1
12/24/2021 08:00	1	1
12/24/2021 09:00	1	1
12/24/2021 10:00	1	1
12/24/2021 11:00	1	1
12/24/2021 12:00	1	1
12/24/2021 13:00	1	1
12/24/2021 14:00	1	1
12/24/2021 15:00	1	1
12/24/2021 16:00	1	1
12/24/2021 17:00	1	1
12/24/2021 18:00	1	1
12/24/2021 19:00	1	1
12/24/2021 20:00	1	1
12/24/2021 21:00	1	1
12/24/2021 22:00	1	1
12/24/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/25/2021 00:00	1	1
12/25/2021 01:00	1	1
12/25/2021 02:00	1	1
12/25/2021 03:00	1	1
12/25/2021 04:00	1	1
12/25/2021 05:00	1	1
12/25/2021 06:00	1	1
12/25/2021 07:00	1	1
12/25/2021 08:00	1	1
12/25/2021 09:00	1	1
12/25/2021 10:00	1	1
12/25/2021 11:00	1	1
12/25/2021 12:00	1	1
12/25/2021 13:00	1	1
12/25/2021 14:00	1	1
12/25/2021 15:00	1	1
12/25/2021 16:00	1	1
12/25/2021 17:00	1	1
12/25/2021 18:00	1	1
12/25/2021 19:00	1	1
12/25/2021 20:00	1	1
12/25/2021 21:00	1	1
12/25/2021 22:00	1	1
12/25/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/26/2021 00:00	1	1
12/26/2021 01:00	1	1
12/26/2021 02:00	1	1
12/26/2021 03:00	1	1
12/26/2021 04:00	1	1
12/26/2021 05:00	1	1
12/26/2021 06:00	1	1
12/26/2021 07:00	1	1
12/26/2021 08:00	1	1
12/26/2021 09:00	1	1
12/26/2021 10:00	4	1
12/26/2021 11:00	12	1
12/26/2021 12:00	15	1
12/26/2021 13:00	15	1
12/26/2021 14:00	12	1
12/26/2021 15:00	4	9
12/26/2021 16:00	1	16
12/26/2021 17:00	1	16
12/26/2021 18:00	1	15
12/26/2021 19:00	1	8
12/26/2021 20:00	1	1
12/26/2021 21:00	1	1
12/26/2021 22:00	1	1
12/26/2021 23:00	1	1
Average/Sum#:	3	3
Minimum:	1	1
Maximum:	15	16
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/27/2021 00:00	1	1
12/27/2021 01:00	1	1
12/27/2021 02:00	1	1
12/27/2021 03:00	1	1
12/27/2021 04:00	1	1
12/27/2021 05:00	1	1
12/27/2021 06:00	1	1
12/27/2021 07:00	1	1
12/27/2021 08:00	1	1
12/27/2021 09:00	1	1
12/27/2021 10:00	1	1
12/27/2021 11:00	1	1
12/27/2021 12:00	1	1
12/27/2021 13:00	1	1
12/27/2021 14:00	1	1
12/27/2021 15:00	1	1
12/27/2021 16:00	1	1
12/27/2021 17:00	1	1
12/27/2021 18:00	1	1
12/27/2021 19:00	1	1
12/27/2021 20:00	1	1
12/27/2021 21:00	1	1
12/27/2021 22:00	1	1
12/27/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/28/2021 00:00	1	1
12/28/2021 01:00	1	1
12/28/2021 02:00	1	1
12/28/2021 03:00	1	1
12/28/2021 04:00	1	1
12/28/2021 05:00	1	1
12/28/2021 06:00	1	1
12/28/2021 07:00	1	1
12/28/2021 08:00	1	1
12/28/2021 09:00	1	1
12/28/2021 10:00	1	1
12/28/2021 11:00	1	1
12/28/2021 12:00	1	1
12/28/2021 13:00	1	1
12/28/2021 14:00	1	1
12/28/2021 15:00	1	1
12/28/2021 16:00	1	1
12/28/2021 17:00	1	1
12/28/2021 18:00	1	1
12/28/2021 19:00	1	1
12/28/2021 20:00	1	1
12/28/2021 21:00	1	1
12/28/2021 22:00	1	1
12/28/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/29/2021 00:00	1	1
12/29/2021 01:00	1	1
12/29/2021 02:00	1	1
12/29/2021 03:00	1	1
12/29/2021 04:00	1	1
12/29/2021 05:00	1	1
12/29/2021 06:00	1	1
12/29/2021 07:00	1	1
12/29/2021 08:00	1	1
12/29/2021 09:00	1	1
12/29/2021 10:00	1	1
12/29/2021 11:00	1	1
12/29/2021 12:00	1	1
12/29/2021 13:00	1	1
12/29/2021 14:00	1	1
12/29/2021 15:00	1	1
12/29/2021 16:00	1	1
12/29/2021 17:00	1	1
12/29/2021 18:00	1	1
12/29/2021 19:00	1	1
12/29/2021 20:00	1	1
12/29/2021 21:00	1	1
12/29/2021 22:00	1	1
12/29/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/30/2021 00:00	1	1
12/30/2021 01:00	1	1
12/30/2021 02:00	1	1
12/30/2021 03:00	1	1
12/30/2021 04:00	1	1
12/30/2021 05:00	1	1
12/30/2021 06:00	1	1
12/30/2021 07:00	1	1
12/30/2021 08:00	1	1
12/30/2021 09:00	1	1
12/30/2021 10:00	1	1
12/30/2021 11:00	1	1
12/30/2021 12:00	1	1
12/30/2021 13:00	1	1
12/30/2021 14:00	1	1
12/30/2021 15:00	1	1
12/30/2021 16:00	1	1
12/30/2021 17:00	1	1
12/30/2021 18:00	1	1
12/30/2021 19:00	1	1
12/30/2021 20:00	1	1
12/30/2021 21:00	1	1
12/30/2021 22:00	1	1
12/30/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 06:56 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
12/31/2021 00:00	1	1
12/31/2021 01:00	1	1
12/31/2021 02:00	1	1
12/31/2021 03:00	1	1
12/31/2021 04:00	1	1
12/31/2021 05:00	1	1
12/31/2021 06:00	1	1
12/31/2021 07:00	1	1
12/31/2021 08:00	1	1
12/31/2021 09:00	1	1
12/31/2021 10:00	1	1
12/31/2021 11:00	1	1
12/31/2021 12:00	1	1
12/31/2021 13:00	1	1
12/31/2021 14:00	1	1
12/31/2021 15:00	1	1
12/31/2021 16:00	1	1
12/31/2021 17:00	1	1
12/31/2021 18:00	1	1
12/31/2021 19:00	1	1
12/31/2021 20:00	1	1
12/31/2021 21:00	1	1
12/31/2021 22:00	1	1
12/31/2021 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0.00	0.00

Excess Emission Report

CT1 NOx 30 Day Rolling Average (KKKK)

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 06:58 **Location:** Maxwell, CA

Tag Name: CT1_NOx_30D_Ppmvdc_1D
Total Operating Time: 74.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 18.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**74.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 NOx 30 Day Rolling Average (KKKK)

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 06:59 **Location:** Maxwell, CA

Tag Name: CT2_NOx_30D_Ppmvdc_1D
Total Operating Time: 75.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 17.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**75.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 4
Excess Emission/Downtime Report

FCD: AQ-4
Title V: #29

EDS-CMS Reports

EDS/CMS Summary Report

CT1 - CO LbPerHr

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59
Generated: 01/10/2022 07:00

Facility Name: COLUSA GENERATING STATION
Location: Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_CO_LbPerHr_1H
EDS Data from: CT1_CONormalOp_LbPerHr_1H
Emission Limitation: CT1_COLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,647.00 Hour(s)
Operating time for CMS: 1,647.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	3
e. Unknown causes	1
2. Total CMS Downtime	4
3. Total Downtime as a percentage of operating time	0.24
4. Total Availability as a percentage of operating time	99.76

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT1 - CO Ppmvdc

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 07:03 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_CO_Ppmvdc_1H
EDS Data from: CT1_CO_3Hr_Ppmvdc_1H
Emission Limitation: CT1_COLimit_3Hr_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,647.00 Hour(s)
Operating time for CMS: 1,647.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	1
d. Other known causes	3
e. Unknown causes	0
2. Total CMS Downtime	4
3. Total Downtime as a percentage of operating time	0.24
4. Total Availability as a percentage of operating time	99.76

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT1 - NOx LbPerHr

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 07:04 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_NOx_LbPerHr_1H
EDS Data from: CT1_NOxNormalOp_LbPerHr_1H
Emission Limitation: CT1_NOxLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,647.00 Hour(s)
Operating time for CMS: 1,647.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	1
d. Other known causes	3
e. Unknown causes	0
2. Total CMS Downtime	4
3. Total Downtime as a percentage of operating time	0.24
4. Total Availability as a percentage of operating time	99.76

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT1 - NOx Ppmvdc

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 07:04 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_NOx_Ppmvdc_1H
EDS Data from: CT1_NOx_Ppmvdc_1H
Emission Limitation: CT1_NOxLimit_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,647.00 Hour(s)
Operating time for CMS: 1,647.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	1
d. Other known causes	3
e. Unknown causes	0
2. Total CMS Downtime	4
3. Total Downtime as a percentage of operating time	0.24
4. Total Availability as a percentage of operating time	99.76

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - CO LbPerHr

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59
Generated: 01/10/2022 07:05

Facility Name: COLUSA GENERATING STATION
Location: Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_CO_LbPerHr_1H
EDS Data from: CT2_CONormalOp_LbPerHr_1H
Emission Limitation: CT2_COLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,549.00 Hour(s)
Operating time for CMS: 1,549.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	1
d. Other known causes	1
e. Unknown causes	0
2. Total CMS Downtime	2
3. Total Downtime as a percentage of operating time	0.13
4. Total Availability as a percentage of operating time	99.87

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - CO Ppmvdc

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59
Generated: 01/10/2022 07:05

Facility Name: COLUSA GENERATING STATION
Location: Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_CO_Ppmvdc_1H
EDS Data from: CT2_CO_3Hr_Ppmvdc_1H
Emission Limitation: CT2_COLimit_3Hr_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,549.00 Hour(s)
Operating time for CMS: 1,549.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	1
d. Other known causes	1
e. Unknown causes	0
2. Total CMS Downtime	2
3. Total Downtime as a percentage of operating time	0.13
4. Total Availability as a percentage of operating time	99.87

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - NOx LbPerHr

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59
Generated: 01/10/2022 07:06

Facility Name: COLUSA GENERATING STATION
Location: Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_NOx_LbPerHr_1H
EDS Data from: CT2_NOxNormalOp_LbPerHr_1H
Emission Limitation: CT2_NOxLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,549.00 Hour(s)
Operating time for CMS: 1,549.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	1
d. Other known causes	1
e. Unknown causes	0
2. Total CMS Downtime	2
3. Total Downtime as a percentage of operating time	0.13
4. Total Availability as a percentage of operating time	99.87

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - NOx Ppmvdc

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59
Generated: 01/10/2022 07:06

Facility Name: COLUSA GENERATING STATION
Location: Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_NOx_Ppmvdc_1H
EDS Data from: CT2_NOx_Ppmvdc_1H
Emission Limitation: CT2_NOxLimit_Ppmvdc_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Process Unit(s) Description:

Operating time for EDS: 1,549.00 Hour(s)
Operating time for CMS: 1,549.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	1
d. Other known causes	1
e. Unknown causes	0
2. Total CMS Downtime	2
3. Total Downtime as a percentage of operating time	0.13
4. Total Availability as a percentage of operating time	99.87

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

Excess Emission Report

CT1 - CO LbPerHr Normal Operating 1-Hour Block Average

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 07:07 **Location:** Maxwell, CA

Tag Name: CT1_CONormalOp_LbPerHr_1H
Total Operating Time: 1,647.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 561.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,647.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - CO Ppmvdc 3-Hour Rolling Average

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 07:08 **Location:** Maxwell, CA

Tag Name: CT1_CO_3Hr_Ppmvdc_1H
Total Operating Time: 1,647.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 561.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,647.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - NOx LbPerHr Normal Operating 1-Hour Block Average

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 07:09 **Location:** Maxwell, CA

Tag Name: CT1_NOxNormalOp_LbPerHr_1H
Total Operating Time: 1,647.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 561.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,647.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - NOx Ppmvdc 1-Hour Block Average

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 07:10 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Ppmvdc_1H
Total Operating Time: 1,647.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 561.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,647.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - CO LbPerHr Normal Operating 1-Hour Block Average

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 07:14 **Location:** Maxwell, CA

Tag Name: CT2_CONormalOp_LbPerHr_1H
Total Operating Time: 1,549.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 659.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,549.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - CO LbPerHr Normal Operating 1-Hour Block Average

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 07:15 **Location:** Maxwell, CA

Tag Name: CT2_CONormalOp_LbPerHr_1H
Total Operating Time: 1,549.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 659.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,549.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NOx LbPerHr Normal Operating 1-Hour Block Average

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 07:16 **Location:** Maxwell, CA

Tag Name: CT2_NOxNormalOp_LbPerHr_1H
Total Operating Time: 1,549.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 659.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,549.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NOx Ppmvdc 1-Hour Block Average

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 07:18 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Ppmvdc_1H
Total Operating Time: 1,549.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 659.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,549.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Invalid Data Report

CT1 - Stack CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 07:30 **Location:** Maxwell, CA

Tag Name: CT1_CO_LbPerHr_1H
Total Operating Time: 1,647.00 Hour(s)
Non-Operating Time: 561.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	10/26/2021 08:00	10/26/2021 09:59	2	4 - Other known causes	8 - Quarterly Maintenance
2	11/05/2021 09:00	11/05/2021 09:59	1		
3	12/02/2021 14:00	12/02/2021 14:59	1	9 - CEMS failed calibration	3 - Performed manual calibration

Total Operating Time:	**1,647.00 Hour(s)**
Total Monitor Downtime (Online only):	**4.00 Hour(s)**
Percent Monitor Availability:	**99.76 %**
Percent Monitor Downtime:	**0.24 %**

Report Code	Type	Text	Duration	Duration Percent
9	Reason	CEMS failed calibration	1	25.00
4	Reason	Other known causes	2	50.00
3	Action	Performed manual calibration	1	25.00
8	Action	Quarterly Maintenance	2	50.00

Invalid Data Report

CT1 - Stack NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 07:31 **Location:** Maxwell, CA

Tag Name: CT1_NOx_LbPerHr_1H
Total Operating Time: 1,647.00 Hour(s)
Non-Operating Time: 561.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	10/26/2021 08:00	10/26/2021 09:59	2	4 - Other known causes	8 - Quarterly Maintenance
2	11/05/2021 09:00	11/05/2021 09:59	1	3 - Quality assurance calibration	4 - Quarterly linearity/cga
3	12/02/2021 14:00	12/02/2021 14:59	1	9 - CEMS failed calibration	3 - Performed manual calibration

Total Operating Time:	**1,647.00 Hour(s)**
Total Monitor Downtime (Online only):	**4.00 Hour(s)**
Percent Monitor Availability:	**99.76 %**
Percent Monitor Downtime:	**0.24 %**

Report Code	Type	Text	Duration	Duration Percent
9	Reason	CEMS failed calibration	1	25.00
4	Reason	Other known causes	2	50.00
3	Reason	Quality assurance calibration	1	25.00
3	Action	Performed manual calibration	1	25.00
4	Action	Quarterly linearity/cga	1	25.00
8	Action	Quarterly Maintenance	2	50.00

Invalid Data Report

CT2 - Stack CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 07:48 **Location:** Maxwell, CA

Tag Name: CT2_CO_LbPerHr_1H
Total Operating Time: 1,549.00 Hour(s)
Non-Operating Time: 659.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	10/26/2021 11:00	10/26/2021 11:59	1	4 - Other known causes	8 - Quarterly Maintenance
2	11/08/2021 16:00	11/08/2021 16:59	1	3 - Quality assurance calibration	4 - Quarterly linearity/cga

Total Operating Time:	**1,549.00 Hour(s)**
Total Monitor Downtime (Online only):	**2.00 Hour(s)**
Percent Monitor Availability:	**99.87 %**
Percent Monitor Downtime:	**0.13 %**

Report Code	Type	Text	Duration	Duration Percent
4	Reason	Other known causes	1	50.00
3	Reason	Quality assurance calibration	1	50.00
4	Action	Quarterly linearity/cga	1	50.00
8	Action	Quarterly Maintenance	1	50.00

Invalid Data Report

CT2 - Stack NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 07:49 **Location:** Maxwell, CA

Tag Name: CT2_NOx_LbPerHr_1H
Total Operating Time: 1,549.00 Hour(s)
Non-Operating Time: 659.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	10/26/2021 11:00	10/26/2021 11:59	1	4 - Other known causes	8 - Quarterly Maintenance
2	11/08/2021 16:00	11/08/2021 16:59	1	3 - Quality assurance calibration	4 - Quarterly linearity/cga

Total Operating Time:	**1,549.00 Hour(s)**
Total Monitor Downtime (Online only):	**2.00 Hour(s)**
Percent Monitor Availability:	**99.87 %**
Percent Monitor Downtime:	**0.13 %**

Report Code	Type	Text	Duration	Duration Percent
4	Reason	Other known causes	1	50.00
3	Reason	Quality assurance calibration	1	50.00
4	Action	Quarterly linearity/cga	1	50.00
8	Action	Quarterly Maintenance	1	50.00

ATTACHMENT 5
Hourly Emissions – VOC

FCD: AQ-14
Title V: #6

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/01/2021 00:00	0.3	14.0	1,526.8	0.4	1.1	1	1	0
10/01/2021 01:00	0.4	14.0	1,537.0	0.4	1.1	1	1	0
10/01/2021 02:00	0.4	14.0	1,534.3	0.4	1.1	1	1	0
10/01/2021 03:00	0.4	14.0	1,535.7	0.4	1.1	1	1	0
10/01/2021 04:00	0.4	14.0	1,526.8	0.4	1.1	1	1	1
10/01/2021 05:00	-1.4	12.8	2,010.3	-0.8	1.4	1	1	1
10/01/2021 06:00	-0.8	13.1	1,721.5	-0.5	1.2	1	1	1
10/01/2021 07:00	0.4	14.0	1,438.0	0.4	1.0	1	1	0
10/01/2021 08:00	0.4	14.0	1,354.6	0.4	0.9	1	1	0
10/01/2021 09:00	0.4	14.0	1,355.6	0.4	0.9	1	1	0
10/01/2021 10:00	0.4	14.1	1,360.0	0.4	1.0	1	1	0
10/01/2021 11:00	0.4	14.1	1,365.7	0.4	1.0	1	1	0
10/01/2021 12:00	0.4	14.1	1,380.7	0.4	1.0	1	1	0
10/01/2021 13:00	0.4	13.9	1,726.7	0.4	1.2	1	1	0
10/01/2021 14:00	0.3	13.9	1,546.2	0.4	1.1	1	1	0
10/01/2021 15:00	0.4	13.9	1,720.8	0.4	1.2	1	1	0
10/01/2021 16:00	0.4	13.9	1,704.1	0.4	1.2	1	1	0
10/01/2021 17:00	0.3	13.7	1,786.8	0.4	1.3	1	1	0
10/01/2021 18:00	0.3	13.7	1,778.8	0.4	1.2	1	1	0
10/01/2021 19:00	0.3	13.9	1,702.4	0.4	1.2	1	1	0
10/01/2021 20:00	0.3	13.9	1,684.2	0.4	1.2	1	1	0
10/01/2021 21:00	0.3	13.9	1,663.3	0.4	1.2	1	1	0
10/01/2021 22:00	0.4	14.0	1,677.1	0.4	1.2	1	1	0
10/01/2021 23:00	0.4	14.0	1,683.2	0.4	1.2	1	1	0
Average/Sum#:	0.2	13.9	1,596.7	0.3	1.1	24 #	24 #	3 #
Minimum:	-1.4	12.8	1,354.6	-0.8	0.9	1	1	0
Maximum:	0.4	14.1	2,010.3	0.4	1.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/02/2021 00:00	0.4	14.0	1,688.8	0.4	1.2	1	1	0
10/02/2021 01:00	0.4	14.0	1,676.6	0.4	1.2	1	1	0
10/02/2021 02:00	0.4	14.0	1,537.6	0.4	1.1	1	1	0
10/02/2021 03:00	0.4	14.0	1,662.8	0.4	1.2	1	1	0
10/02/2021 04:00	0.4	14.0	1,678.6	0.4	1.2	1	1	0
10/02/2021 05:00	0.4	14.0	1,670.9	0.4	1.2	1	1	0
10/02/2021 06:00	0.4	14.0	1,637.2	0.4	1.1	1	1	0
10/02/2021 07:00	0.4	14.0	1,460.7	0.4	1.0	1	1	0
10/02/2021 08:00	0.4	14.0	1,347.5	0.4	0.9	1	1	0
10/02/2021 09:00	0.4	14.1	1,312.8	0.4	0.9	1	1	0
10/02/2021 10:00	0.4	14.1	1,288.4	0.4	0.9	1	1	0
10/02/2021 11:00	0.4	14.1	1,287.0	0.4	0.9	1	1	0
10/02/2021 12:00	0.4	14.1	1,301.1	0.4	0.9	1	1	0
10/02/2021 13:00	0.4	14.1	1,371.0	0.4	1.0	1	1	0
10/02/2021 14:00	0.4	13.9	1,658.4	0.4	1.2	1	1	0
10/02/2021 15:00	0.4	13.9	1,702.1	0.4	1.2	1	1	0
10/02/2021 16:00	0.3	13.9	1,624.5	0.4	1.1	1	1	0
10/02/2021 17:00	0.3	13.7	1,754.0	0.4	1.2	1	1	0
10/02/2021 18:00	0.3	13.7	1,777.0	0.4	1.2	1	1	0
10/02/2021 19:00	0.3	13.9	1,699.2	0.4	1.2	1	1	0
10/02/2021 20:00	0.3	13.9	1,672.1	0.4	1.2	1	1	0
10/02/2021 21:00	0.3	13.9	1,690.3	0.4	1.2	1	1	0
10/02/2021 22:00	0.3	13.9	1,691.0	0.4	1.2	1	1	0
10/02/2021 23:00	0.4	13.9	1,683.8	0.4	1.2	1	1	0
Average/Sum#:	0.4	14.0	1,578.1	0.4	1.1	24 #	24 #	0 #
Minimum:	0.3	13.7	1,287.0	0.4	0.9	1	1	0
Maximum:	0.4	14.1	1,777.0	0.4	1.2	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/03/2021 00:00	0.4	14.0	1,629.9	0.4	1.1	1	1	0
10/03/2021 01:00	0.4	14.0	1,574.6	0.4	1.1	1	1	0
10/03/2021 02:00	0.4	14.0	1,453.7	0.4	1.0	1	1	0
10/03/2021 03:00	0.4	14.0	1,416.3	0.4	1.0	1	1	0
10/03/2021 04:00	0.4	14.0	1,468.2	0.4	1.0	1	1	0
10/03/2021 05:00	0.4	14.0	1,454.1	0.4	1.0	1	1	0
10/03/2021 06:00	0.4	14.0	1,458.1	0.4	1.0	1	1	0
10/03/2021 07:00	0.4	14.1	1,291.6	0.4	0.9	1	1	0
10/03/2021 08:00	0.4	14.0	1,354.3	0.4	0.9	1	1	0
10/03/2021 09:00	0.4	14.1	1,292.2	0.4	0.9	1	1	0
10/03/2021 10:00	0.4	14.1	1,286.3	0.4	0.9	1	1	0
10/03/2021 11:00	0.4	14.1	1,346.5	0.4	0.9	1	1	0
10/03/2021 12:00	0.4	14.1	1,415.3	0.4	1.0	1	1	0
10/03/2021 13:00	0.4	13.9	1,612.2	0.4	1.1	1	1	0
10/03/2021 14:00	0.3	13.9	1,683.0	0.4	1.2	1	1	0
10/03/2021 15:00	0.3	13.9	1,689.1	0.4	1.2	1	1	0
10/03/2021 16:00	0.3	13.9	1,605.8	0.4	1.1	1	1	0
10/03/2021 17:00	0.3	14.0	1,424.8	0.4	1.0	1	1	0
10/03/2021 18:00	0.3	13.8	1,743.3	0.4	1.2	1	1	0
10/03/2021 19:00	0.3	13.9	1,640.0	0.4	1.1	1	1	0
10/03/2021 20:00	0.3	13.9	1,680.5	0.4	1.2	1	1	0
10/03/2021 21:00	0.3	13.9	1,628.0	0.4	1.1	1	1	0
10/03/2021 22:00	0.3	13.9	1,669.1	0.4	1.2	1	1	0
10/03/2021 23:00	0.3	13.9	1,686.4	0.4	1.2	1	1	0
Average/Sum#:	0.4	14.0	1,521.0	0.4	1.1	24 #	24 #	0 #
Minimum:	0.3	13.8	1,286.3	0.4	0.9	1	1	0
Maximum:	0.4	14.1	1,743.3	0.4	1.2	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/04/2021 00:00	0.3	13.9	1,666.2	0.4	1.2	1	1	0
10/04/2021 01:00	0.2	13.9	1,539.0	0.3	1.1	1	1	0
10/04/2021 02:00	0.2	13.9	1,551.2	0.3	1.1	1	1	0
10/04/2021 03:00	0.3	13.9	1,618.2	0.4	1.1	1	1	0
10/04/2021 04:00	0.3	13.9	1,667.7	0.4	1.2	1	1	0
10/04/2021 05:00	0.3	13.9	1,683.0	0.4	1.2	1	1	0
10/04/2021 06:00	0.3	13.9	1,637.9	0.4	1.1	1	1	0
10/04/2021 07:00	0.4	14.0	1,601.9	0.4	1.1	1	1	0
10/04/2021 08:00	0.3	13.9	1,614.7	0.4	1.1	1	1	0
10/04/2021 09:00	0.4	14.0	1,594.3	0.4	1.1	1	1	0
10/04/2021 10:00	0.3	13.9	1,547.3	0.4	1.1	1	1	0
10/04/2021 11:00	0.3	13.9	1,635.6	0.4	1.1	1	1	0
10/04/2021 12:00	0.3	13.9	1,658.7	0.4	1.2	1	1	0
10/04/2021 13:00	0.3	13.9	1,614.0	0.4	1.1	1	1	0
10/04/2021 14:00	0.3	13.9	1,691.2	0.4	1.2	1	1	0
10/04/2021 15:00	0.3	13.9	1,630.2	0.4	1.1	1	1	0
10/04/2021 16:00	0.3	13.8	1,757.8	0.4	1.2	1	1	0
10/04/2021 17:00	0.3	13.7	1,776.3	0.4	1.2	1	1	0
10/04/2021 18:00	0.3	13.7	1,772.6	0.4	1.2	1	1	0
10/04/2021 19:00	0.3	13.8	1,750.7	0.4	1.2	1	1	0
10/04/2021 20:00	0.3	13.7	1,750.3	0.4	1.2	1	1	0
10/04/2021 21:00	0.3	13.8	1,747.7	0.4	1.2	1	1	0
10/04/2021 22:00	0.3	13.9	1,586.4	0.4	1.1	1	1	0
10/04/2021 23:00	0.4	14.0	1,597.6	0.4	1.1	1	1	0
Average/Sum#:	0.3	13.9	1,653.8	0.4	1.1	24 #	24 #	0 #
Minimum:	0.2	13.7	1,539.0	0.3	1.1	1	1	0
Maximum:	0.4	14.0	1,776.3	0.4	1.2	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/05/2021 00:00	0.4	14.0	1,554.4	0.4	1.1	1	1	0
10/05/2021 01:00	0.4	14.0	1,538.6	0.4	1.1	1	1	0
10/05/2021 02:00	0.3	14.0	1,524.7	0.4	1.1	1	1	0
10/05/2021 03:00	0.4	13.9	1,617.1	0.4	1.1	1	1	0
10/05/2021 04:00	0.3	13.9	1,577.3	0.4	1.1	1	1	0
10/05/2021 05:00	0.3	13.8	1,673.6	0.4	1.2	1	1	0
10/05/2021 06:00	0.2	13.9	1,680.8	0.3	1.2	1	1	0
10/05/2021 07:00	0.2	13.9	1,633.4	0.3	1.1	1	1	0
10/05/2021 08:00	0.2	13.9	1,599.9	0.3	1.1	1	1	0
10/05/2021 09:00	0.2	13.9	1,643.1	0.3	1.2	1	1	0
10/05/2021 10:00	0.3	13.9	1,661.0	0.4	1.2	1	1	0
10/05/2021 11:00	0.4	14.0	1,641.0	0.4	1.1	1	1	0
10/05/2021 12:00	0.4	13.9	1,711.2	0.4	1.2	1	1	0
10/05/2021 13:00	0.4	13.9	1,661.7	0.4	1.2	1	1	0
10/05/2021 14:00	0.3	13.9	1,640.2	0.4	1.1	1	1	0
10/05/2021 15:00	0.3	13.9	1,684.1	0.4	1.2	1	1	0
10/05/2021 16:00	0.3	13.9	1,673.1	0.4	1.2	1	1	0
10/05/2021 17:00	0.3	13.9	1,632.6	0.4	1.1	1	1	0
10/05/2021 18:00	0.3	13.9	1,626.2	0.4	1.1	1	1	0
10/05/2021 19:00	0.3	13.9	1,681.5	0.4	1.2	1	1	0
10/05/2021 20:00	0.2	13.9	1,590.7	0.3	1.1	1	1	0
10/05/2021 21:00	0.3	14.0	1,507.9	0.4	1.1	1	1	0
10/05/2021 22:00	0.4	14.0	1,636.5	0.4	1.1	1	1	0
10/05/2021 23:00	0.3	14.0	1,410.5	0.4	1.0	1	1	0
Average/Sum#:	0.3	13.9	1,616.7	0.4	1.1	24 #	24 #	0 #
Minimum:	0.2	13.8	1,410.5	0.3	1.0	1	1	0
Maximum:	0.4	14.0	1,711.2	0.4	1.2	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/06/2021 00:00	0.1	14.0	1,295.0	0.2	0.9	1	1	0
10/06/2021 01:00	0.1	14.0	1,294.9	0.2	0.9	1	1	0
10/06/2021 02:00	0.1	14.0	1,295.2	0.1	0.9	1	1	0
10/06/2021 03:00	0.1	14.0	1,295.5	0.1	0.9	1	1	0
10/06/2021 04:00	0.1	14.0	1,319.0	0.1	0.9	1	1	0
10/06/2021 05:00	0.3	13.9	1,528.7	0.4	1.1	1	1	0
10/06/2021 06:00	0.3	13.9	1,599.7	0.4	1.1	1	1	0
10/06/2021 07:00	0.3	13.9	1,563.6	0.4	1.1	1	1	0
10/06/2021 08:00	0.1	13.9	1,404.1	0.2	1.0	1	1	0
10/06/2021 09:00	0.4	13.9	1,585.6	0.4	1.1	1	1	0
10/06/2021 10:00	0.3	13.9	1,567.8	0.4	1.1	1	1	0
10/06/2021 11:00	0.3	13.9	1,507.1	0.4	1.1	1	1	0
10/06/2021 12:00	0.4	13.9	1,609.5	0.4	1.1	1	1	0
10/06/2021 13:00	0.4	13.9	1,636.5	0.4	1.1	1	1	0
10/06/2021 14:00	0.4	13.9	1,682.2	0.4	1.2	1	1	0
10/06/2021 15:00	0.3	13.9	1,668.2	0.4	1.2	1	1	0
10/06/2021 16:00	0.3	13.9	1,641.6	0.4	1.1	1	1	0
10/06/2021 17:00	0.1	13.9	1,392.9	0.2	1.0	1	1	0
10/06/2021 18:00	0.2	13.9	1,595.2	0.3	1.1	1	1	0
10/06/2021 19:00	0.3	13.9	1,626.1	0.4	1.1	1	1	0
10/06/2021 20:00	0.3	13.8	1,720.9	0.4	1.2	1	1	0
10/06/2021 21:00	0.3	13.9	1,641.9	0.4	1.1	1	1	0
10/06/2021 22:00	0.2	13.9	1,586.7	0.3	1.1	1	1	0
10/06/2021 23:00	0.3	13.9	1,685.2	0.4	1.2	1	1	0
Average/Sum#:	0.3	13.9	1,531.0	0.3	1.1	24 #	24 #	0 #
Minimum:	0.1	13.8	1,294.9	0.1	0.9	1	1	0
Maximum:	0.4	14.0	1,720.9	0.4	1.2	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/07/2021 00:00	0.3	13.9	1,550.3	0.4	1.1	1	1	0
10/07/2021 01:00	0.3	13.9	1,548.9	0.4	1.1	1	1	0
10/07/2021 02:00	0.3	13.9	1,546.0	0.4	1.1	1	1	0
10/07/2021 03:00	0.2	14.0	1,459.9	0.3	1.0	1	1	0
10/07/2021 04:00	0.4	13.9	1,657.6	0.4	1.2	1	1	0
10/07/2021 05:00	0.4	13.9	1,640.7	0.4	1.1	1	1	0
10/07/2021 06:00	0.4	13.9	1,688.4	0.4	1.2	1	1	0
10/07/2021 07:00	0.4	13.9	1,630.0	0.4	1.1	1	1	0
10/07/2021 08:00	0.4	13.9	1,616.8	0.4	1.1	1	1	0
10/07/2021 09:00	0.4	13.9	1,542.5	0.4	1.1	1	1	0
10/07/2021 10:00	0.4	13.9	1,528.4	0.4	1.1	1	1	0
10/07/2021 11:00	0.4	14.0	1,544.1	0.4	1.1	1	1	0
10/07/2021 12:00	0.4	14.0	1,547.9	0.4	1.1	1	1	0
10/07/2021 13:00	0.4	14.0	1,546.4	0.4	1.1	1	1	0
10/07/2021 14:00	0.4	13.9	1,685.3	0.4	1.2	1	1	0
10/07/2021 15:00	0.3	13.9	1,670.6	0.4	1.2	1	1	0
10/07/2021 16:00	0.3	13.9	1,703.6	0.4	1.2	1	1	0
10/07/2021 17:00	0.3	13.7	1,813.3	0.4	1.3	1	1	0
10/07/2021 18:00	0.3	13.8	1,761.9	0.4	1.2	1	1	0
10/07/2021 19:00	0.2	13.9	1,655.6	0.3	1.2	1	1	0
10/07/2021 20:00	0.2	13.8	1,627.5	0.3	1.1	1	1	0
10/07/2021 21:00	0.3	13.9	1,664.9	0.4	1.2	1	1	0
10/07/2021 22:00	0.4	13.9	1,675.8	0.4	1.2	1	1	0
10/07/2021 23:00	0.3	13.9	1,594.0	0.4	1.1	1	1	0
Average/Sum#:	0.3	13.9	1,620.9	0.4	1.1	24 #	24 #	0 #
Minimum:	0.2	13.7	1,459.9	0.3	1.0	1	1	0
Maximum:	0.4	14.0	1,813.3	0.4	1.3	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/08/2021 00:00	0.3	13.9	1,512.8	0.4	1.1	1	1	0
10/08/2021 01:00	0.3	13.9	1,500.4	0.4	1.1	1	1	0
10/08/2021 02:00	0.3	13.9	1,531.9	0.4	1.1	1	1	0
10/08/2021 03:00	0.3	13.9	1,587.0	0.4	1.1	1	1	0
10/08/2021 04:00	0.4	13.9	1,665.2	0.4	1.2	1	1	0
10/08/2021 05:00	0.3	13.9	1,558.2	0.4	1.1	1	1	0
10/08/2021 06:00	0.4	13.9	1,657.0	0.4	1.2	1	1	0
10/08/2021 07:00	0.3	13.9	1,539.1	0.4	1.1	1	1	0
10/08/2021 08:00	0.3	13.9	1,546.9	0.4	1.1	1	1	0
10/08/2021 09:00	0.2	14.0	1,394.2	0.3	1.0	1	1	0
10/08/2021 10:00	0.4	13.9	1,653.2	0.4	1.2	1	1	0
10/08/2021 11:00	0.3	14.0	1,465.4	0.4	1.0	1	1	0
10/08/2021 12:00	0.4	13.9	1,605.4	0.4	1.1	1	1	0
10/08/2021 13:00	0.4	14.0	1,572.0	0.4	1.1	1	1	0
10/08/2021 14:00	0.3	14.0	1,538.5	0.4	1.1	1	1	0
10/08/2021 15:00	0.4	14.0	1,620.8	0.4	1.1	1	1	0
10/08/2021 16:00	0.4	14.0	1,681.0	0.4	1.2	1	1	0
10/08/2021 17:00	0.4	14.0	1,604.7	0.4	1.1	1	1	0
10/08/2021 18:00	0.4	14.0	1,620.8	0.4	1.1	1	1	0
10/08/2021 19:00	0.4	13.9	1,645.3	0.4	1.2	1	1	0
10/08/2021 20:00	0.1	14.0	1,376.5	0.2	1.0	1	1	0
10/08/2021 21:00	0.0	16.7	321.4	0.0	0.2	1	0	0
10/08/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.3	14.1	1,509.0	0.4	1.1	22 #	21 #	0 #
Minimum:	0.0	13.9	321.4	0.0	0.2	0	0	0
Maximum:	0.4	16.7	1,681.0	0.4	1.2	1	1	0
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/09/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/10/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/11/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/12/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/13/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/14/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/15/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/16/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/17/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/18/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/19/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/20/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2021 13:00	0.0	17.9	288.6	0.0	0.2	1	0	0
10/20/2021 14:00	0.0	16.3	621.0	0.0	0.4	1	0	0
10/20/2021 15:00	0.0	13.8	1,514.3	0.0	1.1	1	0	1
10/20/2021 16:00	-0.7	12.7	1,858.7	-0.2	1.3	1	1	1
10/20/2021 17:00	0.1	13.8	1,682.9	0.2	1.2	1	1	1
10/20/2021 18:00	-1.2	12.9	1,994.9	-0.8	1.4	1	1	1
10/20/2021 19:00	-0.8	12.8	2,042.0	-0.4	1.4	1	1	1
10/20/2021 20:00	-0.5	12.1	2,183.3	-0.1	1.5	1	1	1
10/20/2021 21:00	-0.4	12.3	2,115.5	-0.1	1.5	1	1	1
10/20/2021 22:00	0.0	15.6	654.4	0.0	0.5	1	0	0
10/20/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	-0.4	14.0	1,495.6	-0.1	1.1	10 #	6 #	7 #
Minimum:	-1.2	12.1	288.6	-0.8	0.2	0	0	0
Maximum:	0.1	17.9	2,183.3	0.2	1.5	1	1	1
%SI	58.33	58.33	58.33	58.33	58.33	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/21/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/22/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/23/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2021 01:00	0.0	17.8	320.9	0.0	0.2	1	0	0
10/23/2021 02:00	0.0	17.3	379.9	0.0	0.3	1	0	0
10/23/2021 03:00	0.0	16.0	739.1	0.0	0.5	1	0	0
10/23/2021 04:00	0.2	13.9	1,516.5	0.3	1.1	1	1	0
10/23/2021 05:00	0.3	13.9	1,576.3	0.4	1.1	1	1	0
10/23/2021 06:00	0.4	13.9	1,761.6	0.4	1.2	1	1	0
10/23/2021 07:00	0.3	13.9	1,496.0	0.4	1.0	1	1	0
10/23/2021 08:00	0.4	13.9	1,644.8	0.4	1.2	1	1	0
10/23/2021 09:00	0.2	13.9	1,399.8	0.3	1.0	1	1	0
10/23/2021 10:00	0.4	13.9	1,599.4	0.4	1.1	1	1	0
10/23/2021 11:00	0.4	13.9	1,570.7	0.4	1.1	1	1	0
10/23/2021 12:00	0.4	13.9	1,616.5	0.4	1.1	1	1	0
10/23/2021 13:00	0.4	13.9	1,579.5	0.4	1.1	1	1	0
10/23/2021 14:00	0.4	13.9	1,663.6	0.4	1.2	1	1	0
10/23/2021 15:00	0.4	13.9	1,638.0	0.4	1.1	1	1	0
10/23/2021 16:00	0.4	13.8	1,667.4	0.4	1.2	1	1	0
10/23/2021 17:00	-0.5	13.0	1,955.9	-0.2	1.4	1	1	1
10/23/2021 18:00	-0.5	12.6	2,055.0	-0.2	1.4	1	1	1
10/23/2021 19:00	0.2	13.8	1,653.2	0.4	1.2	1	1	1
10/23/2021 20:00	0.2	13.8	1,676.0	0.4	1.2	1	1	1
10/23/2021 21:00	-0.5	12.7	2,033.9	-0.2	1.4	1	1	1
10/23/2021 22:00	0.0	13.8	1,476.4	0.0	1.0	1	0	1
10/23/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.2	14.2	1,500.9	0.2	1.1	22 #	18 #	6 #
Minimum:	-0.5	12.6	320.9	-0.2	0.2	0	0	0
Maximum:	0.4	17.8	2,055.0	0.4	1.4	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/24/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2021 07:00	0.0	17.7	337.7	0.0	0.2	1	0	0
10/24/2021 08:00	0.0	15.1	1,060.4	0.0	0.7	1	0	0
10/24/2021 09:00	0.4	13.9	1,571.7	0.4	1.1	1	1	0
10/24/2021 10:00	0.4	13.9	1,581.6	0.4	1.1	1	1	0
10/24/2021 11:00	0.3	13.9	1,562.2	0.4	1.1	1	1	0
10/24/2021 12:00	0.4	13.9	1,618.0	0.4	1.1	1	1	0
10/24/2021 13:00	0.3	13.9	1,511.9	0.4	1.1	1	1	0
10/24/2021 14:00	0.4	13.9	1,629.5	0.4	1.1	1	1	0
10/24/2021 15:00	0.4	13.9	1,654.3	0.4	1.2	1	1	0
10/24/2021 16:00	0.4	13.7	1,765.5	0.4	1.2	1	1	0
10/24/2021 17:00	-0.7	12.7	2,020.0	-0.2	1.4	1	1	1
10/24/2021 18:00	-0.5	12.4	2,049.3	-0.2	1.4	1	1	1
10/24/2021 19:00	0.4	13.9	1,694.2	0.4	1.2	1	1	0
10/24/2021 20:00	0.2	13.9	1,731.8	0.2	1.2	1	1	1
10/24/2021 21:00	-0.4	12.7	2,033.3	-0.1	1.4	1	1	1
10/24/2021 22:00	-0.1	13.3	1,685.5	0.1	1.2	1	1	1
10/24/2021 23:00	0.2	14.0	1,412.7	0.3	1.0	1	1	0
Average/Sum#:	0.1	13.9	1,583.5	0.2	1.1	17 #	15 #	5 #
Minimum:	-0.7	12.4	337.7	-0.2	0.2	0	0	0
Maximum:	0.4	17.7	2,049.3	0.4	1.4	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/25/2021 00:00	0.3	13.9	1,548.6	0.4	1.1	1	1	0
10/25/2021 01:00	0.3	13.9	1,538.7	0.4	1.1	1	1	0
10/25/2021 02:00	0.2	13.9	1,492.1	0.3	1.0	1	1	0
10/25/2021 03:00	0.3	13.9	1,549.7	0.4	1.1	1	1	0
10/25/2021 04:00	0.3	13.9	1,567.8	0.4	1.1	1	1	0
10/25/2021 05:00	0.4	13.8	1,783.7	0.4	1.2	1	1	0
10/25/2021 06:00	0.3	13.9	1,634.7	0.4	1.1	1	1	0
10/25/2021 07:00	0.4	13.7	1,804.1	0.4	1.3	1	1	0
10/25/2021 08:00	0.4	13.9	1,686.3	0.4	1.2	1	1	0
10/25/2021 09:00	0.1	13.8	1,789.5	0.2	1.3	1	1	1
10/25/2021 10:00	-0.7	13.0	1,970.9	-0.4	1.4	1	1	1
10/25/2021 11:00	-0.7	12.8	2,051.1	-0.4	1.4	1	1	1
10/25/2021 12:00	-0.5	13.0	1,973.2	-0.2	1.4	1	1	1
10/25/2021 13:00	0.3	13.9	1,642.6	0.4	1.1	1	1	0
10/25/2021 14:00	0.3	14.0	1,553.7	0.4	1.1	1	1	0
10/25/2021 15:00	0.1	13.9	1,574.6	0.2	1.1	1	1	1
10/25/2021 16:00	-0.8	12.6	2,095.0	-0.4	1.5	1	1	1
10/25/2021 17:00	-0.5	12.5	2,120.4	-0.2	1.5	1	1	1
10/25/2021 18:00	-0.2	12.7	2,064.1	0.1	1.4	1	1	1
10/25/2021 19:00	-0.7	13.8	1,650.6	-0.4	1.2	1	1	1
10/25/2021 20:00	-0.4	14.0	1,495.4	-0.2	1.0	1	1	0
10/25/2021 21:00	-0.5	13.1	1,968.7	-0.2	1.4	1	1	1
10/25/2021 22:00	-0.1	13.5	1,701.8	0.1	1.2	1	1	1
10/25/2021 23:00	0.2	14.0	1,362.6	0.3	1.0	1	1	0
Average/Sum#:	-0.1	13.6	1,734.2	0.1	1.2	24 #	24 #	11 #
Minimum:	-0.8	12.5	1,362.6	-0.4	1.0	1	1	0
Maximum:	0.4	14.0	2,120.4	0.4	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/26/2021 00:00	0.1	14.0	1,363.5	0.2	1.0	1	1	0
10/26/2021 01:00	0.2	14.0	1,366.4	0.3	1.0	1	1	0
10/26/2021 02:00	0.2	14.0	1,371.6	0.3	1.0	1	1	0
10/26/2021 03:00	0.2	14.0	1,373.2	0.3	1.0	1	1	0
10/26/2021 04:00	0.3	13.9	1,530.4	0.4	1.1	1	1	0
10/26/2021 05:00	0.4	13.8	1,807.4	0.4	1.3	1	1	0
10/26/2021 06:00	0.2	13.9	1,490.9	0.3	1.0	1	1	0
10/26/2021 07:00	0.3	13.9	1,614.3	0.4	1.1	1	1	0
10/26/2021 08:00	0.6	0.0	1,607.2	0.6	1.1	1	1	0
10/26/2021 09:00	0.7	0.0	1,595.2	0.7	1.1	1	1	1
10/26/2021 10:00	-0.1	12.6	2,046.5	0.1	1.4	1	1	1
10/26/2021 11:00	0.1	13.0	1,954.9	0.2	1.4	1	1	1
10/26/2021 12:00	0.6	13.8	1,687.7	0.6	1.2	1	1	0
10/26/2021 13:00	0.5	13.9	1,478.8	0.5	1.0	1	1	0
10/26/2021 14:00	0.5	13.9	1,450.7	0.5	1.0	1	1	0
10/26/2021 15:00	0.5	13.8	1,575.7	0.5	1.1	1	1	1
10/26/2021 16:00	-0.1	12.7	2,042.2	0.1	1.4	1	1	1
10/26/2021 17:00	0.1	12.4	2,119.7	0.2	1.5	1	1	1
10/26/2021 18:00	0.1	12.6	2,091.1	0.2	1.5	1	1	1
10/26/2021 19:00	0.1	12.6	2,047.6	0.2	1.4	1	1	1
10/26/2021 20:00	0.6	13.8	1,584.6	0.6	1.1	1	1	0
10/26/2021 21:00	0.7	13.8	1,790.8	0.7	1.3	1	1	1
10/26/2021 22:00	-0.1	12.7	2,071.7	0.1	1.5	1	1	1
10/26/2021 23:00	0.1	12.8	2,016.8	0.2	1.4	1	1	1
Average/Sum#:	0.3	13.5	1,711.6	0.3	1.2	24 #	24 #	11 #
Minimum:	-0.1	12.4	1,363.5	0.1	1.0	1	1	0
Maximum:	0.7	14.0	2,119.7	0.7	1.5	1	1	1
%SI	8.33	8.33	0.00	8.33	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/27/2021 00:00	0.5	13.8	1,563.7	0.5	1.1	1	1	0
10/27/2021 01:00	0.4	13.8	1,592.2	0.4	1.1	1	1	1
10/27/2021 02:00	0.1	13.1	1,964.8	0.2	1.4	1	1	1
10/27/2021 03:00	0.2	13.2	1,935.8	0.4	1.4	1	1	1
10/27/2021 04:00	0.6	13.8	1,602.1	0.6	1.1	1	1	0
10/27/2021 05:00	0.7	13.8	1,616.8	0.7	1.1	1	1	1
10/27/2021 06:00	-0.1	13.0	2,018.4	0.1	1.4	1	1	1
10/27/2021 07:00	-0.1	12.7	2,066.7	0.1	1.4	1	1	1
10/27/2021 08:00	0.2	13.2	1,951.2	0.4	1.4	1	1	1
10/27/2021 09:00	0.5	13.9	1,494.3	0.5	1.0	1	1	1
10/27/2021 10:00	0.5	13.9	1,454.8	0.5	1.0	1	1	0
10/27/2021 11:00	0.6	13.8	1,610.6	0.6	1.1	1	1	0
10/27/2021 12:00	0.5	13.9	1,339.4	0.5	0.9	1	1	0
10/27/2021 13:00	0.6	13.9	1,488.9	0.6	1.0	1	1	0
10/27/2021 14:00	0.4	13.3	1,856.6	0.4	1.3	1	1	1
10/27/2021 15:00	0.2	12.9	1,907.8	0.4	1.3	1	1	1
10/27/2021 16:00	0.7	13.8	1,711.2	0.7	1.2	1	1	1
10/27/2021 17:00	0.1	12.9	1,982.5	0.2	1.4	1	1	1
10/27/2021 18:00	0.1	12.3	2,133.1	0.2	1.5	1	1	1
10/27/2021 19:00	0.2	12.1	2,182.6	0.4	1.5	1	1	1
10/27/2021 20:00	0.2	12.3	2,135.5	0.4	1.5	1	1	1
10/27/2021 21:00	0.2	12.3	2,149.7	0.4	1.5	1	1	1
10/27/2021 22:00	0.4	12.7	2,047.0	0.5	1.4	1	1	1
10/27/2021 23:00	0.4	13.3	1,845.7	0.4	1.3	1	1	1
Average/Sum#:	0.3	13.2	1,818.8	0.4	1.3	24 #	24 #	18 #
Minimum:	-0.1	12.1	1,339.4	0.1	0.9	1	1	0
Maximum:	0.7	13.9	2,182.6	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/28/2021 00:00	0.5	13.9	1,361.0	0.5	1.0	1	1	0
10/28/2021 01:00	0.4	13.9	1,355.2	0.4	0.9	1	1	0
10/28/2021 02:00	0.4	13.9	1,357.9	0.4	1.0	1	1	0
10/28/2021 03:00	0.4	13.9	1,358.5	0.4	1.0	1	1	0
10/28/2021 04:00	0.5	13.8	1,542.5	0.5	1.1	1	1	0
10/28/2021 05:00	-0.1	12.8	2,003.7	0.1	1.4	1	1	1
10/28/2021 06:00	-0.1	13.0	1,984.4	0.1	1.4	1	1	1
10/28/2021 07:00	0.2	13.3	1,831.5	0.4	1.3	1	1	1
10/28/2021 08:00	0.4	13.9	1,360.2	0.4	1.0	1	1	0
10/28/2021 09:00	0.4	13.9	1,366.0	0.4	1.0	1	1	0
10/28/2021 10:00	0.5	13.9	1,373.7	0.5	1.0	1	1	0
10/28/2021 11:00	0.5	13.9	1,381.5	0.5	1.0	1	1	0
10/28/2021 12:00	0.6	13.7	1,740.9	0.6	1.2	1	1	0
10/28/2021 13:00	0.4	13.8	1,500.5	0.4	1.1	1	1	0
10/28/2021 14:00	0.6	13.9	1,534.6	0.6	1.1	1	1	0
10/28/2021 15:00	0.7	13.8	1,580.9	0.7	1.1	1	1	1
10/28/2021 16:00	0.1	12.4	2,087.8	0.2	1.5	1	1	1
10/28/2021 17:00	0.2	11.9	2,202.0	0.4	1.5	1	1	1
10/28/2021 18:00	0.4	12.0	2,193.7	0.5	1.5	1	1	1
10/28/2021 19:00	0.4	12.0	2,188.3	0.5	1.5	1	1	1
10/28/2021 20:00	0.4	12.1	2,172.5	0.5	1.5	1	1	1
10/28/2021 21:00	0.2	12.4	2,109.0	0.4	1.5	1	1	1
10/28/2021 22:00	0.2	12.5	2,086.6	0.4	1.5	1	1	1
10/28/2021 23:00	0.2	12.7	2,015.0	0.4	1.4	1	1	1
Average/Sum#:	0.4	13.2	1,737.0	0.4	1.2	24 #	24 #	12 #
Minimum:	-0.1	11.9	1,355.2	0.1	0.9	1	1	0
Maximum:	0.7	13.9	2,202.0	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/29/2021 00:00	0.2	13.0	1,949.1	0.4	1.4	1	1	1
10/29/2021 01:00	0.2	13.0	1,951.6	0.4	1.4	1	1	1
10/29/2021 02:00	0.2	13.1	1,947.0	0.4	1.4	1	1	1
10/29/2021 03:00	0.2	13.0	1,947.5	0.4	1.4	1	1	1
10/29/2021 04:00	0.1	13.0	1,947.2	0.2	1.4	1	1	1
10/29/2021 05:00	0.1	13.0	1,950.0	0.2	1.4	1	1	1
10/29/2021 06:00	0.1	13.1	1,951.4	0.2	1.4	1	1	1
10/29/2021 07:00	0.1	13.1	1,949.5	0.2	1.4	1	1	1
10/29/2021 08:00	0.1	13.1	1,947.5	0.2	1.4	1	1	1
10/29/2021 09:00	0.2	13.2	1,752.5	0.4	1.2	1	1	1
10/29/2021 10:00	0.4	13.7	1,449.0	0.4	1.0	1	1	1
10/29/2021 11:00	0.4	12.8	1,981.4	0.5	1.4	1	1	1
10/29/2021 12:00	0.4	13.1	1,762.5	0.4	1.2	1	1	1
10/29/2021 13:00	0.4	13.7	1,438.3	0.4	1.0	1	1	1
10/29/2021 14:00	0.1	12.7	1,993.4	0.2	1.4	1	1	1
10/29/2021 15:00	0.1	12.7	1,995.1	0.2	1.4	1	1	1
10/29/2021 16:00	0.1	12.7	1,993.2	0.2	1.4	1	1	1
10/29/2021 17:00	0.1	12.8	1,989.9	0.2	1.4	1	1	1
10/29/2021 18:00	0.1	12.8	1,986.4	0.2	1.4	1	1	1
10/29/2021 19:00	0.1	12.8	1,985.2	0.2	1.4	1	1	1
10/29/2021 20:00	0.1	12.8	1,981.8	0.2	1.4	1	1	1
10/29/2021 21:00	0.1	12.8	1,978.1	0.2	1.4	1	1	1
10/29/2021 22:00	0.2	12.9	1,963.8	0.4	1.4	1	1	1
10/29/2021 23:00	0.1	12.6	2,027.9	0.2	1.4	1	1	1
Average/Sum#:	0.2	13.0	1,909.1	0.3	1.4	24 #	24 #	24 #
Minimum:	0.1	12.6	1,438.3	0.2	1.0	1	1	1
Maximum:	0.4	13.7	2,027.9	0.5	1.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/30/2021 00:00	0.7	13.7	1,659.6	0.7	1.2	1	1	1
10/30/2021 01:00	0.5	13.8	1,470.0	0.5	1.0	1	1	0
10/30/2021 02:00	0.2	13.2	1,786.9	0.4	1.3	1	1	1
10/30/2021 03:00	0.1	13.0	1,938.3	0.2	1.4	1	1	1
10/30/2021 04:00	0.6	13.8	1,638.9	0.6	1.1	1	1	0
10/30/2021 05:00	0.7	13.7	1,697.1	0.7	1.2	1	1	1
10/30/2021 06:00	-0.1	12.7	2,022.7	0.1	1.4	1	1	1
10/30/2021 07:00	0.1	13.0	1,945.0	0.2	1.4	1	1	1
10/30/2021 08:00	0.5	13.8	1,517.6	0.5	1.1	1	1	0
10/30/2021 09:00	0.3	13.9	1,350.1	0.4	0.9	1	1	0
10/30/2021 10:00	0.4	13.9	1,350.1	0.4	0.9	1	1	0
10/30/2021 11:00	0.6	13.8	1,483.5	0.6	1.0	1	1	0
10/30/2021 12:00	0.6	13.9	1,399.9	0.6	1.0	1	1	0
10/30/2021 13:00	0.5	13.9	1,409.0	0.5	1.0	1	1	0
10/30/2021 14:00	0.6	13.9	1,531.7	0.6	1.1	1	1	0
10/30/2021 15:00	0.7	13.8	1,624.8	0.7	1.1	1	1	1
10/30/2021 16:00	-0.1	12.6	2,048.4	0.1	1.4	1	1	1
10/30/2021 17:00	-0.1	12.4	2,109.1	0.2	1.5	1	1	1
10/30/2021 18:00	-0.2	12.5	2,086.5	0.1	1.5	1	1	1
10/30/2021 19:00	0.1	12.7	2,003.7	0.2	1.4	1	1	1
10/30/2021 20:00	0.6	13.8	1,677.2	0.6	1.2	1	1	0
10/30/2021 21:00	0.7	13.8	1,645.4	0.7	1.2	1	1	1
10/30/2021 22:00	-0.1	12.8	2,019.3	0.1	1.4	1	1	1
10/30/2021 23:00	0.1	13.0	1,934.0	0.2	1.4	1	1	1
Average/Sum#:	0.3	13.4	1,722.9	0.4	1.2	24 #	24 #	14 #
Minimum:	-0.2	12.4	1,350.1	0.1	0.9	1	1	0
Maximum:	0.7	13.9	2,109.1	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/31/2021 00:00	0.6	13.8	1,666.6	0.6	1.2	1	1	0
10/31/2021 01:00	0.5	13.8	1,577.3	0.5	1.1	1	1	1
10/31/2021 02:00	0.4	13.1	1,952.5	0.4	1.4	1	1	1
10/31/2021 03:00	0.4	13.1	1,928.8	0.4	1.4	1	1	1
10/31/2021 04:00	0.6	13.8	1,701.4	0.6	1.2	1	1	0
10/31/2021 05:00	0.7	13.8	1,573.7	0.7	1.1	1	1	1
10/31/2021 06:00	-0.1	12.8	2,045.2	0.1	1.4	1	1	1
10/31/2021 07:00	0.1	13.1	1,942.4	0.2	1.4	1	1	1
10/31/2021 08:00	0.6	13.8	1,658.3	0.6	1.2	1	1	0
10/31/2021 09:00	0.6	13.8	1,592.7	0.6	1.1	1	1	0
10/31/2021 10:00	0.4	13.9	1,415.7	0.4	1.0	1	1	0
10/31/2021 11:00	0.6	13.8	1,558.0	0.6	1.1	1	1	0
10/31/2021 12:00	0.6	13.8	1,610.2	0.6	1.1	1	1	0
10/31/2021 13:00	0.6	13.8	1,696.3	0.6	1.2	1	1	0
10/31/2021 14:00	0.6	13.9	1,575.5	0.6	1.1	1	1	0
10/31/2021 15:00	0.5	13.8	1,610.0	0.5	1.1	1	1	1
10/31/2021 16:00	-0.1	12.7	2,009.4	0.1	1.4	1	1	1
10/31/2021 17:00	-0.1	12.5	2,055.8	0.1	1.4	1	1	1
10/31/2021 18:00	0.1	12.5	2,069.8	0.2	1.4	1	1	1
10/31/2021 19:00	0.1	12.9	1,952.2	0.2	1.4	1	1	1
10/31/2021 20:00	0.6	13.8	1,693.9	0.6	1.2	1	1	0
10/31/2021 21:00	0.5	13.8	1,585.1	0.5	1.1	1	1	1
10/31/2021 22:00	-0.1	12.8	2,016.5	0.1	1.4	1	1	1
10/31/2021 23:00	0.1	13.0	1,944.3	0.2	1.4	1	1	1
Average/Sum#:	0.4	13.4	1,768.0	0.4	1.2	24 #	24 #	14 #
Minimum:	-0.1	12.5	1,415.7	0.1	1.0	1	1	0
Maximum:	0.7	13.9	2,069.8	0.7	1.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/01/2021 00:00	0.6	13.8	1,635.1	0.6	1.1	1	1	0
11/01/2021 01:00	0.7	13.7	1,693.5	0.7	1.2	1	1	1
11/01/2021 02:00	-0.1	13.0	1,951.2	0.1	1.4	1	1	1
11/01/2021 03:00	-0.1	12.7	2,003.4	0.1	1.4	1	1	1
11/01/2021 04:00	0.7	13.8	1,598.1	0.7	1.1	1	1	1
11/01/2021 05:00	0.7	13.7	1,688.6	0.7	1.2	1	1	1
11/01/2021 06:00	-0.2	12.5	2,066.7	0.1	1.4	1	1	1
11/01/2021 07:00	-0.1	12.3	2,118.8	0.2	1.5	1	1	1
11/01/2021 08:00	0.1	12.9	1,963.2	0.2	1.4	1	1	1
11/01/2021 09:00	0.5	13.8	1,577.1	0.5	1.1	1	1	0
11/01/2021 10:00	0.5	13.8	1,538.3	0.5	1.1	1	1	1
11/01/2021 11:00	-0.1	12.6	2,040.4	0.1	1.4	1	1	1
11/01/2021 12:00	-0.1	12.5	2,033.3	0.1	1.4	1	1	1
11/01/2021 13:00	0.6	13.8	1,716.1	0.6	1.2	1	1	0
11/01/2021 14:00	0.6	13.6	1,803.2	0.6	1.3	1	1	0
11/01/2021 15:00	-0.1	12.6	2,035.9	0.1	1.4	1	1	1
11/01/2021 16:00	0.1	12.4	2,072.0	0.2	1.5	1	1	1
11/01/2021 17:00	0.2	11.9	2,205.0	0.4	1.5	1	1	1
11/01/2021 18:00	0.1	12.0	2,167.8	0.2	1.5	1	1	1
11/01/2021 19:00	0.2	11.9	2,202.3	0.4	1.5	1	1	1
11/01/2021 20:00	0.2	11.8	2,228.3	0.4	1.6	1	1	1
11/01/2021 21:00	0.2	11.9	2,209.1	0.4	1.5	1	1	1
11/01/2021 22:00	0.1	12.4	2,109.1	0.2	1.5	1	1	1
11/01/2021 23:00	0.1	13.1	1,929.3	0.2	1.4	1	1	1
Average/Sum#:	0.2	12.9	1,941.1	0.3	1.4	24 #	24 #	20 #
Minimum:	-0.2	11.8	1,538.3	0.1	1.1	1	1	0
Maximum:	0.7	13.8	2,228.3	0.7	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/02/2021 00:00	0.5	13.8	1,564.4	0.5	1.1	1	1	0
11/02/2021 01:00	0.4	13.8	1,588.3	0.4	1.1	1	1	1
11/02/2021 02:00	-0.2	13.1	1,952.4	-0.1	1.4	1	1	1
11/02/2021 03:00	0.1	13.1	1,940.9	0.2	1.4	1	1	1
11/02/2021 04:00	0.7	13.7	1,660.4	0.7	1.2	1	1	1
11/02/2021 05:00	0.7	13.8	1,639.6	0.7	1.1	1	1	1
11/02/2021 06:00	-0.1	12.6	2,065.5	0.1	1.4	1	1	1
11/02/2021 07:00	0.1	12.6	2,067.5	0.2	1.4	1	1	1
11/02/2021 08:00	0.1	13.1	1,947.1	0.2	1.4	1	1	1
11/02/2021 09:00	0.6	13.8	1,524.3	0.6	1.1	1	1	0
11/02/2021 10:00	0.6	13.8	1,633.7	0.6	1.1	1	1	0
11/02/2021 11:00	0.4	13.9	1,330.6	0.4	0.9	1	1	0
11/02/2021 12:00	0.6	13.9	1,533.6	0.6	1.1	1	1	0
11/02/2021 13:00	0.6	13.9	1,636.6	0.6	1.1	1	1	0
11/02/2021 14:00	0.6	13.9	1,622.1	0.6	1.1	1	1	0
11/02/2021 15:00	0.7	13.8	1,649.3	0.7	1.2	1	1	1
11/02/2021 16:00	-0.1	12.6	2,054.5	0.1	1.4	1	1	1
11/02/2021 17:00	0.1	12.0	2,168.6	0.2	1.5	1	1	1
11/02/2021 18:00	0.2	12.1	2,167.3	0.4	1.5	1	1	1
11/02/2021 19:00	-0.1	11.8	2,239.2	0.2	1.6	1	1	1
11/02/2021 20:00	-0.2	12.1	2,174.8	0.1	1.5	1	1	1
11/02/2021 21:00	-0.2	12.2	2,156.4	0.1	1.5	1	1	1
11/02/2021 22:00	0.1	12.3	2,126.3	0.2	1.5	1	1	1
11/02/2021 23:00	0.2	12.9	1,964.6	0.4	1.4	1	1	1
Average/Sum#:	0.3	13.1	1,850.3	0.4	1.3	24 #	24 #	17 #
Minimum:	-0.2	11.8	1,330.6	-0.1	0.9	1	1	0
Maximum:	0.7	13.9	2,239.2	0.7	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/03/2021 00:00	0.6	13.9	1,693.3	0.6	1.2	1	1	0
11/03/2021 01:00	0.7	13.8	1,645.7	0.7	1.2	1	1	1
11/03/2021 02:00	-0.2	13.1	1,946.2	-0.1	1.4	1	1	1
11/03/2021 03:00	-0.1	13.1	1,936.1	0.1	1.4	1	1	1
11/03/2021 04:00	0.5	13.7	1,659.7	0.5	1.2	1	1	1
11/03/2021 05:00	0.7	13.8	1,786.9	0.7	1.3	1	1	1
11/03/2021 06:00	-0.4	12.9	2,013.9	-0.1	1.4	1	1	1
11/03/2021 07:00	-0.2	13.0	1,983.4	0.1	1.4	1	1	1
11/03/2021 08:00	0.7	13.7	1,679.1	0.7	1.2	1	1	1
11/03/2021 09:00	0.6	13.8	1,688.5	0.6	1.2	1	1	0
11/03/2021 10:00	0.6	13.9	1,591.5	0.6	1.1	1	1	0
11/03/2021 11:00	0.6	13.9	1,702.2	0.6	1.2	1	1	0
11/03/2021 12:00	0.6	13.9	1,532.4	0.6	1.1	1	1	0
11/03/2021 13:00	0.6	13.9	1,700.0	0.6	1.2	1	1	0
11/03/2021 14:00	0.6	13.9	1,521.9	0.6	1.1	1	1	0
11/03/2021 15:00	0.7	13.8	1,598.3	0.7	1.1	1	1	1
11/03/2021 16:00	-0.7	12.5	2,053.5	-0.2	1.4	1	1	1
11/03/2021 17:00	-0.2	11.8	2,209.9	0.1	1.5	1	1	1
11/03/2021 18:00	-0.5	12.0	2,166.9	-0.1	1.5	1	1	1
11/03/2021 19:00	-0.4	11.8	2,229.6	-0.1	1.6	1	1	1
11/03/2021 20:00	-0.4	11.8	2,207.3	-0.1	1.5	1	1	1
11/03/2021 21:00	-0.2	12.1	2,151.9	0.1	1.5	1	1	1
11/03/2021 22:00	-0.1	12.3	2,087.8	0.2	1.5	1	1	1
11/03/2021 23:00	-0.2	12.9	1,939.3	0.1	1.4	1	1	1
Average/Sum#:	0.2	13.1	1,863.6	0.3	1.3	24 #	24 #	17 #
Minimum:	-0.7	11.8	1,521.9	-0.2	1.1	1	1	0
Maximum:	0.7	13.9	2,229.6	0.7	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/04/2021 00:00	0.6	13.8	1,479.7	0.6	1.0	1	1	0
11/04/2021 01:00	0.4	13.7	1,595.4	0.4	1.1	1	1	1
11/04/2021 02:00	-0.5	12.9	1,955.7	-0.2	1.4	1	1	1
11/04/2021 03:00	-0.2	12.7	1,983.9	0.1	1.4	1	1	1
11/04/2021 04:00	0.7	13.8	1,692.1	0.7	1.2	1	1	1
11/04/2021 05:00	0.7	13.7	1,777.3	0.7	1.2	1	1	1
11/04/2021 06:00	-0.8	12.7	2,022.2	-0.4	1.4	1	1	1
11/04/2021 07:00	-0.2	12.7	2,000.2	0.1	1.4	1	1	1
11/04/2021 08:00	0.6	13.9	1,599.3	0.6	1.1	1	1	0
11/04/2021 09:00	0.6	13.9	1,533.5	0.6	1.1	1	1	0
11/04/2021 10:00	0.6	13.9	1,526.0	0.6	1.1	1	1	0
11/04/2021 11:00	0.6	13.9	1,499.5	0.6	1.0	1	1	0
11/04/2021 12:00	0.5	14.0	1,387.7	0.5	1.0	1	1	0
11/04/2021 13:00	0.6	13.9	1,549.4	0.6	1.1	1	1	0
11/04/2021 14:00	0.6	13.9	1,666.7	0.6	1.2	1	1	0
11/04/2021 15:00	0.6	13.9	1,567.9	0.6	1.1	1	1	0
11/04/2021 16:00	-0.4	12.7	2,014.7	-0.1	1.4	1	1	1
11/04/2021 17:00	-0.4	12.4	2,094.6	-0.1	1.5	1	1	1
11/04/2021 18:00	-0.2	12.5	2,064.8	0.1	1.4	1	1	1
11/04/2021 19:00	0.7	13.8	1,702.6	0.7	1.2	1	1	1
11/04/2021 20:00	0.7	13.8	1,645.3	0.7	1.2	1	1	1
11/04/2021 21:00	-0.1	12.7	2,030.4	0.1	1.4	1	1	1
11/04/2021 22:00	0.2	13.3	1,688.6	0.4	1.2	1	1	1
11/04/2021 23:00	0.4	13.9	1,363.5	0.4	1.0	1	1	0
Average/Sum#:	0.3	13.4	1,726.7	0.4	1.2	24 #	24 #	14 #
Minimum:	-0.8	12.4	1,363.5	-0.4	1.0	1	1	0
Maximum:	0.7	14.0	2,094.6	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/05/2021 00:00	0.4	13.9	1,350.7	0.4	0.9	1	1	0
11/05/2021 01:00	0.5	13.9	1,360.1	0.5	1.0	1	1	0
11/05/2021 02:00	0.4	13.9	1,363.9	0.4	1.0	1	1	0
11/05/2021 03:00	0.5	13.9	1,399.7	0.5	1.0	1	1	0
11/05/2021 04:00	0.6	13.8	1,591.3	0.6	1.1	1	1	0
11/05/2021 05:00	-0.8	12.2	2,093.0	-0.4	1.5	1	1	1
11/05/2021 06:00	-0.5	12.6	2,068.0	-0.2	1.4	1	1	1
11/05/2021 07:00	-0.5	12.6	1,871.7	-0.2	1.3	1	1	1
11/05/2021 08:00	0.3	13.9	1,369.5	0.4	1.0	1	1	0
11/05/2021 09:00	0.6	0.0	1,377.5	0.6	1.0	1	1	0
11/05/2021 10:00	0.5	13.9	1,374.4	0.5	1.0	1	1	0
11/05/2021 11:00	0.4	13.9	1,375.0	0.4	1.0	1	1	0
11/05/2021 12:00	0.4	13.9	1,420.9	0.4	1.0	1	1	0
11/05/2021 13:00	0.4	13.8	1,805.1	0.4	1.3	1	1	0
11/05/2021 14:00	0.4	13.8	1,580.6	0.4	1.1	1	1	0
11/05/2021 15:00	0.4	13.8	1,576.0	0.4	1.1	1	1	1
11/05/2021 16:00	-0.7	12.5	2,076.9	-0.2	1.5	1	1	1
11/05/2021 17:00	-0.4	12.4	2,107.0	-0.1	1.5	1	1	1
11/05/2021 18:00	-0.2	12.4	2,089.2	0.1	1.5	1	1	1
11/05/2021 19:00	-0.2	12.8	1,984.7	0.1	1.4	1	1	1
11/05/2021 20:00	0.6	13.8	1,673.4	0.6	1.2	1	1	0
11/05/2021 21:00	0.7	13.8	1,790.6	0.7	1.3	1	1	1
11/05/2021 22:00	-0.9	12.8	2,033.4	-0.5	1.4	1	1	1
11/05/2021 23:00	-0.4	13.0	1,953.8	-0.1	1.4	1	1	1
Average/Sum#:	0.1	13.4	1,695.3	0.2	1.2	24 #	24 #	11 #
Minimum:	-0.9	12.2	1,350.7	-0.5	0.9	1	1	0
Maximum:	0.7	13.9	2,107.0	0.7	1.5	1	1	1
%SI	4.17	4.17	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/06/2021 00:00	0.7	13.7	1,698.3	0.7	1.2	1	1	1
11/06/2021 01:00	0.5	13.8	1,607.9	0.5	1.1	1	1	0
11/06/2021 02:00	-0.7	13.1	1,960.6	-0.4	1.4	1	1	1
11/06/2021 03:00	-0.5	13.1	1,952.7	-0.2	1.4	1	1	1
11/06/2021 04:00	0.7	13.8	1,695.2	0.7	1.2	1	1	1
11/06/2021 05:00	0.7	13.8	1,624.5	0.7	1.1	1	1	1
11/06/2021 06:00	-0.9	12.8	2,020.5	-0.5	1.4	1	1	1
11/06/2021 07:00	-0.2	13.0	1,944.0	0.1	1.4	1	1	1
11/06/2021 08:00	0.6	13.8	1,621.0	0.6	1.1	1	1	0
11/06/2021 09:00	0.6	13.8	1,619.9	0.6	1.1	1	1	0
11/06/2021 10:00	0.6	13.8	1,625.9	0.6	1.1	1	1	0
11/06/2021 11:00	0.6	13.8	1,560.7	0.6	1.1	1	1	0
11/06/2021 12:00	0.6	13.8	1,553.8	0.6	1.1	1	1	0
11/06/2021 13:00	0.6	13.8	1,583.2	0.6	1.1	1	1	0
11/06/2021 14:00	0.5	13.9	1,490.6	0.5	1.0	1	1	0
11/06/2021 15:00	0.5	13.8	1,595.8	0.5	1.1	1	1	0
11/06/2021 16:00	-0.5	12.7	2,017.7	-0.2	1.4	1	1	1
11/06/2021 17:00	-0.4	12.3	2,105.8	-0.1	1.5	1	1	1
11/06/2021 18:00	-0.2	13.0	1,928.1	0.1	1.3	1	1	1
11/06/2021 19:00	0.6	13.8	1,672.3	0.6	1.2	1	1	0
11/06/2021 20:00	0.5	13.7	1,690.4	0.5	1.2	1	1	1
11/06/2021 21:00	-1.1	12.9	1,998.3	-0.7	1.4	1	1	1
11/06/2021 22:00	0.0	13.9	1,482.6	0.0	1.0	1	0	1
11/06/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.2	13.5	1,741.3	0.3	1.2	23 #	22 #	13 #
Minimum:	-1.1	12.3	1,482.6	-0.7	1.0	0	0	0
Maximum:	0.7	13.9	2,105.8	0.7	1.5	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/07/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/08/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/09/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/09/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/09/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/09/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/09/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/09/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/09/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/09/2021 07:00	0.0	17.5	372.4	0.0	0.3	1	0	0
11/09/2021 08:00	0.0	14.9	1,039.3	0.0	0.7	1	0	0
11/09/2021 09:00	0.6	13.8	1,722.8	0.6	1.2	1	1	0
11/09/2021 10:00	0.5	13.8	1,527.8	0.5	1.1	1	1	0
11/09/2021 11:00	0.5	13.8	1,581.8	0.5	1.1	1	1	0
11/09/2021 12:00	0.5	13.8	1,552.3	0.5	1.1	1	1	0
11/09/2021 13:00	0.6	13.8	1,684.2	0.6	1.2	1	1	0
11/09/2021 14:00	0.6	13.8	1,632.3	0.6	1.1	1	1	0
11/09/2021 15:00	0.4	13.8	1,532.2	0.4	1.1	1	1	0
11/09/2021 16:00	0.5	13.8	1,574.7	0.5	1.1	1	1	0
11/09/2021 17:00	-0.5	13.3	1,867.2	-0.2	1.3	1	1	1
11/09/2021 18:00	-0.5	12.3	2,146.4	-0.1	1.5	1	1	1
11/09/2021 19:00	-0.4	12.0	2,213.1	-0.1	1.5	1	1	1
11/09/2021 20:00	-0.2	12.3	2,117.6	0.1	1.5	1	1	1
11/09/2021 21:00	0.6	13.8	1,620.9	0.6	1.1	1	1	0
11/09/2021 22:00	0.6	13.8	1,732.5	0.6	1.2	1	1	0
11/09/2021 23:00	-0.7	12.9	2,019.2	-0.4	1.4	1	1	1
Average/Sum#:	0.2	13.7	1,643.3	0.3	1.1	17 #	15 #	5 #
Minimum:	-0.7	12.0	372.4	-0.4	0.3	0	0	0
Maximum:	0.6	17.5	2,213.1	0.6	1.5	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/10/2021 00:00	-0.1	13.3	1,842.8	0.1	1.3	1	1	1
11/10/2021 01:00	0.6	13.6	1,809.3	0.6	1.3	1	1	0
11/10/2021 02:00	0.5	13.8	1,596.6	0.5	1.1	1	1	1
11/10/2021 03:00	-0.9	13.1	1,970.3	-0.5	1.4	1	1	1
11/10/2021 04:00	-0.4	13.2	1,948.6	-0.1	1.4	1	1	1
11/10/2021 05:00	0.6	13.8	1,712.8	0.6	1.2	1	1	0
11/10/2021 06:00	0.7	13.8	1,793.0	0.7	1.3	1	1	1
11/10/2021 07:00	-1.1	13.0	2,003.3	-0.7	1.4	1	1	1
11/10/2021 08:00	-0.4	13.2	1,943.5	-0.1	1.4	1	1	1
11/10/2021 09:00	0.6	13.9	1,559.3	0.6	1.1	1	1	0
11/10/2021 10:00	0.5	13.9	1,479.9	0.5	1.0	1	1	0
11/10/2021 11:00	0.5	13.9	1,421.3	0.5	1.0	1	1	0
11/10/2021 12:00	0.5	13.9	1,472.0	0.5	1.0	1	1	0
11/10/2021 13:00	0.4	13.9	1,355.1	0.4	0.9	1	1	0
11/10/2021 14:00	0.5	13.9	1,495.5	0.5	1.0	1	1	0
11/10/2021 15:00	0.5	13.8	1,593.9	0.5	1.1	1	1	1
11/10/2021 16:00	-0.5	12.8	2,020.5	-0.2	1.4	1	1	1
11/10/2021 17:00	-0.2	12.7	2,038.8	0.1	1.4	1	1	1
11/10/2021 18:00	-0.4	12.5	2,093.5	-0.1	1.5	1	1	1
11/10/2021 19:00	-0.2	12.5	2,090.4	0.1	1.5	1	1	1
11/10/2021 20:00	-0.2	12.8	2,016.0	0.1	1.4	1	1	1
11/10/2021 21:00	0.6	13.8	1,704.2	0.6	1.2	1	1	0
11/10/2021 22:00	0.7	13.8	1,781.7	0.7	1.2	1	1	1
11/10/2021 23:00	-0.7	12.8	2,041.3	-0.4	1.4	1	1	1
Average/Sum#:	0.1	13.4	1,782.7	0.2	1.2	24 #	24 #	15 #
Minimum:	-1.1	12.5	1,355.1	-0.7	0.9	1	1	0
Maximum:	0.7	13.9	2,093.5	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/11/2021 00:00	-0.2	13.0	1,952.5	0.1	1.4	1	1	1
11/11/2021 01:00	0.0	15.8	584.7	0.0	0.4	1	0	0
11/11/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/11/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/11/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/11/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/11/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/11/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/11/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/11/2021 09:00	0.0	18.0	315.5	0.0	0.2	1	0	0
11/11/2021 10:00	0.0	15.6	790.8	0.0	0.6	1	0	0
11/11/2021 11:00	0.4	13.9	1,404.0	0.4	1.0	1	1	0
11/11/2021 12:00	0.4	13.9	1,369.5	0.4	1.0	1	1	0
11/11/2021 13:00	0.6	13.8	1,714.5	0.6	1.2	1	1	0
11/11/2021 14:00	0.5	13.9	1,519.7	0.5	1.1	1	1	0
11/11/2021 15:00	0.6	13.9	1,668.3	0.6	1.2	1	1	0
11/11/2021 16:00	-0.1	13.3	1,845.6	0.1	1.3	1	1	1
11/11/2021 17:00	-0.2	12.2	2,117.2	0.1	1.5	1	1	1
11/11/2021 18:00	-0.2	12.3	2,117.0	0.1	1.5	1	1	1
11/11/2021 19:00	-0.4	12.3	2,121.6	-0.1	1.5	1	1	1
11/11/2021 20:00	-0.4	12.3	2,096.0	-0.1	1.5	1	1	1
11/11/2021 21:00	0.5	13.8	1,691.2	0.5	1.2	1	1	0
11/11/2021 22:00	0.7	13.8	1,776.3	0.7	1.2	1	1	1
11/11/2021 23:00	-0.4	12.9	2,001.4	-0.1	1.4	1	1	1
Average/Sum#:	0.1	13.8	1,593.3	0.2	1.1	17 #	14 #	8 #
Minimum:	-0.4	12.2	315.5	-0.1	0.2	0	0	0
Maximum:	0.7	18.0	2,121.6	0.7	1.5	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/12/2021 00:00	-0.4	13.1	1,931.6	-0.1	1.4	1	1	1
11/12/2021 01:00	0.5	13.8	1,575.3	0.5	1.1	1	1	0
11/12/2021 02:00	0.5	13.8	1,542.3	0.5	1.1	1	1	0
11/12/2021 03:00	0.5	13.8	1,545.6	0.5	1.1	1	1	0
11/12/2021 04:00	0.2	13.8	1,585.9	0.4	1.1	1	1	1
11/12/2021 05:00	-0.4	12.6	2,049.3	-0.1	1.4	1	1	1
11/12/2021 06:00	-0.4	12.6	2,082.5	-0.1	1.5	1	1	1
11/12/2021 07:00	0.1	13.5	1,692.3	0.2	1.2	1	1	1
11/12/2021 08:00	0.4	13.9	1,425.3	0.4	1.0	1	1	0
11/12/2021 09:00	0.4	13.9	1,370.0	0.4	1.0	1	1	0
11/12/2021 10:00	0.4	13.9	1,375.6	0.4	1.0	1	1	0
11/12/2021 11:00	0.4	13.9	1,382.6	0.4	1.0	1	1	0
11/12/2021 12:00	0.3	13.9	1,384.5	0.4	1.0	1	1	0
11/12/2021 13:00	0.3	13.9	1,387.1	0.4	1.0	1	1	0
11/12/2021 14:00	0.3	13.9	1,388.9	0.4	1.0	1	1	0
11/12/2021 15:00	0.5	13.8	1,645.1	0.5	1.2	1	1	0
11/12/2021 16:00	0.5	13.8	1,587.3	0.5	1.1	1	1	0
11/12/2021 17:00	0.4	13.9	1,445.7	0.4	1.0	1	1	0
11/12/2021 18:00	0.2	13.8	1,592.6	0.4	1.1	1	1	1
11/12/2021 19:00	-0.7	12.7	2,060.1	-0.2	1.4	1	1	1
11/12/2021 20:00	-0.4	12.9	1,986.3	-0.1	1.4	1	1	1
11/12/2021 21:00	0.6	13.8	1,635.0	0.6	1.1	1	1	0
11/12/2021 22:00	0.5	13.8	1,699.8	0.5	1.2	1	1	1
11/12/2021 23:00	-0.5	12.8	2,041.9	-0.2	1.4	1	1	1
Average/Sum#:	0.2	13.6	1,642.2	0.3	1.2	24 #	24 #	10 #
Minimum:	-0.7	12.6	1,370.0	-0.2	1.0	1	1	0
Maximum:	0.6	13.9	2,082.5	0.6	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/13/2021 00:00	0.0	14.4	1,231.8	0.0	0.9	1	0	1
11/13/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/13/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/13/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/13/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/13/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/13/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/13/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/13/2021 08:00	0.0	18.0	317.7	0.0	0.2	1	0	0
11/13/2021 09:00	0.0	15.4	951.3	0.0	0.7	1	0	0
11/13/2021 10:00	0.2	13.9	1,388.0	0.3	1.0	1	1	0
11/13/2021 11:00	0.3	13.9	1,374.3	0.4	1.0	1	1	0
11/13/2021 12:00	0.4	13.9	1,384.4	0.4	1.0	1	1	0
11/13/2021 13:00	0.6	13.8	1,743.1	0.6	1.2	1	1	0
11/13/2021 14:00	0.5	13.9	1,499.1	0.5	1.0	1	1	0
11/13/2021 15:00	0.6	13.9	1,709.3	0.6	1.2	1	1	0
11/13/2021 16:00	0.5	13.7	1,785.0	0.5	1.2	1	1	1
11/13/2021 17:00	-0.5	12.6	2,039.4	-0.2	1.4	1	1	1
11/13/2021 18:00	-0.4	12.7	1,990.3	-0.1	1.4	1	1	1
11/13/2021 19:00	0.6	13.8	1,705.5	0.6	1.2	1	1	0
11/13/2021 20:00	0.7	13.8	1,793.6	0.7	1.3	1	1	1
11/13/2021 21:00	-0.9	12.8	2,036.0	-0.5	1.4	1	1	1
11/13/2021 22:00	0.0	13.7	1,498.3	0.0	1.0	1	0	1
11/13/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.2	14.0	1,527.9	0.2	1.1	16 #	12 #	7 #
Minimum:	-0.9	12.6	317.7	-0.5	0.2	0	0	0
Maximum:	0.7	18.0	2,039.4	0.7	1.4	1	1	1
%SI	33.33	33.33	33.33	33.33	33.33	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/14/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 09:00	0.0	18.6	225.9	0.0	0.2	1	0	0
11/14/2021 10:00	0.0	17.2	411.0	0.0	0.3	1	0	0
11/14/2021 11:00	0.0	14.4	1,197.1	0.0	0.8	1	0	0
11/14/2021 12:00	0.1	13.9	1,368.4	0.2	1.0	1	1	0
11/14/2021 13:00	0.2	13.9	1,380.1	0.3	1.0	1	1	0
11/14/2021 14:00	0.4	13.8	1,652.0	0.4	1.2	1	1	0
11/14/2021 15:00	0.5	13.8	1,612.8	0.5	1.1	1	1	0
11/14/2021 16:00	0.2	13.9	1,322.3	0.3	0.9	1	1	0
11/14/2021 17:00	0.2	13.8	1,592.4	0.4	1.1	1	1	1
11/14/2021 18:00	-0.7	12.6	2,061.9	-0.2	1.4	1	1	1
11/14/2021 19:00	-0.5	13.0	1,963.3	-0.2	1.4	1	1	1
11/14/2021 20:00	0.4	13.6	1,726.8	0.4	1.2	1	1	1
11/14/2021 21:00	0.4	13.8	1,590.0	0.4	1.1	1	1	1
11/14/2021 22:00	-1.1	12.7	2,056.4	-0.7	1.4	1	1	1
11/14/2021 23:00	-0.1	13.4	1,668.3	0.1	1.2	1	1	1
Average/Sum#:	0.0	14.2	1,455.2	0.1	1.0	15 #	12 #	7 #
Minimum:	-1.1	12.6	225.9	-0.7	0.2	0	0	0
Maximum:	0.5	18.6	2,061.9	0.5	1.4	1	1	1
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/15/2021 00:00	0.2	13.9	1,365.2	0.3	1.0	1	1	0
11/15/2021 01:00	0.3	13.9	1,359.6	0.4	1.0	1	1	0
11/15/2021 02:00	0.3	13.9	1,365.3	0.4	1.0	1	1	0
11/15/2021 03:00	0.3	13.9	1,371.1	0.4	1.0	1	1	0
11/15/2021 04:00	0.3	13.9	1,371.7	0.4	1.0	1	1	0
11/15/2021 05:00	0.4	13.8	1,445.3	0.4	1.0	1	1	0
11/15/2021 06:00	0.4	13.8	1,566.5	0.4	1.1	1	1	0
11/15/2021 07:00	0.5	13.8	1,748.6	0.5	1.2	1	1	0
11/15/2021 08:00	0.4	13.8	1,588.8	0.4	1.1	1	1	0
11/15/2021 09:00	0.3	13.9	1,416.2	0.4	1.0	1	1	0
11/15/2021 10:00	0.2	13.8	1,635.2	0.4	1.1	1	1	1
11/15/2021 11:00	-0.8	13.1	1,970.9	-0.5	1.4	1	1	1
11/15/2021 12:00	-0.7	13.1	1,965.0	-0.4	1.4	1	1	1
11/15/2021 13:00	-0.1	13.7	1,530.2	0.1	1.1	1	1	1
11/15/2021 14:00	0.4	13.8	1,602.0	0.4	1.1	1	1	0
11/15/2021 15:00	-0.5	13.0	1,965.9	-0.2	1.4	1	1	1
11/15/2021 16:00	-0.4	12.9	2,007.4	-0.1	1.4	1	1	1
11/15/2021 17:00	-0.5	13.1	1,955.3	-0.2	1.4	1	1	1
11/15/2021 18:00	-0.5	13.1	1,965.9	-0.2	1.4	1	1	1
11/15/2021 19:00	-0.4	12.5	2,093.6	-0.1	1.5	1	1	1
11/15/2021 20:00	-0.7	13.1	1,952.0	-0.4	1.4	1	1	1
11/15/2021 21:00	-0.7	13.1	1,952.9	-0.4	1.4	1	1	1
11/15/2021 22:00	-0.8	13.1	1,945.7	-0.5	1.4	1	1	1
11/15/2021 23:00	-0.8	13.1	1,933.9	-0.5	1.4	1	1	1
Average/Sum#:	-0.1	13.5	1,711.4	0.1	1.2	24 #	24 #	13 #
Minimum:	-0.8	12.5	1,359.6	-0.5	1.0	1	1	0
Maximum:	0.5	13.9	2,093.6	0.5	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/16/2021 00:00	0.0	15.5	671.1	0.0	0.5	1	0	0
11/16/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/16/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/16/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/16/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/16/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/16/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/16/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/16/2021 08:00	0.0	18.0	312.6	0.0	0.2	1	0	0
11/16/2021 09:00	0.0	15.9	752.6	0.0	0.5	1	0	0
11/16/2021 10:00	0.3	13.9	1,384.7	0.4	1.0	1	1	0
11/16/2021 11:00	0.4	13.9	1,378.4	0.4	1.0	1	1	0
11/16/2021 12:00	0.5	13.9	1,382.3	0.5	1.0	1	1	0
11/16/2021 13:00	0.6	13.8	1,541.1	0.6	1.1	1	1	0
11/16/2021 14:00	0.6	13.8	1,742.5	0.6	1.2	1	1	0
11/16/2021 15:00	0.5	13.9	1,497.9	0.5	1.0	1	1	0
11/16/2021 16:00	0.5	13.9	1,509.9	0.5	1.1	1	1	0
11/16/2021 17:00	-0.8	13.0	1,962.3	-0.4	1.4	1	1	1
11/16/2021 18:00	-0.8	12.7	2,057.6	-0.4	1.4	1	1	1
11/16/2021 19:00	-0.5	13.1	1,969.3	-0.2	1.4	1	1	1
11/16/2021 20:00	-0.4	12.4	2,132.7	-0.1	1.5	1	1	1
11/16/2021 21:00	-0.2	12.2	2,173.2	0.1	1.5	1	1	1
11/16/2021 22:00	-0.1	12.5	2,099.3	0.1	1.5	1	1	1
11/16/2021 23:00	-0.2	12.2	2,168.9	0.1	1.5	1	1	1
Average/Sum#:	0.0	13.8	1,572.7	0.2	1.1	17 #	14 #	7 #
Minimum:	-0.8	12.2	312.6	-0.4	0.2	0	0	0
Maximum:	0.6	18.0	2,173.2	0.6	1.5	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/17/2021 00:00	-0.1	12.9	2,000.4	0.1	1.4	1	1	1
11/17/2021 01:00	-0.2	13.2	1,953.8	-0.1	1.4	1	1	1
11/17/2021 02:00	-0.2	13.2	1,955.4	-0.1	1.4	1	1	1
11/17/2021 03:00	-0.4	13.2	1,955.8	-0.1	1.4	1	1	1
11/17/2021 04:00	-0.4	13.0	2,020.2	-0.1	1.4	1	1	1
11/17/2021 05:00	-0.4	12.8	2,043.5	-0.1	1.4	1	1	1
11/17/2021 06:00	-0.4	12.1	2,228.8	-0.1	1.6	1	1	1
11/17/2021 07:00	-0.2	12.4	2,137.6	0.1	1.5	1	1	1
11/17/2021 08:00	-0.8	13.3	1,959.0	-0.5	1.4	1	1	1
11/17/2021 09:00	-0.8	13.2	1,948.6	-0.5	1.4	1	1	1
11/17/2021 10:00	0.4	13.8	1,551.5	0.4	1.1	1	1	0
11/17/2021 11:00	-0.4	13.4	1,887.9	-0.2	1.3	1	1	1
11/17/2021 12:00	-0.7	13.2	1,955.7	-0.4	1.4	1	1	1
11/17/2021 13:00	0.1	13.7	1,513.8	0.2	1.1	1	1	1
11/17/2021 14:00	0.4	13.9	1,467.8	0.4	1.0	1	1	0
11/17/2021 15:00	-0.4	13.0	1,946.1	-0.1	1.4	1	1	1
11/17/2021 16:00	-0.4	12.6	2,069.2	-0.1	1.4	1	1	1
11/17/2021 17:00	-0.2	12.2	2,158.7	0.1	1.5	1	1	1
11/17/2021 18:00	-0.2	12.2	2,172.8	0.1	1.5	1	1	1
11/17/2021 19:00	-0.2	12.0	2,218.9	0.1	1.6	1	1	1
11/17/2021 20:00	-0.1	12.0	2,225.3	0.2	1.6	1	1	1
11/17/2021 21:00	-0.2	12.4	2,120.7	0.1	1.5	1	1	1
11/17/2021 22:00	-0.4	13.2	1,950.5	-0.1	1.4	1	1	1
11/17/2021 23:00	-0.4	13.2	1,954.7	-0.1	1.4	1	1	1
Average/Sum#:	-0.3	12.9	1,974.9	0.0	1.4	24 #	24 #	22 #
Minimum:	-0.8	12.0	1,467.8	-0.5	1.0	1	1	0
Maximum:	0.4	13.9	2,228.8	0.4	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/18/2021 00:00	-0.5	13.2	1,951.5	-0.2	1.4	1	1	1
11/18/2021 01:00	-0.5	13.2	1,953.1	-0.2	1.4	1	1	1
11/18/2021 02:00	-0.5	13.2	1,954.5	-0.2	1.4	1	1	1
11/18/2021 03:00	-0.5	13.2	1,957.9	-0.2	1.4	1	1	1
11/18/2021 04:00	-0.5	13.2	1,958.0	-0.2	1.4	1	1	1
11/18/2021 05:00	-0.5	12.7	2,049.3	-0.2	1.4	1	1	1
11/18/2021 06:00	-0.4	12.3	2,177.5	-0.1	1.5	1	1	1
11/18/2021 07:00	-0.2	12.4	2,137.5	0.1	1.5	1	1	1
11/18/2021 08:00	-0.2	12.8	2,037.1	0.1	1.4	1	1	1
11/18/2021 09:00	-0.5	13.2	1,933.0	-0.2	1.4	1	1	1
11/18/2021 10:00	0.5	13.8	1,665.8	0.5	1.2	1	1	1
11/18/2021 11:00	-0.8	13.1	1,957.5	-0.5	1.4	1	1	1
11/18/2021 12:00	-0.4	13.1	1,955.1	-0.1	1.4	1	1	1
11/18/2021 13:00	0.1	13.7	1,528.5	0.2	1.1	1	1	1
11/18/2021 14:00	0.4	13.9	1,504.3	0.4	1.1	1	1	0
11/18/2021 15:00	0.1	13.5	1,836.7	0.2	1.3	1	1	1
11/18/2021 16:00	-0.5	12.3	2,132.9	-0.1	1.5	1	1	1
11/18/2021 17:00	-0.4	12.1	2,173.0	-0.1	1.5	1	1	1
11/18/2021 18:00	-0.2	11.8	2,264.0	0.1	1.6	1	1	1
11/18/2021 19:00	-0.2	12.1	2,176.4	0.1	1.5	1	1	1
11/18/2021 20:00	-0.2	12.4	2,107.9	0.1	1.5	1	1	1
11/18/2021 21:00	-0.4	13.0	1,974.8	-0.1	1.4	1	1	1
11/18/2021 22:00	-0.5	13.2	1,942.5	-0.2	1.4	1	1	1
11/18/2021 23:00	-0.5	13.2	1,941.6	-0.2	1.4	1	1	1
Average/Sum#:	-0.3	12.9	1,969.6	0.0	1.4	24 #	24 #	23 #
Minimum:	-0.8	11.8	1,504.3	-0.5	1.1	1	1	0
Maximum:	0.5	13.9	2,264.0	0.5	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/19/2021 00:00	-0.7	13.2	1,940.1	-0.4	1.4	1	1	1
11/19/2021 01:00	-0.7	13.2	1,917.3	-0.4	1.3	1	1	1
11/19/2021 02:00	0.5	13.8	1,638.8	0.5	1.1	1	1	0
11/19/2021 03:00	-1.1	13.1	1,950.0	-0.7	1.4	1	1	1
11/19/2021 04:00	-0.4	12.7	2,041.1	-0.1	1.4	1	1	1
11/19/2021 05:00	-0.4	12.5	2,087.2	-0.1	1.5	1	1	1
11/19/2021 06:00	-0.4	12.3	2,141.1	-0.1	1.5	1	1	1
11/19/2021 07:00	-0.4	12.4	2,117.1	-0.1	1.5	1	1	1
11/19/2021 08:00	-0.4	13.0	1,984.3	-0.1	1.4	1	1	1
11/19/2021 09:00	-0.5	13.1	1,951.1	-0.2	1.4	1	1	1
11/19/2021 10:00	-0.5	13.1	1,951.2	-0.2	1.4	1	1	1
11/19/2021 11:00	-0.4	13.0	1,980.8	-0.1	1.4	1	1	1
11/19/2021 12:00	-0.4	13.0	1,976.8	-0.1	1.4	1	1	1
11/19/2021 13:00	-0.4	12.4	2,120.2	-0.1	1.5	1	1	1
11/19/2021 14:00	-0.2	12.4	2,116.6	0.1	1.5	1	1	1
11/19/2021 15:00	-0.2	12.7	2,029.8	0.1	1.4	1	1	1
11/19/2021 16:00	-0.2	12.6	2,057.4	0.1	1.4	1	1	1
11/19/2021 17:00	-0.2	12.6	2,070.8	0.1	1.4	1	1	1
11/19/2021 18:00	-0.2	12.6	2,080.5	0.1	1.5	1	1	1
11/19/2021 19:00	-0.4	13.1	1,946.7	-0.1	1.4	1	1	1
11/19/2021 20:00	0.6	13.8	1,684.6	0.6	1.2	1	1	0
11/19/2021 21:00	0.7	13.8	1,765.6	0.7	1.2	1	1	1
11/19/2021 22:00	-0.4	13.0	1,998.7	-0.1	1.4	1	1	1
11/19/2021 23:00	-0.2	13.0	1,979.3	0.1	1.4	1	1	1
Average/Sum#:	-0.3	12.9	1,980.3	0.0	1.4	24 #	24 #	22 #
Minimum:	-1.1	12.3	1,638.8	-0.7	1.1	1	1	0
Maximum:	0.7	13.8	2,141.1	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:08 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/20/2021 00:00	-0.4	13.2	1,937.5	-0.1	1.4	1	1	1
11/20/2021 01:00	0.6	13.9	1,586.2	0.6	1.1	1	1	0
11/20/2021 02:00	0.6	13.9	1,551.2	0.6	1.1	1	1	0
11/20/2021 03:00	0.6	13.9	1,549.8	0.6	1.1	1	1	0
11/20/2021 04:00	0.5	13.8	1,702.1	0.5	1.2	1	1	1
11/20/2021 05:00	-0.4	12.6	2,052.9	-0.1	1.4	1	1	1
11/20/2021 06:00	-0.2	12.9	2,007.6	0.1	1.4	1	1	1
11/20/2021 07:00	0.6	13.9	1,648.4	0.6	1.2	1	1	0
11/20/2021 08:00	0.6	13.9	1,660.5	0.6	1.2	1	1	0
11/20/2021 09:00	0.5	13.9	1,472.2	0.5	1.0	1	1	0
11/20/2021 10:00	0.6	13.9	1,518.7	0.6	1.1	1	1	0
11/20/2021 11:00	0.6	13.9	1,591.4	0.6	1.1	1	1	0
11/20/2021 12:00	0.6	14.0	1,453.4	0.6	1.0	1	1	0
11/20/2021 13:00	0.6	14.0	1,488.4	0.6	1.0	1	1	0
11/20/2021 14:00	0.6	13.9	1,506.0	0.6	1.1	1	1	0
11/20/2021 15:00	0.5	13.8	1,618.3	0.5	1.1	1	1	1
11/20/2021 16:00	-0.4	12.7	2,033.1	-0.1	1.4	1	1	1
11/20/2021 17:00	-0.2	12.6	2,073.9	0.1	1.5	1	1	1
11/20/2021 18:00	-0.1	13.0	1,956.5	0.1	1.4	1	1	1
11/20/2021 19:00	0.6	13.9	1,711.1	0.6	1.2	1	1	0
11/20/2021 20:00	0.6	13.7	1,799.7	0.6	1.3	1	1	0
11/20/2021 21:00	-0.5	12.8	2,045.9	-0.2	1.4	1	1	1
11/20/2021 22:00	-0.2	12.3	2,136.6	0.1	1.5	1	1	1
11/20/2021 23:00	0.2	13.2	1,878.6	0.4	1.3	1	1	1
Average/Sum#:	0.3	13.5	1,749.2	0.4	1.2	24 #	24 #	11 #
Minimum:	-0.5	12.3	1,453.4	-0.2	1.0	1	1	0
Maximum:	0.6	14.0	2,136.6	0.6	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/21/2021 00:00	0.7	13.8	1,748.0	0.7	1.2	1	1	1
11/21/2021 01:00	-0.4	13.2	1,955.7	-0.1	1.4	1	1	1
11/21/2021 02:00	0.0	14.2	1,408.9	0.0	1.0	1	0	1
11/21/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/21/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/21/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/21/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/21/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/21/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/21/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/21/2021 10:00	0.0	18.4	253.9	0.0	0.2	1	0	0
11/21/2021 11:00	0.0	16.1	733.3	0.0	0.5	1	0	0
11/21/2021 12:00	0.6	14.0	1,409.2	0.6	1.0	1	1	0
11/21/2021 13:00	0.6	14.0	1,373.1	0.6	1.0	1	1	0
11/21/2021 14:00	0.6	13.9	1,636.0	0.6	1.1	1	1	0
11/21/2021 15:00	0.6	13.9	1,607.2	0.6	1.1	1	1	0
11/21/2021 16:00	0.5	14.0	1,332.1	0.5	0.9	1	1	0
11/21/2021 17:00	0.7	13.9	1,586.5	0.7	1.1	1	1	1
11/21/2021 18:00	-0.5	12.7	2,050.3	-0.2	1.4	1	1	1
11/21/2021 19:00	-0.2	12.5	2,062.8	0.1	1.4	1	1	1
11/21/2021 20:00	0.6	13.9	1,693.0	0.6	1.2	1	1	0
11/21/2021 21:00	0.6	13.7	1,793.9	0.6	1.3	1	1	0
11/21/2021 22:00	-0.7	13.1	1,999.1	-0.4	1.4	1	1	1
11/21/2021 23:00	0.1	13.5	1,699.9	0.2	1.2	1	1	1
Average/Sum#:	0.2	14.0	1,549.6	0.3	1.1	17 #	14 #	8 #
Minimum:	-0.7	12.5	253.9	-0.4	0.2	0	0	0
Maximum:	0.7	18.4	2,062.8	0.7	1.4	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/22/2021 00:00	0.4	13.9	1,388.2	0.4	1.0	1	1	0
11/22/2021 01:00	0.4	13.9	1,359.8	0.4	1.0	1	1	0
11/22/2021 02:00	0.4	13.9	1,375.9	0.4	1.0	1	1	0
11/22/2021 03:00	0.4	13.9	1,498.2	0.4	1.0	1	1	0
11/22/2021 04:00	0.4	13.9	1,439.4	0.4	1.0	1	1	0
11/22/2021 05:00	0.4	13.9	1,498.7	0.4	1.0	1	1	1
11/22/2021 06:00	-1.4	13.2	1,984.3	-0.9	1.4	1	1	1
11/22/2021 07:00	-0.5	13.0	2,002.3	-0.2	1.4	1	1	1
11/22/2021 08:00	0.4	13.9	1,464.6	0.4	1.0	1	1	0
11/22/2021 09:00	0.4	13.9	1,395.8	0.4	1.0	1	1	0
11/22/2021 10:00	0.4	13.9	1,377.3	0.4	1.0	1	1	0
11/22/2021 11:00	0.4	13.9	1,383.5	0.4	1.0	1	1	0
11/22/2021 12:00	0.6	13.8	1,736.8	0.6	1.2	1	1	0
11/22/2021 13:00	0.6	13.9	1,519.6	0.6	1.1	1	1	0
11/22/2021 14:00	0.6	13.9	1,706.3	0.6	1.2	1	1	0
11/22/2021 15:00	0.6	13.9	1,746.7	0.6	1.2	1	1	0
11/22/2021 16:00	-0.1	13.0	1,957.7	0.1	1.4	1	1	1
11/22/2021 17:00	-0.4	12.6	2,071.8	-0.1	1.5	1	1	1
11/22/2021 18:00	-0.2	12.0	2,184.5	0.1	1.5	1	1	1
11/22/2021 19:00	-0.2	12.1	2,169.6	0.1	1.5	1	1	1
11/22/2021 20:00	-0.1	12.2	2,130.1	0.2	1.5	1	1	1
11/22/2021 21:00	0.6	13.8	1,646.2	0.6	1.2	1	1	0
11/22/2021 22:00	0.7	13.8	1,815.4	0.7	1.3	1	1	1
11/22/2021 23:00	-0.5	12.8	2,045.2	-0.2	1.4	1	1	1
Average/Sum#:	0.2	13.5	1,704.1	0.3	1.2	24 #	24 #	10 #
Minimum:	-1.4	12.0	1,359.8	-0.9	1.0	1	1	0
Maximum:	0.7	13.9	2,184.5	0.7	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/23/2021 00:00	-0.4	13.1	1,950.0	-0.1	1.4	1	1	1
11/23/2021 01:00	0.4	13.9	1,505.4	0.4	1.1	1	1	0
11/23/2021 02:00	0.5	13.8	1,714.3	0.5	1.2	1	1	1
11/23/2021 03:00	-1.8	13.2	1,965.3	-1.2	1.4	1	1	1
11/23/2021 04:00	-0.4	13.2	1,937.8	-0.1	1.4	1	1	1
11/23/2021 05:00	0.6	13.8	1,689.2	0.6	1.2	1	1	0
11/23/2021 06:00	0.5	13.8	1,632.8	0.5	1.1	1	1	0
11/23/2021 07:00	-0.9	13.0	2,003.7	-0.5	1.4	1	1	1
11/23/2021 08:00	-0.2	12.9	1,995.3	0.1	1.4	1	1	1
11/23/2021 09:00	0.6	13.8	1,629.9	0.6	1.1	1	1	0
11/23/2021 10:00	0.6	13.8	1,573.2	0.6	1.1	1	1	0
11/23/2021 11:00	0.6	13.9	1,509.4	0.6	1.1	1	1	0
11/23/2021 12:00	0.5	13.9	1,395.1	0.5	1.0	1	1	0
11/23/2021 13:00	0.6	13.9	1,565.8	0.6	1.1	1	1	0
11/23/2021 14:00	0.6	13.9	1,667.1	0.6	1.2	1	1	0
11/23/2021 15:00	0.4	13.8	1,624.2	0.4	1.1	1	1	1
11/23/2021 16:00	-0.4	12.7	2,056.8	-0.1	1.4	1	1	1
11/23/2021 17:00	-0.4	12.6	2,079.4	-0.1	1.5	1	1	1
11/23/2021 18:00	-0.2	12.6	2,086.0	0.1	1.5	1	1	1
11/23/2021 19:00	-0.2	13.1	1,949.4	-0.1	1.4	1	1	1
11/23/2021 20:00	0.6	13.9	1,709.1	0.6	1.2	1	1	0
11/23/2021 21:00	0.5	13.9	1,579.6	0.5	1.1	1	1	1
11/23/2021 22:00	-0.4	12.8	2,056.5	-0.1	1.4	1	1	1
11/23/2021 23:00	-0.2	13.1	1,965.6	-0.1	1.4	1	1	1
Average/Sum#:	0.1	13.4	1,785.0	0.2	1.3	24 #	24 #	14 #
Minimum:	-1.8	12.6	1,395.1	-1.2	1.0	1	1	0
Maximum:	0.6	13.9	2,086.0	0.6	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/24/2021 00:00	-0.4	13.2	1,944.3	-0.1	1.4	1	1	1
11/24/2021 01:00	0.5	13.9	1,515.5	0.5	1.1	1	1	0
11/24/2021 02:00	0.4	13.8	1,609.8	0.4	1.1	1	1	1
11/24/2021 03:00	-1.1	13.2	1,968.4	-0.7	1.4	1	1	1
11/24/2021 04:00	-0.4	13.1	1,967.3	-0.1	1.4	1	1	1
11/24/2021 05:00	0.6	13.9	1,680.8	0.6	1.2	1	1	0
11/24/2021 06:00	0.2	13.8	1,609.5	0.4	1.1	1	1	1
11/24/2021 07:00	-0.2	13.0	2,002.5	0.1	1.4	1	1	1
11/24/2021 08:00	-0.2	13.1	1,955.1	-0.1	1.4	1	1	1
11/24/2021 09:00	0.6	13.9	1,665.4	0.6	1.2	1	1	0
11/24/2021 10:00	0.6	13.9	1,629.1	0.6	1.1	1	1	0
11/24/2021 11:00	0.6	13.9	1,695.9	0.6	1.2	1	1	0
11/24/2021 12:00	0.6	13.9	1,611.6	0.6	1.1	1	1	0
11/24/2021 13:00	0.6	13.9	1,641.9	0.6	1.1	1	1	0
11/24/2021 14:00	0.6	13.9	1,622.1	0.6	1.1	1	1	0
11/24/2021 15:00	0.7	13.8	1,690.0	0.7	1.2	1	1	1
11/24/2021 16:00	-0.4	12.9	2,010.3	-0.1	1.4	1	1	1
11/24/2021 17:00	-0.4	12.7	2,053.3	-0.1	1.4	1	1	1
11/24/2021 18:00	-0.2	12.6	2,071.3	0.1	1.4	1	1	1
11/24/2021 19:00	-0.2	12.7	2,023.1	0.1	1.4	1	1	1
11/24/2021 20:00	0.6	13.9	1,607.9	0.6	1.1	1	1	0
11/24/2021 21:00	0.7	13.8	1,754.6	0.7	1.2	1	1	1
11/24/2021 22:00	-0.2	13.0	1,985.5	0.1	1.4	1	1	1
11/24/2021 23:00	-0.2	13.2	1,920.1	-0.1	1.3	1	1	1
Average/Sum#:	0.1	13.5	1,801.5	0.3	1.3	24 #	24 #	15 #
Minimum:	-1.1	12.6	1,515.5	-0.7	1.1	1	1	0
Maximum:	0.7	13.9	2,071.3	0.7	1.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/25/2021 00:00	0.0	15.8	577.1	0.0	0.4	1	0	0
11/25/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	15.8	577.1	0.0	0.4	1 #	0 #	0 #
Minimum:	0.0	15.8	577.1	0.0	0.4	0	0	0
Maximum:	0.0	15.8	577.1	0.0	0.4	1	0	0
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/26/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/27/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/28/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/29/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/29/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/29/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/29/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/29/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/29/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/29/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/29/2021 07:00	0.0	19.1	132.4	0.0	0.1	1	0	0
11/29/2021 08:00	0.0	17.2	373.8	0.0	0.3	1	0	0
11/29/2021 09:00	0.0	17.3	386.4	0.0	0.3	1	0	0
11/29/2021 10:00	0.0	16.7	571.3	0.0	0.4	1	0	0
11/29/2021 11:00	0.0	15.3	934.5	0.0	0.7	1	0	0
11/29/2021 12:00	0.6	13.9	1,369.2	0.6	1.0	1	1	0
11/29/2021 13:00	0.6	13.9	1,363.4	0.6	1.0	1	1	0
11/29/2021 14:00	0.6	13.8	1,623.3	0.6	1.1	1	1	0
11/29/2021 15:00	0.6	13.8	1,587.4	0.6	1.1	1	1	0
11/29/2021 16:00	0.6	13.7	1,703.6	0.6	1.2	1	1	0
11/29/2021 17:00	-0.2	12.7	1,956.3	0.1	1.4	1	1	1
11/29/2021 18:00	-0.4	12.2	2,108.8	-0.1	1.5	1	1	1
11/29/2021 19:00	-0.5	12.5	2,044.0	-0.2	1.4	1	1	1
11/29/2021 20:00	0.5	13.8	1,663.4	0.5	1.2	1	1	1
11/29/2021 21:00	0.5	13.7	1,792.3	0.5	1.3	1	1	1
11/29/2021 22:00	-0.4	12.9	1,987.5	-0.1	1.4	1	1	1
11/29/2021 23:00	0.0	14.3	1,216.7	0.0	0.9	1	0	1
Average/Sum#:	0.1	14.5	1,342.0	0.2	1.0	17 #	11 #	7 #
Minimum:	-0.5	12.2	132.4	-0.2	0.1	0	0	0
Maximum:	0.6	19.1	2,108.8	0.6	1.5	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/30/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/30/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/30/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/30/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/30/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/30/2021 05:00	0.0	18.3	259.4	0.0	0.2	1	0	0
11/30/2021 06:00	0.0	16.1	731.3	0.0	0.5	1	0	0
11/30/2021 07:00	0.4	13.9	1,335.2	0.4	0.9	1	1	0
11/30/2021 08:00	0.4	13.9	1,308.0	0.4	0.9	1	1	0
11/30/2021 09:00	0.4	13.9	1,307.4	0.4	0.9	1	1	0
11/30/2021 10:00	0.3	13.9	1,239.1	0.4	0.9	1	1	0
11/30/2021 11:00	0.4	13.9	1,236.7	0.4	0.9	1	1	0
11/30/2021 12:00	0.5	13.9	1,402.9	0.5	1.0	1	1	0
11/30/2021 13:00	0.6	13.9	1,474.7	0.6	1.0	1	1	0
11/30/2021 14:00	0.6	13.9	1,602.8	0.6	1.1	1	1	0
11/30/2021 15:00	0.6	13.9	1,745.5	0.6	1.2	1	1	0
11/30/2021 16:00	0.6	13.9	1,745.1	0.6	1.2	1	1	0
11/30/2021 17:00	0.6	13.9	1,744.5	0.6	1.2	1	1	0
11/30/2021 18:00	0.6	13.9	1,743.7	0.6	1.2	1	1	0
11/30/2021 19:00	0.6	13.9	1,736.0	0.6	1.2	1	1	0
11/30/2021 20:00	0.6	13.9	1,724.4	0.6	1.2	1	1	0
11/30/2021 21:00	0.6	13.9	1,727.3	0.6	1.2	1	1	0
11/30/2021 22:00	0.6	13.9	1,742.6	0.6	1.2	1	1	0
11/30/2021 23:00	0.2	13.1	1,951.3	0.4	1.4	1	1	1
Average/Sum#:	0.5	14.2	1,460.9	0.5	1.0	19 #	17 #	1 #
Minimum:	0.0	13.1	259.4	0.0	0.2	0	0	0
Maximum:	0.6	18.3	1,951.3	0.6	1.4	1	1	1
%SI	20.83	20.83	20.83	20.83	20.83	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/01/2021 00:00	0.2	13.1	1,953.1	0.4	1.4	1	1	1
12/01/2021 01:00	0.5	13.8	1,511.9	0.5	1.1	1	1	1
12/01/2021 02:00	0.4	13.9	1,312.6	0.4	0.9	1	1	0
12/01/2021 03:00	0.5	13.8	1,721.4	0.5	1.2	1	1	0
12/01/2021 04:00	0.1	13.5	1,846.0	0.2	1.3	1	1	1
12/01/2021 05:00	0.1	13.3	1,855.6	0.2	1.3	1	1	1
12/01/2021 06:00	0.1	13.5	1,705.5	0.2	1.2	1	1	1
12/01/2021 07:00	-0.5	12.0	2,228.2	-0.1	1.6	1	1	1
12/01/2021 08:00	-0.1	11.8	2,250.2	0.2	1.6	1	1	1
12/01/2021 09:00	-0.2	11.9	2,237.8	0.1	1.6	1	1	1
12/01/2021 10:00	-0.1	11.7	2,248.5	0.2	1.6	1	1	1
12/01/2021 11:00	-0.5	11.6	2,257.4	-0.1	1.6	1	1	1
12/01/2021 12:00	-0.5	11.5	2,278.4	-0.1	1.6	1	1	1
12/01/2021 13:00	-0.5	11.5	2,274.0	-0.1	1.6	1	1	1
12/01/2021 14:00	-0.5	11.5	2,277.2	-0.1	1.6	1	1	1
12/01/2021 15:00	-0.5	11.5	2,264.4	-0.1	1.6	1	1	1
12/01/2021 16:00	-0.5	11.5	2,266.3	-0.1	1.6	1	1	1
12/01/2021 17:00	-0.5	11.5	2,269.2	-0.1	1.6	1	1	1
12/01/2021 18:00	-0.5	11.5	2,270.4	-0.1	1.6	1	1	1
12/01/2021 19:00	-0.5	11.6	2,257.4	-0.1	1.6	1	1	1
12/01/2021 20:00	-0.9	12.2	2,151.0	-0.4	1.5	1	1	1
12/01/2021 21:00	-0.8	12.3	2,116.7	-0.4	1.5	1	1	1
12/01/2021 22:00	-0.8	12.6	2,064.1	-0.4	1.4	1	1	1
12/01/2021 23:00	-0.8	13.1	1,941.5	-0.5	1.4	1	1	1
Average/Sum#:	-0.3	12.3	2,065.0	0.0	1.5	24 #	24 #	22 #
Minimum:	-0.9	11.5	1,312.6	-0.5	0.9	1	1	0
Maximum:	0.5	13.9	2,278.4	0.5	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/02/2021 00:00	0.0	14.5	1,197.3	0.0	0.8	1	0	1
12/02/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2021 06:00	0.0	17.5	413.3	0.0	0.3	1	0	0
12/02/2021 07:00	0.0	14.3	1,176.4	0.0	0.8	1	0	0
12/02/2021 08:00	0.1	13.9	1,353.2	0.2	0.9	1	1	0
12/02/2021 09:00	0.1	13.9	1,386.4	0.2	1.0	1	1	0
12/02/2021 10:00	0.1	13.8	1,516.9	0.2	1.1	1	1	0
12/02/2021 11:00	0.2	13.9	1,580.5	0.3	1.1	1	1	0
12/02/2021 12:00	0.2	13.7	1,697.6	0.3	1.2	1	1	0
12/02/2021 13:00	0.2	13.6	1,797.2	0.3	1.3	1	1	0
12/02/2021 14:00	0.2	0.0	1,792.4	0.5	1.3	1	1	0
12/02/2021 15:00	0.2	13.7	1,787.0	0.3	1.3	1	1	0
12/02/2021 16:00	0.2	13.6	1,789.1	0.3	1.3	1	1	0
12/02/2021 17:00	0.2	13.6	1,788.2	0.3	1.3	1	1	0
12/02/2021 18:00	0.2	13.6	1,786.4	0.3	1.3	1	1	0
12/02/2021 19:00	0.2	13.6	1,787.4	0.3	1.3	1	1	0
12/02/2021 20:00	0.2	13.7	1,776.1	0.3	1.2	1	1	0
12/02/2021 21:00	-1.1	13.1	1,925.5	-0.7	1.3	1	1	1
12/02/2021 22:00	-1.1	12.6	2,031.9	-0.7	1.4	1	1	1
12/02/2021 23:00	-0.7	13.2	1,890.4	-0.4	1.3	1	1	1
Average/Sum#:	0.0	13.9	1,603.9	0.1	1.1	19 #	16 #	4 #
Minimum:	-1.1	12.6	413.3	-0.7	0.3	0	0	0
Maximum:	0.2	17.5	2,031.9	0.3	1.4	1	1	1
%SI	20.83	25.00	20.83	25.00	20.83	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/03/2021 00:00	0.1	13.9	1,352.5	0.2	0.9	1	1	0
12/03/2021 01:00	0.1	13.9	1,349.1	0.2	0.9	1	1	0
12/03/2021 02:00	0.1	13.9	1,359.2	0.1	1.0	1	1	0
12/03/2021 03:00	0.1	13.8	1,637.6	0.1	1.1	1	1	0
12/03/2021 04:00	0.1	13.8	1,622.4	0.1	1.1	1	1	0
12/03/2021 05:00	0.1	13.9	1,424.8	0.1	1.0	1	1	0
12/03/2021 06:00	0.1	13.8	1,634.2	0.2	1.1	1	1	0
12/03/2021 07:00	-0.1	13.8	1,892.2	0.1	1.3	1	1	1
12/03/2021 08:00	-1.1	11.9	2,218.9	-0.5	1.6	1	1	1
12/03/2021 09:00	-0.9	11.9	2,236.2	-0.4	1.6	1	1	1
12/03/2021 10:00	-0.8	11.8	2,247.0	-0.2	1.6	1	1	1
12/03/2021 11:00	-0.8	11.7	2,250.2	-0.2	1.6	1	1	1
12/03/2021 12:00	-0.8	11.7	2,250.8	-0.2	1.6	1	1	1
12/03/2021 13:00	-0.8	11.7	2,257.2	-0.2	1.6	1	1	1
12/03/2021 14:00	-0.8	11.7	2,256.8	-0.2	1.6	1	1	1
12/03/2021 15:00	-0.8	11.6	2,251.8	-0.2	1.6	1	1	1
12/03/2021 16:00	-0.7	12.8	1,925.7	-0.4	1.3	1	1	1
12/03/2021 17:00	0.2	13.5	1,818.3	0.3	1.3	1	1	0
12/03/2021 18:00	0.2	13.6	1,817.4	0.3	1.3	1	1	0
12/03/2021 19:00	-0.1	13.6	1,820.6	0.1	1.3	1	1	1
12/03/2021 20:00	-1.2	12.8	1,993.5	-0.7	1.4	1	1	1
12/03/2021 21:00	-1.1	12.3	2,117.7	-0.5	1.5	1	1	1
12/03/2021 22:00	-1.1	12.4	2,113.3	-0.5	1.5	1	1	1
12/03/2021 23:00	0.0	13.6	1,606.5	0.0	1.1	1	0	1
Average/Sum#:	-0.4	12.9	1,893.9	-0.1	1.3	24 #	23 #	15 #
Minimum:	-1.2	11.6	1,349.1	-0.7	0.9	1	0	0
Maximum:	0.2	13.9	2,257.2	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/04/2021 00:00	0.0	19.4	0.2	0.0	0.0	1	0	0
12/04/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2021 03:00	0.0	18.7	198.1	0.0	0.1	1	0	0
12/04/2021 04:00	0.0	15.6	853.7	0.0	0.6	1	0	0
12/04/2021 05:00	0.1	13.7	1,609.8	0.2	1.1	1	1	0
12/04/2021 06:00	-1.1	13.2	1,826.8	-0.7	1.3	1	1	1
12/04/2021 07:00	-0.5	13.0	1,878.9	-0.2	1.3	1	1	1
12/04/2021 08:00	0.2	13.5	1,861.7	0.3	1.3	1	1	0
12/04/2021 09:00	0.2	13.5	1,859.1	0.3	1.3	1	1	0
12/04/2021 10:00	0.2	13.8	1,800.3	0.3	1.3	1	1	0
12/04/2021 11:00	0.2	13.8	1,802.6	0.3	1.3	1	1	0
12/04/2021 12:00	0.1	13.8	1,647.7	0.2	1.2	1	1	0
12/04/2021 13:00	0.1	13.8	1,477.2	0.2	1.0	1	1	0
12/04/2021 14:00	0.1	13.9	1,371.9	0.1	1.0	1	1	0
12/04/2021 15:00	0.1	13.7	1,645.5	0.2	1.2	1	1	0
12/04/2021 16:00	0.1	13.8	1,577.4	0.2	1.1	1	1	0
12/04/2021 17:00	0.1	13.8	1,723.5	0.2	1.2	1	1	0
12/04/2021 18:00	-1.8	13.2	1,928.9	-1.2	1.4	1	1	1
12/04/2021 19:00	-0.9	13.3	1,852.4	-0.7	1.3	1	1	1
12/04/2021 20:00	0.2	13.8	1,634.1	0.3	1.1	1	1	0
12/04/2021 21:00	0.2	13.8	1,623.1	0.3	1.1	1	1	0
12/04/2021 22:00	0.1	13.8	1,603.5	0.2	1.1	1	1	0
12/04/2021 23:00	0.0	16.1	424.5	0.0	0.3	1	0	0
Average/Sum#:	-0.1	14.3	1,463.7	0.0	1.0	22 #	18 #	4 #
Minimum:	-1.8	13.0	0.2	-1.2	0.0	0	0	0
Maximum:	0.2	19.4	1,928.9	0.3	1.4	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/05/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2021 07:00	0.0	17.6	360.0	0.0	0.3	1	0	0
12/05/2021 08:00	0.0	15.4	865.3	0.0	0.6	1	0	0
12/05/2021 09:00	0.0	13.8	1,564.6	0.1	1.1	1	1	0
12/05/2021 10:00	0.0	13.8	1,545.5	0.1	1.1	1	1	0
12/05/2021 11:00	0.0	13.8	1,383.1	0.1	1.0	1	1	0
12/05/2021 12:00	0.0	13.8	1,372.4	0.1	1.0	1	1	0
12/05/2021 13:00	0.1	13.7	1,746.1	0.2	1.2	1	1	0
12/05/2021 14:00	0.1	13.8	1,535.4	0.2	1.1	1	1	0
12/05/2021 15:00	0.2	13.8	1,682.4	0.3	1.2	1	1	0
12/05/2021 16:00	-0.2	13.8	1,614.5	-0.1	1.1	1	1	1
12/05/2021 17:00	-1.1	12.9	1,990.9	-0.7	1.4	1	1	1
12/05/2021 18:00	-1.2	12.4	2,125.6	-0.7	1.5	1	1	1
12/05/2021 19:00	-1.1	12.2	2,150.2	-0.5	1.5	1	1	1
12/05/2021 20:00	-0.9	11.9	2,244.0	-0.4	1.6	1	1	1
12/05/2021 21:00	-0.9	12.1	2,188.7	-0.4	1.5	1	1	1
12/05/2021 22:00	-1.1	12.1	2,183.1	-0.5	1.5	1	1	1
12/05/2021 23:00	-0.9	12.5	2,100.5	-0.5	1.5	1	1	1
Average/Sum#:	-0.4	13.5	1,685.4	-0.2	1.2	17 #	15 #	8 #
Minimum:	-1.2	11.9	360.0	-0.7	0.3	0	0	0
Maximum:	0.2	17.6	2,244.0	0.3	1.6	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/06/2021 00:00	-0.9	12.9	1,993.5	-0.5	1.4	1	1	1
12/06/2021 01:00	0.2	13.8	1,715.2	0.3	1.2	1	1	0
12/06/2021 02:00	-0.2	13.7	1,766.3	-0.1	1.2	1	1	1
12/06/2021 03:00	-1.4	13.1	1,982.0	-0.9	1.4	1	1	1
12/06/2021 04:00	-1.1	13.0	1,965.8	-0.7	1.4	1	1	1
12/06/2021 05:00	0.1	13.8	1,650.8	0.2	1.2	1	1	0
12/06/2021 06:00	-0.9	13.2	1,898.0	-0.5	1.3	1	1	1
12/06/2021 07:00	-1.1	12.2	2,191.1	-0.5	1.5	1	1	1
12/06/2021 08:00	-1.1	12.1	2,192.7	-0.5	1.5	1	1	1
12/06/2021 09:00	-0.5	13.5	1,737.7	-0.2	1.2	1	1	1
12/06/2021 10:00	0.2	13.8	1,795.1	0.3	1.3	1	1	0
12/06/2021 11:00	-1.1	12.9	2,018.7	-0.7	1.4	1	1	1
12/06/2021 12:00	-1.1	12.1	2,201.3	-0.5	1.5	1	1	1
12/06/2021 13:00	-0.8	12.8	1,934.7	-0.4	1.4	1	1	1
12/06/2021 14:00	0.2	13.8	1,651.5	0.3	1.2	1	1	0
12/06/2021 15:00	-1.1	13.4	1,850.3	-0.7	1.3	1	1	1
12/06/2021 16:00	-1.1	12.6	2,090.0	-0.7	1.5	1	1	1
12/06/2021 17:00	-1.1	12.4	2,130.7	-0.5	1.5	1	1	1
12/06/2021 18:00	-1.1	11.9	2,230.7	-0.5	1.6	1	1	1
12/06/2021 19:00	-1.1	12.1	2,182.1	-0.5	1.5	1	1	1
12/06/2021 20:00	-0.9	12.0	2,211.0	-0.4	1.5	1	1	1
12/06/2021 21:00	-1.1	12.3	2,135.6	-0.5	1.5	1	1	1
12/06/2021 22:00	-1.1	12.3	2,132.6	-0.5	1.5	1	1	1
12/06/2021 23:00	-1.1	12.3	2,137.3	-0.5	1.5	1	1	1
Average/Sum#:	-0.8	12.8	1,991.4	-0.4	1.4	24 #	24 #	20 #
Minimum:	-1.4	11.9	1,650.8	-0.9	1.2	1	1	0
Maximum:	0.2	13.8	2,230.7	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/07/2021 00:00	-0.9	12.5	2,090.9	-0.5	1.5	1	1	1
12/07/2021 01:00	-0.2	13.7	1,537.4	-0.1	1.1	1	1	1
12/07/2021 02:00	-0.2	13.7	1,699.9	-0.1	1.2	1	1	1
12/07/2021 03:00	-0.5	13.1	1,962.6	-0.2	1.4	1	1	1
12/07/2021 04:00	-1.1	12.4	2,121.0	-0.5	1.5	1	1	1
12/07/2021 05:00	-0.1	13.8	1,730.5	0.1	1.2	1	1	1
12/07/2021 06:00	0.1	13.8	1,653.3	0.2	1.2	1	1	0
12/07/2021 07:00	-1.2	13.0	1,981.9	-0.8	1.4	1	1	1
12/07/2021 08:00	-1.1	12.0	2,214.4	-0.5	1.6	1	1	1
12/07/2021 09:00	-0.9	12.3	2,109.3	-0.5	1.5	1	1	1
12/07/2021 10:00	0.2	13.6	1,821.3	0.3	1.3	1	1	0
12/07/2021 11:00	0.2	13.7	1,800.1	0.3	1.3	1	1	0
12/07/2021 12:00	0.2	13.6	1,812.2	0.3	1.3	1	1	0
12/07/2021 13:00	-0.2	13.6	1,793.7	-0.1	1.3	1	1	1
12/07/2021 14:00	-1.1	12.4	2,078.9	-0.5	1.5	1	1	1
12/07/2021 15:00	-0.8	11.7	2,214.0	-0.2	1.5	1	1	1
12/07/2021 16:00	-0.7	11.6	2,246.9	-0.2	1.6	1	1	1
12/07/2021 17:00	-0.8	11.8	2,229.1	-0.2	1.6	1	1	1
12/07/2021 18:00	-0.8	11.8	2,240.7	-0.2	1.6	1	1	1
12/07/2021 19:00	-0.9	11.9	2,222.9	-0.4	1.6	1	1	1
12/07/2021 20:00	-0.8	11.9	2,220.2	-0.4	1.6	1	1	1
12/07/2021 21:00	-0.8	11.9	2,209.8	-0.4	1.5	1	1	1
12/07/2021 22:00	-0.9	12.2	2,138.8	-0.4	1.5	1	1	1
12/07/2021 23:00	-0.9	12.3	2,130.7	-0.5	1.5	1	1	1
Average/Sum#:	-0.6	12.7	2,010.9	-0.2	1.4	24 #	24 #	20 #
Minimum:	-1.2	11.6	1,537.4	-0.8	1.1	1	1	0
Maximum:	0.2	13.8	2,246.9	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/08/2021 00:00	-0.9	12.5	2,058.6	-0.5	1.4	1	1	1
12/08/2021 01:00	0.2	13.8	1,613.9	0.3	1.1	1	1	0
12/08/2021 02:00	-0.1	13.8	1,324.6	0.1	0.9	1	1	0
12/08/2021 03:00	0.2	13.7	1,745.4	0.3	1.2	1	1	0
12/08/2021 04:00	-0.8	13.4	1,840.6	-0.5	1.3	1	1	1
12/08/2021 05:00	-0.7	13.3	1,889.0	-0.4	1.3	1	1	1
12/08/2021 06:00	-0.1	13.7	1,771.3	0.1	1.2	1	1	1
12/08/2021 07:00	-1.7	12.9	2,003.1	-1.1	1.4	1	1	1
12/08/2021 08:00	-0.8	13.1	1,873.7	-0.5	1.3	1	1	1
12/08/2021 09:00	-0.1	13.8	1,375.8	0.1	1.0	1	1	0
12/08/2021 10:00	-0.1	13.8	1,342.7	0.1	0.9	1	1	0
12/08/2021 11:00	0.2	13.7	1,731.0	0.3	1.2	1	1	0
12/08/2021 12:00	-0.9	13.3	1,863.0	-0.7	1.3	1	1	1
12/08/2021 13:00	-0.9	13.3	1,849.3	-0.7	1.3	1	1	1
12/08/2021 14:00	0.0	13.8	1,328.4	0.1	0.9	1	1	0
12/08/2021 15:00	0.0	13.8	1,396.1	0.1	1.0	1	1	0
12/08/2021 16:00	0.1	13.7	1,721.3	0.2	1.2	1	1	0
12/08/2021 17:00	-1.8	13.0	1,981.0	-1.2	1.4	1	1	1
12/08/2021 18:00	-1.2	12.2	2,152.7	-0.7	1.5	1	1	1
12/08/2021 19:00	-1.2	12.2	2,143.1	-0.7	1.5	1	1	1
12/08/2021 20:00	-1.1	12.2	2,131.3	-0.5	1.5	1	1	1
12/08/2021 21:00	-1.1	12.5	2,070.2	-0.5	1.4	1	1	1
12/08/2021 22:00	-0.9	12.6	2,051.4	-0.5	1.4	1	1	1
12/08/2021 23:00	-1.1	12.5	2,076.9	-0.5	1.5	1	1	1
Average/Sum#:	-0.6	13.2	1,805.6	-0.3	1.3	24 #	24 #	15 #
Minimum:	-1.8	12.2	1,324.6	-1.2	0.9	1	1	0
Maximum:	0.2	13.8	2,152.7	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/09/2021 00:00	-1.1	13.0	1,944.8	-0.7	1.4	1	1	1
12/09/2021 01:00	0.1	13.8	1,500.7	0.1	1.1	1	1	0
12/09/2021 02:00	-0.5	13.7	1,584.5	-0.4	1.1	1	1	1
12/09/2021 03:00	-1.2	13.0	1,967.9	-0.8	1.4	1	1	1
12/09/2021 04:00	-1.1	12.8	1,999.0	-0.7	1.4	1	1	1
12/09/2021 05:00	0.1	13.8	1,553.7	0.1	1.1	1	1	0
12/09/2021 06:00	-0.4	13.7	1,639.6	-0.2	1.1	1	1	1
12/09/2021 07:00	-0.7	13.0	1,998.5	-0.4	1.4	1	1	1
12/09/2021 08:00	-0.7	12.7	2,055.2	-0.2	1.4	1	1	1
12/09/2021 09:00	-0.5	12.7	2,040.3	-0.2	1.4	1	1	1
12/09/2021 10:00	-0.1	13.7	1,610.1	0.1	1.1	1	1	1
12/09/2021 11:00	-0.1	13.8	1,715.0	0.1	1.2	1	1	1
12/09/2021 12:00	-0.9	12.8	2,026.3	-0.5	1.4	1	1	1
12/09/2021 13:00	-0.8	12.8	1,990.8	-0.4	1.4	1	1	1
12/09/2021 14:00	0.2	13.9	1,455.5	0.3	1.0	1	1	0
12/09/2021 15:00	-0.1	13.8	1,513.7	0.1	1.1	1	1	1
12/09/2021 16:00	-0.9	12.9	2,001.4	-0.5	1.4	1	1	1
12/09/2021 17:00	-1.1	12.3	2,149.9	-0.5	1.5	1	1	1
12/09/2021 18:00	-0.9	12.4	2,124.3	-0.5	1.5	1	1	1
12/09/2021 19:00	-0.9	12.3	2,154.1	-0.5	1.5	1	1	1
12/09/2021 20:00	-0.9	12.3	2,165.9	-0.5	1.5	1	1	1
12/09/2021 21:00	-0.9	12.3	2,169.5	-0.5	1.5	1	1	1
12/09/2021 22:00	-0.9	12.9	2,034.6	-0.5	1.4	1	1	1
12/09/2021 23:00	-0.8	12.7	2,071.8	-0.4	1.5	1	1	1
Average/Sum#:	-0.6	13.0	1,894.5	-0.3	1.3	24 #	24 #	21 #
Minimum:	-1.2	12.3	1,455.5	-0.8	1.0	1	1	0
Maximum:	0.2	13.9	2,169.5	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/10/2021 00:00	-0.9	13.1	1,960.1	-0.5	1.4	1	1	1
12/10/2021 01:00	0.1	13.9	1,544.3	0.2	1.1	1	1	0
12/10/2021 02:00	0.1	13.8	1,612.1	0.2	1.1	1	1	0
12/10/2021 03:00	-0.4	13.3	1,936.6	-0.1	1.4	1	1	1
12/10/2021 04:00	-0.5	13.3	1,958.8	-0.2	1.4	1	1	1
12/10/2021 05:00	0.1	13.8	1,626.8	0.2	1.1	1	1	0
12/10/2021 06:00	-0.2	13.8	1,756.9	-0.1	1.2	1	1	1
12/10/2021 07:00	-1.4	13.1	1,992.1	-0.9	1.4	1	1	1
12/10/2021 08:00	-1.1	13.2	1,961.8	-0.7	1.4	1	1	1
12/10/2021 09:00	0.2	13.8	1,619.4	0.3	1.1	1	1	0
12/10/2021 10:00	0.2	13.8	1,704.7	0.3	1.2	1	1	0
12/10/2021 11:00	0.2	13.8	1,633.7	0.3	1.1	1	1	0
12/10/2021 12:00	0.2	13.8	1,684.9	0.3	1.2	1	1	0
12/10/2021 13:00	0.2	13.9	1,607.0	0.3	1.1	1	1	0
12/10/2021 14:00	0.1	13.9	1,318.3	0.1	0.9	1	1	0
12/10/2021 15:00	0.1	13.8	1,583.9	0.2	1.1	1	1	0
12/10/2021 16:00	-1.2	13.1	1,973.0	-0.8	1.4	1	1	1
12/10/2021 17:00	-0.9	12.0	2,227.9	-0.4	1.6	1	1	1
12/10/2021 18:00	-0.9	12.2	2,192.2	-0.4	1.5	1	1	1
12/10/2021 19:00	-0.9	12.2	2,190.4	-0.4	1.5	1	1	1
12/10/2021 20:00	-0.9	12.1	2,222.1	-0.4	1.6	1	1	1
12/10/2021 21:00	-0.9	12.3	2,170.9	-0.5	1.5	1	1	1
12/10/2021 22:00	-0.9	12.6	2,125.4	-0.5	1.5	1	1	1
12/10/2021 23:00	-0.9	12.6	2,126.2	-0.5	1.5	1	1	1
Average/Sum#:	-0.4	13.2	1,863.7	-0.2	1.3	24 #	24 #	14 #
Minimum:	-1.4	12.0	1,318.3	-0.9	0.9	1	1	0
Maximum:	0.2	13.9	2,227.9	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/11/2021 00:00	-0.9	12.7	2,122.3	-0.5	1.5	1	1	1
12/11/2021 01:00	-0.8	12.9	2,057.5	-0.4	1.4	1	1	1
12/11/2021 02:00	-1.1	13.2	1,950.8	-0.7	1.4	1	1	1
12/11/2021 03:00	0.1	13.8	1,639.2	0.2	1.1	1	1	0
12/11/2021 04:00	-0.2	13.8	1,710.0	-0.1	1.2	1	1	1
12/11/2021 05:00	-0.9	12.9	2,026.9	-0.5	1.4	1	1	1
12/11/2021 06:00	-0.9	12.7	2,102.2	-0.5	1.5	1	1	1
12/11/2021 07:00	-0.8	12.9	2,035.9	-0.4	1.4	1	1	1
12/11/2021 08:00	0.1	13.8	1,614.0	0.1	1.1	1	1	0
12/11/2021 09:00	-0.2	13.8	1,398.6	0.0	1.0	1	1	0
12/11/2021 10:00	-0.2	13.8	1,432.0	0.0	1.0	1	1	0
12/11/2021 11:00	-0.2	13.9	1,331.4	-0.1	0.9	1	1	0
12/11/2021 12:00	-0.2	13.9	1,328.8	-0.1	0.9	1	1	0
12/11/2021 13:00	0.0	13.8	1,517.3	0.1	1.1	1	1	0
12/11/2021 14:00	0.1	13.8	1,555.1	0.1	1.1	1	1	0
12/11/2021 15:00	0.1	13.8	1,645.7	0.1	1.2	1	1	0
12/11/2021 16:00	-1.5	12.6	2,120.6	-0.9	1.5	1	1	1
12/11/2021 17:00	-1.1	12.0	2,235.4	-0.5	1.6	1	1	1
12/11/2021 18:00	-0.9	12.1	2,219.7	-0.4	1.6	1	1	1
12/11/2021 19:00	-0.9	11.9	2,268.6	-0.4	1.6	1	1	1
12/11/2021 20:00	-0.9	12.1	2,220.4	-0.4	1.6	1	1	1
12/11/2021 21:00	-0.9	11.8	2,264.3	-0.4	1.6	1	1	1
12/11/2021 22:00	-0.9	12.0	2,213.7	-0.4	1.5	1	1	1
12/11/2021 23:00	-0.9	12.5	2,111.0	-0.5	1.5	1	1	1
Average/Sum#:	-0.6	13.0	1,880.1	-0.3	1.3	24 #	24 #	15 #
Minimum:	-1.5	11.8	1,328.8	-0.9	0.9	1	1	0
Maximum:	0.1	13.9	2,268.6	0.2	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/12/2021 00:00	-0.9	12.5	2,099.1	-0.5	1.5	1	1	1
12/12/2021 01:00	-0.9	12.7	2,050.8	-0.5	1.4	1	1	1
12/12/2021 02:00	-1.1	13.2	1,934.7	-0.7	1.4	1	1	1
12/12/2021 03:00	0.1	13.8	1,610.8	0.2	1.1	1	1	0
12/12/2021 04:00	-0.2	13.7	1,745.7	-0.1	1.2	1	1	1
12/12/2021 05:00	-0.9	12.8	2,014.9	-0.5	1.4	1	1	1
12/12/2021 06:00	-1.1	12.7	2,045.5	-0.7	1.4	1	1	1
12/12/2021 07:00	-0.4	13.7	1,634.2	-0.2	1.1	1	1	1
12/12/2021 08:00	0.1	13.8	1,606.5	0.2	1.1	1	1	0
12/12/2021 09:00	-0.1	13.8	1,407.3	0.1	1.0	1	1	0
12/12/2021 10:00	0.1	13.8	1,610.9	0.1	1.1	1	1	0
12/12/2021 11:00	0.1	13.7	1,700.3	0.2	1.2	1	1	0
12/12/2021 12:00	0.1	13.8	1,622.6	0.2	1.1	1	1	0
12/12/2021 13:00	0.1	13.8	1,647.7	0.2	1.2	1	1	0
12/12/2021 14:00	0.1	13.8	1,605.2	0.1	1.1	1	1	0
12/12/2021 15:00	-0.8	13.7	1,598.0	-0.5	1.1	1	1	1
12/12/2021 16:00	-1.2	12.5	2,074.5	-0.7	1.5	1	1	1
12/12/2021 17:00	-1.1	12.1	2,158.6	-0.5	1.5	1	1	1
12/12/2021 18:00	-1.1	12.1	2,154.4	-0.5	1.5	1	1	1
12/12/2021 19:00	-0.8	11.8	2,216.5	-0.2	1.6	1	1	1
12/12/2021 20:00	-0.9	12.1	2,147.3	-0.4	1.5	1	1	1
12/12/2021 21:00	-0.9	12.1	2,153.4	-0.4	1.5	1	1	1
12/12/2021 22:00	-0.9	12.3	2,120.5	-0.5	1.5	1	1	1
12/12/2021 23:00	-0.9	12.5	2,067.2	-0.5	1.4	1	1	1
Average/Sum#:	-0.6	13.0	1,876.1	-0.3	1.3	24 #	24 #	16 #
Minimum:	-1.2	11.8	1,407.3	-0.7	1.0	1	1	0
Maximum:	0.1	13.8	2,216.5	0.2	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/13/2021 00:00	-1.1	13.0	1,935.9	-0.7	1.4	1	1	1
12/13/2021 01:00	0.2	13.7	1,705.2	0.3	1.2	1	1	0
12/13/2021 02:00	-0.4	13.7	1,684.2	-0.2	1.2	1	1	1
12/13/2021 03:00	-1.2	12.7	2,017.7	-0.7	1.4	1	1	1
12/13/2021 04:00	-1.1	12.9	1,949.1	-0.7	1.4	1	1	1
12/13/2021 05:00	0.1	13.8	1,595.8	0.1	1.1	1	1	0
12/13/2021 06:00	-0.4	13.6	1,788.5	-0.2	1.3	1	1	1
12/13/2021 07:00	-1.2	12.4	2,093.5	-0.7	1.5	1	1	1
12/13/2021 08:00	-0.9	11.9	2,194.6	-0.4	1.5	1	1	1
12/13/2021 09:00	-0.9	12.0	2,157.9	-0.4	1.5	1	1	1
12/13/2021 10:00	-0.9	12.2	2,125.1	-0.4	1.5	1	1	1
12/13/2021 11:00	-0.9	12.6	2,012.1	-0.5	1.4	1	1	1
12/13/2021 12:00	0.2	13.8	1,649.6	0.3	1.2	1	1	0
12/13/2021 13:00	-0.2	13.6	1,798.6	-0.1	1.3	1	1	1
12/13/2021 14:00	-1.1	12.5	2,049.8	-0.5	1.4	1	1	1
12/13/2021 15:00	-0.9	11.7	2,231.9	-0.4	1.6	1	1	1
12/13/2021 16:00	-0.7	11.5	2,286.9	-0.2	1.6	1	1	1
12/13/2021 17:00	-0.7	11.4	2,309.3	-0.2	1.6	1	1	1
12/13/2021 18:00	-0.7	11.4	2,312.4	-0.2	1.6	1	1	1
12/13/2021 19:00	-0.7	11.5	2,304.5	-0.2	1.6	1	1	1
12/13/2021 20:00	-0.8	12.0	2,174.8	-0.4	1.5	1	1	1
12/13/2021 21:00	-0.9	12.3	2,112.6	-0.5	1.5	1	1	1
12/13/2021 22:00	-0.9	12.6	2,048.9	-0.5	1.4	1	1	1
12/13/2021 23:00	-0.9	12.6	2,057.9	-0.5	1.4	1	1	1
Average/Sum#:	-0.7	12.6	2,024.9	-0.3	1.4	24 #	24 #	21 #
Minimum:	-1.2	11.4	1,595.8	-0.7	1.1	1	1	0
Maximum:	0.2	13.8	2,312.4	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/14/2021 00:00	-0.8	13.2	1,841.6	-0.5	1.3	1	1	1
12/14/2021 01:00	-0.1	13.9	1,300.6	0.0	0.9	1	1	0
12/14/2021 02:00	-0.1	13.8	1,320.8	0.1	0.9	1	1	0
12/14/2021 03:00	0.2	13.7	1,755.8	0.3	1.2	1	1	0
12/14/2021 04:00	-0.7	13.4	1,872.8	-0.4	1.3	1	1	1
12/14/2021 05:00	-0.7	13.4	1,871.7	-0.4	1.3	1	1	1
12/14/2021 06:00	-0.2	13.7	1,725.4	-0.1	1.2	1	1	1
12/14/2021 07:00	-0.9	12.6	2,085.5	-0.5	1.5	1	1	1
12/14/2021 08:00	-0.9	12.4	2,112.1	-0.5	1.5	1	1	1
12/14/2021 09:00	-0.7	12.9	1,976.2	-0.4	1.4	1	1	1
12/14/2021 10:00	0.1	13.8	1,622.7	0.2	1.1	1	1	0
12/14/2021 11:00	-0.4	13.8	1,640.8	-0.2	1.1	1	1	1
12/14/2021 12:00	-1.1	12.8	2,040.7	-0.7	1.4	1	1	1
12/14/2021 13:00	-0.9	13.1	1,934.5	-0.5	1.4	1	1	1
12/14/2021 14:00	0.2	13.8	1,649.6	0.3	1.2	1	1	0
12/14/2021 15:00	0.1	13.8	1,539.2	0.1	1.1	1	1	0
12/14/2021 16:00	-1.1	12.9	2,002.4	-0.7	1.4	1	1	1
12/14/2021 17:00	-0.8	11.7	2,301.1	-0.2	1.6	1	1	1
12/14/2021 18:00	-0.9	11.9	2,243.4	-0.4	1.6	1	1	1
12/14/2021 19:00	-0.8	11.7	2,299.5	-0.2	1.6	1	1	1
12/14/2021 20:00	-0.8	11.7	2,303.6	-0.2	1.6	1	1	1
12/14/2021 21:00	-0.9	12.0	2,238.0	-0.4	1.6	1	1	1
12/14/2021 22:00	-0.9	12.4	2,143.1	-0.5	1.5	1	1	1
12/14/2021 23:00	-0.8	12.8	2,049.8	-0.4	1.4	1	1	1
Average/Sum#:	-0.6	13.0	1,911.3	-0.3	1.3	24 #	24 #	18 #
Minimum:	-1.1	11.7	1,300.6	-0.7	0.9	1	1	0
Maximum:	0.2	13.9	2,303.6	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/15/2021 00:00	-1.1	13.1	1,973.0	-0.7	1.4	1	1	1
12/15/2021 01:00	0.1	13.8	1,567.8	0.1	1.1	1	1	0
12/15/2021 02:00	-0.5	13.8	1,675.9	-0.4	1.2	1	1	1
12/15/2021 03:00	-1.1	13.2	1,967.2	-0.7	1.4	1	1	1
12/15/2021 04:00	-1.2	13.2	1,948.6	-0.8	1.4	1	1	1
12/15/2021 05:00	0.0	13.8	1,589.5	0.1	1.1	1	1	0
12/15/2021 06:00	-0.8	13.3	1,899.4	-0.5	1.3	1	1	1
12/15/2021 07:00	-1.1	12.2	2,192.1	-0.5	1.5	1	1	1
12/15/2021 08:00	-0.9	12.9	1,997.6	-0.5	1.4	1	1	1
12/15/2021 09:00	0.1	13.8	1,599.5	0.1	1.1	1	1	0
12/15/2021 10:00	0.1	13.8	1,624.5	0.2	1.1	1	1	0
12/15/2021 11:00	-0.4	13.7	1,617.0	-0.2	1.1	1	1	1
12/15/2021 12:00	-0.8	12.8	2,020.0	-0.4	1.4	1	1	1
12/15/2021 13:00	-0.8	12.7	2,013.3	-0.4	1.4	1	1	1
12/15/2021 14:00	0.1	13.8	1,564.7	0.2	1.1	1	1	0
12/15/2021 15:00	-0.2	13.7	1,723.9	-0.1	1.2	1	1	1
12/15/2021 16:00	-1.1	12.3	2,148.3	-0.5	1.5	1	1	1
12/15/2021 17:00	-0.8	11.5	2,298.6	-0.2	1.6	1	1	1
12/15/2021 18:00	-0.8	11.6	2,292.5	-0.2	1.6	1	1	1
12/15/2021 19:00	-0.8	11.6	2,288.0	-0.2	1.6	1	1	1
12/15/2021 20:00	-0.8	11.6	2,290.7	-0.2	1.6	1	1	1
12/15/2021 21:00	-0.8	11.8	2,240.6	-0.2	1.6	1	1	1
12/15/2021 22:00	-1.1	12.3	2,141.0	-0.5	1.5	1	1	1
12/15/2021 23:00	-1.1	12.4	2,112.4	-0.5	1.5	1	1	1
Average/Sum#:	-0.7	12.9	1,949.4	-0.3	1.4	24 #	24 #	19 #
Minimum:	-1.2	11.5	1,564.7	-0.8	1.1	1	1	0
Maximum:	0.1	13.8	2,298.6	0.2	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/16/2021 00:00	-0.9	12.6	2,067.2	-0.5	1.4	1	1	1
12/16/2021 01:00	-0.9	13.0	1,974.1	-0.5	1.4	1	1	1
12/16/2021 02:00	0.1	13.8	1,583.8	0.2	1.1	1	1	0
12/16/2021 03:00	0.1	13.8	1,588.8	0.2	1.1	1	1	0
12/16/2021 04:00	-0.2	13.8	1,627.6	-0.1	1.1	1	1	1
12/16/2021 05:00	-1.1	12.6	2,052.6	-0.7	1.4	1	1	1
12/16/2021 06:00	-1.1	11.8	2,275.8	-0.5	1.6	1	1	1
12/16/2021 07:00	-0.9	11.9	2,256.8	-0.4	1.6	1	1	1
12/16/2021 08:00	-0.9	12.6	2,071.2	-0.5	1.4	1	1	1
12/16/2021 09:00	-0.9	13.0	1,980.8	-0.5	1.4	1	1	1
12/16/2021 10:00	0.1	13.8	1,497.3	0.1	1.0	1	1	0
12/16/2021 11:00	-0.4	13.8	1,625.2	-0.2	1.1	1	1	1
12/16/2021 12:00	-1.4	12.8	2,043.0	-0.8	1.4	1	1	1
12/16/2021 13:00	-1.1	13.2	1,946.2	-0.7	1.4	1	1	1
12/16/2021 14:00	0.1	13.8	1,562.9	0.2	1.1	1	1	0
12/16/2021 15:00	-0.4	13.8	1,601.6	-0.2	1.1	1	1	1
12/16/2021 16:00	-1.7	12.4	2,137.2	-0.9	1.5	1	1	1
12/16/2021 17:00	-0.9	11.8	2,274.9	-0.4	1.6	1	1	1
12/16/2021 18:00	-0.9	11.8	2,276.4	-0.4	1.6	1	1	1
12/16/2021 19:00	-0.8	11.8	2,278.2	-0.2	1.6	1	1	1
12/16/2021 20:00	-0.8	11.8	2,286.1	-0.2	1.6	1	1	1
12/16/2021 21:00	-0.8	11.9	2,271.3	-0.4	1.6	1	1	1
12/16/2021 22:00	-0.9	12.4	2,139.0	-0.5	1.5	1	1	1
12/16/2021 23:00	-0.9	12.6	2,088.5	-0.5	1.5	1	1	1
Average/Sum#:	-0.7	12.8	1,979.4	-0.4	1.4	24 #	24 #	20 #
Minimum:	-1.7	11.8	1,497.3	-0.9	1.0	1	1	0
Maximum:	0.1	13.8	2,286.1	0.2	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/17/2021 00:00	-0.9	13.2	1,942.9	-0.5	1.4	1	1	1
12/17/2021 01:00	0.1	13.8	1,565.8	0.2	1.1	1	1	0
12/17/2021 02:00	0.1	13.8	1,560.1	0.2	1.1	1	1	0
12/17/2021 03:00	-0.2	13.8	1,718.2	-0.1	1.2	1	1	1
12/17/2021 04:00	-1.1	12.9	2,025.9	-0.7	1.4	1	1	1
12/17/2021 05:00	-0.9	12.9	2,034.0	-0.5	1.4	1	1	1
12/17/2021 06:00	-1.1	12.0	2,248.6	-0.5	1.6	1	1	1
12/17/2021 07:00	-0.9	12.1	2,236.2	-0.4	1.6	1	1	1
12/17/2021 08:00	-0.9	13.0	2,037.9	-0.5	1.4	1	1	1
12/17/2021 09:00	-1.1	13.2	1,946.0	-0.7	1.4	1	1	1
12/17/2021 10:00	0.1	13.8	1,584.2	0.2	1.1	1	1	0
12/17/2021 11:00	0.1	13.8	1,551.7	0.2	1.1	1	1	0
12/17/2021 12:00	0.1	13.9	1,393.3	0.1	1.0	1	1	0
12/17/2021 13:00	0.2	13.8	1,659.0	0.3	1.2	1	1	0
12/17/2021 14:00	0.1	13.9	1,501.0	0.2	1.1	1	1	0
12/17/2021 15:00	-0.4	13.8	1,605.8	-0.2	1.1	1	1	1
12/17/2021 16:00	-1.2	12.7	2,069.4	-0.7	1.4	1	1	1
12/17/2021 17:00	-0.9	11.7	2,295.8	-0.4	1.6	1	1	1
12/17/2021 18:00	-0.8	11.7	2,299.7	-0.2	1.6	1	1	1
12/17/2021 19:00	-0.8	11.8	2,297.7	-0.2	1.6	1	1	1
12/17/2021 20:00	-0.8	11.7	2,303.1	-0.2	1.6	1	1	1
12/17/2021 21:00	-0.8	11.8	2,289.2	-0.2	1.6	1	1	1
12/17/2021 22:00	-0.9	12.5	2,137.5	-0.5	1.5	1	1	1
12/17/2021 23:00	-0.9	12.9	2,044.4	-0.5	1.4	1	1	1
Average/Sum#:	-0.6	12.9	1,931.1	-0.2	1.4	24 #	24 #	17 #
Minimum:	-1.2	11.7	1,393.3	-0.7	1.0	1	1	0
Maximum:	0.2	13.9	2,303.1	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/18/2021 00:00	-1.1	13.2	1,954.4	-0.7	1.4	1	1	1
12/18/2021 01:00	-0.4	13.8	1,623.0	-0.2	1.1	1	1	1
12/18/2021 02:00	0.1	13.8	1,744.1	0.2	1.2	1	1	0
12/18/2021 03:00	-1.1	12.9	2,071.3	-0.7	1.4	1	1	1
12/18/2021 04:00	-1.1	13.0	2,025.4	-0.7	1.4	1	1	1
12/18/2021 05:00	-0.2	13.8	1,694.8	-0.1	1.2	1	1	1
12/18/2021 06:00	-0.2	13.8	1,789.4	-0.1	1.3	1	1	1
12/18/2021 07:00	-1.5	13.0	2,048.1	-0.9	1.4	1	1	1
12/18/2021 08:00	-1.1	13.0	2,038.3	-0.7	1.4	1	1	1
12/18/2021 09:00	-1.1	13.0	2,011.9	-0.7	1.4	1	1	1
12/18/2021 10:00	0.1	13.8	1,564.8	0.1	1.1	1	1	0
12/18/2021 11:00	0.1	13.8	1,604.0	0.1	1.1	1	1	0
12/18/2021 12:00	0.1	13.8	1,564.9	0.1	1.1	1	1	0
12/18/2021 13:00	0.1	13.8	1,549.8	0.1	1.1	1	1	0
12/18/2021 14:00	0.1	13.8	1,555.0	0.1	1.1	1	1	0
12/18/2021 15:00	0.0	13.8	1,511.5	0.1	1.1	1	1	0
12/18/2021 16:00	-1.1	13.3	1,884.1	-0.7	1.3	1	1	1
12/18/2021 17:00	-1.2	12.1	2,219.0	-0.7	1.6	1	1	1
12/18/2021 18:00	-1.1	12.4	2,152.8	-0.5	1.5	1	1	1
12/18/2021 19:00	-1.1	12.0	2,247.1	-0.5	1.6	1	1	1
12/18/2021 20:00	-0.9	11.9	2,277.2	-0.4	1.6	1	1	1
12/18/2021 21:00	-0.9	12.3	2,177.8	-0.5	1.5	1	1	1
12/18/2021 22:00	-0.9	12.6	2,119.7	-0.5	1.5	1	1	1
12/18/2021 23:00	-0.9	12.9	2,038.6	-0.5	1.4	1	1	1
Average/Sum#:	-0.6	13.2	1,894.5	-0.3	1.3	24 #	24 #	17 #
Minimum:	-1.5	11.9	1,511.5	-0.9	1.1	1	1	0
Maximum:	0.1	13.8	2,277.2	0.2	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/19/2021 00:00	-0.9	12.7	2,084.6	-0.5	1.5	1	1	1
12/19/2021 01:00	-1.1	12.9	2,016.1	-0.7	1.4	1	1	1
12/19/2021 02:00	0.1	13.8	1,634.7	0.2	1.1	1	1	0
12/19/2021 03:00	0.1	13.7	1,705.1	0.2	1.2	1	1	0
12/19/2021 04:00	-1.2	13.0	2,010.4	-0.8	1.4	1	1	1
12/19/2021 05:00	-1.1	13.0	2,032.4	-0.7	1.4	1	1	1
12/19/2021 06:00	-1.1	13.1	1,992.7	-0.7	1.4	1	1	1
12/19/2021 07:00	-1.2	13.0	2,028.6	-0.8	1.4	1	1	1
12/19/2021 08:00	-1.2	13.0	2,025.2	-0.8	1.4	1	1	1
12/19/2021 09:00	-1.2	13.2	1,960.8	-0.8	1.4	1	1	1
12/19/2021 10:00	0.0	13.8	1,509.6	0.1	1.1	1	1	0
12/19/2021 11:00	0.0	13.8	1,506.8	0.1	1.1	1	1	0
12/19/2021 12:00	-0.1	13.8	1,467.5	0.1	1.0	1	1	0
12/19/2021 13:00	0.1	13.8	1,614.3	0.2	1.1	1	1	0
12/19/2021 14:00	0.1	13.8	1,615.0	0.2	1.1	1	1	0
12/19/2021 15:00	0.1	13.8	1,600.5	0.1	1.1	1	1	0
12/19/2021 16:00	-1.2	12.9	2,012.3	-0.8	1.4	1	1	1
12/19/2021 17:00	-1.1	12.1	2,222.8	-0.5	1.6	1	1	1
12/19/2021 18:00	-1.1	12.5	2,140.1	-0.5	1.5	1	1	1
12/19/2021 19:00	-1.1	12.3	2,173.0	-0.5	1.5	1	1	1
12/19/2021 20:00	-1.1	12.4	2,153.1	-0.5	1.5	1	1	1
12/19/2021 21:00	-1.1	12.5	2,141.0	-0.5	1.5	1	1	1
12/19/2021 22:00	-1.1	12.5	2,136.0	-0.5	1.5	1	1	1
12/19/2021 23:00	-0.9	12.6	2,094.6	-0.5	1.5	1	1	1
Average/Sum#:	-0.7	13.1	1,911.6	-0.4	1.3	24 #	24 #	16 #
Minimum:	-1.2	12.1	1,467.5	-0.8	1.0	1	1	0
Maximum:	0.1	13.8	2,222.8	0.2	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/20/2021 00:00	-0.9	12.7	2,094.2	-0.5	1.5	1	1	1
12/20/2021 01:00	-1.1	13.0	1,994.4	-0.7	1.4	1	1	1
12/20/2021 02:00	0.1	13.7	1,718.1	0.2	1.2	1	1	0
12/20/2021 03:00	-0.2	13.7	1,758.0	-0.1	1.2	1	1	1
12/20/2021 04:00	-1.2	12.9	2,038.4	-0.8	1.4	1	1	1
12/20/2021 05:00	-1.2	12.4	2,144.9	-0.7	1.5	1	1	1
12/20/2021 06:00	-1.1	12.1	2,243.0	-0.5	1.6	1	1	1
12/20/2021 07:00	-0.9	12.4	2,143.5	-0.5	1.5	1	1	1
12/20/2021 08:00	-0.9	12.9	2,016.4	-0.5	1.4	1	1	1
12/20/2021 09:00	0.1	13.8	1,663.9	0.2	1.2	1	1	0
12/20/2021 10:00	-0.2	13.8	1,354.3	0.0	0.9	1	1	0
12/20/2021 11:00	0.1	13.8	1,662.4	0.2	1.2	1	1	0
12/20/2021 12:00	-1.1	13.4	1,889.8	-0.7	1.3	1	1	1
12/20/2021 13:00	-1.1	12.4	2,153.3	-0.5	1.5	1	1	1
12/20/2021 14:00	-1.1	12.0	2,236.5	-0.5	1.6	1	1	1
12/20/2021 15:00	-0.9	12.0	2,229.7	-0.4	1.6	1	1	1
12/20/2021 16:00	-0.9	11.8	2,284.5	-0.4	1.6	1	1	1
12/20/2021 17:00	-0.9	11.7	2,299.6	-0.4	1.6	1	1	1
12/20/2021 18:00	-0.8	11.7	2,300.8	-0.2	1.6	1	1	1
12/20/2021 19:00	-0.8	11.7	2,313.4	-0.2	1.6	1	1	1
12/20/2021 20:00	-0.8	11.7	2,316.6	-0.2	1.6	1	1	1
12/20/2021 21:00	-0.8	11.7	2,321.3	-0.2	1.6	1	1	1
12/20/2021 22:00	-0.8	11.7	2,303.5	-0.2	1.6	1	1	1
12/20/2021 23:00	-0.9	12.4	2,142.3	-0.5	1.5	1	1	1
Average/Sum#:	-0.8	12.6	2,067.6	-0.3	1.4	24 #	24 #	20 #
Minimum:	-1.2	11.7	1,354.3	-0.8	0.9	1	1	0
Maximum:	0.1	13.8	2,321.3	0.2	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/21/2021 00:00	-0.9	12.5	2,098.4	-0.5	1.5	1	1	1
12/21/2021 01:00	0.2	13.8	1,701.1	0.3	1.2	1	1	0
12/21/2021 02:00	-0.2	13.7	1,817.0	-0.1	1.3	1	1	1
12/21/2021 03:00	-1.1	13.0	2,036.9	-0.7	1.4	1	1	1
12/21/2021 04:00	-1.1	13.0	1,996.3	-0.7	1.4	1	1	1
12/21/2021 05:00	0.1	13.8	1,686.5	0.2	1.2	1	1	0
12/21/2021 06:00	-0.2	13.8	1,772.5	-0.1	1.2	1	1	1
12/21/2021 07:00	-1.4	12.8	2,091.3	-0.8	1.5	1	1	1
12/21/2021 08:00	-1.1	11.9	2,282.0	-0.5	1.6	1	1	1
12/21/2021 09:00	-0.9	12.5	2,117.5	-0.5	1.5	1	1	1
12/21/2021 10:00	0.1	13.8	1,635.9	0.2	1.1	1	1	0
12/21/2021 11:00	-0.1	13.7	1,821.6	0.1	1.3	1	1	1
12/21/2021 12:00	-1.1	12.8	2,073.0	-0.7	1.5	1	1	1
12/21/2021 13:00	-1.1	12.9	2,012.9	-0.7	1.4	1	1	1
12/21/2021 14:00	0.1	13.8	1,665.2	0.2	1.2	1	1	0
12/21/2021 15:00	-0.1	13.7	1,820.4	0.1	1.3	1	1	1
12/21/2021 16:00	-1.8	12.8	2,071.1	-1.1	1.4	1	1	1
12/21/2021 17:00	-1.1	12.0	2,278.3	-0.5	1.6	1	1	1
12/21/2021 18:00	-0.9	11.9	2,292.2	-0.4	1.6	1	1	1
12/21/2021 19:00	-0.9	11.8	2,295.6	-0.4	1.6	1	1	1
12/21/2021 20:00	-0.9	11.8	2,293.3	-0.4	1.6	1	1	1
12/21/2021 21:00	-0.9	12.0	2,235.2	-0.4	1.6	1	1	1
12/21/2021 22:00	-0.9	12.5	2,139.8	-0.5	1.5	1	1	1
12/21/2021 23:00	-0.9	12.7	2,089.3	-0.5	1.5	1	1	1
Average/Sum#:	-0.7	12.9	2,013.5	-0.4	1.4	24 #	24 #	20 #
Minimum:	-1.8	11.8	1,635.9	-1.1	1.1	1	1	0
Maximum:	0.2	13.8	2,295.6	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/22/2021 00:00	-1.1	13.2	1,955.6	-0.7	1.4	1	1	1
12/22/2021 01:00	0.1	13.8	1,633.5	0.2	1.1	1	1	0
12/22/2021 02:00	-0.4	13.7	1,699.0	-0.2	1.2	1	1	1
12/22/2021 03:00	-1.4	13.2	1,974.4	-0.9	1.4	1	1	1
12/22/2021 04:00	-1.1	13.2	1,954.3	-0.7	1.4	1	1	1
12/22/2021 05:00	-0.2	13.8	1,473.4	0.0	1.0	1	1	0
12/22/2021 06:00	-0.4	13.7	1,709.1	-0.2	1.2	1	1	1
12/22/2021 07:00	-1.2	13.0	1,998.4	-0.8	1.4	1	1	1
12/22/2021 08:00	-1.1	13.0	1,989.2	-0.7	1.4	1	1	1
12/22/2021 09:00	0.0	13.8	1,453.1	0.1	1.0	1	1	0
12/22/2021 10:00	-0.7	13.7	1,532.4	-0.4	1.1	1	1	1
12/22/2021 11:00	-1.2	13.0	2,009.3	-0.8	1.4	1	1	1
12/22/2021 12:00	-1.2	13.2	1,955.8	-0.8	1.4	1	1	1
12/22/2021 13:00	-0.2	13.7	1,631.3	-0.1	1.1	1	1	1
12/22/2021 14:00	0.2	13.7	1,802.3	0.3	1.3	1	1	0
12/22/2021 15:00	-1.4	12.9	2,014.2	-0.8	1.4	1	1	1
12/22/2021 16:00	-1.1	12.6	2,073.9	-0.7	1.5	1	1	1
12/22/2021 17:00	-1.2	12.3	2,168.2	-0.7	1.5	1	1	1
12/22/2021 18:00	-0.9	12.8	2,031.0	-0.5	1.4	1	1	1
12/22/2021 19:00	-1.1	13.0	1,988.5	-0.7	1.4	1	1	1
12/22/2021 20:00	-0.9	12.8	2,009.9	-0.5	1.4	1	1	1
12/22/2021 21:00	0.1	13.8	1,561.2	0.1	1.1	1	1	0
12/22/2021 22:00	-0.2	13.7	1,767.2	-0.1	1.2	1	1	1
12/22/2021 23:00	-1.2	12.7	2,051.5	-0.7	1.4	1	1	1
Average/Sum#:	-0.7	13.3	1,851.5	-0.4	1.3	24 #	24 #	19 #
Minimum:	-1.4	12.3	1,453.1	-0.9	1.0	1	1	0
Maximum:	0.2	13.8	2,168.2	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/23/2021 00:00	-1.2	13.1	1,942.7	-0.8	1.4	1	1	1
12/23/2021 01:00	0.1	13.8	1,586.5	0.1	1.1	1	1	0
12/23/2021 02:00	-0.5	13.7	1,633.4	-0.4	1.1	1	1	1
12/23/2021 03:00	-1.4	13.1	1,962.4	-0.9	1.4	1	1	1
12/23/2021 04:00	-1.2	13.1	1,936.7	-0.8	1.4	1	1	1
12/23/2021 05:00	0.1	13.7	1,660.4	0.1	1.2	1	1	0
12/23/2021 06:00	-0.5	13.6	1,654.8	-0.2	1.2	1	1	1
12/23/2021 07:00	-1.2	12.5	2,072.6	-0.7	1.5	1	1	1
12/23/2021 08:00	-1.1	13.0	1,950.8	-0.7	1.4	1	1	1
12/23/2021 09:00	0.1	13.8	1,558.8	0.1	1.1	1	1	0
12/23/2021 10:00	-0.4	13.7	1,652.7	-0.2	1.2	1	1	1
12/23/2021 11:00	-0.9	13.0	1,957.5	-0.5	1.4	1	1	1
12/23/2021 12:00	-0.9	13.0	1,934.2	-0.5	1.4	1	1	1
12/23/2021 13:00	0.1	13.8	1,630.1	0.2	1.1	1	1	0
12/23/2021 14:00	-0.1	13.8	1,326.6	0.1	0.9	1	1	0
12/23/2021 15:00	0.1	13.7	1,632.9	0.2	1.1	1	1	0
12/23/2021 16:00	-0.9	13.2	1,853.6	-0.5	1.3	1	1	1
12/23/2021 17:00	-1.1	12.9	1,933.2	-0.7	1.4	1	1	1
12/23/2021 18:00	-0.2	13.7	1,677.9	-0.1	1.2	1	1	1
12/23/2021 19:00	-1.2	12.8	1,985.6	-0.7	1.4	1	1	1
12/23/2021 20:00	-1.1	12.9	1,944.8	-0.7	1.4	1	1	1
12/23/2021 21:00	0.1	13.8	1,475.6	0.1	1.0	1	1	0
12/23/2021 22:00	-0.5	13.7	1,597.7	-0.4	1.1	1	1	1
12/23/2021 23:00	-1.1	12.8	2,003.2	-0.7	1.4	1	1	1
Average/Sum#:	-0.6	13.3	1,773.5	-0.4	1.3	24 #	24 #	17 #
Minimum:	-1.4	12.5	1,326.6	-0.9	0.9	1	1	0
Maximum:	0.1	13.8	2,072.6	0.2	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/24/2021 00:00	-1.1	12.9	1,952.4	-0.7	1.4	1	1	1
12/24/2021 01:00	0.1	13.8	1,533.6	0.2	1.1	1	1	0
12/24/2021 02:00	0.1	13.8	1,483.7	0.1	1.0	1	1	0
12/24/2021 03:00	-0.1	13.8	1,364.6	0.1	1.0	1	1	0
12/24/2021 04:00	-0.1	13.8	1,369.5	0.1	1.0	1	1	0
12/24/2021 05:00	0.1	13.8	1,761.1	0.2	1.2	1	1	0
12/24/2021 06:00	-0.7	13.3	1,863.2	-0.4	1.3	1	1	1
12/24/2021 07:00	-0.8	13.2	1,893.7	-0.5	1.3	1	1	1
12/24/2021 08:00	-0.4	13.7	1,668.5	-0.2	1.2	1	1	1
12/24/2021 09:00	-1.4	13.0	1,974.9	-0.8	1.4	1	1	1
12/24/2021 10:00	-1.1	13.0	1,961.2	-0.7	1.4	1	1	1
12/24/2021 11:00	0.1	13.9	1,406.3	0.1	1.0	1	1	0
12/24/2021 12:00	0.2	13.8	1,629.2	0.3	1.1	1	1	0
12/24/2021 13:00	0.1	13.9	1,428.8	0.2	1.0	1	1	0
12/24/2021 14:00	0.1	13.9	1,417.3	0.2	1.0	1	1	0
12/24/2021 15:00	0.1	13.8	1,498.3	0.2	1.0	1	1	0
12/24/2021 16:00	-0.4	13.8	1,519.2	-0.2	1.1	1	1	1
12/24/2021 17:00	-0.9	12.9	1,998.6	-0.5	1.4	1	1	1
12/24/2021 18:00	-1.1	12.8	2,022.1	-0.7	1.4	1	1	1
12/24/2021 19:00	-0.9	12.8	2,027.1	-0.5	1.4	1	1	1
12/24/2021 20:00	-1.1	13.1	1,934.3	-0.7	1.4	1	1	1
12/24/2021 21:00	0.1	13.9	1,412.2	0.1	1.0	1	1	0
12/24/2021 22:00	-0.4	13.7	1,608.4	-0.2	1.1	1	1	1
12/24/2021 23:00	-1.1	12.7	2,042.7	-0.7	1.4	1	1	1
Average/Sum#:	-0.4	13.5	1,698.8	-0.2	1.2	24 #	24 #	13 #
Minimum:	-1.4	12.7	1,364.6	-0.8	1.0	1	1	0
Maximum:	0.2	13.9	2,042.7	0.3	1.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/25/2021 00:00	-1.1	13.1	1,951.8	-0.7	1.4	1	1	1
12/25/2021 01:00	0.1	13.8	1,560.4	0.2	1.1	1	1	0
12/25/2021 02:00	0.1	13.8	1,448.9	0.1	1.0	1	1	0
12/25/2021 03:00	-0.1	13.8	1,358.0	0.1	1.0	1	1	0
12/25/2021 04:00	-0.4	13.7	1,587.8	-0.2	1.1	1	1	1
12/25/2021 05:00	-1.1	12.8	2,018.2	-0.7	1.4	1	1	1
12/25/2021 06:00	-1.2	13.1	1,950.7	-0.8	1.4	1	1	1
12/25/2021 07:00	-0.4	13.7	1,587.5	-0.2	1.1	1	1	1
12/25/2021 08:00	0.1	13.8	1,616.8	0.1	1.1	1	1	0
12/25/2021 09:00	0.0	13.8	1,417.7	0.1	1.0	1	1	0
12/25/2021 10:00	0.1	13.8	1,637.8	0.2	1.1	1	1	0
12/25/2021 11:00	0.1	13.8	1,599.0	0.2	1.1	1	1	0
12/25/2021 12:00	0.1	13.8	1,564.8	0.2	1.1	1	1	0
12/25/2021 13:00	0.1	13.8	1,505.3	0.2	1.1	1	1	0
12/25/2021 14:00	0.1	13.8	1,611.8	0.2	1.1	1	1	0
12/25/2021 15:00	0.1	13.8	1,627.7	0.2	1.1	1	1	0
12/25/2021 16:00	-0.8	13.1	1,934.9	-0.5	1.4	1	1	1
12/25/2021 17:00	-1.2	12.5	2,081.0	-0.7	1.5	1	1	1
12/25/2021 18:00	-1.1	12.5	2,084.9	-0.5	1.5	1	1	1
12/25/2021 19:00	-1.1	12.6	2,076.0	-0.7	1.5	1	1	1
12/25/2021 20:00	-1.1	13.1	1,946.4	-0.7	1.4	1	1	1
12/25/2021 21:00	0.1	13.8	1,659.1	0.2	1.2	1	1	0
12/25/2021 22:00	-0.4	13.8	1,604.3	-0.2	1.1	1	1	1
12/25/2021 23:00	-1.2	12.9	2,019.0	-0.8	1.4	1	1	1
Average/Sum#:	-0.4	13.4	1,727.1	-0.2	1.2	24 #	24 #	12 #
Minimum:	-1.2	12.5	1,358.0	-0.8	1.0	1	1	0
Maximum:	0.1	13.8	2,084.9	0.2	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/26/2021 00:00	0.0	14.3	1,235.1	0.0	0.9	1	0	1
12/26/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 10:00	0.0	19.1	136.1	0.0	0.1	1	0	0
12/26/2021 11:00	0.0	17.2	397.2	0.0	0.3	1	0	0
12/26/2021 12:00	0.0	15.7	770.7	0.0	0.5	1	0	0
12/26/2021 13:00	0.0	13.8	1,403.5	0.1	1.0	1	1	0
12/26/2021 14:00	0.0	13.8	1,372.2	0.1	1.0	1	1	0
12/26/2021 15:00	0.1	13.8	1,649.6	0.1	1.2	1	1	0
12/26/2021 16:00	0.1	13.8	1,648.3	0.2	1.2	1	1	0
12/26/2021 17:00	0.1	13.7	1,759.2	0.2	1.2	1	1	0
12/26/2021 18:00	-0.2	13.7	1,762.5	-0.1	1.2	1	1	1
12/26/2021 19:00	-1.1	13.0	1,993.4	-0.7	1.4	1	1	1
12/26/2021 20:00	-1.1	12.8	2,007.9	-0.7	1.4	1	1	1
12/26/2021 21:00	0.1	13.8	1,635.5	0.2	1.1	1	1	0
12/26/2021 22:00	-0.2	13.7	1,719.1	-0.1	1.2	1	1	1
12/26/2021 23:00	-1.1	12.8	2,029.2	-0.7	1.4	1	1	1
Average/Sum#:	-0.2	14.3	1,434.6	-0.1	1.0	15 #	11 #	6 #
Minimum:	-1.1	12.8	136.1	-0.7	0.1	0	0	0
Maximum:	0.1	19.1	2,029.2	0.2	1.4	1	1	1
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/27/2021 00:00	-1.1	12.7	2,061.3	-0.7	1.4	1	1	1
12/27/2021 01:00	-1.1	12.9	1,993.2	-0.7	1.4	1	1	1
12/27/2021 02:00	0.2	13.8	1,667.4	0.3	1.2	1	1	0
12/27/2021 03:00	0.1	13.8	1,517.7	0.1	1.1	1	1	0
12/27/2021 04:00	0.1	13.8	1,526.5	0.1	1.1	1	1	0
12/27/2021 05:00	-0.2	13.7	1,685.5	-0.1	1.2	1	1	1
12/27/2021 06:00	-1.2	12.8	2,060.6	-0.7	1.4	1	1	1
12/27/2021 07:00	-1.2	12.1	2,196.9	-0.7	1.5	1	1	1
12/27/2021 08:00	-1.2	12.3	2,158.1	-0.7	1.5	1	1	1
12/27/2021 09:00	-1.1	12.1	2,190.4	-0.5	1.5	1	1	1
12/27/2021 10:00	-1.1	12.3	2,131.5	-0.5	1.5	1	1	1
12/27/2021 11:00	-0.9	12.4	2,074.5	-0.5	1.5	1	1	1
12/27/2021 12:00	0.2	13.8	1,710.1	0.3	1.2	1	1	0
12/27/2021 13:00	0.1	13.8	1,646.9	0.2	1.2	1	1	0
12/27/2021 14:00	-0.9	13.0	1,998.5	-0.5	1.4	1	1	1
12/27/2021 15:00	-1.1	12.4	2,147.8	-0.5	1.5	1	1	1
12/27/2021 16:00	-0.9	11.7	2,320.2	-0.4	1.6	1	1	1
12/27/2021 17:00	-0.8	11.6	2,334.5	-0.2	1.6	1	1	1
12/27/2021 18:00	-0.8	11.6	2,319.8	-0.2	1.6	1	1	1
12/27/2021 19:00	-0.8	11.7	2,319.4	-0.2	1.6	1	1	1
12/27/2021 20:00	-0.8	11.7	2,325.3	-0.2	1.6	1	1	1
12/27/2021 21:00	-0.8	11.7	2,289.1	-0.2	1.6	1	1	1
12/27/2021 22:00	-0.9	12.6	2,102.6	-0.5	1.5	1	1	1
12/27/2021 23:00	-0.9	12.7	2,082.8	-0.5	1.5	1	1	1
Average/Sum#:	-0.7	12.6	2,035.9	-0.3	1.4	24 #	24 #	19 #
Minimum:	-1.2	11.6	1,517.7	-0.7	1.1	1	1	0
Maximum:	0.2	13.8	2,334.5	0.3	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/28/2021 00:00	-1.2	13.2	1,958.0	-0.8	1.4	1	1	1
12/28/2021 01:00	0.1	13.8	1,536.4	0.2	1.1	1	1	0
12/28/2021 02:00	-0.4	13.8	1,639.2	-0.2	1.1	1	1	1
12/28/2021 03:00	-1.2	13.2	1,986.0	-0.8	1.4	1	1	1
12/28/2021 04:00	-1.1	13.2	1,956.4	-0.7	1.4	1	1	1
12/28/2021 05:00	0.1	13.8	1,581.9	0.1	1.1	1	1	0
12/28/2021 06:00	-0.4	13.7	1,744.9	-0.2	1.2	1	1	1
12/28/2021 07:00	-1.2	13.1	2,000.1	-0.8	1.4	1	1	1
12/28/2021 08:00	-1.1	12.9	2,038.7	-0.7	1.4	1	1	1
12/28/2021 09:00	-1.1	12.9	2,012.1	-0.7	1.4	1	1	1
12/28/2021 10:00	0.1	13.8	1,559.1	0.1	1.1	1	1	0
12/28/2021 11:00	0.0	13.8	1,446.4	0.1	1.0	1	1	0
12/28/2021 12:00	0.1	13.8	1,544.4	0.1	1.1	1	1	0
12/28/2021 13:00	-1.1	13.4	1,881.2	-0.7	1.3	1	1	1
12/28/2021 14:00	-0.9	13.1	1,939.7	-0.5	1.4	1	1	1
12/28/2021 15:00	-0.4	13.7	1,694.4	-0.2	1.2	1	1	1
12/28/2021 16:00	-1.2	12.4	2,151.1	-0.7	1.5	1	1	1
12/28/2021 17:00	-0.9	11.6	2,329.9	-0.4	1.6	1	1	1
12/28/2021 18:00	-0.9	11.7	2,295.2	-0.4	1.6	1	1	1
12/28/2021 19:00	-1.1	12.2	2,209.8	-0.5	1.5	1	1	1
12/28/2021 20:00	-1.1	12.3	2,171.2	-0.5	1.5	1	1	1
12/28/2021 21:00	-1.1	12.5	2,125.6	-0.5	1.5	1	1	1
12/28/2021 22:00	-1.1	12.6	2,110.5	-0.7	1.5	1	1	1
12/28/2021 23:00	-0.9	12.8	2,053.5	-0.5	1.4	1	1	1
Average/Sum#:	-0.8	13.1	1,915.2	-0.4	1.3	24 #	24 #	19 #
Minimum:	-1.2	11.6	1,446.4	-0.8	1.0	1	1	0
Maximum:	0.1	13.8	2,329.9	0.2	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/29/2021 00:00	-1.1	13.1	1,960.9	-0.7	1.4	1	1	1
12/29/2021 01:00	0.0	13.8	1,536.5	0.1	1.1	1	1	0
12/29/2021 02:00	-0.5	13.7	1,606.1	-0.4	1.1	1	1	1
12/29/2021 03:00	-1.2	13.1	1,988.4	-0.8	1.4	1	1	1
12/29/2021 04:00	-1.2	13.1	1,974.4	-0.8	1.4	1	1	1
12/29/2021 05:00	-0.2	13.8	1,479.0	0.0	1.0	1	1	0
12/29/2021 06:00	-0.2	13.7	1,781.0	-0.1	1.2	1	1	1
12/29/2021 07:00	-1.2	12.9	2,041.2	-0.8	1.4	1	1	1
12/29/2021 08:00	-1.1	13.0	2,009.2	-0.7	1.4	1	1	1
12/29/2021 09:00	-0.1	13.8	1,440.5	0.1	1.0	1	1	0
12/29/2021 10:00	-0.5	13.7	1,651.0	-0.4	1.2	1	1	1
12/29/2021 11:00	-1.2	12.8	2,055.2	-0.7	1.4	1	1	1
12/29/2021 12:00	-1.1	13.2	1,960.8	-0.7	1.4	1	1	1
12/29/2021 13:00	0.1	13.8	1,690.4	0.2	1.2	1	1	0
12/29/2021 14:00	-0.2	13.8	1,699.6	-0.1	1.2	1	1	1
12/29/2021 15:00	-1.1	12.8	2,046.7	-0.7	1.4	1	1	1
12/29/2021 16:00	-1.1	12.5	2,126.0	-0.5	1.5	1	1	1
12/29/2021 17:00	-1.1	11.8	2,303.4	-0.5	1.6	1	1	1
12/29/2021 18:00	-0.9	11.8	2,298.1	-0.4	1.6	1	1	1
12/29/2021 19:00	-0.9	11.7	2,315.1	-0.4	1.6	1	1	1
12/29/2021 20:00	-0.9	11.7	2,315.6	-0.4	1.6	1	1	1
12/29/2021 21:00	-0.9	12.4	2,152.7	-0.5	1.5	1	1	1
12/29/2021 22:00	-1.1	13.0	2,015.8	-0.7	1.4	1	1	1
12/29/2021 23:00	-0.9	12.9	2,043.7	-0.5	1.4	1	1	1
Average/Sum#:	-0.8	13.0	1,937.1	-0.4	1.4	24 #	24 #	20 #
Minimum:	-1.2	11.7	1,440.5	-0.8	1.0	1	1	0
Maximum:	0.1	13.8	2,315.6	0.2	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/30/2021 00:00	-1.1	13.2	1,959.6	-0.7	1.4	1	1	1
12/30/2021 01:00	0.2	13.8	1,665.7	0.3	1.2	1	1	0
12/30/2021 02:00	-0.1	13.8	1,383.9	0.1	1.0	1	1	0
12/30/2021 03:00	0.2	13.8	1,773.2	0.3	1.2	1	1	0
12/30/2021 04:00	-0.8	13.5	1,890.0	-0.5	1.3	1	1	1
12/30/2021 05:00	-0.8	13.4	1,861.3	-0.5	1.3	1	1	1
12/30/2021 06:00	-0.2	13.8	1,725.8	-0.1	1.2	1	1	1
12/30/2021 07:00	-1.4	12.9	2,067.7	-0.8	1.4	1	1	1
12/30/2021 08:00	-1.2	12.4	2,177.5	-0.7	1.5	1	1	1
12/30/2021 09:00	-1.1	12.7	2,063.6	-0.7	1.4	1	1	1
12/30/2021 10:00	0.1	13.8	1,656.9	0.2	1.2	1	1	0
12/30/2021 11:00	-0.4	13.8	1,692.9	-0.2	1.2	1	1	1
12/30/2021 12:00	-1.2	12.8	2,040.9	-0.7	1.4	1	1	1
12/30/2021 13:00	-1.1	13.2	1,935.5	-0.7	1.4	1	1	1
12/30/2021 14:00	0.2	13.8	1,678.0	0.3	1.2	1	1	0
12/30/2021 15:00	-0.4	13.8	1,635.1	-0.2	1.1	1	1	1
12/30/2021 16:00	-1.1	12.9	2,026.0	-0.7	1.4	1	1	1
12/30/2021 17:00	-1.2	12.3	2,158.0	-0.7	1.5	1	1	1
12/30/2021 18:00	-1.1	12.4	2,129.0	-0.5	1.5	1	1	1
12/30/2021 19:00	-1.1	12.9	2,030.1	-0.7	1.4	1	1	1
12/30/2021 20:00	-1.2	12.4	2,148.3	-0.7	1.5	1	1	1
12/30/2021 21:00	-1.1	12.4	2,130.5	-0.5	1.5	1	1	1
12/30/2021 22:00	-1.1	12.6	2,098.0	-0.7	1.5	1	1	1
12/30/2021 23:00	-0.9	12.8	2,057.9	-0.5	1.4	1	1	1
Average/Sum#:	-0.7	13.1	1,916.1	-0.4	1.3	24 #	24 #	19 #
Minimum:	-1.4	12.3	1,383.9	-0.8	1.0	1	1	0
Maximum:	0.2	13.8	2,177.5	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/31/2021 00:00	-1.1	13.1	1,952.2	-0.7	1.4	1	1	1
12/31/2021 01:00	0.1	13.8	1,544.8	0.2	1.1	1	1	0
12/31/2021 02:00	-0.1	13.9	1,351.7	0.0	0.9	1	1	0
12/31/2021 03:00	0.2	13.8	1,763.6	0.3	1.2	1	1	0
12/31/2021 04:00	-0.7	13.5	1,876.1	-0.4	1.3	1	1	1
12/31/2021 05:00	-0.8	13.4	1,858.3	-0.5	1.3	1	1	1
12/31/2021 06:00	-0.5	13.8	1,447.5	-0.4	1.0	1	1	1
12/31/2021 07:00	-1.1	12.8	2,046.6	-0.7	1.4	1	1	1
12/31/2021 08:00	-1.1	12.8	2,055.5	-0.7	1.4	1	1	1
12/31/2021 09:00	-1.2	13.2	1,960.5	-0.8	1.4	1	1	1
12/31/2021 10:00	0.1	13.8	1,515.5	0.1	1.1	1	1	0
12/31/2021 11:00	0.1	13.8	1,482.4	0.1	1.0	1	1	0
12/31/2021 12:00	0.1	13.8	1,610.8	0.2	1.1	1	1	0
12/31/2021 13:00	0.0	13.9	1,325.1	0.1	0.9	1	1	0
12/31/2021 14:00	0.1	13.9	1,466.8	0.1	1.0	1	1	0
12/31/2021 15:00	-0.2	13.8	1,652.8	-0.1	1.2	1	1	1
12/31/2021 16:00	-1.2	12.6	2,081.9	-0.7	1.5	1	1	1
12/31/2021 17:00	-1.2	12.2	2,178.5	-0.7	1.5	1	1	1
12/31/2021 18:00	-1.1	12.2	2,174.3	-0.5	1.5	1	1	1
12/31/2021 19:00	-1.1	12.1	2,212.4	-0.5	1.5	1	1	1
12/31/2021 20:00	-1.1	12.5	2,108.3	-0.5	1.5	1	1	1
12/31/2021 21:00	0.2	13.8	1,599.6	0.3	1.1	1	1	0
12/31/2021 22:00	-0.1	13.8	1,797.9	0.1	1.3	1	1	1
12/31/2021 23:00	-1.2	13.1	2,011.0	-0.8	1.4	1	1	1
Average/Sum#:	-0.5	13.3	1,794.8	-0.3	1.3	24 #	24 #	15 #
Minimum:	-1.2	12.1	1,325.1	-0.8	0.9	1	1	0
Maximum:	0.2	13.9	2,212.4	0.3	1.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/01/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2021 13:00	0.0	17.8	303.3	0.0	0.1	1	0	0
10/01/2021 14:00	0.0	15.2	960.0	0.0	0.3	1	0	0
10/01/2021 15:00	0.6	13.9	1,682.6	0.6	0.5	1	1	0
10/01/2021 16:00	0.6	13.8	1,663.3	0.6	0.5	1	1	0
10/01/2021 17:00	0.6	13.7	1,728.6	0.6	0.5	1	1	0
10/01/2021 18:00	0.6	13.7	1,722.5	0.6	0.5	1	1	0
10/01/2021 19:00	0.6	13.9	1,657.8	0.6	0.5	1	1	0
10/01/2021 20:00	0.6	13.9	1,641.4	0.6	0.5	1	1	0
10/01/2021 21:00	0.6	13.9	1,622.1	0.6	0.5	1	1	0
10/01/2021 22:00	0.6	14.0	1,638.2	0.6	0.5	1	1	0
10/01/2021 23:00	0.6	14.0	1,644.1	0.6	0.5	1	1	0
Average/Sum#:	0.5	14.3	1,478.5	0.5	0.4	11 #	9 #	0 #
Minimum:	0.0	13.7	303.3	0.0	0.1	0	0	0
Maximum:	0.6	17.8	1,728.6	0.6	0.5	1	1	0
%SI	54.17	54.17	54.17	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/02/2021 00:00	0.6	14.0	1,651.2	0.6	0.5	1	1	0
10/02/2021 01:00	0.6	14.0	1,639.5	0.6	0.5	1	1	0
10/02/2021 02:00	0.6	14.0	1,502.5	0.6	0.5	1	1	0
10/02/2021 03:00	0.6	14.0	1,623.4	0.6	0.5	1	1	0
10/02/2021 04:00	0.6	14.0	1,640.5	0.6	0.5	1	1	0
10/02/2021 05:00	0.6	14.0	1,634.3	0.6	0.5	1	1	0
10/02/2021 06:00	0.6	14.0	1,599.3	0.6	0.5	1	1	0
10/02/2021 07:00	0.6	14.0	1,433.8	0.6	0.4	1	1	0
10/02/2021 08:00	0.6	14.1	1,319.2	0.6	0.4	1	1	0
10/02/2021 09:00	0.6	14.1	1,285.9	0.6	0.4	1	1	0
10/02/2021 10:00	0.6	14.1	1,261.6	0.6	0.4	1	1	0
10/02/2021 11:00	0.6	14.1	1,261.8	0.6	0.4	1	1	0
10/02/2021 12:00	0.6	14.1	1,276.2	0.6	0.4	1	1	0
10/02/2021 13:00	0.6	14.1	1,342.6	0.6	0.4	1	1	0
10/02/2021 14:00	0.6	13.9	1,618.7	0.6	0.5	1	1	0
10/02/2021 15:00	0.6	13.9	1,660.3	0.6	0.5	1	1	0
10/02/2021 16:00	0.6	13.9	1,585.1	0.6	0.5	1	1	0
10/02/2021 17:00	0.6	13.7	1,704.2	0.6	0.5	1	1	0
10/02/2021 18:00	0.6	13.7	1,717.9	0.6	0.5	1	1	0
10/02/2021 19:00	0.6	13.9	1,654.7	0.6	0.5	1	1	0
10/02/2021 20:00	0.6	13.9	1,630.4	0.6	0.5	1	1	0
10/02/2021 21:00	0.6	13.9	1,648.0	0.6	0.5	1	1	0
10/02/2021 22:00	0.6	13.9	1,649.3	0.6	0.5	1	1	0
10/02/2021 23:00	0.6	13.9	1,643.2	0.6	0.5	1	1	0
Average/Sum#:	0.6	14.0	1,541.0	0.6	0.5	24 #	24 #	0 #
Minimum:	0.6	13.7	1,261.6	0.6	0.4	1	1	0
Maximum:	0.6	14.1	1,717.9	0.6	0.5	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/03/2021 00:00	0.6	14.0	1,593.1	0.6	0.5	1	1	0
10/03/2021 01:00	0.6	14.0	1,538.5	0.6	0.5	1	1	0
10/03/2021 02:00	0.6	14.0	1,418.9	0.6	0.4	1	1	0
10/03/2021 03:00	0.6	14.0	1,383.3	0.6	0.4	1	1	0
10/03/2021 04:00	0.6	14.0	1,435.6	0.6	0.4	1	1	0
10/03/2021 05:00	0.6	14.0	1,421.9	0.6	0.4	1	1	0
10/03/2021 06:00	0.6	14.0	1,425.6	0.6	0.4	1	1	0
10/03/2021 07:00	0.6	14.1	1,263.1	0.6	0.4	1	1	0
10/03/2021 08:00	0.6	14.0	1,326.2	0.6	0.4	1	1	0
10/03/2021 09:00	0.6	14.1	1,264.0	0.6	0.4	1	1	0
10/03/2021 10:00	0.6	14.1	1,266.8	0.6	0.4	1	1	0
10/03/2021 11:00	0.6	14.1	1,321.5	0.6	0.4	1	1	0
10/03/2021 12:00	0.6	14.1	1,384.6	0.6	0.4	1	1	0
10/03/2021 13:00	0.6	13.9	1,576.0	0.6	0.5	1	1	0
10/03/2021 14:00	0.6	13.9	1,648.0	0.6	0.5	1	1	0
10/03/2021 15:00	0.6	13.9	1,652.9	0.6	0.5	1	1	0
10/03/2021 16:00	0.6	13.9	1,570.0	0.6	0.5	1	1	0
10/03/2021 17:00	0.6	14.0	1,393.1	0.6	0.4	1	1	0
10/03/2021 18:00	0.6	13.8	1,702.2	0.6	0.5	1	1	0
10/03/2021 19:00	0.6	13.9	1,603.4	0.6	0.5	1	1	0
10/03/2021 20:00	0.6	13.9	1,639.6	0.6	0.5	1	1	0
10/03/2021 21:00	0.6	13.9	1,586.8	0.6	0.5	1	1	0
10/03/2021 22:00	0.6	13.9	1,628.4	0.6	0.5	1	1	0
10/03/2021 23:00	0.6	13.9	1,645.9	0.6	0.5	1	1	0
Average/Sum#:	0.6	14.0	1,487.1	0.6	0.5	24 #	24 #	0 #
Minimum:	0.6	13.8	1,263.1	0.6	0.4	1	1	0
Maximum:	0.6	14.1	1,702.2	0.6	0.5	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/04/2021 00:00	0.6	13.9	1,626.1	0.6	0.5	1	1	0
10/04/2021 01:00	0.6	13.9	1,502.3	0.6	0.5	1	1	0
10/04/2021 02:00	0.6	13.9	1,514.2	0.6	0.5	1	1	0
10/04/2021 03:00	0.6	13.9	1,578.6	0.6	0.5	1	1	0
10/04/2021 04:00	0.6	13.9	1,627.6	0.6	0.5	1	1	0
10/04/2021 05:00	0.6	13.9	1,642.0	0.6	0.5	1	1	0
10/04/2021 06:00	0.6	13.9	1,600.6	0.6	0.5	1	1	0
10/04/2021 07:00	0.6	14.0	1,567.1	0.6	0.5	1	1	0
10/04/2021 08:00	0.6	13.9	1,584.8	0.6	0.5	1	1	0
10/04/2021 09:00	0.6	14.0	1,566.7	0.6	0.5	1	1	0
10/04/2021 10:00	0.6	13.9	1,509.7	0.6	0.5	1	1	0
10/04/2021 11:00	0.6	13.9	1,599.5	0.6	0.5	1	1	0
10/04/2021 12:00	0.6	13.9	1,625.2	0.6	0.5	1	1	0
10/04/2021 13:00	0.6	13.9	1,580.6	0.6	0.5	1	1	0
10/04/2021 14:00	0.6	13.9	1,658.7	0.6	0.5	1	1	0
10/04/2021 15:00	0.6	13.9	1,595.5	0.6	0.5	1	1	0
10/04/2021 16:00	0.6	13.7	1,715.2	0.6	0.5	1	1	0
10/04/2021 17:00	0.6	13.7	1,721.5	0.6	0.5	1	1	0
10/04/2021 18:00	0.6	13.7	1,723.1	0.6	0.5	1	1	0
10/04/2021 19:00	0.6	13.8	1,703.6	0.6	0.5	1	1	0
10/04/2021 20:00	0.6	13.7	1,699.8	0.6	0.5	1	1	0
10/04/2021 21:00	0.6	13.8	1,696.6	0.6	0.5	1	1	0
10/04/2021 22:00	0.6	13.9	1,548.6	0.6	0.5	1	1	0
10/04/2021 23:00	0.6	14.0	1,560.2	0.6	0.5	1	1	0
Average/Sum#:	0.6	13.9	1,614.5	0.6	0.5	24 #	24 #	0 #
Minimum:	0.6	13.7	1,502.3	0.6	0.5	1	1	0
Maximum:	0.6	14.0	1,723.1	0.6	0.5	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/05/2021 00:00	0.6	14.0	1,530.4	0.6	0.5	1	1	0
10/05/2021 01:00	0.6	14.0	1,513.7	0.6	0.5	1	1	0
10/05/2021 02:00	0.6	14.0	1,499.5	0.6	0.4	1	1	0
10/05/2021 03:00	0.6	14.0	1,587.0	0.6	0.5	1	1	0
10/05/2021 04:00	0.6	14.0	1,543.8	0.6	0.5	1	1	0
10/05/2021 05:00	0.6	13.9	1,640.7	0.6	0.5	1	1	0
10/05/2021 06:00	0.6	13.9	1,647.6	0.6	0.5	1	1	0
10/05/2021 07:00	0.6	13.9	1,596.6	0.6	0.5	1	1	0
10/05/2021 08:00	0.6	13.9	1,563.3	0.6	0.5	1	1	0
10/05/2021 09:00	0.6	13.9	1,607.2	0.6	0.5	1	1	0
10/05/2021 10:00	0.6	13.9	1,621.3	0.6	0.5	1	1	0
10/05/2021 11:00	0.6	13.9	1,599.8	0.6	0.5	1	1	0
10/05/2021 12:00	0.6	13.9	1,666.5	0.6	0.5	1	1	0
10/05/2021 13:00	0.6	13.9	1,637.4	0.6	0.5	1	1	0
10/05/2021 14:00	0.6	14.0	1,592.9	0.6	0.5	1	1	0
10/05/2021 15:00	0.6	13.9	1,637.6	0.6	0.5	1	1	0
10/05/2021 16:00	0.6	13.9	1,636.2	0.6	0.5	1	1	0
10/05/2021 17:00	0.6	13.9	1,594.9	0.6	0.5	1	1	0
10/05/2021 18:00	0.6	13.9	1,587.4	0.6	0.5	1	1	0
10/05/2021 19:00	0.6	13.9	1,642.0	0.6	0.5	1	1	0
10/05/2021 20:00	0.6	13.9	1,553.5	0.6	0.5	1	1	0
10/05/2021 21:00	0.6	14.0	1,474.4	0.6	0.4	1	1	0
10/05/2021 22:00	0.6	14.0	1,598.7	0.6	0.5	1	1	0
10/05/2021 23:00	0.6	14.0	1,380.2	0.6	0.4	1	1	0
Average/Sum#:	0.6	13.9	1,581.4	0.6	0.5	24 #	24 #	0 #
Minimum:	0.6	13.9	1,380.2	0.6	0.4	1	1	0
Maximum:	0.6	14.0	1,666.5	0.6	0.5	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/06/2021 00:00	0.6	14.0	1,264.6	0.6	0.4	1	1	0
10/06/2021 01:00	0.6	14.0	1,264.8	0.6	0.4	1	1	0
10/06/2021 02:00	0.6	14.0	1,265.9	0.6	0.4	1	1	0
10/06/2021 03:00	0.6	14.0	1,266.5	0.6	0.4	1	1	0
10/06/2021 04:00	0.6	14.0	1,290.2	0.6	0.4	1	1	0
10/06/2021 05:00	0.6	13.9	1,499.2	0.6	0.4	1	1	0
10/06/2021 06:00	0.6	13.9	1,566.9	0.6	0.5	1	1	0
10/06/2021 07:00	0.6	13.9	1,532.6	0.6	0.5	1	1	0
10/06/2021 08:00	0.6	14.0	1,372.3	0.6	0.4	1	1	0
10/06/2021 09:00	0.6	13.9	1,553.5	0.6	0.5	1	1	0
10/06/2021 10:00	0.6	13.9	1,536.2	0.6	0.5	1	1	0
10/06/2021 11:00	0.6	13.9	1,476.4	0.6	0.4	1	1	0
10/06/2021 12:00	0.6	13.9	1,572.5	0.6	0.5	1	1	0
10/06/2021 13:00	0.6	13.9	1,602.3	0.6	0.5	1	1	0
10/06/2021 14:00	0.6	13.9	1,646.5	0.6	0.5	1	1	0
10/06/2021 15:00	0.6	13.9	1,631.3	0.6	0.5	1	1	0
10/06/2021 16:00	0.6	13.9	1,603.7	0.6	0.5	1	1	0
10/06/2021 17:00	0.6	14.0	1,362.3	0.6	0.4	1	1	0
10/06/2021 18:00	0.6	13.9	1,556.8	0.6	0.5	1	1	0
10/06/2021 19:00	0.6	13.9	1,586.2	0.6	0.5	1	1	0
10/06/2021 20:00	0.6	13.8	1,684.4	0.6	0.5	1	1	0
10/06/2021 21:00	0.6	13.9	1,603.1	0.6	0.5	1	1	0
10/06/2021 22:00	0.6	13.9	1,549.1	0.6	0.5	1	1	0
10/06/2021 23:00	0.6	13.9	1,651.3	0.6	0.5	1	1	0
Average/Sum#:	0.6	13.9	1,497.4	0.6	0.5	24 #	24 #	0 #
Minimum:	0.6	13.8	1,264.6	0.6	0.4	1	1	0
Maximum:	0.6	14.0	1,684.4	0.6	0.5	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/07/2021 00:00	0.6	13.9	1,516.4	0.6	0.5	1	1	0
10/07/2021 01:00	0.6	13.9	1,518.1	0.6	0.5	1	1	0
10/07/2021 02:00	0.6	13.9	1,511.9	0.6	0.5	1	1	0
10/07/2021 03:00	0.6	14.0	1,437.1	0.6	0.4	1	1	0
10/07/2021 04:00	0.6	13.9	1,622.6	0.6	0.5	1	1	0
10/07/2021 05:00	0.6	13.9	1,606.6	0.6	0.5	1	1	0
10/07/2021 06:00	0.6	13.9	1,655.9	0.6	0.5	1	1	0
10/07/2021 07:00	0.6	13.9	1,598.4	0.6	0.5	1	1	0
10/07/2021 08:00	0.6	13.9	1,588.1	0.6	0.5	1	1	0
10/07/2021 09:00	0.6	13.9	1,511.8	0.6	0.5	1	1	0
10/07/2021 10:00	0.6	14.0	1,492.8	0.6	0.4	1	1	0
10/07/2021 11:00	0.6	14.0	1,508.2	0.6	0.5	1	1	0
10/07/2021 12:00	0.6	14.0	1,511.2	0.6	0.5	1	1	0
10/07/2021 13:00	0.6	14.0	1,510.6	0.6	0.5	1	1	0
10/07/2021 14:00	0.6	13.9	1,646.1	0.6	0.5	1	1	0
10/07/2021 15:00	0.6	13.9	1,631.2	0.6	0.5	1	1	0
10/07/2021 16:00	0.6	13.9	1,662.5	0.6	0.5	1	1	0
10/07/2021 17:00	0.6	13.7	1,758.1	0.6	0.5	1	1	0
10/07/2021 18:00	0.6	13.8	1,713.2	0.6	0.5	1	1	0
10/07/2021 19:00	0.6	13.9	1,613.7	0.6	0.5	1	1	0
10/07/2021 20:00	0.6	13.8	1,596.7	0.6	0.5	1	1	0
10/07/2021 21:00	0.6	13.9	1,631.6	0.6	0.5	1	1	0
10/07/2021 22:00	0.6	13.9	1,643.1	0.6	0.5	1	1	0
10/07/2021 23:00	0.6	14.0	1,560.8	0.6	0.5	1	1	0
Average/Sum#:	0.6	13.9	1,585.3	0.6	0.5	24 #	24 #	0 #
Minimum:	0.6	13.7	1,437.1	0.6	0.4	1	1	0
Maximum:	0.6	14.0	1,758.1	0.6	0.5	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/08/2021 00:00	0.6	14.0	1,480.0	0.6	0.4	1	1	0
10/08/2021 01:00	0.6	13.9	1,467.1	0.6	0.4	1	1	0
10/08/2021 02:00	0.6	13.9	1,498.1	0.6	0.4	1	1	0
10/08/2021 03:00	0.6	13.9	1,550.9	0.6	0.5	1	1	0
10/08/2021 04:00	0.6	13.9	1,627.0	0.6	0.5	1	1	0
10/08/2021 05:00	0.6	13.9	1,523.2	0.6	0.5	1	1	0
10/08/2021 06:00	0.6	13.9	1,619.0	0.6	0.5	1	1	0
10/08/2021 07:00	0.6	13.9	1,504.9	0.6	0.5	1	1	0
10/08/2021 08:00	0.6	13.9	1,513.8	0.6	0.5	1	1	0
10/08/2021 09:00	0.6	14.0	1,365.0	0.6	0.4	1	1	0
10/08/2021 10:00	0.6	13.9	1,621.7	0.6	0.5	1	1	0
10/08/2021 11:00	0.6	14.0	1,434.4	0.6	0.4	1	1	0
10/08/2021 12:00	0.6	14.0	1,568.8	0.6	0.5	1	1	0
10/08/2021 13:00	0.6	14.0	1,536.6	0.6	0.5	1	1	0
10/08/2021 14:00	0.6	14.0	1,503.6	0.6	0.5	1	1	0
10/08/2021 15:00	0.6	14.0	1,583.3	0.6	0.5	1	1	0
10/08/2021 16:00	0.6	14.0	1,643.4	0.6	0.5	1	1	0
10/08/2021 17:00	0.6	14.0	1,567.2	0.6	0.5	1	1	0
10/08/2021 18:00	0.6	14.0	1,582.3	0.6	0.5	1	1	0
10/08/2021 19:00	0.6	14.0	1,609.4	0.6	0.5	1	1	0
10/08/2021 20:00	0.6	14.0	1,352.2	0.6	0.4	1	1	0
10/08/2021 21:00	0.0	16.3	409.7	0.0	0.1	1	0	0
10/08/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.6	14.1	1,480.1	0.6	0.5	22 #	21 #	0 #
Minimum:	0.0	13.9	409.7	0.0	0.1	0	0	0
Maximum:	0.6	16.3	1,643.4	0.6	0.5	1	1	0
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/09/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/10/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/11/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/12/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/13/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/14/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/15/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/16/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/17/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/18/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/19/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/20/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2021 08:00	0.0	18.5	205.9	0.0	0.1	1	0	0
10/20/2021 09:00	0.0	17.3	375.6	0.0	0.1	1	0	0
10/20/2021 10:00	0.0	17.3	399.4	0.0	0.1	1	0	0
10/20/2021 11:00	0.0	16.9	654.5	0.0	0.2	1	0	0
10/20/2021 12:00	0.0	15.0	1,078.8	0.0	0.3	1	0	0
10/20/2021 13:00	0.6	14.0	1,338.5	0.6	0.4	1	1	0
10/20/2021 14:00	0.6	14.0	1,269.5	0.6	0.4	1	1	0
10/20/2021 15:00	0.7	13.9	1,458.2	0.7	0.4	1	1	1
10/20/2021 16:00	0.7	12.9	1,805.5	0.7	0.5	1	1	1
10/20/2021 17:00	0.7	13.8	1,648.0	0.7	0.5	1	1	1
10/20/2021 18:00	-0.9	13.0	1,943.6	-0.5	0.6	1	1	1
10/20/2021 19:00	-0.4	12.9	1,984.1	-0.1	0.6	1	1	1
10/20/2021 20:00	0.7	12.3	2,110.9	0.7	0.6	1	1	1
10/20/2021 21:00	0.7	12.4	2,049.9	0.7	0.6	1	1	1
10/20/2021 22:00	0.0	15.6	632.2	0.0	0.2	1	0	0
10/20/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.2	14.7	1,263.6	0.3	0.4	15 #	9 #	7 #
Minimum:	-0.9	12.3	205.9	-0.5	0.1	0	0	0
Maximum:	0.7	18.5	2,110.9	0.7	0.6	1	1	1
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/21/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/22/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/23/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2021 05:00	0.0	20.7	0.2	0.0	0.0	1	0	0
10/23/2021 06:00	0.0	17.3	372.8	0.0	0.1	1	0	0
10/23/2021 07:00	0.0	14.5	1,275.2	0.0	0.4	1	0	0
10/23/2021 08:00	0.6	13.9	1,613.3	0.6	0.5	1	1	0
10/23/2021 09:00	0.6	14.0	1,371.1	0.6	0.4	1	1	0
10/23/2021 10:00	0.6	13.9	1,566.5	0.6	0.5	1	1	0
10/23/2021 11:00	0.6	13.9	1,539.5	0.6	0.5	1	1	0
10/23/2021 12:00	0.6	13.9	1,583.1	0.6	0.5	1	1	0
10/23/2021 13:00	0.6	13.9	1,546.6	0.6	0.5	1	1	0
10/23/2021 14:00	0.6	13.9	1,628.0	0.6	0.5	1	1	0
10/23/2021 15:00	0.6	13.9	1,602.6	0.6	0.5	1	1	0
10/23/2021 16:00	0.6	13.8	1,632.6	0.6	0.5	1	1	0
10/23/2021 17:00	-0.1	13.0	1,930.3	0.1	0.6	1	1	1
10/23/2021 18:00	0.7	12.7	2,002.8	0.7	0.6	1	1	1
10/23/2021 19:00	0.7	13.8	1,617.2	0.7	0.5	1	1	1
10/23/2021 20:00	0.7	13.8	1,642.8	0.7	0.5	1	1	1
10/23/2021 21:00	0.2	12.8	1,981.3	0.4	0.6	1	1	1
10/23/2021 22:00	0.0	13.8	1,440.9	0.0	0.4	1	0	1
10/23/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.4	14.3	1,463.7	0.4	0.5	18 #	14 #	6 #
Minimum:	-0.1	12.7	0.2	0.0	0.0	0	0	0
Maximum:	0.7	20.7	2,002.8	0.7	0.6	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/24/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2021 03:00	0.0	18.8	181.9	0.0	0.1	1	0	0
10/24/2021 04:00	0.0	15.4	891.2	0.0	0.3	1	0	0
10/24/2021 05:00	0.6	13.9	1,393.2	0.6	0.4	1	1	0
10/24/2021 06:00	0.6	13.9	1,377.8	0.6	0.4	1	1	0
10/24/2021 07:00	0.6	13.8	1,699.4	0.6	0.5	1	1	0
10/24/2021 08:00	0.6	13.9	1,543.6	0.6	0.5	1	1	0
10/24/2021 09:00	0.6	13.9	1,536.6	0.6	0.5	1	1	0
10/24/2021 10:00	0.6	13.9	1,547.9	0.6	0.5	1	1	0
10/24/2021 11:00	0.6	13.9	1,528.4	0.6	0.5	1	1	0
10/24/2021 12:00	0.6	13.9	1,583.9	0.6	0.5	1	1	0
10/24/2021 13:00	0.6	13.9	1,484.3	0.6	0.4	1	1	0
10/24/2021 14:00	0.6	13.9	1,601.0	0.6	0.5	1	1	0
10/24/2021 15:00	0.6	13.9	1,623.8	0.6	0.5	1	1	0
10/24/2021 16:00	0.6	13.7	1,719.8	0.6	0.5	1	1	0
10/24/2021 17:00	0.7	12.9	1,918.2	0.7	0.6	1	1	1
10/24/2021 18:00	0.7	12.6	1,979.4	0.7	0.6	1	1	1
10/24/2021 19:00	0.6	13.9	1,656.6	0.6	0.5	1	1	0
10/24/2021 20:00	0.7	13.9	1,691.3	0.7	0.5	1	1	1
10/24/2021 21:00	0.7	12.7	1,979.6	0.7	0.6	1	1	1
10/24/2021 22:00	0.7	13.3	1,645.0	0.7	0.5	1	1	1
10/24/2021 23:00	0.0	15.0	872.1	0.0	0.3	1	0	0
Average/Sum#:	0.5	14.0	1,497.9	0.5	0.5	21 #	18 #	5 #
Minimum:	0.0	12.6	181.9	0.0	0.1	0	0	0
Maximum:	0.7	18.8	1,979.6	0.7	0.6	1	1	1
%SI	12.50	12.50	12.50	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/25/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2021 05:00	0.0	17.6	400.9	0.0	0.1	1	0	0
10/25/2021 06:00	0.0	14.3	1,388.9	0.0	0.4	1	0	0
10/25/2021 07:00	0.6	13.8	1,749.2	0.6	0.5	1	1	0
10/25/2021 08:00	0.6	13.9	1,651.9	0.6	0.5	1	1	0
10/25/2021 09:00	0.7	13.8	1,760.8	0.7	0.5	1	1	1
10/25/2021 10:00	0.4	13.0	1,959.7	0.5	0.6	1	1	1
10/25/2021 11:00	0.5	12.9	1,984.8	0.5	0.6	1	1	1
10/25/2021 12:00	-0.1	13.1	1,911.0	0.1	0.6	1	1	1
10/25/2021 13:00	0.6	13.9	1,606.7	0.6	0.5	1	1	0
10/25/2021 14:00	0.6	14.0	1,524.7	0.6	0.5	1	1	0
10/25/2021 15:00	0.7	13.9	1,541.9	0.7	0.5	1	1	1
10/25/2021 16:00	0.4	12.7	2,029.1	0.5	0.6	1	1	1
10/25/2021 17:00	0.7	12.6	2,061.3	0.7	0.6	1	1	1
10/25/2021 18:00	0.5	12.7	2,027.3	0.5	0.6	1	1	1
10/25/2021 19:00	0.2	13.8	1,624.4	0.4	0.5	1	1	1
10/25/2021 20:00	0.4	14.0	1,465.6	0.4	0.4	1	1	0
10/25/2021 21:00	0.1	13.2	1,906.0	0.2	0.6	1	1	1
10/25/2021 22:00	0.7	13.6	1,666.5	0.7	0.5	1	1	1
10/25/2021 23:00	0.0	15.0	860.1	0.0	0.3	1	0	0
Average/Sum#:	0.4	13.8	1,637.9	0.4	0.5	19 #	16 #	11 #
Minimum:	-0.1	12.6	400.9	0.0	0.1	0	0	0
Maximum:	0.7	17.6	2,061.3	0.7	0.6	1	1	1
%SI	20.83	20.83	20.83	20.83	20.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/26/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2021 05:00	0.0	17.8	384.5	0.0	0.1	1	0	0
10/26/2021 06:00	0.0	14.5	1,216.6	0.0	0.4	1	0	0
10/26/2021 07:00	0.6	13.9	1,580.4	0.6	0.5	1	1	0
10/26/2021 08:00	0.6	13.9	1,573.4	0.6	0.5	1	1	0
10/26/2021 09:00	0.7	13.9	1,564.2	0.7	0.5	1	1	1
10/26/2021 10:00	0.7	12.8	1,991.0	0.7	0.6	1	1	1
10/26/2021 11:00	0.7	0.0	1,906.4	0.7	0.6	1	1	1
10/26/2021 12:00	0.6	13.9	1,652.4	0.6	0.5	1	1	0
10/26/2021 13:00	0.6	14.0	1,448.0	0.6	0.4	1	1	0
10/26/2021 14:00	0.6	14.0	1,428.8	0.6	0.4	1	1	0
10/26/2021 15:00	0.7	13.9	1,546.6	0.7	0.5	1	1	1
10/26/2021 16:00	0.7	12.9	1,982.6	0.7	0.6	1	1	1
10/26/2021 17:00	0.7	12.6	2,054.0	0.7	0.6	1	1	1
10/26/2021 18:00	0.7	12.8	2,025.3	0.7	0.6	1	1	1
10/26/2021 19:00	0.7	12.9	1,982.3	0.7	0.6	1	1	1
10/26/2021 20:00	0.6	13.9	1,554.0	0.6	0.5	1	1	0
10/26/2021 21:00	0.7	13.8	1,762.8	0.7	0.5	1	1	1
10/26/2021 22:00	0.5	12.8	2,005.1	0.5	0.6	1	1	1
10/26/2021 23:00	0.4	12.9	1,959.9	0.5	0.6	1	1	1
Average/Sum#:	0.6	13.7	1,664.1	0.6	0.5	19 #	17 #	11 #
Minimum:	0.0	12.6	384.5	0.0	0.1	0	0	0
Maximum:	0.7	17.8	2,054.0	0.7	0.6	1	1	1
%SI	25.00	25.00	20.83	25.00	20.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/27/2021 00:00	0.6	13.9	1,536.6	0.6	0.5	1	1	0
10/27/2021 01:00	0.7	13.9	1,562.4	0.7	0.5	1	1	1
10/27/2021 02:00	0.4	13.3	1,916.3	0.4	0.6	1	1	1
10/27/2021 03:00	0.4	13.3	1,890.7	0.4	0.6	1	1	1
10/27/2021 04:00	0.6	13.9	1,569.8	0.6	0.5	1	1	0
10/27/2021 05:00	0.7	13.9	1,589.1	0.7	0.5	1	1	1
10/27/2021 06:00	0.4	13.1	1,930.4	0.4	0.6	1	1	1
10/27/2021 07:00	0.7	13.0	1,955.1	0.7	0.6	1	1	1
10/27/2021 08:00	0.5	13.2	1,919.1	0.5	0.6	1	1	1
10/27/2021 09:00	0.7	13.9	1,465.3	0.7	0.4	1	1	1
10/27/2021 10:00	0.6	14.0	1,422.4	0.6	0.4	1	1	0
10/27/2021 11:00	0.6	13.9	1,571.3	0.6	0.5	1	1	0
10/27/2021 12:00	0.6	14.0	1,308.4	0.6	0.4	1	1	0
10/27/2021 13:00	0.6	14.0	1,453.4	0.6	0.4	1	1	0
10/27/2021 14:00	0.7	13.4	1,802.6	0.7	0.5	1	1	1
10/27/2021 15:00	0.7	13.0	1,853.8	0.7	0.6	1	1	1
10/27/2021 16:00	0.7	13.9	1,674.7	0.7	0.5	1	1	1
10/27/2021 17:00	0.7	13.0	1,929.1	0.7	0.6	1	1	1
10/27/2021 18:00	0.7	12.5	2,057.9	0.7	0.6	1	1	1
10/27/2021 19:00	0.7	12.3	2,098.0	0.7	0.6	1	1	1
10/27/2021 20:00	0.7	12.4	2,061.7	0.7	0.6	1	1	1
10/27/2021 21:00	0.7	12.4	2,070.4	0.7	0.6	1	1	1
10/27/2021 22:00	0.7	12.7	1,983.7	0.7	0.6	1	1	1
10/27/2021 23:00	0.7	13.3	1,801.4	0.7	0.5	1	1	1
Average/Sum#:	0.6	13.3	1,767.7	0.6	0.5	24 #	24 #	18 #
Minimum:	0.4	12.3	1,308.4	0.4	0.4	1	1	0
Maximum:	0.7	14.0	2,098.0	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/28/2021 00:00	0.0	14.5	1,106.1	0.0	0.3	1	0	0
10/28/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2021 12:00	0.0	18.1	281.5	0.0	0.1	1	0	0
10/28/2021 13:00	0.0	15.2	941.9	0.0	0.3	1	0	0
10/28/2021 14:00	0.6	14.0	1,503.4	0.6	0.5	1	1	0
10/28/2021 15:00	0.7	13.9	1,533.4	0.7	0.5	1	1	1
10/28/2021 16:00	0.7	12.5	2,006.9	0.7	0.6	1	1	1
10/28/2021 17:00	0.7	12.0	2,130.0	0.7	0.6	1	1	1
10/28/2021 18:00	0.7	12.1	2,121.2	0.7	0.6	1	1	1
10/28/2021 19:00	0.7	12.0	2,127.8	0.7	0.6	1	1	1
10/28/2021 20:00	0.7	12.2	2,101.6	0.7	0.6	1	1	1
10/28/2021 21:00	0.7	12.5	2,037.7	0.7	0.6	1	1	1
10/28/2021 22:00	0.7	12.6	2,013.5	0.7	0.6	1	1	1
10/28/2021 23:00	0.7	12.8	1,954.1	0.7	0.6	1	1	1
Average/Sum#:	0.5	13.4	1,681.5	0.5	0.5	13 #	10 #	9 #
Minimum:	0.0	12.0	281.5	0.0	0.1	0	0	0
Maximum:	0.7	18.1	2,130.0	0.7	0.6	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/29/2021 00:00	-0.1	13.2	1,899.0	0.1	0.6	1	1	1
10/29/2021 01:00	-0.4	13.2	1,903.3	-0.1	0.6	1	1	1
10/29/2021 02:00	-0.4	13.2	1,896.5	-0.1	0.6	1	1	1
10/29/2021 03:00	-0.4	13.2	1,895.9	-0.1	0.6	1	1	1
10/29/2021 04:00	-0.5	13.2	1,896.0	-0.2	0.6	1	1	1
10/29/2021 05:00	-0.7	13.2	1,898.2	-0.4	0.6	1	1	1
10/29/2021 06:00	-0.8	13.2	1,900.8	-0.5	0.6	1	1	1
10/29/2021 07:00	-0.7	13.2	1,898.4	-0.4	0.6	1	1	1
10/29/2021 08:00	-0.5	13.2	1,897.8	-0.2	0.6	1	1	1
10/29/2021 09:00	0.4	13.3	1,705.9	0.4	0.5	1	1	1
10/29/2021 10:00	0.7	13.8	1,410.3	0.7	0.4	1	1	1
10/29/2021 11:00	0.7	13.0	1,915.2	0.7	0.6	1	1	1
10/29/2021 12:00	0.7	13.2	1,708.9	0.7	0.5	1	1	1
10/29/2021 13:00	0.7	13.8	1,404.1	0.7	0.4	1	1	1
10/29/2021 14:00	0.7	12.8	1,922.5	0.7	0.6	1	1	1
10/29/2021 15:00	0.7	12.8	1,923.0	0.7	0.6	1	1	1
10/29/2021 16:00	0.7	12.9	1,920.3	0.7	0.6	1	1	1
10/29/2021 17:00	0.7	12.9	1,917.5	0.7	0.6	1	1	1
10/29/2021 18:00	0.7	12.9	1,914.0	0.7	0.6	1	1	1
10/29/2021 19:00	0.7	12.9	1,912.5	0.7	0.6	1	1	1
10/29/2021 20:00	0.7	12.9	1,911.0	0.7	0.6	1	1	1
10/29/2021 21:00	0.7	13.0	1,909.3	0.7	0.6	1	1	1
10/29/2021 22:00	0.5	13.0	1,903.6	0.5	0.6	1	1	1
10/29/2021 23:00	0.7	12.7	1,964.6	0.7	0.6	1	1	1
Average/Sum#:	0.2	13.1	1,851.2	0.3	0.6	24 #	24 #	24 #
Minimum:	-0.8	12.7	1,404.1	-0.5	0.4	1	1	1
Maximum:	0.7	13.8	1,964.6	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/30/2021 00:00	0.7	13.8	1,631.0	0.7	0.5	1	1	1
10/30/2021 01:00	0.6	13.9	1,445.3	0.6	0.4	1	1	0
10/30/2021 02:00	0.7	13.3	1,739.8	0.7	0.5	1	1	1
10/30/2021 03:00	0.2	13.1	1,891.1	0.4	0.6	1	1	1
10/30/2021 04:00	0.6	13.9	1,600.7	0.6	0.5	1	1	0
10/30/2021 05:00	0.7	13.8	1,664.5	0.7	0.5	1	1	1
10/30/2021 06:00	0.2	12.8	1,977.2	0.4	0.6	1	1	1
10/30/2021 07:00	-0.1	13.1	1,904.1	0.1	0.6	1	1	1
10/30/2021 08:00	0.6	13.9	1,508.7	0.6	0.5	1	1	0
10/30/2021 09:00	0.6	13.9	1,506.0	0.6	0.5	1	1	0
10/30/2021 10:00	0.6	13.9	1,513.5	0.6	0.5	1	1	0
10/30/2021 11:00	0.6	13.9	1,555.7	0.6	0.5	1	1	0
10/30/2021 12:00	0.6	14.0	1,374.2	0.6	0.4	1	1	0
10/30/2021 13:00	0.6	14.0	1,385.3	0.6	0.4	1	1	0
10/30/2021 14:00	0.6	14.0	1,502.2	0.6	0.5	1	1	0
10/30/2021 15:00	0.7	13.9	1,582.2	0.7	0.5	1	1	1
10/30/2021 16:00	0.5	12.7	1,999.1	0.5	0.6	1	1	1
10/30/2021 17:00	0.7	12.4	2,059.0	0.7	0.6	1	1	1
10/30/2021 18:00	0.7	12.6	2,035.9	0.7	0.6	1	1	1
10/30/2021 19:00	0.5	12.8	1,971.6	0.5	0.6	1	1	1
10/30/2021 20:00	0.6	13.9	1,647.4	0.6	0.5	1	1	0
10/30/2021 21:00	0.7	13.9	1,615.0	0.7	0.5	1	1	1
10/30/2021 22:00	0.4	12.9	1,967.5	0.5	0.6	1	1	1
10/30/2021 23:00	0.1	13.2	1,904.1	0.2	0.6	1	1	1
Average/Sum#:	0.5	13.5	1,707.5	0.6	0.5	24 #	24 #	14 #
Minimum:	-0.1	12.4	1,374.2	0.1	0.4	1	1	0
Maximum:	0.7	14.0	2,059.0	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/31/2021 00:00	0.6	13.9	1,635.0	0.6	0.5	1	1	0
10/31/2021 01:00	0.7	13.9	1,544.4	0.7	0.5	1	1	1
10/31/2021 02:00	-0.9	13.2	1,920.3	-0.5	0.6	1	1	1
10/31/2021 03:00	-0.2	13.2	1,904.6	-0.1	0.6	1	1	1
10/31/2021 04:00	0.6	13.9	1,665.6	0.6	0.5	1	1	0
10/31/2021 05:00	0.7	13.9	1,535.1	0.7	0.5	1	1	1
10/31/2021 06:00	0.5	12.9	1,989.0	0.5	0.6	1	1	1
10/31/2021 07:00	0.1	13.2	1,904.0	0.2	0.6	1	1	1
10/31/2021 08:00	0.6	13.9	1,622.9	0.6	0.5	1	1	0
10/31/2021 09:00	0.6	13.9	1,560.0	0.6	0.5	1	1	0
10/31/2021 10:00	0.6	14.0	1,385.0	0.6	0.4	1	1	0
10/31/2021 11:00	0.6	13.9	1,525.8	0.6	0.5	1	1	0
10/31/2021 12:00	0.6	13.9	1,573.1	0.6	0.5	1	1	0
10/31/2021 13:00	0.6	13.9	1,655.3	0.6	0.5	1	1	0
10/31/2021 14:00	0.6	14.0	1,537.8	0.6	0.5	1	1	0
10/31/2021 15:00	0.7	13.9	1,575.6	0.7	0.5	1	1	1
10/31/2021 16:00	0.7	13.0	1,960.3	0.7	0.6	1	1	1
10/31/2021 17:00	0.7	12.8	2,002.8	0.7	0.6	1	1	1
10/31/2021 18:00	0.7	12.8	2,011.6	0.7	0.6	1	1	1
10/31/2021 19:00	0.7	13.1	1,912.1	0.7	0.6	1	1	1
10/31/2021 20:00	0.6	13.9	1,666.5	0.6	0.5	1	1	0
10/31/2021 21:00	0.7	13.9	1,549.5	0.7	0.5	1	1	1
10/31/2021 22:00	0.5	12.9	1,964.6	0.5	0.6	1	1	1
10/31/2021 23:00	0.2	13.1	1,903.5	0.4	0.6	1	1	1
Average/Sum#:	0.5	13.5	1,729.4	0.5	0.5	24 #	24 #	14 #
Minimum:	-0.9	12.8	1,385.0	-0.5	0.4	1	1	0
Maximum:	0.7	14.0	2,011.6	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/01/2021 00:00	0.6	13.9	1,599.7	0.6	0.5	1	1	0
11/01/2021 01:00	0.7	13.8	1,658.0	0.7	0.5	1	1	1
11/01/2021 02:00	-0.4	13.2	1,905.2	-0.1	0.6	1	1	1
11/01/2021 03:00	0.5	12.9	1,959.2	0.5	0.6	1	1	1
11/01/2021 04:00	0.7	13.9	1,572.7	0.7	0.5	1	1	1
11/01/2021 05:00	0.7	13.8	1,659.3	0.7	0.5	1	1	1
11/01/2021 06:00	0.5	12.7	2,012.0	0.5	0.6	1	1	1
11/01/2021 07:00	0.7	12.5	2,060.9	0.7	0.6	1	1	1
11/01/2021 08:00	0.4	13.0	1,925.5	0.5	0.6	1	1	1
11/01/2021 09:00	0.6	13.9	1,547.0	0.6	0.5	1	1	0
11/01/2021 10:00	0.7	13.9	1,501.1	0.7	0.5	1	1	1
11/01/2021 11:00	0.7	12.8	1,991.3	0.7	0.6	1	1	1
11/01/2021 12:00	0.7	12.7	1,983.5	0.7	0.6	1	1	1
11/01/2021 13:00	0.6	13.9	1,680.6	0.6	0.5	1	1	0
11/01/2021 14:00	0.6	13.7	1,758.6	0.6	0.5	1	1	0
11/01/2021 15:00	0.5	12.8	1,980.0	0.5	0.6	1	1	1
11/01/2021 16:00	0.7	12.7	2,020.2	0.7	0.6	1	1	1
11/01/2021 17:00	0.7	12.2	2,129.7	0.7	0.6	1	1	1
11/01/2021 18:00	0.7	12.3	2,097.3	0.7	0.6	1	1	1
11/01/2021 19:00	0.7	12.2	2,125.2	0.7	0.6	1	1	1
11/01/2021 20:00	0.7	12.2	2,139.6	0.7	0.6	1	1	1
11/01/2021 21:00	0.7	12.2	2,128.1	0.7	0.6	1	1	1
11/01/2021 22:00	0.7	12.6	2,040.1	0.7	0.6	1	1	1
11/01/2021 23:00	-0.1	13.2	1,893.4	0.1	0.6	1	1	1
Average/Sum#:	0.6	13.0	1,890.3	0.6	0.6	24 #	24 #	20 #
Minimum:	-0.4	12.2	1,501.1	-0.1	0.5	1	1	0
Maximum:	0.7	13.9	2,139.6	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/02/2021 00:00	0.6	13.9	1,534.0	0.6	0.5	1	1	0
11/02/2021 01:00	0.6	13.9	1,557.3	0.6	0.5	1	1	0
11/02/2021 02:00	-0.4	13.2	1,923.9	-0.1	0.6	1	1	1
11/02/2021 03:00	-0.4	13.1	1,919.3	-0.1	0.6	1	1	1
11/02/2021 04:00	0.7	13.8	1,623.3	0.7	0.5	1	1	1
11/02/2021 05:00	0.7	13.9	1,605.1	0.7	0.5	1	1	1
11/02/2021 06:00	0.5	12.8	2,010.9	0.5	0.6	1	1	1
11/02/2021 07:00	0.7	12.8	2,011.2	0.7	0.6	1	1	1
11/02/2021 08:00	0.2	13.2	1,910.7	0.4	0.6	1	1	1
11/02/2021 09:00	0.6	13.9	1,500.3	0.6	0.5	1	1	0
11/02/2021 10:00	0.6	13.9	1,605.1	0.6	0.5	1	1	0
11/02/2021 11:00	0.6	14.0	1,301.3	0.6	0.4	1	1	0
11/02/2021 12:00	0.6	14.0	1,496.6	0.6	0.4	1	1	0
11/02/2021 13:00	0.6	13.9	1,597.3	0.6	0.5	1	1	0
11/02/2021 14:00	0.6	14.0	1,583.7	0.6	0.5	1	1	0
11/02/2021 15:00	0.7	13.9	1,610.2	0.7	0.5	1	1	1
11/02/2021 16:00	0.5	12.7	2,000.1	0.5	0.6	1	1	1
11/02/2021 17:00	0.7	12.3	2,109.6	0.7	0.6	1	1	1
11/02/2021 18:00	0.7	12.3	2,105.5	0.7	0.6	1	1	1
11/02/2021 19:00	0.7	12.1	2,173.6	0.7	0.7	1	1	1
11/02/2021 20:00	0.7	12.3	2,111.5	0.7	0.6	1	1	1
11/02/2021 21:00	0.7	12.4	2,093.2	0.7	0.6	1	1	1
11/02/2021 22:00	0.7	12.5	2,076.7	0.7	0.6	1	1	1
11/02/2021 23:00	-0.2	13.0	1,931.8	0.1	0.6	1	1	1
Average/Sum#:	0.5	13.2	1,808.0	0.5	0.6	24 #	24 #	16 #
Minimum:	-0.4	12.1	1,301.3	-0.1	0.4	1	1	0
Maximum:	0.7	14.0	2,173.6	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/03/2021 00:00	0.6	13.9	1,667.3	0.6	0.5	1	1	0
11/03/2021 01:00	0.7	13.8	1,613.3	0.7	0.5	1	1	1
11/03/2021 02:00	-0.8	13.2	1,905.7	-0.5	0.6	1	1	1
11/03/2021 03:00	-0.8	13.2	1,906.7	-0.5	0.6	1	1	1
11/03/2021 04:00	0.7	13.9	1,638.8	0.7	0.5	1	1	1
11/03/2021 05:00	0.7	13.8	1,759.8	0.7	0.5	1	1	1
11/03/2021 06:00	-0.1	13.0	1,959.8	0.1	0.6	1	1	1
11/03/2021 07:00	-0.1	13.1	1,944.7	0.1	0.6	1	1	1
11/03/2021 08:00	0.7	13.8	1,649.3	0.7	0.5	1	1	1
11/03/2021 09:00	0.6	13.9	1,661.6	0.6	0.5	1	1	0
11/03/2021 10:00	0.6	13.9	1,552.3	0.6	0.5	1	1	0
11/03/2021 11:00	0.6	13.9	1,662.2	0.6	0.5	1	1	0
11/03/2021 12:00	0.6	14.0	1,507.5	0.6	0.5	1	1	0
11/03/2021 13:00	0.6	14.0	1,661.5	0.6	0.5	1	1	0
11/03/2021 14:00	0.6	14.0	1,488.6	0.6	0.4	1	1	0
11/03/2021 15:00	0.7	13.9	1,562.0	0.7	0.5	1	1	1
11/03/2021 16:00	0.4	12.7	1,987.1	0.5	0.6	1	1	1
11/03/2021 17:00	0.7	12.1	2,126.0	0.7	0.6	1	1	1
11/03/2021 18:00	0.7	12.3	2,086.9	0.7	0.6	1	1	1
11/03/2021 19:00	0.7	12.1	2,138.7	0.7	0.6	1	1	1
11/03/2021 20:00	0.7	12.2	2,124.9	0.7	0.6	1	1	1
11/03/2021 21:00	0.7	12.4	2,081.7	0.7	0.6	1	1	1
11/03/2021 22:00	0.7	12.6	2,032.9	0.7	0.6	1	1	1
11/03/2021 23:00	-0.5	13.0	1,906.5	-0.2	0.6	1	1	1
Average/Sum#:	0.4	13.3	1,817.7	0.5	0.5	24 #	24 #	17 #
Minimum:	-0.8	12.1	1,488.6	-0.5	0.4	1	1	0
Maximum:	0.7	14.0	2,138.7	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/04/2021 00:00	0.6	13.9	1,453.2	0.6	0.4	1	1	0
11/04/2021 01:00	0.7	13.8	1,566.5	0.7	0.5	1	1	1
11/04/2021 02:00	-0.5	13.1	1,912.8	-0.2	0.6	1	1	1
11/04/2021 03:00	0.7	12.9	1,944.2	0.7	0.6	1	1	1
11/04/2021 04:00	0.7	13.8	1,664.8	0.7	0.5	1	1	1
11/04/2021 05:00	0.7	13.8	1,743.5	0.7	0.5	1	1	1
11/04/2021 06:00	-0.2	12.8	1,968.8	0.1	0.6	1	1	1
11/04/2021 07:00	0.5	12.8	1,950.1	0.5	0.6	1	1	1
11/04/2021 08:00	0.6	13.9	1,566.2	0.6	0.5	1	1	0
11/04/2021 09:00	0.6	14.0	1,498.9	0.6	0.4	1	1	0
11/04/2021 10:00	0.6	14.0	1,491.2	0.6	0.4	1	1	0
11/04/2021 11:00	0.6	14.0	1,465.8	0.6	0.4	1	1	0
11/04/2021 12:00	0.6	14.0	1,365.4	0.6	0.4	1	1	0
11/04/2021 13:00	0.6	14.0	1,524.8	0.6	0.5	1	1	0
11/04/2021 14:00	0.6	14.0	1,632.8	0.6	0.5	1	1	0
11/04/2021 15:00	0.6	14.0	1,534.7	0.6	0.5	1	1	0
11/04/2021 16:00	0.5	12.9	1,953.0	0.5	0.6	1	1	1
11/04/2021 17:00	0.7	12.6	2,029.2	0.7	0.6	1	1	1
11/04/2021 18:00	0.7	12.7	1,999.2	0.7	0.6	1	1	1
11/04/2021 19:00	0.7	13.9	1,661.5	0.7	0.5	1	1	1
11/04/2021 20:00	0.7	13.9	1,605.9	0.7	0.5	1	1	1
11/04/2021 21:00	0.4	12.9	1,988.3	0.5	0.6	1	1	1
11/04/2021 22:00	0.7	13.4	1,653.9	0.7	0.5	1	1	1
11/04/2021 23:00	0.0	15.1	862.3	0.0	0.3	1	0	0
Average/Sum#:	0.5	13.6	1,668.2	0.5	0.5	24 #	23 #	14 #
Minimum:	-0.5	12.6	862.3	-0.2	0.3	1	0	0
Maximum:	0.7	15.1	2,029.2	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/05/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2021 13:00	0.0	17.7	339.3	0.0	0.1	1	0	0
11/05/2021 14:00	0.0	14.7	1,252.5	0.0	0.4	1	0	0
11/05/2021 15:00	0.7	13.9	1,542.8	0.7	0.5	1	1	1
11/05/2021 16:00	0.2	12.7	2,027.7	0.4	0.6	1	1	1
11/05/2021 17:00	0.7	12.5	2,056.9	0.7	0.6	1	1	1
11/05/2021 18:00	0.7	12.7	2,038.7	0.7	0.6	1	1	1
11/05/2021 19:00	0.1	12.9	1,945.0	0.2	0.6	1	1	1
11/05/2021 20:00	0.6	13.9	1,644.4	0.6	0.5	1	1	0
11/05/2021 21:00	0.7	13.8	1,758.5	0.7	0.5	1	1	1
11/05/2021 22:00	0.4	13.0	1,976.7	0.5	0.6	1	1	1
11/05/2021 23:00	0.4	13.2	1,922.0	0.4	0.6	1	1	1
Average/Sum#:	0.4	13.7	1,682.2	0.4	0.5	11 #	9 #	8 #
Minimum:	0.0	12.5	339.3	0.0	0.1	0	0	0
Maximum:	0.7	17.7	2,056.9	0.7	0.6	1	1	1
%SI	54.17	54.17	54.17	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/06/2021 00:00	0.7	13.8	1,664.2	0.7	0.5	1	1	1
11/06/2021 01:00	0.6	13.9	1,572.1	0.6	0.5	1	1	0
11/06/2021 02:00	-0.8	13.3	1,895.0	-0.5	0.6	1	1	1
11/06/2021 03:00	-0.9	13.2	1,915.3	-0.5	0.6	1	1	1
11/06/2021 04:00	0.7	13.9	1,663.3	0.7	0.5	1	1	1
11/06/2021 05:00	0.7	13.9	1,592.6	0.7	0.5	1	1	1
11/06/2021 06:00	-0.2	12.9	1,968.5	0.1	0.6	1	1	1
11/06/2021 07:00	0.1	13.1	1,912.4	0.2	0.6	1	1	1
11/06/2021 08:00	0.6	13.9	1,585.1	0.6	0.5	1	1	0
11/06/2021 09:00	0.6	13.9	1,583.7	0.6	0.5	1	1	0
11/06/2021 10:00	0.6	13.9	1,588.6	0.6	0.5	1	1	0
11/06/2021 11:00	0.6	13.9	1,524.7	0.6	0.5	1	1	0
11/06/2021 12:00	0.6	13.9	1,519.7	0.6	0.5	1	1	0
11/06/2021 13:00	0.6	13.9	1,550.3	0.6	0.5	1	1	0
11/06/2021 14:00	0.6	14.0	1,456.7	0.6	0.4	1	1	0
11/06/2021 15:00	0.6	13.9	1,562.8	0.6	0.5	1	1	0
11/06/2021 16:00	-0.4	12.9	1,960.0	-0.1	0.6	1	1	1
11/06/2021 17:00	0.7	12.5	2,037.2	0.7	0.6	1	1	1
11/06/2021 18:00	-0.1	13.1	1,901.0	0.1	0.6	1	1	1
11/06/2021 19:00	0.6	13.9	1,642.7	0.6	0.5	1	1	0
11/06/2021 20:00	0.7	13.8	1,655.9	0.7	0.5	1	1	1
11/06/2021 21:00	-0.4	13.1	1,946.8	-0.1	0.6	1	1	1
11/06/2021 22:00	0.0	14.0	1,448.1	0.0	0.4	1	0	1
11/06/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.3	13.6	1,702.0	0.4	0.5	23 #	22 #	13 #
Minimum:	-0.9	12.5	1,448.1	-0.5	0.4	0	0	0
Maximum:	0.7	14.0	2,037.2	0.7	0.6	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/07/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/08/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 12:00	0.0	18.0	282.3	0.0	0.1	1	0	0
11/08/2021 13:00	0.0	16.9	504.9	0.0	0.2	1	0	0
11/08/2021 14:00	0.0	15.2	931.0	0.0	0.3	1	0	0
11/08/2021 15:00	0.6	14.0	1,644.3	0.6	0.5	1	1	0
11/08/2021 16:00	0.7	0.0	2,007.5	0.7	0.6	1	1	1
11/08/2021 17:00	0.7	12.1	2,126.2	0.7	0.6	1	1	1
11/08/2021 18:00	0.2	12.9	1,973.7	0.4	0.6	1	1	1
11/08/2021 19:00	-0.2	13.1	1,940.4	-0.1	0.6	1	1	1
11/08/2021 20:00	0.7	12.4	2,104.2	0.7	0.6	1	1	1
11/08/2021 21:00	0.5	12.6	2,057.7	0.5	0.6	1	1	1
11/08/2021 22:00	-0.9	13.3	1,880.3	-0.7	0.6	1	1	1
11/08/2021 23:00	0.0	15.8	561.5	0.0	0.2	1	0	0
Average/Sum#:	0.1	14.2	1,501.2	0.2	0.5	12 #	8 #	7 #
Minimum:	-0.9	12.1	282.3	-0.7	0.1	0	0	0
Maximum:	0.7	18.0	2,126.2	0.7	0.6	1	1	1
%SI	54.17	54.17	50.00	54.17	50.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/09/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/09/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/09/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/09/2021 03:00	0.0	18.1	303.5	0.0	0.1	1	0	0
11/09/2021 04:00	0.0	15.4	905.7	0.0	0.3	1	0	0
11/09/2021 05:00	0.6	13.9	1,498.9	0.6	0.4	1	1	0
11/09/2021 06:00	0.6	13.9	1,538.4	0.6	0.5	1	1	0
11/09/2021 07:00	0.6	13.8	1,742.0	0.6	0.5	1	1	0
11/09/2021 08:00	0.6	13.9	1,539.3	0.6	0.5	1	1	0
11/09/2021 09:00	0.6	13.9	1,681.6	0.6	0.5	1	1	0
11/09/2021 10:00	0.6	13.9	1,491.2	0.6	0.4	1	1	0
11/09/2021 11:00	0.6	13.9	1,546.2	0.6	0.5	1	1	0
11/09/2021 12:00	0.6	13.9	1,517.2	0.6	0.5	1	1	0
11/09/2021 13:00	0.6	13.9	1,647.6	0.6	0.5	1	1	0
11/09/2021 14:00	0.6	13.9	1,596.7	0.6	0.5	1	1	0
11/09/2021 15:00	0.6	13.9	1,497.0	0.6	0.4	1	1	0
11/09/2021 16:00	0.6	13.9	1,538.2	0.6	0.5	1	1	0
11/09/2021 17:00	-0.2	13.4	1,821.2	-0.1	0.5	1	1	1
11/09/2021 18:00	0.7	12.5	2,080.4	0.7	0.6	1	1	1
11/09/2021 19:00	0.7	12.3	2,136.6	0.7	0.6	1	1	1
11/09/2021 20:00	0.7	12.5	2,052.3	0.7	0.6	1	1	1
11/09/2021 21:00	0.6	13.9	1,580.5	0.6	0.5	1	1	0
11/09/2021 22:00	0.6	13.8	1,692.7	0.6	0.5	1	1	0
11/09/2021 23:00	-0.4	13.0	1,962.9	-0.1	0.6	1	1	1
Average/Sum#:	0.5	13.9	1,589.1	0.5	0.5	21 #	19 #	5 #
Minimum:	-0.4	12.3	303.5	-0.1	0.1	0	0	0
Maximum:	0.7	18.1	2,136.6	0.7	0.6	1	1	1
%SI	12.50	12.50	12.50	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/10/2021 00:00	0.1	13.4	1,806.2	0.2	0.5	1	1	1
11/10/2021 01:00	0.6	13.7	1,760.1	0.6	0.5	1	1	0
11/10/2021 02:00	0.7	13.9	1,557.6	0.7	0.5	1	1	1
11/10/2021 03:00	-1.2	13.2	1,927.4	-0.8	0.6	1	1	1
11/10/2021 04:00	-0.9	13.2	1,909.8	-0.5	0.6	1	1	1
11/10/2021 05:00	0.6	13.9	1,677.6	0.6	0.5	1	1	0
11/10/2021 06:00	0.7	13.9	1,762.0	0.7	0.5	1	1	1
11/10/2021 07:00	-0.9	13.2	1,951.5	-0.5	0.6	1	1	1
11/10/2021 08:00	-0.7	13.2	1,908.2	-0.4	0.6	1	1	1
11/10/2021 09:00	0.6	14.0	1,528.6	0.6	0.5	1	1	0
11/10/2021 10:00	0.6	14.0	1,453.0	0.6	0.4	1	1	0
11/10/2021 11:00	0.6	14.0	1,402.4	0.6	0.4	1	1	0
11/10/2021 12:00	0.6	14.0	1,450.4	0.6	0.4	1	1	0
11/10/2021 13:00	0.6	14.0	1,325.7	0.6	0.4	1	1	0
11/10/2021 14:00	0.6	14.0	1,458.8	0.6	0.4	1	1	0
11/10/2021 15:00	0.7	13.9	1,559.2	0.7	0.5	1	1	1
11/10/2021 16:00	0.1	13.0	1,964.7	0.2	0.6	1	1	1
11/10/2021 17:00	0.7	12.9	1,981.1	0.7	0.6	1	1	1
11/10/2021 18:00	0.7	12.7	2,026.0	0.7	0.6	1	1	1
11/10/2021 19:00	0.7	12.7	2,021.3	0.7	0.6	1	1	1
11/10/2021 20:00	0.7	12.9	1,958.1	0.7	0.6	1	1	1
11/10/2021 21:00	0.6	13.9	1,671.4	0.6	0.5	1	1	0
11/10/2021 22:00	0.7	13.8	1,746.1	0.7	0.5	1	1	1
11/10/2021 23:00	0.2	12.9	1,985.2	0.4	0.6	1	1	1
Average/Sum#:	0.3	13.5	1,741.4	0.4	0.5	24 #	24 #	15 #
Minimum:	-1.2	12.7	1,325.7	-0.8	0.4	1	1	0
Maximum:	0.7	14.0	2,026.0	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/11/2021 00:00	-0.2	13.1	1,912.6	-0.1	0.6	1	1	1
11/11/2021 01:00	0.0	15.8	583.8	0.0	0.2	1	0	0
11/11/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/11/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/11/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/11/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/11/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/11/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/11/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/11/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/11/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/11/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/11/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/11/2021 13:00	0.0	17.8	323.9	0.0	0.1	1	0	0
11/11/2021 14:00	0.0	15.0	1,021.2	0.0	0.3	1	0	0
11/11/2021 15:00	0.6	13.9	1,628.0	0.6	0.5	1	1	0
11/11/2021 16:00	0.4	13.4	1,781.2	0.4	0.5	1	1	1
11/11/2021 17:00	0.7	12.5	2,048.6	0.7	0.6	1	1	1
11/11/2021 18:00	0.7	12.5	2,052.8	0.7	0.6	1	1	1
11/11/2021 19:00	0.7	12.5	2,058.1	0.7	0.6	1	1	1
11/11/2021 20:00	0.7	12.5	2,034.5	0.7	0.6	1	1	1
11/11/2021 21:00	0.6	13.9	1,660.4	0.6	0.5	1	1	0
11/11/2021 22:00	0.7	13.8	1,745.3	0.7	0.5	1	1	1
11/11/2021 23:00	0.4	13.0	1,952.9	0.5	0.6	1	1	1
Average/Sum#:	0.4	13.8	1,600.3	0.4	0.5	13 #	10 #	8 #
Minimum:	-0.2	12.5	323.9	-0.1	0.1	0	0	0
Maximum:	0.7	17.8	2,058.1	0.7	0.6	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/12/2021 00:00	0.1	13.2	1,897.7	0.2	0.6	1	1	1
11/12/2021 01:00	0.6	13.9	1,551.9	0.6	0.5	1	1	0
11/12/2021 02:00	0.6	13.9	1,520.6	0.6	0.5	1	1	0
11/12/2021 03:00	0.6	13.9	1,526.4	0.6	0.5	1	1	0
11/12/2021 04:00	0.7	13.9	1,549.7	0.7	0.5	1	1	1
11/12/2021 05:00	0.4	12.9	1,992.8	0.5	0.6	1	1	1
11/12/2021 06:00	0.7	12.8	2,022.2	0.7	0.6	1	1	1
11/12/2021 07:00	0.7	13.6	1,651.9	0.7	0.5	1	1	1
11/12/2021 08:00	0.0	15.1	871.0	0.0	0.3	1	0	0
11/12/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/12/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/12/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/12/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/12/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/12/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/12/2021 15:00	0.0	18.0	315.7	0.0	0.1	1	0	0
11/12/2021 16:00	0.0	15.7	835.3	0.0	0.3	1	0	0
11/12/2021 17:00	0.6	13.9	1,412.8	0.6	0.4	1	1	0
11/12/2021 18:00	0.7	13.9	1,563.6	0.7	0.5	1	1	1
11/12/2021 19:00	0.5	12.8	2,001.4	0.5	0.6	1	1	1
11/12/2021 20:00	0.7	13.0	1,940.4	0.7	0.6	1	1	1
11/12/2021 21:00	0.6	13.9	1,605.2	0.6	0.5	1	1	0
11/12/2021 22:00	0.7	13.8	1,667.1	0.7	0.5	1	1	1
11/12/2021 23:00	0.5	12.9	1,983.5	0.5	0.6	1	1	1
Average/Sum#:	0.5	14.0	1,550.5	0.5	0.5	18 #	15 #	10 #
Minimum:	0.0	12.8	315.7	0.0	0.1	0	0	0
Maximum:	0.7	18.0	2,022.2	0.7	0.6	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/13/2021 00:00	0.0	14.4	1,208.7	0.0	0.4	1	0	1
11/13/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/13/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/13/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/13/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/13/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/13/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/13/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/13/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/13/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/13/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/13/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/13/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/13/2021 13:00	0.0	17.7	347.6	0.0	0.1	1	0	0
11/13/2021 14:00	0.0	15.0	1,057.3	0.0	0.3	1	0	0
11/13/2021 15:00	0.6	13.9	1,671.8	0.6	0.5	1	1	0
11/13/2021 16:00	0.7	13.8	1,734.3	0.7	0.5	1	1	1
11/13/2021 17:00	0.5	12.9	1,981.2	0.5	0.6	1	1	1
11/13/2021 18:00	0.7	12.9	1,940.1	0.7	0.6	1	1	1
11/13/2021 19:00	0.6	13.9	1,679.5	0.6	0.5	1	1	0
11/13/2021 20:00	0.7	13.8	1,763.0	0.7	0.5	1	1	1
11/13/2021 21:00	0.4	12.9	1,979.3	0.5	0.6	1	1	1
11/13/2021 22:00	0.0	13.8	1,460.7	0.0	0.4	1	0	1
11/13/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.4	14.1	1,529.4	0.4	0.5	11 #	7 #	7 #
Minimum:	0.0	12.9	347.6	0.0	0.1	0	0	0
Maximum:	0.7	17.7	1,981.2	0.7	0.6	1	1	1
%SI	54.17	54.17	54.17	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/14/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 14:00	0.0	18.6	217.0	0.0	0.1	1	0	0
11/14/2021 15:00	0.0	16.1	718.4	0.0	0.2	1	0	0
11/14/2021 16:00	0.6	14.0	1,293.1	0.6	0.4	1	1	0
11/14/2021 17:00	0.7	13.9	1,563.8	0.7	0.5	1	1	1
11/14/2021 18:00	0.2	12.8	2,003.8	0.4	0.6	1	1	1
11/14/2021 19:00	0.4	13.0	1,930.1	0.5	0.6	1	1	1
11/14/2021 20:00	0.7	13.7	1,703.6	0.7	0.5	1	1	1
11/14/2021 21:00	0.7	13.9	1,557.5	0.7	0.5	1	1	1
11/14/2021 22:00	0.2	12.8	1,998.8	0.4	0.6	1	1	1
11/14/2021 23:00	0.5	13.5	1,631.6	0.5	0.5	1	1	1
Average/Sum#:	0.4	14.2	1,461.8	0.5	0.5	10 #	8 #	7 #
Minimum:	0.0	12.8	217.0	0.0	0.1	0	0	0
Maximum:	0.7	18.6	2,003.8	0.7	0.6	1	1	1
%SI	58.33	58.33	58.33	58.33	58.33	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/15/2021 00:00	0.0	14.9	905.6	0.0	0.3	1	0	0
11/15/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/15/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/15/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/15/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/15/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/15/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/15/2021 07:00	0.0	18.0	324.5	0.0	0.1	1	0	0
11/15/2021 08:00	0.0	15.8	793.0	0.0	0.2	1	0	0
11/15/2021 09:00	0.6	13.9	1,396.9	0.6	0.4	1	1	0
11/15/2021 10:00	0.7	13.9	1,603.7	0.7	0.5	1	1	1
11/15/2021 11:00	-2.9	13.2	1,929.8	-2.0	0.6	1	1	1
11/15/2021 12:00	-2.7	13.2	1,930.1	-2.0	0.6	1	1	1
11/15/2021 13:00	0.2	13.8	1,501.1	0.4	0.5	1	1	1
11/15/2021 14:00	0.6	13.9	1,568.6	0.6	0.5	1	1	0
11/15/2021 15:00	0.2	13.1	1,912.9	0.4	0.6	1	1	1
11/15/2021 16:00	0.1	13.0	1,957.3	0.2	0.6	1	1	1
11/15/2021 17:00	-0.8	13.2	1,919.1	-0.5	0.6	1	1	1
11/15/2021 18:00	-0.5	13.2	1,929.7	-0.2	0.6	1	1	1
11/15/2021 19:00	0.7	12.8	2,023.8	0.7	0.6	1	1	1
11/15/2021 20:00	-0.2	13.2	1,917.6	-0.1	0.6	1	1	1
11/15/2021 21:00	-0.4	13.2	1,913.8	-0.1	0.6	1	1	1
11/15/2021 22:00	-0.5	13.2	1,912.4	-0.2	0.6	1	1	1
11/15/2021 23:00	-0.7	13.2	1,893.0	-0.4	0.6	1	1	1
Average/Sum#:	-0.3	13.8	1,629.6	-0.1	0.5	18 #	15 #	13 #
Minimum:	-2.9	12.8	324.5	-2.0	0.1	0	0	0
Maximum:	0.7	18.0	2,023.8	0.7	0.6	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/16/2021 00:00	0.0	15.7	597.7	0.0	0.2	1	0	0
11/16/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/16/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/16/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/16/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/16/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/16/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/16/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/16/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/16/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/16/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/16/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/16/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/16/2021 13:00	0.0	18.8	193.3	0.0	0.1	1	0	0
11/16/2021 14:00	0.0	16.7	536.5	0.0	0.2	1	0	0
11/16/2021 15:00	0.0	14.3	1,349.4	0.0	0.4	1	0	0
11/16/2021 16:00	0.6	14.0	1,478.2	0.6	0.4	1	1	0
11/16/2021 17:00	0.2	13.2	1,911.6	0.4	0.6	1	1	1
11/16/2021 18:00	0.4	12.9	2,005.0	0.5	0.6	1	1	1
11/16/2021 19:00	0.1	13.2	1,941.0	0.2	0.6	1	1	1
11/16/2021 20:00	0.7	12.5	2,091.7	0.7	0.6	1	1	1
11/16/2021 21:00	0.7	12.4	2,117.0	0.7	0.6	1	1	1
11/16/2021 22:00	0.7	12.7	2,026.9	0.7	0.6	1	1	1
11/16/2021 23:00	0.7	12.5	2,077.5	0.7	0.6	1	1	1
Average/Sum#:	0.3	14.1	1,527.2	0.4	0.5	12 #	8 #	7 #
Minimum:	0.0	12.4	193.3	0.0	0.1	0	0	0
Maximum:	0.7	18.8	2,117.0	0.7	0.6	1	1	1
%SI	50.00	50.00	50.00	50.00	50.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/17/2021 00:00	0.7	13.1	1,944.4	0.7	0.6	1	1	1
11/17/2021 01:00	0.4	13.3	1,908.2	0.4	0.6	1	1	1
11/17/2021 02:00	0.1	13.3	1,909.6	0.2	0.6	1	1	1
11/17/2021 03:00	0.1	13.3	1,910.5	0.2	0.6	1	1	1
11/17/2021 04:00	0.4	13.1	1,962.2	0.4	0.6	1	1	1
11/17/2021 05:00	0.4	13.1	1,983.4	0.4	0.6	1	1	1
11/17/2021 06:00	0.7	12.4	2,128.2	0.7	0.6	1	1	1
11/17/2021 07:00	0.7	12.7	2,054.3	0.7	0.6	1	1	1
11/17/2021 08:00	-0.7	13.3	1,919.2	-0.4	0.6	1	1	1
11/17/2021 09:00	-0.7	13.3	1,907.6	-0.4	0.6	1	1	1
11/17/2021 10:00	0.6	13.9	1,520.6	0.6	0.5	1	1	0
11/17/2021 11:00	0.4	13.5	1,840.5	0.4	0.6	1	1	1
11/17/2021 12:00	-0.1	13.3	1,921.5	0.1	0.6	1	1	1
11/17/2021 13:00	0.7	13.7	1,482.9	0.7	0.4	1	1	1
11/17/2021 14:00	0.6	14.0	1,434.4	0.6	0.4	1	1	0
11/17/2021 15:00	0.4	13.1	1,908.9	0.4	0.6	1	1	1
11/17/2021 16:00	0.7	12.7	2,031.3	0.7	0.6	1	1	1
11/17/2021 17:00	0.7	12.4	2,103.6	0.7	0.6	1	1	1
11/17/2021 18:00	0.7	12.4	2,095.3	0.7	0.6	1	1	1
11/17/2021 19:00	0.7	12.3	2,122.7	0.7	0.6	1	1	1
11/17/2021 20:00	0.7	12.3	2,126.1	0.7	0.6	1	1	1
11/17/2021 21:00	0.7	12.7	2,041.8	0.7	0.6	1	1	1
11/17/2021 22:00	0.2	13.3	1,915.8	0.4	0.6	1	1	1
11/17/2021 23:00	0.1	13.3	1,909.3	0.2	0.6	1	1	1
Average/Sum#:	0.4	13.1	1,920.1	0.4	0.6	24 #	24 #	22 #
Minimum:	-0.7	12.3	1,434.4	-0.4	0.4	1	1	0
Maximum:	0.7	14.0	2,128.2	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/18/2021 00:00	-0.1	13.3	1,908.0	0.1	0.6	1	1	1
11/18/2021 01:00	-0.2	13.3	1,908.9	-0.1	0.6	1	1	1
11/18/2021 02:00	-0.2	13.3	1,911.8	-0.1	0.6	1	1	1
11/18/2021 03:00	-0.2	13.3	1,912.6	-0.1	0.6	1	1	1
11/18/2021 04:00	-0.2	13.3	1,912.7	-0.1	0.6	1	1	1
11/18/2021 05:00	0.2	13.0	1,993.5	0.4	0.6	1	1	1
11/18/2021 06:00	0.7	12.5	2,097.3	0.7	0.6	1	1	1
11/18/2021 07:00	0.7	12.7	2,060.2	0.7	0.6	1	1	1
11/18/2021 08:00	0.5	13.0	1,978.8	0.5	0.6	1	1	1
11/18/2021 09:00	-0.1	13.3	1,891.0	0.1	0.6	1	1	1
11/18/2021 10:00	0.7	13.9	1,635.9	0.7	0.5	1	1	1
11/18/2021 11:00	0.2	13.2	1,923.3	0.4	0.6	1	1	1
11/18/2021 12:00	0.2	13.2	1,919.7	0.4	0.6	1	1	1
11/18/2021 13:00	0.7	13.8	1,497.9	0.7	0.4	1	1	1
11/18/2021 14:00	0.6	13.9	1,474.9	0.6	0.4	1	1	0
11/18/2021 15:00	0.7	13.6	1,800.1	0.7	0.5	1	1	1
11/18/2021 16:00	0.7	12.6	2,063.1	0.7	0.6	1	1	1
11/18/2021 17:00	0.7	12.4	2,095.8	0.7	0.6	1	1	1
11/18/2021 18:00	0.7	12.1	2,150.3	0.7	0.6	1	1	1
11/18/2021 19:00	0.7	12.4	2,089.1	0.7	0.6	1	1	1
11/18/2021 20:00	0.7	12.7	2,036.3	0.7	0.6	1	1	1
11/18/2021 21:00	0.4	13.1	1,931.3	0.4	0.6	1	1	1
11/18/2021 22:00	-0.1	13.2	1,909.9	0.1	0.6	1	1	1
11/18/2021 23:00	-0.1	13.2	1,908.4	0.1	0.6	1	1	1
Average/Sum#:	0.3	13.1	1,917.1	0.4	0.6	24 #	24 #	23 #
Minimum:	-0.2	12.1	1,474.9	-0.1	0.4	1	1	0
Maximum:	0.7	13.9	2,150.3	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/19/2021 00:00	-0.2	13.2	1,907.8	-0.1	0.6	1	1	1
11/19/2021 01:00	-0.2	13.2	1,877.7	-0.1	0.6	1	1	1
11/19/2021 02:00	0.6	13.9	1,605.5	0.6	0.5	1	1	0
11/19/2021 03:00	0.7	13.2	1,910.6	0.7	0.6	1	1	1
11/19/2021 04:00	0.7	13.0	1,980.2	0.7	0.6	1	1	1
11/19/2021 05:00	0.7	12.8	2,016.6	0.7	0.6	1	1	1
11/19/2021 06:00	0.7	12.7	2,051.7	0.7	0.6	1	1	1
11/19/2021 07:00	0.7	12.7	2,030.6	0.7	0.6	1	1	1
11/19/2021 08:00	0.7	13.2	1,932.1	0.7	0.6	1	1	1
11/19/2021 09:00	0.7	13.3	1,905.6	0.7	0.6	1	1	1
11/19/2021 10:00	0.5	13.3	1,912.0	0.5	0.6	1	1	1
11/19/2021 11:00	0.7	13.2	1,930.4	0.7	0.6	1	1	1
11/19/2021 12:00	0.7	13.2	1,925.4	0.7	0.6	1	1	1
11/19/2021 13:00	0.7	12.8	2,029.7	0.7	0.6	1	1	1
11/19/2021 14:00	0.7	12.7	2,028.8	0.7	0.6	1	1	1
11/19/2021 15:00	0.7	13.0	1,966.6	0.7	0.6	1	1	1
11/19/2021 16:00	0.7	12.9	1,989.8	0.7	0.6	1	1	1
11/19/2021 17:00	0.7	12.9	2,000.4	0.7	0.6	1	1	1
11/19/2021 18:00	0.7	12.9	2,007.9	0.7	0.6	1	1	1
11/19/2021 19:00	0.7	13.2	1,901.9	0.7	0.6	1	1	1
11/19/2021 20:00	0.6	13.9	1,648.2	0.6	0.5	1	1	0
11/19/2021 21:00	0.7	13.8	1,727.9	0.7	0.5	1	1	1
11/19/2021 22:00	0.5	13.1	1,944.7	0.5	0.6	1	1	1
11/19/2021 23:00	0.5	13.1	1,933.8	0.5	0.6	1	1	1
Average/Sum#:	0.6	13.1	1,923.6	0.6	0.6	24 #	24 #	22 #
Minimum:	-0.2	12.7	1,605.5	-0.1	0.5	1	1	0
Maximum:	0.7	13.9	2,051.7	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/20/2021 00:00	0.4	13.2	1,898.5	0.4	0.6	1	1	1
11/20/2021 01:00	0.6	14.0	1,549.2	0.6	0.5	1	1	0
11/20/2021 02:00	0.6	14.0	1,527.0	0.6	0.5	1	1	0
11/20/2021 03:00	0.6	14.0	1,525.7	0.6	0.5	1	1	0
11/20/2021 04:00	0.7	13.9	1,663.4	0.7	0.5	1	1	1
11/20/2021 05:00	0.5	12.9	1,993.6	0.5	0.6	1	1	1
11/20/2021 06:00	0.5	13.1	1,956.4	0.5	0.6	1	1	1
11/20/2021 07:00	0.6	14.0	1,612.3	0.6	0.5	1	1	0
11/20/2021 08:00	0.6	14.0	1,627.2	0.6	0.5	1	1	0
11/20/2021 09:00	0.6	14.0	1,451.4	0.6	0.4	1	1	0
11/20/2021 10:00	0.6	14.0	1,497.7	0.6	0.4	1	1	0
11/20/2021 11:00	0.6	14.0	1,562.8	0.6	0.5	1	1	0
11/20/2021 12:00	0.6	14.0	1,428.9	0.6	0.4	1	1	0
11/20/2021 13:00	0.6	14.0	1,466.0	0.6	0.4	1	1	0
11/20/2021 14:00	0.6	14.0	1,482.7	0.6	0.4	1	1	0
11/20/2021 15:00	0.7	13.9	1,586.5	0.7	0.5	1	1	1
11/20/2021 16:00	0.7	12.9	1,974.3	0.7	0.6	1	1	1
11/20/2021 17:00	0.7	12.8	2,011.6	0.7	0.6	1	1	1
11/20/2021 18:00	0.7	13.1	1,910.1	0.7	0.6	1	1	1
11/20/2021 19:00	0.6	14.0	1,680.4	0.6	0.5	1	1	0
11/20/2021 20:00	0.7	13.8	1,755.8	0.7	0.5	1	1	1
11/20/2021 21:00	0.7	12.9	1,985.2	0.7	0.6	1	1	1
11/20/2021 22:00	0.7	12.6	2,059.7	0.7	0.6	1	1	1
11/20/2021 23:00	0.7	13.3	1,833.8	0.7	0.6	1	1	1
Average/Sum#:	0.6	13.6	1,710.0	0.6	0.5	24 #	24 #	12 #
Minimum:	0.4	12.6	1,428.9	0.4	0.4	1	1	0
Maximum:	0.7	14.0	2,059.7	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/21/2021 00:00	0.7	13.9	1,713.0	0.7	0.5	1	1	1
11/21/2021 01:00	0.4	13.3	1,909.7	0.4	0.6	1	1	1
11/21/2021 02:00	0.0	14.2	1,404.0	0.0	0.4	1	0	1
11/21/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/21/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/21/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/21/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/21/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/21/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/21/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/21/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/21/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/21/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/21/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/21/2021 14:00	0.0	17.9	304.2	0.0	0.1	1	0	0
11/21/2021 15:00	0.0	16.1	733.6	0.0	0.2	1	0	0
11/21/2021 16:00	0.6	14.1	1,303.2	0.6	0.4	1	1	0
11/21/2021 17:00	0.7	14.0	1,548.9	0.7	0.5	1	1	1
11/21/2021 18:00	0.7	12.9	1,985.6	0.7	0.6	1	1	1
11/21/2021 19:00	0.7	12.7	1,997.8	0.7	0.6	1	1	1
11/21/2021 20:00	0.6	14.0	1,665.8	0.6	0.5	1	1	0
11/21/2021 21:00	0.6	13.9	1,749.7	0.6	0.5	1	1	0
11/21/2021 22:00	0.4	13.2	1,948.4	0.4	0.6	1	1	1
11/21/2021 23:00	0.7	13.6	1,668.6	0.7	0.5	1	1	1
Average/Sum#:	0.5	14.1	1,533.3	0.5	0.5	13 #	10 #	8 #
Minimum:	0.0	12.7	304.2	0.0	0.1	0	0	0
Maximum:	0.7	17.9	1,997.8	0.7	0.6	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/22/2021 00:00	0.0	15.0	923.0	0.0	0.3	1	0	0
11/22/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/22/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/22/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/22/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/22/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/22/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/22/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/22/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/22/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/22/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/22/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/22/2021 12:00	0.0	17.7	377.3	0.0	0.1	1	0	0
11/22/2021 13:00	0.0	14.7	1,148.0	0.0	0.3	1	0	0
11/22/2021 14:00	0.6	14.0	1,666.9	0.6	0.5	1	1	0
11/22/2021 15:00	0.6	13.9	1,713.2	0.6	0.5	1	1	0
11/22/2021 16:00	0.7	13.2	1,905.1	0.7	0.6	1	1	1
11/22/2021 17:00	0.7	12.8	2,005.5	0.7	0.6	1	1	1
11/22/2021 18:00	0.7	12.5	2,076.7	0.7	0.6	1	1	1
11/22/2021 19:00	0.7	12.5	2,068.7	0.7	0.6	1	1	1
11/22/2021 20:00	0.7	12.6	2,027.7	0.7	0.6	1	1	1
11/22/2021 21:00	0.6	13.9	1,610.0	0.6	0.5	1	1	0
11/22/2021 22:00	0.7	13.8	1,772.2	0.7	0.5	1	1	1
11/22/2021 23:00	0.7	12.9	1,987.2	0.7	0.6	1	1	1
Average/Sum#:	0.5	13.8	1,637.0	0.5	0.5	13 #	10 #	7 #
Minimum:	0.0	12.5	377.3	0.0	0.1	0	0	0
Maximum:	0.7	17.7	2,076.7	0.7	0.6	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/23/2021 00:00	0.5	13.2	1,915.6	0.5	0.6	1	1	1
11/23/2021 01:00	0.6	14.0	1,475.3	0.6	0.4	1	1	0
11/23/2021 02:00	0.7	13.9	1,674.0	0.7	0.5	1	1	1
11/23/2021 03:00	0.1	13.3	1,921.6	0.2	0.6	1	1	1
11/23/2021 04:00	0.2	13.3	1,896.0	0.4	0.6	1	1	1
11/23/2021 05:00	0.6	13.9	1,648.7	0.6	0.5	1	1	0
11/23/2021 06:00	0.6	13.8	1,596.1	0.6	0.5	1	1	0
11/23/2021 07:00	0.4	13.1	1,952.6	0.4	0.6	1	1	1
11/23/2021 08:00	0.7	13.0	1,946.6	0.7	0.6	1	1	1
11/23/2021 09:00	0.6	13.9	1,593.8	0.6	0.5	1	1	0
11/23/2021 10:00	0.6	13.9	1,543.8	0.6	0.5	1	1	0
11/23/2021 11:00	0.6	14.0	1,491.7	0.6	0.4	1	1	0
11/23/2021 12:00	0.6	14.0	1,373.5	0.6	0.4	1	1	0
11/23/2021 13:00	0.6	14.0	1,529.4	0.6	0.5	1	1	0
11/23/2021 14:00	0.6	14.0	1,626.3	0.6	0.5	1	1	0
11/23/2021 15:00	0.7	13.9	1,586.5	0.7	0.5	1	1	1
11/23/2021 16:00	0.7	12.8	1,993.9	0.7	0.6	1	1	1
11/23/2021 17:00	0.7	12.8	2,011.8	0.7	0.6	1	1	1
11/23/2021 18:00	0.7	12.8	2,018.4	0.7	0.6	1	1	1
11/23/2021 19:00	0.7	13.2	1,894.6	0.7	0.6	1	1	1
11/23/2021 20:00	0.6	14.0	1,676.8	0.6	0.5	1	1	0
11/23/2021 21:00	0.7	14.0	1,546.2	0.7	0.5	1	1	1
11/23/2021 22:00	0.7	13.0	1,993.3	0.7	0.6	1	1	1
11/23/2021 23:00	0.7	13.3	1,924.5	0.7	0.6	1	1	1
Average/Sum#:	0.6	13.5	1,743.0	0.6	0.5	24 #	24 #	14 #
Minimum:	0.1	12.8	1,373.5	0.2	0.4	1	1	0
Maximum:	0.7	14.0	2,018.4	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/24/2021 00:00	0.7	13.4	1,904.6	0.7	0.6	1	1	1
11/24/2021 01:00	0.6	14.0	1,484.5	0.6	0.4	1	1	0
11/24/2021 02:00	0.7	13.9	1,572.4	0.7	0.5	1	1	1
11/24/2021 03:00	0.2	13.3	1,922.9	0.4	0.6	1	1	1
11/24/2021 04:00	0.4	13.2	1,920.5	0.4	0.6	1	1	1
11/24/2021 05:00	0.6	14.0	1,645.0	0.6	0.5	1	1	0
11/24/2021 06:00	0.7	13.8	1,574.2	0.7	0.5	1	1	1
11/24/2021 07:00	0.5	13.1	1,955.5	0.5	0.6	1	1	1
11/24/2021 08:00	0.5	13.2	1,913.5	0.5	0.6	1	1	1
11/24/2021 09:00	0.6	14.0	1,631.5	0.6	0.5	1	1	0
11/24/2021 10:00	0.6	14.0	1,597.2	0.6	0.5	1	1	0
11/24/2021 11:00	0.6	14.0	1,666.2	0.6	0.5	1	1	0
11/24/2021 12:00	0.6	14.0	1,580.4	0.6	0.5	1	1	0
11/24/2021 13:00	0.6	14.0	1,604.4	0.6	0.5	1	1	0
11/24/2021 14:00	0.6	14.0	1,586.2	0.6	0.5	1	1	0
11/24/2021 15:00	0.7	13.9	1,648.8	0.7	0.5	1	1	1
11/24/2021 16:00	0.4	13.1	1,955.5	0.4	0.6	1	1	1
11/24/2021 17:00	0.7	12.9	1,995.0	0.7	0.6	1	1	1
11/24/2021 18:00	0.7	12.8	2,011.7	0.7	0.6	1	1	1
11/24/2021 19:00	0.7	12.9	1,968.2	0.7	0.6	1	1	1
11/24/2021 20:00	0.6	14.0	1,577.8	0.6	0.5	1	1	0
11/24/2021 21:00	0.7	13.9	1,719.7	0.7	0.5	1	1	1
11/24/2021 22:00	0.4	13.2	1,934.3	0.4	0.6	1	1	1
11/24/2021 23:00	0.1	13.3	1,876.8	0.2	0.6	1	1	1
Average/Sum#:	0.6	13.6	1,760.3	0.6	0.5	24 #	24 #	15 #
Minimum:	0.1	12.8	1,484.5	0.2	0.4	1	1	0
Maximum:	0.7	14.0	2,011.7	0.7	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/25/2021 00:00	0.0	15.9	568.1	0.0	0.2	1	0	0
11/25/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	15.9	568.1	0.0	0.2	1 #	0 #	0 #
Minimum:	0.0	15.9	568.1	0.0	0.2	0	0	0
Maximum:	0.0	15.9	568.1	0.0	0.2	1	0	0
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/26/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/27/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/28/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/29/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/29/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/29/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/29/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/29/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/29/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/29/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/29/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/29/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/29/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/29/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/29/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/29/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/29/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/29/2021 14:00	0.0	17.7	319.7	0.0	0.1	1	0	0
11/29/2021 15:00	0.0	16.0	743.8	0.0	0.2	1	0	0
11/29/2021 16:00	0.6	13.9	1,657.4	0.6	0.5	1	1	0
11/29/2021 17:00	0.7	13.0	1,893.5	0.7	0.6	1	1	1
11/29/2021 18:00	0.7	12.5	2,040.3	0.7	0.6	1	1	1
11/29/2021 19:00	0.7	12.8	1,984.1	0.7	0.6	1	1	1
11/29/2021 20:00	0.7	13.9	1,625.1	0.7	0.5	1	1	1
11/29/2021 21:00	0.7	13.8	1,767.3	0.7	0.5	1	1	1
11/29/2021 22:00	0.7	13.1	1,940.2	0.7	0.6	1	1	1
11/29/2021 23:00	0.0	14.4	1,198.0	0.0	0.4	1	0	1
Average/Sum#:	0.5	14.1	1,516.9	0.5	0.5	10 #	7 #	7 #
Minimum:	0.0	12.5	319.7	0.0	0.1	0	0	0
Maximum:	0.7	17.7	2,040.3	0.7	0.6	1	1	1
%SI	58.33	58.33	58.33	58.33	58.33	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/30/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/30/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/30/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/30/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/30/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/30/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/30/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/30/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/30/2021 08:00	0.0	18.1	303.1	0.0	0.1	1	0	0
11/30/2021 09:00	0.0	15.6	877.7	0.0	0.3	1	0	0
11/30/2021 10:00	0.6	13.8	1,771.8	0.6	0.5	1	1	0
11/30/2021 11:00	0.6	13.7	1,775.6	0.6	0.5	1	1	0
11/30/2021 12:00	0.6	13.8	1,749.2	0.6	0.5	1	1	0
11/30/2021 13:00	0.6	13.8	1,731.9	0.6	0.5	1	1	0
11/30/2021 14:00	0.6	13.8	1,724.6	0.6	0.5	1	1	0
11/30/2021 15:00	0.6	13.8	1,722.3	0.6	0.5	1	1	0
11/30/2021 16:00	0.6	13.8	1,725.3	0.6	0.5	1	1	0
11/30/2021 17:00	0.6	13.8	1,728.5	0.6	0.5	1	1	0
11/30/2021 18:00	0.6	13.8	1,726.0	0.6	0.5	1	1	0
11/30/2021 19:00	0.6	13.9	1,724.5	0.6	0.5	1	1	0
11/30/2021 20:00	0.6	13.9	1,689.7	0.6	0.5	1	1	0
11/30/2021 21:00	0.6	14.1	1,251.5	0.6	0.4	1	1	0
11/30/2021 22:00	0.6	13.8	1,737.6	0.6	0.5	1	1	0
11/30/2021 23:00	0.1	13.2	1,904.6	0.2	0.6	1	1	1
Average/Sum#:	0.5	14.2	1,571.5	0.5	0.5	16 #	14 #	1 #
Minimum:	0.0	13.2	303.1	0.0	0.1	0	0	0
Maximum:	0.6	18.1	1,904.6	0.6	0.6	1	1	1
%SI	33.33	33.33	33.33	33.33	33.33	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/01/2021 00:00	0.1	13.2	1,904.6	0.2	0.6	1	1	1
12/01/2021 01:00	0.7	13.9	1,489.3	0.7	0.4	1	1	1
12/01/2021 02:00	0.6	14.0	1,284.6	0.6	0.4	1	1	0
12/01/2021 03:00	0.6	13.9	1,689.5	0.6	0.5	1	1	0
12/01/2021 04:00	0.4	13.6	1,798.1	0.4	0.5	1	1	1
12/01/2021 05:00	0.7	13.3	1,809.1	0.7	0.5	1	1	1
12/01/2021 06:00	0.7	13.4	1,671.5	0.7	0.5	1	1	1
12/01/2021 07:00	0.7	12.3	2,156.1	0.7	0.6	1	1	1
12/01/2021 08:00	0.7	12.1	2,166.2	0.7	0.6	1	1	1
12/01/2021 09:00	0.7	12.2	2,151.2	0.7	0.6	1	1	1
12/01/2021 10:00	0.7	12.1	2,164.9	0.7	0.6	1	1	1
12/01/2021 11:00	0.7	12.0	2,173.6	0.7	0.7	1	1	1
12/01/2021 12:00	0.2	11.9	2,175.4	0.4	0.7	1	1	1
12/01/2021 13:00	0.4	11.9	2,161.0	0.5	0.6	1	1	1
12/01/2021 14:00	0.4	11.9	2,154.4	0.5	0.6	1	1	1
12/01/2021 15:00	0.4	11.9	2,150.8	0.5	0.6	1	1	1
12/01/2021 16:00	0.4	11.9	2,159.9	0.5	0.6	1	1	1
12/01/2021 17:00	0.2	11.9	2,168.1	0.4	0.7	1	1	1
12/01/2021 18:00	0.2	11.9	2,168.2	0.4	0.7	1	1	1
12/01/2021 19:00	0.2	12.0	2,154.3	0.4	0.6	1	1	1
12/01/2021 20:00	0.1	12.5	2,075.6	0.2	0.6	1	1	1
12/01/2021 21:00	0.1	12.6	2,047.6	0.2	0.6	1	1	1
12/01/2021 22:00	0.1	12.8	2,000.1	0.2	0.6	1	1	1
12/01/2021 23:00	-0.9	13.2	1,902.2	-0.5	0.6	1	1	1
Average/Sum#:	0.4	12.6	1,990.7	0.5	0.6	24 #	24 #	22 #
Minimum:	-0.9	11.9	1,284.6	-0.5	0.4	1	1	0
Maximum:	0.7	14.0	2,175.4	0.7	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/02/2021 00:00	0.0	14.6	1,181.9	0.0	0.4	1	0	1
12/02/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2021 04:00	0.0	16.5	646.8	0.0	0.2	1	0	0
12/02/2021 05:00	0.4	14.0	1,349.3	0.4	0.4	1	1	0
12/02/2021 06:00	0.4	14.0	1,302.7	0.4	0.4	1	1	0
12/02/2021 07:00	0.4	14.0	1,342.7	0.4	0.4	1	1	0
12/02/2021 08:00	0.4	14.0	1,240.0	0.4	0.4	1	1	0
12/02/2021 09:00	0.4	14.0	1,211.5	0.4	0.4	1	1	0
12/02/2021 10:00	0.4	14.0	1,363.7	0.4	0.4	1	1	0
12/02/2021 11:00	0.4	14.0	1,437.1	0.4	0.4	1	1	0
12/02/2021 12:00	0.4	14.0	1,579.4	0.4	0.5	1	1	0
12/02/2021 13:00	0.4	13.9	1,701.8	0.4	0.5	1	1	0
12/02/2021 14:00	0.3	13.9	1,699.4	0.4	0.5	1	1	0
12/02/2021 15:00	0.4	13.9	1,699.3	0.4	0.5	1	1	0
12/02/2021 16:00	0.4	13.9	1,697.2	0.4	0.5	1	1	0
12/02/2021 17:00	0.4	13.9	1,696.1	0.4	0.5	1	1	0
12/02/2021 18:00	0.4	13.9	1,695.5	0.4	0.5	1	1	0
12/02/2021 19:00	0.4	13.9	1,694.2	0.4	0.5	1	1	0
12/02/2021 20:00	0.3	13.7	1,753.2	0.4	0.5	1	1	0
12/02/2021 21:00	-0.9	13.2	1,887.6	-0.5	0.6	1	1	1
12/02/2021 22:00	-0.2	12.8	1,982.3	0.1	0.6	1	1	1
12/02/2021 23:00	-0.2	13.2	1,851.3	-0.1	0.6	1	1	1
Average/Sum#:	0.2	14.0	1,524.4	0.3	0.5	21 #	19 #	4 #
Minimum:	-0.9	12.8	646.8	-0.5	0.2	0	0	0
Maximum:	0.4	16.5	1,982.3	0.4	0.6	1	1	1
%SI	12.50	12.50	12.50	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/03/2021 00:00	0.0	14.5	1,113.9	0.0	0.3	1	0	0
12/03/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2021 03:00	0.0	18.6	226.9	0.0	0.1	1	0	0
12/03/2021 04:00	0.0	16.1	714.9	0.0	0.2	1	0	0
12/03/2021 05:00	0.4	13.9	1,395.3	0.4	0.4	1	1	0
12/03/2021 06:00	0.3	13.9	1,601.3	0.4	0.5	1	1	0
12/03/2021 07:00	-0.5	13.4	1,844.7	-0.2	0.6	1	1	1
12/03/2021 08:00	-0.2	12.3	2,147.3	0.1	0.6	1	1	1
12/03/2021 09:00	0.1	12.2	2,157.3	0.2	0.6	1	1	1
12/03/2021 10:00	0.1	12.1	2,158.6	0.2	0.6	1	1	1
12/03/2021 11:00	0.1	12.1	2,167.3	0.2	0.7	1	1	1
12/03/2021 12:00	0.1	12.1	2,165.5	0.2	0.6	1	1	1
12/03/2021 13:00	0.1	12.0	2,165.4	0.2	0.6	1	1	1
12/03/2021 14:00	0.1	12.0	2,161.1	0.2	0.6	1	1	1
12/03/2021 15:00	0.1	12.0	2,160.8	0.2	0.6	1	1	1
12/03/2021 16:00	-0.2	13.0	1,857.0	0.1	0.6	1	1	1
12/03/2021 17:00	0.4	13.8	1,722.0	0.4	0.5	1	1	0
12/03/2021 18:00	0.4	13.8	1,689.8	0.4	0.5	1	1	0
12/03/2021 19:00	0.1	13.8	1,694.2	0.2	0.5	1	1	1
12/03/2021 20:00	-1.1	13.0	1,941.3	-0.7	0.6	1	1	1
12/03/2021 21:00	-0.2	12.5	2,050.4	0.1	0.6	1	1	1
12/03/2021 22:00	-0.2	12.6	2,047.6	0.1	0.6	1	1	1
12/03/2021 23:00	0.0	13.8	1,547.7	0.0	0.5	1	0	1
Average/Sum#:	0.0	13.3	1,760.5	0.1	0.5	22 #	18 #	15 #
Minimum:	-1.1	12.0	226.9	-0.7	0.1	0	0	0
Maximum:	0.4	18.6	2,167.3	0.4	0.7	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/04/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2021 05:00	0.0	18.8	190.7	0.0	0.1	1	0	0
12/04/2021 06:00	0.0	18.1	289.9	0.0	0.1	1	0	0
12/04/2021 07:00	0.0	14.5	1,311.0	0.0	0.4	1	0	0
12/04/2021 08:00	0.4	13.8	1,699.3	0.4	0.5	1	1	0
12/04/2021 09:00	0.3	13.8	1,700.8	0.4	0.5	1	1	0
12/04/2021 10:00	0.4	13.8	1,755.7	0.4	0.5	1	1	0
12/04/2021 11:00	0.4	13.8	1,760.5	0.4	0.5	1	1	0
12/04/2021 12:00	0.0	14.3	1,438.3	0.0	0.4	1	0	0
12/04/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2021 15:00	0.0	18.9	182.3	0.0	0.1	1	0	0
12/04/2021 16:00	0.0	15.8	776.3	0.0	0.2	1	0	0
12/04/2021 17:00	0.4	13.8	1,683.4	0.4	0.5	1	1	0
12/04/2021 18:00	-1.4	13.3	1,888.5	-0.9	0.6	1	1	1
12/04/2021 19:00	-1.1	13.3	1,819.9	-0.7	0.5	1	1	1
12/04/2021 20:00	0.3	13.8	1,597.8	0.4	0.5	1	1	0
12/04/2021 21:00	0.3	13.8	1,580.6	0.4	0.5	1	1	0
12/04/2021 22:00	0.3	13.8	1,565.3	0.4	0.5	1	1	0
12/04/2021 23:00	0.0	15.9	526.3	0.0	0.2	1	0	0
Average/Sum#:	0.0	14.9	1,280.4	0.1	0.4	17 #	10 #	2 #
Minimum:	-1.4	13.3	182.3	-0.9	0.1	0	0	0
Maximum:	0.4	18.9	1,888.5	0.4	0.6	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/05/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2021 13:00	0.0	18.0	309.9	0.0	0.1	1	0	0
12/05/2021 14:00	0.0	15.3	925.2	0.0	0.3	1	0	0
12/05/2021 15:00	0.4	13.9	1,651.9	0.4	0.5	1	1	0
12/05/2021 16:00	0.2	13.8	1,581.7	0.4	0.5	1	1	1
12/05/2021 17:00	-0.9	13.0	1,937.9	-0.5	0.6	1	1	1
12/05/2021 18:00	-0.2	12.5	2,065.2	0.1	0.6	1	1	1
12/05/2021 19:00	-0.2	12.5	2,087.6	0.1	0.6	1	1	1
12/05/2021 20:00	-0.1	12.2	2,167.8	0.2	0.7	1	1	1
12/05/2021 21:00	-0.1	12.4	2,114.9	0.2	0.6	1	1	1
12/05/2021 22:00	-0.1	12.4	2,113.8	0.2	0.6	1	1	1
12/05/2021 23:00	-0.2	12.7	2,039.7	0.1	0.6	1	1	1
Average/Sum#:	-0.1	13.5	1,726.9	0.1	0.5	11 #	9 #	8 #
Minimum:	-0.9	12.2	309.9	-0.5	0.1	0	0	0
Maximum:	0.4	18.0	2,167.8	0.4	0.7	1	1	1
%SI	54.17	54.17	54.17	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/06/2021 00:00	-0.8	13.0	1,944.7	-0.4	0.6	1	1	1
12/06/2021 01:00	0.4	13.8	1,673.4	0.4	0.5	1	1	0
12/06/2021 02:00	0.1	13.8	1,727.9	0.2	0.5	1	1	1
12/06/2021 03:00	-0.7	13.2	1,939.5	-0.4	0.6	1	1	1
12/06/2021 04:00	-0.7	13.2	1,916.5	-0.4	0.6	1	1	1
12/06/2021 05:00	0.4	13.8	1,608.7	0.4	0.5	1	1	0
12/06/2021 06:00	-0.7	13.2	1,848.8	-0.4	0.6	1	1	1
12/06/2021 07:00	-0.2	12.4	2,123.2	0.1	0.6	1	1	1
12/06/2021 08:00	-0.1	12.4	2,122.0	0.2	0.6	1	1	1
12/06/2021 09:00	-0.1	13.6	1,694.1	0.1	0.5	1	1	1
12/06/2021 10:00	0.4	13.8	1,760.3	0.4	0.5	1	1	0
12/06/2021 11:00	-0.8	13.1	1,965.7	-0.5	0.6	1	1	1
12/06/2021 12:00	-0.1	12.3	2,128.2	0.2	0.6	1	1	1
12/06/2021 13:00	-0.2	13.0	1,878.4	0.1	0.6	1	1	1
12/06/2021 14:00	0.4	13.8	1,609.1	0.4	0.5	1	1	0
12/06/2021 15:00	-0.8	13.5	1,802.0	-0.5	0.5	1	1	1
12/06/2021 16:00	-0.4	12.7	2,031.4	-0.1	0.6	1	1	1
12/06/2021 17:00	-0.2	12.6	2,067.8	0.1	0.6	1	1	1
12/06/2021 18:00	-0.1	12.2	2,154.2	0.2	0.6	1	1	1
12/06/2021 19:00	-0.1	12.4	2,112.9	0.2	0.6	1	1	1
12/06/2021 20:00	-0.1	12.3	2,136.7	0.2	0.6	1	1	1
12/06/2021 21:00	-0.2	12.6	2,069.5	0.1	0.6	1	1	1
12/06/2021 22:00	-0.2	12.6	2,065.4	0.1	0.6	1	1	1
12/06/2021 23:00	-0.2	12.6	2,069.0	0.1	0.6	1	1	1
Average/Sum#:	-0.2	13.0	1,935.4	0.0	0.6	24 #	24 #	20 #
Minimum:	-0.8	12.2	1,608.7	-0.5	0.5	1	1	0
Maximum:	0.4	13.8	2,154.2	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/07/2021 00:00	-0.4	12.7	2,027.5	-0.1	0.6	1	1	1
12/07/2021 01:00	0.1	13.8	1,501.4	0.2	0.5	1	1	1
12/07/2021 02:00	-0.1	13.8	1,657.4	0.1	0.5	1	1	1
12/07/2021 03:00	-1.2	13.2	1,918.6	-0.8	0.6	1	1	1
12/07/2021 04:00	-0.2	12.6	2,055.9	0.1	0.6	1	1	1
12/07/2021 05:00	-0.1	13.7	1,691.1	0.1	0.5	1	1	1
12/07/2021 06:00	0.4	13.8	1,616.9	0.4	0.5	1	1	0
12/07/2021 07:00	-0.9	13.1	1,930.6	-0.5	0.6	1	1	1
12/07/2021 08:00	-0.1	12.3	2,140.3	0.2	0.6	1	1	1
12/07/2021 09:00	-0.2	12.5	2,049.5	0.1	0.6	1	1	1
12/07/2021 10:00	0.4	13.7	1,775.2	0.4	0.5	1	1	0
12/07/2021 11:00	0.4	13.7	1,777.3	0.4	0.5	1	1	0
12/07/2021 12:00	0.4	13.7	1,749.5	0.4	0.5	1	1	0
12/07/2021 13:00	0.1	13.7	1,746.6	0.2	0.5	1	1	1
12/07/2021 14:00	-0.1	12.6	2,004.1	0.1	0.6	1	1	1
12/07/2021 15:00	0.1	12.0	2,132.8	0.2	0.6	1	1	1
12/07/2021 16:00	0.1	12.0	2,165.3	0.2	0.6	1	1	1
12/07/2021 17:00	0.1	12.1	2,143.7	0.2	0.6	1	1	1
12/07/2021 18:00	-0.1	12.1	2,155.7	0.2	0.6	1	1	1
12/07/2021 19:00	-0.1	12.2	2,142.4	0.2	0.6	1	1	1
12/07/2021 20:00	-0.1	12.2	2,143.1	0.2	0.6	1	1	1
12/07/2021 21:00	-0.1	12.2	2,138.7	0.2	0.6	1	1	1
12/07/2021 22:00	-0.1	12.5	2,075.2	0.1	0.6	1	1	1
12/07/2021 23:00	-0.2	12.5	2,065.7	0.1	0.6	1	1	1
Average/Sum#:	-0.1	12.9	1,950.2	0.1	0.6	24 #	24 #	20 #
Minimum:	-1.2	12.0	1,501.4	-0.8	0.5	1	1	0
Maximum:	0.4	13.8	2,165.3	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/08/2021 00:00	-0.4	12.7	1,997.5	-0.1	0.6	1	1	1
12/08/2021 01:00	0.4	13.9	1,575.5	0.4	0.5	1	1	0
12/08/2021 02:00	0.4	13.9	1,296.2	0.4	0.4	1	1	0
12/08/2021 03:00	0.3	13.8	1,707.2	0.4	0.5	1	1	0
12/08/2021 04:00	-0.5	13.4	1,794.3	-0.2	0.5	1	1	1
12/08/2021 05:00	-0.4	13.2	1,839.7	-0.1	0.6	1	1	1
12/08/2021 06:00	0.2	13.8	1,730.5	0.4	0.5	1	1	1
12/08/2021 07:00	-0.9	13.0	1,949.8	-0.5	0.6	1	1	1
12/08/2021 08:00	-0.7	13.2	1,829.4	-0.4	0.5	1	1	1
12/08/2021 09:00	0.4	13.9	1,348.3	0.4	0.4	1	1	0
12/08/2021 10:00	0.4	13.9	1,313.8	0.4	0.4	1	1	0
12/08/2021 11:00	0.3	13.8	1,692.8	0.4	0.5	1	1	0
12/08/2021 12:00	-0.9	13.4	1,816.1	-0.7	0.5	1	1	1
12/08/2021 13:00	-0.9	13.4	1,802.7	-0.7	0.5	1	1	1
12/08/2021 14:00	0.4	13.9	1,291.8	0.4	0.4	1	1	0
12/08/2021 15:00	0.4	13.9	1,365.0	0.4	0.4	1	1	0
12/08/2021 16:00	0.3	13.8	1,681.7	0.4	0.5	1	1	0
12/08/2021 17:00	-1.4	13.1	1,931.5	-0.9	0.6	1	1	1
12/08/2021 18:00	-0.2	12.4	2,091.0	0.1	0.6	1	1	1
12/08/2021 19:00	-0.2	12.4	2,081.3	0.1	0.6	1	1	1
12/08/2021 20:00	-0.2	12.5	2,066.9	0.1	0.6	1	1	1
12/08/2021 21:00	-0.2	12.7	2,010.8	0.1	0.6	1	1	1
12/08/2021 22:00	-0.2	12.8	1,991.7	0.1	0.6	1	1	1
12/08/2021 23:00	-0.2	12.7	2,012.3	0.1	0.6	1	1	1
Average/Sum#:	-0.2	13.3	1,759.1	0.0	0.5	24 #	24 #	15 #
Minimum:	-1.4	12.4	1,291.8	-0.9	0.4	1	1	0
Maximum:	0.4	13.9	2,091.0	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/09/2021 00:00	-1.4	13.2	1,895.8	-0.9	0.6	1	1	1
12/09/2021 01:00	0.3	13.9	1,468.3	0.4	0.4	1	1	0
12/09/2021 02:00	0.1	13.8	1,547.9	0.2	0.5	1	1	1
12/09/2021 03:00	-1.4	13.1	1,921.3	-0.9	0.6	1	1	1
12/09/2021 04:00	-0.7	12.9	1,943.7	-0.4	0.6	1	1	1
12/09/2021 05:00	0.3	13.9	1,518.3	0.4	0.5	1	1	0
12/09/2021 06:00	0.1	13.8	1,600.6	0.2	0.5	1	1	1
12/09/2021 07:00	-1.7	13.1	1,941.6	-1.1	0.6	1	1	1
12/09/2021 08:00	-0.2	12.8	2,001.0	0.1	0.6	1	1	1
12/09/2021 09:00	-0.4	12.8	1,998.0	-0.1	0.6	1	1	1
12/09/2021 10:00	0.1	13.8	1,577.9	0.2	0.5	1	1	1
12/09/2021 11:00	0.2	13.8	1,683.7	0.4	0.5	1	1	1
12/09/2021 12:00	-0.2	12.9	1,966.4	0.1	0.6	1	1	1
12/09/2021 13:00	-0.2	13.0	1,937.1	0.1	0.6	1	1	1
12/09/2021 14:00	0.4	14.0	1,428.9	0.4	0.4	1	1	0
12/09/2021 15:00	0.2	13.9	1,480.9	0.2	0.4	1	1	1
12/09/2021 16:00	-0.5	13.1	1,944.6	-0.2	0.6	1	1	1
12/09/2021 17:00	-0.1	12.5	2,078.3	0.1	0.6	1	1	1
12/09/2021 18:00	-0.1	12.6	2,053.9	0.1	0.6	1	1	1
12/09/2021 19:00	-0.1	12.5	2,078.5	0.1	0.6	1	1	1
12/09/2021 20:00	-0.1	12.5	2,084.7	0.1	0.6	1	1	1
12/09/2021 21:00	-0.1	12.5	2,084.9	0.1	0.6	1	1	1
12/09/2021 22:00	-0.5	13.0	1,970.1	-0.2	0.6	1	1	1
12/09/2021 23:00	-0.1	12.9	1,996.3	0.1	0.6	1	1	1
Average/Sum#:	-0.3	13.2	1,841.8	0.0	0.6	24 #	24 #	21 #
Minimum:	-1.7	12.5	1,428.9	-1.1	0.4	1	1	0
Maximum:	0.4	14.0	2,084.9	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/10/2021 00:00	-0.9	13.2	1,906.6	-0.5	0.6	1	1	1
12/10/2021 01:00	0.4	13.9	1,512.5	0.4	0.5	1	1	0
12/10/2021 02:00	0.4	13.9	1,582.0	0.4	0.5	1	1	0
12/10/2021 03:00	-1.1	13.4	1,883.4	-0.7	0.6	1	1	1
12/10/2021 04:00	-1.1	13.3	1,906.9	-0.7	0.6	1	1	1
12/10/2021 05:00	0.4	13.9	1,587.5	0.4	0.5	1	1	0
12/10/2021 06:00	0.2	13.8	1,709.9	0.4	0.5	1	1	1
12/10/2021 07:00	-0.7	13.3	1,935.7	-0.4	0.6	1	1	1
12/10/2021 08:00	-0.7	13.3	1,904.4	-0.4	0.6	1	1	1
12/10/2021 09:00	0.4	13.9	1,582.3	0.4	0.5	1	1	0
12/10/2021 10:00	0.4	13.9	1,666.5	0.4	0.5	1	1	0
12/10/2021 11:00	0.4	13.9	1,598.7	0.4	0.5	1	1	0
12/10/2021 12:00	0.4	13.9	1,650.1	0.4	0.5	1	1	0
12/10/2021 13:00	0.4	13.9	1,572.6	0.4	0.5	1	1	0
12/10/2021 14:00	0.4	14.0	1,290.1	0.4	0.4	1	1	0
12/10/2021 15:00	0.4	13.9	1,550.9	0.4	0.5	1	1	0
12/10/2021 16:00	-1.4	13.3	1,922.0	-0.9	0.6	1	1	1
12/10/2021 17:00	-0.1	12.3	2,150.4	0.2	0.6	1	1	1
12/10/2021 18:00	-0.1	12.4	2,120.0	0.2	0.6	1	1	1
12/10/2021 19:00	-0.1	12.4	2,122.0	0.2	0.6	1	1	1
12/10/2021 20:00	-0.1	12.3	2,147.6	0.2	0.6	1	1	1
12/10/2021 21:00	-0.1	12.5	2,106.8	0.1	0.6	1	1	1
12/10/2021 22:00	-0.2	12.8	2,053.4	0.1	0.6	1	1	1
12/10/2021 23:00	-0.2	12.9	2,056.0	0.1	0.6	1	1	1
Average/Sum#:	-0.1	13.3	1,813.3	0.1	0.6	24 #	24 #	14 #
Minimum:	-1.4	12.3	1,290.1	-0.9	0.4	1	1	0
Maximum:	0.4	14.0	2,150.4	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/11/2021 00:00	-0.4	12.8	2,053.8	-0.1	0.6	1	1	1
12/11/2021 01:00	-0.5	13.1	1,995.8	-0.2	0.6	1	1	1
12/11/2021 02:00	-1.4	13.3	1,899.3	-0.9	0.6	1	1	1
12/11/2021 03:00	0.4	13.9	1,596.5	0.4	0.5	1	1	0
12/11/2021 04:00	0.1	13.8	1,665.1	0.2	0.5	1	1	1
12/11/2021 05:00	-0.7	13.2	1,976.3	-0.4	0.6	1	1	1
12/11/2021 06:00	-0.2	12.9	2,043.3	0.1	0.6	1	1	1
12/11/2021 07:00	-0.4	13.1	1,982.2	-0.1	0.6	1	1	1
12/11/2021 08:00	0.4	13.9	1,582.6	0.4	0.5	1	1	0
12/11/2021 09:00	0.3	13.9	1,365.7	0.4	0.4	1	1	0
12/11/2021 10:00	0.3	13.9	1,399.0	0.4	0.4	1	1	0
12/11/2021 11:00	0.3	13.9	1,300.8	0.4	0.4	1	1	0
12/11/2021 12:00	0.3	13.9	1,299.0	0.4	0.4	1	1	0
12/11/2021 13:00	0.3	13.9	1,479.4	0.4	0.4	1	1	0
12/11/2021 14:00	0.3	13.9	1,518.2	0.4	0.5	1	1	0
12/11/2021 15:00	0.3	13.8	1,608.2	0.4	0.5	1	1	0
12/11/2021 16:00	-0.4	12.8	2,055.8	-0.1	0.6	1	1	1
12/11/2021 17:00	0.1	12.4	2,149.6	0.2	0.6	1	1	1
12/11/2021 18:00	0.1	12.5	2,135.0	0.2	0.6	1	1	1
12/11/2021 19:00	0.1	12.3	2,169.0	0.2	0.7	1	1	1
12/11/2021 20:00	0.1	12.5	2,132.0	0.2	0.6	1	1	1
12/11/2021 21:00	0.1	12.3	2,165.8	0.2	0.6	1	1	1
12/11/2021 22:00	0.1	12.5	2,127.1	0.2	0.6	1	1	1
12/11/2021 23:00	-0.1	12.8	2,045.4	0.1	0.6	1	1	1
Average/Sum#:	0.0	13.2	1,822.7	0.1	0.5	24 #	24 #	15 #
Minimum:	-1.4	12.3	1,299.0	-0.9	0.4	1	1	0
Maximum:	0.4	13.9	2,169.0	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/12/2021 00:00	-0.1	12.8	2,035.7	0.1	0.6	1	1	1
12/12/2021 01:00	-0.1	13.0	1,993.6	0.1	0.6	1	1	1
12/12/2021 02:00	-0.7	13.3	1,892.2	-0.4	0.6	1	1	1
12/12/2021 03:00	0.3	13.9	1,574.5	0.4	0.5	1	1	0
12/12/2021 04:00	0.1	13.8	1,711.2	0.2	0.5	1	1	1
12/12/2021 05:00	-0.4	13.0	1,967.2	-0.1	0.6	1	1	1
12/12/2021 06:00	-0.2	13.0	1,996.1	0.1	0.6	1	1	1
12/12/2021 07:00	0.1	13.8	1,599.3	0.2	0.5	1	1	1
12/12/2021 08:00	0.3	13.9	1,570.1	0.4	0.5	1	1	0
12/12/2021 09:00	0.3	13.9	1,374.3	0.4	0.4	1	1	0
12/12/2021 10:00	0.3	13.8	1,573.3	0.4	0.5	1	1	0
12/12/2021 11:00	0.3	13.8	1,665.6	0.4	0.5	1	1	0
12/12/2021 12:00	0.3	13.8	1,586.0	0.4	0.5	1	1	0
12/12/2021 13:00	0.3	13.8	1,611.2	0.4	0.5	1	1	0
12/12/2021 14:00	0.3	13.8	1,568.5	0.4	0.5	1	1	0
12/12/2021 15:00	-0.1	13.8	1,563.4	0.1	0.5	1	1	1
12/12/2021 16:00	-0.4	12.8	2,015.8	-0.1	0.6	1	1	1
12/12/2021 17:00	0.1	12.5	2,090.9	0.2	0.6	1	1	1
12/12/2021 18:00	0.1	12.5	2,084.7	0.2	0.6	1	1	1
12/12/2021 19:00	0.1	12.3	2,127.0	0.2	0.6	1	1	1
12/12/2021 20:00	0.1	12.5	2,077.0	0.2	0.6	1	1	1
12/12/2021 21:00	0.1	12.5	2,080.2	0.2	0.6	1	1	1
12/12/2021 22:00	0.1	12.6	2,053.3	0.2	0.6	1	1	1
12/12/2021 23:00	-0.1	12.8	2,007.9	0.1	0.6	1	1	1
Average/Sum#:	0.0	13.2	1,825.8	0.2	0.6	24 #	24 #	16 #
Minimum:	-0.7	12.3	1,374.3	-0.4	0.4	1	1	0
Maximum:	0.3	13.9	2,127.0	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/13/2021 00:00	-0.7	13.2	1,897.0	-0.4	0.6	1	1	1
12/13/2021 01:00	0.3	13.8	1,670.8	0.4	0.5	1	1	0
12/13/2021 02:00	0.1	13.8	1,646.7	0.2	0.5	1	1	1
12/13/2021 03:00	-0.5	12.9	1,968.0	-0.2	0.6	1	1	1
12/13/2021 04:00	-0.9	13.0	1,912.8	-0.5	0.6	1	1	1
12/13/2021 05:00	0.3	13.9	1,568.6	0.4	0.5	1	1	0
12/13/2021 06:00	-0.1	13.7	1,753.4	0.1	0.5	1	1	1
12/13/2021 07:00	-0.7	12.6	2,037.1	-0.2	0.6	1	1	1
12/13/2021 08:00	-0.1	12.2	2,128.6	0.2	0.6	1	1	1
12/13/2021 09:00	-0.1	12.3	2,100.2	0.2	0.6	1	1	1
12/13/2021 10:00	-0.1	12.4	2,069.5	0.2	0.6	1	1	1
12/13/2021 11:00	-0.4	12.8	1,966.3	-0.1	0.6	1	1	1
12/13/2021 12:00	0.4	13.9	1,620.9	0.4	0.5	1	1	0
12/13/2021 13:00	0.1	13.7	1,764.2	0.2	0.5	1	1	1
12/13/2021 14:00	-0.2	12.8	1,994.4	0.1	0.6	1	1	1
12/13/2021 15:00	0.1	12.2	2,141.6	0.2	0.6	1	1	1
12/13/2021 16:00	0.1	12.1	2,170.0	0.2	0.7	1	1	1
12/13/2021 17:00	0.2	12.0	2,179.8	0.4	0.7	1	1	1
12/13/2021 18:00	0.2	12.1	2,174.9	0.4	0.7	1	1	1
12/13/2021 19:00	0.1	11.9	2,193.4	0.2	0.7	1	1	1
12/13/2021 20:00	-0.1	12.3	2,092.1	0.2	0.6	1	1	1
12/13/2021 21:00	-0.1	12.6	2,040.2	0.1	0.6	1	1	1
12/13/2021 22:00	-0.4	12.8	1,991.0	-0.1	0.6	1	1	1
12/13/2021 23:00	-0.2	12.8	1,997.2	0.1	0.6	1	1	1
Average/Sum#:	-0.1	12.8	1,961.6	0.1	0.6	24 #	24 #	21 #
Minimum:	-0.9	11.9	1,568.6	-0.5	0.5	1	1	0
Maximum:	0.4	13.9	2,193.4	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 VOC, Ppmvdc 1 Hour(s)	> Limit Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/14/2021 00:00	-0.8	13.3	1,806.2	-0.5	0.5	1	1	1
12/14/2021 01:00	0.4	13.9	1,275.7	0.4	0.4	1	1	0
12/14/2021 02:00	0.3	13.9	1,295.1	0.4	0.4	1	1	0
12/14/2021 03:00	0.3	13.8	1,715.6	0.4	0.5	1	1	0
12/14/2021 04:00	-1.2	13.5	1,831.2	-0.8	0.5	1	1	1
12/14/2021 05:00	-0.7	13.3	1,818.3	-0.4	0.5	1	1	1
12/14/2021 06:00	0.1	13.8	1,686.4	0.2	0.5	1	1	1
12/14/2021 07:00	-0.2	12.9	2,022.3	0.1	0.6	1	1	1
12/14/2021 08:00	-0.1	12.7	2,059.8	0.1	0.6	1	1	1
12/14/2021 09:00	-0.4	13.1	1,935.1	-0.1	0.6	1	1	1
12/14/2021 10:00	0.4	13.9	1,591.5	0.4	0.5	1	1	0
12/14/2021 11:00	0.1	13.8	1,606.5	0.2	0.5	1	1	1
12/14/2021 12:00	-0.2	13.0	1,988.6	0.1	0.6	1	1	1
12/14/2021 13:00	-0.5	13.3	1,897.5	-0.2	0.6	1	1	1
12/14/2021 14:00	0.4	13.9	1,623.3	0.4	0.5	1	1	0
12/14/2021 15:00	0.4	13.9	1,510.4	0.4	0.5	1	1	0
12/14/2021 16:00	-0.2	13.1	1,948.4	-0.1	0.6	1	1	1
12/14/2021 17:00	0.1	12.2	2,195.7	0.2	0.7	1	1	1
12/14/2021 18:00	0.1	12.4	2,155.7	0.2	0.6	1	1	1
12/14/2021 19:00	0.1	12.2	2,192.6	0.2	0.7	1	1	1
12/14/2021 20:00	0.1	12.2	2,196.1	0.2	0.7	1	1	1
12/14/2021 21:00	0.1	12.4	2,153.1	0.2	0.6	1	1	1
12/14/2021 22:00	0.1	12.7	2,075.7	0.2	0.6	1	1	1
12/14/2021 23:00	-0.2	13.1	1,995.8	-0.1	0.6	1	1	1
Average/Sum#:	-0.1	13.2	1,857.4	0.1	0.6	24 #	24 #	18 #
Minimum:	-1.2	12.2	1,275.7	-0.8	0.4	1	1	0
Maximum:	0.4	13.9	2,196.1	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/15/2021 00:00	-0.8	13.2	1,925.9	-0.5	0.6	1	1	1
12/15/2021 01:00	0.4	13.9	1,530.8	0.4	0.5	1	1	0
12/15/2021 02:00	0.1	13.8	1,636.2	0.2	0.5	1	1	1
12/15/2021 03:00	-0.8	13.3	1,918.0	-0.5	0.6	1	1	1
12/15/2021 04:00	-0.8	13.3	1,905.7	-0.5	0.6	1	1	1
12/15/2021 05:00	0.3	13.9	1,556.9	0.4	0.5	1	1	0
12/15/2021 06:00	-0.4	13.3	1,857.5	-0.1	0.6	1	1	1
12/15/2021 07:00	-0.1	12.6	2,108.6	0.1	0.6	1	1	1
12/15/2021 08:00	-0.8	13.1	1,952.9	-0.5	0.6	1	1	1
12/15/2021 09:00	0.4	13.9	1,569.3	0.4	0.5	1	1	0
12/15/2021 10:00	0.3	13.8	1,594.3	0.4	0.5	1	1	0
12/15/2021 11:00	0.1	13.8	1,585.1	0.2	0.5	1	1	1
12/15/2021 12:00	-0.8	13.0	1,979.7	-0.4	0.6	1	1	1
12/15/2021 13:00	-0.7	12.9	1,978.1	-0.4	0.6	1	1	1
12/15/2021 14:00	0.4	13.9	1,537.7	0.4	0.5	1	1	0
12/15/2021 15:00	0.1	13.8	1,694.9	0.2	0.5	1	1	1
12/15/2021 16:00	-0.1	12.6	2,080.8	0.1	0.6	1	1	1
12/15/2021 17:00	0.1	12.1	2,195.1	0.2	0.7	1	1	1
12/15/2021 18:00	0.1	12.2	2,187.3	0.2	0.7	1	1	1
12/15/2021 19:00	0.1	12.2	2,185.5	0.2	0.7	1	1	1
12/15/2021 20:00	0.1	12.2	2,187.7	0.2	0.7	1	1	1
12/15/2021 21:00	0.1	12.3	2,149.5	0.2	0.6	1	1	1
12/15/2021 22:00	-0.1	12.6	2,076.3	0.1	0.6	1	1	1
12/15/2021 23:00	-0.1	12.7	2,049.8	0.1	0.6	1	1	1
Average/Sum#:	-0.1	13.1	1,893.5	0.0	0.6	24 #	24 #	19 #
Minimum:	-0.8	12.1	1,530.8	-0.5	0.5	1	1	0
Maximum:	0.4	13.9	2,195.1	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/16/2021 00:00	-0.1	12.9	2,008.6	0.1	0.6	1	1	1
12/16/2021 01:00	-0.4	13.1	1,928.9	-0.1	0.6	1	1	1
12/16/2021 02:00	0.3	13.9	1,551.7	0.4	0.5	1	1	0
12/16/2021 03:00	0.3	13.9	1,553.4	0.4	0.5	1	1	0
12/16/2021 04:00	0.1	13.8	1,593.3	0.2	0.5	1	1	1
12/16/2021 05:00	-0.4	13.0	1,998.6	-0.1	0.6	1	1	1
12/16/2021 06:00	0.1	12.3	2,178.2	0.2	0.7	1	1	1
12/16/2021 07:00	0.1	12.3	2,165.3	0.2	0.6	1	1	1
12/16/2021 08:00	-0.1	12.9	1,998.3	0.1	0.6	1	1	1
12/16/2021 09:00	-0.8	13.1	1,944.0	-0.5	0.6	1	1	1
12/16/2021 10:00	-0.1	13.7	1,473.4	0.1	0.4	1	1	1
12/16/2021 11:00	0.1	13.8	1,589.2	0.2	0.5	1	1	1
12/16/2021 12:00	-0.9	12.9	1,989.7	-0.5	0.6	1	1	1
12/16/2021 13:00	-0.8	13.2	1,905.6	-0.5	0.6	1	1	1
12/16/2021 14:00	0.3	13.9	1,530.4	0.4	0.5	1	1	0
12/16/2021 15:00	-0.1	13.8	1,568.0	0.1	0.5	1	1	1
12/16/2021 16:00	-1.2	12.6	2,075.8	-0.7	0.6	1	1	1
12/16/2021 17:00	-0.2	12.1	2,200.8	0.1	0.7	1	1	1
12/16/2021 18:00	-0.2	12.1	2,200.9	0.1	0.7	1	1	1
12/16/2021 19:00	-0.2	12.1	2,200.3	0.1	0.7	1	1	1
12/16/2021 20:00	-0.2	12.1	2,202.0	0.1	0.7	1	1	1
12/16/2021 21:00	-0.2	12.2	2,180.6	0.1	0.7	1	1	1
12/16/2021 22:00	-0.4	12.7	2,071.6	-0.1	0.6	1	1	1
12/16/2021 23:00	-0.5	12.8	2,032.0	-0.2	0.6	1	1	1
Average/Sum#:	-0.2	13.0	1,922.5	0.0	0.6	24 #	24 #	21 #
Minimum:	-1.2	12.1	1,473.4	-0.7	0.4	1	1	0
Maximum:	0.3	13.9	2,202.0	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/17/2021 00:00	-1.2	13.3	1,893.8	-0.8	0.6	1	1	1
12/17/2021 01:00	0.3	13.9	1,532.7	0.4	0.5	1	1	0
12/17/2021 02:00	0.3	13.9	1,527.6	0.4	0.5	1	1	0
12/17/2021 03:00	0.1	13.8	1,676.0	0.2	0.5	1	1	1
12/17/2021 04:00	-1.2	13.1	1,975.0	-0.8	0.6	1	1	1
12/17/2021 05:00	-1.1	13.1	1,979.0	-0.7	0.6	1	1	1
12/17/2021 06:00	-0.2	12.3	2,156.0	0.1	0.6	1	1	1
12/17/2021 07:00	-0.2	12.4	2,129.7	0.1	0.6	1	1	1
12/17/2021 08:00	-0.7	13.1	1,992.5	-0.4	0.6	1	1	1
12/17/2021 09:00	-0.8	13.3	1,905.9	-0.5	0.6	1	1	1
12/17/2021 10:00	0.3	13.9	1,552.3	0.4	0.5	1	1	0
12/17/2021 11:00	0.3	13.9	1,518.0	0.4	0.5	1	1	0
12/17/2021 12:00	0.3	14.0	1,366.5	0.4	0.4	1	1	0
12/17/2021 13:00	0.3	13.9	1,625.8	0.4	0.5	1	1	0
12/17/2021 14:00	0.3	13.9	1,469.5	0.4	0.4	1	1	0
12/17/2021 15:00	0.1	13.9	1,575.2	0.2	0.5	1	1	1
12/17/2021 16:00	-1.5	12.9	2,006.6	-0.9	0.6	1	1	1
12/17/2021 17:00	-0.1	12.1	2,185.5	0.2	0.7	1	1	1
12/17/2021 18:00	-0.1	12.1	2,187.8	0.2	0.7	1	1	1
12/17/2021 19:00	-0.1	12.2	2,185.9	0.2	0.7	1	1	1
12/17/2021 20:00	-0.1	12.1	2,188.9	0.2	0.7	1	1	1
12/17/2021 21:00	-0.1	12.2	2,179.0	0.2	0.7	1	1	1
12/17/2021 22:00	-0.4	12.7	2,064.9	-0.1	0.6	1	1	1
12/17/2021 23:00	-0.7	13.0	1,993.7	-0.4	0.6	1	1	1
Average/Sum#:	-0.3	13.1	1,869.5	0.0	0.6	24 #	24 #	17 #
Minimum:	-1.5	12.1	1,366.5	-0.9	0.4	1	1	0
Maximum:	0.3	14.0	2,188.9	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/18/2021 00:00	-0.9	13.2	1,906.6	-0.5	0.6	1	1	1
12/18/2021 01:00	0.1	13.8	1,588.9	0.2	0.5	1	1	1
12/18/2021 02:00	0.3	13.8	1,694.7	0.4	0.5	1	1	0
12/18/2021 03:00	-0.5	13.3	1,947.8	-0.2	0.6	1	1	1
12/18/2021 04:00	-0.5	13.2	1,959.8	-0.2	0.6	1	1	1
12/18/2021 05:00	0.1	13.8	1,653.3	0.2	0.5	1	1	1
12/18/2021 06:00	0.1	13.8	1,737.8	0.2	0.5	1	1	1
12/18/2021 07:00	-0.7	13.1	2,002.3	-0.4	0.6	1	1	1
12/18/2021 08:00	-0.9	13.1	1,997.8	-0.5	0.6	1	1	1
12/18/2021 09:00	-0.8	13.1	1,969.5	-0.5	0.6	1	1	1
12/18/2021 10:00	0.3	13.9	1,529.6	0.4	0.5	1	1	0
12/18/2021 11:00	0.3	13.9	1,564.8	0.4	0.5	1	1	0
12/18/2021 12:00	0.3	13.9	1,527.1	0.4	0.5	1	1	0
12/18/2021 13:00	0.3	13.9	1,514.1	0.4	0.5	1	1	0
12/18/2021 14:00	0.3	13.9	1,526.1	0.4	0.5	1	1	0
12/18/2021 15:00	0.3	13.9	1,481.0	0.4	0.4	1	1	0
12/18/2021 16:00	-0.7	13.3	1,840.4	-0.4	0.6	1	1	1
12/18/2021 17:00	-0.2	12.4	2,136.6	0.1	0.6	1	1	1
12/18/2021 18:00	-0.4	12.6	2,086.0	-0.1	0.6	1	1	1
12/18/2021 19:00	-0.2	12.3	2,158.6	0.1	0.6	1	1	1
12/18/2021 20:00	-0.2	12.2	2,179.7	0.1	0.7	1	1	1
12/18/2021 21:00	-0.2	12.5	2,102.7	0.1	0.6	1	1	1
12/18/2021 22:00	-0.4	12.8	2,056.2	-0.1	0.6	1	1	1
12/18/2021 23:00	-0.7	13.0	1,987.9	-0.4	0.6	1	1	1
Average/Sum#:	-0.2	13.3	1,839.6	0.0	0.6	24 #	24 #	17 #
Minimum:	-0.9	12.2	1,481.0	-0.5	0.4	1	1	0
Maximum:	0.3	13.9	2,179.7	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/19/2021 00:00	-0.4	12.9	2,022.7	-0.1	0.6	1	1	1
12/19/2021 01:00	-0.8	13.1	1,964.3	-0.5	0.6	1	1	1
12/19/2021 02:00	0.3	13.9	1,596.1	0.4	0.5	1	1	0
12/19/2021 03:00	0.3	13.8	1,664.6	0.4	0.5	1	1	0
12/19/2021 04:00	-0.2	13.2	1,960.3	-0.1	0.6	1	1	1
12/19/2021 05:00	-0.2	13.1	1,982.3	-0.1	0.6	1	1	1
12/19/2021 06:00	-0.4	13.2	1,947.3	-0.1	0.6	1	1	1
12/19/2021 07:00	-0.4	13.1	1,983.3	-0.1	0.6	1	1	1
12/19/2021 08:00	-0.4	13.1	1,984.6	-0.1	0.6	1	1	1
12/19/2021 09:00	-0.5	13.3	1,917.3	-0.2	0.6	1	1	1
12/19/2021 10:00	0.3	13.9	1,481.7	0.4	0.4	1	1	0
12/19/2021 11:00	0.3	13.9	1,470.8	0.4	0.4	1	1	0
12/19/2021 12:00	0.3	13.9	1,432.6	0.4	0.4	1	1	0
12/19/2021 13:00	0.3	13.9	1,575.5	0.4	0.5	1	1	0
12/19/2021 14:00	0.3	13.9	1,576.4	0.4	0.5	1	1	0
12/19/2021 15:00	0.3	13.9	1,564.3	0.4	0.5	1	1	0
12/19/2021 16:00	-0.5	13.1	1,958.5	-0.2	0.6	1	1	1
12/19/2021 17:00	-0.2	12.4	2,142.5	0.1	0.6	1	1	1
12/19/2021 18:00	-0.2	12.7	2,077.9	0.1	0.6	1	1	1
12/19/2021 19:00	-0.2	12.6	2,100.5	0.1	0.6	1	1	1
12/19/2021 20:00	-0.4	12.6	2,083.2	-0.1	0.6	1	1	1
12/19/2021 21:00	-0.2	12.7	2,075.3	0.1	0.6	1	1	1
12/19/2021 22:00	-0.2	12.7	2,070.6	0.1	0.6	1	1	1
12/19/2021 23:00	-0.4	12.8	2,034.7	-0.1	0.6	1	1	1
Average/Sum#:	-0.1	13.2	1,861.1	0.1	0.6	24 #	24 #	16 #
Minimum:	-0.8	12.4	1,432.6	-0.5	0.4	1	1	0
Maximum:	0.3	13.9	2,142.5	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/20/2021 00:00	-0.4	12.9	2,032.3	-0.1	0.6	1	1	1
12/20/2021 01:00	-0.8	13.1	1,947.6	-0.5	0.6	1	1	1
12/20/2021 02:00	0.3	13.8	1,680.8	0.4	0.5	1	1	0
12/20/2021 03:00	0.1	13.8	1,714.5	0.2	0.5	1	1	1
12/20/2021 04:00	-0.5	13.1	1,988.3	-0.2	0.6	1	1	1
12/20/2021 05:00	-0.4	12.7	2,082.6	-0.1	0.6	1	1	1
12/20/2021 06:00	-0.2	12.3	2,153.8	0.1	0.6	1	1	1
12/20/2021 07:00	-0.2	12.7	2,076.5	0.1	0.6	1	1	1
12/20/2021 08:00	-0.7	13.1	1,963.9	-0.4	0.6	1	1	1
12/20/2021 09:00	0.4	13.9	1,638.9	0.4	0.5	1	1	0
12/20/2021 10:00	0.3	13.9	1,328.5	0.4	0.4	1	1	0
12/20/2021 11:00	0.3	13.8	1,624.1	0.4	0.5	1	1	0
12/20/2021 12:00	-0.4	13.4	1,844.7	-0.2	0.6	1	1	1
12/20/2021 13:00	-0.2	12.6	2,084.1	0.1	0.6	1	1	1
12/20/2021 14:00	-0.2	12.3	2,145.1	0.1	0.6	1	1	1
12/20/2021 15:00	-0.1	12.3	2,139.9	0.2	0.6	1	1	1
12/20/2021 16:00	-0.1	12.2	2,176.6	0.2	0.7	1	1	1
12/20/2021 17:00	-0.1	12.2	2,184.3	0.2	0.7	1	1	1
12/20/2021 18:00	-0.1	12.2	2,185.4	0.2	0.7	1	1	1
12/20/2021 19:00	-0.1	12.1	2,192.2	0.2	0.7	1	1	1
12/20/2021 20:00	-0.1	12.1	2,192.8	0.2	0.7	1	1	1
12/20/2021 21:00	-0.1	12.1	2,195.0	0.2	0.7	1	1	1
12/20/2021 22:00	-0.1	12.1	2,185.6	0.2	0.7	1	1	1
12/20/2021 23:00	-0.2	12.6	2,071.5	0.1	0.6	1	1	1
Average/Sum#:	-0.2	12.8	1,992.9	0.1	0.6	24 #	24 #	20 #
Minimum:	-0.8	12.1	1,328.5	-0.5	0.4	1	1	0
Maximum:	0.4	13.9	2,195.0	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/21/2021 00:00	-0.4	12.8	2,031.0	-0.1	0.6	1	1	1
12/21/2021 01:00	0.2	13.9	1,663.4	0.2	0.5	1	1	1
12/21/2021 02:00	0.1	13.8	1,778.5	0.2	0.5	1	1	1
12/21/2021 03:00	-0.4	13.1	1,986.1	-0.1	0.6	1	1	1
12/21/2021 04:00	-0.7	13.1	1,949.3	-0.4	0.6	1	1	1
12/21/2021 05:00	0.3	13.8	1,646.9	0.4	0.5	1	1	0
12/21/2021 06:00	0.1	13.8	1,730.8	0.2	0.5	1	1	1
12/21/2021 07:00	-0.2	13.0	2,028.9	0.1	0.6	1	1	1
12/21/2021 08:00	-0.1	12.4	2,164.9	0.2	0.6	1	1	1
12/21/2021 09:00	-0.1	12.8	2,040.8	0.1	0.6	1	1	1
12/21/2021 10:00	0.4	13.9	1,597.3	0.4	0.5	1	1	0
12/21/2021 11:00	0.1	13.8	1,773.1	0.2	0.5	1	1	1
12/21/2021 12:00	-0.9	13.0	2,017.6	-0.5	0.6	1	1	1
12/21/2021 13:00	-0.9	13.1	1,965.2	-0.5	0.6	1	1	1
12/21/2021 14:00	0.4	13.8	1,634.5	0.4	0.5	1	1	0
12/21/2021 15:00	0.1	13.8	1,774.2	0.2	0.5	1	1	1
12/21/2021 16:00	-1.5	13.0	2,019.4	-0.9	0.6	1	1	1
12/21/2021 17:00	-0.2	12.2	2,208.2	0.1	0.7	1	1	1
12/21/2021 18:00	-0.1	12.1	2,216.6	0.2	0.7	1	1	1
12/21/2021 19:00	-0.1	12.1	2,216.3	0.2	0.7	1	1	1
12/21/2021 20:00	-0.1	12.1	2,212.7	0.2	0.7	1	1	1
12/21/2021 21:00	-0.1	12.3	2,161.1	0.2	0.6	1	1	1
12/21/2021 22:00	-0.2	12.7	2,074.9	0.1	0.6	1	1	1
12/21/2021 23:00	-0.4	12.9	2,031.3	-0.1	0.6	1	1	1
Average/Sum#:	-0.2	13.1	1,955.1	0.0	0.6	24 #	24 #	21 #
Minimum:	-1.5	12.1	1,597.3	-0.9	0.5	1	1	0
Maximum:	0.4	13.9	2,216.6	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/22/2021 00:00	-1.8	13.3	1,905.0	-1.2	0.6	1	1	1
12/22/2021 01:00	0.4	13.9	1,598.3	0.4	0.5	1	1	0
12/22/2021 02:00	0.1	13.8	1,661.0	0.2	0.5	1	1	1
12/22/2021 03:00	-3.0	13.3	1,932.5	-2.1	0.6	1	1	1
12/22/2021 04:00	-2.6	13.3	1,914.3	-1.8	0.6	1	1	1
12/22/2021 05:00	0.4	13.9	1,447.1	0.4	0.4	1	1	0
12/22/2021 06:00	0.1	13.8	1,670.4	0.2	0.5	1	1	1
12/22/2021 07:00	-1.7	13.1	1,961.6	-1.1	0.6	1	1	1
12/22/2021 08:00	-1.5	13.1	1,951.4	-0.9	0.6	1	1	1
12/22/2021 09:00	0.3	13.9	1,424.1	0.4	0.4	1	1	0
12/22/2021 10:00	0.1	13.8	1,500.8	0.2	0.5	1	1	1
12/22/2021 11:00	-0.8	13.1	1,961.9	-0.5	0.6	1	1	1
12/22/2021 12:00	-0.8	13.3	1,919.0	-0.5	0.6	1	1	1
12/22/2021 13:00	0.1	13.8	1,605.4	0.2	0.5	1	1	1
12/22/2021 14:00	0.3	13.8	1,768.3	0.4	0.5	1	1	0
12/22/2021 15:00	-1.2	13.1	1,967.2	-0.8	0.6	1	1	1
12/22/2021 16:00	-0.5	12.8	2,020.2	-0.2	0.6	1	1	1
12/22/2021 17:00	-0.2	12.5	2,104.7	0.1	0.6	1	1	1
12/22/2021 18:00	-0.8	13.0	1,983.5	-0.4	0.6	1	1	1
12/22/2021 19:00	-1.1	13.1	1,945.2	-0.7	0.6	1	1	1
12/22/2021 20:00	-0.7	13.0	1,961.3	-0.4	0.6	1	1	1
12/22/2021 21:00	0.3	13.9	1,531.0	0.4	0.5	1	1	0
12/22/2021 22:00	-0.1	13.8	1,728.2	0.1	0.5	1	1	1
12/22/2021 23:00	-1.1	12.9	2,000.2	-0.7	0.6	1	1	1
Average/Sum#:	-0.7	13.4	1,810.9	-0.3	0.6	24 #	24 #	19 #
Minimum:	-3.0	12.5	1,424.1	-2.1	0.4	1	1	0
Maximum:	0.4	13.9	2,104.7	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/23/2021 00:00	-1.4	13.2	1,907.8	-0.9	0.6	1	1	1
12/23/2021 01:00	0.3	13.9	1,563.8	0.4	0.5	1	1	0
12/23/2021 02:00	0.1	13.8	1,598.1	0.2	0.5	1	1	1
12/23/2021 03:00	-0.5	13.2	1,920.3	-0.2	0.6	1	1	1
12/23/2021 04:00	-0.5	13.2	1,896.3	-0.2	0.6	1	1	1
12/23/2021 05:00	0.3	13.8	1,625.6	0.4	0.5	1	1	0
12/23/2021 06:00	-0.4	13.7	1,618.0	-0.2	0.5	1	1	1
12/23/2021 07:00	-0.7	12.8	2,014.5	-0.4	0.6	1	1	1
12/23/2021 08:00	-1.2	13.1	1,909.0	-0.8	0.6	1	1	1
12/23/2021 09:00	0.3	13.9	1,528.6	0.4	0.5	1	1	0
12/23/2021 10:00	0.1	13.8	1,623.1	0.2	0.5	1	1	1
12/23/2021 11:00	-0.8	13.1	1,918.0	-0.5	0.6	1	1	1
12/23/2021 12:00	-0.8	13.1	1,892.2	-0.5	0.6	1	1	1
12/23/2021 13:00	0.3	13.8	1,599.0	0.4	0.5	1	1	0
12/23/2021 14:00	0.3	13.9	1,300.2	0.4	0.4	1	1	0
12/23/2021 15:00	0.3	13.9	1,602.7	0.4	0.5	1	1	0
12/23/2021 16:00	-0.5	13.4	1,816.2	-0.2	0.5	1	1	1
12/23/2021 17:00	-0.5	13.1	1,891.9	-0.2	0.6	1	1	1
12/23/2021 18:00	0.1	13.8	1,639.7	0.2	0.5	1	1	1
12/23/2021 19:00	-2.4	13.0	1,926.7	-1.7	0.6	1	1	1
12/23/2021 20:00	-0.8	13.1	1,889.6	-0.5	0.6	1	1	1
12/23/2021 21:00	0.3	13.9	1,445.7	0.4	0.4	1	1	0
12/23/2021 22:00	0.1	13.8	1,560.5	0.2	0.5	1	1	1
12/23/2021 23:00	-0.9	13.0	1,944.0	-0.5	0.6	1	1	1
Average/Sum#:	-0.4	13.5	1,734.6	-0.1	0.5	24 #	24 #	17 #
Minimum:	-2.4	12.8	1,300.2	-1.7	0.4	1	1	0
Maximum:	0.3	13.9	2,014.5	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/24/2021 00:00	-0.8	13.1	1,899.6	-0.5	0.6	1	1	1
12/24/2021 01:00	0.4	13.9	1,499.4	0.4	0.4	1	1	0
12/24/2021 02:00	0.3	13.9	1,452.9	0.4	0.4	1	1	0
12/24/2021 03:00	0.3	13.9	1,339.1	0.4	0.4	1	1	0
12/24/2021 04:00	0.3	13.9	1,343.8	0.4	0.4	1	1	0
12/24/2021 05:00	0.3	13.9	1,724.5	0.4	0.5	1	1	0
12/24/2021 06:00	-0.9	13.3	1,811.3	-0.7	0.5	1	1	1
12/24/2021 07:00	-0.7	13.3	1,846.5	-0.4	0.6	1	1	1
12/24/2021 08:00	0.1	13.8	1,631.2	0.2	0.5	1	1	1
12/24/2021 09:00	-0.9	13.1	1,931.0	-0.5	0.6	1	1	1
12/24/2021 10:00	-0.8	13.1	1,914.8	-0.5	0.6	1	1	1
12/24/2021 11:00	0.4	14.0	1,379.4	0.4	0.4	1	1	0
12/24/2021 12:00	0.4	13.9	1,598.2	0.4	0.5	1	1	0
12/24/2021 13:00	0.4	14.0	1,402.6	0.4	0.4	1	1	0
12/24/2021 14:00	0.3	14.0	1,389.1	0.4	0.4	1	1	0
12/24/2021 15:00	0.3	13.9	1,471.0	0.4	0.4	1	1	0
12/24/2021 16:00	0.1	13.9	1,490.2	0.2	0.4	1	1	1
12/24/2021 17:00	-0.7	13.0	1,944.0	-0.4	0.6	1	1	1
12/24/2021 18:00	-0.4	12.9	1,962.2	-0.1	0.6	1	1	1
12/24/2021 19:00	-0.4	12.9	1,970.6	-0.1	0.6	1	1	1
12/24/2021 20:00	-0.7	13.2	1,902.1	-0.4	0.6	1	1	1
12/24/2021 21:00	0.3	14.0	1,386.4	0.4	0.4	1	1	0
12/24/2021 22:00	0.1	13.8	1,578.1	0.2	0.5	1	1	1
12/24/2021 23:00	-0.4	12.9	1,993.2	-0.1	0.6	1	1	1
Average/Sum#:	-0.1	13.6	1,660.9	0.1	0.5	24 #	24 #	13 #
Minimum:	-0.9	12.9	1,339.1	-0.7	0.4	1	1	0
Maximum:	0.4	14.0	1,993.2	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/25/2021 00:00	-0.7	13.1	1,916.4	-0.4	0.6	1	1	1
12/25/2021 01:00	0.3	13.9	1,532.8	0.4	0.5	1	1	0
12/25/2021 02:00	0.3	13.9	1,428.9	0.4	0.4	1	1	0
12/25/2021 03:00	0.3	13.9	1,339.8	0.4	0.4	1	1	0
12/25/2021 04:00	0.1	13.8	1,557.0	0.2	0.5	1	1	1
12/25/2021 05:00	-0.7	13.0	1,967.0	-0.4	0.6	1	1	1
12/25/2021 06:00	-0.8	13.1	1,918.1	-0.5	0.6	1	1	1
12/25/2021 07:00	0.1	13.8	1,558.6	0.2	0.5	1	1	1
12/25/2021 08:00	0.3	13.8	1,583.5	0.4	0.5	1	1	0
12/25/2021 09:00	0.3	13.9	1,390.3	0.4	0.4	1	1	0
12/25/2021 10:00	0.3	13.8	1,609.0	0.4	0.5	1	1	0
12/25/2021 11:00	0.3	13.9	1,564.4	0.4	0.5	1	1	0
12/25/2021 12:00	0.3	13.9	1,532.1	0.4	0.5	1	1	0
12/25/2021 13:00	0.3	13.9	1,473.5	0.4	0.4	1	1	0
12/25/2021 14:00	0.3	13.9	1,582.5	0.4	0.5	1	1	0
12/25/2021 15:00	0.3	13.9	1,590.9	0.4	0.5	1	1	0
12/25/2021 16:00	-0.5	13.2	1,884.3	-0.2	0.6	1	1	1
12/25/2021 17:00	-0.4	12.7	2,018.8	-0.1	0.6	1	1	1
12/25/2021 18:00	-0.2	12.7	2,020.0	0.1	0.6	1	1	1
12/25/2021 19:00	-0.2	12.8	2,012.3	0.1	0.6	1	1	1
12/25/2021 20:00	-0.7	13.2	1,904.1	-0.4	0.6	1	1	1
12/25/2021 21:00	0.3	13.9	1,623.6	0.4	0.5	1	1	0
12/25/2021 22:00	0.1	13.9	1,570.0	0.2	0.5	1	1	1
12/25/2021 23:00	-0.2	13.1	1,960.9	-0.1	0.6	1	1	1
Average/Sum#:	0.0	13.5	1,689.1	0.1	0.5	24 #	24 #	12 #
Minimum:	-0.8	12.7	1,339.8	-0.5	0.4	1	1	0
Maximum:	0.3	13.9	2,020.0	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/26/2021 00:00	0.0	14.4	1,212.6	0.0	0.4	1	0	1
12/26/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 15:00	0.0	18.7	203.8	0.0	0.1	1	0	0
12/26/2021 16:00	0.0	16.1	713.1	0.0	0.2	1	0	0
12/26/2021 17:00	0.3	13.8	1,726.0	0.4	0.5	1	1	0
12/26/2021 18:00	0.1	13.8	1,731.1	0.2	0.5	1	1	1
12/26/2021 19:00	-0.5	13.0	1,966.7	-0.2	0.6	1	1	1
12/26/2021 20:00	-0.4	13.0	1,958.9	-0.1	0.6	1	1	1
12/26/2021 21:00	0.4	13.9	1,604.7	0.4	0.5	1	1	0
12/26/2021 22:00	0.1	13.8	1,688.8	0.2	0.5	1	1	1
12/26/2021 23:00	-0.2	13.1	1,968.1	-0.1	0.6	1	1	1
Average/Sum#:	0.0	14.4	1,477.4	0.1	0.5	10 #	7 #	6 #
Minimum:	-0.5	13.0	203.8	-0.2	0.1	0	0	0
Maximum:	0.4	18.7	1,968.1	0.4	0.6	1	1	1
%SI	58.33	58.33	58.33	58.33	58.33	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/27/2021 00:00	-0.1	12.9	2,004.4	0.1	0.6	1	1	1
12/27/2021 01:00	-0.1	13.1	1,946.2	0.1	0.6	1	1	1
12/27/2021 02:00	0.4	13.9	1,630.6	0.4	0.5	1	1	0
12/27/2021 03:00	0.3	13.9	1,484.6	0.4	0.4	1	1	0
12/27/2021 04:00	0.3	13.9	1,495.7	0.4	0.4	1	1	0
12/27/2021 05:00	0.1	13.8	1,648.3	0.2	0.5	1	1	1
12/27/2021 06:00	-0.2	12.9	2,002.9	0.1	0.6	1	1	1
12/27/2021 07:00	-0.1	12.5	2,105.6	0.1	0.6	1	1	1
12/27/2021 08:00	-0.1	12.6	2,079.8	0.1	0.6	1	1	1
12/27/2021 09:00	0.1	12.6	2,093.9	0.2	0.6	1	1	1
12/27/2021 10:00	0.1	12.7	2,048.0	0.2	0.6	1	1	1
12/27/2021 11:00	0.1	12.8	1,992.0	0.2	0.6	1	1	1
12/27/2021 12:00	0.4	13.9	1,675.0	0.4	0.5	1	1	0
12/27/2021 13:00	0.4	13.9	1,616.6	0.4	0.5	1	1	0
12/27/2021 14:00	-0.4	13.1	1,944.3	-0.1	0.6	1	1	1
12/27/2021 15:00	-0.2	12.6	2,066.6	0.1	0.6	1	1	1
12/27/2021 16:00	-0.1	12.1	2,186.8	0.2	0.7	1	1	1
12/27/2021 17:00	0.1	12.1	2,198.9	0.2	0.7	1	1	1
12/27/2021 18:00	-0.1	12.1	2,197.4	0.2	0.7	1	1	1
12/27/2021 19:00	-0.1	12.1	2,200.4	0.2	0.7	1	1	1
12/27/2021 20:00	-0.1	12.1	2,202.2	0.2	0.7	1	1	1
12/27/2021 21:00	-0.1	12.2	2,182.2	0.2	0.7	1	1	1
12/27/2021 22:00	-0.2	12.8	2,045.7	0.1	0.6	1	1	1
12/27/2021 23:00	-0.2	12.9	2,027.4	0.1	0.6	1	1	1
Average/Sum#:	0.0	12.9	1,961.5	0.2	0.6	24 #	24 #	19 #
Minimum:	-0.4	12.1	1,484.6	-0.1	0.4	1	1	0
Maximum:	0.4	13.9	2,202.2	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/28/2021 00:00	-0.8	13.3	1,913.9	-0.5	0.6	1	1	1
12/28/2021 01:00	0.4	13.9	1,513.2	0.4	0.5	1	1	0
12/28/2021 02:00	0.1	13.9	1,599.1	0.2	0.5	1	1	1
12/28/2021 03:00	-0.7	13.3	1,933.3	-0.4	0.6	1	1	1
12/28/2021 04:00	-0.5	13.3	1,909.1	-0.2	0.6	1	1	1
12/28/2021 05:00	0.4	13.9	1,549.2	0.4	0.5	1	1	0
12/28/2021 06:00	-0.1	13.8	1,705.2	0.1	0.5	1	1	1
12/28/2021 07:00	-0.7	13.2	1,959.5	-0.4	0.6	1	1	1
12/28/2021 08:00	-0.5	13.1	1,992.9	-0.2	0.6	1	1	1
12/28/2021 09:00	-0.4	13.1	1,964.5	-0.1	0.6	1	1	1
12/28/2021 10:00	0.4	13.9	1,526.1	0.4	0.5	1	1	0
12/28/2021 11:00	0.3	13.9	1,418.2	0.4	0.4	1	1	0
12/28/2021 12:00	0.3	13.9	1,509.8	0.4	0.5	1	1	0
12/28/2021 13:00	-0.4	13.5	1,842.5	-0.2	0.6	1	1	1
12/28/2021 14:00	-0.2	13.2	1,896.8	-0.1	0.6	1	1	1
12/28/2021 15:00	0.1	13.8	1,653.6	0.2	0.5	1	1	1
12/28/2021 16:00	-0.2	12.7	2,080.7	0.1	0.6	1	1	1
12/28/2021 17:00	0.1	12.2	2,218.2	0.2	0.7	1	1	1
12/28/2021 18:00	0.1	12.3	2,194.9	0.2	0.7	1	1	1
12/28/2021 19:00	0.1	12.5	2,130.1	0.2	0.6	1	1	1
12/28/2021 20:00	-0.1	12.7	2,100.0	0.1	0.6	1	1	1
12/28/2021 21:00	-0.1	12.8	2,057.9	0.1	0.6	1	1	1
12/28/2021 22:00	-0.1	12.9	2,048.7	0.1	0.6	1	1	1
12/28/2021 23:00	-0.2	13.0	1,995.8	0.1	0.6	1	1	1
Average/Sum#:	-0.1	13.3	1,863.1	0.1	0.6	24 #	24 #	19 #
Minimum:	-0.8	12.2	1,418.2	-0.5	0.4	1	1	0
Maximum:	0.4	13.9	2,218.2	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/29/2021 00:00	-0.5	13.3	1,910.1	-0.2	0.6	1	1	1
12/29/2021 01:00	0.4	13.9	1,504.1	0.4	0.5	1	1	0
12/29/2021 02:00	0.1	13.8	1,567.7	0.2	0.5	1	1	1
12/29/2021 03:00	-1.5	13.3	1,935.3	-1.1	0.6	1	1	1
12/29/2021 04:00	-1.2	13.3	1,922.4	-0.8	0.6	1	1	1
12/29/2021 05:00	0.3	13.9	1,449.1	0.4	0.4	1	1	0
12/29/2021 06:00	0.1	13.8	1,741.8	0.2	0.5	1	1	1
12/29/2021 07:00	-0.9	13.1	1,989.3	-0.5	0.6	1	1	1
12/29/2021 08:00	-0.8	13.1	1,954.4	-0.5	0.6	1	1	1
12/29/2021 09:00	0.3	13.9	1,410.8	0.4	0.4	1	1	0
12/29/2021 10:00	0.1	13.8	1,611.3	0.2	0.5	1	1	1
12/29/2021 11:00	-0.7	13.0	2,004.5	-0.4	0.6	1	1	1
12/29/2021 12:00	-1.1	13.3	1,911.2	-0.7	0.6	1	1	1
12/29/2021 13:00	0.4	13.9	1,652.0	0.4	0.5	1	1	0
12/29/2021 14:00	0.1	13.8	1,661.2	0.2	0.5	1	1	1
12/29/2021 15:00	-0.7	13.0	1,998.2	-0.4	0.6	1	1	1
12/29/2021 16:00	-0.4	12.7	2,064.6	-0.1	0.6	1	1	1
12/29/2021 17:00	-0.1	12.1	2,226.0	0.2	0.7	1	1	1
12/29/2021 18:00	-0.1	12.1	2,216.8	0.2	0.7	1	1	1
12/29/2021 19:00	-0.1	12.1	2,230.3	0.2	0.7	1	1	1
12/29/2021 20:00	-0.1	12.1	2,230.6	0.2	0.7	1	1	1
12/29/2021 21:00	-0.4	12.6	2,089.9	-0.1	0.6	1	1	1
12/29/2021 22:00	-1.1	13.1	1,965.3	-0.7	0.6	1	1	1
12/29/2021 23:00	-0.7	13.1	1,989.3	-0.4	0.6	1	1	1
Average/Sum#:	-0.4	13.2	1,884.8	-0.1	0.6	24 #	24 #	20 #
Minimum:	-1.5	12.1	1,410.8	-1.1	0.4	1	1	0
Maximum:	0.4	13.9	2,230.6	0.4	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/30/2021 00:00	-1.1	13.3	1,907.5	-0.7	0.6	1	1	1
12/30/2021 01:00	0.4	13.9	1,628.9	0.4	0.5	1	1	0
12/30/2021 02:00	0.3	13.9	1,355.2	0.4	0.4	1	1	0
12/30/2021 03:00	0.3	13.8	1,725.5	0.4	0.5	1	1	0
12/30/2021 04:00	-0.7	13.5	1,841.8	-0.4	0.6	1	1	1
12/30/2021 05:00	-0.8	13.4	1,818.0	-0.5	0.5	1	1	1
12/30/2021 06:00	0.1	13.8	1,684.9	0.2	0.5	1	1	1
12/30/2021 07:00	-0.5	13.1	2,017.1	-0.2	0.6	1	1	1
12/30/2021 08:00	-0.1	12.7	2,112.7	0.1	0.6	1	1	1
12/30/2021 09:00	-0.2	13.0	2,007.3	0.1	0.6	1	1	1
12/30/2021 10:00	0.4	13.9	1,616.8	0.4	0.5	1	1	0
12/30/2021 11:00	0.1	13.8	1,653.3	0.2	0.5	1	1	1
12/30/2021 12:00	-0.4	13.1	1,985.9	-0.1	0.6	1	1	1
12/30/2021 13:00	-0.4	13.3	1,894.5	-0.1	0.6	1	1	1
12/30/2021 14:00	0.4	13.9	1,652.0	0.4	0.5	1	1	0
12/30/2021 15:00	0.1	13.9	1,599.6	0.2	0.5	1	1	1
12/30/2021 16:00	-1.1	13.1	1,974.2	-0.7	0.6	1	1	1
12/30/2021 17:00	-0.2	12.5	2,097.6	0.1	0.6	1	1	1
12/30/2021 18:00	-0.2	12.6	2,072.8	0.1	0.6	1	1	1
12/30/2021 19:00	-0.7	13.0	1,981.7	-0.4	0.6	1	1	1
12/30/2021 20:00	-0.2	12.7	2,074.9	0.1	0.6	1	1	1
12/30/2021 21:00	-0.2	12.6	2,073.2	0.1	0.6	1	1	1
12/30/2021 22:00	-0.4	12.8	2,044.2	-0.1	0.6	1	1	1
12/30/2021 23:00	-0.4	13.0	2,004.7	-0.1	0.6	1	1	1
Average/Sum#:	-0.2	13.3	1,867.7	0.0	0.6	24 #	24 #	19 #
Minimum:	-1.1	12.5	1,355.2	-0.7	0.4	1	1	0
Maximum:	0.4	13.9	2,112.7	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - VOC

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 08:09 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/31/2021 00:00	-0.7	13.3	1,912.7	-0.4	0.6	1	1	1
12/31/2021 01:00	0.4	13.9	1,519.2	0.4	0.5	1	1	0
12/31/2021 02:00	0.3	13.9	1,323.4	0.4	0.4	1	1	0
12/31/2021 03:00	0.3	13.8	1,721.3	0.4	0.5	1	1	0
12/31/2021 04:00	-0.7	13.5	1,842.0	-0.4	0.6	1	1	1
12/31/2021 05:00	-0.7	13.4	1,820.7	-0.4	0.5	1	1	1
12/31/2021 06:00	0.1	13.9	1,417.0	0.2	0.4	1	1	1
12/31/2021 07:00	-0.5	13.0	1,997.5	-0.2	0.6	1	1	1
12/31/2021 08:00	-0.4	13.0	2,006.8	-0.1	0.6	1	1	1
12/31/2021 09:00	-0.7	13.3	1,914.6	-0.4	0.6	1	1	1
12/31/2021 10:00	0.4	13.9	1,489.1	0.4	0.4	1	1	0
12/31/2021 11:00	0.4	13.9	1,450.8	0.4	0.4	1	1	0
12/31/2021 12:00	0.4	13.9	1,574.4	0.4	0.5	1	1	0
12/31/2021 13:00	0.4	14.0	1,300.1	0.4	0.4	1	1	0
12/31/2021 14:00	0.4	14.0	1,438.8	0.4	0.4	1	1	0
12/31/2021 15:00	-0.1	13.8	1,623.4	0.1	0.5	1	1	1
12/31/2021 16:00	-0.4	12.8	2,021.3	-0.1	0.6	1	1	1
12/31/2021 17:00	-0.2	12.5	2,095.7	0.1	0.6	1	1	1
12/31/2021 18:00	-0.2	12.5	2,097.3	0.1	0.6	1	1	1
12/31/2021 19:00	-0.1	12.4	2,119.3	0.2	0.6	1	1	1
12/31/2021 20:00	-0.2	12.7	2,031.2	0.1	0.6	1	1	1
12/31/2021 21:00	0.4	13.9	1,566.2	0.4	0.5	1	1	0
12/31/2021 22:00	0.4	13.8	1,754.3	0.4	0.5	1	1	0
12/31/2021 23:00	-0.2	13.3	1,937.0	-0.1	0.6	1	1	1
Average/Sum#:	-0.1	13.4	1,748.9	0.1	0.5	24 #	24 #	14 #
Minimum:	-0.7	12.4	1,300.1	-0.4	0.4	1	1	0
Maximum:	0.4	14.0	2,119.3	0.4	0.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Excess Emission Report

CT1 - VOC Lb 1-Day Block Average

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 08:11 **Location:** Maxwell, CA

Tag Name: CT1_VOC_Lb_1D
Total Operating Time: 74.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 18.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**74.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - VOC LbPerHr 1-Hour Block Average

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 08:46 **Location:** Maxwell, CA

Tag Name: CT1_VOC_LbPerHr_1H
Total Operating Time: 1,594.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 614.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,594.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - VOC Ppmvdc 1-Hour Block Average

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 08:47 **Location:** Maxwell, CA

Tag Name: CT1_VOC_Ppmvdc_1H
Total Operating Time: 1,594.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 614.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,594.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 -VOC Lb 1-Day Block Average

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 08:48 **Location:** Maxwell, CA

Tag Name: CT2_VOC_Lb_1D
Total Operating Time: 75.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 17.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**75.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - VOC LbPerHr 1-Hour Block Average

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 09:09 **Location:** Maxwell, CA

Tag Name: CT2_VOC_LbPerHr_1H
Total Operating Time: 1,466.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 742.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,466.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - VOC Ppmvdc 1-Hour Block Average

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 09:10 **Location:** Maxwell, CA

Tag Name: CT2_VOC_Ppmvdc_1H
Total Operating Time: 1,466.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 742.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,466.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 6
Hourly Emissions – NOx

FCD: AQ-15
Title V: #6

Excess Emission Report

CT1 - NOx Lb 1-Day Block Average

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 09:11 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Lb_1D
Total Operating Time: 1,647.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 561.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,647.00 Hour(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NOx Lb 1-Day Block Average

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 09:11 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Lb_1D
Total Operating Time: 1,549.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 659.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,549.00 Hour(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/01/2021 00:00	0.9	14.0	1,526.8	0.8	4.60	1	1	0
10/01/2021 01:00	0.6	14.0	1,537.0	0.5	3.10	1	1	0
10/01/2021 02:00	0.5	14.0	1,534.3	0.4	3.10	1	1	0
10/01/2021 03:00	0.5	14.0	1,535.7	0.4	3.10	1	1	0
10/01/2021 04:00	0.6	14.0	1,526.8	0.5	3.10	1	1	1
10/01/2021 05:00	1.0	12.8	2,010.3	0.7	6.00	1	1	1
10/01/2021 06:00	1.0	13.1	1,721.5	0.8	5.20	1	1	1
10/01/2021 07:00	0.7	14.0	1,438.0	0.6	2.90	1	1	0
10/01/2021 08:00	0.9	14.0	1,354.6	0.8	4.10	1	1	0
10/01/2021 09:00	0.9	14.0	1,355.6	0.8	4.10	1	1	0
10/01/2021 10:00	0.8	14.1	1,360.0	0.7	4.10	1	1	0
10/01/2021 11:00	0.8	14.1	1,365.7	0.7	4.10	1	1	0
10/01/2021 12:00	0.7	14.1	1,380.7	0.6	2.80	1	1	0
10/01/2021 13:00	0.9	13.9	1,726.7	0.8	5.20	1	1	0
10/01/2021 14:00	0.8	13.9	1,546.2	0.7	3.10	1	1	0
10/01/2021 15:00	0.8	13.9	1,720.8	0.7	3.40	1	1	0
10/01/2021 16:00	0.8	13.9	1,704.1	0.7	3.40	1	1	0
10/01/2021 17:00	0.8	13.7	1,786.8	0.7	3.60	1	1	0
10/01/2021 18:00	0.8	13.7	1,778.8	0.7	3.60	1	1	0
10/01/2021 19:00	0.9	13.9	1,702.4	0.8	5.10	1	1	0
10/01/2021 20:00	0.8	13.9	1,684.2	0.7	3.40	1	1	0
10/01/2021 21:00	0.9	13.9	1,663.3	0.8	5.00	1	1	0
10/01/2021 22:00	0.6	14.0	1,677.1	0.5	3.40	1	1	0
10/01/2021 23:00	0.4	14.0	1,683.2	0.3	1.70	1	1	0
Average/Sum#:	0.8	13.9	1,596.7	0.7	91.20 #	24 #	24 #	3 #
Minimum:	0.4	12.8	1,354.6	0.3	1.70	1	1	0
Maximum:	1.0	14.1	2,010.3	0.8	6.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/02/2021 00:00	0.4	14.0	1,688.8	0.3	1.70	1	1	0
10/02/2021 01:00	0.4	14.0	1,676.6	0.3	1.70	1	1	0
10/02/2021 02:00	0.5	14.0	1,537.6	0.4	3.10	1	1	0
10/02/2021 03:00	0.4	14.0	1,662.8	0.3	1.70	1	1	0
10/02/2021 04:00	0.4	14.0	1,678.6	0.3	1.70	1	1	0
10/02/2021 05:00	0.4	14.0	1,670.9	0.3	1.70	1	1	0
10/02/2021 06:00	0.4	14.0	1,637.2	0.3	1.60	1	1	0
10/02/2021 07:00	0.5	14.0	1,460.7	0.4	2.90	1	1	0
10/02/2021 08:00	0.7	14.0	1,347.5	0.6	2.70	1	1	0
10/02/2021 09:00	0.8	14.1	1,312.8	0.7	3.90	1	1	0
10/02/2021 10:00	0.7	14.1	1,288.4	0.6	2.60	1	1	0
10/02/2021 11:00	0.7	14.1	1,287.0	0.6	2.60	1	1	0
10/02/2021 12:00	0.6	14.1	1,301.1	0.5	2.60	1	1	0
10/02/2021 13:00	0.5	14.1	1,371.0	0.4	2.70	1	1	0
10/02/2021 14:00	0.7	13.9	1,658.4	0.6	3.30	1	1	0
10/02/2021 15:00	0.7	13.9	1,702.1	0.6	3.40	1	1	0
10/02/2021 16:00	0.8	13.9	1,624.5	0.7	3.20	1	1	0
10/02/2021 17:00	0.9	13.7	1,754.0	0.7	5.30	1	1	0
10/02/2021 18:00	0.8	13.7	1,777.0	0.7	3.60	1	1	0
10/02/2021 19:00	0.8	13.9	1,699.2	0.7	3.40	1	1	0
10/02/2021 20:00	0.8	13.9	1,672.1	0.7	3.30	1	1	0
10/02/2021 21:00	0.9	13.9	1,690.3	0.8	5.10	1	1	0
10/02/2021 22:00	0.9	13.9	1,691.0	0.8	5.10	1	1	0
10/02/2021 23:00	0.7	13.9	1,683.8	0.6	3.40	1	1	0
Average/Sum#:	0.6	14.0	1,578.1	0.5	72.30 #	24 #	24 #	0 #
Minimum:	0.4	13.7	1,287.0	0.3	1.60	1	1	0
Maximum:	0.9	14.1	1,777.0	0.8	5.30	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/03/2021 00:00	0.6	14.0	1,629.9	0.5	3.30	1	1	0
10/03/2021 01:00	0.6	14.0	1,574.6	0.5	3.10	1	1	0
10/03/2021 02:00	0.7	14.0	1,453.7	0.6	2.90	1	1	0
10/03/2021 03:00	0.7	14.0	1,416.3	0.6	2.80	1	1	0
10/03/2021 04:00	0.7	14.0	1,468.2	0.6	2.90	1	1	0
10/03/2021 05:00	0.6	14.0	1,454.1	0.5	2.90	1	1	0
10/03/2021 06:00	0.5	14.0	1,458.1	0.4	2.90	1	1	0
10/03/2021 07:00	0.7	14.1	1,291.6	0.6	2.60	1	1	0
10/03/2021 08:00	0.8	14.0	1,354.3	0.7	4.10	1	1	0
10/03/2021 09:00	0.7	14.1	1,292.2	0.6	2.60	1	1	0
10/03/2021 10:00	0.7	14.1	1,286.3	0.6	2.60	1	1	0
10/03/2021 11:00	0.7	14.1	1,346.5	0.6	2.70	1	1	0
10/03/2021 12:00	0.7	14.1	1,415.3	0.6	2.80	1	1	0
10/03/2021 13:00	0.7	13.9	1,612.2	0.6	3.20	1	1	0
10/03/2021 14:00	0.7	13.9	1,683.0	0.6	3.40	1	1	0
10/03/2021 15:00	0.7	13.9	1,689.1	0.6	3.40	1	1	0
10/03/2021 16:00	0.8	13.9	1,605.8	0.7	3.20	1	1	0
10/03/2021 17:00	0.7	14.0	1,424.8	0.6	2.80	1	1	0
10/03/2021 18:00	0.8	13.8	1,743.3	0.7	3.50	1	1	0
10/03/2021 19:00	0.8	13.9	1,640.0	0.7	3.30	1	1	0
10/03/2021 20:00	0.7	13.9	1,680.5	0.6	3.40	1	1	0
10/03/2021 21:00	0.8	13.9	1,628.0	0.7	3.30	1	1	0
10/03/2021 22:00	0.8	13.9	1,669.1	0.7	3.30	1	1	0
10/03/2021 23:00	0.8	13.9	1,686.4	0.7	3.40	1	1	0
Average/Sum#:	0.7	14.0	1,521.0	0.6	74.40 #	24 #	24 #	0 #
Minimum:	0.5	13.8	1,286.3	0.4	2.60	1	1	0
Maximum:	0.8	14.1	1,743.3	0.7	4.10	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/04/2021 00:00	0.8	13.9	1,666.2	0.7	3.30	1	1	0
10/04/2021 01:00	0.8	13.9	1,539.0	0.7	3.10	1	1	0
10/04/2021 02:00	0.8	13.9	1,551.2	0.7	3.10	1	1	0
10/04/2021 03:00	0.9	13.9	1,618.2	0.8	4.90	1	1	0
10/04/2021 04:00	0.8	13.9	1,667.7	0.7	3.30	1	1	0
10/04/2021 05:00	0.9	13.9	1,683.0	0.8	5.00	1	1	0
10/04/2021 06:00	0.8	13.9	1,637.9	0.7	3.30	1	1	0
10/04/2021 07:00	0.6	14.0	1,601.9	0.5	3.20	1	1	0
10/04/2021 08:00	0.7	13.9	1,614.7	0.6	3.20	1	1	0
10/04/2021 09:00	0.6	14.0	1,594.3	0.5	3.20	1	1	0
10/04/2021 10:00	0.7	13.9	1,547.3	0.6	3.10	1	1	0
10/04/2021 11:00	0.7	13.9	1,635.6	0.6	3.30	1	1	0
10/04/2021 12:00	0.7	13.9	1,658.7	0.6	3.30	1	1	0
10/04/2021 13:00	0.6	13.9	1,614.0	0.5	3.20	1	1	0
10/04/2021 14:00	0.6	13.9	1,691.2	0.5	3.40	1	1	0
10/04/2021 15:00	0.7	13.9	1,630.2	0.6	3.30	1	1	0
10/04/2021 16:00	0.7	13.8	1,757.8	0.6	3.50	1	1	0
10/04/2021 17:00	0.7	13.7	1,776.3	0.6	3.60	1	1	0
10/04/2021 18:00	0.7	13.7	1,772.6	0.6	3.50	1	1	0
10/04/2021 19:00	0.7	13.8	1,750.7	0.6	3.50	1	1	0
10/04/2021 20:00	0.7	13.7	1,750.3	0.6	3.50	1	1	0
10/04/2021 21:00	0.7	13.8	1,747.7	0.6	3.50	1	1	0
10/04/2021 22:00	0.7	13.9	1,586.4	0.6	3.20	1	1	0
10/04/2021 23:00	0.5	14.0	1,597.6	0.4	3.20	1	1	0
Average/Sum#:	0.7	13.9	1,653.8	0.6	82.70 #	24 #	24 #	0 #
Minimum:	0.5	13.7	1,539.0	0.4	3.10	1	1	0
Maximum:	0.9	14.0	1,776.3	0.8	5.00	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/05/2021 00:00	0.5	14.0	1,554.4	0.4	3.10	1	1	0
10/05/2021 01:00	0.6	14.0	1,538.6	0.5	3.10	1	1	0
10/05/2021 02:00	0.6	14.0	1,524.7	0.5	3.00	1	1	0
10/05/2021 03:00	0.5	13.9	1,617.1	0.4	3.20	1	1	0
10/05/2021 04:00	0.6	13.9	1,577.3	0.5	3.20	1	1	0
10/05/2021 05:00	0.7	13.8	1,673.6	0.6	3.30	1	1	0
10/05/2021 06:00	0.8	13.9	1,680.8	0.7	3.40	1	1	0
10/05/2021 07:00	0.8	13.9	1,633.4	0.7	3.30	1	1	0
10/05/2021 08:00	0.8	13.9	1,599.9	0.7	3.20	1	1	0
10/05/2021 09:00	0.8	13.9	1,643.1	0.7	3.30	1	1	0
10/05/2021 10:00	0.6	13.9	1,661.0	0.5	3.30	1	1	0
10/05/2021 11:00	0.5	14.0	1,641.0	0.4	3.30	1	1	0
10/05/2021 12:00	0.7	13.9	1,711.2	0.6	3.40	1	1	0
10/05/2021 13:00	0.7	13.9	1,661.7	0.6	3.30	1	1	0
10/05/2021 14:00	0.7	13.9	1,640.2	0.6	3.30	1	1	0
10/05/2021 15:00	0.6	13.9	1,684.1	0.5	3.40	1	1	0
10/05/2021 16:00	0.7	13.9	1,673.1	0.6	3.30	1	1	0
10/05/2021 17:00	0.7	13.9	1,632.6	0.6	3.30	1	1	0
10/05/2021 18:00	0.8	13.9	1,626.2	0.7	3.30	1	1	0
10/05/2021 19:00	0.7	13.9	1,681.5	0.6	3.40	1	1	0
10/05/2021 20:00	0.8	13.9	1,590.7	0.7	3.20	1	1	0
10/05/2021 21:00	0.6	14.0	1,507.9	0.5	3.00	1	1	0
10/05/2021 22:00	0.5	14.0	1,636.5	0.4	3.30	1	1	0
10/05/2021 23:00	0.6	14.0	1,410.5	0.5	2.80	1	1	0
Average/Sum#:	0.7	13.9	1,616.7	0.6	77.70 #	24 #	24 #	0 #
Minimum:	0.5	13.8	1,410.5	0.4	2.80	1	1	0
Maximum:	0.8	14.0	1,711.2	0.7	3.40	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/06/2021 00:00	0.7	14.0	1,295.0	0.6	2.60	1	1	0
10/06/2021 01:00	0.8	14.0	1,294.9	0.7	3.90	1	1	0
10/06/2021 02:00	0.8	14.0	1,295.2	0.7	3.90	1	1	0
10/06/2021 03:00	0.8	14.0	1,295.5	0.7	3.90	1	1	0
10/06/2021 04:00	0.8	14.0	1,319.0	0.7	4.00	1	1	0
10/06/2021 05:00	0.9	13.9	1,528.7	0.8	4.60	1	1	0
10/06/2021 06:00	0.8	13.9	1,599.7	0.7	3.20	1	1	0
10/06/2021 07:00	0.7	13.9	1,563.6	0.6	3.10	1	1	0
10/06/2021 08:00	0.8	13.9	1,404.1	0.7	2.80	1	1	0
10/06/2021 09:00	0.8	13.9	1,585.6	0.7	3.20	1	1	0
10/06/2021 10:00	0.8	13.9	1,567.8	0.7	3.10	1	1	0
10/06/2021 11:00	0.7	13.9	1,507.1	0.6	3.00	1	1	0
10/06/2021 12:00	0.7	13.9	1,609.5	0.6	3.20	1	1	0
10/06/2021 13:00	0.5	13.9	1,636.5	0.4	3.30	1	1	0
10/06/2021 14:00	0.5	13.9	1,682.2	0.4	3.40	1	1	0
10/06/2021 15:00	0.8	13.9	1,668.2	0.7	3.30	1	1	0
10/06/2021 16:00	0.8	13.9	1,641.6	0.7	3.30	1	1	0
10/06/2021 17:00	0.7	13.9	1,392.9	0.6	2.80	1	1	0
10/06/2021 18:00	0.9	13.9	1,595.2	0.8	4.80	1	1	0
10/06/2021 19:00	0.9	13.9	1,626.1	0.8	4.90	1	1	0
10/06/2021 20:00	0.8	13.8	1,720.9	0.7	3.40	1	1	0
10/06/2021 21:00	0.8	13.9	1,641.9	0.7	3.30	1	1	0
10/06/2021 22:00	0.8	13.9	1,586.7	0.7	3.20	1	1	0
10/06/2021 23:00	0.8	13.9	1,685.2	0.7	3.40	1	1	0
Average/Sum#:	0.8	13.9	1,531.0	0.7	83.60 #	24 #	24 #	0 #
Minimum:	0.5	13.8	1,294.9	0.4	2.60	1	1	0
Maximum:	0.9	14.0	1,720.9	0.8	4.90	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/07/2021 00:00	0.7	13.9	1,550.3	0.6	3.10	1	1	0
10/07/2021 01:00	0.6	13.9	1,548.9	0.5	3.10	1	1	0
10/07/2021 02:00	0.6	13.9	1,546.0	0.5	3.10	1	1	0
10/07/2021 03:00	0.7	14.0	1,459.9	0.6	2.90	1	1	0
10/07/2021 04:00	0.8	13.9	1,657.6	0.7	3.30	1	1	0
10/07/2021 05:00	0.8	13.9	1,640.7	0.7	3.30	1	1	0
10/07/2021 06:00	0.8	13.9	1,688.4	0.7	3.40	1	1	0
10/07/2021 07:00	0.7	13.9	1,630.0	0.6	3.30	1	1	0
10/07/2021 08:00	0.8	13.9	1,616.8	0.7	3.20	1	1	0
10/07/2021 09:00	0.8	13.9	1,542.5	0.7	3.10	1	1	0
10/07/2021 10:00	0.7	13.9	1,528.4	0.6	3.10	1	1	0
10/07/2021 11:00	0.8	14.0	1,544.1	0.7	4.60	1	1	0
10/07/2021 12:00	0.7	14.0	1,547.9	0.6	3.10	1	1	0
10/07/2021 13:00	0.7	14.0	1,546.4	0.6	3.10	1	1	0
10/07/2021 14:00	0.8	13.9	1,685.3	0.7	3.40	1	1	0
10/07/2021 15:00	0.9	13.9	1,670.6	0.8	5.00	1	1	0
10/07/2021 16:00	0.9	13.9	1,703.6	0.8	5.10	1	1	0
10/07/2021 17:00	0.8	13.7	1,813.3	0.7	3.60	1	1	0
10/07/2021 18:00	0.8	13.8	1,761.9	0.7	3.50	1	1	0
10/07/2021 19:00	0.8	13.9	1,655.6	0.7	3.30	1	1	0
10/07/2021 20:00	0.8	13.8	1,627.5	0.7	3.30	1	1	0
10/07/2021 21:00	0.8	13.9	1,664.9	0.7	3.30	1	1	0
10/07/2021 22:00	0.8	13.9	1,675.8	0.7	3.40	1	1	0
10/07/2021 23:00	0.8	13.9	1,594.0	0.7	3.20	1	1	0
Average/Sum#:	0.8	13.9	1,620.9	0.7	82.80 #	24 #	24 #	0 #
Minimum:	0.6	13.7	1,459.9	0.5	2.90	1	1	0
Maximum:	0.9	14.0	1,813.3	0.8	5.10	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/08/2021 00:00	0.7	13.9	1,512.8	0.6	3.00	1	1	0
10/08/2021 01:00	0.8	13.9	1,500.4	0.7	3.00	1	1	0
10/08/2021 02:00	0.8	13.9	1,531.9	0.7	3.10	1	1	0
10/08/2021 03:00	0.8	13.9	1,587.0	0.7	3.20	1	1	0
10/08/2021 04:00	0.8	13.9	1,665.2	0.7	3.30	1	1	0
10/08/2021 05:00	0.9	13.9	1,558.2	0.8	4.70	1	1	0
10/08/2021 06:00	0.8	13.9	1,657.0	0.7	3.30	1	1	0
10/08/2021 07:00	0.8	13.9	1,539.1	0.7	3.10	1	1	0
10/08/2021 08:00	0.9	13.9	1,546.9	0.8	4.60	1	1	0
10/08/2021 09:00	0.8	14.0	1,394.2	0.7	4.20	1	1	0
10/08/2021 10:00	0.8	13.9	1,653.2	0.7	3.30	1	1	0
10/08/2021 11:00	0.8	14.0	1,465.4	0.7	4.40	1	1	0
10/08/2021 12:00	0.7	13.9	1,605.4	0.6	3.20	1	1	0
10/08/2021 13:00	0.6	14.0	1,572.0	0.5	3.10	1	1	0
10/08/2021 14:00	0.6	14.0	1,538.5	0.5	3.10	1	1	0
10/08/2021 15:00	0.6	14.0	1,620.8	0.5	3.20	1	1	0
10/08/2021 16:00	0.5	14.0	1,681.0	0.4	3.40	1	1	0
10/08/2021 17:00	0.6	14.0	1,604.7	0.5	3.20	1	1	0
10/08/2021 18:00	0.6	14.0	1,620.8	0.5	3.20	1	1	0
10/08/2021 19:00	0.6	13.9	1,645.3	0.5	3.30	1	1	0
10/08/2021 20:00	0.6	14.0	1,376.5	0.5	2.80	1	1	0
10/08/2021 21:00	9.5	16.7	321.4	13.3	2.67	1	0	0
10/08/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.1	14.1	1,509.0	1.2	74.37 #	22 #	21 #	0 #
Minimum:	0.5	13.9	321.4	0.4	2.67	0	0	0
Maximum:	9.5	16.7	1,681.0	13.3	4.70	1	1	0
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/09/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/10/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/11/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/12/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/13/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/14/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/15/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/16/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/17/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/18/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/19/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/20/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/20/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/20/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/20/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/20/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/20/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/20/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/20/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/20/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/20/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/20/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/20/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/20/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/20/2021 13:00	24.9	17.9	288.6	49.0	30.10	1	0	0
10/20/2021 14:00	22.4	16.3	621.0	28.7	65.80	1	0	0
10/20/2021 15:00	2.4	13.8	1,514.3	2.0	10.60	1	0	1
10/20/2021 16:00	0.9	12.7	1,858.7	0.6	3.70	1	1	1
10/20/2021 17:00	0.9	13.8	1,682.9	0.7	5.00	1	1	1
10/20/2021 18:00	1.1	12.9	1,994.9	0.8	6.00	1	1	1
10/20/2021 19:00	1.3	12.8	2,042.0	0.9	6.10	1	1	1
10/20/2021 20:00	1.3	12.1	2,183.3	0.9	6.50	1	1	1
10/20/2021 21:00	1.3	12.3	2,115.5	0.9	6.30	1	1	1
10/20/2021 22:00	5.4	15.6	654.4	6.0	3.31	1	0	0
10/20/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	6.2	14.0	1,495.6	9.1	143.41 #	10 #	6 #	7 #
Minimum:	0.9	12.1	288.6	0.6	3.31	0	0	0
Maximum:	24.9	17.9	2,183.3	49.0	65.80	1	1	1
%SI	58.33	58.33	58.33	58.33	58.33	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/21/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/22/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/23/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2021 01:00	30.2	17.8	320.9	57.5	42.84	1	0	0
10/23/2021 02:00	15.5	17.3	379.9	25.4	35.70	1	0	0
10/23/2021 03:00	7.6	16.0	739.1	9.2	25.10	1	0	0
10/23/2021 04:00	0.4	13.9	1,516.5	0.3	1.50	1	1	0
10/23/2021 05:00	0.8	13.9	1,576.3	0.7	3.20	1	1	0
10/23/2021 06:00	0.7	13.9	1,761.6	0.6	3.50	1	1	0
10/23/2021 07:00	0.7	13.9	1,496.0	0.6	3.00	1	1	0
10/23/2021 08:00	0.8	13.9	1,644.8	0.7	3.30	1	1	0
10/23/2021 09:00	0.8	13.9	1,399.8	0.7	2.80	1	1	0
10/23/2021 10:00	0.9	13.9	1,599.4	0.8	4.80	1	1	0
10/23/2021 11:00	0.8	13.9	1,570.7	0.7	3.10	1	1	0
10/23/2021 12:00	0.8	13.9	1,616.5	0.7	3.20	1	1	0
10/23/2021 13:00	0.8	13.9	1,579.5	0.7	3.20	1	1	0
10/23/2021 14:00	0.8	13.9	1,663.6	0.7	3.30	1	1	0
10/23/2021 15:00	0.8	13.9	1,638.0	0.7	3.30	1	1	0
10/23/2021 16:00	0.8	13.8	1,667.4	0.7	3.30	1	1	0
10/23/2021 17:00	1.0	13.0	1,955.9	0.7	5.90	1	1	1
10/23/2021 18:00	1.3	12.6	2,055.0	0.9	6.20	1	1	1
10/23/2021 19:00	0.8	13.8	1,653.2	0.7	3.30	1	1	1
10/23/2021 20:00	0.7	13.8	1,676.0	0.6	3.40	1	1	1
10/23/2021 21:00	1.1	12.7	2,033.9	0.8	6.10	1	1	1
10/23/2021 22:00	2.2	13.8	1,476.4	1.8	7.52	1	0	1
10/23/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	3.2	14.2	1,500.9	4.8	177.56 #	22 #	18 #	6 #
Minimum:	0.4	12.6	320.9	0.3	1.50	0	0	0
Maximum:	30.2	17.8	2,055.0	57.5	42.84	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/24/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2021 07:00	12.7	17.7	337.7	23.4	21.17	1	0	0
10/24/2021 08:00	5.1	15.1	1,060.4	5.2	20.10	1	0	0
10/24/2021 09:00	0.5	13.9	1,571.7	0.4	3.10	1	1	0
10/24/2021 10:00	0.8	13.9	1,581.6	0.7	3.20	1	1	0
10/24/2021 11:00	0.8	13.9	1,562.2	0.7	3.10	1	1	0
10/24/2021 12:00	0.7	13.9	1,618.0	0.6	3.20	1	1	0
10/24/2021 13:00	0.8	13.9	1,511.9	0.7	3.00	1	1	0
10/24/2021 14:00	0.8	13.9	1,629.5	0.7	3.30	1	1	0
10/24/2021 15:00	0.8	13.9	1,654.3	0.7	3.30	1	1	0
10/24/2021 16:00	0.8	13.7	1,765.5	0.7	3.50	1	1	0
10/24/2021 17:00	1.1	12.7	2,020.0	0.8	6.10	1	1	1
10/24/2021 18:00	1.3	12.4	2,049.3	0.9	6.10	1	1	1
10/24/2021 19:00	0.8	13.9	1,694.2	0.7	3.40	1	1	0
10/24/2021 20:00	0.8	13.9	1,731.8	0.7	3.50	1	1	1
10/24/2021 21:00	1.0	12.7	2,033.3	0.7	6.10	1	1	1
10/24/2021 22:00	0.9	13.3	1,685.5	0.7	5.10	1	1	1
10/24/2021 23:00	0.8	14.0	1,412.7	0.7	4.20	1	1	0
Average/Sum#:	1.8	13.9	1,583.5	2.3	101.47 #	17 #	15 #	5 #
Minimum:	0.5	12.4	337.7	0.4	3.00	0	0	0
Maximum:	12.7	17.7	2,049.3	23.4	21.17	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/25/2021 00:00	0.8	13.9	1,548.6	0.7	3.10	1	1	0
10/25/2021 01:00	0.8	13.9	1,538.7	0.7	3.10	1	1	0
10/25/2021 02:00	0.8	13.9	1,492.1	0.7	3.00	1	1	0
10/25/2021 03:00	0.8	13.9	1,549.7	0.7	3.10	1	1	0
10/25/2021 04:00	0.8	13.9	1,567.8	0.7	3.10	1	1	0
10/25/2021 05:00	0.7	13.8	1,783.7	0.6	3.60	1	1	0
10/25/2021 06:00	0.7	13.9	1,634.7	0.6	3.30	1	1	0
10/25/2021 07:00	0.6	13.7	1,804.1	0.5	3.60	1	1	0
10/25/2021 08:00	0.5	13.9	1,686.3	0.4	3.40	1	1	0
10/25/2021 09:00	0.7	13.8	1,789.5	0.6	3.60	1	1	1
10/25/2021 10:00	0.9	13.0	1,970.9	0.7	3.90	1	1	1
10/25/2021 11:00	1.1	12.8	2,051.1	0.8	6.20	1	1	1
10/25/2021 12:00	1.2	13.0	1,973.2	0.9	5.90	1	1	1
10/25/2021 13:00	0.9	13.9	1,642.6	0.8	4.90	1	1	0
10/25/2021 14:00	0.6	14.0	1,553.7	0.5	3.10	1	1	0
10/25/2021 15:00	0.7	13.9	1,574.6	0.6	3.10	1	1	1
10/25/2021 16:00	1.1	12.6	2,095.0	0.8	6.30	1	1	1
10/25/2021 17:00	1.2	12.5	2,120.4	0.8	6.40	1	1	1
10/25/2021 18:00	1.1	12.7	2,064.1	0.8	6.20	1	1	1
10/25/2021 19:00	0.6	13.8	1,650.6	0.5	3.30	1	1	1
10/25/2021 20:00	0.6	14.0	1,495.4	0.5	3.00	1	1	0
10/25/2021 21:00	0.9	13.1	1,968.7	0.7	5.90	1	1	1
10/25/2021 22:00	0.8	13.5	1,701.8	0.6	3.40	1	1	1
10/25/2021 23:00	0.8	14.0	1,362.6	0.7	4.10	1	1	0
Average/Sum#:	0.8	13.6	1,734.2	0.7	98.60 #	24 #	24 #	11 #
Minimum:	0.5	12.5	1,362.6	0.4	3.00	1	1	0
Maximum:	1.2	14.0	2,120.4	0.9	6.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/26/2021 00:00	0.9	14.0	1,363.5	0.8	4.10	1	1	0
10/26/2021 01:00	0.9	14.0	1,366.4	0.8	4.10	1	1	0
10/26/2021 02:00	0.9	14.0	1,371.6	0.8	4.10	1	1	0
10/26/2021 03:00	0.9	14.0	1,373.2	0.8	4.10	1	1	0
10/26/2021 04:00	0.8	13.9	1,530.4	0.7	3.10	1	1	0
10/26/2021 05:00	0.7	13.8	1,807.4	0.6	3.60	1	1	0
10/26/2021 06:00	0.7	13.9	1,490.9	0.6	3.00	1	1	0
10/26/2021 07:00	0.7	13.9	1,614.3	0.6	3.20	1	1	0
10/26/2021 08:00	0.0	0.0	1,607.2	0.0	0.00	1	1	0
10/26/2021 09:00	0.0	0.0	1,595.2	0.0	0.00	1	1	1
10/26/2021 10:00	1.3	12.6	2,046.5	0.9	6.10	1	1	1
10/26/2021 11:00	1.2	13.0	1,954.9	0.9	5.90	1	1	1
10/26/2021 12:00	1.1	13.8	1,687.7	0.9	5.10	1	1	0
10/26/2021 13:00	1.1	13.9	1,478.8	0.9	4.40	1	1	0
10/26/2021 14:00	1.1	13.9	1,450.7	0.9	4.40	1	1	0
10/26/2021 15:00	1.1	13.8	1,575.7	0.9	4.70	1	1	1
10/26/2021 16:00	1.3	12.7	2,042.2	0.9	6.10	1	1	1
10/26/2021 17:00	1.3	12.4	2,119.7	0.9	6.40	1	1	1
10/26/2021 18:00	1.3	12.6	2,091.1	0.9	6.30	1	1	1
10/26/2021 19:00	1.3	12.6	2,047.6	0.9	6.10	1	1	1
10/26/2021 20:00	1.1	13.8	1,584.6	0.9	4.80	1	1	0
10/26/2021 21:00	1.1	13.8	1,790.8	0.9	5.40	1	1	1
10/26/2021 22:00	1.3	12.7	2,071.7	0.9	6.20	1	1	1
10/26/2021 23:00	1.3	12.8	2,016.8	0.9	6.10	1	1	1
Average/Sum#:	1.1	13.5	1,711.6	0.8	107.30 #	24 #	24 #	11 #
Minimum:	0.7	12.4	1,363.5	0.6	3.00	1	1	0
Maximum:	1.3	14.0	2,119.7	0.9	6.40	1	1	1
%SI	8.33	8.33	0.00	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/27/2021 00:00	1.1	13.8	1,563.7	0.9	4.70	1	1	0
10/27/2021 01:00	1.1	13.8	1,592.2	0.9	4.80	1	1	1
10/27/2021 02:00	1.2	13.1	1,964.8	0.9	5.90	1	1	1
10/27/2021 03:00	1.2	13.2	1,935.8	0.9	5.80	1	1	1
10/27/2021 04:00	1.1	13.8	1,602.1	0.9	4.80	1	1	0
10/27/2021 05:00	1.0	13.8	1,616.8	0.8	4.90	1	1	1
10/27/2021 06:00	1.3	13.0	2,018.4	1.0	8.10	1	1	1
10/27/2021 07:00	1.5	12.7	2,066.7	1.1	8.30	1	1	1
10/27/2021 08:00	1.4	13.2	1,951.2	1.1	7.80	1	1	1
10/27/2021 09:00	1.3	13.9	1,494.3	1.1	6.00	1	1	1
10/27/2021 10:00	1.3	13.9	1,454.8	1.1	5.80	1	1	0
10/27/2021 11:00	1.3	13.8	1,610.6	1.1	6.40	1	1	0
10/27/2021 12:00	1.2	13.9	1,339.4	1.0	5.40	1	1	0
10/27/2021 13:00	1.3	13.9	1,488.9	1.1	6.00	1	1	0
10/27/2021 14:00	1.4	13.3	1,856.6	1.1	7.40	1	1	1
10/27/2021 15:00	1.5	12.9	1,907.8	1.1	7.60	1	1	1
10/27/2021 16:00	1.3	13.8	1,711.2	1.1	6.80	1	1	1
10/27/2021 17:00	1.4	12.9	1,982.5	1.0	7.90	1	1	1
10/27/2021 18:00	1.6	12.3	2,133.1	1.1	8.50	1	1	1
10/27/2021 19:00	1.7	12.1	2,182.6	1.1	8.70	1	1	1
10/27/2021 20:00	1.7	12.3	2,135.5	1.2	8.50	1	1	1
10/27/2021 21:00	1.7	12.3	2,149.7	1.2	8.60	1	1	1
10/27/2021 22:00	1.6	12.7	2,047.0	1.2	8.20	1	1	1
10/27/2021 23:00	1.5	13.3	1,845.7	1.2	7.40	1	1	1
Average/Sum#:	1.4	13.2	1,818.8	1.1	164.30 #	24 #	24 #	18 #
Minimum:	1.0	12.1	1,339.4	0.8	4.70	1	1	0
Maximum:	1.7	13.9	2,182.6	1.2	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/28/2021 00:00	1.2	13.9	1,361.0	1.0	5.40	1	1	0
10/28/2021 01:00	1.3	13.9	1,355.2	1.1	5.40	1	1	0
10/28/2021 02:00	1.3	13.9	1,357.9	1.1	5.40	1	1	0
10/28/2021 03:00	1.3	13.9	1,358.5	1.1	5.40	1	1	0
10/28/2021 04:00	1.4	13.8	1,542.5	1.2	6.20	1	1	0
10/28/2021 05:00	1.3	12.8	2,003.7	0.9	6.00	1	1	1
10/28/2021 06:00	1.1	13.0	1,984.4	0.8	6.00	1	1	1
10/28/2021 07:00	1.2	13.3	1,831.5	0.9	5.50	1	1	1
10/28/2021 08:00	1.1	13.9	1,360.2	0.9	4.10	1	1	0
10/28/2021 09:00	1.1	13.9	1,366.0	0.9	4.10	1	1	0
10/28/2021 10:00	1.1	13.9	1,373.7	0.9	4.10	1	1	0
10/28/2021 11:00	1.1	13.9	1,381.5	0.9	4.10	1	1	0
10/28/2021 12:00	1.1	13.7	1,740.9	0.9	5.20	1	1	0
10/28/2021 13:00	1.1	13.8	1,500.5	0.9	4.50	1	1	0
10/28/2021 14:00	1.1	13.9	1,534.6	0.9	4.60	1	1	0
10/28/2021 15:00	1.1	13.8	1,580.9	0.9	4.70	1	1	1
10/28/2021 16:00	1.3	12.4	2,087.8	0.9	6.30	1	1	1
10/28/2021 17:00	1.3	11.9	2,202.0	0.9	6.60	1	1	1
10/28/2021 18:00	1.3	12.0	2,193.7	0.9	6.60	1	1	1
10/28/2021 19:00	1.3	12.0	2,188.3	0.9	6.60	1	1	1
10/28/2021 20:00	1.3	12.1	2,172.5	0.9	6.50	1	1	1
10/28/2021 21:00	1.3	12.4	2,109.0	0.9	6.30	1	1	1
10/28/2021 22:00	1.3	12.5	2,086.6	0.9	6.30	1	1	1
10/28/2021 23:00	1.3	12.7	2,015.0	0.9	6.00	1	1	1
Average/Sum#:	1.2	13.2	1,737.0	0.9	131.90 #	24 #	24 #	12 #
Minimum:	1.1	11.9	1,355.2	0.8	4.10	1	1	0
Maximum:	1.4	13.9	2,202.0	1.2	6.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/29/2021 00:00	1.2	13.0	1,949.1	0.9	5.80	1	1	1
10/29/2021 01:00	1.2	13.0	1,951.6	0.9	5.90	1	1	1
10/29/2021 02:00	1.2	13.1	1,947.0	0.9	5.80	1	1	1
10/29/2021 03:00	1.2	13.0	1,947.5	0.9	5.80	1	1	1
10/29/2021 04:00	1.2	13.0	1,947.2	0.9	5.80	1	1	1
10/29/2021 05:00	1.2	13.0	1,950.0	0.9	5.90	1	1	1
10/29/2021 06:00	1.2	13.1	1,951.4	0.9	5.90	1	1	1
10/29/2021 07:00	1.2	13.1	1,949.5	0.9	5.80	1	1	1
10/29/2021 08:00	1.2	13.1	1,947.5	0.9	5.80	1	1	1
10/29/2021 09:00	1.2	13.2	1,752.5	0.9	5.30	1	1	1
10/29/2021 10:00	1.1	13.7	1,449.0	0.9	4.30	1	1	1
10/29/2021 11:00	1.3	12.8	1,981.4	0.9	5.90	1	1	1
10/29/2021 12:00	1.2	13.1	1,762.5	0.9	5.30	1	1	1
10/29/2021 13:00	1.1	13.7	1,438.3	0.9	4.30	1	1	1
10/29/2021 14:00	1.2	12.7	1,993.4	0.9	6.00	1	1	1
10/29/2021 15:00	1.2	12.7	1,995.1	0.9	6.00	1	1	1
10/29/2021 16:00	1.3	12.7	1,993.2	0.9	6.00	1	1	1
10/29/2021 17:00	1.3	12.8	1,989.9	0.9	6.00	1	1	1
10/29/2021 18:00	1.3	12.8	1,986.4	0.9	6.00	1	1	1
10/29/2021 19:00	1.2	12.8	1,985.2	0.9	6.00	1	1	1
10/29/2021 20:00	1.2	12.8	1,981.8	0.9	5.90	1	1	1
10/29/2021 21:00	1.3	12.8	1,978.1	0.9	5.90	1	1	1
10/29/2021 22:00	1.2	12.9	1,963.8	0.9	5.90	1	1	1
10/29/2021 23:00	1.3	12.6	2,027.9	0.9	6.10	1	1	1
Average/Sum#:	1.2	13.0	1,909.1	0.9	137.40 #	24 #	24 #	24 #
Minimum:	1.1	12.6	1,438.3	0.9	4.30	1	1	1
Maximum:	1.3	13.7	2,027.9	0.9	6.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/30/2021 00:00	1.1	13.7	1,659.6	0.9	5.00	1	1	1
10/30/2021 01:00	1.1	13.8	1,470.0	0.9	4.40	1	1	0
10/30/2021 02:00	1.2	13.2	1,786.9	0.9	5.40	1	1	1
10/30/2021 03:00	1.2	13.0	1,938.3	0.9	5.80	1	1	1
10/30/2021 04:00	1.1	13.8	1,638.9	0.9	4.90	1	1	0
10/30/2021 05:00	1.0	13.7	1,697.1	0.8	5.10	1	1	1
10/30/2021 06:00	1.3	12.7	2,022.7	0.9	6.10	1	1	1
10/30/2021 07:00	1.2	13.0	1,945.0	0.9	5.80	1	1	1
10/30/2021 08:00	1.1	13.8	1,517.6	0.9	4.60	1	1	0
10/30/2021 09:00	1.0	13.9	1,350.1	0.8	4.10	1	1	0
10/30/2021 10:00	1.1	13.9	1,350.1	0.9	4.10	1	1	0
10/30/2021 11:00	1.1	13.8	1,483.5	0.9	4.50	1	1	0
10/30/2021 12:00	1.0	13.9	1,399.9	0.8	4.20	1	1	0
10/30/2021 13:00	1.0	13.9	1,409.0	0.8	4.20	1	1	0
10/30/2021 14:00	1.1	13.9	1,531.7	0.9	4.60	1	1	0
10/30/2021 15:00	1.1	13.8	1,624.8	0.9	4.90	1	1	1
10/30/2021 16:00	1.3	12.6	2,048.4	0.9	6.10	1	1	1
10/30/2021 17:00	1.3	12.4	2,109.1	0.9	6.30	1	1	1
10/30/2021 18:00	1.3	12.5	2,086.5	0.9	6.30	1	1	1
10/30/2021 19:00	1.3	12.7	2,003.7	0.9	6.00	1	1	1
10/30/2021 20:00	1.1	13.8	1,677.2	0.9	5.00	1	1	0
10/30/2021 21:00	1.1	13.8	1,645.4	0.9	4.90	1	1	1
10/30/2021 22:00	1.3	12.8	2,019.3	0.9	6.10	1	1	1
10/30/2021 23:00	1.2	13.0	1,934.0	0.9	5.80	1	1	1
Average/Sum#:	1.2	13.4	1,722.9	0.9	124.20 #	24 #	24 #	14 #
Minimum:	1.0	12.4	1,350.1	0.8	4.10	1	1	0
Maximum:	1.3	13.9	2,109.1	0.9	6.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/31/2021 00:00	1.1	13.8	1,666.6	0.9	5.00	1	1	0
10/31/2021 01:00	1.1	13.8	1,577.3	0.9	4.70	1	1	1
10/31/2021 02:00	1.2	13.1	1,952.5	0.9	5.90	1	1	1
10/31/2021 03:00	1.2	13.1	1,928.8	0.9	5.80	1	1	1
10/31/2021 04:00	1.1	13.8	1,701.4	0.9	5.10	1	1	0
10/31/2021 05:00	1.0	13.8	1,573.7	0.8	4.70	1	1	1
10/31/2021 06:00	1.3	12.8	2,045.2	0.9	6.10	1	1	1
10/31/2021 07:00	1.2	13.1	1,942.4	0.9	5.80	1	1	1
10/31/2021 08:00	1.1	13.8	1,658.3	0.9	5.00	1	1	0
10/31/2021 09:00	1.1	13.8	1,592.7	0.9	4.80	1	1	0
10/31/2021 10:00	1.1	13.9	1,415.7	0.9	4.20	1	1	0
10/31/2021 11:00	1.1	13.8	1,558.0	0.9	4.70	1	1	0
10/31/2021 12:00	1.1	13.8	1,610.2	0.9	4.80	1	1	0
10/31/2021 13:00	1.1	13.8	1,696.3	0.9	5.10	1	1	0
10/31/2021 14:00	1.1	13.9	1,575.5	0.9	4.70	1	1	0
10/31/2021 15:00	1.1	13.8	1,610.0	0.9	4.80	1	1	1
10/31/2021 16:00	1.3	12.7	2,009.4	0.9	6.00	1	1	1
10/31/2021 17:00	1.3	12.5	2,055.8	0.9	6.20	1	1	1
10/31/2021 18:00	1.3	12.5	2,069.8	0.9	6.20	1	1	1
10/31/2021 19:00	1.2	12.9	1,952.2	0.9	5.90	1	1	1
10/31/2021 20:00	1.1	13.8	1,693.9	0.9	5.10	1	1	0
10/31/2021 21:00	1.0	13.8	1,585.1	0.8	4.80	1	1	1
10/31/2021 22:00	1.3	12.8	2,016.5	0.9	6.00	1	1	1
10/31/2021 23:00	1.2	13.0	1,944.3	0.9	5.80	1	1	1
Average/Sum#:	1.2	13.4	1,768.0	0.9	127.20 #	24 #	24 #	14 #
Minimum:	1.0	12.5	1,415.7	0.8	4.20	1	1	0
Maximum:	1.3	13.9	2,069.8	0.9	6.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/01/2021 00:00	1.1	13.8	1,635.1	0.9	4.90	1	1	0
11/01/2021 01:00	1.1	13.7	1,693.5	0.9	5.10	1	1	1
11/01/2021 02:00	1.2	13.0	1,951.2	0.9	5.90	1	1	1
11/01/2021 03:00	1.3	12.7	2,003.4	0.9	6.00	1	1	1
11/01/2021 04:00	1.1	13.8	1,598.1	0.9	4.80	1	1	1
11/01/2021 05:00	0.9	13.7	1,688.6	0.7	5.10	1	1	1
11/01/2021 06:00	1.3	12.5	2,066.7	0.9	6.20	1	1	1
11/01/2021 07:00	1.3	12.3	2,118.8	0.9	6.40	1	1	1
11/01/2021 08:00	1.2	12.9	1,963.2	0.9	5.90	1	1	1
11/01/2021 09:00	1.0	13.8	1,577.1	0.8	4.70	1	1	0
11/01/2021 10:00	1.1	13.8	1,538.3	0.9	4.60	1	1	1
11/01/2021 11:00	1.3	12.6	2,040.4	0.9	6.10	1	1	1
11/01/2021 12:00	1.3	12.5	2,033.3	0.9	6.10	1	1	1
11/01/2021 13:00	1.1	13.8	1,716.1	0.9	5.10	1	1	0
11/01/2021 14:00	1.1	13.6	1,803.2	0.9	5.40	1	1	0
11/01/2021 15:00	1.3	12.6	2,035.9	0.9	6.10	1	1	1
11/01/2021 16:00	1.3	12.4	2,072.0	0.9	6.20	1	1	1
11/01/2021 17:00	1.4	11.9	2,205.0	0.9	6.60	1	1	1
11/01/2021 18:00	1.3	12.0	2,167.8	0.9	6.50	1	1	1
11/01/2021 19:00	1.3	11.9	2,202.3	0.9	6.60	1	1	1
11/01/2021 20:00	1.4	11.8	2,228.3	0.9	6.70	1	1	1
11/01/2021 21:00	1.4	11.9	2,209.1	0.9	6.60	1	1	1
11/01/2021 22:00	1.3	12.4	2,109.1	0.9	6.30	1	1	1
11/01/2021 23:00	1.2	13.1	1,929.3	0.9	5.80	1	1	1
Average/Sum#:	1.2	12.9	1,941.1	0.9	139.70 #	24 #	24 #	20 #
Minimum:	0.9	11.8	1,538.3	0.7	4.60	1	1	0
Maximum:	1.4	13.8	2,228.3	0.9	6.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/02/2021 00:00	1.1	13.8	1,564.4	0.9	4.70	1	1	0
11/02/2021 01:00	1.1	13.8	1,588.3	0.9	4.80	1	1	1
11/02/2021 02:00	1.2	13.1	1,952.4	0.9	5.90	1	1	1
11/02/2021 03:00	1.2	13.1	1,940.9	0.9	5.80	1	1	1
11/02/2021 04:00	1.1	13.7	1,660.4	0.9	5.00	1	1	1
11/02/2021 05:00	1.1	13.8	1,639.6	0.9	4.90	1	1	1
11/02/2021 06:00	1.3	12.6	2,065.5	0.9	6.20	1	1	1
11/02/2021 07:00	1.3	12.6	2,067.5	0.9	6.20	1	1	1
11/02/2021 08:00	1.2	13.1	1,947.1	0.9	5.80	1	1	1
11/02/2021 09:00	1.1	13.8	1,524.3	0.9	4.60	1	1	0
11/02/2021 10:00	1.1	13.8	1,633.7	0.9	4.90	1	1	0
11/02/2021 11:00	1.0	13.9	1,330.6	0.8	4.00	1	1	0
11/02/2021 12:00	1.2	13.9	1,533.6	1.0	6.10	1	1	0
11/02/2021 13:00	1.4	13.9	1,636.6	1.2	6.50	1	1	0
11/02/2021 14:00	1.4	13.9	1,622.1	1.2	6.50	1	1	0
11/02/2021 15:00	1.5	13.8	1,649.3	1.2	8.20	1	1	1
11/02/2021 16:00	1.9	12.6	2,054.5	1.4	10.30	1	1	1
11/02/2021 17:00	2.3	12.0	2,168.6	1.5	13.00	1	1	1
11/02/2021 18:00	2.3	12.1	2,167.3	1.5	13.00	1	1	1
11/02/2021 19:00	2.6	11.8	2,239.2	1.7	13.40	1	1	1
11/02/2021 20:00	2.4	12.1	2,174.8	1.6	13.00	1	1	1
11/02/2021 21:00	2.3	12.2	2,156.4	1.6	12.90	1	1	1
11/02/2021 22:00	2.2	12.3	2,126.3	1.5	12.80	1	1	1
11/02/2021 23:00	2.0	12.9	1,964.6	1.5	9.80	1	1	1
Average/Sum#:	1.6	13.1	1,850.3	1.2	188.30 #	24 #	24 #	17 #
Minimum:	1.0	11.8	1,330.6	0.8	4.00	1	1	0
Maximum:	2.6	13.9	2,239.2	1.7	13.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/03/2021 00:00	1.4	13.9	1,693.3	1.2	6.80	1	1	0
11/03/2021 01:00	1.4	13.8	1,645.7	1.2	6.60	1	1	1
11/03/2021 02:00	1.7	13.1	1,946.2	1.3	9.70	1	1	1
11/03/2021 03:00	1.8	13.1	1,936.1	1.4	9.70	1	1	1
11/03/2021 04:00	1.6	13.7	1,659.7	1.3	8.30	1	1	1
11/03/2021 05:00	1.0	13.8	1,786.9	0.8	5.40	1	1	1
11/03/2021 06:00	1.2	12.9	2,013.9	0.9	6.00	1	1	1
11/03/2021 07:00	1.2	13.0	1,983.4	0.9	6.00	1	1	1
11/03/2021 08:00	1.1	13.7	1,679.1	0.9	5.00	1	1	1
11/03/2021 09:00	1.1	13.8	1,688.5	0.9	5.10	1	1	0
11/03/2021 10:00	1.1	13.9	1,591.5	0.9	4.80	1	1	0
11/03/2021 11:00	1.1	13.9	1,702.2	0.9	5.10	1	1	0
11/03/2021 12:00	1.1	13.9	1,532.4	0.9	4.60	1	1	0
11/03/2021 13:00	1.1	13.9	1,700.0	0.9	5.10	1	1	0
11/03/2021 14:00	1.1	13.9	1,521.9	0.9	4.60	1	1	0
11/03/2021 15:00	1.1	13.8	1,598.3	0.9	4.80	1	1	1
11/03/2021 16:00	1.3	12.5	2,053.5	0.9	6.20	1	1	1
11/03/2021 17:00	1.4	11.8	2,209.9	0.9	6.60	1	1	1
11/03/2021 18:00	1.4	12.0	2,166.9	0.9	6.50	1	1	1
11/03/2021 19:00	1.4	11.8	2,229.6	0.9	6.70	1	1	1
11/03/2021 20:00	1.4	11.8	2,207.3	0.9	6.60	1	1	1
11/03/2021 21:00	1.4	12.1	2,151.9	0.9	6.50	1	1	1
11/03/2021 22:00	1.3	12.3	2,087.8	0.9	6.30	1	1	1
11/03/2021 23:00	1.2	12.9	1,939.3	0.9	5.80	1	1	1
Average/Sum#:	1.3	13.1	1,863.6	1.0	148.80 #	24 #	24 #	17 #
Minimum:	1.0	11.8	1,521.9	0.8	4.60	1	1	0
Maximum:	1.8	13.9	2,229.6	1.4	9.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/04/2021 00:00	1.1	13.8	1,479.7	0.9	4.40	1	1	0
11/04/2021 01:00	1.1	13.7	1,595.4	0.9	4.80	1	1	1
11/04/2021 02:00	1.2	12.9	1,955.7	0.9	5.90	1	1	1
11/04/2021 03:00	1.3	12.7	1,983.9	0.9	6.00	1	1	1
11/04/2021 04:00	1.1	13.8	1,692.1	0.9	5.10	1	1	1
11/04/2021 05:00	1.1	13.7	1,777.3	0.9	5.30	1	1	1
11/04/2021 06:00	1.3	12.7	2,022.2	0.9	6.10	1	1	1
11/04/2021 07:00	1.3	12.7	2,000.2	0.9	6.00	1	1	1
11/04/2021 08:00	1.0	13.9	1,599.3	0.8	4.80	1	1	0
11/04/2021 09:00	1.1	13.9	1,533.5	0.9	4.60	1	1	0
11/04/2021 10:00	1.1	13.9	1,526.0	0.9	4.60	1	1	0
11/04/2021 11:00	1.1	13.9	1,499.5	0.9	4.50	1	1	0
11/04/2021 12:00	1.1	14.0	1,387.7	0.9	4.20	1	1	0
11/04/2021 13:00	1.1	13.9	1,549.4	0.9	4.60	1	1	0
11/04/2021 14:00	1.0	13.9	1,666.7	0.8	5.00	1	1	0
11/04/2021 15:00	1.1	13.9	1,567.9	0.9	4.70	1	1	0
11/04/2021 16:00	1.3	12.7	2,014.7	0.9	6.00	1	1	1
11/04/2021 17:00	1.3	12.4	2,094.6	0.9	6.30	1	1	1
11/04/2021 18:00	1.3	12.5	2,064.8	0.9	6.20	1	1	1
11/04/2021 19:00	1.1	13.8	1,702.6	0.9	5.10	1	1	1
11/04/2021 20:00	1.1	13.8	1,645.3	0.9	4.90	1	1	1
11/04/2021 21:00	1.3	12.7	2,030.4	0.9	6.10	1	1	1
11/04/2021 22:00	1.1	13.3	1,688.6	0.9	5.10	1	1	1
11/04/2021 23:00	1.1	13.9	1,363.5	0.9	4.10	1	1	0
Average/Sum#:	1.2	13.4	1,726.7	0.9	124.40 #	24 #	24 #	14 #
Minimum:	1.0	12.4	1,363.5	0.8	4.10	1	1	0
Maximum:	1.3	14.0	2,094.6	0.9	6.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/05/2021 00:00	1.1	13.9	1,350.7	0.9	4.10	1	1	0
11/05/2021 01:00	1.1	13.9	1,360.1	0.9	4.10	1	1	0
11/05/2021 02:00	1.1	13.9	1,363.9	0.9	4.10	1	1	0
11/05/2021 03:00	1.1	13.9	1,399.7	0.9	4.20	1	1	0
11/05/2021 04:00	1.1	13.8	1,591.3	0.9	4.80	1	1	0
11/05/2021 05:00	1.4	12.2	2,093.0	0.9	6.30	1	1	1
11/05/2021 06:00	1.3	12.6	2,068.0	0.9	6.20	1	1	1
11/05/2021 07:00	1.3	12.6	1,871.7	0.9	5.60	1	1	1
11/05/2021 08:00	0.5	13.9	1,369.5	0.4	2.70	1	1	0
11/05/2021 09:00	0.0	0.0	1,377.5	0.0	0.00	1	1	0
11/05/2021 10:00	0.4	13.9	1,374.4	0.3	1.40	1	1	0
11/05/2021 11:00	0.4	13.9	1,375.0	0.3	1.40	1	1	0
11/05/2021 12:00	0.4	13.9	1,420.9	0.3	1.40	1	1	0
11/05/2021 13:00	1.0	13.8	1,805.1	0.8	5.40	1	1	0
11/05/2021 14:00	0.7	13.8	1,580.6	0.6	3.20	1	1	0
11/05/2021 15:00	0.6	13.8	1,576.0	0.5	3.20	1	1	1
11/05/2021 16:00	1.3	12.5	2,076.9	0.9	6.20	1	1	1
11/05/2021 17:00	1.3	12.4	2,107.0	0.9	6.30	1	1	1
11/05/2021 18:00	1.3	12.4	2,089.2	0.9	6.30	1	1	1
11/05/2021 19:00	1.3	12.8	1,984.7	0.9	6.00	1	1	1
11/05/2021 20:00	1.1	13.8	1,673.4	0.9	5.00	1	1	0
11/05/2021 21:00	1.1	13.8	1,790.6	0.9	5.40	1	1	1
11/05/2021 22:00	1.3	12.8	2,033.4	0.9	6.10	1	1	1
11/05/2021 23:00	1.2	13.0	1,953.8	0.9	5.90	1	1	1
Average/Sum#:	1.0	13.4	1,695.3	0.8	105.30 #	24 #	24 #	11 #
Minimum:	0.4	12.2	1,350.7	0.3	1.40	1	1	0
Maximum:	1.4	13.9	2,107.0	0.9	6.30	1	1	1
%SI	4.17	4.17	0.00	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/06/2021 00:00	1.1	13.7	1,698.3	0.9	5.10	1	1	1
11/06/2021 01:00	1.1	13.8	1,607.9	0.9	4.80	1	1	0
11/06/2021 02:00	1.2	13.1	1,960.6	0.9	5.90	1	1	1
11/06/2021 03:00	1.2	13.1	1,952.7	0.9	5.90	1	1	1
11/06/2021 04:00	1.1	13.8	1,695.2	0.9	5.10	1	1	1
11/06/2021 05:00	1.0	13.8	1,624.5	0.8	4.90	1	1	1
11/06/2021 06:00	1.2	12.8	2,020.5	0.9	6.10	1	1	1
11/06/2021 07:00	1.2	13.0	1,944.0	0.9	5.80	1	1	1
11/06/2021 08:00	1.1	13.8	1,621.0	0.9	4.90	1	1	0
11/06/2021 09:00	1.1	13.8	1,619.9	0.9	4.90	1	1	0
11/06/2021 10:00	1.1	13.8	1,625.9	0.9	4.90	1	1	0
11/06/2021 11:00	1.1	13.8	1,560.7	0.9	4.70	1	1	0
11/06/2021 12:00	1.1	13.8	1,553.8	0.9	4.70	1	1	0
11/06/2021 13:00	1.1	13.8	1,583.2	0.9	4.70	1	1	0
11/06/2021 14:00	1.1	13.9	1,490.6	0.9	4.50	1	1	0
11/06/2021 15:00	1.1	13.8	1,595.8	0.9	4.80	1	1	0
11/06/2021 16:00	1.3	12.7	2,017.7	0.9	6.10	1	1	1
11/06/2021 17:00	1.3	12.3	2,105.8	0.9	6.30	1	1	1
11/06/2021 18:00	1.2	13.0	1,928.1	0.9	5.80	1	1	1
11/06/2021 19:00	1.1	13.8	1,672.3	0.9	5.00	1	1	0
11/06/2021 20:00	1.1	13.7	1,690.4	0.9	5.10	1	1	1
11/06/2021 21:00	1.2	12.9	1,998.3	0.9	6.00	1	1	1
11/06/2021 22:00	2.2	13.9	1,482.6	1.9	7.59	1	0	1
11/06/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.2	13.5	1,741.3	0.9	123.59 #	23 #	22 #	13 #
Minimum:	1.0	12.3	1,482.6	0.8	4.50	0	0	0
Maximum:	2.2	13.9	2,105.8	1.9	7.59	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/07/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/08/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/08/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/08/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/08/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/08/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/08/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/08/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/08/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/08/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/08/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/08/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/08/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/08/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/08/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/08/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/08/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/08/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/08/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/08/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/08/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/08/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/08/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/08/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/08/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/09/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/09/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/09/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/09/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/09/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/09/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/09/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/09/2021 07:00	30.3	17.5	372.4	52.6	59.20	1	0	0
11/09/2021 08:00	9.8	14.9	1,039.3	9.6	37.40	1	0	0
11/09/2021 09:00	1.1	13.8	1,722.8	0.9	5.20	1	1	0
11/09/2021 10:00	1.1	13.8	1,527.8	0.9	4.60	1	1	0
11/09/2021 11:00	1.1	13.8	1,581.8	0.9	4.70	1	1	0
11/09/2021 12:00	1.1	13.8	1,552.3	0.9	4.70	1	1	0
11/09/2021 13:00	1.1	13.8	1,684.2	0.9	5.10	1	1	0
11/09/2021 14:00	1.1	13.8	1,632.3	0.9	4.90	1	1	0
11/09/2021 15:00	1.1	13.8	1,532.2	0.9	4.60	1	1	0
11/09/2021 16:00	1.1	13.8	1,574.7	0.9	4.70	1	1	0
11/09/2021 17:00	1.2	13.3	1,867.2	0.9	5.60	1	1	1
11/09/2021 18:00	1.3	12.3	2,146.4	0.9	6.40	1	1	1
11/09/2021 19:00	1.4	12.0	2,213.1	0.9	6.60	1	1	1
11/09/2021 20:00	1.3	12.3	2,117.6	0.9	6.40	1	1	1
11/09/2021 21:00	1.1	13.8	1,620.9	0.9	4.90	1	1	0
11/09/2021 22:00	1.1	13.8	1,732.5	0.9	5.20	1	1	0
11/09/2021 23:00	1.2	12.9	2,019.2	0.9	6.10	1	1	1
Average/Sum#:	3.4	13.7	1,643.3	4.5	176.30 #	17 #	15 #	5 #
Minimum:	1.1	12.0	372.4	0.9	4.60	0	0	0
Maximum:	30.3	17.5	2,213.1	52.6	59.20	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/10/2021 00:00	1.2	13.3	1,842.8	0.9	5.50	1	1	1
11/10/2021 01:00	1.1	13.6	1,809.3	0.9	5.40	1	1	0
11/10/2021 02:00	1.1	13.8	1,596.6	0.9	4.80	1	1	1
11/10/2021 03:00	1.2	13.1	1,970.3	0.9	5.90	1	1	1
11/10/2021 04:00	1.2	13.2	1,948.6	0.9	5.80	1	1	1
11/10/2021 05:00	1.1	13.8	1,712.8	0.9	5.10	1	1	0
11/10/2021 06:00	1.1	13.8	1,793.0	0.9	5.40	1	1	1
11/10/2021 07:00	1.2	13.0	2,003.3	0.9	6.00	1	1	1
11/10/2021 08:00	1.2	13.2	1,943.5	0.9	5.80	1	1	1
11/10/2021 09:00	1.1	13.9	1,559.3	0.9	4.70	1	1	0
11/10/2021 10:00	1.1	13.9	1,479.9	0.9	4.40	1	1	0
11/10/2021 11:00	1.1	13.9	1,421.3	0.9	4.30	1	1	0
11/10/2021 12:00	1.1	13.9	1,472.0	0.9	4.40	1	1	0
11/10/2021 13:00	1.1	13.9	1,355.1	0.9	4.10	1	1	0
11/10/2021 14:00	1.1	13.9	1,495.5	0.9	4.50	1	1	0
11/10/2021 15:00	1.1	13.8	1,593.9	0.9	4.80	1	1	1
11/10/2021 16:00	1.3	12.8	2,020.5	0.9	6.10	1	1	1
11/10/2021 17:00	1.3	12.7	2,038.8	0.9	6.10	1	1	1
11/10/2021 18:00	1.3	12.5	2,093.5	0.9	6.30	1	1	1
11/10/2021 19:00	1.3	12.5	2,090.4	0.9	6.30	1	1	1
11/10/2021 20:00	1.3	12.8	2,016.0	0.9	6.00	1	1	1
11/10/2021 21:00	1.1	13.8	1,704.2	0.9	5.10	1	1	0
11/10/2021 22:00	1.1	13.8	1,781.7	0.9	5.30	1	1	1
11/10/2021 23:00	1.3	12.8	2,041.3	0.9	6.10	1	1	1
Average/Sum#:	1.2	13.4	1,782.7	0.9	128.20 #	24 #	24 #	15 #
Minimum:	1.1	12.5	1,355.1	0.9	4.10	1	1	0
Maximum:	1.3	13.9	2,093.5	0.9	6.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/11/2021 00:00	1.2	13.0	1,952.5	0.9	5.90	1	1	1
11/11/2021 01:00	4.0	15.8	584.7	4.6	2.28	1	0	0
11/11/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/11/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/11/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/11/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/11/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/11/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/11/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/11/2021 09:00	20.5	18.0	315.5	41.7	20.90	1	0	0
11/11/2021 10:00	15.0	15.6	790.8	16.7	49.00	1	0	0
11/11/2021 11:00	0.9	13.9	1,404.0	0.8	4.20	1	1	0
11/11/2021 12:00	1.6	13.9	1,369.5	1.3	6.80	1	1	0
11/11/2021 13:00	1.7	13.8	1,714.5	1.4	8.60	1	1	0
11/11/2021 14:00	1.0	13.9	1,519.7	0.8	4.60	1	1	0
11/11/2021 15:00	1.1	13.9	1,668.3	0.9	5.00	1	1	0
11/11/2021 16:00	1.2	13.3	1,845.6	0.9	5.50	1	1	1
11/11/2021 17:00	1.3	12.2	2,117.2	0.9	6.40	1	1	1
11/11/2021 18:00	1.3	12.3	2,117.0	0.9	6.40	1	1	1
11/11/2021 19:00	1.3	12.3	2,121.6	0.9	6.40	1	1	1
11/11/2021 20:00	1.3	12.3	2,096.0	0.9	6.30	1	1	1
11/11/2021 21:00	1.1	13.8	1,691.2	0.9	5.10	1	1	0
11/11/2021 22:00	1.1	13.8	1,776.3	0.9	5.30	1	1	1
11/11/2021 23:00	1.3	12.9	2,001.4	1.0	8.00	1	1	1
Average/Sum#:	3.3	13.8	1,593.3	4.5	156.68 #	17 #	14 #	8 #
Minimum:	0.9	12.2	315.5	0.8	2.28	0	0	0
Maximum:	20.5	18.0	2,121.6	41.7	49.00	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/12/2021 00:00	1.2	13.1	1,931.6	0.9	5.80	1	1	1
11/12/2021 01:00	1.1	13.8	1,575.3	0.9	4.70	1	1	0
11/12/2021 02:00	1.1	13.8	1,542.3	0.9	4.60	1	1	0
11/12/2021 03:00	1.1	13.8	1,545.6	0.9	4.60	1	1	0
11/12/2021 04:00	1.1	13.8	1,585.9	0.9	4.80	1	1	1
11/12/2021 05:00	1.3	12.6	2,049.3	0.9	6.10	1	1	1
11/12/2021 06:00	1.3	12.6	2,082.5	0.9	6.20	1	1	1
11/12/2021 07:00	1.1	13.5	1,692.3	0.9	5.10	1	1	1
11/12/2021 08:00	1.0	13.9	1,425.3	0.8	4.30	1	1	0
11/12/2021 09:00	1.1	13.9	1,370.0	0.9	4.10	1	1	0
11/12/2021 10:00	1.1	13.9	1,375.6	0.9	4.10	1	1	0
11/12/2021 11:00	1.1	13.9	1,382.6	0.9	4.10	1	1	0
11/12/2021 12:00	1.1	13.9	1,384.5	0.9	4.20	1	1	0
11/12/2021 13:00	1.1	13.9	1,387.1	0.9	4.20	1	1	0
11/12/2021 14:00	1.1	13.9	1,388.9	0.9	4.20	1	1	0
11/12/2021 15:00	1.1	13.8	1,645.1	0.9	4.90	1	1	0
11/12/2021 16:00	1.1	13.8	1,587.3	0.9	4.80	1	1	0
11/12/2021 17:00	1.1	13.9	1,445.7	0.9	4.30	1	1	0
11/12/2021 18:00	1.1	13.8	1,592.6	0.9	4.80	1	1	1
11/12/2021 19:00	1.3	12.7	2,060.1	0.9	6.20	1	1	1
11/12/2021 20:00	1.2	12.9	1,986.3	0.9	6.00	1	1	1
11/12/2021 21:00	1.1	13.8	1,635.0	0.9	4.90	1	1	0
11/12/2021 22:00	1.1	13.8	1,699.8	0.9	5.10	1	1	1
11/12/2021 23:00	1.3	12.8	2,041.9	0.9	6.10	1	1	1
Average/Sum#:	1.1	13.6	1,642.2	0.9	118.20 #	24 #	24 #	10 #
Minimum:	1.0	12.6	1,370.0	0.8	4.10	1	1	0
Maximum:	1.3	13.9	2,082.5	0.9	6.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/13/2021 00:00	1.9	14.4	1,231.8	1.7	3.55	1	0	1
11/13/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/13/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/13/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/13/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/13/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/13/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/13/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/13/2021 08:00	16.5	18.0	317.7	33.6	16.94	1	0	0
11/13/2021 09:00	7.0	15.4	951.3	7.5	26.60	1	0	0
11/13/2021 10:00	1.1	13.9	1,388.0	0.9	4.20	1	1	0
11/13/2021 11:00	1.1	13.9	1,374.3	0.9	4.10	1	1	0
11/13/2021 12:00	1.1	13.9	1,384.4	0.9	4.20	1	1	0
11/13/2021 13:00	1.0	13.8	1,743.1	0.8	5.20	1	1	0
11/13/2021 14:00	1.1	13.9	1,499.1	0.9	4.50	1	1	0
11/13/2021 15:00	1.1	13.9	1,709.3	0.9	5.10	1	1	0
11/13/2021 16:00	1.1	13.7	1,785.0	0.9	5.40	1	1	1
11/13/2021 17:00	1.3	12.6	2,039.4	0.9	6.10	1	1	1
11/13/2021 18:00	1.3	12.7	1,990.3	0.9	6.00	1	1	1
11/13/2021 19:00	1.1	13.8	1,705.5	0.9	5.10	1	1	0
11/13/2021 20:00	1.1	13.8	1,793.6	0.9	5.40	1	1	1
11/13/2021 21:00	1.3	12.8	2,036.0	0.9	6.10	1	1	1
11/13/2021 22:00	1.9	13.7	1,498.3	1.6	6.57	1	0	1
11/13/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	2.6	14.0	1,527.9	3.4	115.06 #	16 #	12 #	7 #
Minimum:	1.0	12.6	317.7	0.8	3.55	0	0	0
Maximum:	16.5	18.0	2,039.4	33.6	26.60	1	1	1
%SI	33.33	33.33	33.33	33.33	33.33	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/14/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/14/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/14/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/14/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/14/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/14/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/14/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/14/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/14/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/14/2021 09:00	11.0	18.6	225.9	28.2	5.17	1	0	0
11/14/2021 10:00	19.4	17.2	411.0	30.9	46.90	1	0	0
11/14/2021 11:00	4.5	14.4	1,197.1	4.1	18.00	1	0	0
11/14/2021 12:00	1.1	13.9	1,368.4	0.9	4.10	1	1	0
11/14/2021 13:00	1.1	13.9	1,380.1	0.9	4.10	1	1	0
11/14/2021 14:00	1.1	13.8	1,652.0	0.9	5.00	1	1	0
11/14/2021 15:00	1.1	13.8	1,612.8	0.9	4.80	1	1	0
11/14/2021 16:00	1.1	13.9	1,322.3	0.9	4.00	1	1	0
11/14/2021 17:00	1.1	13.8	1,592.4	0.9	4.80	1	1	1
11/14/2021 18:00	1.3	12.6	2,061.9	0.9	6.20	1	1	1
11/14/2021 19:00	1.2	13.0	1,963.3	0.9	5.90	1	1	1
11/14/2021 20:00	1.1	13.6	1,726.8	0.9	5.20	1	1	1
11/14/2021 21:00	1.1	13.8	1,590.0	0.9	4.80	1	1	1
11/14/2021 22:00	1.3	12.7	2,056.4	0.9	6.20	1	1	1
11/14/2021 23:00	1.1	13.4	1,668.3	0.9	5.00	1	1	1
Average/Sum#:	3.2	14.2	1,455.2	4.9	130.17 #	15 #	12 #	7 #
Minimum:	1.1	12.6	225.9	0.9	4.00	0	0	0
Maximum:	19.4	18.6	2,061.9	30.9	46.90	1	1	1
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/15/2021 00:00	1.1	13.9	1,365.2	0.9	4.10	1	1	0
11/15/2021 01:00	1.1	13.9	1,359.6	0.9	4.10	1	1	0
11/15/2021 02:00	1.1	13.9	1,365.3	0.9	4.10	1	1	0
11/15/2021 03:00	1.1	13.9	1,371.1	0.9	4.10	1	1	0
11/15/2021 04:00	1.1	13.9	1,371.7	0.9	4.10	1	1	0
11/15/2021 05:00	1.1	13.8	1,445.3	0.9	4.30	1	1	0
11/15/2021 06:00	1.1	13.8	1,566.5	0.9	4.70	1	1	0
11/15/2021 07:00	1.1	13.8	1,748.6	0.9	5.20	1	1	0
11/15/2021 08:00	1.1	13.8	1,588.8	0.9	4.80	1	1	0
11/15/2021 09:00	1.1	13.9	1,416.2	0.9	4.20	1	1	0
11/15/2021 10:00	1.1	13.8	1,635.2	0.9	4.90	1	1	1
11/15/2021 11:00	1.2	13.1	1,970.9	0.9	5.90	1	1	1
11/15/2021 12:00	1.2	13.1	1,965.0	0.9	5.90	1	1	1
11/15/2021 13:00	1.1	13.7	1,530.2	0.9	4.60	1	1	1
11/15/2021 14:00	1.0	13.8	1,602.0	0.8	4.80	1	1	0
11/15/2021 15:00	1.2	13.0	1,965.9	0.9	5.90	1	1	1
11/15/2021 16:00	1.2	12.9	2,007.4	0.9	6.00	1	1	1
11/15/2021 17:00	1.2	13.1	1,955.3	0.9	5.90	1	1	1
11/15/2021 18:00	1.2	13.1	1,965.9	0.9	5.90	1	1	1
11/15/2021 19:00	1.3	12.5	2,093.6	0.9	6.30	1	1	1
11/15/2021 20:00	1.2	13.1	1,952.0	0.9	5.90	1	1	1
11/15/2021 21:00	1.2	13.1	1,952.9	0.9	5.90	1	1	1
11/15/2021 22:00	1.2	13.1	1,945.7	0.9	5.80	1	1	1
11/15/2021 23:00	1.2	13.1	1,933.9	0.9	5.80	1	1	1
Average/Sum#:	1.1	13.5	1,711.4	0.9	123.20 #	24 #	24 #	13 #
Minimum:	1.0	12.5	1,359.6	0.8	4.10	1	1	0
Maximum:	1.3	13.9	2,093.6	0.9	6.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/16/2021 00:00	3.3	15.5	671.1	3.6	2.35	1	0	0
11/16/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/16/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/16/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/16/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/16/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/16/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/16/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/16/2021 08:00	19.7	18.0	312.6	40.1	19.91	1	0	0
11/16/2021 09:00	9.9	15.9	752.6	11.7	32.40	1	0	0
11/16/2021 10:00	1.1	13.9	1,384.7	0.9	4.20	1	1	0
11/16/2021 11:00	1.6	13.9	1,378.4	1.3	6.90	1	1	0
11/16/2021 12:00	1.0	13.9	1,382.3	0.8	4.10	1	1	0
11/16/2021 13:00	1.1	13.8	1,541.1	0.9	4.60	1	1	0
11/16/2021 14:00	1.1	13.8	1,742.5	0.9	5.20	1	1	0
11/16/2021 15:00	1.1	13.9	1,497.9	0.9	4.50	1	1	0
11/16/2021 16:00	1.1	13.9	1,509.9	0.9	4.50	1	1	0
11/16/2021 17:00	1.2	13.0	1,962.3	0.9	5.90	1	1	1
11/16/2021 18:00	1.3	12.7	2,057.6	0.9	6.20	1	1	1
11/16/2021 19:00	1.2	13.1	1,969.3	0.9	5.90	1	1	1
11/16/2021 20:00	1.3	12.4	2,132.7	0.9	6.40	1	1	1
11/16/2021 21:00	1.3	12.2	2,173.2	0.9	6.50	1	1	1
11/16/2021 22:00	1.3	12.5	2,099.3	0.9	6.30	1	1	1
11/16/2021 23:00	1.3	12.2	2,168.9	0.9	6.50	1	1	1
Average/Sum#:	2.9	13.8	1,572.7	4.0	132.36 #	17 #	14 #	7 #
Minimum:	1.0	12.2	312.6	0.8	2.35	0	0	0
Maximum:	19.7	18.0	2,173.2	40.1	32.40	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/17/2021 00:00	1.2	12.9	2,000.4	0.9	6.00	1	1	1
11/17/2021 01:00	1.2	13.2	1,953.8	0.9	5.90	1	1	1
11/17/2021 02:00	1.2	13.2	1,955.4	0.9	5.90	1	1	1
11/17/2021 03:00	1.2	13.2	1,955.8	0.9	5.90	1	1	1
11/17/2021 04:00	1.2	13.0	2,020.2	0.9	6.10	1	1	1
11/17/2021 05:00	1.3	12.8	2,043.5	0.9	6.10	1	1	1
11/17/2021 06:00	1.3	12.1	2,228.8	0.9	6.70	1	1	1
11/17/2021 07:00	1.3	12.4	2,137.6	0.9	6.40	1	1	1
11/17/2021 08:00	1.2	13.3	1,959.0	0.9	5.90	1	1	1
11/17/2021 09:00	1.2	13.2	1,948.6	0.9	5.80	1	1	1
11/17/2021 10:00	1.1	13.8	1,551.5	0.9	4.70	1	1	0
11/17/2021 11:00	1.2	13.4	1,887.9	0.9	5.70	1	1	1
11/17/2021 12:00	1.2	13.2	1,955.7	0.9	5.90	1	1	1
11/17/2021 13:00	1.1	13.7	1,513.8	0.9	4.50	1	1	1
11/17/2021 14:00	1.1	13.9	1,467.8	0.9	4.40	1	1	0
11/17/2021 15:00	1.3	13.0	1,946.1	1.0	7.80	1	1	1
11/17/2021 16:00	1.3	12.6	2,069.2	0.9	6.20	1	1	1
11/17/2021 17:00	1.3	12.2	2,158.7	0.9	6.50	1	1	1
11/17/2021 18:00	1.3	12.2	2,172.8	0.9	6.50	1	1	1
11/17/2021 19:00	1.4	12.0	2,218.9	0.9	6.70	1	1	1
11/17/2021 20:00	1.4	12.0	2,225.3	0.9	6.70	1	1	1
11/17/2021 21:00	1.3	12.4	2,120.7	0.9	6.40	1	1	1
11/17/2021 22:00	1.2	13.2	1,950.5	0.9	5.90	1	1	1
11/17/2021 23:00	1.2	13.2	1,954.7	0.9	5.90	1	1	1
Average/Sum#:	1.2	12.9	1,974.9	0.9	144.50 #	24 #	24 #	22 #
Minimum:	1.1	12.0	1,467.8	0.9	4.40	1	1	0
Maximum:	1.4	13.9	2,228.8	1.0	7.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/18/2021 00:00	1.2	13.2	1,951.5	0.9	5.90	1	1	1
11/18/2021 01:00	1.2	13.2	1,953.1	0.9	5.90	1	1	1
11/18/2021 02:00	1.2	13.2	1,954.5	0.9	5.90	1	1	1
11/18/2021 03:00	1.2	13.2	1,957.9	0.9	5.90	1	1	1
11/18/2021 04:00	1.2	13.2	1,958.0	0.9	5.90	1	1	1
11/18/2021 05:00	1.3	12.7	2,049.3	0.9	6.10	1	1	1
11/18/2021 06:00	1.3	12.3	2,177.5	0.9	6.50	1	1	1
11/18/2021 07:00	1.3	12.4	2,137.5	0.9	6.40	1	1	1
11/18/2021 08:00	1.2	12.8	2,037.1	0.9	6.10	1	1	1
11/18/2021 09:00	1.2	13.2	1,933.0	0.9	5.80	1	1	1
11/18/2021 10:00	1.1	13.8	1,665.8	0.9	5.00	1	1	1
11/18/2021 11:00	1.2	13.1	1,957.5	0.9	5.90	1	1	1
11/18/2021 12:00	1.2	13.1	1,955.1	0.9	5.90	1	1	1
11/18/2021 13:00	1.1	13.7	1,528.5	0.9	4.60	1	1	1
11/18/2021 14:00	1.1	13.9	1,504.3	0.9	4.50	1	1	0
11/18/2021 15:00	1.2	13.5	1,836.7	1.0	7.30	1	1	1
11/18/2021 16:00	1.3	12.3	2,132.9	0.9	6.40	1	1	1
11/18/2021 17:00	1.4	12.1	2,173.0	0.9	6.50	1	1	1
11/18/2021 18:00	1.4	11.8	2,264.0	0.9	6.80	1	1	1
11/18/2021 19:00	1.3	12.1	2,176.4	0.9	6.50	1	1	1
11/18/2021 20:00	1.3	12.4	2,107.9	0.9	6.30	1	1	1
11/18/2021 21:00	1.2	13.0	1,974.8	0.9	5.90	1	1	1
11/18/2021 22:00	1.2	13.2	1,942.5	0.9	5.80	1	1	1
11/18/2021 23:00	1.2	13.2	1,941.6	0.9	5.80	1	1	1
Average/Sum#:	1.2	12.9	1,969.6	0.9	143.60 #	24 #	24 #	23 #
Minimum:	1.1	11.8	1,504.3	0.9	4.50	1	1	0
Maximum:	1.4	13.9	2,264.0	1.0	7.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/19/2021 00:00	1.2	13.2	1,940.1	0.9	5.80	1	1	1
11/19/2021 01:00	1.2	13.2	1,917.3	0.9	5.80	1	1	1
11/19/2021 02:00	1.0	13.8	1,638.8	0.8	4.90	1	1	0
11/19/2021 03:00	1.2	13.1	1,950.0	0.9	5.90	1	1	1
11/19/2021 04:00	1.3	12.7	2,041.1	0.9	6.10	1	1	1
11/19/2021 05:00	1.3	12.5	2,087.2	0.9	6.30	1	1	1
11/19/2021 06:00	1.3	12.3	2,141.1	0.9	6.40	1	1	1
11/19/2021 07:00	1.3	12.4	2,117.1	0.9	6.40	1	1	1
11/19/2021 08:00	1.2	13.0	1,984.3	0.9	6.00	1	1	1
11/19/2021 09:00	1.2	13.1	1,951.1	0.9	5.90	1	1	1
11/19/2021 10:00	1.2	13.1	1,951.2	0.9	5.90	1	1	1
11/19/2021 11:00	1.2	13.0	1,980.8	0.9	5.90	1	1	1
11/19/2021 12:00	1.2	13.0	1,976.8	0.9	5.90	1	1	1
11/19/2021 13:00	1.3	12.4	2,120.2	0.9	6.40	1	1	1
11/19/2021 14:00	1.3	12.4	2,116.6	0.9	6.30	1	1	1
11/19/2021 15:00	1.3	12.7	2,029.8	0.9	6.10	1	1	1
11/19/2021 16:00	1.3	12.6	2,057.4	0.9	6.20	1	1	1
11/19/2021 17:00	1.3	12.6	2,070.8	0.9	6.20	1	1	1
11/19/2021 18:00	1.3	12.6	2,080.5	0.9	6.20	1	1	1
11/19/2021 19:00	1.2	13.1	1,946.7	0.9	5.80	1	1	1
11/19/2021 20:00	1.1	13.8	1,684.6	0.9	5.10	1	1	0
11/19/2021 21:00	1.1	13.8	1,765.6	0.9	5.30	1	1	1
11/19/2021 22:00	1.2	13.0	1,998.7	0.9	6.00	1	1	1
11/19/2021 23:00	1.2	13.0	1,979.3	0.9	5.90	1	1	1
Average/Sum#:	1.2	12.9	1,980.3	0.9	142.70 #	24 #	24 #	22 #
Minimum:	1.0	12.3	1,638.8	0.8	4.90	1	1	0
Maximum:	1.3	13.8	2,141.1	0.9	6.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/20/2021 00:00	1.2	13.2	1,937.5	0.9	5.80	1	1	1
11/20/2021 01:00	1.1	13.9	1,586.2	0.9	4.80	1	1	0
11/20/2021 02:00	1.1	13.9	1,551.2	0.9	4.70	1	1	0
11/20/2021 03:00	1.1	13.9	1,549.8	0.9	4.60	1	1	0
11/20/2021 04:00	1.1	13.8	1,702.1	0.9	5.10	1	1	1
11/20/2021 05:00	1.2	12.6	2,052.9	0.9	6.20	1	1	1
11/20/2021 06:00	1.2	12.9	2,007.6	0.9	6.00	1	1	1
11/20/2021 07:00	1.1	13.9	1,648.4	0.9	4.90	1	1	0
11/20/2021 08:00	1.1	13.9	1,660.5	0.9	5.00	1	1	0
11/20/2021 09:00	1.1	13.9	1,472.2	0.9	4.40	1	1	0
11/20/2021 10:00	1.1	13.9	1,518.7	0.9	4.60	1	1	0
11/20/2021 11:00	1.1	13.9	1,591.4	0.9	4.80	1	1	0
11/20/2021 12:00	1.1	14.0	1,453.4	0.9	4.40	1	1	0
11/20/2021 13:00	1.1	14.0	1,488.4	0.9	4.50	1	1	0
11/20/2021 14:00	1.1	13.9	1,506.0	0.9	4.50	1	1	0
11/20/2021 15:00	1.1	13.8	1,618.3	0.9	4.90	1	1	1
11/20/2021 16:00	1.3	12.7	2,033.1	0.9	6.10	1	1	1
11/20/2021 17:00	1.3	12.6	2,073.9	0.9	6.20	1	1	1
11/20/2021 18:00	1.2	13.0	1,956.5	0.9	5.90	1	1	1
11/20/2021 19:00	1.0	13.9	1,711.1	0.8	5.10	1	1	0
11/20/2021 20:00	1.1	13.7	1,799.7	0.9	5.40	1	1	0
11/20/2021 21:00	1.3	12.8	2,045.9	0.9	6.10	1	1	1
11/20/2021 22:00	1.3	12.3	2,136.6	0.9	6.40	1	1	1
11/20/2021 23:00	1.2	13.2	1,878.6	0.9	5.60	1	1	1
Average/Sum#:	1.2	13.5	1,749.2	0.9	126.00 #	24 #	24 #	11 #
Minimum:	1.0	12.3	1,453.4	0.8	4.40	1	1	0
Maximum:	1.3	14.0	2,136.6	0.9	6.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/21/2021 00:00	1.1	13.8	1,748.0	0.9	5.20	1	1	1
11/21/2021 01:00	1.2	13.2	1,955.7	0.9	5.90	1	1	1
11/21/2021 02:00	1.9	14.2	1,408.9	1.7	8.08	1	0	1
11/21/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/21/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/21/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/21/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/21/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/21/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/21/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/21/2021 10:00	16.8	18.4	253.9	39.6	10.39	1	0	0
11/21/2021 11:00	16.1	16.1	733.3	19.8	53.50	1	0	0
11/21/2021 12:00	1.0	14.0	1,409.2	0.9	4.20	1	1	0
11/21/2021 13:00	1.5	14.0	1,373.1	1.3	6.90	1	1	0
11/21/2021 14:00	1.7	13.9	1,636.0	1.4	8.20	1	1	0
11/21/2021 15:00	1.0	13.9	1,607.2	0.8	4.80	1	1	0
11/21/2021 16:00	1.1	14.0	1,332.1	0.9	4.00	1	1	0
11/21/2021 17:00	1.1	13.9	1,586.5	0.9	4.80	1	1	1
11/21/2021 18:00	1.3	12.7	2,050.3	0.9	6.20	1	1	1
11/21/2021 19:00	1.3	12.5	2,062.8	0.9	6.20	1	1	1
11/21/2021 20:00	1.0	13.9	1,693.0	0.8	5.10	1	1	0
11/21/2021 21:00	1.1	13.7	1,793.9	0.9	5.40	1	1	0
11/21/2021 22:00	1.2	13.1	1,999.1	0.9	6.00	1	1	1
11/21/2021 23:00	1.1	13.5	1,699.9	0.9	5.10	1	1	1
Average/Sum#:	3.0	14.0	1,549.6	4.4	149.97 #	17 #	14 #	8 #
Minimum:	1.0	12.5	253.9	0.8	4.00	0	0	0
Maximum:	16.8	18.4	2,062.8	39.6	53.50	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/22/2021 00:00	1.1	13.9	1,388.2	0.9	4.20	1	1	0
11/22/2021 01:00	1.1	13.9	1,359.8	0.9	4.10	1	1	0
11/22/2021 02:00	1.1	13.9	1,375.9	0.9	4.10	1	1	0
11/22/2021 03:00	1.1	13.9	1,498.2	0.9	4.50	1	1	0
11/22/2021 04:00	1.1	13.9	1,439.4	0.9	4.30	1	1	0
11/22/2021 05:00	1.1	13.9	1,498.7	0.9	4.50	1	1	1
11/22/2021 06:00	1.2	13.2	1,984.3	0.9	6.00	1	1	1
11/22/2021 07:00	1.2	13.0	2,002.3	0.9	6.00	1	1	1
11/22/2021 08:00	1.1	13.9	1,464.6	0.9	4.40	1	1	0
11/22/2021 09:00	1.1	13.9	1,395.8	0.9	4.20	1	1	0
11/22/2021 10:00	1.1	13.9	1,377.3	0.9	4.10	1	1	0
11/22/2021 11:00	1.1	13.9	1,383.5	0.9	4.20	1	1	0
11/22/2021 12:00	1.1	13.8	1,736.8	0.9	5.20	1	1	0
11/22/2021 13:00	1.1	13.9	1,519.6	0.9	4.60	1	1	0
11/22/2021 14:00	1.1	13.9	1,706.3	0.9	5.10	1	1	0
11/22/2021 15:00	1.1	13.9	1,746.7	0.9	5.20	1	1	0
11/22/2021 16:00	1.2	13.0	1,957.7	0.9	5.90	1	1	1
11/22/2021 17:00	1.3	12.6	2,071.8	0.9	6.20	1	1	1
11/22/2021 18:00	1.3	12.0	2,184.5	0.9	6.60	1	1	1
11/22/2021 19:00	1.4	12.1	2,169.6	0.9	6.50	1	1	1
11/22/2021 20:00	1.3	12.2	2,130.1	0.9	6.40	1	1	1
11/22/2021 21:00	1.1	13.8	1,646.2	0.9	4.90	1	1	0
11/22/2021 22:00	1.1	13.8	1,815.4	0.9	5.40	1	1	1
11/22/2021 23:00	1.3	12.8	2,045.2	0.9	6.10	1	1	1
Average/Sum#:	1.2	13.5	1,704.1	0.9	122.70 #	24 #	24 #	10 #
Minimum:	1.1	12.0	1,359.8	0.9	4.10	1	1	0
Maximum:	1.4	13.9	2,184.5	0.9	6.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/23/2021 00:00	1.2	13.1	1,950.0	0.9	5.90	1	1	1
11/23/2021 01:00	1.1	13.9	1,505.4	0.9	4.50	1	1	0
11/23/2021 02:00	1.1	13.8	1,714.3	0.9	5.10	1	1	1
11/23/2021 03:00	1.2	13.2	1,965.3	0.9	5.90	1	1	1
11/23/2021 04:00	1.2	13.2	1,937.8	0.9	5.80	1	1	1
11/23/2021 05:00	1.0	13.8	1,689.2	0.8	5.10	1	1	0
11/23/2021 06:00	1.1	13.8	1,632.8	0.9	4.90	1	1	0
11/23/2021 07:00	1.2	13.0	2,003.7	0.9	6.00	1	1	1
11/23/2021 08:00	1.2	12.9	1,995.3	0.9	6.00	1	1	1
11/23/2021 09:00	1.1	13.8	1,629.9	0.9	4.90	1	1	0
11/23/2021 10:00	1.1	13.8	1,573.2	0.9	4.70	1	1	0
11/23/2021 11:00	1.1	13.9	1,509.4	0.9	4.50	1	1	0
11/23/2021 12:00	1.1	13.9	1,395.1	0.9	4.20	1	1	0
11/23/2021 13:00	1.1	13.9	1,565.8	0.9	4.70	1	1	0
11/23/2021 14:00	1.1	13.9	1,667.1	0.9	5.00	1	1	0
11/23/2021 15:00	1.1	13.8	1,624.2	0.9	4.90	1	1	1
11/23/2021 16:00	1.3	12.7	2,056.8	0.9	6.20	1	1	1
11/23/2021 17:00	1.3	12.6	2,079.4	0.9	6.20	1	1	1
11/23/2021 18:00	1.3	12.6	2,086.0	0.9	6.30	1	1	1
11/23/2021 19:00	1.2	13.1	1,949.4	0.9	5.80	1	1	1
11/23/2021 20:00	1.1	13.9	1,709.1	0.9	5.10	1	1	0
11/23/2021 21:00	1.1	13.9	1,579.6	0.9	4.70	1	1	1
11/23/2021 22:00	1.3	12.8	2,056.5	0.9	6.20	1	1	1
11/23/2021 23:00	1.2	13.1	1,965.6	0.9	5.90	1	1	1
Average/Sum#:	1.2	13.4	1,785.0	0.9	128.50 #	24 #	24 #	14 #
Minimum:	1.0	12.6	1,395.1	0.8	4.20	1	1	0
Maximum:	1.3	13.9	2,086.0	0.9	6.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/24/2021 00:00	1.2	13.2	1,944.3	0.9	5.80	1	1	1
11/24/2021 01:00	1.1	13.9	1,515.5	0.9	4.50	1	1	0
11/24/2021 02:00	1.0	13.8	1,609.8	0.8	4.80	1	1	1
11/24/2021 03:00	1.2	13.2	1,968.4	0.9	5.90	1	1	1
11/24/2021 04:00	1.2	13.1	1,967.3	0.9	5.90	1	1	1
11/24/2021 05:00	1.0	13.9	1,680.8	0.8	5.00	1	1	0
11/24/2021 06:00	1.1	13.8	1,609.5	0.9	4.80	1	1	1
11/24/2021 07:00	1.2	13.0	2,002.5	0.9	6.00	1	1	1
11/24/2021 08:00	1.2	13.1	1,955.1	0.9	5.90	1	1	1
11/24/2021 09:00	1.1	13.9	1,665.4	0.9	5.00	1	1	0
11/24/2021 10:00	1.1	13.9	1,629.1	0.9	4.90	1	1	0
11/24/2021 11:00	1.1	13.9	1,695.9	0.9	5.10	1	1	0
11/24/2021 12:00	1.1	13.9	1,611.6	0.9	4.80	1	1	0
11/24/2021 13:00	1.1	13.9	1,641.9	0.9	4.90	1	1	0
11/24/2021 14:00	1.1	13.9	1,622.1	0.9	4.90	1	1	0
11/24/2021 15:00	1.1	13.8	1,690.0	0.9	5.10	1	1	1
11/24/2021 16:00	1.3	12.9	2,010.3	1.0	8.00	1	1	1
11/24/2021 17:00	1.3	12.7	2,053.3	0.9	6.20	1	1	1
11/24/2021 18:00	1.3	12.6	2,071.3	0.9	6.20	1	1	1
11/24/2021 19:00	1.3	12.7	2,023.1	0.9	6.10	1	1	1
11/24/2021 20:00	1.1	13.9	1,607.9	0.9	4.80	1	1	0
11/24/2021 21:00	1.1	13.8	1,754.6	0.9	5.30	1	1	1
11/24/2021 22:00	1.2	13.0	1,985.5	0.9	6.00	1	1	1
11/24/2021 23:00	1.2	13.2	1,920.1	0.9	5.80	1	1	1
Average/Sum#:	1.2	13.5	1,801.5	0.9	131.70 #	24 #	24 #	15 #
Minimum:	1.0	12.6	1,515.5	0.8	4.50	1	1	0
Maximum:	1.3	13.9	2,071.3	1.0	8.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/25/2021 00:00	4.4	15.8	577.1	5.1	2.53	1	0	0
11/25/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	4.4	15.8	577.1	5.1	2.53 #	1 #	0 #	0 #
Minimum:	4.4	15.8	577.1	5.1	2.53	0	0	0
Maximum:	4.4	15.8	577.1	5.1	2.53	1	0	0
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/26/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/27/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/28/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/29/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/29/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/29/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/29/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/29/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/29/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/29/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/29/2021 07:00	9.4	19.1	132.4	30.8	2.57	1	0	0
11/29/2021 08:00	30.8	17.2	373.8	49.1	67.70	1	0	0
11/29/2021 09:00	4.6	17.3	386.4	7.5	10.80	1	0	0
11/29/2021 10:00	7.4	16.7	571.3	10.4	21.70	1	0	0
11/29/2021 11:00	9.9	15.3	934.5	10.4	35.50	1	0	0
11/29/2021 12:00	0.9	13.9	1,369.2	0.8	4.10	1	1	0
11/29/2021 13:00	1.1	13.9	1,363.4	0.9	4.10	1	1	0
11/29/2021 14:00	1.1	13.8	1,623.3	0.9	4.90	1	1	0
11/29/2021 15:00	1.1	13.8	1,587.4	0.9	4.80	1	1	0
11/29/2021 16:00	1.1	13.7	1,703.6	0.9	5.10	1	1	0
11/29/2021 17:00	1.3	12.7	1,956.3	0.9	5.90	1	1	1
11/29/2021 18:00	1.3	12.2	2,108.8	0.9	6.30	1	1	1
11/29/2021 19:00	1.3	12.5	2,044.0	0.9	6.10	1	1	1
11/29/2021 20:00	1.1	13.8	1,663.4	0.9	5.00	1	1	1
11/29/2021 21:00	1.1	13.7	1,792.3	0.9	5.40	1	1	1
11/29/2021 22:00	1.2	12.9	1,987.5	0.9	6.00	1	1	1
11/29/2021 23:00	2.7	14.3	1,216.7	2.4	5.17	1	0	1
Average/Sum#:	4.6	14.5	1,342.0	7.1	201.14 #	17 #	11 #	7 #
Minimum:	0.9	12.2	132.4	0.8	2.57	0	0	0
Maximum:	30.8	19.1	2,108.8	49.1	67.70	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/30/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/30/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/30/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/30/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/30/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/30/2021 05:00	7.0	18.3	259.4	15.9	4.28	1	0	0
11/30/2021 06:00	8.6	16.1	731.3	10.6	28.50	1	0	0
11/30/2021 07:00	1.0	13.9	1,335.2	0.8	4.00	1	1	0
11/30/2021 08:00	1.1	13.9	1,308.0	0.9	3.90	1	1	0
11/30/2021 09:00	1.1	13.9	1,307.4	0.9	3.90	1	1	0
11/30/2021 10:00	1.1	13.9	1,239.1	0.9	3.70	1	1	0
11/30/2021 11:00	1.1	13.9	1,236.7	0.9	3.70	1	1	0
11/30/2021 12:00	1.1	13.9	1,402.9	0.9	4.20	1	1	0
11/30/2021 13:00	1.1	13.9	1,474.7	0.9	4.40	1	1	0
11/30/2021 14:00	1.1	13.9	1,602.8	0.9	4.80	1	1	0
11/30/2021 15:00	1.1	13.9	1,745.5	0.9	5.20	1	1	0
11/30/2021 16:00	1.1	13.9	1,745.1	0.9	5.20	1	1	0
11/30/2021 17:00	1.1	13.9	1,744.5	0.9	5.20	1	1	0
11/30/2021 18:00	1.1	13.9	1,743.7	0.9	5.20	1	1	0
11/30/2021 19:00	1.1	13.9	1,736.0	0.9	5.20	1	1	0
11/30/2021 20:00	1.1	13.9	1,724.4	0.9	5.20	1	1	0
11/30/2021 21:00	1.1	13.9	1,727.3	0.9	5.20	1	1	0
11/30/2021 22:00	1.1	13.9	1,742.6	0.9	5.20	1	1	0
11/30/2021 23:00	1.2	13.1	1,951.3	0.9	5.90	1	1	1
Average/Sum#:	1.8	14.2	1,460.9	2.2	112.88 #	19 #	17 #	1 #
Minimum:	1.0	13.1	259.4	0.8	3.70	0	0	0
Maximum:	8.6	18.3	1,951.3	15.9	28.50	1	1	1
%SI	20.83	20.83	20.83	20.83	20.83	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/01/2021 00:00	1.2	13.1	1,953.1	0.9	5.90	1	1	1
12/01/2021 01:00	1.1	13.8	1,511.9	0.9	4.50	1	1	1
12/01/2021 02:00	1.1	13.9	1,312.6	0.9	3.90	1	1	0
12/01/2021 03:00	1.1	13.8	1,721.4	0.9	5.20	1	1	0
12/01/2021 04:00	1.2	13.5	1,846.0	1.0	7.40	1	1	1
12/01/2021 05:00	1.1	13.3	1,855.6	0.9	5.60	1	1	1
12/01/2021 06:00	1.1	13.5	1,705.5	0.9	5.10	1	1	1
12/01/2021 07:00	1.4	12.0	2,228.2	0.9	6.70	1	1	1
12/01/2021 08:00	1.4	11.8	2,250.2	0.9	6.80	1	1	1
12/01/2021 09:00	1.3	11.9	2,237.8	0.9	6.70	1	1	1
12/01/2021 10:00	1.4	11.7	2,248.5	0.9	6.70	1	1	1
12/01/2021 11:00	1.3	11.6	2,257.4	0.8	6.80	1	1	1
12/01/2021 12:00	1.4	11.5	2,278.4	0.9	6.80	1	1	1
12/01/2021 13:00	1.4	11.5	2,274.0	0.9	6.80	1	1	1
12/01/2021 14:00	1.4	11.5	2,277.2	0.9	6.80	1	1	1
12/01/2021 15:00	1.4	11.5	2,264.4	0.9	6.80	1	1	1
12/01/2021 16:00	1.4	11.5	2,266.3	0.9	6.80	1	1	1
12/01/2021 17:00	1.4	11.5	2,269.2	0.9	6.80	1	1	1
12/01/2021 18:00	1.4	11.5	2,270.4	0.9	6.80	1	1	1
12/01/2021 19:00	1.4	11.6	2,257.4	0.9	6.80	1	1	1
12/01/2021 20:00	1.3	12.2	2,151.0	0.9	6.50	1	1	1
12/01/2021 21:00	1.3	12.3	2,116.7	0.9	6.40	1	1	1
12/01/2021 22:00	1.3	12.6	2,064.1	0.9	6.20	1	1	1
12/01/2021 23:00	1.2	13.1	1,941.5	0.9	5.80	1	1	1
Average/Sum#:	1.3	12.3	2,065.0	0.9	150.60 #	24 #	24 #	22 #
Minimum:	1.1	11.5	1,312.6	0.8	3.90	1	1	0
Maximum:	1.4	13.9	2,278.4	1.0	7.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/02/2021 00:00	2.6	14.5	1,197.3	2.4	5.40	1	0	1
12/02/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2021 06:00	7.4	17.5	413.3	12.8	13.00	1	0	0
12/02/2021 07:00	5.0	14.3	1,176.4	4.5	18.80	1	0	0
12/02/2021 08:00	1.4	13.9	1,353.2	1.2	5.40	1	1	0
12/02/2021 09:00	1.8	13.9	1,386.4	1.5	8.30	1	1	0
12/02/2021 10:00	1.9	13.8	1,516.9	1.6	9.10	1	1	0
12/02/2021 11:00	1.8	13.9	1,580.5	1.5	9.50	1	1	0
12/02/2021 12:00	1.8	13.7	1,697.6	1.5	8.50	1	1	0
12/02/2021 13:00	1.7	13.6	1,797.2	1.4	9.00	1	1	0
12/02/2021 14:00	0.0	0.0	1,792.4	0.0	0.00	1	1	0
12/02/2021 15:00	1.0	13.7	1,787.0	0.8	5.40	1	1	0
12/02/2021 16:00	1.1	13.6	1,789.1	0.9	5.40	1	1	0
12/02/2021 17:00	1.1	13.6	1,788.2	0.9	5.40	1	1	0
12/02/2021 18:00	1.1	13.6	1,786.4	0.9	5.40	1	1	0
12/02/2021 19:00	1.1	13.6	1,787.4	0.9	5.40	1	1	0
12/02/2021 20:00	1.2	13.7	1,776.1	1.0	7.10	1	1	0
12/02/2021 21:00	1.2	13.1	1,925.5	0.9	5.80	1	1	1
12/02/2021 22:00	1.3	12.6	2,031.9	0.9	6.10	1	1	1
12/02/2021 23:00	1.2	13.2	1,890.4	0.9	5.70	1	1	1
Average/Sum#:	2.0	13.9	1,603.9	2.0	138.70 #	19 #	16 #	4 #
Minimum:	1.0	12.6	413.3	0.8	5.40	0	0	0
Maximum:	7.4	17.5	2,031.9	12.8	18.80	1	1	1
%SI	25.00	25.00	20.83	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/03/2021 00:00	1.1	13.9	1,352.5	0.9	4.10	1	1	0
12/03/2021 01:00	1.1	13.9	1,349.1	0.9	4.00	1	1	0
12/03/2021 02:00	1.1	13.9	1,359.2	0.9	4.10	1	1	0
12/03/2021 03:00	1.1	13.8	1,637.6	0.9	4.90	1	1	0
12/03/2021 04:00	1.1	13.8	1,622.4	0.9	4.90	1	1	0
12/03/2021 05:00	1.2	13.9	1,424.8	1.0	5.70	1	1	0
12/03/2021 06:00	1.1	13.8	1,634.2	0.9	4.90	1	1	0
12/03/2021 07:00	1.1	13.8	1,892.2	0.9	5.70	1	1	1
12/03/2021 08:00	1.4	11.9	2,218.9	0.9	6.70	1	1	1
12/03/2021 09:00	1.4	11.9	2,236.2	0.9	6.70	1	1	1
12/03/2021 10:00	1.4	11.8	2,247.0	0.9	6.70	1	1	1
12/03/2021 11:00	1.4	11.7	2,250.2	0.9	6.80	1	1	1
12/03/2021 12:00	1.4	11.7	2,250.8	0.9	6.80	1	1	1
12/03/2021 13:00	1.5	11.7	2,257.2	1.0	9.00	1	1	1
12/03/2021 14:00	1.5	11.7	2,256.8	1.0	9.00	1	1	1
12/03/2021 15:00	1.4	11.6	2,251.8	0.9	6.80	1	1	1
12/03/2021 16:00	1.3	12.8	1,925.7	0.9	5.80	1	1	1
12/03/2021 17:00	1.2	13.5	1,818.3	1.0	7.30	1	1	0
12/03/2021 18:00	1.2	13.6	1,817.4	1.0	7.30	1	1	0
12/03/2021 19:00	1.2	13.6	1,820.6	1.0	7.30	1	1	1
12/03/2021 20:00	1.2	12.8	1,993.5	0.9	6.00	1	1	1
12/03/2021 21:00	1.3	12.3	2,117.7	0.9	6.40	1	1	1
12/03/2021 22:00	1.4	12.4	2,113.3	1.0	8.50	1	1	1
12/03/2021 23:00	1.8	13.6	1,606.5	1.5	8.00	1	0	1
Average/Sum#:	1.3	12.9	1,893.9	1.0	153.40 #	24 #	23 #	15 #
Minimum:	1.1	11.6	1,349.1	0.9	4.00	1	0	0
Maximum:	1.8	13.9	2,257.2	1.5	9.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/04/2021 00:00	0.1	19.4	0.2	0.4	0.00	1	0	0
12/04/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2021 03:00	0.2	18.7	198.1	0.5	0.07	1	0	0
12/04/2021 04:00	4.2	15.6	853.7	4.7	14.50	1	0	0
12/04/2021 05:00	1.1	13.7	1,609.8	0.9	4.80	1	1	0
12/04/2021 06:00	1.2	13.2	1,826.8	0.9	5.50	1	1	1
12/04/2021 07:00	1.3	13.0	1,878.9	1.0	7.50	1	1	1
12/04/2021 08:00	1.2	13.5	1,861.7	1.0	7.40	1	1	0
12/04/2021 09:00	1.2	13.5	1,859.1	1.0	7.40	1	1	0
12/04/2021 10:00	1.1	13.8	1,800.3	0.9	5.40	1	1	0
12/04/2021 11:00	1.2	13.8	1,802.6	1.0	7.20	1	1	0
12/04/2021 12:00	1.2	13.8	1,647.7	1.0	6.60	1	1	0
12/04/2021 13:00	1.1	13.8	1,477.2	0.9	4.40	1	1	0
12/04/2021 14:00	1.1	13.9	1,371.9	0.9	4.10	1	1	0
12/04/2021 15:00	1.1	13.7	1,645.5	0.9	4.90	1	1	0
12/04/2021 16:00	1.1	13.8	1,577.4	0.9	4.70	1	1	0
12/04/2021 17:00	1.1	13.8	1,723.5	0.9	5.20	1	1	0
12/04/2021 18:00	1.2	13.2	1,928.9	0.9	5.80	1	1	1
12/04/2021 19:00	1.2	13.3	1,852.4	0.9	5.60	1	1	1
12/04/2021 20:00	1.2	13.8	1,634.1	1.0	6.50	1	1	0
12/04/2021 21:00	1.1	13.8	1,623.1	0.9	4.90	1	1	0
12/04/2021 22:00	1.1	13.8	1,603.5	0.9	4.80	1	1	0
12/04/2021 23:00	2.9	16.1	424.5	3.6	0.99	1	0	0
Average/Sum#:	1.3	14.3	1,463.7	1.2	118.26 #	22 #	18 #	4 #
Minimum:	0.1	13.0	0.2	0.4	0.00	0	0	0
Maximum:	4.2	19.4	1,928.9	4.7	14.50	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/05/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/05/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/05/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/05/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/05/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/05/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/05/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/05/2021 07:00	14.5	17.6	360.0	25.9	24.91	1	0	0
12/05/2021 08:00	9.6	15.4	865.3	10.3	32.90	1	0	0
12/05/2021 09:00	1.1	13.8	1,564.6	0.9	4.70	1	1	0
12/05/2021 10:00	1.1	13.8	1,545.5	0.9	4.60	1	1	0
12/05/2021 11:00	1.1	13.8	1,383.1	0.9	4.10	1	1	0
12/05/2021 12:00	1.1	13.8	1,372.4	0.9	4.10	1	1	0
12/05/2021 13:00	1.2	13.7	1,746.1	1.0	7.00	1	1	0
12/05/2021 14:00	1.1	13.8	1,535.4	0.9	4.60	1	1	0
12/05/2021 15:00	1.1	13.8	1,682.4	0.9	5.00	1	1	0
12/05/2021 16:00	1.1	13.8	1,614.5	0.9	4.80	1	1	1
12/05/2021 17:00	1.3	12.9	1,990.9	1.0	8.00	1	1	1
12/05/2021 18:00	1.3	12.4	2,125.6	0.9	6.40	1	1	1
12/05/2021 19:00	1.4	12.2	2,150.2	0.9	6.50	1	1	1
12/05/2021 20:00	1.4	11.9	2,244.0	0.9	6.70	1	1	1
12/05/2021 21:00	1.4	12.1	2,188.7	0.9	6.60	1	1	1
12/05/2021 22:00	1.4	12.1	2,183.1	0.9	6.50	1	1	1
12/05/2021 23:00	1.3	12.5	2,100.5	0.9	6.30	1	1	1
Average/Sum#:	2.5	13.5	1,685.4	2.9	143.71 #	17 #	15 #	8 #
Minimum:	1.1	11.9	360.0	0.9	4.10	0	0	0
Maximum:	14.5	17.6	2,244.0	25.9	32.90	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/06/2021 00:00	1.3	12.9	1,993.5	1.0	8.00	1	1	1
12/06/2021 01:00	1.1	13.8	1,715.2	0.9	5.10	1	1	0
12/06/2021 02:00	1.2	13.7	1,766.3	1.0	7.10	1	1	1
12/06/2021 03:00	1.2	13.1	1,982.0	0.9	5.90	1	1	1
12/06/2021 04:00	1.3	13.0	1,965.8	1.0	7.90	1	1	1
12/06/2021 05:00	1.2	13.8	1,650.8	1.0	6.60	1	1	0
12/06/2021 06:00	1.2	13.2	1,898.0	0.9	5.70	1	1	1
12/06/2021 07:00	1.4	12.2	2,191.1	0.9	6.60	1	1	1
12/06/2021 08:00	1.4	12.1	2,192.7	0.9	6.60	1	1	1
12/06/2021 09:00	1.2	13.5	1,737.7	1.0	7.00	1	1	1
12/06/2021 10:00	1.1	13.8	1,795.1	0.9	5.40	1	1	0
12/06/2021 11:00	1.3	12.9	2,018.7	1.0	8.10	1	1	1
12/06/2021 12:00	1.4	12.1	2,201.3	0.9	6.60	1	1	1
12/06/2021 13:00	1.3	12.8	1,934.7	0.9	5.80	1	1	1
12/06/2021 14:00	1.1	13.8	1,651.5	0.9	5.00	1	1	0
12/06/2021 15:00	1.2	13.4	1,850.3	0.9	5.60	1	1	1
12/06/2021 16:00	1.3	12.6	2,090.0	0.9	6.30	1	1	1
12/06/2021 17:00	1.3	12.4	2,130.7	0.9	6.40	1	1	1
12/06/2021 18:00	1.4	11.9	2,230.7	0.9	6.70	1	1	1
12/06/2021 19:00	1.4	12.1	2,182.1	0.9	6.50	1	1	1
12/06/2021 20:00	1.4	12.0	2,211.0	0.9	6.60	1	1	1
12/06/2021 21:00	1.3	12.3	2,135.6	0.9	6.40	1	1	1
12/06/2021 22:00	1.3	12.3	2,132.6	0.9	6.40	1	1	1
12/06/2021 23:00	1.3	12.3	2,137.3	0.9	6.40	1	1	1
Average/Sum#:	1.3	12.8	1,991.4	0.9	154.70 #	24 #	24 #	20 #
Minimum:	1.1	11.9	1,650.8	0.9	5.00	1	1	0
Maximum:	1.4	13.8	2,230.7	1.0	8.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/07/2021 00:00	1.3	12.5	2,090.9	0.9	6.30	1	1	1
12/07/2021 01:00	1.1	13.7	1,537.4	0.9	4.60	1	1	1
12/07/2021 02:00	1.1	13.7	1,699.9	0.9	5.10	1	1	1
12/07/2021 03:00	1.2	13.1	1,962.6	0.9	5.90	1	1	1
12/07/2021 04:00	1.3	12.4	2,121.0	0.9	6.40	1	1	1
12/07/2021 05:00	1.1	13.8	1,730.5	0.9	5.20	1	1	1
12/07/2021 06:00	1.1	13.8	1,653.3	0.9	5.00	1	1	0
12/07/2021 07:00	1.3	13.0	1,981.9	1.0	7.90	1	1	1
12/07/2021 08:00	1.4	12.0	2,214.4	0.9	6.60	1	1	1
12/07/2021 09:00	1.4	12.3	2,109.3	1.0	8.40	1	1	1
12/07/2021 10:00	1.2	13.6	1,821.3	1.0	7.30	1	1	0
12/07/2021 11:00	1.2	13.7	1,800.1	1.0	7.20	1	1	0
12/07/2021 12:00	1.2	13.6	1,812.2	1.0	7.20	1	1	0
12/07/2021 13:00	1.2	13.6	1,793.7	1.0	7.20	1	1	1
12/07/2021 14:00	1.3	12.4	2,078.9	0.9	6.20	1	1	1
12/07/2021 15:00	1.4	11.7	2,214.0	0.9	6.60	1	1	1
12/07/2021 16:00	1.4	11.6	2,246.9	0.9	6.70	1	1	1
12/07/2021 17:00	1.4	11.8	2,229.1	0.9	6.70	1	1	1
12/07/2021 18:00	1.4	11.8	2,240.7	0.9	6.70	1	1	1
12/07/2021 19:00	1.4	11.9	2,222.9	0.9	6.70	1	1	1
12/07/2021 20:00	1.4	11.9	2,220.2	0.9	6.70	1	1	1
12/07/2021 21:00	1.4	11.9	2,209.8	0.9	6.60	1	1	1
12/07/2021 22:00	1.4	12.2	2,138.8	0.9	6.40	1	1	1
12/07/2021 23:00	1.4	12.3	2,130.7	1.0	8.50	1	1	1
Average/Sum#:	1.3	12.7	2,010.9	0.9	158.10 #	24 #	24 #	20 #
Minimum:	1.1	11.6	1,537.4	0.9	4.60	1	1	0
Maximum:	1.4	13.8	2,246.9	1.0	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/08/2021 00:00	1.3	12.5	2,058.6	0.9	6.20	1	1	1
12/08/2021 01:00	1.1	13.8	1,613.9	0.9	4.80	1	1	0
12/08/2021 02:00	1.1	13.8	1,324.6	0.9	4.00	1	1	0
12/08/2021 03:00	1.1	13.7	1,745.4	0.9	5.20	1	1	0
12/08/2021 04:00	1.2	13.4	1,840.6	0.9	5.50	1	1	1
12/08/2021 05:00	1.2	13.3	1,889.0	0.9	5.70	1	1	1
12/08/2021 06:00	1.1	13.7	1,771.3	0.9	5.30	1	1	1
12/08/2021 07:00	1.3	12.9	2,003.1	1.0	8.00	1	1	1
12/08/2021 08:00	1.2	13.1	1,873.7	0.9	5.60	1	1	1
12/08/2021 09:00	1.1	13.8	1,375.8	0.9	4.10	1	1	0
12/08/2021 10:00	1.1	13.8	1,342.7	0.9	4.00	1	1	0
12/08/2021 11:00	1.1	13.7	1,731.0	0.9	5.20	1	1	0
12/08/2021 12:00	1.2	13.3	1,863.0	0.9	5.60	1	1	1
12/08/2021 13:00	1.2	13.3	1,849.3	0.9	5.50	1	1	1
12/08/2021 14:00	1.1	13.8	1,328.4	0.9	4.00	1	1	0
12/08/2021 15:00	1.1	13.8	1,396.1	0.9	4.20	1	1	0
12/08/2021 16:00	1.1	13.7	1,721.3	0.9	5.20	1	1	0
12/08/2021 17:00	1.3	13.0	1,981.0	1.0	7.90	1	1	1
12/08/2021 18:00	1.4	12.2	2,152.7	0.9	6.50	1	1	1
12/08/2021 19:00	1.4	12.2	2,143.1	0.9	6.40	1	1	1
12/08/2021 20:00	1.4	12.2	2,131.3	0.9	6.40	1	1	1
12/08/2021 21:00	1.3	12.5	2,070.2	0.9	6.20	1	1	1
12/08/2021 22:00	1.3	12.6	2,051.4	0.9	6.20	1	1	1
12/08/2021 23:00	1.3	12.5	2,076.9	0.9	6.20	1	1	1
Average/Sum#:	1.2	13.2	1,805.6	0.9	133.90 #	24 #	24 #	15 #
Minimum:	1.1	12.2	1,324.6	0.9	4.00	1	1	0
Maximum:	1.4	13.8	2,152.7	1.0	8.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/09/2021 00:00	1.2	13.0	1,944.8	0.9	5.80	1	1	1
12/09/2021 01:00	1.1	13.8	1,500.7	0.9	4.50	1	1	0
12/09/2021 02:00	1.1	13.7	1,584.5	0.9	4.80	1	1	1
12/09/2021 03:00	1.3	13.0	1,967.9	1.0	7.90	1	1	1
12/09/2021 04:00	1.3	12.8	1,999.0	0.9	6.00	1	1	1
12/09/2021 05:00	1.1	13.8	1,553.7	0.9	4.70	1	1	0
12/09/2021 06:00	1.1	13.7	1,639.6	0.9	4.90	1	1	1
12/09/2021 07:00	1.3	13.0	1,998.5	1.0	8.00	1	1	1
12/09/2021 08:00	1.3	12.7	2,055.2	0.9	6.20	1	1	1
12/09/2021 09:00	1.3	12.7	2,040.3	0.9	6.10	1	1	1
12/09/2021 10:00	1.1	13.7	1,610.1	0.9	4.80	1	1	1
12/09/2021 11:00	1.1	13.8	1,715.0	0.9	5.10	1	1	1
12/09/2021 12:00	1.3	12.8	2,026.3	0.9	6.10	1	1	1
12/09/2021 13:00	1.3	12.8	1,990.8	0.9	6.00	1	1	1
12/09/2021 14:00	1.1	13.9	1,455.5	0.9	4.40	1	1	0
12/09/2021 15:00	1.1	13.8	1,513.7	0.9	4.50	1	1	1
12/09/2021 16:00	1.3	12.9	2,001.4	1.0	8.00	1	1	1
12/09/2021 17:00	1.4	12.3	2,149.9	1.0	8.60	1	1	1
12/09/2021 18:00	1.3	12.4	2,124.3	0.9	6.40	1	1	1
12/09/2021 19:00	1.3	12.3	2,154.1	0.9	6.50	1	1	1
12/09/2021 20:00	1.3	12.3	2,165.9	0.9	6.50	1	1	1
12/09/2021 21:00	1.3	12.3	2,169.5	0.9	6.50	1	1	1
12/09/2021 22:00	1.3	12.9	2,034.6	1.0	8.10	1	1	1
12/09/2021 23:00	1.3	12.7	2,071.8	0.9	6.20	1	1	1
Average/Sum#:	1.2	13.0	1,894.5	0.9	146.60 #	24 #	24 #	21 #
Minimum:	1.1	12.3	1,455.5	0.9	4.40	1	1	0
Maximum:	1.4	13.9	2,169.5	1.0	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/10/2021 00:00	1.2	13.1	1,960.1	0.9	5.90	1	1	1
12/10/2021 01:00	1.1	13.9	1,544.3	0.9	4.60	1	1	0
12/10/2021 02:00	1.1	13.8	1,612.1	0.9	4.80	1	1	0
12/10/2021 03:00	1.2	13.3	1,936.6	0.9	5.80	1	1	1
12/10/2021 04:00	1.2	13.3	1,958.8	0.9	5.90	1	1	1
12/10/2021 05:00	1.0	13.8	1,626.8	0.8	4.90	1	1	0
12/10/2021 06:00	1.1	13.8	1,756.9	0.9	5.30	1	1	1
12/10/2021 07:00	1.2	13.1	1,992.1	0.9	6.00	1	1	1
12/10/2021 08:00	1.2	13.2	1,961.8	0.9	5.90	1	1	1
12/10/2021 09:00	1.1	13.8	1,619.4	0.9	4.90	1	1	0
12/10/2021 10:00	1.1	13.8	1,704.7	0.9	5.10	1	1	0
12/10/2021 11:00	1.1	13.8	1,633.7	0.9	4.90	1	1	0
12/10/2021 12:00	1.1	13.8	1,684.9	0.9	5.10	1	1	0
12/10/2021 13:00	1.1	13.9	1,607.0	0.9	4.80	1	1	0
12/10/2021 14:00	1.1	13.9	1,318.3	0.9	4.00	1	1	0
12/10/2021 15:00	1.1	13.8	1,583.9	0.9	4.80	1	1	0
12/10/2021 16:00	1.2	13.1	1,973.0	0.9	5.90	1	1	1
12/10/2021 17:00	1.4	12.0	2,227.9	0.9	6.70	1	1	1
12/10/2021 18:00	1.4	12.2	2,192.2	0.9	6.60	1	1	1
12/10/2021 19:00	1.3	12.2	2,190.4	0.9	6.60	1	1	1
12/10/2021 20:00	1.4	12.1	2,222.1	0.9	6.70	1	1	1
12/10/2021 21:00	1.3	12.3	2,170.9	0.9	6.50	1	1	1
12/10/2021 22:00	1.3	12.6	2,125.4	0.9	6.40	1	1	1
12/10/2021 23:00	1.3	12.6	2,126.2	0.9	6.40	1	1	1
Average/Sum#:	1.2	13.2	1,863.7	0.9	134.50 #	24 #	24 #	14 #
Minimum:	1.0	12.0	1,318.3	0.8	4.00	1	1	0
Maximum:	1.4	13.9	2,227.9	0.9	6.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/11/2021 00:00	1.3	12.7	2,122.3	0.9	6.40	1	1	1
12/11/2021 01:00	1.3	12.9	2,057.5	1.0	8.20	1	1	1
12/11/2021 02:00	1.2	13.2	1,950.8	0.9	5.90	1	1	1
12/11/2021 03:00	1.1	13.8	1,639.2	0.9	4.90	1	1	0
12/11/2021 04:00	1.1	13.8	1,710.0	0.9	5.10	1	1	1
12/11/2021 05:00	1.4	12.9	2,026.9	1.0	8.10	1	1	1
12/11/2021 06:00	1.3	12.7	2,102.2	0.9	6.30	1	1	1
12/11/2021 07:00	1.3	12.9	2,035.9	1.0	8.10	1	1	1
12/11/2021 08:00	1.1	13.8	1,614.0	0.9	4.80	1	1	0
12/11/2021 09:00	1.1	13.8	1,398.6	0.9	4.20	1	1	0
12/11/2021 10:00	1.1	13.8	1,432.0	0.9	4.30	1	1	0
12/11/2021 11:00	1.1	13.9	1,331.4	0.9	4.00	1	1	0
12/11/2021 12:00	1.1	13.9	1,328.8	0.9	4.00	1	1	0
12/11/2021 13:00	1.1	13.8	1,517.3	0.9	4.60	1	1	0
12/11/2021 14:00	1.1	13.8	1,555.1	0.9	4.70	1	1	0
12/11/2021 15:00	1.1	13.8	1,645.7	0.9	4.90	1	1	0
12/11/2021 16:00	1.3	12.6	2,120.6	0.9	6.40	1	1	1
12/11/2021 17:00	1.4	12.0	2,235.4	0.9	6.70	1	1	1
12/11/2021 18:00	1.4	12.1	2,219.7	0.9	6.70	1	1	1
12/11/2021 19:00	1.4	11.9	2,268.6	0.9	6.80	1	1	1
12/11/2021 20:00	1.4	12.1	2,220.4	0.9	6.70	1	1	1
12/11/2021 21:00	1.4	11.8	2,264.3	0.9	6.80	1	1	1
12/11/2021 22:00	1.4	12.0	2,213.7	0.9	6.60	1	1	1
12/11/2021 23:00	1.3	12.5	2,111.0	0.9	6.30	1	1	1
Average/Sum#:	1.2	13.0	1,880.1	0.9	141.50 #	24 #	24 #	15 #
Minimum:	1.1	11.8	1,328.8	0.9	4.00	1	1	0
Maximum:	1.4	13.9	2,268.6	1.0	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/12/2021 00:00	1.3	12.5	2,099.1	0.9	6.30	1	1	1
12/12/2021 01:00	1.3	12.7	2,050.8	0.9	6.20	1	1	1
12/12/2021 02:00	1.2	13.2	1,934.7	0.9	5.80	1	1	1
12/12/2021 03:00	1.1	13.8	1,610.8	0.9	4.80	1	1	0
12/12/2021 04:00	1.1	13.7	1,745.7	0.9	5.20	1	1	1
12/12/2021 05:00	1.4	12.8	2,014.9	1.0	8.10	1	1	1
12/12/2021 06:00	1.3	12.7	2,045.5	0.9	6.10	1	1	1
12/12/2021 07:00	1.1	13.7	1,634.2	0.9	4.90	1	1	1
12/12/2021 08:00	1.1	13.8	1,606.5	0.9	4.80	1	1	0
12/12/2021 09:00	1.1	13.8	1,407.3	0.9	4.20	1	1	0
12/12/2021 10:00	1.1	13.8	1,610.9	0.9	4.80	1	1	0
12/12/2021 11:00	1.2	13.7	1,700.3	1.0	6.80	1	1	0
12/12/2021 12:00	1.1	13.8	1,622.6	0.9	4.90	1	1	0
12/12/2021 13:00	1.1	13.8	1,647.7	0.9	4.90	1	1	0
12/12/2021 14:00	1.2	13.8	1,605.2	1.0	6.40	1	1	0
12/12/2021 15:00	1.1	13.7	1,598.0	0.9	4.80	1	1	1
12/12/2021 16:00	1.3	12.5	2,074.5	0.9	6.20	1	1	1
12/12/2021 17:00	1.4	12.1	2,158.6	0.9	6.50	1	1	1
12/12/2021 18:00	1.4	12.1	2,154.4	0.9	6.50	1	1	1
12/12/2021 19:00	1.4	11.8	2,216.5	0.9	6.60	1	1	1
12/12/2021 20:00	1.4	12.1	2,147.3	0.9	6.40	1	1	1
12/12/2021 21:00	1.4	12.1	2,153.4	0.9	6.50	1	1	1
12/12/2021 22:00	1.3	12.3	2,120.5	0.9	6.40	1	1	1
12/12/2021 23:00	1.3	12.5	2,067.2	0.9	6.20	1	1	1
Average/Sum#:	1.2	13.0	1,876.1	0.9	140.30 #	24 #	24 #	16 #
Minimum:	1.1	11.8	1,407.3	0.9	4.20	1	1	0
Maximum:	1.4	13.8	2,216.5	1.0	8.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/13/2021 00:00	1.2	13.0	1,935.9	0.9	5.80	1	1	1
12/13/2021 01:00	1.2	13.7	1,705.2	1.0	6.80	1	1	0
12/13/2021 02:00	1.1	13.7	1,684.2	0.9	5.10	1	1	1
12/13/2021 03:00	1.3	12.7	2,017.7	0.9	6.10	1	1	1
12/13/2021 04:00	1.3	12.9	1,949.1	1.0	7.80	1	1	1
12/13/2021 05:00	1.2	13.8	1,595.8	1.0	6.40	1	1	0
12/13/2021 06:00	1.1	13.6	1,788.5	0.9	5.40	1	1	1
12/13/2021 07:00	1.4	12.4	2,093.5	1.0	8.40	1	1	1
12/13/2021 08:00	1.4	11.9	2,194.6	0.9	6.60	1	1	1
12/13/2021 09:00	1.4	12.0	2,157.9	0.9	6.50	1	1	1
12/13/2021 10:00	1.3	12.2	2,125.1	0.9	6.40	1	1	1
12/13/2021 11:00	1.3	12.6	2,012.1	0.9	6.00	1	1	1
12/13/2021 12:00	1.1	13.8	1,649.6	0.9	4.90	1	1	0
12/13/2021 13:00	1.1	13.6	1,798.6	0.9	5.40	1	1	1
12/13/2021 14:00	1.3	12.5	2,049.8	0.9	6.10	1	1	1
12/13/2021 15:00	1.4	11.7	2,231.9	0.9	6.70	1	1	1
12/13/2021 16:00	1.5	11.5	2,286.9	0.9	6.90	1	1	1
12/13/2021 17:00	1.5	11.4	2,309.3	0.9	6.90	1	1	1
12/13/2021 18:00	1.5	11.4	2,312.4	0.9	6.90	1	1	1
12/13/2021 19:00	1.5	11.5	2,304.5	0.9	6.90	1	1	1
12/13/2021 20:00	1.4	12.0	2,174.8	0.9	6.50	1	1	1
12/13/2021 21:00	1.3	12.3	2,112.6	0.9	6.30	1	1	1
12/13/2021 22:00	1.3	12.6	2,048.9	0.9	6.10	1	1	1
12/13/2021 23:00	1.3	12.6	2,057.9	0.9	6.20	1	1	1
Average/Sum#:	1.3	12.6	2,024.9	0.9	153.10 #	24 #	24 #	21 #
Minimum:	1.1	11.4	1,595.8	0.9	4.90	1	1	0
Maximum:	1.5	13.8	2,312.4	1.0	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/14/2021 00:00	1.2	13.2	1,841.6	0.9	5.50	1	1	1
12/14/2021 01:00	1.1	13.9	1,300.6	0.9	3.90	1	1	0
12/14/2021 02:00	1.1	13.8	1,320.8	0.9	4.00	1	1	0
12/14/2021 03:00	1.1	13.7	1,755.8	0.9	5.30	1	1	0
12/14/2021 04:00	1.2	13.4	1,872.8	0.9	5.60	1	1	1
12/14/2021 05:00	1.2	13.4	1,871.7	0.9	5.60	1	1	1
12/14/2021 06:00	1.1	13.7	1,725.4	0.9	5.20	1	1	1
12/14/2021 07:00	1.3	12.6	2,085.5	0.9	6.30	1	1	1
12/14/2021 08:00	1.3	12.4	2,112.1	0.9	6.30	1	1	1
12/14/2021 09:00	1.3	12.9	1,976.2	1.0	7.90	1	1	1
12/14/2021 10:00	1.1	13.8	1,622.7	0.9	4.90	1	1	0
12/14/2021 11:00	1.1	13.8	1,640.8	0.9	4.90	1	1	1
12/14/2021 12:00	1.3	12.8	2,040.7	0.9	6.10	1	1	1
12/14/2021 13:00	1.2	13.1	1,934.5	0.9	5.80	1	1	1
12/14/2021 14:00	1.1	13.8	1,649.6	0.9	4.90	1	1	0
12/14/2021 15:00	1.1	13.8	1,539.2	0.9	4.60	1	1	0
12/14/2021 16:00	1.3	12.9	2,002.4	1.0	8.00	1	1	1
12/14/2021 17:00	1.4	11.7	2,301.1	0.9	6.90	1	1	1
12/14/2021 18:00	1.4	11.9	2,243.4	0.9	6.70	1	1	1
12/14/2021 19:00	1.4	11.7	2,299.5	0.9	6.90	1	1	1
12/14/2021 20:00	1.4	11.7	2,303.6	0.9	6.90	1	1	1
12/14/2021 21:00	1.4	12.0	2,238.0	0.9	6.70	1	1	1
12/14/2021 22:00	1.3	12.4	2,143.1	0.9	6.40	1	1	1
12/14/2021 23:00	1.3	12.8	2,049.8	0.9	6.10	1	1	1
Average/Sum#:	1.2	13.0	1,911.3	0.9	141.40 #	24 #	24 #	18 #
Minimum:	1.1	11.7	1,300.6	0.9	3.90	1	1	0
Maximum:	1.4	13.9	2,303.6	1.0	8.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/15/2021 00:00	1.2	13.1	1,973.0	0.9	5.90	1	1	1
12/15/2021 01:00	1.1	13.8	1,567.8	0.9	4.70	1	1	0
12/15/2021 02:00	1.1	13.8	1,675.9	0.9	5.00	1	1	1
12/15/2021 03:00	1.2	13.2	1,967.2	0.9	5.90	1	1	1
12/15/2021 04:00	1.2	13.2	1,948.6	0.9	5.80	1	1	1
12/15/2021 05:00	1.0	13.8	1,589.5	0.8	4.80	1	1	0
12/15/2021 06:00	1.2	13.3	1,899.4	0.9	5.70	1	1	1
12/15/2021 07:00	1.3	12.2	2,192.1	0.9	6.60	1	1	1
12/15/2021 08:00	1.3	12.9	1,997.6	1.0	8.00	1	1	1
12/15/2021 09:00	1.1	13.8	1,599.5	0.9	4.80	1	1	0
12/15/2021 10:00	1.1	13.8	1,624.5	0.9	4.90	1	1	0
12/15/2021 11:00	1.1	13.7	1,617.0	0.9	4.90	1	1	1
12/15/2021 12:00	1.3	12.8	2,020.0	0.9	6.10	1	1	1
12/15/2021 13:00	1.3	12.7	2,013.3	0.9	6.00	1	1	1
12/15/2021 14:00	1.1	13.8	1,564.7	0.9	4.70	1	1	0
12/15/2021 15:00	1.1	13.7	1,723.9	0.9	5.20	1	1	1
12/15/2021 16:00	1.4	12.3	2,148.3	1.0	8.60	1	1	1
12/15/2021 17:00	1.5	11.5	2,298.6	0.9	6.90	1	1	1
12/15/2021 18:00	0.9	11.6	2,292.5	0.6	4.60	1	1	1
12/15/2021 19:00	1.4	11.6	2,288.0	0.9	6.90	1	1	1
12/15/2021 20:00	1.4	11.6	2,290.7	0.9	6.90	1	1	1
12/15/2021 21:00	1.4	11.8	2,240.6	0.9	6.70	1	1	1
12/15/2021 22:00	1.4	12.3	2,141.0	1.0	8.60	1	1	1
12/15/2021 23:00	1.3	12.4	2,112.4	0.9	6.30	1	1	1
Average/Sum#:	1.2	12.9	1,949.4	0.9	144.50 #	24 #	24 #	19 #
Minimum:	0.9	11.5	1,564.7	0.6	4.60	1	1	0
Maximum:	1.5	13.8	2,298.6	1.0	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/16/2021 00:00	1.3	12.6	2,067.2	0.9	6.20	1	1	1
12/16/2021 01:00	1.3	13.0	1,974.1	1.0	7.90	1	1	1
12/16/2021 02:00	1.1	13.8	1,583.8	0.9	4.80	1	1	0
12/16/2021 03:00	1.1	13.8	1,588.8	0.9	4.80	1	1	0
12/16/2021 04:00	1.1	13.8	1,627.6	0.9	4.90	1	1	1
12/16/2021 05:00	1.4	12.6	2,052.6	1.0	8.20	1	1	1
12/16/2021 06:00	1.4	11.8	2,275.8	0.9	6.80	1	1	1
12/16/2021 07:00	1.4	11.9	2,256.8	0.9	6.80	1	1	1
12/16/2021 08:00	1.3	12.6	2,071.2	0.9	6.20	1	1	1
12/16/2021 09:00	1.3	13.0	1,980.8	1.0	7.90	1	1	1
12/16/2021 10:00	1.1	13.8	1,497.3	0.9	4.50	1	1	0
12/16/2021 11:00	1.1	13.8	1,625.2	0.9	4.90	1	1	1
12/16/2021 12:00	1.1	12.8	2,043.0	0.8	6.10	1	1	1
12/16/2021 13:00	1.1	13.2	1,946.2	0.8	5.80	1	1	1
12/16/2021 14:00	1.0	13.8	1,562.9	0.8	4.70	1	1	0
12/16/2021 15:00	1.0	13.8	1,601.6	0.8	4.80	1	1	1
12/16/2021 16:00	1.3	12.4	2,137.2	0.9	6.40	1	1	1
12/16/2021 17:00	1.4	11.8	2,274.9	0.9	6.80	1	1	1
12/16/2021 18:00	1.4	11.8	2,276.4	0.9	6.80	1	1	1
12/16/2021 19:00	1.4	11.8	2,278.2	0.9	6.80	1	1	1
12/16/2021 20:00	1.4	11.8	2,286.1	0.9	6.90	1	1	1
12/16/2021 21:00	1.4	11.9	2,271.3	0.9	6.80	1	1	1
12/16/2021 22:00	1.3	12.4	2,139.0	0.9	6.40	1	1	1
12/16/2021 23:00	1.3	12.6	2,088.5	0.9	6.30	1	1	1
Average/Sum#:	1.3	12.8	1,979.4	0.9	148.50 #	24 #	24 #	20 #
Minimum:	1.0	11.8	1,497.3	0.8	4.50	1	1	0
Maximum:	1.4	13.8	2,286.1	1.0	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/17/2021 00:00	1.2	13.2	1,942.9	0.9	5.80	1	1	1
12/17/2021 01:00	1.1	13.8	1,565.8	0.9	4.70	1	1	0
12/17/2021 02:00	1.1	13.8	1,560.1	0.9	4.70	1	1	0
12/17/2021 03:00	1.1	13.8	1,718.2	0.9	5.20	1	1	1
12/17/2021 04:00	1.3	12.9	2,025.9	1.0	8.10	1	1	1
12/17/2021 05:00	1.3	12.9	2,034.0	1.0	8.10	1	1	1
12/17/2021 06:00	1.4	12.0	2,248.6	0.9	6.70	1	1	1
12/17/2021 07:00	1.4	12.1	2,236.2	0.9	6.70	1	1	1
12/17/2021 08:00	1.2	13.0	2,037.9	0.9	6.10	1	1	1
12/17/2021 09:00	1.2	13.2	1,946.0	0.9	5.80	1	1	1
12/17/2021 10:00	1.1	13.8	1,584.2	0.9	4.80	1	1	0
12/17/2021 11:00	1.1	13.8	1,551.7	0.9	4.70	1	1	0
12/17/2021 12:00	1.1	13.9	1,393.3	0.9	4.20	1	1	0
12/17/2021 13:00	1.1	13.8	1,659.0	0.9	5.00	1	1	0
12/17/2021 14:00	1.1	13.9	1,501.0	0.9	4.50	1	1	0
12/17/2021 15:00	1.1	13.8	1,605.8	0.9	4.80	1	1	1
12/17/2021 16:00	1.3	12.7	2,069.4	0.9	6.20	1	1	1
12/17/2021 17:00	1.4	11.7	2,295.8	0.9	6.90	1	1	1
12/17/2021 18:00	1.4	11.7	2,299.7	0.9	6.90	1	1	1
12/17/2021 19:00	1.4	11.8	2,297.7	0.9	6.90	1	1	1
12/17/2021 20:00	1.4	11.7	2,303.1	0.9	6.90	1	1	1
12/17/2021 21:00	1.4	11.8	2,289.2	0.9	6.90	1	1	1
12/17/2021 22:00	1.3	12.5	2,137.5	0.9	6.40	1	1	1
12/17/2021 23:00	1.3	12.9	2,044.4	1.0	8.20	1	1	1
Average/Sum#:	1.2	12.9	1,931.1	0.9	145.20 #	24 #	24 #	17 #
Minimum:	1.1	11.7	1,393.3	0.9	4.20	1	1	0
Maximum:	1.4	13.9	2,303.1	1.0	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/18/2021 00:00	1.2	13.2	1,954.4	0.9	5.90	1	1	1
12/18/2021 01:00	1.1	13.8	1,623.0	0.9	4.90	1	1	1
12/18/2021 02:00	1.1	13.8	1,744.1	0.9	5.20	1	1	0
12/18/2021 03:00	1.3	12.9	2,071.3	1.0	8.30	1	1	1
12/18/2021 04:00	1.2	13.0	2,025.4	0.9	6.10	1	1	1
12/18/2021 05:00	1.2	13.8	1,694.8	1.0	6.80	1	1	1
12/18/2021 06:00	1.2	13.8	1,789.4	1.0	7.20	1	1	1
12/18/2021 07:00	1.3	13.0	2,048.1	1.0	8.20	1	1	1
12/18/2021 08:00	1.3	13.0	2,038.3	1.0	8.20	1	1	1
12/18/2021 09:00	1.2	13.0	2,011.9	0.9	6.00	1	1	1
12/18/2021 10:00	1.1	13.8	1,564.8	0.9	4.70	1	1	0
12/18/2021 11:00	1.1	13.8	1,604.0	0.9	4.80	1	1	0
12/18/2021 12:00	1.1	13.8	1,564.9	0.9	4.70	1	1	0
12/18/2021 13:00	1.1	13.8	1,549.8	0.9	4.60	1	1	0
12/18/2021 14:00	1.1	13.8	1,555.0	0.9	4.70	1	1	0
12/18/2021 15:00	1.1	13.8	1,511.5	0.9	4.50	1	1	0
12/18/2021 16:00	1.2	13.3	1,884.1	0.9	5.70	1	1	1
12/18/2021 17:00	1.4	12.1	2,219.0	0.9	6.70	1	1	1
12/18/2021 18:00	1.3	12.4	2,152.8	0.9	6.50	1	1	1
12/18/2021 19:00	1.4	12.0	2,247.1	0.9	6.70	1	1	1
12/18/2021 20:00	1.4	11.9	2,277.2	0.9	6.80	1	1	1
12/18/2021 21:00	1.4	12.3	2,177.8	1.0	8.70	1	1	1
12/18/2021 22:00	1.3	12.6	2,119.7	0.9	6.40	1	1	1
12/18/2021 23:00	1.2	12.9	2,038.6	0.9	6.10	1	1	1
Average/Sum#:	1.2	13.2	1,894.5	0.9	148.40 #	24 #	24 #	17 #
Minimum:	1.1	11.9	1,511.5	0.9	4.50	1	1	0
Maximum:	1.4	13.8	2,277.2	1.0	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/19/2021 00:00	1.3	12.7	2,084.6	0.9	6.30	1	1	1
12/19/2021 01:00	1.2	12.9	2,016.1	0.9	6.00	1	1	1
12/19/2021 02:00	1.2	13.8	1,634.7	1.0	6.50	1	1	0
12/19/2021 03:00	1.1	13.7	1,705.1	0.9	5.10	1	1	0
12/19/2021 04:00	1.2	13.0	2,010.4	0.9	6.00	1	1	1
12/19/2021 05:00	1.3	13.0	2,032.4	1.0	8.10	1	1	1
12/19/2021 06:00	1.2	13.1	1,992.7	0.9	6.00	1	1	1
12/19/2021 07:00	1.2	13.0	2,028.6	0.9	6.10	1	1	1
12/19/2021 08:00	1.2	13.0	2,025.2	0.9	6.10	1	1	1
12/19/2021 09:00	1.2	13.2	1,960.8	0.9	5.90	1	1	1
12/19/2021 10:00	1.1	13.8	1,509.6	0.9	4.50	1	1	0
12/19/2021 11:00	1.2	13.8	1,506.8	1.0	6.00	1	1	0
12/19/2021 12:00	1.1	13.8	1,467.5	0.9	4.40	1	1	0
12/19/2021 13:00	1.1	13.8	1,614.3	0.9	4.80	1	1	0
12/19/2021 14:00	1.2	13.8	1,615.0	1.0	6.50	1	1	0
12/19/2021 15:00	1.1	13.8	1,600.5	0.9	4.80	1	1	0
12/19/2021 16:00	1.3	12.9	2,012.3	1.0	8.00	1	1	1
12/19/2021 17:00	1.4	12.1	2,222.8	0.9	6.70	1	1	1
12/19/2021 18:00	1.3	12.5	2,140.1	0.9	6.40	1	1	1
12/19/2021 19:00	1.3	12.3	2,173.0	0.9	6.50	1	1	1
12/19/2021 20:00	1.3	12.4	2,153.1	0.9	6.50	1	1	1
12/19/2021 21:00	1.3	12.5	2,141.0	0.9	6.40	1	1	1
12/19/2021 22:00	1.3	12.5	2,136.0	0.9	6.40	1	1	1
12/19/2021 23:00	1.3	12.6	2,094.6	0.9	6.30	1	1	1
Average/Sum#:	1.2	13.1	1,911.6	0.9	146.30 #	24 #	24 #	16 #
Minimum:	1.1	12.1	1,467.5	0.9	4.40	1	1	0
Maximum:	1.4	13.8	2,222.8	1.0	8.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/20/2021 00:00	1.3	12.7	2,094.2	0.9	6.30	1	1	1
12/20/2021 01:00	1.2	13.0	1,994.4	0.9	6.00	1	1	1
12/20/2021 02:00	1.2	13.7	1,718.1	1.0	6.90	1	1	0
12/20/2021 03:00	1.2	13.7	1,758.0	1.0	7.00	1	1	1
12/20/2021 04:00	1.2	12.9	2,038.4	0.9	6.10	1	1	1
12/20/2021 05:00	1.4	12.4	2,144.9	1.0	8.60	1	1	1
12/20/2021 06:00	1.4	12.1	2,243.0	0.9	6.70	1	1	1
12/20/2021 07:00	1.3	12.4	2,143.5	0.9	6.40	1	1	1
12/20/2021 08:00	1.3	12.9	2,016.4	1.0	8.10	1	1	1
12/20/2021 09:00	1.1	13.8	1,663.9	0.9	5.00	1	1	0
12/20/2021 10:00	1.1	13.8	1,354.3	0.9	4.10	1	1	0
12/20/2021 11:00	1.1	13.8	1,662.4	0.9	5.00	1	1	0
12/20/2021 12:00	1.2	13.4	1,889.8	0.9	5.70	1	1	1
12/20/2021 13:00	1.3	12.4	2,153.3	0.9	6.50	1	1	1
12/20/2021 14:00	1.4	12.0	2,236.5	0.9	6.70	1	1	1
12/20/2021 15:00	1.4	12.0	2,229.7	0.9	6.70	1	1	1
12/20/2021 16:00	1.4	11.8	2,284.5	0.9	6.90	1	1	1
12/20/2021 17:00	1.4	11.7	2,299.6	0.9	6.90	1	1	1
12/20/2021 18:00	1.4	11.7	2,300.8	0.9	6.90	1	1	1
12/20/2021 19:00	1.4	11.7	2,313.4	0.9	6.90	1	1	1
12/20/2021 20:00	1.4	11.7	2,316.6	0.9	6.90	1	1	1
12/20/2021 21:00	1.4	11.7	2,321.3	0.9	7.00	1	1	1
12/20/2021 22:00	1.4	11.7	2,303.5	0.9	6.90	1	1	1
12/20/2021 23:00	1.3	12.4	2,142.3	0.9	6.40	1	1	1
Average/Sum#:	1.3	12.6	2,067.6	0.9	156.60 #	24 #	24 #	20 #
Minimum:	1.1	11.7	1,354.3	0.9	4.10	1	1	0
Maximum:	1.4	13.8	2,321.3	1.0	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/21/2021 00:00	1.3	12.5	2,098.4	0.9	6.30	1	1	1
12/21/2021 01:00	1.1	13.8	1,701.1	0.9	5.10	1	1	0
12/21/2021 02:00	1.1	13.7	1,817.0	0.9	5.50	1	1	1
12/21/2021 03:00	1.3	13.0	2,036.9	1.0	8.10	1	1	1
12/21/2021 04:00	1.2	13.0	1,996.3	0.9	6.00	1	1	1
12/21/2021 05:00	1.2	13.8	1,686.5	1.0	6.70	1	1	0
12/21/2021 06:00	1.1	13.8	1,772.5	0.9	5.30	1	1	1
12/21/2021 07:00	1.3	12.8	2,091.3	0.9	6.30	1	1	1
12/21/2021 08:00	1.4	11.9	2,282.0	0.9	6.80	1	1	1
12/21/2021 09:00	1.3	12.5	2,117.5	0.9	6.40	1	1	1
12/21/2021 10:00	1.1	13.8	1,635.9	0.9	4.90	1	1	0
12/21/2021 11:00	1.2	13.7	1,821.6	1.0	7.30	1	1	1
12/21/2021 12:00	1.3	12.8	2,073.0	0.9	6.20	1	1	1
12/21/2021 13:00	1.3	12.9	2,012.9	1.0	8.10	1	1	1
12/21/2021 14:00	1.1	13.8	1,665.2	0.9	5.00	1	1	0
12/21/2021 15:00	1.2	13.7	1,820.4	1.0	7.30	1	1	1
12/21/2021 16:00	1.3	12.8	2,071.1	0.9	6.20	1	1	1
12/21/2021 17:00	1.4	12.0	2,278.3	0.9	6.80	1	1	1
12/21/2021 18:00	1.4	11.9	2,292.2	0.9	6.90	1	1	1
12/21/2021 19:00	1.4	11.8	2,295.6	0.9	6.90	1	1	1
12/21/2021 20:00	1.4	11.8	2,293.3	0.9	6.90	1	1	1
12/21/2021 21:00	1.4	12.0	2,235.2	0.9	6.70	1	1	1
12/21/2021 22:00	1.3	12.5	2,139.8	0.9	6.40	1	1	1
12/21/2021 23:00	1.3	12.7	2,089.3	0.9	6.30	1	1	1
Average/Sum#:	1.3	12.9	2,013.5	0.9	154.40 #	24 #	24 #	20 #
Minimum:	1.1	11.8	1,635.9	0.9	4.90	1	1	0
Maximum:	1.4	13.8	2,295.6	1.0	8.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/22/2021 00:00	1.2	13.2	1,955.6	0.9	5.90	1	1	1
12/22/2021 01:00	1.1	13.8	1,633.5	0.9	4.90	1	1	0
12/22/2021 02:00	1.1	13.7	1,699.0	0.9	5.10	1	1	1
12/22/2021 03:00	1.2	13.2	1,974.4	0.9	5.90	1	1	1
12/22/2021 04:00	1.2	13.2	1,954.3	0.9	5.90	1	1	1
12/22/2021 05:00	1.0	13.8	1,473.4	0.8	4.40	1	1	0
12/22/2021 06:00	1.1	13.7	1,709.1	0.9	5.10	1	1	1
12/22/2021 07:00	1.3	13.0	1,998.4	1.0	8.00	1	1	1
12/22/2021 08:00	1.3	13.0	1,989.2	1.0	8.00	1	1	1
12/22/2021 09:00	1.1	13.8	1,453.1	0.9	4.40	1	1	0
12/22/2021 10:00	1.1	13.7	1,532.4	0.9	4.60	1	1	1
12/22/2021 11:00	1.2	13.0	2,009.3	0.9	6.00	1	1	1
12/22/2021 12:00	1.2	13.2	1,955.8	0.9	5.90	1	1	1
12/22/2021 13:00	1.2	13.7	1,631.3	1.0	6.50	1	1	1
12/22/2021 14:00	1.2	13.7	1,802.3	1.0	7.20	1	1	0
12/22/2021 15:00	1.3	12.9	2,014.2	1.0	8.10	1	1	1
12/22/2021 16:00	1.3	12.6	2,073.9	0.9	6.20	1	1	1
12/22/2021 17:00	1.4	12.3	2,168.2	1.0	8.70	1	1	1
12/22/2021 18:00	1.2	12.8	2,031.0	0.9	6.10	1	1	1
12/22/2021 19:00	1.3	13.0	1,988.5	1.0	8.00	1	1	1
12/22/2021 20:00	1.3	12.8	2,009.9	0.9	6.00	1	1	1
12/22/2021 21:00	1.1	13.8	1,561.2	0.9	4.70	1	1	0
12/22/2021 22:00	1.1	13.7	1,767.2	0.9	5.30	1	1	1
12/22/2021 23:00	1.3	12.7	2,051.5	0.9	6.20	1	1	1
Average/Sum#:	1.2	13.3	1,851.5	0.9	147.10 #	24 #	24 #	19 #
Minimum:	1.0	12.3	1,453.1	0.8	4.40	1	1	0
Maximum:	1.4	13.8	2,168.2	1.0	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/23/2021 00:00	1.2	13.1	1,942.7	0.9	5.80	1	1	1
12/23/2021 01:00	1.1	13.8	1,586.5	0.9	4.80	1	1	0
12/23/2021 02:00	1.1	13.7	1,633.4	0.9	4.90	1	1	1
12/23/2021 03:00	1.3	13.1	1,962.4	1.0	7.80	1	1	1
12/23/2021 04:00	1.2	13.1	1,936.7	0.9	5.80	1	1	1
12/23/2021 05:00	1.2	13.7	1,660.4	1.0	6.60	1	1	0
12/23/2021 06:00	1.1	13.6	1,654.8	0.9	5.00	1	1	1
12/23/2021 07:00	1.3	12.5	2,072.6	0.9	6.20	1	1	1
12/23/2021 08:00	1.2	13.0	1,950.8	0.9	5.90	1	1	1
12/23/2021 09:00	1.1	13.8	1,558.8	0.9	4.70	1	1	0
12/23/2021 10:00	1.1	13.7	1,652.7	0.9	5.00	1	1	1
12/23/2021 11:00	1.2	13.0	1,957.5	0.9	5.90	1	1	1
12/23/2021 12:00	1.3	13.0	1,934.2	1.0	7.70	1	1	1
12/23/2021 13:00	1.1	13.8	1,630.1	0.9	4.90	1	1	0
12/23/2021 14:00	1.1	13.8	1,326.6	0.9	4.00	1	1	0
12/23/2021 15:00	1.2	13.7	1,632.9	1.0	6.50	1	1	0
12/23/2021 16:00	1.2	13.2	1,853.6	0.9	5.60	1	1	1
12/23/2021 17:00	1.3	12.9	1,933.2	1.0	7.70	1	1	1
12/23/2021 18:00	1.1	13.7	1,677.9	0.9	5.00	1	1	1
12/23/2021 19:00	1.3	12.8	1,985.6	0.9	6.00	1	1	1
12/23/2021 20:00	1.3	12.9	1,944.8	1.0	7.80	1	1	1
12/23/2021 21:00	1.1	13.8	1,475.6	0.9	4.40	1	1	0
12/23/2021 22:00	1.1	13.7	1,597.7	0.9	4.80	1	1	1
12/23/2021 23:00	1.3	12.8	2,003.2	0.9	6.00	1	1	1
Average/Sum#:	1.2	13.3	1,773.5	0.9	138.80 #	24 #	24 #	17 #
Minimum:	1.1	12.5	1,326.6	0.9	4.00	1	1	0
Maximum:	1.3	13.8	2,072.6	1.0	7.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/24/2021 00:00	1.3	12.9	1,952.4	1.0	7.80	1	1	1
12/24/2021 01:00	1.1	13.8	1,533.6	0.9	4.60	1	1	0
12/24/2021 02:00	1.1	13.8	1,483.7	0.9	4.50	1	1	0
12/24/2021 03:00	1.1	13.8	1,364.6	0.9	4.10	1	1	0
12/24/2021 04:00	1.1	13.8	1,369.5	0.9	4.10	1	1	0
12/24/2021 05:00	1.0	13.8	1,761.1	0.8	5.30	1	1	0
12/24/2021 06:00	1.2	13.3	1,863.2	0.9	5.60	1	1	1
12/24/2021 07:00	1.2	13.2	1,893.7	0.9	5.70	1	1	1
12/24/2021 08:00	1.1	13.7	1,668.5	0.9	5.00	1	1	1
12/24/2021 09:00	1.3	13.0	1,974.9	1.0	7.90	1	1	1
12/24/2021 10:00	1.3	13.0	1,961.2	1.0	7.80	1	1	1
12/24/2021 11:00	1.1	13.9	1,406.3	0.9	4.20	1	1	0
12/24/2021 12:00	1.1	13.8	1,629.2	0.9	4.90	1	1	0
12/24/2021 13:00	1.1	13.9	1,428.8	0.9	4.30	1	1	0
12/24/2021 14:00	1.1	13.9	1,417.3	0.9	4.30	1	1	0
12/24/2021 15:00	1.1	13.8	1,498.3	0.9	4.50	1	1	0
12/24/2021 16:00	1.1	13.8	1,519.2	0.9	4.60	1	1	1
12/24/2021 17:00	1.3	12.9	1,998.6	1.0	8.00	1	1	1
12/24/2021 18:00	1.3	12.8	2,022.1	0.9	6.10	1	1	1
12/24/2021 19:00	1.3	12.8	2,027.1	0.9	6.10	1	1	1
12/24/2021 20:00	1.2	13.1	1,934.3	0.9	5.80	1	1	1
12/24/2021 21:00	1.1	13.9	1,412.2	0.9	4.20	1	1	0
12/24/2021 22:00	1.1	13.7	1,608.4	0.9	4.80	1	1	1
12/24/2021 23:00	1.3	12.7	2,042.7	0.9	6.10	1	1	1
Average/Sum#:	1.2	13.5	1,698.8	0.9	130.30 #	24 #	24 #	13 #
Minimum:	1.0	12.7	1,364.6	0.8	4.10	1	1	0
Maximum:	1.3	13.9	2,042.7	1.0	8.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/25/2021 00:00	1.2	13.1	1,951.8	0.9	5.90	1	1	1
12/25/2021 01:00	1.1	13.8	1,560.4	0.9	4.70	1	1	0
12/25/2021 02:00	1.1	13.8	1,448.9	0.9	4.30	1	1	0
12/25/2021 03:00	1.1	13.8	1,358.0	0.9	4.10	1	1	0
12/25/2021 04:00	1.2	13.7	1,587.8	1.0	6.40	1	1	1
12/25/2021 05:00	1.4	12.8	2,018.2	1.0	8.10	1	1	1
12/25/2021 06:00	1.2	13.1	1,950.7	0.9	5.90	1	1	1
12/25/2021 07:00	1.1	13.7	1,587.5	0.9	4.80	1	1	1
12/25/2021 08:00	1.2	13.8	1,616.8	1.0	6.50	1	1	0
12/25/2021 09:00	1.1	13.8	1,417.7	0.9	4.30	1	1	0
12/25/2021 10:00	1.1	13.8	1,637.8	0.9	4.90	1	1	0
12/25/2021 11:00	1.1	13.8	1,599.0	0.9	4.80	1	1	0
12/25/2021 12:00	1.1	13.8	1,564.8	0.9	4.70	1	1	0
12/25/2021 13:00	1.1	13.8	1,505.3	0.9	4.50	1	1	0
12/25/2021 14:00	1.1	13.8	1,611.8	0.9	4.80	1	1	0
12/25/2021 15:00	1.1	13.8	1,627.7	0.9	4.90	1	1	0
12/25/2021 16:00	1.3	13.1	1,934.9	1.0	7.70	1	1	1
12/25/2021 17:00	1.3	12.5	2,081.0	0.9	6.20	1	1	1
12/25/2021 18:00	1.3	12.5	2,084.9	0.9	6.30	1	1	1
12/25/2021 19:00	1.3	12.6	2,076.0	0.9	6.20	1	1	1
12/25/2021 20:00	1.2	13.1	1,946.4	0.9	5.80	1	1	1
12/25/2021 21:00	1.1	13.8	1,659.1	0.9	5.00	1	1	0
12/25/2021 22:00	1.1	13.8	1,604.3	0.9	4.80	1	1	1
12/25/2021 23:00	1.3	12.9	2,019.0	1.0	8.10	1	1	1
Average/Sum#:	1.2	13.4	1,727.1	0.9	133.70 #	24 #	24 #	12 #
Minimum:	1.1	12.5	1,358.0	0.9	4.10	1	1	0
Maximum:	1.4	13.8	2,084.9	1.0	8.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/26/2021 00:00	2.1	14.3	1,235.1	1.9	4.30	1	0	1
12/26/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/26/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/26/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/26/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/26/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/26/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/26/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/26/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/26/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/26/2021 10:00	4.1	19.1	136.1	13.4	1.09	1	0	0
12/26/2021 11:00	19.8	17.2	397.2	31.6	46.10	1	0	0
12/26/2021 12:00	12.2	15.7	770.7	13.8	39.30	1	0	0
12/26/2021 13:00	1.0	13.8	1,403.5	0.8	4.20	1	1	0
12/26/2021 14:00	1.1	13.8	1,372.2	0.9	4.10	1	1	0
12/26/2021 15:00	1.1	13.8	1,649.6	0.9	4.90	1	1	0
12/26/2021 16:00	1.1	13.8	1,648.3	0.9	4.90	1	1	0
12/26/2021 17:00	1.1	13.7	1,759.2	0.9	5.30	1	1	0
12/26/2021 18:00	1.1	13.7	1,762.5	0.9	5.30	1	1	1
12/26/2021 19:00	1.3	13.0	1,993.4	1.0	8.00	1	1	1
12/26/2021 20:00	1.3	12.8	2,007.9	0.9	6.00	1	1	1
12/26/2021 21:00	1.1	13.8	1,635.5	0.9	4.90	1	1	0
12/26/2021 22:00	1.1	13.7	1,719.1	0.9	5.20	1	1	1
12/26/2021 23:00	1.3	12.8	2,029.2	0.9	6.10	1	1	1
Average/Sum#:	3.4	14.3	1,434.6	4.7	149.69 #	15 #	11 #	6 #
Minimum:	1.0	12.8	136.1	0.8	1.09	0	0	0
Maximum:	19.8	19.1	2,029.2	31.6	46.10	1	1	1
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/27/2021 00:00	1.3	12.7	2,061.3	0.9	6.20	1	1	1
12/27/2021 01:00	1.3	12.9	1,993.2	1.0	8.00	1	1	1
12/27/2021 02:00	1.1	13.8	1,667.4	0.9	5.00	1	1	0
12/27/2021 03:00	1.1	13.8	1,517.7	0.9	4.60	1	1	0
12/27/2021 04:00	1.1	13.8	1,526.5	0.9	4.60	1	1	0
12/27/2021 05:00	1.1	13.7	1,685.5	0.9	5.10	1	1	1
12/27/2021 06:00	1.3	12.8	2,060.6	0.9	6.20	1	1	1
12/27/2021 07:00	1.4	12.1	2,196.9	0.9	6.60	1	1	1
12/27/2021 08:00	1.4	12.3	2,158.1	1.0	8.60	1	1	1
12/27/2021 09:00	1.4	12.1	2,190.4	0.9	6.60	1	1	1
12/27/2021 10:00	1.4	12.3	2,131.5	1.0	8.50	1	1	1
12/27/2021 11:00	1.3	12.4	2,074.5	0.9	6.20	1	1	1
12/27/2021 12:00	1.1	13.8	1,710.1	0.9	5.10	1	1	0
12/27/2021 13:00	1.1	13.8	1,646.9	0.9	4.90	1	1	0
12/27/2021 14:00	1.3	13.0	1,998.5	1.0	8.00	1	1	1
12/27/2021 15:00	1.3	12.4	2,147.8	0.9	6.40	1	1	1
12/27/2021 16:00	1.4	11.7	2,320.2	0.9	7.00	1	1	1
12/27/2021 17:00	1.5	11.6	2,334.5	1.0	9.30	1	1	1
12/27/2021 18:00	1.4	11.6	2,319.8	0.9	7.00	1	1	1
12/27/2021 19:00	1.4	11.7	2,319.4	0.9	7.00	1	1	1
12/27/2021 20:00	1.5	11.7	2,325.3	1.0	9.30	1	1	1
12/27/2021 21:00	1.4	11.7	2,289.1	0.9	6.90	1	1	1
12/27/2021 22:00	1.3	12.6	2,102.6	0.9	6.30	1	1	1
12/27/2021 23:00	1.3	12.7	2,082.8	0.9	6.20	1	1	1
Average/Sum#:	1.3	12.6	2,035.9	0.9	159.60 #	24 #	24 #	19 #
Minimum:	1.1	11.6	1,517.7	0.9	4.60	1	1	0
Maximum:	1.5	13.8	2,334.5	1.0	9.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/28/2021 00:00	1.2	13.2	1,958.0	0.9	5.90	1	1	1
12/28/2021 01:00	1.1	13.8	1,536.4	0.9	4.60	1	1	0
12/28/2021 02:00	1.1	13.8	1,639.2	0.9	4.90	1	1	1
12/28/2021 03:00	1.2	13.2	1,986.0	0.9	6.00	1	1	1
12/28/2021 04:00	1.2	13.2	1,956.4	0.9	5.90	1	1	1
12/28/2021 05:00	1.1	13.8	1,581.9	0.9	4.70	1	1	0
12/28/2021 06:00	1.1	13.7	1,744.9	0.9	5.20	1	1	1
12/28/2021 07:00	1.2	13.1	2,000.1	0.9	6.00	1	1	1
12/28/2021 08:00	1.3	12.9	2,038.7	1.0	8.20	1	1	1
12/28/2021 09:00	1.3	12.9	2,012.1	1.0	8.00	1	1	1
12/28/2021 10:00	1.1	13.8	1,559.1	0.9	4.70	1	1	0
12/28/2021 11:00	1.1	13.8	1,446.4	0.9	4.30	1	1	0
12/28/2021 12:00	1.1	13.8	1,544.4	0.9	4.60	1	1	0
12/28/2021 13:00	1.2	13.4	1,881.2	0.9	5.60	1	1	1
12/28/2021 14:00	1.3	13.1	1,939.7	1.0	7.80	1	1	1
12/28/2021 15:00	1.1	13.7	1,694.4	0.9	5.10	1	1	1
12/28/2021 16:00	1.4	12.4	2,151.1	1.0	8.60	1	1	1
12/28/2021 17:00	1.4	11.6	2,329.9	0.9	7.00	1	1	1
12/28/2021 18:00	1.4	11.7	2,295.2	0.9	6.90	1	1	1
12/28/2021 19:00	1.4	12.2	2,209.8	0.9	6.60	1	1	1
12/28/2021 20:00	1.4	12.3	2,171.2	1.0	8.70	1	1	1
12/28/2021 21:00	1.3	12.5	2,125.6	0.9	6.40	1	1	1
12/28/2021 22:00	1.3	12.6	2,110.5	0.9	6.30	1	1	1
12/28/2021 23:00	1.3	12.8	2,053.5	0.9	6.20	1	1	1
Average/Sum#:	1.2	13.1	1,915.2	0.9	148.20 #	24 #	24 #	19 #
Minimum:	1.1	11.6	1,446.4	0.9	4.30	1	1	0
Maximum:	1.4	13.8	2,329.9	1.0	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/29/2021 00:00	1.2	13.1	1,960.9	0.9	5.90	1	1	1
12/29/2021 01:00	1.1	13.8	1,536.5	0.9	4.60	1	1	0
12/29/2021 02:00	1.1	13.7	1,606.1	0.9	4.80	1	1	1
12/29/2021 03:00	1.2	13.1	1,988.4	0.9	6.00	1	1	1
12/29/2021 04:00	1.2	13.1	1,974.4	0.9	5.90	1	1	1
12/29/2021 05:00	1.1	13.8	1,479.0	0.9	4.40	1	1	0
12/29/2021 06:00	1.1	13.7	1,781.0	0.9	5.30	1	1	1
12/29/2021 07:00	1.3	12.9	2,041.2	1.0	8.20	1	1	1
12/29/2021 08:00	1.3	13.0	2,009.2	1.0	8.00	1	1	1
12/29/2021 09:00	1.1	13.8	1,440.5	0.9	4.30	1	1	0
12/29/2021 10:00	1.1	13.7	1,651.0	0.9	5.00	1	1	1
12/29/2021 11:00	1.3	12.8	2,055.2	0.9	6.20	1	1	1
12/29/2021 12:00	1.2	13.2	1,960.8	0.9	5.90	1	1	1
12/29/2021 13:00	1.1	13.8	1,690.4	0.9	5.10	1	1	0
12/29/2021 14:00	1.1	13.8	1,699.6	0.9	5.10	1	1	1
12/29/2021 15:00	1.3	12.8	2,046.7	0.9	6.10	1	1	1
12/29/2021 16:00	1.3	12.5	2,126.0	0.9	6.40	1	1	1
12/29/2021 17:00	1.4	11.8	2,303.4	0.9	6.90	1	1	1
12/29/2021 18:00	1.4	11.8	2,298.1	0.9	6.90	1	1	1
12/29/2021 19:00	1.4	11.7	2,315.1	0.9	6.90	1	1	1
12/29/2021 20:00	1.4	11.7	2,315.6	0.9	6.90	1	1	1
12/29/2021 21:00	1.3	12.4	2,152.7	0.9	6.50	1	1	1
12/29/2021 22:00	1.3	13.0	2,015.8	1.0	8.10	1	1	1
12/29/2021 23:00	1.3	12.9	2,043.7	1.0	8.20	1	1	1
Average/Sum#:	1.2	13.0	1,937.1	0.9	147.60 #	24 #	24 #	20 #
Minimum:	1.1	11.7	1,440.5	0.9	4.30	1	1	0
Maximum:	1.4	13.8	2,315.6	1.0	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/30/2021 00:00	1.2	13.2	1,959.6	0.9	5.90	1	1	1
12/30/2021 01:00	1.1	13.8	1,665.7	0.9	5.00	1	1	0
12/30/2021 02:00	1.1	13.8	1,383.9	0.9	4.20	1	1	0
12/30/2021 03:00	1.1	13.8	1,773.2	0.9	5.30	1	1	0
12/30/2021 04:00	1.2	13.5	1,890.0	1.0	7.60	1	1	1
12/30/2021 05:00	1.2	13.4	1,861.3	0.9	5.60	1	1	1
12/30/2021 06:00	1.1	13.8	1,725.8	0.9	5.20	1	1	1
12/30/2021 07:00	1.3	12.9	2,067.7	1.0	8.30	1	1	1
12/30/2021 08:00	1.4	12.4	2,177.5	1.0	8.70	1	1	1
12/30/2021 09:00	1.3	12.7	2,063.6	0.9	6.20	1	1	1
12/30/2021 10:00	1.1	13.8	1,656.9	0.9	5.00	1	1	0
12/30/2021 11:00	1.1	13.8	1,692.9	0.9	5.10	1	1	1
12/30/2021 12:00	1.3	12.8	2,040.9	0.9	6.10	1	1	1
12/30/2021 13:00	1.2	13.2	1,935.5	0.9	5.80	1	1	1
12/30/2021 14:00	1.1	13.8	1,678.0	0.9	5.00	1	1	0
12/30/2021 15:00	1.1	13.8	1,635.1	0.9	4.90	1	1	1
12/30/2021 16:00	1.3	12.9	2,026.0	1.0	8.10	1	1	1
12/30/2021 17:00	1.4	12.3	2,158.0	1.0	8.60	1	1	1
12/30/2021 18:00	1.3	12.4	2,129.0	0.9	6.40	1	1	1
12/30/2021 19:00	1.3	12.9	2,030.1	1.0	8.10	1	1	1
12/30/2021 20:00	1.3	12.4	2,148.3	0.9	6.40	1	1	1
12/30/2021 21:00	1.3	12.4	2,130.5	0.9	6.40	1	1	1
12/30/2021 22:00	1.3	12.6	2,098.0	0.9	6.30	1	1	1
12/30/2021 23:00	1.3	12.8	2,057.9	0.9	6.20	1	1	1
Average/Sum#:	1.2	13.1	1,916.1	0.9	150.40 #	24 #	24 #	19 #
Minimum:	1.1	12.3	1,383.9	0.9	4.20	1	1	0
Maximum:	1.4	13.8	2,177.5	1.0	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/31/2021 00:00	1.2	13.1	1,952.2	0.9	5.90	1	1	1
12/31/2021 01:00	1.1	13.8	1,544.8	0.9	4.60	1	1	0
12/31/2021 02:00	1.1	13.9	1,351.7	0.9	4.10	1	1	0
12/31/2021 03:00	1.1	13.8	1,763.6	0.9	5.30	1	1	0
12/31/2021 04:00	1.2	13.5	1,876.1	1.0	7.50	1	1	1
12/31/2021 05:00	1.2	13.4	1,858.3	0.9	5.60	1	1	1
12/31/2021 06:00	1.1	13.8	1,447.5	0.9	4.30	1	1	1
12/31/2021 07:00	1.3	12.8	2,046.6	0.9	6.10	1	1	1
12/31/2021 08:00	1.3	12.8	2,055.5	0.9	6.20	1	1	1
12/31/2021 09:00	1.2	13.2	1,960.5	0.9	5.90	1	1	1
12/31/2021 10:00	1.1	13.8	1,515.5	0.9	4.50	1	1	0
12/31/2021 11:00	1.1	13.8	1,482.4	0.9	4.40	1	1	0
12/31/2021 12:00	1.1	13.8	1,610.8	0.9	4.80	1	1	0
12/31/2021 13:00	1.1	13.9	1,325.1	0.9	4.00	1	1	0
12/31/2021 14:00	1.1	13.9	1,466.8	0.9	4.40	1	1	0
12/31/2021 15:00	1.1	13.8	1,652.8	0.9	5.00	1	1	1
12/31/2021 16:00	1.3	12.6	2,081.9	0.9	6.20	1	1	1
12/31/2021 17:00	1.4	12.2	2,178.5	0.9	6.50	1	1	1
12/31/2021 18:00	1.4	12.2	2,174.3	0.9	6.50	1	1	1
12/31/2021 19:00	1.4	12.1	2,212.4	0.9	6.60	1	1	1
12/31/2021 20:00	1.3	12.5	2,108.3	0.9	6.30	1	1	1
12/31/2021 21:00	1.1	13.8	1,599.6	0.9	4.80	1	1	0
12/31/2021 22:00	1.1	13.8	1,797.9	0.9	5.40	1	1	1
12/31/2021 23:00	1.2	13.1	2,011.0	0.9	6.00	1	1	1
Average/Sum#:	1.2	13.3	1,794.8	0.9	130.90 #	24 #	24 #	15 #
Minimum:	1.1	12.1	1,325.1	0.9	4.00	1	1	0
Maximum:	1.4	13.9	2,212.4	1.0	7.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/01/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/01/2021 13:00	31.2	17.8	303.3	59.4	36.52	1	0	0
10/01/2021 14:00	17.9	15.2	960.0	18.5	65.30	1	0	0
10/01/2021 15:00	1.3	13.9	1,682.6	1.1	6.70	1	1	0
10/01/2021 16:00	1.3	13.8	1,663.3	1.1	6.70	1	1	0
10/01/2021 17:00	1.3	13.7	1,728.6	1.1	6.90	1	1	0
10/01/2021 18:00	1.3	13.7	1,722.5	1.1	6.90	1	1	0
10/01/2021 19:00	1.2	13.9	1,657.8	1.0	6.60	1	1	0
10/01/2021 20:00	1.2	13.9	1,641.4	1.0	6.60	1	1	0
10/01/2021 21:00	1.2	13.9	1,622.1	1.0	6.50	1	1	0
10/01/2021 22:00	1.2	14.0	1,638.2	1.0	6.60	1	1	0
10/01/2021 23:00	1.2	14.0	1,644.1	1.0	6.60	1	1	0
Average/Sum#:	5.5	14.3	1,478.5	7.9	161.92 #	11 #	9 #	0 #
Minimum:	1.2	13.7	303.3	1.0	6.50	0	0	0
Maximum:	31.2	17.8	1,728.6	59.4	65.30	1	1	0
%SI	54.17	54.17	54.17	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/02/2021 00:00	1.2	14.0	1,651.2	1.0	6.60	1	1	0
10/02/2021 01:00	1.3	14.0	1,639.5	1.1	6.60	1	1	0
10/02/2021 02:00	1.1	14.0	1,502.5	0.9	4.50	1	1	0
10/02/2021 03:00	1.2	14.0	1,623.4	1.0	6.50	1	1	0
10/02/2021 04:00	1.3	14.0	1,640.5	1.1	6.60	1	1	0
10/02/2021 05:00	1.2	14.0	1,634.3	1.0	6.50	1	1	0
10/02/2021 06:00	1.2	14.0	1,599.3	1.0	6.40	1	1	0
10/02/2021 07:00	1.0	14.0	1,433.8	0.9	4.30	1	1	0
10/02/2021 08:00	1.0	14.1	1,319.2	0.9	4.00	1	1	0
10/02/2021 09:00	1.0	14.1	1,285.9	0.9	3.90	1	1	0
10/02/2021 10:00	0.9	14.1	1,261.6	0.8	3.80	1	1	0
10/02/2021 11:00	0.9	14.1	1,261.8	0.8	3.80	1	1	0
10/02/2021 12:00	0.8	14.1	1,276.2	0.7	3.80	1	1	0
10/02/2021 13:00	1.0	14.1	1,342.6	0.9	4.00	1	1	0
10/02/2021 14:00	1.2	13.9	1,618.7	1.0	6.50	1	1	0
10/02/2021 15:00	1.3	13.9	1,660.3	1.1	6.60	1	1	0
10/02/2021 16:00	1.2	13.9	1,585.1	1.0	6.30	1	1	0
10/02/2021 17:00	1.3	13.7	1,704.2	1.1	6.80	1	1	0
10/02/2021 18:00	1.4	13.7	1,717.9	1.1	6.90	1	1	0
10/02/2021 19:00	1.2	13.9	1,654.7	1.0	6.60	1	1	0
10/02/2021 20:00	1.2	13.9	1,630.4	1.0	6.50	1	1	0
10/02/2021 21:00	1.2	13.9	1,648.0	1.0	6.60	1	1	0
10/02/2021 22:00	1.2	13.9	1,649.3	1.0	6.60	1	1	0
10/02/2021 23:00	1.2	13.9	1,643.2	1.0	6.60	1	1	0
Average/Sum#:	1.1	14.0	1,541.0	1.0	137.30 #	24 #	24 #	0 #
Minimum:	0.8	13.7	1,261.6	0.7	3.80	1	1	0
Maximum:	1.4	14.1	1,717.9	1.1	6.90	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/03/2021 00:00	1.2	14.0	1,593.1	1.0	6.40	1	1	0
10/03/2021 01:00	1.1	14.0	1,538.5	0.9	4.60	1	1	0
10/03/2021 02:00	1.0	14.0	1,418.9	0.9	4.30	1	1	0
10/03/2021 03:00	1.0	14.0	1,383.3	0.9	4.10	1	1	0
10/03/2021 04:00	1.1	14.0	1,435.6	0.9	4.30	1	1	0
10/03/2021 05:00	1.0	14.0	1,421.9	0.9	4.30	1	1	0
10/03/2021 06:00	1.0	14.0	1,425.6	0.9	4.30	1	1	0
10/03/2021 07:00	0.7	14.1	1,263.1	0.6	2.50	1	1	0
10/03/2021 08:00	1.0	14.0	1,326.2	0.9	4.00	1	1	0
10/03/2021 09:00	0.9	14.1	1,264.0	0.8	3.80	1	1	0
10/03/2021 10:00	0.8	14.1	1,266.8	0.7	3.80	1	1	0
10/03/2021 11:00	0.9	14.1	1,321.5	0.8	4.00	1	1	0
10/03/2021 12:00	1.0	14.1	1,384.6	0.9	4.20	1	1	0
10/03/2021 13:00	1.3	13.9	1,576.0	1.1	6.30	1	1	0
10/03/2021 14:00	1.2	13.9	1,648.0	1.0	6.60	1	1	0
10/03/2021 15:00	1.3	13.9	1,652.9	1.1	6.60	1	1	0
10/03/2021 16:00	1.2	13.9	1,570.0	1.0	6.30	1	1	0
10/03/2021 17:00	1.0	14.0	1,393.1	0.9	4.20	1	1	0
10/03/2021 18:00	1.3	13.8	1,702.2	1.1	6.80	1	1	0
10/03/2021 19:00	1.2	13.9	1,603.4	1.0	6.40	1	1	0
10/03/2021 20:00	1.2	13.9	1,639.6	1.0	6.60	1	1	0
10/03/2021 21:00	1.2	13.9	1,586.8	1.0	6.30	1	1	0
10/03/2021 22:00	1.2	13.9	1,628.4	1.0	6.50	1	1	0
10/03/2021 23:00	1.2	13.9	1,645.9	1.0	6.60	1	1	0
Average/Sum#:	1.1	14.0	1,487.1	0.9	123.80 #	24 #	24 #	0 #
Minimum:	0.7	13.8	1,263.1	0.6	2.50	1	1	0
Maximum:	1.3	14.1	1,702.2	1.1	6.80	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/04/2021 00:00	1.2	13.9	1,626.1	1.0	6.50	1	1	0
10/04/2021 01:00	1.2	13.9	1,502.3	1.0	6.00	1	1	0
10/04/2021 02:00	1.2	13.9	1,514.2	1.0	6.10	1	1	0
10/04/2021 03:00	1.2	13.9	1,578.6	1.0	6.30	1	1	0
10/04/2021 04:00	1.2	13.9	1,627.6	1.0	6.50	1	1	0
10/04/2021 05:00	1.2	13.9	1,642.0	1.0	6.60	1	1	0
10/04/2021 06:00	1.2	13.9	1,600.6	1.0	6.40	1	1	0
10/04/2021 07:00	1.1	14.0	1,567.1	0.9	4.70	1	1	0
10/04/2021 08:00	1.1	13.9	1,584.8	0.9	4.80	1	1	0
10/04/2021 09:00	1.1	14.0	1,566.7	0.9	4.70	1	1	0
10/04/2021 10:00	1.1	13.9	1,509.7	0.9	4.50	1	1	0
10/04/2021 11:00	1.2	13.9	1,599.5	1.0	6.40	1	1	0
10/04/2021 12:00	1.3	13.9	1,625.2	1.1	6.50	1	1	0
10/04/2021 13:00	1.2	13.9	1,580.6	1.0	6.30	1	1	0
10/04/2021 14:00	1.3	13.9	1,658.7	1.1	6.60	1	1	0
10/04/2021 15:00	1.2	13.9	1,595.5	1.0	6.40	1	1	0
10/04/2021 16:00	1.3	13.7	1,715.2	1.1	6.90	1	1	0
10/04/2021 17:00	1.4	13.7	1,721.5	1.1	6.90	1	1	0
10/04/2021 18:00	1.4	13.7	1,723.1	1.1	6.90	1	1	0
10/04/2021 19:00	1.3	13.8	1,703.6	1.1	6.80	1	1	0
10/04/2021 20:00	1.3	13.7	1,699.8	1.1	6.80	1	1	0
10/04/2021 21:00	1.3	13.8	1,696.6	1.1	6.80	1	1	0
10/04/2021 22:00	1.1	13.9	1,548.6	0.9	4.60	1	1	0
10/04/2021 23:00	1.1	14.0	1,560.2	0.9	4.70	1	1	0
Average/Sum#:	1.2	13.9	1,614.5	1.0	145.70 #	24 #	24 #	0 #
Minimum:	1.1	13.7	1,502.3	0.9	4.50	1	1	0
Maximum:	1.4	14.0	1,723.1	1.1	6.90	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/05/2021 00:00	1.1	14.0	1,530.4	0.9	4.60	1	1	0
10/05/2021 01:00	1.0	14.0	1,513.7	0.9	4.50	1	1	0
10/05/2021 02:00	1.0	14.0	1,499.5	0.9	4.50	1	1	0
10/05/2021 03:00	1.1	14.0	1,587.0	0.9	4.80	1	1	0
10/05/2021 04:00	1.1	14.0	1,543.8	0.9	4.60	1	1	0
10/05/2021 05:00	1.1	13.9	1,640.7	0.9	4.90	1	1	0
10/05/2021 06:00	1.2	13.9	1,647.6	1.0	6.60	1	1	0
10/05/2021 07:00	1.1	13.9	1,596.6	0.9	4.80	1	1	0
10/05/2021 08:00	1.1	13.9	1,563.3	0.9	4.70	1	1	0
10/05/2021 09:00	1.2	13.9	1,607.2	1.0	6.40	1	1	0
10/05/2021 10:00	1.2	13.9	1,621.3	1.0	6.50	1	1	0
10/05/2021 11:00	1.2	13.9	1,599.8	1.0	6.40	1	1	0
10/05/2021 12:00	1.3	13.9	1,666.5	1.1	6.70	1	1	0
10/05/2021 13:00	1.3	13.9	1,637.4	1.1	6.50	1	1	0
10/05/2021 14:00	1.1	14.0	1,592.9	0.9	4.80	1	1	0
10/05/2021 15:00	1.1	13.9	1,637.6	0.9	4.90	1	1	0
10/05/2021 16:00	1.2	13.9	1,636.2	1.0	6.50	1	1	0
10/05/2021 17:00	1.2	13.9	1,594.9	1.0	6.40	1	1	0
10/05/2021 18:00	1.1	13.9	1,587.4	0.9	4.80	1	1	0
10/05/2021 19:00	1.2	13.9	1,642.0	1.0	6.60	1	1	0
10/05/2021 20:00	1.2	13.9	1,553.5	1.0	6.20	1	1	0
10/05/2021 21:00	1.0	14.0	1,474.4	0.9	4.40	1	1	0
10/05/2021 22:00	1.1	14.0	1,598.7	0.9	4.80	1	1	0
10/05/2021 23:00	0.9	14.0	1,380.2	0.8	4.10	1	1	0
Average/Sum#:	1.1	13.9	1,581.4	0.9	130.00 #	24 #	24 #	0 #
Minimum:	0.9	13.9	1,380.2	0.8	4.10	1	1	0
Maximum:	1.3	14.0	1,666.5	1.1	6.70	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/06/2021 00:00	0.8	14.0	1,264.6	0.7	3.80	1	1	0
10/06/2021 01:00	0.8	14.0	1,264.8	0.7	3.80	1	1	0
10/06/2021 02:00	0.9	14.0	1,265.9	0.8	3.80	1	1	0
10/06/2021 03:00	0.9	14.0	1,266.5	0.8	3.80	1	1	0
10/06/2021 04:00	0.9	14.0	1,290.2	0.8	3.90	1	1	0
10/06/2021 05:00	1.1	13.9	1,499.2	0.9	4.50	1	1	0
10/06/2021 06:00	1.0	13.9	1,566.9	0.8	4.70	1	1	0
10/06/2021 07:00	1.0	13.9	1,532.6	0.8	4.60	1	1	0
10/06/2021 08:00	0.9	14.0	1,372.3	0.8	4.10	1	1	0
10/06/2021 09:00	1.1	13.9	1,553.5	0.9	4.70	1	1	0
10/06/2021 10:00	1.1	13.9	1,536.2	0.9	4.60	1	1	0
10/06/2021 11:00	1.0	13.9	1,476.4	0.8	4.40	1	1	0
10/06/2021 12:00	1.1	13.9	1,572.5	0.9	4.70	1	1	0
10/06/2021 13:00	1.1	13.9	1,602.3	0.9	4.80	1	1	0
10/06/2021 14:00	1.2	13.9	1,646.5	1.0	6.60	1	1	0
10/06/2021 15:00	1.2	13.9	1,631.3	1.0	6.50	1	1	0
10/06/2021 16:00	1.2	13.9	1,603.7	1.0	6.40	1	1	0
10/06/2021 17:00	0.9	14.0	1,362.3	0.8	4.10	1	1	0
10/06/2021 18:00	1.2	13.9	1,556.8	1.0	6.20	1	1	0
10/06/2021 19:00	1.2	13.9	1,586.2	1.0	6.30	1	1	0
10/06/2021 20:00	1.2	13.8	1,684.4	1.0	6.70	1	1	0
10/06/2021 21:00	1.2	13.9	1,603.1	1.0	6.40	1	1	0
10/06/2021 22:00	1.2	13.9	1,549.1	1.0	6.20	1	1	0
10/06/2021 23:00	1.2	13.9	1,651.3	1.0	6.60	1	1	0
Average/Sum#:	1.1	13.9	1,497.4	0.9	122.20 #	24 #	24 #	0 #
Minimum:	0.8	13.8	1,264.6	0.7	3.80	1	1	0
Maximum:	1.2	14.0	1,684.4	1.0	6.70	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/07/2021 00:00	1.1	13.9	1,516.4	0.9	4.50	1	1	0
10/07/2021 01:00	1.1	13.9	1,518.1	0.9	4.60	1	1	0
10/07/2021 02:00	1.1	13.9	1,511.9	0.9	4.50	1	1	0
10/07/2021 03:00	1.0	14.0	1,437.1	0.9	4.30	1	1	0
10/07/2021 04:00	1.1	13.9	1,622.6	0.9	4.90	1	1	0
10/07/2021 05:00	1.1	13.9	1,606.6	0.9	4.80	1	1	0
10/07/2021 06:00	1.1	13.9	1,655.9	0.9	5.00	1	1	0
10/07/2021 07:00	1.1	13.9	1,598.4	0.9	4.80	1	1	0
10/07/2021 08:00	1.0	13.9	1,588.1	0.8	4.80	1	1	0
10/07/2021 09:00	1.0	13.9	1,511.8	0.8	4.50	1	1	0
10/07/2021 10:00	1.0	14.0	1,492.8	0.9	4.50	1	1	0
10/07/2021 11:00	1.1	14.0	1,508.2	0.9	4.50	1	1	0
10/07/2021 12:00	1.1	14.0	1,511.2	0.9	4.50	1	1	0
10/07/2021 13:00	1.1	14.0	1,510.6	0.9	4.50	1	1	0
10/07/2021 14:00	1.2	13.9	1,646.1	1.0	6.60	1	1	0
10/07/2021 15:00	1.2	13.9	1,631.2	1.0	6.50	1	1	0
10/07/2021 16:00	1.2	13.9	1,662.5	1.0	6.70	1	1	0
10/07/2021 17:00	1.3	13.7	1,758.1	1.1	7.00	1	1	0
10/07/2021 18:00	1.3	13.8	1,713.2	1.1	6.90	1	1	0
10/07/2021 19:00	1.1	13.9	1,613.7	0.9	4.80	1	1	0
10/07/2021 20:00	1.1	13.8	1,596.7	0.9	4.80	1	1	0
10/07/2021 21:00	1.1	13.9	1,631.6	0.9	4.90	1	1	0
10/07/2021 22:00	1.2	13.9	1,643.1	1.0	6.60	1	1	0
10/07/2021 23:00	1.1	14.0	1,560.8	0.9	4.70	1	1	0
Average/Sum#:	1.1	13.9	1,585.3	0.9	124.20 #	24 #	24 #	0 #
Minimum:	1.0	13.7	1,437.1	0.8	4.30	1	1	0
Maximum:	1.3	14.0	1,758.1	1.1	7.00	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/08/2021 00:00	1.1	14.0	1,480.0	0.9	4.40	1	1	0
10/08/2021 01:00	1.1	13.9	1,467.1	0.9	4.40	1	1	0
10/08/2021 02:00	1.1	13.9	1,498.1	0.9	4.50	1	1	0
10/08/2021 03:00	1.1	13.9	1,550.9	0.9	4.70	1	1	0
10/08/2021 04:00	1.1	13.9	1,627.0	0.9	4.90	1	1	0
10/08/2021 05:00	1.1	13.9	1,523.2	0.9	4.60	1	1	0
10/08/2021 06:00	1.2	13.9	1,619.0	1.0	6.50	1	1	0
10/08/2021 07:00	1.0	13.9	1,504.9	0.8	4.50	1	1	0
10/08/2021 08:00	1.1	13.9	1,513.8	0.9	4.50	1	1	0
10/08/2021 09:00	0.9	14.0	1,365.0	0.8	4.10	1	1	0
10/08/2021 10:00	1.2	13.9	1,621.7	1.0	6.50	1	1	0
10/08/2021 11:00	1.0	14.0	1,434.4	0.9	4.30	1	1	0
10/08/2021 12:00	1.1	14.0	1,568.8	0.9	4.70	1	1	0
10/08/2021 13:00	1.1	14.0	1,536.6	0.9	4.60	1	1	0
10/08/2021 14:00	1.1	14.0	1,503.6	0.9	4.50	1	1	0
10/08/2021 15:00	1.2	14.0	1,583.3	1.0	6.30	1	1	0
10/08/2021 16:00	1.2	14.0	1,643.4	1.0	6.60	1	1	0
10/08/2021 17:00	1.1	14.0	1,567.2	0.9	4.70	1	1	0
10/08/2021 18:00	1.2	14.0	1,582.3	1.0	6.30	1	1	0
10/08/2021 19:00	1.1	14.0	1,609.4	0.9	4.80	1	1	0
10/08/2021 20:00	0.9	14.0	1,352.2	0.8	4.10	1	1	0
10/08/2021 21:00	4.7	16.3	409.7	6.0	1.80	1	0	0
10/08/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/08/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.3	14.1	1,480.1	1.1	106.30 #	22 #	21 #	0 #
Minimum:	0.9	13.9	409.7	0.8	1.80	0	0	0
Maximum:	4.7	16.3	1,643.4	6.0	6.60	1	1	0
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/09/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/09/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/10/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/10/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/11/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/11/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/12/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/12/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/13/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/13/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/14/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/14/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/15/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/15/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/16/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/16/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/17/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/17/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/18/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/18/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/19/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/19/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/20/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/20/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/20/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/20/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/20/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/20/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/20/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/20/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/20/2021 08:00	13.1	18.5	205.9	32.2	6.13	1	0	0
10/20/2021 09:00	31.8	17.3	375.6	52.1	72.10	1	0	0
10/20/2021 10:00	5.0	17.3	399.4	8.2	12.00	1	0	0
10/20/2021 11:00	9.8	16.9	654.5	14.5	34.70	1	0	0
10/20/2021 12:00	4.7	15.0	1,078.8	4.7	18.30	1	0	0
10/20/2021 13:00	0.4	14.0	1,338.5	0.3	1.30	1	1	0
10/20/2021 14:00	0.4	14.0	1,269.5	0.3	1.30	1	1	0
10/20/2021 15:00	0.5	13.9	1,458.2	0.4	2.90	1	1	1
10/20/2021 16:00	1.0	12.9	1,805.5	0.7	5.40	1	1	1
10/20/2021 17:00	0.7	13.8	1,648.0	0.6	3.30	1	1	1
10/20/2021 18:00	1.0	13.0	1,943.6	0.7	5.80	1	1	1
10/20/2021 19:00	1.1	12.9	1,984.1	0.8	6.00	1	1	1
10/20/2021 20:00	1.3	12.3	2,110.9	0.9	6.30	1	1	1
10/20/2021 21:00	1.3	12.4	2,049.9	0.9	6.10	1	1	1
10/20/2021 22:00	4.3	15.6	632.2	4.8	2.62	1	0	0
10/20/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	5.1	14.7	1,263.6	8.1	184.25 #	15 #	9 #	7 #
Minimum:	0.4	12.3	205.9	0.3	1.30	0	0	0
Maximum:	31.8	18.5	2,110.9	52.1	72.10	1	1	1
%SI	37.50	37.50	37.50	37.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/21/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/21/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/22/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/22/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/23/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/23/2021 05:00	0.9	20.7	0.2	26.6	0.00	1	0	0
10/23/2021 06:00	24.6	17.3	372.8	40.3	55.50	1	0	0
10/23/2021 07:00	4.1	14.5	1,275.2	3.8	17.90	1	0	0
10/23/2021 08:00	0.5	13.9	1,613.3	0.4	3.20	1	1	0
10/23/2021 09:00	0.4	14.0	1,371.1	0.3	1.40	1	1	0
10/23/2021 10:00	0.6	13.9	1,566.5	0.5	3.10	1	1	0
10/23/2021 11:00	0.5	13.9	1,539.5	0.4	3.10	1	1	0
10/23/2021 12:00	0.5	13.9	1,583.1	0.4	3.20	1	1	0
10/23/2021 13:00	0.5	13.9	1,546.6	0.4	3.10	1	1	0
10/23/2021 14:00	0.6	13.9	1,628.0	0.5	3.30	1	1	0
10/23/2021 15:00	0.5	13.9	1,602.6	0.4	3.20	1	1	0
10/23/2021 16:00	0.6	13.8	1,632.6	0.5	3.30	1	1	0
10/23/2021 17:00	0.9	13.0	1,930.3	0.7	3.90	1	1	1
10/23/2021 18:00	1.1	12.7	2,002.8	0.8	6.00	1	1	1
10/23/2021 19:00	0.6	13.8	1,617.2	0.5	3.20	1	1	1
10/23/2021 20:00	0.6	13.8	1,642.8	0.5	3.30	1	1	1
10/23/2021 21:00	1.0	12.8	1,981.3	0.7	5.90	1	1	1
10/23/2021 22:00	1.8	13.8	1,440.9	1.5	6.28	1	0	1
10/23/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	2.2	14.3	1,463.7	4.4	128.88 #	18 #	14 #	6 #
Minimum:	0.4	12.7	0.2	0.3	0.00	0	0	0
Maximum:	24.6	20.7	2,002.8	40.3	55.50	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/24/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/24/2021 03:00	0.5	18.8	181.9	1.4	0.16	1	0	0
10/24/2021 04:00	7.4	15.4	891.2	7.9	25.80	1	0	0
10/24/2021 05:00	0.4	13.9	1,393.2	0.3	1.40	1	1	0
10/24/2021 06:00	0.5	13.9	1,377.8	0.4	2.80	1	1	0
10/24/2021 07:00	0.7	13.8	1,699.4	0.6	3.40	1	1	0
10/24/2021 08:00	0.5	13.9	1,543.6	0.4	3.10	1	1	0
10/24/2021 09:00	0.5	13.9	1,536.6	0.4	3.10	1	1	0
10/24/2021 10:00	0.5	13.9	1,547.9	0.4	3.10	1	1	0
10/24/2021 11:00	0.5	13.9	1,528.4	0.4	3.10	1	1	0
10/24/2021 12:00	0.5	13.9	1,583.9	0.4	3.20	1	1	0
10/24/2021 13:00	0.5	13.9	1,484.3	0.4	3.00	1	1	0
10/24/2021 14:00	0.6	13.9	1,601.0	0.5	3.20	1	1	0
10/24/2021 15:00	0.5	13.9	1,623.8	0.4	3.20	1	1	0
10/24/2021 16:00	0.7	13.7	1,719.8	0.6	3.40	1	1	0
10/24/2021 17:00	0.9	12.9	1,918.2	0.7	3.80	1	1	1
10/24/2021 18:00	1.1	12.6	1,979.4	0.8	5.90	1	1	1
10/24/2021 19:00	0.6	13.9	1,656.6	0.5	3.30	1	1	0
10/24/2021 20:00	0.6	13.9	1,691.3	0.5	3.40	1	1	1
10/24/2021 21:00	1.0	12.7	1,979.6	0.7	5.90	1	1	1
10/24/2021 22:00	0.8	13.3	1,645.0	0.6	3.30	1	1	1
10/24/2021 23:00	1.7	15.0	872.1	1.7	1.98	1	0	0
Average/Sum#:	1.0	14.0	1,497.9	1.0	89.54 #	21 #	18 #	5 #
Minimum:	0.4	12.6	181.9	0.3	0.16	0	0	0
Maximum:	7.4	18.8	1,979.6	7.9	25.80	1	1	1
%SI	12.50	12.50	12.50	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/25/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/25/2021 05:00	5.0	17.6	400.9	8.9	7.00	1	0	0
10/25/2021 06:00	4.7	14.3	1,388.9	4.2	20.80	1	0	0
10/25/2021 07:00	0.8	13.8	1,749.2	0.7	3.50	1	1	0
10/25/2021 08:00	0.5	13.9	1,651.9	0.4	3.30	1	1	0
10/25/2021 09:00	0.7	13.8	1,760.8	0.6	3.50	1	1	1
10/25/2021 10:00	1.0	13.0	1,959.7	0.7	5.90	1	1	1
10/25/2021 11:00	1.1	12.9	1,984.8	0.8	6.00	1	1	1
10/25/2021 12:00	1.1	13.1	1,911.0	0.8	5.70	1	1	1
10/25/2021 13:00	0.6	13.9	1,606.7	0.5	3.20	1	1	0
10/25/2021 14:00	0.5	14.0	1,524.7	0.4	3.00	1	1	0
10/25/2021 15:00	0.6	13.9	1,541.9	0.5	3.10	1	1	1
10/25/2021 16:00	1.1	12.7	2,029.1	0.8	6.10	1	1	1
10/25/2021 17:00	1.2	12.6	2,061.3	0.9	6.20	1	1	1
10/25/2021 18:00	1.2	12.7	2,027.3	0.9	6.10	1	1	1
10/25/2021 19:00	0.6	13.8	1,624.4	0.5	3.20	1	1	1
10/25/2021 20:00	0.4	14.0	1,465.6	0.3	1.50	1	1	0
10/25/2021 21:00	0.9	13.2	1,906.0	0.7	5.70	1	1	1
10/25/2021 22:00	0.8	13.6	1,666.5	0.6	3.30	1	1	1
10/25/2021 23:00	2.0	15.0	860.1	2.0	2.28	1	0	0
Average/Sum#:	1.3	13.8	1,637.9	1.3	99.38 #	19 #	16 #	11 #
Minimum:	0.4	12.6	400.9	0.3	1.50	0	0	0
Maximum:	5.0	17.6	2,061.3	8.9	20.80	1	1	1
%SI	20.83	20.83	20.83	20.83	20.83	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/26/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/26/2021 05:00	5.3	17.8	384.5	10.1	7.10	1	0	0
10/26/2021 06:00	4.9	14.5	1,216.6	4.5	20.70	1	0	0
10/26/2021 07:00	0.5	13.9	1,580.4	0.4	3.20	1	1	0
10/26/2021 08:00	0.5	13.9	1,573.4	0.4	3.10	1	1	0
10/26/2021 09:00	0.5	13.9	1,564.2	0.4	3.10	1	1	1
10/26/2021 10:00	0.8	12.8	1,991.0	0.6	4.00	1	1	1
10/26/2021 11:00	0.0	0.0	1,906.4	0.0	0.00	1	1	1
10/26/2021 12:00	0.5	13.9	1,652.4	0.4	3.30	1	1	0
10/26/2021 13:00	0.3	14.0	1,448.0	0.3	1.40	1	1	0
10/26/2021 14:00	0.3	14.0	1,428.8	0.3	1.40	1	1	0
10/26/2021 15:00	0.4	13.9	1,546.6	0.3	1.50	1	1	1
10/26/2021 16:00	0.9	12.9	1,982.6	0.7	4.00	1	1	1
10/26/2021 17:00	1.0	12.6	2,054.0	0.7	6.20	1	1	1
10/26/2021 18:00	1.0	12.8	2,025.3	0.7	6.10	1	1	1
10/26/2021 19:00	1.0	12.9	1,982.3	0.7	5.90	1	1	1
10/26/2021 20:00	0.4	13.9	1,554.0	0.3	1.60	1	1	0
10/26/2021 21:00	0.5	13.8	1,762.8	0.4	3.50	1	1	1
10/26/2021 22:00	0.9	12.8	2,005.1	0.7	4.00	1	1	1
10/26/2021 23:00	0.9	12.9	1,959.9	0.7	3.90	1	1	1
Average/Sum#:	1.1	13.7	1,664.1	1.3	84.00 #	19 #	17 #	11 #
Minimum:	0.3	12.6	384.5	0.3	1.40	0	0	0
Maximum:	5.3	17.8	2,054.0	10.1	20.70	1	1	1
%SI	25.00	25.00	20.83	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/27/2021 00:00	0.4	13.9	1,536.6	0.3	1.50	1	1	0
10/27/2021 01:00	0.4	13.9	1,562.4	0.3	1.60	1	1	1
10/27/2021 02:00	0.7	13.3	1,916.3	0.5	3.80	1	1	1
10/27/2021 03:00	0.7	13.3	1,890.7	0.5	3.80	1	1	1
10/27/2021 04:00	0.4	13.9	1,569.8	0.3	1.60	1	1	0
10/27/2021 05:00	0.4	13.9	1,589.1	0.3	1.60	1	1	1
10/27/2021 06:00	0.8	13.1	1,930.4	0.6	3.90	1	1	1
10/27/2021 07:00	0.9	13.0	1,955.1	0.7	3.90	1	1	1
10/27/2021 08:00	0.9	13.2	1,919.1	0.7	5.80	1	1	1
10/27/2021 09:00	0.4	13.9	1,465.3	0.3	1.50	1	1	1
10/27/2021 10:00	0.3	14.0	1,422.4	0.3	1.40	1	1	0
10/27/2021 11:00	0.4	13.9	1,571.3	0.3	1.60	1	1	0
10/27/2021 12:00	0.3	14.0	1,308.4	0.3	1.30	1	1	0
10/27/2021 13:00	0.3	14.0	1,453.4	0.3	1.50	1	1	0
10/27/2021 14:00	0.8	13.4	1,802.6	0.6	3.60	1	1	1
10/27/2021 15:00	0.9	13.0	1,853.8	0.7	3.70	1	1	1
10/27/2021 16:00	0.6	13.9	1,674.7	0.5	3.30	1	1	1
10/27/2021 17:00	0.9	13.0	1,929.1	0.7	3.90	1	1	1
10/27/2021 18:00	1.1	12.5	2,057.9	0.8	6.20	1	1	1
10/27/2021 19:00	1.2	12.3	2,098.0	0.8	6.30	1	1	1
10/27/2021 20:00	1.2	12.4	2,061.7	0.8	6.20	1	1	1
10/27/2021 21:00	1.2	12.4	2,070.4	0.8	6.20	1	1	1
10/27/2021 22:00	1.1	12.7	1,983.7	0.8	6.00	1	1	1
10/27/2021 23:00	0.9	13.3	1,801.4	0.7	5.40	1	1	1
Average/Sum#:	0.7	13.3	1,767.7	0.5	85.60 #	24 #	24 #	18 #
Minimum:	0.3	12.3	1,308.4	0.3	1.30	1	1	0
Maximum:	1.2	14.0	2,098.0	0.8	6.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/28/2021 00:00	0.9	14.5	1,106.1	0.8	3.04	1	0	0
10/28/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
10/28/2021 12:00	18.1	18.1	281.5	38.1	15.09	1	0	0
10/28/2021 13:00	12.3	15.2	941.9	12.7	44.30	1	0	0
10/28/2021 14:00	0.3	14.0	1,503.4	0.3	1.50	1	1	0
10/28/2021 15:00	0.5	13.9	1,533.4	0.4	3.10	1	1	1
10/28/2021 16:00	1.0	12.5	2,006.9	0.7	6.00	1	1	1
10/28/2021 17:00	1.5	12.0	2,130.0	1.0	8.50	1	1	1
10/28/2021 18:00	1.4	12.1	2,121.2	0.9	6.40	1	1	1
10/28/2021 19:00	1.5	12.0	2,127.8	1.0	8.50	1	1	1
10/28/2021 20:00	1.4	12.2	2,101.6	0.9	6.30	1	1	1
10/28/2021 21:00	1.2	12.5	2,037.7	0.8	6.10	1	1	1
10/28/2021 22:00	1.2	12.6	2,013.5	0.9	6.00	1	1	1
10/28/2021 23:00	1.1	12.8	1,954.1	0.8	5.90	1	1	1
Average/Sum#:	3.3	13.4	1,681.5	4.6	120.73 #	13 #	10 #	9 #
Minimum:	0.3	12.0	281.5	0.3	1.50	0	0	0
Maximum:	18.1	18.1	2,130.0	38.1	44.30	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/29/2021 00:00	1.0	13.2	1,899.0	0.8	5.70	1	1	1
10/29/2021 01:00	0.9	13.2	1,903.3	0.7	5.70	1	1	1
10/29/2021 02:00	0.9	13.2	1,896.5	0.7	5.70	1	1	1
10/29/2021 03:00	0.9	13.2	1,895.9	0.7	5.70	1	1	1
10/29/2021 04:00	0.9	13.2	1,896.0	0.7	5.70	1	1	1
10/29/2021 05:00	0.9	13.2	1,898.2	0.7	5.70	1	1	1
10/29/2021 06:00	0.9	13.2	1,900.8	0.7	5.70	1	1	1
10/29/2021 07:00	0.9	13.2	1,898.4	0.7	5.70	1	1	1
10/29/2021 08:00	0.9	13.2	1,897.8	0.7	5.70	1	1	1
10/29/2021 09:00	0.8	13.3	1,705.9	0.6	3.40	1	1	1
10/29/2021 10:00	0.4	13.8	1,410.3	0.3	1.40	1	1	1
10/29/2021 11:00	1.0	13.0	1,915.2	0.7	5.70	1	1	1
10/29/2021 12:00	0.8	13.2	1,708.9	0.6	3.40	1	1	1
10/29/2021 13:00	0.4	13.8	1,404.1	0.3	1.40	1	1	1
10/29/2021 14:00	1.0	12.8	1,922.5	0.7	5.80	1	1	1
10/29/2021 15:00	1.0	12.8	1,923.0	0.7	5.80	1	1	1
10/29/2021 16:00	1.0	12.9	1,920.3	0.7	5.80	1	1	1
10/29/2021 17:00	1.0	12.9	1,917.5	0.7	5.80	1	1	1
10/29/2021 18:00	1.0	12.9	1,914.0	0.7	5.70	1	1	1
10/29/2021 19:00	1.0	12.9	1,912.5	0.7	5.70	1	1	1
10/29/2021 20:00	1.0	12.9	1,911.0	0.7	5.70	1	1	1
10/29/2021 21:00	1.0	13.0	1,909.3	0.7	5.70	1	1	1
10/29/2021 22:00	0.9	13.0	1,903.6	0.7	3.80	1	1	1
10/29/2021 23:00	1.0	12.7	1,964.6	0.7	5.90	1	1	1
Average/Sum#:	0.9	13.1	1,851.2	0.7	122.30 #	24 #	24 #	24 #
Minimum:	0.4	12.7	1,404.1	0.3	1.40	1	1	1
Maximum:	1.0	13.8	1,964.6	0.8	5.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/30/2021 00:00	0.5	13.8	1,631.0	0.4	3.30	1	1	1
10/30/2021 01:00	0.4	13.9	1,445.3	0.3	1.40	1	1	0
10/30/2021 02:00	0.7	13.3	1,739.8	0.5	3.50	1	1	1
10/30/2021 03:00	0.9	13.1	1,891.1	0.7	5.70	1	1	1
10/30/2021 04:00	0.5	13.9	1,600.7	0.4	3.20	1	1	0
10/30/2021 05:00	0.5	13.8	1,664.5	0.4	3.30	1	1	1
10/30/2021 06:00	0.9	12.8	1,977.2	0.7	4.00	1	1	1
10/30/2021 07:00	0.9	13.1	1,904.1	0.7	5.70	1	1	1
10/30/2021 08:00	0.4	13.9	1,508.7	0.3	1.50	1	1	0
10/30/2021 09:00	0.4	13.9	1,506.0	0.3	1.50	1	1	0
10/30/2021 10:00	0.4	13.9	1,513.5	0.3	1.50	1	1	0
10/30/2021 11:00	0.4	13.9	1,555.7	0.3	1.60	1	1	0
10/30/2021 12:00	0.3	14.0	1,374.2	0.3	1.40	1	1	0
10/30/2021 13:00	0.3	14.0	1,385.3	0.3	1.40	1	1	0
10/30/2021 14:00	0.4	14.0	1,502.2	0.3	1.50	1	1	0
10/30/2021 15:00	0.5	13.9	1,582.2	0.4	3.20	1	1	1
10/30/2021 16:00	1.0	12.7	1,999.1	0.7	6.00	1	1	1
10/30/2021 17:00	1.3	12.4	2,059.0	0.9	6.20	1	1	1
10/30/2021 18:00	1.1	12.6	2,035.9	0.8	6.10	1	1	1
10/30/2021 19:00	1.1	12.8	1,971.6	0.8	5.90	1	1	1
10/30/2021 20:00	0.5	13.9	1,647.4	0.4	3.30	1	1	0
10/30/2021 21:00	0.4	13.9	1,615.0	0.3	1.60	1	1	1
10/30/2021 22:00	0.9	12.9	1,967.5	0.7	3.90	1	1	1
10/30/2021 23:00	1.0	13.2	1,904.1	0.8	5.70	1	1	1
Average/Sum#:	0.7	13.5	1,707.5	0.5	82.40 #	24 #	24 #	14 #
Minimum:	0.3	12.4	1,374.2	0.3	1.40	1	1	0
Maximum:	1.3	14.0	2,059.0	0.9	6.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/31/2021 00:00	0.4	13.9	1,635.0	0.3	1.60	1	1	0
10/31/2021 01:00	0.4	13.9	1,544.4	0.3	1.50	1	1	1
10/31/2021 02:00	0.8	13.2	1,920.3	0.6	3.80	1	1	1
10/31/2021 03:00	0.9	13.2	1,904.6	0.7	5.70	1	1	1
10/31/2021 04:00	0.4	13.9	1,665.6	0.3	1.70	1	1	0
10/31/2021 05:00	0.4	13.9	1,535.1	0.3	1.50	1	1	1
10/31/2021 06:00	1.0	12.9	1,989.0	0.7	6.00	1	1	1
10/31/2021 07:00	0.8	13.2	1,904.0	0.6	3.80	1	1	1
10/31/2021 08:00	0.4	13.9	1,622.9	0.3	1.60	1	1	0
10/31/2021 09:00	0.4	13.9	1,560.0	0.3	1.60	1	1	0
10/31/2021 10:00	0.3	14.0	1,385.0	0.3	1.40	1	1	0
10/31/2021 11:00	0.4	13.9	1,525.8	0.3	1.50	1	1	0
10/31/2021 12:00	0.4	13.9	1,573.1	0.3	1.60	1	1	0
10/31/2021 13:00	0.4	13.9	1,655.3	0.3	1.70	1	1	0
10/31/2021 14:00	0.4	14.0	1,537.8	0.3	1.50	1	1	0
10/31/2021 15:00	0.5	13.9	1,575.6	0.4	3.20	1	1	1
10/31/2021 16:00	0.9	13.0	1,960.3	0.7	3.90	1	1	1
10/31/2021 17:00	1.0	12.8	2,002.8	0.7	6.00	1	1	1
10/31/2021 18:00	1.0	12.8	2,011.6	0.7	6.00	1	1	1
10/31/2021 19:00	1.0	13.1	1,912.1	0.8	5.70	1	1	1
10/31/2021 20:00	0.5	13.9	1,666.5	0.4	3.30	1	1	0
10/31/2021 21:00	0.4	13.9	1,549.5	0.3	1.50	1	1	1
10/31/2021 22:00	0.9	12.9	1,964.6	0.7	3.90	1	1	1
10/31/2021 23:00	1.0	13.1	1,903.5	0.8	5.70	1	1	1
Average/Sum#:	0.6	13.5	1,729.4	0.5	75.70 #	24 #	24 #	14 #
Minimum:	0.3	12.8	1,385.0	0.3	1.40	1	1	0
Maximum:	1.0	14.0	2,011.6	0.8	6.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/01/2021 00:00	0.5	13.9	1,599.7	0.4	3.20	1	1	0
11/01/2021 01:00	0.5	13.8	1,658.0	0.4	3.30	1	1	1
11/01/2021 02:00	0.9	13.2	1,905.2	0.7	5.70	1	1	1
11/01/2021 03:00	1.0	12.9	1,959.2	0.7	5.90	1	1	1
11/01/2021 04:00	0.5	13.9	1,572.7	0.4	3.10	1	1	1
11/01/2021 05:00	0.5	13.8	1,659.3	0.4	3.30	1	1	1
11/01/2021 06:00	1.0	12.7	2,012.0	0.7	6.00	1	1	1
11/01/2021 07:00	1.1	12.5	2,060.9	0.8	6.20	1	1	1
11/01/2021 08:00	1.0	13.0	1,925.5	0.7	5.80	1	1	1
11/01/2021 09:00	0.4	13.9	1,547.0	0.3	1.50	1	1	0
11/01/2021 10:00	0.4	13.9	1,501.1	0.3	1.50	1	1	1
11/01/2021 11:00	1.0	12.8	1,991.3	0.7	6.00	1	1	1
11/01/2021 12:00	1.1	12.7	1,983.5	0.8	6.00	1	1	1
11/01/2021 13:00	0.5	13.9	1,680.6	0.4	3.40	1	1	0
11/01/2021 14:00	0.7	13.7	1,758.6	0.6	3.50	1	1	0
11/01/2021 15:00	0.9	12.8	1,980.0	0.7	4.00	1	1	1
11/01/2021 16:00	1.1	12.7	2,020.2	0.8	6.10	1	1	1
11/01/2021 17:00	1.2	12.2	2,129.7	0.8	6.40	1	1	1
11/01/2021 18:00	1.2	12.3	2,097.3	0.8	6.30	1	1	1
11/01/2021 19:00	1.2	12.2	2,125.2	0.8	6.40	1	1	1
11/01/2021 20:00	1.3	12.2	2,139.6	0.9	6.40	1	1	1
11/01/2021 21:00	1.2	12.2	2,128.1	0.8	6.40	1	1	1
11/01/2021 22:00	1.1	12.6	2,040.1	0.8	6.10	1	1	1
11/01/2021 23:00	0.9	13.2	1,893.4	0.7	5.70	1	1	1
Average/Sum#:	0.9	13.0	1,890.3	0.6	118.20 #	24 #	24 #	20 #
Minimum:	0.4	12.2	1,501.1	0.3	1.50	1	1	0
Maximum:	1.3	13.9	2,139.6	0.9	6.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/02/2021 00:00	0.5	13.9	1,534.0	0.4	3.10	1	1	0
11/02/2021 01:00	0.4	13.9	1,557.3	0.3	1.60	1	1	0
11/02/2021 02:00	0.8	13.2	1,923.9	0.6	3.80	1	1	1
11/02/2021 03:00	0.9	13.1	1,919.3	0.7	5.80	1	1	1
11/02/2021 04:00	0.5	13.8	1,623.3	0.4	3.20	1	1	1
11/02/2021 05:00	0.4	13.9	1,605.1	0.3	1.60	1	1	1
11/02/2021 06:00	1.0	12.8	2,010.9	0.7	6.00	1	1	1
11/02/2021 07:00	1.0	12.8	2,011.2	0.7	6.00	1	1	1
11/02/2021 08:00	0.8	13.2	1,910.7	0.6	3.80	1	1	1
11/02/2021 09:00	0.4	13.9	1,500.3	0.3	1.50	1	1	0
11/02/2021 10:00	0.4	13.9	1,605.1	0.3	1.60	1	1	0
11/02/2021 11:00	0.2	14.0	1,301.3	0.2	1.30	1	1	0
11/02/2021 12:00	0.4	14.0	1,496.6	0.3	1.50	1	1	0
11/02/2021 13:00	0.4	13.9	1,597.3	0.3	1.60	1	1	0
11/02/2021 14:00	0.4	14.0	1,583.7	0.3	1.60	1	1	0
11/02/2021 15:00	0.5	13.9	1,610.2	0.4	3.20	1	1	1
11/02/2021 16:00	1.0	12.7	2,000.1	0.7	6.00	1	1	1
11/02/2021 17:00	1.3	12.3	2,109.6	0.9	6.30	1	1	1
11/02/2021 18:00	1.3	12.3	2,105.5	0.9	6.30	1	1	1
11/02/2021 19:00	1.4	12.1	2,173.6	0.9	6.50	1	1	1
11/02/2021 20:00	1.3	12.3	2,111.5	0.9	6.30	1	1	1
11/02/2021 21:00	1.2	12.4	2,093.2	0.8	6.30	1	1	1
11/02/2021 22:00	1.2	12.5	2,076.7	0.8	6.20	1	1	1
11/02/2021 23:00	1.0	13.0	1,931.8	0.7	5.80	1	1	1
Average/Sum#:	0.8	13.2	1,808.0	0.6	96.90 #	24 #	24 #	16 #
Minimum:	0.2	12.1	1,301.3	0.2	1.30	1	1	0
Maximum:	1.4	14.0	2,173.6	0.9	6.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/03/2021 00:00	0.5	13.9	1,667.3	0.4	3.30	1	1	0
11/03/2021 01:00	0.5	13.8	1,613.3	0.4	3.20	1	1	1
11/03/2021 02:00	0.9	13.2	1,905.7	0.7	5.70	1	1	1
11/03/2021 03:00	0.8	13.2	1,906.7	0.6	3.80	1	1	1
11/03/2021 04:00	0.4	13.9	1,638.8	0.3	1.60	1	1	1
11/03/2021 05:00	0.5	13.8	1,759.8	0.4	3.50	1	1	1
11/03/2021 06:00	1.0	13.0	1,959.8	0.7	5.90	1	1	1
11/03/2021 07:00	0.9	13.1	1,944.7	0.7	5.80	1	1	1
11/03/2021 08:00	0.5	13.8	1,649.3	0.4	3.30	1	1	1
11/03/2021 09:00	0.4	13.9	1,661.6	0.3	1.70	1	1	0
11/03/2021 10:00	0.4	13.9	1,552.3	0.3	1.60	1	1	0
11/03/2021 11:00	0.4	13.9	1,662.2	0.3	1.70	1	1	0
11/03/2021 12:00	0.4	14.0	1,507.5	0.3	1.50	1	1	0
11/03/2021 13:00	0.4	14.0	1,661.5	0.3	1.70	1	1	0
11/03/2021 14:00	0.4	14.0	1,488.6	0.3	1.50	1	1	0
11/03/2021 15:00	0.5	13.9	1,562.0	0.4	3.10	1	1	1
11/03/2021 16:00	1.0	12.7	1,987.1	0.7	6.00	1	1	1
11/03/2021 17:00	1.4	12.1	2,126.0	0.9	6.40	1	1	1
11/03/2021 18:00	1.2	12.3	2,086.9	0.8	6.30	1	1	1
11/03/2021 19:00	1.4	12.1	2,138.7	0.9	6.40	1	1	1
11/03/2021 20:00	1.3	12.2	2,124.9	0.9	6.40	1	1	1
11/03/2021 21:00	1.2	12.4	2,081.7	0.8	6.20	1	1	1
11/03/2021 22:00	1.1	12.6	2,032.9	0.8	6.10	1	1	1
11/03/2021 23:00	1.0	13.0	1,906.5	0.7	5.70	1	1	1
Average/Sum#:	0.8	13.3	1,817.7	0.6	98.40 #	24 #	24 #	17 #
Minimum:	0.4	12.1	1,488.6	0.3	1.50	1	1	0
Maximum:	1.4	14.0	2,138.7	0.9	6.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/04/2021 00:00	0.4	13.9	1,453.2	0.3	1.50	1	1	0
11/04/2021 01:00	0.5	13.8	1,566.5	0.4	3.10	1	1	1
11/04/2021 02:00	0.9	13.1	1,912.8	0.7	5.70	1	1	1
11/04/2021 03:00	1.0	12.9	1,944.2	0.7	5.80	1	1	1
11/04/2021 04:00	0.5	13.8	1,664.8	0.4	3.30	1	1	1
11/04/2021 05:00	0.7	13.8	1,743.5	0.6	3.50	1	1	1
11/04/2021 06:00	1.0	12.8	1,968.8	0.7	5.90	1	1	1
11/04/2021 07:00	1.1	12.8	1,950.1	0.8	5.90	1	1	1
11/04/2021 08:00	0.4	13.9	1,566.2	0.3	1.60	1	1	0
11/04/2021 09:00	0.4	14.0	1,498.9	0.3	1.50	1	1	0
11/04/2021 10:00	0.4	14.0	1,491.2	0.3	1.50	1	1	0
11/04/2021 11:00	0.4	14.0	1,465.8	0.3	1.50	1	1	0
11/04/2021 12:00	0.3	14.0	1,365.4	0.3	1.40	1	1	0
11/04/2021 13:00	0.4	14.0	1,524.8	0.3	1.50	1	1	0
11/04/2021 14:00	0.4	14.0	1,632.8	0.3	1.60	1	1	0
11/04/2021 15:00	0.4	14.0	1,534.7	0.3	1.50	1	1	0
11/04/2021 16:00	0.9	12.9	1,953.0	0.7	3.90	1	1	1
11/04/2021 17:00	1.1	12.6	2,029.2	0.8	6.10	1	1	1
11/04/2021 18:00	1.1	12.7	1,999.2	0.8	6.00	1	1	1
11/04/2021 19:00	0.5	13.9	1,661.5	0.4	3.30	1	1	1
11/04/2021 20:00	0.4	13.9	1,605.9	0.3	1.60	1	1	1
11/04/2021 21:00	1.0	12.9	1,988.3	0.7	6.00	1	1	1
11/04/2021 22:00	0.7	13.4	1,653.9	0.6	3.30	1	1	1
11/04/2021 23:00	1.9	15.1	862.3	1.9	2.28	1	0	0
Average/Sum#:	0.7	13.6	1,668.2	0.6	79.28 #	24 #	23 #	14 #
Minimum:	0.3	12.6	862.3	0.3	1.40	1	0	0
Maximum:	1.9	15.1	2,029.2	1.9	6.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/05/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/05/2021 13:00	22.5	17.7	339.3	41.5	35.29	1	0	0
11/05/2021 14:00	6.5	14.7	1,252.5	6.2	28.80	1	0	0
11/05/2021 15:00	0.5	13.9	1,542.8	0.4	3.10	1	1	1
11/05/2021 16:00	0.9	12.7	2,027.7	0.6	4.10	1	1	1
11/05/2021 17:00	1.1	12.5	2,056.9	0.8	6.20	1	1	1
11/05/2021 18:00	1.1	12.7	2,038.7	0.8	6.10	1	1	1
11/05/2021 19:00	1.0	12.9	1,945.0	0.7	5.80	1	1	1
11/05/2021 20:00	0.5	13.9	1,644.4	0.4	3.30	1	1	0
11/05/2021 21:00	0.5	13.8	1,758.5	0.4	3.50	1	1	1
11/05/2021 22:00	0.8	13.0	1,976.7	0.6	4.00	1	1	1
11/05/2021 23:00	0.9	13.2	1,922.0	0.7	5.80	1	1	1
Average/Sum#:	3.3	13.7	1,682.2	4.8	105.99 #	11 #	9 #	8 #
Minimum:	0.5	12.5	339.3	0.4	3.10	0	0	0
Maximum:	22.5	17.7	2,056.9	41.5	35.29	1	1	1
%SI	54.17	54.17	54.17	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/06/2021 00:00	0.5	13.8	1,664.2	0.4	3.30	1	1	1
11/06/2021 01:00	0.4	13.9	1,572.1	0.3	1.60	1	1	0
11/06/2021 02:00	0.7	13.3	1,895.0	0.5	3.80	1	1	1
11/06/2021 03:00	0.8	13.2	1,915.3	0.6	3.80	1	1	1
11/06/2021 04:00	0.4	13.9	1,663.3	0.3	1.70	1	1	1
11/06/2021 05:00	0.4	13.9	1,592.6	0.3	1.60	1	1	1
11/06/2021 06:00	1.0	12.9	1,968.5	0.7	5.90	1	1	1
11/06/2021 07:00	0.9	13.1	1,912.4	0.7	5.70	1	1	1
11/06/2021 08:00	0.4	13.9	1,585.1	0.3	1.60	1	1	0
11/06/2021 09:00	0.4	13.9	1,583.7	0.3	1.60	1	1	0
11/06/2021 10:00	0.4	13.9	1,588.6	0.3	1.60	1	1	0
11/06/2021 11:00	0.4	13.9	1,524.7	0.3	1.50	1	1	0
11/06/2021 12:00	0.4	13.9	1,519.7	0.3	1.50	1	1	0
11/06/2021 13:00	0.4	13.9	1,550.3	0.3	1.60	1	1	0
11/06/2021 14:00	0.3	14.0	1,456.7	0.3	1.50	1	1	0
11/06/2021 15:00	0.5	13.9	1,562.8	0.4	3.10	1	1	0
11/06/2021 16:00	0.9	12.9	1,960.0	0.7	3.90	1	1	1
11/06/2021 17:00	1.2	12.5	2,037.2	0.8	6.10	1	1	1
11/06/2021 18:00	1.0	13.1	1,901.0	0.8	5.70	1	1	1
11/06/2021 19:00	0.5	13.9	1,642.7	0.4	3.30	1	1	0
11/06/2021 20:00	0.5	13.8	1,655.9	0.4	3.30	1	1	1
11/06/2021 21:00	0.9	13.1	1,946.8	0.7	5.80	1	1	1
11/06/2021 22:00	2.0	14.0	1,448.1	1.7	6.35	1	0	1
11/06/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.7	13.6	1,702.0	0.5	75.85 #	23 #	22 #	13 #
Minimum:	0.3	12.5	1,448.1	0.3	1.50	0	0	0
Maximum:	2.0	14.0	2,037.2	1.7	6.35	1	1	1
%SI	4.17	4.17	4.17	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/07/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/07/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/08/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/08/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/08/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/08/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/08/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/08/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/08/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/08/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/08/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/08/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/08/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/08/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/08/2021 12:00	26.8	18.0	282.3	54.5	40.82	1	0	0
11/08/2021 13:00	14.6	16.9	504.9	21.5	39.90	1	0	0
11/08/2021 14:00	16.2	15.2	931.0	16.8	57.70	1	0	0
11/08/2021 15:00	0.4	14.0	1,644.3	0.3	1.60	1	1	0
11/08/2021 16:00	0.0	0.0	2,007.5	0.0	0.00	1	1	1
11/08/2021 17:00	1.4	12.1	2,126.2	0.9	6.40	1	1	1
11/08/2021 18:00	1.2	12.9	1,973.7	0.9	5.90	1	1	1
11/08/2021 19:00	1.0	13.1	1,940.4	0.8	5.80	1	1	1
11/08/2021 20:00	1.4	12.4	2,104.2	1.0	8.40	1	1	1
11/08/2021 21:00	1.3	12.6	2,057.7	0.9	6.20	1	1	1
11/08/2021 22:00	0.8	13.3	1,880.3	0.6	3.80	1	1	1
11/08/2021 23:00	2.7	15.8	561.5	3.1	1.47	1	0	0
Average/Sum#:	6.2	14.2	1,501.2	9.2	177.99 #	12 #	8 #	7 #
Minimum:	0.4	12.1	282.3	0.3	1.47	0	0	0
Maximum:	26.8	18.0	2,126.2	54.5	57.70	1	1	1
%SI	54.17	54.17	50.00	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/09/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/09/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/09/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/09/2021 03:00	2.7	18.1	303.5	5.7	2.24	1	0	0
11/09/2021 04:00	5.7	15.4	905.7	6.1	20.80	1	0	0
11/09/2021 05:00	0.4	13.9	1,498.9	0.3	1.50	1	1	0
11/09/2021 06:00	0.4	13.9	1,538.4	0.3	1.50	1	1	0
11/09/2021 07:00	0.6	13.8	1,742.0	0.5	3.50	1	1	0
11/09/2021 08:00	0.4	13.9	1,539.3	0.3	1.50	1	1	0
11/09/2021 09:00	0.5	13.9	1,681.6	0.4	3.40	1	1	0
11/09/2021 10:00	0.4	13.9	1,491.2	0.3	1.50	1	1	0
11/09/2021 11:00	0.4	13.9	1,546.2	0.3	1.50	1	1	0
11/09/2021 12:00	0.4	13.9	1,517.2	0.3	1.50	1	1	0
11/09/2021 13:00	0.5	13.9	1,647.6	0.4	3.30	1	1	0
11/09/2021 14:00	0.4	13.9	1,596.7	0.3	1.60	1	1	0
11/09/2021 15:00	0.4	13.9	1,497.0	0.3	1.50	1	1	0
11/09/2021 16:00	0.4	13.9	1,538.2	0.3	1.50	1	1	0
11/09/2021 17:00	0.7	13.4	1,821.2	0.6	3.60	1	1	1
11/09/2021 18:00	1.0	12.5	2,080.4	0.7	6.20	1	1	1
11/09/2021 19:00	1.2	12.3	2,136.6	0.8	6.40	1	1	1
11/09/2021 20:00	1.1	12.5	2,052.3	0.8	6.20	1	1	1
11/09/2021 21:00	0.5	13.9	1,580.5	0.4	3.20	1	1	0
11/09/2021 22:00	0.5	13.8	1,692.7	0.4	3.40	1	1	0
11/09/2021 23:00	0.8	13.0	1,962.9	0.6	3.90	1	1	1
Average/Sum#:	0.9	13.9	1,589.1	1.0	79.74 #	21 #	19 #	5 #
Minimum:	0.4	12.3	303.5	0.3	1.50	0	0	0
Maximum:	5.7	18.1	2,136.6	6.1	20.80	1	1	1
%SI	12.50	12.50	12.50	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/10/2021 00:00	0.8	13.4	1,806.2	0.6	3.60	1	1	1
11/10/2021 01:00	0.7	13.7	1,760.1	0.6	3.50	1	1	0
11/10/2021 02:00	0.4	13.9	1,557.6	0.3	1.60	1	1	1
11/10/2021 03:00	0.7	13.2	1,927.4	0.5	3.90	1	1	1
11/10/2021 04:00	0.8	13.2	1,909.8	0.6	3.80	1	1	1
11/10/2021 05:00	0.5	13.9	1,677.6	0.4	3.40	1	1	0
11/10/2021 06:00	0.5	13.9	1,762.0	0.4	3.50	1	1	1
11/10/2021 07:00	0.8	13.2	1,951.5	0.6	3.90	1	1	1
11/10/2021 08:00	0.8	13.2	1,908.2	0.6	3.80	1	1	1
11/10/2021 09:00	0.4	14.0	1,528.6	0.3	1.50	1	1	0
11/10/2021 10:00	0.4	14.0	1,453.0	0.3	1.50	1	1	0
11/10/2021 11:00	0.3	14.0	1,402.4	0.3	1.40	1	1	0
11/10/2021 12:00	0.4	14.0	1,450.4	0.3	1.50	1	1	0
11/10/2021 13:00	0.3	14.0	1,325.7	0.3	1.30	1	1	0
11/10/2021 14:00	0.4	14.0	1,458.8	0.3	1.50	1	1	0
11/10/2021 15:00	0.5	13.9	1,559.2	0.4	3.10	1	1	1
11/10/2021 16:00	0.9	13.0	1,964.7	0.7	3.90	1	1	1
11/10/2021 17:00	1.0	12.9	1,981.1	0.7	5.90	1	1	1
11/10/2021 18:00	1.1	12.7	2,026.0	0.8	6.10	1	1	1
11/10/2021 19:00	1.1	12.7	2,021.3	0.8	6.10	1	1	1
11/10/2021 20:00	1.1	12.9	1,958.1	0.8	5.90	1	1	1
11/10/2021 21:00	0.5	13.9	1,671.4	0.4	3.30	1	1	0
11/10/2021 22:00	0.5	13.8	1,746.1	0.4	3.50	1	1	1
11/10/2021 23:00	0.9	12.9	1,985.2	0.7	4.00	1	1	1
Average/Sum#:	0.7	13.5	1,741.4	0.5	81.50 #	24 #	24 #	15 #
Minimum:	0.3	12.7	1,325.7	0.3	1.30	1	1	0
Maximum:	1.1	14.0	2,026.0	0.8	6.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/11/2021 00:00	1.0	13.1	1,912.6	0.8	5.70	1	1	1
11/11/2021 01:00	3.9	15.8	583.8	4.5	2.28	1	0	0
11/11/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/11/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/11/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/11/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/11/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/11/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/11/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/11/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/11/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/11/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/11/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/11/2021 13:00	24.5	17.8	323.9	46.6	30.64	1	0	0
11/11/2021 14:00	10.8	15.0	1,021.2	10.8	40.80	1	0	0
11/11/2021 15:00	0.5	13.9	1,628.0	0.4	3.30	1	1	0
11/11/2021 16:00	0.8	13.4	1,781.2	0.6	3.60	1	1	1
11/11/2021 17:00	1.1	12.5	2,048.6	0.8	6.10	1	1	1
11/11/2021 18:00	1.1	12.5	2,052.8	0.8	6.20	1	1	1
11/11/2021 19:00	1.1	12.5	2,058.1	0.8	6.20	1	1	1
11/11/2021 20:00	1.1	12.5	2,034.5	0.8	6.10	1	1	1
11/11/2021 21:00	0.5	13.9	1,660.4	0.4	3.30	1	1	0
11/11/2021 22:00	0.6	13.8	1,745.3	0.5	3.50	1	1	1
11/11/2021 23:00	0.9	13.0	1,952.9	0.7	3.90	1	1	1
Average/Sum#:	3.7	13.8	1,600.3	5.3	121.62 #	13 #	10 #	8 #
Minimum:	0.5	12.5	323.9	0.4	2.28	0	0	0
Maximum:	24.5	17.8	2,058.1	46.6	40.80	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/12/2021 00:00	0.8	13.2	1,897.7	0.6	3.80	1	1	1
11/12/2021 01:00	0.4	13.9	1,551.9	0.3	1.60	1	1	0
11/12/2021 02:00	0.4	13.9	1,520.6	0.3	1.50	1	1	0
11/12/2021 03:00	0.4	13.9	1,526.4	0.3	1.50	1	1	0
11/12/2021 04:00	0.4	13.9	1,549.7	0.3	1.50	1	1	1
11/12/2021 05:00	0.9	12.9	1,992.8	0.7	4.00	1	1	1
11/12/2021 06:00	1.1	12.8	2,022.2	0.8	6.10	1	1	1
11/12/2021 07:00	0.6	13.6	1,651.9	0.5	3.30	1	1	1
11/12/2021 08:00	1.6	15.1	871.0	1.6	2.08	1	0	0
11/12/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/12/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/12/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/12/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/12/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/12/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/12/2021 15:00	10.2	18.0	315.7	20.8	10.32	1	0	0
11/12/2021 16:00	7.1	15.7	835.3	8.1	25.10	1	0	0
11/12/2021 17:00	0.3	13.9	1,412.8	0.3	1.40	1	1	0
11/12/2021 18:00	0.5	13.9	1,563.6	0.4	3.10	1	1	1
11/12/2021 19:00	0.9	12.8	2,001.4	0.7	4.00	1	1	1
11/12/2021 20:00	1.0	13.0	1,940.4	0.7	5.80	1	1	1
11/12/2021 21:00	0.5	13.9	1,605.2	0.4	3.20	1	1	0
11/12/2021 22:00	0.5	13.8	1,667.1	0.4	3.30	1	1	1
11/12/2021 23:00	0.9	12.9	1,983.5	0.7	4.00	1	1	1
Average/Sum#:	1.6	14.0	1,550.5	2.1	85.60 #	18 #	15 #	10 #
Minimum:	0.3	12.8	315.7	0.3	1.40	0	0	0
Maximum:	10.2	18.0	2,022.2	20.8	25.10	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/13/2021 00:00	2.1	14.4	1,208.7	1.9	4.08	1	0	1
11/13/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/13/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/13/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/13/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/13/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/13/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/13/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/13/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/13/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/13/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/13/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/13/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/13/2021 13:00	19.3	17.7	347.6	35.6	31.85	1	0	0
11/13/2021 14:00	5.2	15.0	1,057.3	5.2	20.10	1	0	0
11/13/2021 15:00	0.5	13.9	1,671.8	0.4	3.30	1	1	0
11/13/2021 16:00	0.7	13.8	1,734.3	0.6	3.50	1	1	1
11/13/2021 17:00	0.9	12.9	1,981.2	0.7	4.00	1	1	1
11/13/2021 18:00	1.0	12.9	1,940.1	0.7	5.80	1	1	1
11/13/2021 19:00	0.5	13.9	1,679.5	0.4	3.40	1	1	0
11/13/2021 20:00	0.6	13.8	1,763.0	0.5	3.50	1	1	1
11/13/2021 21:00	0.9	12.9	1,979.3	0.7	4.00	1	1	1
11/13/2021 22:00	1.8	13.8	1,460.7	1.5	6.42	1	0	1
11/13/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	3.0	14.1	1,529.4	4.4	89.95 #	11 #	7 #	7 #
Minimum:	0.5	12.9	347.6	0.4	3.30	0	0	0
Maximum:	19.3	17.7	1,981.2	35.6	31.85	1	1	1
%SI	54.17	54.17	54.17	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/14/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/14/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/14/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/14/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/14/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/14/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/14/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/14/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/14/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/14/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/14/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/14/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/14/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/14/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/14/2021 14:00	11.6	18.6	217.0	29.8	5.26	1	0	0
11/14/2021 15:00	20.3	16.1	718.4	25.0	66.10	1	0	0
11/14/2021 16:00	0.2	14.0	1,293.1	0.2	1.30	1	1	0
11/14/2021 17:00	0.5	13.9	1,563.8	0.4	3.10	1	1	1
11/14/2021 18:00	0.9	12.8	2,003.8	0.7	4.00	1	1	1
11/14/2021 19:00	0.9	13.0	1,930.1	0.7	3.90	1	1	1
11/14/2021 20:00	0.6	13.7	1,703.6	0.5	3.40	1	1	1
11/14/2021 21:00	0.4	13.9	1,557.5	0.3	1.60	1	1	1
11/14/2021 22:00	0.9	12.8	1,998.8	0.7	4.00	1	1	1
11/14/2021 23:00	0.6	13.5	1,631.6	0.5	3.30	1	1	1
Average/Sum#:	3.7	14.2	1,461.8	5.9	95.96 #	10 #	8 #	7 #
Minimum:	0.2	12.8	217.0	0.2	1.30	0	0	0
Maximum:	20.3	18.6	2,003.8	29.8	66.10	1	1	1
%SI	58.33	58.33	58.33	58.33	58.33	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/15/2021 00:00	1.7	14.9	905.6	1.7	2.27	1	0	0
11/15/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/15/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/15/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/15/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/15/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/15/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/15/2021 07:00	13.5	18.0	324.5	27.5	13.78	1	0	0
11/15/2021 08:00	9.6	15.8	793.0	11.1	32.50	1	0	0
11/15/2021 09:00	0.2	13.9	1,396.9	0.2	1.40	1	1	0
11/15/2021 10:00	0.5	13.9	1,603.7	0.4	3.20	1	1	1
11/15/2021 11:00	0.8	13.2	1,929.8	0.6	3.90	1	1	1
11/15/2021 12:00	0.8	13.2	1,930.1	0.6	3.90	1	1	1
11/15/2021 13:00	0.5	13.8	1,501.1	0.4	3.00	1	1	1
11/15/2021 14:00	0.5	13.9	1,568.6	0.4	3.10	1	1	0
11/15/2021 15:00	0.8	13.1	1,912.9	0.6	3.80	1	1	1
11/15/2021 16:00	0.9	13.0	1,957.3	0.7	3.90	1	1	1
11/15/2021 17:00	0.8	13.2	1,919.1	0.6	3.80	1	1	1
11/15/2021 18:00	0.8	13.2	1,929.7	0.6	3.90	1	1	1
11/15/2021 19:00	1.0	12.8	2,023.8	0.7	6.10	1	1	1
11/15/2021 20:00	0.9	13.2	1,917.6	0.7	5.80	1	1	1
11/15/2021 21:00	0.9	13.2	1,913.8	0.7	5.70	1	1	1
11/15/2021 22:00	0.8	13.2	1,912.4	0.6	3.80	1	1	1
11/15/2021 23:00	0.9	13.2	1,893.0	0.7	5.70	1	1	1
Average/Sum#:	2.0	13.8	1,629.6	2.7	109.55 #	18 #	15 #	13 #
Minimum:	0.2	12.8	324.5	0.2	1.40	0	0	0
Maximum:	13.5	18.0	2,023.8	27.5	32.50	1	1	1
%SI	25.00	25.00	25.00	25.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/16/2021 00:00	3.8	15.7	597.7	4.3	2.21	1	0	0
11/16/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/16/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/16/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/16/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/16/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/16/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/16/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/16/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/16/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/16/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/16/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/16/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/16/2021 13:00	8.7	18.8	193.3	24.4	3.48	1	0	0
11/16/2021 14:00	23.6	16.7	536.5	33.2	65.50	1	0	0
11/16/2021 15:00	5.2	14.3	1,349.4	4.6	22.90	1	0	0
11/16/2021 16:00	0.5	14.0	1,478.2	0.4	3.00	1	1	0
11/16/2021 17:00	0.9	13.2	1,911.6	0.7	5.70	1	1	1
11/16/2021 18:00	1.1	12.9	2,005.0	0.8	6.00	1	1	1
11/16/2021 19:00	1.0	13.2	1,941.0	0.8	5.80	1	1	1
11/16/2021 20:00	1.2	12.5	2,091.7	0.8	6.30	1	1	1
11/16/2021 21:00	1.3	12.4	2,117.0	0.9	6.40	1	1	1
11/16/2021 22:00	1.3	12.7	2,026.9	0.9	6.10	1	1	1
11/16/2021 23:00	1.5	12.5	2,077.5	1.1	8.30	1	1	1
Average/Sum#:	4.2	14.1	1,527.2	6.1	141.69 #	12 #	8 #	7 #
Minimum:	0.5	12.4	193.3	0.4	2.21	0	0	0
Maximum:	23.6	18.8	2,117.0	33.2	65.50	1	1	1
%SI	50.00	50.00	50.00	50.00	50.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/17/2021 00:00	1.2	13.1	1,944.4	0.9	5.80	1	1	1
11/17/2021 01:00	1.2	13.3	1,908.2	0.9	5.70	1	1	1
11/17/2021 02:00	1.1	13.3	1,909.6	0.9	5.70	1	1	1
11/17/2021 03:00	1.1	13.3	1,910.5	0.9	5.70	1	1	1
11/17/2021 04:00	1.1	13.1	1,962.2	0.8	5.90	1	1	1
11/17/2021 05:00	1.0	13.1	1,983.4	0.8	6.00	1	1	1
11/17/2021 06:00	1.3	12.4	2,128.2	0.9	6.40	1	1	1
11/17/2021 07:00	1.1	12.7	2,054.3	0.8	6.20	1	1	1
11/17/2021 08:00	0.8	13.3	1,919.2	0.6	3.80	1	1	1
11/17/2021 09:00	0.9	13.3	1,907.6	0.7	5.70	1	1	1
11/17/2021 10:00	0.5	13.9	1,520.6	0.4	3.00	1	1	0
11/17/2021 11:00	0.8	13.5	1,840.5	0.6	3.70	1	1	1
11/17/2021 12:00	0.9	13.3	1,921.5	0.7	5.80	1	1	1
11/17/2021 13:00	0.5	13.7	1,482.9	0.4	3.00	1	1	1
11/17/2021 14:00	0.4	14.0	1,434.4	0.3	1.40	1	1	0
11/17/2021 15:00	0.9	13.1	1,908.9	0.7	5.70	1	1	1
11/17/2021 16:00	1.1	12.7	2,031.3	0.8	6.10	1	1	1
11/17/2021 17:00	1.3	12.4	2,103.6	0.9	6.30	1	1	1
11/17/2021 18:00	1.3	12.4	2,095.3	0.9	6.30	1	1	1
11/17/2021 19:00	1.4	12.3	2,122.7	1.0	8.50	1	1	1
11/17/2021 20:00	1.4	12.3	2,126.1	1.0	8.50	1	1	1
11/17/2021 21:00	1.2	12.7	2,041.8	0.9	6.10	1	1	1
11/17/2021 22:00	0.9	13.3	1,915.8	0.7	5.70	1	1	1
11/17/2021 23:00	0.8	13.3	1,909.3	0.6	3.80	1	1	1
Average/Sum#:	1.0	13.1	1,920.1	0.8	130.80 #	24 #	24 #	22 #
Minimum:	0.4	12.3	1,434.4	0.3	1.40	1	1	0
Maximum:	1.4	14.0	2,128.2	1.0	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/18/2021 00:00	0.8	13.3	1,908.0	0.6	3.80	1	1	1
11/18/2021 01:00	0.8	13.3	1,908.9	0.6	3.80	1	1	1
11/18/2021 02:00	0.8	13.3	1,911.8	0.6	3.80	1	1	1
11/18/2021 03:00	0.7	13.3	1,912.6	0.5	3.80	1	1	1
11/18/2021 04:00	0.7	13.3	1,912.7	0.5	3.80	1	1	1
11/18/2021 05:00	0.9	13.0	1,993.5	0.7	4.00	1	1	1
11/18/2021 06:00	1.2	12.5	2,097.3	0.8	6.30	1	1	1
11/18/2021 07:00	1.2	12.7	2,060.2	0.9	6.20	1	1	1
11/18/2021 08:00	1.0	13.0	1,978.8	0.7	5.90	1	1	1
11/18/2021 09:00	0.8	13.3	1,891.0	0.6	3.80	1	1	1
11/18/2021 10:00	0.5	13.9	1,635.9	0.4	3.30	1	1	1
11/18/2021 11:00	0.9	13.2	1,923.3	0.7	5.80	1	1	1
11/18/2021 12:00	0.9	13.2	1,919.7	0.7	5.80	1	1	1
11/18/2021 13:00	0.5	13.8	1,497.9	0.4	3.00	1	1	1
11/18/2021 14:00	0.4	13.9	1,474.9	0.3	1.50	1	1	0
11/18/2021 15:00	0.7	13.6	1,800.1	0.6	3.60	1	1	1
11/18/2021 16:00	1.1	12.6	2,063.1	0.8	6.20	1	1	1
11/18/2021 17:00	1.3	12.4	2,095.8	0.9	6.30	1	1	1
11/18/2021 18:00	1.4	12.1	2,150.3	0.9	6.50	1	1	1
11/18/2021 19:00	1.3	12.4	2,089.1	0.9	6.30	1	1	1
11/18/2021 20:00	1.2	12.7	2,036.3	0.9	6.10	1	1	1
11/18/2021 21:00	1.0	13.1	1,931.3	0.8	5.80	1	1	1
11/18/2021 22:00	0.9	13.2	1,909.9	0.7	5.70	1	1	1
11/18/2021 23:00	0.9	13.2	1,908.4	0.7	5.70	1	1	1
Average/Sum#:	0.9	13.1	1,917.1	0.7	116.80 #	24 #	24 #	23 #
Minimum:	0.4	12.1	1,474.9	0.3	1.50	1	1	0
Maximum:	1.4	13.9	2,150.3	0.9	6.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/19/2021 00:00	0.9	13.2	1,907.8	0.7	5.70	1	1	1
11/19/2021 01:00	0.9	13.2	1,877.7	0.7	5.60	1	1	1
11/19/2021 02:00	0.5	13.9	1,605.5	0.4	3.20	1	1	0
11/19/2021 03:00	0.8	13.2	1,910.6	0.6	3.80	1	1	1
11/19/2021 04:00	1.0	13.0	1,980.2	0.7	5.90	1	1	1
11/19/2021 05:00	1.1	12.8	2,016.6	0.8	6.00	1	1	1
11/19/2021 06:00	1.2	12.7	2,051.7	0.9	6.20	1	1	1
11/19/2021 07:00	1.1	12.7	2,030.6	0.8	6.10	1	1	1
11/19/2021 08:00	1.0	13.2	1,932.1	0.8	5.80	1	1	1
11/19/2021 09:00	0.8	13.3	1,905.6	0.6	3.80	1	1	1
11/19/2021 10:00	0.9	13.3	1,912.0	0.7	5.70	1	1	1
11/19/2021 11:00	1.0	13.2	1,930.4	0.8	5.80	1	1	1
11/19/2021 12:00	1.0	13.2	1,925.4	0.8	5.80	1	1	1
11/19/2021 13:00	1.1	12.8	2,029.7	0.8	6.10	1	1	1
11/19/2021 14:00	1.1	12.7	2,028.8	0.8	6.10	1	1	1
11/19/2021 15:00	1.1	13.0	1,966.6	0.8	5.90	1	1	1
11/19/2021 16:00	1.1	12.9	1,989.8	0.8	6.00	1	1	1
11/19/2021 17:00	1.0	12.9	2,000.4	0.7	6.00	1	1	1
11/19/2021 18:00	1.1	12.9	2,007.9	0.8	6.00	1	1	1
11/19/2021 19:00	1.0	13.2	1,901.9	0.8	5.70	1	1	1
11/19/2021 20:00	0.5	13.9	1,648.2	0.4	3.30	1	1	0
11/19/2021 21:00	0.6	13.8	1,727.9	0.5	3.50	1	1	1
11/19/2021 22:00	1.0	13.1	1,944.7	0.8	5.80	1	1	1
11/19/2021 23:00	1.1	13.1	1,933.8	0.8	5.80	1	1	1
Average/Sum#:	1.0	13.1	1,923.6	0.7	129.60 #	24 #	24 #	22 #
Minimum:	0.5	12.7	1,605.5	0.4	3.20	1	1	0
Maximum:	1.2	13.9	2,051.7	0.9	6.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/20/2021 00:00	1.0	13.2	1,898.5	0.8	5.70	1	1	1
11/20/2021 01:00	0.5	14.0	1,549.2	0.4	3.10	1	1	0
11/20/2021 02:00	0.4	14.0	1,527.0	0.3	1.50	1	1	0
11/20/2021 03:00	0.4	14.0	1,525.7	0.3	1.50	1	1	0
11/20/2021 04:00	0.5	13.9	1,663.4	0.4	3.30	1	1	1
11/20/2021 05:00	1.0	12.9	1,993.6	0.7	6.00	1	1	1
11/20/2021 06:00	1.1	13.1	1,956.4	0.8	5.90	1	1	1
11/20/2021 07:00	0.5	14.0	1,612.3	0.4	3.20	1	1	0
11/20/2021 08:00	0.5	14.0	1,627.2	0.4	3.30	1	1	0
11/20/2021 09:00	0.4	14.0	1,451.4	0.3	1.50	1	1	0
11/20/2021 10:00	0.4	14.0	1,497.7	0.3	1.50	1	1	0
11/20/2021 11:00	0.4	14.0	1,562.8	0.3	1.60	1	1	0
11/20/2021 12:00	0.3	14.0	1,428.9	0.3	1.40	1	1	0
11/20/2021 13:00	0.4	14.0	1,466.0	0.3	1.50	1	1	0
11/20/2021 14:00	0.4	14.0	1,482.7	0.3	1.50	1	1	0
11/20/2021 15:00	0.6	13.9	1,586.5	0.5	3.20	1	1	1
11/20/2021 16:00	1.3	12.9	1,974.3	1.0	7.90	1	1	1
11/20/2021 17:00	1.5	12.8	2,011.6	1.1	8.00	1	1	1
11/20/2021 18:00	1.5	13.1	1,910.1	1.1	7.60	1	1	1
11/20/2021 19:00	0.6	14.0	1,680.4	0.5	3.40	1	1	0
11/20/2021 20:00	0.9	13.8	1,755.8	0.7	5.30	1	1	1
11/20/2021 21:00	1.4	12.9	1,985.2	1.0	7.90	1	1	1
11/20/2021 22:00	1.5	12.6	2,059.7	1.1	8.20	1	1	1
11/20/2021 23:00	1.2	13.3	1,833.8	0.9	5.50	1	1	1
Average/Sum#:	0.8	13.6	1,710.0	0.6	99.50 #	24 #	24 #	12 #
Minimum:	0.3	12.6	1,428.9	0.3	1.40	1	1	0
Maximum:	1.5	14.0	2,059.7	1.1	8.20	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/21/2021 00:00	0.6	13.9	1,713.0	0.5	3.40	1	1	1
11/21/2021 01:00	1.1	13.3	1,909.7	0.9	5.70	1	1	1
11/21/2021 02:00	1.5	14.2	1,404.0	1.3	6.51	1	0	1
11/21/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/21/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/21/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/21/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/21/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/21/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/21/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/21/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/21/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/21/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/21/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/21/2021 14:00	26.9	17.9	304.2	52.9	27.87	1	0	0
11/21/2021 15:00	13.5	16.1	733.6	16.6	44.70	1	0	0
11/21/2021 16:00	0.2	14.1	1,303.2	0.2	1.30	1	1	0
11/21/2021 17:00	0.6	14.0	1,548.9	0.5	3.10	1	1	1
11/21/2021 18:00	1.4	12.9	1,985.6	1.0	7.90	1	1	1
11/21/2021 19:00	1.5	12.7	1,997.8	1.1	8.00	1	1	1
11/21/2021 20:00	0.6	14.0	1,665.8	0.5	3.30	1	1	0
11/21/2021 21:00	1.0	13.9	1,749.7	0.8	5.20	1	1	0
11/21/2021 22:00	1.0	13.2	1,948.4	0.8	5.80	1	1	1
11/21/2021 23:00	0.7	13.6	1,668.6	0.6	3.30	1	1	1
Average/Sum#:	3.9	14.1	1,533.3	6.0	126.08 #	13 #	10 #	8 #
Minimum:	0.2	12.7	304.2	0.2	1.30	0	0	0
Maximum:	26.9	17.9	1,997.8	52.9	44.70	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/22/2021 00:00	2.3	15.0	923.0	2.3	3.48	1	0	0
11/22/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/22/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/22/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/22/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/22/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/22/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/22/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/22/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/22/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/22/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/22/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/22/2021 12:00	22.7	17.7	377.3	41.9	36.60	1	0	0
11/22/2021 13:00	9.6	14.7	1,148.0	9.1	39.00	1	0	0
11/22/2021 14:00	0.5	14.0	1,666.9	0.4	3.30	1	1	0
11/22/2021 15:00	0.6	13.9	1,713.2	0.5	3.40	1	1	0
11/22/2021 16:00	1.0	13.2	1,905.1	0.8	5.70	1	1	1
11/22/2021 17:00	1.2	12.8	2,005.5	0.9	6.00	1	1	1
11/22/2021 18:00	1.4	12.5	2,076.7	1.0	8.30	1	1	1
11/22/2021 19:00	1.3	12.5	2,068.7	0.9	6.20	1	1	1
11/22/2021 20:00	1.3	12.6	2,027.7	0.9	6.10	1	1	1
11/22/2021 21:00	0.5	13.9	1,610.0	0.4	3.20	1	1	0
11/22/2021 22:00	0.6	13.8	1,772.2	0.5	3.50	1	1	1
11/22/2021 23:00	1.0	12.9	1,987.2	0.7	6.00	1	1	1
Average/Sum#:	3.4	13.8	1,637.0	4.6	130.78 #	13 #	10 #	7 #
Minimum:	0.5	12.5	377.3	0.4	3.20	0	0	0
Maximum:	22.7	17.7	2,076.7	41.9	39.00	1	1	1
%SI	45.83	45.83	45.83	45.83	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/23/2021 00:00	1.0	13.2	1,915.6	0.8	5.70	1	1	1
11/23/2021 01:00	0.4	14.0	1,475.3	0.3	1.50	1	1	0
11/23/2021 02:00	0.5	13.9	1,674.0	0.4	3.30	1	1	1
11/23/2021 03:00	0.8	13.3	1,921.6	0.6	3.80	1	1	1
11/23/2021 04:00	0.8	13.3	1,896.0	0.6	3.80	1	1	1
11/23/2021 05:00	0.5	13.9	1,648.7	0.4	3.30	1	1	0
11/23/2021 06:00	0.6	13.8	1,596.1	0.5	3.20	1	1	0
11/23/2021 07:00	0.9	13.1	1,952.6	0.7	5.90	1	1	1
11/23/2021 08:00	1.1	13.0	1,946.6	0.8	5.80	1	1	1
11/23/2021 09:00	0.5	13.9	1,593.8	0.4	3.20	1	1	0
11/23/2021 10:00	0.4	13.9	1,543.8	0.3	1.50	1	1	0
11/23/2021 11:00	0.4	14.0	1,491.7	0.3	1.50	1	1	0
11/23/2021 12:00	0.3	14.0	1,373.5	0.3	1.40	1	1	0
11/23/2021 13:00	0.4	14.0	1,529.4	0.3	1.50	1	1	0
11/23/2021 14:00	0.5	14.0	1,626.3	0.4	3.30	1	1	0
11/23/2021 15:00	0.6	13.9	1,586.5	0.5	3.20	1	1	1
11/23/2021 16:00	1.2	12.8	1,993.9	0.9	6.00	1	1	1
11/23/2021 17:00	1.4	12.8	2,011.8	1.0	8.00	1	1	1
11/23/2021 18:00	1.4	12.8	2,018.4	1.0	8.10	1	1	1
11/23/2021 19:00	1.2	13.2	1,894.6	0.9	5.70	1	1	1
11/23/2021 20:00	0.6	14.0	1,676.8	0.5	3.40	1	1	0
11/23/2021 21:00	0.5	14.0	1,546.2	0.4	3.10	1	1	1
11/23/2021 22:00	1.1	13.0	1,993.3	0.8	6.00	1	1	1
11/23/2021 23:00	1.1	13.3	1,924.5	0.9	5.80	1	1	1
Average/Sum#:	0.8	13.5	1,743.0	0.6	98.00 #	24 #	24 #	14 #
Minimum:	0.3	12.8	1,373.5	0.3	1.40	1	1	0
Maximum:	1.4	14.0	2,018.4	1.0	8.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/24/2021 00:00	1.0	13.4	1,904.6	0.8	5.70	1	1	1
11/24/2021 01:00	0.4	14.0	1,484.5	0.3	1.50	1	1	0
11/24/2021 02:00	0.5	13.9	1,572.4	0.4	3.10	1	1	1
11/24/2021 03:00	0.9	13.3	1,922.9	0.7	5.80	1	1	1
11/24/2021 04:00	1.1	13.2	1,920.5	0.8	5.80	1	1	1
11/24/2021 05:00	0.5	14.0	1,645.0	0.4	3.30	1	1	0
11/24/2021 06:00	0.7	13.8	1,574.2	0.6	3.10	1	1	1
11/24/2021 07:00	1.1	13.1	1,955.5	0.8	5.90	1	1	1
11/24/2021 08:00	1.1	13.2	1,913.5	0.8	5.70	1	1	1
11/24/2021 09:00	0.5	14.0	1,631.5	0.4	3.30	1	1	0
11/24/2021 10:00	0.4	14.0	1,597.2	0.3	1.60	1	1	0
11/24/2021 11:00	0.5	14.0	1,666.2	0.4	3.30	1	1	0
11/24/2021 12:00	0.4	14.0	1,580.4	0.3	1.60	1	1	0
11/24/2021 13:00	0.5	14.0	1,604.4	0.4	3.20	1	1	0
11/24/2021 14:00	0.4	14.0	1,586.2	0.3	1.60	1	1	0
11/24/2021 15:00	0.6	13.9	1,648.8	0.5	3.30	1	1	1
11/24/2021 16:00	1.2	13.1	1,955.5	0.9	5.90	1	1	1
11/24/2021 17:00	1.5	12.9	1,995.0	1.1	8.00	1	1	1
11/24/2021 18:00	1.5	12.8	2,011.7	1.1	8.00	1	1	1
11/24/2021 19:00	1.5	12.9	1,968.2	1.1	7.90	1	1	1
11/24/2021 20:00	0.5	14.0	1,577.8	0.4	3.20	1	1	0
11/24/2021 21:00	0.7	13.9	1,719.7	0.6	3.40	1	1	1
11/24/2021 22:00	1.3	13.2	1,934.3	1.0	7.70	1	1	1
11/24/2021 23:00	1.4	13.3	1,876.8	1.1	7.50	1	1	1
Average/Sum#:	0.8	13.6	1,760.3	0.6	109.40 #	24 #	24 #	15 #
Minimum:	0.4	12.8	1,484.5	0.3	1.50	1	1	0
Maximum:	1.5	14.0	2,011.7	1.1	8.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/25/2021 00:00	5.8	15.9	568.1	6.8	3.27	1	0	0
11/25/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/25/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	5.8	15.9	568.1	6.8	3.27 #	1 #	0 #	0 #
Minimum:	5.8	15.9	568.1	6.8	3.27	0	0	0
Maximum:	5.8	15.9	568.1	6.8	3.27	1	0	0
%SI	95.83	95.83	95.83	95.83	95.83	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/26/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/26/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/27/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/27/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/28/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/28/2021 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/29/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/29/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/29/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/29/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/29/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/29/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/29/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/29/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/29/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/29/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/29/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/29/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/29/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/29/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/29/2021 14:00	27.9	17.7	319.7	51.4	42.49	1	0	0
11/29/2021 15:00	12.2	16.0	743.8	14.7	40.20	1	0	0
11/29/2021 16:00	0.6	13.9	1,657.4	0.5	3.30	1	1	0
11/29/2021 17:00	1.0	13.0	1,893.5	0.7	5.70	1	1	1
11/29/2021 18:00	1.3	12.5	2,040.3	0.9	6.10	1	1	1
11/29/2021 19:00	1.2	12.8	1,984.1	0.9	6.00	1	1	1
11/29/2021 20:00	0.6	13.9	1,625.1	0.5	3.30	1	1	1
11/29/2021 21:00	0.7	13.8	1,767.3	0.6	3.50	1	1	1
11/29/2021 22:00	0.9	13.1	1,940.2	0.7	5.80	1	1	1
11/29/2021 23:00	2.8	14.4	1,198.0	2.5	5.08	1	0	1
Average/Sum#:	4.9	14.1	1,516.9	7.3	121.47 #	10 #	7 #	7 #
Minimum:	0.6	12.5	319.7	0.5	3.30	0	0	0
Maximum:	27.9	17.7	2,040.3	51.4	42.49	1	1	1
%SI	58.33	58.33	58.33	58.33	58.33	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/30/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/30/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/30/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/30/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/30/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/30/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/30/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/30/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
11/30/2021 08:00	20.8	18.1	303.1	43.8	18.54	1	0	0
11/30/2021 09:00	10.1	15.6	877.7	11.2	36.00	1	0	0
11/30/2021 10:00	0.7	13.8	1,771.8	0.6	3.50	1	1	0
11/30/2021 11:00	0.8	13.7	1,775.6	0.7	3.60	1	1	0
11/30/2021 12:00	0.8	13.8	1,749.2	0.7	3.50	1	1	0
11/30/2021 13:00	0.9	13.8	1,731.9	0.7	5.20	1	1	0
11/30/2021 14:00	0.9	13.8	1,724.6	0.7	5.20	1	1	0
11/30/2021 15:00	0.9	13.8	1,722.3	0.7	5.20	1	1	0
11/30/2021 16:00	0.9	13.8	1,725.3	0.7	5.20	1	1	0
11/30/2021 17:00	0.9	13.8	1,728.5	0.7	5.20	1	1	0
11/30/2021 18:00	1.0	13.8	1,726.0	0.8	5.20	1	1	0
11/30/2021 19:00	0.8	13.9	1,724.5	0.7	3.40	1	1	0
11/30/2021 20:00	0.7	13.9	1,689.7	0.6	3.40	1	1	0
11/30/2021 21:00	0.2	14.1	1,251.5	0.2	1.30	1	1	0
11/30/2021 22:00	0.9	13.8	1,737.6	0.7	5.20	1	1	0
11/30/2021 23:00	1.1	13.2	1,904.6	0.8	5.70	1	1	1
Average/Sum#:	2.7	14.2	1,571.5	4.0	115.34 #	16 #	14 #	1 #
Minimum:	0.2	13.2	303.1	0.2	1.30	0	0	0
Maximum:	20.8	18.1	1,904.6	43.8	36.00	1	1	1
%SI	33.33	33.33	33.33	33.33	33.33	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/01/2021 00:00	1.2	13.2	1,904.6	0.9	5.70	1	1	1
12/01/2021 01:00	0.6	13.9	1,489.3	0.5	3.00	1	1	1
12/01/2021 02:00	0.3	14.0	1,284.6	0.3	1.30	1	1	0
12/01/2021 03:00	0.5	13.9	1,689.5	0.4	3.40	1	1	0
12/01/2021 04:00	0.8	13.6	1,798.1	0.6	3.60	1	1	1
12/01/2021 05:00	1.0	13.3	1,809.1	0.8	5.40	1	1	1
12/01/2021 06:00	0.8	13.4	1,671.5	0.6	3.30	1	1	1
12/01/2021 07:00	1.4	12.3	2,156.1	1.0	8.60	1	1	1
12/01/2021 08:00	1.6	12.1	2,166.2	1.1	8.70	1	1	1
12/01/2021 09:00	1.5	12.2	2,151.2	1.0	8.60	1	1	1
12/01/2021 10:00	1.6	12.1	2,164.9	1.1	8.70	1	1	1
12/01/2021 11:00	1.6	12.0	2,173.6	1.1	8.70	1	1	1
12/01/2021 12:00	1.6	11.9	2,175.4	1.0	8.70	1	1	1
12/01/2021 13:00	1.7	11.9	2,161.0	1.1	8.60	1	1	1
12/01/2021 14:00	1.7	11.9	2,154.4	1.1	8.60	1	1	1
12/01/2021 15:00	1.7	11.9	2,150.8	1.1	8.60	1	1	1
12/01/2021 16:00	1.7	11.9	2,159.9	1.1	8.60	1	1	1
12/01/2021 17:00	1.7	11.9	2,168.1	1.1	8.70	1	1	1
12/01/2021 18:00	1.7	11.9	2,168.2	1.1	8.70	1	1	1
12/01/2021 19:00	1.7	12.0	2,154.3	1.1	8.60	1	1	1
12/01/2021 20:00	1.4	12.5	2,075.6	1.0	8.30	1	1	1
12/01/2021 21:00	1.3	12.6	2,047.6	0.9	6.10	1	1	1
12/01/2021 22:00	1.2	12.8	2,000.1	0.9	6.00	1	1	1
12/01/2021 23:00	1.1	13.2	1,902.2	0.8	5.70	1	1	1
Average/Sum#:	1.3	12.6	1,990.7	0.9	164.20 #	24 #	24 #	22 #
Minimum:	0.3	11.9	1,284.6	0.3	1.30	1	1	0
Maximum:	1.7	14.0	2,175.4	1.1	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/02/2021 00:00	2.4	14.6	1,181.9	2.2	4.75	1	0	1
12/02/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/02/2021 04:00	6.5	16.5	646.8	8.7	19.67	1	0	0
12/02/2021 05:00	0.2	14.0	1,349.3	0.2	1.30	1	1	0
12/02/2021 06:00	0.3	14.0	1,302.7	0.3	1.30	1	1	0
12/02/2021 07:00	0.3	14.0	1,342.7	0.3	1.30	1	1	0
12/02/2021 08:00	0.2	14.0	1,240.0	0.2	1.20	1	1	0
12/02/2021 09:00	0.2	14.0	1,211.5	0.2	1.20	1	1	0
12/02/2021 10:00	0.3	14.0	1,363.7	0.3	1.40	1	1	0
12/02/2021 11:00	0.4	14.0	1,437.1	0.3	1.40	1	1	0
12/02/2021 12:00	0.5	14.0	1,579.4	0.4	3.20	1	1	0
12/02/2021 13:00	0.6	13.9	1,701.8	0.5	3.40	1	1	0
12/02/2021 14:00	0.9	13.9	1,699.4	0.8	5.10	1	1	0
12/02/2021 15:00	0.9	13.9	1,699.3	0.8	5.10	1	1	0
12/02/2021 16:00	0.9	13.9	1,697.2	0.8	5.10	1	1	0
12/02/2021 17:00	0.9	13.9	1,696.1	0.8	5.10	1	1	0
12/02/2021 18:00	0.9	13.9	1,695.5	0.8	5.10	1	1	0
12/02/2021 19:00	0.9	13.9	1,694.2	0.8	5.10	1	1	0
12/02/2021 20:00	1.1	13.7	1,753.2	0.9	5.30	1	1	0
12/02/2021 21:00	1.2	13.2	1,887.6	0.9	5.70	1	1	1
12/02/2021 22:00	1.5	12.8	1,982.3	1.1	7.90	1	1	1
12/02/2021 23:00	1.3	13.2	1,851.3	1.0	7.40	1	1	1
Average/Sum#:	1.1	14.0	1,524.4	1.1	97.02 #	21 #	19 #	4 #
Minimum:	0.2	12.8	646.8	0.2	1.20	0	0	0
Maximum:	6.5	16.5	1,982.3	8.7	19.67	1	1	1
%SI	12.50	12.50	12.50	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/03/2021 00:00	1.4	14.5	1,113.9	1.3	5.15	1	0	0
12/03/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/03/2021 03:00	0.5	18.6	226.9	1.3	0.24	1	0	0
12/03/2021 04:00	6.9	16.1	714.9	8.5	22.20	1	0	0
12/03/2021 05:00	0.6	13.9	1,395.3	0.5	2.80	1	1	0
12/03/2021 06:00	0.8	13.9	1,601.3	0.7	3.20	1	1	0
12/03/2021 07:00	1.1	13.4	1,844.7	0.9	5.50	1	1	1
12/03/2021 08:00	1.6	12.3	2,147.3	1.1	8.60	1	1	1
12/03/2021 09:00	1.7	12.2	2,157.3	1.2	8.60	1	1	1
12/03/2021 10:00	1.7	12.1	2,158.6	1.1	8.60	1	1	1
12/03/2021 11:00	1.7	12.1	2,167.3	1.1	8.70	1	1	1
12/03/2021 12:00	1.7	12.1	2,165.5	1.1	8.70	1	1	1
12/03/2021 13:00	1.7	12.0	2,165.4	1.1	8.70	1	1	1
12/03/2021 14:00	1.7	12.0	2,161.1	1.1	8.60	1	1	1
12/03/2021 15:00	1.7	12.0	2,160.8	1.1	8.60	1	1	1
12/03/2021 16:00	1.4	13.0	1,857.0	1.0	7.40	1	1	1
12/03/2021 17:00	0.9	13.8	1,722.0	0.7	5.20	1	1	0
12/03/2021 18:00	0.9	13.8	1,689.8	0.7	5.10	1	1	0
12/03/2021 19:00	0.9	13.8	1,694.2	0.7	5.10	1	1	1
12/03/2021 20:00	1.3	13.0	1,941.3	1.0	7.80	1	1	1
12/03/2021 21:00	1.6	12.5	2,050.4	1.1	8.20	1	1	1
12/03/2021 22:00	1.6	12.6	2,047.6	1.1	8.20	1	1	1
12/03/2021 23:00	2.1	13.8	1,547.7	1.7	9.30	1	0	1
Average/Sum#:	1.6	13.3	1,760.5	1.4	164.49 #	22 #	18 #	15 #
Minimum:	0.5	12.0	226.9	0.5	0.24	0	0	0
Maximum:	6.9	18.6	2,167.3	8.5	22.20	1	1	1
%SI	8.33	8.33	8.33	8.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/04/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2021 05:00	1.1	18.8	190.7	3.1	0.42	1	0	0
12/04/2021 06:00	3.1	18.1	289.9	6.5	2.66	1	0	0
12/04/2021 07:00	4.1	14.5	1,311.0	3.8	18.40	1	0	0
12/04/2021 08:00	0.8	13.8	1,699.3	0.7	3.40	1	1	0
12/04/2021 09:00	0.9	13.8	1,700.8	0.7	5.10	1	1	0
12/04/2021 10:00	0.9	13.8	1,755.7	0.7	5.30	1	1	0
12/04/2021 11:00	0.9	13.8	1,760.5	0.7	5.30	1	1	0
12/04/2021 12:00	1.5	14.3	1,438.3	1.3	6.62	1	0	0
12/04/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/04/2021 15:00	0.3	18.9	182.3	0.9	0.09	1	0	0
12/04/2021 16:00	5.2	15.8	776.3	6.0	17.10	1	0	0
12/04/2021 17:00	0.8	13.8	1,683.4	0.7	3.40	1	1	0
12/04/2021 18:00	1.1	13.3	1,888.5	0.9	5.70	1	1	1
12/04/2021 19:00	1.1	13.3	1,819.9	0.9	5.50	1	1	1
12/04/2021 20:00	0.8	13.8	1,597.8	0.7	3.20	1	1	0
12/04/2021 21:00	0.8	13.8	1,580.6	0.7	3.20	1	1	0
12/04/2021 22:00	0.8	13.8	1,565.3	0.7	3.10	1	1	0
12/04/2021 23:00	3.1	15.9	526.3	3.7	1.50	1	0	0
Average/Sum#:	1.6	14.9	1,280.4	1.9	89.99 #	17 #	10 #	2 #
Minimum:	0.3	13.3	182.3	0.7	0.09	0	0	0
Maximum:	5.2	18.9	1,888.5	6.5	18.40	1	1	1
%SI	29.17	29.17	29.17	29.17	29.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/05/2021 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/05/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/05/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/05/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/05/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/05/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/05/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/05/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/05/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/05/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/05/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/05/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/05/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/05/2021 13:00	21.1	18.0	309.9	42.9	19.60	1	0	0
12/05/2021 14:00	13.3	15.3	925.2	14.0	48.10	1	0	0
12/05/2021 15:00	0.9	13.9	1,651.9	0.8	5.00	1	1	0
12/05/2021 16:00	0.9	13.8	1,581.7	0.7	4.70	1	1	1
12/05/2021 17:00	1.3	13.0	1,937.9	1.0	7.80	1	1	1
12/05/2021 18:00	1.5	12.5	2,065.2	1.1	8.30	1	1	1
12/05/2021 19:00	1.6	12.5	2,087.6	1.1	8.40	1	1	1
12/05/2021 20:00	1.7	12.2	2,167.8	1.2	8.70	1	1	1
12/05/2021 21:00	1.6	12.4	2,114.9	1.1	8.50	1	1	1
12/05/2021 22:00	1.6	12.4	2,113.8	1.1	8.50	1	1	1
12/05/2021 23:00	1.5	12.7	2,039.7	1.1	8.20	1	1	1
Average/Sum#:	4.3	13.5	1,726.9	6.0	135.80 #	11 #	9 #	8 #
Minimum:	0.9	12.2	309.9	0.7	4.70	0	0	0
Maximum:	21.1	18.0	2,167.8	42.9	48.10	1	1	1
%SI	54.17	54.17	54.17	54.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/06/2021 00:00	1.4	13.0	1,944.7	1.0	7.80	1	1	1
12/06/2021 01:00	0.8	13.8	1,673.4	0.7	3.30	1	1	0
12/06/2021 02:00	0.9	13.8	1,727.9	0.7	5.20	1	1	1
12/06/2021 03:00	1.2	13.2	1,939.5	0.9	5.80	1	1	1
12/06/2021 04:00	1.4	13.2	1,916.5	1.1	7.70	1	1	1
12/06/2021 05:00	0.8	13.8	1,608.7	0.7	3.20	1	1	0
12/06/2021 06:00	1.2	13.2	1,848.8	0.9	5.50	1	1	1
12/06/2021 07:00	1.6	12.4	2,123.2	1.1	8.50	1	1	1
12/06/2021 08:00	1.6	12.4	2,122.0	1.1	8.50	1	1	1
12/06/2021 09:00	1.0	13.6	1,694.1	0.8	5.10	1	1	1
12/06/2021 10:00	0.9	13.8	1,760.3	0.7	5.30	1	1	0
12/06/2021 11:00	1.3	13.1	1,965.7	1.0	7.90	1	1	1
12/06/2021 12:00	1.6	12.3	2,128.2	1.1	8.50	1	1	1
12/06/2021 13:00	1.4	13.0	1,878.4	1.0	7.50	1	1	1
12/06/2021 14:00	0.8	13.8	1,609.1	0.7	3.20	1	1	0
12/06/2021 15:00	1.0	13.5	1,802.0	0.8	5.40	1	1	1
12/06/2021 16:00	1.4	12.7	2,031.4	1.0	8.10	1	1	1
12/06/2021 17:00	1.5	12.6	2,067.8	1.1	8.30	1	1	1
12/06/2021 18:00	1.7	12.2	2,154.2	1.2	8.60	1	1	1
12/06/2021 19:00	1.6	12.4	2,112.9	1.1	8.50	1	1	1
12/06/2021 20:00	1.7	12.3	2,136.7	1.2	8.50	1	1	1
12/06/2021 21:00	1.5	12.6	2,069.5	1.1	8.30	1	1	1
12/06/2021 22:00	1.5	12.6	2,065.4	1.1	8.30	1	1	1
12/06/2021 23:00	1.5	12.6	2,069.0	1.1	8.30	1	1	1
Average/Sum#:	1.3	13.0	1,935.4	1.0	165.30 #	24 #	24 #	20 #
Minimum:	0.8	12.2	1,608.7	0.7	3.20	1	1	0
Maximum:	1.7	13.8	2,154.2	1.2	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/07/2021 00:00	1.5	12.7	2,027.5	1.1	8.10	1	1	1
12/07/2021 01:00	0.8	13.8	1,501.4	0.7	3.00	1	1	1
12/07/2021 02:00	0.9	13.8	1,657.4	0.7	5.00	1	1	1
12/07/2021 03:00	1.2	13.2	1,918.6	0.9	5.80	1	1	1
12/07/2021 04:00	1.5	12.6	2,055.9	1.1	8.20	1	1	1
12/07/2021 05:00	1.0	13.7	1,691.1	0.8	5.10	1	1	1
12/07/2021 06:00	0.9	13.8	1,616.9	0.7	4.90	1	1	0
12/07/2021 07:00	1.2	13.1	1,930.6	0.9	5.80	1	1	1
12/07/2021 08:00	1.6	12.3	2,140.3	1.1	8.60	1	1	1
12/07/2021 09:00	1.6	12.5	2,049.5	1.1	8.20	1	1	1
12/07/2021 10:00	1.1	13.7	1,775.2	0.9	5.30	1	1	0
12/07/2021 11:00	1.0	13.7	1,777.3	0.8	5.30	1	1	0
12/07/2021 12:00	1.0	13.7	1,749.5	0.8	5.20	1	1	0
12/07/2021 13:00	1.1	13.7	1,746.6	0.9	5.20	1	1	1
12/07/2021 14:00	1.4	12.6	2,004.1	1.0	8.00	1	1	1
12/07/2021 15:00	1.7	12.0	2,132.8	1.1	8.50	1	1	1
12/07/2021 16:00	1.7	12.0	2,165.3	1.1	8.70	1	1	1
12/07/2021 17:00	1.7	12.1	2,143.7	1.1	8.60	1	1	1
12/07/2021 18:00	1.7	12.1	2,155.7	1.1	8.60	1	1	1
12/07/2021 19:00	1.6	12.2	2,142.4	1.1	8.60	1	1	1
12/07/2021 20:00	1.7	12.2	2,143.1	1.2	8.60	1	1	1
12/07/2021 21:00	1.7	12.2	2,138.7	1.2	8.60	1	1	1
12/07/2021 22:00	1.6	12.5	2,075.2	1.1	8.30	1	1	1
12/07/2021 23:00	1.6	12.5	2,065.7	1.1	8.30	1	1	1
Average/Sum#:	1.4	12.9	1,950.2	1.0	168.50 #	24 #	24 #	20 #
Minimum:	0.8	12.0	1,501.4	0.7	3.00	1	1	0
Maximum:	1.7	13.8	2,165.3	1.2	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/08/2021 00:00	1.5	12.7	1,997.5	1.1	8.00	1	1	1
12/08/2021 01:00	0.8	13.9	1,575.5	0.7	3.20	1	1	0
12/08/2021 02:00	0.7	13.9	1,296.2	0.6	2.60	1	1	0
12/08/2021 03:00	0.9	13.8	1,707.2	0.7	5.10	1	1	0
12/08/2021 04:00	1.1	13.4	1,794.3	0.9	5.40	1	1	1
12/08/2021 05:00	1.3	13.2	1,839.7	1.0	7.40	1	1	1
12/08/2021 06:00	1.0	13.8	1,730.5	0.8	5.20	1	1	1
12/08/2021 07:00	1.3	13.0	1,949.8	1.0	7.80	1	1	1
12/08/2021 08:00	1.2	13.2	1,829.4	0.9	5.50	1	1	1
12/08/2021 09:00	0.7	13.9	1,348.3	0.6	2.70	1	1	0
12/08/2021 10:00	0.7	13.9	1,313.8	0.6	2.60	1	1	0
12/08/2021 11:00	0.9	13.8	1,692.8	0.7	5.10	1	1	0
12/08/2021 12:00	1.0	13.4	1,816.1	0.8	5.40	1	1	1
12/08/2021 13:00	1.1	13.4	1,802.7	0.9	5.40	1	1	1
12/08/2021 14:00	0.7	13.9	1,291.8	0.6	2.60	1	1	0
12/08/2021 15:00	0.7	13.9	1,365.0	0.6	2.70	1	1	0
12/08/2021 16:00	0.9	13.8	1,681.7	0.7	5.00	1	1	0
12/08/2021 17:00	1.3	13.1	1,931.5	1.0	7.70	1	1	1
12/08/2021 18:00	1.6	12.4	2,091.0	1.1	8.40	1	1	1
12/08/2021 19:00	1.6	12.4	2,081.3	1.1	8.30	1	1	1
12/08/2021 20:00	1.6	12.5	2,066.9	1.1	8.30	1	1	1
12/08/2021 21:00	1.5	12.7	2,010.8	1.1	8.00	1	1	1
12/08/2021 22:00	1.5	12.8	1,991.7	1.1	8.00	1	1	1
12/08/2021 23:00	1.5	12.7	2,012.3	1.1	8.00	1	1	1
Average/Sum#:	1.1	13.3	1,759.1	0.9	138.40 #	24 #	24 #	15 #
Minimum:	0.7	12.4	1,291.8	0.6	2.60	1	1	0
Maximum:	1.6	13.9	2,091.0	1.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/09/2021 00:00	1.4	13.2	1,895.8	1.1	7.60	1	1	1
12/09/2021 01:00	0.8	13.9	1,468.3	0.7	2.90	1	1	0
12/09/2021 02:00	0.9	13.8	1,547.9	0.7	4.60	1	1	1
12/09/2021 03:00	1.3	13.1	1,921.3	1.0	7.70	1	1	1
12/09/2021 04:00	1.4	12.9	1,943.7	1.0	7.80	1	1	1
12/09/2021 05:00	0.8	13.9	1,518.3	0.7	3.00	1	1	0
12/09/2021 06:00	1.0	13.8	1,600.6	0.8	4.80	1	1	1
12/09/2021 07:00	1.3	13.1	1,941.6	1.0	7.80	1	1	1
12/09/2021 08:00	1.5	12.8	2,001.0	1.1	8.00	1	1	1
12/09/2021 09:00	1.5	12.8	1,998.0	1.1	8.00	1	1	1
12/09/2021 10:00	0.9	13.8	1,577.9	0.7	4.70	1	1	1
12/09/2021 11:00	1.0	13.8	1,683.7	0.8	5.10	1	1	1
12/09/2021 12:00	1.5	12.9	1,966.4	1.1	7.90	1	1	1
12/09/2021 13:00	1.5	13.0	1,937.1	1.1	7.70	1	1	1
12/09/2021 14:00	0.8	14.0	1,428.9	0.7	4.30	1	1	0
12/09/2021 15:00	0.8	13.9	1,480.9	0.7	3.00	1	1	1
12/09/2021 16:00	1.4	13.1	1,944.6	1.1	7.80	1	1	1
12/09/2021 17:00	1.6	12.5	2,078.3	1.1	8.30	1	1	1
12/09/2021 18:00	1.6	12.6	2,053.9	1.1	8.20	1	1	1
12/09/2021 19:00	1.6	12.5	2,078.5	1.1	8.30	1	1	1
12/09/2021 20:00	1.6	12.5	2,084.7	1.1	8.30	1	1	1
12/09/2021 21:00	1.6	12.5	2,084.9	1.1	8.30	1	1	1
12/09/2021 22:00	1.4	13.0	1,970.1	1.0	7.90	1	1	1
12/09/2021 23:00	1.5	12.9	1,996.3	1.1	8.00	1	1	1
Average/Sum#:	1.3	13.2	1,841.8	1.0	160.00 #	24 #	24 #	21 #
Minimum:	0.8	12.5	1,428.9	0.7	2.90	1	1	0
Maximum:	1.6	14.0	2,084.9	1.1	8.30	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/10/2021 00:00	1.3	13.2	1,906.6	1.0	7.60	1	1	1
12/10/2021 01:00	0.8	13.9	1,512.5	0.7	3.00	1	1	0
12/10/2021 02:00	0.8	13.9	1,582.0	0.7	3.20	1	1	0
12/10/2021 03:00	1.2	13.4	1,883.4	0.9	5.70	1	1	1
12/10/2021 04:00	1.2	13.3	1,906.9	0.9	5.70	1	1	1
12/10/2021 05:00	0.8	13.9	1,587.5	0.7	3.20	1	1	0
12/10/2021 06:00	0.9	13.8	1,709.9	0.7	5.10	1	1	1
12/10/2021 07:00	1.2	13.3	1,935.7	0.9	5.80	1	1	1
12/10/2021 08:00	1.2	13.3	1,904.4	0.9	5.70	1	1	1
12/10/2021 09:00	0.8	13.9	1,582.3	0.7	3.20	1	1	0
12/10/2021 10:00	0.8	13.9	1,666.5	0.7	3.30	1	1	0
12/10/2021 11:00	0.8	13.9	1,598.7	0.7	3.20	1	1	0
12/10/2021 12:00	0.8	13.9	1,650.1	0.7	3.30	1	1	0
12/10/2021 13:00	0.8	13.9	1,572.6	0.7	3.10	1	1	0
12/10/2021 14:00	0.6	14.0	1,290.1	0.5	2.60	1	1	0
12/10/2021 15:00	0.8	13.9	1,550.9	0.7	3.10	1	1	0
12/10/2021 16:00	1.3	13.3	1,922.0	1.0	7.70	1	1	1
12/10/2021 17:00	1.6	12.3	2,150.4	1.1	8.60	1	1	1
12/10/2021 18:00	1.6	12.4	2,120.0	1.1	8.50	1	1	1
12/10/2021 19:00	1.6	12.4	2,122.0	1.1	8.50	1	1	1
12/10/2021 20:00	1.6	12.3	2,147.6	1.1	8.60	1	1	1
12/10/2021 21:00	1.6	12.5	2,106.8	1.1	8.40	1	1	1
12/10/2021 22:00	1.5	12.8	2,053.4	1.1	8.20	1	1	1
12/10/2021 23:00	1.5	12.9	2,056.0	1.1	8.20	1	1	1
Average/Sum#:	1.1	13.3	1,813.3	0.9	133.50 #	24 #	24 #	14 #
Minimum:	0.6	12.3	1,290.1	0.5	2.60	1	1	0
Maximum:	1.6	14.0	2,150.4	1.1	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/11/2021 00:00	1.6	12.8	2,053.8	1.2	8.20	1	1	1
12/11/2021 01:00	1.5	13.1	1,995.8	1.1	8.00	1	1	1
12/11/2021 02:00	1.2	13.3	1,899.3	0.9	5.70	1	1	1
12/11/2021 03:00	0.8	13.9	1,596.5	0.7	3.20	1	1	0
12/11/2021 04:00	0.9	13.8	1,665.1	0.7	5.00	1	1	1
12/11/2021 05:00	1.2	13.2	1,976.3	0.9	5.90	1	1	1
12/11/2021 06:00	1.3	12.9	2,043.3	1.0	8.20	1	1	1
12/11/2021 07:00	1.3	13.1	1,982.2	1.0	7.90	1	1	1
12/11/2021 08:00	0.8	13.9	1,582.6	0.7	3.20	1	1	0
12/11/2021 09:00	0.7	13.9	1,365.7	0.6	2.70	1	1	0
12/11/2021 10:00	0.7	13.9	1,399.0	0.6	2.80	1	1	0
12/11/2021 11:00	0.7	13.9	1,300.8	0.6	2.60	1	1	0
12/11/2021 12:00	0.7	13.9	1,299.0	0.6	2.60	1	1	0
12/11/2021 13:00	0.8	13.9	1,479.4	0.7	3.00	1	1	0
12/11/2021 14:00	0.8	13.9	1,518.2	0.7	3.00	1	1	0
12/11/2021 15:00	0.8	13.8	1,608.2	0.7	3.20	1	1	0
12/11/2021 16:00	1.3	12.8	2,055.8	0.9	6.20	1	1	1
12/11/2021 17:00	1.6	12.4	2,149.6	1.1	8.60	1	1	1
12/11/2021 18:00	1.6	12.5	2,135.0	1.1	8.50	1	1	1
12/11/2021 19:00	1.7	12.3	2,169.0	1.2	8.70	1	1	1
12/11/2021 20:00	1.6	12.5	2,132.0	1.1	8.50	1	1	1
12/11/2021 21:00	1.6	12.3	2,165.8	1.1	8.70	1	1	1
12/11/2021 22:00	1.6	12.5	2,127.1	1.1	8.50	1	1	1
12/11/2021 23:00	1.5	12.8	2,045.4	1.1	8.20	1	1	1
Average/Sum#:	1.2	13.2	1,822.7	0.9	141.10 #	24 #	24 #	15 #
Minimum:	0.7	12.3	1,299.0	0.6	2.60	1	1	0
Maximum:	1.7	13.9	2,169.0	1.2	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/12/2021 00:00	1.5	12.8	2,035.7	1.1	8.10	1	1	1
12/12/2021 01:00	1.5	13.0	1,993.6	1.1	8.00	1	1	1
12/12/2021 02:00	1.2	13.3	1,892.2	0.9	5.70	1	1	1
12/12/2021 03:00	0.9	13.9	1,574.5	0.8	4.70	1	1	0
12/12/2021 04:00	0.9	13.8	1,711.2	0.7	5.10	1	1	1
12/12/2021 05:00	1.3	13.0	1,967.2	1.0	7.90	1	1	1
12/12/2021 06:00	1.4	13.0	1,996.1	1.0	8.00	1	1	1
12/12/2021 07:00	0.9	13.8	1,599.3	0.7	4.80	1	1	1
12/12/2021 08:00	0.9	13.9	1,570.1	0.8	4.70	1	1	0
12/12/2021 09:00	0.7	13.9	1,374.3	0.6	2.70	1	1	0
12/12/2021 10:00	0.9	13.8	1,573.3	0.7	4.70	1	1	0
12/12/2021 11:00	0.9	13.8	1,665.6	0.7	5.00	1	1	0
12/12/2021 12:00	0.8	13.8	1,586.0	0.7	3.20	1	1	0
12/12/2021 13:00	0.9	13.8	1,611.2	0.7	4.80	1	1	0
12/12/2021 14:00	0.8	13.8	1,568.5	0.7	3.10	1	1	0
12/12/2021 15:00	0.9	13.8	1,563.4	0.7	4.70	1	1	1
12/12/2021 16:00	1.4	12.8	2,015.8	1.0	8.10	1	1	1
12/12/2021 17:00	1.6	12.5	2,090.9	1.1	8.40	1	1	1
12/12/2021 18:00	1.6	12.5	2,084.7	1.1	8.30	1	1	1
12/12/2021 19:00	1.7	12.3	2,127.0	1.2	8.50	1	1	1
12/12/2021 20:00	1.6	12.5	2,077.0	1.1	8.30	1	1	1
12/12/2021 21:00	1.6	12.5	2,080.2	1.1	8.30	1	1	1
12/12/2021 22:00	1.5	12.6	2,053.3	1.1	8.20	1	1	1
12/12/2021 23:00	1.5	12.8	2,007.9	1.1	8.00	1	1	1
Average/Sum#:	1.2	13.2	1,825.8	0.9	151.30 #	24 #	24 #	16 #
Minimum:	0.7	12.3	1,374.3	0.6	2.70	1	1	0
Maximum:	1.7	13.9	2,127.0	1.2	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/13/2021 00:00	1.3	13.2	1,897.0	1.0	7.60	1	1	1
12/13/2021 01:00	0.9	13.8	1,670.8	0.7	5.00	1	1	0
12/13/2021 02:00	0.9	13.8	1,646.7	0.7	4.90	1	1	1
12/13/2021 03:00	1.4	12.9	1,968.0	1.0	7.90	1	1	1
12/13/2021 04:00	1.4	13.0	1,912.8	1.0	7.70	1	1	1
12/13/2021 05:00	0.9	13.9	1,568.6	0.8	4.70	1	1	0
12/13/2021 06:00	1.1	13.7	1,753.4	0.9	5.30	1	1	1
12/13/2021 07:00	1.5	12.6	2,037.1	1.1	8.10	1	1	1
12/13/2021 08:00	1.7	12.2	2,128.6	1.2	8.50	1	1	1
12/13/2021 09:00	1.7	12.3	2,100.2	1.2	8.40	1	1	1
12/13/2021 10:00	1.6	12.4	2,069.5	1.1	8.30	1	1	1
12/13/2021 11:00	1.5	12.8	1,966.3	1.1	7.90	1	1	1
12/13/2021 12:00	0.9	13.9	1,620.9	0.8	4.90	1	1	0
12/13/2021 13:00	1.1	13.7	1,764.2	0.9	5.30	1	1	1
12/13/2021 14:00	1.4	12.8	1,994.4	1.0	8.00	1	1	1
12/13/2021 15:00	1.7	12.2	2,141.6	1.2	8.60	1	1	1
12/13/2021 16:00	1.7	12.1	2,170.0	1.1	8.70	1	1	1
12/13/2021 17:00	1.7	12.0	2,179.8	1.1	8.70	1	1	1
12/13/2021 18:00	1.7	12.1	2,174.9	1.1	8.70	1	1	1
12/13/2021 19:00	1.7	11.9	2,193.4	1.1	8.80	1	1	1
12/13/2021 20:00	1.6	12.3	2,092.1	1.1	8.40	1	1	1
12/13/2021 21:00	1.6	12.6	2,040.2	1.1	8.20	1	1	1
12/13/2021 22:00	1.6	12.8	1,991.0	1.2	8.00	1	1	1
12/13/2021 23:00	1.6	12.8	1,997.2	1.2	8.00	1	1	1
Average/Sum#:	1.4	12.8	1,961.6	1.0	178.60 #	24 #	24 #	21 #
Minimum:	0.9	11.9	1,568.6	0.7	4.70	1	1	0
Maximum:	1.7	13.9	2,193.4	1.2	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/14/2021 00:00	1.3	13.3	1,806.2	1.0	7.20	1	1	1
12/14/2021 01:00	0.7	13.9	1,275.7	0.6	2.60	1	1	0
12/14/2021 02:00	0.7	13.9	1,295.1	0.6	2.60	1	1	0
12/14/2021 03:00	0.9	13.8	1,715.6	0.7	5.10	1	1	0
12/14/2021 04:00	1.1	13.5	1,831.2	0.9	5.50	1	1	1
12/14/2021 05:00	1.2	13.3	1,818.3	0.9	5.50	1	1	1
12/14/2021 06:00	1.0	13.8	1,686.4	0.8	5.10	1	1	1
12/14/2021 07:00	1.4	12.9	2,022.3	1.0	8.10	1	1	1
12/14/2021 08:00	1.5	12.7	2,059.8	1.1	8.20	1	1	1
12/14/2021 09:00	1.4	13.1	1,935.1	1.1	7.70	1	1	1
12/14/2021 10:00	0.9	13.9	1,591.5	0.8	4.80	1	1	0
12/14/2021 11:00	0.8	13.8	1,606.5	0.7	3.20	1	1	1
12/14/2021 12:00	1.3	13.0	1,988.6	1.0	8.00	1	1	1
12/14/2021 13:00	1.2	13.3	1,897.5	0.9	5.70	1	1	1
12/14/2021 14:00	0.9	13.9	1,623.3	0.8	4.90	1	1	0
12/14/2021 15:00	0.8	13.9	1,510.4	0.7	3.00	1	1	0
12/14/2021 16:00	1.3	13.1	1,948.4	1.0	7.80	1	1	1
12/14/2021 17:00	1.7	12.2	2,195.7	1.2	8.80	1	1	1
12/14/2021 18:00	1.6	12.4	2,155.7	1.1	8.60	1	1	1
12/14/2021 19:00	1.7	12.2	2,192.6	1.2	8.80	1	1	1
12/14/2021 20:00	1.7	12.2	2,196.1	1.2	8.80	1	1	1
12/14/2021 21:00	1.6	12.4	2,153.1	1.1	8.60	1	1	1
12/14/2021 22:00	1.5	12.7	2,075.7	1.1	8.30	1	1	1
12/14/2021 23:00	1.5	13.1	1,995.8	1.1	8.00	1	1	1
Average/Sum#:	1.2	13.2	1,857.4	0.9	154.90 #	24 #	24 #	18 #
Minimum:	0.7	12.2	1,275.7	0.6	2.60	1	1	0
Maximum:	1.7	13.9	2,196.1	1.2	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/15/2021 00:00	1.4	13.2	1,925.9	1.1	7.70	1	1	1
12/15/2021 01:00	0.8	13.9	1,530.8	0.7	3.10	1	1	0
12/15/2021 02:00	0.9	13.8	1,636.2	0.7	4.90	1	1	1
12/15/2021 03:00	1.1	13.3	1,918.0	0.9	5.80	1	1	1
12/15/2021 04:00	1.1	13.3	1,905.7	0.9	5.70	1	1	1
12/15/2021 05:00	0.8	13.9	1,556.9	0.7	3.10	1	1	0
12/15/2021 06:00	1.2	13.3	1,857.5	0.9	5.60	1	1	1
12/15/2021 07:00	1.6	12.6	2,108.6	1.1	8.40	1	1	1
12/15/2021 08:00	1.4	13.1	1,952.9	1.1	7.80	1	1	1
12/15/2021 09:00	0.8	13.9	1,569.3	0.7	3.10	1	1	0
12/15/2021 10:00	0.8	13.8	1,594.3	0.7	3.20	1	1	0
12/15/2021 11:00	0.8	13.8	1,585.1	0.7	3.20	1	1	1
12/15/2021 12:00	1.3	13.0	1,979.7	1.0	7.90	1	1	1
12/15/2021 13:00	1.4	12.9	1,978.1	1.0	7.90	1	1	1
12/15/2021 14:00	0.8	13.9	1,537.7	0.7	3.10	1	1	0
12/15/2021 15:00	1.0	13.8	1,694.9	0.8	5.10	1	1	1
12/15/2021 16:00	1.4	12.6	2,080.8	1.0	8.30	1	1	1
12/15/2021 17:00	1.7	12.1	2,195.1	1.1	8.80	1	1	1
12/15/2021 18:00	1.7	12.2	2,187.3	1.2	8.70	1	1	1
12/15/2021 19:00	1.6	12.2	2,185.5	1.1	8.70	1	1	1
12/15/2021 20:00	1.7	12.2	2,187.7	1.2	8.80	1	1	1
12/15/2021 21:00	1.7	12.3	2,149.5	1.2	8.60	1	1	1
12/15/2021 22:00	1.5	12.6	2,076.3	1.1	8.30	1	1	1
12/15/2021 23:00	1.5	12.7	2,049.8	1.1	8.20	1	1	1
Average/Sum#:	1.3	13.1	1,893.5	0.9	154.00 #	24 #	24 #	19 #
Minimum:	0.8	12.1	1,530.8	0.7	3.10	1	1	0
Maximum:	1.7	13.9	2,195.1	1.2	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/16/2021 00:00	1.5	12.9	2,008.6	1.1	8.00	1	1	1
12/16/2021 01:00	1.4	13.1	1,928.9	1.1	7.70	1	1	1
12/16/2021 02:00	0.9	13.9	1,551.7	0.8	4.70	1	1	0
12/16/2021 03:00	0.9	13.9	1,553.4	0.8	4.70	1	1	0
12/16/2021 04:00	0.9	13.8	1,593.3	0.7	4.80	1	1	1
12/16/2021 05:00	1.3	13.0	1,998.6	1.0	8.00	1	1	1
12/16/2021 06:00	1.5	12.3	2,178.2	1.0	8.70	1	1	1
12/16/2021 07:00	1.6	12.3	2,165.3	1.1	8.70	1	1	1
12/16/2021 08:00	1.5	12.9	1,998.3	1.1	8.00	1	1	1
12/16/2021 09:00	1.4	13.1	1,944.0	1.1	7.80	1	1	1
12/16/2021 10:00	0.9	13.7	1,473.4	0.7	4.40	1	1	1
12/16/2021 11:00	0.9	13.8	1,589.2	0.7	4.80	1	1	1
12/16/2021 12:00	1.4	12.9	1,989.7	1.0	8.00	1	1	1
12/16/2021 13:00	1.2	13.2	1,905.6	0.9	5.70	1	1	1
12/16/2021 14:00	0.9	13.9	1,530.4	0.8	4.60	1	1	0
12/16/2021 15:00	0.9	13.8	1,568.0	0.7	4.70	1	1	1
12/16/2021 16:00	1.5	12.6	2,075.8	1.1	8.30	1	1	1
12/16/2021 17:00	1.7	12.1	2,200.8	1.1	8.80	1	1	1
12/16/2021 18:00	1.7	12.1	2,200.9	1.1	8.80	1	1	1
12/16/2021 19:00	1.7	12.1	2,200.3	1.1	8.80	1	1	1
12/16/2021 20:00	1.7	12.1	2,202.0	1.1	8.80	1	1	1
12/16/2021 21:00	1.6	12.2	2,180.6	1.1	8.70	1	1	1
12/16/2021 22:00	1.6	12.7	2,071.6	1.2	8.30	1	1	1
12/16/2021 23:00	1.5	12.8	2,032.0	1.1	8.10	1	1	1
Average/Sum#:	1.3	13.0	1,922.5	1.0	171.90 #	24 #	24 #	21 #
Minimum:	0.9	12.1	1,473.4	0.7	4.40	1	1	0
Maximum:	1.7	13.9	2,202.0	1.2	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/17/2021 00:00	1.2	13.3	1,893.8	0.9	5.70	1	1	1
12/17/2021 01:00	0.8	13.9	1,532.7	0.7	3.10	1	1	0
12/17/2021 02:00	0.8	13.9	1,527.6	0.7	3.10	1	1	0
12/17/2021 03:00	0.9	13.8	1,676.0	0.7	5.00	1	1	1
12/17/2021 04:00	1.4	13.1	1,975.0	1.1	7.90	1	1	1
12/17/2021 05:00	1.5	13.1	1,979.0	1.1	7.90	1	1	1
12/17/2021 06:00	1.4	12.3	2,156.0	1.0	8.60	1	1	1
12/17/2021 07:00	1.6	12.4	2,129.7	1.1	8.50	1	1	1
12/17/2021 08:00	1.5	13.1	1,992.5	1.1	8.00	1	1	1
12/17/2021 09:00	1.2	13.3	1,905.9	0.9	5.70	1	1	1
12/17/2021 10:00	0.9	13.9	1,552.3	0.8	4.70	1	1	0
12/17/2021 11:00	0.9	13.9	1,518.0	0.8	4.60	1	1	0
12/17/2021 12:00	0.7	14.0	1,366.5	0.6	2.70	1	1	0
12/17/2021 13:00	0.9	13.9	1,625.8	0.8	4.90	1	1	0
12/17/2021 14:00	0.8	13.9	1,469.5	0.7	2.90	1	1	0
12/17/2021 15:00	0.9	13.9	1,575.2	0.8	4.70	1	1	1
12/17/2021 16:00	1.4	12.9	2,006.6	1.0	8.00	1	1	1
12/17/2021 17:00	1.7	12.1	2,185.5	1.1	8.70	1	1	1
12/17/2021 18:00	1.7	12.1	2,187.8	1.1	8.80	1	1	1
12/17/2021 19:00	1.7	12.2	2,185.9	1.2	8.70	1	1	1
12/17/2021 20:00	1.7	12.1	2,188.9	1.1	8.80	1	1	1
12/17/2021 21:00	1.7	12.2	2,179.0	1.2	8.70	1	1	1
12/17/2021 22:00	1.6	12.7	2,064.9	1.2	8.30	1	1	1
12/17/2021 23:00	1.5	13.0	1,993.7	1.1	8.00	1	1	1
Average/Sum#:	1.3	13.1	1,869.5	1.0	156.00 #	24 #	24 #	17 #
Minimum:	0.7	12.1	1,366.5	0.6	2.70	1	1	0
Maximum:	1.7	14.0	2,188.9	1.2	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/18/2021 00:00	1.2	13.2	1,906.6	0.9	5.70	1	1	1
12/18/2021 01:00	0.9	13.8	1,588.9	0.7	4.80	1	1	1
12/18/2021 02:00	0.9	13.8	1,694.7	0.7	5.10	1	1	0
12/18/2021 03:00	1.2	13.3	1,947.8	0.9	5.80	1	1	1
12/18/2021 04:00	1.3	13.2	1,959.8	1.0	7.80	1	1	1
12/18/2021 05:00	0.9	13.8	1,653.3	0.7	5.00	1	1	1
12/18/2021 06:00	0.9	13.8	1,737.8	0.7	5.20	1	1	1
12/18/2021 07:00	1.4	13.1	2,002.3	1.1	8.00	1	1	1
12/18/2021 08:00	1.4	13.1	1,997.8	1.1	8.00	1	1	1
12/18/2021 09:00	1.4	13.1	1,969.5	1.1	7.90	1	1	1
12/18/2021 10:00	0.8	13.9	1,529.6	0.7	3.10	1	1	0
12/18/2021 11:00	0.9	13.9	1,564.8	0.8	4.70	1	1	0
12/18/2021 12:00	0.8	13.9	1,527.1	0.7	3.10	1	1	0
12/18/2021 13:00	0.8	13.9	1,514.1	0.7	3.00	1	1	0
12/18/2021 14:00	0.9	13.9	1,526.1	0.8	4.60	1	1	0
12/18/2021 15:00	0.8	13.9	1,481.0	0.7	3.00	1	1	0
12/18/2021 16:00	1.1	13.3	1,840.4	0.9	5.50	1	1	1
12/18/2021 17:00	1.6	12.4	2,136.6	1.1	8.50	1	1	1
12/18/2021 18:00	1.6	12.6	2,086.0	1.1	8.30	1	1	1
12/18/2021 19:00	1.7	12.3	2,158.6	1.2	8.60	1	1	1
12/18/2021 20:00	1.7	12.2	2,179.7	1.2	8.70	1	1	1
12/18/2021 21:00	1.6	12.5	2,102.7	1.1	8.40	1	1	1
12/18/2021 22:00	1.6	12.8	2,056.2	1.2	8.20	1	1	1
12/18/2021 23:00	1.5	13.0	1,987.9	1.1	8.00	1	1	1
Average/Sum#:	1.2	13.3	1,839.6	0.9	149.00 #	24 #	24 #	17 #
Minimum:	0.8	12.2	1,481.0	0.7	3.00	1	1	0
Maximum:	1.7	13.9	2,179.7	1.2	8.70	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/19/2021 00:00	1.6	12.9	2,022.7	1.2	8.10	1	1	1
12/19/2021 01:00	1.5	13.1	1,964.3	1.1	7.90	1	1	1
12/19/2021 02:00	0.9	13.9	1,596.1	0.8	4.80	1	1	0
12/19/2021 03:00	0.9	13.8	1,664.6	0.7	5.00	1	1	0
12/19/2021 04:00	1.3	13.2	1,960.3	1.0	7.80	1	1	1
12/19/2021 05:00	1.4	13.1	1,982.3	1.1	7.90	1	1	1
12/19/2021 06:00	1.4	13.2	1,947.3	1.1	7.80	1	1	1
12/19/2021 07:00	1.4	13.1	1,983.3	1.1	7.90	1	1	1
12/19/2021 08:00	1.4	13.1	1,984.6	1.1	7.90	1	1	1
12/19/2021 09:00	1.2	13.3	1,917.3	0.9	5.80	1	1	1
12/19/2021 10:00	0.8	13.9	1,481.7	0.7	3.00	1	1	0
12/19/2021 11:00	0.8	13.9	1,470.8	0.7	2.90	1	1	0
12/19/2021 12:00	0.8	13.9	1,432.6	0.7	2.90	1	1	0
12/19/2021 13:00	0.9	13.9	1,575.5	0.8	4.70	1	1	0
12/19/2021 14:00	0.9	13.9	1,576.4	0.8	4.70	1	1	0
12/19/2021 15:00	0.8	13.9	1,564.3	0.7	3.10	1	1	0
12/19/2021 16:00	1.3	13.1	1,958.5	1.0	7.80	1	1	1
12/19/2021 17:00	1.6	12.4	2,142.5	1.1	8.60	1	1	1
12/19/2021 18:00	1.6	12.7	2,077.9	1.2	8.30	1	1	1
12/19/2021 19:00	1.6	12.6	2,100.5	1.1	8.40	1	1	1
12/19/2021 20:00	1.6	12.6	2,083.2	1.1	8.30	1	1	1
12/19/2021 21:00	1.6	12.7	2,075.3	1.2	8.30	1	1	1
12/19/2021 22:00	1.6	12.7	2,070.6	1.2	8.30	1	1	1
12/19/2021 23:00	1.6	12.8	2,034.7	1.2	8.10	1	1	1
Average/Sum#:	1.3	13.2	1,861.1	1.0	158.30 #	24 #	24 #	16 #
Minimum:	0.8	12.4	1,432.6	0.7	2.90	1	1	0
Maximum:	1.6	13.9	2,142.5	1.2	8.60	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/20/2021 00:00	1.5	12.9	2,032.3	1.1	8.10	1	1	1
12/20/2021 01:00	1.4	13.1	1,947.6	1.1	7.80	1	1	1
12/20/2021 02:00	0.9	13.8	1,680.8	0.7	5.00	1	1	0
12/20/2021 03:00	0.9	13.8	1,714.5	0.7	5.10	1	1	1
12/20/2021 04:00	1.3	13.1	1,988.3	1.0	8.00	1	1	1
12/20/2021 05:00	1.6	12.7	2,082.6	1.2	8.30	1	1	1
12/20/2021 06:00	1.5	12.3	2,153.8	1.0	8.60	1	1	1
12/20/2021 07:00	1.5	12.7	2,076.5	1.1	8.30	1	1	1
12/20/2021 08:00	1.4	13.1	1,963.9	1.1	7.90	1	1	1
12/20/2021 09:00	0.9	13.9	1,638.9	0.8	4.90	1	1	0
12/20/2021 10:00	0.7	13.9	1,328.5	0.6	2.70	1	1	0
12/20/2021 11:00	0.9	13.8	1,624.1	0.7	4.90	1	1	0
12/20/2021 12:00	1.1	13.4	1,844.7	0.9	5.50	1	1	1
12/20/2021 13:00	1.6	12.6	2,084.1	1.1	8.30	1	1	1
12/20/2021 14:00	1.6	12.3	2,145.1	1.1	8.60	1	1	1
12/20/2021 15:00	1.6	12.3	2,139.9	1.1	8.60	1	1	1
12/20/2021 16:00	1.7	12.2	2,176.6	1.2	8.70	1	1	1
12/20/2021 17:00	1.7	12.2	2,184.3	1.2	8.70	1	1	1
12/20/2021 18:00	1.7	12.2	2,185.4	1.2	8.70	1	1	1
12/20/2021 19:00	1.7	12.1	2,192.2	1.1	8.80	1	1	1
12/20/2021 20:00	1.7	12.1	2,192.8	1.1	8.80	1	1	1
12/20/2021 21:00	1.7	12.1	2,195.0	1.1	8.80	1	1	1
12/20/2021 22:00	1.7	12.1	2,185.6	1.1	8.70	1	1	1
12/20/2021 23:00	1.6	12.6	2,071.5	1.1	8.30	1	1	1
Average/Sum#:	1.4	12.8	1,992.9	1.0	180.10 #	24 #	24 #	20 #
Minimum:	0.7	12.1	1,328.5	0.6	2.70	1	1	0
Maximum:	1.7	13.9	2,195.0	1.2	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/21/2021 00:00	1.5	12.8	2,031.0	1.1	8.10	1	1	1
12/21/2021 01:00	0.9	13.9	1,663.4	0.8	5.00	1	1	1
12/21/2021 02:00	0.9	13.8	1,778.5	0.7	5.30	1	1	1
12/21/2021 03:00	1.4	13.1	1,986.1	1.1	7.90	1	1	1
12/21/2021 04:00	1.4	13.1	1,949.3	1.1	7.80	1	1	1
12/21/2021 05:00	0.9	13.8	1,646.9	0.7	4.90	1	1	0
12/21/2021 06:00	0.9	13.8	1,730.8	0.7	5.20	1	1	1
12/21/2021 07:00	1.3	13.0	2,028.9	1.0	8.10	1	1	1
12/21/2021 08:00	1.6	12.4	2,164.9	1.1	8.70	1	1	1
12/21/2021 09:00	1.5	12.8	2,040.8	1.1	8.20	1	1	1
12/21/2021 10:00	0.9	13.9	1,597.3	0.8	4.80	1	1	0
12/21/2021 11:00	1.0	13.8	1,773.1	0.8	5.30	1	1	1
12/21/2021 12:00	1.4	13.0	2,017.6	1.0	8.10	1	1	1
12/21/2021 13:00	1.4	13.1	1,965.2	1.1	7.90	1	1	1
12/21/2021 14:00	0.9	13.8	1,634.5	0.7	4.90	1	1	0
12/21/2021 15:00	0.9	13.8	1,774.2	0.7	5.30	1	1	1
12/21/2021 16:00	1.4	13.0	2,019.4	1.0	8.10	1	1	1
12/21/2021 17:00	1.7	12.2	2,208.2	1.2	8.80	1	1	1
12/21/2021 18:00	1.7	12.1	2,216.6	1.1	8.90	1	1	1
12/21/2021 19:00	1.7	12.1	2,216.3	1.1	8.90	1	1	1
12/21/2021 20:00	1.7	12.1	2,212.7	1.1	8.90	1	1	1
12/21/2021 21:00	1.6	12.3	2,161.1	1.1	8.60	1	1	1
12/21/2021 22:00	1.6	12.7	2,074.9	1.2	8.30	1	1	1
12/21/2021 23:00	1.6	12.9	2,031.3	1.2	8.10	1	1	1
Average/Sum#:	1.3	13.1	1,955.1	1.0	174.10 #	24 #	24 #	21 #
Minimum:	0.9	12.1	1,597.3	0.7	4.80	1	1	0
Maximum:	1.7	13.9	2,216.6	1.2	8.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/22/2021 00:00	1.3	13.3	1,905.0	1.0	7.60	1	1	1
12/22/2021 01:00	0.9	13.9	1,598.3	0.8	4.80	1	1	0
12/22/2021 02:00	0.9	13.8	1,661.0	0.7	5.00	1	1	1
12/22/2021 03:00	1.1	13.3	1,932.5	0.9	5.80	1	1	1
12/22/2021 04:00	1.2	13.3	1,914.3	0.9	5.70	1	1	1
12/22/2021 05:00	0.8	13.9	1,447.1	0.7	2.90	1	1	0
12/22/2021 06:00	0.9	13.8	1,670.4	0.7	5.00	1	1	1
12/22/2021 07:00	1.3	13.1	1,961.6	1.0	7.80	1	1	1
12/22/2021 08:00	1.4	13.1	1,951.4	1.1	7.80	1	1	1
12/22/2021 09:00	0.8	13.9	1,424.1	0.7	2.80	1	1	0
12/22/2021 10:00	0.8	13.8	1,500.8	0.7	3.00	1	1	1
12/22/2021 11:00	1.3	13.1	1,961.9	1.0	7.80	1	1	1
12/22/2021 12:00	1.2	13.3	1,919.0	0.9	5.80	1	1	1
12/22/2021 13:00	0.9	13.8	1,605.4	0.7	4.80	1	1	1
12/22/2021 14:00	1.0	13.8	1,768.3	0.8	5.30	1	1	0
12/22/2021 15:00	1.3	13.1	1,967.2	1.0	7.90	1	1	1
12/22/2021 16:00	1.5	12.8	2,020.2	1.1	8.10	1	1	1
12/22/2021 17:00	1.6	12.5	2,104.7	1.1	8.40	1	1	1
12/22/2021 18:00	1.5	13.0	1,983.5	1.1	7.90	1	1	1
12/22/2021 19:00	1.4	13.1	1,945.2	1.1	7.80	1	1	1
12/22/2021 20:00	1.5	13.0	1,961.3	1.1	7.80	1	1	1
12/22/2021 21:00	0.9	13.9	1,531.0	0.8	4.60	1	1	0
12/22/2021 22:00	1.0	13.8	1,728.2	0.8	5.20	1	1	1
12/22/2021 23:00	1.4	12.9	2,000.2	1.0	8.00	1	1	1
Average/Sum#:	1.2	13.4	1,810.9	0.9	147.60 #	24 #	24 #	19 #
Minimum:	0.8	12.5	1,424.1	0.7	2.80	1	1	0
Maximum:	1.6	13.9	2,104.7	1.1	8.40	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/23/2021 00:00	1.3	13.2	1,907.8	1.0	7.60	1	1	1
12/23/2021 01:00	0.9	13.9	1,563.8	0.8	4.70	1	1	0
12/23/2021 02:00	1.0	13.8	1,598.1	0.8	4.80	1	1	1
12/23/2021 03:00	1.2	13.2	1,920.3	0.9	5.80	1	1	1
12/23/2021 04:00	1.3	13.2	1,896.3	1.0	7.60	1	1	1
12/23/2021 05:00	0.9	13.8	1,625.6	0.7	4.90	1	1	0
12/23/2021 06:00	1.0	13.7	1,618.0	0.8	4.90	1	1	1
12/23/2021 07:00	1.4	12.8	2,014.5	1.0	8.10	1	1	1
12/23/2021 08:00	1.4	13.1	1,909.0	1.1	7.60	1	1	1
12/23/2021 09:00	0.9	13.9	1,528.6	0.8	4.60	1	1	0
12/23/2021 10:00	0.9	13.8	1,623.1	0.7	4.90	1	1	1
12/23/2021 11:00	1.3	13.1	1,918.0	1.0	7.70	1	1	1
12/23/2021 12:00	1.4	13.1	1,892.2	1.1	7.60	1	1	1
12/23/2021 13:00	0.9	13.8	1,599.0	0.7	4.80	1	1	0
12/23/2021 14:00	0.7	13.9	1,300.2	0.6	2.60	1	1	0
12/23/2021 15:00	0.9	13.9	1,602.7	0.8	4.80	1	1	0
12/23/2021 16:00	1.2	13.4	1,816.2	0.9	5.40	1	1	1
12/23/2021 17:00	1.4	13.1	1,891.9	1.1	7.60	1	1	1
12/23/2021 18:00	1.0	13.8	1,639.7	0.8	4.90	1	1	1
12/23/2021 19:00	1.4	13.0	1,926.7	1.0	7.70	1	1	1
12/23/2021 20:00	1.5	13.1	1,889.6	1.1	7.60	1	1	1
12/23/2021 21:00	0.8	13.9	1,445.7	0.7	2.90	1	1	0
12/23/2021 22:00	1.0	13.8	1,560.5	0.8	4.70	1	1	1
12/23/2021 23:00	1.3	13.0	1,944.0	1.0	7.80	1	1	1
Average/Sum#:	1.1	13.5	1,734.6	0.9	141.60 #	24 #	24 #	17 #
Minimum:	0.7	12.8	1,300.2	0.6	2.60	1	1	0
Maximum:	1.5	13.9	2,014.5	1.1	8.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/24/2021 00:00	1.4	13.1	1,899.6	1.1	7.60	1	1	1
12/24/2021 01:00	0.9	13.9	1,499.4	0.8	4.50	1	1	0
12/24/2021 02:00	0.8	13.9	1,452.9	0.7	2.90	1	1	0
12/24/2021 03:00	0.7	13.9	1,339.1	0.6	2.70	1	1	0
12/24/2021 04:00	0.7	13.9	1,343.8	0.6	2.70	1	1	0
12/24/2021 05:00	0.9	13.9	1,724.5	0.8	5.20	1	1	0
12/24/2021 06:00	1.2	13.3	1,811.3	0.9	5.40	1	1	1
12/24/2021 07:00	1.2	13.3	1,846.5	0.9	5.50	1	1	1
12/24/2021 08:00	0.9	13.8	1,631.2	0.7	4.90	1	1	1
12/24/2021 09:00	1.2	13.1	1,931.0	0.9	5.80	1	1	1
12/24/2021 10:00	1.4	13.1	1,914.8	1.1	7.70	1	1	1
12/24/2021 11:00	0.8	14.0	1,379.4	0.7	4.10	1	1	0
12/24/2021 12:00	0.9	13.9	1,598.2	0.8	4.80	1	1	0
12/24/2021 13:00	0.7	14.0	1,402.6	0.6	2.80	1	1	0
12/24/2021 14:00	0.8	14.0	1,389.1	0.7	4.20	1	1	0
12/24/2021 15:00	0.8	13.9	1,471.0	0.7	2.90	1	1	0
12/24/2021 16:00	0.8	13.9	1,490.2	0.7	3.00	1	1	1
12/24/2021 17:00	1.4	13.0	1,944.0	1.0	7.80	1	1	1
12/24/2021 18:00	1.5	12.9	1,962.2	1.1	7.80	1	1	1
12/24/2021 19:00	1.6	12.9	1,970.6	1.2	7.90	1	1	1
12/24/2021 20:00	1.5	13.2	1,902.1	1.1	7.60	1	1	1
12/24/2021 21:00	0.8	14.0	1,386.4	0.7	4.20	1	1	0
12/24/2021 22:00	0.9	13.8	1,578.1	0.7	4.70	1	1	1
12/24/2021 23:00	1.4	12.9	1,993.2	1.0	8.00	1	1	1
Average/Sum#:	1.1	13.6	1,660.9	0.8	124.70 #	24 #	24 #	13 #
Minimum:	0.7	12.9	1,339.1	0.6	2.70	1	1	0
Maximum:	1.6	14.0	1,993.2	1.2	8.00	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/25/2021 00:00	1.5	13.1	1,916.4	1.1	7.70	1	1	1
12/25/2021 01:00	0.9	13.9	1,532.8	0.8	4.60	1	1	0
12/25/2021 02:00	0.8	13.9	1,428.9	0.7	2.90	1	1	0
12/25/2021 03:00	0.7	13.9	1,339.8	0.6	2.70	1	1	0
12/25/2021 04:00	0.9	13.8	1,557.0	0.7	4.70	1	1	1
12/25/2021 05:00	1.3	13.0	1,967.0	1.0	7.90	1	1	1
12/25/2021 06:00	1.3	13.1	1,918.1	1.0	7.70	1	1	1
12/25/2021 07:00	0.9	13.8	1,558.6	0.7	4.70	1	1	1
12/25/2021 08:00	0.9	13.8	1,583.5	0.7	4.80	1	1	0
12/25/2021 09:00	0.7	13.9	1,390.3	0.6	2.80	1	1	0
12/25/2021 10:00	0.9	13.8	1,609.0	0.7	4.80	1	1	0
12/25/2021 11:00	0.8	13.9	1,564.4	0.7	3.10	1	1	0
12/25/2021 12:00	0.8	13.9	1,532.1	0.7	3.10	1	1	0
12/25/2021 13:00	0.8	13.9	1,473.5	0.7	2.90	1	1	0
12/25/2021 14:00	0.8	13.9	1,582.5	0.7	3.20	1	1	0
12/25/2021 15:00	0.9	13.9	1,590.9	0.8	4.80	1	1	0
12/25/2021 16:00	1.3	13.2	1,884.3	1.0	7.50	1	1	1
12/25/2021 17:00	1.5	12.7	2,018.8	1.1	8.10	1	1	1
12/25/2021 18:00	1.6	12.7	2,020.0	1.2	8.10	1	1	1
12/25/2021 19:00	1.6	12.8	2,012.3	1.2	8.00	1	1	1
12/25/2021 20:00	1.4	13.2	1,904.1	1.1	7.60	1	1	1
12/25/2021 21:00	0.9	13.9	1,623.6	0.8	4.90	1	1	0
12/25/2021 22:00	0.8	13.9	1,570.0	0.7	3.10	1	1	1
12/25/2021 23:00	1.3	13.1	1,960.9	1.0	7.80	1	1	1
Average/Sum#:	1.1	13.5	1,689.1	0.8	127.50 #	24 #	24 #	12 #
Minimum:	0.7	12.7	1,339.8	0.6	2.70	1	1	0
Maximum:	1.6	13.9	2,020.0	1.2	8.10	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 NOx, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/26/2021 00:00	2.9	14.4	1,212.6	2.6	6.05	1	0	1
12/26/2021 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/26/2021 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/26/2021 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/26/2021 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/26/2021 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/26/2021 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/26/2021 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/26/2021 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/26/2021 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/26/2021 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/26/2021 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/26/2021 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/26/2021 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/26/2021 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
12/26/2021 15:00	11.4	18.7	203.8	30.6	4.60	1	0	0
12/26/2021 16:00	23.3	16.1	713.1	28.6	75.60	1	0	0
12/26/2021 17:00	0.9	13.8	1,726.0	0.7	5.20	1	1	0
12/26/2021 18:00	1.0	13.8	1,731.1	0.8	5.20	1	1	1
12/26/2021 19:00	1.4	13.0	1,966.7	1.0	7.90	1	1	1
12/26/2021 20:00	1.4	13.0	1,958.9	1.0	7.80	1	1	1
12/26/2021 21:00	0.9	13.9	1,604.7	0.8	4.80	1	1	0
12/26/2021 22:00	0.9	13.8	1,688.8	0.7	5.10	1	1	1
12/26/2021 23:00	1.3	13.1	1,968.1	1.0	7.90	1	1	1
Average/Sum#:	4.5	14.4	1,477.4	6.8	130.15 #	10 #	7 #	6 #
Minimum:	0.9	13.0	203.8	0.7	4.60	0	0	0
Maximum:	23.3	18.7	1,968.1	30.6	75.60	1	1	1
%SI	58.33	58.33	58.33	58.33	58.33	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/27/2021 00:00	1.4	12.9	2,004.4	1.0	8.00	1	1	1
12/27/2021 01:00	1.4	13.1	1,946.2	1.1	7.80	1	1	1
12/27/2021 02:00	0.9	13.9	1,630.6	0.8	4.90	1	1	0
12/27/2021 03:00	0.8	13.9	1,484.6	0.7	3.00	1	1	0
12/27/2021 04:00	0.8	13.9	1,495.7	0.7	3.00	1	1	0
12/27/2021 05:00	0.9	13.8	1,648.3	0.7	4.90	1	1	1
12/27/2021 06:00	1.3	12.9	2,002.9	1.0	8.00	1	1	1
12/27/2021 07:00	1.5	12.5	2,105.6	1.1	8.40	1	1	1
12/27/2021 08:00	1.5	12.6	2,079.8	1.1	8.30	1	1	1
12/27/2021 09:00	1.6	12.6	2,093.9	1.1	8.40	1	1	1
12/27/2021 10:00	1.6	12.7	2,048.0	1.2	8.20	1	1	1
12/27/2021 11:00	1.5	12.8	1,992.0	1.1	8.00	1	1	1
12/27/2021 12:00	0.9	13.9	1,675.0	0.8	5.00	1	1	0
12/27/2021 13:00	0.9	13.9	1,616.6	0.8	4.80	1	1	0
12/27/2021 14:00	1.4	13.1	1,944.3	1.1	7.80	1	1	1
12/27/2021 15:00	1.6	12.6	2,066.6	1.1	8.30	1	1	1
12/27/2021 16:00	1.7	12.1	2,186.8	1.1	8.70	1	1	1
12/27/2021 17:00	1.7	12.1	2,198.9	1.1	8.80	1	1	1
12/27/2021 18:00	1.7	12.1	2,197.4	1.1	8.80	1	1	1
12/27/2021 19:00	1.7	12.1	2,200.4	1.1	8.80	1	1	1
12/27/2021 20:00	1.7	12.1	2,202.2	1.1	8.80	1	1	1
12/27/2021 21:00	1.7	12.2	2,182.2	1.2	8.70	1	1	1
12/27/2021 22:00	1.6	12.8	2,045.7	1.2	8.20	1	1	1
12/27/2021 23:00	1.6	12.9	2,027.4	1.2	8.10	1	1	1
Average/Sum#:	1.4	12.9	1,961.5	1.0	175.70 #	24 #	24 #	19 #
Minimum:	0.8	12.1	1,484.6	0.7	3.00	1	1	0
Maximum:	1.7	13.9	2,202.2	1.2	8.80	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/28/2021 00:00	1.2	13.3	1,913.9	0.9	5.70	1	1	1
12/28/2021 01:00	0.8	13.9	1,513.2	0.7	3.00	1	1	0
12/28/2021 02:00	0.8	13.9	1,599.1	0.7	3.20	1	1	1
12/28/2021 03:00	1.2	13.3	1,933.3	0.9	5.80	1	1	1
12/28/2021 04:00	1.2	13.3	1,909.1	0.9	5.70	1	1	1
12/28/2021 05:00	0.8	13.9	1,549.2	0.7	3.10	1	1	0
12/28/2021 06:00	0.9	13.8	1,705.2	0.7	5.10	1	1	1
12/28/2021 07:00	1.2	13.2	1,959.5	0.9	5.90	1	1	1
12/28/2021 08:00	1.4	13.1	1,992.9	1.1	8.00	1	1	1
12/28/2021 09:00	1.4	13.1	1,964.5	1.1	7.90	1	1	1
12/28/2021 10:00	0.8	13.9	1,526.1	0.7	3.10	1	1	0
12/28/2021 11:00	0.8	13.9	1,418.2	0.7	2.80	1	1	0
12/28/2021 12:00	0.8	13.9	1,509.8	0.7	3.00	1	1	0
12/28/2021 13:00	1.1	13.5	1,842.5	0.9	5.50	1	1	1
12/28/2021 14:00	1.3	13.2	1,896.8	1.0	7.60	1	1	1
12/28/2021 15:00	0.9	13.8	1,653.6	0.7	5.00	1	1	1
12/28/2021 16:00	1.4	12.7	2,080.7	1.0	8.30	1	1	1
12/28/2021 17:00	1.7	12.2	2,218.2	1.2	8.90	1	1	1
12/28/2021 18:00	1.7	12.3	2,194.9	1.2	8.80	1	1	1
12/28/2021 19:00	1.6	12.5	2,130.1	1.1	8.50	1	1	1
12/28/2021 20:00	1.5	12.7	2,100.0	1.1	8.40	1	1	1
12/28/2021 21:00	1.5	12.8	2,057.9	1.1	8.20	1	1	1
12/28/2021 22:00	1.5	12.9	2,048.7	1.1	8.20	1	1	1
12/28/2021 23:00	1.5	13.0	1,995.8	1.1	8.00	1	1	1
Average/Sum#:	1.2	13.3	1,863.1	0.9	147.70 #	24 #	24 #	19 #
Minimum:	0.8	12.2	1,418.2	0.7	2.80	1	1	0
Maximum:	1.7	13.9	2,218.2	1.2	8.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/29/2021 00:00	1.2	13.3	1,910.1	0.9	5.70	1	1	1
12/29/2021 01:00	0.8	13.9	1,504.1	0.7	3.00	1	1	0
12/29/2021 02:00	0.9	13.8	1,567.7	0.7	4.70	1	1	1
12/29/2021 03:00	1.1	13.3	1,935.3	0.9	5.80	1	1	1
12/29/2021 04:00	1.2	13.3	1,922.4	0.9	5.80	1	1	1
12/29/2021 05:00	0.8	13.9	1,449.1	0.7	2.90	1	1	0
12/29/2021 06:00	1.0	13.8	1,741.8	0.8	5.20	1	1	1
12/29/2021 07:00	1.3	13.1	1,989.3	1.0	8.00	1	1	1
12/29/2021 08:00	1.3	13.1	1,954.4	1.0	7.80	1	1	1
12/29/2021 09:00	0.8	13.9	1,410.8	0.7	2.80	1	1	0
12/29/2021 10:00	0.8	13.8	1,611.3	0.7	3.20	1	1	1
12/29/2021 11:00	1.3	13.0	2,004.5	1.0	8.00	1	1	1
12/29/2021 12:00	1.2	13.3	1,911.2	0.9	5.70	1	1	1
12/29/2021 13:00	0.9	13.9	1,652.0	0.8	5.00	1	1	0
12/29/2021 14:00	0.9	13.8	1,661.2	0.7	5.00	1	1	1
12/29/2021 15:00	1.3	13.0	1,998.2	1.0	8.00	1	1	1
12/29/2021 16:00	1.6	12.7	2,064.6	1.2	8.30	1	1	1
12/29/2021 17:00	1.7	12.1	2,226.0	1.1	8.90	1	1	1
12/29/2021 18:00	1.7	12.1	2,216.8	1.1	8.90	1	1	1
12/29/2021 19:00	1.7	12.1	2,230.3	1.1	8.90	1	1	1
12/29/2021 20:00	1.7	12.1	2,230.6	1.1	8.90	1	1	1
12/29/2021 21:00	1.6	12.6	2,089.9	1.1	8.40	1	1	1
12/29/2021 22:00	1.4	13.1	1,965.3	1.1	7.90	1	1	1
12/29/2021 23:00	1.5	13.1	1,989.3	1.1	8.00	1	1	1
Average/Sum#:	1.2	13.2	1,884.8	0.9	154.80 #	24 #	24 #	20 #
Minimum:	0.8	12.1	1,410.8	0.7	2.80	1	1	0
Maximum:	1.7	13.9	2,230.6	1.2	8.90	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/30/2021 00:00	1.2	13.3	1,907.5	0.9	5.70	1	1	1
12/30/2021 01:00	0.9	13.9	1,628.9	0.8	4.90	1	1	0
12/30/2021 02:00	0.7	13.9	1,355.2	0.6	2.70	1	1	0
12/30/2021 03:00	0.9	13.8	1,725.5	0.7	5.20	1	1	0
12/30/2021 04:00	1.0	13.5	1,841.8	0.8	5.50	1	1	1
12/30/2021 05:00	1.0	13.4	1,818.0	0.8	5.50	1	1	1
12/30/2021 06:00	0.9	13.8	1,684.9	0.7	5.10	1	1	1
12/30/2021 07:00	1.3	13.1	2,017.1	1.0	8.10	1	1	1
12/30/2021 08:00	1.5	12.7	2,112.7	1.1	8.50	1	1	1
12/30/2021 09:00	1.4	13.0	2,007.3	1.0	8.00	1	1	1
12/30/2021 10:00	0.9	13.9	1,616.8	0.8	4.90	1	1	0
12/30/2021 11:00	0.9	13.8	1,653.3	0.7	5.00	1	1	1
12/30/2021 12:00	1.3	13.1	1,985.9	1.0	7.90	1	1	1
12/30/2021 13:00	1.2	13.3	1,894.5	0.9	5.70	1	1	1
12/30/2021 14:00	0.9	13.9	1,652.0	0.8	5.00	1	1	0
12/30/2021 15:00	0.9	13.9	1,599.6	0.8	4.80	1	1	1
12/30/2021 16:00	1.3	13.1	1,974.2	1.0	7.90	1	1	1
12/30/2021 17:00	1.6	12.5	2,097.6	1.1	8.40	1	1	1
12/30/2021 18:00	1.6	12.6	2,072.8	1.1	8.30	1	1	1
12/30/2021 19:00	1.4	13.0	1,981.7	1.0	7.90	1	1	1
12/30/2021 20:00	1.6	12.7	2,074.9	1.2	8.30	1	1	1
12/30/2021 21:00	1.6	12.6	2,073.2	1.1	8.30	1	1	1
12/30/2021 22:00	1.6	12.8	2,044.2	1.2	8.20	1	1	1
12/30/2021 23:00	1.5	13.0	2,004.7	1.1	8.00	1	1	1
Average/Sum#:	1.2	13.3	1,867.7	0.9	157.80 #	24 #	24 #	19 #
Minimum:	0.7	12.5	1,355.2	0.6	2.70	1	1	0
Maximum:	1.6	13.9	2,112.7	1.2	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NOx

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:13 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/31/2021 00:00	1.3	13.3	1,912.7	1.0	7.70	1	1	1
12/31/2021 01:00	0.8	13.9	1,519.2	0.7	3.00	1	1	0
12/31/2021 02:00	0.7	13.9	1,323.4	0.6	2.60	1	1	0
12/31/2021 03:00	0.9	13.8	1,721.3	0.7	5.20	1	1	0
12/31/2021 04:00	1.0	13.5	1,842.0	0.8	5.50	1	1	1
12/31/2021 05:00	1.2	13.4	1,820.7	0.9	5.50	1	1	1
12/31/2021 06:00	0.8	13.9	1,417.0	0.7	2.80	1	1	1
12/31/2021 07:00	1.4	13.0	1,997.5	1.0	8.00	1	1	1
12/31/2021 08:00	1.5	13.0	2,006.8	1.1	8.00	1	1	1
12/31/2021 09:00	1.2	13.3	1,914.6	0.9	5.70	1	1	1
12/31/2021 10:00	0.8	13.9	1,489.1	0.7	3.00	1	1	0
12/31/2021 11:00	0.8	13.9	1,450.8	0.7	2.90	1	1	0
12/31/2021 12:00	0.8	13.9	1,574.4	0.7	3.10	1	1	0
12/31/2021 13:00	0.7	14.0	1,300.1	0.6	2.60	1	1	0
12/31/2021 14:00	0.8	14.0	1,438.8	0.7	4.30	1	1	0
12/31/2021 15:00	0.9	13.8	1,623.4	0.7	4.90	1	1	1
12/31/2021 16:00	1.4	12.8	2,021.3	1.0	8.10	1	1	1
12/31/2021 17:00	1.6	12.5	2,095.7	1.1	8.40	1	1	1
12/31/2021 18:00	1.6	12.5	2,097.3	1.1	8.40	1	1	1
12/31/2021 19:00	1.6	12.4	2,119.3	1.1	8.50	1	1	1
12/31/2021 20:00	1.5	12.7	2,031.2	1.1	8.10	1	1	1
12/31/2021 21:00	0.9	13.9	1,566.2	0.8	4.70	1	1	0
12/31/2021 22:00	1.0	13.8	1,754.3	0.8	5.30	1	1	0
12/31/2021 23:00	1.2	13.3	1,937.0	0.9	5.80	1	1	1
Average/Sum#:	1.1	13.4	1,748.9	0.9	132.10 #	24 #	24 #	14 #
Minimum:	0.7	12.4	1,300.1	0.6	2.60	1	1	0
Maximum:	1.6	14.0	2,119.3	1.1	8.50	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

ATTACHMENT 7
Hourly Emissions – CO

FCD: AQ-16
Title V: #6

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/01/2021 00:00	0.4	14.0	1,526.8	0.6	1.2	1	0	0
10/01/2021 01:00	0.3	14.0	1,537.0	0.3	0.9	1	0	0
10/01/2021 02:00	0.2	14.0	1,534.3	0.3	0.6	1	0	0
10/01/2021 03:00	0.2	14.0	1,535.7	0.2	0.6	1	0	0
10/01/2021 04:00	0.2	14.0	1,526.8	0.2	0.6	1	0	1
10/01/2021 05:00	1.4	12.8	2,010.3	0.5	4.6	1	0	1
10/01/2021 06:00	1.0	13.1	1,721.5	0.7	2.9	1	0	1
10/01/2021 07:00	0.3	14.0	1,438.0	0.7	0.8	1	0	0
10/01/2021 08:00	0.3	14.0	1,354.6	0.5	0.8	1	0	0
10/01/2021 09:00	0.2	14.0	1,355.6	0.3	0.5	1	0	0
10/01/2021 10:00	0.2	14.1	1,360.0	0.2	0.5	1	0	0
10/01/2021 11:00	0.2	14.1	1,365.7	0.2	0.5	1	0	0
10/01/2021 12:00	0.2	14.1	1,380.7	0.2	0.5	1	0	0
10/01/2021 13:00	0.3	13.9	1,726.7	0.2	1.0	1	0	0
10/01/2021 14:00	0.4	13.9	1,546.2	0.3	1.2	1	0	0
10/01/2021 15:00	0.3	13.9	1,720.8	0.3	1.0	1	1	0
10/01/2021 16:00	0.3	13.9	1,704.1	0.3	1.0	1	1	0
10/01/2021 17:00	0.4	13.7	1,786.8	0.3	1.3	1	1	0
10/01/2021 18:00	0.4	13.7	1,778.8	0.3	1.3	1	1	0
10/01/2021 19:00	0.4	13.9	1,702.4	0.3	1.3	1	1	0
10/01/2021 20:00	0.4	13.9	1,684.2	0.3	1.3	1	1	0
10/01/2021 21:00	0.4	13.9	1,663.3	0.3	1.3	1	1	0
10/01/2021 22:00	0.3	14.0	1,677.1	0.3	1.0	1	1	0
10/01/2021 23:00	0.2	14.0	1,683.2	0.3	0.6	1	1	0
Average/Sum#:	0.4	13.9	1,596.7	0.3	27.3 #	24 #	9 #	3 #
Minimum:	0.2	12.8	1,354.6	0.2	0.5	1	0	0
Maximum:	1.4	14.1	2,010.3	0.7	4.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/02/2021 00:00	0.2	14.0	1,688.8	0.2	0.6	1	1	0
10/02/2021 01:00	0.2	14.0	1,676.6	0.2	0.6	1	1	0
10/02/2021 02:00	0.2	14.0	1,537.6	0.2	0.6	1	1	0
10/02/2021 03:00	0.2	14.0	1,662.8	0.2	0.6	1	1	0
10/02/2021 04:00	0.2	14.0	1,678.6	0.2	0.6	1	1	0
10/02/2021 05:00	0.3	14.0	1,670.9	0.2	1.0	1	1	0
10/02/2021 06:00	0.2	14.0	1,637.2	0.2	0.6	1	1	0
10/02/2021 07:00	0.2	14.0	1,460.7	0.2	0.6	1	1	0
10/02/2021 08:00	0.2	14.0	1,347.5	0.2	0.5	1	1	0
10/02/2021 09:00	0.2	14.1	1,312.8	0.2	0.5	1	1	0
10/02/2021 10:00	0.2	14.1	1,288.4	0.2	0.5	1	1	0
10/02/2021 11:00	0.2	14.1	1,287.0	0.2	0.5	1	1	0
10/02/2021 12:00	0.2	14.1	1,301.1	0.2	0.5	1	1	0
10/02/2021 13:00	0.2	14.1	1,371.0	0.2	0.5	1	1	0
10/02/2021 14:00	0.3	13.9	1,658.4	0.2	0.9	1	1	0
10/02/2021 15:00	0.3	13.9	1,702.1	0.3	1.0	1	1	0
10/02/2021 16:00	0.4	13.9	1,624.5	0.3	1.2	1	1	0
10/02/2021 17:00	0.4	13.7	1,754.0	0.3	1.3	1	1	0
10/02/2021 18:00	0.4	13.7	1,777.0	0.3	1.3	1	1	0
10/02/2021 19:00	0.4	13.9	1,699.2	0.3	1.3	1	1	0
10/02/2021 20:00	0.4	13.9	1,672.1	0.3	1.3	1	1	0
10/02/2021 21:00	0.4	13.9	1,690.3	0.3	1.3	1	1	0
10/02/2021 22:00	0.4	13.9	1,691.0	0.3	1.3	1	1	0
10/02/2021 23:00	0.3	13.9	1,683.8	0.3	1.0	1	1	0
Average/Sum#:	0.3	14.0	1,578.1	0.2	20.1 #	24 #	24 #	0 #
Minimum:	0.2	13.7	1,287.0	0.2	0.5	1	1	0
Maximum:	0.4	14.1	1,777.0	0.3	1.3	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/03/2021 00:00	0.2	14.0	1,629.9	0.3	0.6	1	1	0
10/03/2021 01:00	0.2	14.0	1,574.6	0.2	0.6	1	1	0
10/03/2021 02:00	0.2	14.0	1,453.7	0.2	0.6	1	1	0
10/03/2021 03:00	0.2	14.0	1,416.3	0.2	0.5	1	1	0
10/03/2021 04:00	0.2	14.0	1,468.2	0.2	0.6	1	1	0
10/03/2021 05:00	0.2	14.0	1,454.1	0.2	0.6	1	1	0
10/03/2021 06:00	0.2	14.0	1,458.1	0.2	0.6	1	1	0
10/03/2021 07:00	0.3	14.1	1,291.6	0.2	0.8	1	1	0
10/03/2021 08:00	0.3	14.0	1,354.3	0.3	0.8	1	1	0
10/03/2021 09:00	0.3	14.1	1,292.2	0.3	0.8	1	1	0
10/03/2021 10:00	0.3	14.1	1,286.3	0.3	0.7	1	1	0
10/03/2021 11:00	0.2	14.1	1,346.5	0.3	0.5	1	1	0
10/03/2021 12:00	0.2	14.1	1,415.3	0.2	0.5	1	1	0
10/03/2021 13:00	0.3	13.9	1,612.2	0.2	0.9	1	1	0
10/03/2021 14:00	0.4	13.9	1,683.0	0.3	1.3	1	1	0
10/03/2021 15:00	0.4	13.9	1,689.1	0.3	1.3	1	1	0
10/03/2021 16:00	0.4	13.9	1,605.8	0.3	1.2	1	1	0
10/03/2021 17:00	0.4	14.0	1,424.8	0.3	1.1	1	1	0
10/03/2021 18:00	0.4	13.8	1,743.3	0.3	1.3	1	1	0
10/03/2021 19:00	0.4	13.9	1,640.0	0.3	1.2	1	1	0
10/03/2021 20:00	0.4	13.9	1,680.5	0.3	1.3	1	1	0
10/03/2021 21:00	0.4	13.9	1,628.0	0.3	1.2	1	1	0
10/03/2021 22:00	0.4	13.9	1,669.1	0.3	1.3	1	1	0
10/03/2021 23:00	0.4	13.9	1,686.4	0.3	1.3	1	1	0
Average/Sum#:	0.3	14.0	1,521.0	0.3	21.6 #	24 #	24 #	0 #
Minimum:	0.2	13.8	1,286.3	0.2	0.5	1	1	0
Maximum:	0.4	14.1	1,743.3	0.3	1.3	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/04/2021 00:00	0.4	13.9	1,666.2	0.3	1.3	1	1	0
10/04/2021 01:00	0.5	13.9	1,539.0	0.3	1.5	1	1	0
10/04/2021 02:00	0.5	13.9	1,551.2	0.4	1.5	1	1	0
10/04/2021 03:00	0.4	13.9	1,618.2	0.4	1.2	1	1	0
10/04/2021 04:00	0.4	13.9	1,667.7	0.3	1.3	1	1	0
10/04/2021 05:00	0.4	13.9	1,683.0	0.3	1.3	1	1	0
10/04/2021 06:00	0.4	13.9	1,637.9	0.3	1.2	1	1	0
10/04/2021 07:00	0.3	14.0	1,601.9	0.3	0.9	1	1	0
10/04/2021 08:00	0.4	13.9	1,614.7	0.3	1.2	1	1	0
10/04/2021 09:00	0.3	14.0	1,594.3	0.3	0.9	1	1	0
10/04/2021 10:00	0.4	13.9	1,547.3	0.3	1.2	1	1	0
10/04/2021 11:00	0.4	13.9	1,635.6	0.3	1.2	1	1	0
10/04/2021 12:00	0.4	13.9	1,658.7	0.3	1.3	1	1	0
10/04/2021 13:00	0.4	13.9	1,614.0	0.3	1.2	1	1	0
10/04/2021 14:00	0.4	13.9	1,691.2	0.3	1.3	1	1	0
10/04/2021 15:00	0.4	13.9	1,630.2	0.3	1.2	1	1	0
10/04/2021 16:00	0.4	13.8	1,757.8	0.3	1.3	1	1	0
10/04/2021 17:00	0.4	13.7	1,776.3	0.3	1.3	1	1	0
10/04/2021 18:00	0.4	13.7	1,772.6	0.3	1.3	1	1	0
10/04/2021 19:00	0.4	13.8	1,750.7	0.3	1.3	1	1	0
10/04/2021 20:00	0.4	13.7	1,750.3	0.3	1.3	1	1	0
10/04/2021 21:00	0.4	13.8	1,747.7	0.3	1.3	1	1	0
10/04/2021 22:00	0.4	13.9	1,586.4	0.3	1.2	1	1	0
10/04/2021 23:00	0.3	14.0	1,597.6	0.3	0.9	1	1	0
Average/Sum#:	0.4	13.9	1,653.8	0.3	29.6 #	24 #	24 #	0 #
Minimum:	0.3	13.7	1,539.0	0.3	0.9	1	1	0
Maximum:	0.5	14.0	1,776.3	0.4	1.5	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/05/2021 00:00	0.3	14.0	1,554.4	0.3	0.9	1	1	0
10/05/2021 01:00	0.3	14.0	1,538.6	0.3	0.9	1	1	0
10/05/2021 02:00	0.4	14.0	1,524.7	0.3	1.2	1	1	0
10/05/2021 03:00	0.3	13.9	1,617.1	0.3	0.9	1	1	0
10/05/2021 04:00	0.4	13.9	1,577.3	0.3	1.2	1	1	0
10/05/2021 05:00	0.4	13.8	1,673.6	0.3	1.2	1	1	0
10/05/2021 06:00	0.5	13.9	1,680.8	0.3	1.6	1	1	0
10/05/2021 07:00	0.5	13.9	1,633.4	0.4	1.5	1	1	0
10/05/2021 08:00	0.5	13.9	1,599.9	0.4	1.5	1	1	0
10/05/2021 09:00	0.5	13.9	1,643.1	0.4	1.6	1	1	0
10/05/2021 10:00	0.4	13.9	1,661.0	0.4	1.3	1	1	0
10/05/2021 11:00	0.3	14.0	1,641.0	0.3	0.9	1	1	0
10/05/2021 12:00	0.3	13.9	1,711.2	0.3	1.0	1	1	0
10/05/2021 13:00	0.3	13.9	1,661.7	0.3	0.9	1	1	0
10/05/2021 14:00	0.4	13.9	1,640.2	0.3	1.2	1	1	0
10/05/2021 15:00	0.4	13.9	1,684.1	0.3	1.3	1	1	0
10/05/2021 16:00	0.4	13.9	1,673.1	0.3	1.3	1	1	0
10/05/2021 17:00	0.4	13.9	1,632.6	0.3	1.2	1	1	0
10/05/2021 18:00	0.4	13.9	1,626.2	0.3	1.2	1	1	0
10/05/2021 19:00	0.4	13.9	1,681.5	0.3	1.3	1	1	0
10/05/2021 20:00	0.5	13.9	1,590.7	0.3	1.5	1	1	0
10/05/2021 21:00	0.4	14.0	1,507.9	0.3	1.2	1	1	0
10/05/2021 22:00	0.3	14.0	1,636.5	0.3	0.9	1	1	0
10/05/2021 23:00	0.4	14.0	1,410.5	0.3	1.1	1	1	0
Average/Sum#:	0.4	13.9	1,616.7	0.3	28.8 #	24 #	24 #	0 #
Minimum:	0.3	13.8	1,410.5	0.3	0.9	1	1	0
Maximum:	0.5	14.0	1,711.2	0.4	1.6	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/06/2021 00:00	0.6	14.0	1,295.0	0.4	1.5	1	1	0
10/06/2021 01:00	0.6	14.0	1,294.9	0.4	1.5	1	1	0
10/06/2021 02:00	0.7	14.0	1,295.2	0.5	1.7	1	1	0
10/06/2021 03:00	0.7	14.0	1,295.5	0.6	1.7	1	1	0
10/06/2021 04:00	0.7	14.0	1,319.0	0.6	1.8	1	1	0
10/06/2021 05:00	0.4	13.9	1,528.7	0.5	1.2	1	1	0
10/06/2021 06:00	0.4	13.9	1,599.7	0.4	1.2	1	1	0
10/06/2021 07:00	0.4	13.9	1,563.6	0.3	1.2	1	1	0
10/06/2021 08:00	0.6	13.9	1,404.1	0.4	1.6	1	1	0
10/06/2021 09:00	0.3	13.9	1,585.6	0.4	0.9	1	1	0
10/06/2021 10:00	0.4	13.9	1,567.8	0.4	1.2	1	1	0
10/06/2021 11:00	0.4	13.9	1,507.1	0.3	1.1	1	1	0
10/06/2021 12:00	0.3	13.9	1,609.5	0.3	0.9	1	1	0
10/06/2021 13:00	0.3	13.9	1,636.5	0.3	0.9	1	1	0
10/06/2021 14:00	0.3	13.9	1,682.2	0.3	1.0	1	1	0
10/06/2021 15:00	0.4	13.9	1,668.2	0.3	1.3	1	1	0
10/06/2021 16:00	0.4	13.9	1,641.6	0.3	1.2	1	1	0
10/06/2021 17:00	0.6	13.9	1,392.9	0.4	1.6	1	1	0
10/06/2021 18:00	0.5	13.9	1,595.2	0.4	1.5	1	1	0
10/06/2021 19:00	0.4	13.9	1,626.1	0.4	1.2	1	1	0
10/06/2021 20:00	0.4	13.8	1,720.9	0.3	1.3	1	1	0
10/06/2021 21:00	0.4	13.9	1,641.9	0.3	1.2	1	1	0
10/06/2021 22:00	0.5	13.9	1,586.7	0.3	1.5	1	1	0
10/06/2021 23:00	0.4	13.9	1,685.2	0.3	1.3	1	1	0
Average/Sum#:	0.5	13.9	1,531.0	0.4	31.5 #	24 #	24 #	0 #
Minimum:	0.3	13.8	1,294.9	0.3	0.9	1	1	0
Maximum:	0.7	14.0	1,720.9	0.6	1.8	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/07/2021 00:00	0.4	13.9	1,550.3	0.3	1.2	1	1	0
10/07/2021 01:00	0.4	13.9	1,548.9	0.3	1.2	1	1	0
10/07/2021 02:00	0.4	13.9	1,546.0	0.3	1.2	1	1	0
10/07/2021 03:00	0.5	14.0	1,459.9	0.3	1.4	1	1	0
10/07/2021 04:00	0.3	13.9	1,657.6	0.3	0.9	1	1	0
10/07/2021 05:00	0.3	13.9	1,640.7	0.3	0.9	1	1	0
10/07/2021 06:00	0.3	13.9	1,688.4	0.3	1.0	1	1	0
10/07/2021 07:00	0.3	13.9	1,630.0	0.3	0.9	1	1	0
10/07/2021 08:00	0.3	13.9	1,616.8	0.3	0.9	1	1	0
10/07/2021 09:00	0.3	13.9	1,542.5	0.3	0.9	1	1	0
10/07/2021 10:00	0.3	13.9	1,528.4	0.3	0.9	1	1	0
10/07/2021 11:00	0.3	14.0	1,544.1	0.3	0.9	1	1	0
10/07/2021 12:00	0.3	14.0	1,547.9	0.3	0.9	1	1	0
10/07/2021 13:00	0.3	14.0	1,546.4	0.3	0.9	1	1	0
10/07/2021 14:00	0.3	13.9	1,685.3	0.3	1.0	1	1	0
10/07/2021 15:00	0.4	13.9	1,670.6	0.3	1.3	1	1	0
10/07/2021 16:00	0.4	13.9	1,703.6	0.3	1.3	1	1	0
10/07/2021 17:00	0.4	13.7	1,813.3	0.3	1.3	1	1	0
10/07/2021 18:00	0.4	13.8	1,761.9	0.3	1.3	1	1	0
10/07/2021 19:00	0.5	13.9	1,655.6	0.3	1.6	1	1	0
10/07/2021 20:00	0.5	13.8	1,627.5	0.4	1.5	1	1	0
10/07/2021 21:00	0.4	13.9	1,664.9	0.4	1.3	1	1	0
10/07/2021 22:00	0.3	13.9	1,675.8	0.3	0.9	1	1	0
10/07/2021 23:00	0.4	13.9	1,594.0	0.3	1.2	1	1	0
Average/Sum#:	0.4	13.9	1,620.9	0.3	26.8 #	24 #	24 #	0 #
Minimum:	0.3	13.7	1,459.9	0.3	0.9	1	1	0
Maximum:	0.5	14.0	1,813.3	0.4	1.6	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/08/2021 00:00	0.4	13.9	1,512.8	0.3	1.1	1	1	0
10/08/2021 01:00	0.4	13.9	1,500.4	0.3	1.1	1	1	0
10/08/2021 02:00	0.4	13.9	1,531.9	0.3	1.2	1	1	0
10/08/2021 03:00	0.4	13.9	1,587.0	0.3	1.2	1	1	0
10/08/2021 04:00	0.3	13.9	1,665.2	0.3	0.9	1	1	0
10/08/2021 05:00	0.4	13.9	1,558.2	0.3	1.2	1	1	0
10/08/2021 06:00	0.3	13.9	1,657.0	0.3	0.9	1	1	0
10/08/2021 07:00	0.4	13.9	1,539.1	0.3	1.2	1	1	0
10/08/2021 08:00	0.4	13.9	1,546.9	0.3	1.2	1	1	0
10/08/2021 09:00	0.5	14.0	1,394.2	0.3	1.3	1	1	0
10/08/2021 10:00	0.3	13.9	1,653.2	0.3	0.9	1	1	0
10/08/2021 11:00	0.4	14.0	1,465.4	0.3	1.1	1	1	0
10/08/2021 12:00	0.3	13.9	1,605.4	0.3	0.9	1	1	0
10/08/2021 13:00	0.3	14.0	1,572.0	0.3	0.9	1	1	0
10/08/2021 14:00	0.4	14.0	1,538.5	0.3	1.2	1	1	0
10/08/2021 15:00	0.3	14.0	1,620.8	0.3	0.9	1	1	0
10/08/2021 16:00	0.3	14.0	1,681.0	0.3	1.0	1	1	0
10/08/2021 17:00	0.3	14.0	1,604.7	0.3	0.9	1	1	0
10/08/2021 18:00	0.3	14.0	1,620.8	0.3	0.9	1	1	0
10/08/2021 19:00	0.3	13.9	1,645.3	0.3	0.9	1	1	0
10/08/2021 20:00	0.6	14.0	1,376.5	0.4	1.6	1	1	0
10/08/2021 21:00	33.5	16.7	321.4	0.0	5.8	1	0	0
10/08/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	1.9	14.1	1,509.0	0.3	28.3 #	22 #	21 #	0 #
Minimum:	0.3	13.9	321.4	0.3	0.9	0	0	0
Maximum:	33.5	16.7	1,681.0	0.4	5.8	1	1	0
%SI	8.33	8.33	8.33	12.50	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/09/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/10/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/11/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/12/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/13/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/14/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/15/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/16/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/17/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/18/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/19/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/20/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2021 13:00	104.5	17.9	288.6	0.0	77.0	1	1	0
10/20/2021 14:00	41.7	16.3	621.0	0.0	74.3	1	1	0
10/20/2021 15:00	1.8	13.8	1,514.3	0.0	5.1	1	1	1
10/20/2021 16:00	0.9	12.7	1,858.7	0.0	2.7	1	1	1
10/20/2021 17:00	0.4	13.8	1,682.9	0.0	1.3	1	1	1
10/20/2021 18:00	1.3	12.9	1,994.9	0.6	4.3	1	1	1
10/20/2021 19:00	1.0	12.8	2,042.0	0.7	3.3	1	1	1
10/20/2021 20:00	0.8	12.1	2,183.3	0.7	2.6	1	1	1
10/20/2021 21:00	0.7	12.3	2,115.5	0.6	2.3	1	1	1
10/20/2021 22:00	22.2	15.6	654.4	0.0	8.3	1	0	0
10/20/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	17.5	14.0	1,495.6	0.7	181.2 #	10 #	9 #	7 #
Minimum:	0.4	12.1	288.6	0.6	1.3	0	0	0
Maximum:	104.5	17.9	2,183.3	0.7	77.0	1	1	1
%SI	58.33	58.33	58.33	83.33	58.33	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/21/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/22/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/23/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2021 01:00	86.1	17.8	320.9	0.0	74.2	1	0	0
10/23/2021 02:00	25.0	17.3	379.9	0.0	34.8	1	0	0
10/23/2021 03:00	51.8	16.0	739.1	0.0	103.2	1	0	0
10/23/2021 04:00	0.5	13.9	1,516.5	0.0	1.4	1	0	0
10/23/2021 05:00	0.4	13.9	1,576.3	0.0	1.2	1	0	0
10/23/2021 06:00	0.3	13.9	1,761.6	0.3	1.0	1	0	0
10/23/2021 07:00	0.4	13.9	1,496.0	0.3	1.1	1	0	0
10/23/2021 08:00	0.3	13.9	1,644.8	0.3	0.9	1	1	0
10/23/2021 09:00	0.5	13.9	1,399.8	0.3	1.3	1	1	0
10/23/2021 10:00	0.3	13.9	1,599.4	0.3	0.9	1	1	0
10/23/2021 11:00	0.3	13.9	1,570.7	0.3	0.9	1	1	0
10/23/2021 12:00	0.3	13.9	1,616.5	0.3	0.9	1	1	0
10/23/2021 13:00	0.3	13.9	1,579.5	0.3	0.9	1	1	0
10/23/2021 14:00	0.3	13.9	1,663.6	0.3	0.9	1	1	0
10/23/2021 15:00	0.3	13.9	1,638.0	0.3	0.9	1	1	0
10/23/2021 16:00	0.3	13.8	1,667.4	0.3	0.9	1	1	0
10/23/2021 17:00	0.8	13.0	1,955.9	0.4	2.6	1	1	1
10/23/2021 18:00	0.8	12.6	2,055.0	0.5	2.6	1	1	1
10/23/2021 19:00	0.3	13.8	1,653.2	0.5	0.9	1	1	1
10/23/2021 20:00	0.3	13.8	1,676.0	0.3	0.9	1	1	1
10/23/2021 21:00	0.8	12.7	2,033.9	0.3	2.6	1	1	1
10/23/2021 22:00	7.9	13.8	1,476.4	0.0	15.8	1	0	1
10/23/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	8.1	14.2	1,500.9	0.3	250.8 #	22 #	14 #	6 #
Minimum:	0.3	12.6	320.9	0.3	0.9	0	0	0
Maximum:	86.1	17.8	2,055.0	0.5	103.2	1	1	1
%SI	8.33	8.33	8.33	33.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/24/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/24/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	1	0
10/24/2021 07:00	30.2	17.7	337.7	0.0	30.7	1	1	0
10/24/2021 08:00	43.5	15.1	1,060.4	0.0	105.0	1	1	0
10/24/2021 09:00	0.3	13.9	1,571.7	0.0	0.9	1	1	0
10/24/2021 10:00	0.3	13.9	1,581.6	0.0	0.9	1	1	0
10/24/2021 11:00	0.4	13.9	1,562.2	0.3	1.2	1	1	0
10/24/2021 12:00	0.3	13.9	1,618.0	0.3	0.9	1	1	0
10/24/2021 13:00	0.4	13.9	1,511.9	0.3	1.1	1	1	0
10/24/2021 14:00	0.3	13.9	1,629.5	0.3	0.9	1	1	0
10/24/2021 15:00	0.3	13.9	1,654.3	0.3	0.9	1	1	0
10/24/2021 16:00	0.3	13.7	1,765.5	0.3	1.0	1	1	0
10/24/2021 17:00	0.9	12.7	2,020.0	0.4	2.9	1	1	1
10/24/2021 18:00	0.8	12.4	2,049.3	0.5	2.5	1	1	1
10/24/2021 19:00	0.2	13.9	1,694.2	0.5	0.6	1	1	0
10/24/2021 20:00	0.3	13.9	1,731.8	0.4	1.0	1	1	1
10/24/2021 21:00	0.7	12.7	2,033.3	0.3	2.3	1	1	1
10/24/2021 22:00	0.5	13.3	1,685.5	0.4	1.5	1	1	1
10/24/2021 23:00	0.5	14.0	1,412.7	0.4	1.4	1	0	0
Average/Sum#:	4.7	13.9	1,583.5	0.4	155.7 #	17 #	18 #	5 #
Minimum:	0.2	12.4	337.7	0.3	0.6	0	0	0
Maximum:	43.5	17.7	2,049.3	0.5	105.0	1	1	1
%SI	29.17	29.17	29.17	45.83	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/25/2021 00:00	0.4	13.9	1,548.6	0.4	1.2	1	0	0
10/25/2021 01:00	0.4	13.9	1,538.7	0.3	1.2	1	0	0
10/25/2021 02:00	0.5	13.9	1,492.1	0.3	1.4	1	0	0
10/25/2021 03:00	0.4	13.9	1,549.7	0.3	1.2	1	0	0
10/25/2021 04:00	0.4	13.9	1,567.8	0.3	1.2	1	0	0
10/25/2021 05:00	0.3	13.8	1,783.7	0.3	1.0	1	0	0
10/25/2021 06:00	0.4	13.9	1,634.7	0.3	1.2	1	0	0
10/25/2021 07:00	0.3	13.7	1,804.1	0.2	1.0	1	1	0
10/25/2021 08:00	0.2	13.9	1,686.3	0.2	0.6	1	1	0
10/25/2021 09:00	0.4	13.8	1,789.5	0.2	1.3	1	1	1
10/25/2021 10:00	0.9	13.0	1,970.9	0.4	3.0	1	1	1
10/25/2021 11:00	0.9	12.8	2,051.1	0.6	3.0	1	1	1
10/25/2021 12:00	0.8	13.0	1,973.2	0.7	2.6	1	1	1
10/25/2021 13:00	0.4	13.9	1,642.6	0.5	1.2	1	1	0
10/25/2021 14:00	0.4	14.0	1,553.7	0.4	1.2	1	1	0
10/25/2021 15:00	0.4	13.9	1,574.6	0.3	1.2	1	1	1
10/25/2021 16:00	1.0	12.6	2,095.0	0.4	3.3	1	1	1
10/25/2021 17:00	0.8	12.5	2,120.4	0.5	2.7	1	1	1
10/25/2021 18:00	0.6	12.7	2,064.1	0.6	2.0	1	1	1
10/25/2021 19:00	0.9	13.8	1,650.6	0.6	2.8	1	1	1
10/25/2021 20:00	1.3	14.0	1,495.4	0.7	3.7	1	1	0
10/25/2021 21:00	0.8	13.1	1,968.7	0.8	2.7	1	1	1
10/25/2021 22:00	0.5	13.5	1,701.8	0.7	1.5	1	1	1
10/25/2021 23:00	0.5	14.0	1,362.6	0.5	1.3	1	0	0
Average/Sum#:	0.6	13.6	1,734.2	0.4	43.5 #	24 #	16 #	11 #
Minimum:	0.2	12.5	1,362.6	0.2	0.6	1	0	0
Maximum:	1.3	14.0	2,120.4	0.8	3.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/26/2021 00:00	0.6	14.0	1,363.5	0.4	1.6	1	0	0
10/26/2021 01:00	0.5	14.0	1,366.4	0.4	1.3	1	0	0
10/26/2021 02:00	0.5	14.0	1,371.6	0.4	1.3	1	0	0
10/26/2021 03:00	0.5	14.0	1,373.2	0.4	1.3	1	0	0
10/26/2021 04:00	0.4	13.9	1,530.4	0.4	1.2	1	0	0
10/26/2021 05:00	0.3	13.8	1,807.4	0.3	1.0	1	0	0
10/26/2021 06:00	0.5	13.9	1,490.9	0.3	1.4	1	0	0
10/26/2021 07:00	0.4	13.9	1,614.3	0.3	1.2	1	1	0
10/26/2021 08:00	0.0	0.0	1,607.2	0.0	0.0	1	1	0
10/26/2021 09:00	0.0	0.0	1,595.2	0.0	0.0	1	1	1
10/26/2021 10:00	0.5	12.6	2,046.5	0.0	1.6	1	1	1
10/26/2021 11:00	0.4	13.0	1,954.9	0.0	1.3	1	1	1
10/26/2021 12:00	0.0	13.8	1,687.7	0.2	0.0	1	1	0
10/26/2021 13:00	0.1	13.9	1,478.8	0.1	0.3	1	1	0
10/26/2021 14:00	0.1	13.9	1,450.7	0.1	0.3	1	1	0
10/26/2021 15:00	0.1	13.8	1,575.7	0.1	0.3	1	1	1
10/26/2021 16:00	0.5	12.7	2,042.2	0.2	1.6	1	1	1
10/26/2021 17:00	0.4	12.4	2,119.7	0.3	1.3	1	1	1
10/26/2021 18:00	0.4	12.6	2,091.1	0.3	1.3	1	1	1
10/26/2021 19:00	0.4	12.6	2,047.6	0.3	1.3	1	1	1
10/26/2021 20:00	0.0	13.8	1,584.6	0.2	0.0	1	1	0
10/26/2021 21:00	0.0	13.8	1,790.8	0.1	0.0	1	1	1
10/26/2021 22:00	0.5	12.7	2,071.7	0.1	1.7	1	1	1
10/26/2021 23:00	0.4	12.8	2,016.8	0.2	1.3	1	1	1
Average/Sum#:	0.3	13.5	1,711.6	0.3	22.6 #	24 #	17 #	11 #
Minimum:	0.0	12.4	1,363.5	0.1	0.0	1	0	0
Maximum:	0.6	14.0	2,119.7	0.4	1.7	1	1	1
%SI	8.33	8.33	0.00	16.67	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/27/2021 00:00	0.1	13.8	1,563.7	0.3	0.3	1	1	0
10/27/2021 01:00	0.2	13.8	1,592.2	0.2	0.6	1	1	1
10/27/2021 02:00	0.4	13.1	1,964.8	0.2	1.3	1	1	1
10/27/2021 03:00	0.3	13.2	1,935.8	0.2	1.0	1	1	1
10/27/2021 04:00	0.0	13.8	1,602.1	0.2	0.0	1	1	0
10/27/2021 05:00	0.0	13.8	1,616.8	0.1	0.0	1	1	1
10/27/2021 06:00	0.5	13.0	2,018.4	0.1	1.7	1	1	1
10/27/2021 07:00	0.5	12.7	2,066.7	0.3	1.7	1	1	1
10/27/2021 08:00	0.3	13.2	1,951.2	0.3	1.0	1	1	1
10/27/2021 09:00	0.1	13.9	1,494.3	0.2	0.3	1	1	1
10/27/2021 10:00	0.1	13.9	1,454.8	0.1	0.3	1	1	0
10/27/2021 11:00	0.0	13.8	1,610.6	0.1	0.0	1	1	0
10/27/2021 12:00	0.1	13.9	1,339.4	0.1	0.3	1	1	0
10/27/2021 13:00	0.0	13.9	1,488.9	0.0	0.0	1	1	0
10/27/2021 14:00	0.2	13.3	1,856.6	0.1	0.6	1	1	1
10/27/2021 15:00	0.3	12.9	1,907.8	0.1	0.9	1	1	1
10/27/2021 16:00	0.0	13.8	1,711.2	0.1	0.0	1	1	1
10/27/2021 17:00	0.4	12.9	1,982.5	0.2	1.3	1	1	1
10/27/2021 18:00	0.4	12.3	2,133.1	0.2	1.3	1	1	1
10/27/2021 19:00	0.3	12.1	2,182.6	0.3	1.0	1	1	1
10/27/2021 20:00	0.3	12.3	2,135.5	0.2	1.0	1	1	1
10/27/2021 21:00	0.3	12.3	2,149.7	0.2	1.0	1	1	1
10/27/2021 22:00	0.2	12.7	2,047.0	0.2	0.7	1	1	1
10/27/2021 23:00	0.2	13.3	1,845.7	0.2	0.6	1	1	1
Average/Sum#:	0.2	13.2	1,818.8	0.2	16.9 #	24 #	24 #	18 #
Minimum:	0.0	12.1	1,339.4	0.0	0.0	1	1	0
Maximum:	0.5	13.9	2,182.6	0.3	1.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/28/2021 00:00	0.1	13.9	1,361.0	0.1	0.3	1	0	0
10/28/2021 01:00	0.2	13.9	1,355.2	0.2	0.5	1	0	0
10/28/2021 02:00	0.2	13.9	1,357.9	0.2	0.5	1	0	0
10/28/2021 03:00	0.2	13.9	1,358.5	0.2	0.5	1	0	0
10/28/2021 04:00	0.1	13.8	1,542.5	0.2	0.3	1	0	0
10/28/2021 05:00	0.5	12.8	2,003.7	0.2	1.6	1	0	1
10/28/2021 06:00	0.5	13.0	1,984.4	0.3	1.7	1	0	1
10/28/2021 07:00	0.3	13.3	1,831.5	0.3	1.0	1	0	1
10/28/2021 08:00	0.2	13.9	1,360.2	0.3	0.5	1	0	0
10/28/2021 09:00	0.2	13.9	1,366.0	0.2	0.5	1	0	0
10/28/2021 10:00	0.1	13.9	1,373.7	0.2	0.3	1	0	0
10/28/2021 11:00	0.1	13.9	1,381.5	0.1	0.3	1	0	0
10/28/2021 12:00	0.0	13.7	1,740.9	0.1	0.0	1	0	0
10/28/2021 13:00	0.2	13.8	1,500.5	0.1	0.6	1	0	0
10/28/2021 14:00	0.0	13.9	1,534.6	0.1	0.0	1	1	0
10/28/2021 15:00	0.0	13.8	1,580.9	0.1	0.0	1	1	1
10/28/2021 16:00	0.4	12.4	2,087.8	0.1	1.3	1	1	1
10/28/2021 17:00	0.3	11.9	2,202.0	0.2	1.0	1	1	1
10/28/2021 18:00	0.2	12.0	2,193.7	0.2	0.7	1	1	1
10/28/2021 19:00	0.2	12.0	2,188.3	0.1	0.6	1	1	1
10/28/2021 20:00	0.2	12.1	2,172.5	0.1	0.7	1	1	1
10/28/2021 21:00	0.3	12.4	2,109.0	0.1	1.0	1	1	1
10/28/2021 22:00	0.3	12.5	2,086.6	0.2	1.0	1	1	1
10/28/2021 23:00	0.3	12.7	2,015.0	0.2	1.0	1	1	1
Average/Sum#:	0.2	13.2	1,737.0	0.2	15.9 #	24 #	10 #	12 #
Minimum:	0.0	11.9	1,355.2	0.1	0.0	1	0	0
Maximum:	0.5	13.9	2,202.0	0.3	1.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/29/2021 00:00	0.3	13.0	1,949.1	0.2	1.0	1	1	1
10/29/2021 01:00	0.3	13.0	1,951.6	0.2	1.0	1	1	1
10/29/2021 02:00	0.3	13.1	1,947.0	0.2	1.0	1	1	1
10/29/2021 03:00	0.3	13.0	1,947.5	0.2	1.0	1	1	1
10/29/2021 04:00	0.4	13.0	1,947.2	0.2	1.3	1	1	1
10/29/2021 05:00	0.4	13.0	1,950.0	0.3	1.3	1	1	1
10/29/2021 06:00	0.4	13.1	1,951.4	0.3	1.3	1	1	1
10/29/2021 07:00	0.4	13.1	1,949.5	0.3	1.3	1	1	1
10/29/2021 08:00	0.4	13.1	1,947.5	0.3	1.3	1	1	1
10/29/2021 09:00	0.3	13.2	1,752.5	0.3	0.9	1	1	1
10/29/2021 10:00	0.2	13.7	1,449.0	0.2	0.5	1	1	1
10/29/2021 11:00	0.2	12.8	1,981.4	0.2	0.6	1	1	1
10/29/2021 12:00	0.2	13.1	1,762.5	0.2	0.6	1	1	1
10/29/2021 13:00	0.2	13.7	1,438.3	0.2	0.5	1	1	1
10/29/2021 14:00	0.4	12.7	1,993.4	0.2	1.3	1	1	1
10/29/2021 15:00	0.4	12.7	1,995.1	0.3	1.3	1	1	1
10/29/2021 16:00	0.4	12.7	1,993.2	0.3	1.3	1	1	1
10/29/2021 17:00	0.4	12.8	1,989.9	0.3	1.3	1	1	1
10/29/2021 18:00	0.4	12.8	1,986.4	0.3	1.3	1	1	1
10/29/2021 19:00	0.4	12.8	1,985.2	0.3	1.3	1	1	1
10/29/2021 20:00	0.4	12.8	1,981.8	0.3	1.3	1	1	1
10/29/2021 21:00	0.4	12.8	1,978.1	0.3	1.3	1	1	1
10/29/2021 22:00	0.3	12.9	1,963.8	0.3	1.0	1	1	1
10/29/2021 23:00	0.4	12.6	2,027.9	0.3	1.3	1	1	1
Average/Sum#:	0.3	13.0	1,909.1	0.3	26.3 #	24 #	24 #	24 #
Minimum:	0.2	12.6	1,438.3	0.2	0.5	1	1	1
Maximum:	0.4	13.7	2,027.9	0.3	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/30/2021 00:00	0.0	13.7	1,659.6	0.2	0.0	1	1	1
10/30/2021 01:00	0.1	13.8	1,470.0	0.1	0.3	1	1	0
10/30/2021 02:00	0.3	13.2	1,786.9	0.1	0.9	1	1	1
10/30/2021 03:00	0.4	13.0	1,938.3	0.2	1.3	1	1	1
10/30/2021 04:00	0.0	13.8	1,638.9	0.2	0.0	1	1	0
10/30/2021 05:00	0.0	13.7	1,697.1	0.1	0.0	1	1	1
10/30/2021 06:00	0.5	12.7	2,022.7	0.1	1.6	1	1	1
10/30/2021 07:00	0.4	13.0	1,945.0	0.2	1.3	1	1	1
10/30/2021 08:00	0.1	13.8	1,517.6	0.3	0.3	1	1	0
10/30/2021 09:00	0.4	13.9	1,350.1	0.2	1.0	1	1	0
10/30/2021 10:00	0.3	13.9	1,350.1	0.2	0.8	1	1	0
10/30/2021 11:00	0.0	13.8	1,483.5	0.2	0.0	1	1	0
10/30/2021 12:00	0.0	13.9	1,399.9	0.1	0.0	1	1	0
10/30/2021 13:00	0.1	13.9	1,409.0	0.0	0.3	1	1	0
10/30/2021 14:00	0.0	13.9	1,531.7	0.0	0.0	1	1	0
10/30/2021 15:00	0.0	13.8	1,624.8	0.0	0.0	1	1	1
10/30/2021 16:00	0.5	12.6	2,048.4	0.1	1.6	1	1	1
10/30/2021 17:00	0.5	12.4	2,109.1	0.2	1.6	1	1	1
10/30/2021 18:00	0.6	12.5	2,086.5	0.4	2.0	1	1	1
10/30/2021 19:00	0.4	12.7	2,003.7	0.3	1.3	1	1	1
10/30/2021 20:00	0.0	13.8	1,677.2	0.2	0.0	1	1	0
10/30/2021 21:00	0.0	13.8	1,645.4	0.1	0.0	1	1	1
10/30/2021 22:00	0.5	12.8	2,019.3	0.1	1.6	1	1	1
10/30/2021 23:00	0.4	13.0	1,934.0	0.2	1.3	1	1	1
Average/Sum#:	0.2	13.4	1,722.9	0.2	17.2 #	24 #	24 #	14 #
Minimum:	0.0	12.4	1,350.1	0.0	0.0	1	1	0
Maximum:	0.6	13.9	2,109.1	0.4	2.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
10/31/2021 00:00	0.0	13.8	1,666.6	0.2	0.0	1	1	0
10/31/2021 01:00	0.1	13.8	1,577.3	0.1	0.3	1	1	1
10/31/2021 02:00	0.2	13.1	1,952.5	0.1	0.7	1	1	1
10/31/2021 03:00	0.2	13.1	1,928.8	0.2	0.7	1	1	1
10/31/2021 04:00	0.0	13.8	1,701.4	0.1	0.0	1	1	0
10/31/2021 05:00	0.0	13.8	1,573.7	0.1	0.0	1	1	1
10/31/2021 06:00	0.5	12.8	2,045.2	0.1	1.7	1	1	1
10/31/2021 07:00	0.4	13.1	1,942.4	0.2	1.3	1	1	1
10/31/2021 08:00	0.0	13.8	1,658.3	0.2	0.0	1	1	0
10/31/2021 09:00	0.0	13.8	1,592.7	0.1	0.0	1	1	0
10/31/2021 10:00	0.2	13.9	1,415.7	0.1	0.5	1	1	0
10/31/2021 11:00	0.0	13.8	1,558.0	0.1	0.0	1	1	0
10/31/2021 12:00	0.0	13.8	1,610.2	0.1	0.0	1	1	0
10/31/2021 13:00	0.0	13.8	1,696.3	0.0	0.0	1	1	0
10/31/2021 14:00	0.0	13.9	1,575.5	0.0	0.0	1	1	0
10/31/2021 15:00	0.1	13.8	1,610.0	0.0	0.3	1	1	1
10/31/2021 16:00	0.5	12.7	2,009.4	0.2	1.6	1	1	1
10/31/2021 17:00	0.5	12.5	2,055.8	0.3	1.6	1	1	1
10/31/2021 18:00	0.4	12.5	2,069.8	0.4	1.3	1	1	1
10/31/2021 19:00	0.4	12.9	1,952.2	0.3	1.3	1	1	1
10/31/2021 20:00	0.0	13.8	1,693.9	0.2	0.0	1	1	0
10/31/2021 21:00	0.1	13.8	1,585.1	0.1	0.3	1	1	1
10/31/2021 22:00	0.5	12.8	2,016.5	0.2	1.6	1	1	1
10/31/2021 23:00	0.4	13.0	1,944.3	0.3	1.3	1	1	1
Average/Sum#:	0.2	13.4	1,768.0	0.2	14.5 #	24 #	24 #	14 #
Minimum:	0.0	12.5	1,415.7	0.0	0.0	1	1	0
Maximum:	0.5	13.9	2,069.8	0.4	1.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/01/2021 00:00	0.0	13.8	1,635.1	0.2	0.0	1	1	0
11/01/2021 01:00	0.0	13.7	1,693.5	0.1	0.0	1	1	1
11/01/2021 02:00	0.5	13.0	1,951.2	0.1	1.6	1	1	1
11/01/2021 03:00	0.5	12.7	2,003.4	0.3	1.6	1	1	1
11/01/2021 04:00	0.0	13.8	1,598.1	0.3	0.0	1	1	1
11/01/2021 05:00	0.0	13.7	1,688.6	0.1	0.0	1	1	1
11/01/2021 06:00	0.6	12.5	2,066.7	0.1	1.9	1	1	1
11/01/2021 07:00	0.5	12.3	2,118.8	0.2	1.6	1	1	1
11/01/2021 08:00	0.4	12.9	1,963.2	0.3	1.3	1	1	1
11/01/2021 09:00	0.1	13.8	1,577.1	0.2	0.3	1	1	0
11/01/2021 10:00	0.1	13.8	1,538.3	0.2	0.3	1	1	1
11/01/2021 11:00	0.5	12.6	2,040.4	0.2	1.6	1	1	1
11/01/2021 12:00	0.5	12.5	2,033.3	0.3	1.6	1	1	1
11/01/2021 13:00	0.0	13.8	1,716.1	0.3	0.0	1	1	0
11/01/2021 14:00	0.0	13.6	1,803.2	0.1	0.0	1	1	0
11/01/2021 15:00	0.5	12.6	2,035.9	0.1	1.6	1	1	1
11/01/2021 16:00	0.4	12.4	2,072.0	0.2	1.3	1	1	1
11/01/2021 17:00	0.3	11.9	2,205.0	0.3	1.0	1	1	1
11/01/2021 18:00	0.4	12.0	2,167.8	0.3	1.3	1	1	1
11/01/2021 19:00	0.3	11.9	2,202.3	0.2	1.0	1	1	1
11/01/2021 20:00	0.3	11.8	2,228.3	0.2	1.0	1	1	1
11/01/2021 21:00	0.3	11.9	2,209.1	0.2	1.0	1	1	1
11/01/2021 22:00	0.4	12.4	2,109.1	0.2	1.3	1	1	1
11/01/2021 23:00	0.4	13.1	1,929.3	0.3	1.3	1	1	1
Average/Sum#:	0.3	12.9	1,941.1	0.2	22.6 #	24 #	24 #	20 #
Minimum:	0.0	11.8	1,538.3	0.1	0.0	1	1	0
Maximum:	0.6	13.8	2,228.3	0.3	1.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/02/2021 00:00	0.1	13.8	1,564.4	0.2	0.3	1	1	0
11/02/2021 01:00	0.2	13.8	1,588.3	0.2	0.6	1	1	1
11/02/2021 02:00	0.6	13.1	1,952.4	0.3	2.0	1	1	1
11/02/2021 03:00	0.4	13.1	1,940.9	0.3	1.3	1	1	1
11/02/2021 04:00	0.0	13.7	1,660.4	0.3	0.0	1	1	1
11/02/2021 05:00	0.0	13.8	1,639.6	0.1	0.0	1	1	1
11/02/2021 06:00	0.5	12.6	2,065.5	0.1	1.6	1	1	1
11/02/2021 07:00	0.4	12.6	2,067.5	0.2	1.3	1	1	1
11/02/2021 08:00	0.4	13.1	1,947.1	0.3	1.3	1	1	1
11/02/2021 09:00	0.0	13.8	1,524.3	0.2	0.0	1	1	0
11/02/2021 10:00	0.0	13.8	1,633.7	0.1	0.0	1	1	0
11/02/2021 11:00	0.2	13.9	1,330.6	0.1	0.5	1	1	0
11/02/2021 12:00	0.0	13.9	1,533.6	0.1	0.0	1	1	0
11/02/2021 13:00	0.0	13.9	1,636.6	0.1	0.0	1	1	0
11/02/2021 14:00	0.0	13.9	1,622.1	0.0	0.0	1	1	0
11/02/2021 15:00	0.0	13.8	1,649.3	0.0	0.0	1	1	1
11/02/2021 16:00	0.5	12.6	2,054.5	0.1	1.6	1	1	1
11/02/2021 17:00	0.4	12.0	2,168.6	0.2	1.3	1	1	1
11/02/2021 18:00	0.3	12.1	2,167.3	0.3	1.0	1	1	1
11/02/2021 19:00	0.5	11.8	2,239.2	0.3	1.6	1	1	1
11/02/2021 20:00	0.6	12.1	2,174.8	0.3	2.0	1	1	1
11/02/2021 21:00	0.6	12.2	2,156.4	0.4	2.0	1	1	1
11/02/2021 22:00	0.4	12.3	2,126.3	0.4	1.3	1	1	1
11/02/2021 23:00	0.3	12.9	1,964.6	0.3	1.0	1	1	1
Average/Sum#:	0.3	13.1	1,850.3	0.2	20.7 #	24 #	24 #	17 #
Minimum:	0.0	11.8	1,330.6	0.0	0.0	1	1	0
Maximum:	0.6	13.9	2,239.2	0.4	2.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/03/2021 00:00	0.0	13.9	1,693.3	0.2	0.0	1	1	0
11/03/2021 01:00	0.0	13.8	1,645.7	0.1	0.0	1	1	1
11/03/2021 02:00	0.6	13.1	1,946.2	0.2	2.0	1	1	1
11/03/2021 03:00	0.5	13.1	1,936.1	0.3	1.6	1	1	1
11/03/2021 04:00	0.1	13.7	1,659.7	0.3	0.3	1	1	1
11/03/2021 05:00	0.0	13.8	1,786.9	0.2	0.0	1	1	1
11/03/2021 06:00	0.7	12.9	2,013.9	0.2	2.3	1	1	1
11/03/2021 07:00	0.6	13.0	1,983.4	0.3	2.0	1	1	1
11/03/2021 08:00	0.0	13.7	1,679.1	0.3	0.0	1	1	1
11/03/2021 09:00	0.0	13.8	1,688.5	0.1	0.0	1	1	0
11/03/2021 10:00	0.0	13.9	1,591.5	0.0	0.0	1	1	0
11/03/2021 11:00	0.0	13.9	1,702.2	0.0	0.0	1	1	0
11/03/2021 12:00	0.0	13.9	1,532.4	0.0	0.0	1	1	0
11/03/2021 13:00	0.0	13.9	1,700.0	0.0	0.0	1	1	0
11/03/2021 14:00	0.0	13.9	1,521.9	0.0	0.0	1	1	0
11/03/2021 15:00	0.0	13.8	1,598.3	0.0	0.0	1	1	1
11/03/2021 16:00	0.9	12.5	2,053.5	0.2	2.9	1	1	1
11/03/2021 17:00	0.6	11.8	2,209.9	0.3	1.9	1	1	1
11/03/2021 18:00	0.8	12.0	2,166.9	0.5	2.6	1	1	1
11/03/2021 19:00	0.7	11.8	2,229.6	0.5	2.3	1	1	1
11/03/2021 20:00	0.7	11.8	2,207.3	0.5	2.2	1	1	1
11/03/2021 21:00	0.6	12.1	2,151.9	0.5	1.9	1	1	1
11/03/2021 22:00	0.5	12.3	2,087.8	0.4	1.6	1	1	1
11/03/2021 23:00	0.6	12.9	1,939.3	0.4	1.9	1	1	1
Average/Sum#:	0.3	13.1	1,863.6	0.2	25.5 #	24 #	24 #	17 #
Minimum:	0.0	11.8	1,521.9	0.0	0.0	1	1	0
Maximum:	0.9	13.9	2,229.6	0.5	2.9	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/04/2021 00:00	0.0	13.8	1,479.7	0.2	0.0	1	1	0
11/04/2021 01:00	0.2	13.7	1,595.4	0.2	0.6	1	1	1
11/04/2021 02:00	0.8	12.9	1,955.7	0.3	2.6	1	1	1
11/04/2021 03:00	0.6	12.7	1,983.9	0.4	1.9	1	1	1
11/04/2021 04:00	0.0	13.8	1,692.1	0.3	0.0	1	1	1
11/04/2021 05:00	0.0	13.7	1,777.3	0.1	0.0	1	1	1
11/04/2021 06:00	1.0	12.7	2,022.2	0.2	3.3	1	1	1
11/04/2021 07:00	0.6	12.7	2,000.2	0.4	1.9	1	1	1
11/04/2021 08:00	0.0	13.9	1,599.3	0.4	0.0	1	1	0
11/04/2021 09:00	0.0	13.9	1,533.5	0.1	0.0	1	1	0
11/04/2021 10:00	0.0	13.9	1,526.0	0.0	0.0	1	1	0
11/04/2021 11:00	0.0	13.9	1,499.5	0.0	0.0	1	1	0
11/04/2021 12:00	0.1	14.0	1,387.7	0.0	0.3	1	1	0
11/04/2021 13:00	0.0	13.9	1,549.4	0.0	0.0	1	1	0
11/04/2021 14:00	0.0	13.9	1,666.7	0.0	0.0	1	1	0
11/04/2021 15:00	0.0	13.9	1,567.9	0.0	0.0	1	1	0
11/04/2021 16:00	0.7	12.7	2,014.7	0.2	2.3	1	1	1
11/04/2021 17:00	0.7	12.4	2,094.6	0.3	2.3	1	1	1
11/04/2021 18:00	0.6	12.5	2,064.8	0.5	1.9	1	1	1
11/04/2021 19:00	0.0	13.8	1,702.6	0.3	0.0	1	1	1
11/04/2021 20:00	0.0	13.8	1,645.3	0.1	0.0	1	1	1
11/04/2021 21:00	0.5	12.7	2,030.4	0.1	1.6	1	1	1
11/04/2021 22:00	0.3	13.3	1,688.6	0.2	0.9	1	1	1
11/04/2021 23:00	0.2	13.9	1,363.5	0.3	0.5	1	0	0
Average/Sum#:	0.3	13.4	1,726.7	0.2	20.1 #	24 #	23 #	14 #
Minimum:	0.0	12.4	1,363.5	0.0	0.0	1	0	0
Maximum:	1.0	14.0	2,094.6	0.5	3.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/05/2021 00:00	0.2	13.9	1,350.7	0.2	0.5	1	0	0
11/05/2021 01:00	0.1	13.9	1,360.1	0.2	0.3	1	0	0
11/05/2021 02:00	0.2	13.9	1,363.9	0.2	0.5	1	0	0
11/05/2021 03:00	0.1	13.9	1,399.7	0.1	0.3	1	0	0
11/05/2021 04:00	0.0	13.8	1,591.3	0.1	0.0	1	0	0
11/05/2021 05:00	1.0	12.2	2,093.0	0.3	3.2	1	0	1
11/05/2021 06:00	0.8	12.6	2,068.0	0.4	2.6	1	0	1
11/05/2021 07:00	0.8	12.6	1,871.7	0.6	2.4	1	0	1
11/05/2021 08:00	0.4	13.9	1,369.5	0.5	1.0	1	0	0
11/05/2021 09:00	0.0	0.0	1,377.5	0.0	0.0	1	0	0
11/05/2021 10:00	0.1	13.9	1,374.4	0.0	0.3	1	0	0
11/05/2021 11:00	0.3	13.9	1,375.0	0.0	0.8	1	0	0
11/05/2021 12:00	0.2	13.9	1,420.9	0.2	0.5	1	0	0
11/05/2021 13:00	0.2	13.8	1,805.1	0.2	0.7	1	0	0
11/05/2021 14:00	0.2	13.8	1,580.6	0.2	0.6	1	0	0
11/05/2021 15:00	0.2	13.8	1,576.0	0.2	0.6	1	1	1
11/05/2021 16:00	0.9	12.5	2,076.9	0.3	2.9	1	1	1
11/05/2021 17:00	0.7	12.4	2,107.0	0.4	2.3	1	1	1
11/05/2021 18:00	0.6	12.4	2,089.2	0.5	1.9	1	1	1
11/05/2021 19:00	0.6	12.8	1,984.7	0.4	1.9	1	1	1
11/05/2021 20:00	0.0	13.8	1,673.4	0.3	0.0	1	1	0
11/05/2021 21:00	0.0	13.8	1,790.6	0.1	0.0	1	1	1
11/05/2021 22:00	1.1	12.8	2,033.4	0.3	3.6	1	1	1
11/05/2021 23:00	0.7	13.0	1,953.8	0.4	2.3	1	1	1
Average/Sum#:	0.4	13.4	1,695.3	0.3	29.2 #	24 #	9 #	11 #
Minimum:	0.0	12.2	1,350.7	0.1	0.0	1	0	0
Maximum:	1.1	13.9	2,107.0	0.6	3.6	1	1	1
%SI	4.17	4.17	0.00	12.50	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/06/2021 00:00	0.0	13.7	1,698.3	0.4	0.0	1	1	1
11/06/2021 01:00	0.1	13.8	1,607.9	0.2	0.3	1	1	0
11/06/2021 02:00	0.9	13.1	1,960.6	0.3	3.0	1	1	1
11/06/2021 03:00	0.8	13.1	1,952.7	0.5	2.6	1	1	1
11/06/2021 04:00	0.0	13.8	1,695.2	0.4	0.0	1	1	1
11/06/2021 05:00	0.0	13.8	1,624.5	0.2	0.0	1	1	1
11/06/2021 06:00	1.1	12.8	2,020.5	0.3	3.6	1	1	1
11/06/2021 07:00	0.6	13.0	1,944.0	0.4	1.9	1	1	1
11/06/2021 08:00	0.0	13.8	1,621.0	0.4	0.0	1	1	0
11/06/2021 09:00	0.0	13.8	1,619.9	0.1	0.0	1	1	0
11/06/2021 10:00	0.0	13.8	1,625.9	0.0	0.0	1	1	0
11/06/2021 11:00	0.0	13.8	1,560.7	0.0	0.0	1	1	0
11/06/2021 12:00	0.0	13.8	1,553.8	0.0	0.0	1	1	0
11/06/2021 13:00	0.0	13.8	1,583.2	0.0	0.0	1	1	0
11/06/2021 14:00	0.1	13.9	1,490.6	0.0	0.3	1	1	0
11/06/2021 15:00	0.1	13.8	1,595.8	0.1	0.3	1	1	0
11/06/2021 16:00	0.8	12.7	2,017.7	0.3	2.6	1	1	1
11/06/2021 17:00	0.7	12.3	2,105.8	0.4	2.3	1	1	1
11/06/2021 18:00	0.6	13.0	1,928.1	0.5	1.9	1	1	1
11/06/2021 19:00	0.0	13.8	1,672.3	0.3	0.0	1	1	0
11/06/2021 20:00	0.1	13.7	1,690.4	0.2	0.3	1	1	1
11/06/2021 21:00	1.2	12.9	1,998.3	0.3	4.0	1	1	1
11/06/2021 22:00	6.6	13.9	1,482.6	0.0	13.5	1	0	1
11/06/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.6	13.5	1,741.3	0.2	36.6 #	23 #	22 #	13 #
Minimum:	0.0	12.3	1,482.6	0.0	0.0	0	0	0
Maximum:	6.6	13.9	2,105.8	0.5	13.5	1	1	1
%SI	4.17	4.17	4.17	8.33	4.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/07/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/08/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	1	0
11/08/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	1	0
11/08/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	1	0
11/08/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	1	0
11/08/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	1	0
11/08/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	1	0
11/08/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	1	0
11/08/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	1	0
11/08/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	8 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	1	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/09/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/09/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/09/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/09/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/09/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/09/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	1	0
11/09/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	1	0
11/09/2021 07:00	68.3	17.5	372.4	0.0	81.0	1	1	0
11/09/2021 08:00	51.6	14.9	1,039.3	0.0	118.0	1	1	0
11/09/2021 09:00	0.0	13.8	1,722.8	0.0	0.0	1	1	0
11/09/2021 10:00	0.1	13.8	1,527.8	0.0	0.3	1	1	0
11/09/2021 11:00	0.1	13.8	1,581.8	0.1	0.3	1	1	0
11/09/2021 12:00	0.1	13.8	1,552.3	0.1	0.3	1	1	0
11/09/2021 13:00	0.0	13.8	1,684.2	0.1	0.0	1	1	0
11/09/2021 14:00	0.0	13.8	1,632.3	0.0	0.0	1	1	0
11/09/2021 15:00	0.2	13.8	1,532.2	0.1	0.6	1	1	0
11/09/2021 16:00	0.1	13.8	1,574.7	0.1	0.3	1	1	0
11/09/2021 17:00	0.8	13.3	1,867.2	0.3	2.6	1	1	1
11/09/2021 18:00	0.8	12.3	2,146.4	0.4	2.6	1	1	1
11/09/2021 19:00	0.7	12.0	2,213.1	0.5	2.3	1	1	1
11/09/2021 20:00	0.6	12.3	2,117.6	0.5	2.0	1	1	1
11/09/2021 21:00	0.0	13.8	1,620.9	0.3	0.0	1	1	0
11/09/2021 22:00	0.0	13.8	1,732.5	0.1	0.0	1	1	0
11/09/2021 23:00	0.9	12.9	2,019.2	0.2	3.0	1	1	1
Average/Sum#:	7.3	13.7	1,643.3	0.2	213.3 #	17 #	19 #	5 #
Minimum:	0.0	12.0	372.4	0.0	0.0	0	0	0
Maximum:	68.3	17.5	2,213.1	0.5	118.0	1	1	1
%SI	29.17	29.17	29.17	45.83	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/10/2021 00:00	0.5	13.3	1,842.8	0.4	1.6	1	1	1
11/10/2021 01:00	0.0	13.6	1,809.3	0.4	0.0	1	1	0
11/10/2021 02:00	0.1	13.8	1,596.6	0.2	0.3	1	1	1
11/10/2021 03:00	1.1	13.1	1,970.3	0.3	3.7	1	1	1
11/10/2021 04:00	0.7	13.2	1,948.6	0.5	2.3	1	1	1
11/10/2021 05:00	0.0	13.8	1,712.8	0.4	0.0	1	1	0
11/10/2021 06:00	0.0	13.8	1,793.0	0.2	0.0	1	1	1
11/10/2021 07:00	1.2	13.0	2,003.3	0.3	4.0	1	1	1
11/10/2021 08:00	0.7	13.2	1,943.5	0.5	2.3	1	1	1
11/10/2021 09:00	0.0	13.9	1,559.3	0.5	0.0	1	1	0
11/10/2021 10:00	0.1	13.9	1,479.9	0.2	0.3	1	1	0
11/10/2021 11:00	0.1	13.9	1,421.3	0.1	0.3	1	1	0
11/10/2021 12:00	0.1	13.9	1,472.0	0.1	0.3	1	1	0
11/10/2021 13:00	0.2	13.9	1,355.1	0.1	0.5	1	1	0
11/10/2021 14:00	0.1	13.9	1,495.5	0.1	0.3	1	1	0
11/10/2021 15:00	0.1	13.8	1,593.9	0.1	0.3	1	1	1
11/10/2021 16:00	0.8	12.8	2,020.5	0.3	2.6	1	1	1
11/10/2021 17:00	0.6	12.7	2,038.8	0.4	2.0	1	1	1
11/10/2021 18:00	0.7	12.5	2,093.5	0.5	2.3	1	1	1
11/10/2021 19:00	0.6	12.5	2,090.4	0.4	2.0	1	1	1
11/10/2021 20:00	0.6	12.8	2,016.0	0.4	2.0	1	1	1
11/10/2021 21:00	0.0	13.8	1,704.2	0.3	0.0	1	1	0
11/10/2021 22:00	0.0	13.8	1,781.7	0.1	0.0	1	1	1
11/10/2021 23:00	0.9	12.8	2,041.3	0.2	3.0	1	1	1
Average/Sum#:	0.4	13.4	1,782.7	0.3	30.1 #	24 #	24 #	15 #
Minimum:	0.0	12.5	1,355.1	0.1	0.0	1	1	0
Maximum:	1.2	13.9	2,093.5	0.5	4.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/11/2021 00:00	0.6	13.0	1,952.5	0.4	2.0	1	1	1
11/11/2021 01:00	21.5	15.8	584.7	0.0	7.5	1	0	0
11/11/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/11/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/11/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/11/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/11/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/11/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/11/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/11/2021 09:00	33.3	18.0	315.5	0.0	20.6	1	0	0
11/11/2021 10:00	95.7	15.6	790.8	0.0	188.6	1	0	0
11/11/2021 11:00	0.2	13.9	1,404.0	0.0	0.5	1	0	0
11/11/2021 12:00	0.2	13.9	1,369.5	0.0	0.5	1	0	0
11/11/2021 13:00	0.0	13.8	1,714.5	0.1	0.0	1	0	0
11/11/2021 14:00	0.1	13.9	1,519.7	0.1	0.3	1	0	0
11/11/2021 15:00	0.0	13.9	1,668.3	0.0	0.0	1	1	0
11/11/2021 16:00	0.5	13.3	1,845.6	0.2	1.6	1	1	1
11/11/2021 17:00	0.6	12.2	2,117.2	0.3	1.9	1	1	1
11/11/2021 18:00	0.6	12.3	2,117.0	0.4	2.0	1	1	1
11/11/2021 19:00	0.7	12.3	2,121.6	0.4	2.3	1	1	1
11/11/2021 20:00	0.7	12.3	2,096.0	0.5	2.3	1	1	1
11/11/2021 21:00	0.1	13.8	1,691.2	0.4	0.3	1	1	0
11/11/2021 22:00	0.0	13.8	1,776.3	0.2	0.0	1	1	1
11/11/2021 23:00	0.7	12.9	2,001.4	0.2	2.3	1	1	1
Average/Sum#:	9.1	13.8	1,593.3	0.3	232.7 #	17 #	10 #	8 #
Minimum:	0.0	12.2	315.5	0.0	0.0	0	0	0
Maximum:	95.7	18.0	2,121.6	0.5	188.6	1	1	1
%SI	29.17	29.17	29.17	50.00	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/12/2021 00:00	0.7	13.1	1,931.6	0.3	2.3	1	1	1
11/12/2021 01:00	0.1	13.8	1,575.3	0.4	0.3	1	1	0
11/12/2021 02:00	0.1	13.8	1,542.3	0.2	0.3	1	1	0
11/12/2021 03:00	0.1	13.8	1,545.6	0.1	0.3	1	1	0
11/12/2021 04:00	0.3	13.8	1,585.9	0.1	0.9	1	1	1
11/12/2021 05:00	0.7	12.6	2,049.3	0.3	2.3	1	1	1
11/12/2021 06:00	0.7	12.6	2,082.5	0.4	2.3	1	1	1
11/12/2021 07:00	0.4	13.5	1,692.3	0.4	1.2	1	1	1
11/12/2021 08:00	0.3	13.9	1,425.3	0.4	0.8	1	0	0
11/12/2021 09:00	0.3	13.9	1,370.0	0.3	0.8	1	0	0
11/12/2021 10:00	0.3	13.9	1,375.6	0.3	0.8	1	0	0
11/12/2021 11:00	0.3	13.9	1,382.6	0.3	0.8	1	0	0
11/12/2021 12:00	0.4	13.9	1,384.5	0.3	1.0	1	0	0
11/12/2021 13:00	0.4	13.9	1,387.1	0.3	1.0	1	0	0
11/12/2021 14:00	0.4	13.9	1,388.9	0.3	1.0	1	0	0
11/12/2021 15:00	0.1	13.8	1,645.1	0.2	0.3	1	0	0
11/12/2021 16:00	0.1	13.8	1,587.3	0.2	0.3	1	0	0
11/12/2021 17:00	0.3	13.9	1,445.7	0.2	0.8	1	1	0
11/12/2021 18:00	0.3	13.8	1,592.6	0.2	0.9	1	1	1
11/12/2021 19:00	0.9	12.7	2,060.1	0.4	3.0	1	1	1
11/12/2021 20:00	0.7	12.9	1,986.3	0.4	2.3	1	1	1
11/12/2021 21:00	0.0	13.8	1,635.0	0.4	0.0	1	1	0
11/12/2021 22:00	0.1	13.8	1,699.8	0.2	0.3	1	1	1
11/12/2021 23:00	0.8	12.8	2,041.9	0.2	2.7	1	1	1
Average/Sum#:	0.4	13.6	1,642.2	0.3	26.7 #	24 #	15 #	10 #
Minimum:	0.0	12.6	1,370.0	0.1	0.0	1	0	0
Maximum:	0.9	13.9	2,082.5	0.4	3.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/13/2021 00:00	10.5	14.4	1,231.8	0.0	12.6	1	0	1
11/13/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/13/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/13/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/13/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/13/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/13/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/13/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/13/2021 08:00	35.7	18.0	317.7	0.0	22.2	1	0	0
11/13/2021 09:00	43.2	15.4	951.3	0.0	98.7	1	0	0
11/13/2021 10:00	0.5	13.9	1,388.0	0.0	1.3	1	0	0
11/13/2021 11:00	0.4	13.9	1,374.3	0.0	1.0	1	0	0
11/13/2021 12:00	0.3	13.9	1,384.4	0.3	0.8	1	0	0
11/13/2021 13:00	0.0	13.8	1,743.1	0.2	0.0	1	0	0
11/13/2021 14:00	0.1	13.9	1,499.1	0.1	0.3	1	0	0
11/13/2021 15:00	0.0	13.9	1,709.3	0.0	0.0	1	1	0
11/13/2021 16:00	0.1	13.7	1,785.0	0.1	0.3	1	1	1
11/13/2021 17:00	0.8	12.6	2,039.4	0.2	2.6	1	1	1
11/13/2021 18:00	0.7	12.7	1,990.3	0.4	2.2	1	1	1
11/13/2021 19:00	0.0	13.8	1,705.5	0.4	0.0	1	1	0
11/13/2021 20:00	0.0	13.8	1,793.6	0.2	0.0	1	1	1
11/13/2021 21:00	1.1	12.8	2,036.0	0.3	3.7	1	1	1
11/13/2021 22:00	9.0	13.7	1,498.3	0.0	18.0	1	0	1
11/13/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	6.4	14.0	1,527.9	0.2	163.7 #	16 #	7 #	7 #
Minimum:	0.0	12.6	317.7	0.0	0.0	0	0	0
Maximum:	43.2	18.0	2,039.4	0.4	98.7	1	1	1
%SI	33.33	33.33	33.33	58.33	33.33	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/14/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 09:00	69.4	18.6	225.9	0.0	19.8	1	0	0
11/14/2021 10:00	36.0	17.2	411.0	0.0	52.8	1	0	0
11/14/2021 11:00	34.7	14.4	1,197.1	0.0	84.4	1	0	0
11/14/2021 12:00	0.6	13.9	1,368.4	0.0	1.5	1	0	0
11/14/2021 13:00	0.5	13.9	1,380.1	0.0	1.3	1	0	0
11/14/2021 14:00	0.2	13.8	1,652.0	0.4	0.6	1	0	0
11/14/2021 15:00	0.1	13.8	1,612.8	0.2	0.3	1	0	0
11/14/2021 16:00	0.5	13.9	1,322.3	0.2	1.2	1	1	0
11/14/2021 17:00	0.3	13.8	1,592.4	0.2	0.9	1	1	1
11/14/2021 18:00	0.9	12.6	2,061.9	0.4	3.0	1	1	1
11/14/2021 19:00	0.8	13.0	1,963.3	0.5	2.6	1	1	1
11/14/2021 20:00	0.2	13.6	1,726.8	0.5	0.6	1	1	1
11/14/2021 21:00	0.2	13.8	1,590.0	0.3	0.6	1	1	1
11/14/2021 22:00	1.2	12.7	2,056.4	0.4	4.0	1	1	1
11/14/2021 23:00	0.5	13.4	1,668.3	0.5	1.5	1	1	1
Average/Sum#:	9.7	14.2	1,455.2	0.4	175.1 #	15 #	8 #	7 #
Minimum:	0.1	12.6	225.9	0.2	0.3	0	0	0
Maximum:	69.4	18.6	2,061.9	0.5	84.4	1	1	1
%SI	37.50	37.50	37.50	58.33	37.50	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/15/2021 00:00	0.5	13.9	1,365.2	0.6	1.3	1	0	0
11/15/2021 01:00	0.4	13.9	1,359.6	0.4	1.0	1	0	0
11/15/2021 02:00	0.4	13.9	1,365.3	0.3	1.0	1	0	0
11/15/2021 03:00	0.4	13.9	1,371.1	0.3	1.0	1	0	0
11/15/2021 04:00	0.4	13.9	1,371.7	0.3	1.0	1	0	0
11/15/2021 05:00	0.3	13.8	1,445.3	0.3	0.8	1	0	0
11/15/2021 06:00	0.2	13.8	1,566.5	0.2	0.6	1	0	0
11/15/2021 07:00	0.1	13.8	1,748.6	0.2	0.3	1	0	0
11/15/2021 08:00	0.2	13.8	1,588.8	0.2	0.6	1	0	0
11/15/2021 09:00	0.4	13.9	1,416.2	0.2	1.1	1	1	0
11/15/2021 10:00	0.3	13.8	1,635.2	0.2	0.9	1	1	1
11/15/2021 11:00	1.0	13.1	1,970.9	0.4	3.3	1	1	1
11/15/2021 12:00	0.9	13.1	1,965.0	0.6	3.0	1	1	1
11/15/2021 13:00	0.5	13.7	1,530.2	0.6	1.4	1	1	1
11/15/2021 14:00	0.2	13.8	1,602.0	0.4	0.6	1	1	0
11/15/2021 15:00	0.8	13.0	1,965.9	0.4	2.6	1	1	1
11/15/2021 16:00	0.7	12.9	2,007.4	0.4	2.3	1	1	1
11/15/2021 17:00	0.8	13.1	1,955.3	0.6	2.6	1	1	1
11/15/2021 18:00	0.8	13.1	1,965.9	0.6	2.7	1	1	1
11/15/2021 19:00	0.7	12.5	2,093.6	0.6	2.3	1	1	1
11/15/2021 20:00	0.9	13.1	1,952.0	0.6	3.0	1	1	1
11/15/2021 21:00	0.9	13.1	1,952.9	0.6	3.0	1	1	1
11/15/2021 22:00	1.0	13.1	1,945.7	0.7	3.3	1	1	1
11/15/2021 23:00	1.0	13.1	1,933.9	0.8	3.3	1	1	1
Average/Sum#:	0.6	13.5	1,711.4	0.4	43.0 #	24 #	15 #	13 #
Minimum:	0.1	12.5	1,359.6	0.2	0.3	1	0	0
Maximum:	1.0	13.9	2,093.6	0.8	3.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/16/2021 00:00	23.2	15.5	671.1	0.0	10.3	1	0	0
11/16/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/16/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/16/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/16/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/16/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/16/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/16/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/16/2021 08:00	39.9	18.0	312.6	0.0	24.4	1	0	0
11/16/2021 09:00	66.5	15.9	752.6	0.0	132.2	1	0	0
11/16/2021 10:00	0.4	13.9	1,384.7	0.0	1.0	1	0	0
11/16/2021 11:00	0.2	13.9	1,378.4	0.0	0.5	1	0	0
11/16/2021 12:00	0.1	13.9	1,382.3	0.2	0.3	1	0	0
11/16/2021 13:00	0.0	13.8	1,541.1	0.1	0.0	1	0	0
11/16/2021 14:00	0.0	13.8	1,742.5	0.0	0.0	1	0	0
11/16/2021 15:00	0.1	13.9	1,497.9	0.0	0.3	1	0	0
11/16/2021 16:00	0.1	13.9	1,509.9	0.1	0.3	1	1	0
11/16/2021 17:00	1.0	13.0	1,962.3	0.3	3.3	1	1	1
11/16/2021 18:00	1.0	12.7	2,057.6	0.5	3.3	1	1	1
11/16/2021 19:00	0.8	13.1	1,969.3	0.7	2.7	1	1	1
11/16/2021 20:00	0.7	12.4	2,132.7	0.6	2.3	1	1	1
11/16/2021 21:00	0.6	12.2	2,173.2	0.5	2.0	1	1	1
11/16/2021 22:00	0.5	12.5	2,099.3	0.4	1.7	1	1	1
11/16/2021 23:00	0.6	12.2	2,168.9	0.4	2.0	1	1	1
Average/Sum#:	8.0	13.8	1,572.7	0.3	186.6 #	17 #	8 #	7 #
Minimum:	0.0	12.2	312.6	0.0	0.0	0	0	0
Maximum:	66.5	18.0	2,173.2	0.7	132.2	1	1	1
%SI	29.17	29.17	29.17	50.00	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/17/2021 00:00	0.5	12.9	2,000.4	0.4	1.7	1	1	1
11/17/2021 01:00	0.6	13.2	1,953.8	0.4	2.0	1	1	1
11/17/2021 02:00	0.6	13.2	1,955.4	0.5	2.0	1	1	1
11/17/2021 03:00	0.7	13.2	1,955.8	0.5	2.3	1	1	1
11/17/2021 04:00	0.7	13.0	2,020.2	0.5	2.4	1	1	1
11/17/2021 05:00	0.7	12.8	2,043.5	0.5	2.3	1	1	1
11/17/2021 06:00	0.7	12.1	2,228.8	0.5	2.3	1	1	1
11/17/2021 07:00	0.6	12.4	2,137.6	0.5	2.0	1	1	1
11/17/2021 08:00	1.0	13.3	1,959.0	0.6	3.4	1	1	1
11/17/2021 09:00	1.0	13.2	1,948.6	0.7	3.3	1	1	1
11/17/2021 10:00	0.2	13.8	1,551.5	0.6	0.6	1	1	0
11/17/2021 11:00	0.7	13.4	1,887.9	0.5	2.3	1	1	1
11/17/2021 12:00	0.9	13.2	1,955.7	0.5	3.0	1	1	1
11/17/2021 13:00	0.4	13.7	1,513.8	0.5	1.1	1	1	1
11/17/2021 14:00	0.2	13.9	1,467.8	0.4	0.6	1	1	0
11/17/2021 15:00	0.7	13.0	1,946.1	0.3	2.3	1	1	1
11/17/2021 16:00	0.7	12.6	2,069.2	0.4	2.3	1	1	1
11/17/2021 17:00	0.6	12.2	2,158.7	0.5	2.0	1	1	1
11/17/2021 18:00	0.6	12.2	2,172.8	0.4	2.0	1	1	1
11/17/2021 19:00	0.6	12.0	2,218.9	0.4	2.0	1	1	1
11/17/2021 20:00	0.5	12.0	2,225.3	0.4	1.7	1	1	1
11/17/2021 21:00	0.6	12.4	2,120.7	0.4	2.0	1	1	1
11/17/2021 22:00	0.7	13.2	1,950.5	0.4	2.3	1	1	1
11/17/2021 23:00	0.7	13.2	1,954.7	0.5	2.3	1	1	1
Average/Sum#:	0.6	12.9	1,974.9	0.5	50.2 #	24 #	24 #	22 #
Minimum:	0.2	12.0	1,467.8	0.3	0.6	1	1	0
Maximum:	1.0	13.9	2,228.8	0.7	3.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/18/2021 00:00	0.8	13.2	1,951.5	0.5	2.7	1	1	1
11/18/2021 01:00	0.8	13.2	1,953.1	0.6	2.7	1	1	1
11/18/2021 02:00	0.8	13.2	1,954.5	0.6	2.7	1	1	1
11/18/2021 03:00	0.8	13.2	1,957.9	0.6	2.7	1	1	1
11/18/2021 04:00	0.8	13.2	1,958.0	0.6	2.7	1	1	1
11/18/2021 05:00	0.8	12.7	2,049.3	0.6	2.6	1	1	1
11/18/2021 06:00	0.7	12.3	2,177.5	0.6	2.3	1	1	1
11/18/2021 07:00	0.6	12.4	2,137.5	0.5	2.0	1	1	1
11/18/2021 08:00	0.6	12.8	2,037.1	0.4	2.0	1	1	1
11/18/2021 09:00	0.8	13.2	1,933.0	0.5	2.7	1	1	1
11/18/2021 10:00	0.1	13.8	1,665.8	0.4	0.3	1	1	1
11/18/2021 11:00	1.0	13.1	1,957.5	0.5	3.3	1	1	1
11/18/2021 12:00	0.7	13.1	1,955.1	0.5	2.3	1	1	1
11/18/2021 13:00	0.4	13.7	1,528.5	0.5	1.1	1	1	1
11/18/2021 14:00	0.2	13.9	1,504.3	0.3	0.6	1	1	0
11/18/2021 15:00	0.4	13.5	1,836.7	0.3	1.3	1	1	1
11/18/2021 16:00	0.8	12.3	2,132.9	0.3	2.6	1	1	1
11/18/2021 17:00	0.7	12.1	2,173.0	0.4	2.3	1	1	1
11/18/2021 18:00	0.6	11.8	2,264.0	0.5	2.0	1	1	1
11/18/2021 19:00	0.6	12.1	2,176.4	0.4	2.0	1	1	1
11/18/2021 20:00	0.6	12.4	2,107.9	0.4	2.0	1	1	1
11/18/2021 21:00	0.7	13.0	1,974.8	0.4	2.3	1	1	1
11/18/2021 22:00	0.8	13.2	1,942.5	0.5	2.7	1	1	1
11/18/2021 23:00	0.8	13.2	1,941.6	0.6	2.7	1	1	1
Average/Sum#:	0.7	12.9	1,969.6	0.5	52.6 #	24 #	24 #	23 #
Minimum:	0.1	11.8	1,504.3	0.3	0.3	1	1	0
Maximum:	1.0	13.9	2,264.0	0.6	3.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/19/2021 00:00	0.9	13.2	1,940.1	0.6	3.0	1	1	1
11/19/2021 01:00	0.9	13.2	1,917.3	0.7	3.0	1	1	1
11/19/2021 02:00	0.1	13.8	1,638.8	0.5	0.3	1	1	0
11/19/2021 03:00	1.2	13.1	1,950.0	0.6	4.0	1	1	1
11/19/2021 04:00	0.7	12.7	2,041.1	0.5	2.3	1	1	1
11/19/2021 05:00	0.7	12.5	2,087.2	0.6	2.3	1	1	1
11/19/2021 06:00	0.7	12.3	2,141.1	0.5	2.3	1	1	1
11/19/2021 07:00	0.7	12.4	2,117.1	0.5	2.3	1	1	1
11/19/2021 08:00	0.7	13.0	1,984.3	0.5	2.3	1	1	1
11/19/2021 09:00	0.8	13.1	1,951.1	0.5	2.6	1	1	1
11/19/2021 10:00	0.8	13.1	1,951.2	0.6	2.6	1	1	1
11/19/2021 11:00	0.7	13.0	1,980.8	0.6	2.3	1	1	1
11/19/2021 12:00	0.7	13.0	1,976.8	0.5	2.3	1	1	1
11/19/2021 13:00	0.7	12.4	2,120.2	0.5	2.3	1	1	1
11/19/2021 14:00	0.6	12.4	2,116.6	0.5	2.0	1	1	1
11/19/2021 15:00	0.6	12.7	2,029.8	0.4	2.0	1	1	1
11/19/2021 16:00	0.6	12.6	2,057.4	0.4	2.0	1	1	1
11/19/2021 17:00	0.6	12.6	2,070.8	0.4	2.0	1	1	1
11/19/2021 18:00	0.6	12.6	2,080.5	0.4	2.0	1	1	1
11/19/2021 19:00	0.7	13.1	1,946.7	0.4	2.3	1	1	1
11/19/2021 20:00	0.0	13.8	1,684.6	0.3	0.0	1	1	0
11/19/2021 21:00	0.0	13.8	1,765.6	0.2	0.0	1	1	1
11/19/2021 22:00	0.7	13.0	1,998.7	0.2	2.3	1	1	1
11/19/2021 23:00	0.6	13.0	1,979.3	0.3	2.0	1	1	1
Average/Sum#:	0.6	12.9	1,980.3	0.5	50.5 #	24 #	24 #	22 #
Minimum:	0.0	12.3	1,638.8	0.2	0.0	1	1	0
Maximum:	1.2	13.8	2,141.1	0.7	4.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/20/2021 00:00	0.7	13.2	1,937.5	0.5	2.3	1	1	1
11/20/2021 01:00	0.0	13.9	1,586.2	0.3	0.0	1	1	0
11/20/2021 02:00	0.0	13.9	1,551.2	0.2	0.0	1	1	0
11/20/2021 03:00	0.0	13.9	1,549.8	0.0	0.0	1	1	0
11/20/2021 04:00	0.1	13.8	1,702.1	0.0	0.3	1	1	1
11/20/2021 05:00	0.7	12.6	2,052.9	0.2	2.3	1	1	1
11/20/2021 06:00	0.6	12.9	2,007.6	0.3	2.0	1	1	1
11/20/2021 07:00	0.0	13.9	1,648.4	0.3	0.0	1	1	0
11/20/2021 08:00	0.0	13.9	1,660.5	0.1	0.0	1	1	0
11/20/2021 09:00	0.1	13.9	1,472.2	0.0	0.3	1	1	0
11/20/2021 10:00	0.0	13.9	1,518.7	0.0	0.0	1	1	0
11/20/2021 11:00	0.0	13.9	1,591.4	0.0	0.0	1	1	0
11/20/2021 12:00	0.0	14.0	1,453.4	0.0	0.0	1	1	0
11/20/2021 13:00	0.0	14.0	1,488.4	0.0	0.0	1	1	0
11/20/2021 14:00	0.0	13.9	1,506.0	0.0	0.0	1	1	0
11/20/2021 15:00	0.1	13.8	1,618.3	0.0	0.3	1	1	1
11/20/2021 16:00	0.7	12.7	2,033.1	0.2	2.3	1	1	1
11/20/2021 17:00	0.6	12.6	2,073.9	0.3	2.0	1	1	1
11/20/2021 18:00	0.5	13.0	1,956.5	0.4	1.6	1	1	1
11/20/2021 19:00	0.0	13.9	1,711.1	0.3	0.0	1	1	0
11/20/2021 20:00	0.0	13.7	1,799.7	0.1	0.0	1	1	0
11/20/2021 21:00	0.8	12.8	2,045.9	0.2	2.7	1	1	1
11/20/2021 22:00	0.6	12.3	2,136.6	0.3	2.0	1	1	1
11/20/2021 23:00	0.3	13.2	1,878.6	0.4	1.0	1	1	1
Average/Sum#:	0.2	13.5	1,749.2	0.2	19.1 #	24 #	24 #	11 #
Minimum:	0.0	12.3	1,453.4	0.0	0.0	1	1	0
Maximum:	0.8	14.0	2,136.6	0.5	2.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/21/2021 00:00	0.0	13.8	1,748.0	0.2	0.0	1	1	1
11/21/2021 01:00	0.7	13.2	1,955.7	0.2	2.3	1	1	1
11/21/2021 02:00	5.1	14.2	1,408.9	0.0	13.5	1	0	1
11/21/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/21/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/21/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/21/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/21/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/21/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/21/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/21/2021 10:00	25.8	18.4	253.9	0.0	9.7	1	0	0
11/21/2021 11:00	35.2	16.1	733.3	0.0	71.0	1	0	0
11/21/2021 12:00	0.0	14.0	1,409.2	0.0	0.0	1	0	0
11/21/2021 13:00	0.0	14.0	1,373.1	0.0	0.0	1	0	0
11/21/2021 14:00	0.0	13.9	1,636.0	0.0	0.0	1	0	0
11/21/2021 15:00	0.0	13.9	1,607.2	0.0	0.0	1	0	0
11/21/2021 16:00	0.1	14.0	1,332.1	0.0	0.3	1	1	0
11/21/2021 17:00	0.0	13.9	1,586.5	0.0	0.0	1	1	1
11/21/2021 18:00	0.8	12.7	2,050.3	0.2	2.6	1	1	1
11/21/2021 19:00	0.6	12.5	2,062.8	0.3	1.9	1	1	1
11/21/2021 20:00	0.0	13.9	1,693.0	0.3	0.0	1	1	0
11/21/2021 21:00	0.0	13.7	1,793.9	0.1	0.0	1	1	0
11/21/2021 22:00	0.9	13.1	1,999.1	0.2	3.0	1	1	1
11/21/2021 23:00	0.4	13.5	1,699.9	0.3	1.2	1	1	1
Average/Sum#:	4.1	14.0	1,549.6	0.2	105.5 #	17 #	10 #	8 #
Minimum:	0.0	12.5	253.9	0.0	0.0	0	0	0
Maximum:	35.2	18.4	2,062.8	0.3	71.0	1	1	1
%SI	29.17	29.17	29.17	50.00	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/22/2021 00:00	0.3	13.9	1,388.2	0.4	0.8	1	0	0
11/22/2021 01:00	0.2	13.9	1,359.8	0.3	0.5	1	0	0
11/22/2021 02:00	0.2	13.9	1,375.9	0.2	0.5	1	0	0
11/22/2021 03:00	0.2	13.9	1,498.2	0.2	0.6	1	0	0
11/22/2021 04:00	0.2	13.9	1,439.4	0.2	0.5	1	0	0
11/22/2021 05:00	0.2	13.9	1,498.7	0.2	0.6	1	0	1
11/22/2021 06:00	1.4	13.2	1,984.3	0.5	4.8	1	0	1
11/22/2021 07:00	0.8	13.0	2,002.3	0.6	2.7	1	0	1
11/22/2021 08:00	0.3	13.9	1,464.6	0.7	0.8	1	0	0
11/22/2021 09:00	0.3	13.9	1,395.8	0.4	0.8	1	0	0
11/22/2021 10:00	0.2	13.9	1,377.3	0.3	0.5	1	0	0
11/22/2021 11:00	0.2	13.9	1,383.5	0.2	0.5	1	0	0
11/22/2021 12:00	0.0	13.8	1,736.8	0.1	0.0	1	0	0
11/22/2021 13:00	0.0	13.9	1,519.6	0.1	0.0	1	0	0
11/22/2021 14:00	0.0	13.9	1,706.3	0.0	0.0	1	1	0
11/22/2021 15:00	0.0	13.9	1,746.7	0.0	0.0	1	1	0
11/22/2021 16:00	0.5	13.0	1,957.7	0.1	1.6	1	1	1
11/22/2021 17:00	0.7	12.6	2,071.8	0.3	2.3	1	1	1
11/22/2021 18:00	0.6	12.0	2,184.5	0.4	1.9	1	1	1
11/22/2021 19:00	0.6	12.1	2,169.6	0.4	2.0	1	1	1
11/22/2021 20:00	0.5	12.2	2,130.1	0.4	1.6	1	1	1
11/22/2021 21:00	0.0	13.8	1,646.2	0.2	0.0	1	1	0
11/22/2021 22:00	0.0	13.8	1,815.4	0.1	0.0	1	1	1
11/22/2021 23:00	0.8	12.8	2,045.2	0.2	2.7	1	1	1
Average/Sum#:	0.3	13.5	1,704.1	0.3	25.7 #	24 #	10 #	10 #
Minimum:	0.0	12.0	1,359.8	0.0	0.0	1	0	0
Maximum:	1.4	13.9	2,184.5	0.7	4.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/23/2021 00:00	0.7	13.1	1,950.0	0.4	2.3	1	1	1
11/23/2021 01:00	0.2	13.9	1,505.4	0.4	0.6	1	1	0
11/23/2021 02:00	0.1	13.8	1,714.3	0.3	0.3	1	1	1
11/23/2021 03:00	1.7	13.2	1,965.3	0.5	5.7	1	1	1
11/23/2021 04:00	0.7	13.2	1,937.8	0.6	2.3	1	1	1
11/23/2021 05:00	0.0	13.8	1,689.2	0.6	0.0	1	1	0
11/23/2021 06:00	0.1	13.8	1,632.8	0.2	0.3	1	1	0
11/23/2021 07:00	1.1	13.0	2,003.7	0.3	3.7	1	1	1
11/23/2021 08:00	0.6	12.9	1,995.3	0.4	2.0	1	1	1
11/23/2021 09:00	0.0	13.8	1,629.9	0.4	0.0	1	1	0
11/23/2021 10:00	0.0	13.8	1,573.2	0.1	0.0	1	1	0
11/23/2021 11:00	0.0	13.9	1,509.4	0.0	0.0	1	1	0
11/23/2021 12:00	0.1	13.9	1,395.1	0.0	0.3	1	1	0
11/23/2021 13:00	0.0	13.9	1,565.8	0.0	0.0	1	1	0
11/23/2021 14:00	0.0	13.9	1,667.1	0.0	0.0	1	1	0
11/23/2021 15:00	0.2	13.8	1,624.2	0.1	0.6	1	1	1
11/23/2021 16:00	0.7	12.7	2,056.8	0.2	2.3	1	1	1
11/23/2021 17:00	0.7	12.6	2,079.4	0.4	2.3	1	1	1
11/23/2021 18:00	0.6	12.6	2,086.0	0.5	2.0	1	1	1
11/23/2021 19:00	0.6	13.1	1,949.4	0.5	2.0	1	1	1
11/23/2021 20:00	0.0	13.9	1,709.1	0.3	0.0	1	1	0
11/23/2021 21:00	0.1	13.9	1,579.6	0.2	0.3	1	1	1
11/23/2021 22:00	0.7	12.8	2,056.5	0.2	2.3	1	1	1
11/23/2021 23:00	0.6	13.1	1,965.6	0.4	2.0	1	1	1
Average/Sum#:	0.4	13.4	1,785.0	0.3	31.3 #	24 #	24 #	14 #
Minimum:	0.0	12.6	1,395.1	0.0	0.0	1	1	0
Maximum:	1.7	13.9	2,086.0	0.6	5.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/24/2021 00:00	0.7	13.2	1,944.3	0.5	2.3	1	1	1
11/24/2021 01:00	0.1	13.9	1,515.5	0.4	0.3	1	1	0
11/24/2021 02:00	0.2	13.8	1,609.8	0.3	0.6	1	1	1
11/24/2021 03:00	1.2	13.2	1,968.4	0.4	4.1	1	1	1
11/24/2021 04:00	0.7	13.1	1,967.3	0.5	2.3	1	1	1
11/24/2021 05:00	0.0	13.9	1,680.8	0.5	0.0	1	1	0
11/24/2021 06:00	0.3	13.8	1,609.5	0.2	0.9	1	1	1
11/24/2021 07:00	0.6	13.0	2,002.5	0.2	2.0	1	1	1
11/24/2021 08:00	0.6	13.1	1,955.1	0.4	2.0	1	1	1
11/24/2021 09:00	0.0	13.9	1,665.4	0.3	0.0	1	1	0
11/24/2021 10:00	0.0	13.9	1,629.1	0.2	0.0	1	1	0
11/24/2021 11:00	0.0	13.9	1,695.9	0.0	0.0	1	1	0
11/24/2021 12:00	0.0	13.9	1,611.6	0.0	0.0	1	1	0
11/24/2021 13:00	0.0	13.9	1,641.9	0.0	0.0	1	1	0
11/24/2021 14:00	0.0	13.9	1,622.1	0.0	0.0	1	1	0
11/24/2021 15:00	0.0	13.8	1,690.0	0.0	0.0	1	1	1
11/24/2021 16:00	0.7	12.9	2,010.3	0.2	2.3	1	1	1
11/24/2021 17:00	0.7	12.7	2,053.3	0.3	2.3	1	1	1
11/24/2021 18:00	0.6	12.6	2,071.3	0.5	2.0	1	1	1
11/24/2021 19:00	0.6	12.7	2,023.1	0.4	2.0	1	1	1
11/24/2021 20:00	0.0	13.9	1,607.9	0.3	0.0	1	1	0
11/24/2021 21:00	0.0	13.8	1,754.6	0.1	0.0	1	1	1
11/24/2021 22:00	0.6	13.0	1,985.5	0.1	2.0	1	1	1
11/24/2021 23:00	0.6	13.2	1,920.1	0.3	2.0	1	1	1
Average/Sum#:	0.3	13.5	1,801.5	0.3	27.1 #	24 #	24 #	15 #
Minimum:	0.0	12.6	1,515.5	0.0	0.0	1	1	0
Maximum:	1.2	13.9	2,071.3	0.5	4.1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/25/2021 00:00	18.5	15.8	577.1	0.0	6.3	1	0	0
11/25/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	18.5	15.8	577.1	0.0	6.3 #	1 #	0 #	0 #
Minimum:	18.5	15.8	577.1	0.0	6.3	0	0	0
Maximum:	18.5	15.8	577.1	0.0	6.3	1	0	0
%SI	95.83	95.83	95.83	100.00	95.83	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/26/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/27/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/28/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/29/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/29/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/29/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/29/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/29/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/29/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/29/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/29/2021 07:00	116.8	19.1	132.4	0.0	20.4	1	0	0
11/29/2021 08:00	41.8	17.2	373.8	0.0	55.8	1	0	0
11/29/2021 09:00	18.7	17.3	386.4	0.0	26.5	1	0	0
11/29/2021 10:00	62.1	16.7	571.3	0.0	111.6	1	0	0
11/29/2021 11:00	57.7	15.3	934.5	0.0	127.2	1	0	0
11/29/2021 12:00	0.0	13.9	1,369.2	0.0	0.0	1	0	0
11/29/2021 13:00	0.0	13.9	1,363.4	0.0	0.0	1	0	0
11/29/2021 14:00	0.0	13.8	1,623.3	0.0	0.0	1	0	0
11/29/2021 15:00	0.0	13.8	1,587.4	0.0	0.0	1	0	0
11/29/2021 16:00	0.0	13.7	1,703.6	0.0	0.0	1	1	0
11/29/2021 17:00	0.6	12.7	1,956.3	0.1	1.9	1	1	1
11/29/2021 18:00	0.7	12.2	2,108.8	0.3	2.2	1	1	1
11/29/2021 19:00	0.8	12.5	2,044.0	0.5	2.6	1	1	1
11/29/2021 20:00	0.1	13.8	1,663.4	0.4	0.3	1	1	1
11/29/2021 21:00	0.1	13.7	1,792.3	0.3	0.3	1	1	1
11/29/2021 22:00	0.7	12.9	1,987.5	0.2	2.3	1	1	1
11/29/2021 23:00	12.2	14.3	1,216.7	0.0	14.0	1	0	1
Average/Sum#:	18.4	14.5	1,342.0	0.2	365.1 #	17 #	7 #	7 #
Minimum:	0.0	12.2	132.4	0.0	0.0	0	0	0
Maximum:	116.8	19.1	2,108.8	0.5	127.2	1	1	1
%SI	29.17	29.17	29.17	62.50	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
11/30/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/30/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/30/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/30/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/30/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/30/2021 05:00	21.3	18.3	259.4	0.0	7.9	1	0	0
11/30/2021 06:00	29.7	16.1	731.3	0.0	59.8	1	0	0
11/30/2021 07:00	0.3	13.9	1,335.2	0.0	0.8	1	0	0
11/30/2021 08:00	0.3	13.9	1,308.0	0.0	0.7	1	0	0
11/30/2021 09:00	0.3	13.9	1,307.4	0.3	0.7	1	0	0
11/30/2021 10:00	0.4	13.9	1,239.1	0.3	0.9	1	1	0
11/30/2021 11:00	0.3	13.9	1,236.7	0.3	0.7	1	1	0
11/30/2021 12:00	0.1	13.9	1,402.9	0.2	0.3	1	1	0
11/30/2021 13:00	0.0	13.9	1,474.7	0.1	0.0	1	1	0
11/30/2021 14:00	0.0	13.9	1,602.8	0.0	0.0	1	1	0
11/30/2021 15:00	0.0	13.9	1,745.5	0.0	0.0	1	1	0
11/30/2021 16:00	0.0	13.9	1,745.1	0.0	0.0	1	1	0
11/30/2021 17:00	0.0	13.9	1,744.5	0.0	0.0	1	1	0
11/30/2021 18:00	0.0	13.9	1,743.7	0.0	0.0	1	1	0
11/30/2021 19:00	0.0	13.9	1,736.0	0.0	0.0	1	1	0
11/30/2021 20:00	0.0	13.9	1,724.4	0.0	0.0	1	1	0
11/30/2021 21:00	0.0	13.9	1,727.3	0.0	0.0	1	1	0
11/30/2021 22:00	0.0	13.9	1,742.6	0.0	0.0	1	1	0
11/30/2021 23:00	0.3	13.1	1,951.3	0.1	1.0	1	1	1
Average/Sum#:	2.8	14.2	1,460.9	0.1	72.8 #	19 #	14 #	1 #
Minimum:	0.0	13.1	259.4	0.0	0.0	0	0	0
Maximum:	29.7	18.3	1,951.3	0.3	59.8	1	1	1
%SI	20.83	20.83	20.83	37.50	20.83	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/01/2021 00:00	0.3	13.1	1,953.1	0.1	1.0	1	1	1
12/01/2021 01:00	0.1	13.8	1,511.9	0.2	0.3	1	1	1
12/01/2021 02:00	0.3	13.9	1,312.6	0.2	0.7	1	1	0
12/01/2021 03:00	0.1	13.8	1,721.4	0.2	0.3	1	1	0
12/01/2021 04:00	0.4	13.5	1,846.0	0.2	1.3	1	1	1
12/01/2021 05:00	0.4	13.3	1,855.6	0.2	1.3	1	1	1
12/01/2021 06:00	0.4	13.5	1,705.5	0.3	1.2	1	1	1
12/01/2021 07:00	0.8	12.0	2,228.2	0.4	2.6	1	1	1
12/01/2021 08:00	0.5	11.8	2,250.2	0.4	1.6	1	1	1
12/01/2021 09:00	0.6	11.9	2,237.8	0.4	2.0	1	1	1
12/01/2021 10:00	0.5	11.7	2,248.5	0.3	1.6	1	1	1
12/01/2021 11:00	0.8	11.6	2,257.4	0.4	2.6	1	1	1
12/01/2021 12:00	0.8	11.5	2,278.4	0.4	2.6	1	1	1
12/01/2021 13:00	0.8	11.5	2,274.0	0.5	2.6	1	1	1
12/01/2021 14:00	0.8	11.5	2,277.2	0.5	2.6	1	1	1
12/01/2021 15:00	0.8	11.5	2,264.4	0.5	2.5	1	1	1
12/01/2021 16:00	0.8	11.5	2,266.3	0.5	2.5	1	1	1
12/01/2021 17:00	0.8	11.5	2,269.2	0.5	2.6	1	1	1
12/01/2021 18:00	0.8	11.5	2,270.4	0.5	2.6	1	1	1
12/01/2021 19:00	0.8	11.6	2,257.4	0.5	2.6	1	1	1
12/01/2021 20:00	1.1	12.2	2,151.0	0.6	3.6	1	1	1
12/01/2021 21:00	1.0	12.3	2,116.7	0.6	3.3	1	1	1
12/01/2021 22:00	1.0	12.6	2,064.1	0.7	3.3	1	1	1
12/01/2021 23:00	1.0	13.1	1,941.5	0.7	3.3	1	1	1
Average/Sum#:	0.7	12.3	2,065.0	0.4	50.6 #	24 #	24 #	22 #
Minimum:	0.1	11.5	1,312.6	0.1	0.3	1	1	0
Maximum:	1.1	13.9	2,278.4	0.7	3.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/02/2021 00:00	11.4	14.5	1,197.3	0.0	14.1	1	0	1
12/02/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	1	0
12/02/2021 06:00	41.5	17.5	413.3	0.0	44.6	1	1	0
12/02/2021 07:00	26.3	14.3	1,176.4	0.0	61.9	1	1	0
12/02/2021 08:00	0.6	13.9	1,353.2	0.0	1.5	1	1	0
12/02/2021 09:00	0.6	13.9	1,386.4	0.0	1.6	1	1	0
12/02/2021 10:00	0.6	13.8	1,516.9	0.5	1.7	1	1	0
12/02/2021 11:00	0.5	13.9	1,580.5	0.5	1.5	1	1	0
12/02/2021 12:00	0.5	13.7	1,697.6	0.4	1.6	1	1	0
12/02/2021 13:00	0.5	13.6	1,797.2	0.4	1.6	1	1	0
12/02/2021 14:00	0.5	0.0	1,792.4	0.0	0.6	1	1	0
12/02/2021 15:00	0.5	13.7	1,787.0	0.0	1.6	1	1	0
12/02/2021 16:00	0.5	13.6	1,789.1	0.0	1.6	1	1	0
12/02/2021 17:00	0.5	13.6	1,788.2	0.4	1.6	1	1	0
12/02/2021 18:00	0.5	13.6	1,786.4	0.4	1.6	1	1	0
12/02/2021 19:00	0.5	13.6	1,787.4	0.4	1.6	1	1	0
12/02/2021 20:00	0.5	13.7	1,776.1	0.4	1.6	1	1	0
12/02/2021 21:00	1.2	13.1	1,925.5	0.6	3.9	1	1	1
12/02/2021 22:00	1.2	12.6	2,031.9	0.7	3.9	1	1	1
12/02/2021 23:00	0.9	13.2	1,890.4	0.8	2.9	1	1	1
Average/Sum#:	4.7	13.9	1,603.9	0.5	150.4 #	19 #	19 #	4 #
Minimum:	0.5	12.6	413.3	0.4	1.5	0	0	0
Maximum:	41.5	17.5	2,031.9	0.8	61.9	1	1	1
%SI	20.83	25.00	20.83	54.17	25.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/03/2021 00:00	0.6	13.9	1,352.5	0.7	1.5	1	0	0
12/03/2021 01:00	0.6	13.9	1,349.1	0.6	1.5	1	0	0
12/03/2021 02:00	0.7	13.9	1,359.2	0.5	1.8	1	0	0
12/03/2021 03:00	0.7	13.8	1,637.6	0.6	2.1	1	0	0
12/03/2021 04:00	0.7	13.8	1,622.4	0.6	2.1	1	0	0
12/03/2021 05:00	0.7	13.9	1,424.8	0.6	1.9	1	1	0
12/03/2021 06:00	0.6	13.8	1,634.2	0.6	1.8	1	1	0
12/03/2021 07:00	0.5	13.8	1,892.2	0.5	1.8	1	1	1
12/03/2021 08:00	1.2	11.9	2,218.9	0.6	3.9	1	1	1
12/03/2021 09:00	1.1	11.9	2,236.2	0.6	3.6	1	1	1
12/03/2021 10:00	1.0	11.8	2,247.0	0.7	3.3	1	1	1
12/03/2021 11:00	1.0	11.7	2,250.2	0.6	3.2	1	1	1
12/03/2021 12:00	1.0	11.7	2,250.8	0.6	3.2	1	1	1
12/03/2021 13:00	1.0	11.7	2,257.2	0.6	3.2	1	1	1
12/03/2021 14:00	1.0	11.7	2,256.8	0.6	3.2	1	1	1
12/03/2021 15:00	1.0	11.6	2,251.8	0.6	3.2	1	1	1
12/03/2021 16:00	0.9	12.8	1,925.7	0.6	2.8	1	1	1
12/03/2021 17:00	0.5	13.5	1,818.3	0.6	1.6	1	1	0
12/03/2021 18:00	0.5	13.6	1,817.4	0.5	1.6	1	1	0
12/03/2021 19:00	0.5	13.6	1,820.6	0.4	1.6	1	1	1
12/03/2021 20:00	1.3	12.8	1,993.5	0.6	4.2	1	1	1
12/03/2021 21:00	1.2	12.3	2,117.7	0.7	3.9	1	1	1
12/03/2021 22:00	1.2	12.4	2,113.3	0.8	3.9	1	1	1
12/03/2021 23:00	6.6	13.6	1,606.5	0.0	19.2	1	0	1
Average/Sum#:	1.1	12.9	1,893.9	0.6	80.1 #	24 #	18 #	15 #
Minimum:	0.5	11.6	1,349.1	0.4	1.5	1	0	0
Maximum:	6.6	13.9	2,257.2	0.8	19.2	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/04/2021 00:00	17.1	19.4	0.2	0.0	0.0	1	0	0
12/04/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2021 03:00	10.0	18.7	198.1	0.0	2.1	1	0	0
12/04/2021 04:00	31.9	15.6	853.7	0.0	67.9	1	0	0
12/04/2021 05:00	0.6	13.7	1,609.8	0.0	1.8	1	0	0
12/04/2021 06:00	1.2	13.2	1,826.8	0.0	3.8	1	0	1
12/04/2021 07:00	0.8	13.0	1,878.9	0.7	2.5	1	0	1
12/04/2021 08:00	0.5	13.5	1,861.7	0.6	1.7	1	1	0
12/04/2021 09:00	0.5	13.5	1,859.1	0.5	1.7	1	1	0
12/04/2021 10:00	0.5	13.8	1,800.3	0.4	1.7	1	1	0
12/04/2021 11:00	0.5	13.8	1,802.6	0.4	1.7	1	1	0
12/04/2021 12:00	0.6	13.8	1,647.7	0.4	1.8	1	0	0
12/04/2021 13:00	0.6	13.8	1,477.2	0.5	1.6	1	0	0
12/04/2021 14:00	0.7	13.9	1,371.9	0.5	1.8	1	0	0
12/04/2021 15:00	0.6	13.7	1,645.5	0.5	1.8	1	0	0
12/04/2021 16:00	0.6	13.8	1,577.4	0.5	1.8	1	0	0
12/04/2021 17:00	0.6	13.8	1,723.5	0.5	1.9	1	1	0
12/04/2021 18:00	1.7	13.2	1,928.9	0.8	5.6	1	1	1
12/04/2021 19:00	1.1	13.3	1,852.4	0.9	3.5	1	1	1
12/04/2021 20:00	0.5	13.8	1,634.1	0.9	1.5	1	1	0
12/04/2021 21:00	0.5	13.8	1,623.1	0.6	1.5	1	1	0
12/04/2021 22:00	0.6	13.8	1,603.5	0.4	1.8	1	1	0
12/04/2021 23:00	38.3	16.1	424.5	0.0	8.0	1	0	0
Average/Sum#:	5.0	14.3	1,463.7	0.6	117.5 #	22 #	10 #	4 #
Minimum:	0.5	13.0	0.2	0.4	0.0	0	0	0
Maximum:	38.3	19.4	1,928.9	0.9	67.9	1	1	1
%SI	8.33	8.33	8.33	33.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/05/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2021 07:00	32.1	17.6	360.0	0.0	33.3	1	0	0
12/05/2021 08:00	84.3	15.4	865.3	0.0	175.2	1	0	0
12/05/2021 09:00	0.8	13.8	1,564.6	0.0	2.3	1	0	0
12/05/2021 10:00	0.8	13.8	1,545.5	0.0	2.3	1	0	0
12/05/2021 11:00	0.8	13.8	1,383.1	0.7	2.1	1	0	0
12/05/2021 12:00	0.8	13.8	1,372.4	0.7	2.0	1	0	0
12/05/2021 13:00	0.6	13.7	1,746.1	0.6	1.9	1	0	0
12/05/2021 14:00	0.6	13.8	1,535.4	0.6	1.7	1	0	0
12/05/2021 15:00	0.5	13.8	1,682.4	0.5	1.6	1	1	0
12/05/2021 16:00	0.6	13.8	1,614.5	0.5	1.8	1	1	1
12/05/2021 17:00	1.2	12.9	1,990.9	0.6	3.9	1	1	1
12/05/2021 18:00	1.3	12.4	2,125.6	0.8	4.3	1	1	1
12/05/2021 19:00	1.2	12.2	2,150.2	0.9	3.9	1	1	1
12/05/2021 20:00	1.1	11.9	2,244.0	0.8	3.6	1	1	1
12/05/2021 21:00	1.1	12.1	2,188.7	0.7	3.6	1	1	1
12/05/2021 22:00	1.2	12.1	2,183.1	0.7	3.9	1	1	1
12/05/2021 23:00	1.1	12.5	2,100.5	0.8	3.6	1	1	1
Average/Sum#:	7.7	13.5	1,685.4	0.7	251.0 #	17 #	9 #	8 #
Minimum:	0.5	11.9	360.0	0.5	1.6	0	0	0
Maximum:	84.3	17.6	2,244.0	0.9	175.2	1	1	1
%SI	29.17	29.17	29.17	45.83	29.17	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/06/2021 00:00	1.1	12.9	1,993.5	0.8	3.6	1	1	1
12/06/2021 01:00	0.5	13.8	1,715.2	0.7	1.6	1	1	0
12/06/2021 02:00	0.6	13.7	1,766.3	0.6	1.9	1	1	1
12/06/2021 03:00	1.4	13.1	1,982.0	0.7	4.7	1	1	1
12/06/2021 04:00	1.2	13.0	1,965.8	0.8	3.9	1	1	1
12/06/2021 05:00	0.6	13.8	1,650.8	0.8	1.8	1	1	0
12/06/2021 06:00	1.1	13.2	1,898.0	0.7	3.6	1	1	1
12/06/2021 07:00	1.2	12.2	2,191.1	0.7	4.0	1	1	1
12/06/2021 08:00	1.2	12.1	2,192.7	0.8	3.9	1	1	1
12/06/2021 09:00	0.8	13.5	1,737.7	0.7	2.5	1	1	1
12/06/2021 10:00	0.5	13.8	1,795.1	0.6	1.7	1	1	0
12/06/2021 11:00	1.2	12.9	2,018.7	0.6	4.0	1	1	1
12/06/2021 12:00	1.2	12.1	2,201.3	0.7	4.0	1	1	1
12/06/2021 13:00	1.0	12.8	1,934.7	0.8	3.2	1	1	1
12/06/2021 14:00	0.5	13.8	1,651.5	0.6	1.5	1	1	0
12/06/2021 15:00	1.2	13.4	1,850.3	0.7	3.9	1	1	1
12/06/2021 16:00	1.2	12.6	2,090.0	0.7	4.0	1	1	1
12/06/2021 17:00	1.2	12.4	2,130.7	0.9	4.0	1	1	1
12/06/2021 18:00	1.2	11.9	2,230.7	0.8	3.9	1	1	1
12/06/2021 19:00	1.2	12.1	2,182.1	0.8	3.9	1	1	1
12/06/2021 20:00	1.1	12.0	2,211.0	0.8	3.6	1	1	1
12/06/2021 21:00	1.2	12.3	2,135.6	0.8	3.9	1	1	1
12/06/2021 22:00	1.2	12.3	2,132.6	0.8	3.9	1	1	1
12/06/2021 23:00	1.2	12.3	2,137.3	0.8	3.9	1	1	1
Average/Sum#:	1.0	12.8	1,991.4	0.7	80.9 #	24 #	24 #	20 #
Minimum:	0.5	11.9	1,650.8	0.6	1.5	1	1	0
Maximum:	1.4	13.8	2,230.7	0.9	4.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/07/2021 00:00	1.1	12.5	2,090.9	0.8	3.6	1	1	1
12/07/2021 01:00	0.6	13.7	1,537.4	0.7	1.7	1	1	1
12/07/2021 02:00	0.6	13.7	1,699.9	0.6	1.9	1	1	1
12/07/2021 03:00	0.8	13.1	1,962.6	0.5	2.7	1	1	1
12/07/2021 04:00	1.2	12.4	2,121.0	0.6	4.0	1	1	1
12/07/2021 05:00	0.5	13.8	1,730.5	0.6	1.6	1	1	1
12/07/2021 06:00	0.6	13.8	1,653.3	0.6	1.8	1	1	0
12/07/2021 07:00	1.3	13.0	1,981.9	0.6	4.3	1	1	1
12/07/2021 08:00	1.2	12.0	2,214.4	0.8	3.9	1	1	1
12/07/2021 09:00	1.1	12.3	2,109.3	0.9	3.6	1	1	1
12/07/2021 10:00	0.5	13.6	1,821.3	0.7	1.6	1	1	0
12/07/2021 11:00	0.5	13.7	1,800.1	0.5	1.7	1	1	0
12/07/2021 12:00	0.5	13.6	1,812.2	0.4	1.6	1	1	0
12/07/2021 13:00	0.6	13.6	1,793.7	0.4	1.9	1	1	1
12/07/2021 14:00	1.2	12.4	2,078.9	0.6	3.9	1	1	1
12/07/2021 15:00	1.0	11.7	2,214.0	0.6	3.2	1	1	1
12/07/2021 16:00	0.9	11.6	2,246.9	0.7	2.9	1	1	1
12/07/2021 17:00	1.0	11.8	2,229.1	0.6	3.2	1	1	1
12/07/2021 18:00	1.0	11.8	2,240.7	0.6	3.3	1	1	1
12/07/2021 19:00	1.1	11.9	2,222.9	0.6	3.6	1	1	1
12/07/2021 20:00	1.0	11.9	2,220.2	0.7	3.3	1	1	1
12/07/2021 21:00	1.0	11.9	2,209.8	0.7	3.2	1	1	1
12/07/2021 22:00	1.1	12.2	2,138.8	0.7	3.6	1	1	1
12/07/2021 23:00	1.1	12.3	2,130.7	0.7	3.6	1	1	1
Average/Sum#:	0.9	12.7	2,010.9	0.6	69.7 #	24 #	24 #	20 #
Minimum:	0.5	11.6	1,537.4	0.4	1.6	1	1	0
Maximum:	1.3	13.8	2,246.9	0.9	4.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/08/2021 00:00	1.1	12.5	2,058.6	0.8	3.6	1	1	1
12/08/2021 01:00	0.5	13.8	1,613.9	0.7	1.5	1	1	0
12/08/2021 02:00	0.9	13.8	1,324.6	0.6	2.2	1	1	0
12/08/2021 03:00	0.5	13.7	1,745.4	0.5	1.6	1	1	0
12/08/2021 04:00	1.0	13.4	1,840.6	0.6	3.2	1	1	1
12/08/2021 05:00	0.9	13.3	1,889.0	0.6	3.0	1	1	1
12/08/2021 06:00	0.5	13.7	1,771.3	0.6	1.6	1	1	1
12/08/2021 07:00	1.6	12.9	2,003.1	0.8	5.3	1	1	1
12/08/2021 08:00	1.0	13.1	1,873.7	0.8	3.2	1	1	1
12/08/2021 09:00	0.9	13.8	1,375.8	0.9	2.3	1	1	0
12/08/2021 10:00	0.9	13.8	1,342.7	0.7	2.2	1	1	0
12/08/2021 11:00	0.5	13.7	1,731.0	0.6	1.6	1	1	0
12/08/2021 12:00	1.1	13.3	1,863.0	0.7	3.6	1	1	1
12/08/2021 13:00	1.1	13.3	1,849.3	0.7	3.5	1	1	1
12/08/2021 14:00	0.8	13.8	1,328.4	0.8	2.0	1	1	0
12/08/2021 15:00	0.8	13.8	1,396.1	0.8	2.1	1	1	0
12/08/2021 16:00	0.6	13.7	1,721.3	0.6	1.9	1	1	0
12/08/2021 17:00	1.7	13.0	1,981.0	0.8	5.6	1	1	1
12/08/2021 18:00	1.3	12.2	2,152.7	0.9	4.2	1	1	1
12/08/2021 19:00	1.3	12.2	2,143.1	1.0	4.2	1	1	1
12/08/2021 20:00	1.2	12.2	2,131.3	0.9	3.9	1	1	1
12/08/2021 21:00	1.2	12.5	2,070.2	0.8	3.9	1	1	1
12/08/2021 22:00	1.1	12.6	2,051.4	0.8	3.6	1	1	1
12/08/2021 23:00	1.2	12.5	2,076.9	0.8	3.9	1	1	1
Average/Sum#:	1.0	13.2	1,805.6	0.7	73.7 #	24 #	24 #	15 #
Minimum:	0.5	12.2	1,324.6	0.5	1.5	1	1	0
Maximum:	1.7	13.8	2,152.7	1.0	5.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/09/2021 00:00	1.2	13.0	1,944.8	0.8	3.9	1	1	1
12/09/2021 01:00	0.7	13.8	1,500.7	0.8	2.0	1	1	0
12/09/2021 02:00	0.8	13.7	1,584.5	0.7	2.3	1	1	1
12/09/2021 03:00	1.3	13.0	1,967.9	0.8	4.3	1	1	1
12/09/2021 04:00	1.2	12.8	1,999.0	0.9	3.9	1	1	1
12/09/2021 05:00	0.7	13.8	1,553.7	0.8	2.0	1	1	0
12/09/2021 06:00	0.7	13.7	1,639.6	0.7	2.1	1	1	1
12/09/2021 07:00	0.9	13.0	1,998.5	0.6	3.0	1	1	1
12/09/2021 08:00	0.9	12.7	2,055.2	0.6	3.0	1	1	1
12/09/2021 09:00	0.8	12.7	2,040.3	0.6	2.6	1	1	1
12/09/2021 10:00	0.5	13.7	1,610.1	0.5	1.5	1	1	1
12/09/2021 11:00	0.5	13.8	1,715.0	0.5	1.6	1	1	1
12/09/2021 12:00	1.1	12.8	2,026.3	0.5	3.6	1	1	1
12/09/2021 13:00	1.0	12.8	1,990.8	0.6	3.2	1	1	1
12/09/2021 14:00	0.5	13.9	1,455.5	0.6	1.4	1	1	0
12/09/2021 15:00	0.5	13.8	1,513.7	0.5	1.4	1	1	1
12/09/2021 16:00	1.1	12.9	2,001.4	0.5	3.6	1	1	1
12/09/2021 17:00	1.2	12.3	2,149.9	0.7	4.0	1	1	1
12/09/2021 18:00	1.1	12.4	2,124.3	0.8	3.6	1	1	1
12/09/2021 19:00	1.1	12.3	2,154.1	0.8	3.6	1	1	1
12/09/2021 20:00	1.1	12.3	2,165.9	0.8	3.7	1	1	1
12/09/2021 21:00	1.1	12.3	2,169.5	0.8	3.7	1	1	1
12/09/2021 22:00	1.1	12.9	2,034.6	0.8	3.7	1	1	1
12/09/2021 23:00	1.0	12.7	2,071.8	0.8	3.3	1	1	1
Average/Sum#:	0.9	13.0	1,894.5	0.7	71.0 #	24 #	24 #	21 #
Minimum:	0.5	12.3	1,455.5	0.5	1.4	1	1	0
Maximum:	1.3	13.9	2,169.5	0.9	4.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/10/2021 00:00	1.1	13.1	1,960.1	0.8	3.7	1	1	1
12/10/2021 01:00	0.6	13.9	1,544.3	0.7	1.7	1	1	0
12/10/2021 02:00	0.6	13.8	1,612.1	0.6	1.8	1	1	0
12/10/2021 03:00	0.7	13.3	1,936.6	0.5	2.4	1	1	1
12/10/2021 04:00	0.8	13.3	1,958.8	0.5	2.7	1	1	1
12/10/2021 05:00	0.6	13.8	1,626.8	0.5	1.8	1	1	0
12/10/2021 06:00	0.6	13.8	1,756.9	0.5	2.0	1	1	1
12/10/2021 07:00	1.4	13.1	1,992.1	0.7	4.7	1	1	1
12/10/2021 08:00	1.2	13.2	1,961.8	0.8	4.0	1	1	1
12/10/2021 09:00	0.5	13.8	1,619.4	0.8	1.5	1	1	0
12/10/2021 10:00	0.5	13.8	1,704.7	0.6	1.6	1	1	0
12/10/2021 11:00	0.5	13.8	1,633.7	0.4	1.5	1	1	0
12/10/2021 12:00	0.5	13.8	1,684.9	0.4	1.6	1	1	0
12/10/2021 13:00	0.5	13.9	1,607.0	0.4	1.5	1	1	0
12/10/2021 14:00	0.7	13.9	1,318.3	0.5	1.7	1	1	0
12/10/2021 15:00	0.6	13.8	1,583.9	0.5	1.8	1	1	0
12/10/2021 16:00	1.3	13.1	1,973.0	0.7	4.3	1	1	1
12/10/2021 17:00	1.1	12.0	2,227.9	0.7	3.6	1	1	1
12/10/2021 18:00	1.1	12.2	2,192.2	0.8	3.7	1	1	1
12/10/2021 19:00	1.1	12.2	2,190.4	0.7	3.7	1	1	1
12/10/2021 20:00	1.1	12.1	2,222.1	0.7	3.7	1	1	1
12/10/2021 21:00	1.1	12.3	2,170.9	0.7	3.7	1	1	1
12/10/2021 22:00	1.1	12.6	2,125.4	0.8	3.7	1	1	1
12/10/2021 23:00	1.1	12.6	2,126.2	0.8	3.7	1	1	1
Average/Sum#:	0.9	13.2	1,863.7	0.6	66.1 #	24 #	24 #	14 #
Minimum:	0.5	12.0	1,318.3	0.4	1.5	1	1	0
Maximum:	1.4	13.9	2,227.9	0.8	4.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/11/2021 00:00	1.1	12.7	2,122.3	0.8	3.8	1	1	1
12/11/2021 01:00	1.0	12.9	2,057.5	0.8	3.4	1	1	1
12/11/2021 02:00	1.2	13.2	1,950.8	0.8	4.0	1	1	1
12/11/2021 03:00	0.6	13.8	1,639.2	0.7	1.8	1	1	0
12/11/2021 04:00	0.6	13.8	1,710.0	0.6	1.9	1	1	1
12/11/2021 05:00	1.1	12.9	2,026.9	0.6	3.7	1	1	1
12/11/2021 06:00	1.1	12.7	2,102.2	0.7	3.7	1	1	1
12/11/2021 07:00	1.0	12.9	2,035.9	0.8	3.4	1	1	1
12/11/2021 08:00	0.7	13.8	1,614.0	0.7	2.1	1	1	0
12/11/2021 09:00	1.0	13.8	1,398.6	0.7	2.6	1	1	0
12/11/2021 10:00	1.0	13.8	1,432.0	0.7	2.7	1	1	0
12/11/2021 11:00	1.1	13.9	1,331.4	0.8	2.8	1	1	0
12/11/2021 12:00	1.1	13.9	1,328.8	0.9	2.8	1	1	0
12/11/2021 13:00	0.8	13.8	1,517.3	0.8	2.3	1	1	0
12/11/2021 14:00	0.7	13.8	1,555.1	0.7	2.0	1	1	0
12/11/2021 15:00	0.7	13.8	1,645.7	0.6	2.1	1	1	0
12/11/2021 16:00	1.5	12.6	2,120.6	0.8	5.1	1	1	1
12/11/2021 17:00	1.2	12.0	2,235.4	0.8	4.0	1	1	1
12/11/2021 18:00	1.1	12.1	2,219.7	0.9	3.7	1	1	1
12/11/2021 19:00	1.1	11.9	2,268.6	0.7	3.7	1	1	1
12/11/2021 20:00	1.1	12.1	2,220.4	0.7	3.7	1	1	1
12/11/2021 21:00	1.1	11.8	2,264.3	0.7	3.6	1	1	1
12/11/2021 22:00	1.1	12.0	2,213.7	0.7	3.6	1	1	1
12/11/2021 23:00	1.1	12.5	2,111.0	0.7	3.7	1	1	1
Average/Sum#:	1.0	13.0	1,880.1	0.7	76.2 #	24 #	24 #	15 #
Minimum:	0.6	11.8	1,328.8	0.6	1.8	1	1	0
Maximum:	1.5	13.9	2,268.6	0.9	5.1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/12/2021 00:00	1.1	12.5	2,099.1	0.8	3.6	1	1	1
12/12/2021 01:00	1.1	12.7	2,050.8	0.8	3.6	1	1	1
12/12/2021 02:00	1.2	13.2	1,934.7	0.8	4.0	1	1	1
12/12/2021 03:00	0.6	13.8	1,610.8	0.7	1.8	1	1	0
12/12/2021 04:00	0.6	13.7	1,745.7	0.6	1.9	1	1	1
12/12/2021 05:00	1.1	12.8	2,014.9	0.6	3.6	1	1	1
12/12/2021 06:00	1.2	12.7	2,045.5	0.7	4.0	1	1	1
12/12/2021 07:00	0.7	13.7	1,634.2	0.8	2.1	1	1	1
12/12/2021 08:00	0.6	13.8	1,606.5	0.7	1.8	1	1	0
12/12/2021 09:00	0.9	13.8	1,407.3	0.6	2.4	1	1	0
12/12/2021 10:00	0.7	13.8	1,610.9	0.6	2.1	1	1	0
12/12/2021 11:00	0.6	13.7	1,700.3	0.6	1.9	1	1	0
12/12/2021 12:00	0.6	13.8	1,622.6	0.5	1.8	1	1	0
12/12/2021 13:00	0.6	13.8	1,647.7	0.5	1.8	1	1	0
12/12/2021 14:00	0.7	13.8	1,605.2	0.5	2.1	1	1	0
12/12/2021 15:00	1.0	13.7	1,598.0	0.6	2.9	1	1	1
12/12/2021 16:00	1.3	12.5	2,074.5	0.8	4.2	1	1	1
12/12/2021 17:00	1.2	12.1	2,158.6	0.8	3.9	1	1	1
12/12/2021 18:00	1.2	12.1	2,154.4	0.8	3.9	1	1	1
12/12/2021 19:00	1.0	11.8	2,216.5	0.7	3.2	1	1	1
12/12/2021 20:00	1.1	12.1	2,147.3	0.7	3.5	1	1	1
12/12/2021 21:00	1.1	12.1	2,153.4	0.7	3.6	1	1	1
12/12/2021 22:00	1.1	12.3	2,120.5	0.7	3.6	1	1	1
12/12/2021 23:00	1.1	12.5	2,067.2	0.8	3.6	1	1	1
Average/Sum#:	0.9	13.0	1,876.1	0.7	70.9 #	24 #	24 #	16 #
Minimum:	0.6	11.8	1,407.3	0.5	1.8	1	1	0
Maximum:	1.3	13.8	2,216.5	0.8	4.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/13/2021 00:00	1.2	13.0	1,935.9	0.8	3.9	1	1	1
12/13/2021 01:00	0.5	13.7	1,705.2	0.7	1.6	1	1	0
12/13/2021 02:00	0.7	13.7	1,684.2	0.6	2.2	1	1	1
12/13/2021 03:00	1.3	12.7	2,017.7	0.6	4.2	1	1	1
12/13/2021 04:00	1.2	12.9	1,949.1	0.8	3.9	1	1	1
12/13/2021 05:00	0.7	13.8	1,595.8	0.8	2.1	1	1	0
12/13/2021 06:00	0.7	13.6	1,788.5	0.7	2.3	1	1	1
12/13/2021 07:00	1.3	12.4	2,093.5	0.7	4.2	1	1	1
12/13/2021 08:00	1.1	11.9	2,194.6	0.7	3.5	1	1	1
12/13/2021 09:00	1.1	12.0	2,157.9	0.8	3.5	1	1	1
12/13/2021 10:00	1.1	12.2	2,125.1	0.7	3.5	1	1	1
12/13/2021 11:00	1.1	12.6	2,012.1	0.7	3.5	1	1	1
12/13/2021 12:00	0.5	13.8	1,649.6	0.6	1.5	1	1	0
12/13/2021 13:00	0.6	13.6	1,798.6	0.6	2.0	1	1	1
12/13/2021 14:00	1.2	12.5	2,049.8	0.6	3.9	1	1	1
12/13/2021 15:00	1.1	11.7	2,231.9	0.7	3.5	1	1	1
12/13/2021 16:00	0.9	11.5	2,286.9	0.7	2.9	1	1	1
12/13/2021 17:00	0.9	11.4	2,309.3	0.6	2.9	1	1	1
12/13/2021 18:00	0.9	11.4	2,312.4	0.6	2.9	1	1	1
12/13/2021 19:00	0.9	11.5	2,304.5	0.6	2.9	1	1	1
12/13/2021 20:00	1.0	12.0	2,174.8	0.6	3.2	1	1	1
12/13/2021 21:00	1.1	12.3	2,112.6	0.7	3.6	1	1	1
12/13/2021 22:00	1.1	12.6	2,048.9	0.8	3.6	1	1	1
12/13/2021 23:00	1.1	12.6	2,057.9	0.8	3.6	1	1	1
Average/Sum#:	1.0	12.6	2,024.9	0.7	74.9 #	24 #	24 #	21 #
Minimum:	0.5	11.4	1,595.8	0.6	1.5	1	1	0
Maximum:	1.3	13.8	2,312.4	0.8	4.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/14/2021 00:00	1.0	13.2	1,841.6	0.8	3.2	1	1	1
12/14/2021 01:00	0.9	13.9	1,300.6	0.8	2.2	1	1	0
12/14/2021 02:00	0.9	13.8	1,320.8	0.8	2.2	1	1	0
12/14/2021 03:00	0.5	13.7	1,755.8	0.6	1.6	1	1	0
12/14/2021 04:00	0.9	13.4	1,872.8	0.6	3.0	1	1	1
12/14/2021 05:00	0.9	13.4	1,871.7	0.6	3.0	1	1	1
12/14/2021 06:00	0.6	13.7	1,725.4	0.6	1.9	1	1	1
12/14/2021 07:00	1.1	12.6	2,085.5	0.7	3.7	1	1	1
12/14/2021 08:00	1.1	12.4	2,112.1	0.7	3.6	1	1	1
12/14/2021 09:00	0.9	12.9	1,976.2	0.8	2.9	1	1	1
12/14/2021 10:00	0.6	13.8	1,622.7	0.7	1.8	1	1	0
12/14/2021 11:00	0.7	13.8	1,640.8	0.6	2.1	1	1	1
12/14/2021 12:00	1.2	12.8	2,040.7	0.7	4.0	1	1	1
12/14/2021 13:00	1.1	13.1	1,934.5	0.8	3.6	1	1	1
12/14/2021 14:00	0.5	13.8	1,649.6	0.7	1.5	1	1	0
12/14/2021 15:00	0.7	13.8	1,539.2	0.6	2.0	1	1	0
12/14/2021 16:00	1.2	12.9	2,002.4	0.6	4.0	1	1	1
12/14/2021 17:00	1.0	11.7	2,301.1	0.7	3.3	1	1	1
12/14/2021 18:00	1.1	11.9	2,243.4	0.7	3.6	1	1	1
12/14/2021 19:00	1.0	11.7	2,299.5	0.6	3.3	1	1	1
12/14/2021 20:00	1.0	11.7	2,303.6	0.6	3.3	1	1	1
12/14/2021 21:00	1.1	12.0	2,238.0	0.6	3.7	1	1	1
12/14/2021 22:00	1.1	12.4	2,143.1	0.7	3.7	1	1	1
12/14/2021 23:00	1.0	12.8	2,049.8	0.7	3.3	1	1	1
Average/Sum#:	0.9	13.0	1,911.3	0.7	70.5 #	24 #	24 #	18 #
Minimum:	0.5	11.7	1,300.6	0.6	1.5	1	1	0
Maximum:	1.2	13.9	2,303.6	0.8	4.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/15/2021 00:00	1.2	13.1	1,973.0	0.8	4.0	1	1	1
12/15/2021 01:00	0.7	13.8	1,567.8	0.7	2.0	1	1	0
12/15/2021 02:00	0.8	13.8	1,675.9	0.7	2.5	1	1	1
12/15/2021 03:00	1.2	13.2	1,967.2	0.7	4.0	1	1	1
12/15/2021 04:00	1.3	13.2	1,948.6	0.9	4.3	1	1	1
12/15/2021 05:00	0.8	13.8	1,589.5	0.9	2.4	1	1	0
12/15/2021 06:00	1.0	13.3	1,899.4	0.8	3.3	1	1	1
12/15/2021 07:00	1.2	12.2	2,192.1	0.8	4.0	1	1	1
12/15/2021 08:00	1.1	12.9	1,997.6	0.8	3.6	1	1	1
12/15/2021 09:00	0.7	13.8	1,599.5	0.7	2.1	1	1	0
12/15/2021 10:00	0.6	13.8	1,624.5	0.6	1.8	1	1	0
12/15/2021 11:00	0.7	13.7	1,617.0	0.6	2.1	1	1	1
12/15/2021 12:00	1.0	12.8	2,020.0	0.6	3.3	1	1	1
12/15/2021 13:00	1.0	12.7	2,013.3	0.7	3.2	1	1	1
12/15/2021 14:00	0.6	13.8	1,564.7	0.6	1.7	1	1	0
12/15/2021 15:00	0.6	13.7	1,723.9	0.6	1.9	1	1	1
12/15/2021 16:00	1.2	12.3	2,148.3	0.6	4.0	1	1	1
12/15/2021 17:00	1.0	11.5	2,298.6	0.6	3.2	1	1	1
12/15/2021 18:00	1.0	11.6	2,292.5	0.7	3.3	1	1	1
12/15/2021 19:00	1.0	11.6	2,288.0	0.6	3.2	1	1	1
12/15/2021 20:00	1.0	11.6	2,290.7	0.6	3.3	1	1	1
12/15/2021 21:00	1.0	11.8	2,240.6	0.6	3.3	1	1	1
12/15/2021 22:00	1.2	12.3	2,141.0	0.7	3.9	1	1	1
12/15/2021 23:00	1.2	12.4	2,112.4	0.7	3.9	1	1	1
Average/Sum#:	1.0	12.9	1,949.4	0.7	74.3 #	24 #	24 #	19 #
Minimum:	0.6	11.5	1,564.7	0.6	1.7	1	1	0
Maximum:	1.3	13.8	2,298.6	0.9	4.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/16/2021 00:00	1.1	12.6	2,067.2	0.8	3.6	1	1	1
12/16/2021 01:00	1.1	13.0	1,974.1	0.8	3.6	1	1	1
12/16/2021 02:00	0.6	13.8	1,583.8	0.7	1.8	1	1	0
12/16/2021 03:00	0.6	13.8	1,588.8	0.6	1.8	1	1	0
12/16/2021 04:00	0.6	13.8	1,627.6	0.5	1.8	1	1	1
12/16/2021 05:00	1.2	12.6	2,052.6	0.6	3.9	1	1	1
12/16/2021 06:00	1.2	11.8	2,275.8	0.7	4.0	1	1	1
12/16/2021 07:00	1.1	11.9	2,256.8	0.8	3.6	1	1	1
12/16/2021 08:00	1.1	12.6	2,071.2	0.8	3.6	1	1	1
12/16/2021 09:00	1.1	13.0	1,980.8	0.8	3.6	1	1	1
12/16/2021 10:00	0.7	13.8	1,497.3	0.7	1.9	1	1	0
12/16/2021 11:00	0.7	13.8	1,625.2	0.7	2.1	1	1	1
12/16/2021 12:00	1.4	12.8	2,043.0	0.7	4.7	1	1	1
12/16/2021 13:00	1.2	13.2	1,946.2	0.8	4.0	1	1	1
12/16/2021 14:00	0.6	13.8	1,562.9	0.8	1.7	1	1	0
12/16/2021 15:00	0.7	13.8	1,601.6	0.7	2.1	1	1	1
12/16/2021 16:00	1.6	12.4	2,137.2	0.7	5.3	1	1	1
12/16/2021 17:00	1.1	11.8	2,274.9	0.8	3.6	1	1	1
12/16/2021 18:00	1.1	11.8	2,276.4	0.8	3.6	1	1	1
12/16/2021 19:00	1.0	11.8	2,278.2	0.7	3.3	1	1	1
12/16/2021 20:00	1.0	11.8	2,286.1	0.6	3.3	1	1	1
12/16/2021 21:00	1.0	11.9	2,271.3	0.6	3.3	1	1	1
12/16/2021 22:00	1.1	12.4	2,139.0	0.7	3.7	1	1	1
12/16/2021 23:00	1.1	12.6	2,088.5	0.8	3.7	1	1	1
Average/Sum#:	1.0	12.8	1,979.4	0.7	77.6 #	24 #	24 #	20 #
Minimum:	0.6	11.8	1,497.3	0.5	1.7	1	1	0
Maximum:	1.6	13.8	2,286.1	0.8	5.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/17/2021 00:00	1.1	13.2	1,942.9	0.8	3.7	1	1	1
12/17/2021 01:00	0.6	13.8	1,565.8	0.7	1.7	1	1	0
12/17/2021 02:00	0.6	13.8	1,560.1	0.6	1.7	1	1	0
12/17/2021 03:00	0.6	13.8	1,718.2	0.5	1.9	1	1	1
12/17/2021 04:00	1.2	12.9	2,025.9	0.6	4.0	1	1	1
12/17/2021 05:00	1.1	12.9	2,034.0	0.7	3.7	1	1	1
12/17/2021 06:00	1.2	12.0	2,248.6	0.8	4.0	1	1	1
12/17/2021 07:00	1.1	12.1	2,236.2	0.8	3.7	1	1	1
12/17/2021 08:00	1.1	13.0	2,037.9	0.8	3.7	1	1	1
12/17/2021 09:00	1.2	13.2	1,946.0	0.8	4.0	1	1	1
12/17/2021 10:00	0.6	13.8	1,584.2	0.7	1.8	1	1	0
12/17/2021 11:00	0.6	13.8	1,551.7	0.6	1.7	1	1	0
12/17/2021 12:00	0.7	13.9	1,393.3	0.5	1.8	1	1	0
12/17/2021 13:00	0.5	13.8	1,659.0	0.5	1.5	1	1	0
12/17/2021 14:00	0.6	13.9	1,501.0	0.5	1.7	1	1	0
12/17/2021 15:00	0.7	13.8	1,605.8	0.5	2.1	1	1	1
12/17/2021 16:00	1.3	12.7	2,069.4	0.7	4.3	1	1	1
12/17/2021 17:00	1.1	11.7	2,295.8	0.7	3.6	1	1	1
12/17/2021 18:00	1.0	11.7	2,299.7	0.7	3.3	1	1	1
12/17/2021 19:00	1.0	11.8	2,297.7	0.6	3.3	1	1	1
12/17/2021 20:00	1.0	11.7	2,303.1	0.6	3.3	1	1	1
12/17/2021 21:00	1.0	11.8	2,289.2	0.6	3.3	1	1	1
12/17/2021 22:00	1.1	12.5	2,137.5	0.7	3.7	1	1	1
12/17/2021 23:00	1.1	12.9	2,044.4	0.7	3.7	1	1	1
Average/Sum#:	0.9	12.9	1,931.1	0.7	71.2 #	24 #	24 #	17 #
Minimum:	0.5	11.7	1,393.3	0.5	1.5	1	1	0
Maximum:	1.3	13.9	2,303.1	0.8	4.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/18/2021 00:00	1.2	13.2	1,954.4	0.8	4.0	1	1	1
12/18/2021 01:00	0.7	13.8	1,623.0	0.8	2.1	1	1	1
12/18/2021 02:00	0.6	13.8	1,744.1	0.7	1.9	1	1	0
12/18/2021 03:00	1.2	12.9	2,071.3	0.7	4.1	1	1	1
12/18/2021 04:00	1.2	13.0	2,025.4	0.8	4.1	1	1	1
12/18/2021 05:00	0.6	13.8	1,694.8	0.8	1.9	1	1	1
12/18/2021 06:00	0.6	13.8	1,789.4	0.6	2.0	1	1	1
12/18/2021 07:00	1.5	13.0	2,048.1	0.7	5.1	1	1	1
12/18/2021 08:00	1.2	13.0	2,038.3	0.8	4.1	1	1	1
12/18/2021 09:00	1.2	13.0	2,011.9	1.0	4.0	1	1	1
12/18/2021 10:00	0.7	13.8	1,564.8	0.8	2.0	1	1	0
12/18/2021 11:00	0.7	13.8	1,604.0	0.7	2.1	1	1	0
12/18/2021 12:00	0.7	13.8	1,564.9	0.6	2.0	1	1	0
12/18/2021 13:00	0.7	13.8	1,549.8	0.6	2.0	1	1	0
12/18/2021 14:00	0.7	13.8	1,555.0	0.6	2.0	1	1	0
12/18/2021 15:00	0.8	13.8	1,511.5	0.6	2.2	1	1	0
12/18/2021 16:00	1.2	13.3	1,884.1	0.7	3.9	1	1	1
12/18/2021 17:00	1.3	12.1	2,219.0	0.8	4.3	1	1	1
12/18/2021 18:00	1.2	12.4	2,152.8	0.9	4.0	1	1	1
12/18/2021 19:00	1.2	12.0	2,247.1	0.8	4.0	1	1	1
12/18/2021 20:00	1.1	11.9	2,277.2	0.8	3.7	1	1	1
12/18/2021 21:00	1.1	12.3	2,177.8	0.8	3.7	1	1	1
12/18/2021 22:00	1.1	12.6	2,119.7	0.8	3.7	1	1	1
12/18/2021 23:00	1.1	12.9	2,038.6	0.8	3.7	1	1	1
Average/Sum#:	1.0	13.2	1,894.5	0.8	76.6 #	24 #	24 #	17 #
Minimum:	0.6	11.9	1,511.5	0.6	1.9	1	1	0
Maximum:	1.5	13.8	2,277.2	1.0	5.1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/19/2021 00:00	1.1	12.7	2,084.6	0.8	3.7	1	1	1
12/19/2021 01:00	1.2	12.9	2,016.1	0.8	4.0	1	1	1
12/19/2021 02:00	0.6	13.8	1,634.7	0.7	1.8	1	1	0
12/19/2021 03:00	0.6	13.7	1,705.1	0.6	1.9	1	1	0
12/19/2021 04:00	1.3	13.0	2,010.4	0.7	4.4	1	1	1
12/19/2021 05:00	1.2	13.0	2,032.4	0.8	4.1	1	1	1
12/19/2021 06:00	1.2	13.1	1,992.7	0.9	4.0	1	1	1
12/19/2021 07:00	1.3	13.0	2,028.6	0.9	4.4	1	1	1
12/19/2021 08:00	1.3	13.0	2,025.2	1.0	4.4	1	1	1
12/19/2021 09:00	1.3	13.2	1,960.8	1.0	4.4	1	1	1
12/19/2021 10:00	0.8	13.8	1,509.6	0.9	2.2	1	1	0
12/19/2021 11:00	0.8	13.8	1,506.8	0.8	2.2	1	1	0
12/19/2021 12:00	0.9	13.8	1,467.5	0.7	2.5	1	1	0
12/19/2021 13:00	0.6	13.8	1,614.3	0.6	1.8	1	1	0
12/19/2021 14:00	0.6	13.8	1,615.0	0.6	1.8	1	1	0
12/19/2021 15:00	0.7	13.8	1,600.5	0.5	2.1	1	1	0
12/19/2021 16:00	1.3	12.9	2,012.3	0.7	4.3	1	1	1
12/19/2021 17:00	1.2	12.1	2,222.8	0.8	4.0	1	1	1
12/19/2021 18:00	1.2	12.5	2,140.1	0.9	4.0	1	1	1
12/19/2021 19:00	1.2	12.3	2,173.0	0.8	4.0	1	1	1
12/19/2021 20:00	1.2	12.4	2,153.1	0.8	4.0	1	1	1
12/19/2021 21:00	1.2	12.5	2,141.0	0.8	4.0	1	1	1
12/19/2021 22:00	1.2	12.5	2,136.0	0.8	4.0	1	1	1
12/19/2021 23:00	1.1	12.6	2,094.6	0.8	3.7	1	1	1
Average/Sum#:	1.0	13.1	1,911.6	0.8	81.7 #	24 #	24 #	16 #
Minimum:	0.6	12.1	1,467.5	0.5	1.8	1	1	0
Maximum:	1.3	13.8	2,222.8	1.0	4.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/20/2021 00:00	1.1	12.7	2,094.2	0.8	3.7	1	1	1
12/20/2021 01:00	1.2	13.0	1,994.4	0.8	4.0	1	1	1
12/20/2021 02:00	0.6	13.7	1,718.1	0.7	1.9	1	1	0
12/20/2021 03:00	0.6	13.7	1,758.0	0.6	1.9	1	1	1
12/20/2021 04:00	1.3	12.9	2,038.4	0.7	4.4	1	1	1
12/20/2021 05:00	1.3	12.4	2,144.9	0.8	4.3	1	1	1
12/20/2021 06:00	1.2	12.1	2,243.0	0.9	4.0	1	1	1
12/20/2021 07:00	1.1	12.4	2,143.5	0.8	3.7	1	1	1
12/20/2021 08:00	1.1	12.9	2,016.4	0.8	3.7	1	1	1
12/20/2021 09:00	0.6	13.8	1,663.9	0.7	1.9	1	1	0
12/20/2021 10:00	1.0	13.8	1,354.3	0.7	2.5	1	1	0
12/20/2021 11:00	0.6	13.8	1,662.4	0.6	1.9	1	1	0
12/20/2021 12:00	1.2	13.4	1,889.8	0.7	4.0	1	1	1
12/20/2021 13:00	1.2	12.4	2,153.3	0.7	4.0	1	1	1
12/20/2021 14:00	1.2	12.0	2,236.5	0.8	4.0	1	1	1
12/20/2021 15:00	1.1	12.0	2,229.7	0.8	3.6	1	1	1
12/20/2021 16:00	1.1	11.8	2,284.5	0.7	3.6	1	1	1
12/20/2021 17:00	1.1	11.7	2,299.6	0.7	3.6	1	1	1
12/20/2021 18:00	1.0	11.7	2,300.8	0.7	3.3	1	1	1
12/20/2021 19:00	1.0	11.7	2,313.4	0.6	3.3	1	1	1
12/20/2021 20:00	1.0	11.7	2,316.6	0.6	3.3	1	1	1
12/20/2021 21:00	1.0	11.7	2,321.3	0.6	3.3	1	1	1
12/20/2021 22:00	1.0	11.7	2,303.5	0.6	3.3	1	1	1
12/20/2021 23:00	1.1	12.4	2,142.3	0.7	3.7	1	1	1
Average/Sum#:	1.0	12.6	2,067.6	0.7	80.9 #	24 #	24 #	20 #
Minimum:	0.6	11.7	1,354.3	0.6	1.9	1	1	0
Maximum:	1.3	13.8	2,321.3	0.9	4.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/21/2021 00:00	1.1	12.5	2,098.4	0.7	3.6	1	1	1
12/21/2021 01:00	0.5	13.8	1,701.1	0.7	1.6	1	1	0
12/21/2021 02:00	0.6	13.7	1,817.0	0.6	2.0	1	1	1
12/21/2021 03:00	1.2	13.0	2,036.9	0.6	4.1	1	1	1
12/21/2021 04:00	1.2	13.0	1,996.3	0.8	4.0	1	1	1
12/21/2021 05:00	0.6	13.8	1,686.5	0.8	1.9	1	1	0
12/21/2021 06:00	0.6	13.8	1,772.5	0.6	2.0	1	1	1
12/21/2021 07:00	1.4	12.8	2,091.3	0.7	4.8	1	1	1
12/21/2021 08:00	1.2	11.9	2,282.0	0.8	4.0	1	1	1
12/21/2021 09:00	1.1	12.5	2,117.5	0.9	3.7	1	1	1
12/21/2021 10:00	0.6	13.8	1,635.9	0.7	1.8	1	1	0
12/21/2021 11:00	0.5	13.7	1,821.6	0.6	1.7	1	1	1
12/21/2021 12:00	1.2	12.8	2,073.0	0.6	4.1	1	1	1
12/21/2021 13:00	1.2	12.9	2,012.9	0.7	4.0	1	1	1
12/21/2021 14:00	0.6	13.8	1,665.2	0.8	1.9	1	1	0
12/21/2021 15:00	0.5	13.7	1,820.4	0.6	1.7	1	1	1
12/21/2021 16:00	1.7	12.8	2,071.1	0.7	5.7	1	1	1
12/21/2021 17:00	1.2	12.0	2,278.3	0.8	4.1	1	1	1
12/21/2021 18:00	1.1	11.9	2,292.2	0.9	3.7	1	1	1
12/21/2021 19:00	1.1	11.8	2,295.6	0.7	3.7	1	1	1
12/21/2021 20:00	1.1	11.8	2,293.3	0.7	3.7	1	1	1
12/21/2021 21:00	1.1	12.0	2,235.2	0.7	3.6	1	1	1
12/21/2021 22:00	1.1	12.5	2,139.8	0.7	3.7	1	1	1
12/21/2021 23:00	1.1	12.7	2,089.3	0.8	3.7	1	1	1
Average/Sum#:	1.0	12.9	2,013.5	0.7	78.8 #	24 #	24 #	20 #
Minimum:	0.5	11.8	1,635.9	0.6	1.6	1	1	0
Maximum:	1.7	13.8	2,295.6	0.9	5.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/22/2021 00:00	1.2	13.2	1,955.6	0.8	4.0	1	1	1
12/22/2021 01:00	0.6	13.8	1,633.5	0.7	1.8	1	1	0
12/22/2021 02:00	0.7	13.7	1,699.0	0.7	2.2	1	1	1
12/22/2021 03:00	1.4	13.2	1,974.4	0.7	4.7	1	1	1
12/22/2021 04:00	1.2	13.2	1,954.3	0.9	4.0	1	1	1
12/22/2021 05:00	1.0	13.8	1,473.4	0.9	2.7	1	1	0
12/22/2021 06:00	0.7	13.7	1,709.1	0.8	2.2	1	1	1
12/22/2021 07:00	1.3	13.0	1,998.4	0.8	4.3	1	1	1
12/22/2021 08:00	1.2	13.0	1,989.2	0.8	4.0	1	1	1
12/22/2021 09:00	0.8	13.8	1,453.1	0.9	2.2	1	1	0
12/22/2021 10:00	0.9	13.7	1,532.4	0.8	2.5	1	1	1
12/22/2021 11:00	1.3	13.0	2,009.3	0.8	4.4	1	1	1
12/22/2021 12:00	1.3	13.2	1,955.8	0.9	4.4	1	1	1
12/22/2021 13:00	0.6	13.7	1,631.3	0.8	1.8	1	1	1
12/22/2021 14:00	0.5	13.7	1,802.3	0.6	1.7	1	1	0
12/22/2021 15:00	1.4	12.9	2,014.2	0.6	4.7	1	1	1
12/22/2021 16:00	1.2	12.6	2,073.9	0.8	4.0	1	1	1
12/22/2021 17:00	1.3	12.3	2,168.2	0.9	4.3	1	1	1
12/22/2021 18:00	1.1	12.8	2,031.0	0.9	3.6	1	1	1
12/22/2021 19:00	1.2	13.0	1,988.5	0.9	4.0	1	1	1
12/22/2021 20:00	1.1	12.8	2,009.9	0.8	3.6	1	1	1
12/22/2021 21:00	0.7	13.8	1,561.2	0.8	2.0	1	1	0
12/22/2021 22:00	0.6	13.7	1,767.2	0.6	1.9	1	1	1
12/22/2021 23:00	1.3	12.7	2,051.5	0.7	4.3	1	1	1
Average/Sum#:	1.0	13.3	1,851.5	0.8	79.3 #	24 #	24 #	19 #
Minimum:	0.5	12.3	1,453.1	0.6	1.7	1	1	0
Maximum:	1.4	13.8	2,168.2	0.9	4.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/23/2021 00:00	1.3	13.1	1,942.7	0.8	4.3	1	1	1
12/23/2021 01:00	0.7	13.8	1,586.5	0.8	2.1	1	1	0
12/23/2021 02:00	0.8	13.7	1,633.4	0.8	2.4	1	1	1
12/23/2021 03:00	1.4	13.1	1,962.4	0.8	4.7	1	1	1
12/23/2021 04:00	1.3	13.1	1,936.7	0.9	4.3	1	1	1
12/23/2021 05:00	0.7	13.7	1,660.4	0.9	2.1	1	1	0
12/23/2021 06:00	0.8	13.6	1,654.8	0.7	2.4	1	1	1
12/23/2021 07:00	1.3	12.5	2,072.6	0.7	4.2	1	1	1
12/23/2021 08:00	1.2	13.0	1,950.8	0.8	3.9	1	1	1
12/23/2021 09:00	0.7	13.8	1,558.8	0.8	2.0	1	1	0
12/23/2021 10:00	0.7	13.7	1,652.7	0.7	2.1	1	1	1
12/23/2021 11:00	1.1	13.0	1,957.5	0.7	3.6	1	1	1
12/23/2021 12:00	1.1	13.0	1,934.2	0.7	3.6	1	1	1
12/23/2021 13:00	0.6	13.8	1,630.1	0.7	1.8	1	1	0
12/23/2021 14:00	0.9	13.8	1,326.6	0.7	2.2	1	1	0
12/23/2021 15:00	0.6	13.7	1,632.9	0.6	1.8	1	1	0
12/23/2021 16:00	1.1	13.2	1,853.6	0.7	3.5	1	1	1
12/23/2021 17:00	1.2	12.9	1,933.2	0.7	3.8	1	1	1
12/23/2021 18:00	0.6	13.7	1,677.9	0.7	1.8	1	1	1
12/23/2021 19:00	1.3	12.8	1,985.6	0.8	4.2	1	1	1
12/23/2021 20:00	1.2	12.9	1,944.8	0.8	3.9	1	1	1
12/23/2021 21:00	0.7	13.8	1,475.6	0.8	1.9	1	1	0
12/23/2021 22:00	0.8	13.7	1,597.7	0.7	2.3	1	1	1
12/23/2021 23:00	1.2	12.8	2,003.2	0.7	3.9	1	1	1
Average/Sum#:	1.0	13.3	1,773.5	0.8	72.8 #	24 #	24 #	17 #
Minimum:	0.6	12.5	1,326.6	0.6	1.8	1	1	0
Maximum:	1.4	13.8	2,072.6	0.9	4.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/24/2021 00:00	1.2	12.9	1,952.4	0.8	3.9	1	1	1
12/24/2021 01:00	0.6	13.8	1,533.6	0.8	1.7	1	1	0
12/24/2021 02:00	0.7	13.8	1,483.7	0.7	1.9	1	1	0
12/24/2021 03:00	0.9	13.8	1,364.6	0.6	2.3	1	1	0
12/24/2021 04:00	0.9	13.8	1,369.5	0.7	2.3	1	1	0
12/24/2021 05:00	0.6	13.8	1,761.1	0.6	2.0	1	1	0
12/24/2021 06:00	0.9	13.3	1,863.2	0.6	2.9	1	1	1
12/24/2021 07:00	1.0	13.2	1,893.7	0.7	3.2	1	1	1
12/24/2021 08:00	0.7	13.7	1,668.5	0.7	2.1	1	1	1
12/24/2021 09:00	1.4	13.0	1,974.9	0.8	4.6	1	1	1
12/24/2021 10:00	1.2	13.0	1,961.2	0.8	3.9	1	1	1
12/24/2021 11:00	0.7	13.9	1,406.3	0.8	1.9	1	1	0
12/24/2021 12:00	0.5	13.8	1,629.2	0.6	1.5	1	1	0
12/24/2021 13:00	0.6	13.9	1,428.8	0.5	1.6	1	1	0
12/24/2021 14:00	0.6	13.9	1,417.3	0.5	1.6	1	1	0
12/24/2021 15:00	0.6	13.8	1,498.3	0.5	1.7	1	1	0
12/24/2021 16:00	0.7	13.8	1,519.2	0.5	2.0	1	1	1
12/24/2021 17:00	1.1	12.9	1,998.6	0.6	3.6	1	1	1
12/24/2021 18:00	1.2	12.8	2,022.1	0.8	4.0	1	1	1
12/24/2021 19:00	1.1	12.8	2,027.1	0.8	3.6	1	1	1
12/24/2021 20:00	1.2	13.1	1,934.3	0.9	3.9	1	1	1
12/24/2021 21:00	0.7	13.9	1,412.2	0.8	1.9	1	1	0
12/24/2021 22:00	0.7	13.7	1,608.4	0.7	2.1	1	1	1
12/24/2021 23:00	1.2	12.7	2,042.7	0.7	3.9	1	1	1
Average/Sum#:	0.9	13.5	1,698.8	0.7	64.1 #	24 #	24 #	13 #
Minimum:	0.5	12.7	1,364.6	0.5	1.5	1	1	0
Maximum:	1.4	13.9	2,042.7	0.9	4.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/25/2021 00:00	1.2	13.1	1,951.8	0.8	4.0	1	1	1
12/25/2021 01:00	0.6	13.8	1,560.4	0.8	1.7	1	1	0
12/25/2021 02:00	0.7	13.8	1,448.9	0.7	1.9	1	1	0
12/25/2021 03:00	0.9	13.8	1,358.0	0.6	2.3	1	1	0
12/25/2021 04:00	0.7	13.7	1,587.8	0.6	2.0	1	1	1
12/25/2021 05:00	1.2	12.8	2,018.2	0.7	3.9	1	1	1
12/25/2021 06:00	1.3	13.1	1,950.7	0.8	4.3	1	1	1
12/25/2021 07:00	0.7	13.7	1,587.5	0.8	2.0	1	1	1
12/25/2021 08:00	0.7	13.8	1,616.8	0.7	2.1	1	1	0
12/25/2021 09:00	0.8	13.8	1,417.7	0.6	2.1	1	1	0
12/25/2021 10:00	0.6	13.8	1,637.8	0.6	1.8	1	1	0
12/25/2021 11:00	0.6	13.8	1,599.0	0.6	1.8	1	1	0
12/25/2021 12:00	0.6	13.8	1,564.8	0.5	1.7	1	1	0
12/25/2021 13:00	0.6	13.8	1,505.3	0.5	1.7	1	1	0
12/25/2021 14:00	0.6	13.8	1,611.8	0.5	1.8	1	1	0
12/25/2021 15:00	0.6	13.8	1,627.7	0.5	1.8	1	1	0
12/25/2021 16:00	1.0	13.1	1,934.9	0.6	3.3	1	1	1
12/25/2021 17:00	1.3	12.5	2,081.0	0.7	4.3	1	1	1
12/25/2021 18:00	1.2	12.5	2,084.9	0.8	3.9	1	1	1
12/25/2021 19:00	1.2	12.6	2,076.0	0.9	4.0	1	1	1
12/25/2021 20:00	1.2	13.1	1,946.4	0.9	4.0	1	1	1
12/25/2021 21:00	0.6	13.8	1,659.1	0.8	1.9	1	1	0
12/25/2021 22:00	0.7	13.8	1,604.3	0.7	2.1	1	1	1
12/25/2021 23:00	1.3	12.9	2,019.0	0.7	4.3	1	1	1
Average/Sum#:	0.9	13.4	1,727.1	0.7	64.7 #	24 #	24 #	12 #
Minimum:	0.6	12.5	1,358.0	0.5	1.7	1	1	0
Maximum:	1.3	13.8	2,084.9	0.9	4.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/26/2021 00:00	11.3	14.3	1,235.1	0.0	14.0	1	0	1
12/26/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 10:00	61.4	19.1	136.1	0.0	10.4	1	0	0
12/26/2021 11:00	26.2	17.2	397.2	0.0	37.1	1	0	0
12/26/2021 12:00	61.0	15.7	770.7	0.0	119.4	1	0	0
12/26/2021 13:00	0.8	13.8	1,403.5	0.0	2.1	1	0	0
12/26/2021 14:00	0.8	13.8	1,372.2	0.0	2.0	1	0	0
12/26/2021 15:00	0.7	13.8	1,649.6	0.7	2.1	1	0	0
12/26/2021 16:00	0.6	13.8	1,648.3	0.6	1.8	1	0	0
12/26/2021 17:00	0.6	13.7	1,759.2	0.5	1.9	1	1	0
12/26/2021 18:00	0.6	13.7	1,762.5	0.5	1.9	1	1	1
12/26/2021 19:00	1.2	13.0	1,993.4	0.6	4.0	1	1	1
12/26/2021 20:00	1.2	12.8	2,007.9	0.8	3.9	1	1	1
12/26/2021 21:00	0.6	13.8	1,635.5	0.8	1.8	1	1	0
12/26/2021 22:00	0.6	13.7	1,719.1	0.6	1.9	1	1	1
12/26/2021 23:00	1.2	12.8	2,029.2	0.6	4.0	1	1	1
Average/Sum#:	11.3	14.3	1,434.6	0.6	208.3 #	15 #	7 #	6 #
Minimum:	0.6	12.8	136.1	0.5	1.8	0	0	0
Maximum:	61.4	19.1	2,029.2	0.8	119.4	1	1	1
%SI	37.50	37.50	37.50	62.50	37.50	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/27/2021 00:00	1.2	12.7	2,061.3	0.8	4.0	1	1	1
12/27/2021 01:00	1.2	12.9	1,993.2	0.9	3.9	1	1	1
12/27/2021 02:00	0.5	13.8	1,667.4	0.7	1.6	1	1	0
12/27/2021 03:00	0.7	13.8	1,517.7	0.6	2.0	1	1	0
12/27/2021 04:00	0.7	13.8	1,526.5	0.5	2.0	1	1	0
12/27/2021 05:00	0.6	13.7	1,685.5	0.6	1.9	1	1	1
12/27/2021 06:00	1.3	12.8	2,060.6	0.7	4.4	1	1	1
12/27/2021 07:00	1.3	12.1	2,196.9	0.8	4.3	1	1	1
12/27/2021 08:00	1.3	12.3	2,158.1	0.9	4.3	1	1	1
12/27/2021 09:00	1.2	12.1	2,190.4	0.9	3.9	1	1	1
12/27/2021 10:00	1.2	12.3	2,131.5	0.8	3.9	1	1	1
12/27/2021 11:00	1.1	12.4	2,074.5	0.8	3.5	1	1	1
12/27/2021 12:00	0.5	13.8	1,710.1	0.7	1.6	1	1	0
12/27/2021 13:00	0.6	13.8	1,646.9	0.6	1.8	1	1	0
12/27/2021 14:00	1.1	13.0	1,998.5	0.6	3.7	1	1	1
12/27/2021 15:00	1.2	12.4	2,147.8	0.7	4.0	1	1	1
12/27/2021 16:00	1.1	11.7	2,320.2	0.8	3.7	1	1	1
12/27/2021 17:00	1.0	11.6	2,334.5	0.7	3.3	1	1	1
12/27/2021 18:00	1.0	11.6	2,319.8	0.6	3.3	1	1	1
12/27/2021 19:00	1.0	11.7	2,319.4	0.6	3.3	1	1	1
12/27/2021 20:00	1.0	11.7	2,325.3	0.6	3.3	1	1	1
12/27/2021 21:00	1.0	11.7	2,289.1	0.6	3.3	1	1	1
12/27/2021 22:00	1.1	12.6	2,102.6	0.7	3.7	1	1	1
12/27/2021 23:00	1.1	12.7	2,082.8	0.7	3.7	1	1	1
Average/Sum#:	1.0	12.6	2,035.9	0.7	78.4 #	24 #	24 #	19 #
Minimum:	0.5	11.6	1,517.7	0.5	1.6	1	1	0
Maximum:	1.3	13.8	2,334.5	0.9	4.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/28/2021 00:00	1.3	13.2	1,958.0	0.9	4.4	1	1	1
12/28/2021 01:00	0.6	13.8	1,536.4	0.8	1.7	1	1	0
12/28/2021 02:00	0.7	13.8	1,639.2	0.7	2.1	1	1	1
12/28/2021 03:00	1.3	13.2	1,986.0	0.7	4.4	1	1	1
12/28/2021 04:00	1.2	13.2	1,956.4	0.8	4.0	1	1	1
12/28/2021 05:00	0.7	13.8	1,581.9	0.8	2.1	1	1	0
12/28/2021 06:00	0.7	13.7	1,744.9	0.7	2.2	1	1	1
12/28/2021 07:00	1.3	13.1	2,000.1	0.7	4.4	1	1	1
12/28/2021 08:00	1.2	12.9	2,038.7	0.8	4.0	1	1	1
12/28/2021 09:00	1.2	12.9	2,012.1	0.9	4.0	1	1	1
12/28/2021 10:00	0.7	13.8	1,559.1	0.8	2.0	1	1	0
12/28/2021 11:00	0.8	13.8	1,446.4	0.7	2.2	1	1	0
12/28/2021 12:00	0.7	13.8	1,544.4	0.6	2.0	1	1	0
12/28/2021 13:00	1.2	13.4	1,881.2	0.7	4.0	1	1	1
12/28/2021 14:00	1.1	13.1	1,939.7	0.8	3.6	1	1	1
12/28/2021 15:00	0.7	13.7	1,694.4	0.8	2.2	1	1	1
12/28/2021 16:00	1.3	12.4	2,151.1	0.8	4.3	1	1	1
12/28/2021 17:00	1.1	11.6	2,329.9	0.7	3.6	1	1	1
12/28/2021 18:00	1.1	11.7	2,295.2	0.8	3.6	1	1	1
12/28/2021 19:00	1.2	12.2	2,209.8	0.7	4.0	1	1	1
12/28/2021 20:00	1.2	12.3	2,171.2	0.8	4.0	1	1	1
12/28/2021 21:00	1.2	12.5	2,125.6	0.8	4.0	1	1	1
12/28/2021 22:00	1.2	12.6	2,110.5	0.8	4.0	1	1	1
12/28/2021 23:00	1.1	12.8	2,053.5	0.8	3.7	1	1	1
Average/Sum#:	1.0	13.1	1,915.2	0.8	80.5 #	24 #	24 #	19 #
Minimum:	0.6	11.6	1,446.4	0.6	1.7	1	1	0
Maximum:	1.3	13.8	2,329.9	0.9	4.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/29/2021 00:00	1.2	13.1	1,960.9	0.9	4.0	1	1	1
12/29/2021 01:00	0.8	13.8	1,536.5	0.8	2.3	1	1	0
12/29/2021 02:00	0.8	13.7	1,606.1	0.8	2.4	1	1	1
12/29/2021 03:00	1.3	13.1	1,988.4	0.8	4.4	1	1	1
12/29/2021 04:00	1.3	13.1	1,974.4	0.9	4.3	1	1	1
12/29/2021 05:00	1.0	13.8	1,479.0	0.9	2.8	1	1	0
12/29/2021 06:00	0.6	13.7	1,781.0	0.8	2.0	1	1	1
12/29/2021 07:00	1.3	12.9	2,041.2	0.8	4.4	1	1	1
12/29/2021 08:00	1.2	13.0	2,009.2	0.8	4.0	1	1	1
12/29/2021 09:00	0.9	13.8	1,440.5	0.9	2.4	1	1	0
12/29/2021 10:00	0.8	13.7	1,651.0	0.8	2.4	1	1	1
12/29/2021 11:00	1.3	12.8	2,055.2	0.8	4.4	1	1	1
12/29/2021 12:00	1.2	13.2	1,960.8	0.8	4.0	1	1	1
12/29/2021 13:00	0.6	13.8	1,690.4	0.8	1.9	1	1	0
12/29/2021 14:00	0.6	13.8	1,699.6	0.6	1.9	1	1	1
12/29/2021 15:00	1.2	12.8	2,046.7	0.6	4.0	1	1	1
12/29/2021 16:00	1.2	12.5	2,126.0	0.7	4.0	1	1	1
12/29/2021 17:00	1.2	11.8	2,303.4	0.8	4.0	1	1	1
12/29/2021 18:00	1.1	11.8	2,298.1	0.8	3.7	1	1	1
12/29/2021 19:00	1.1	11.7	2,315.1	0.7	3.7	1	1	1
12/29/2021 20:00	1.1	11.7	2,315.6	0.7	3.7	1	1	1
12/29/2021 21:00	1.1	12.4	2,152.7	0.7	3.7	1	1	1
12/29/2021 22:00	1.2	13.0	2,015.8	0.8	4.0	1	1	1
12/29/2021 23:00	1.1	12.9	2,043.7	0.8	3.7	1	1	1
Average/Sum#:	1.1	13.0	1,937.1	0.8	82.1 #	24 #	24 #	20 #
Minimum:	0.6	11.7	1,440.5	0.6	1.9	1	1	0
Maximum:	1.3	13.8	2,315.6	0.9	4.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/30/2021 00:00	1.2	13.2	1,959.6	0.9	4.0	1	1	1
12/30/2021 01:00	0.5	13.8	1,665.7	0.7	1.5	1	1	0
12/30/2021 02:00	0.9	13.8	1,383.9	0.7	2.3	1	1	0
12/30/2021 03:00	0.5	13.8	1,773.2	0.5	1.6	1	1	0
12/30/2021 04:00	1.0	13.5	1,890.0	0.6	3.4	1	1	1
12/30/2021 05:00	1.0	13.4	1,861.3	0.7	3.3	1	1	1
12/30/2021 06:00	0.6	13.8	1,725.8	0.7	1.9	1	1	1
12/30/2021 07:00	1.4	12.9	2,067.7	0.8	4.8	1	1	1
12/30/2021 08:00	1.3	12.4	2,177.5	0.8	4.4	1	1	1
12/30/2021 09:00	1.2	12.7	2,063.6	0.9	4.0	1	1	1
12/30/2021 10:00	0.6	13.8	1,656.9	0.8	1.8	1	1	0
12/30/2021 11:00	0.7	13.8	1,692.9	0.7	2.2	1	1	1
12/30/2021 12:00	1.3	12.8	2,040.9	0.7	4.3	1	1	1
12/30/2021 13:00	1.2	13.2	1,935.5	0.8	4.0	1	1	1
12/30/2021 14:00	0.5	13.8	1,678.0	0.7	1.6	1	1	0
12/30/2021 15:00	0.7	13.8	1,635.1	0.6	2.1	1	1	1
12/30/2021 16:00	1.2	12.9	2,026.0	0.6	4.0	1	1	1
12/30/2021 17:00	1.3	12.3	2,158.0	0.8	4.3	1	1	1
12/30/2021 18:00	1.2	12.4	2,129.0	0.9	4.0	1	1	1
12/30/2021 19:00	1.2	12.9	2,030.1	0.9	4.0	1	1	1
12/30/2021 20:00	1.3	12.4	2,148.3	0.9	4.3	1	1	1
12/30/2021 21:00	1.2	12.4	2,130.5	0.9	4.0	1	1	1
12/30/2021 22:00	1.2	12.6	2,098.0	0.9	4.0	1	1	1
12/30/2021 23:00	1.1	12.8	2,057.9	0.8	3.7	1	1	1
Average/Sum#:	1.0	13.1	1,916.1	0.8	79.5 #	24 #	24 #	19 #
Minimum:	0.5	12.3	1,383.9	0.5	1.5	1	1	0
Maximum:	1.4	13.8	2,177.5	0.9	4.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT1 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
12/31/2021 00:00	1.2	13.1	1,952.2	0.9	4.0	1	1	1
12/31/2021 01:00	0.6	13.8	1,544.8	0.7	1.7	1	1	0
12/31/2021 02:00	0.9	13.9	1,351.7	0.7	2.3	1	1	0
12/31/2021 03:00	0.5	13.8	1,763.6	0.6	1.6	1	1	0
12/31/2021 04:00	0.9	13.5	1,876.1	0.6	3.0	1	1	1
12/31/2021 05:00	1.0	13.4	1,858.3	0.6	3.3	1	1	1
12/31/2021 06:00	0.8	13.8	1,447.5	0.7	2.2	1	1	1
12/31/2021 07:00	1.2	12.8	2,046.6	0.8	4.0	1	1	1
12/31/2021 08:00	1.2	12.8	2,055.5	0.8	4.0	1	1	1
12/31/2021 09:00	1.3	13.2	1,960.5	0.9	4.4	1	1	1
12/31/2021 10:00	0.7	13.8	1,515.5	0.8	2.0	1	1	0
12/31/2021 11:00	0.7	13.8	1,482.4	0.7	1.9	1	1	0
12/31/2021 12:00	0.6	13.8	1,610.8	0.6	1.8	1	1	0
12/31/2021 13:00	0.8	13.9	1,325.1	0.6	2.0	1	1	0
12/31/2021 14:00	0.7	13.9	1,466.8	0.6	1.9	1	1	0
12/31/2021 15:00	0.6	13.8	1,652.8	0.6	1.8	1	1	1
12/31/2021 16:00	1.3	12.6	2,081.9	0.7	4.3	1	1	1
12/31/2021 17:00	1.3	12.2	2,178.5	0.8	4.3	1	1	1
12/31/2021 18:00	1.2	12.2	2,174.3	0.9	4.0	1	1	1
12/31/2021 19:00	1.2	12.1	2,212.4	0.8	4.0	1	1	1
12/31/2021 20:00	1.2	12.5	2,108.3	0.8	4.0	1	1	1
12/31/2021 21:00	0.5	13.8	1,599.6	0.7	1.5	1	1	0
12/31/2021 22:00	0.5	13.8	1,797.9	0.5	1.7	1	1	1
12/31/2021 23:00	1.3	13.1	2,011.0	0.6	4.4	1	1	1
Average/Sum#:	0.9	13.3	1,794.8	0.7	70.1 #	24 #	24 #	15 #
Minimum:	0.5	12.1	1,325.1	0.5	1.5	1	1	0
Maximum:	1.3	13.9	2,212.4	0.9	4.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/01/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/01/2021 13:00	45.9	17.8	303.3	0.0	32.6	1	0	0
10/01/2021 14:00	17.8	15.2	960.0	0.0	39.6	1	0	0
10/01/2021 15:00	0.0	13.9	1,682.6	0.0	0.0	1	1	0
10/01/2021 16:00	0.0	13.8	1,663.3	0.0	0.0	1	1	0
10/01/2021 17:00	0.0	13.7	1,728.6	0.0	0.0	1	1	0
10/01/2021 18:00	0.0	13.7	1,722.5	0.0	0.0	1	1	0
10/01/2021 19:00	0.0	13.9	1,657.8	0.0	0.0	1	1	0
10/01/2021 20:00	0.0	13.9	1,641.4	0.0	0.0	1	1	0
10/01/2021 21:00	0.0	13.9	1,622.1	0.0	0.0	1	1	0
10/01/2021 22:00	0.0	14.0	1,638.2	0.0	0.0	1	1	0
10/01/2021 23:00	0.0	14.0	1,644.1	0.0	0.0	1	1	0
Average/Sum#:	5.8	14.3	1,478.5	0.0	72.2 #	11 #	9 #	0 #
Minimum:	0.0	13.7	303.3	0.0	0.0	0	0	0
Maximum:	45.9	17.8	1,728.6	0.0	39.6	1	1	0
%SI	54.17	54.17	54.17	70.83	54.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/02/2021 00:00	0.0	14.0	1,651.2	0.0	0.0	1	1	0
10/02/2021 01:00	0.0	14.0	1,639.5	0.0	0.0	1	1	0
10/02/2021 02:00	0.0	14.0	1,502.5	0.0	0.0	1	1	0
10/02/2021 03:00	0.0	14.0	1,623.4	0.0	0.0	1	1	0
10/02/2021 04:00	0.0	14.0	1,640.5	0.0	0.0	1	1	0
10/02/2021 05:00	0.0	14.0	1,634.3	0.0	0.0	1	1	0
10/02/2021 06:00	0.0	14.0	1,599.3	0.0	0.0	1	1	0
10/02/2021 07:00	0.0	14.0	1,433.8	0.0	0.0	1	1	0
10/02/2021 08:00	0.0	14.1	1,319.2	0.0	0.0	1	1	0
10/02/2021 09:00	0.0	14.1	1,285.9	0.0	0.0	1	1	0
10/02/2021 10:00	0.0	14.1	1,261.6	0.0	0.0	1	1	0
10/02/2021 11:00	0.0	14.1	1,261.8	0.0	0.0	1	1	0
10/02/2021 12:00	0.0	14.1	1,276.2	0.0	0.0	1	1	0
10/02/2021 13:00	0.0	14.1	1,342.6	0.0	0.0	1	1	0
10/02/2021 14:00	0.0	13.9	1,618.7	0.0	0.0	1	1	0
10/02/2021 15:00	0.0	13.9	1,660.3	0.0	0.0	1	1	0
10/02/2021 16:00	0.0	13.9	1,585.1	0.0	0.0	1	1	0
10/02/2021 17:00	0.0	13.7	1,704.2	0.0	0.0	1	1	0
10/02/2021 18:00	0.0	13.7	1,717.9	0.0	0.0	1	1	0
10/02/2021 19:00	0.0	13.9	1,654.7	0.0	0.0	1	1	0
10/02/2021 20:00	0.0	13.9	1,630.4	0.0	0.0	1	1	0
10/02/2021 21:00	0.0	13.9	1,648.0	0.0	0.0	1	1	0
10/02/2021 22:00	0.0	13.9	1,649.3	0.0	0.0	1	1	0
10/02/2021 23:00	0.0	13.9	1,643.2	0.0	0.0	1	1	0
Average/Sum#:	0.0	14.0	1,541.0	0.0	0.0 #	24 #	24 #	0 #
Minimum:	0.0	13.7	1,261.6	0.0	0.0	1	1	0
Maximum:	0.0	14.1	1,717.9	0.0	0.0	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/03/2021 00:00	0.0	14.0	1,593.1	0.0	0.0	1	1	0
10/03/2021 01:00	0.0	14.0	1,538.5	0.0	0.0	1	1	0
10/03/2021 02:00	0.0	14.0	1,418.9	0.0	0.0	1	1	0
10/03/2021 03:00	0.0	14.0	1,383.3	0.0	0.0	1	1	0
10/03/2021 04:00	0.0	14.0	1,435.6	0.0	0.0	1	1	0
10/03/2021 05:00	0.0	14.0	1,421.9	0.0	0.0	1	1	0
10/03/2021 06:00	0.0	14.0	1,425.6	0.0	0.0	1	1	0
10/03/2021 07:00	0.0	14.1	1,263.1	0.0	0.0	1	1	0
10/03/2021 08:00	0.0	14.0	1,326.2	0.0	0.0	1	1	0
10/03/2021 09:00	0.0	14.1	1,264.0	0.0	0.0	1	1	0
10/03/2021 10:00	0.0	14.1	1,266.8	0.0	0.0	1	1	0
10/03/2021 11:00	0.0	14.1	1,321.5	0.0	0.0	1	1	0
10/03/2021 12:00	0.0	14.1	1,384.6	0.0	0.0	1	1	0
10/03/2021 13:00	0.0	13.9	1,576.0	0.0	0.0	1	1	0
10/03/2021 14:00	0.0	13.9	1,648.0	0.0	0.0	1	1	0
10/03/2021 15:00	0.0	13.9	1,652.9	0.0	0.0	1	1	0
10/03/2021 16:00	0.0	13.9	1,570.0	0.0	0.0	1	1	0
10/03/2021 17:00	0.0	14.0	1,393.1	0.0	0.0	1	1	0
10/03/2021 18:00	0.0	13.8	1,702.2	0.0	0.0	1	1	0
10/03/2021 19:00	0.0	13.9	1,603.4	0.0	0.0	1	1	0
10/03/2021 20:00	0.0	13.9	1,639.6	0.0	0.0	1	1	0
10/03/2021 21:00	0.0	13.9	1,586.8	0.0	0.0	1	1	0
10/03/2021 22:00	0.0	13.9	1,628.4	0.0	0.0	1	1	0
10/03/2021 23:00	0.0	13.9	1,645.9	0.0	0.0	1	1	0
Average/Sum#:	0.0	14.0	1,487.1	0.0	0.0 #	24 #	24 #	0 #
Minimum:	0.0	13.8	1,263.1	0.0	0.0	1	1	0
Maximum:	0.0	14.1	1,702.2	0.0	0.0	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/04/2021 00:00	0.0	13.9	1,626.1	0.0	0.0	1	1	0
10/04/2021 01:00	0.0	13.9	1,502.3	0.0	0.0	1	1	0
10/04/2021 02:00	0.0	13.9	1,514.2	0.0	0.0	1	1	0
10/04/2021 03:00	0.0	13.9	1,578.6	0.0	0.0	1	1	0
10/04/2021 04:00	0.0	13.9	1,627.6	0.0	0.0	1	1	0
10/04/2021 05:00	0.0	13.9	1,642.0	0.0	0.0	1	1	0
10/04/2021 06:00	0.0	13.9	1,600.6	0.0	0.0	1	1	0
10/04/2021 07:00	0.0	14.0	1,567.1	0.0	0.0	1	1	0
10/04/2021 08:00	0.0	13.9	1,584.8	0.0	0.0	1	1	0
10/04/2021 09:00	0.0	14.0	1,566.7	0.0	0.0	1	1	0
10/04/2021 10:00	0.0	13.9	1,509.7	0.0	0.0	1	1	0
10/04/2021 11:00	0.0	13.9	1,599.5	0.0	0.0	1	1	0
10/04/2021 12:00	0.0	13.9	1,625.2	0.0	0.0	1	1	0
10/04/2021 13:00	0.0	13.9	1,580.6	0.0	0.0	1	1	0
10/04/2021 14:00	0.0	13.9	1,658.7	0.0	0.0	1	1	0
10/04/2021 15:00	0.0	13.9	1,595.5	0.0	0.0	1	1	0
10/04/2021 16:00	0.0	13.7	1,715.2	0.0	0.0	1	1	0
10/04/2021 17:00	0.0	13.7	1,721.5	0.0	0.0	1	1	0
10/04/2021 18:00	0.0	13.7	1,723.1	0.0	0.0	1	1	0
10/04/2021 19:00	0.0	13.8	1,703.6	0.0	0.0	1	1	0
10/04/2021 20:00	0.0	13.7	1,699.8	0.0	0.0	1	1	0
10/04/2021 21:00	0.0	13.8	1,696.6	0.0	0.0	1	1	0
10/04/2021 22:00	0.0	13.9	1,548.6	0.0	0.0	1	1	0
10/04/2021 23:00	0.0	14.0	1,560.2	0.0	0.0	1	1	0
Average/Sum#:	0.0	13.9	1,614.5	0.0	0.0 #	24 #	24 #	0 #
Minimum:	0.0	13.7	1,502.3	0.0	0.0	1	1	0
Maximum:	0.0	14.0	1,723.1	0.0	0.0	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/05/2021 00:00	0.0	14.0	1,530.4	0.0	0.0	1	1	0
10/05/2021 01:00	0.0	14.0	1,513.7	0.0	0.0	1	1	0
10/05/2021 02:00	0.0	14.0	1,499.5	0.0	0.0	1	1	0
10/05/2021 03:00	0.0	14.0	1,587.0	0.0	0.0	1	1	0
10/05/2021 04:00	0.0	14.0	1,543.8	0.0	0.0	1	1	0
10/05/2021 05:00	0.0	13.9	1,640.7	0.0	0.0	1	1	0
10/05/2021 06:00	0.0	13.9	1,647.6	0.0	0.0	1	1	0
10/05/2021 07:00	0.0	13.9	1,596.6	0.0	0.0	1	1	0
10/05/2021 08:00	0.0	13.9	1,563.3	0.0	0.0	1	1	0
10/05/2021 09:00	0.0	13.9	1,607.2	0.0	0.0	1	1	0
10/05/2021 10:00	0.0	13.9	1,621.3	0.0	0.0	1	1	0
10/05/2021 11:00	0.0	13.9	1,599.8	0.0	0.0	1	1	0
10/05/2021 12:00	0.0	13.9	1,666.5	0.0	0.0	1	1	0
10/05/2021 13:00	0.0	13.9	1,637.4	0.0	0.0	1	1	0
10/05/2021 14:00	0.0	14.0	1,592.9	0.0	0.0	1	1	0
10/05/2021 15:00	0.0	13.9	1,637.6	0.0	0.0	1	1	0
10/05/2021 16:00	0.0	13.9	1,636.2	0.0	0.0	1	1	0
10/05/2021 17:00	0.0	13.9	1,594.9	0.0	0.0	1	1	0
10/05/2021 18:00	0.0	13.9	1,587.4	0.0	0.0	1	1	0
10/05/2021 19:00	0.0	13.9	1,642.0	0.0	0.0	1	1	0
10/05/2021 20:00	0.0	13.9	1,553.5	0.0	0.0	1	1	0
10/05/2021 21:00	0.0	14.0	1,474.4	0.0	0.0	1	1	0
10/05/2021 22:00	0.0	14.0	1,598.7	0.0	0.0	1	1	0
10/05/2021 23:00	0.0	14.0	1,380.2	0.0	0.0	1	1	0
Average/Sum#:	0.0	13.9	1,581.4	0.0	0.0 #	24 #	24 #	0 #
Minimum:	0.0	13.9	1,380.2	0.0	0.0	1	1	0
Maximum:	0.0	14.0	1,666.5	0.0	0.0	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/06/2021 00:00	0.0	14.0	1,264.6	0.0	0.0	1	1	0
10/06/2021 01:00	0.0	14.0	1,264.8	0.0	0.0	1	1	0
10/06/2021 02:00	0.0	14.0	1,265.9	0.0	0.0	1	1	0
10/06/2021 03:00	0.0	14.0	1,266.5	0.0	0.0	1	1	0
10/06/2021 04:00	0.0	14.0	1,290.2	0.0	0.0	1	1	0
10/06/2021 05:00	0.0	13.9	1,499.2	0.0	0.0	1	1	0
10/06/2021 06:00	0.0	13.9	1,566.9	0.0	0.0	1	1	0
10/06/2021 07:00	0.0	13.9	1,532.6	0.0	0.0	1	1	0
10/06/2021 08:00	0.0	14.0	1,372.3	0.0	0.0	1	1	0
10/06/2021 09:00	0.0	13.9	1,553.5	0.0	0.0	1	1	0
10/06/2021 10:00	0.0	13.9	1,536.2	0.0	0.0	1	1	0
10/06/2021 11:00	0.0	13.9	1,476.4	0.0	0.0	1	1	0
10/06/2021 12:00	0.0	13.9	1,572.5	0.0	0.0	1	1	0
10/06/2021 13:00	0.0	13.9	1,602.3	0.0	0.0	1	1	0
10/06/2021 14:00	0.0	13.9	1,646.5	0.0	0.0	1	1	0
10/06/2021 15:00	0.0	13.9	1,631.3	0.0	0.0	1	1	0
10/06/2021 16:00	0.0	13.9	1,603.7	0.0	0.0	1	1	0
10/06/2021 17:00	0.0	14.0	1,362.3	0.0	0.0	1	1	0
10/06/2021 18:00	0.0	13.9	1,556.8	0.0	0.0	1	1	0
10/06/2021 19:00	0.0	13.9	1,586.2	0.0	0.0	1	1	0
10/06/2021 20:00	0.0	13.8	1,684.4	0.0	0.0	1	1	0
10/06/2021 21:00	0.0	13.9	1,603.1	0.0	0.0	1	1	0
10/06/2021 22:00	0.0	13.9	1,549.1	0.0	0.0	1	1	0
10/06/2021 23:00	0.0	13.9	1,651.3	0.0	0.0	1	1	0
Average/Sum#:	0.0	13.9	1,497.4	0.0	0.0 #	24 #	24 #	0 #
Minimum:	0.0	13.8	1,264.6	0.0	0.0	1	1	0
Maximum:	0.0	14.0	1,684.4	0.0	0.0	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/07/2021 00:00	0.0	13.9	1,516.4	0.0	0.0	1	1	0
10/07/2021 01:00	0.0	13.9	1,518.1	0.0	0.0	1	1	0
10/07/2021 02:00	0.0	13.9	1,511.9	0.0	0.0	1	1	0
10/07/2021 03:00	0.0	14.0	1,437.1	0.0	0.0	1	1	0
10/07/2021 04:00	0.0	13.9	1,622.6	0.0	0.0	1	1	0
10/07/2021 05:00	0.0	13.9	1,606.6	0.0	0.0	1	1	0
10/07/2021 06:00	0.0	13.9	1,655.9	0.0	0.0	1	1	0
10/07/2021 07:00	0.0	13.9	1,598.4	0.0	0.0	1	1	0
10/07/2021 08:00	0.0	13.9	1,588.1	0.0	0.0	1	1	0
10/07/2021 09:00	0.0	13.9	1,511.8	0.0	0.0	1	1	0
10/07/2021 10:00	0.0	14.0	1,492.8	0.0	0.0	1	1	0
10/07/2021 11:00	0.0	14.0	1,508.2	0.0	0.0	1	1	0
10/07/2021 12:00	0.0	14.0	1,511.2	0.0	0.0	1	1	0
10/07/2021 13:00	0.0	14.0	1,510.6	0.0	0.0	1	1	0
10/07/2021 14:00	0.0	13.9	1,646.1	0.0	0.0	1	1	0
10/07/2021 15:00	0.0	13.9	1,631.2	0.0	0.0	1	1	0
10/07/2021 16:00	0.0	13.9	1,662.5	0.0	0.0	1	1	0
10/07/2021 17:00	0.0	13.7	1,758.1	0.0	0.0	1	1	0
10/07/2021 18:00	0.0	13.8	1,713.2	0.0	0.0	1	1	0
10/07/2021 19:00	0.0	13.9	1,613.7	0.0	0.0	1	1	0
10/07/2021 20:00	0.0	13.8	1,596.7	0.0	0.0	1	1	0
10/07/2021 21:00	0.0	13.9	1,631.6	0.0	0.0	1	1	0
10/07/2021 22:00	0.0	13.9	1,643.1	0.0	0.0	1	1	0
10/07/2021 23:00	0.0	14.0	1,560.8	0.0	0.0	1	1	0
Average/Sum#:	0.0	13.9	1,585.3	0.0	0.0 #	24 #	24 #	0 #
Minimum:	0.0	13.7	1,437.1	0.0	0.0	1	1	0
Maximum:	0.0	14.0	1,758.1	0.0	0.0	1	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/08/2021 00:00	0.0	14.0	1,480.0	0.0	0.0	1	1	0
10/08/2021 01:00	0.0	13.9	1,467.1	0.0	0.0	1	1	0
10/08/2021 02:00	0.0	13.9	1,498.1	0.0	0.0	1	1	0
10/08/2021 03:00	0.0	13.9	1,550.9	0.0	0.0	1	1	0
10/08/2021 04:00	0.0	13.9	1,627.0	0.0	0.0	1	1	0
10/08/2021 05:00	0.0	13.9	1,523.2	0.0	0.0	1	1	0
10/08/2021 06:00	0.0	13.9	1,619.0	0.0	0.0	1	1	0
10/08/2021 07:00	0.0	13.9	1,504.9	0.0	0.0	1	1	0
10/08/2021 08:00	0.0	13.9	1,513.8	0.0	0.0	1	1	0
10/08/2021 09:00	0.0	14.0	1,365.0	0.0	0.0	1	1	0
10/08/2021 10:00	0.0	13.9	1,621.7	0.0	0.0	1	1	0
10/08/2021 11:00	0.0	14.0	1,434.4	0.0	0.0	1	1	0
10/08/2021 12:00	0.0	14.0	1,568.8	0.0	0.0	1	1	0
10/08/2021 13:00	0.0	14.0	1,536.6	0.0	0.0	1	1	0
10/08/2021 14:00	0.0	14.0	1,503.6	0.0	0.0	1	1	0
10/08/2021 15:00	0.0	14.0	1,583.3	0.0	0.0	1	1	0
10/08/2021 16:00	0.0	14.0	1,643.4	0.0	0.0	1	1	0
10/08/2021 17:00	0.0	14.0	1,567.2	0.0	0.0	1	1	0
10/08/2021 18:00	0.0	14.0	1,582.3	0.0	0.0	1	1	0
10/08/2021 19:00	0.0	14.0	1,609.4	0.0	0.0	1	1	0
10/08/2021 20:00	0.0	14.0	1,352.2	0.0	0.0	1	1	0
10/08/2021 21:00	21.0	16.3	409.7	0.0	4.9	1	0	0
10/08/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/08/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	1.0	14.1	1,480.1	0.0	4.9 #	22 #	21 #	0 #
Minimum:	0.0	13.9	409.7	0.0	0.0	0	0	0
Maximum:	21.0	16.3	1,643.4	0.0	4.9	1	1	0
%SI	8.33	8.33	8.33	12.50	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/09/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/09/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/10/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/10/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/11/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/11/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/12/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/12/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/13/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/13/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/14/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/14/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/15/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/15/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/16/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/16/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/17/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/17/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/18/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/18/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/19/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/19/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/20/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/20/2021 08:00	141.6	18.5	205.9	0.0	40.1	1	0	0
10/20/2021 09:00	38.9	17.3	375.6	0.0	53.6	1	0	0
10/20/2021 10:00	15.6	17.3	399.4	0.0	22.9	1	0	0
10/20/2021 11:00	58.2	16.9	654.5	0.0	125.8	1	0	0
10/20/2021 12:00	28.1	15.0	1,078.8	0.0	67.9	1	0	0
10/20/2021 13:00	0.0	14.0	1,338.5	0.0	0.0	1	1	0
10/20/2021 14:00	0.0	14.0	1,269.5	0.0	0.0	1	1	0
10/20/2021 15:00	0.0	13.9	1,458.2	0.0	0.0	1	1	1
10/20/2021 16:00	0.0	12.9	1,805.5	0.0	0.0	1	1	1
10/20/2021 17:00	0.0	13.8	1,648.0	0.0	0.0	1	1	1
10/20/2021 18:00	1.1	13.0	1,943.6	0.3	3.6	1	1	1
10/20/2021 19:00	0.7	12.9	1,984.1	0.4	2.3	1	1	1
10/20/2021 20:00	0.0	12.3	2,110.9	0.4	0.0	1	1	1
10/20/2021 21:00	0.0	12.4	2,049.9	0.2	0.0	1	1	1
10/20/2021 22:00	16.2	15.6	632.2	0.0	5.9	1	0	0
10/20/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	20.0	14.7	1,263.6	0.2	322.1 #	15 #	9 #	7 #
Minimum:	0.0	12.3	205.9	0.0	0.0	0	0	0
Maximum:	141.6	18.5	2,110.9	0.4	125.8	1	1	1
%SI	37.50	37.50	37.50	70.83	37.50	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/21/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/21/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/22/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/22/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/23/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/23/2021 05:00	53.0	20.7	0.2	0.0	0.1	1	0	0
10/23/2021 06:00	60.2	17.3	372.8	0.0	82.3	1	0	0
10/23/2021 07:00	13.2	14.5	1,275.2	0.0	34.7	1	0	0
10/23/2021 08:00	0.0	13.9	1,613.3	0.0	0.0	1	1	0
10/23/2021 09:00	0.0	14.0	1,371.1	0.0	0.0	1	1	0
10/23/2021 10:00	0.0	13.9	1,566.5	0.0	0.0	1	1	0
10/23/2021 11:00	0.0	13.9	1,539.5	0.0	0.0	1	1	0
10/23/2021 12:00	0.0	13.9	1,583.1	0.0	0.0	1	1	0
10/23/2021 13:00	0.0	13.9	1,546.6	0.0	0.0	1	1	0
10/23/2021 14:00	0.0	13.9	1,628.0	0.0	0.0	1	1	0
10/23/2021 15:00	0.0	13.9	1,602.6	0.0	0.0	1	1	0
10/23/2021 16:00	0.0	13.8	1,632.6	0.0	0.0	1	1	0
10/23/2021 17:00	0.5	13.0	1,930.3	0.1	1.6	1	1	1
10/23/2021 18:00	0.0	12.7	2,002.8	0.1	0.0	1	1	1
10/23/2021 19:00	0.0	13.8	1,617.2	0.1	0.0	1	1	1
10/23/2021 20:00	0.0	13.8	1,642.8	0.0	0.0	1	1	1
10/23/2021 21:00	0.3	12.8	1,981.3	0.1	1.0	1	1	1
10/23/2021 22:00	4.9	13.8	1,440.9	0.0	9.6	1	0	1
10/23/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	7.3	14.3	1,463.7	0.0	129.3 #	18 #	14 #	6 #
Minimum:	0.0	12.7	0.2	0.0	0.0	0	0	0
Maximum:	60.2	20.7	2,002.8	0.1	82.3	1	1	1
%SI	25.00	25.00	25.00	50.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/24/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/24/2021 03:00	10.0	18.8	181.9	0.0	2.1	1	0	0
10/24/2021 04:00	38.2	15.4	891.2	0.0	81.7	1	0	0
10/24/2021 05:00	0.0	13.9	1,393.2	0.0	0.0	1	1	0
10/24/2021 06:00	0.0	13.9	1,377.8	0.0	0.0	1	1	0
10/24/2021 07:00	0.0	13.8	1,699.4	0.0	0.0	1	1	0
10/24/2021 08:00	0.0	13.9	1,543.6	0.0	0.0	1	1	0
10/24/2021 09:00	0.0	13.9	1,536.6	0.0	0.0	1	1	0
10/24/2021 10:00	0.0	13.9	1,547.9	0.0	0.0	1	1	0
10/24/2021 11:00	0.0	13.9	1,528.4	0.0	0.0	1	1	0
10/24/2021 12:00	0.0	13.9	1,583.9	0.0	0.0	1	1	0
10/24/2021 13:00	0.0	13.9	1,484.3	0.0	0.0	1	1	0
10/24/2021 14:00	0.0	13.9	1,601.0	0.0	0.0	1	1	0
10/24/2021 15:00	0.0	13.9	1,623.8	0.0	0.0	1	1	0
10/24/2021 16:00	0.0	13.7	1,719.8	0.0	0.0	1	1	0
10/24/2021 17:00	0.0	12.9	1,918.2	0.0	0.0	1	1	1
10/24/2021 18:00	0.0	12.6	1,979.4	0.0	0.0	1	1	1
10/24/2021 19:00	0.0	13.9	1,656.6	0.0	0.0	1	1	0
10/24/2021 20:00	0.0	13.9	1,691.3	0.0	0.0	1	1	1
10/24/2021 21:00	0.0	12.7	1,979.6	0.0	0.0	1	1	1
10/24/2021 22:00	0.0	13.3	1,645.0	0.0	0.0	1	1	1
10/24/2021 23:00	10.5	15.0	872.1	0.0	7.8	1	0	0
Average/Sum#:	2.8	14.0	1,497.9	0.0	91.6 #	21 #	18 #	5 #
Minimum:	0.0	12.6	181.9	0.0	0.0	0	0	0
Maximum:	38.2	18.8	1,979.6	0.0	81.7	1	1	1
%SI	12.50	12.50	12.50	33.33	12.50	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/25/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/25/2021 05:00	26.3	17.6	400.9	0.0	22.4	1	0	0
10/25/2021 06:00	15.3	14.3	1,388.9	0.0	42.5	1	0	0
10/25/2021 07:00	0.0	13.8	1,749.2	0.0	0.0	1	1	0
10/25/2021 08:00	0.0	13.9	1,651.9	0.0	0.0	1	1	0
10/25/2021 09:00	0.0	13.8	1,760.8	0.0	0.0	1	1	1
10/25/2021 10:00	0.2	13.0	1,959.7	0.0	0.7	1	1	1
10/25/2021 11:00	0.1	12.9	1,984.8	0.1	0.3	1	1	1
10/25/2021 12:00	0.5	13.1	1,911.0	0.2	1.6	1	1	1
10/25/2021 13:00	0.0	13.9	1,606.7	0.2	0.0	1	1	0
10/25/2021 14:00	0.0	14.0	1,524.7	0.1	0.0	1	1	0
10/25/2021 15:00	0.0	13.9	1,541.9	0.0	0.0	1	1	1
10/25/2021 16:00	0.2	12.7	2,029.1	0.0	0.7	1	1	1
10/25/2021 17:00	0.0	12.6	2,061.3	0.0	0.0	1	1	1
10/25/2021 18:00	0.1	12.7	2,027.3	0.1	0.3	1	1	1
10/25/2021 19:00	0.3	13.8	1,624.4	0.1	0.9	1	1	1
10/25/2021 20:00	0.3	14.0	1,465.6	0.2	0.8	1	1	0
10/25/2021 21:00	0.4	13.2	1,906.0	0.3	1.3	1	1	1
10/25/2021 22:00	0.0	13.6	1,666.5	0.2	0.0	1	1	1
10/25/2021 23:00	8.9	15.0	860.1	0.0	6.5	1	0	0
Average/Sum#:	2.8	13.8	1,637.9	0.1	78.0 #	19 #	16 #	11 #
Minimum:	0.0	12.6	400.9	0.0	0.0	0	0	0
Maximum:	26.3	17.6	2,061.3	0.3	42.5	1	1	1
%SI	20.83	20.83	20.83	41.67	20.83	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/26/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/26/2021 05:00	23.5	17.8	384.5	0.0	19.3	1	0	0
10/26/2021 06:00	19.8	14.5	1,216.6	0.0	49.7	1	0	0
10/26/2021 07:00	0.0	13.9	1,580.4	0.0	0.0	1	1	0
10/26/2021 08:00	0.0	13.9	1,573.4	0.0	0.0	1	1	0
10/26/2021 09:00	0.0	13.9	1,564.2	0.0	0.0	1	1	1
10/26/2021 10:00	0.0	12.8	1,991.0	0.0	0.0	1	1	1
10/26/2021 11:00	0.0	0.0	1,906.4	0.0	0.0	1	1	1
10/26/2021 12:00	0.0	13.9	1,652.4	0.0	0.0	1	1	0
10/26/2021 13:00	0.0	14.0	1,448.0	0.0	0.0	1	1	0
10/26/2021 14:00	0.0	14.0	1,428.8	0.0	0.0	1	1	0
10/26/2021 15:00	0.0	13.9	1,546.6	0.0	0.0	1	1	1
10/26/2021 16:00	0.0	12.9	1,982.6	0.0	0.0	1	1	1
10/26/2021 17:00	0.0	12.6	2,054.0	0.0	0.0	1	1	1
10/26/2021 18:00	0.0	12.8	2,025.3	0.0	0.0	1	1	1
10/26/2021 19:00	0.0	12.9	1,982.3	0.0	0.0	1	1	1
10/26/2021 20:00	0.0	13.9	1,554.0	0.0	0.0	1	1	0
10/26/2021 21:00	0.0	13.8	1,762.8	0.0	0.0	1	1	1
10/26/2021 22:00	0.1	12.8	2,005.1	0.0	0.3	1	1	1
10/26/2021 23:00	0.2	12.9	1,959.9	0.1	0.6	1	1	1
Average/Sum#:	2.4	13.7	1,664.1	0.0	69.9 #	19 #	17 #	11 #
Minimum:	0.0	12.6	384.5	0.0	0.0	0	0	0
Maximum:	23.5	17.8	2,054.0	0.1	49.7	1	1	1
%SI	25.00	25.00	20.83	50.00	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/27/2021 00:00	0.0	13.9	1,536.6	0.1	0.0	1	1	0
10/27/2021 01:00	0.0	13.9	1,562.4	0.0	0.0	1	1	1
10/27/2021 02:00	0.2	13.3	1,916.3	0.1	0.7	1	1	1
10/27/2021 03:00	0.2	13.3	1,890.7	0.1	0.7	1	1	1
10/27/2021 04:00	0.0	13.9	1,569.8	0.1	0.0	1	1	0
10/27/2021 05:00	0.0	13.9	1,589.1	0.1	0.0	1	1	1
10/27/2021 06:00	0.2	13.1	1,930.4	0.1	0.7	1	1	1
10/27/2021 07:00	0.0	13.0	1,955.1	0.1	0.0	1	1	1
10/27/2021 08:00	0.1	13.2	1,919.1	0.1	0.3	1	1	1
10/27/2021 09:00	0.0	13.9	1,465.3	0.0	0.0	1	1	1
10/27/2021 10:00	0.0	14.0	1,422.4	0.0	0.0	1	1	0
10/27/2021 11:00	0.0	13.9	1,571.3	0.0	0.0	1	1	0
10/27/2021 12:00	0.0	14.0	1,308.4	0.0	0.0	1	1	0
10/27/2021 13:00	0.0	14.0	1,453.4	0.0	0.0	1	1	0
10/27/2021 14:00	0.0	13.4	1,802.6	0.0	0.0	1	1	1
10/27/2021 15:00	0.0	13.0	1,853.8	0.0	0.0	1	1	1
10/27/2021 16:00	0.0	13.9	1,674.7	0.0	0.0	1	1	1
10/27/2021 17:00	0.0	13.0	1,929.1	0.0	0.0	1	1	1
10/27/2021 18:00	0.0	12.5	2,057.9	0.0	0.0	1	1	1
10/27/2021 19:00	0.0	12.3	2,098.0	0.0	0.0	1	1	1
10/27/2021 20:00	0.0	12.4	2,061.7	0.0	0.0	1	1	1
10/27/2021 21:00	0.0	12.4	2,070.4	0.0	0.0	1	1	1
10/27/2021 22:00	0.0	12.7	1,983.7	0.0	0.0	1	1	1
10/27/2021 23:00	0.0	13.3	1,801.4	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.3	1,767.7	0.0	2.4 #	24 #	24 #	18 #
Minimum:	0.0	12.3	1,308.4	0.0	0.0	1	1	0
Maximum:	0.2	14.0	2,098.0	0.1	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/28/2021 00:00	4.3	14.5	1,106.1	0.0	9.0	1	0	0
10/28/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
10/28/2021 12:00	31.5	18.1	281.5	0.0	15.9	1	0	0
10/28/2021 13:00	23.8	15.2	941.9	0.0	51.9	1	0	0
10/28/2021 14:00	0.0	14.0	1,503.4	0.0	0.0	1	1	0
10/28/2021 15:00	0.0	13.9	1,533.4	0.0	0.0	1	1	1
10/28/2021 16:00	0.0	12.5	2,006.9	0.0	0.0	1	1	1
10/28/2021 17:00	0.0	12.0	2,130.0	0.0	0.0	1	1	1
10/28/2021 18:00	0.0	12.1	2,121.2	0.0	0.0	1	1	1
10/28/2021 19:00	0.0	12.0	2,127.8	0.0	0.0	1	1	1
10/28/2021 20:00	0.0	12.2	2,101.6	0.0	0.0	1	1	1
10/28/2021 21:00	0.0	12.5	2,037.7	0.0	0.0	1	1	1
10/28/2021 22:00	0.0	12.6	2,013.5	0.0	0.0	1	1	1
10/28/2021 23:00	0.0	12.8	1,954.1	0.0	0.0	1	1	1
Average/Sum#:	4.6	13.4	1,681.5	0.0	76.8 #	13 #	10 #	9 #
Minimum:	0.0	12.0	281.5	0.0	0.0	0	0	0
Maximum:	31.5	18.1	2,130.0	0.0	51.9	1	1	1
%SI	45.83	45.83	45.83	66.67	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/29/2021 00:00	0.5	13.2	1,899.0	0.1	1.6	1	1	1
10/29/2021 01:00	0.7	13.2	1,903.3	0.3	2.3	1	1	1
10/29/2021 02:00	0.7	13.2	1,896.5	0.5	2.3	1	1	1
10/29/2021 03:00	0.7	13.2	1,895.9	0.5	2.3	1	1	1
10/29/2021 04:00	0.8	13.2	1,896.0	0.5	2.6	1	1	1
10/29/2021 05:00	0.9	13.2	1,898.2	0.6	2.9	1	1	1
10/29/2021 06:00	1.0	13.2	1,900.8	0.7	3.3	1	1	1
10/29/2021 07:00	0.9	13.2	1,898.4	0.7	2.9	1	1	1
10/29/2021 08:00	0.8	13.2	1,897.8	0.7	2.6	1	1	1
10/29/2021 09:00	0.2	13.3	1,705.9	0.5	0.6	1	1	1
10/29/2021 10:00	0.0	13.8	1,410.3	0.3	0.0	1	1	1
10/29/2021 11:00	0.0	13.0	1,915.2	0.1	0.0	1	1	1
10/29/2021 12:00	0.0	13.2	1,708.9	0.0	0.0	1	1	1
10/29/2021 13:00	0.0	13.8	1,404.1	0.0	0.0	1	1	1
10/29/2021 14:00	0.0	12.8	1,922.5	0.0	0.0	1	1	1
10/29/2021 15:00	0.0	12.8	1,923.0	0.0	0.0	1	1	1
10/29/2021 16:00	0.0	12.9	1,920.3	0.0	0.0	1	1	1
10/29/2021 17:00	0.0	12.9	1,917.5	0.0	0.0	1	1	1
10/29/2021 18:00	0.0	12.9	1,914.0	0.0	0.0	1	1	1
10/29/2021 19:00	0.0	12.9	1,912.5	0.0	0.0	1	1	1
10/29/2021 20:00	0.0	12.9	1,911.0	0.0	0.0	1	1	1
10/29/2021 21:00	0.0	13.0	1,909.3	0.0	0.0	1	1	1
10/29/2021 22:00	0.1	13.0	1,903.6	0.0	0.3	1	1	1
10/29/2021 23:00	0.0	12.7	1,964.6	0.0	0.0	1	1	1
Average/Sum#:	0.3	13.1	1,851.2	0.2	23.7 #	24 #	24 #	24 #
Minimum:	0.0	12.7	1,404.1	0.0	0.0	1	1	1
Maximum:	1.0	13.8	1,964.6	0.7	3.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/30/2021 00:00	0.0	13.8	1,631.0	0.0	0.0	1	1	1
10/30/2021 01:00	0.0	13.9	1,445.3	0.0	0.0	1	1	0
10/30/2021 02:00	0.0	13.3	1,739.8	0.0	0.0	1	1	1
10/30/2021 03:00	0.3	13.1	1,891.1	0.1	1.0	1	1	1
10/30/2021 04:00	0.0	13.9	1,600.7	0.1	0.0	1	1	0
10/30/2021 05:00	0.0	13.8	1,664.5	0.1	0.0	1	1	1
10/30/2021 06:00	0.3	12.8	1,977.2	0.1	1.0	1	1	1
10/30/2021 07:00	0.5	13.1	1,904.1	0.2	1.6	1	1	1
10/30/2021 08:00	0.0	13.9	1,508.7	0.2	0.0	1	1	0
10/30/2021 09:00	0.0	13.9	1,506.0	0.1	0.0	1	1	0
10/30/2021 10:00	0.0	13.9	1,513.5	0.0	0.0	1	1	0
10/30/2021 11:00	0.0	13.9	1,555.7	0.0	0.0	1	1	0
10/30/2021 12:00	0.0	14.0	1,374.2	0.0	0.0	1	1	0
10/30/2021 13:00	0.0	14.0	1,385.3	0.0	0.0	1	1	0
10/30/2021 14:00	0.0	14.0	1,502.2	0.0	0.0	1	1	0
10/30/2021 15:00	0.0	13.9	1,582.2	0.0	0.0	1	1	1
10/30/2021 16:00	0.1	12.7	1,999.1	0.0	0.3	1	1	1
10/30/2021 17:00	0.0	12.4	2,059.0	0.0	0.0	1	1	1
10/30/2021 18:00	0.0	12.6	2,035.9	0.0	0.0	1	1	1
10/30/2021 19:00	0.1	12.8	1,971.6	0.0	0.3	1	1	1
10/30/2021 20:00	0.0	13.9	1,647.4	0.0	0.0	1	1	0
10/30/2021 21:00	0.0	13.9	1,615.0	0.0	0.0	1	1	1
10/30/2021 22:00	0.2	12.9	1,967.5	0.0	0.6	1	1	1
10/30/2021 23:00	0.4	13.2	1,904.1	0.1	1.3	1	1	1
Average/Sum#:	0.1	13.5	1,707.5	0.0	6.1 #	24 #	24 #	14 #
Minimum:	0.0	12.4	1,374.2	0.0	0.0	1	1	0
Maximum:	0.5	14.0	2,059.0	0.2	1.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
10/31/2021 00:00	0.0	13.9	1,635.0	0.1	0.0	1	1	0
10/31/2021 01:00	0.0	13.9	1,544.4	0.1	0.0	1	1	1
10/31/2021 02:00	1.1	13.2	1,920.3	0.3	3.6	1	1	1
10/31/2021 03:00	0.6	13.2	1,904.6	0.4	2.0	1	1	1
10/31/2021 04:00	0.0	13.9	1,665.6	0.4	0.0	1	1	0
10/31/2021 05:00	0.0	13.9	1,535.1	0.2	0.0	1	1	1
10/31/2021 06:00	0.1	12.9	1,989.0	0.0	0.3	1	1	1
10/31/2021 07:00	0.4	13.2	1,904.0	0.1	1.3	1	1	1
10/31/2021 08:00	0.0	13.9	1,622.9	0.1	0.0	1	1	0
10/31/2021 09:00	0.0	13.9	1,560.0	0.1	0.0	1	1	0
10/31/2021 10:00	0.0	14.0	1,385.0	0.0	0.0	1	1	0
10/31/2021 11:00	0.0	13.9	1,525.8	0.0	0.0	1	1	0
10/31/2021 12:00	0.0	13.9	1,573.1	0.0	0.0	1	1	0
10/31/2021 13:00	0.0	13.9	1,655.3	0.0	0.0	1	1	0
10/31/2021 14:00	0.0	14.0	1,537.8	0.0	0.0	1	1	0
10/31/2021 15:00	0.0	13.9	1,575.6	0.0	0.0	1	1	1
10/31/2021 16:00	0.0	13.0	1,960.3	0.0	0.0	1	1	1
10/31/2021 17:00	0.0	12.8	2,002.8	0.0	0.0	1	1	1
10/31/2021 18:00	0.0	12.8	2,011.6	0.0	0.0	1	1	1
10/31/2021 19:00	0.0	13.1	1,912.1	0.0	0.0	1	1	1
10/31/2021 20:00	0.0	13.9	1,666.5	0.0	0.0	1	1	0
10/31/2021 21:00	0.0	13.9	1,549.5	0.0	0.0	1	1	1
10/31/2021 22:00	0.1	12.9	1,964.6	0.0	0.3	1	1	1
10/31/2021 23:00	0.3	13.1	1,903.5	0.1	1.0	1	1	1
Average/Sum#:	0.1	13.5	1,729.4	0.1	8.5 #	24 #	24 #	14 #
Minimum:	0.0	12.8	1,385.0	0.0	0.0	1	1	0
Maximum:	1.1	14.0	2,011.6	0.4	3.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/01/2021 00:00	0.0	13.9	1,599.7	0.1	0.0	1	1	0
11/01/2021 01:00	0.0	13.8	1,658.0	0.1	0.0	1	1	1
11/01/2021 02:00	0.7	13.2	1,905.2	0.2	2.3	1	1	1
11/01/2021 03:00	0.1	12.9	1,959.2	0.2	0.3	1	1	1
11/01/2021 04:00	0.0	13.9	1,572.7	0.2	0.0	1	1	1
11/01/2021 05:00	0.0	13.8	1,659.3	0.0	0.0	1	1	1
11/01/2021 06:00	0.1	12.7	2,012.0	0.0	0.3	1	1	1
11/01/2021 07:00	0.0	12.5	2,060.9	0.0	0.0	1	1	1
11/01/2021 08:00	0.2	13.0	1,925.5	0.1	0.6	1	1	1
11/01/2021 09:00	0.0	13.9	1,547.0	0.0	0.0	1	1	0
11/01/2021 10:00	0.0	13.9	1,501.1	0.0	0.0	1	1	1
11/01/2021 11:00	0.0	12.8	1,991.3	0.0	0.0	1	1	1
11/01/2021 12:00	0.0	12.7	1,983.5	0.0	0.0	1	1	1
11/01/2021 13:00	0.0	13.9	1,680.6	0.0	0.0	1	1	0
11/01/2021 14:00	0.0	13.7	1,758.6	0.0	0.0	1	1	0
11/01/2021 15:00	0.1	12.8	1,980.0	0.0	0.3	1	1	1
11/01/2021 16:00	0.0	12.7	2,020.2	0.0	0.0	1	1	1
11/01/2021 17:00	0.0	12.2	2,129.7	0.0	0.0	1	1	1
11/01/2021 18:00	0.0	12.3	2,097.3	0.0	0.0	1	1	1
11/01/2021 19:00	0.0	12.2	2,125.2	0.0	0.0	1	1	1
11/01/2021 20:00	0.0	12.2	2,139.6	0.0	0.0	1	1	1
11/01/2021 21:00	0.0	12.2	2,128.1	0.0	0.0	1	1	1
11/01/2021 22:00	0.0	12.6	2,040.1	0.0	0.0	1	1	1
11/01/2021 23:00	0.5	13.2	1,893.4	0.1	1.6	1	1	1
Average/Sum#:	0.1	13.0	1,890.3	0.0	5.4 #	24 #	24 #	20 #
Minimum:	0.0	12.2	1,501.1	0.0	0.0	1	1	0
Maximum:	0.7	13.9	2,139.6	0.2	2.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/02/2021 00:00	0.0	13.9	1,534.0	0.1	0.0	1	1	0
11/02/2021 01:00	0.0	13.9	1,557.3	0.1	0.0	1	1	0
11/02/2021 02:00	0.7	13.2	1,923.9	0.2	2.3	1	1	1
11/02/2021 03:00	0.7	13.1	1,919.3	0.3	2.3	1	1	1
11/02/2021 04:00	0.0	13.8	1,623.3	0.3	0.0	1	1	1
11/02/2021 05:00	0.0	13.9	1,605.1	0.2	0.0	1	1	1
11/02/2021 06:00	0.1	12.8	2,010.9	0.0	0.3	1	1	1
11/02/2021 07:00	0.0	12.8	2,011.2	0.0	0.0	1	1	1
11/02/2021 08:00	0.3	13.2	1,910.7	0.1	1.0	1	1	1
11/02/2021 09:00	0.0	13.9	1,500.3	0.1	0.0	1	1	0
11/02/2021 10:00	0.0	13.9	1,605.1	0.1	0.0	1	1	0
11/02/2021 11:00	0.0	14.0	1,301.3	0.0	0.0	1	1	0
11/02/2021 12:00	0.0	14.0	1,496.6	0.0	0.0	1	1	0
11/02/2021 13:00	0.0	13.9	1,597.3	0.0	0.0	1	1	0
11/02/2021 14:00	0.0	14.0	1,583.7	0.0	0.0	1	1	0
11/02/2021 15:00	0.0	13.9	1,610.2	0.0	0.0	1	1	1
11/02/2021 16:00	0.1	12.7	2,000.1	0.0	0.3	1	1	1
11/02/2021 17:00	0.0	12.3	2,109.6	0.0	0.0	1	1	1
11/02/2021 18:00	0.0	12.3	2,105.5	0.0	0.0	1	1	1
11/02/2021 19:00	0.0	12.1	2,173.6	0.0	0.0	1	1	1
11/02/2021 20:00	0.0	12.3	2,111.5	0.0	0.0	1	1	1
11/02/2021 21:00	0.0	12.4	2,093.2	0.0	0.0	1	1	1
11/02/2021 22:00	0.0	12.5	2,076.7	0.0	0.0	1	1	1
11/02/2021 23:00	0.6	13.0	1,931.8	0.1	1.9	1	1	1
Average/Sum#:	0.1	13.2	1,808.0	0.1	8.1 #	24 #	24 #	16 #
Minimum:	0.0	12.1	1,301.3	0.0	0.0	1	1	0
Maximum:	0.7	14.0	2,173.6	0.3	2.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/03/2021 00:00	0.0	13.9	1,667.3	0.1	0.0	1	1	0
11/03/2021 01:00	0.0	13.8	1,613.3	0.1	0.0	1	1	1
11/03/2021 02:00	1.0	13.2	1,905.7	0.3	3.3	1	1	1
11/03/2021 03:00	1.0	13.2	1,906.7	0.5	3.3	1	1	1
11/03/2021 04:00	0.0	13.9	1,638.8	0.5	0.0	1	1	1
11/03/2021 05:00	0.0	13.8	1,759.8	0.3	0.0	1	1	1
11/03/2021 06:00	0.5	13.0	1,959.8	0.1	1.6	1	1	1
11/03/2021 07:00	0.5	13.1	1,944.7	0.3	1.6	1	1	1
11/03/2021 08:00	0.0	13.8	1,649.3	0.3	0.0	1	1	1
11/03/2021 09:00	0.0	13.9	1,661.6	0.1	0.0	1	1	0
11/03/2021 10:00	0.0	13.9	1,552.3	0.0	0.0	1	1	0
11/03/2021 11:00	0.0	13.9	1,662.2	0.0	0.0	1	1	0
11/03/2021 12:00	0.0	14.0	1,507.5	0.0	0.0	1	1	0
11/03/2021 13:00	0.0	14.0	1,661.5	0.0	0.0	1	1	0
11/03/2021 14:00	0.0	14.0	1,488.6	0.0	0.0	1	1	0
11/03/2021 15:00	0.0	13.9	1,562.0	0.0	0.0	1	1	1
11/03/2021 16:00	0.2	12.7	1,987.1	0.0	0.6	1	1	1
11/03/2021 17:00	0.0	12.1	2,126.0	0.0	0.0	1	1	1
11/03/2021 18:00	0.0	12.3	2,086.9	0.0	0.0	1	1	1
11/03/2021 19:00	0.0	12.1	2,138.7	0.0	0.0	1	1	1
11/03/2021 20:00	0.0	12.2	2,124.9	0.0	0.0	1	1	1
11/03/2021 21:00	0.0	12.4	2,081.7	0.0	0.0	1	1	1
11/03/2021 22:00	0.0	12.6	2,032.9	0.0	0.0	1	1	1
11/03/2021 23:00	0.8	13.0	1,906.5	0.2	2.5	1	1	1
Average/Sum#:	0.2	13.3	1,817.7	0.1	12.9 #	24 #	24 #	17 #
Minimum:	0.0	12.1	1,488.6	0.0	0.0	1	1	0
Maximum:	1.0	14.0	2,138.7	0.5	3.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/04/2021 00:00	0.0	13.9	1,453.2	0.2	0.0	1	1	0
11/04/2021 01:00	0.0	13.8	1,566.5	0.2	0.0	1	1	1
11/04/2021 02:00	0.8	13.1	1,912.8	0.2	2.6	1	1	1
11/04/2021 03:00	0.0	12.9	1,944.2	0.2	0.0	1	1	1
11/04/2021 04:00	0.0	13.8	1,664.8	0.2	0.0	1	1	1
11/04/2021 05:00	0.0	13.8	1,743.5	0.0	0.0	1	1	1
11/04/2021 06:00	0.6	12.8	1,968.8	0.1	1.9	1	1	1
11/04/2021 07:00	0.1	12.8	1,950.1	0.2	0.3	1	1	1
11/04/2021 08:00	0.0	13.9	1,566.2	0.2	0.0	1	1	0
11/04/2021 09:00	0.0	14.0	1,498.9	0.0	0.0	1	1	0
11/04/2021 10:00	0.0	14.0	1,491.2	0.0	0.0	1	1	0
11/04/2021 11:00	0.0	14.0	1,465.8	0.0	0.0	1	1	0
11/04/2021 12:00	0.0	14.0	1,365.4	0.0	0.0	1	1	0
11/04/2021 13:00	0.0	14.0	1,524.8	0.0	0.0	1	1	0
11/04/2021 14:00	0.0	14.0	1,632.8	0.0	0.0	1	1	0
11/04/2021 15:00	0.0	14.0	1,534.7	0.0	0.0	1	1	0
11/04/2021 16:00	0.1	12.9	1,953.0	0.0	0.3	1	1	1
11/04/2021 17:00	0.0	12.6	2,029.2	0.0	0.0	1	1	1
11/04/2021 18:00	0.0	12.7	1,999.2	0.0	0.0	1	1	1
11/04/2021 19:00	0.0	13.9	1,661.5	0.0	0.0	1	1	1
11/04/2021 20:00	0.0	13.9	1,605.9	0.0	0.0	1	1	1
11/04/2021 21:00	0.2	12.9	1,988.3	0.0	0.7	1	1	1
11/04/2021 22:00	0.0	13.4	1,653.9	0.0	0.0	1	1	1
11/04/2021 23:00	8.8	15.1	862.3	0.0	6.6	1	0	0
Average/Sum#:	0.4	13.6	1,668.2	0.1	12.4 #	24 #	23 #	14 #
Minimum:	0.0	12.6	862.3	0.0	0.0	1	0	0
Maximum:	8.8	15.1	2,029.2	0.2	6.6	1	1	1
%SI	0.00	0.00	0.00	4.17	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/05/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/05/2021 13:00	21.5	17.7	339.3	0.0	20.5	1	0	0
11/05/2021 14:00	14.5	14.7	1,252.5	0.0	38.7	1	0	0
11/05/2021 15:00	0.0	13.9	1,542.8	0.0	0.0	1	1	1
11/05/2021 16:00	0.3	12.7	2,027.7	0.0	1.0	1	1	1
11/05/2021 17:00	0.0	12.5	2,056.9	0.1	0.0	1	1	1
11/05/2021 18:00	0.0	12.7	2,038.7	0.1	0.0	1	1	1
11/05/2021 19:00	0.4	12.9	1,945.0	0.1	1.3	1	1	1
11/05/2021 20:00	0.0	13.9	1,644.4	0.1	0.0	1	1	0
11/05/2021 21:00	0.0	13.8	1,758.5	0.1	0.0	1	1	1
11/05/2021 22:00	0.2	13.0	1,976.7	0.0	0.7	1	1	1
11/05/2021 23:00	0.2	13.2	1,922.0	0.1	0.7	1	1	1
Average/Sum#:	3.4	13.7	1,682.2	0.1	62.9 #	11 #	9 #	8 #
Minimum:	0.0	12.5	339.3	0.0	0.0	0	0	0
Maximum:	21.5	17.7	2,056.9	0.1	38.7	1	1	1
%SI	54.17	54.17	54.17	70.83	54.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/06/2021 00:00	0.0	13.8	1,664.2	0.1	0.0	1	1	1
11/06/2021 01:00	0.0	13.9	1,572.1	0.1	0.0	1	1	0
11/06/2021 02:00	1.0	13.3	1,895.0	0.3	3.3	1	1	1
11/06/2021 03:00	1.1	13.2	1,915.3	0.5	3.6	1	1	1
11/06/2021 04:00	0.0	13.9	1,663.3	0.5	0.0	1	1	1
11/06/2021 05:00	0.0	13.9	1,592.6	0.3	0.0	1	1	1
11/06/2021 06:00	0.6	12.9	1,968.5	0.1	1.9	1	1	1
11/06/2021 07:00	0.4	13.1	1,912.4	0.2	1.3	1	1	1
11/06/2021 08:00	0.0	13.9	1,585.1	0.2	0.0	1	1	0
11/06/2021 09:00	0.0	13.9	1,583.7	0.1	0.0	1	1	0
11/06/2021 10:00	0.0	13.9	1,588.6	0.0	0.0	1	1	0
11/06/2021 11:00	0.0	13.9	1,524.7	0.0	0.0	1	1	0
11/06/2021 12:00	0.0	13.9	1,519.7	0.0	0.0	1	1	0
11/06/2021 13:00	0.0	13.9	1,550.3	0.0	0.0	1	1	0
11/06/2021 14:00	0.0	14.0	1,456.7	0.0	0.0	1	1	0
11/06/2021 15:00	0.0	13.9	1,562.8	0.0	0.0	1	1	0
11/06/2021 16:00	0.7	12.9	1,960.0	0.2	2.3	1	1	1
11/06/2021 17:00	0.0	12.5	2,037.2	0.2	0.0	1	1	1
11/06/2021 18:00	0.5	13.1	1,901.0	0.3	1.6	1	1	1
11/06/2021 19:00	0.0	13.9	1,642.7	0.1	0.0	1	1	0
11/06/2021 20:00	0.0	13.8	1,655.9	0.1	0.0	1	1	1
11/06/2021 21:00	0.7	13.1	1,946.8	0.2	2.3	1	1	1
11/06/2021 22:00	5.1	14.0	1,448.1	0.0	10.3	1	0	1
11/06/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.4	13.6	1,702.0	0.2	26.6 #	23 #	22 #	13 #
Minimum:	0.0	12.5	1,448.1	0.0	0.0	0	0	0
Maximum:	5.1	14.0	2,037.2	0.5	10.3	1	1	1
%SI	4.17	4.17	4.17	8.33	4.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/07/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/07/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/08/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/08/2021 12:00	62.5	18.0	282.3	0.0	57.9	1	0	0
11/08/2021 13:00	27.4	16.9	504.9	0.0	45.7	1	0	0
11/08/2021 14:00	38.8	15.2	931.0	0.0	83.7	1	0	0
11/08/2021 15:00	0.0	14.0	1,644.3	0.0	0.0	1	1	0
11/08/2021 16:00	0.0	0.0	2,007.5	0.0	0.0	1	1	1
11/08/2021 17:00	0.0	12.1	2,126.2	0.0	0.0	1	1	1
11/08/2021 18:00	0.3	12.9	1,973.7	0.0	1.0	1	1	1
11/08/2021 19:00	0.6	13.1	1,940.4	0.2	2.0	1	1	1
11/08/2021 20:00	0.0	12.4	2,104.2	0.2	0.0	1	1	1
11/08/2021 21:00	0.1	12.6	2,057.7	0.2	0.3	1	1	1
11/08/2021 22:00	1.1	13.3	1,880.3	0.3	3.6	1	1	1
11/08/2021 23:00	18.7	15.8	561.5	0.0	6.0	1	0	0
Average/Sum#:	13.6	14.2	1,501.2	0.2	200.2 #	12 #	8 #	7 #
Minimum:	0.0	12.1	282.3	0.2	0.0	0	0	0
Maximum:	62.5	18.0	2,126.2	0.3	83.7	1	1	1
%SI	54.17	54.17	50.00	83.33	54.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/09/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/09/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/09/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/09/2021 03:00	17.2	18.1	303.5	0.0	8.6	1	0	0
11/09/2021 04:00	33.9	15.4	905.7	0.0	73.7	1	0	0
11/09/2021 05:00	0.0	13.9	1,498.9	0.0	0.0	1	1	0
11/09/2021 06:00	0.0	13.9	1,538.4	0.0	0.0	1	1	0
11/09/2021 07:00	0.0	13.8	1,742.0	0.0	0.0	1	1	0
11/09/2021 08:00	0.0	13.9	1,539.3	0.0	0.0	1	1	0
11/09/2021 09:00	0.0	13.9	1,681.6	0.0	0.0	1	1	0
11/09/2021 10:00	0.0	13.9	1,491.2	0.0	0.0	1	1	0
11/09/2021 11:00	0.0	13.9	1,546.2	0.0	0.0	1	1	0
11/09/2021 12:00	0.0	13.9	1,517.2	0.0	0.0	1	1	0
11/09/2021 13:00	0.0	13.9	1,647.6	0.0	0.0	1	1	0
11/09/2021 14:00	0.0	13.9	1,596.7	0.0	0.0	1	1	0
11/09/2021 15:00	0.0	13.9	1,497.0	0.0	0.0	1	1	0
11/09/2021 16:00	0.0	13.9	1,538.2	0.0	0.0	1	1	0
11/09/2021 17:00	0.6	13.4	1,821.2	0.2	1.9	1	1	1
11/09/2021 18:00	0.0	12.5	2,080.4	0.2	0.0	1	1	1
11/09/2021 19:00	0.0	12.3	2,136.6	0.2	0.0	1	1	1
11/09/2021 20:00	0.0	12.5	2,052.3	0.0	0.0	1	1	1
11/09/2021 21:00	0.0	13.9	1,580.5	0.0	0.0	1	1	0
11/09/2021 22:00	0.0	13.8	1,692.7	0.0	0.0	1	1	0
11/09/2021 23:00	0.7	13.0	1,962.9	0.2	2.3	1	1	1
Average/Sum#:	2.5	13.9	1,589.1	0.0	86.5 #	21 #	19 #	5 #
Minimum:	0.0	12.3	303.5	0.0	0.0	0	0	0
Maximum:	33.9	18.1	2,136.6	0.2	73.7	1	1	1
%SI	12.50	12.50	12.50	29.17	12.50	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/10/2021 00:00	0.4	13.4	1,806.2	0.3	1.3	1	1	1
11/10/2021 01:00	0.0	13.7	1,760.1	0.3	0.0	1	1	0
11/10/2021 02:00	0.0	13.9	1,557.6	0.1	0.0	1	1	1
11/10/2021 03:00	1.3	13.2	1,927.4	0.3	4.3	1	1	1
11/10/2021 04:00	1.1	13.2	1,909.8	0.6	3.6	1	1	1
11/10/2021 05:00	0.0	13.9	1,677.6	0.6	0.0	1	1	0
11/10/2021 06:00	0.0	13.9	1,762.0	0.3	0.0	1	1	1
11/10/2021 07:00	1.1	13.2	1,951.5	0.3	3.7	1	1	1
11/10/2021 08:00	0.9	13.2	1,908.2	0.5	2.9	1	1	1
11/10/2021 09:00	0.0	14.0	1,528.6	0.5	0.0	1	1	0
11/10/2021 10:00	0.0	14.0	1,453.0	0.2	0.0	1	1	0
11/10/2021 11:00	0.0	14.0	1,402.4	0.0	0.0	1	1	0
11/10/2021 12:00	0.0	14.0	1,450.4	0.0	0.0	1	1	0
11/10/2021 13:00	0.0	14.0	1,325.7	0.0	0.0	1	1	0
11/10/2021 14:00	0.0	14.0	1,458.8	0.0	0.0	1	1	0
11/10/2021 15:00	0.0	13.9	1,559.2	0.0	0.0	1	1	1
11/10/2021 16:00	0.4	13.0	1,964.7	0.1	1.3	1	1	1
11/10/2021 17:00	0.0	12.9	1,981.1	0.1	0.0	1	1	1
11/10/2021 18:00	0.0	12.7	2,026.0	0.1	0.0	1	1	1
11/10/2021 19:00	0.0	12.7	2,021.3	0.0	0.0	1	1	1
11/10/2021 20:00	0.0	12.9	1,958.1	0.0	0.0	1	1	1
11/10/2021 21:00	0.0	13.9	1,671.4	0.0	0.0	1	1	0
11/10/2021 22:00	0.0	13.8	1,746.1	0.0	0.0	1	1	1
11/10/2021 23:00	0.3	12.9	1,985.2	0.1	1.0	1	1	1
Average/Sum#:	0.2	13.5	1,741.4	0.2	18.1 #	24 #	24 #	15 #
Minimum:	0.0	12.7	1,325.7	0.0	0.0	1	1	0
Maximum:	1.3	14.0	2,026.0	0.6	4.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/11/2021 00:00	0.6	13.1	1,912.6	0.2	1.9	1	1	1
11/11/2021 01:00	15.5	15.8	583.8	0.0	5.4	1	0	0
11/11/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/11/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/11/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/11/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/11/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/11/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/11/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/11/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/11/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/11/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/11/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/11/2021 13:00	28.5	17.8	323.9	0.0	21.6	1	0	0
11/11/2021 14:00	35.5	15.0	1,021.2	0.0	81.2	1	0	0
11/11/2021 15:00	0.0	13.9	1,628.0	0.0	0.0	1	1	0
11/11/2021 16:00	0.2	13.4	1,781.2	0.0	0.6	1	1	1
11/11/2021 17:00	0.0	12.5	2,048.6	0.1	0.0	1	1	1
11/11/2021 18:00	0.0	12.5	2,052.8	0.1	0.0	1	1	1
11/11/2021 19:00	0.0	12.5	2,058.1	0.0	0.0	1	1	1
11/11/2021 20:00	0.0	12.5	2,034.5	0.0	0.0	1	1	1
11/11/2021 21:00	0.0	13.9	1,660.4	0.0	0.0	1	1	0
11/11/2021 22:00	0.0	13.8	1,745.3	0.0	0.0	1	1	1
11/11/2021 23:00	0.2	13.0	1,952.9	0.0	0.7	1	1	1
Average/Sum#:	6.2	13.8	1,600.3	0.1	111.4 #	13 #	10 #	8 #
Minimum:	0.0	12.5	323.9	0.0	0.0	0	0	0
Maximum:	35.5	17.8	2,058.1	0.2	81.2	1	1	1
%SI	45.83	45.83	45.83	66.67	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/12/2021 00:00	0.4	13.2	1,897.7	0.1	1.3	1	1	1
11/12/2021 01:00	0.0	13.9	1,551.9	0.1	0.0	1	1	0
11/12/2021 02:00	0.0	13.9	1,520.6	0.1	0.0	1	1	0
11/12/2021 03:00	0.0	13.9	1,526.4	0.0	0.0	1	1	0
11/12/2021 04:00	0.0	13.9	1,549.7	0.0	0.0	1	1	1
11/12/2021 05:00	0.2	12.9	1,992.8	0.0	0.7	1	1	1
11/12/2021 06:00	0.0	12.8	2,022.2	0.0	0.0	1	1	1
11/12/2021 07:00	0.0	13.6	1,651.9	0.0	0.0	1	1	1
11/12/2021 08:00	10.9	15.1	871.0	0.0	8.6	1	0	0
11/12/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/12/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/12/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/12/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/12/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/12/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/12/2021 15:00	21.7	18.0	315.7	0.0	13.4	1	0	0
11/12/2021 16:00	34.8	15.7	835.3	0.0	73.8	1	0	0
11/12/2021 17:00	0.0	13.9	1,412.8	0.0	0.0	1	1	0
11/12/2021 18:00	0.0	13.9	1,563.6	0.0	0.0	1	1	1
11/12/2021 19:00	0.1	12.8	2,001.4	0.0	0.3	1	1	1
11/12/2021 20:00	0.0	13.0	1,940.4	0.0	0.0	1	1	1
11/12/2021 21:00	0.0	13.9	1,605.2	0.0	0.0	1	1	0
11/12/2021 22:00	0.0	13.8	1,667.1	0.0	0.0	1	1	1
11/12/2021 23:00	0.1	12.9	1,983.5	0.0	0.3	1	1	1
Average/Sum#:	3.8	14.0	1,550.5	0.0	98.4 #	18 #	15 #	10 #
Minimum:	0.0	12.8	315.7	0.0	0.0	0	0	0
Maximum:	34.8	18.0	2,022.2	0.1	73.8	1	1	1
%SI	25.00	25.00	25.00	45.83	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/13/2021 00:00	8.1	14.4	1,208.7	0.0	9.6	1	0	1
11/13/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/13/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/13/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/13/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/13/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/13/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/13/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/13/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/13/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/13/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/13/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/13/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/13/2021 13:00	22.2	17.7	347.6	0.0	22.3	1	0	0
11/13/2021 14:00	23.4	15.0	1,057.3	0.0	55.4	1	0	0
11/13/2021 15:00	0.0	13.9	1,671.8	0.0	0.0	1	1	0
11/13/2021 16:00	0.0	13.8	1,734.3	0.0	0.0	1	1	1
11/13/2021 17:00	0.1	12.9	1,981.2	0.0	0.3	1	1	1
11/13/2021 18:00	0.0	12.9	1,940.1	0.0	0.0	1	1	1
11/13/2021 19:00	0.0	13.9	1,679.5	0.0	0.0	1	1	0
11/13/2021 20:00	0.0	13.8	1,763.0	0.0	0.0	1	1	1
11/13/2021 21:00	0.2	12.9	1,979.3	0.0	0.7	1	1	1
11/13/2021 22:00	5.8	13.8	1,460.7	0.0	11.5	1	0	1
11/13/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	5.4	14.1	1,529.4	0.0	99.8 #	11 #	7 #	7 #
Minimum:	0.0	12.9	347.6	0.0	0.0	0	0	0
Maximum:	23.4	17.7	1,981.2	0.0	55.4	1	1	1
%SI	54.17	54.17	54.17	79.17	54.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/14/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/14/2021 14:00	82.4	18.6	217.0	0.0	22.6	1	0	0
11/14/2021 15:00	33.7	16.1	718.4	0.0	66.6	1	0	0
11/14/2021 16:00	0.0	14.0	1,293.1	0.0	0.0	1	1	0
11/14/2021 17:00	0.0	13.9	1,563.8	0.0	0.0	1	1	1
11/14/2021 18:00	0.3	12.8	2,003.8	0.1	1.0	1	1	1
11/14/2021 19:00	0.2	13.0	1,930.1	0.1	0.6	1	1	1
11/14/2021 20:00	0.0	13.7	1,703.6	0.1	0.0	1	1	1
11/14/2021 21:00	0.0	13.9	1,557.5	0.0	0.0	1	1	1
11/14/2021 22:00	0.3	12.8	1,998.8	0.1	1.0	1	1	1
11/14/2021 23:00	0.1	13.5	1,631.6	0.1	0.3	1	1	1
Average/Sum#:	11.7	14.2	1,461.8	0.1	92.1 #	10 #	8 #	7 #
Minimum:	0.0	12.8	217.0	0.0	0.0	0	0	0
Maximum:	82.4	18.6	2,003.8	0.1	66.6	1	1	1
%SI	58.33	58.33	58.33	75.00	58.33	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/15/2021 00:00	11.4	14.9	905.6	0.0	9.5	1	0	0
11/15/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/15/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/15/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/15/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/15/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/15/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/15/2021 07:00	25.7	18.0	324.5	0.0	16.0	1	0	0
11/15/2021 08:00	42.4	15.8	793.0	0.0	87.1	1	0	0
11/15/2021 09:00	0.0	13.9	1,396.9	0.0	0.0	1	1	0
11/15/2021 10:00	0.0	13.9	1,603.7	0.0	0.0	1	1	1
11/15/2021 11:00	2.4	13.2	1,929.8	0.6	7.9	1	1	1
11/15/2021 12:00	2.3	13.2	1,930.1	1.2	7.6	1	1	1
11/15/2021 13:00	0.3	13.8	1,501.1	1.3	0.8	1	1	1
11/15/2021 14:00	0.0	13.9	1,568.6	0.7	0.0	1	1	0
11/15/2021 15:00	0.3	13.1	1,912.9	0.1	1.0	1	1	1
11/15/2021 16:00	0.4	13.0	1,957.3	0.2	1.3	1	1	1
11/15/2021 17:00	1.0	13.2	1,919.1	0.4	3.3	1	1	1
11/15/2021 18:00	0.8	13.2	1,929.7	0.6	2.6	1	1	1
11/15/2021 19:00	0.0	12.8	2,023.8	0.5	0.0	1	1	1
11/15/2021 20:00	0.6	13.2	1,917.6	0.4	2.0	1	1	1
11/15/2021 21:00	0.7	13.2	1,913.8	0.3	2.3	1	1	1
11/15/2021 22:00	0.8	13.2	1,912.4	0.5	2.6	1	1	1
11/15/2021 23:00	0.9	13.2	1,893.0	0.6	2.9	1	1	1
Average/Sum#:	5.0	13.8	1,629.6	0.6	146.9 #	18 #	15 #	13 #
Minimum:	0.0	12.8	324.5	0.1	0.0	0	0	0
Maximum:	42.4	18.0	2,023.8	1.3	87.1	1	1	1
%SI	25.00	25.00	25.00	45.83	25.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/16/2021 00:00	21.9	15.7	597.7	0.0	7.6	1	0	0
11/16/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/16/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/16/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/16/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/16/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/16/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/16/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/16/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/16/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/16/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/16/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/16/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/16/2021 13:00	50.2	18.8	193.3	0.0	12.2	1	0	0
11/16/2021 14:00	39.1	16.7	536.5	0.0	66.0	1	0	0
11/16/2021 15:00	11.0	14.3	1,349.4	0.0	29.7	1	0	0
11/16/2021 16:00	0.0	14.0	1,478.2	0.0	0.0	1	1	0
11/16/2021 17:00	0.3	13.2	1,911.6	0.0	1.0	1	1	1
11/16/2021 18:00	0.2	12.9	2,005.0	0.1	0.7	1	1	1
11/16/2021 19:00	0.4	13.2	1,941.0	0.2	1.3	1	1	1
11/16/2021 20:00	0.0	12.5	2,091.7	0.1	0.0	1	1	1
11/16/2021 21:00	0.0	12.4	2,117.0	0.1	0.0	1	1	1
11/16/2021 22:00	0.0	12.7	2,026.9	0.0	0.0	1	1	1
11/16/2021 23:00	0.0	12.5	2,077.5	0.0	0.0	1	1	1
Average/Sum#:	10.3	14.1	1,527.2	0.1	118.5 #	12 #	8 #	7 #
Minimum:	0.0	12.4	193.3	0.0	0.0	0	0	0
Maximum:	50.2	18.8	2,117.0	0.2	66.0	1	1	1
%SI	50.00	50.00	50.00	75.00	50.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/17/2021 00:00	0.0	13.1	1,944.4	0.0	0.0	1	1	1
11/17/2021 01:00	0.2	13.3	1,908.2	0.1	0.7	1	1	1
11/17/2021 02:00	0.4	13.3	1,909.6	0.2	1.3	1	1	1
11/17/2021 03:00	0.4	13.3	1,910.5	0.3	1.3	1	1	1
11/17/2021 04:00	0.2	13.1	1,962.2	0.3	0.7	1	1	1
11/17/2021 05:00	0.2	13.1	1,983.4	0.2	0.7	1	1	1
11/17/2021 06:00	0.0	12.4	2,128.2	0.1	0.0	1	1	1
11/17/2021 07:00	0.0	12.7	2,054.3	0.1	0.0	1	1	1
11/17/2021 08:00	0.9	13.3	1,919.2	0.2	3.0	1	1	1
11/17/2021 09:00	0.9	13.3	1,907.6	0.5	3.0	1	1	1
11/17/2021 10:00	0.0	13.9	1,520.6	0.5	0.0	1	1	0
11/17/2021 11:00	0.2	13.5	1,840.5	0.3	0.7	1	1	1
11/17/2021 12:00	0.5	13.3	1,921.5	0.2	1.7	1	1	1
11/17/2021 13:00	0.0	13.7	1,482.9	0.2	0.0	1	1	1
11/17/2021 14:00	0.0	14.0	1,434.4	0.1	0.0	1	1	0
11/17/2021 15:00	0.2	13.1	1,908.9	0.1	0.6	1	1	1
11/17/2021 16:00	0.0	12.7	2,031.3	0.1	0.0	1	1	1
11/17/2021 17:00	0.0	12.4	2,103.6	0.1	0.0	1	1	1
11/17/2021 18:00	0.0	12.4	2,095.3	0.0	0.0	1	1	1
11/17/2021 19:00	0.0	12.3	2,122.7	0.0	0.0	1	1	1
11/17/2021 20:00	0.0	12.3	2,126.1	0.0	0.0	1	1	1
11/17/2021 21:00	0.0	12.7	2,041.8	0.0	0.0	1	1	1
11/17/2021 22:00	0.3	13.3	1,915.8	0.1	1.0	1	1	1
11/17/2021 23:00	0.4	13.3	1,909.3	0.2	1.3	1	1	1
Average/Sum#:	0.2	13.1	1,920.1	0.2	16.0 #	24 #	24 #	22 #
Minimum:	0.0	12.3	1,434.4	0.0	0.0	1	1	0
Maximum:	0.9	14.0	2,128.2	0.5	3.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/18/2021 00:00	0.5	13.3	1,908.0	0.3	1.7	1	1	1
11/18/2021 01:00	0.6	13.3	1,908.9	0.4	2.0	1	1	1
11/18/2021 02:00	0.6	13.3	1,911.8	0.5	2.0	1	1	1
11/18/2021 03:00	0.6	13.3	1,912.6	0.5	2.0	1	1	1
11/18/2021 04:00	0.6	13.3	1,912.7	0.5	2.0	1	1	1
11/18/2021 05:00	0.3	13.0	1,993.5	0.4	1.0	1	1	1
11/18/2021 06:00	0.0	12.5	2,097.3	0.2	0.0	1	1	1
11/18/2021 07:00	0.0	12.7	2,060.2	0.1	0.0	1	1	1
11/18/2021 08:00	0.1	13.0	1,978.8	0.0	0.3	1	1	1
11/18/2021 09:00	0.5	13.3	1,891.0	0.2	1.6	1	1	1
11/18/2021 10:00	0.0	13.9	1,635.9	0.2	0.0	1	1	1
11/18/2021 11:00	0.3	13.2	1,923.3	0.2	1.0	1	1	1
11/18/2021 12:00	0.3	13.2	1,919.7	0.1	1.0	1	1	1
11/18/2021 13:00	0.0	13.8	1,497.9	0.1	0.0	1	1	1
11/18/2021 14:00	0.0	13.9	1,474.9	0.1	0.0	1	1	0
11/18/2021 15:00	0.0	13.6	1,800.1	0.0	0.0	1	1	1
11/18/2021 16:00	0.0	12.6	2,063.1	0.0	0.0	1	1	1
11/18/2021 17:00	0.0	12.4	2,095.8	0.0	0.0	1	1	1
11/18/2021 18:00	0.0	12.1	2,150.3	0.0	0.0	1	1	1
11/18/2021 19:00	0.0	12.4	2,089.1	0.0	0.0	1	1	1
11/18/2021 20:00	0.0	12.7	2,036.3	0.0	0.0	1	1	1
11/18/2021 21:00	0.2	13.1	1,931.3	0.1	0.7	1	1	1
11/18/2021 22:00	0.5	13.2	1,909.9	0.2	1.6	1	1	1
11/18/2021 23:00	0.5	13.2	1,908.4	0.3	1.6	1	1	1
Average/Sum#:	0.2	13.1	1,917.1	0.2	18.5 #	24 #	24 #	23 #
Minimum:	0.0	12.1	1,474.9	0.0	0.0	1	1	0
Maximum:	0.6	13.9	2,150.3	0.5	2.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/19/2021 00:00	0.6	13.2	1,907.8	0.4	2.0	1	1	1
11/19/2021 01:00	0.6	13.2	1,877.7	0.5	1.9	1	1	1
11/19/2021 02:00	0.0	13.9	1,605.5	0.3	0.0	1	1	0
11/19/2021 03:00	0.0	13.2	1,910.6	0.2	0.0	1	1	1
11/19/2021 04:00	0.0	13.0	1,980.2	0.0	0.0	1	1	1
11/19/2021 05:00	0.0	12.8	2,016.6	0.0	0.0	1	1	1
11/19/2021 06:00	0.0	12.7	2,051.7	0.0	0.0	1	1	1
11/19/2021 07:00	0.0	12.7	2,030.6	0.0	0.0	1	1	1
11/19/2021 08:00	0.0	13.2	1,932.1	0.0	0.0	1	1	1
11/19/2021 09:00	0.0	13.3	1,905.6	0.0	0.0	1	1	1
11/19/2021 10:00	0.1	13.3	1,912.0	0.0	0.3	1	1	1
11/19/2021 11:00	0.0	13.2	1,930.4	0.0	0.0	1	1	1
11/19/2021 12:00	0.0	13.2	1,925.4	0.0	0.0	1	1	1
11/19/2021 13:00	0.0	12.8	2,029.7	0.0	0.0	1	1	1
11/19/2021 14:00	0.0	12.7	2,028.8	0.0	0.0	1	1	1
11/19/2021 15:00	0.0	13.0	1,966.6	0.0	0.0	1	1	1
11/19/2021 16:00	0.0	12.9	1,989.8	0.0	0.0	1	1	1
11/19/2021 17:00	0.0	12.9	2,000.4	0.0	0.0	1	1	1
11/19/2021 18:00	0.0	12.9	2,007.9	0.0	0.0	1	1	1
11/19/2021 19:00	0.0	13.2	1,901.9	0.0	0.0	1	1	1
11/19/2021 20:00	0.0	13.9	1,648.2	0.0	0.0	1	1	0
11/19/2021 21:00	0.0	13.8	1,727.9	0.0	0.0	1	1	1
11/19/2021 22:00	0.1	13.1	1,944.7	0.0	0.3	1	1	1
11/19/2021 23:00	0.1	13.1	1,933.8	0.1	0.3	1	1	1
Average/Sum#:	0.1	13.1	1,923.6	0.1	4.8 #	24 #	24 #	22 #
Minimum:	0.0	12.7	1,605.5	0.0	0.0	1	1	0
Maximum:	0.6	13.9	2,051.7	0.5	2.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/20/2021 00:00	0.2	13.2	1,898.5	0.1	0.7	1	1	1
11/20/2021 01:00	0.0	14.0	1,549.2	0.1	0.0	1	1	0
11/20/2021 02:00	0.0	14.0	1,527.0	0.1	0.0	1	1	0
11/20/2021 03:00	0.0	14.0	1,525.7	0.0	0.0	1	1	0
11/20/2021 04:00	0.0	13.9	1,663.4	0.0	0.0	1	1	1
11/20/2021 05:00	0.1	12.9	1,993.6	0.0	0.3	1	1	1
11/20/2021 06:00	0.1	13.1	1,956.4	0.1	0.3	1	1	1
11/20/2021 07:00	0.0	14.0	1,612.3	0.1	0.0	1	1	0
11/20/2021 08:00	0.0	14.0	1,627.2	0.0	0.0	1	1	0
11/20/2021 09:00	0.0	14.0	1,451.4	0.0	0.0	1	1	0
11/20/2021 10:00	0.0	14.0	1,497.7	0.0	0.0	1	1	0
11/20/2021 11:00	0.0	14.0	1,562.8	0.0	0.0	1	1	0
11/20/2021 12:00	0.0	14.0	1,428.9	0.0	0.0	1	1	0
11/20/2021 13:00	0.0	14.0	1,466.0	0.0	0.0	1	1	0
11/20/2021 14:00	0.0	14.0	1,482.7	0.0	0.0	1	1	0
11/20/2021 15:00	0.0	13.9	1,586.5	0.0	0.0	1	1	1
11/20/2021 16:00	0.0	12.9	1,974.3	0.0	0.0	1	1	1
11/20/2021 17:00	0.0	12.8	2,011.6	0.0	0.0	1	1	1
11/20/2021 18:00	0.0	13.1	1,910.1	0.0	0.0	1	1	1
11/20/2021 19:00	0.0	14.0	1,680.4	0.0	0.0	1	1	0
11/20/2021 20:00	0.0	13.8	1,755.8	0.0	0.0	1	1	1
11/20/2021 21:00	0.0	12.9	1,985.2	0.0	0.0	1	1	1
11/20/2021 22:00	0.0	12.6	2,059.7	0.0	0.0	1	1	1
11/20/2021 23:00	0.0	13.3	1,833.8	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.6	1,710.0	0.0	1.3 #	24 #	24 #	12 #
Minimum:	0.0	12.6	1,428.9	0.0	0.0	1	1	0
Maximum:	0.2	14.0	2,059.7	0.1	0.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/21/2021 00:00	0.0	13.9	1,713.0	0.0	0.0	1	1	1
11/21/2021 01:00	0.2	13.3	1,909.7	0.1	0.7	1	1	1
11/21/2021 02:00	3.4	14.2	1,404.0	0.0	8.7	1	0	1
11/21/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/21/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/21/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/21/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/21/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/21/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/21/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/21/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/21/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/21/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/21/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/21/2021 14:00	19.0	17.9	304.2	0.0	11.9	1	0	0
11/21/2021 15:00	20.9	16.1	733.6	0.0	42.2	1	0	0
11/21/2021 16:00	0.0	14.1	1,303.2	0.0	0.0	1	1	0
11/21/2021 17:00	0.0	14.0	1,548.9	0.0	0.0	1	1	1
11/21/2021 18:00	0.0	12.9	1,985.6	0.0	0.0	1	1	1
11/21/2021 19:00	0.0	12.7	1,997.8	0.0	0.0	1	1	1
11/21/2021 20:00	0.0	14.0	1,665.8	0.0	0.0	1	1	0
11/21/2021 21:00	0.0	13.9	1,749.7	0.0	0.0	1	1	0
11/21/2021 22:00	0.2	13.2	1,948.4	0.1	0.7	1	1	1
11/21/2021 23:00	0.0	13.6	1,668.6	0.1	0.0	1	1	1
Average/Sum#:	3.4	14.1	1,533.3	0.0	64.2 #	13 #	10 #	8 #
Minimum:	0.0	12.7	304.2	0.0	0.0	0	0	0
Maximum:	20.9	17.9	1,997.8	0.1	42.2	1	1	1
%SI	45.83	45.83	45.83	66.67	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/22/2021 00:00	8.5	15.0	923.0	0.0	8.3	1	0	0
11/22/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/22/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/22/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/22/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/22/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/22/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/22/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/22/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/22/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/22/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/22/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/22/2021 12:00	23.7	17.7	377.3	0.0	23.2	1	0	0
11/22/2021 13:00	23.8	14.7	1,148.0	0.0	58.2	1	0	0
11/22/2021 14:00	0.0	14.0	1,666.9	0.0	0.0	1	1	0
11/22/2021 15:00	0.0	13.9	1,713.2	0.0	0.0	1	1	0
11/22/2021 16:00	0.0	13.2	1,905.1	0.0	0.0	1	1	1
11/22/2021 17:00	0.0	12.8	2,005.5	0.0	0.0	1	1	1
11/22/2021 18:00	0.0	12.5	2,076.7	0.0	0.0	1	1	1
11/22/2021 19:00	0.0	12.5	2,068.7	0.0	0.0	1	1	1
11/22/2021 20:00	0.0	12.6	2,027.7	0.0	0.0	1	1	1
11/22/2021 21:00	0.0	13.9	1,610.0	0.0	0.0	1	1	0
11/22/2021 22:00	0.0	13.8	1,772.2	0.0	0.0	1	1	1
11/22/2021 23:00	0.0	12.9	1,987.2	0.0	0.0	1	1	1
Average/Sum#:	4.3	13.8	1,637.0	0.0	89.7 #	13 #	10 #	7 #
Minimum:	0.0	12.5	377.3	0.0	0.0	0	0	0
Maximum:	23.8	17.7	2,076.7	0.0	58.2	1	1	1
%SI	45.83	45.83	45.83	66.67	45.83	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/23/2021 00:00	0.1	13.2	1,915.6	0.0	0.3	1	1	1
11/23/2021 01:00	0.0	14.0	1,475.3	0.0	0.0	1	1	0
11/23/2021 02:00	0.0	13.9	1,674.0	0.0	0.0	1	1	1
11/23/2021 03:00	0.4	13.3	1,921.6	0.1	1.3	1	1	1
11/23/2021 04:00	0.3	13.3	1,896.0	0.2	1.0	1	1	1
11/23/2021 05:00	0.0	13.9	1,648.7	0.2	0.0	1	1	0
11/23/2021 06:00	0.0	13.8	1,596.1	0.1	0.0	1	1	0
11/23/2021 07:00	0.2	13.1	1,952.6	0.1	0.7	1	1	1
11/23/2021 08:00	0.0	13.0	1,946.6	0.1	0.0	1	1	1
11/23/2021 09:00	0.0	13.9	1,593.8	0.1	0.0	1	1	0
11/23/2021 10:00	0.0	13.9	1,543.8	0.0	0.0	1	1	0
11/23/2021 11:00	0.0	14.0	1,491.7	0.0	0.0	1	1	0
11/23/2021 12:00	0.0	14.0	1,373.5	0.0	0.0	1	1	0
11/23/2021 13:00	0.0	14.0	1,529.4	0.0	0.0	1	1	0
11/23/2021 14:00	0.0	14.0	1,626.3	0.0	0.0	1	1	0
11/23/2021 15:00	0.0	13.9	1,586.5	0.0	0.0	1	1	1
11/23/2021 16:00	0.0	12.8	1,993.9	0.0	0.0	1	1	1
11/23/2021 17:00	0.0	12.8	2,011.8	0.0	0.0	1	1	1
11/23/2021 18:00	0.0	12.8	2,018.4	0.0	0.0	1	1	1
11/23/2021 19:00	0.0	13.2	1,894.6	0.0	0.0	1	1	1
11/23/2021 20:00	0.0	14.0	1,676.8	0.0	0.0	1	1	0
11/23/2021 21:00	0.0	14.0	1,546.2	0.0	0.0	1	1	1
11/23/2021 22:00	0.0	13.0	1,993.3	0.0	0.0	1	1	1
11/23/2021 23:00	0.0	13.3	1,924.5	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.5	1,743.0	0.0	3.3 #	24 #	24 #	14 #
Minimum:	0.0	12.8	1,373.5	0.0	0.0	1	1	0
Maximum:	0.4	14.0	2,018.4	0.2	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/24/2021 00:00	0.0	13.4	1,904.6	0.0	0.0	1	1	1
11/24/2021 01:00	0.0	14.0	1,484.5	0.0	0.0	1	1	0
11/24/2021 02:00	0.0	13.9	1,572.4	0.0	0.0	1	1	1
11/24/2021 03:00	0.3	13.3	1,922.9	0.1	1.0	1	1	1
11/24/2021 04:00	0.2	13.2	1,920.5	0.1	0.7	1	1	1
11/24/2021 05:00	0.0	14.0	1,645.0	0.1	0.0	1	1	0
11/24/2021 06:00	0.0	13.8	1,574.2	0.1	0.0	1	1	1
11/24/2021 07:00	0.1	13.1	1,955.5	0.0	0.3	1	1	1
11/24/2021 08:00	0.1	13.2	1,913.5	0.1	0.3	1	1	1
11/24/2021 09:00	0.0	14.0	1,631.5	0.1	0.0	1	1	0
11/24/2021 10:00	0.0	14.0	1,597.2	0.0	0.0	1	1	0
11/24/2021 11:00	0.0	14.0	1,666.2	0.0	0.0	1	1	0
11/24/2021 12:00	0.0	14.0	1,580.4	0.0	0.0	1	1	0
11/24/2021 13:00	0.0	14.0	1,604.4	0.0	0.0	1	1	0
11/24/2021 14:00	0.0	14.0	1,586.2	0.0	0.0	1	1	0
11/24/2021 15:00	0.0	13.9	1,648.8	0.0	0.0	1	1	1
11/24/2021 16:00	0.2	13.1	1,955.5	0.1	0.7	1	1	1
11/24/2021 17:00	0.0	12.9	1,995.0	0.1	0.0	1	1	1
11/24/2021 18:00	0.0	12.8	2,011.7	0.1	0.0	1	1	1
11/24/2021 19:00	0.0	12.9	1,968.2	0.0	0.0	1	1	1
11/24/2021 20:00	0.0	14.0	1,577.8	0.0	0.0	1	1	0
11/24/2021 21:00	0.0	13.9	1,719.7	0.0	0.0	1	1	1
11/24/2021 22:00	0.2	13.2	1,934.3	0.1	0.7	1	1	1
11/24/2021 23:00	0.4	13.3	1,876.8	0.2	1.3	1	1	1
Average/Sum#:	0.1	13.6	1,760.3	0.1	5.0 #	24 #	24 #	15 #
Minimum:	0.0	12.8	1,484.5	0.0	0.0	1	1	0
Maximum:	0.4	14.0	2,011.7	0.2	1.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/25/2021 00:00	13.2	15.9	568.1	0.0	4.6	1	0	0
11/25/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/25/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	13.2	15.9	568.1	0.0	4.6 #	1 #	0 #	0 #
Minimum:	13.2	15.9	568.1	0.0	4.6	0	0	0
Maximum:	13.2	15.9	568.1	0.0	4.6	1	0	0
%SI	95.83	95.83	95.83	100.00	95.83	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/26/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/26/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/27/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/27/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/28/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/28/2021 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.00	100.00	100.00	100.00	100.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/29/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/29/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/29/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/29/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/29/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/29/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/29/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/29/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/29/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/29/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/29/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/29/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/29/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/29/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/29/2021 14:00	73.3	17.7	319.7	0.0	67.7	1	0	0
11/29/2021 15:00	19.3	16.0	743.8	0.0	38.7	1	0	0
11/29/2021 16:00	0.0	13.9	1,657.4	0.0	0.0	1	1	0
11/29/2021 17:00	0.0	13.0	1,893.5	0.0	0.0	1	1	1
11/29/2021 18:00	0.0	12.5	2,040.3	0.0	0.0	1	1	1
11/29/2021 19:00	0.0	12.8	1,984.1	0.0	0.0	1	1	1
11/29/2021 20:00	0.0	13.9	1,625.1	0.0	0.0	1	1	1
11/29/2021 21:00	0.0	13.8	1,767.3	0.0	0.0	1	1	1
11/29/2021 22:00	0.0	13.1	1,940.2	0.0	0.0	1	1	1
11/29/2021 23:00	8.3	14.4	1,198.0	0.0	9.5	1	0	1
Average/Sum#:	10.1	14.1	1,516.9	0.0	115.9 #	10 #	7 #	7 #
Minimum:	0.0	12.5	319.7	0.0	0.0	0	0	0
Maximum:	73.3	17.7	2,040.3	0.0	67.7	1	1	1
%SI	58.33	58.33	58.33	79.17	58.33	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
11/30/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/30/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/30/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/30/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/30/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/30/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/30/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/30/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
11/30/2021 08:00	19.2	18.1	303.1	0.0	10.4	1	0	0
11/30/2021 09:00	21.5	15.6	877.7	0.0	47.0	1	0	0
11/30/2021 10:00	0.0	13.8	1,771.8	0.0	0.0	1	1	0
11/30/2021 11:00	0.0	13.7	1,775.6	0.0	0.0	1	1	0
11/30/2021 12:00	0.0	13.8	1,749.2	0.0	0.0	1	1	0
11/30/2021 13:00	0.0	13.8	1,731.9	0.0	0.0	1	1	0
11/30/2021 14:00	0.0	13.8	1,724.6	0.0	0.0	1	1	0
11/30/2021 15:00	0.0	13.8	1,722.3	0.0	0.0	1	1	0
11/30/2021 16:00	0.0	13.8	1,725.3	0.0	0.0	1	1	0
11/30/2021 17:00	0.0	13.8	1,728.5	0.0	0.0	1	1	0
11/30/2021 18:00	0.0	13.8	1,726.0	0.0	0.0	1	1	0
11/30/2021 19:00	0.0	13.9	1,724.5	0.0	0.0	1	1	0
11/30/2021 20:00	0.0	13.9	1,689.7	0.0	0.0	1	1	0
11/30/2021 21:00	0.0	14.1	1,251.5	0.0	0.0	1	1	0
11/30/2021 22:00	0.0	13.8	1,737.6	0.0	0.0	1	1	0
11/30/2021 23:00	0.4	13.2	1,904.6	0.1	1.3	1	1	1
Average/Sum#:	2.6	14.2	1,571.5	0.0	58.7 #	16 #	14 #	1 #
Minimum:	0.0	13.2	303.1	0.0	0.0	0	0	0
Maximum:	21.5	18.1	1,904.6	0.1	47.0	1	1	1
%SI	33.33	33.33	33.33	50.00	33.33	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/01/2021 00:00	0.4	13.2	1,904.6	0.2	1.3	1	1	1
12/01/2021 01:00	0.0	13.9	1,489.3	0.2	0.0	1	1	1
12/01/2021 02:00	0.0	14.0	1,284.6	0.1	0.0	1	1	0
12/01/2021 03:00	0.0	13.9	1,689.5	0.0	0.0	1	1	0
12/01/2021 04:00	0.2	13.6	1,798.1	0.1	0.7	1	1	1
12/01/2021 05:00	0.0	13.3	1,809.1	0.1	0.0	1	1	1
12/01/2021 06:00	0.0	13.4	1,671.5	0.1	0.0	1	1	1
12/01/2021 07:00	0.0	12.3	2,156.1	0.0	0.0	1	1	1
12/01/2021 08:00	0.0	12.1	2,166.2	0.0	0.0	1	1	1
12/01/2021 09:00	0.0	12.2	2,151.2	0.0	0.0	1	1	1
12/01/2021 10:00	0.0	12.1	2,164.9	0.0	0.0	1	1	1
12/01/2021 11:00	0.0	12.0	2,173.6	0.0	0.0	1	1	1
12/01/2021 12:00	0.3	11.9	2,175.4	0.1	1.0	1	1	1
12/01/2021 13:00	0.2	11.9	2,161.0	0.1	0.6	1	1	1
12/01/2021 14:00	0.2	11.9	2,154.4	0.1	0.6	1	1	1
12/01/2021 15:00	0.2	11.9	2,150.8	0.1	0.6	1	1	1
12/01/2021 16:00	0.2	11.9	2,159.9	0.1	0.6	1	1	1
12/01/2021 17:00	0.3	11.9	2,168.1	0.1	1.0	1	1	1
12/01/2021 18:00	0.3	11.9	2,168.2	0.2	1.0	1	1	1
12/01/2021 19:00	0.3	12.0	2,154.3	0.2	1.0	1	1	1
12/01/2021 20:00	0.4	12.5	2,075.6	0.2	1.3	1	1	1
12/01/2021 21:00	0.4	12.6	2,047.6	0.3	1.3	1	1	1
12/01/2021 22:00	0.4	12.8	2,000.1	0.3	1.3	1	1	1
12/01/2021 23:00	1.1	13.2	1,902.2	0.5	3.6	1	1	1
Average/Sum#:	0.2	12.6	1,990.7	0.1	15.9 #	24 #	24 #	22 #
Minimum:	0.0	11.9	1,284.6	0.0	0.0	1	1	0
Maximum:	1.1	14.0	2,175.4	0.5	3.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/02/2021 00:00	7.8	14.6	1,181.9	0.0	9.7	1	0	1
12/02/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/02/2021 04:00	30.4	16.5	646.8	0.0	56.1	1	0	0
12/02/2021 05:00	0.3	14.0	1,349.3	0.0	0.8	1	1	0
12/02/2021 06:00	0.2	14.0	1,302.7	0.0	0.5	1	1	0
12/02/2021 07:00	0.2	14.0	1,342.7	0.2	0.5	1	1	0
12/02/2021 08:00	0.3	14.0	1,240.0	0.2	0.7	1	1	0
12/02/2021 09:00	0.2	14.0	1,211.5	0.2	0.5	1	1	0
12/02/2021 10:00	0.3	14.0	1,363.7	0.3	0.8	1	1	0
12/02/2021 11:00	0.2	14.0	1,437.1	0.2	0.6	1	1	0
12/02/2021 12:00	0.3	14.0	1,579.4	0.3	0.9	1	1	0
12/02/2021 13:00	0.3	13.9	1,701.8	0.3	1.0	1	1	0
12/02/2021 14:00	0.4	13.9	1,699.4	0.3	1.3	1	1	0
12/02/2021 15:00	0.3	13.9	1,699.3	0.3	1.0	1	1	0
12/02/2021 16:00	0.3	13.9	1,697.2	0.3	1.0	1	1	0
12/02/2021 17:00	0.3	13.9	1,696.1	0.3	1.0	1	1	0
12/02/2021 18:00	0.3	13.9	1,695.5	0.3	1.0	1	1	0
12/02/2021 19:00	0.3	13.9	1,694.2	0.3	1.0	1	1	0
12/02/2021 20:00	0.4	13.7	1,753.2	0.3	1.3	1	1	0
12/02/2021 21:00	1.1	13.2	1,887.6	0.5	3.6	1	1	1
12/02/2021 22:00	0.6	12.8	1,982.3	0.5	1.9	1	1	1
12/02/2021 23:00	0.6	13.2	1,851.3	0.6	1.9	1	1	1
Average/Sum#:	2.1	14.0	1,524.4	0.3	87.1 #	21 #	19 #	4 #
Minimum:	0.2	12.8	646.8	0.2	0.5	0	0	0
Maximum:	30.4	16.5	1,982.3	0.6	56.1	1	1	1
%SI	12.50	12.50	12.50	29.17	12.50	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/03/2021 00:00	4.9	14.5	1,113.9	0.0	10.4	1	0	0
12/03/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/03/2021 03:00	8.5	18.6	226.9	0.0	2.4	1	0	0
12/03/2021 04:00	32.9	16.1	714.9	0.0	64.7	1	0	0
12/03/2021 05:00	0.3	13.9	1,395.3	0.0	0.8	1	1	0
12/03/2021 06:00	0.4	13.9	1,601.3	0.0	1.2	1	1	0
12/03/2021 07:00	0.8	13.4	1,844.7	0.4	2.6	1	1	1
12/03/2021 08:00	0.6	12.3	2,147.3	0.4	2.0	1	1	1
12/03/2021 09:00	0.4	12.2	2,157.3	0.4	1.3	1	1	1
12/03/2021 10:00	0.4	12.1	2,158.6	0.3	1.3	1	1	1
12/03/2021 11:00	0.4	12.1	2,167.3	0.3	1.3	1	1	1
12/03/2021 12:00	0.4	12.1	2,165.5	0.3	1.3	1	1	1
12/03/2021 13:00	0.4	12.0	2,165.4	0.3	1.3	1	1	1
12/03/2021 14:00	0.4	12.0	2,161.1	0.3	1.3	1	1	1
12/03/2021 15:00	0.4	12.0	2,160.8	0.3	1.3	1	1	1
12/03/2021 16:00	0.6	13.0	1,857.0	0.3	1.9	1	1	1
12/03/2021 17:00	0.3	13.8	1,722.0	0.3	1.0	1	1	0
12/03/2021 18:00	0.3	13.8	1,689.8	0.3	0.9	1	1	0
12/03/2021 19:00	0.4	13.8	1,694.2	0.2	1.3	1	1	1
12/03/2021 20:00	1.2	13.0	1,941.3	0.5	3.9	1	1	1
12/03/2021 21:00	0.6	12.5	2,050.4	0.5	1.9	1	1	1
12/03/2021 22:00	0.6	12.6	2,047.6	0.6	2.0	1	1	1
12/03/2021 23:00	5.3	13.8	1,547.7	0.0	15.3	1	0	1
Average/Sum#:	2.8	13.3	1,760.5	0.4	121.4 #	22 #	18 #	15 #
Minimum:	0.3	12.0	226.9	0.2	0.8	0	0	0
Maximum:	32.9	18.6	2,167.3	0.6	64.7	1	1	1
%SI	8.33	8.33	8.33	33.33	8.33	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/04/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2021 05:00	9.8	18.8	190.7	0.0	2.4	1	0	0
12/04/2021 06:00	24.6	18.1	289.9	0.0	12.8	1	0	0
12/04/2021 07:00	23.4	14.5	1,311.0	0.0	63.3	1	0	0
12/04/2021 08:00	0.3	13.8	1,699.3	0.0	0.9	1	1	0
12/04/2021 09:00	0.4	13.8	1,700.8	0.0	1.3	1	1	0
12/04/2021 10:00	0.3	13.8	1,755.7	0.2	1.0	1	1	0
12/04/2021 11:00	0.3	13.8	1,760.5	0.2	1.0	1	1	0
12/04/2021 12:00	6.0	14.3	1,438.3	0.0	15.9	1	0	0
12/04/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/04/2021 15:00	8.7	18.9	182.3	0.0	1.9	1	0	0
12/04/2021 16:00	33.5	15.8	776.3	0.0	67.3	1	0	0
12/04/2021 17:00	0.3	13.8	1,683.4	0.0	0.9	1	1	0
12/04/2021 18:00	1.4	13.3	1,888.5	0.0	4.6	1	1	1
12/04/2021 19:00	1.2	13.3	1,819.9	0.7	3.8	1	1	1
12/04/2021 20:00	0.4	13.8	1,597.8	0.8	1.2	1	1	0
12/04/2021 21:00	0.4	13.8	1,580.6	0.5	1.2	1	1	0
12/04/2021 22:00	0.4	13.8	1,565.3	0.3	1.2	1	1	0
12/04/2021 23:00	21.5	15.9	526.3	0.0	6.6	1	0	0
Average/Sum#:	7.8	14.9	1,280.4	0.5	187.3 #	17 #	10 #	2 #
Minimum:	0.3	13.3	182.3	0.2	0.9	0	0	0
Maximum:	33.5	18.9	1,888.5	0.8	67.3	1	1	1
%SI	29.17	29.17	29.17	75.00	29.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/05/2021 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/05/2021 13:00	46.8	18.0	309.9	0.0	26.4	1	0	0
12/05/2021 14:00	27.0	15.3	925.2	0.0	58.9	1	0	0
12/05/2021 15:00	0.3	13.9	1,651.9	0.0	0.9	1	1	0
12/05/2021 16:00	0.3	13.8	1,581.7	0.0	0.9	1	1	1
12/05/2021 17:00	1.1	13.0	1,937.9	0.4	3.6	1	1	1
12/05/2021 18:00	0.6	12.5	2,065.2	0.5	1.9	1	1	1
12/05/2021 19:00	0.6	12.5	2,087.6	0.5	2.0	1	1	1
12/05/2021 20:00	0.5	12.2	2,167.8	0.4	1.6	1	1	1
12/05/2021 21:00	0.5	12.4	2,114.9	0.3	1.6	1	1	1
12/05/2021 22:00	0.5	12.4	2,113.8	0.3	1.6	1	1	1
12/05/2021 23:00	0.6	12.7	2,039.7	0.3	2.0	1	1	1
Average/Sum#:	7.2	13.5	1,726.9	0.4	101.4 #	11 #	9 #	8 #
Minimum:	0.3	12.2	309.9	0.3	0.9	0	0	0
Maximum:	46.8	18.0	2,167.8	0.5	58.9	1	1	1
%SI	54.17	54.17	54.17	70.83	54.17	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/06/2021 00:00	1.0	13.0	1,944.7	0.5	3.3	1	1	1
12/06/2021 01:00	0.3	13.8	1,673.4	0.4	0.9	1	1	0
12/06/2021 02:00	0.4	13.8	1,727.9	0.4	1.3	1	1	1
12/06/2021 03:00	0.9	13.2	1,939.5	0.4	3.0	1	1	1
12/06/2021 04:00	0.9	13.2	1,916.5	0.6	3.0	1	1	1
12/06/2021 05:00	0.3	13.8	1,608.7	0.5	0.9	1	1	0
12/06/2021 06:00	0.9	13.2	1,848.8	0.5	2.9	1	1	1
12/06/2021 07:00	0.6	12.4	2,123.2	0.4	2.0	1	1	1
12/06/2021 08:00	0.5	12.4	2,122.0	0.5	1.6	1	1	1
12/06/2021 09:00	0.5	13.6	1,694.1	0.4	1.5	1	1	1
12/06/2021 10:00	0.3	13.8	1,760.3	0.3	1.0	1	1	0
12/06/2021 11:00	1.0	13.1	1,965.7	0.5	3.3	1	1	1
12/06/2021 12:00	0.5	12.3	2,128.2	0.4	1.6	1	1	1
12/06/2021 13:00	0.6	13.0	1,878.4	0.5	1.9	1	1	1
12/06/2021 14:00	0.3	13.8	1,609.1	0.3	0.9	1	1	0
12/06/2021 15:00	1.0	13.5	1,802.0	0.5	3.2	1	1	1
12/06/2021 16:00	0.7	12.7	2,031.4	0.5	2.3	1	1	1
12/06/2021 17:00	0.6	12.6	2,067.8	0.6	2.0	1	1	1
12/06/2021 18:00	0.5	12.2	2,154.2	0.4	1.6	1	1	1
12/06/2021 19:00	0.5	12.4	2,112.9	0.3	1.6	1	1	1
12/06/2021 20:00	0.5	12.3	2,136.7	0.3	1.6	1	1	1
12/06/2021 21:00	0.6	12.6	2,069.5	0.3	2.0	1	1	1
12/06/2021 22:00	0.6	12.6	2,065.4	0.4	2.0	1	1	1
12/06/2021 23:00	0.6	12.6	2,069.0	0.4	2.0	1	1	1
Average/Sum#:	0.6	13.0	1,935.4	0.4	47.4 #	24 #	24 #	20 #
Minimum:	0.3	12.2	1,608.7	0.3	0.9	1	1	0
Maximum:	1.0	13.8	2,154.2	0.6	3.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/07/2021 00:00	0.7	12.7	2,027.5	0.4	2.3	1	1	1
12/07/2021 01:00	0.4	13.8	1,501.4	0.4	1.1	1	1	1
12/07/2021 02:00	0.5	13.8	1,657.4	0.4	1.5	1	1	1
12/07/2021 03:00	1.3	13.2	1,918.6	0.6	4.3	1	1	1
12/07/2021 04:00	0.6	12.6	2,055.9	0.6	2.0	1	1	1
12/07/2021 05:00	0.5	13.7	1,691.1	0.6	1.6	1	1	1
12/07/2021 06:00	0.3	13.8	1,616.9	0.3	0.9	1	1	0
12/07/2021 07:00	1.1	13.1	1,930.6	0.5	3.6	1	1	1
12/07/2021 08:00	0.5	12.3	2,140.3	0.4	1.6	1	1	1
12/07/2021 09:00	0.6	12.5	2,049.5	0.5	1.9	1	1	1
12/07/2021 10:00	0.3	13.7	1,775.2	0.3	1.0	1	1	0
12/07/2021 11:00	0.3	13.7	1,777.3	0.3	1.0	1	1	0
12/07/2021 12:00	0.3	13.7	1,749.5	0.2	1.0	1	1	0
12/07/2021 13:00	0.4	13.7	1,746.6	0.2	1.3	1	1	1
12/07/2021 14:00	0.5	12.6	2,004.1	0.3	1.6	1	1	1
12/07/2021 15:00	0.4	12.0	2,132.8	0.3	1.3	1	1	1
12/07/2021 16:00	0.4	12.0	2,165.3	0.3	1.3	1	1	1
12/07/2021 17:00	0.4	12.1	2,143.7	0.3	1.3	1	1	1
12/07/2021 18:00	0.5	12.1	2,155.7	0.3	1.6	1	1	1
12/07/2021 19:00	0.5	12.2	2,142.4	0.3	1.6	1	1	1
12/07/2021 20:00	0.5	12.2	2,143.1	0.3	1.6	1	1	1
12/07/2021 21:00	0.5	12.2	2,138.7	0.3	1.6	1	1	1
12/07/2021 22:00	0.5	12.5	2,075.2	0.3	1.6	1	1	1
12/07/2021 23:00	0.6	12.5	2,065.7	0.4	1.9	1	1	1
Average/Sum#:	0.5	12.9	1,950.2	0.4	40.5 #	24 #	24 #	20 #
Minimum:	0.3	12.0	1,501.4	0.2	0.9	1	1	0
Maximum:	1.3	13.8	2,165.3	0.6	4.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/08/2021 00:00	0.7	12.7	1,997.5	0.4	2.3	1	1	1
12/08/2021 01:00	0.3	13.9	1,575.5	0.4	0.9	1	1	0
12/08/2021 02:00	0.3	13.9	1,296.2	0.4	0.7	1	1	0
12/08/2021 03:00	0.4	13.8	1,707.2	0.3	1.3	1	1	0
12/08/2021 04:00	0.8	13.4	1,794.3	0.4	2.5	1	1	1
12/08/2021 05:00	0.7	13.2	1,839.7	0.5	2.2	1	1	1
12/08/2021 06:00	0.3	13.8	1,730.5	0.4	1.0	1	1	1
12/08/2021 07:00	1.1	13.0	1,949.8	0.5	3.6	1	1	1
12/08/2021 08:00	0.9	13.2	1,829.4	0.6	2.8	1	1	1
12/08/2021 09:00	0.3	13.9	1,348.3	0.6	0.8	1	1	0
12/08/2021 10:00	0.3	13.9	1,313.8	0.4	0.7	1	1	0
12/08/2021 11:00	0.4	13.8	1,692.8	0.3	1.3	1	1	0
12/08/2021 12:00	1.1	13.4	1,816.1	0.5	3.5	1	1	1
12/08/2021 13:00	1.1	13.4	1,802.7	0.7	3.5	1	1	1
12/08/2021 14:00	0.3	13.9	1,291.8	0.7	0.7	1	1	0
12/08/2021 15:00	0.3	13.9	1,365.0	0.5	0.8	1	1	0
12/08/2021 16:00	0.4	13.8	1,681.7	0.3	1.3	1	1	0
12/08/2021 17:00	1.4	13.1	1,931.5	0.6	4.6	1	1	1
12/08/2021 18:00	0.6	12.4	2,091.0	0.6	1.9	1	1	1
12/08/2021 19:00	0.6	12.4	2,081.3	0.6	1.9	1	1	1
12/08/2021 20:00	0.6	12.5	2,066.9	0.4	1.9	1	1	1
12/08/2021 21:00	0.6	12.7	2,010.8	0.4	1.9	1	1	1
12/08/2021 22:00	0.6	12.8	1,991.7	0.4	1.9	1	1	1
12/08/2021 23:00	0.6	12.7	2,012.3	0.4	1.9	1	1	1
Average/Sum#:	0.6	13.3	1,759.1	0.5	45.9 #	24 #	24 #	15 #
Minimum:	0.3	12.4	1,291.8	0.3	0.7	1	1	0
Maximum:	1.4	13.9	2,091.0	0.7	4.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/09/2021 00:00	1.4	13.2	1,895.8	0.6	4.6	1	1	1
12/09/2021 01:00	0.4	13.9	1,468.3	0.6	1.1	1	1	0
12/09/2021 02:00	0.4	13.8	1,547.9	0.6	1.2	1	1	1
12/09/2021 03:00	1.4	13.1	1,921.3	0.6	4.6	1	1	1
12/09/2021 04:00	0.9	12.9	1,943.7	0.7	2.9	1	1	1
12/09/2021 05:00	0.4	13.9	1,518.3	0.7	1.1	1	1	0
12/09/2021 06:00	0.4	13.8	1,600.6	0.4	1.2	1	1	1
12/09/2021 07:00	1.6	13.1	1,941.6	0.6	5.3	1	1	1
12/09/2021 08:00	0.6	12.8	2,001.0	0.6	2.0	1	1	1
12/09/2021 09:00	0.7	12.8	1,998.0	0.7	2.3	1	1	1
12/09/2021 10:00	0.4	13.8	1,577.9	0.4	1.2	1	1	1
12/09/2021 11:00	0.3	13.8	1,683.7	0.3	0.9	1	1	1
12/09/2021 12:00	0.6	12.9	1,966.4	0.3	1.9	1	1	1
12/09/2021 13:00	0.6	13.0	1,937.1	0.3	1.9	1	1	1
12/09/2021 14:00	0.2	14.0	1,428.9	0.3	0.5	1	1	0
12/09/2021 15:00	0.3	13.9	1,480.9	0.3	0.8	1	1	1
12/09/2021 16:00	0.8	13.1	1,944.6	0.4	2.6	1	1	1
12/09/2021 17:00	0.5	12.5	2,078.3	0.4	1.6	1	1	1
12/09/2021 18:00	0.5	12.6	2,053.9	0.5	1.6	1	1	1
12/09/2021 19:00	0.5	12.5	2,078.5	0.4	1.6	1	1	1
12/09/2021 20:00	0.5	12.5	2,084.7	0.4	1.6	1	1	1
12/09/2021 21:00	0.5	12.5	2,084.9	0.4	1.6	1	1	1
12/09/2021 22:00	0.8	13.0	1,970.1	0.5	2.6	1	1	1
12/09/2021 23:00	0.5	12.9	1,996.3	0.5	1.6	1	1	1
Average/Sum#:	0.6	13.2	1,841.8	0.5	48.3 #	24 #	24 #	21 #
Minimum:	0.2	12.5	1,428.9	0.3	0.5	1	1	0
Maximum:	1.6	14.0	2,084.9	0.7	5.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/10/2021 00:00	1.1	13.2	1,906.6	0.6	3.6	1	1	1
12/10/2021 01:00	0.3	13.9	1,512.5	0.5	0.9	1	1	0
12/10/2021 02:00	0.3	13.9	1,582.0	0.5	0.9	1	1	0
12/10/2021 03:00	1.2	13.4	1,883.4	0.5	4.0	1	1	1
12/10/2021 04:00	1.2	13.3	1,906.9	0.7	4.0	1	1	1
12/10/2021 05:00	0.3	13.9	1,587.5	0.7	0.9	1	1	0
12/10/2021 06:00	0.3	13.8	1,709.9	0.5	1.0	1	1	1
12/10/2021 07:00	0.9	13.3	1,935.7	0.4	3.0	1	1	1
12/10/2021 08:00	0.9	13.3	1,904.4	0.5	3.0	1	1	1
12/10/2021 09:00	0.3	13.9	1,582.3	0.6	0.9	1	1	0
12/10/2021 10:00	0.3	13.9	1,666.5	0.4	0.9	1	1	0
12/10/2021 11:00	0.3	13.9	1,598.7	0.3	0.9	1	1	0
12/10/2021 12:00	0.3	13.9	1,650.1	0.3	0.9	1	1	0
12/10/2021 13:00	0.3	13.9	1,572.6	0.3	0.9	1	1	0
12/10/2021 14:00	0.3	14.0	1,290.1	0.3	0.7	1	1	0
12/10/2021 15:00	0.3	13.9	1,550.9	0.3	0.9	1	1	0
12/10/2021 16:00	1.4	13.3	1,922.0	0.6	4.7	1	1	1
12/10/2021 17:00	0.5	12.3	2,150.4	0.6	1.7	1	1	1
12/10/2021 18:00	0.5	12.4	2,120.0	0.6	1.6	1	1	1
12/10/2021 19:00	0.5	12.4	2,122.0	0.3	1.6	1	1	1
12/10/2021 20:00	0.5	12.3	2,147.6	0.3	1.6	1	1	1
12/10/2021 21:00	0.5	12.5	2,106.8	0.3	1.7	1	1	1
12/10/2021 22:00	0.6	12.8	2,053.4	0.4	2.0	1	1	1
12/10/2021 23:00	0.6	12.9	2,056.0	0.4	2.0	1	1	1
Average/Sum#:	0.6	13.3	1,813.3	0.5	44.3 #	24 #	24 #	14 #
Minimum:	0.3	12.3	1,290.1	0.3	0.7	1	1	0
Maximum:	1.4	14.0	2,150.4	0.7	4.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/11/2021 00:00	0.7	12.8	2,053.8	0.4	2.3	1	1	1
12/11/2021 01:00	0.8	13.1	1,995.8	0.5	2.7	1	1	1
12/11/2021 02:00	1.4	13.3	1,899.3	0.7	4.6	1	1	1
12/11/2021 03:00	0.3	13.9	1,596.5	0.7	0.9	1	1	0
12/11/2021 04:00	0.4	13.8	1,665.1	0.6	1.2	1	1	1
12/11/2021 05:00	0.9	13.2	1,976.3	0.4	3.1	1	1	1
12/11/2021 06:00	0.6	12.9	2,043.3	0.5	2.0	1	1	1
12/11/2021 07:00	0.7	13.1	1,982.2	0.5	2.3	1	1	1
12/11/2021 08:00	0.3	13.9	1,582.6	0.4	0.9	1	1	0
12/11/2021 09:00	0.4	13.9	1,365.7	0.4	1.0	1	1	0
12/11/2021 10:00	0.4	13.9	1,399.0	0.3	1.1	1	1	0
12/11/2021 11:00	0.4	13.9	1,300.8	0.3	1.0	1	1	0
12/11/2021 12:00	0.4	13.9	1,299.0	0.3	1.0	1	1	0
12/11/2021 13:00	0.4	13.9	1,479.4	0.3	1.1	1	1	0
12/11/2021 14:00	0.4	13.9	1,518.2	0.3	1.1	1	1	0
12/11/2021 15:00	0.4	13.8	1,608.2	0.3	1.2	1	1	0
12/11/2021 16:00	0.7	12.8	2,055.8	0.4	2.3	1	1	1
12/11/2021 17:00	0.4	12.4	2,149.6	0.4	1.3	1	1	1
12/11/2021 18:00	0.4	12.5	2,135.0	0.4	1.3	1	1	1
12/11/2021 19:00	0.4	12.3	2,169.0	0.3	1.3	1	1	1
12/11/2021 20:00	0.4	12.5	2,132.0	0.3	1.3	1	1	1
12/11/2021 21:00	0.4	12.3	2,165.8	0.3	1.3	1	1	1
12/11/2021 22:00	0.4	12.5	2,127.1	0.3	1.3	1	1	1
12/11/2021 23:00	0.5	12.8	2,045.4	0.3	1.7	1	1	1
Average/Sum#:	0.5	13.2	1,822.7	0.4	39.3 #	24 #	24 #	15 #
Minimum:	0.3	12.3	1,299.0	0.3	0.9	1	1	0
Maximum:	1.4	13.9	2,169.0	0.7	4.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/12/2021 00:00	0.5	12.8	2,035.7	0.4	1.7	1	1	1
12/12/2021 01:00	0.5	13.0	1,993.6	0.4	1.7	1	1	1
12/12/2021 02:00	0.9	13.3	1,892.2	0.5	3.0	1	1	1
12/12/2021 03:00	0.4	13.9	1,574.5	0.5	1.2	1	1	0
12/12/2021 04:00	0.4	13.8	1,711.2	0.4	1.3	1	1	1
12/12/2021 05:00	0.7	13.0	1,967.2	0.4	2.3	1	1	1
12/12/2021 06:00	0.6	13.0	1,996.1	0.4	2.0	1	1	1
12/12/2021 07:00	0.4	13.8	1,599.3	0.4	1.2	1	1	1
12/12/2021 08:00	0.4	13.9	1,570.1	0.3	1.2	1	1	0
12/12/2021 09:00	0.4	13.9	1,374.3	0.3	1.0	1	1	0
12/12/2021 10:00	0.4	13.8	1,573.3	0.3	1.2	1	1	0
12/12/2021 11:00	0.4	13.8	1,665.6	0.3	1.2	1	1	0
12/12/2021 12:00	0.4	13.8	1,586.0	0.3	1.2	1	1	0
12/12/2021 13:00	0.4	13.8	1,611.2	0.3	1.2	1	1	0
12/12/2021 14:00	0.4	13.8	1,568.5	0.3	1.2	1	1	0
12/12/2021 15:00	0.5	13.8	1,563.4	0.3	1.5	1	1	1
12/12/2021 16:00	0.7	12.8	2,015.8	0.4	2.3	1	1	1
12/12/2021 17:00	0.4	12.5	2,090.9	0.4	1.3	1	1	1
12/12/2021 18:00	0.4	12.5	2,084.7	0.4	1.3	1	1	1
12/12/2021 19:00	0.4	12.3	2,127.0	0.3	1.3	1	1	1
12/12/2021 20:00	0.4	12.5	2,077.0	0.3	1.3	1	1	1
12/12/2021 21:00	0.4	12.5	2,080.2	0.3	1.3	1	1	1
12/12/2021 22:00	0.4	12.6	2,053.3	0.3	1.3	1	1	1
12/12/2021 23:00	0.5	12.8	2,007.9	0.3	1.6	1	1	1
Average/Sum#:	0.5	13.2	1,825.8	0.4	35.8 #	24 #	24 #	16 #
Minimum:	0.4	12.3	1,374.3	0.3	1.0	1	1	0
Maximum:	0.9	13.9	2,127.0	0.5	3.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/13/2021 00:00	0.9	13.2	1,897.0	0.5	2.9	1	1	1
12/13/2021 01:00	0.4	13.8	1,670.8	0.5	1.2	1	1	0
12/13/2021 02:00	0.4	13.8	1,646.7	0.4	1.2	1	1	1
12/13/2021 03:00	0.8	12.9	1,968.0	0.4	2.6	1	1	1
12/13/2021 04:00	1.1	13.0	1,912.8	0.6	3.5	1	1	1
12/13/2021 05:00	0.4	13.9	1,568.6	0.6	1.2	1	1	0
12/13/2021 06:00	0.5	13.7	1,753.4	0.5	1.6	1	1	1
12/13/2021 07:00	0.9	12.6	2,037.1	0.4	2.9	1	1	1
12/13/2021 08:00	0.5	12.2	2,128.6	0.4	1.6	1	1	1
12/13/2021 09:00	0.5	12.3	2,100.2	0.4	1.6	1	1	1
12/13/2021 10:00	0.5	12.4	2,069.5	0.3	1.6	1	1	1
12/13/2021 11:00	0.7	12.8	1,966.3	0.4	2.2	1	1	1
12/13/2021 12:00	0.3	13.9	1,620.9	0.4	0.9	1	1	0
12/13/2021 13:00	0.4	13.7	1,764.2	0.4	1.3	1	1	1
12/13/2021 14:00	0.6	12.8	1,994.4	0.3	2.0	1	1	1
12/13/2021 15:00	0.4	12.2	2,141.6	0.3	1.3	1	1	1
12/13/2021 16:00	0.4	12.1	2,170.0	0.3	1.3	1	1	1
12/13/2021 17:00	0.3	12.0	2,179.8	0.3	1.0	1	1	1
12/13/2021 18:00	0.3	12.1	2,174.9	0.2	1.0	1	1	1
12/13/2021 19:00	0.4	11.9	2,193.4	0.2	1.3	1	1	1
12/13/2021 20:00	0.5	12.3	2,092.1	0.3	1.6	1	1	1
12/13/2021 21:00	0.5	12.6	2,040.2	0.3	1.6	1	1	1
12/13/2021 22:00	0.7	12.8	1,991.0	0.4	2.3	1	1	1
12/13/2021 23:00	0.6	12.8	1,997.2	0.4	2.0	1	1	1
Average/Sum#:	0.5	12.8	1,961.6	0.4	41.7 #	24 #	24 #	21 #
Minimum:	0.3	11.9	1,568.6	0.2	0.9	1	1	0
Maximum:	1.1	13.9	2,193.4	0.6	3.5	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/14/2021 00:00	1.0	13.3	1,806.2	0.6	3.1	1	1	1
12/14/2021 01:00	0.3	13.9	1,275.7	0.5	0.7	1	1	0
12/14/2021 02:00	0.4	13.9	1,295.1	0.5	1.0	1	1	0
12/14/2021 03:00	0.4	13.8	1,715.6	0.3	1.3	1	1	0
12/14/2021 04:00	1.3	13.5	1,831.2	0.5	4.2	1	1	1
12/14/2021 05:00	0.9	13.3	1,818.3	0.7	2.8	1	1	1
12/14/2021 06:00	0.4	13.8	1,686.4	0.7	1.3	1	1	1
12/14/2021 07:00	0.6	12.9	2,022.3	0.5	2.0	1	1	1
12/14/2021 08:00	0.5	12.7	2,059.8	0.4	1.7	1	1	1
12/14/2021 09:00	0.7	13.1	1,935.1	0.4	2.3	1	1	1
12/14/2021 10:00	0.3	13.9	1,591.5	0.4	0.9	1	1	0
12/14/2021 11:00	0.4	13.8	1,606.5	0.4	1.2	1	1	1
12/14/2021 12:00	0.6	13.0	1,988.6	0.3	2.0	1	1	1
12/14/2021 13:00	0.8	13.3	1,897.5	0.4	2.6	1	1	1
12/14/2021 14:00	0.3	13.9	1,623.3	0.4	0.9	1	1	0
12/14/2021 15:00	0.3	13.9	1,510.4	0.4	0.9	1	1	0
12/14/2021 16:00	0.6	13.1	1,948.4	0.4	2.0	1	1	1
12/14/2021 17:00	0.4	12.2	2,195.7	0.4	1.3	1	1	1
12/14/2021 18:00	0.4	12.4	2,155.7	0.4	1.3	1	1	1
12/14/2021 19:00	0.4	12.2	2,192.6	0.3	1.3	1	1	1
12/14/2021 20:00	0.4	12.2	2,196.1	0.3	1.3	1	1	1
12/14/2021 21:00	0.4	12.4	2,153.1	0.3	1.3	1	1	1
12/14/2021 22:00	0.4	12.7	2,075.7	0.3	1.3	1	1	1
12/14/2021 23:00	0.6	13.1	1,995.8	0.4	2.0	1	1	1
Average/Sum#:	0.5	13.2	1,857.4	0.4	40.7 #	24 #	24 #	18 #
Minimum:	0.3	12.2	1,275.7	0.3	0.7	1	1	0
Maximum:	1.3	13.9	2,196.1	0.7	4.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/15/2021 00:00	1.0	13.2	1,925.9	0.5	3.3	1	1	1
12/15/2021 01:00	0.3	13.9	1,530.8	0.5	0.9	1	1	0
12/15/2021 02:00	0.4	13.8	1,636.2	0.5	1.2	1	1	1
12/15/2021 03:00	1.0	13.3	1,918.0	0.5	3.3	1	1	1
12/15/2021 04:00	1.0	13.3	1,905.7	0.6	3.3	1	1	1
12/15/2021 05:00	0.4	13.9	1,556.9	0.6	1.2	1	1	0
12/15/2021 06:00	0.7	13.3	1,857.5	0.5	2.3	1	1	1
12/15/2021 07:00	0.5	12.6	2,108.6	0.4	1.7	1	1	1
12/15/2021 08:00	1.0	13.1	1,952.9	0.6	3.3	1	1	1
12/15/2021 09:00	0.3	13.9	1,569.3	0.5	0.9	1	1	0
12/15/2021 10:00	0.4	13.8	1,594.3	0.5	1.2	1	1	0
12/15/2021 11:00	0.4	13.8	1,585.1	0.3	1.2	1	1	1
12/15/2021 12:00	1.0	13.0	1,979.7	0.4	3.3	1	1	1
12/15/2021 13:00	0.9	12.9	1,978.1	0.6	2.9	1	1	1
12/15/2021 14:00	0.3	13.9	1,537.7	0.6	0.9	1	1	0
12/15/2021 15:00	0.4	13.8	1,694.9	0.4	1.3	1	1	1
12/15/2021 16:00	0.5	12.6	2,080.8	0.3	1.7	1	1	1
12/15/2021 17:00	0.4	12.1	2,195.1	0.3	1.3	1	1	1
12/15/2021 18:00	0.4	12.2	2,187.3	0.3	1.3	1	1	1
12/15/2021 19:00	0.4	12.2	2,185.5	0.3	1.3	1	1	1
12/15/2021 20:00	0.4	12.2	2,187.7	0.3	1.3	1	1	1
12/15/2021 21:00	0.4	12.3	2,149.5	0.3	1.3	1	1	1
12/15/2021 22:00	0.5	12.6	2,076.3	0.3	1.7	1	1	1
12/15/2021 23:00	0.5	12.7	2,049.8	0.4	1.7	1	1	1
Average/Sum#:	0.6	13.1	1,893.5	0.4	43.8 #	24 #	24 #	19 #
Minimum:	0.3	12.1	1,530.8	0.3	0.9	1	1	0
Maximum:	1.0	13.9	2,195.1	0.6	3.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/16/2021 00:00	0.5	12.9	2,008.6	0.4	1.7	1	1	1
12/16/2021 01:00	0.7	13.1	1,928.9	0.4	2.3	1	1	1
12/16/2021 02:00	0.4	13.9	1,551.7	0.4	1.2	1	1	0
12/16/2021 03:00	0.4	13.9	1,553.4	0.4	1.2	1	1	0
12/16/2021 04:00	0.4	13.8	1,593.3	0.3	1.2	1	1	1
12/16/2021 05:00	0.7	13.0	1,998.6	0.4	2.3	1	1	1
12/16/2021 06:00	0.4	12.3	2,178.2	0.4	1.3	1	1	1
12/16/2021 07:00	0.4	12.3	2,165.3	0.4	1.3	1	1	1
12/16/2021 08:00	0.5	12.9	1,998.3	0.3	1.6	1	1	1
12/16/2021 09:00	1.0	13.1	1,944.0	0.5	3.3	1	1	1
12/16/2021 10:00	0.5	13.7	1,473.4	0.5	1.4	1	1	1
12/16/2021 11:00	0.4	13.8	1,589.2	0.5	1.2	1	1	1
12/16/2021 12:00	1.1	12.9	1,989.7	0.5	3.6	1	1	1
12/16/2021 13:00	1.0	13.2	1,905.6	0.6	3.3	1	1	1
12/16/2021 14:00	0.4	13.9	1,530.4	0.6	1.2	1	1	0
12/16/2021 15:00	0.5	13.8	1,568.0	0.5	1.5	1	1	1
12/16/2021 16:00	1.3	12.6	2,075.8	0.5	4.3	1	1	1
12/16/2021 17:00	0.6	12.1	2,200.8	0.6	2.0	1	1	1
12/16/2021 18:00	0.6	12.1	2,200.9	0.6	2.0	1	1	1
12/16/2021 19:00	0.6	12.1	2,200.3	0.4	2.0	1	1	1
12/16/2021 20:00	0.6	12.1	2,202.0	0.4	2.0	1	1	1
12/16/2021 21:00	0.6	12.2	2,180.6	0.4	2.0	1	1	1
12/16/2021 22:00	0.7	12.7	2,071.6	0.4	2.3	1	1	1
12/16/2021 23:00	0.8	12.8	2,032.0	0.5	2.7	1	1	1
Average/Sum#:	0.6	13.0	1,922.5	0.5	48.9 #	24 #	24 #	21 #
Minimum:	0.4	12.1	1,473.4	0.3	1.2	1	1	0
Maximum:	1.3	13.9	2,202.0	0.6	4.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/17/2021 00:00	1.3	13.3	1,893.8	0.7	4.3	1	1	1
12/17/2021 01:00	0.4	13.9	1,532.7	0.6	1.2	1	1	0
12/17/2021 02:00	0.4	13.9	1,527.6	0.5	1.2	1	1	0
12/17/2021 03:00	0.4	13.8	1,676.0	0.3	1.2	1	1	1
12/17/2021 04:00	1.3	13.1	1,975.0	0.5	4.3	1	1	1
12/17/2021 05:00	1.2	13.1	1,979.0	0.7	4.0	1	1	1
12/17/2021 06:00	0.6	12.3	2,156.0	0.8	2.0	1	1	1
12/17/2021 07:00	0.6	12.4	2,129.7	0.6	2.0	1	1	1
12/17/2021 08:00	0.9	13.1	1,992.5	0.5	3.0	1	1	1
12/17/2021 09:00	1.0	13.3	1,905.9	0.6	3.3	1	1	1
12/17/2021 10:00	0.4	13.9	1,552.3	0.6	1.2	1	1	0
12/17/2021 11:00	0.4	13.9	1,518.0	0.5	1.1	1	1	0
12/17/2021 12:00	0.4	14.0	1,366.5	0.3	1.0	1	1	0
12/17/2021 13:00	0.4	13.9	1,625.8	0.3	1.2	1	1	0
12/17/2021 14:00	0.4	13.9	1,469.5	0.3	1.1	1	1	0
12/17/2021 15:00	0.4	13.9	1,575.2	0.3	1.2	1	1	1
12/17/2021 16:00	1.5	12.9	2,006.6	0.6	5.0	1	1	1
12/17/2021 17:00	0.5	12.1	2,185.5	0.6	1.6	1	1	1
12/17/2021 18:00	0.5	12.1	2,187.8	0.6	1.6	1	1	1
12/17/2021 19:00	0.5	12.2	2,185.9	0.3	1.7	1	1	1
12/17/2021 20:00	0.5	12.1	2,188.9	0.3	1.6	1	1	1
12/17/2021 21:00	0.5	12.2	2,179.0	0.3	1.7	1	1	1
12/17/2021 22:00	0.7	12.7	2,064.9	0.4	2.3	1	1	1
12/17/2021 23:00	0.9	13.0	1,993.7	0.5	3.0	1	1	1
Average/Sum#:	0.7	13.1	1,869.5	0.5	51.8 #	24 #	24 #	17 #
Minimum:	0.4	12.1	1,366.5	0.3	1.0	1	1	0
Maximum:	1.5	14.0	2,188.9	0.8	5.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/18/2021 00:00	1.1	13.2	1,906.6	0.7	3.6	1	1	1
12/18/2021 01:00	0.4	13.8	1,588.9	0.6	1.2	1	1	1
12/18/2021 02:00	0.4	13.8	1,694.7	0.5	1.3	1	1	0
12/18/2021 03:00	0.8	13.3	1,947.8	0.4	2.7	1	1	1
12/18/2021 04:00	0.8	13.2	1,959.8	0.5	2.7	1	1	1
12/18/2021 05:00	0.4	13.8	1,653.3	0.5	1.2	1	1	1
12/18/2021 06:00	0.4	13.8	1,737.8	0.4	1.3	1	1	1
12/18/2021 07:00	0.9	13.1	2,002.3	0.4	3.1	1	1	1
12/18/2021 08:00	1.1	13.1	1,997.8	0.6	3.7	1	1	1
12/18/2021 09:00	1.0	13.1	1,969.5	0.8	3.3	1	1	1
12/18/2021 10:00	0.4	13.9	1,529.6	0.6	1.2	1	1	0
12/18/2021 11:00	0.4	13.9	1,564.8	0.5	1.2	1	1	0
12/18/2021 12:00	0.4	13.9	1,527.1	0.3	1.2	1	1	0
12/18/2021 13:00	0.4	13.9	1,514.1	0.3	1.1	1	1	0
12/18/2021 14:00	0.4	13.9	1,526.1	0.3	1.2	1	1	0
12/18/2021 15:00	0.4	13.9	1,481.0	0.3	1.1	1	1	0
12/18/2021 16:00	0.9	13.3	1,840.4	0.4	2.9	1	1	1
12/18/2021 17:00	0.6	12.4	2,136.6	0.5	2.0	1	1	1
12/18/2021 18:00	0.7	12.6	2,086.0	0.5	2.3	1	1	1
12/18/2021 19:00	0.6	12.3	2,158.6	0.4	2.0	1	1	1
12/18/2021 20:00	0.6	12.2	2,179.7	0.4	2.0	1	1	1
12/18/2021 21:00	0.6	12.5	2,102.7	0.4	2.0	1	1	1
12/18/2021 22:00	0.7	12.8	2,056.2	0.4	2.3	1	1	1
12/18/2021 23:00	0.9	13.0	1,987.9	0.5	3.0	1	1	1
Average/Sum#:	0.6	13.3	1,839.6	0.5	49.6 #	24 #	24 #	17 #
Minimum:	0.4	12.2	1,481.0	0.3	1.1	1	1	0
Maximum:	1.1	13.9	2,179.7	0.8	3.7	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/19/2021 00:00	0.7	12.9	2,022.7	0.6	2.3	1	1	1
12/19/2021 01:00	1.0	13.1	1,964.3	0.7	3.3	1	1	1
12/19/2021 02:00	0.4	13.9	1,596.1	0.5	1.2	1	1	0
12/19/2021 03:00	0.4	13.8	1,664.6	0.5	1.2	1	1	0
12/19/2021 04:00	0.6	13.2	1,960.3	0.4	2.0	1	1	1
12/19/2021 05:00	0.6	13.1	1,982.3	0.4	2.0	1	1	1
12/19/2021 06:00	0.7	13.2	1,947.3	0.5	2.3	1	1	1
12/19/2021 07:00	0.7	13.1	1,983.3	0.5	2.4	1	1	1
12/19/2021 08:00	0.7	13.1	1,984.6	0.5	2.4	1	1	1
12/19/2021 09:00	0.8	13.3	1,917.3	0.5	2.7	1	1	1
12/19/2021 10:00	0.4	13.9	1,481.7	0.5	1.1	1	1	0
12/19/2021 11:00	0.4	13.9	1,470.8	0.4	1.1	1	1	0
12/19/2021 12:00	0.4	13.9	1,432.6	0.3	1.1	1	1	0
12/19/2021 13:00	0.4	13.9	1,575.5	0.3	1.2	1	1	0
12/19/2021 14:00	0.4	13.9	1,576.4	0.3	1.2	1	1	0
12/19/2021 15:00	0.4	13.9	1,564.3	0.3	1.2	1	1	0
12/19/2021 16:00	0.8	13.1	1,958.5	0.4	2.7	1	1	1
12/19/2021 17:00	0.6	12.4	2,142.5	0.4	2.0	1	1	1
12/19/2021 18:00	0.6	12.7	2,077.9	0.5	2.0	1	1	1
12/19/2021 19:00	0.6	12.6	2,100.5	0.4	2.0	1	1	1
12/19/2021 20:00	0.7	12.6	2,083.2	0.4	2.3	1	1	1
12/19/2021 21:00	0.6	12.7	2,075.3	0.4	2.0	1	1	1
12/19/2021 22:00	0.6	12.7	2,070.6	0.4	2.0	1	1	1
12/19/2021 23:00	0.7	12.8	2,034.7	0.4	2.3	1	1	1
Average/Sum#:	0.6	13.2	1,861.1	0.4	46.0 #	24 #	24 #	16 #
Minimum:	0.4	12.4	1,432.6	0.3	1.1	1	1	0
Maximum:	1.0	13.9	2,142.5	0.7	3.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/20/2021 00:00	0.7	12.9	2,032.3	0.5	2.3	1	1	1
12/20/2021 01:00	1.0	13.1	1,947.6	0.6	3.3	1	1	1
12/20/2021 02:00	0.4	13.8	1,680.8	0.5	1.3	1	1	0
12/20/2021 03:00	0.4	13.8	1,714.5	0.5	1.3	1	1	1
12/20/2021 04:00	0.8	13.1	1,988.3	0.4	2.7	1	1	1
12/20/2021 05:00	0.7	12.7	2,082.6	0.5	2.3	1	1	1
12/20/2021 06:00	0.6	12.3	2,153.8	0.5	2.0	1	1	1
12/20/2021 07:00	0.6	12.7	2,076.5	0.4	2.0	1	1	1
12/20/2021 08:00	0.9	13.1	1,963.9	0.5	3.0	1	1	1
12/20/2021 09:00	0.3	13.9	1,638.9	0.5	0.9	1	1	0
12/20/2021 10:00	0.4	13.9	1,328.5	0.4	1.0	1	1	0
12/20/2021 11:00	0.4	13.8	1,624.1	0.3	1.2	1	1	0
12/20/2021 12:00	0.7	13.4	1,844.7	0.4	2.3	1	1	1
12/20/2021 13:00	0.6	12.6	2,084.1	0.4	2.0	1	1	1
12/20/2021 14:00	0.6	12.3	2,145.1	0.5	2.0	1	1	1
12/20/2021 15:00	0.5	12.3	2,139.9	0.4	1.6	1	1	1
12/20/2021 16:00	0.5	12.2	2,176.6	0.3	1.7	1	1	1
12/20/2021 17:00	0.5	12.2	2,184.3	0.3	1.7	1	1	1
12/20/2021 18:00	0.5	12.2	2,185.4	0.3	1.7	1	1	1
12/20/2021 19:00	0.5	12.1	2,192.2	0.3	1.6	1	1	1
12/20/2021 20:00	0.5	12.1	2,192.8	0.3	1.6	1	1	1
12/20/2021 21:00	0.5	12.1	2,195.0	0.3	1.6	1	1	1
12/20/2021 22:00	0.5	12.1	2,185.6	0.3	1.6	1	1	1
12/20/2021 23:00	0.6	12.6	2,071.5	0.3	2.0	1	1	1
Average/Sum#:	0.6	12.8	1,992.9	0.4	44.7 #	24 #	24 #	20 #
Minimum:	0.3	12.1	1,328.5	0.3	0.9	1	1	0
Maximum:	1.0	13.9	2,195.0	0.6	3.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/21/2021 00:00	0.7	12.8	2,031.0	0.4	2.3	1	1	1
12/21/2021 01:00	0.3	13.9	1,663.4	0.4	0.9	1	1	1
12/21/2021 02:00	0.4	13.8	1,778.5	0.4	1.3	1	1	1
12/21/2021 03:00	0.7	13.1	1,986.1	0.4	2.4	1	1	1
12/21/2021 04:00	0.9	13.1	1,949.3	0.5	3.0	1	1	1
12/21/2021 05:00	0.4	13.8	1,646.9	0.5	1.2	1	1	0
12/21/2021 06:00	0.4	13.8	1,730.8	0.4	1.3	1	1	1
12/21/2021 07:00	0.6	13.0	2,028.9	0.3	2.0	1	1	1
12/21/2021 08:00	0.5	12.4	2,164.9	0.3	1.7	1	1	1
12/21/2021 09:00	0.5	12.8	2,040.8	0.4	1.7	1	1	1
12/21/2021 10:00	0.3	13.9	1,597.3	0.3	0.9	1	1	0
12/21/2021 11:00	0.4	13.8	1,773.1	0.3	1.3	1	1	1
12/21/2021 12:00	1.1	13.0	2,017.6	0.5	3.7	1	1	1
12/21/2021 13:00	1.1	13.1	1,965.2	0.6	3.7	1	1	1
12/21/2021 14:00	0.3	13.8	1,634.5	0.6	0.9	1	1	0
12/21/2021 15:00	0.4	13.8	1,774.2	0.4	1.3	1	1	1
12/21/2021 16:00	1.5	13.0	2,019.4	0.5	5.1	1	1	1
12/21/2021 17:00	0.6	12.2	2,208.2	0.6	2.0	1	1	1
12/21/2021 18:00	0.5	12.1	2,216.6	0.6	1.7	1	1	1
12/21/2021 19:00	0.5	12.1	2,216.3	0.3	1.7	1	1	1
12/21/2021 20:00	0.5	12.1	2,212.7	0.3	1.7	1	1	1
12/21/2021 21:00	0.5	12.3	2,161.1	0.3	1.7	1	1	1
12/21/2021 22:00	0.6	12.7	2,074.9	0.3	2.0	1	1	1
12/21/2021 23:00	0.7	12.9	2,031.3	0.4	2.3	1	1	1
Average/Sum#:	0.6	13.1	1,955.1	0.4	47.8 #	24 #	24 #	21 #
Minimum:	0.3	12.1	1,597.3	0.3	0.9	1	1	0
Maximum:	1.5	13.9	2,216.6	0.6	5.1	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/22/2021 00:00	1.7	13.3	1,905.0	0.7	5.6	1	1	1
12/22/2021 01:00	0.3	13.9	1,598.3	0.7	0.9	1	1	0
12/22/2021 02:00	0.4	13.8	1,661.0	0.6	1.2	1	1	1
12/22/2021 03:00	2.5	13.3	1,932.5	0.8	8.4	1	1	1
12/22/2021 04:00	2.2	13.3	1,914.3	1.3	7.3	1	1	1
12/22/2021 05:00	0.3	13.9	1,447.1	1.3	0.8	1	1	0
12/22/2021 06:00	0.4	13.8	1,670.4	0.8	1.2	1	1	1
12/22/2021 07:00	1.6	13.1	1,961.6	0.6	5.3	1	1	1
12/22/2021 08:00	1.5	13.1	1,951.4	0.9	5.0	1	1	1
12/22/2021 09:00	0.4	13.9	1,424.1	0.9	1.1	1	1	0
12/22/2021 10:00	0.4	13.8	1,500.8	0.6	1.1	1	1	1
12/22/2021 11:00	1.0	13.1	1,961.9	0.5	3.3	1	1	1
12/22/2021 12:00	1.0	13.3	1,919.0	0.6	3.3	1	1	1
12/22/2021 13:00	0.4	13.8	1,605.4	0.6	1.2	1	1	1
12/22/2021 14:00	0.4	13.8	1,768.3	0.5	1.3	1	1	0
12/22/2021 15:00	1.3	13.1	1,967.2	0.5	4.3	1	1	1
12/22/2021 16:00	0.8	12.8	2,020.2	0.6	2.6	1	1	1
12/22/2021 17:00	0.6	12.5	2,104.7	0.7	2.0	1	1	1
12/22/2021 18:00	1.0	13.0	1,983.5	0.6	3.3	1	1	1
12/22/2021 19:00	1.2	13.1	1,945.2	0.7	4.0	1	1	1
12/22/2021 20:00	0.9	13.0	1,961.3	0.8	3.0	1	1	1
12/22/2021 21:00	0.4	13.9	1,531.0	0.6	1.2	1	1	0
12/22/2021 22:00	0.5	13.8	1,728.2	0.5	1.6	1	1	1
12/22/2021 23:00	1.2	12.9	2,000.2	0.5	4.0	1	1	1
Average/Sum#:	0.9	13.4	1,810.9	0.7	73.0 #	24 #	24 #	19 #
Minimum:	0.3	12.5	1,424.1	0.5	0.8	1	1	0
Maximum:	2.5	13.9	2,104.7	1.3	8.4	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/23/2021 00:00	1.4	13.2	1,907.8	0.8	4.6	1	1	1
12/23/2021 01:00	0.4	13.9	1,563.8	0.8	1.2	1	1	0
12/23/2021 02:00	0.4	13.8	1,598.1	0.6	1.2	1	1	1
12/23/2021 03:00	0.8	13.2	1,920.3	0.4	2.6	1	1	1
12/23/2021 04:00	0.8	13.2	1,896.3	0.5	2.6	1	1	1
12/23/2021 05:00	0.4	13.8	1,625.6	0.5	1.2	1	1	0
12/23/2021 06:00	0.7	13.7	1,618.0	0.5	2.1	1	1	1
12/23/2021 07:00	0.9	12.8	2,014.5	0.5	3.0	1	1	1
12/23/2021 08:00	1.3	13.1	1,909.0	0.8	4.2	1	1	1
12/23/2021 09:00	0.4	13.9	1,528.6	0.7	1.2	1	1	0
12/23/2021 10:00	0.4	13.8	1,623.1	0.5	1.2	1	1	1
12/23/2021 11:00	1.0	13.1	1,918.0	0.5	3.2	1	1	1
12/23/2021 12:00	1.0	13.1	1,892.2	0.6	3.2	1	1	1
12/23/2021 13:00	0.4	13.8	1,599.0	0.6	1.2	1	1	0
12/23/2021 14:00	0.4	13.9	1,300.2	0.5	1.0	1	1	0
12/23/2021 15:00	0.4	13.9	1,602.7	0.3	1.2	1	1	0
12/23/2021 16:00	0.8	13.4	1,816.2	0.4	2.6	1	1	1
12/23/2021 17:00	0.8	13.1	1,891.9	0.5	2.6	1	1	1
12/23/2021 18:00	0.4	13.8	1,639.7	0.5	1.2	1	1	1
12/23/2021 19:00	2.1	13.0	1,926.7	0.8	6.8	1	1	1
12/23/2021 20:00	1.0	13.1	1,889.6	0.9	3.2	1	1	1
12/23/2021 21:00	0.4	13.9	1,445.7	0.9	1.1	1	1	0
12/23/2021 22:00	0.4	13.8	1,560.5	0.5	1.2	1	1	1
12/23/2021 23:00	1.1	13.0	1,944.0	0.5	3.6	1	1	1
Average/Sum#:	0.8	13.5	1,734.6	0.6	57.2 #	24 #	24 #	17 #
Minimum:	0.4	12.8	1,300.2	0.3	1.0	1	1	0
Maximum:	2.1	13.9	2,014.5	0.9	6.8	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/24/2021 00:00	1.0	13.1	1,899.6	0.6	3.2	1	1	1
12/24/2021 01:00	0.3	13.9	1,499.4	0.6	0.8	1	1	0
12/24/2021 02:00	0.4	13.9	1,452.9	0.5	1.1	1	1	0
12/24/2021 03:00	0.4	13.9	1,339.1	0.3	1.0	1	1	0
12/24/2021 04:00	0.4	13.9	1,343.8	0.3	1.0	1	1	0
12/24/2021 05:00	0.4	13.9	1,724.5	0.3	1.3	1	1	0
12/24/2021 06:00	1.1	13.3	1,811.3	0.5	3.5	1	1	1
12/24/2021 07:00	0.9	13.3	1,846.5	0.6	2.9	1	1	1
12/24/2021 08:00	0.4	13.8	1,631.2	0.6	1.2	1	1	1
12/24/2021 09:00	1.1	13.1	1,931.0	0.6	3.6	1	1	1
12/24/2021 10:00	1.0	13.1	1,914.8	0.6	3.2	1	1	1
12/24/2021 11:00	0.3	14.0	1,379.4	0.6	0.8	1	1	0
12/24/2021 12:00	0.3	13.9	1,598.2	0.5	0.9	1	1	0
12/24/2021 13:00	0.3	14.0	1,402.6	0.3	0.8	1	1	0
12/24/2021 14:00	0.4	14.0	1,389.1	0.3	1.1	1	1	0
12/24/2021 15:00	0.4	13.9	1,471.0	0.3	1.1	1	1	0
12/24/2021 16:00	0.4	13.9	1,490.2	0.3	1.1	1	1	1
12/24/2021 17:00	0.9	13.0	1,944.0	0.4	2.9	1	1	1
12/24/2021 18:00	0.7	12.9	1,962.2	0.5	2.3	1	1	1
12/24/2021 19:00	0.7	12.9	1,970.6	0.6	2.3	1	1	1
12/24/2021 20:00	0.9	13.2	1,902.1	0.6	2.9	1	1	1
12/24/2021 21:00	0.4	14.0	1,386.4	0.5	1.1	1	1	0
12/24/2021 22:00	0.4	13.8	1,578.1	0.4	1.2	1	1	1
12/24/2021 23:00	0.7	12.9	1,993.2	0.4	2.3	1	1	1
Average/Sum#:	0.6	13.6	1,660.9	0.5	43.6 #	24 #	24 #	13 #
Minimum:	0.3	12.9	1,339.1	0.3	0.8	1	1	0
Maximum:	1.1	14.0	1,993.2	0.6	3.6	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/25/2021 00:00	0.9	13.1	1,916.4	0.5	2.9	1	1	1
12/25/2021 01:00	0.4	13.9	1,532.8	0.5	1.2	1	1	0
12/25/2021 02:00	0.4	13.9	1,428.9	0.4	1.1	1	1	0
12/25/2021 03:00	0.4	13.9	1,339.8	0.3	1.0	1	1	0
12/25/2021 04:00	0.4	13.8	1,557.0	0.3	1.2	1	1	1
12/25/2021 05:00	0.9	13.0	1,967.0	0.4	3.0	1	1	1
12/25/2021 06:00	1.0	13.1	1,918.1	0.6	3.2	1	1	1
12/25/2021 07:00	0.4	13.8	1,558.6	0.6	1.2	1	1	1
12/25/2021 08:00	0.4	13.8	1,583.5	0.5	1.2	1	1	0
12/25/2021 09:00	0.4	13.9	1,390.3	0.3	1.0	1	1	0
12/25/2021 10:00	0.4	13.8	1,609.0	0.3	1.2	1	1	0
12/25/2021 11:00	0.4	13.9	1,564.4	0.3	1.2	1	1	0
12/25/2021 12:00	0.4	13.9	1,532.1	0.3	1.2	1	1	0
12/25/2021 13:00	0.4	13.9	1,473.5	0.3	1.1	1	1	0
12/25/2021 14:00	0.4	13.9	1,582.5	0.3	1.2	1	1	0
12/25/2021 15:00	0.4	13.9	1,590.9	0.3	1.2	1	1	0
12/25/2021 16:00	0.8	13.2	1,884.3	0.4	2.6	1	1	1
12/25/2021 17:00	0.7	12.7	2,018.8	0.5	2.3	1	1	1
12/25/2021 18:00	0.6	12.7	2,020.0	0.5	2.0	1	1	1
12/25/2021 19:00	0.6	12.8	2,012.3	0.4	2.0	1	1	1
12/25/2021 20:00	0.9	13.2	1,904.1	0.5	2.9	1	1	1
12/25/2021 21:00	0.4	13.9	1,623.6	0.5	1.2	1	1	0
12/25/2021 22:00	0.4	13.9	1,570.0	0.4	1.2	1	1	1
12/25/2021 23:00	0.6	13.1	1,960.9	0.4	2.0	1	1	1
Average/Sum#:	0.5	13.5	1,689.1	0.4	40.3 #	24 #	24 #	12 #
Minimum:	0.4	12.7	1,339.8	0.3	1.0	1	1	0
Maximum:	1.0	13.9	2,020.0	0.6	3.2	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/26/2021 00:00	7.8	14.4	1,212.6	0.0	9.6	1	0	1
12/26/2021 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
12/26/2021 15:00	68.5	18.7	203.8	0.0	16.8	1	0	0
12/26/2021 16:00	31.5	16.1	713.1	0.0	61.8	1	0	0
12/26/2021 17:00	0.4	13.8	1,726.0	0.0	1.3	1	1	0
12/26/2021 18:00	0.4	13.8	1,731.1	0.0	1.3	1	1	1
12/26/2021 19:00	0.8	13.0	1,966.7	0.4	2.6	1	1	1
12/26/2021 20:00	0.7	13.0	1,958.9	0.5	2.3	1	1	1
12/26/2021 21:00	0.3	13.9	1,604.7	0.5	0.9	1	1	0
12/26/2021 22:00	0.4	13.8	1,688.8	0.4	1.3	1	1	1
12/26/2021 23:00	0.6	13.1	1,968.1	0.4	2.0	1	1	1
Average/Sum#:	11.1	14.4	1,477.4	0.4	99.9 #	10 #	7 #	6 #
Minimum:	0.3	13.0	203.8	0.4	0.9	0	0	0
Maximum:	68.5	18.7	1,968.1	0.5	61.8	1	1	1
%SI	58.33	58.33	58.33	79.17	58.33	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/27/2021 00:00	0.5	12.9	2,004.4	0.4	1.7	1	1	1
12/27/2021 01:00	0.5	13.1	1,946.2	0.4	1.6	1	1	1
12/27/2021 02:00	0.3	13.9	1,630.6	0.4	0.9	1	1	0
12/27/2021 03:00	0.4	13.9	1,484.6	0.3	1.1	1	1	0
12/27/2021 04:00	0.4	13.9	1,495.7	0.3	1.1	1	1	0
12/27/2021 05:00	0.4	13.8	1,648.3	0.3	1.2	1	1	1
12/27/2021 06:00	0.6	12.9	2,002.9	0.3	2.0	1	1	1
12/27/2021 07:00	0.5	12.5	2,105.6	0.4	1.7	1	1	1
12/27/2021 08:00	0.5	12.6	2,079.8	0.4	1.7	1	1	1
12/27/2021 09:00	0.4	12.6	2,093.9	0.4	1.3	1	1	1
12/27/2021 10:00	0.4	12.7	2,048.0	0.3	1.3	1	1	1
12/27/2021 11:00	0.4	12.8	1,992.0	0.3	1.3	1	1	1
12/27/2021 12:00	0.3	13.9	1,675.0	0.3	0.9	1	1	0
12/27/2021 13:00	0.3	13.9	1,616.6	0.3	0.9	1	1	0
12/27/2021 14:00	0.7	13.1	1,944.3	0.4	2.3	1	1	1
12/27/2021 15:00	0.6	12.6	2,066.6	0.4	2.0	1	1	1
12/27/2021 16:00	0.5	12.1	2,186.8	0.4	1.6	1	1	1
12/27/2021 17:00	0.4	12.1	2,198.9	0.3	1.3	1	1	1
12/27/2021 18:00	0.5	12.1	2,197.4	0.3	1.6	1	1	1
12/27/2021 19:00	0.5	12.1	2,200.4	0.3	1.7	1	1	1
12/27/2021 20:00	0.5	12.1	2,202.2	0.3	1.7	1	1	1
12/27/2021 21:00	0.5	12.2	2,182.2	0.3	1.7	1	1	1
12/27/2021 22:00	0.6	12.8	2,045.7	0.3	2.0	1	1	1
12/27/2021 23:00	0.6	12.9	2,027.4	0.4	2.0	1	1	1
Average/Sum#:	0.5	12.9	1,961.5	0.3	36.6 #	24 #	24 #	19 #
Minimum:	0.3	12.1	1,484.6	0.3	0.9	1	1	0
Maximum:	0.7	13.9	2,202.2	0.4	2.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/28/2021 00:00	1.0	13.3	1,913.9	0.5	3.3	1	1	1
12/28/2021 01:00	0.3	13.9	1,513.2	0.5	0.9	1	1	0
12/28/2021 02:00	0.4	13.9	1,599.1	0.5	1.2	1	1	1
12/28/2021 03:00	0.9	13.3	1,933.3	0.4	3.0	1	1	1
12/28/2021 04:00	0.8	13.3	1,909.1	0.5	2.7	1	1	1
12/28/2021 05:00	0.3	13.9	1,549.2	0.5	0.9	1	1	0
12/28/2021 06:00	0.5	13.8	1,705.2	0.4	1.6	1	1	1
12/28/2021 07:00	0.9	13.2	1,959.5	0.5	3.0	1	1	1
12/28/2021 08:00	0.8	13.1	1,992.9	0.6	2.7	1	1	1
12/28/2021 09:00	0.7	13.1	1,964.5	0.6	2.3	1	1	1
12/28/2021 10:00	0.3	13.9	1,526.1	0.5	0.9	1	1	0
12/28/2021 11:00	0.4	13.9	1,418.2	0.4	1.1	1	1	0
12/28/2021 12:00	0.4	13.9	1,509.8	0.3	1.1	1	1	0
12/28/2021 13:00	0.7	13.5	1,842.5	0.4	2.3	1	1	1
12/28/2021 14:00	0.6	13.2	1,896.8	0.5	2.0	1	1	1
12/28/2021 15:00	0.4	13.8	1,653.6	0.5	1.2	1	1	1
12/28/2021 16:00	0.6	12.7	2,080.7	0.4	2.0	1	1	1
12/28/2021 17:00	0.4	12.2	2,218.2	0.3	1.3	1	1	1
12/28/2021 18:00	0.4	12.3	2,194.9	0.3	1.3	1	1	1
12/28/2021 19:00	0.4	12.5	2,130.1	0.3	1.3	1	1	1
12/28/2021 20:00	0.5	12.7	2,100.0	0.3	1.7	1	1	1
12/28/2021 21:00	0.5	12.8	2,057.9	0.4	1.7	1	1	1
12/28/2021 22:00	0.5	12.9	2,048.7	0.4	1.7	1	1	1
12/28/2021 23:00	0.6	13.0	1,995.8	0.4	2.0	1	1	1
Average/Sum#:	0.6	13.3	1,863.1	0.4	43.2 #	24 #	24 #	19 #
Minimum:	0.3	12.2	1,418.2	0.3	0.9	1	1	0
Maximum:	1.0	13.9	2,218.2	0.6	3.3	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/29/2021 00:00	0.8	13.3	1,910.1	0.5	2.7	1	1	1
12/29/2021 01:00	0.3	13.9	1,504.1	0.4	0.9	1	1	0
12/29/2021 02:00	0.4	13.8	1,567.7	0.4	1.2	1	1	1
12/29/2021 03:00	1.5	13.3	1,935.3	0.6	5.0	1	1	1
12/29/2021 04:00	1.3	13.3	1,922.4	0.8	4.3	1	1	1
12/29/2021 05:00	0.4	13.9	1,449.1	0.8	1.1	1	1	0
12/29/2021 06:00	0.4	13.8	1,741.8	0.5	1.3	1	1	1
12/29/2021 07:00	1.1	13.1	1,989.3	0.5	3.7	1	1	1
12/29/2021 08:00	1.0	13.1	1,954.4	0.6	3.3	1	1	1
12/29/2021 09:00	0.4	13.9	1,410.8	0.6	1.1	1	1	0
12/29/2021 10:00	0.4	13.8	1,611.3	0.5	1.2	1	1	1
12/29/2021 11:00	0.9	13.0	2,004.5	0.4	3.0	1	1	1
12/29/2021 12:00	1.2	13.3	1,911.2	0.6	4.0	1	1	1
12/29/2021 13:00	0.3	13.9	1,652.0	0.6	0.9	1	1	0
12/29/2021 14:00	0.4	13.8	1,661.2	0.5	1.2	1	1	1
12/29/2021 15:00	0.9	13.0	1,998.2	0.4	3.0	1	1	1
12/29/2021 16:00	0.7	12.7	2,064.6	0.5	2.3	1	1	1
12/29/2021 17:00	0.5	12.1	2,226.0	0.5	1.7	1	1	1
12/29/2021 18:00	0.5	12.1	2,216.8	0.4	1.7	1	1	1
12/29/2021 19:00	0.5	12.1	2,230.3	0.3	1.7	1	1	1
12/29/2021 20:00	0.5	12.1	2,230.6	0.3	1.7	1	1	1
12/29/2021 21:00	0.7	12.6	2,089.9	0.4	2.3	1	1	1
12/29/2021 22:00	1.2	13.1	1,965.3	0.6	4.0	1	1	1
12/29/2021 23:00	0.9	13.1	1,989.3	0.7	3.0	1	1	1
Average/Sum#:	0.7	13.2	1,884.8	0.5	56.3 #	24 #	24 #	20 #
Minimum:	0.3	12.1	1,410.8	0.3	0.9	1	1	0
Maximum:	1.5	13.9	2,230.6	0.8	5.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/30/2021 00:00	1.2	13.3	1,907.5	0.8	4.0	1	1	1
12/30/2021 01:00	0.3	13.9	1,628.9	0.6	0.9	1	1	0
12/30/2021 02:00	0.4	13.9	1,355.2	0.5	1.0	1	1	0
12/30/2021 03:00	0.4	13.8	1,725.5	0.3	1.3	1	1	0
12/30/2021 04:00	0.9	13.5	1,841.8	0.4	3.0	1	1	1
12/30/2021 05:00	1.0	13.4	1,818.0	0.6	3.2	1	1	1
12/30/2021 06:00	0.4	13.8	1,684.9	0.6	1.3	1	1	1
12/30/2021 07:00	0.8	13.1	2,017.1	0.6	2.7	1	1	1
12/30/2021 08:00	0.5	12.7	2,112.7	0.4	1.7	1	1	1
12/30/2021 09:00	0.6	13.0	2,007.3	0.5	2.0	1	1	1
12/30/2021 10:00	0.3	13.9	1,616.8	0.4	0.9	1	1	0
12/30/2021 11:00	0.4	13.8	1,653.3	0.3	1.2	1	1	1
12/30/2021 12:00	0.7	13.1	1,985.9	0.4	2.4	1	1	1
12/30/2021 13:00	0.7	13.3	1,894.5	0.4	2.3	1	1	1
12/30/2021 14:00	0.3	13.9	1,652.0	0.4	0.9	1	1	0
12/30/2021 15:00	0.4	13.9	1,599.6	0.4	1.2	1	1	1
12/30/2021 16:00	1.2	13.1	1,974.2	0.5	4.0	1	1	1
12/30/2021 17:00	0.6	12.5	2,097.6	0.5	2.0	1	1	1
12/30/2021 18:00	0.6	12.6	2,072.8	0.6	2.0	1	1	1
12/30/2021 19:00	0.9	13.0	1,981.7	0.5	3.0	1	1	1
12/30/2021 20:00	0.6	12.7	2,074.9	0.5	2.0	1	1	1
12/30/2021 21:00	0.6	12.6	2,073.2	0.5	2.0	1	1	1
12/30/2021 22:00	0.7	12.8	2,044.2	0.4	2.3	1	1	1
12/30/2021 23:00	0.7	13.0	2,004.7	0.5	2.3	1	1	1
Average/Sum#:	0.6	13.3	1,867.7	0.5	49.6 #	24 #	24 #	19 #
Minimum:	0.3	12.5	1,355.2	0.3	0.9	1	1	0
Maximum:	1.2	13.9	2,112.7	0.8	4.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - CO

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	> Limit Unit CT2 CO, _3Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
12/31/2021 00:00	0.9	13.3	1,912.7	0.6	3.0	1	1	1
12/31/2021 01:00	0.3	13.9	1,519.2	0.5	0.9	1	1	0
12/31/2021 02:00	0.4	13.9	1,323.4	0.4	1.0	1	1	0
12/31/2021 03:00	0.4	13.8	1,721.3	0.3	1.3	1	1	0
12/31/2021 04:00	0.9	13.5	1,842.0	0.4	3.0	1	1	1
12/31/2021 05:00	0.9	13.4	1,820.7	0.6	2.9	1	1	1
12/31/2021 06:00	0.4	13.9	1,417.0	0.6	1.1	1	1	1
12/31/2021 07:00	0.8	13.0	1,997.5	0.5	2.7	1	1	1
12/31/2021 08:00	0.7	13.0	2,006.8	0.5	2.3	1	1	1
12/31/2021 09:00	0.9	13.3	1,914.6	0.6	3.0	1	1	1
12/31/2021 10:00	0.3	13.9	1,489.1	0.5	0.8	1	1	0
12/31/2021 11:00	0.3	13.9	1,450.8	0.4	0.8	1	1	0
12/31/2021 12:00	0.3	13.9	1,574.4	0.3	0.9	1	1	0
12/31/2021 13:00	0.3	14.0	1,300.1	0.3	0.7	1	1	0
12/31/2021 14:00	0.3	14.0	1,438.8	0.3	0.8	1	1	0
12/31/2021 15:00	0.5	13.8	1,623.4	0.3	1.5	1	1	1
12/31/2021 16:00	0.7	12.8	2,021.3	0.4	2.3	1	1	1
12/31/2021 17:00	0.6	12.5	2,095.7	0.4	2.0	1	1	1
12/31/2021 18:00	0.6	12.5	2,097.3	0.4	2.0	1	1	1
12/31/2021 19:00	0.5	12.4	2,119.3	0.4	1.6	1	1	1
12/31/2021 20:00	0.6	12.7	2,031.2	0.4	2.0	1	1	1
12/31/2021 21:00	0.3	13.9	1,566.2	0.3	0.9	1	1	0
12/31/2021 22:00	0.3	13.8	1,754.3	0.3	1.0	1	1	0
12/31/2021 23:00	0.6	13.3	1,937.0	0.3	2.0	1	1	1
Average/Sum#:	0.5	13.4	1,748.9	0.4	40.5 #	24 #	24 #	14 #
Minimum:	0.3	12.4	1,300.1	0.3	0.7	1	1	0
Maximum:	0.9	14.0	2,119.3	0.6	3.0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Excess Emission Report

CT1 - CO Lb 1-Day Block Average

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 09:28 **Location:** Maxwell, CA

Tag Name: CT1_CO_Lb_1D
Total Operating Time: 1,647.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 561.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,647.00 Hour(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - CO Lb 1-Day Block Average

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 09:29 **Location:** Maxwell, CA

Tag Name: CT2_CO_Lb_1D
Total Operating Time: 1,549.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 659.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,549.00 Hour(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 8
Hourly Emissions – NH_3

FCD: AQ-18
Title V: #6

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/01/2021 00:00	10.3	13.8	8.6	100.6	3,030,198.8	1,526.8	1.1	0.6
10/01/2021 01:00	9.6	13.8	8.0	99.6	3,050,442.4	1,537.0	1.1	0.6
10/01/2021 02:00	9.3	13.8	7.7	98.9	3,045,083.8	1,534.3	1.1	0.6
10/01/2021 03:00	9.2	13.8	7.6	98.8	3,047,862.4	1,535.7	1.1	0.6
10/01/2021 04:00	9.4	13.8	7.8	98.6	3,030,198.8	1,526.8	1.1	0.6
10/01/2021 05:00	9.8	13.4	7.7	133.5	3,398,708.4	2,010.3	1.3	1.0
10/01/2021 06:00	10.6	13.5	8.5	120.0	3,022,389.8	1,721.5	1.3	0.9
10/01/2021 07:00	10.2	13.9	8.6	95.2	2,853,959.8	1,438.0	1.1	0.6
10/01/2021 08:00	10.0	13.9	8.4	89.2	2,688,438.1	1,354.6	1.1	0.5
10/01/2021 09:00	9.8	13.9	8.3	88.6	2,690,422.7	1,355.6	1.1	0.5
10/01/2021 10:00	9.6	13.9	8.1	88.2	2,738,848.8	1,360.0	1.0	0.5
10/01/2021 11:00	9.5	13.9	8.0	88.0	2,750,327.8	1,365.7	1.0	0.5
10/01/2021 12:00	9.5	13.9	8.0	88.6	2,780,535.7	1,380.7	1.0	0.6
10/01/2021 13:00	9.5	13.8	7.9	108.9	3,377,978.7	1,726.7	1.1	0.7
10/01/2021 14:00	10.4	13.8	8.6	102.2	3,024,862.8	1,546.2	1.1	0.6
10/01/2021 15:00	9.8	13.8	8.1	109.9	3,366,436.4	1,720.8	1.1	0.7
10/01/2021 16:00	10.1	13.7	8.3	109.9	3,333,765.8	1,704.1	1.1	0.7
10/01/2021 17:00	10.1	13.5	8.1	114.0	3,398,454.8	1,786.8	1.1	0.7
10/01/2021 18:00	10.1	13.5	8.1	113.7	3,383,239.0	1,778.8	1.1	0.7
10/01/2021 19:00	10.2	13.7	8.4	110.4	3,330,440.1	1,702.4	1.1	0.7
10/01/2021 20:00	10.1	13.7	8.3	109.1	3,294,835.1	1,684.2	1.1	0.7
10/01/2021 21:00	10.4	13.7	8.5	109.0	3,253,948.0	1,663.3	1.1	0.7
10/01/2021 22:00	9.5	13.8	7.9	107.3	3,328,495.1	1,677.1	1.0	0.7
10/01/2021 23:00	8.9	13.8	7.4	106.0	3,340,601.6	1,683.2	1.0	0.7
Average/Sum#:	9.8	13.8	8.1	103.7	3,106,686.4	1,596.7	1.1	0.7
Minimum:	8.9	13.4	7.4	88.0	2,688,438.1	1,354.6	1.0	0.5
Maximum:	10.6	13.9	8.6	133.5	3,398,708.4	2,010.3	1.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/02/2021 00:00	8.8	13.8	7.3	105.8	3,351,715.8	1,688.8	1.0	0.7
10/02/2021 01:00	8.7	13.9	7.3	105.0	3,327,502.8	1,676.6	1.0	0.7
10/02/2021 02:00	9.2	13.9	7.8	98.6	3,051,633.2	1,537.6	1.0	0.6
10/02/2021 03:00	8.7	13.8	7.2	104.3	3,300,114.3	1,662.8	1.0	0.7
10/02/2021 04:00	8.5	13.9	7.2	104.5	3,331,472.1	1,678.6	1.0	0.7
10/02/2021 05:00	8.6	13.8	7.1	102.0	3,316,190.1	1,670.9	1.0	0.7
10/02/2021 06:00	9.1	13.8	7.6	104.4	3,249,306.7	1,637.2	1.0	0.7
10/02/2021 07:00	9.6	13.8	8.0	95.1	2,899,011.9	1,460.7	1.1	0.6
10/02/2021 08:00	9.8	13.9	8.3	89.0	2,674,346.9	1,347.5	1.1	0.5
10/02/2021 09:00	9.7	13.9	8.2	88.6	2,643,794.6	1,312.8	1.1	0.5
10/02/2021 10:00	9.6	14.0	8.2	87.6	2,594,656.4	1,288.4	1.1	0.5
10/02/2021 11:00	9.5	14.0	8.1	87.5	2,591,837.0	1,287.0	1.1	0.5
10/02/2021 12:00	9.4	14.0	8.0	87.5	2,620,232.4	1,301.1	1.1	0.5
10/02/2021 13:00	9.2	13.9	7.8	88.6	2,761,001.2	1,371.0	1.0	0.5
10/02/2021 14:00	9.2	13.8	7.6	104.4	3,244,362.0	1,658.4	1.1	0.7
10/02/2021 15:00	9.6	13.7	7.9	108.7	3,329,853.2	1,702.1	1.1	0.7
10/02/2021 16:00	10.4	13.7	8.5	106.6	3,178,042.7	1,624.5	1.1	0.6
10/02/2021 17:00	10.3	13.5	8.2	112.7	3,336,070.0	1,754.0	1.1	0.7
10/02/2021 18:00	10.1	13.5	8.1	113.4	3,379,815.5	1,777.0	1.1	0.7
10/02/2021 19:00	10.0	13.7	8.2	110.0	3,324,179.9	1,699.2	1.1	0.7
10/02/2021 20:00	10.2	13.7	8.4	109.3	3,271,163.6	1,672.1	1.1	0.7
10/02/2021 21:00	10.3	13.7	8.4	110.2	3,306,768.6	1,690.3	1.1	0.7
10/02/2021 22:00	10.3	13.7	8.4	110.3	3,308,138.0	1,691.0	1.1	0.7
10/02/2021 23:00	9.7	13.8	8.1	108.3	3,294,052.5	1,683.8	1.1	0.7
Average/Sum#:	9.5	13.8	7.9	101.8	3,111,885.9	1,578.1	1.1	0.6
Minimum:	8.5	13.5	7.1	87.5	2,591,837.0	1,287.0	1.0	0.5
Maximum:	10.4	14.0	8.5	113.4	3,379,815.5	1,777.0	1.1	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/03/2021 00:00	9.7	13.8	8.1	106.0	3,234,818.6	1,629.9	1.1	0.7
10/03/2021 01:00	9.6	13.8	8.0	102.9	3,125,066.1	1,574.6	1.1	0.6
10/03/2021 02:00	9.8	13.8	8.1	94.8	2,885,119.2	1,453.7	1.1	0.6
10/03/2021 03:00	9.8	13.8	8.1	93.1	2,810,892.4	1,416.3	1.1	0.6
10/03/2021 04:00	9.5	13.8	7.9	94.6	2,913,896.9	1,468.2	1.1	0.6
10/03/2021 05:00	9.4	13.8	7.8	94.0	2,885,913.0	1,454.1	1.1	0.6
10/03/2021 06:00	9.7	13.8	8.1	95.8	2,893,851.7	1,458.1	1.1	0.6
10/03/2021 07:00	9.8	13.9	8.3	88.3	2,601,100.8	1,291.6	1.1	0.5
10/03/2021 08:00	9.6	13.9	8.1	88.1	2,687,842.7	1,354.3	1.1	0.5
10/03/2021 09:00	9.6	13.9	8.1	87.8	2,602,309.1	1,292.2	1.1	0.5
10/03/2021 10:00	9.6	13.9	8.1	87.6	2,590,427.3	1,286.3	1.1	0.5
10/03/2021 11:00	9.6	13.9	8.1	89.5	2,711,661.7	1,346.5	1.1	0.5
10/03/2021 12:00	9.4	13.9	7.9	92.3	2,850,215.2	1,415.3	1.1	0.6
10/03/2021 13:00	9.6	13.8	8.0	103.0	3,153,980.0	1,612.2	1.1	0.6
10/03/2021 14:00	9.7	13.7	7.9	108.1	3,292,487.5	1,683.0	1.1	0.7
10/03/2021 15:00	9.5	13.7	7.8	107.9	3,304,421.0	1,689.1	1.1	0.7
10/03/2021 16:00	10.2	13.7	8.4	105.2	3,141,459.5	1,605.8	1.1	0.6
10/03/2021 17:00	10.2	13.8	8.5	95.0	2,827,762.1	1,424.8	1.1	0.6
10/03/2021 18:00	9.9	13.6	8.0	110.8	3,362,419.1	1,743.3	1.1	0.7
10/03/2021 19:00	10.1	13.7	8.3	107.0	3,208,365.7	1,640.0	1.1	0.7
10/03/2021 20:00	9.8	13.7	8.0	108.5	3,287,596.7	1,680.5	1.1	0.7
10/03/2021 21:00	10.2	13.7	8.4	106.3	3,184,889.9	1,628.0	1.1	0.7
10/03/2021 22:00	10.0	13.7	8.2	108.3	3,265,294.6	1,669.1	1.1	0.7
10/03/2021 23:00	10.0	13.7	8.2	109.2	3,299,139.0	1,686.4	1.1	0.7
Average/Sum#:	9.8	13.8	8.1	99.3	3,005,038.7	1,521.0	1.1	0.6
Minimum:	9.4	13.6	7.8	87.6	2,590,427.3	1,286.3	1.1	0.5
Maximum:	10.2	13.9	8.5	110.8	3,362,419.1	1,743.3	1.1	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/04/2021 00:00	10.0	13.7	8.2	108.5	3,259,621.3	1,666.2	1.1	0.7
10/04/2021 01:00	10.4	13.7	8.5	101.7	3,010,777.3	1,539.0	1.1	0.6
10/04/2021 02:00	10.4	13.7	8.5	102.4	3,034,644.4	1,551.2	1.1	0.6
10/04/2021 03:00	10.3	13.7	8.4	106.7	3,165,717.9	1,618.2	1.1	0.6
10/04/2021 04:00	10.0	13.7	8.2	108.4	3,262,555.8	1,667.7	1.1	0.7
10/04/2021 05:00	10.0	13.7	8.2	105.7	3,292,487.5	1,683.0	1.0	0.7
10/04/2021 06:00	10.3	13.7	8.4	107.5	3,204,257.4	1,637.9	1.1	0.7
10/04/2021 07:00	9.7	13.8	8.1	103.4	3,179,247.7	1,601.9	1.1	0.6
10/04/2021 08:00	9.9	13.7	8.1	106.0	3,158,870.8	1,614.7	1.1	0.6
10/04/2021 09:00	9.5	13.8	7.9	102.8	3,164,164.2	1,594.3	1.1	0.6
10/04/2021 10:00	10.0	13.8	8.3	100.6	3,027,014.8	1,547.3	1.1	0.6
10/04/2021 11:00	9.9	13.7	8.1	105.4	3,199,757.9	1,635.6	1.1	0.7
10/04/2021 12:00	9.7	13.7	7.9	106.7	3,244,948.9	1,658.7	1.1	0.7
10/04/2021 13:00	9.8	13.7	8.0	104.3	3,157,501.4	1,614.0	1.1	0.6
10/04/2021 14:00	9.6	13.7	7.9	107.9	3,308,529.3	1,691.2	1.1	0.7
10/04/2021 15:00	10.0	13.7	8.2	105.8	3,189,193.8	1,630.2	1.1	0.7
10/04/2021 16:00	9.7	13.6	7.8	111.5	3,390,386.2	1,757.8	1.1	0.7
10/04/2021 17:00	9.9	13.5	7.9	112.9	3,378,484.1	1,776.3	1.1	0.7
10/04/2021 18:00	9.9	13.5	7.9	113.1	3,371,446.8	1,772.6	1.1	0.7
10/04/2021 19:00	9.9	13.6	8.0	112.1	3,376,691.9	1,750.7	1.1	0.7
10/04/2021 20:00	10.0	13.5	8.0	111.9	3,329,032.6	1,750.3	1.1	0.7
10/04/2021 21:00	10.0	13.6	8.1	111.8	3,370,905.6	1,747.7	1.1	0.7
10/04/2021 22:00	10.1	13.7	8.3	103.9	3,103,506.9	1,586.4	1.1	0.6
10/04/2021 23:00	9.4	13.8	7.8	102.6	3,170,713.6	1,597.6	1.1	0.6
Average/Sum#:	9.9	13.7	8.1	106.8	3,222,935.8	1,653.8	1.1	0.7
Minimum:	9.4	13.5	7.8	100.6	3,010,777.3	1,539.0	1.0	0.6
Maximum:	10.4	13.8	8.5	113.1	3,390,386.2	1,776.3	1.1	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/05/2021 00:00	9.4	13.8	7.8	99.9	3,084,975.7	1,554.4	1.1	0.6
10/05/2021 01:00	9.6	13.8	8.0	99.2	3,053,617.9	1,538.6	1.1	0.6
10/05/2021 02:00	9.6	13.8	8.0	98.7	3,026,031.0	1,524.7	1.1	0.6
10/05/2021 03:00	9.2	13.8	7.6	103.6	3,163,566.0	1,617.1	1.1	0.6
10/05/2021 04:00	9.6	13.8	8.0	101.9	3,085,704.4	1,577.3	1.1	0.6
10/05/2021 05:00	9.5	13.7	7.8	106.7	3,227,984.0	1,673.6	1.1	0.7
10/05/2021 06:00	10.1	13.7	8.3	110.0	3,288,183.6	1,680.8	1.1	0.7
10/05/2021 07:00	10.3	13.7	8.4	107.3	3,195,454.0	1,633.4	1.1	0.7
10/05/2021 08:00	10.5	13.7	8.6	105.2	3,129,917.2	1,599.9	1.1	0.6
10/05/2021 09:00	10.3	13.7	8.4	107.5	3,214,430.3	1,643.1	1.1	0.7
10/05/2021 10:00	9.7	13.8	8.1	106.4	3,249,448.4	1,661.0	1.1	0.7
10/05/2021 11:00	9.3	13.8	7.7	104.3	3,256,848.4	1,641.0	1.0	0.7
10/05/2021 12:00	9.8	13.7	8.0	109.0	3,347,655.7	1,711.2	1.1	0.7
10/05/2021 13:00	9.7	13.8	8.1	106.5	3,250,817.9	1,661.7	1.1	0.7
10/05/2021 14:00	9.7	13.8	8.1	104.9	3,208,757.0	1,640.2	1.1	0.7
10/05/2021 15:00	9.6	13.8	8.0	107.7	3,294,639.4	1,684.1	1.1	0.7
10/05/2021 16:00	9.8	13.8	8.1	107.4	3,273,119.9	1,673.1	1.1	0.7
10/05/2021 17:00	10.1	13.7	8.3	106.3	3,193,888.9	1,632.6	1.1	0.7
10/05/2021 18:00	10.4	13.7	8.5	106.9	3,181,368.5	1,626.2	1.1	0.7
10/05/2021 19:00	10.0	13.7	8.2	108.8	3,289,553.0	1,681.5	1.1	0.7
10/05/2021 20:00	10.4	13.7	8.5	104.9	3,111,919.1	1,590.7	1.1	0.6
10/05/2021 21:00	10.0	13.8	8.3	98.6	2,992,688.4	1,507.9	1.1	0.6
10/05/2021 22:00	9.2	13.8	7.6	104.4	3,247,917.4	1,636.5	1.0	0.7
10/05/2021 23:00	10.1	13.8	8.4	93.8	2,799,381.3	1,410.5	1.1	0.6
Average/Sum#:	9.8	13.8	8.1	104.6	3,173,661.1	1,616.7	1.1	0.7
Minimum:	9.2	13.7	7.6	93.8	2,799,381.3	1,410.5	1.0	0.6
Maximum:	10.5	13.8	8.6	110.0	3,347,655.7	1,711.2	1.1	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/06/2021 00:00	10.3	13.9	8.7	89.0	2,570,151.6	1,295.0	1.1	0.5
10/06/2021 01:00	10.2	13.9	8.6	88.9	2,569,953.1	1,294.9	1.1	0.5
10/06/2021 02:00	10.2	13.9	8.6	88.8	2,570,548.5	1,295.2	1.1	0.5
10/06/2021 03:00	10.2	13.9	8.6	88.9	2,571,143.9	1,295.5	1.1	0.5
10/06/2021 04:00	10.2	13.8	8.5	89.1	2,617,783.7	1,319.0	1.1	0.5
10/06/2021 05:00	10.1	13.7	8.3	99.9	2,990,627.2	1,528.7	1.1	0.6
10/06/2021 06:00	10.2	13.7	8.4	105.5	3,129,526.0	1,599.7	1.1	0.6
10/06/2021 07:00	10.0	13.7	8.2	102.6	3,058,902.8	1,563.6	1.1	0.6
10/06/2021 08:00	10.2	13.8	8.5	93.1	2,746,869.7	1,404.1	1.1	0.6
10/06/2021 09:00	9.9	13.7	8.1	102.8	3,101,941.9	1,585.6	1.1	0.6
10/06/2021 10:00	9.9	13.7	8.1	102.3	3,067,119.4	1,567.8	1.1	0.6
10/06/2021 11:00	9.8	13.8	8.1	98.1	2,948,370.7	1,507.1	1.1	0.6
10/06/2021 12:00	9.5	13.8	7.9	103.0	3,148,697.9	1,609.5	1.1	0.6
10/06/2021 13:00	9.1	13.8	7.6	103.4	3,201,518.6	1,636.5	1.1	0.7
10/06/2021 14:00	9.1	13.8	7.6	106.1	3,290,922.4	1,682.2	1.1	0.7
10/06/2021 15:00	9.9	13.7	8.1	107.6	3,263,533.9	1,668.2	1.1	0.7
10/06/2021 16:00	10.2	13.7	8.4	107.1	3,211,495.8	1,641.6	1.1	0.7
10/06/2021 17:00	10.5	13.8	8.7	93.6	2,724,958.9	1,392.9	1.1	0.6
10/06/2021 18:00	10.4	13.7	8.5	104.9	3,120,722.5	1,595.2	1.1	0.6
10/06/2021 19:00	10.3	13.7	8.4	106.5	3,181,172.8	1,626.1	1.1	0.7
10/06/2021 20:00	10.0	13.6	8.1	111.0	3,319,214.7	1,720.9	1.1	0.7
10/06/2021 21:00	10.1	13.7	8.3	107.0	3,212,082.7	1,641.9	1.1	0.7
10/06/2021 22:00	10.5	13.7	8.6	104.2	3,104,093.8	1,586.7	1.1	0.6
10/06/2021 23:00	10.0	13.7	8.2	109.7	3,296,791.4	1,685.2	1.1	0.7
Average/Sum#:	10.0	13.8	8.3	100.5	3,000,756.0	1,531.0	1.1	0.6
Minimum:	9.1	13.6	7.6	88.8	2,569,953.1	1,294.9	1.1	0.5
Maximum:	10.5	13.9	8.7	111.0	3,319,214.7	1,720.9	1.1	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/07/2021 00:00	10.1	13.8	8.4	101.6	3,032,883.7	1,550.3	1.1	0.6
10/07/2021 01:00	9.9	13.8	8.2	101.1	3,030,144.9	1,548.9	1.1	0.6
10/07/2021 02:00	9.7	13.8	8.1	100.1	3,024,471.6	1,546.0	1.1	0.6
10/07/2021 03:00	9.9	13.8	8.2	94.8	2,897,424.1	1,459.9	1.1	0.6
10/07/2021 04:00	9.8	13.7	8.0	106.8	3,242,796.9	1,657.6	1.1	0.7
10/07/2021 05:00	9.9	13.7	8.1	104.4	3,209,735.1	1,640.7	1.1	0.7
10/07/2021 06:00	10.1	13.7	8.3	109.8	3,303,051.6	1,688.4	1.1	0.7
10/07/2021 07:00	9.9	13.7	8.1	106.2	3,188,802.5	1,630.0	1.1	0.7
10/07/2021 08:00	9.9	13.7	8.1	105.1	3,162,979.1	1,616.8	1.1	0.6
10/07/2021 09:00	9.9	13.8	8.2	100.4	3,017,624.4	1,542.5	1.1	0.6
10/07/2021 10:00	9.9	13.8	8.2	99.9	2,990,040.3	1,528.4	1.1	0.6
10/07/2021 11:00	9.8	13.8	8.1	99.8	3,064,533.6	1,544.1	1.1	0.6
10/07/2021 12:00	9.8	13.8	8.1	100.3	3,072,075.4	1,547.9	1.1	0.6
10/07/2021 13:00	9.9	13.8	8.2	100.2	3,069,098.4	1,546.4	1.1	0.6
10/07/2021 14:00	9.9	13.7	8.1	108.3	3,296,987.0	1,685.3	1.1	0.7
10/07/2021 15:00	10.4	13.7	8.5	109.0	3,268,229.1	1,670.6	1.1	0.7
10/07/2021 16:00	10.3	13.7	8.4	110.6	3,332,787.7	1,703.6	1.1	0.7
10/07/2021 17:00	10.0	13.5	8.0	115.0	3,448,857.3	1,813.3	1.1	0.7
10/07/2021 18:00	10.1	13.6	8.2	113.1	3,398,294.1	1,761.9	1.1	0.7
10/07/2021 19:00	10.5	13.7	8.6	108.1	3,238,884.3	1,655.6	1.1	0.7
10/07/2021 20:00	10.4	13.7	8.5	106.3	3,139,067.9	1,627.5	1.1	0.7
10/07/2021 21:00	10.2	13.7	8.4	108.2	3,257,078.1	1,664.9	1.1	0.7
10/07/2021 22:00	10.0	13.8	8.3	108.8	3,278,402.0	1,675.8	1.1	0.7
10/07/2021 23:00	10.1	13.8	8.4	103.9	3,118,375.0	1,594.0	1.1	0.6
Average/Sum#:	10.0	13.7	8.2	105.1	3,170,109.3	1,620.9	1.1	0.7
Minimum:	9.7	13.5	8.0	94.8	2,897,424.1	1,459.9	1.1	0.6
Maximum:	10.5	13.8	8.6	115.0	3,448,857.3	1,813.3	1.1	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/08/2021 00:00	10.3	13.8	8.6	99.2	2,959,521.7	1,512.8	1.1	0.6
10/08/2021 01:00	10.2	13.7	8.4	97.8	2,935,263.4	1,500.4	1.1	0.6
10/08/2021 02:00	10.1	13.7	8.3	99.7	2,996,887.4	1,531.9	1.1	0.6
10/08/2021 03:00	10.1	13.7	8.3	103.2	3,104,680.7	1,587.0	1.1	0.6
10/08/2021 04:00	9.9	13.7	8.1	107.5	3,257,665.0	1,665.2	1.1	0.7
10/08/2021 05:00	10.4	13.7	8.5	101.9	3,048,338.7	1,558.2	1.1	0.6
10/08/2021 06:00	10.2	13.7	8.4	107.4	3,241,623.1	1,657.0	1.1	0.7
10/08/2021 07:00	10.4	13.7	8.5	102.4	3,010,973.0	1,539.1	1.1	0.6
10/08/2021 08:00	10.3	13.7	8.4	101.2	3,026,232.3	1,546.9	1.1	0.6
10/08/2021 09:00	10.2	13.8	8.5	93.1	2,767,031.1	1,394.2	1.1	0.6
10/08/2021 10:00	9.9	13.8	8.2	106.4	3,234,189.1	1,653.2	1.1	0.7
10/08/2021 11:00	10.1	13.8	8.4	95.5	2,908,339.8	1,465.4	1.1	0.6
10/08/2021 12:00	9.5	13.8	7.9	102.3	3,140,677.0	1,605.4	1.1	0.6
10/08/2021 13:00	9.4	13.8	7.8	99.7	3,119,906.0	1,572.0	1.0	0.6
10/08/2021 14:00	9.6	13.8	8.0	99.0	3,053,419.4	1,538.5	1.1	0.6
10/08/2021 15:00	9.3	13.8	7.7	102.5	3,216,758.0	1,620.8	1.0	0.6
10/08/2021 16:00	9.1	13.8	7.6	105.8	3,336,235.3	1,681.0	1.0	0.7
10/08/2021 17:00	9.6	13.8	8.0	103.2	3,184,804.8	1,604.7	1.1	0.6
10/08/2021 18:00	9.5	13.8	7.9	103.8	3,216,758.0	1,620.8	1.0	0.6
10/08/2021 19:00	9.5	13.8	7.9	105.4	3,218,734.2	1,645.3	1.1	0.7
10/08/2021 20:00	10.1	13.9	8.5	93.2	2,731,902.4	1,376.5	1.1	0.6
10/08/2021 21:00	26.5	17.1	41.1	198.0	1,047,935.7	321.4	6.5	0.8
10/08/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	10.6	13.9	9.7	105.8	2,988,994.4	1,509.0	1.3	0.6
Minimum:	9.1	13.7	7.6	93.1	1,047,935.7	321.4	1.0	0.6
Maximum:	26.5	17.1	41.1	198.0	3,336,235.3	1,681.0	6.5	0.8
%SI	8.33	8.33	8.33	8.33	8.33	8.33	8.33	8.33

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/09/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/10/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/11/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/12/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/13/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/14/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/15/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/16/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/17/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/18/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/19/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/20/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/20/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/20/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/20/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/20/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/20/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/20/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/20/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/20/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/20/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/20/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/20/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/20/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/20/2021 13:00	32.5	17.5	56.4	0.0	1,317,386.3	288.6	0.0	0.0
10/20/2021 14:00	45.0	16.1	55.3	188.8	1,848,722.9	621.0	0.0	0.0
10/20/2021 15:00	11.0	13.7	9.0	160.0	2,920,731.5	1,514.3	1.9	1.1
10/20/2021 16:00	9.6	13.3	7.5	120.4	3,104,084.3	1,858.7	1.3	0.9
10/20/2021 17:00	9.3	13.6	7.5	105.1	3,245,921.5	1,682.9	1.1	0.7
10/20/2021 18:00	9.2	13.3	7.1	115.9	3,414,830.9	1,994.9	1.1	0.8
10/20/2021 19:00	9.3	13.3	7.2	122.1	3,452,302.0	2,042.0	1.2	1.0
10/20/2021 20:00	9.3	13.2	7.1	136.5	3,397,573.0	2,183.3	1.4	1.1
10/20/2021 21:00	9.2	13.2	7.0	132.4	3,368,624.7	2,115.5	1.3	1.1
10/20/2021 22:00	21.3	15.8	24.6	173.3	1,690,851.5	654.4	3.4	0.9
10/20/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	16.6	14.3	18.9	125.5	2,776,102.9	1,495.6	1.3	0.8
Minimum:	9.2	13.2	7.0	0.0	1,317,386.3	288.6	0.0	0.0
Maximum:	45.0	17.5	56.4	188.8	3,452,302.0	2,183.3	3.4	1.1
%SI	58.33	58.33	58.33	58.33	58.33	58.33	58.33	58.33

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/21/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/22/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/23/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2021 01:00	35.5	17.4	59.8	0.0	1,417,575.1	320.9	0.0	0.0
10/23/2021 02:00	37.0	17.1	57.4	196.5	1,445,123.1	379.9	4.4	0.6
10/23/2021 03:00	38.1	15.7	43.2	266.3	2,065,595.0	739.1	4.1	1.2
10/23/2021 04:00	9.9	13.7	8.1	109.6	2,966,760.1	1,516.5	1.2	0.8
10/23/2021 05:00	10.0	13.7	8.2	101.1	3,083,748.1	1,576.3	1.1	0.6
10/23/2021 06:00	9.6	13.7	7.9	109.3	3,446,254.3	1,761.6	1.0	0.7
10/23/2021 07:00	10.5	13.7	8.6	100.1	2,926,655.5	1,496.0	1.1	0.6
10/23/2021 08:00	10.2	13.7	8.4	107.1	3,217,756.0	1,644.8	1.1	0.7
10/23/2021 09:00	10.5	13.8	8.7	94.4	2,738,457.5	1,399.8	1.1	0.6
10/23/2021 10:00	10.1	13.7	8.3	103.8	3,128,939.1	1,599.4	1.1	0.6
10/23/2021 11:00	10.1	13.7	8.3	102.6	3,072,792.7	1,570.7	1.1	0.6
10/23/2021 12:00	10.1	13.7	8.3	104.9	3,162,392.2	1,616.5	1.1	0.6
10/23/2021 13:00	10.1	13.7	8.3	102.9	3,090,008.3	1,579.5	1.1	0.6
10/23/2021 14:00	9.9	13.7	8.1	107.7	3,254,534.9	1,663.6	1.1	0.7
10/23/2021 15:00	10.1	13.7	8.3	106.4	3,204,453.1	1,638.0	1.1	0.7
10/23/2021 16:00	10.0	13.6	8.1	107.5	3,216,025.7	1,667.4	1.1	0.7
10/23/2021 17:00	9.8	13.3	7.6	118.2	3,390,452.1	1,955.9	1.2	1.0
10/23/2021 18:00	10.0	13.2	7.7	124.8	3,390,562.8	2,055.0	1.2	1.0
10/23/2021 19:00	9.8	13.7	8.0	107.5	3,188,637.2	1,653.2	1.1	0.7
10/23/2021 20:00	9.7	13.6	7.8	107.0	3,232,613.1	1,676.0	1.1	0.7
10/23/2021 21:00	9.9	13.2	7.6	122.3	3,396,673.5	2,033.9	1.2	1.0
10/23/2021 22:00	13.4	14.2	11.8	133.3	2,847,631.2	1,476.4	1.5	0.9
10/23/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	13.8	14.1	14.5	115.2	2,949,256.4	1,500.9	1.4	0.7
Minimum:	9.6	13.2	7.6	0.0	1,417,575.1	320.9	0.0	0.0
Maximum:	38.1	17.4	59.8	266.3	3,446,254.3	2,055.0	4.4	1.2
%SI	8.33	8.33	8.33	8.33	8.33	8.33	8.33	8.33

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/24/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2021 07:00	35.8	17.3	58.7	132.6	1,445,170.7	337.7	0.0	0.0
10/24/2021 08:00	31.4	14.8	30.4	228.5	2,503,685.5	1,060.4	2.9	1.2
10/24/2021 09:00	10.4	13.7	8.5	105.0	3,074,749.0	1,571.7	1.1	0.6
10/24/2021 10:00	10.4	13.7	8.5	103.6	3,094,116.6	1,581.6	1.1	0.6
10/24/2021 11:00	10.5	13.7	8.6	101.2	3,056,164.0	1,562.2	1.1	0.6
10/24/2021 12:00	10.3	13.7	8.4	108.4	3,165,326.6	1,618.0	1.1	0.6
10/24/2021 13:00	10.5	13.7	8.6	100.0	2,957,761.0	1,511.9	1.1	0.6
10/24/2021 14:00	10.2	13.7	8.4	105.8	3,187,824.3	1,629.5	1.1	0.7
10/24/2021 15:00	10.3	13.7	8.4	108.0	3,236,341.1	1,654.3	1.1	0.7
10/24/2021 16:00	10.0	13.5	8.0	112.3	3,357,942.7	1,765.5	1.1	0.7
10/24/2021 17:00	10.2	13.2	7.8	122.5	3,373,460.1	2,020.0	1.2	1.0
10/24/2021 18:00	10.1	13.2	7.7	127.4	3,301,601.6	2,049.3	1.3	1.0
10/24/2021 19:00	9.8	13.7	8.0	109.2	3,314,398.3	1,694.2	1.1	0.7
10/24/2021 20:00	9.8	13.7	8.0	110.4	3,387,955.9	1,731.8	1.1	0.7
10/24/2021 21:00	10.4	13.1	7.9	125.6	3,395,671.5	2,033.3	1.2	1.0
10/24/2021 22:00	10.1	13.5	8.1	110.9	3,037,058.9	1,685.5	1.2	0.8
10/24/2021 23:00	10.3	13.8	8.6	93.2	2,803,747.6	1,412.7	1.1	0.6
Average/Sum#:	13.0	13.9	12.5	117.9	3,040,763.3	1,583.5	1.2	0.7
Minimum:	9.8	13.1	7.7	93.2	1,445,170.7	337.7	0.0	0.0
Maximum:	35.8	17.3	58.7	228.5	3,395,671.5	2,049.3	2.9	1.2
%SI	29.17	29.17	29.17	29.17	29.17	29.17	29.17	29.17

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/25/2021 00:00	10.1	13.7	8.3	100.7	3,029,558.0	1,548.6	1.1	0.6
10/25/2021 01:00	10.1	13.7	8.3	100.5	3,010,190.4	1,538.7	1.1	0.6
10/25/2021 02:00	10.2	13.7	8.4	97.6	2,919,025.9	1,492.1	1.1	0.6
10/25/2021 03:00	10.2	13.7	8.4	101.0	3,031,710.0	1,549.7	1.1	0.6
10/25/2021 04:00	10.1	13.7	8.3	102.1	3,067,119.4	1,567.8	1.1	0.6
10/25/2021 05:00	9.7	13.5	7.7	110.6	3,440,341.2	1,783.7	1.1	0.7
10/25/2021 06:00	10.1	13.7	8.3	104.7	3,197,997.2	1,634.7	1.1	0.7
10/25/2021 07:00	9.7	13.5	7.7	113.6	3,431,359.1	1,804.1	1.1	0.7
10/25/2021 08:00	9.5	13.8	7.9	107.6	3,298,943.3	1,686.3	1.1	0.7
10/25/2021 09:00	9.5	13.6	7.7	112.3	3,451,528.1	1,789.5	1.1	0.7
10/25/2021 10:00	10.2	13.3	7.9	120.9	3,416,453.8	1,970.9	1.2	1.0
10/25/2021 11:00	10.3	13.2	7.9	125.1	3,467,686.9	2,051.1	1.2	1.0
10/25/2021 12:00	10.1	13.3	7.8	119.4	3,420,440.8	1,973.2	1.2	1.0
10/25/2021 13:00	10.2	13.7	8.4	108.2	3,213,452.1	1,642.6	1.1	0.7
10/25/2021 14:00	9.9	13.8	8.2	102.1	3,083,586.5	1,553.7	1.1	0.6
10/25/2021 15:00	10.0	13.7	8.2	103.0	3,080,422.3	1,574.6	1.1	0.6
10/25/2021 16:00	10.4	13.2	8.0	129.1	3,456,559.1	2,095.0	1.2	1.0
10/25/2021 17:00	10.2	13.2	7.8	131.9	3,456,818.4	2,120.4	1.3	1.1
10/25/2021 18:00	9.8	13.2	7.5	126.6	3,447,108.4	2,064.1	1.2	1.0
10/25/2021 19:00	9.3	13.7	7.6	106.9	3,183,622.4	1,650.6	1.1	0.7
10/25/2021 20:00	9.6	13.8	8.0	97.6	2,967,880.0	1,495.4	1.1	0.6
10/25/2021 21:00	9.3	13.3	7.2	116.2	3,456,392.0	1,968.7	1.1	0.8
10/25/2021 22:00	9.4	13.6	7.6	107.8	3,149,306.0	1,701.8	1.1	0.7
10/25/2021 23:00	10.0	13.8	8.3	90.3	2,704,315.5	1,362.6	1.1	0.5
Average/Sum#:	9.9	13.6	8.0	109.8	3,224,242.4	1,734.2	1.1	0.7
Minimum:	9.3	13.2	7.2	90.3	2,704,315.5	1,362.6	1.1	0.5
Maximum:	10.4	13.8	8.4	131.9	3,467,686.9	2,120.4	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/26/2021 00:00	10.1	13.8	8.4	90.2	2,706,101.7	1,363.5	1.1	0.5
10/26/2021 01:00	10.2	13.8	8.5	90.4	2,711,857.2	1,366.4	1.1	0.5
10/26/2021 02:00	10.2	13.8	8.5	90.5	2,722,177.5	1,371.6	1.1	0.5
10/26/2021 03:00	10.2	13.8	8.5	90.6	2,725,353.0	1,373.2	1.1	0.5
10/26/2021 04:00	10.0	13.7	8.2	100.4	2,993,953.0	1,530.4	1.1	0.6
10/26/2021 05:00	9.4	13.6	7.6	113.9	3,486,053.0	1,807.4	1.1	0.7
10/26/2021 06:00	10.5	13.8	8.7	99.4	2,916,678.3	1,490.9	1.1	0.6
10/26/2021 07:00	10.0	13.7	8.2	105.6	3,158,088.3	1,614.3	1.1	0.6
10/26/2021 08:00	0.0	0.0	0.0	104.5	1,053,080.8	1,607.2	3.7	2.3
10/26/2021 09:00	0.0	0.0	0.0	102.5	1,045,218.1	1,595.2	3.7	2.2
10/26/2021 10:00	10.8	13.1	8.2	144.6	3,376,538.6	2,046.5	1.4	1.0
10/26/2021 11:00	10.6	13.2	8.1	139.0	3,388,718.6	1,954.9	1.4	1.0
10/26/2021 12:00	10.2	13.7	8.4	126.2	3,255,179.6	1,687.7	1.3	0.8
10/26/2021 13:00	10.5	13.7	8.6	109.4	2,893,006.8	1,478.8	1.2	0.7
10/26/2021 14:00	10.6	13.7	8.7	109.4	2,838,034.2	1,450.7	1.3	0.7
10/26/2021 15:00	10.2	13.6	8.2	112.6	3,039,157.7	1,575.7	1.2	0.8
10/26/2021 16:00	10.3	13.2	7.9	142.6	3,410,534.7	2,042.2	1.4	1.0
10/26/2021 17:00	10.3	13.1	7.8	159.4	3,415,022.2	2,119.7	1.6	1.3
10/26/2021 18:00	10.1	13.1	7.6	149.7	3,450,124.5	2,091.1	1.5	1.3
10/26/2021 19:00	9.9	13.1	7.5	150.4	3,378,353.5	2,047.6	1.5	1.2
10/26/2021 20:00	10.0	13.6	8.1	118.1	3,056,323.8	1,584.6	1.3	0.8
10/26/2021 21:00	9.5	13.6	7.7	123.7	3,454,035.5	1,790.8	1.2	0.9
10/26/2021 22:00	10.3	13.1	7.8	148.0	3,459,800.6	2,071.7	1.5	1.2
10/26/2021 23:00	9.9	13.2	7.6	142.6	3,409,697.7	2,016.8	1.4	1.0
Average/Sum#:	10.2	13.5	8.1	119.3	3,147,490.5	1,711.6	1.3	0.8
Minimum:	9.4	13.1	7.5	90.2	2,706,101.7	1,363.5	1.1	0.5
Maximum:	10.8	13.8	8.7	159.4	3,486,053.0	2,119.7	1.6	1.3
%SI	8.33	8.33	8.33	0.00	8.33	0.00	8.33	8.33

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/27/2021 00:00	10.2	13.6	8.2	117.5	3,016,012.5	1,563.7	1.3	0.8
10/27/2021 01:00	9.9	13.6	8.0	118.7	3,070,982.4	1,592.2	1.3	0.8
10/27/2021 02:00	9.7	13.3	7.5	131.0	3,449,544.9	1,964.8	1.3	1.0
10/27/2021 03:00	9.4	13.4	7.4	131.0	3,442,768.5	1,935.8	1.3	1.0
10/27/2021 04:00	10.2	13.6	8.2	125.9	3,090,077.2	1,602.1	1.4	0.8
10/27/2021 05:00	10.3	13.6	8.3	126.8	3,118,430.1	1,616.8	1.4	0.8
10/27/2021 06:00	10.4	13.2	8.0	132.2	3,498,792.6	2,018.4	1.3	1.0
10/27/2021 07:00	10.2	13.1	7.7	136.1	3,451,450.5	2,066.7	1.3	1.0
10/27/2021 08:00	9.6	13.3	7.5	125.0	3,470,157.0	1,951.2	1.2	1.0
10/27/2021 09:00	10.3	13.7	8.4	106.9	2,923,329.8	1,494.3	1.2	0.7
10/27/2021 10:00	10.6	13.7	8.7	103.8	2,846,055.1	1,454.8	1.2	0.7
10/27/2021 11:00	10.4	13.6	8.4	114.3	3,106,471.7	1,610.6	1.2	0.8
10/27/2021 12:00	10.6	13.8	8.8	98.9	2,620,295.7	1,339.4	1.2	0.7
10/27/2021 13:00	10.5	13.7	8.6	106.9	2,912,765.7	1,488.9	1.2	0.7
10/27/2021 14:00	10.2	13.3	7.9	125.9	3,345,359.6	1,856.6	1.3	0.9
10/27/2021 15:00	10.1	13.3	7.8	130.3	3,265,734.8	1,907.8	1.3	1.0
10/27/2021 16:00	9.9	13.6	8.0	118.5	3,300,505.6	1,711.2	1.2	0.9
10/27/2021 17:00	10.1	13.2	7.7	128.6	3,393,604.8	1,982.5	1.3	1.0
10/27/2021 18:00	10.3	13.0	7.7	145.0	3,396,650.2	2,133.1	1.5	1.3
10/27/2021 19:00	10.3	13.0	7.7	152.4	3,396,483.7	2,182.6	1.5	1.3
10/27/2021 20:00	10.1	13.0	7.5	145.1	3,400,471.8	2,135.5	1.5	1.3
10/27/2021 21:00	10.1	13.0	7.5	147.0	3,423,083.3	2,149.7	1.5	1.3
10/27/2021 22:00	10.1	13.1	7.6	136.7	3,418,550.9	2,047.0	1.4	1.0
10/27/2021 23:00	9.9	13.3	7.7	123.2	3,325,719.2	1,845.7	1.2	0.9
Average/Sum#:	10.1	13.4	8.0	126.2	3,236,804.1	1,818.8	1.3	0.9
Minimum:	9.4	13.0	7.4	98.9	2,620,295.7	1,339.4	1.2	0.7
Maximum:	10.6	13.8	8.8	152.4	3,498,792.6	2,182.6	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/28/2021 00:00	10.3	13.8	8.6	100.0	2,662,552.3	1,361.0	1.2	0.7
10/28/2021 01:00	10.6	13.7	8.7	97.9	2,651,205.6	1,355.2	1.2	0.7
10/28/2021 02:00	10.6	13.7	8.7	97.8	2,656,487.7	1,357.9	1.2	0.7
10/28/2021 03:00	10.7	13.7	8.8	97.7	2,657,661.5	1,358.5	1.2	0.7
10/28/2021 04:00	10.4	13.6	8.4	107.8	2,975,122.7	1,542.5	1.2	0.8
10/28/2021 05:00	10.4	13.2	8.0	158.7	3,387,550.2	2,003.7	1.6	1.2
10/28/2021 06:00	10.5	13.2	8.0	140.0	3,439,855.4	1,984.4	1.4	1.0
10/28/2021 07:00	10.3	13.4	8.1	138.9	3,300,132.6	1,831.5	1.4	0.9
10/28/2021 08:00	10.9	13.7	8.9	102.4	2,660,987.2	1,360.2	1.3	0.7
10/28/2021 09:00	10.8	13.7	8.9	104.1	2,672,333.9	1,366.0	1.3	0.7
10/28/2021 10:00	10.7	13.7	8.8	104.9	2,687,397.5	1,373.7	1.3	0.7
10/28/2021 11:00	10.6	13.7	8.7	104.7	2,702,656.8	1,381.5	1.3	0.7
10/28/2021 12:00	10.3	13.5	8.2	141.2	3,311,154.0	1,740.9	1.4	0.9
10/28/2021 13:00	10.9	13.6	8.8	113.2	2,894,114.5	1,500.5	1.3	0.8
10/28/2021 14:00	10.4	13.7	8.5	116.1	3,002,169.5	1,534.6	1.3	0.8
10/28/2021 15:00	10.4	13.6	8.4	117.7	3,049,187.3	1,580.9	1.3	0.8
10/28/2021 16:00	10.6	13.1	8.0	149.1	3,363,628.5	2,087.8	1.5	1.3
10/28/2021 17:00	10.6	12.9	7.8	176.8	3,350,525.0	2,202.0	1.8	1.5
10/28/2021 18:00	10.4	12.9	7.7	172.9	3,375,400.3	2,193.7	1.8	1.5
10/28/2021 19:00	10.4	12.9	7.7	180.8	3,367,091.4	2,188.3	1.9	1.5
10/28/2021 20:00	10.3	12.9	7.6	172.1	3,380,766.4	2,172.5	1.8	1.5
10/28/2021 21:00	10.2	13.0	7.6	159.2	3,397,783.6	2,109.0	1.6	1.3
10/28/2021 22:00	10.2	13.1	7.7	154.5	3,401,715.4	2,086.6	1.6	1.3
10/28/2021 23:00	10.0	13.1	7.6	146.8	3,365,109.9	2,015.0	1.5	1.2
Average/Sum#:	10.5	13.4	8.3	131.5	3,071,357.9	1,737.0	1.4	1.0
Minimum:	10.0	12.9	7.6	97.7	2,651,205.6	1,355.2	1.2	0.7
Maximum:	10.9	13.8	8.9	180.8	3,439,855.4	2,202.0	1.9	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/29/2021 00:00	9.9	13.2	7.6	139.6	3,378,664.6	1,949.1	1.4	1.0
10/29/2021 01:00	10.0	13.2	7.7	137.8	3,382,998.3	1,951.6	1.4	1.0
10/29/2021 02:00	10.1	13.2	7.7	139.0	3,418,293.9	1,947.0	1.4	1.0
10/29/2021 03:00	10.1	13.2	7.7	139.0	3,375,891.1	1,947.5	1.4	1.0
10/29/2021 04:00	10.1	13.2	7.7	139.0	3,375,371.1	1,947.2	1.4	1.0
10/29/2021 05:00	10.2	13.2	7.8	148.9	3,380,224.7	1,950.0	1.5	1.2
10/29/2021 06:00	10.6	13.2	8.1	138.6	3,426,018.9	1,951.4	1.4	1.0
10/29/2021 07:00	10.3	13.2	7.9	138.5	3,422,683.1	1,949.5	1.4	1.0
10/29/2021 08:00	10.3	13.2	7.9	140.1	3,419,171.8	1,947.5	1.4	1.0
10/29/2021 09:00	10.3	13.4	8.1	132.0	3,116,774.3	1,752.5	1.4	0.9
10/29/2021 10:00	10.4	13.6	8.4	118.6	2,755,966.6	1,449.0	1.5	0.9
10/29/2021 11:00	10.5	13.1	7.9	142.3	3,349,848.7	1,981.4	1.4	1.0
10/29/2021 12:00	10.4	13.3	8.1	133.3	3,094,372.4	1,762.5	1.5	1.1
10/29/2021 13:00	10.3	13.6	8.3	118.6	2,735,615.4	1,438.3	1.5	0.9
10/29/2021 14:00	10.4	13.1	7.9	139.8	3,329,037.3	1,993.4	1.4	1.0
10/29/2021 15:00	10.3	13.1	7.8	146.3	3,331,876.3	1,995.1	1.5	1.2
10/29/2021 16:00	10.2	13.1	7.7	143.6	3,328,703.3	1,993.2	1.5	1.2
10/29/2021 17:00	10.2	13.1	7.7	142.3	3,364,219.2	1,989.9	1.4	1.0
10/29/2021 18:00	10.2	13.1	7.7	142.3	3,358,302.0	1,986.4	1.4	1.0
10/29/2021 19:00	10.2	13.1	7.7	143.4	3,356,273.2	1,985.2	1.5	1.2
10/29/2021 20:00	10.2	13.1	7.7	142.5	3,350,525.0	1,981.8	1.4	1.0
10/29/2021 21:00	10.1	13.1	7.6	140.7	3,344,269.6	1,978.1	1.4	1.0
10/29/2021 22:00	10.1	13.1	7.6	141.4	3,361,594.5	1,963.8	1.4	1.0
10/29/2021 23:00	10.3	13.1	7.8	146.5	3,345,850.3	2,027.9	1.5	1.2
Average/Sum#:	10.2	13.2	7.8	138.9	3,295,939.4	1,909.1	1.4	1.0
Minimum:	9.9	13.1	7.6	118.6	2,735,615.4	1,438.3	1.4	0.9
Maximum:	10.6	13.6	8.4	148.9	3,426,018.9	2,027.9	1.5	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/30/2021 00:00	9.9	13.6	8.0	128.3	3,156,523.2	1,659.6	1.4	0.8
10/30/2021 01:00	10.5	13.6	8.5	110.0	2,835,287.1	1,470.0	1.3	0.7
10/30/2021 02:00	10.3	13.3	8.0	131.9	3,177,953.8	1,786.9	1.4	0.9
10/30/2021 03:00	10.1	13.1	7.6	139.2	3,359,943.4	1,938.3	1.4	1.0
10/30/2021 04:00	10.1	13.6	8.2	124.6	3,161,055.8	1,638.9	1.3	0.8
10/30/2021 05:00	10.2	13.6	8.2	130.4	3,227,847.4	1,697.1	1.4	0.8
10/30/2021 06:00	10.7	13.1	8.1	139.8	3,377,969.1	2,022.7	1.4	1.0
10/30/2021 07:00	10.2	13.2	7.8	139.7	3,371,557.5	1,945.0	1.4	1.0
10/30/2021 08:00	10.4	13.6	8.4	110.9	2,927,096.4	1,517.6	1.3	0.8
10/30/2021 09:00	10.8	13.7	8.9	104.4	2,641,228.4	1,350.1	1.3	0.7
10/30/2021 10:00	10.8	13.7	8.9	105.9	2,641,228.4	1,350.1	1.3	0.7
10/30/2021 11:00	10.5	13.6	8.5	127.0	2,861,325.5	1,483.5	1.5	0.9
10/30/2021 12:00	10.7	13.7	8.8	105.3	2,738,653.1	1,399.9	1.3	0.7
10/30/2021 13:00	10.6	13.7	8.7	110.0	2,756,455.7	1,409.0	1.3	0.7
10/30/2021 14:00	10.1	13.7	8.3	108.4	2,996,496.2	1,531.7	1.2	0.8
10/30/2021 15:00	10.1	13.6	8.2	119.8	3,133,860.2	1,624.8	1.3	0.8
10/30/2021 16:00	10.4	13.1	7.9	143.6	3,379,673.4	2,048.4	1.4	1.0
10/30/2021 17:00	10.5	13.1	7.9	165.7	3,397,944.7	2,109.1	1.7	1.5
10/30/2021 18:00	10.6	13.1	8.0	160.0	3,401,552.4	2,086.5	1.6	1.3
10/30/2021 19:00	10.1	13.2	7.7	144.3	3,346,238.6	2,003.7	1.5	1.2
10/30/2021 20:00	9.6	13.6	7.8	116.9	3,234,927.6	1,677.2	1.2	0.8
10/30/2021 21:00	9.7	13.6	7.8	116.6	3,173,592.8	1,645.4	1.2	0.8
10/30/2021 22:00	9.8	13.2	7.5	141.7	3,413,924.3	2,019.3	1.4	1.0
10/30/2021 23:00	9.5	13.3	7.4	135.8	3,352,489.6	1,934.0	1.4	1.0
Average/Sum#:	10.3	13.4	8.1	127.5	3,127,701.0	1,722.9	1.4	0.9
Minimum:	9.5	13.1	7.4	104.4	2,641,228.4	1,350.1	1.2	0.7
Maximum:	10.8	13.7	8.9	165.7	3,413,924.3	2,109.1	1.7	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
10/31/2021 00:00	9.8	13.6	7.9	124.4	3,214,482.6	1,666.6	1.3	0.8
10/31/2021 01:00	10.1	13.6	8.2	113.0	3,042,243.8	1,577.3	1.2	0.8
10/31/2021 02:00	9.6	13.3	7.5	131.2	3,427,950.1	1,952.5	1.3	1.0
10/31/2021 03:00	9.5	13.3	7.4	132.0	3,386,340.7	1,928.8	1.3	1.0
10/31/2021 04:00	9.8	13.6	7.9	124.7	3,281,603.7	1,701.4	1.3	0.9
10/31/2021 05:00	10.4	13.7	8.5	119.8	3,035,300.2	1,573.7	1.3	0.8
10/31/2021 06:00	10.3	13.2	7.9	140.0	3,457,712.0	2,045.2	1.4	1.0
10/31/2021 07:00	9.5	13.4	7.5	133.2	3,410,217.9	1,942.4	1.3	1.0
10/31/2021 08:00	9.9	13.6	8.0	124.1	3,198,473.9	1,658.3	1.3	0.8
10/31/2021 09:00	10.1	13.6	8.2	118.9	3,071,946.8	1,592.7	1.3	0.8
10/31/2021 10:00	10.5	13.7	8.6	110.0	2,769,563.0	1,415.7	1.3	0.7
10/31/2021 11:00	10.2	13.6	8.2	115.8	3,005,018.6	1,558.0	1.3	0.8
10/31/2021 12:00	10.0	13.7	8.2	118.9	3,105,700.2	1,610.2	1.3	0.8
10/31/2021 13:00	9.6	13.7	7.9	120.1	3,271,767.0	1,696.3	1.2	0.8
10/31/2021 14:00	10.0	13.7	8.2	115.1	3,082,183.0	1,575.5	1.2	0.8
10/31/2021 15:00	10.1	13.6	8.2	117.9	3,105,314.4	1,610.0	1.3	0.8
10/31/2021 16:00	10.1	13.2	7.7	140.4	3,355,757.8	2,009.4	1.4	1.0
10/31/2021 17:00	10.0	13.2	7.7	151.4	3,351,503.2	2,055.8	1.5	1.2
10/31/2021 18:00	9.9	13.1	7.5	153.7	3,374,326.9	2,069.8	1.6	1.2
10/31/2021 19:00	9.7	13.2	7.4	141.8	3,341,737.9	1,952.2	1.4	1.0
10/31/2021 20:00	9.6	13.6	7.8	122.9	3,267,138.0	1,693.9	1.3	0.8
10/31/2021 21:00	9.9	13.6	8.0	115.8	3,057,288.2	1,585.1	1.3	0.8
10/31/2021 22:00	10.0	13.2	7.7	142.2	3,409,190.5	2,016.5	1.4	1.0
10/31/2021 23:00	9.8	13.2	7.5	141.7	3,370,344.1	1,944.3	1.4	1.0
Average/Sum#:	9.9	13.5	7.9	127.9	3,224,712.7	1,768.0	1.3	0.9
Minimum:	9.5	13.1	7.4	110.0	2,769,563.0	1,415.7	1.2	0.7
Maximum:	10.5	13.7	8.6	153.7	3,457,712.0	2,069.8	1.6	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/01/2021 00:00	9.8	13.6	7.9	121.6	3,153,726.5	1,635.1	1.3	0.8
11/01/2021 01:00	9.7	13.5	7.7	121.3	3,221,000.3	1,693.5	1.3	0.8
11/01/2021 02:00	9.9	13.2	7.6	139.0	3,382,304.9	1,951.2	1.4	1.0
11/01/2021 03:00	9.9	13.2	7.6	144.7	3,345,737.6	2,003.4	1.5	1.2
11/01/2021 04:00	10.0	13.6	8.1	118.6	3,082,362.1	1,598.1	1.3	0.8
11/01/2021 05:00	9.9	13.6	8.0	133.6	3,211,680.6	1,688.6	1.4	0.8
11/01/2021 06:00	10.5	13.1	7.9	146.7	3,369,273.1	2,066.7	1.5	1.2
11/01/2021 07:00	10.3	13.1	7.8	163.4	3,373,879.5	2,118.8	1.7	1.5
11/01/2021 08:00	9.8	13.2	7.5	143.5	3,360,567.4	1,963.2	1.5	1.2
11/01/2021 09:00	10.0	13.6	8.1	120.4	3,041,858.0	1,577.1	1.3	0.8
11/01/2021 10:00	10.3	13.6	8.3	111.4	2,967,021.9	1,538.3	1.2	0.8
11/01/2021 11:00	10.2	13.1	7.7	147.0	3,366,474.1	2,040.4	1.5	1.2
11/01/2021 12:00	10.1	13.1	7.6	152.1	3,314,822.1	2,033.3	1.6	1.2
11/01/2021 13:00	9.6	13.6	7.8	122.5	3,309,956.6	1,716.1	1.2	0.9
11/01/2021 14:00	9.8	13.4	7.7	127.4	3,382,665.8	1,803.2	1.3	0.9
11/01/2021 15:00	10.2	13.1	7.7	145.7	3,359,049.5	2,035.9	1.5	1.2
11/01/2021 16:00	10.1	13.1	7.6	151.8	3,338,173.3	2,072.0	1.6	1.2
11/01/2021 17:00	10.2	13.0	7.6	176.9	3,355,089.7	2,205.0	1.8	1.5
11/01/2021 18:00	10.0	13.0	7.5	167.1	3,335,548.5	2,167.8	1.7	1.5
11/01/2021 19:00	10.2	13.0	7.6	174.9	3,350,981.5	2,202.3	1.8	1.5
11/01/2021 20:00	10.2	13.0	7.6	181.0	3,353,283.9	2,228.3	1.9	1.6
11/01/2021 21:00	10.2	13.0	7.6	180.6	3,361,328.2	2,209.1	1.9	1.5
11/01/2021 22:00	10.0	13.1	7.6	159.1	3,397,944.7	2,109.1	1.6	1.3
11/01/2021 23:00	9.5	13.3	7.4	137.9	3,387,218.5	1,929.3	1.4	1.0
Average/Sum#:	10.0	13.3	7.7	145.3	3,296,747.8	1,941.1	1.5	1.1
Minimum:	9.5	13.0	7.4	111.4	2,967,021.9	1,538.3	1.2	0.8
Maximum:	10.5	13.6	8.3	181.0	3,397,944.7	2,228.3	1.9	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/02/2021 00:00	10.2	13.6	8.2	117.1	3,017,362.7	1,564.4	1.3	0.8
11/02/2021 01:00	10.2	13.7	8.4	117.2	3,063,460.2	1,588.3	1.3	0.8
11/02/2021 02:00	9.7	13.3	7.5	133.8	3,427,774.6	1,952.4	1.3	1.0
11/02/2021 03:00	9.6	13.3	7.5	134.5	3,407,584.3	1,940.9	1.3	1.0
11/02/2021 04:00	10.4	13.6	8.4	134.0	3,158,044.8	1,660.4	1.4	0.8
11/02/2021 05:00	10.3	13.6	8.3	123.6	3,162,405.9	1,639.6	1.3	0.8
11/02/2021 06:00	10.6	13.1	8.0	146.4	3,407,886.8	2,065.5	1.5	1.2
11/02/2021 07:00	10.3	13.1	7.8	152.2	3,411,186.6	2,067.5	1.5	1.2
11/02/2021 08:00	9.6	13.3	7.5	137.2	3,418,469.5	1,947.1	1.4	1.0
11/02/2021 09:00	10.3	13.6	8.3	113.7	2,940,019.1	1,524.3	1.3	0.8
11/02/2021 10:00	10.0	13.6	8.1	124.8	3,151,026.2	1,633.7	1.3	0.8
11/02/2021 11:00	10.5	13.8	8.7	98.6	2,603,080.1	1,330.6	1.2	0.7
11/02/2021 12:00	10.1	13.7	8.3	104.1	3,000,213.2	1,533.6	1.1	0.6
11/02/2021 13:00	9.8	13.7	8.0	105.3	3,201,714.2	1,636.6	1.1	0.7
11/02/2021 14:00	9.9	13.7	8.1	104.9	3,173,347.6	1,622.1	1.1	0.6
11/02/2021 15:00	10.0	13.6	8.1	105.9	3,181,115.0	1,649.3	1.1	0.7
11/02/2021 16:00	10.1	13.2	7.7	124.6	3,389,737.8	2,054.5	1.2	1.0
11/02/2021 17:00	10.1	13.1	7.6	135.0	3,336,779.5	2,168.6	1.4	1.1
11/02/2021 18:00	9.9	13.1	7.5	134.3	3,372,674.4	2,167.3	1.4	1.1
11/02/2021 19:00	10.5	13.0	7.8	142.5	3,369,686.9	2,239.2	1.5	1.3
11/02/2021 20:00	10.6	13.0	7.9	136.4	3,384,345.6	2,174.8	1.4	1.1
11/02/2021 21:00	10.5	13.1	7.9	134.6	3,394,283.6	2,156.4	1.3	1.1
11/02/2021 22:00	10.1	13.1	7.6	131.2	3,385,822.2	2,126.3	1.3	1.1
11/02/2021 23:00	9.6	13.3	7.5	117.9	3,362,963.9	1,964.6	1.2	1.0
Average/Sum#:	10.1	13.4	7.9	125.4	3,238,374.4	1,850.3	1.3	0.9
Minimum:	9.6	13.0	7.5	98.6	2,603,080.1	1,330.6	1.1	0.6
Maximum:	10.6	13.8	8.7	152.2	3,427,774.6	2,239.2	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/03/2021 00:00	9.3	13.7	7.6	108.4	3,312,637.6	1,693.3	1.1	0.7
11/03/2021 01:00	9.7	13.6	7.8	105.0	3,174,171.4	1,645.7	1.1	0.7
11/03/2021 02:00	9.6	13.3	7.5	114.3	3,416,889.4	1,946.2	1.1	0.8
11/03/2021 03:00	9.3	13.4	7.3	113.1	3,399,157.1	1,936.1	1.1	0.8
11/03/2021 04:00	9.9	13.6	8.0	108.0	3,156,713.4	1,659.7	1.1	0.7
11/03/2021 05:00	9.2	13.6	7.4	128.8	3,446,513.3	1,786.9	1.3	0.9
11/03/2021 06:00	10.2	13.2	7.8	139.5	3,447,354.7	2,013.9	1.4	1.0
11/03/2021 07:00	9.6	13.3	7.5	136.9	3,438,121.9	1,983.4	1.3	1.0
11/03/2021 08:00	9.9	13.6	8.0	128.0	3,193,611.8	1,679.1	1.3	0.8
11/03/2021 09:00	9.8	13.6	7.9	123.3	3,256,722.6	1,688.5	1.3	0.8
11/03/2021 10:00	10.1	13.7	8.3	116.4	3,113,484.2	1,591.5	1.2	0.8
11/03/2021 11:00	9.5	13.7	7.8	118.6	3,330,048.8	1,702.2	1.2	0.9
11/03/2021 12:00	10.0	13.7	8.2	110.0	2,997,865.6	1,532.4	1.2	0.8
11/03/2021 13:00	9.2	13.7	7.5	110.5	3,325,744.9	1,700.0	1.1	0.7
11/03/2021 14:00	10.0	13.7	8.2	108.7	2,977,324.2	1,521.9	1.2	0.8
11/03/2021 15:00	10.0	13.6	8.1	116.8	3,082,747.9	1,598.3	1.3	0.8
11/03/2021 16:00	10.1	13.2	7.7	145.5	3,347,753.5	2,053.5	1.5	1.2
11/03/2021 17:00	10.4	13.0	7.8	185.3	3,325,594.4	2,209.9	1.9	1.5
11/03/2021 18:00	10.6	13.1	8.0	176.7	3,334,163.7	2,166.9	1.8	1.5
11/03/2021 19:00	10.7	13.0	8.0	189.2	3,355,240.2	2,229.6	2.0	1.8
11/03/2021 20:00	10.7	13.0	8.0	184.5	3,321,681.8	2,207.3	1.9	1.5
11/03/2021 21:00	10.3	13.1	7.8	165.9	3,348,709.5	2,151.9	1.7	1.5
11/03/2021 22:00	9.9	13.1	7.5	157.7	3,324,516.5	2,087.8	1.6	1.3
11/03/2021 23:00	9.8	13.2	7.5	140.0	3,319,655.9	1,939.3	1.4	1.0
Average/Sum#:	9.9	13.4	7.8	134.6	3,281,101.0	1,863.6	1.4	1.0
Minimum:	9.2	13.0	7.3	105.0	2,977,324.2	1,521.9	1.1	0.7
Maximum:	10.7	13.7	8.3	189.2	3,447,354.7	2,229.6	2.0	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/04/2021 00:00	10.2	13.6	8.2	110.8	2,853,996.1	1,479.7	1.3	0.7
11/04/2021 01:00	10.1	13.6	8.2	117.3	3,034,416.2	1,595.4	1.3	0.8
11/04/2021 02:00	10.1	13.2	7.7	139.1	3,347,729.1	1,955.7	1.4	1.0
11/04/2021 03:00	10.1	13.2	7.7	143.9	3,313,172.0	1,983.9	1.5	1.2
11/04/2021 04:00	9.5	13.7	7.8	119.7	3,263,666.2	1,692.1	1.2	0.8
11/04/2021 05:00	9.7	13.5	7.7	125.6	3,380,386.1	1,777.3	1.2	0.9
11/04/2021 06:00	10.4	13.2	8.0	141.6	3,377,134.1	2,022.2	1.4	1.0
11/04/2021 07:00	10.1	13.2	7.7	147.6	3,340,393.5	2,000.2	1.5	1.2
11/04/2021 08:00	9.9	13.7	8.1	116.8	3,128,743.5	1,599.3	1.2	0.8
11/04/2021 09:00	10.2	13.7	8.4	110.4	3,000,017.6	1,533.5	1.2	0.8
11/04/2021 10:00	10.2	13.7	8.4	109.6	2,985,345.2	1,526.0	1.2	0.8
11/04/2021 11:00	10.1	13.7	8.3	106.7	2,933,502.7	1,499.5	1.2	0.7
11/04/2021 12:00	10.3	13.8	8.6	99.7	2,754,130.8	1,387.7	1.2	0.7
11/04/2021 13:00	9.9	13.7	8.1	112.5	3,031,123.1	1,549.4	1.2	0.8
11/04/2021 14:00	9.5	13.7	7.8	119.0	3,260,599.5	1,666.7	1.2	0.8
11/04/2021 15:00	10.0	13.7	8.2	110.0	3,067,315.0	1,567.9	1.2	0.8
11/04/2021 16:00	10.1	13.2	7.7	144.2	3,364,608.9	2,014.7	1.5	1.2
11/04/2021 17:00	9.9	13.1	7.5	154.2	3,374,583.9	2,094.6	1.6	1.3
11/04/2021 18:00	9.9	13.2	7.6	150.5	3,366,175.6	2,064.8	1.5	1.2
11/04/2021 19:00	9.3	13.7	7.6	118.3	3,283,918.2	1,702.6	1.2	0.9
11/04/2021 20:00	9.7	13.6	7.8	119.2	3,173,399.9	1,645.3	1.3	0.8
11/04/2021 21:00	10.1	13.1	7.6	145.7	3,390,828.4	2,030.4	1.5	1.2
11/04/2021 22:00	9.9	13.4	7.8	124.8	3,042,644.8	1,688.6	1.4	0.8
11/04/2021 23:00	10.4	13.7	8.5	103.8	2,667,443.1	1,363.5	1.3	0.7
Average/Sum#:	10.0	13.5	8.0	124.6	3,155,636.4	1,726.7	1.3	0.9
Minimum:	9.3	13.1	7.5	99.7	2,667,443.1	1,363.5	1.2	0.7
Maximum:	10.4	13.8	8.6	154.2	3,390,828.4	2,094.6	1.6	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/05/2021 00:00	10.7	13.7	8.8	106.6	2,642,402.2	1,350.7	1.3	0.7
11/05/2021 01:00	10.6	13.7	8.7	104.2	2,660,791.6	1,360.1	1.3	0.7
11/05/2021 02:00	10.7	13.7	8.8	105.8	2,668,225.6	1,363.9	1.3	0.7
11/05/2021 03:00	10.6	13.7	8.7	108.6	2,738,261.9	1,399.7	1.3	0.7
11/05/2021 04:00	10.3	13.6	8.3	119.4	3,069,246.5	1,591.3	1.3	0.8
11/05/2021 05:00	9.9	13.3	7.7	169.9	3,294,488.8	2,093.0	1.8	1.5
11/05/2021 06:00	10.5	13.2	8.0	155.2	3,412,011.6	2,068.0	1.6	1.2
11/05/2021 07:00	10.3	13.4	8.1	186.3	3,088,134.5	1,871.7	2.1	1.5
11/05/2021 08:00	10.8	13.7	8.9	169.1	2,679,181.0	1,369.5	2.2	1.1
11/05/2021 09:00	10.7	13.7	8.8	170.6	902,575.2	1,377.5	6.9	3.7
11/05/2021 10:00	10.7	13.7	8.8	162.1	2,688,767.0	1,374.4	2.1	1.1
11/05/2021 11:00	10.6	13.7	8.7	157.5	2,689,940.8	1,375.0	2.0	1.1
11/05/2021 12:00	10.5	13.7	8.6	161.6	2,779,735.9	1,420.9	2.0	1.1
11/05/2021 13:00	9.9	13.5	7.9	160.2	3,481,616.8	1,805.1	1.6	1.1
11/05/2021 14:00	0.0	0.0	0.0	157.2	3,048,608.7	1,580.6	1.9	1.1
11/05/2021 15:00	11.0	13.5	8.8	159.3	3,039,736.4	1,576.0	1.8	1.1
11/05/2021 16:00	11.0	13.1	8.3	142.6	3,385,901.8	2,076.9	1.4	1.0
11/05/2021 17:00	10.5	13.1	7.9	154.5	3,394,561.4	2,107.0	1.6	1.3
11/05/2021 18:00	10.2	13.1	7.7	151.9	3,365,884.0	2,089.2	1.5	1.3
11/05/2021 19:00	9.8	13.2	7.5	143.3	3,355,427.9	1,984.7	1.5	1.2
11/05/2021 20:00	9.8	13.6	7.9	123.7	3,227,598.3	1,673.4	1.3	0.8
11/05/2021 21:00	9.3	13.6	7.5	120.1	3,453,649.7	1,790.6	1.2	0.9
11/05/2021 22:00	9.9	13.2	7.6	140.0	3,437,762.4	2,033.4	1.4	1.0
11/05/2021 23:00	9.6	13.3	7.5	135.3	3,386,811.8	1,953.8	1.4	1.0
Average/Sum#:	10.3	13.5	8.2	144.4	3,086,467.2	1,695.3	1.6	1.0
Minimum:	9.3	13.1	7.5	104.2	2,642,402.2	1,350.7	1.2	0.7
Maximum:	11.0	13.7	8.9	186.3	3,481,616.8	2,107.0	2.2	1.5
%SI	4.17	4.17	4.17	0.00	4.17	0.00	8.33	8.33

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/06/2021 00:00	10.0	13.6	8.1	128.8	3,230,129.8	1,698.3	1.3	0.8
11/06/2021 01:00	9.9	13.6	8.0	114.7	3,101,264.0	1,607.9	1.2	0.8
11/06/2021 02:00	9.8	13.3	7.6	134.5	3,442,171.1	1,960.6	1.3	1.0
11/06/2021 03:00	9.5	13.4	7.5	133.2	3,428,301.3	1,952.7	1.3	1.0
11/06/2021 04:00	9.9	13.6	8.0	127.8	3,269,645.4	1,695.2	1.3	0.8
11/06/2021 05:00	10.0	13.7	8.2	118.6	3,133,281.6	1,624.5	1.3	0.8
11/06/2021 06:00	10.3	13.2	7.9	143.5	3,415,953.0	2,020.5	1.4	1.0
11/06/2021 07:00	9.8	13.3	7.6	139.2	3,369,824.1	1,944.0	1.4	1.0
11/06/2021 08:00	10.0	13.6	8.1	117.7	3,126,530.9	1,621.0	1.3	0.8
11/06/2021 09:00	10.2	13.6	8.2	120.7	3,124,409.2	1,619.9	1.3	0.8
11/06/2021 10:00	10.3	13.6	8.3	121.6	3,135,981.8	1,625.9	1.3	0.8
11/06/2021 11:00	10.4	13.6	8.4	114.2	3,010,226.2	1,560.7	1.3	0.8
11/06/2021 12:00	10.4	13.6	8.4	119.6	2,996,917.8	1,553.8	1.3	0.8
11/06/2021 13:00	10.1	13.6	8.2	116.5	3,053,623.5	1,583.2	1.3	0.8
11/06/2021 14:00	10.3	13.7	8.4	109.6	2,916,091.4	1,490.6	1.2	0.7
11/06/2021 15:00	9.9	13.6	8.0	114.0	3,077,926.0	1,595.8	1.2	0.8
11/06/2021 16:00	10.1	13.2	7.7	149.2	3,369,619.0	2,017.7	1.5	1.2
11/06/2021 17:00	10.1	13.1	7.6	156.7	3,353,178.9	2,105.8	1.6	1.3
11/06/2021 18:00	9.5	13.3	7.4	138.1	3,342,262.2	1,928.1	1.4	1.0
11/06/2021 19:00	9.7	13.6	7.8	122.4	3,225,476.6	1,672.3	1.3	0.8
11/06/2021 20:00	9.7	13.6	7.8	120.5	3,215,104.1	1,690.4	1.3	0.8
11/06/2021 21:00	9.8	13.2	7.5	140.4	3,420,650.9	1,998.3	1.4	1.0
11/06/2021 22:00	13.8	14.1	12.0	145.0	2,900,440.8	1,482.6	1.7	1.0
11/06/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	10.2	13.5	8.1	128.1	3,202,565.6	1,741.3	1.3	0.9
Minimum:	9.5	13.1	7.4	109.6	2,900,440.8	1,482.6	1.2	0.7
Maximum:	13.8	14.1	12.0	156.7	3,442,171.1	2,105.8	1.7	1.3
%SI	4.17	4.17	4.17	4.17	4.17	4.17	4.17	4.17

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/07/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/08/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/08/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/08/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/08/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/08/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/08/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/08/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/08/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/08/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/08/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/08/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/08/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/08/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/08/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/08/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/08/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/08/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/08/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/08/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/08/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/08/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/08/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/08/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/08/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/09/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/09/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/09/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/09/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/09/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/09/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/09/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/09/2021 07:00	38.2	17.1	59.3	25.4	1,499,922.5	372.4	0.0	0.0
11/09/2021 08:00	36.8	14.7	35.0	237.4	2,372,071.3	1,039.3	3.2	1.2
11/09/2021 09:00	10.5	13.6	8.5	135.0	3,322,879.3	1,722.8	1.4	0.9
11/09/2021 10:00	10.9	13.6	8.8	118.9	2,946,769.8	1,527.8	1.3	0.8
11/09/2021 11:00	10.9	13.6	8.8	123.9	3,050,923.2	1,581.8	1.4	0.8
11/09/2021 12:00	10.9	13.6	8.8	119.6	2,994,024.6	1,552.3	1.3	0.8
11/09/2021 13:00	10.6	13.6	8.6	131.9	3,248,428.9	1,684.2	1.4	0.8
11/09/2021 14:00	10.8	13.6	8.7	125.9	3,148,325.9	1,632.3	1.3	0.8
11/09/2021 15:00	10.7	13.6	8.6	115.4	2,955,256.4	1,532.2	1.3	0.8
11/09/2021 16:00	11.0	13.6	8.9	122.1	3,037,229.0	1,574.7	1.3	0.8
11/09/2021 17:00	10.3	13.4	8.1	135.6	3,364,459.5	1,867.2	1.4	0.9
11/09/2021 18:00	10.5	13.1	7.9	158.7	3,417,828.5	2,146.4	1.6	1.3
11/09/2021 19:00	10.5	13.0	7.8	173.1	3,405,250.7	2,213.1	1.8	1.5
11/09/2021 20:00	10.2	13.1	7.7	164.0	3,371,968.7	2,117.6	1.7	1.5
11/09/2021 21:00	10.5	13.6	8.5	126.8	3,126,338.0	1,620.9	1.4	0.8
11/09/2021 22:00	10.1	13.6	8.2	133.5	3,341,588.4	1,732.5	1.3	0.9
11/09/2021 23:00	10.1	13.2	7.7	143.6	3,456,427.1	2,019.2	1.4	1.0
Average/Sum#:	13.7	13.7	12.9	134.8	3,062,334.8	1,643.3	1.4	0.9
Minimum:	10.1	13.0	7.7	25.4	1,499,922.5	372.4	0.0	0.0
Maximum:	38.2	17.1	59.3	237.4	3,456,427.1	2,213.1	3.2	1.5
%SI	29.17	29.17	29.17	29.17	29.17	29.17	29.17	29.17

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/10/2021 00:00	9.8	13.4	7.7	137.4	3,320,493.8	1,842.8	1.4	0.9
11/10/2021 01:00	10.0	13.4	7.9	128.5	3,394,109.0	1,809.3	1.3	0.9
11/10/2021 02:00	10.3	13.7	8.4	117.6	3,079,469.0	1,596.6	1.3	0.8
11/10/2021 03:00	9.7	13.4	7.6	130.3	3,459,201.1	1,970.3	1.3	1.0
11/10/2021 04:00	9.6	13.4	7.6	133.3	3,465,532.9	1,948.6	1.3	1.0
11/10/2021 05:00	10.1	13.6	8.2	129.9	3,303,591.7	1,712.8	1.3	0.9
11/10/2021 06:00	9.7	13.6	7.8	119.7	3,458,278.8	1,793.0	1.1	0.7
11/10/2021 07:00	9.9	13.3	7.7	138.9	3,472,617.6	2,003.3	1.4	1.0
11/10/2021 08:00	9.5	13.4	7.5	133.6	3,456,462.7	1,943.5	1.3	1.0
11/10/2021 09:00	10.4	13.7	8.5	118.2	3,050,490.6	1,559.3	1.3	0.8
11/10/2021 10:00	10.8	13.7	8.9	111.4	2,895,158.8	1,479.9	1.3	0.7
11/10/2021 11:00	10.7	13.7	8.8	106.2	2,780,518.4	1,421.3	1.3	0.7
11/10/2021 12:00	10.7	13.7	8.8	112.8	2,879,703.8	1,472.0	1.3	0.7
11/10/2021 13:00	10.7	13.8	8.9	102.3	2,651,010.0	1,355.1	1.3	0.7
11/10/2021 14:00	10.5	13.7	8.6	115.1	2,925,677.4	1,495.5	1.3	0.7
11/10/2021 15:00	10.2	13.6	8.2	118.2	3,074,261.3	1,593.9	1.3	0.8
11/10/2021 16:00	10.0	13.2	7.7	142.1	3,415,953.0	2,020.5	1.4	1.0
11/10/2021 17:00	10.0	13.2	7.7	145.3	3,404,856.6	2,038.8	1.5	1.2
11/10/2021 18:00	10.0	13.1	7.6	151.8	3,412,964.2	2,093.5	1.5	1.3
11/10/2021 19:00	9.9	13.1	7.5	153.3	3,407,910.4	2,090.4	1.5	1.3
11/10/2021 20:00	9.8	13.2	7.5	147.3	3,408,345.1	2,016.0	1.5	1.2
11/10/2021 21:00	9.8	13.6	7.9	129.6	3,287,004.3	1,704.2	1.3	0.9
11/10/2021 22:00	9.4	13.6	7.6	125.3	3,436,483.7	1,781.7	1.2	0.9
11/10/2021 23:00	9.7	13.3	7.5	142.6	3,451,118.5	2,041.3	1.4	1.0
Average/Sum#:	10.1	13.5	8.0	128.8	3,245,467.2	1,782.7	1.3	0.9
Minimum:	9.4	13.1	7.5	102.3	2,651,010.0	1,355.1	1.1	0.7
Maximum:	10.8	13.8	8.9	153.3	3,472,617.6	2,093.5	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/11/2021 00:00	9.6	13.3	7.5	137.8	3,384,558.4	1,952.5	1.4	1.0
11/11/2021 01:00	23.4	16.0	28.2	165.0	1,570,004.8	584.7	3.4	0.8
11/11/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/11/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/11/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/11/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/11/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/11/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/11/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/11/2021 09:00	34.9	17.5	60.6	39.3	1,489,839.3	315.5	0.0	0.0
11/11/2021 10:00	48.5	15.4	52.0	259.1	2,043,284.5	790.8	4.0	1.2
11/11/2021 11:00	10.8	13.7	8.9	110.6	2,746,674.1	1,404.0	1.3	0.7
11/11/2021 12:00	10.9	13.8	9.1	91.1	2,679,181.0	1,369.5	1.1	0.5
11/11/2021 13:00	10.1	13.6	8.2	108.5	3,306,870.6	1,714.5	1.1	0.7
11/11/2021 14:00	10.7	13.7	8.8	116.2	2,973,020.3	1,519.7	1.3	0.8
11/11/2021 15:00	10.2	13.7	8.4	123.7	3,263,729.6	1,668.3	1.3	0.8
11/11/2021 16:00	10.3	13.4	8.1	138.0	3,325,539.0	1,845.6	1.4	0.9
11/11/2021 17:00	10.7	13.1	8.1	166.4	3,332,580.8	2,117.2	1.7	1.5
11/11/2021 18:00	10.7	13.1	8.1	168.7	3,371,013.3	2,117.0	1.7	1.5
11/11/2021 19:00	10.7	13.1	8.1	169.0	3,378,338.1	2,121.6	1.7	1.5
11/11/2021 20:00	10.6	13.1	8.0	167.4	3,337,573.8	2,096.0	1.7	1.5
11/11/2021 21:00	10.7	13.6	8.6	142.9	3,261,930.3	1,691.2	1.5	1.0
11/11/2021 22:00	10.0	13.6	8.1	133.4	3,426,068.4	1,776.3	1.3	0.9
11/11/2021 23:00	10.3	13.2	7.9	142.5	3,425,957.5	2,001.4	1.4	1.0
Average/Sum#:	14.9	13.9	15.1	140.0	2,959,774.3	1,593.3	1.6	1.0
Minimum:	9.6	13.1	7.5	39.3	1,489,839.3	315.5	0.0	0.0
Maximum:	48.5	17.5	60.6	259.1	3,426,068.4	2,121.6	4.0	1.5
%SI	29.17	29.17	29.17	29.17	29.17	29.17	29.17	29.17

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/12/2021 00:00	9.9	13.3	7.7	139.9	3,391,256.6	1,931.6	1.4	1.0
11/12/2021 01:00	10.6	13.6	8.6	124.4	3,038,386.2	1,575.3	1.4	0.8
11/12/2021 02:00	10.8	13.6	8.7	120.3	2,974,736.9	1,542.3	1.3	0.8
11/12/2021 03:00	10.8	13.6	8.7	119.5	2,981,101.9	1,545.6	1.3	0.8
11/12/2021 04:00	10.4	13.6	8.4	121.8	3,058,831.2	1,585.9	1.3	0.8
11/12/2021 05:00	10.3	13.2	7.9	143.4	3,381,158.3	2,049.3	1.4	1.0
11/12/2021 06:00	10.6	13.1	8.0	152.6	3,435,935.3	2,082.5	1.5	1.2
11/12/2021 07:00	10.3	13.5	8.2	133.2	3,131,725.5	1,692.3	1.4	0.8
11/12/2021 08:00	10.7	13.7	8.8	116.5	2,788,343.7	1,425.3	1.4	0.7
11/12/2021 09:00	10.8	13.7	8.9	110.1	2,680,159.2	1,370.0	1.4	0.7
11/12/2021 10:00	10.9	13.7	8.9	107.3	2,691,114.5	1,375.6	1.3	0.7
11/12/2021 11:00	10.9	13.7	8.9	108.5	2,704,808.8	1,382.6	1.3	0.7
11/12/2021 12:00	10.9	13.7	8.9	106.8	2,708,525.8	1,384.5	1.3	0.7
11/12/2021 13:00	10.9	13.7	8.9	109.4	2,713,612.2	1,387.1	1.3	0.7
11/12/2021 14:00	10.8	13.7	8.9	106.7	2,717,133.6	1,388.9	1.3	0.7
11/12/2021 15:00	10.4	13.6	8.4	137.0	3,173,014.2	1,645.1	1.5	1.0
11/12/2021 16:00	10.5	13.6	8.5	120.0	3,061,531.4	1,587.3	1.3	0.8
11/12/2021 17:00	10.8	13.7	8.9	112.9	2,828,252.6	1,445.7	1.3	0.7
11/12/2021 18:00	10.3	13.6	8.3	123.9	3,071,753.9	1,592.6	1.4	0.8
11/12/2021 19:00	10.3	13.1	7.8	147.5	3,440,428.3	2,060.1	1.5	1.2
11/12/2021 20:00	10.1	13.2	7.7	146.3	3,400,109.6	1,986.3	1.5	1.2
11/12/2021 21:00	10.5	13.6	8.5	130.4	3,153,533.6	1,635.0	1.4	0.8
11/12/2021 22:00	10.2	13.6	8.2	131.5	3,278,517.7	1,699.8	1.3	0.8
11/12/2021 23:00	10.2	13.2	7.8	147.1	3,452,132.9	2,041.9	1.4	1.0
Average/Sum#:	10.5	13.5	8.4	125.7	3,052,337.7	1,642.2	1.4	0.9
Minimum:	9.9	13.1	7.7	106.7	2,680,159.2	1,370.0	1.3	0.7
Maximum:	10.9	13.7	8.9	152.6	3,452,132.9	2,082.5	1.5	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/13/2021 00:00	15.9	14.6	14.9	158.2	2,595,164.5	1,231.8	2.0	1.0
11/13/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/13/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/13/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/13/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/13/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/13/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/13/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/13/2021 08:00	33.8	17.5	58.7	64.0	1,500,228.0	317.7	0.0	0.0
11/13/2021 09:00	34.2	15.2	35.4	226.9	2,368,606.2	951.3	3.0	1.1
11/13/2021 10:00	10.9	13.7	8.9	103.2	2,715,372.9	1,388.0	1.3	0.7
11/13/2021 11:00	11.0	13.7	9.0	107.6	2,688,571.3	1,374.3	1.3	0.7
11/13/2021 12:00	11.0	13.7	9.0	109.6	2,708,330.2	1,384.4	1.3	0.7
11/13/2021 13:00	10.1	13.6	8.2	131.5	3,362,033.3	1,743.1	1.3	0.9
11/13/2021 14:00	10.6	13.7	8.7	110.4	2,932,720.1	1,499.1	1.2	0.7
11/13/2021 15:00	10.2	13.7	8.4	132.5	3,343,938.7	1,709.3	1.3	0.9
11/13/2021 16:00	10.1	13.5	8.1	130.9	3,395,031.3	1,785.0	1.3	0.9
11/13/2021 17:00	10.4	13.2	8.0	146.2	3,364,824.2	2,039.4	1.5	1.2
11/13/2021 18:00	10.3	13.2	7.9	148.1	3,323,860.2	1,990.3	1.5	1.2
11/13/2021 19:00	10.3	13.6	8.3	135.8	3,289,511.7	1,705.5	1.4	0.9
11/13/2021 20:00	10.0	13.6	8.1	133.6	3,459,436.0	1,793.6	1.3	0.9
11/13/2021 21:00	10.2	13.2	7.8	144.4	3,442,158.1	2,036.0	1.4	1.0
11/13/2021 22:00	14.1	14.1	12.2	156.0	2,849,734.1	1,498.3	1.8	1.0
11/13/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	13.9	14.0	13.9	133.7	2,958,720.1	1,527.9	1.4	0.9
Minimum:	10.0	13.2	7.8	64.0	1,500,228.0	317.7	0.0	0.0
Maximum:	34.2	17.5	58.7	226.9	3,459,436.0	2,039.4	3.0	1.2
%SI	33.33	33.33	33.33	33.33	33.33	33.33	33.33	33.33

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/14/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/14/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/14/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/14/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/14/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/14/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/14/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/14/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/14/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/14/2021 09:00	25.1	17.7	46.3	0.0	1,345,012.9	225.9	0.0	0.0
11/14/2021 10:00	41.0	17.1	63.7	158.7	1,521,171.4	411.0	0.0	0.0
11/14/2021 11:00	24.3	14.2	21.4	186.3	2,522,058.4	1,197.1	2.4	1.1
11/14/2021 12:00	11.2	13.7	9.2	108.0	2,677,029.0	1,368.4	1.3	0.7
11/14/2021 13:00	11.0	13.7	9.0	108.8	2,699,918.0	1,380.1	1.3	0.7
11/14/2021 14:00	10.6	13.5	8.5	133.3	3,186,322.7	1,652.0	1.4	0.8
11/14/2021 15:00	10.7	13.6	8.6	123.3	3,110,715.0	1,612.8	1.3	0.8
11/14/2021 16:00	11.1	13.7	9.1	105.3	2,586,842.7	1,322.3	1.3	0.7
11/14/2021 17:00	10.5	13.6	8.5	121.1	3,071,368.2	1,592.4	1.3	0.8
11/14/2021 18:00	10.5	13.1	7.9	149.2	3,401,947.2	2,061.9	1.5	1.2
11/14/2021 19:00	10.1	13.3	7.8	141.2	3,403,279.6	1,963.3	1.4	1.0
11/14/2021 20:00	10.4	13.5	8.3	140.8	3,239,345.2	1,726.8	1.5	1.0
11/14/2021 21:00	10.4	13.6	8.4	122.8	3,066,739.1	1,590.0	1.3	0.8
11/14/2021 22:00	10.4	13.1	7.9	145.9	3,434,249.2	2,056.4	1.4	1.0
11/14/2021 23:00	10.3	13.5	8.2	129.6	3,046,147.6	1,668.3	1.4	0.8
Average/Sum#:	14.5	14.1	15.5	125.0	2,820,809.7	1,455.2	1.3	0.8
Minimum:	10.1	13.1	7.8	0.0	1,345,012.9	225.9	0.0	0.0
Maximum:	41.0	17.7	63.7	186.3	3,434,249.2	2,061.9	2.4	1.2
%SI	37.50	37.50	37.50	37.50	37.50	37.50	37.50	37.50

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/15/2021 00:00	10.8	13.7	8.9	110.9	2,670,768.8	1,365.2	1.4	0.7
11/15/2021 01:00	10.9	13.7	8.9	105.6	2,659,813.4	1,359.6	1.3	0.7
11/15/2021 02:00	11.0	13.7	9.0	108.5	2,670,964.4	1,365.3	1.3	0.7
11/15/2021 03:00	11.0	13.7	9.0	107.0	2,682,311.1	1,371.1	1.3	0.7
11/15/2021 04:00	11.0	13.7	9.0	107.6	2,683,484.9	1,371.7	1.3	0.7
11/15/2021 05:00	10.9	13.7	8.9	114.1	2,787,646.6	1,445.3	1.4	0.7
11/15/2021 06:00	10.9	13.6	8.8	117.6	3,021,413.1	1,566.5	1.3	0.8
11/15/2021 07:00	10.0	13.6	8.1	139.7	3,372,641.5	1,748.6	1.4	0.9
11/15/2021 08:00	10.5	13.6	8.5	120.9	3,064,424.6	1,588.8	1.3	0.8
11/15/2021 09:00	10.8	13.7	8.9	106.7	2,770,541.2	1,416.2	1.3	0.7
11/15/2021 10:00	10.0	13.6	8.1	123.8	3,153,919.4	1,635.2	1.3	0.8
11/15/2021 11:00	9.7	13.3	7.5	132.0	3,460,254.5	1,970.9	1.3	1.0
11/15/2021 12:00	9.6	13.3	7.5	136.4	3,449,896.0	1,965.0	1.3	1.0
11/15/2021 13:00	10.3	13.6	8.3	120.3	2,910,407.2	1,530.2	1.4	0.8
11/15/2021 14:00	10.1	13.6	8.2	123.5	3,089,884.3	1,602.0	1.3	0.8
11/15/2021 15:00	9.9	13.3	7.7	137.3	3,407,786.6	1,965.9	1.4	1.0
11/15/2021 16:00	9.8	13.2	7.5	143.4	3,436,228.1	2,007.4	1.4	1.0
11/15/2021 17:00	9.5	13.3	7.4	133.9	3,432,866.0	1,955.3	1.3	1.0
11/15/2021 18:00	9.6	13.3	7.5	137.5	3,451,476.1	1,965.9	1.3	1.0
11/15/2021 19:00	10.0	13.1	7.6	153.1	3,413,127.3	2,093.6	1.5	1.3
11/15/2021 20:00	9.4	13.3	7.3	132.7	3,427,072.3	1,952.0	1.3	1.0
11/15/2021 21:00	9.6	13.3	7.5	135.3	3,428,652.4	1,952.9	1.3	1.0
11/15/2021 22:00	9.6	13.3	7.5	134.3	3,416,011.6	1,945.7	1.3	1.0
11/15/2021 23:00	9.6	13.3	7.5	132.5	3,395,294.6	1,933.9	1.3	1.0
Average/Sum#:	10.2	13.5	8.1	125.6	3,135,703.6	1,711.4	1.3	0.9
Minimum:	9.4	13.1	7.3	105.6	2,659,813.4	1,359.6	1.3	0.7
Maximum:	11.0	13.7	9.0	153.1	3,460,254.5	2,093.6	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/16/2021 00:00	21.5	15.7	24.4	160.6	1,701,890.2	671.1	3.1	0.8
11/16/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/16/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/16/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/16/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/16/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/16/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/16/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/16/2021 08:00	33.0	17.5	57.3	33.5	1,476,145.0	312.6	0.0	0.0
11/16/2021 09:00	38.3	15.7	43.5	239.3	2,061,257.6	752.6	3.7	1.1
11/16/2021 10:00	10.9	13.7	8.9	100.1	2,708,917.1	1,384.7	1.2	0.7
11/16/2021 11:00	10.7	13.8	8.9	105.1	2,696,592.2	1,378.4	1.3	0.7
11/16/2021 12:00	10.7	13.8	8.9	102.9	2,704,221.9	1,382.3	1.2	0.7
11/16/2021 13:00	10.5	13.7	8.6	120.4	2,972,422.4	1,541.1	1.4	0.8
11/16/2021 14:00	10.2	13.6	8.2	133.0	3,360,876.0	1,742.5	1.3	0.9
11/16/2021 15:00	10.7	13.7	8.8	114.5	2,930,372.5	1,497.9	1.3	0.7
11/16/2021 16:00	10.5	13.7	8.6	115.1	2,953,848.4	1,509.9	1.3	0.8
11/16/2021 17:00	10.2	13.3	7.9	144.1	3,401,546.2	1,962.3	1.4	1.0
11/16/2021 18:00	10.2	13.2	7.8	156.9	3,436,253.2	2,057.6	1.6	1.2
11/16/2021 19:00	9.9	13.4	7.8	138.6	3,457,445.4	1,969.3	1.4	1.0
11/16/2021 20:00	10.4	13.2	8.0	169.1	3,435,966.3	2,132.7	1.7	1.5
11/16/2021 21:00	10.2	13.2	7.8	171.2	3,420,727.7	2,173.2	1.7	1.5
11/16/2021 22:00	10.0	13.2	7.7	162.8	3,422,419.8	2,099.3	1.6	1.3
11/16/2021 23:00	10.1	13.2	7.7	170.6	3,413,959.2	2,168.9	1.7	1.5
Average/Sum#:	14.0	14.0	14.2	137.5	2,914,991.8	1,572.7	1.6	1.0
Minimum:	9.9	13.2	7.7	33.5	1,476,145.0	312.6	0.0	0.0
Maximum:	38.3	17.5	57.3	239.3	3,457,445.4	2,173.2	3.7	1.5
%SI	29.17	29.17	29.17	29.17	29.17	29.17	29.17	29.17

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/17/2021 00:00	9.8	13.3	7.6	149.3	3,424,245.7	2,000.4	1.5	1.2
11/17/2021 01:00	9.6	13.4	7.6	135.7	3,474,781.0	1,953.8	1.3	1.0
11/17/2021 02:00	9.5	13.4	7.5	134.5	3,477,626.5	1,955.4	1.3	1.0
11/17/2021 03:00	9.5	13.4	7.5	134.9	3,478,337.9	1,955.8	1.3	1.0
11/17/2021 04:00	9.7	13.3	7.5	145.7	3,501,912.8	2,020.2	1.4	1.0
11/17/2021 05:00	9.6	13.3	7.5	146.7	3,454,837.9	2,043.5	1.4	1.0
11/17/2021 06:00	10.5	13.1	7.9	171.8	3,468,378.5	2,228.8	1.7	1.6
11/17/2021 07:00	10.0	13.2	7.7	161.4	3,443,860.7	2,137.6	1.6	1.3
11/17/2021 08:00	9.5	13.4	7.5	138.6	3,529,871.5	1,959.0	1.3	1.0
11/17/2021 09:00	9.4	13.4	7.4	134.3	3,465,532.9	1,948.6	1.3	1.0
11/17/2021 10:00	10.2	13.7	8.4	118.0	2,992,481.6	1,551.5	1.3	0.8
11/17/2021 11:00	9.7	13.4	7.6	134.2	3,447,115.1	1,887.9	1.3	0.9
11/17/2021 12:00	9.7	13.4	7.6	139.0	3,478,160.1	1,955.7	1.4	1.0
11/17/2021 13:00	10.3	13.7	8.4	118.8	2,879,214.8	1,513.8	1.4	0.8
11/17/2021 14:00	10.4	13.7	8.5	117.2	2,871,487.3	1,467.8	1.4	0.7
11/17/2021 15:00	9.9	13.3	7.7	136.9	3,373,464.3	1,946.1	1.4	1.0
11/17/2021 16:00	10.0	13.2	7.7	156.5	3,413,991.5	2,069.2	1.6	1.2
11/17/2021 17:00	10.0	13.1	7.6	170.0	3,397,903.9	2,158.7	1.7	1.5
11/17/2021 18:00	10.0	13.1	7.6	169.6	3,420,098.0	2,172.8	1.7	1.5
11/17/2021 19:00	10.0	13.1	7.6	181.0	3,414,175.0	2,218.9	1.8	1.6
11/17/2021 20:00	10.0	13.1	7.6	179.1	3,424,022.6	2,225.3	1.8	1.6
11/17/2021 21:00	9.8	13.2	7.5	163.2	3,416,633.3	2,120.7	1.6	1.3
11/17/2021 22:00	9.2	13.4	7.2	132.0	3,468,912.0	1,950.5	1.3	1.0
11/17/2021 23:00	9.4	13.4	7.4	139.5	3,476,381.6	1,954.7	1.4	1.0
Average/Sum#:	9.8	13.3	7.7	146.2	3,383,059.4	1,974.9	1.5	1.1
Minimum:	9.2	13.1	7.2	117.2	2,871,487.3	1,467.8	1.3	0.7
Maximum:	10.5	13.7	8.5	181.0	3,529,871.5	2,228.8	1.8	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/18/2021 00:00	9.3	13.4	7.3	131.9	3,470,690.5	1,951.5	1.3	1.0
11/18/2021 01:00	9.3	13.4	7.3	133.8	3,473,536.1	1,953.1	1.3	1.0
11/18/2021 02:00	9.3	13.4	7.3	131.6	3,476,025.9	1,954.5	1.3	1.0
11/18/2021 03:00	9.5	13.4	7.5	137.6	3,482,072.7	1,957.9	1.3	1.0
11/18/2021 04:00	9.3	13.4	7.3	132.0	3,482,250.6	1,958.0	1.3	1.0
11/18/2021 05:00	9.7	13.3	7.5	154.0	3,422,391.9	2,049.3	1.5	1.2
11/18/2021 06:00	10.4	13.1	7.9	162.7	3,467,350.7	2,177.5	1.6	1.3
11/18/2021 07:00	10.1	13.1	7.6	160.3	3,443,699.6	2,137.5	1.6	1.3
11/18/2021 08:00	9.7	13.2	7.4	147.4	3,444,017.8	2,037.1	1.5	1.2
11/18/2021 09:00	9.4	13.4	7.4	134.5	3,437,788.7	1,933.0	1.3	1.0
11/18/2021 10:00	9.8	13.6	7.9	125.6	3,212,939.6	1,665.8	1.3	0.8
11/18/2021 11:00	9.5	13.4	7.5	133.3	3,436,728.5	1,957.5	1.3	1.0
11/18/2021 12:00	9.5	13.3	7.4	135.8	3,432,514.9	1,955.1	1.3	1.0
11/18/2021 13:00	10.3	13.6	8.3	120.3	2,907,173.8	1,528.5	1.4	0.8
11/18/2021 14:00	10.2	13.7	8.4	116.6	2,942,893.0	1,504.3	1.3	0.8
11/18/2021 15:00	9.6	13.4	7.6	129.4	3,398,948.3	1,836.7	1.3	0.9
11/18/2021 16:00	10.2	13.1	7.7	161.0	3,396,331.7	2,132.9	1.6	1.3
11/18/2021 17:00	10.2	13.1	7.7	167.9	3,381,544.5	2,173.0	1.7	1.5
11/18/2021 18:00	10.2	13.0	7.6	189.3	3,407,007.5	2,264.0	1.9	1.6
11/18/2021 19:00	10.0	13.1	7.6	171.0	3,386,835.5	2,176.4	1.7	1.5
11/18/2021 20:00	9.9	13.1	7.5	161.5	3,396,011.4	2,107.9	1.6	1.3
11/18/2021 21:00	9.7	13.2	7.4	140.8	3,423,214.3	1,974.8	1.4	1.0
11/18/2021 22:00	9.5	13.4	7.5	136.8	3,454,684.2	1,942.5	1.3	1.0
11/18/2021 23:00	9.6	13.4	7.6	137.2	3,453,083.6	1,941.6	1.3	1.0
Average/Sum#:	9.8	13.3	7.6	143.8	3,384,572.3	1,969.6	1.4	1.1
Minimum:	9.3	13.0	7.3	116.6	2,907,173.8	1,504.3	1.3	0.8
Maximum:	10.4	13.7	8.4	189.3	3,482,250.6	2,264.0	1.9	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/19/2021 00:00	9.7	13.4	7.6	137.8	3,450,415.9	1,940.1	1.4	1.0
11/19/2021 01:00	9.7	13.4	7.6	135.9	3,409,866.7	1,917.3	1.3	1.0
11/19/2021 02:00	10.2	13.6	8.2	130.8	3,160,862.9	1,638.8	1.4	0.8
11/19/2021 03:00	9.6	13.4	7.6	135.8	3,423,561.0	1,950.0	1.3	1.0
11/19/2021 04:00	10.2	13.2	7.8	151.1	3,408,697.7	2,041.1	1.5	1.2
11/19/2021 05:00	10.3	13.1	7.8	161.0	3,402,693.5	2,087.2	1.6	1.3
11/19/2021 06:00	10.7	13.1	8.1	162.9	3,409,389.0	2,141.1	1.6	1.3
11/19/2021 07:00	10.3	13.1	7.8	164.6	3,410,833.4	2,117.1	1.7	1.5
11/19/2021 08:00	10.0	13.2	7.7	145.8	3,439,682.0	1,984.3	1.4	1.0
11/19/2021 09:00	9.7	13.4	7.6	139.7	3,425,492.2	1,951.1	1.4	1.0
11/19/2021 10:00	9.8	13.3	7.6	149.0	3,425,667.8	1,951.2	1.5	1.2
11/19/2021 11:00	10.1	13.2	7.7	141.8	3,433,615.0	1,980.8	1.4	1.0
11/19/2021 12:00	10.1	13.2	7.7	147.0	3,426,681.2	1,976.8	1.5	1.2
11/19/2021 13:00	10.3	13.1	7.8	163.6	3,415,827.7	2,120.2	1.6	1.3
11/19/2021 14:00	10.0	13.1	7.6	161.6	3,410,027.8	2,116.6	1.6	1.3
11/19/2021 15:00	9.9	13.2	7.6	150.6	3,389,826.4	2,029.8	1.5	1.2
11/19/2021 16:00	9.9	13.2	7.6	152.9	3,394,522.6	2,057.4	1.5	1.2
11/19/2021 17:00	9.9	13.2	7.6	153.4	3,416,631.3	2,070.8	1.5	1.2
11/19/2021 18:00	9.9	13.2	7.6	153.8	3,432,635.5	2,080.5	1.5	1.2
11/19/2021 19:00	9.5	13.3	7.4	137.9	3,417,767.2	1,946.7	1.4	1.0
11/19/2021 20:00	10.0	13.6	8.1	130.7	3,249,200.4	1,684.6	1.4	0.8
11/19/2021 21:00	9.9	13.6	8.0	130.6	3,405,430.6	1,765.6	1.3	0.9
11/19/2021 22:00	10.1	13.2	7.7	142.5	3,464,643.7	1,998.7	1.4	1.0
11/19/2021 23:00	9.9	13.3	7.7	142.5	3,431,014.8	1,979.3	1.4	1.0
Average/Sum#:	10.0	13.3	7.7	146.8	3,402,291.1	1,980.3	1.5	1.1
Minimum:	9.5	13.1	7.4	130.6	3,160,862.9	1,638.8	1.3	0.8
Maximum:	10.7	13.6	8.2	164.6	3,464,643.7	2,141.1	1.7	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/20/2021 00:00	9.6	13.4	7.6	136.1	3,445,791.9	1,937.5	1.3	1.0
11/20/2021 01:00	10.3	13.6	8.3	120.0	3,103,115.7	1,586.2	1.3	0.8
11/20/2021 02:00	10.6	13.6	8.6	118.9	3,034,644.4	1,551.2	1.3	0.8
11/20/2021 03:00	10.5	13.7	8.6	116.1	3,031,905.6	1,549.8	1.3	0.8
11/20/2021 04:00	10.0	13.6	8.1	125.9	3,282,953.9	1,702.1	1.3	0.9
11/20/2021 05:00	9.9	13.3	7.7	146.7	3,387,098.0	2,052.9	1.5	1.2
11/20/2021 06:00	10.2	13.3	7.9	143.5	3,436,570.5	2,007.6	1.4	1.0
11/20/2021 07:00	10.3	13.7	8.4	126.3	3,224,798.8	1,648.4	1.3	0.8
11/20/2021 08:00	10.4	13.7	8.5	130.1	3,248,470.3	1,660.5	1.3	0.8
11/20/2021 09:00	10.8	13.7	8.9	111.6	2,880,095.1	1,472.2	1.3	0.7
11/20/2021 10:00	10.6	13.7	8.7	119.0	2,971,064.0	1,518.7	1.3	0.8
11/20/2021 11:00	10.4	13.7	8.5	121.6	3,113,288.5	1,591.4	1.3	0.8
11/20/2021 12:00	10.6	13.7	8.7	108.6	2,884,523.8	1,453.4	1.2	0.7
11/20/2021 13:00	10.5	13.7	8.6	112.9	2,953,987.3	1,488.4	1.3	0.7
11/20/2021 14:00	10.4	13.7	8.5	113.3	2,946,218.7	1,506.0	1.3	0.8
11/20/2021 15:00	10.2	13.6	8.2	121.7	3,121,323.2	1,618.3	1.3	0.8
11/20/2021 16:00	10.3	13.3	8.0	153.7	3,395,337.5	2,033.1	1.5	1.2
11/20/2021 17:00	10.2	13.3	7.9	166.5	3,421,746.1	2,073.9	1.7	1.5
11/20/2021 18:00	10.0	13.3	7.8	151.9	3,391,492.2	1,956.5	1.5	1.2
11/20/2021 19:00	9.0	13.7	7.4	114.0	3,347,460.1	1,711.1	1.1	0.7
11/20/2021 20:00	9.8	13.5	7.8	137.1	3,422,990.4	1,799.7	1.4	0.9
11/20/2021 21:00	10.3	13.3	8.0	156.4	3,458,895.5	2,045.9	1.5	1.2
11/20/2021 22:00	10.1	13.2	7.7	172.0	3,402,223.4	2,136.6	1.7	1.5
11/20/2021 23:00	9.6	13.4	7.6	137.7	3,341,039.8	1,878.6	1.4	0.9
Average/Sum#:	10.2	13.5	8.2	131.7	3,218,626.4	1,749.2	1.4	0.9
Minimum:	9.0	13.2	7.4	108.6	2,880,095.1	1,453.4	1.1	0.7
Maximum:	10.8	13.7	8.9	172.0	3,458,895.5	2,136.6	1.7	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/21/2021 00:00	9.2	13.7	7.5	123.1	3,371,484.3	1,748.0	1.2	0.9
11/21/2021 01:00	9.7	13.4	7.6	143.6	3,478,160.1	1,955.7	1.4	1.0
11/21/2021 02:00	13.3	14.2	11.7	136.8	2,879,674.6	1,408.9	1.6	0.8
11/21/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/21/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/21/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/21/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/21/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/21/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/21/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/21/2021 10:00	32.0	17.7	59.0	0.0	1,390,787.4	253.9	0.0	0.0
11/21/2021 11:00	41.9	15.9	49.4	223.2	2,092,081.0	733.3	3.4	1.0
11/21/2021 12:00	10.4	13.8	8.6	99.3	2,796,801.2	1,409.2	1.2	0.7
11/21/2021 13:00	10.5	13.8	8.7	90.4	2,725,154.5	1,373.1	1.1	0.5
11/21/2021 14:00	10.3	13.7	8.4	104.5	3,200,540.4	1,636.0	1.1	0.7
11/21/2021 15:00	10.4	13.7	8.5	126.2	3,144,198.4	1,607.2	1.3	0.8
11/21/2021 16:00	10.7	13.8	8.9	100.9	2,643,782.9	1,332.1	1.3	0.7
11/21/2021 17:00	10.4	13.7	8.5	128.0	3,103,702.6	1,586.5	1.4	0.8
11/21/2021 18:00	10.5	13.3	8.2	154.6	3,424,062.0	2,050.3	1.5	1.2
11/21/2021 19:00	10.4	13.3	8.1	172.1	3,362,915.0	2,062.8	1.8	1.4
11/21/2021 20:00	9.3	13.7	7.6	118.0	3,312,050.7	1,693.0	1.2	0.8
11/21/2021 21:00	10.0	13.5	8.0	144.1	3,411,958.9	1,793.9	1.4	0.9
11/21/2021 22:00	9.5	13.3	7.4	136.4	3,509,764.5	1,999.1	1.3	1.0
11/21/2021 23:00	9.8	13.5	7.8	124.5	3,145,789.9	1,699.9	1.3	0.8
Average/Sum#:	13.4	14.0	13.8	125.0	2,999,582.8	1,549.6	1.4	0.8
Minimum:	9.2	13.3	7.4	0.0	1,390,787.4	253.9	0.0	0.0
Maximum:	41.9	17.7	59.0	223.2	3,509,764.5	2,062.8	3.4	1.4
%SI	29.17	29.17	29.17	29.17	29.17	29.17	29.17	29.17

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/22/2021 00:00	10.6	13.8	8.8	105.6	2,715,764.2	1,388.2	1.3	0.7
11/22/2021 01:00	10.5	13.8	8.7	103.1	2,660,204.7	1,359.8	1.3	0.7
11/22/2021 02:00	10.4	13.8	8.6	103.1	2,691,701.4	1,375.9	1.3	0.7
11/22/2021 03:00	10.2	13.7	8.4	109.9	2,930,959.4	1,498.2	1.2	0.7
11/22/2021 04:00	10.4	13.8	8.6	105.8	2,815,927.8	1,439.4	1.2	0.7
11/22/2021 05:00	10.4	13.8	8.6	120.7	2,931,937.6	1,498.7	1.4	0.7
11/22/2021 06:00	9.6	13.4	7.6	139.7	3,529,024.4	1,984.3	1.3	1.0
11/22/2021 07:00	9.7	13.4	7.6	144.9	3,470,884.1	2,002.3	1.4	1.0
11/22/2021 08:00	10.4	13.7	8.5	107.9	2,865,227.1	1,464.6	1.2	0.7
11/22/2021 09:00	10.5	13.8	8.7	103.9	2,730,632.2	1,395.8	1.3	0.7
11/22/2021 10:00	10.4	13.8	8.6	104.4	2,694,440.3	1,377.3	1.3	0.7
11/22/2021 11:00	10.5	13.8	8.7	105.9	2,706,569.5	1,383.5	1.3	0.7
11/22/2021 12:00	9.7	13.6	7.8	127.3	3,349,882.1	1,736.8	1.3	0.9
11/22/2021 13:00	10.4	13.7	8.5	113.7	2,972,824.7	1,519.6	1.3	0.8
11/22/2021 14:00	9.7	13.7	7.9	121.2	3,338,069.8	1,706.3	1.2	0.9
11/22/2021 15:00	9.3	13.7	7.6	118.5	3,417,105.1	1,746.7	1.2	0.9
11/22/2021 16:00	10.1	13.3	7.8	141.4	3,393,572.3	1,957.7	1.4	1.0
11/22/2021 17:00	10.0	13.2	7.7	154.5	3,418,281.3	2,071.8	1.5	1.2
11/22/2021 18:00	10.1	13.1	7.6	174.7	3,361,244.5	2,184.5	1.8	1.5
11/22/2021 19:00	10.0	13.1	7.6	170.9	3,376,253.6	2,169.6	1.8	1.5
11/22/2021 20:00	9.9	13.2	7.6	174.7	3,352,886.1	2,130.1	1.8	1.5
11/22/2021 21:00	9.8	13.7	8.0	123.3	3,175,135.8	1,646.2	1.3	0.8
11/22/2021 22:00	9.0	13.6	7.3	119.3	3,501,483.1	1,815.4	1.1	0.7
11/22/2021 23:00	9.9	13.2	7.6	145.8	3,457,712.0	2,045.2	1.4	1.0
Average/Sum#:	10.1	13.6	8.1	126.7	3,119,071.8	1,704.1	1.4	0.9
Minimum:	9.0	13.1	7.3	103.1	2,660,204.7	1,359.8	1.1	0.7
Maximum:	10.6	13.8	8.8	174.7	3,529,024.4	2,184.5	1.8	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/23/2021 00:00	9.4	13.4	7.4	135.1	3,423,561.0	1,950.0	1.3	1.0
11/23/2021 01:00	10.2	13.7	8.4	110.1	2,945,045.0	1,505.4	1.2	0.8
11/23/2021 02:00	9.8	13.6	7.9	128.5	3,306,484.8	1,714.3	1.3	0.9
11/23/2021 03:00	9.4	13.4	7.4	131.8	3,495,233.4	1,965.3	1.3	1.0
11/23/2021 04:00	9.4	13.4	7.4	132.1	3,446,325.4	1,937.8	1.3	1.0
11/23/2021 05:00	10.3	13.6	8.3	133.5	3,258,072.8	1,689.2	1.4	0.8
11/23/2021 06:00	10.5	13.6	8.5	119.1	3,149,290.3	1,632.8	1.3	0.8
11/23/2021 07:00	10.1	13.3	7.8	145.7	3,473,310.9	2,003.7	1.4	1.0
11/23/2021 08:00	10.1	13.2	7.7	145.9	3,415,515.6	1,995.3	1.5	1.2
11/23/2021 09:00	10.4	13.6	8.4	125.9	3,143,696.9	1,629.9	1.3	0.8
11/23/2021 10:00	10.5	13.6	8.5	122.8	3,034,335.8	1,573.2	1.4	0.8
11/23/2021 11:00	10.6	13.7	8.7	120.4	2,952,870.2	1,509.4	1.4	0.8
11/23/2021 12:00	10.6	13.7	8.7	106.2	2,729,262.8	1,395.1	1.3	0.7
11/23/2021 13:00	10.3	13.7	8.4	120.7	3,063,206.7	1,565.8	1.3	0.8
11/23/2021 14:00	9.9	13.7	8.1	120.3	3,261,382.0	1,667.1	1.2	0.8
11/23/2021 15:00	10.2	13.6	8.2	123.2	3,132,702.9	1,624.2	1.3	0.8
11/23/2021 16:00	10.0	13.2	7.7	149.5	3,434,917.2	2,056.8	1.5	1.2
11/23/2021 17:00	10.0	13.2	7.7	159.3	3,430,820.6	2,079.4	1.6	1.2
11/23/2021 18:00	9.9	13.2	7.6	159.1	3,441,710.0	2,086.0	1.6	1.3
11/23/2021 19:00	9.7	13.3	7.5	143.1	3,422,507.6	1,949.4	1.4	1.0
11/23/2021 20:00	9.3	13.7	7.6	116.4	3,343,547.4	1,709.1	1.2	0.9
11/23/2021 21:00	9.8	13.7	8.0	111.6	3,090,203.9	1,579.6	1.2	0.8
11/23/2021 22:00	10.0	13.2	7.7	152.3	3,476,816.4	2,056.5	1.5	1.2
11/23/2021 23:00	9.4	13.4	7.4	138.6	3,450,949.4	1,965.6	1.4	1.0
Average/Sum#:	10.0	13.5	8.0	131.3	3,263,407.0	1,785.0	1.4	0.9
Minimum:	9.3	13.2	7.4	106.2	2,729,262.8	1,395.1	1.2	0.7
Maximum:	10.6	13.7	8.7	159.3	3,495,233.4	2,086.0	1.6	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/24/2021 00:00	9.2	13.5	7.3	134.4	3,457,885.5	1,944.3	1.3	1.0
11/24/2021 01:00	10.2	13.7	8.4	113.8	2,964,803.8	1,515.5	1.3	0.8
11/24/2021 02:00	10.0	13.7	8.2	121.6	3,104,928.7	1,609.8	1.3	0.8
11/24/2021 03:00	9.5	13.4	7.5	132.0	3,500,746.7	1,968.4	1.3	1.0
11/24/2021 04:00	9.7	13.4	7.6	142.7	3,453,934.1	1,967.3	1.4	1.0
11/24/2021 05:00	10.1	13.7	8.3	134.8	3,288,183.6	1,680.8	1.4	0.8
11/24/2021 06:00	10.3	13.7	8.4	116.8	3,104,350.1	1,609.5	1.2	0.8
11/24/2021 07:00	10.2	13.3	7.9	145.1	3,471,230.8	2,002.5	1.4	1.0
11/24/2021 08:00	9.7	13.4	7.6	140.4	3,432,514.9	1,955.1	1.4	1.0
11/24/2021 09:00	10.1	13.7	8.3	129.9	3,258,056.2	1,665.4	1.3	0.8
11/24/2021 10:00	10.3	13.7	8.4	123.4	3,187,041.8	1,629.1	1.3	0.8
11/24/2021 11:00	10.0	13.7	8.2	125.1	3,317,724.0	1,695.9	1.3	0.8
11/24/2021 12:00	10.2	13.7	8.4	118.8	3,152,806.2	1,611.6	1.2	0.8
11/24/2021 13:00	10.1	13.7	8.3	120.9	3,212,082.7	1,641.9	1.2	0.8
11/24/2021 14:00	10.2	13.7	8.4	122.4	3,173,347.6	1,622.1	1.3	0.8
11/24/2021 15:00	10.2	13.6	8.2	128.2	3,259,615.8	1,690.0	1.3	0.8
11/24/2021 16:00	10.3	13.3	8.0	146.7	3,441,192.3	2,010.3	1.4	1.0
11/24/2021 17:00	10.4	13.3	8.1	164.6	3,429,072.1	2,053.3	1.6	1.2
11/24/2021 18:00	10.5	13.3	8.2	171.1	3,417,456.3	2,071.3	1.7	1.4
11/24/2021 19:00	10.3	13.3	8.0	165.3	3,378,637.2	2,023.1	1.7	1.4
11/24/2021 20:00	9.9	13.7	8.1	118.8	3,145,567.8	1,607.9	1.3	0.8
11/24/2021 21:00	9.5	13.6	7.7	127.3	3,384,214.1	1,754.6	1.3	0.9
11/24/2021 22:00	10.3	13.3	8.0	156.4	3,441,762.2	1,985.5	1.5	1.2
11/24/2021 23:00	9.9	13.4	7.8	145.7	3,414,846.4	1,920.1	1.4	1.0
Average/Sum#:	10.0	13.5	8.1	135.3	3,308,000.0	1,801.5	1.4	0.9
Minimum:	9.2	13.3	7.3	113.8	2,964,803.8	1,515.5	1.2	0.8
Maximum:	10.5	13.7	8.4	171.1	3,500,746.7	2,071.3	1.7	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/25/2021 00:00	25.3	16.1	31.1	174.7	1,549,597.7	577.1	3.7	0.8
11/25/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	25.3	16.1	31.1	174.7	1,549,597.7	577.1	3.7	0.8
Minimum:	25.3	16.1	31.1	174.7	1,549,597.7	577.1	3.7	0.8
Maximum:	25.3	16.1	31.1	174.7	1,549,597.7	577.1	3.7	0.8
%SI	95.83	95.83	95.83	95.83	95.83	95.83	95.83	95.83

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/26/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/27/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/28/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/29/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/29/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/29/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/29/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/29/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/29/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/29/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/29/2021 07:00	17.4	18.2	38.0	0.0	1,007,287.7	132.4	0.0	0.0
11/29/2021 08:00	40.1	17.1	62.3	71.9	1,383,488.7	373.8	0.0	0.0
11/29/2021 09:00	34.6	17.1	53.7	266.2	1,469,848.8	386.4	5.8	0.9
11/29/2021 10:00	39.6	16.5	53.1	264.2	1,862,743.2	571.3	4.4	1.0
11/29/2021 11:00	38.5	15.0	38.5	242.8	2,285,226.9	934.5	3.4	1.2
11/29/2021 12:00	10.7	13.7	8.8	107.3	2,678,594.1	1,369.2	1.3	0.7
11/29/2021 13:00	10.9	13.7	8.9	107.3	2,667,247.4	1,363.4	1.3	0.7
11/29/2021 14:00	10.4	13.6	8.4	128.9	3,130,967.0	1,623.3	1.4	0.8
11/29/2021 15:00	10.7	13.6	8.6	125.9	3,061,724.3	1,587.4	1.4	0.8
11/29/2021 16:00	10.4	13.5	8.3	132.7	3,240,210.3	1,703.6	1.4	0.9
11/29/2021 17:00	10.6	13.2	8.1	149.7	3,267,079.2	1,956.3	1.6	1.2
11/29/2021 18:00	10.6	13.1	8.0	170.0	3,319,358.8	2,108.8	1.8	1.5
11/29/2021 19:00	10.6	13.1	8.0	166.4	3,332,266.0	2,044.0	1.7	1.4
11/29/2021 20:00	10.9	13.6	8.8	144.5	3,208,310.6	1,663.4	1.5	1.0
11/29/2021 21:00	9.8	13.5	7.8	132.3	3,408,915.7	1,792.3	1.3	0.9
11/29/2021 22:00	10.2	13.2	7.8	145.9	3,402,163.7	1,987.5	1.5	1.2
11/29/2021 23:00	16.7	14.6	15.6	152.9	2,524,513.1	1,216.7	2.0	1.0
Average/Sum#:	17.8	14.5	20.7	147.6	2,661,761.5	1,342.0	1.9	0.9
Minimum:	9.8	13.1	7.8	0.0	1,007,287.7	132.4	0.0	0.0
Maximum:	40.1	18.2	62.3	266.2	3,408,915.7	2,108.8	5.8	1.5
%SI	29.17	29.17	29.17	29.17	29.17	29.17	29.17	29.17

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
11/30/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/30/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/30/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/30/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/30/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/30/2021 05:00	0.0	0.0	0.0	100.3	1,366,264.2	259.4	0.0	0.0
11/30/2021 06:00	39.0	15.9	46.0	241.4	2,086,375.1	731.3	3.6	1.0
11/30/2021 07:00	11.2	13.8	9.3	105.1	2,612,079.2	1,335.2	1.3	0.7
11/30/2021 08:00	11.3	13.8	9.4	110.5	2,558,867.3	1,308.0	1.4	0.7
11/30/2021 09:00	11.3	13.8	9.4	108.6	2,557,693.5	1,307.4	1.4	0.7
11/30/2021 10:00	11.3	13.8	9.4	103.2	2,424,076.8	1,239.1	1.4	0.6
11/30/2021 11:00	11.3	13.8	9.4	104.1	2,419,381.6	1,236.7	1.4	0.6
11/30/2021 12:00	11.0	13.7	9.0	115.1	2,744,522.1	1,402.9	1.4	0.7
11/30/2021 13:00	10.8	13.7	8.9	113.8	2,884,985.9	1,474.7	1.3	0.7
11/30/2021 14:00	10.2	13.7	8.4	121.4	3,135,590.6	1,602.8	1.3	0.8
11/30/2021 15:00	9.4	13.7	7.7	121.8	3,414,757.5	1,745.5	1.2	0.9
11/30/2021 16:00	9.3	13.7	7.6	119.7	3,413,975.0	1,745.1	1.2	0.9
11/30/2021 17:00	9.3	13.7	7.6	119.2	3,412,801.2	1,744.5	1.2	0.9
11/30/2021 18:00	9.3	13.7	7.6	117.7	3,411,236.1	1,743.7	1.1	0.7
11/30/2021 19:00	9.3	13.7	7.6	115.7	3,396,172.5	1,736.0	1.1	0.7
11/30/2021 20:00	9.2	13.7	7.5	115.7	3,373,479.2	1,724.4	1.1	0.7
11/30/2021 21:00	9.2	13.7	7.5	114.8	3,379,152.5	1,727.3	1.1	0.7
11/30/2021 22:00	9.2	13.7	7.5	119.4	3,409,084.2	1,742.6	1.2	0.9
11/30/2021 23:00	10.2	13.3	7.9	142.2	3,425,843.3	1,951.3	1.4	1.0
Average/Sum#:	11.8	13.8	10.4	121.6	2,917,175.7	1,460.9	1.4	0.8
Minimum:	9.2	13.3	7.5	100.3	1,366,264.2	259.4	1.1	0.6
Maximum:	39.0	15.9	46.0	241.4	3,425,843.3	1,951.3	3.6	1.0
%SI	25.00	25.00	25.00	20.83	20.83	20.83	25.00	25.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/01/2021 00:00	10.3	13.2	7.9	149.4	3,429,003.5	1,953.1	1.5	1.2
12/01/2021 01:00	10.7	13.7	8.8	120.2	2,916,102.4	1,511.9	1.4	0.8
12/01/2021 02:00	11.0	13.8	9.1	102.9	2,567,866.4	1,312.6	1.3	0.7
12/01/2021 03:00	10.1	13.6	8.2	139.6	3,320,179.1	1,721.4	1.4	0.9
12/01/2021 04:00	9.8	13.4	7.7	131.4	3,416,158.7	1,846.0	1.3	0.9
12/01/2021 05:00	10.4	13.3	8.1	145.1	3,343,557.7	1,855.6	1.5	1.1
12/01/2021 06:00	10.5	13.5	8.4	127.8	3,156,153.1	1,705.5	1.4	0.9
12/01/2021 07:00	10.4	13.1	7.9	182.0	3,428,484.7	2,228.2	1.8	1.6
12/01/2021 08:00	10.4	13.1	7.9	193.2	3,386,240.4	2,250.2	2.0	1.8
12/01/2021 09:00	10.4	13.0	7.8	190.3	3,404,997.7	2,237.8	1.9	1.6
12/01/2021 10:00	10.3	13.0	7.7	190.2	3,346,903.0	2,248.5	2.0	1.8
12/01/2021 11:00	10.4	13.0	7.8	188.3	3,324,020.0	2,257.4	2.0	1.8
12/01/2021 12:00	10.4	13.0	7.8	229.7	3,319,251.6	2,278.4	2.4	2.1
12/01/2021 13:00	10.4	13.0	7.8	211.4	3,312,841.5	2,274.0	2.2	1.8
12/01/2021 14:00	10.4	13.0	7.8	209.4	3,317,503.4	2,277.2	2.2	1.8
12/01/2021 15:00	10.3	13.0	7.7	207.7	3,298,855.9	2,264.4	2.2	1.8
12/01/2021 16:00	10.3	13.0	7.7	208.8	3,301,623.9	2,266.3	2.2	1.8
12/01/2021 17:00	10.3	13.0	7.7	211.5	3,305,848.7	2,269.2	2.3	2.0
12/01/2021 18:00	10.3	13.0	7.7	214.1	3,307,596.9	2,270.4	2.3	2.0
12/01/2021 19:00	10.3	13.0	7.7	205.5	3,324,020.0	2,257.4	2.2	1.8
12/01/2021 20:00	9.9	13.1	7.5	169.4	3,385,783.7	2,151.0	1.7	1.5
12/01/2021 21:00	10.0	13.1	7.6	166.6	3,370,535.6	2,116.7	1.7	1.5
12/01/2021 22:00	10.0	13.2	7.7	160.6	3,405,577.0	2,064.1	1.6	1.2
12/01/2021 23:00	9.5	13.4	7.5	140.5	3,408,637.7	1,941.5	1.4	1.0
Average/Sum#:	10.3	13.2	7.9	174.8	3,295,739.3	2,065.0	1.8	1.5
Minimum:	9.5	13.0	7.5	102.9	2,567,866.4	1,312.6	1.3	0.7
Maximum:	11.0	13.8	9.1	229.7	3,429,003.5	2,278.4	2.4	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/02/2021 00:00	16.0	14.7	15.2	151.0	2,561,893.5	1,197.3	1.9	0.8
12/02/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2021 06:00	40.6	17.1	63.0	194.8	1,664,656.2	413.3	0.0	0.0
12/02/2021 07:00	21.1	14.1	18.3	169.2	2,440,895.2	1,176.4	2.3	1.1
12/02/2021 08:00	11.0	13.7	9.0	92.5	2,647,293.0	1,353.2	1.1	0.5
12/02/2021 09:00	11.1	13.7	9.1	92.3	2,712,242.8	1,386.4	1.1	0.6
12/02/2021 10:00	11.1	13.6	9.0	101.0	2,925,746.3	1,516.9	1.1	0.6
12/02/2021 11:00	11.0	13.6	8.9	105.5	3,091,964.6	1,580.5	1.1	0.6
12/02/2021 12:00	10.7	13.5	8.5	110.6	3,228,798.4	1,697.6	1.1	0.7
12/02/2021 13:00	10.4	13.5	8.3	115.4	3,371,410.3	1,797.2	1.1	0.7
12/02/2021 14:00	10.4	13.5	8.3	114.9	1,174,428.8	1,792.4	3.5	2.3
12/02/2021 15:00	10.4	13.5	8.3	137.8	3,398,835.2	1,787.0	1.4	0.9
12/02/2021 16:00	10.4	13.4	8.2	140.7	3,356,215.3	1,789.1	1.4	0.9
12/02/2021 17:00	10.3	13.5	8.2	137.0	3,354,527.0	1,788.2	1.4	0.9
12/02/2021 18:00	10.2	13.5	8.1	137.0	3,351,150.3	1,786.4	1.4	0.9
12/02/2021 19:00	10.2	13.5	8.1	136.3	3,353,026.2	1,787.4	1.4	0.9
12/02/2021 20:00	9.7	13.5	7.7	126.6	3,378,103.7	1,776.1	1.3	0.9
12/02/2021 21:00	10.1	13.3	7.8	140.0	3,380,547.0	1,925.5	1.4	1.0
12/02/2021 22:00	10.3	13.2	7.9	156.5	3,352,449.9	2,031.9	1.6	1.2
12/02/2021 23:00	9.8	13.3	7.6	143.7	3,362,025.8	1,890.4	1.5	1.1
Average/Sum#:	12.9	13.8	12.1	131.7	3,051,765.6	1,603.9	1.3	0.8
Minimum:	9.7	13.2	7.6	92.3	1,664,656.2	413.3	0.0	0.0
Maximum:	40.6	17.1	63.0	194.8	3,398,835.2	2,031.9	2.3	1.2
%SI	20.83	20.83	20.83	20.83	25.00	20.83	25.00	25.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/03/2021 00:00	10.8	13.8	9.0	109.6	2,645,923.5	1,352.5	1.4	0.7
12/03/2021 01:00	11.0	13.7	9.0	110.3	2,639,272.1	1,349.1	1.4	0.7
12/03/2021 02:00	10.9	13.7	8.9	108.0	2,659,030.9	1,359.2	1.3	0.7
12/03/2021 03:00	10.3	13.6	8.3	133.3	3,158,548.4	1,637.6	1.4	0.8
12/03/2021 04:00	10.3	13.6	8.3	121.7	3,129,231.2	1,622.4	1.3	0.8
12/03/2021 05:00	11.0	13.8	9.1	118.7	2,787,365.5	1,424.8	1.4	0.7
12/03/2021 06:00	10.6	13.6	8.6	125.4	3,151,990.6	1,634.2	1.3	0.8
12/03/2021 07:00	9.5	13.6	7.7	127.7	3,649,612.4	1,892.2	1.2	0.9
12/03/2021 08:00	11.0	13.1	8.3	174.4	3,376,239.7	2,218.9	1.8	1.6
12/03/2021 09:00	10.7	13.1	8.1	203.6	3,402,563.1	2,236.2	2.1	1.8
12/03/2021 10:00	10.5	13.1	7.9	208.9	3,381,424.8	2,247.0	2.2	1.8
12/03/2021 11:00	10.5	13.1	7.9	213.1	3,349,433.4	2,250.2	2.2	1.8
12/03/2021 12:00	10.6	13.1	8.0	214.7	3,350,326.5	2,250.8	2.2	1.8
12/03/2021 13:00	10.6	13.1	8.0	218.8	3,359,853.0	2,257.2	2.3	2.0
12/03/2021 14:00	10.6	13.1	8.0	216.7	3,359,257.6	2,256.8	2.3	2.0
12/03/2021 15:00	10.5	13.1	7.9	213.5	3,315,774.0	2,251.8	2.3	2.0
12/03/2021 16:00	10.0	13.3	7.8	171.1	3,255,679.7	1,925.7	1.8	1.3
12/03/2021 17:00	10.1	13.5	8.1	165.9	3,364,897.8	1,818.3	1.7	1.3
12/03/2021 18:00	10.1	13.5	8.1	152.5	3,409,303.9	1,817.4	1.5	1.1
12/03/2021 19:00	10.1	13.5	8.1	158.4	3,415,306.9	1,820.6	1.6	1.1
12/03/2021 20:00	10.3	13.3	8.0	157.9	3,370,305.6	1,993.5	1.6	1.2
12/03/2021 21:00	10.4	13.2	8.0	174.5	3,372,127.9	2,117.7	1.8	1.5
12/03/2021 22:00	10.3	13.2	7.9	177.2	3,404,711.2	2,113.3	1.8	1.5
12/03/2021 23:00	13.2	13.9	11.1	163.1	3,013,671.6	1,606.5	1.8	1.1
Average/Sum#:	10.6	13.4	8.3	164.1	3,221,743.8	1,893.9	1.7	1.3
Minimum:	9.5	13.1	7.7	108.0	2,639,272.1	1,349.1	1.2	0.7
Maximum:	13.2	13.9	11.1	218.8	3,649,612.4	2,257.2	2.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/04/2021 00:00	3.1	19.3	11.4	133.5	1,825.9	0.2	2,743.7	0.2
12/04/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2021 03:00	22.3	18.0	45.4	203.2	1,233,104.4	198.1	5.2	0.4
12/04/2021 04:00	34.5	15.5	37.7	234.7	2,205,806.8	853.7	3.3	1.1
12/04/2021 05:00	10.5	13.7	8.6	147.7	3,061,804.7	1,609.8	1.6	1.0
12/04/2021 06:00	10.5	13.5	8.4	164.5	3,248,914.9	1,826.8	1.7	1.3
12/04/2021 07:00	10.3	13.4	8.1	178.2	3,256,976.6	1,878.9	1.9	1.3
12/04/2021 08:00	10.4	13.5	8.3	165.7	3,445,212.7	1,861.7	1.6	1.1
12/04/2021 09:00	10.5	13.5	8.4	163.5	3,440,401.2	1,859.1	1.6	1.1
12/04/2021 10:00	10.3	13.7	8.4	162.2	3,472,358.8	1,800.3	1.6	1.1
12/04/2021 11:00	10.1	13.7	8.3	157.6	3,476,794.9	1,802.6	1.5	1.1
12/04/2021 12:00	10.3	13.7	8.4	140.5	3,178,029.0	1,647.7	1.5	1.0
12/04/2021 13:00	11.2	13.7	9.2	134.1	2,849,174.2	1,477.2	1.6	0.9
12/04/2021 14:00	11.2	13.8	9.3	120.9	2,683,876.2	1,371.9	1.5	0.8
12/04/2021 15:00	10.8	13.6	8.7	156.7	3,129,705.3	1,645.5	1.7	1.2
12/04/2021 16:00	10.6	13.8	8.8	133.6	3,042,436.7	1,577.4	1.5	0.9
12/04/2021 17:00	10.1	13.7	8.3	152.9	3,324,229.5	1,723.5	1.6	1.0
12/04/2021 18:00	10.0	13.4	7.9	146.0	3,430,497.0	1,928.9	1.4	1.0
12/04/2021 19:00	10.1	13.5	8.1	150.8	3,337,791.7	1,852.4	1.5	1.1
12/04/2021 20:00	10.9	13.7	8.9	151.7	3,151,797.7	1,634.1	1.6	1.0
12/04/2021 21:00	11.0	13.7	9.0	143.8	3,130,581.3	1,623.1	1.5	1.0
12/04/2021 22:00	11.0	13.7	9.0	146.4	3,092,777.5	1,603.5	1.6	1.0
12/04/2021 23:00	26.8	16.6	36.8	184.4	1,211,084.7	424.5	5.0	0.8
Average/Sum#:	12.6	14.3	13.0	157.8	2,836,599.2	1,463.7	126.6	1.0
Minimum:	3.1	13.4	7.9	120.9	1,825.9	0.2	1.4	0.2
Maximum:	34.5	19.3	45.4	234.7	3,476,794.9	1,928.9	2,743.7	1.3
%SI	8.33	8.33	8.33	8.33	8.33	8.33	8.33	8.33

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/05/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/05/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/05/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/05/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/05/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/05/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/05/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/05/2021 07:00	38.6	17.4	65.1	129.9	1,493,917.5	360.0	0.0	0.0
12/05/2021 08:00	40.9	15.3	43.1	258.9	2,154,478.0	865.3	3.8	1.3
12/05/2021 09:00	10.9	13.7	8.9	140.0	3,017,748.4	1,564.6	1.6	0.9
12/05/2021 10:00	11.1	13.7	9.1	134.2	2,980,909.0	1,545.5	1.5	0.9
12/05/2021 11:00	11.3	13.8	9.4	123.7	2,667,677.3	1,383.1	1.6	0.8
12/05/2021 12:00	11.4	13.8	9.5	120.1	2,647,039.5	1,372.4	1.5	0.8
12/05/2021 13:00	10.4	13.6	8.4	165.1	3,321,044.3	1,746.1	1.7	1.2
12/05/2021 14:00	10.9	13.8	9.1	131.7	2,961,428.4	1,535.4	1.5	0.9
12/05/2021 15:00	10.7	13.7	8.8	152.7	3,244,957.2	1,682.4	1.6	1.0
12/05/2021 16:00	10.6	13.7	8.7	140.0	3,113,993.9	1,614.5	1.5	1.0
12/05/2021 17:00	10.5	13.3	8.2	158.1	3,407,983.8	1,990.9	1.6	1.2
12/05/2021 18:00	10.6	13.2	8.1	180.4	3,424,527.6	2,125.6	1.8	1.5
12/05/2021 19:00	10.6	13.2	8.1	183.7	3,384,524.5	2,150.2	1.9	1.5
12/05/2021 20:00	10.5	13.1	7.9	201.1	3,414,431.5	2,244.0	2.1	1.8
12/05/2021 21:00	10.3	13.2	7.9	190.8	3,405,976.3	2,188.7	1.9	1.5
12/05/2021 22:00	10.3	13.1	7.8	188.5	3,397,261.8	2,183.1	1.9	1.5
12/05/2021 23:00	10.1	13.2	7.7	174.4	3,424,376.1	2,100.5	1.8	1.5
Average/Sum#:	14.1	13.8	13.9	163.1	3,027,192.7	1,685.4	1.7	1.1
Minimum:	10.1	13.1	7.7	120.1	1,493,917.5	360.0	0.0	0.0
Maximum:	40.9	17.4	65.1	258.9	3,424,527.6	2,244.0	3.8	1.8
%SI	29.17	29.17	29.17	29.17	29.17	29.17	29.17	29.17

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/06/2021 00:00	9.9	13.3	7.7	165.8	3,412,434.4	1,993.5	1.7	1.4
12/06/2021 01:00	10.3	13.7	8.4	147.5	3,308,220.7	1,715.2	1.5	1.0
12/06/2021 02:00	10.0	13.7	8.2	152.0	3,359,464.3	1,766.3	1.5	1.1
12/06/2021 03:00	9.9	13.4	7.8	153.8	3,479,742.5	1,982.0	1.5	1.2
12/06/2021 04:00	10.0	13.4	7.9	157.0	3,407,613.2	1,965.8	1.6	1.2
12/06/2021 05:00	10.4	13.7	8.5	137.8	3,184,008.1	1,650.8	1.5	1.0
12/06/2021 06:00	10.1	13.5	8.1	154.2	3,375,542.2	1,898.0	1.6	1.1
12/06/2021 07:00	10.4	13.1	7.9	182.1	3,448,903.2	2,191.1	1.8	1.5
12/06/2021 08:00	10.3	13.1	7.8	188.5	3,412,201.0	2,192.7	1.9	1.5
12/06/2021 09:00	10.2	13.6	8.2	156.3	3,215,741.6	1,737.7	1.7	1.2
12/06/2021 10:00	9.6	13.7	7.9	141.0	3,462,329.2	1,795.1	1.4	0.9
12/06/2021 11:00	10.0	13.3	7.8	160.5	3,455,571.3	2,018.7	1.6	1.2
12/06/2021 12:00	10.3	13.1	7.8	189.4	3,425,584.0	2,201.3	1.9	1.5
12/06/2021 13:00	10.0	13.4	7.9	162.7	3,270,895.5	1,934.7	1.7	1.4
12/06/2021 14:00	10.6	13.7	8.7	145.7	3,185,358.3	1,651.5	1.5	1.0
12/06/2021 15:00	10.0	13.5	8.0	155.3	3,378,461.3	1,850.3	1.6	1.1
12/06/2021 16:00	10.2	13.2	7.8	168.6	3,448,309.6	2,090.0	1.7	1.5
12/06/2021 17:00	10.2	13.2	7.8	177.8	3,432,744.2	2,130.7	1.8	1.5
12/06/2021 18:00	10.3	13.1	7.8	196.5	3,394,194.4	2,230.7	2.0	1.8
12/06/2021 19:00	10.2	13.2	7.8	187.5	3,395,705.6	2,182.1	1.9	1.5
12/06/2021 20:00	10.2	13.1	7.7	194.2	3,402,019.5	2,211.0	2.0	1.8
12/06/2021 21:00	10.1	13.2	7.7	176.8	3,400,631.1	2,135.6	1.8	1.5
12/06/2021 22:00	10.1	13.2	7.7	175.0	3,395,854.0	2,132.6	1.8	1.5
12/06/2021 23:00	10.1	13.2	7.7	177.3	3,403,338.1	2,137.3	1.8	1.5
Average/Sum#:	10.1	13.4	7.9	166.8	3,377,286.1	1,991.4	1.7	1.3
Minimum:	9.6	13.1	7.7	137.8	3,184,008.1	1,650.8	1.4	0.9
Maximum:	10.6	13.7	8.7	196.5	3,479,742.5	2,230.7	2.0	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/07/2021 00:00	10.0	13.2	7.7	173.6	3,408,725.5	2,090.9	1.8	1.5
12/07/2021 01:00	10.5	13.7	8.6	130.3	2,924,101.5	1,537.4	1.5	0.9
12/07/2021 02:00	10.3	13.7	8.4	149.3	3,233,172.9	1,699.9	1.6	1.0
12/07/2021 03:00	9.9	13.4	7.8	150.1	3,445,682.4	1,962.6	1.5	1.2
12/07/2021 04:00	10.4	13.2	8.0	175.7	3,417,116.6	2,121.0	1.8	1.5
12/07/2021 05:00	10.0	13.6	8.1	145.6	3,337,730.8	1,730.5	1.5	1.0
12/07/2021 06:00	10.7	13.7	8.8	140.1	3,188,830.0	1,653.3	1.5	1.0
12/07/2021 07:00	10.2	13.4	8.0	158.8	3,435,521.8	1,981.9	1.6	1.2
12/07/2021 08:00	10.5	13.1	7.9	191.9	3,407,251.0	2,214.4	2.0	1.8
12/07/2021 09:00	10.2	13.2	7.8	182.6	3,358,752.2	2,109.3	1.9	1.5
12/07/2021 10:00	9.7	13.6	7.8	148.2	3,416,620.0	1,821.3	1.5	1.1
12/07/2021 11:00	9.8	13.6	7.9	151.7	3,423,751.2	1,800.1	1.5	1.1
12/07/2021 12:00	12.0	13.5	9.6	187.9	3,399,549.1	1,812.2	1.9	1.3
12/07/2021 13:00	10.2	13.5	8.1	148.1	3,364,844.5	1,793.7	1.5	1.1
12/07/2021 14:00	10.5	13.3	8.2	163.8	3,349,289.8	2,078.9	1.7	1.5
12/07/2021 15:00	10.4	13.1	7.9	203.5	3,295,549.5	2,214.0	2.2	1.8
12/07/2021 16:00	10.3	13.1	7.8	207.7	3,308,558.8	2,246.9	2.2	1.8
12/07/2021 17:00	10.2	13.1	7.7	199.6	3,354,487.8	2,229.1	2.1	1.8
12/07/2021 18:00	10.2	13.1	7.7	201.1	3,371,944.2	2,240.7	2.1	1.8
12/07/2021 19:00	10.2	13.1	7.7	194.3	3,382,326.1	2,222.9	2.0	1.8
12/07/2021 20:00	10.2	13.1	7.7	195.9	3,378,217.8	2,220.2	2.0	1.8
12/07/2021 21:00	10.2	13.1	7.7	194.9	3,362,393.3	2,209.8	2.0	1.8
12/07/2021 22:00	10.1	13.2	7.7	180.4	3,366,580.3	2,138.8	1.9	1.5
12/07/2021 23:00	10.2	13.2	7.8	182.0	3,392,828.5	2,130.7	1.9	1.5
Average/Sum#:	10.3	13.3	8.0	173.2	3,346,826.1	2,010.9	1.8	1.4
Minimum:	9.7	13.1	7.7	130.3	2,924,101.5	1,537.4	1.5	0.9
Maximum:	12.0	13.7	9.6	207.7	3,445,682.4	2,246.9	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/08/2021 00:00	10.0	13.3	7.8	170.7	3,356,067.9	2,058.6	1.8	1.4
12/08/2021 01:00	10.4	13.7	8.5	138.0	3,112,836.6	1,613.9	1.5	1.0
12/08/2021 02:00	10.9	13.8	9.1	111.9	2,554,844.4	1,324.6	1.5	0.8
12/08/2021 03:00	10.2	13.7	8.4	160.8	3,319,712.9	1,745.4	1.7	1.2
12/08/2021 04:00	10.1	13.5	8.1	151.0	3,360,750.0	1,840.6	1.5	1.1
12/08/2021 05:00	10.3	13.3	8.0	159.3	3,403,740.3	1,889.0	1.6	1.1
12/08/2021 06:00	10.1	13.6	8.2	143.0	3,368,974.2	1,771.3	1.4	0.9
12/08/2021 07:00	10.2	13.3	7.9	153.3	3,428,867.5	2,003.1	1.5	1.2
12/08/2021 08:00	10.0	13.4	7.9	160.1	3,289,603.2	1,873.7	1.7	1.3
12/08/2021 09:00	11.0	13.8	9.1	114.1	2,653,597.3	1,375.8	1.4	0.7
12/08/2021 10:00	11.0	13.8	9.1	111.1	2,589,755.1	1,342.7	1.4	0.7
12/08/2021 11:00	10.1	13.7	8.3	154.0	3,292,324.5	1,731.0	1.6	1.0
12/08/2021 12:00	9.5	13.5	7.6	143.2	3,356,891.6	1,863.0	1.5	1.1
12/08/2021 13:00	9.8	13.5	7.8	150.3	3,332,205.9	1,849.3	1.5	1.1
12/08/2021 14:00	11.0	13.8	9.1	109.5	2,562,173.7	1,328.4	1.4	0.7
12/08/2021 15:00	10.9	13.8	9.1	120.8	2,692,751.2	1,396.1	1.5	0.8
12/08/2021 16:00	10.1	13.7	8.3	148.9	3,273,875.3	1,721.3	1.5	1.0
12/08/2021 17:00	10.0	13.3	7.8	157.7	3,433,961.7	1,981.0	1.6	1.2
12/08/2021 18:00	10.5	13.1	7.9	180.7	3,388,459.6	2,152.7	1.8	1.5
12/08/2021 19:00	10.3	13.2	7.9	180.6	3,373,348.7	2,143.1	1.9	1.5
12/08/2021 20:00	10.3	13.2	7.9	178.3	3,354,774.9	2,131.3	1.8	1.5
12/08/2021 21:00	10.2	13.2	7.8	169.9	3,374,979.0	2,070.2	1.7	1.4
12/08/2021 22:00	10.2	13.2	7.8	170.4	3,384,623.1	2,051.4	1.7	1.4
12/08/2021 23:00	10.2	13.2	7.8	172.1	3,385,901.8	2,076.9	1.8	1.5
Average/Sum#:	10.3	13.5	8.2	150.4	3,193,542.5	1,805.6	1.6	1.1
Minimum:	9.5	13.1	7.6	109.5	2,554,844.4	1,324.6	1.4	0.7
Maximum:	11.0	13.8	9.1	180.7	3,433,961.7	2,152.7	1.9	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/09/2021 00:00	9.7	13.4	7.6	153.7	3,371,210.8	1,944.8	1.6	1.2
12/09/2021 01:00	10.7	13.7	8.8	125.1	2,894,500.2	1,500.7	1.4	0.8
12/09/2021 02:00	10.4	13.7	8.5	136.3	3,013,684.6	1,584.5	1.5	1.0
12/09/2021 03:00	10.1	13.4	7.9	152.8	3,411,253.5	1,967.9	1.5	1.2
12/09/2021 04:00	10.3	13.3	8.0	165.4	3,379,604.1	1,999.0	1.7	1.4
12/09/2021 05:00	10.8	13.7	8.9	135.7	2,996,724.9	1,553.7	1.5	0.9
12/09/2021 06:00	10.6	13.7	8.7	136.2	3,118,483.6	1,639.6	1.5	1.0
12/09/2021 07:00	10.6	13.2	8.1	165.2	3,464,297.0	1,998.5	1.6	1.2
12/09/2021 08:00	10.7	13.1	8.1	168.2	3,432,245.1	2,055.2	1.7	1.4
12/09/2021 09:00	10.4	13.2	8.0	167.1	3,407,361.7	2,040.3	1.7	1.4
12/09/2021 10:00	10.6	13.7	8.7	141.0	3,062,375.3	1,610.1	1.6	1.0
12/09/2021 11:00	9.9	13.7	8.1	144.8	3,307,835.0	1,715.0	1.5	1.0
12/09/2021 12:00	10.3	13.3	8.0	164.0	3,425,758.8	2,026.3	1.6	1.2
12/09/2021 13:00	10.1	13.4	7.9	162.5	3,365,740.8	1,990.8	1.7	1.4
12/09/2021 14:00	10.3	13.8	8.6	120.9	2,847,424.6	1,455.5	1.4	0.7
12/09/2021 15:00	10.4	13.8	8.6	130.8	2,919,574.2	1,513.7	1.5	0.9
12/09/2021 16:00	10.1	13.3	7.8	161.7	3,425,957.5	2,001.4	1.6	1.2
12/09/2021 17:00	10.3	13.2	7.9	180.4	3,423,401.7	2,149.9	1.8	1.5
12/09/2021 18:00	10.1	13.2	7.7	177.2	3,422,433.2	2,124.3	1.8	1.5
12/09/2021 19:00	10.2	13.2	7.8	185.4	3,430,089.6	2,154.1	1.9	1.5
12/09/2021 20:00	10.2	13.2	7.8	185.5	3,448,879.4	2,165.9	1.9	1.5
12/09/2021 21:00	10.1	13.2	7.7	186.3	3,454,611.9	2,169.5	1.9	1.5
12/09/2021 22:00	9.6	13.4	7.6	159.7	3,482,788.6	2,034.6	1.6	1.2
12/09/2021 23:00	9.9	13.3	7.7	163.9	3,459,967.6	2,071.8	1.6	1.2
Average/Sum#:	10.3	13.4	8.1	157.1	3,290,258.5	1,894.5	1.6	1.2
Minimum:	9.6	13.1	7.6	120.9	2,847,424.6	1,455.5	1.4	0.7
Maximum:	10.8	13.8	8.9	186.3	3,482,788.6	2,169.5	1.9	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/10/2021 00:00	9.3	13.5	7.4	150.8	3,441,293.2	1,960.1	1.5	1.2
12/10/2021 01:00	10.3	13.8	8.6	128.0	3,021,145.8	1,544.3	1.4	0.8
12/10/2021 02:00	10.1	13.7	8.3	126.9	3,109,364.9	1,612.1	1.4	0.8
12/10/2021 03:00	9.8	13.5	7.8	147.7	3,489,509.6	1,936.6	1.4	1.0
12/10/2021 04:00	9.5	13.5	7.6	147.0	3,529,511.2	1,958.8	1.4	1.0
12/10/2021 05:00	10.3	13.7	8.4	168.1	3,137,717.7	1,626.8	1.8	1.1
12/10/2021 06:00	10.5	13.7	8.6	152.8	3,388,650.3	1,756.9	1.5	1.1
12/10/2021 07:00	10.0	13.4	7.9	154.1	3,497,474.8	1,992.1	1.5	1.2
12/10/2021 08:00	9.4	13.5	7.5	146.7	3,489,008.8	1,961.8	1.4	1.0
12/10/2021 09:00	10.3	13.8	8.6	133.3	3,123,444.9	1,619.4	1.4	0.8
12/10/2021 10:00	10.4	13.7	8.5	152.0	3,287,968.7	1,704.7	1.6	1.0
12/10/2021 11:00	10.2	13.8	8.5	135.8	3,151,026.2	1,633.7	1.5	1.0
12/10/2021 12:00	10.0	13.8	8.3	141.2	3,249,779.1	1,684.9	1.5	1.0
12/10/2021 13:00	10.3	13.8	8.6	137.1	3,143,807.1	1,607.0	1.5	1.0
12/10/2021 14:00	10.8	13.9	9.1	109.1	2,579,017.4	1,318.3	1.4	0.7
12/10/2021 15:00	10.1	13.8	8.4	132.6	3,054,973.6	1,583.9	1.5	1.0
12/10/2021 16:00	10.0	13.4	7.9	154.5	3,463,941.4	1,973.0	1.5	1.2
12/10/2021 17:00	10.2	13.2	7.8	193.6	3,428,023.1	2,227.9	2.0	1.8
12/10/2021 18:00	10.0	13.2	7.7	189.6	3,450,634.6	2,192.2	1.9	1.5
12/10/2021 19:00	9.9	13.2	7.6	189.7	3,447,801.3	2,190.4	1.9	1.5
12/10/2021 20:00	10.0	13.2	7.7	194.7	3,457,952.2	2,222.1	2.0	1.8
12/10/2021 21:00	9.9	13.2	7.6	184.0	3,456,841.2	2,170.9	1.9	1.5
12/10/2021 22:00	9.7	13.3	7.5	172.6	3,506,716.4	2,125.4	1.7	1.5
12/10/2021 23:00	9.9	13.3	7.7	172.2	3,508,036.3	2,126.2	1.7	1.5
Average/Sum#:	10.0	13.5	8.1	154.8	3,308,901.7	1,863.7	1.6	1.2
Minimum:	9.3	13.2	7.4	109.1	2,579,017.4	1,318.3	1.4	0.7
Maximum:	10.8	13.9	9.1	194.7	3,529,511.2	2,227.9	2.0	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/11/2021 00:00	10.0	13.2	7.7	176.0	3,544,304.1	2,122.3	1.7	1.5
12/11/2021 01:00	9.9	13.3	7.7	165.7	3,521,988.3	2,057.5	1.6	1.2
12/11/2021 02:00	9.9	13.5	7.9	164.1	3,469,445.6	1,950.8	1.6	1.2
12/11/2021 03:00	10.6	13.7	8.7	147.5	3,161,634.4	1,639.2	1.6	1.0
12/11/2021 04:00	10.3	13.7	8.4	152.4	3,298,191.1	1,710.0	1.6	1.0
12/11/2021 05:00	10.0	13.4	7.9	159.4	3,469,607.9	2,026.9	1.6	1.2
12/11/2021 06:00	10.5	13.2	8.0	172.2	3,510,736.5	2,102.2	1.7	1.5
12/11/2021 07:00	10.0	13.4	7.9	174.0	3,485,013.9	2,035.9	1.7	1.4
12/11/2021 08:00	10.7	13.7	8.8	140.6	3,113,029.5	1,614.0	1.5	1.0
12/11/2021 09:00	11.0	13.8	9.1	116.2	2,697,573.2	1,398.6	1.4	0.7
12/11/2021 10:00	11.0	13.7	9.0	120.1	2,761,994.0	1,432.0	1.5	0.9
12/11/2021 11:00	11.0	13.8	9.1	113.8	2,604,645.2	1,331.4	1.5	0.8
12/11/2021 12:00	10.9	13.8	9.1	111.6	2,599,558.7	1,328.8	1.4	0.7
12/11/2021 13:00	10.9	13.7	8.9	136.2	2,926,517.8	1,517.3	1.6	0.9
12/11/2021 14:00	10.9	13.7	8.9	135.2	2,999,425.2	1,555.1	1.5	0.9
12/11/2021 15:00	10.3	13.7	8.4	140.1	3,174,171.4	1,645.7	1.5	1.0
12/11/2021 16:00	10.3	13.2	7.9	171.6	3,498,796.8	2,120.6	1.7	1.5
12/11/2021 17:00	10.3	13.1	7.8	193.6	3,439,563.2	2,235.4	2.0	1.8
12/11/2021 18:00	10.2	13.1	7.7	192.6	3,454,217.4	2,219.7	1.9	1.6
12/11/2021 19:00	10.2	13.1	7.7	203.1	3,451,862.4	2,268.6	2.1	1.8
12/11/2021 20:00	10.0	13.2	7.7	192.2	3,455,306.7	2,220.4	1.9	1.6
12/11/2021 21:00	10.2	13.1	7.7	207.2	3,407,458.9	2,264.3	2.1	1.8
12/11/2021 22:00	10.1	13.1	7.6	192.2	3,406,173.9	2,213.7	2.0	1.8
12/11/2021 23:00	10.1	13.2	7.7	175.6	3,441,493.9	2,111.0	1.8	1.5
Average/Sum#:	10.4	13.4	8.2	160.6	3,245,529.6	1,880.1	1.7	1.3
Minimum:	9.9	13.1	7.6	111.6	2,599,558.7	1,328.8	1.4	0.7
Maximum:	11.0	13.8	9.1	207.2	3,544,304.1	2,268.6	2.1	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/12/2021 00:00	10.1	13.2	7.7	170.8	3,422,093.7	2,099.1	1.7	1.5
12/12/2021 01:00	9.9	13.3	7.7	163.6	3,424,897.0	2,050.8	1.6	1.2
12/12/2021 02:00	9.5	13.5	7.6	154.7	3,440,812.2	1,934.7	1.5	1.2
12/12/2021 03:00	10.4	13.7	8.5	141.1	3,106,857.5	1,610.8	1.5	1.0
12/12/2021 04:00	10.1	13.6	8.2	149.9	3,320,283.5	1,745.7	1.5	1.0
12/12/2021 05:00	10.1	13.3	7.8	163.6	3,406,485.4	2,014.9	1.7	1.4
12/12/2021 06:00	10.4	13.3	8.1	162.7	3,416,045.8	2,045.5	1.6	1.2
12/12/2021 07:00	10.7	13.7	8.8	149.3	3,108,213.0	1,634.2	1.6	1.0
12/12/2021 08:00	10.8	13.7	8.9	146.3	3,098,563.8	1,606.5	1.6	1.0
12/12/2021 09:00	11.2	13.7	9.2	115.5	2,714,353.4	1,407.3	1.4	0.7
12/12/2021 10:00	11.0	13.7	9.0	155.9	3,107,050.3	1,610.9	1.7	1.1
12/12/2021 11:00	10.7	13.7	8.8	158.2	3,233,933.7	1,700.3	1.7	1.2
12/12/2021 12:00	10.7	13.7	8.8	146.0	3,129,616.9	1,622.6	1.6	1.0
12/12/2021 13:00	10.7	13.7	8.8	146.5	3,178,029.0	1,647.7	1.6	1.0
12/12/2021 14:00	10.8	13.7	8.9	140.5	3,096,056.4	1,605.2	1.5	1.0
12/12/2021 15:00	10.6	13.6	8.6	133.7	3,039,361.3	1,598.0	1.5	1.0
12/12/2021 16:00	10.3	13.2	7.9	162.3	3,381,989.1	2,074.5	1.6	1.2
12/12/2021 17:00	10.3	13.1	7.8	184.6	3,359,135.8	2,158.6	1.9	1.5
12/12/2021 18:00	10.2	13.1	7.7	180.6	3,352,599.9	2,154.4	1.9	1.5
12/12/2021 19:00	10.3	13.1	7.8	197.5	3,335,526.5	2,216.5	2.1	1.8
12/12/2021 20:00	10.1	13.1	7.6	178.9	3,341,551.1	2,147.3	1.9	1.5
12/12/2021 21:00	10.1	13.1	7.6	178.5	3,351,043.7	2,153.4	1.9	1.5
12/12/2021 22:00	10.0	13.2	7.7	175.8	3,376,586.5	2,120.5	1.8	1.5
12/12/2021 23:00	9.9	13.2	7.6	170.0	3,370,088.2	2,067.2	1.7	1.4
Average/Sum#:	10.4	13.4	8.2	159.4	3,254,632.2	1,876.1	1.7	1.2
Minimum:	9.5	13.1	7.6	115.5	2,714,353.4	1,407.3	1.4	0.7
Maximum:	11.2	13.7	9.2	197.5	3,440,812.2	2,216.5	2.1	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/13/2021 00:00	9.5	13.4	7.5	149.1	3,355,783.1	1,935.9	1.5	1.2
12/13/2021 01:00	10.1	13.7	8.3	150.2	3,243,253.4	1,705.2	1.6	1.0
12/13/2021 02:00	10.2	13.6	8.2	141.4	3,203,311.9	1,684.2	1.5	1.0
12/13/2021 03:00	10.3	13.2	7.9	157.4	3,369,619.0	2,017.7	1.6	1.2
12/13/2021 04:00	9.9	13.4	7.8	156.3	3,336,431.3	1,949.1	1.6	1.2
12/13/2021 05:00	10.7	13.7	8.8	140.2	3,077,926.0	1,595.8	1.5	1.0
12/13/2021 06:00	10.2	13.5	8.1	147.5	3,355,089.7	1,788.5	1.5	1.1
12/13/2021 07:00	10.6	13.2	8.1	165.1	3,372,811.7	2,093.5	1.7	1.5
12/13/2021 08:00	10.5	13.1	7.9	192.1	3,339,265.3	2,194.6	2.0	1.8
12/13/2021 09:00	10.3	13.1	7.8	185.2	3,320,315.6	2,157.9	1.9	1.5
12/13/2021 10:00	10.2	13.1	7.7	182.4	3,345,015.8	2,125.1	1.9	1.5
12/13/2021 11:00	10.0	13.2	7.7	166.5	3,319,781.7	2,012.1	1.7	1.4
12/13/2021 12:00	10.4	13.7	8.5	145.9	3,181,693.6	1,649.6	1.6	1.0
12/13/2021 13:00	9.9	13.5	7.9	150.0	3,374,036.6	1,798.6	1.5	1.1
12/13/2021 14:00	10.5	13.2	8.0	164.7	3,341,721.6	2,049.8	1.7	1.4
12/13/2021 15:00	10.6	13.0	7.9	202.5	3,322,193.8	2,231.9	2.1	1.8
12/13/2021 16:00	10.6	13.0	7.9	218.3	3,331,634.7	2,286.9	2.3	2.1
12/13/2021 17:00	10.5	13.0	7.8	221.8	3,328,854.5	2,309.3	2.3	2.1
12/13/2021 18:00	10.4	13.0	7.8	222.4	3,333,323.1	2,312.4	2.4	2.1
12/13/2021 19:00	10.3	13.0	7.7	219.7	3,357,275.0	2,304.5	2.3	2.1
12/13/2021 20:00	10.0	13.2	7.7	186.4	3,346,319.3	2,174.8	1.9	1.5
12/13/2021 21:00	9.9	13.2	7.6	177.0	3,364,006.9	2,112.6	1.8	1.5
12/13/2021 22:00	9.9	13.2	7.6	166.5	3,380,498.3	2,048.9	1.7	1.4
12/13/2021 23:00	9.9	13.2	7.6	165.9	3,395,347.5	2,057.9	1.7	1.4
Average/Sum#:	10.2	13.3	7.9	173.9	3,320,646.2	2,024.9	1.8	1.5
Minimum:	9.5	13.0	7.5	140.2	3,077,926.0	1,595.8	1.5	1.0
Maximum:	10.7	13.7	8.8	222.4	3,395,347.5	2,312.4	2.4	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/14/2021 00:00	9.6	13.5	7.7	149.0	3,275,236.3	1,841.6	1.6	1.1
12/14/2021 01:00	11.0	13.8	9.1	107.9	2,544,390.5	1,300.6	1.4	0.7
12/14/2021 02:00	11.1	13.8	9.2	115.1	2,547,515.1	1,320.8	1.5	0.8
12/14/2021 03:00	10.2	13.7	8.4	163.7	3,339,493.5	1,755.8	1.7	1.2
12/14/2021 04:00	9.7	13.5	7.7	145.9	3,419,544.0	1,872.8	1.5	1.1
12/14/2021 05:00	10.3	13.3	8.0	154.5	3,417,535.5	1,871.7	1.5	1.1
12/14/2021 06:00	10.6	13.7	8.7	150.2	3,281,673.4	1,725.4	1.5	1.0
12/14/2021 07:00	10.4	13.2	8.0	165.9	3,440,885.0	2,085.5	1.7	1.5
12/14/2021 08:00	10.4	13.2	8.0	177.8	3,402,777.9	2,112.1	1.8	1.5
12/14/2021 09:00	10.1	13.3	7.8	172.3	3,382,820.6	1,976.2	1.8	1.4
12/14/2021 10:00	10.6	13.7	8.7	145.6	3,129,809.8	1,622.7	1.6	1.0
12/14/2021 11:00	10.5	13.7	8.6	143.8	3,164,720.5	1,640.8	1.5	1.0
12/14/2021 12:00	10.2	13.3	7.9	158.8	3,450,104.1	2,040.7	1.6	1.2
12/14/2021 13:00	9.6	13.5	7.7	151.5	3,396,348.0	1,934.5	1.5	1.2
12/14/2021 14:00	10.5	13.7	8.6	153.3	3,181,693.6	1,649.6	1.6	1.0
12/14/2021 15:00	10.6	13.8	8.8	138.8	2,968,757.8	1,539.2	1.6	0.9
12/14/2021 16:00	9.8	13.4	7.7	154.3	3,427,669.2	2,002.4	1.5	1.2
12/14/2021 17:00	10.3	13.1	7.8	211.6	3,425,198.3	2,301.1	2.2	1.8
12/14/2021 18:00	10.0	13.1	7.6	199.8	3,413,518.5	2,243.4	2.0	1.8
12/14/2021 19:00	9.9	13.1	7.5	215.4	3,422,816.7	2,299.5	2.2	1.8
12/14/2021 20:00	10.0	13.1	7.6	213.8	3,428,919.6	2,303.6	2.2	1.8
12/14/2021 21:00	9.8	13.2	7.5	194.5	3,443,563.8	2,238.0	2.0	1.8
12/14/2021 22:00	9.7	13.2	7.4	175.7	3,452,721.6	2,143.1	1.8	1.5
12/14/2021 23:00	9.6	13.3	7.5	164.0	3,465,489.0	2,049.8	1.6	1.2
Average/Sum#:	10.2	13.4	8.1	163.5	3,284,300.1	1,911.3	1.7	1.3
Minimum:	9.6	13.1	7.4	107.9	2,544,390.5	1,300.6	1.4	0.7
Maximum:	11.1	13.8	9.2	215.4	3,465,489.0	2,303.6	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/15/2021 00:00	9.5	13.4	7.5	153.3	3,463,941.4	1,973.0	1.5	1.2
12/15/2021 01:00	10.6	13.7	8.7	138.2	3,023,920.5	1,567.8	1.5	0.9
12/15/2021 02:00	10.2	13.7	8.4	147.7	3,232,420.2	1,675.9	1.5	1.0
12/15/2021 03:00	9.7	13.5	7.7	155.6	3,498,612.5	1,967.2	1.5	1.2
12/15/2021 04:00	9.7	13.5	7.7	158.3	3,465,532.9	1,948.6	1.6	1.2
12/15/2021 05:00	10.6	13.7	8.7	146.1	3,065,774.7	1,589.5	1.6	1.0
12/15/2021 06:00	10.1	13.5	8.1	157.6	3,422,479.8	1,899.4	1.6	1.1
12/15/2021 07:00	10.3	13.2	7.9	183.7	3,450,477.2	2,192.1	1.8	1.5
12/15/2021 08:00	9.8	13.4	7.7	168.2	3,419,452.7	1,997.6	1.7	1.4
12/15/2021 09:00	10.4	13.7	8.5	138.7	3,085,062.4	1,599.5	1.5	1.0
12/15/2021 10:00	10.6	13.7	8.7	148.9	3,133,281.6	1,624.5	1.6	1.0
12/15/2021 11:00	10.4	13.7	8.5	138.4	3,075,498.9	1,617.0	1.5	1.0
12/15/2021 12:00	10.3	13.3	8.0	161.2	3,415,107.7	2,020.0	1.6	1.2
12/15/2021 13:00	10.1	13.3	7.8	169.3	3,362,270.9	2,013.3	1.7	1.4
12/15/2021 14:00	10.6	13.7	8.7	144.0	3,017,941.3	1,564.7	1.6	0.9
12/15/2021 15:00	10.2	13.6	8.2	150.4	3,278,820.4	1,723.9	1.6	1.0
12/15/2021 16:00	10.5	13.2	8.0	178.5	3,420,854.0	2,148.3	1.8	1.5
12/15/2021 17:00	10.5	13.0	7.8	213.1	3,348,679.7	2,298.6	2.2	1.8
12/15/2021 18:00	10.4	13.0	7.8	290.6	3,375,704.7	2,292.5	3.1	2.8
12/15/2021 19:00	10.4	13.0	7.8	201.0	3,369,078.5	2,288.0	2.1	1.8
12/15/2021 20:00	10.3	13.0	7.7	214.4	3,373,054.2	2,290.7	2.2	1.8
12/15/2021 21:00	10.2	13.1	7.7	202.4	3,371,793.7	2,240.6	2.1	1.8
12/15/2021 22:00	10.1	13.2	7.7	181.4	3,409,229.8	2,141.0	1.8	1.5
12/15/2021 23:00	10.1	13.2	7.7	172.7	3,403,261.3	2,112.4	1.8	1.5
Average/Sum#:	10.2	13.4	8.0	171.4	3,311,760.5	1,949.4	1.8	1.4
Minimum:	9.5	13.0	7.5	138.2	3,017,941.3	1,564.7	1.5	0.9
Maximum:	10.6	13.7	8.7	290.6	3,498,612.5	2,298.6	3.1	2.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/16/2021 00:00	10.1	13.2	7.7	166.1	3,410,691.7	2,067.2	1.7	1.4
12/16/2021 01:00	10.1	13.4	7.9	164.4	3,422,000.9	1,974.1	1.7	1.4
12/16/2021 02:00	10.7	13.7	8.8	142.2	3,054,780.8	1,583.8	1.6	1.0
12/16/2021 03:00	11.0	13.7	9.0	148.4	3,064,424.6	1,588.8	1.6	1.0
12/16/2021 04:00	10.8	13.7	8.9	145.3	3,139,260.7	1,627.6	1.6	1.0
12/16/2021 05:00	10.3	13.3	8.0	164.0	3,386,603.0	2,052.6	1.7	1.4
12/16/2021 06:00	10.9	13.1	8.2	201.4	3,424,764.8	2,275.8	2.0	1.8
12/16/2021 07:00	10.5	13.1	7.9	208.7	3,433,907.7	2,256.8	2.1	1.8
12/16/2021 08:00	10.1	13.2	7.7	170.9	3,417,291.3	2,071.2	1.7	1.4
12/16/2021 09:00	9.9	13.4	7.8	163.8	3,433,615.0	1,980.8	1.6	1.2
12/16/2021 10:00	10.8	13.7	8.9	127.8	2,887,942.4	1,497.3	1.5	0.9
12/16/2021 11:00	10.3	13.7	8.4	152.9	3,134,631.7	1,625.2	1.7	1.1
12/16/2021 12:00	10.2	13.3	7.9	185.5	3,453,992.6	2,043.0	1.9	1.4
12/16/2021 13:00	9.9	13.5	7.9	176.5	3,461,264.6	1,946.2	1.8	1.4
12/16/2021 14:00	10.8	13.7	8.9	157.3	3,014,469.5	1,562.9	1.8	1.1
12/16/2021 15:00	10.5	13.7	8.6	157.4	3,089,112.8	1,601.6	1.7	1.1
12/16/2021 16:00	10.4	13.2	8.0	172.9	3,443,216.2	2,137.2	1.7	1.5
12/16/2021 17:00	10.4	13.1	7.9	210.3	3,423,410.5	2,274.9	2.2	1.8
12/16/2021 18:00	10.2	13.1	7.7	209.3	3,425,667.8	2,276.4	2.1	1.8
12/16/2021 19:00	10.1	13.1	7.6	208.0	3,428,376.5	2,278.2	2.1	1.8
12/16/2021 20:00	10.1	13.1	7.6	212.0	3,440,264.9	2,286.1	2.2	1.8
12/16/2021 21:00	10.0	13.1	7.6	201.2	3,455,970.7	2,271.3	2.0	1.8
12/16/2021 22:00	9.8	13.2	7.5	177.5	3,446,116.2	2,139.0	1.8	1.5
12/16/2021 23:00	9.9	13.3	7.7	170.6	3,445,834.7	2,088.5	1.7	1.5
Average/Sum#:	10.3	13.4	8.1	174.8	3,322,400.5	1,979.4	1.8	1.4
Minimum:	9.8	13.1	7.5	127.8	2,887,942.4	1,497.3	1.5	0.9
Maximum:	11.0	13.7	9.0	212.0	3,461,264.6	2,286.1	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/17/2021 00:00	9.4	13.5	7.5	150.9	3,455,395.6	1,942.9	1.5	1.2
12/17/2021 01:00	10.4	13.7	8.5	135.0	3,020,063.0	1,565.8	1.5	0.9
12/17/2021 02:00	10.6	13.7	8.7	132.6	3,009,069.0	1,560.1	1.5	0.9
12/17/2021 03:00	10.0	13.7	8.2	141.1	3,314,007.0	1,718.2	1.4	0.9
12/17/2021 04:00	9.9	13.3	7.7	162.6	3,467,896.1	2,025.9	1.6	1.2
12/17/2021 05:00	10.1	13.3	7.8	160.9	3,481,761.5	2,034.0	1.6	1.2
12/17/2021 06:00	10.6	13.1	8.0	197.2	3,459,873.8	2,248.6	2.0	1.8
12/17/2021 07:00	10.1	13.2	7.7	198.5	3,479,894.1	2,236.2	2.0	1.8
12/17/2021 08:00	9.6	13.3	7.5	160.1	3,532,594.9	2,037.9	1.6	1.2
12/17/2021 09:00	9.3	13.6	7.5	150.7	3,460,908.9	1,946.0	1.5	1.2
12/17/2021 10:00	10.4	13.7	8.5	135.2	3,055,552.3	1,584.2	1.5	1.0
12/17/2021 11:00	10.6	13.7	8.7	140.4	2,992,867.3	1,551.7	1.6	0.9
12/17/2021 12:00	10.9	13.8	9.1	119.4	2,725,741.4	1,393.3	1.5	0.8
12/17/2021 13:00	10.4	13.7	8.5	148.7	3,199,824.0	1,659.0	1.6	1.0
12/17/2021 14:00	10.7	13.8	8.9	133.2	2,936,437.1	1,501.0	1.5	0.9
12/17/2021 15:00	10.2	13.7	8.4	134.6	3,097,213.6	1,605.8	1.5	1.0
12/17/2021 16:00	10.0	13.3	7.8	164.5	3,455,959.5	2,069.4	1.6	1.2
12/17/2021 17:00	10.3	13.1	7.8	212.4	3,417,309.2	2,295.8	2.2	1.8
12/17/2021 18:00	10.1	13.1	7.6	214.5	3,423,114.4	2,299.7	2.2	1.8
12/17/2021 19:00	9.9	13.1	7.5	212.0	3,457,721.3	2,297.7	2.2	1.8
12/17/2021 20:00	10.0	13.1	7.6	214.6	3,428,175.3	2,303.1	2.2	1.8
12/17/2021 21:00	9.9	13.1	7.5	214.2	3,444,930.0	2,289.2	2.2	1.8
12/17/2021 22:00	9.7	13.2	7.4	176.5	3,484,696.0	2,137.5	1.8	1.5
12/17/2021 23:00	9.7	13.3	7.5	163.7	3,499,564.0	2,044.4	1.6	1.2
Average/Sum#:	10.1	13.4	8.0	165.6	3,304,190.4	1,931.1	1.7	1.3
Minimum:	9.3	13.1	7.4	119.4	2,725,741.4	1,393.3	1.4	0.8
Maximum:	10.9	13.8	9.1	214.6	3,532,594.9	2,303.1	2.2	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/18/2021 00:00	9.8	13.5	7.8	161.5	3,475,848.1	1,954.4	1.6	1.2
12/18/2021 01:00	10.5	13.7	8.6	147.4	3,130,388.4	1,623.0	1.6	1.0
12/18/2021 02:00	10.0	13.7	8.2	152.2	3,363,962.1	1,744.1	1.5	1.0
12/18/2021 03:00	9.8	13.3	7.6	163.0	3,545,610.9	2,071.3	1.6	1.2
12/18/2021 04:00	9.7	13.4	7.6	159.3	3,510,926.8	2,025.4	1.6	1.2
12/18/2021 05:00	10.3	13.7	8.4	150.2	3,268,873.9	1,694.8	1.6	1.0
12/18/2021 06:00	10.3	13.7	8.4	154.7	3,451,335.2	1,789.4	1.5	1.1
12/18/2021 07:00	9.8	13.3	7.6	156.8	3,550,276.1	2,048.1	1.5	1.2
12/18/2021 08:00	9.8	13.3	7.6	155.5	3,533,288.3	2,038.3	1.5	1.2
12/18/2021 09:00	9.8	13.4	7.7	164.7	3,487,525.2	2,011.9	1.6	1.2
12/18/2021 10:00	10.6	13.7	8.7	131.3	3,018,134.2	1,564.8	1.5	0.9
12/18/2021 11:00	10.6	13.7	8.7	143.3	3,093,741.8	1,604.0	1.6	1.0
12/18/2021 12:00	10.8	13.7	8.9	139.8	3,018,327.1	1,564.9	1.6	0.9
12/18/2021 13:00	10.8	13.7	8.9	136.6	2,989,202.7	1,549.8	1.5	0.9
12/18/2021 14:00	10.8	13.7	8.9	136.4	2,999,232.3	1,555.0	1.5	0.9
12/18/2021 15:00	10.6	13.8	8.8	134.4	2,915,330.9	1,511.5	1.6	0.9
12/18/2021 16:00	10.0	13.5	8.0	149.5	3,394,911.2	1,884.1	1.5	1.1
12/18/2021 17:00	10.2	13.1	7.7	189.2	3,453,128.1	2,219.0	1.9	1.6
12/18/2021 18:00	9.9	13.2	7.6	176.2	3,468,349.2	2,152.8	1.8	1.5
12/18/2021 19:00	10.1	13.1	7.6	194.4	3,457,565.8	2,247.1	2.0	1.8
12/18/2021 20:00	9.9	13.1	7.5	201.3	3,464,948.0	2,277.2	2.0	1.8
12/18/2021 21:00	9.8	13.2	7.5	185.6	3,467,828.4	2,177.8	1.9	1.5
12/18/2021 22:00	9.8	13.2	7.5	169.6	3,497,311.9	2,119.7	1.7	1.5
12/18/2021 23:00	9.7	13.3	7.5	159.1	3,489,635.7	2,038.6	1.6	1.2
Average/Sum#:	10.1	13.5	8.1	158.8	3,335,236.8	1,894.5	1.6	1.2
Minimum:	9.7	13.1	7.5	131.3	2,915,330.9	1,511.5	1.5	0.9
Maximum:	10.8	13.8	8.9	201.3	3,550,276.1	2,277.2	2.0	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/19/2021 00:00	9.8	13.2	7.5	166.6	3,481,344.0	2,084.6	1.7	1.5
12/19/2021 01:00	9.7	13.3	7.5	161.2	3,451,120.6	2,016.1	1.6	1.2
12/19/2021 02:00	10.4	13.7	8.5	143.1	3,152,955.0	1,634.7	1.5	1.0
12/19/2021 03:00	10.1	13.7	8.3	151.5	3,243,063.2	1,705.1	1.6	1.0
12/19/2021 04:00	9.8	13.4	7.7	155.3	3,484,925.0	2,010.4	1.5	1.2
12/19/2021 05:00	9.9	13.3	7.7	159.1	3,523,060.9	2,032.4	1.5	1.2
12/19/2021 06:00	10.2	13.4	8.0	159.1	3,498,528.2	1,992.7	1.6	1.2
12/19/2021 07:00	9.8	13.3	7.6	157.2	3,516,473.8	2,028.6	1.5	1.2
12/19/2021 08:00	9.7	13.3	7.5	156.7	3,510,580.1	2,025.2	1.5	1.2
12/19/2021 09:00	9.8	13.5	7.8	163.9	3,487,230.3	1,960.8	1.6	1.2
12/19/2021 10:00	10.7	13.7	8.8	129.3	2,911,666.3	1,509.6	1.5	0.9
12/19/2021 11:00	10.9	13.7	8.9	129.0	2,906,265.7	1,506.8	1.5	0.9
12/19/2021 12:00	11.0	13.7	9.0	125.1	2,830,465.2	1,467.5	1.5	0.9
12/19/2021 13:00	10.9	13.7	8.9	150.6	3,113,608.1	1,614.3	1.6	1.0
12/19/2021 14:00	10.9	13.7	8.9	146.1	3,114,958.3	1,615.0	1.6	1.0
12/19/2021 15:00	10.7	13.7	8.8	144.6	3,086,991.2	1,600.5	1.6	1.0
12/19/2021 16:00	10.2	13.3	7.9	163.3	3,444,615.9	2,012.3	1.6	1.2
12/19/2021 17:00	10.3	13.1	7.8	190.9	3,459,041.5	2,222.8	1.9	1.6
12/19/2021 18:00	10.0	13.2	7.7	178.0	3,488,934.7	2,140.1	1.8	1.5
12/19/2021 19:00	10.0	13.2	7.7	184.2	3,460,185.1	2,173.0	1.8	1.5
12/19/2021 20:00	10.0	13.2	7.7	181.2	3,468,832.5	2,153.1	1.8	1.5
12/19/2021 21:00	9.9	13.2	7.6	176.4	3,490,401.9	2,141.0	1.7	1.5
12/19/2021 22:00	9.8	13.2	7.5	173.0	3,482,250.6	2,136.0	1.7	1.5
12/19/2021 23:00	9.8	13.2	7.5	166.4	3,455,899.2	2,094.6	1.7	1.5
Average/Sum#:	10.2	13.4	8.0	158.8	3,335,974.9	1,911.6	1.6	1.2
Minimum:	9.7	13.1	7.5	125.1	2,830,465.2	1,467.5	1.5	0.9
Maximum:	11.0	13.7	9.0	190.9	3,523,060.9	2,222.8	1.9	1.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/20/2021 00:00	9.8	13.2	7.5	165.7	3,497,376.3	2,094.2	1.6	1.3
12/20/2021 01:00	9.8	13.4	7.7	165.0	3,457,189.9	1,994.4	1.6	1.2
12/20/2021 02:00	10.2	13.7	8.4	153.4	3,267,788.9	1,718.1	1.6	1.0
12/20/2021 03:00	10.0	13.7	8.2	155.0	3,343,677.9	1,758.0	1.6	1.1
12/20/2021 04:00	9.8	13.3	7.6	154.2	3,489,293.3	2,038.4	1.5	1.2
12/20/2021 05:00	10.0	13.2	7.7	170.0	3,455,621.6	2,144.9	1.7	1.5
12/20/2021 06:00	10.4	13.1	7.9	187.7	3,490,476.0	2,243.0	1.9	1.6
12/20/2021 07:00	9.9	13.2	7.6	177.8	3,453,366.1	2,143.5	1.8	1.5
12/20/2021 08:00	9.7	13.4	7.6	163.5	3,451,634.2	2,016.4	1.6	1.2
12/20/2021 09:00	10.2	13.7	8.4	146.8	3,209,275.0	1,663.9	1.6	1.0
12/20/2021 10:00	10.9	13.8	9.1	111.8	2,612,128.8	1,354.3	1.4	0.7
12/20/2021 11:00	10.5	13.7	8.6	156.1	3,206,381.8	1,662.4	1.7	1.2
12/20/2021 12:00	9.7	13.5	7.7	149.5	3,450,584.3	1,889.8	1.5	1.1
12/20/2021 13:00	10.1	13.2	7.7	177.7	3,469,154.7	2,153.3	1.8	1.5
12/20/2021 14:00	10.1	13.1	7.6	196.5	3,441,255.8	2,236.5	2.0	1.8
12/20/2021 15:00	9.9	13.1	7.5	190.6	3,430,792.8	2,229.7	1.9	1.6
12/20/2021 16:00	10.0	13.1	7.6	207.9	3,437,857.1	2,284.5	2.1	1.8
12/20/2021 17:00	9.9	13.1	7.5	206.5	3,422,965.6	2,299.6	2.1	1.8
12/20/2021 18:00	10.0	13.1	7.6	207.4	3,424,751.8	2,300.8	2.1	1.8
12/20/2021 19:00	10.0	13.1	7.6	210.9	3,443,506.9	2,313.4	2.2	1.9
12/20/2021 20:00	9.9	13.1	7.5	211.6	3,448,270.1	2,316.6	2.2	1.9
12/20/2021 21:00	9.8	13.1	7.4	213.3	3,455,266.1	2,321.3	2.2	1.9
12/20/2021 22:00	9.9	13.1	7.5	210.1	3,428,770.7	2,303.5	2.2	1.8
12/20/2021 23:00	9.8	13.2	7.5	177.8	3,451,432.8	2,142.3	1.8	1.5
Average/Sum#:	10.0	13.3	7.8	177.8	3,384,950.8	2,067.6	1.8	1.5
Minimum:	9.7	13.1	7.4	111.8	2,612,128.8	1,354.3	1.4	0.7
Maximum:	10.9	13.8	9.1	213.3	3,497,376.3	2,321.3	2.2	1.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/21/2021 00:00	9.8	13.3	7.6	173.6	3,420,952.5	2,098.4	1.8	1.5
12/21/2021 01:00	10.1	13.7	8.3	154.9	3,281,025.1	1,701.1	1.6	1.0
12/21/2021 02:00	9.7	13.7	7.9	155.3	3,455,894.6	1,817.0	1.5	1.1
12/21/2021 03:00	9.8	13.4	7.7	156.0	3,530,861.4	2,036.9	1.5	1.2
12/21/2021 04:00	9.6	13.4	7.6	157.4	3,460,483.4	1,996.3	1.6	1.2
12/21/2021 05:00	10.3	13.7	8.4	147.2	3,252,865.1	1,686.5	1.5	1.0
12/21/2021 06:00	10.2	13.7	8.4	151.4	3,418,739.0	1,772.5	1.5	1.1
12/21/2021 07:00	10.0	13.3	7.8	160.5	3,535,650.9	2,091.3	1.6	1.3
12/21/2021 08:00	10.2	13.1	7.7	199.7	3,472,251.6	2,282.0	2.0	1.8
12/21/2021 09:00	9.9	13.2	7.6	179.7	3,452,090.6	2,117.5	1.8	1.5
12/21/2021 10:00	10.2	13.7	8.4	142.4	3,155,269.5	1,635.9	1.5	1.0
12/21/2021 11:00	9.7	13.7	7.9	155.2	3,464,643.7	1,821.6	1.5	1.1
12/21/2021 12:00	9.9	13.3	7.7	159.5	3,504,712.0	2,073.0	1.6	1.2
12/21/2021 13:00	9.7	13.3	7.5	164.7	3,445,642.9	2,012.9	1.7	1.4
12/21/2021 14:00	10.3	13.7	8.4	146.1	3,211,782.4	1,665.2	1.5	1.0
12/21/2021 15:00	9.7	13.7	7.9	157.5	3,462,361.3	1,820.4	1.6	1.1
12/21/2021 16:00	10.0	13.3	7.8	158.4	3,501,499.8	2,071.1	1.5	1.2
12/21/2021 17:00	10.3	13.1	7.8	197.1	3,505,572.6	2,278.3	2.0	1.8
12/21/2021 18:00	10.1	13.1	7.6	203.4	3,487,771.7	2,292.2	2.0	1.8
12/21/2021 19:00	10.1	13.1	7.6	206.0	3,454,561.1	2,295.6	2.1	1.8
12/21/2021 20:00	10.1	13.1	7.6	206.4	3,451,099.9	2,293.3	2.1	1.8
12/21/2021 21:00	9.9	13.1	7.5	193.0	3,439,255.5	2,235.2	2.0	1.8
12/21/2021 22:00	9.9	13.2	7.6	174.3	3,488,445.6	2,139.8	1.7	1.5
12/21/2021 23:00	9.8	13.2	7.5	168.9	3,489,193.1	2,089.3	1.7	1.5
Average/Sum#:	10.0	13.4	7.8	169.5	3,430,942.7	2,013.5	1.7	1.4
Minimum:	9.6	13.1	7.5	142.4	3,155,269.5	1,635.9	1.5	1.0
Maximum:	10.3	13.7	8.4	206.4	3,535,650.9	2,295.6	2.1	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/22/2021 00:00	9.6	13.5	7.7	156.8	3,477,982.2	1,955.6	1.5	1.2
12/22/2021 01:00	10.3	13.7	8.4	141.7	3,150,640.5	1,633.5	1.5	1.0
12/22/2021 02:00	10.1	13.7	8.3	143.4	3,231,461.2	1,699.0	1.5	1.0
12/22/2021 03:00	9.7	13.5	7.7	154.5	3,511,417.5	1,974.4	1.5	1.2
12/22/2021 04:00	9.7	13.5	7.7	163.1	3,475,670.2	1,954.3	1.6	1.2
12/22/2021 05:00	10.6	13.7	8.7	127.9	2,841,844.9	1,473.4	1.5	0.9
12/22/2021 06:00	10.7	13.7	8.8	156.7	3,250,671.1	1,709.1	1.6	1.0
12/22/2021 07:00	10.1	13.4	7.9	153.8	3,464,123.7	1,998.4	1.5	1.2
12/22/2021 08:00	10.0	13.4	7.9	161.6	3,448,175.9	1,989.2	1.6	1.2
12/22/2021 09:00	10.7	13.8	8.9	123.0	2,802,690.9	1,453.1	1.5	0.9
12/22/2021 10:00	10.5	13.7	8.6	136.5	2,914,591.6	1,532.4	1.6	0.9
12/22/2021 11:00	10.1	13.3	7.8	155.2	3,483,018.2	2,009.3	1.5	1.2
12/22/2021 12:00	10.1	13.5	8.1	168.0	3,478,337.9	1,955.8	1.7	1.4
12/22/2021 13:00	10.6	13.7	8.7	146.0	3,102,697.2	1,631.3	1.6	1.0
12/22/2021 14:00	9.8	13.6	7.9	151.2	3,427,935.5	1,802.3	1.5	1.1
12/22/2021 15:00	10.1	13.3	7.8	158.2	3,447,868.2	2,014.2	1.6	1.2
12/22/2021 16:00	10.2	13.2	7.8	165.9	3,421,746.1	2,073.9	1.7	1.5
12/22/2021 17:00	10.2	13.2	7.8	181.1	3,452,541.8	2,168.2	1.8	1.5
12/22/2021 18:00	9.9	13.3	7.7	167.1	3,433,704.8	2,031.0	1.7	1.4
12/22/2021 19:00	9.9	13.4	7.8	160.7	3,446,962.5	1,988.5	1.6	1.2
12/22/2021 20:00	10.1	13.3	7.8	163.3	3,398,032.2	2,009.9	1.7	1.4
12/22/2021 21:00	10.6	13.7	8.7	144.8	3,011,190.6	1,561.2	1.6	0.9
12/22/2021 22:00	10.1	13.6	8.2	148.9	3,361,176.1	1,767.2	1.5	1.1
12/22/2021 23:00	10.3	13.2	7.9	161.6	3,426,066.0	2,051.5	1.6	1.2
Average/Sum#:	10.2	13.5	8.1	153.8	3,310,856.1	1,851.5	1.6	1.2
Minimum:	9.6	13.2	7.7	123.0	2,802,690.9	1,453.1	1.5	0.9
Maximum:	10.7	13.8	8.9	181.1	3,511,417.5	2,168.2	1.8	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/23/2021 00:00	9.7	13.4	7.6	150.4	3,410,744.6	1,942.7	1.5	1.2
12/23/2021 01:00	10.5	13.7	8.6	138.2	3,059,988.4	1,586.5	1.5	1.0
12/23/2021 02:00	10.3	13.6	8.3	139.5	3,106,691.4	1,633.4	1.5	1.0
12/23/2021 03:00	9.8	13.4	7.7	146.3	3,445,331.3	1,962.4	1.4	1.0
12/23/2021 04:00	9.7	13.4	7.6	150.7	3,400,210.5	1,936.7	1.5	1.2
12/23/2021 05:00	10.6	13.7	8.7	151.2	3,158,044.8	1,660.4	1.6	1.0
12/23/2021 06:00	10.7	13.6	8.6	147.3	3,104,278.7	1,654.8	1.6	1.0
12/23/2021 07:00	10.4	13.2	8.0	159.4	3,378,891.6	2,072.6	1.6	1.2
12/23/2021 08:00	9.6	13.4	7.6	150.2	3,381,611.5	1,950.8	1.5	1.2
12/23/2021 09:00	10.6	13.7	8.7	136.8	3,006,561.6	1,558.8	1.5	0.9
12/23/2021 10:00	10.3	13.6	8.3	144.2	3,143,399.6	1,652.7	1.6	1.0
12/23/2021 11:00	9.9	13.4	7.8	150.0	3,393,225.6	1,957.5	1.5	1.2
12/23/2021 12:00	9.9	13.3	7.7	158.0	3,352,836.3	1,934.2	1.6	1.2
12/23/2021 13:00	10.3	13.7	8.4	137.5	3,144,082.7	1,630.1	1.5	1.0
12/23/2021 14:00	11.1	13.8	9.2	114.0	2,558,702.0	1,326.6	1.5	0.8
12/23/2021 15:00	10.7	13.7	8.8	153.0	3,105,740.4	1,632.9	1.7	1.1
12/23/2021 16:00	10.1	13.4	7.9	147.4	3,296,578.0	1,853.6	1.5	1.1
12/23/2021 17:00	10.1	13.3	7.8	154.6	3,309,214.0	1,933.2	1.6	1.2
12/23/2021 18:00	10.1	13.6	8.2	139.8	3,191,329.4	1,677.9	1.5	1.0
12/23/2021 19:00	10.2	13.3	7.9	156.1	3,356,949.5	1,985.6	1.6	1.2
12/23/2021 20:00	10.0	13.3	7.8	157.7	3,329,070.7	1,944.8	1.6	1.2
12/23/2021 21:00	10.6	13.7	8.7	122.6	2,846,088.2	1,475.6	1.4	0.7
12/23/2021 22:00	10.4	13.6	8.4	138.9	3,038,790.7	1,597.7	1.6	1.0
12/23/2021 23:00	10.2	13.3	7.9	154.0	3,386,704.8	2,003.2	1.6	1.2
Average/Sum#:	10.2	13.5	8.2	145.7	3,204,377.8	1,773.5	1.5	1.1
Minimum:	9.6	13.2	7.6	114.0	2,558,702.0	1,326.6	1.4	0.7
Maximum:	11.1	13.8	9.2	159.4	3,445,331.3	2,072.6	1.7	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/24/2021 00:00	9.9	13.3	7.7	157.4	3,342,080.2	1,952.4	1.6	1.2
12/24/2021 01:00	10.5	13.7	8.6	127.4	2,957,956.7	1,533.6	1.4	0.8
12/24/2021 02:00	10.7	13.7	8.8	124.4	2,861,711.2	1,483.7	1.5	0.9
12/24/2021 03:00	10.9	13.8	9.1	113.8	2,631,995.1	1,364.6	1.4	0.7
12/24/2021 04:00	11.0	13.8	9.1	117.7	2,641,446.0	1,369.5	1.5	0.8
12/24/2021 05:00	9.6	13.7	7.9	175.9	3,396,751.1	1,761.1	1.8	1.2
12/24/2021 06:00	10.3	13.4	8.1	150.1	3,357,252.0	1,863.2	1.5	1.1
12/24/2021 07:00	9.9	13.4	7.8	151.0	3,367,894.7	1,893.7	1.5	1.1
12/24/2021 08:00	10.2	13.7	8.4	138.3	3,173,450.8	1,668.5	1.5	1.0
12/24/2021 09:00	10.0	13.4	7.9	155.5	3,423,387.6	1,974.9	1.6	1.2
12/24/2021 10:00	9.8	13.4	7.7	152.0	3,399,639.4	1,961.2	1.5	1.2
12/24/2021 11:00	10.6	13.8	8.8	121.1	2,751,173.6	1,406.3	1.5	0.8
12/24/2021 12:00	10.5	13.7	8.6	149.5	3,142,346.8	1,629.2	1.6	1.0
12/24/2021 13:00	10.8	13.8	9.0	123.1	2,795,190.8	1,428.8	1.5	0.9
12/24/2021 14:00	10.9	13.8	9.1	121.2	2,772,693.1	1,417.3	1.5	0.9
12/24/2021 15:00	10.8	13.7	8.9	133.8	2,889,871.2	1,498.3	1.6	0.9
12/24/2021 16:00	10.8	13.7	8.9	137.0	2,930,182.4	1,519.2	1.6	0.9
12/24/2021 17:00	10.3	13.3	8.0	153.3	3,421,164.5	1,998.6	1.5	1.2
12/24/2021 18:00	10.1	13.3	7.8	165.9	3,418,658.1	2,022.1	1.7	1.4
12/24/2021 19:00	10.1	13.3	7.8	164.0	3,427,111.3	2,027.1	1.6	1.2
12/24/2021 20:00	9.6	13.4	7.6	149.3	3,395,996.9	1,934.3	1.5	1.2
12/24/2021 21:00	10.6	13.8	8.8	116.6	2,762,715.9	1,412.2	1.4	0.7
12/24/2021 22:00	10.4	13.7	8.5	134.8	3,059,141.9	1,608.4	1.5	1.0
12/24/2021 23:00	10.3	13.2	7.9	162.9	3,411,369.7	2,042.7	1.6	1.2
Average/Sum#:	10.4	13.6	8.4	141.5	3,113,799.2	1,698.8	1.5	1.0
Minimum:	9.6	13.2	7.6	113.8	2,631,995.1	1,364.6	1.4	0.7
Maximum:	11.0	13.8	9.1	175.9	3,427,111.3	2,042.7	1.8	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/25/2021 00:00	9.6	13.4	7.6	151.2	3,426,721.2	1,951.8	1.5	1.2
12/25/2021 01:00	10.3	13.7	8.4	128.9	3,009,647.6	1,560.4	1.4	0.8
12/25/2021 02:00	10.9	13.7	8.9	126.0	2,794,590.1	1,448.9	1.5	0.9
12/25/2021 03:00	11.0	13.8	9.1	111.0	2,619,265.2	1,358.0	1.4	0.7
12/25/2021 04:00	10.4	13.7	8.5	136.8	3,019,961.2	1,587.8	1.5	1.0
12/25/2021 05:00	10.4	13.2	8.0	162.8	3,412,064.6	2,018.2	1.6	1.2
12/25/2021 06:00	10.0	13.4	7.9	147.0	3,424,789.9	1,950.7	1.5	1.2
12/25/2021 07:00	10.9	13.7	8.9	144.8	3,019,390.6	1,587.5	1.6	1.0
12/25/2021 08:00	10.9	13.7	8.9	151.2	3,118,430.1	1,616.8	1.6	1.0
12/25/2021 09:00	11.2	13.7	9.2	121.9	2,734,412.6	1,417.7	1.5	0.9
12/25/2021 10:00	10.7	13.7	8.8	156.3	3,158,934.2	1,637.8	1.7	1.1
12/25/2021 11:00	10.9	13.7	8.9	140.8	3,084,098.0	1,599.0	1.5	1.0
12/25/2021 12:00	10.9	13.7	8.9	138.6	3,018,134.2	1,564.8	1.5	0.9
12/25/2021 13:00	10.9	13.7	8.9	129.0	2,903,372.6	1,505.3	1.5	0.9
12/25/2021 14:00	10.8	13.7	8.9	147.3	3,108,786.2	1,611.8	1.6	1.0
12/25/2021 15:00	10.6	13.7	8.7	143.2	3,139,453.6	1,627.7	1.5	1.0
12/25/2021 16:00	10.3	13.3	8.0	155.2	3,397,050.3	1,934.9	1.6	1.2
12/25/2021 17:00	10.3	13.2	7.9	169.9	3,392,585.9	2,081.0	1.7	1.5
12/25/2021 18:00	10.1	13.2	7.7	169.7	3,398,943.9	2,084.9	1.7	1.5
12/25/2021 19:00	10.1	13.2	7.7	167.1	3,425,210.9	2,076.0	1.7	1.5
12/25/2021 20:00	9.5	13.4	7.5	151.5	3,417,240.5	1,946.4	1.5	1.2
12/25/2021 21:00	10.4	13.7	8.5	149.7	3,200,016.9	1,659.1	1.6	1.0
12/25/2021 22:00	10.2	13.7	8.4	132.6	3,094,320.5	1,604.3	1.4	0.8
12/25/2021 23:00	10.0	13.3	7.8	153.0	3,456,084.8	2,019.0	1.5	1.2
Average/Sum#:	10.5	13.6	8.4	145.2	3,157,229.4	1,727.1	1.5	1.1
Minimum:	9.5	13.2	7.5	111.0	2,619,265.2	1,358.0	1.4	0.7
Maximum:	11.2	13.8	9.2	169.9	3,456,084.8	2,084.9	1.7	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/26/2021 00:00	16.0	14.7	15.2	165.8	2,562,691.0	1,235.1	2.1	1.0
12/26/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/26/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/26/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/26/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/26/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/26/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/26/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/26/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/26/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/26/2021 10:00	18.5	18.3	42.0	0.0	1,035,437.0	136.1	0.0	0.0
12/26/2021 11:00	43.6	17.2	69.5	162.4	1,470,095.6	397.2	0.0	0.0
12/26/2021 12:00	43.5	15.6	48.4	261.5	2,029,644.9	770.7	4.1	1.2
12/26/2021 13:00	10.9	13.8	9.1	121.4	2,707,024.1	1,403.5	1.5	0.8
12/26/2021 14:00	11.0	13.8	9.1	118.5	2,646,653.7	1,372.2	1.5	0.8
12/26/2021 15:00	10.4	13.7	8.5	145.1	3,181,693.6	1,649.6	1.5	1.0
12/26/2021 16:00	10.6	13.7	8.7	142.7	3,179,186.2	1,648.3	1.5	1.0
12/26/2021 17:00	10.3	13.6	8.3	157.3	3,345,960.2	1,759.2	1.6	1.1
12/26/2021 18:00	10.0	13.6	8.1	142.9	3,352,236.8	1,762.5	1.4	0.9
12/26/2021 19:00	10.4	13.3	8.1	153.8	3,455,456.4	1,993.4	1.5	1.2
12/26/2021 20:00	10.3	13.3	8.0	167.5	3,394,650.9	2,007.9	1.7	1.4
12/26/2021 21:00	10.7	13.7	8.8	141.4	3,154,498.0	1,635.5	1.5	1.0
12/26/2021 22:00	10.4	13.7	8.5	154.8	3,269,690.9	1,719.1	1.6	1.0
12/26/2021 23:00	10.4	13.3	8.1	162.5	3,430,661.7	2,029.2	1.6	1.2
Average/Sum#:	15.8	14.4	17.9	146.5	2,814,372.1	1,434.6	1.5	0.9
Minimum:	10.0	13.3	8.0	0.0	1,035,437.0	136.1	0.0	0.0
Maximum:	43.6	18.3	69.5	261.5	3,455,456.4	2,029.2	4.1	1.4
%SI	37.50	37.50	37.50	37.50	37.50	37.50	37.50	37.50

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/27/2021 00:00	10.3	13.2	7.9	166.2	3,442,432.3	2,061.3	1.7	1.4
12/27/2021 01:00	10.0	13.4	7.9	157.6	3,411,920.9	1,993.2	1.6	1.2
12/27/2021 02:00	10.6	13.7	8.7	156.3	3,216,025.7	1,667.4	1.7	1.2
12/27/2021 03:00	11.0	13.7	9.0	124.9	2,927,289.3	1,517.7	1.4	0.8
12/27/2021 04:00	11.0	13.7	9.0	134.7	2,944,262.4	1,526.5	1.5	0.9
12/27/2021 05:00	10.7	13.7	8.8	151.7	3,205,784.4	1,685.5	1.6	1.0
12/27/2021 06:00	10.4	13.3	8.1	157.2	3,483,748.0	2,060.6	1.5	1.2
12/27/2021 07:00	10.4	13.2	8.0	186.6	3,418,736.9	2,196.9	1.9	1.5
12/27/2021 08:00	10.2	13.2	7.8	181.6	3,436,459.0	2,158.1	1.8	1.5
12/27/2021 09:00	10.2	13.1	7.7	190.0	3,408,621.8	2,190.4	1.9	1.5
12/27/2021 10:00	10.2	13.2	7.8	178.5	3,394,102.4	2,131.5	1.8	1.5
12/27/2021 11:00	10.0	13.3	7.8	175.6	3,342,201.0	2,074.5	1.8	1.5
12/27/2021 12:00	9.8	13.7	8.0	148.7	3,298,384.0	1,710.1	1.5	1.0
12/27/2021 13:00	10.2	13.7	8.4	139.7	3,176,485.9	1,646.9	1.5	1.0
12/27/2021 14:00	10.1	13.4	7.9	159.9	3,464,297.0	1,998.5	1.6	1.2
12/27/2021 15:00	10.3	13.2	7.9	178.0	3,460,293.8	2,147.8	1.8	1.5
12/27/2021 16:00	10.5	13.1	7.9	217.6	3,453,628.8	2,320.2	2.2	1.9
12/27/2021 17:00	10.4	13.1	7.9	223.2	3,437,549.7	2,334.5	2.3	2.1
12/27/2021 18:00	10.3	13.1	7.8	223.9	3,415,904.0	2,319.8	2.3	2.1
12/27/2021 19:00	10.2	13.1	7.7	218.0	3,452,438.0	2,319.4	2.2	1.9
12/27/2021 20:00	10.2	13.1	7.7	220.3	3,461,220.1	2,325.3	2.2	1.9
12/27/2021 21:00	10.2	13.1	7.7	210.7	3,407,336.3	2,289.1	2.2	1.8
12/27/2021 22:00	9.8	13.3	7.6	171.6	3,469,098.4	2,102.6	1.7	1.5
12/27/2021 23:00	9.9	13.3	7.7	171.4	3,478,337.9	2,082.8	1.7	1.5
Average/Sum#:	10.3	13.3	8.0	176.8	3,358,606.6	2,035.9	1.8	1.4
Minimum:	9.8	13.1	7.6	124.9	2,927,289.3	1,517.7	1.4	0.8
Maximum:	11.0	13.7	9.0	223.9	3,483,748.0	2,334.5	2.3	2.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/28/2021 00:00	9.6	13.5	7.7	159.1	3,482,250.6	1,958.0	1.6	1.2
12/28/2021 01:00	10.6	13.7	8.7	130.8	2,963,357.2	1,536.4	1.5	0.9
12/28/2021 02:00	10.1	13.7	8.3	140.6	3,161,634.4	1,639.2	1.5	1.0
12/28/2021 03:00	9.6	13.5	7.7	150.9	3,532,047.8	1,986.0	1.5	1.2
12/28/2021 04:00	9.4	13.5	7.5	150.6	3,479,405.0	1,956.4	1.5	1.2
12/28/2021 05:00	10.5	13.7	8.6	144.7	3,051,116.1	1,581.9	1.6	0.9
12/28/2021 06:00	10.3	13.7	8.4	148.5	3,318,762.0	1,744.9	1.5	1.0
12/28/2021 07:00	9.8	13.4	7.7	152.8	3,511,520.1	2,000.1	1.5	1.2
12/28/2021 08:00	9.8	13.3	7.6	161.3	3,489,806.9	2,038.7	1.6	1.2
12/28/2021 09:00	9.8	13.3	7.6	166.8	3,444,273.5	2,012.1	1.7	1.4
12/28/2021 10:00	10.6	13.7	8.7	130.0	3,007,140.2	1,559.1	1.5	0.9
12/28/2021 11:00	10.9	13.8	9.1	132.1	2,789,768.2	1,446.4	1.6	0.9
12/28/2021 12:00	10.9	13.7	8.9	136.3	2,978,787.4	1,544.4	1.5	0.9
12/28/2021 13:00	9.6	13.5	7.7	146.8	3,434,881.5	1,881.2	1.5	1.1
12/28/2021 14:00	10.0	13.4	7.9	164.2	3,405,477.5	1,939.7	1.7	1.4
12/28/2021 15:00	10.1	13.7	8.3	144.7	3,222,712.1	1,694.4	1.5	1.0
12/28/2021 16:00	10.1	13.2	7.7	174.2	3,465,610.3	2,151.1	1.7	1.5
12/28/2021 17:00	10.2	13.1	7.7	212.9	3,430,776.2	2,329.9	2.2	1.9
12/28/2021 18:00	10.0	13.1	7.6	209.1	3,416,416.1	2,295.2	2.1	1.8
12/28/2021 19:00	9.9	13.2	7.6	187.0	3,478,337.9	2,209.8	1.9	1.5
12/28/2021 20:00	9.8	13.2	7.5	177.6	3,457,318.9	2,171.2	1.8	1.5
12/28/2021 21:00	9.8	13.2	7.5	172.1	3,465,295.8	2,125.6	1.7	1.5
12/28/2021 22:00	9.9	13.2	7.6	172.4	3,482,132.7	2,110.5	1.7	1.5
12/28/2021 23:00	9.8	13.3	7.6	162.1	3,471,744.4	2,053.5	1.6	1.2
Average/Sum#:	10.0	13.4	8.0	159.5	3,330,857.2	1,915.2	1.6	1.2
Minimum:	9.4	13.1	7.5	130.0	2,789,768.2	1,446.4	1.5	0.9
Maximum:	10.9	13.8	9.1	212.9	3,532,047.8	2,329.9	2.2	1.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/29/2021 00:00	9.9	13.5	7.9	163.4	3,442,697.8	1,960.9	1.6	1.2
12/29/2021 01:00	10.6	13.7	8.7	131.1	2,963,550.1	1,536.5	1.5	0.9
12/29/2021 02:00	10.4	13.7	8.5	144.4	3,054,767.4	1,606.1	1.6	1.0
12/29/2021 03:00	9.8	13.5	7.8	156.3	3,490,978.8	1,988.4	1.5	1.2
12/29/2021 04:00	10.1	13.5	8.1	172.1	3,466,399.4	1,974.4	1.7	1.4
12/29/2021 05:00	10.8	13.7	8.9	121.8	2,852,646.0	1,479.0	1.4	0.7
12/29/2021 06:00	10.6	13.6	8.6	168.2	3,387,423.4	1,781.0	1.7	1.2
12/29/2021 07:00	10.3	13.2	7.9	159.2	3,494,086.3	2,041.2	1.6	1.2
12/29/2021 08:00	10.2	13.3	7.9	168.8	3,482,844.9	2,009.2	1.7	1.4
12/29/2021 09:00	10.8	13.8	9.0	122.1	2,778,388.5	1,440.5	1.5	0.9
12/29/2021 10:00	10.3	13.7	8.4	147.5	3,140,166.2	1,651.0	1.6	1.0
12/29/2021 11:00	9.9	13.3	7.7	155.1	3,474,618.5	2,055.2	1.5	1.2
12/29/2021 12:00	9.7	13.5	7.7	157.4	3,487,230.3	1,960.8	1.5	1.2
12/29/2021 13:00	10.3	13.7	8.4	151.5	3,260,387.3	1,690.4	1.6	1.0
12/29/2021 14:00	10.1	13.7	8.3	141.1	3,278,131.9	1,699.6	1.5	1.0
12/29/2021 15:00	10.0	13.3	7.8	159.5	3,460,248.0	2,046.7	1.6	1.2
12/29/2021 16:00	10.0	13.2	7.7	172.9	3,465,947.9	2,126.0	1.7	1.5
12/29/2021 17:00	10.1	13.1	7.6	205.4	3,466,299.0	2,303.4	2.1	1.8
12/29/2021 18:00	10.0	13.1	7.6	202.9	3,458,323.3	2,298.1	2.1	1.8
12/29/2021 19:00	9.9	13.1	7.5	210.6	3,446,037.4	2,315.1	2.1	1.9
12/29/2021 20:00	9.9	13.1	7.5	213.8	3,446,781.6	2,315.6	2.2	1.9
12/29/2021 21:00	9.7	13.2	7.4	179.8	3,468,188.1	2,152.7	1.8	1.5
12/29/2021 22:00	9.4	13.4	7.4	151.5	3,494,285.7	2,015.8	1.5	1.2
12/29/2021 23:00	9.7	13.3	7.5	159.2	3,498,365.8	2,043.7	1.6	1.2
Average/Sum#:	10.1	13.4	8.0	163.2	3,344,116.4	1,937.1	1.7	1.3
Minimum:	9.4	13.1	7.4	121.8	2,778,388.5	1,440.5	1.4	0.7
Maximum:	10.8	13.8	9.0	213.8	3,498,365.8	2,315.6	2.2	1.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/30/2021 00:00	9.5	13.5	7.6	156.4	3,485,096.1	1,959.6	1.5	1.2
12/30/2021 01:00	10.5	13.7	8.6	151.4	3,212,746.8	1,665.7	1.6	1.0
12/30/2021 02:00	11.0	13.7	9.0	116.9	2,669,220.3	1,383.9	1.5	0.8
12/30/2021 03:00	10.3	13.7	8.4	164.3	3,420,089.2	1,773.2	1.6	1.1
12/30/2021 04:00	9.9	13.6	8.0	154.0	3,497,583.9	1,890.0	1.5	1.1
12/30/2021 05:00	10.2	13.5	8.1	151.6	3,398,546.1	1,861.3	1.5	1.1
12/30/2021 06:00	10.6	13.7	8.7	154.8	3,328,665.6	1,725.8	1.6	1.0
12/30/2021 07:00	10.1	13.3	7.8	157.8	3,539,448.5	2,067.7	1.5	1.2
12/30/2021 08:00	10.1	13.2	7.7	179.4	3,508,143.1	2,177.5	1.8	1.5
12/30/2021 09:00	9.8	13.3	7.6	171.7	3,446,273.4	2,063.6	1.7	1.4
12/30/2021 10:00	10.4	13.7	8.5	145.2	3,195,773.6	1,656.9	1.5	1.0
12/30/2021 11:00	10.2	13.7	8.4	148.4	3,265,209.2	1,692.9	1.5	1.0
12/30/2021 12:00	10.1	13.3	7.8	158.1	3,450,442.3	2,040.9	1.6	1.2
12/30/2021 13:00	9.6	13.5	7.7	160.4	3,442,234.9	1,935.5	1.6	1.2
12/30/2021 14:00	10.5	13.7	8.6	155.6	3,236,470.6	1,678.0	1.6	1.0
12/30/2021 15:00	10.1	13.7	8.3	136.7	3,153,726.5	1,635.1	1.5	1.0
12/30/2021 16:00	9.9	13.4	7.8	155.4	3,468,067.3	2,026.0	1.5	1.2
12/30/2021 17:00	10.3	13.2	7.9	180.6	3,436,299.8	2,158.0	1.8	1.5
12/30/2021 18:00	10.1	13.2	7.7	177.2	3,430,005.3	2,129.0	1.8	1.5
12/30/2021 19:00	9.9	13.3	7.7	166.8	3,475,085.6	2,030.1	1.7	1.4
12/30/2021 20:00	10.1	13.2	7.7	180.7	3,461,099.3	2,148.3	1.8	1.5
12/30/2021 21:00	10.0	13.2	7.7	176.6	3,432,421.9	2,130.5	1.8	1.5
12/30/2021 22:00	9.8	13.2	7.5	172.6	3,461,508.9	2,098.0	1.7	1.5
12/30/2021 23:00	9.8	13.3	7.6	163.2	3,479,183.3	2,057.9	1.6	1.2
Average/Sum#:	10.1	13.5	8.0	159.8	3,370,555.9	1,916.1	1.6	1.2
Minimum:	9.5	13.2	7.5	116.9	2,669,220.3	1,383.9	1.5	0.8
Maximum:	11.0	13.7	9.0	180.7	3,539,448.5	2,177.5	1.8	1.5
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:34 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx, Inlet, Ppm 1 Hour(s)	Unit CT1 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT1 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT1 NH3slip, LbPerHr 1 Hour(s)
12/31/2021 00:00	9.8	13.5	7.8	160.6	3,427,423.4	1,952.2	1.6	1.2
12/31/2021 01:00	10.7	13.7	8.8	135.8	2,979,558.9	1,544.8	1.5	0.9
12/31/2021 02:00	10.9	13.8	9.1	116.2	2,644,358.5	1,351.7	1.5	0.8
12/31/2021 03:00	10.2	13.7	8.4	168.6	3,401,573.0	1,763.6	1.7	1.2
12/31/2021 04:00	9.7	13.6	7.8	147.6	3,471,860.9	1,876.1	1.4	0.9
12/31/2021 05:00	10.0	13.5	8.0	151.3	3,393,068.4	1,858.3	1.5	1.1
12/31/2021 06:00	11.2	13.8	9.3	131.2	2,791,889.9	1,447.5	1.6	0.9
12/31/2021 07:00	10.3	13.3	8.0	162.2	3,460,078.9	2,046.6	1.6	1.2
12/31/2021 08:00	10.1	13.3	7.8	165.3	3,475,125.7	2,055.5	1.6	1.2
12/31/2021 09:00	10.1	13.5	8.1	166.5	3,486,696.8	1,960.5	1.6	1.2
12/31/2021 10:00	10.6	13.7	8.7	134.0	2,923,046.0	1,515.5	1.5	0.9
12/31/2021 11:00	10.8	13.7	8.9	135.4	2,859,203.8	1,482.4	1.6	0.9
12/31/2021 12:00	10.7	13.7	8.8	149.9	3,106,857.5	1,610.8	1.6	1.0
12/31/2021 13:00	10.9	13.9	9.2	111.9	2,592,320.4	1,325.1	1.4	0.7
12/31/2021 14:00	10.8	13.8	9.0	136.3	2,869,531.0	1,466.8	1.6	0.9
12/31/2021 15:00	10.3	13.7	8.4	144.9	3,187,865.7	1,652.8	1.5	1.0
12/31/2021 16:00	10.3	13.3	8.0	164.8	3,434,945.3	2,081.9	1.6	1.2
12/31/2021 17:00	10.2	13.2	7.8	185.9	3,429,070.1	2,178.5	1.9	1.5
12/31/2021 18:00	10.1	13.2	7.7	186.2	3,422,459.1	2,174.3	1.9	1.5
12/31/2021 19:00	10.1	13.2	7.7	194.0	3,442,857.4	2,212.4	2.0	1.8
12/31/2021 20:00	9.8	13.3	7.6	176.2	3,437,092.2	2,108.3	1.8	1.5
12/31/2021 21:00	10.3	13.7	8.4	136.9	3,085,255.3	1,599.6	1.5	1.0
12/31/2021 22:00	9.7	13.7	7.9	151.0	3,467,729.7	1,797.9	1.5	1.1
12/31/2021 23:00	9.9	13.4	7.8	159.7	3,530,657.0	2,011.0	1.5	1.2
Average/Sum#:	10.3	13.6	8.3	153.0	3,221,688.5	1,794.8	1.6	1.1
Minimum:	9.7	13.2	7.6	111.9	2,592,320.4	1,325.1	1.4	0.7
Maximum:	11.2	13.9	9.3	194.0	3,530,657.0	2,212.4	2.0	1.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/01/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/01/2021 13:00	37.5	17.5	65.1	0.0	1,339,827.1	303.3	-0.1	0.0
10/01/2021 14:00	31.9	15.1	32.5	190.1	2,306,399.0	960.0	2.6	1.0
10/01/2021 15:00	9.7	13.7	7.9	113.3	3,291,705.0	1,682.6	1.1	0.7
10/01/2021 16:00	10.0	13.7	8.2	123.1	3,208,117.7	1,663.3	1.2	0.8
10/01/2021 17:00	10.6	13.5	8.5	127.3	3,287,759.7	1,728.6	1.2	0.9
10/01/2021 18:00	10.5	13.5	8.4	131.4	3,276,157.6	1,722.5	1.3	0.9
10/01/2021 19:00	9.6	13.7	7.9	110.0	3,243,188.2	1,657.8	1.0	0.7
10/01/2021 20:00	9.9	13.7	8.1	120.4	3,211,104.5	1,641.4	1.2	0.8
10/01/2021 21:00	9.7	13.7	7.9	107.7	3,173,347.6	1,622.1	1.1	0.6
10/01/2021 22:00	9.7	13.8	8.1	113.6	3,251,291.3	1,638.2	1.1	0.7
10/01/2021 23:00	9.0	13.8	7.5	107.6	3,263,000.9	1,644.1	1.0	0.7
Average/Sum#:	14.4	14.2	15.5	113.1	2,986,536.2	1,478.5	1.2	0.7
Minimum:	9.0	13.5	7.5	0.0	1,339,827.1	303.3	-0.1	0.0
Maximum:	37.5	17.5	65.1	190.1	3,291,705.0	1,728.6	2.6	1.0
%SI	54.17	54.17	54.17	54.17	54.17	54.17	54.17	54.17

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/02/2021 00:00	8.9	13.9	7.5	106.8	3,277,092.1	1,651.2	1.0	0.7
10/02/2021 01:00	8.9	13.9	7.5	106.3	3,253,871.4	1,639.5	1.0	0.7
10/02/2021 02:00	8.7	13.9	7.3	98.2	2,981,971.2	1,502.5	1.0	0.6
10/02/2021 03:00	8.9	13.8	7.4	105.4	3,221,918.2	1,623.4	1.0	0.6
10/02/2021 04:00	8.9	13.8	7.4	106.4	3,255,856.1	1,640.5	1.0	0.7
10/02/2021 05:00	8.8	13.8	7.3	105.6	3,243,551.1	1,634.3	1.0	0.7
10/02/2021 06:00	9.0	13.8	7.5	104.5	3,174,087.6	1,599.3	1.0	0.6
10/02/2021 07:00	9.0	13.9	7.6	94.6	2,845,624.2	1,433.8	1.0	0.6
10/02/2021 08:00	7.7	13.9	6.5	84.5	2,656,683.3	1,319.2	1.0	0.5
10/02/2021 09:00	7.5	13.9	6.3	84.4	2,589,621.8	1,285.9	1.0	0.5
10/02/2021 10:00	7.2	13.9	6.1	84.9	2,540,685.0	1,261.6	1.1	0.5
10/02/2021 11:00	7.3	13.9	6.2	85.6	2,541,087.8	1,261.8	1.1	0.5
10/02/2021 12:00	7.3	13.9	6.2	85.9	2,570,087.4	1,276.2	1.1	0.5
10/02/2021 13:00	8.1	13.9	6.8	87.4	2,703,807.6	1,342.6	1.0	0.5
10/02/2021 14:00	9.4	13.7	7.7	110.3	3,166,696.1	1,618.7	1.1	0.6
10/02/2021 15:00	9.6	13.7	7.9	109.6	3,248,079.0	1,660.3	1.0	0.7
10/02/2021 16:00	9.7	13.7	7.9	105.6	3,100,963.7	1,585.1	1.1	0.6
10/02/2021 17:00	10.5	13.5	8.4	128.3	3,241,351.4	1,704.2	1.2	0.9
10/02/2021 18:00	10.4	13.5	8.3	126.0	3,267,408.5	1,717.9	1.2	0.9
10/02/2021 19:00	9.6	13.7	7.9	110.1	3,237,123.6	1,654.7	1.1	0.7
10/02/2021 20:00	9.6	13.7	7.9	108.1	3,189,585.0	1,630.4	1.0	0.7
10/02/2021 21:00	9.5	13.7	7.8	108.7	3,224,016.3	1,648.0	1.0	0.7
10/02/2021 22:00	9.5	13.7	7.8	108.9	3,226,559.5	1,649.3	1.0	0.7
10/02/2021 23:00	9.2	13.8	7.6	107.8	3,214,625.9	1,643.2	1.0	0.7
Average/Sum#:	8.9	13.8	7.4	102.7	3,040,514.7	1,541.0	1.0	0.6
Minimum:	7.2	13.5	6.1	84.4	2,540,685.0	1,261.6	1.0	0.5
Maximum:	10.5	13.9	8.4	128.3	3,277,092.1	1,717.9	1.2	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/03/2021 00:00	9.0	13.8	7.5	104.8	3,161,782.6	1,593.1	1.0	0.6
10/03/2021 01:00	8.7	13.8	7.2	101.1	3,053,419.4	1,538.5	1.0	0.6
10/03/2021 02:00	8.4	13.8	7.0	91.8	2,816,052.5	1,418.9	1.0	0.6
10/03/2021 03:00	8.2	13.9	6.9	89.4	2,745,398.2	1,383.3	1.0	0.6
10/03/2021 04:00	8.7	13.8	7.2	92.8	2,849,196.6	1,435.6	1.0	0.6
10/03/2021 05:00	8.3	13.8	6.9	92.0	2,822,006.6	1,421.9	1.0	0.6
10/03/2021 06:00	8.6	13.8	7.1	95.1	2,829,349.9	1,425.6	1.1	0.6
10/03/2021 07:00	7.5	13.9	6.3	85.3	2,543,705.8	1,263.1	1.1	0.5
10/03/2021 08:00	7.7	13.9	6.5	83.6	2,632,073.4	1,326.2	1.0	0.5
10/03/2021 09:00	7.3	13.9	6.2	83.4	2,545,518.3	1,264.0	1.0	0.5
10/03/2021 10:00	7.2	13.9	6.1	85.9	2,551,157.1	1,266.8	1.1	0.5
10/03/2021 11:00	7.8	13.9	6.6	88.0	2,661,315.2	1,321.5	1.0	0.5
10/03/2021 12:00	8.4	13.9	7.1	91.0	2,788,389.7	1,384.6	1.0	0.6
10/03/2021 13:00	9.6	13.8	8.0	111.0	3,083,161.2	1,576.0	1.1	0.6
10/03/2021 14:00	9.6	13.7	7.9	109.7	3,224,016.3	1,648.0	1.1	0.7
10/03/2021 15:00	9.7	13.7	7.9	109.1	3,233,602.2	1,652.9	1.0	0.7
10/03/2021 16:00	9.7	13.7	7.9	104.8	3,071,423.3	1,570.0	1.1	0.6
10/03/2021 17:00	8.7	13.8	7.2	91.9	2,764,848.0	1,393.1	1.0	0.6
10/03/2021 18:00	10.7	13.6	8.6	139.1	3,283,146.7	1,702.2	1.3	0.9
10/03/2021 19:00	9.5	13.7	7.8	106.6	3,136,764.4	1,603.4	1.1	0.6
10/03/2021 20:00	9.5	13.7	7.8	108.3	3,207,583.2	1,639.6	1.0	0.7
10/03/2021 21:00	9.6	13.7	7.9	105.5	3,104,289.4	1,586.8	1.1	0.6
10/03/2021 22:00	9.5	13.7	7.8	107.6	3,185,672.4	1,628.4	1.0	0.7
10/03/2021 23:00	9.5	13.7	7.8	108.3	3,219,908.0	1,645.9	1.0	0.7
Average/Sum#:	8.8	13.8	7.3	99.4	2,938,074.2	1,487.1	1.0	0.6
Minimum:	7.2	13.6	6.1	83.4	2,543,705.8	1,263.1	1.0	0.5
Maximum:	10.7	13.9	8.6	139.1	3,283,146.7	1,702.2	1.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/04/2021 00:00	9.5	13.7	7.8	107.5	3,181,172.8	1,626.1	1.0	0.7
10/04/2021 01:00	9.6	13.7	7.9	100.5	2,938,980.4	1,502.3	1.1	0.6
10/04/2021 02:00	9.7	13.7	7.9	101.1	2,962,260.6	1,514.2	1.1	0.6
10/04/2021 03:00	9.6	13.7	7.9	105.3	3,088,247.6	1,578.6	1.1	0.6
10/04/2021 04:00	9.5	13.7	7.8	107.5	3,184,107.3	1,627.6	1.0	0.7
10/04/2021 05:00	9.4	13.7	7.7	108.2	3,212,278.3	1,642.0	1.0	0.7
10/04/2021 06:00	9.4	13.7	7.7	105.7	3,131,286.7	1,600.6	1.0	0.6
10/04/2021 07:00	9.5	13.8	7.9	104.2	3,110,181.1	1,567.1	1.0	0.6
10/04/2021 08:00	9.4	13.8	7.8	110.1	3,100,376.8	1,584.8	1.1	0.6
10/04/2021 09:00	9.2	13.8	7.6	103.9	3,109,387.2	1,566.7	1.0	0.6
10/04/2021 10:00	9.2	13.8	7.6	99.2	2,953,457.1	1,509.7	1.0	0.6
10/04/2021 11:00	9.4	13.7	7.7	104.9	3,129,134.7	1,599.5	1.0	0.6
10/04/2021 12:00	9.6	13.7	7.9	107.2	3,179,412.2	1,625.2	1.0	0.7
10/04/2021 13:00	9.5	13.7	7.8	104.4	3,092,160.3	1,580.6	1.0	0.6
10/04/2021 14:00	9.7	13.7	7.9	108.8	3,244,948.9	1,658.7	1.0	0.7
10/04/2021 15:00	9.7	13.7	7.9	105.6	3,121,309.4	1,595.5	1.0	0.6
10/04/2021 16:00	10.3	13.5	8.2	126.0	3,262,273.2	1,715.2	1.2	0.9
10/04/2021 17:00	10.5	13.5	8.4	124.3	3,274,255.7	1,721.5	1.2	0.9
10/04/2021 18:00	10.4	13.5	8.3	123.6	3,277,298.8	1,723.1	1.2	0.9
10/04/2021 19:00	10.2	13.6	8.2	120.5	3,285,847.0	1,703.6	1.1	0.7
10/04/2021 20:00	10.3	13.5	8.2	123.5	3,232,982.7	1,699.8	1.2	0.8
10/04/2021 21:00	10.1	13.6	8.2	122.9	3,272,345.6	1,696.6	1.2	0.8
10/04/2021 22:00	9.3	13.7	7.6	102.8	3,029,558.0	1,548.6	1.1	0.6
10/04/2021 23:00	9.1	13.8	7.6	102.2	3,096,486.8	1,560.2	1.0	0.6
Average/Sum#:	9.7	13.7	7.9	109.6	3,144,572.9	1,614.5	1.1	0.7
Minimum:	9.1	13.5	7.6	99.2	2,938,980.4	1,502.3	1.0	0.6
Maximum:	10.5	13.8	8.4	126.0	3,285,847.0	1,723.1	1.2	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/05/2021 00:00	8.7	13.8	7.2	98.5	3,037,343.6	1,530.4	1.0	0.6
10/05/2021 01:00	8.8	13.8	7.3	97.6	3,004,199.6	1,513.7	1.0	0.6
10/05/2021 02:00	8.9	13.8	7.4	97.7	2,976,017.2	1,499.5	1.0	0.6
10/05/2021 03:00	9.1	13.8	7.6	103.4	3,149,676.1	1,587.0	1.0	0.6
10/05/2021 04:00	9.0	13.8	7.5	100.9	3,063,938.2	1,543.8	1.0	0.6
10/05/2021 05:00	9.6	13.7	7.9	122.0	3,209,735.1	1,640.7	1.2	0.8
10/05/2021 06:00	9.4	13.7	7.7	109.7	3,223,233.7	1,647.6	1.1	0.7
10/05/2021 07:00	9.9	13.7	8.1	107.2	3,123,461.4	1,596.6	1.1	0.6
10/05/2021 08:00	9.9	13.7	8.1	104.2	3,058,315.9	1,563.3	1.0	0.6
10/05/2021 09:00	9.7	13.7	7.9	106.7	3,144,198.4	1,607.2	1.1	0.6
10/05/2021 10:00	9.7	13.7	7.9	107.1	3,171,782.5	1,621.3	1.0	0.6
10/05/2021 11:00	9.7	13.7	7.9	106.1	3,129,721.6	1,599.8	1.0	0.6
10/05/2021 12:00	9.7	13.7	7.9	109.5	3,260,208.2	1,666.5	1.0	0.7
10/05/2021 13:00	9.7	13.8	8.1	108.2	3,203,279.3	1,637.4	1.0	0.7
10/05/2021 14:00	10.9	13.8	9.1	136.6	3,161,385.7	1,592.9	1.3	0.8
10/05/2021 15:00	10.0	13.8	8.3	126.1	3,203,670.5	1,637.6	1.2	0.8
10/05/2021 16:00	9.6	13.7	7.9	107.5	3,200,931.7	1,636.2	1.0	0.7
10/05/2021 17:00	9.8	13.8	8.1	106.9	3,120,135.6	1,594.9	1.1	0.6
10/05/2021 18:00	9.8	13.7	8.0	105.9	3,105,463.2	1,587.4	1.1	0.6
10/05/2021 19:00	9.7	13.7	7.9	108.5	3,212,278.3	1,642.0	1.0	0.7
10/05/2021 20:00	9.9	13.7	8.1	104.1	3,039,144.0	1,553.5	1.1	0.6
10/05/2021 21:00	9.4	13.8	7.8	97.7	2,926,201.9	1,474.4	1.0	0.6
10/05/2021 22:00	9.0	13.8	7.5	104.4	3,172,896.8	1,598.7	1.0	0.6
10/05/2021 23:00	8.0	13.8	6.6	89.3	2,739,245.7	1,380.2	1.0	0.6
Average/Sum#:	9.5	13.8	7.8	106.9	3,109,852.7	1,581.4	1.1	0.6
Minimum:	8.0	13.7	6.6	89.3	2,739,245.7	1,380.2	1.0	0.6
Maximum:	10.9	13.8	9.1	136.6	3,260,208.2	1,666.5	1.3	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/06/2021 00:00	7.1	13.8	5.9	80.8	2,509,817.5	1,264.6	1.0	0.5
10/06/2021 01:00	7.2	13.8	6.0	81.2	2,510,214.4	1,264.8	1.0	0.5
10/06/2021 02:00	7.3	13.8	6.1	81.4	2,512,397.6	1,265.9	1.0	0.5
10/06/2021 03:00	7.3	13.8	6.1	81.7	2,513,588.4	1,266.5	1.0	0.5
10/06/2021 04:00	7.5	13.8	6.2	82.5	2,560,625.1	1,290.2	1.0	0.5
10/06/2021 05:00	8.8	13.7	7.2	96.9	2,932,915.8	1,499.2	1.0	0.6
10/06/2021 06:00	9.2	13.7	7.5	105.0	3,065,358.7	1,566.9	1.1	0.6
10/06/2021 07:00	9.3	13.7	7.6	101.4	2,998,256.9	1,532.6	1.0	0.6
10/06/2021 08:00	8.1	13.8	6.7	88.1	2,723,566.8	1,372.3	1.0	0.5
10/06/2021 09:00	9.1	13.7	7.5	101.0	3,039,144.0	1,553.5	1.0	0.6
10/06/2021 10:00	9.1	13.7	7.5	100.7	3,005,299.6	1,536.2	1.0	0.6
10/06/2021 11:00	8.3	13.8	6.9	94.4	2,888,311.7	1,476.4	1.0	0.6
10/06/2021 12:00	8.9	13.7	7.3	102.2	3,076,314.1	1,572.5	1.0	0.6
10/06/2021 13:00	8.9	13.8	7.4	103.5	3,134,612.4	1,602.3	1.0	0.6
10/06/2021 14:00	9.1	13.8	7.6	106.8	3,221,081.8	1,646.5	1.0	0.7
10/06/2021 15:00	9.5	13.7	7.8	107.3	3,191,345.7	1,631.3	1.0	0.7
10/06/2021 16:00	9.6	13.7	7.9	106.3	3,137,351.3	1,603.7	1.0	0.6
10/06/2021 17:00	8.3	13.8	6.9	88.8	2,703,720.1	1,362.3	1.0	0.5
10/06/2021 18:00	9.8	13.7	8.0	103.6	3,045,599.8	1,556.8	1.1	0.6
10/06/2021 19:00	9.6	13.7	7.9	105.2	3,103,115.7	1,586.2	1.0	0.6
10/06/2021 20:00	10.0	13.6	8.1	121.5	3,248,814.7	1,684.4	1.2	0.8
10/06/2021 21:00	9.5	13.7	7.8	106.3	3,136,177.5	1,603.1	1.1	0.6
10/06/2021 22:00	9.7	13.7	7.9	102.7	3,030,536.2	1,549.1	1.0	0.6
10/06/2021 23:00	9.4	13.7	7.7	108.4	3,230,472.1	1,651.3	1.0	0.7
Average/Sum#:	8.8	13.7	7.2	98.2	2,938,276.6	1,497.4	1.0	0.6
Minimum:	7.1	13.6	5.9	80.8	2,509,817.5	1,264.6	1.0	0.5
Maximum:	10.0	13.8	8.1	121.5	3,248,814.7	1,684.4	1.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/07/2021 00:00	9.6	13.7	7.9	101.0	2,966,564.5	1,516.4	1.1	0.6
10/07/2021 01:00	9.6	13.7	7.9	100.7	2,969,890.2	1,518.1	1.0	0.6
10/07/2021 02:00	9.3	13.8	7.7	99.3	2,957,761.0	1,511.9	1.0	0.6
10/07/2021 03:00	8.4	13.8	7.0	91.8	2,852,173.6	1,437.1	1.0	0.6
10/07/2021 04:00	9.0	13.7	7.4	104.7	3,174,325.7	1,622.6	1.0	0.6
10/07/2021 05:00	9.0	13.7	7.4	104.5	3,143,024.6	1,606.6	1.0	0.6
10/07/2021 06:00	8.8	13.7	7.2	106.2	3,239,471.2	1,655.9	1.0	0.7
10/07/2021 07:00	9.2	13.7	7.5	104.3	3,126,982.8	1,598.4	1.0	0.6
10/07/2021 08:00	8.8	13.7	7.2	102.7	3,106,832.7	1,588.1	1.0	0.6
10/07/2021 09:00	8.6	13.8	7.1	97.5	2,957,565.4	1,511.8	1.0	0.6
10/07/2021 10:00	8.5	13.8	7.1	97.0	2,962,719.9	1,492.8	1.0	0.6
10/07/2021 11:00	8.9	13.8	7.4	97.9	2,993,283.8	1,508.2	1.0	0.6
10/07/2021 12:00	9.0	13.8	7.5	98.7	2,999,237.9	1,511.2	1.0	0.6
10/07/2021 13:00	9.0	13.8	7.5	98.4	2,998,047.1	1,510.6	1.0	0.6
10/07/2021 14:00	9.3	13.7	7.6	107.3	3,220,299.3	1,646.1	1.0	0.7
10/07/2021 15:00	9.6	13.7	7.9	107.7	3,191,150.1	1,631.2	1.0	0.7
10/07/2021 16:00	9.6	13.7	7.9	109.3	3,252,382.9	1,662.5	1.0	0.7
10/07/2021 17:00	10.5	13.5	8.4	132.9	3,343,868.1	1,758.1	1.2	0.9
10/07/2021 18:00	10.0	13.6	8.1	119.1	3,304,363.2	1,713.2	1.1	0.7
10/07/2021 19:00	9.8	13.7	8.0	112.1	3,156,914.5	1,613.7	1.1	0.6
10/07/2021 20:00	9.7	13.7	7.9	114.1	3,079,661.9	1,596.7	1.2	0.8
10/07/2021 21:00	9.3	13.8	7.7	106.1	3,191,932.6	1,631.6	1.0	0.7
10/07/2021 22:00	9.2	13.8	7.6	107.1	3,214,430.3	1,643.1	1.0	0.7
10/07/2021 23:00	9.1	13.8	7.6	101.8	3,097,677.6	1,560.8	1.0	0.6
Average/Sum#:	9.2	13.7	7.6	105.1	3,104,190.0	1,585.3	1.0	0.7
Minimum:	8.4	13.5	7.0	91.8	2,852,173.6	1,437.1	1.0	0.6
Maximum:	10.5	13.8	8.4	132.9	3,343,868.1	1,758.1	1.2	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/08/2021 00:00	9.0	13.8	7.5	96.8	2,937,316.1	1,480.0	1.0	0.6
10/08/2021 01:00	9.0	13.8	7.5	95.3	2,870,117.9	1,467.1	1.0	0.6
10/08/2021 02:00	9.0	13.8	7.5	97.3	2,930,763.8	1,498.1	1.0	0.6
10/08/2021 03:00	9.2	13.7	7.5	101.6	3,034,057.5	1,550.9	1.0	0.6
10/08/2021 04:00	9.1	13.7	7.5	105.7	3,182,933.5	1,627.0	1.0	0.7
10/08/2021 05:00	8.9	13.8	7.4	98.4	2,979,867.5	1,523.2	1.0	0.6
10/08/2021 06:00	9.2	13.7	7.5	102.6	3,167,283.0	1,619.0	1.0	0.6
10/08/2021 07:00	8.9	13.8	7.4	99.2	2,944,066.8	1,504.9	1.0	0.6
10/08/2021 08:00	8.9	13.8	7.4	98.0	2,961,478.0	1,513.8	1.0	0.6
10/08/2021 09:00	8.1	13.8	6.7	88.3	2,709,078.7	1,365.0	1.0	0.5
10/08/2021 10:00	9.1	13.8	7.6	104.7	3,172,565.0	1,621.7	1.0	0.6
10/08/2021 11:00	8.4	13.8	7.0	92.1	2,846,815.0	1,434.4	1.0	0.6
10/08/2021 12:00	9.1	13.8	7.6	101.6	3,113,555.0	1,568.8	1.0	0.6
10/08/2021 13:00	8.8	13.8	7.3	98.5	3,049,648.6	1,536.6	1.0	0.6
10/08/2021 14:00	8.7	13.8	7.2	97.6	2,984,154.4	1,503.6	1.0	0.6
10/08/2021 15:00	9.2	13.8	7.6	102.5	3,142,332.8	1,583.3	1.0	0.6
10/08/2021 16:00	9.1	13.8	7.6	106.3	3,261,611.6	1,643.4	1.0	0.7
10/08/2021 17:00	9.3	13.8	7.7	102.8	3,110,379.6	1,567.2	1.0	0.6
10/08/2021 18:00	9.4	13.8	7.8	103.8	3,140,348.1	1,582.3	1.0	0.6
10/08/2021 19:00	9.1	13.8	7.6	104.6	3,194,132.8	1,609.4	1.0	0.6
10/08/2021 20:00	7.8	13.8	6.5	87.9	2,683,674.9	1,352.2	1.0	0.5
10/08/2021 21:00	21.6	16.6	29.6	173.9	1,219,680.8	409.7	4.5	0.7
10/08/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/08/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	9.5	13.9	8.4	102.7	2,937,993.7	1,480.1	1.2	0.6
Minimum:	7.8	13.7	6.5	87.9	1,219,680.8	409.7	1.0	0.5
Maximum:	21.6	16.6	29.6	173.9	3,261,611.6	1,643.4	4.5	0.7
%SI	8.33	8.33	8.33	8.33	8.33	8.33	8.33	8.33

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/09/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/09/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/10/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/10/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/11/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/11/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/12/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/12/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/13/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/13/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/14/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/14/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/15/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/15/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/16/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/16/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/17/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/17/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/18/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/18/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/19/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/19/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/20/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/20/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/20/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/20/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/20/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/20/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/20/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/20/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/20/2021 08:00	20.2	17.9	39.7	0.0	1,174,852.0	205.9	-0.2	0.0
10/20/2021 09:00	32.8	17.2	52.3	66.8	1,428,766.1	375.6	1.6	0.2
10/20/2021 10:00	28.0	17.2	44.6	256.5	1,519,300.3	399.4	5.2	0.8
10/20/2021 11:00	34.3	16.8	49.4	254.7	2,240,720.6	654.5	3.3	0.9
10/20/2021 12:00	21.0	14.7	20.0	183.3	2,503,957.7	1,078.8	2.3	1.0
10/20/2021 13:00	6.1	13.8	5.1	78.2	2,656,484.8	1,338.5	0.9	0.4
10/20/2021 14:00	6.5	13.8	5.4	79.0	2,519,542.4	1,269.5	1.0	0.5
10/20/2021 15:00	6.8	13.7	5.6	87.2	2,852,706.6	1,458.2	1.0	0.6
10/20/2021 16:00	7.1	13.3	5.5	109.8	3,090,619.7	1,805.5	1.1	0.7
10/20/2021 17:00	6.9	13.6	5.6	97.0	3,178,607.6	1,648.0	1.0	0.7
10/20/2021 18:00	7.3	13.2	5.6	108.7	3,369,130.7	1,943.6	1.0	0.8
10/20/2021 19:00	7.4	13.2	5.7	112.2	3,396,343.7	1,984.1	1.1	0.8
10/20/2021 20:00	7.5	13.0	5.6	124.1	3,361,299.9	2,110.9	1.2	1.1
10/20/2021 21:00	7.4	13.1	5.6	120.7	3,302,568.3	2,049.9	1.2	1.0
10/20/2021 22:00	18.4	15.8	21.3	162.2	1,633,490.7	632.2	3.1	0.8
10/20/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	14.5	14.7	18.5	122.7	2,548,559.4	1,263.6	1.7	0.7
Minimum:	6.1	13.0	5.1	0.0	1,174,852.0	205.9	-0.2	0.0
Maximum:	34.3	17.9	52.3	256.5	3,396,343.7	2,110.9	5.2	1.1
%SI	37.50	37.50	37.50	37.50	37.50	37.50	37.50	37.50

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/21/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/21/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/22/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/22/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/23/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/23/2021 05:00	5.8	19.3	21.4	0.0	13,694.2	0.2	0.1	0.0
10/23/2021 06:00	31.5	17.2	50.2	76.5	1,418,115.0	372.8	1.7	0.3
10/23/2021 07:00	18.4	14.3	16.4	166.4	2,728,578.1	1,275.2	1.9	0.9
10/23/2021 08:00	6.2	13.7	5.1	93.3	3,156,131.9	1,613.3	0.9	0.5
10/23/2021 09:00	6.4	13.8	5.3	82.2	2,721,185.2	1,371.1	1.0	0.5
10/23/2021 10:00	6.4	13.7	5.2	95.9	3,064,576.1	1,566.5	1.0	0.6
10/23/2021 11:00	6.5	13.7	5.3	91.3	3,011,755.5	1,539.5	1.0	0.6
10/23/2021 12:00	6.5	13.7	5.3	93.2	3,097,051.1	1,583.1	1.0	0.6
10/23/2021 13:00	6.5	13.7	5.3	91.4	3,025,645.4	1,546.6	1.0	0.6
10/23/2021 14:00	6.6	13.7	5.4	96.5	3,184,889.9	1,628.0	1.0	0.7
10/23/2021 15:00	6.5	13.7	5.3	94.3	3,135,199.3	1,602.6	1.0	0.6
10/23/2021 16:00	6.8	13.6	5.5	96.7	3,148,904.6	1,632.6	1.0	0.7
10/23/2021 17:00	7.3	13.2	5.6	109.2	3,346,075.8	1,930.3	1.0	0.8
10/23/2021 18:00	7.3	13.1	5.5	114.7	3,344,735.6	2,002.8	1.1	0.8
10/23/2021 19:00	6.3	13.7	5.2	95.4	3,119,201.6	1,617.2	1.0	0.6
10/23/2021 20:00	6.7	13.6	5.4	96.8	3,168,578.0	1,642.8	1.0	0.7
10/23/2021 21:00	7.3	13.2	5.6	113.0	3,349,679.7	1,981.3	1.1	0.8
10/23/2021 22:00	10.5	14.1	9.1	123.4	2,779,160.0	1,440.9	1.4	0.7
10/23/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	8.9	14.2	9.6	96.1	2,822,953.2	1,463.7	1.1	0.6
Minimum:	5.8	13.1	5.1	0.0	13,694.2	0.2	0.1	0.0
Maximum:	31.5	19.3	50.2	166.4	3,349,679.7	2,002.8	1.9	0.9
%SI	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/24/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/24/2021 03:00	17.5	18.0	35.6	147.1	1,186,182.4	181.9	3.7	0.3
10/24/2021 04:00	33.4	15.1	34.0	216.4	2,218,965.5	891.2	2.9	1.0
10/24/2021 05:00	6.2	13.7	5.1	83.4	2,725,545.8	1,393.2	1.0	0.6
10/24/2021 06:00	6.5	13.7	5.3	82.0	2,695,418.5	1,377.8	1.0	0.6
10/24/2021 07:00	7.1	13.6	5.7	98.6	3,277,746.2	1,699.4	1.0	0.7
10/24/2021 08:00	6.6	13.7	5.4	96.8	3,019,776.4	1,543.6	1.0	0.6
10/24/2021 09:00	6.6	13.7	5.4	91.6	3,006,082.2	1,536.6	1.0	0.6
10/24/2021 10:00	6.6	13.7	5.4	91.8	3,028,188.6	1,547.9	1.0	0.6
10/24/2021 11:00	6.6	13.7	5.4	90.4	2,990,040.3	1,528.4	1.0	0.6
10/24/2021 12:00	6.6	13.7	5.4	93.6	3,098,616.1	1,583.9	1.0	0.6
10/24/2021 13:00	6.6	13.7	5.4	88.4	2,903,766.6	1,484.3	1.0	0.6
10/24/2021 14:00	6.7	13.7	5.5	94.4	3,132,069.2	1,601.0	1.0	0.6
10/24/2021 15:00	6.6	13.7	5.4	95.9	3,176,673.3	1,623.8	1.0	0.6
10/24/2021 16:00	7.1	13.5	5.7	102.0	3,271,022.3	1,719.8	1.0	0.7
10/24/2021 17:00	7.5	13.1	5.7	111.9	3,283,537.3	1,918.2	1.1	0.8
10/24/2021 18:00	7.5	13.0	5.6	117.3	3,265,829.7	1,979.4	1.2	1.0
10/24/2021 19:00	6.4	13.7	5.2	97.1	3,240,840.6	1,656.6	1.0	0.7
10/24/2021 20:00	6.8	13.7	5.6	99.7	3,308,724.9	1,691.3	1.0	0.7
10/24/2021 21:00	7.8	13.0	5.8	116.3	3,305,990.9	1,979.6	1.1	0.8
10/24/2021 22:00	7.0	13.4	5.5	101.0	2,964,083.0	1,645.0	1.1	0.7
10/24/2021 23:00	13.7	15.0	13.7	125.6	2,024,194.9	872.1	1.9	0.6
Average/Sum#:	8.9	13.9	8.7	106.7	2,910,633.1	1,497.9	1.3	0.7
Minimum:	6.2	13.0	5.1	82.0	1,186,182.4	181.9	1.0	0.3
Maximum:	33.4	18.0	35.6	216.4	3,308,724.9	1,979.6	3.7	1.0
%SI	12.50	12.50	12.50	12.50	12.50	12.50	12.50	12.50

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/25/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/25/2021 05:00	32.3	17.2	51.5	176.7	1,663,643.1	400.9	2.9	0.4
10/25/2021 06:00	20.6	14.2	18.1	163.3	2,881,808.4	1,388.9	1.7	1.0
10/25/2021 07:00	7.2	13.6	5.8	105.5	3,373,798.8	1,749.2	1.0	0.7
10/25/2021 08:00	6.3	13.8	5.2	96.1	3,231,645.9	1,651.9	0.9	0.5
10/25/2021 09:00	6.9	13.6	5.6	102.9	3,396,172.5	1,760.8	1.0	0.7
10/25/2021 10:00	7.5	13.2	5.7	109.5	3,397,039.2	1,959.7	1.0	0.8
10/25/2021 11:00	7.5	13.2	5.7	113.9	3,397,541.9	1,984.8	1.1	0.8
10/25/2021 12:00	7.4	13.3	5.7	108.7	3,355,089.7	1,911.0	1.0	0.8
10/25/2021 13:00	6.5	13.7	5.3	95.0	3,143,220.2	1,606.7	1.0	0.6
10/25/2021 14:00	6.4	13.8	5.3	89.2	3,026,031.0	1,524.7	0.9	0.5
10/25/2021 15:00	6.8	13.7	5.6	92.0	3,016,450.7	1,541.9	1.0	0.6
10/25/2021 16:00	7.8	13.1	5.9	118.4	3,388,657.3	2,029.1	1.1	0.8
10/25/2021 17:00	7.8	13.0	5.8	121.7	3,400,957.2	2,061.3	1.2	1.0
10/25/2021 18:00	7.6	13.1	5.7	118.4	3,385,651.3	2,027.3	1.1	0.8
10/25/2021 19:00	6.5	13.7	5.3	96.1	3,133,088.7	1,624.4	1.0	0.6
10/25/2021 20:00	6.2	13.8	5.2	84.9	2,908,736.8	1,465.6	0.9	0.4
10/25/2021 21:00	7.2	13.3	5.6	106.5	3,389,770.0	1,906.0	1.0	0.8
10/25/2021 22:00	6.6	13.5	5.3	97.3	3,126,227.0	1,666.5	1.0	0.7
10/25/2021 23:00	13.7	15.1	13.9	124.0	1,996,342.2	860.1	1.9	0.6
Average/Sum#:	9.4	13.8	9.1	111.6	3,084,835.4	1,637.9	1.2	0.7
Minimum:	6.2	13.0	5.2	84.9	1,663,643.1	400.9	0.9	0.4
Maximum:	32.3	17.2	51.5	176.7	3,400,957.2	2,061.3	2.9	1.0
%SI	20.83	20.83	20.83	20.83	20.83	20.83	20.83	20.83

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/26/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/26/2021 05:00	30.8	17.4	51.9	168.2	1,698,528.0	384.5	2.6	0.4
10/26/2021 06:00	22.5	14.4	20.4	164.9	2,603,190.2	1,216.6	1.9	0.9
10/26/2021 07:00	6.4	13.7	5.2	89.7	3,091,769.0	1,580.4	0.9	0.5
10/26/2021 08:00	6.4	13.7	5.2	92.3	3,078,074.8	1,573.4	1.0	0.6
10/26/2021 09:00	6.6	13.7	5.4	91.5	3,060,076.6	1,564.2	0.9	0.5
10/26/2021 10:00	7.4	13.2	5.7	122.9	3,366,078.9	1,991.0	1.2	1.0
10/26/2021 11:00	0.0	0.0	0.0	107.8	1,249,124.7	1,906.4	3.0	2.3
10/26/2021 12:00	6.8	13.7	5.6	99.0	3,232,624.1	1,652.4	1.0	0.7
10/26/2021 13:00	6.9	13.8	5.7	89.0	2,873,806.5	1,448.0	1.0	0.6
10/26/2021 14:00	6.7	13.8	5.6	84.4	2,835,700.8	1,428.8	0.9	0.4
10/26/2021 15:00	7.2	13.7	5.9	93.2	3,025,645.4	1,546.6	1.0	0.6
10/26/2021 16:00	7.9	13.1	6.0	115.1	3,393,776.0	1,982.6	1.1	0.8
10/26/2021 17:00	7.9	13.0	5.9	122.3	3,388,912.9	2,054.0	1.2	1.0
10/26/2021 18:00	7.7	13.0	5.8	118.3	3,424,068.2	2,025.3	1.1	0.8
10/26/2021 19:00	7.5	13.1	5.7	116.4	3,393,262.4	1,982.3	1.1	0.8
10/26/2021 20:00	6.4	13.7	5.2	91.5	3,040,122.1	1,554.0	1.0	0.6
10/26/2021 21:00	6.7	13.6	5.4	101.8	3,400,030.0	1,762.8	0.9	0.5
10/26/2021 22:00	7.7	13.1	5.8	115.3	3,389,917.1	2,005.1	1.1	0.8
10/26/2021 23:00	7.2	13.2	5.5	111.8	3,354,918.6	1,959.9	1.1	0.8
Average/Sum#:	9.3	13.7	9.0	110.3	3,091,694.5	1,664.1	1.2	0.7
Minimum:	6.4	13.0	5.2	84.4	1,698,528.0	384.5	0.9	0.4
Maximum:	30.8	17.4	51.9	168.2	3,424,068.2	2,054.0	2.6	1.0
%SI	25.00	25.00	25.00	20.83	25.00	20.83	25.00	25.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/27/2021 00:00	6.4	13.7	5.2	90.1	3,006,082.2	1,536.6	1.0	0.6
10/27/2021 01:00	6.7	13.7	5.5	91.0	3,056,555.2	1,562.4	0.9	0.5
10/27/2021 02:00	7.1	13.3	5.5	105.8	3,452,931.5	1,916.3	1.0	0.8
10/27/2021 03:00	6.8	13.3	5.3	103.9	3,406,803.5	1,890.7	1.0	0.8
10/27/2021 04:00	6.4	13.7	5.2	92.5	3,071,032.0	1,569.8	1.0	0.6
10/27/2021 05:00	6.5	13.7	5.3	92.5	3,108,789.0	1,589.1	0.9	0.5
10/27/2021 06:00	7.4	13.3	5.7	108.5	3,389,149.8	1,930.4	1.0	0.8
10/27/2021 07:00	7.8	13.1	5.9	113.8	3,389,065.3	1,955.1	1.1	0.8
10/27/2021 08:00	7.1	13.3	5.5	106.3	3,413,068.0	1,919.1	1.0	0.8
10/27/2021 09:00	6.3	13.8	5.2	86.5	2,866,596.5	1,465.3	1.0	0.6
10/27/2021 10:00	6.5	13.8	5.4	83.9	2,822,998.9	1,422.4	0.9	0.4
10/27/2021 11:00	6.6	13.8	5.5	93.0	3,073,966.5	1,571.3	1.0	0.6
10/27/2021 12:00	6.8	13.8	5.7	81.2	2,596,746.2	1,308.4	1.0	0.5
10/27/2021 13:00	6.6	13.8	5.5	87.1	2,884,523.8	1,453.4	1.0	0.6
10/27/2021 14:00	7.7	13.4	6.1	107.2	3,291,365.9	1,802.6	1.0	0.7
10/27/2021 15:00	7.5	13.3	5.8	110.8	3,213,467.0	1,853.8	1.1	0.7
10/27/2021 16:00	6.9	13.7	5.7	98.6	3,276,250.0	1,674.7	1.0	0.7
10/27/2021 17:00	7.6	13.2	5.8	109.6	3,343,995.7	1,929.1	1.0	0.8
10/27/2021 18:00	7.9	12.9	5.8	124.1	3,354,926.7	2,057.9	1.2	1.0
10/27/2021 19:00	8.0	12.9	5.9	130.7	3,340,758.6	2,098.0	1.3	1.0
10/27/2021 20:00	7.7	12.9	5.7	123.9	3,321,579.1	2,061.7	1.2	1.0
10/27/2021 21:00	7.8	12.9	5.8	125.6	3,335,595.6	2,070.4	1.2	1.0
10/27/2021 22:00	7.6	13.1	5.7	116.5	3,312,838.0	1,983.7	1.1	0.8
10/27/2021 23:00	7.0	13.3	5.4	103.4	3,245,896.2	1,801.4	1.0	0.7
Average/Sum#:	7.1	13.4	5.6	103.6	3,190,624.2	1,767.7	1.0	0.7
Minimum:	6.3	12.9	5.2	81.2	2,596,746.2	1,308.4	0.9	0.4
Maximum:	8.0	13.8	6.1	130.7	3,452,931.5	2,098.0	1.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/28/2021 00:00	9.9	14.4	9.0	100.3	2,366,750.5	1,106.1	1.3	0.6
10/28/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10/28/2021 12:00	29.8	17.7	54.9	0.0	1,376,760.6	281.5	-0.3	0.0
10/28/2021 13:00	29.0	15.0	29.0	171.4	2,262,913.7	941.9	2.3	0.8
10/28/2021 14:00	6.7	13.8	5.6	90.0	2,983,757.4	1,503.4	1.0	0.6
10/28/2021 15:00	7.1	13.7	5.8	92.5	2,999,821.9	1,533.4	1.0	0.6
10/28/2021 16:00	8.1	13.1	6.1	119.8	3,271,783.1	2,006.9	1.2	1.0
10/28/2021 17:00	8.3	12.9	6.1	133.6	3,277,386.4	2,130.0	1.3	1.1
10/28/2021 18:00	8.2	12.9	6.0	132.9	3,300,935.2	2,121.2	1.3	1.1
10/28/2021 19:00	8.2	12.9	6.0	133.5	3,274,001.4	2,127.8	1.3	1.1
10/28/2021 20:00	8.0	12.9	5.9	130.4	3,308,025.6	2,101.6	1.3	1.1
10/28/2021 21:00	7.8	13.0	5.8	122.5	3,321,995.3	2,037.7	1.2	1.0
10/28/2021 22:00	7.7	13.1	5.8	119.0	3,322,091.6	2,013.5	1.2	1.0
10/28/2021 23:00	7.5	13.1	5.7	112.6	3,303,694.1	1,954.1	1.1	0.8
Average/Sum#:	11.3	13.7	11.7	112.2	2,951,532.1	1,681.5	1.2	0.8
Minimum:	6.7	12.9	5.6	0.0	1,376,760.6	281.5	-0.3	0.0
Maximum:	29.8	17.7	54.9	171.4	3,322,091.6	2,130.0	2.3	1.1
%SI	45.83	45.83	45.83	45.83	45.83	45.83	45.83	45.83

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/29/2021 00:00	7.3	13.3	5.7	106.0	3,377,320.7	1,899.0	1.0	0.8
10/29/2021 01:00	7.3	13.3	5.7	106.1	3,384,968.1	1,903.3	1.0	0.8
10/29/2021 02:00	7.3	13.3	5.7	106.3	3,372,874.5	1,896.5	1.0	0.8
10/29/2021 03:00	7.3	13.3	5.7	106.4	3,371,807.4	1,895.9	1.0	0.8
10/29/2021 04:00	7.3	13.3	5.7	106.3	3,371,985.2	1,896.0	1.0	0.8
10/29/2021 05:00	7.3	13.3	5.7	106.2	3,375,897.9	1,898.2	1.0	0.8
10/29/2021 06:00	7.3	13.3	5.7	106.9	3,380,521.9	1,900.8	1.0	0.8
10/29/2021 07:00	7.7	13.3	6.0	108.0	3,376,253.6	1,898.4	1.0	0.8
10/29/2021 08:00	7.5	13.3	5.8	107.5	3,375,186.5	1,897.8	1.0	0.8
10/29/2021 09:00	7.2	13.4	5.7	101.2	3,073,817.2	1,705.9	1.1	0.7
10/29/2021 10:00	6.9	13.7	5.7	86.0	2,720,139.7	1,410.3	1.0	0.6
10/29/2021 11:00	7.6	13.2	5.8	109.4	3,319,900.7	1,915.2	1.1	0.8
10/29/2021 12:00	7.2	13.4	5.7	102.6	3,039,232.9	1,708.9	1.1	0.7
10/29/2021 13:00	6.8	13.7	5.6	85.4	2,708,181.4	1,404.1	1.0	0.6
10/29/2021 14:00	7.7	13.2	5.9	110.8	3,250,269.6	1,922.5	1.1	0.8
10/29/2021 15:00	7.5	13.2	5.7	110.8	3,251,114.9	1,923.0	1.1	0.8
10/29/2021 16:00	7.5	13.2	5.7	110.5	3,287,132.1	1,920.3	1.1	0.8
10/29/2021 17:00	7.5	13.2	5.7	110.0	3,282,339.1	1,917.5	1.1	0.8
10/29/2021 18:00	7.4	13.2	5.7	109.7	3,276,347.8	1,914.0	1.1	0.8
10/29/2021 19:00	7.5	13.2	5.7	109.7	3,273,780.2	1,912.5	1.1	0.8
10/29/2021 20:00	7.5	13.2	5.7	109.7	3,271,212.5	1,911.0	1.1	0.8
10/29/2021 21:00	7.4	13.2	5.7	108.9	3,309,673.4	1,909.3	1.1	0.8
10/29/2021 22:00	7.3	13.2	5.6	108.0	3,299,792.7	1,903.6	1.0	0.8
10/29/2021 23:00	7.5	13.1	5.7	114.5	3,280,940.4	1,964.6	1.1	0.8
Average/Sum#:	7.4	13.3	5.7	106.1	3,251,278.8	1,851.2	1.1	0.8
Minimum:	6.8	13.1	5.6	85.4	2,708,181.4	1,404.1	1.0	0.6
Maximum:	7.7	13.7	6.0	114.5	3,384,968.1	1,964.6	1.1	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/30/2021 00:00	6.5	13.7	5.3	95.3	3,145,818.5	1,631.0	1.0	0.7
10/30/2021 01:00	6.6	13.7	5.4	84.8	2,827,470.1	1,445.3	0.9	0.4
10/30/2021 02:00	7.4	13.4	5.8	100.6	3,134,900.7	1,739.8	1.0	0.7
10/30/2021 03:00	7.4	13.2	5.7	107.4	3,320,151.9	1,891.1	1.0	0.8
10/30/2021 04:00	6.5	13.7	5.3	94.3	3,131,482.3	1,600.7	1.0	0.6
10/30/2021 05:00	6.9	13.6	5.6	98.3	3,210,432.2	1,664.5	1.0	0.7
10/30/2021 06:00	7.6	13.1	5.7	111.4	3,342,748.0	1,977.2	1.1	0.8
10/30/2021 07:00	7.6	13.2	5.8	109.7	3,342,975.6	1,904.1	1.0	0.8
10/30/2021 08:00	6.7	13.7	5.5	90.7	2,951,500.8	1,508.7	1.0	0.6
10/30/2021 09:00	6.8	13.7	5.6	89.9	2,946,218.7	1,506.0	1.0	0.6
10/30/2021 10:00	6.9	13.7	5.7	90.3	2,960,891.2	1,513.5	1.0	0.6
10/30/2021 11:00	6.8	13.7	5.6	93.3	3,043,447.9	1,555.7	1.0	0.6
10/30/2021 12:00	6.7	13.8	5.6	83.4	2,727,337.7	1,374.2	1.0	0.5
10/30/2021 13:00	6.7	13.8	5.6	82.6	2,749,367.5	1,385.3	0.9	0.4
10/30/2021 14:00	6.7	13.8	5.6	89.2	2,981,375.8	1,502.2	0.9	0.5
10/30/2021 15:00	7.3	13.7	6.0	95.4	3,095,290.4	1,582.2	1.0	0.6
10/30/2021 16:00	8.2	13.1	6.2	118.0	3,338,556.4	1,999.1	1.1	0.8
10/30/2021 17:00	8.1	13.0	6.0	123.6	3,317,229.2	2,059.0	1.2	1.0
10/30/2021 18:00	8.0	13.1	6.1	120.4	3,359,049.5	2,035.9	1.2	1.0
10/30/2021 19:00	7.8	13.1	5.9	115.8	3,333,280.4	1,971.6	1.1	0.8
10/30/2021 20:00	6.8	13.7	5.6	98.6	3,222,842.5	1,647.4	1.0	0.7
10/30/2021 21:00	6.7	13.7	5.5	95.3	3,159,457.7	1,615.0	1.0	0.6
10/30/2021 22:00	7.6	13.2	5.8	112.3	3,367,928.1	1,967.5	1.1	0.8
10/30/2021 23:00	7.3	13.3	5.7	107.5	3,386,390.9	1,904.1	1.0	0.8
Average/Sum#:	7.2	13.5	5.7	100.3	3,141,506.0	1,707.5	1.0	0.7
Minimum:	6.5	13.0	5.3	82.6	2,727,337.7	1,374.2	0.9	0.4
Maximum:	8.2	13.8	6.2	123.6	3,386,390.9	2,059.0	1.2	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
10/31/2021 00:00	6.3	13.7	5.2	95.5	3,198,584.1	1,635.0	0.9	0.5
10/31/2021 01:00	6.5	13.7	5.3	91.5	3,021,341.5	1,544.4	1.0	0.6
10/31/2021 02:00	7.3	13.3	5.7	107.0	3,415,202.1	1,920.3	1.0	0.8
10/31/2021 03:00	7.2	13.3	5.6	107.0	3,387,280.1	1,904.6	1.0	0.8
10/31/2021 04:00	6.2	13.7	5.1	96.7	3,258,447.5	1,665.6	0.9	0.5
10/31/2021 05:00	6.5	13.7	5.3	90.7	3,003,147.7	1,535.1	1.0	0.6
10/31/2021 06:00	7.4	13.2	5.7	109.0	3,404,731.4	1,989.0	1.0	0.8
10/31/2021 07:00	7.1	13.3	5.5	107.5	3,386,213.0	1,904.0	1.0	0.8
10/31/2021 08:00	6.4	13.7	5.2	95.6	3,174,912.6	1,622.9	1.0	0.6
10/31/2021 09:00	6.5	13.7	5.3	92.9	3,051,860.1	1,560.0	1.0	0.6
10/31/2021 10:00	6.6	13.8	5.5	83.4	2,748,772.1	1,385.0	1.0	0.6
10/31/2021 11:00	6.6	13.8	5.5	90.1	2,984,953.9	1,525.8	1.0	0.6
10/31/2021 12:00	6.5	13.7	5.3	92.9	3,077,487.9	1,573.1	1.0	0.6
10/31/2021 13:00	6.6	13.8	5.5	97.4	3,238,297.4	1,655.3	0.9	0.5
10/31/2021 14:00	6.6	13.8	5.5	91.6	3,052,030.2	1,537.8	0.9	0.5
10/31/2021 15:00	7.0	13.7	5.7	93.5	3,082,378.7	1,575.6	1.0	0.6
10/31/2021 16:00	7.8	13.2	6.0	112.9	3,398,079.3	1,960.3	1.1	0.8
10/31/2021 17:00	7.7	13.1	5.8	116.4	3,386,028.6	2,002.8	1.1	0.8
10/31/2021 18:00	7.6	13.1	5.7	116.6	3,400,906.3	2,011.6	1.1	0.8
10/31/2021 19:00	7.3	13.3	5.7	107.7	3,357,021.0	1,912.1	1.0	0.8
10/31/2021 20:00	6.2	13.7	5.1	96.1	3,260,208.2	1,666.5	0.9	0.5
10/31/2021 21:00	6.6	13.7	5.4	91.4	3,031,318.7	1,549.5	1.0	0.6
10/31/2021 22:00	7.6	13.2	5.8	111.9	3,362,963.9	1,964.6	1.1	0.8
10/31/2021 23:00	7.3	13.3	5.7	107.2	3,341,922.2	1,903.5	1.0	0.8
Average/Sum#:	6.9	13.5	5.5	100.1	3,209,337.0	1,729.4	1.0	0.7
Minimum:	6.2	13.1	5.1	83.4	2,748,772.1	1,385.0	0.9	0.5
Maximum:	7.8	13.8	6.0	116.6	3,415,202.1	2,011.6	1.1	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/01/2021 00:00	6.4	13.7	5.2	94.0	3,129,526.0	1,599.7	1.0	0.6
11/01/2021 01:00	6.7	13.6	5.4	97.4	3,197,895.3	1,658.0	1.0	0.7
11/01/2021 02:00	7.5	13.3	5.8	107.1	3,388,347.2	1,905.2	1.0	0.8
11/01/2021 03:00	7.4	13.2	5.7	111.0	3,353,720.3	1,959.2	1.1	0.8
11/01/2021 04:00	6.3	13.7	5.2	91.6	3,076,705.3	1,572.7	0.9	0.5
11/01/2021 05:00	6.6	13.6	5.3	95.8	3,200,402.6	1,659.3	1.0	0.7
11/01/2021 06:00	7.7	13.1	5.8	114.4	3,360,099.8	2,012.0	1.1	0.8
11/01/2021 07:00	8.0	13.0	6.0	122.7	3,359,817.5	2,060.9	1.2	1.0
11/01/2021 08:00	7.3	13.2	5.6	109.2	3,337,755.3	1,925.5	1.0	0.8
11/01/2021 09:00	6.4	13.7	5.2	91.5	3,026,427.9	1,547.0	1.0	0.6
11/01/2021 10:00	6.7	13.7	5.5	88.7	2,936,632.8	1,501.1	1.0	0.6
11/01/2021 11:00	7.8	13.1	5.9	114.8	3,366,586.1	1,991.3	1.1	0.8
11/01/2021 12:00	7.7	13.1	5.8	116.8	3,312,504.0	1,983.5	1.1	0.8
11/01/2021 13:00	6.5	13.7	5.3	98.1	3,287,792.3	1,680.6	0.9	0.5
11/01/2021 14:00	7.3	13.5	5.8	105.1	3,344,819.1	1,758.6	1.0	0.7
11/01/2021 15:00	7.7	13.1	5.8	115.2	3,347,481.8	1,980.0	1.1	0.8
11/01/2021 16:00	7.6	13.1	5.7	117.2	3,373,794.1	2,020.2	1.1	0.8
11/01/2021 17:00	7.8	12.9	5.8	129.2	3,352,256.4	2,129.7	1.3	1.1
11/01/2021 18:00	7.6	12.9	5.6	124.5	3,339,643.9	2,097.3	1.2	1.0
11/01/2021 19:00	7.6	12.9	5.6	127.9	3,345,173.2	2,125.2	1.2	1.1
11/01/2021 20:00	7.7	12.8	5.6	130.4	3,367,839.6	2,139.6	1.3	1.1
11/01/2021 21:00	7.6	12.9	5.6	128.6	3,349,738.0	2,128.1	1.3	1.1
11/01/2021 22:00	7.4	13.1	5.6	118.6	3,365,979.1	2,040.1	1.1	0.8
11/01/2021 23:00	6.9	13.3	5.4	105.2	3,367,361.2	1,893.4	1.0	0.8
Average/Sum#:	7.3	13.3	5.6	110.6	3,287,012.5	1,890.3	1.1	0.8
Minimum:	6.3	12.8	5.2	88.7	2,936,632.8	1,501.1	0.9	0.5
Maximum:	8.0	13.7	6.0	130.4	3,388,347.2	2,139.6	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/02/2021 00:00	6.4	13.7	5.2	90.8	3,000,995.7	1,534.0	1.0	0.6
11/02/2021 01:00	6.7	13.7	5.5	91.3	3,046,578.0	1,557.3	0.9	0.5
11/02/2021 02:00	7.4	13.3	5.7	107.7	3,421,604.6	1,923.9	1.0	0.8
11/02/2021 03:00	7.3	13.3	5.7	107.3	3,369,661.8	1,919.3	1.0	0.8
11/02/2021 04:00	6.4	13.6	5.2	95.2	3,130,967.0	1,623.3	1.0	0.6
11/02/2021 05:00	6.5	13.7	5.3	93.4	3,140,090.1	1,605.1	0.9	0.5
11/02/2021 06:00	7.6	13.2	5.8	113.4	3,399,722.8	2,010.9	1.1	0.8
11/02/2021 07:00	7.8	13.1	5.9	116.9	3,400,230.0	2,011.2	1.1	0.8
11/02/2021 08:00	6.9	13.3	5.4	106.2	3,398,128.8	1,910.7	1.0	0.8
11/02/2021 09:00	6.4	13.7	5.2	87.8	2,935,067.7	1,500.3	1.0	0.6
11/02/2021 10:00	6.4	13.7	5.2	93.5	3,140,090.1	1,605.1	0.9	0.5
11/02/2021 11:00	6.7	13.8	5.6	80.8	2,582,655.0	1,301.3	1.0	0.5
11/02/2021 12:00	6.6	13.8	5.5	88.2	2,970,261.6	1,496.6	0.9	0.4
11/02/2021 13:00	6.5	13.8	5.4	94.0	3,124,830.8	1,597.3	1.0	0.6
11/02/2021 14:00	6.5	13.8	5.4	93.4	3,143,126.7	1,583.7	0.9	0.5
11/02/2021 15:00	7.0	13.7	5.7	95.9	3,150,067.3	1,610.2	1.0	0.6
11/02/2021 16:00	7.9	13.2	6.1	116.5	3,340,226.5	2,000.1	1.1	0.8
11/02/2021 17:00	7.8	13.0	5.8	126.1	3,359,229.9	2,109.6	1.2	1.1
11/02/2021 18:00	7.7	13.0	5.8	125.1	3,352,701.2	2,105.5	1.2	1.1
11/02/2021 19:00	8.0	12.9	5.9	133.0	3,382,478.2	2,173.6	1.3	1.1
11/02/2021 20:00	7.9	13.0	5.9	126.5	3,362,255.3	2,111.5	1.2	1.1
11/02/2021 21:00	7.9	13.1	6.0	124.8	3,372,328.4	2,093.2	1.2	1.0
11/02/2021 22:00	7.9	13.1	6.0	123.4	3,385,575.7	2,076.7	1.2	1.0
11/02/2021 23:00	7.4	13.3	5.7	110.9	3,348,676.0	1,931.8	1.1	0.8
Average/Sum#:	7.2	13.4	5.6	105.9	3,219,064.6	1,808.0	1.1	0.7
Minimum:	6.4	12.9	5.2	80.8	2,582,655.0	1,301.3	0.9	0.4
Maximum:	8.0	13.8	6.1	133.0	3,421,604.6	2,173.6	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/03/2021 00:00	6.7	13.7	5.5	99.1	3,261,773.3	1,667.3	1.0	0.7
11/03/2021 01:00	6.9	13.7	5.7	95.8	3,111,679.4	1,613.3	1.0	0.6
11/03/2021 02:00	7.5	13.3	5.8	107.5	3,389,236.4	1,905.7	1.0	0.8
11/03/2021 03:00	6.8	13.4	5.3	104.2	3,391,014.9	1,906.7	1.0	0.8
11/03/2021 04:00	6.2	13.7	5.1	94.5	3,206,018.1	1,638.8	0.9	0.5
11/03/2021 05:00	6.4	13.7	5.2	100.6	3,394,243.7	1,759.8	0.9	0.5
11/03/2021 06:00	7.3	13.3	5.7	107.4	3,397,212.5	1,959.8	1.0	0.8
11/03/2021 07:00	7.2	13.4	5.7	108.3	3,414,255.9	1,944.7	1.0	0.8
11/03/2021 08:00	6.3	13.7	5.2	96.4	3,181,115.0	1,649.3	1.0	0.7
11/03/2021 09:00	6.4	13.7	5.2	97.0	3,250,622.2	1,661.6	0.9	0.5
11/03/2021 10:00	6.4	13.8	5.3	91.8	3,036,796.4	1,552.3	1.0	0.6
11/03/2021 11:00	6.4	13.8	5.3	96.9	3,251,796.0	1,662.2	0.9	0.5
11/03/2021 12:00	6.5	13.8	5.4	88.7	2,991,894.6	1,507.5	0.9	0.5
11/03/2021 13:00	6.5	13.8	5.4	97.1	3,297,534.2	1,661.5	0.9	0.5
11/03/2021 14:00	6.5	13.8	5.4	88.3	2,954,384.3	1,488.6	0.9	0.4
11/03/2021 15:00	6.8	13.7	5.6	92.0	3,055,772.7	1,562.0	1.0	0.6
11/03/2021 16:00	7.8	13.2	6.0	116.0	3,318,516.1	1,987.1	1.1	0.8
11/03/2021 17:00	8.1	13.0	6.0	129.7	3,308,404.8	2,126.0	1.3	1.1
11/03/2021 18:00	8.0	13.0	6.0	126.1	3,323,083.4	2,086.9	1.2	1.0
11/03/2021 19:00	8.1	12.9	6.0	131.6	3,328,168.1	2,138.7	1.3	1.1
11/03/2021 20:00	8.0	13.0	6.0	129.9	3,344,701.0	2,124.9	1.3	1.1
11/03/2021 21:00	7.9	13.0	5.9	125.2	3,353,800.9	2,081.7	1.2	1.0
11/03/2021 22:00	7.8	13.1	5.9	120.4	3,354,099.8	2,032.9	1.2	1.0
11/03/2021 23:00	7.6	13.2	5.8	109.3	3,304,819.7	1,906.5	1.1	0.8
Average/Sum#:	7.1	13.4	5.6	106.4	3,259,206.0	1,817.7	1.0	0.7
Minimum:	6.2	12.9	5.1	88.3	2,954,384.3	1,488.6	0.9	0.4
Maximum:	8.1	13.8	6.0	131.6	3,414,255.9	2,138.7	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/04/2021 00:00	6.7	13.7	5.5	87.4	2,842,925.0	1,453.2	1.0	0.6
11/04/2021 01:00	6.8	13.7	5.6	91.5	3,021,413.1	1,566.5	1.0	0.6
11/04/2021 02:00	7.5	13.2	5.7	107.7	3,358,250.0	1,912.8	1.0	0.8
11/04/2021 03:00	7.5	13.2	5.7	110.8	3,328,043.6	1,944.2	1.1	0.8
11/04/2021 04:00	6.4	13.7	5.2	97.0	3,211,010.9	1,664.8	1.0	0.7
11/04/2021 05:00	7.3	13.6	5.9	104.4	3,362,804.8	1,743.5	1.0	0.7
11/04/2021 06:00	7.7	13.2	5.9	112.8	3,328,546.6	1,968.8	1.1	0.8
11/04/2021 07:00	7.9	13.2	6.1	114.6	3,296,931.5	1,950.1	1.1	0.8
11/04/2021 08:00	6.4	13.8	5.3	92.3	3,063,989.2	1,566.2	1.0	0.6
11/04/2021 09:00	6.6	13.8	5.5	88.5	2,974,826.4	1,498.9	0.9	0.4
11/04/2021 10:00	6.6	13.8	5.5	88.0	2,959,544.4	1,491.2	0.9	0.4
11/04/2021 11:00	6.6	13.8	5.5	86.5	2,909,133.7	1,465.8	0.9	0.4
11/04/2021 12:00	6.5	13.9	5.5	80.2	2,709,872.5	1,365.4	0.9	0.4
11/04/2021 13:00	6.6	13.8	5.5	89.0	3,026,229.4	1,524.8	0.9	0.5
11/04/2021 14:00	6.6	13.8	5.5	95.1	3,240,574.1	1,632.8	0.9	0.5
11/04/2021 15:00	6.5	13.8	5.4	90.4	3,045,877.7	1,534.7	0.9	0.5
11/04/2021 16:00	7.8	13.3	6.1	112.9	3,343,107.3	1,953.0	1.1	0.8
11/04/2021 17:00	7.6	13.1	5.7	118.6	3,347,995.1	2,029.2	1.1	0.8
11/04/2021 18:00	7.5	13.2	5.7	115.6	3,338,723.4	1,999.2	1.1	0.8
11/04/2021 19:00	6.2	13.8	5.2	96.7	3,250,426.6	1,661.5	0.9	0.5
11/04/2021 20:00	6.5	13.7	5.3	93.7	3,141,655.2	1,605.9	0.9	0.5
11/04/2021 21:00	7.6	13.2	5.8	113.0	3,403,533.1	1,988.3	1.1	0.8
11/04/2021 22:00	6.8	13.5	5.4	98.3	3,019,854.7	1,653.9	1.0	0.7
11/04/2021 23:00	14.1	15.1	14.3	126.8	2,035,956.3	862.3	1.9	0.6
Average/Sum#:	7.3	13.6	6.0	100.5	3,106,717.7	1,668.2	1.0	0.6
Minimum:	6.2	13.1	5.2	80.2	2,035,956.3	862.3	0.9	0.4
Maximum:	14.1	15.1	14.3	126.8	3,403,533.1	2,029.2	1.9	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/05/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/05/2021 13:00	33.7	17.4	56.8	49.4	1,452,017.8	339.3	0.9	0.1
11/05/2021 14:00	20.9	14.4	19.0	174.5	2,766,458.1	1,252.5	2.0	1.0
11/05/2021 15:00	6.6	13.7	5.4	90.8	3,018,211.3	1,542.8	1.0	0.6
11/05/2021 16:00	7.5	13.1	5.7	116.0	3,386,319.3	2,027.7	1.1	0.8
11/05/2021 17:00	7.6	13.1	5.7	120.0	3,353,296.4	2,056.9	1.2	1.0
11/05/2021 18:00	7.6	13.1	5.7	118.2	3,404,689.6	2,038.7	1.1	0.8
11/05/2021 19:00	7.4	13.2	5.7	111.8	3,329,413.0	1,945.0	1.1	0.8
11/05/2021 20:00	6.4	13.7	5.2	96.3	3,216,973.5	1,644.4	1.0	0.7
11/05/2021 21:00	6.5	13.6	5.3	101.2	3,391,736.3	1,758.5	0.9	0.5
11/05/2021 22:00	7.4	13.2	5.7	111.8	3,426,507.8	1,976.7	1.0	0.8
11/05/2021 23:00	7.1	13.3	5.5	106.9	3,418,225.5	1,922.0	1.0	0.8
Average/Sum#:	10.8	13.8	11.4	108.8	3,105,804.4	1,682.2	1.1	0.7
Minimum:	6.4	13.1	5.2	49.4	1,452,017.8	339.3	0.9	0.1
Maximum:	33.7	17.4	56.8	174.5	3,426,507.8	2,056.9	2.0	1.0
%SI	54.17	54.17	54.17	54.17	54.17	54.17	54.17	54.17

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/06/2021 00:00	6.3	13.7	5.2	96.5	3,209,853.6	1,664.2	1.0	0.7
11/06/2021 01:00	6.6	13.7	5.4	92.3	3,075,531.5	1,572.1	0.9	0.5
11/06/2021 02:00	7.1	13.3	5.5	105.7	3,414,551.6	1,895.0	1.0	0.8
11/06/2021 03:00	6.9	13.3	5.4	104.9	3,406,309.8	1,915.3	1.0	0.8
11/06/2021 04:00	6.2	13.7	5.1	96.5	3,253,948.0	1,663.3	0.9	0.5
11/06/2021 05:00	6.4	13.7	5.2	93.1	3,115,636.1	1,592.6	0.9	0.5
11/06/2021 06:00	7.5	13.3	5.8	110.4	3,369,639.9	1,968.5	1.0	0.8
11/06/2021 07:00	7.6	13.3	5.9	111.4	3,357,547.7	1,912.4	1.1	0.8
11/06/2021 08:00	6.3	13.7	5.2	93.9	3,100,963.7	1,585.1	1.0	0.6
11/06/2021 09:00	6.5	13.7	5.3	93.7	3,098,224.9	1,583.7	1.0	0.6
11/06/2021 10:00	6.5	13.7	5.3	94.4	3,107,810.8	1,588.6	1.0	0.6
11/06/2021 11:00	6.5	13.7	5.3	91.5	2,982,801.9	1,524.7	1.0	0.6
11/06/2021 12:00	6.6	13.7	5.4	91.0	2,973,020.3	1,519.7	1.0	0.6
11/06/2021 13:00	6.6	13.7	5.4	92.8	3,032,883.7	1,550.3	1.0	0.6
11/06/2021 14:00	6.6	13.8	5.5	87.7	2,891,073.2	1,456.7	1.0	0.6
11/06/2021 15:00	6.8	13.7	5.6	92.3	3,057,337.8	1,562.8	1.0	0.6
11/06/2021 16:00	7.8	13.2	6.0	114.5	3,355,089.7	1,960.0	1.1	0.8
11/06/2021 17:00	7.6	13.1	5.7	120.6	3,321,180.2	2,037.2	1.2	1.0
11/06/2021 18:00	7.2	13.3	5.6	107.9	3,337,533.0	1,901.0	1.0	0.8
11/06/2021 19:00	6.3	13.7	5.2	96.5	3,213,647.8	1,642.7	1.0	0.7
11/06/2021 20:00	6.6	13.6	5.3	97.5	3,193,844.8	1,655.9	1.0	0.7
11/06/2021 21:00	7.5	13.3	5.8	110.7	3,417,942.8	1,946.8	1.0	0.8
11/06/2021 22:00	11.0	14.2	9.7	121.5	2,874,005.0	1,448.1	1.3	0.7
11/06/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	7.0	13.6	5.6	100.8	3,180,886.0	1,702.0	1.0	0.7
Minimum:	6.2	13.1	5.1	87.7	2,874,005.0	1,448.1	0.9	0.5
Maximum:	11.0	14.2	9.7	121.5	3,417,942.8	2,037.2	1.3	1.0
%SI	4.17	4.17	4.17	4.17	4.17	4.17	4.17	4.17

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/07/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/07/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/08/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/08/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/08/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/08/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/08/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/08/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/08/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/08/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/08/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/08/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/08/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/08/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/08/2021 12:00	29.6	17.7	54.6	0.0	1,333,063.8	282.3	0.0	0.0
11/08/2021 13:00	37.5	16.7	52.7	215.7	1,728,555.9	504.9	3.7	0.7
11/08/2021 14:00	37.3	15.0	37.3	223.4	2,236,726.5	931.0	3.1	1.1
11/08/2021 15:00	6.2	13.8	5.2	96.7	3,263,397.8	1,644.3	0.9	0.5
11/08/2021 16:00	7.9	13.2	6.1	119.3	1,315,368.2	2,007.5	3.1	2.4
11/08/2021 17:00	8.2	13.1	6.2	147.4	3,308,716.1	2,126.2	1.5	1.3
11/08/2021 18:00	7.7	13.3	6.0	115.0	3,378,541.1	1,973.7	1.1	0.8
11/08/2021 19:00	7.3	13.3	5.7	108.9	3,406,706.5	1,940.4	1.0	0.8
11/08/2021 20:00	8.0	13.1	6.1	126.4	3,390,050.3	2,104.2	1.2	1.1
11/08/2021 21:00	7.8	13.1	5.9	121.3	3,395,017.5	2,057.7	1.2	1.0
11/08/2021 22:00	6.8	13.4	5.3	103.8	3,388,064.0	1,880.3	1.0	0.8
11/08/2021 23:00	20.6	16.0	24.8	162.5	1,507,709.4	561.5	3.3	0.7
Average/Sum#:	15.4	14.3	18.0	128.4	2,757,868.1	1,501.2	1.6	0.8
Minimum:	6.2	13.1	5.2	0.0	1,333,063.8	282.3	0.0	0.0
Maximum:	37.5	17.7	54.6	223.4	3,406,706.5	2,126.2	3.7	1.3
%SI	50.00	50.00	50.00	50.00	54.17	50.00	54.17	54.17

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/09/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/09/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/09/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/09/2021 03:00	28.3	17.7	52.2	173.2	1,484,358.2	303.5	3.1	0.4
11/09/2021 04:00	29.7	15.2	30.7	209.1	2,255,068.5	905.7	2.8	1.0
11/09/2021 05:00	6.6	13.7	5.4	89.3	2,932,328.9	1,498.9	1.0	0.6
11/09/2021 06:00	6.4	13.7	5.2	90.0	3,009,603.5	1,538.4	0.9	0.5
11/09/2021 07:00	7.1	13.6	5.7	100.9	3,359,911.7	1,742.0	0.9	0.5
11/09/2021 08:00	6.8	13.7	5.6	92.1	3,011,364.2	1,539.3	1.0	0.6
11/09/2021 09:00	6.7	13.7	5.5	99.0	3,289,748.6	1,681.6	1.0	0.7
11/09/2021 10:00	7.2	13.8	6.0	90.7	2,917,265.2	1,491.2	1.0	0.6
11/09/2021 11:00	7.0	13.7	5.7	93.5	3,024,862.8	1,546.2	1.0	0.6
11/09/2021 12:00	6.9	13.7	5.7	91.3	2,968,129.5	1,517.2	1.0	0.6
11/09/2021 13:00	6.8	13.7	5.6	98.3	3,223,233.7	1,647.6	1.0	0.7
11/09/2021 14:00	6.7	13.7	5.5	95.2	3,123,657.0	1,596.7	1.0	0.6
11/09/2021 15:00	6.8	13.7	5.6	89.2	2,928,611.9	1,497.0	1.0	0.6
11/09/2021 16:00	6.8	13.7	5.6	92.5	3,009,212.3	1,538.2	1.0	0.6
11/09/2021 17:00	7.3	13.4	5.7	105.1	3,325,327.6	1,821.2	1.0	0.7
11/09/2021 18:00	7.7	13.1	5.8	121.2	3,391,607.7	2,080.4	1.2	1.0
11/09/2021 19:00	7.7	13.0	5.8	126.5	3,402,223.4	2,136.6	1.2	1.1
11/09/2021 20:00	7.4	13.1	5.6	120.0	3,345,797.2	2,052.3	1.2	1.0
11/09/2021 21:00	6.4	13.7	5.2	92.9	3,091,964.6	1,580.5	1.0	0.6
11/09/2021 22:00	6.7	13.6	5.4	98.7	3,264,823.5	1,692.7	1.0	0.7
11/09/2021 23:00	7.3	13.3	5.7	111.0	3,402,586.2	1,962.9	1.0	0.8
Average/Sum#:	9.1	13.8	9.0	108.6	3,036,270.8	1,589.1	1.2	0.7
Minimum:	6.4	13.0	5.2	89.2	1,484,358.2	303.5	0.9	0.4
Maximum:	29.7	17.7	52.2	209.1	3,402,586.2	2,136.6	3.1	1.1
%SI	12.50	12.50	12.50	12.50	12.50	12.50	12.50	12.50

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/10/2021 00:00	6.7	13.4	5.3	102.7	3,297,939.1	1,806.2	1.0	0.7
11/10/2021 01:00	7.0	13.5	5.6	103.9	3,347,672.0	1,760.1	1.0	0.7
11/10/2021 02:00	6.6	13.7	5.4	91.8	3,047,164.9	1,557.6	1.0	0.6
11/10/2021 03:00	7.0	13.3	5.4	105.4	3,427,829.3	1,927.4	1.0	0.8
11/10/2021 04:00	6.9	13.4	5.4	104.9	3,396,528.2	1,909.8	1.0	0.8
11/10/2021 05:00	6.4	13.7	5.2	97.5	3,281,923.4	1,677.6	0.9	0.5
11/10/2021 06:00	6.5	13.7	5.3	99.7	3,447,036.8	1,762.0	0.9	0.5
11/10/2021 07:00	7.6	13.3	5.9	109.0	3,470,690.5	1,951.5	1.0	0.8
11/10/2021 08:00	6.9	13.4	5.4	105.4	3,393,682.6	1,908.2	1.0	0.8
11/10/2021 09:00	6.3	13.8	5.2	89.4	3,033,771.2	1,528.6	0.9	0.5
11/10/2021 10:00	6.5	13.8	5.4	85.2	2,883,729.9	1,453.0	0.9	0.4
11/10/2021 11:00	6.5	13.8	5.4	81.7	2,783,305.4	1,402.4	0.9	0.4
11/10/2021 12:00	6.6	13.8	5.5	84.5	2,878,569.7	1,450.4	0.9	0.4
11/10/2021 13:00	6.8	13.8	5.7	81.1	2,631,081.0	1,325.7	1.0	0.5
11/10/2021 14:00	6.7	13.8	5.6	86.7	2,895,241.0	1,458.8	0.9	0.4
11/10/2021 15:00	7.1	13.7	5.8	93.2	3,050,295.0	1,559.2	1.0	0.6
11/10/2021 16:00	7.6	13.3	5.9	111.6	3,405,706.4	1,964.7	1.0	0.8
11/10/2021 17:00	7.4	13.2	5.7	112.4	3,391,208.3	1,981.1	1.1	0.8
11/10/2021 18:00	7.5	13.1	5.7	116.6	3,383,480.2	2,026.0	1.1	0.8
11/10/2021 19:00	7.4	13.1	5.6	116.2	3,375,631.1	2,021.3	1.1	0.8
11/10/2021 20:00	7.3	13.2	5.6	112.3	3,351,837.4	1,958.1	1.1	0.8
11/10/2021 21:00	6.4	13.7	5.2	97.2	3,269,794.2	1,671.4	0.9	0.5
11/10/2021 22:00	6.7	13.7	5.5	101.8	3,367,819.6	1,746.1	1.0	0.7
11/10/2021 23:00	7.6	13.2	5.8	113.1	3,398,226.6	1,985.2	1.1	0.8
Average/Sum#:	6.9	13.5	5.5	100.1	3,217,090.2	1,741.4	1.0	0.6
Minimum:	6.3	13.1	5.2	81.1	2,631,081.0	1,325.7	0.9	0.4
Maximum:	7.6	13.8	5.9	116.6	3,470,690.5	2,026.0	1.1	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/11/2021 00:00	7.2	13.3	5.6	107.6	3,357,898.8	1,912.6	1.0	0.8
11/11/2021 01:00	20.1	16.0	24.2	153.5	1,567,588.1	583.8	3.0	0.7
11/11/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/11/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/11/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/11/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/11/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/11/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/11/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/11/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/11/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/11/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/11/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/11/2021 13:00	34.0	17.5	59.0	31.2	1,430,827.6	323.9	0.5	0.1
11/11/2021 14:00	29.8	14.8	28.8	197.4	2,370,264.7	1,021.2	2.6	1.0
11/11/2021 15:00	6.6	13.8	5.5	95.6	3,184,889.9	1,628.0	0.9	0.5
11/11/2021 16:00	7.6	13.5	6.1	106.0	3,252,291.6	1,781.2	1.0	0.7
11/11/2021 17:00	7.9	13.1	6.0	121.5	3,339,765.2	2,048.6	1.2	1.0
11/11/2021 18:00	7.7	13.1	5.8	122.9	3,346,612.4	2,052.8	1.2	1.0
11/11/2021 19:00	7.6	13.1	5.7	120.5	3,355,252.8	2,058.1	1.2	1.0
11/11/2021 20:00	7.6	13.1	5.7	119.9	3,316,778.5	2,034.5	1.2	1.0
11/11/2021 21:00	6.5	13.7	5.3	97.3	3,248,274.6	1,660.4	1.0	0.7
11/11/2021 22:00	6.9	13.6	5.6	102.2	3,366,276.6	1,745.3	1.0	0.7
11/11/2021 23:00	7.5	13.2	5.7	110.2	3,385,251.7	1,952.9	1.0	0.8
Average/Sum#:	12.1	14.0	13.0	114.3	2,963,228.7	1,600.3	1.3	0.8
Minimum:	6.5	13.1	5.3	31.2	1,430,827.6	323.9	0.5	0.1
Maximum:	34.0	17.5	59.0	197.4	3,385,251.7	2,058.1	3.0	1.0
%SI	45.83	45.83	45.83	45.83	45.83	45.83	45.83	45.83

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/12/2021 00:00	6.9	13.3	5.4	105.1	3,375,008.6	1,897.7	1.0	0.8
11/12/2021 01:00	6.4	13.7	5.2	91.1	3,036,013.9	1,551.9	1.0	0.6
11/12/2021 02:00	6.6	13.7	5.4	89.1	2,974,781.0	1,520.6	0.9	0.5
11/12/2021 03:00	6.6	13.7	5.4	90.0	2,986,127.7	1,526.4	1.0	0.6
11/12/2021 04:00	6.7	13.7	5.5	91.6	3,031,710.0	1,549.7	1.0	0.6
11/12/2021 05:00	7.5	13.2	5.7	112.6	3,411,236.1	1,992.8	1.1	0.8
11/12/2021 06:00	7.4	13.1	5.6	113.8	3,418,827.1	2,022.2	1.1	0.8
11/12/2021 07:00	6.7	13.6	5.4	99.4	3,098,838.5	1,651.9	1.0	0.7
11/12/2021 08:00	14.3	15.1	14.5	122.0	2,056,497.7	871.0	1.8	0.6
11/12/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/12/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/12/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/12/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/12/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/12/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/12/2021 15:00	28.8	17.6	51.5	85.9	1,490,783.7	315.7	1.4	0.2
11/12/2021 16:00	30.8	15.5	33.7	220.1	2,199,769.6	835.3	3.0	1.0
11/12/2021 17:00	6.5	13.8	5.4	87.5	2,763,889.7	1,412.8	1.0	0.6
11/12/2021 18:00	6.7	13.7	5.5	91.2	3,058,902.8	1,563.6	0.9	0.5
11/12/2021 19:00	7.6	13.1	5.7	113.6	3,383,661.7	2,001.4	1.1	0.8
11/12/2021 20:00	7.3	13.2	5.6	109.7	3,363,583.6	1,940.4	1.0	0.8
11/12/2021 21:00	6.5	13.7	5.3	95.0	3,140,285.7	1,605.2	1.0	0.6
11/12/2021 22:00	6.7	13.7	5.5	97.4	3,215,447.0	1,667.1	1.0	0.7
11/12/2021 23:00	7.5	13.2	5.7	112.3	3,395,316.6	1,983.5	1.1	0.8
Average/Sum#:	9.9	13.9	10.1	107.1	2,966,704.5	1,550.5	1.2	0.7
Minimum:	6.4	13.1	5.2	85.9	1,490,783.7	315.7	0.9	0.2
Maximum:	30.8	17.6	51.5	220.1	3,418,827.1	2,022.2	3.0	1.0
%SI	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/13/2021 00:00	12.7	14.7	12.1	127.2	2,546,497.3	1,208.7	1.5	0.7
11/13/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/13/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/13/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/13/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/13/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/13/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/13/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/13/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/13/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/13/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/13/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/13/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/13/2021 13:00	32.0	17.4	53.9	77.3	1,487,537.2	347.6	1.4	0.2
11/13/2021 14:00	24.3	14.8	23.5	188.4	2,454,054.9	1,057.3	2.3	1.0
11/13/2021 15:00	6.5	13.7	5.3	97.2	3,270,576.7	1,671.8	0.9	0.5
11/13/2021 16:00	7.0	13.6	5.7	102.5	3,345,060.2	1,734.3	1.0	0.7
11/13/2021 17:00	7.7	13.2	5.9	113.2	3,391,379.5	1,981.2	1.1	0.8
11/13/2021 18:00	7.5	13.2	5.7	112.7	3,321,025.3	1,940.1	1.1	0.8
11/13/2021 19:00	6.5	13.7	5.3	98.4	3,285,640.4	1,679.5	1.0	0.7
11/13/2021 20:00	6.7	13.6	5.4	102.6	3,400,415.8	1,763.0	1.0	0.7
11/13/2021 21:00	7.6	13.2	5.8	112.6	3,388,127.1	1,979.3	1.1	0.8
11/13/2021 22:00	11.1	14.1	9.6	125.3	2,817,349.6	1,460.7	1.4	0.7
11/13/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	11.8	14.1	12.6	114.3	2,973,424.0	1,529.4	1.3	0.7
Minimum:	6.5	13.2	5.3	77.3	1,487,537.2	347.6	0.9	0.2
Maximum:	32.0	17.4	53.9	188.4	3,400,415.8	1,981.2	2.3	1.0
%SI	54.17	54.17	54.17	54.17	54.17	54.17	54.17	54.17

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/14/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/14/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/14/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/14/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/14/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/14/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/14/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/14/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/14/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/14/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/14/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/14/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/14/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/14/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/14/2021 14:00	21.7	18.0	44.1	0.0	1,292,022.1	217.0	-0.3	0.0
11/14/2021 15:00	36.0	15.9	42.5	146.8	2,049,571.8	718.4	2.2	0.6
11/14/2021 16:00	6.7	13.8	5.6	86.2	2,566,380.7	1,293.1	1.1	0.5
11/14/2021 17:00	6.8	13.7	5.6	91.8	3,059,294.1	1,563.8	0.9	0.5
11/14/2021 18:00	7.6	13.1	5.7	114.2	3,387,719.2	2,003.8	1.1	0.8
11/14/2021 19:00	7.2	13.2	5.5	108.0	3,345,729.1	1,930.1	1.0	0.8
11/14/2021 20:00	6.6	13.6	5.3	99.9	3,240,210.3	1,703.6	1.0	0.7
11/14/2021 21:00	6.7	13.7	5.5	92.1	3,046,969.3	1,557.5	1.0	0.6
11/14/2021 22:00	7.5	13.2	5.7	113.6	3,379,266.0	1,998.8	1.1	0.8
11/14/2021 23:00	6.7	13.5	5.3	97.4	3,019,395.7	1,631.6	1.0	0.7
Average/Sum#:	11.4	14.2	13.1	95.0	2,838,655.8	1,461.8	1.0	0.6
Minimum:	6.6	13.1	5.3	0.0	1,292,022.1	217.0	-0.3	0.0
Maximum:	36.0	18.0	44.1	146.8	3,387,719.2	2,003.8	2.2	0.8
%SI	58.33	58.33	58.33	58.33	58.33	58.33	58.33	58.33

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/15/2021 00:00	13.9	15.0	13.9	122.0	2,066,917.9	905.6	1.8	0.6
11/15/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/15/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/15/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/15/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/15/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/15/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/15/2021 07:00	30.5	17.6	54.5	67.9	1,532,338.7	324.5	1.0	0.1
11/15/2021 08:00	34.1	15.6	38.0	219.1	2,129,320.7	793.0	3.1	1.0
11/15/2021 09:00	6.5	13.8	5.4	87.5	2,732,784.2	1,396.9	1.0	0.6
11/15/2021 10:00	6.7	13.7	5.5	93.8	3,137,351.3	1,603.7	0.9	0.5
11/15/2021 11:00	7.2	13.3	5.6	106.7	3,432,097.6	1,929.8	1.0	0.8
11/15/2021 12:00	7.0	13.3	5.4	105.9	3,432,631.2	1,930.1	1.0	0.8
11/15/2021 13:00	6.6	13.7	5.4	90.2	2,895,271.8	1,501.1	1.0	0.6
11/15/2021 14:00	6.7	13.7	5.5	92.2	3,068,684.4	1,568.6	1.0	0.6
11/15/2021 15:00	7.3	13.3	5.7	110.7	3,358,425.5	1,912.9	1.1	0.8
11/15/2021 16:00	7.2	13.2	5.5	109.8	3,392,878.9	1,957.3	1.0	0.8
11/15/2021 17:00	6.9	13.3	5.4	105.5	3,413,068.0	1,919.1	1.0	0.8
11/15/2021 18:00	7.0	13.3	5.4	106.1	3,431,919.8	1,929.7	1.0	0.8
11/15/2021 19:00	7.5	13.1	5.7	116.6	3,421,532.2	2,023.8	1.1	0.8
11/15/2021 20:00	6.9	13.3	5.4	104.9	3,410,400.3	1,917.6	1.0	0.8
11/15/2021 21:00	7.0	13.3	5.4	105.1	3,403,642.1	1,913.8	1.0	0.8
11/15/2021 22:00	7.0	13.3	5.4	105.0	3,401,152.2	1,912.4	1.0	0.8
11/15/2021 23:00	7.0	13.3	5.4	104.9	3,366,649.8	1,893.0	1.0	0.8
Average/Sum#:	10.2	13.8	10.5	108.6	3,057,059.3	1,629.6	1.2	0.7
Minimum:	6.5	13.1	5.4	67.9	1,532,338.7	324.5	0.9	0.1
Maximum:	34.1	17.6	54.5	219.1	3,432,631.2	2,023.8	3.1	1.0
%SI	25.00	25.00	25.00	25.00	25.00	25.00	25.00	25.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/16/2021 00:00	19.1	16.0	23.0	154.4	1,574,048.0	597.7	3.1	0.7
11/16/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/16/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/16/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/16/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/16/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/16/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/16/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/16/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/16/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/16/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/16/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/16/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/16/2021 13:00	21.1	18.1	44.5	0.0	1,260,522.5	193.3	-0.4	0.0
11/16/2021 14:00	44.0	16.5	59.0	160.9	1,749,276.6	536.5	2.7	0.5
11/16/2021 15:00	15.1	14.1	13.1	141.9	2,799,850.4	1,349.4	1.6	0.8
11/16/2021 16:00	6.8	13.8	5.7	89.1	2,933,743.7	1,478.2	1.0	0.6
11/16/2021 17:00	7.5	13.3	5.8	111.2	3,399,729.4	1,911.6	1.0	0.8
11/16/2021 18:00	7.6	13.2	5.8	115.8	3,432,119.9	2,005.0	1.1	0.8
11/16/2021 19:00	7.1	13.3	5.5	107.8	3,452,016.5	1,941.0	1.0	0.8
11/16/2021 20:00	7.9	13.0	5.9	124.5	3,410,029.7	2,091.7	1.2	1.0
11/16/2021 21:00	8.0	13.0	6.0	128.4	3,410,672.3	2,117.0	1.2	1.1
11/16/2021 22:00	7.8	13.2	6.0	120.6	3,384,983.3	2,026.9	1.1	0.8
11/16/2021 23:00	8.0	13.1	6.1	125.9	3,386,879.9	2,077.5	1.2	1.0
Average/Sum#:	13.3	14.2	15.5	115.0	2,849,489.4	1,527.2	1.3	0.7
Minimum:	6.8	13.0	5.5	0.0	1,260,522.5	193.3	-0.4	0.0
Maximum:	44.0	18.1	59.0	160.9	3,452,016.5	2,117.0	3.1	1.1
%SI	50.00	50.00	50.00	50.00	50.00	50.00	50.00	50.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/17/2021 00:00	7.5	13.3	5.8	111.6	3,413,729.2	1,944.4	1.0	0.8
11/17/2021 01:00	7.4	13.4	5.8	107.7	3,438,336.3	1,908.2	1.0	0.8
11/17/2021 02:00	7.5	13.4	5.9	107.6	3,440,859.0	1,909.6	1.0	0.8
11/17/2021 03:00	7.4	13.4	5.8	107.4	3,442,480.6	1,910.5	1.0	0.8
11/17/2021 04:00	7.4	13.3	5.7	111.4	3,444,980.2	1,962.2	1.0	0.8
11/17/2021 05:00	7.2	13.3	5.6	112.0	3,482,200.4	1,983.4	1.0	0.8
11/17/2021 06:00	7.7	13.0	5.8	127.2	3,428,716.4	2,128.2	1.2	1.1
11/17/2021 07:00	7.6	13.1	5.7	122.5	3,430,742.1	2,054.3	1.2	1.0
11/17/2021 08:00	6.6	13.4	5.2	103.7	3,458,156.9	1,919.2	1.0	0.8
11/17/2021 09:00	7.0	13.4	5.5	105.4	3,437,255.2	1,907.6	1.0	0.8
11/17/2021 10:00	6.7	13.8	5.6	90.3	2,974,781.0	1,520.6	1.0	0.6
11/17/2021 11:00	7.2	13.5	5.7	106.5	3,405,980.5	1,840.5	1.0	0.7
11/17/2021 12:00	7.0	13.4	5.5	105.9	3,462,301.3	1,921.5	1.0	0.8
11/17/2021 13:00	6.8	13.7	5.6	90.5	2,820,443.6	1,482.9	1.0	0.6
11/17/2021 14:00	6.9	13.8	5.7	86.5	2,846,815.0	1,434.4	1.0	0.6
11/17/2021 15:00	7.7	13.3	6.0	112.2	3,351,402.8	1,908.9	1.1	0.8
11/17/2021 16:00	7.7	13.1	5.8	117.5	3,392,331.4	2,031.3	1.1	0.8
11/17/2021 17:00	7.8	13.0	5.8	125.1	3,389,083.7	2,103.6	1.2	1.1
11/17/2021 18:00	7.7	13.0	5.8	124.6	3,375,711.7	2,095.3	1.2	1.0
11/17/2021 19:00	7.8	13.0	5.8	128.5	3,380,089.7	2,122.7	1.2	1.1
11/17/2021 20:00	7.7	13.0	5.8	128.5	3,385,503.7	2,126.1	1.2	1.1
11/17/2021 21:00	7.3	13.1	5.5	119.4	3,409,866.7	2,041.8	1.1	0.8
11/17/2021 22:00	6.6	13.4	5.2	103.5	3,452,030.6	1,915.8	1.0	0.8
11/17/2021 23:00	6.6	13.4	5.2	103.1	3,440,318.4	1,909.3	1.0	0.8
Average/Sum#:	7.3	13.3	5.7	110.8	3,354,338.2	1,920.1	1.1	0.8
Minimum:	6.6	13.0	5.2	86.5	2,820,443.6	1,434.4	1.0	0.6
Maximum:	7.8	13.8	6.0	128.5	3,482,200.4	2,128.2	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/18/2021 00:00	6.5	13.4	5.1	103.0	3,437,976.0	1,908.0	1.0	0.8
11/18/2021 01:00	6.6	13.4	5.2	103.4	3,439,597.6	1,908.9	1.0	0.8
11/18/2021 02:00	6.6	13.4	5.2	103.7	3,444,823.1	1,911.8	1.0	0.8
11/18/2021 03:00	6.5	13.4	5.1	103.3	3,446,264.6	1,912.6	1.0	0.8
11/18/2021 04:00	6.5	13.4	5.1	103.2	3,446,444.8	1,912.7	1.0	0.8
11/18/2021 05:00	7.1	13.3	5.5	111.4	3,455,629.8	1,993.5	1.0	0.8
11/18/2021 06:00	7.5	13.1	5.7	122.1	3,419,159.2	2,097.3	1.2	1.0
11/18/2021 07:00	7.7	13.1	5.8	121.3	3,440,595.3	2,060.2	1.1	0.8
11/18/2021 08:00	7.2	13.2	5.5	112.2	3,430,148.1	1,978.8	1.1	0.8
11/18/2021 09:00	6.7	13.4	5.3	104.3	3,407,344.1	1,891.0	1.0	0.8
11/18/2021 10:00	6.4	13.7	5.2	94.4	3,200,344.8	1,635.9	0.9	0.5
11/18/2021 11:00	7.2	13.3	5.6	106.6	3,420,537.6	1,923.3	1.0	0.8
11/18/2021 12:00	7.1	13.3	5.5	106.3	3,414,135.1	1,919.7	1.0	0.8
11/18/2021 13:00	6.6	13.7	5.4	90.3	2,889,099.7	1,497.9	1.0	0.6
11/18/2021 14:00	6.7	13.7	5.5	87.8	2,885,377.2	1,474.9	1.0	0.6
11/18/2021 15:00	7.1	13.5	5.7	105.1	3,376,850.5	1,800.1	1.0	0.7
11/18/2021 16:00	7.8	13.0	5.8	121.0	3,403,927.0	2,063.1	1.1	0.8
11/18/2021 17:00	7.7	13.0	5.8	124.8	3,376,517.2	2,095.8	1.2	1.0
11/18/2021 18:00	7.8	12.9	5.8	132.3	3,346,219.6	2,150.3	1.3	1.1
11/18/2021 19:00	7.5	13.0	5.6	124.6	3,365,722.9	2,089.1	1.2	1.0
11/18/2021 20:00	7.4	13.1	5.6	118.6	3,400,681.6	2,036.3	1.1	0.8
11/18/2021 21:00	7.1	13.3	5.5	107.4	3,390,729.9	1,931.3	1.0	0.8
11/18/2021 22:00	6.8	13.3	5.3	104.4	3,396,706.0	1,909.9	1.0	0.8
11/18/2021 23:00	6.9	13.3	5.4	104.8	3,394,038.3	1,908.4	1.0	0.8
Average/Sum#:	7.0	13.3	5.5	109.0	3,359,536.3	1,917.1	1.1	0.8
Minimum:	6.4	12.9	5.1	87.8	2,885,377.2	1,474.9	0.9	0.5
Maximum:	7.8	13.7	5.8	132.3	3,455,629.8	2,150.3	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/19/2021 00:00	7.0	13.3	5.4	105.2	3,392,971.2	1,907.8	1.0	0.8
11/19/2021 01:00	6.9	13.3	5.4	104.9	3,339,439.2	1,877.7	1.0	0.8
11/19/2021 02:00	6.5	13.7	5.3	94.0	3,140,872.6	1,605.5	1.0	0.6
11/19/2021 03:00	7.2	13.3	5.6	106.6	3,397,950.9	1,910.6	1.0	0.8
11/19/2021 04:00	7.6	13.1	5.7	113.5	3,432,574.9	1,980.2	1.1	0.8
11/19/2021 05:00	7.6	13.1	5.7	117.4	3,409,359.5	2,016.6	1.1	0.8
11/19/2021 06:00	7.7	13.0	5.8	120.4	3,426,400.0	2,051.7	1.1	0.8
11/19/2021 07:00	7.9	13.0	5.9	120.7	3,391,162.4	2,030.6	1.1	0.8
11/19/2021 08:00	7.3	13.2	5.6	108.4	3,436,188.1	1,932.1	1.0	0.8
11/19/2021 09:00	6.9	13.3	5.4	105.2	3,433,651.5	1,905.6	1.0	0.8
11/19/2021 10:00	7.1	13.3	5.5	107.3	3,445,183.5	1,912.0	1.0	0.8
11/19/2021 11:00	7.4	13.2	5.7	109.5	3,433,164.7	1,930.4	1.0	0.8
11/19/2021 12:00	7.4	13.2	5.7	109.1	3,424,272.3	1,925.4	1.0	0.8
11/19/2021 13:00	7.8	13.1	5.9	121.2	3,431,507.0	2,029.7	1.1	0.8
11/19/2021 14:00	7.8	13.1	5.9	121.7	3,388,156.3	2,028.8	1.2	1.0
11/19/2021 15:00	7.5	13.2	5.7	113.9	3,409,000.0	1,966.6	1.1	0.8
11/19/2021 16:00	7.5	13.1	5.7	115.7	3,406,100.8	1,989.8	1.1	0.8
11/19/2021 17:00	7.5	13.1	5.7	116.1	3,424,245.7	2,000.4	1.1	0.8
11/19/2021 18:00	7.5	13.1	5.7	116.9	3,437,084.0	2,007.9	1.1	0.8
11/19/2021 19:00	7.1	13.3	5.5	107.5	3,382,478.2	1,901.9	1.0	0.8
11/19/2021 20:00	6.3	13.7	5.2	96.2	3,224,407.5	1,648.2	0.9	0.5
11/19/2021 21:00	6.7	13.6	5.4	100.8	3,332,716.0	1,727.9	1.0	0.7
11/19/2021 22:00	7.6	13.2	5.8	110.0	3,414,255.9	1,944.7	1.0	0.8
11/19/2021 23:00	7.5	13.3	5.8	108.9	3,395,119.1	1,933.8	1.0	0.8
Average/Sum#:	7.3	13.2	5.6	110.5	3,389,510.9	1,923.6	1.0	0.8
Minimum:	6.3	13.0	5.2	94.0	3,140,872.6	1,605.5	0.9	0.5
Maximum:	7.9	13.7	5.9	121.7	3,445,183.5	2,051.7	1.2	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/20/2021 00:00	7.0	13.3	5.4	105.8	3,376,431.4	1,898.5	1.0	0.8
11/20/2021 01:00	6.4	13.8	5.3	91.3	3,074,655.4	1,549.2	0.9	0.5
11/20/2021 02:00	6.5	13.8	5.4	89.2	3,030,595.7	1,527.0	0.9	0.5
11/20/2021 03:00	6.5	13.8	5.4	89.6	3,028,015.6	1,525.7	0.9	0.5
11/20/2021 04:00	6.8	13.7	5.6	97.6	3,254,143.6	1,663.4	0.9	0.5
11/20/2021 05:00	7.8	13.2	6.0	114.5	3,412,605.6	1,993.6	1.1	0.8
11/20/2021 06:00	7.4	13.3	5.7	110.9	3,434,797.3	1,956.4	1.0	0.8
11/20/2021 07:00	6.5	13.8	5.4	96.1	3,199,888.3	1,612.3	1.0	0.6
11/20/2021 08:00	6.5	13.8	5.4	95.4	3,229,459.9	1,627.2	0.9	0.5
11/20/2021 09:00	6.5	13.8	5.4	85.6	2,880,554.4	1,451.4	0.9	0.4
11/20/2021 10:00	6.6	13.8	5.5	87.9	2,972,444.8	1,497.7	0.9	0.4
11/20/2021 11:00	6.5	13.8	5.4	92.0	3,101,647.0	1,562.8	0.9	0.5
11/20/2021 12:00	6.5	13.9	5.5	84.4	2,835,899.3	1,428.9	0.9	0.4
11/20/2021 13:00	6.6	13.9	5.6	86.0	2,909,530.6	1,466.0	0.9	0.4
11/20/2021 14:00	6.6	13.9	5.6	87.2	2,942,674.7	1,482.7	0.9	0.4
11/20/2021 15:00	7.3	13.7	6.0	94.7	3,103,702.6	1,586.5	1.0	0.6
11/20/2021 16:00	8.5	13.3	6.6	117.2	3,379,568.2	1,974.3	1.1	0.8
11/20/2021 17:00	8.3	13.2	6.4	122.2	3,400,906.3	2,011.6	1.2	1.0
11/20/2021 18:00	8.0	13.3	6.2	114.5	3,353,509.6	1,910.1	1.1	0.8
11/20/2021 19:00	6.3	13.8	5.2	96.9	3,335,044.5	1,680.4	0.9	0.5
11/20/2021 20:00	7.8	13.6	6.3	106.6	3,386,528.6	1,755.8	1.0	0.7
11/20/2021 21:00	8.3	13.3	6.4	117.3	3,398,226.6	1,985.2	1.1	0.8
11/20/2021 22:00	8.3	13.1	6.3	129.4	3,398,317.4	2,059.7	1.2	1.0
11/20/2021 23:00	7.3	13.4	5.7	108.1	3,304,276.9	1,833.8	1.1	0.7
Average/Sum#:	7.1	13.6	5.7	100.9	3,197,642.7	1,710.0	1.0	0.6
Minimum:	6.3	13.1	5.2	84.4	2,835,899.3	1,428.9	0.9	0.4
Maximum:	8.5	13.9	6.6	129.4	3,434,797.3	2,059.7	1.2	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/21/2021 00:00	6.6	13.7	5.4	99.8	3,351,177.1	1,713.0	0.9	0.5
11/21/2021 01:00	7.7	13.4	6.1	108.5	3,441,039.1	1,909.7	1.0	0.8
11/21/2021 02:00	10.2	14.2	9.0	111.6	2,869,659.5	1,404.0	1.2	0.7
11/21/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/21/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/21/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/21/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/21/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/21/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/21/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/21/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/21/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/21/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/21/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/21/2021 14:00	35.4	17.5	61.4	10.8	1,388,596.3	304.2	0.1	0.0
11/21/2021 15:00	33.9	15.9	40.0	216.8	2,092,936.9	733.6	3.2	0.9
11/21/2021 16:00	6.1	13.9	5.1	82.1	2,624,461.6	1,303.2	1.0	0.5
11/21/2021 17:00	7.2	13.8	6.0	92.6	3,074,060.0	1,548.9	0.9	0.5
11/21/2021 18:00	8.5	13.2	6.5	118.7	3,398,911.3	1,985.6	1.1	0.8
11/21/2021 19:00	8.2	13.2	6.3	124.6	3,336,385.4	1,997.8	1.2	1.0
11/21/2021 20:00	6.2	13.8	5.2	96.5	3,306,068.3	1,665.8	0.9	0.5
11/21/2021 21:00	8.0	13.7	6.6	107.3	3,422,974.1	1,749.7	1.0	0.7
11/21/2021 22:00	7.3	13.3	5.7	109.3	3,465,177.2	1,948.4	1.0	0.8
11/21/2021 23:00	6.6	13.6	5.3	96.8	3,130,166.5	1,668.6	1.0	0.7
Average/Sum#:	11.7	14.1	13.0	105.8	2,992,431.8	1,533.3	1.1	0.6
Minimum:	6.1	13.2	5.1	10.8	1,388,596.3	304.2	0.1	0.0
Maximum:	35.4	17.5	61.4	216.8	3,465,177.2	1,997.8	3.2	1.0
%SI	45.83	45.83	45.83	45.83	45.83	45.83	45.83	45.83

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/22/2021 00:00	13.5	15.0	13.5	114.3	2,142,336.8	923.0	1.6	0.6
11/22/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/22/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/22/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/22/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/22/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/22/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/22/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/22/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/22/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/22/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/22/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/22/2021 12:00	36.7	17.4	61.9	64.4	1,614,636.9	377.3	1.0	0.2
11/22/2021 13:00	25.4	14.5	23.4	177.5	2,535,643.9	1,148.0	2.2	0.9
11/22/2021 14:00	6.3	13.8	5.2	96.2	3,308,251.5	1,666.9	0.9	0.5
11/22/2021 15:00	6.8	13.7	5.6	100.2	3,351,568.4	1,713.2	0.9	0.5
11/22/2021 16:00	7.9	13.3	6.1	110.7	3,388,169.3	1,905.1	1.0	0.8
11/22/2021 17:00	7.9	13.1	6.0	117.9	3,390,593.3	2,005.5	1.1	0.8
11/22/2021 18:00	8.1	13.0	6.0	127.6	3,385,575.7	2,076.7	1.2	1.0
11/22/2021 19:00	8.0	13.0	6.0	126.7	3,372,533.6	2,068.7	1.2	1.0
11/22/2021 20:00	7.7	13.1	5.8	124.8	3,345,520.3	2,027.7	1.2	1.0
11/22/2021 21:00	6.1	13.8	5.1	93.4	3,149,676.1	1,610.0	0.9	0.5
11/22/2021 22:00	6.5	13.6	5.3	102.2	3,418,160.4	1,772.2	1.0	0.7
11/22/2021 23:00	7.6	13.2	5.8	113.6	3,401,650.2	1,987.2	1.1	0.8
Average/Sum#:	11.4	13.9	12.0	113.0	3,061,870.5	1,637.0	1.2	0.7
Minimum:	6.1	13.0	5.1	64.4	1,614,636.9	377.3	0.9	0.2
Maximum:	36.7	17.4	61.9	177.5	3,418,160.4	2,076.7	2.2	1.0
%SI	45.83	45.83	45.83	45.83	45.83	45.83	45.83	45.83

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/23/2021 00:00	7.0	13.4	5.5	106.3	3,406,843.3	1,915.6	1.0	0.8
11/23/2021 01:00	6.3	13.8	5.2	87.0	2,927,988.1	1,475.3	0.9	0.4
11/23/2021 02:00	6.5	13.7	5.3	96.4	3,274,880.6	1,674.0	0.9	0.5
11/23/2021 03:00	6.8	13.4	5.3	104.7	3,462,481.4	1,921.6	1.0	0.8
11/23/2021 04:00	6.7	13.4	5.3	103.7	3,416,353.5	1,896.0	1.0	0.8
11/23/2021 05:00	6.3	13.7	5.2	96.1	3,225,385.7	1,648.7	0.9	0.5
11/23/2021 06:00	6.5	13.7	5.3	91.0	3,078,504.6	1,596.1	0.9	0.5
11/23/2021 07:00	7.7	13.2	5.9	110.4	3,428,125.7	1,952.6	1.0	0.8
11/23/2021 08:00	7.4	13.2	5.7	110.7	3,374,331.0	1,946.6	1.1	0.8
11/23/2021 09:00	6.3	13.8	5.2	93.4	3,117,983.7	1,593.8	1.0	0.6
11/23/2021 10:00	6.4	13.8	5.3	90.7	3,020,167.7	1,543.8	1.0	0.6
11/23/2021 11:00	6.5	13.8	5.4	87.0	2,960,536.7	1,491.7	0.9	0.4
11/23/2021 12:00	6.5	13.8	5.4	81.0	2,725,948.4	1,373.5	0.9	0.4
11/23/2021 13:00	6.5	13.8	5.4	89.3	3,035,358.9	1,529.4	0.9	0.5
11/23/2021 14:00	6.4	13.8	5.3	94.9	3,227,673.7	1,626.3	0.9	0.5
11/23/2021 15:00	7.1	13.7	5.8	94.8	3,103,702.6	1,586.5	1.0	0.6
11/23/2021 16:00	8.1	13.2	6.2	117.2	3,370,981.8	1,993.9	1.1	0.8
11/23/2021 17:00	8.0	13.2	6.1	119.0	3,401,244.4	2,011.8	1.1	0.8
11/23/2021 18:00	7.7	13.2	5.9	117.9	3,412,402.7	2,018.4	1.1	0.8
11/23/2021 19:00	7.4	13.3	5.7	108.0	3,369,495.4	1,894.6	1.0	0.8
11/23/2021 20:00	6.1	13.8	5.1	96.2	3,327,899.7	1,676.8	0.9	0.5
11/23/2021 21:00	6.7	13.8	5.6	91.1	3,068,701.4	1,546.2	0.9	0.5
11/23/2021 22:00	7.9	13.2	6.1	115.6	3,455,283.1	1,993.3	1.1	0.8
11/23/2021 23:00	7.4	13.3	5.7	108.4	3,467,706.9	1,924.5	1.0	0.8
Average/Sum#:	6.9	13.5	5.5	100.5	3,235,832.5	1,743.0	1.0	0.6
Minimum:	6.1	13.2	5.1	81.0	2,725,948.4	1,373.5	0.9	0.4
Maximum:	8.1	13.8	6.2	119.0	3,467,706.9	2,018.4	1.1	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/24/2021 00:00	7.0	13.4	5.5	105.5	3,477,607.6	1,904.6	1.0	0.8
11/24/2021 01:00	6.2	13.8	5.2	86.4	2,946,247.1	1,484.5	0.9	0.4
11/24/2021 02:00	6.8	13.8	5.7	92.4	3,076,118.4	1,572.4	0.9	0.5
11/24/2021 03:00	7.3	13.4	5.7	107.4	3,464,823.9	1,922.9	1.0	0.8
11/24/2021 04:00	7.3	13.4	5.7	108.3	3,415,557.8	1,920.5	1.0	0.8
11/24/2021 05:00	6.2	13.8	5.2	95.2	3,264,787.1	1,645.0	0.9	0.5
11/24/2021 06:00	6.8	13.8	5.7	91.6	3,036,264.6	1,574.2	1.0	0.6
11/24/2021 07:00	8.0	13.3	6.2	111.3	3,433,217.2	1,955.5	1.0	0.8
11/24/2021 08:00	7.3	13.4	5.7	108.8	3,403,108.5	1,913.5	1.0	0.8
11/24/2021 09:00	6.2	13.8	5.2	94.8	3,237,994.0	1,631.5	0.9	0.5
11/24/2021 10:00	6.4	13.8	5.3	93.4	3,169,919.7	1,597.2	0.9	0.5
11/24/2021 11:00	6.4	13.8	5.3	97.1	3,306,862.2	1,666.2	0.9	0.5
11/24/2021 12:00	6.4	13.8	5.3	92.8	3,136,577.2	1,580.4	0.9	0.5
11/24/2021 13:00	6.4	13.8	5.3	94.5	3,184,209.4	1,604.4	0.9	0.5
11/24/2021 14:00	6.5	13.8	5.4	92.9	3,148,088.3	1,586.2	0.9	0.5
11/24/2021 15:00	7.1	13.7	5.8	98.9	3,225,581.3	1,648.8	1.0	0.7
11/24/2021 16:00	8.1	13.3	6.3	114.0	3,433,217.2	1,955.5	1.1	0.8
11/24/2021 17:00	8.2	13.3	6.4	118.9	3,415,002.1	1,995.0	1.1	0.8
11/24/2021 18:00	8.2	13.2	6.3	122.3	3,401,075.3	2,011.7	1.2	1.0
11/24/2021 19:00	7.9	13.3	6.1	118.3	3,369,126.3	1,968.2	1.1	0.8
11/24/2021 20:00	6.1	13.8	5.1	91.8	3,131,417.1	1,577.8	0.9	0.5
11/24/2021 21:00	6.9	13.7	5.7	100.9	3,364,284.4	1,719.7	0.9	0.5
11/24/2021 22:00	8.1	13.4	6.4	112.1	3,440,100.8	1,934.3	1.0	0.8
11/24/2021 23:00	7.8	13.4	6.1	108.8	3,381,757.5	1,876.8	1.0	0.8
Average/Sum#:	7.1	13.6	5.7	102.4	3,285,956.0	1,760.3	1.0	0.7
Minimum:	6.1	13.2	5.1	86.4	2,946,247.1	1,484.5	0.9	0.4
Maximum:	8.2	13.8	6.4	122.3	3,477,607.6	2,011.7	1.2	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/25/2021 00:00	21.3	16.1	26.2	150.3	1,555,940.0	568.1	3.0	0.7
11/25/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/25/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	21.3	16.1	26.2	150.3	1,555,940.0	568.1	3.0	0.7
Minimum:	21.3	16.1	26.2	150.3	1,555,940.0	568.1	3.0	0.7
Maximum:	21.3	16.1	26.2	150.3	1,555,940.0	568.1	3.0	0.7
%SI	95.83	95.83	95.83	95.83	95.83	95.83	95.83	95.83

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/26/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/26/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/27/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/27/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/28/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/28/2021 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/29/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/29/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/29/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/29/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/29/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/29/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/29/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/29/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/29/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/29/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/29/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/29/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/29/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/29/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/29/2021 14:00	30.4	17.4	51.2	0.0	1,368,140.5	319.7	0.0	0.0
11/29/2021 15:00	29.5	15.8	34.1	200.6	2,078,730.3	743.8	3.0	0.9
11/29/2021 16:00	6.8	13.6	5.5	101.1	3,242,405.7	1,657.4	1.0	0.7
11/29/2021 17:00	7.4	13.3	5.7	111.3	3,282,284.9	1,893.5	1.1	0.8
11/29/2021 18:00	7.7	13.1	5.8	119.8	3,326,234.0	2,040.3	1.2	1.0
11/29/2021 19:00	7.5	13.2	5.7	115.9	3,354,413.5	1,984.1	1.1	0.8
11/29/2021 20:00	6.5	13.7	5.3	96.6	3,179,216.5	1,625.1	1.0	0.7
11/29/2021 21:00	7.1	13.6	5.7	104.2	3,408,709.5	1,767.3	1.0	0.7
11/29/2021 22:00	7.5	13.2	5.7	109.7	3,406,355.4	1,940.2	1.0	0.8
11/29/2021 23:00	13.4	14.6	12.5	130.1	2,523,954.5	1,198.0	1.6	0.7
Average/Sum#:	12.4	14.2	13.7	108.9	2,917,044.5	1,516.9	1.2	0.7
Minimum:	6.5	13.1	5.3	0.0	1,368,140.5	319.7	0.0	0.0
Maximum:	30.4	17.4	51.2	200.6	3,408,709.5	2,040.3	3.0	1.0
%SI	58.33	58.33	58.33	58.33	58.33	58.33	58.33	58.33

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
11/30/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/30/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/30/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/30/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/30/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/30/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/30/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/30/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
11/30/2021 08:00	32.0	17.7	59.0	26.7	1,482,401.9	303.1	0.3	0.0
11/30/2021 09:00	28.9	15.4	31.0	194.8	2,267,818.5	877.7	2.6	0.9
11/30/2021 10:00	6.9	13.6	5.6	105.3	3,417,388.9	1,771.8	1.0	0.7
11/30/2021 11:00	7.3	13.5	5.8	106.8	3,377,152.7	1,775.6	1.0	0.7
11/30/2021 12:00	7.5	13.6	6.1	106.6	3,373,798.8	1,749.2	1.0	0.7
11/30/2021 13:00	7.8	13.6	6.3	106.8	3,340,431.1	1,731.9	1.0	0.7
11/30/2021 14:00	7.8	13.6	6.3	106.4	3,326,351.1	1,724.6	1.0	0.7
11/30/2021 15:00	7.8	13.6	6.3	106.3	3,321,915.0	1,722.3	1.0	0.7
11/30/2021 16:00	7.8	13.6	6.3	106.4	3,327,701.3	1,725.3	1.0	0.7
11/30/2021 17:00	7.7	13.6	6.2	106.3	3,333,873.3	1,728.5	1.0	0.7
11/30/2021 18:00	7.9	13.6	6.4	107.6	3,329,051.4	1,726.0	1.0	0.7
11/30/2021 19:00	7.2	13.7	5.9	105.5	3,373,674.8	1,724.5	1.0	0.7
11/30/2021 20:00	6.9	13.7	5.7	101.6	3,305,594.8	1,689.7	1.0	0.7
11/30/2021 21:00	6.6	13.9	5.6	80.3	2,520,345.0	1,251.5	1.0	0.5
11/30/2021 22:00	7.9	13.7	6.5	106.1	3,351,425.1	1,737.6	1.0	0.7
11/30/2021 23:00	7.8	13.4	6.1	109.3	3,387,280.1	1,904.6	1.0	0.8
Average/Sum#:	10.4	14.0	10.9	105.2	3,114,762.7	1,571.5	1.1	0.7
Minimum:	6.6	13.4	5.6	26.7	1,482,401.9	303.1	0.3	0.0
Maximum:	32.0	17.7	59.0	194.8	3,417,388.9	1,904.6	2.6	0.9
%SI	33.33	33.33	33.33	33.33	33.33	33.33	33.33	33.33

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/01/2021 00:00	7.6	13.3	5.9	108.7	3,387,280.1	1,904.6	1.0	0.8
12/01/2021 01:00	6.5	13.8	5.4	88.8	2,913,548.2	1,489.3	1.0	0.6
12/01/2021 02:00	6.9	13.8	5.7	80.7	2,549,511.0	1,284.6	1.0	0.5
12/01/2021 03:00	6.6	13.7	5.4	98.9	3,305,203.6	1,689.5	0.9	0.5
12/01/2021 04:00	7.3	13.5	5.8	106.1	3,373,098.6	1,798.1	1.0	0.7
12/01/2021 05:00	7.3	13.4	5.7	107.4	3,259,770.6	1,809.1	1.1	0.7
12/01/2021 06:00	6.6	13.7	5.4	93.7	3,051,990.5	1,671.5	1.0	0.7
12/01/2021 07:00	8.2	13.0	6.1	128.6	3,433,274.3	2,156.1	1.2	1.1
12/01/2021 08:00	8.1	13.0	6.0	133.3	3,370,962.6	2,166.2	1.3	1.1
12/01/2021 09:00	7.8	13.0	5.8	130.9	3,386,098.5	2,151.2	1.3	1.1
12/01/2021 10:00	7.9	13.0	5.9	133.4	3,368,939.6	2,164.9	1.3	1.1
12/01/2021 11:00	8.0	13.0	6.0	136.6	3,344,472.9	2,173.6	1.3	1.1
12/01/2021 12:00	8.1	12.9	6.0	144.5	3,310,050.9	2,175.4	1.4	1.1
12/01/2021 13:00	8.1	13.0	6.0	140.8	3,288,140.1	2,161.0	1.4	1.1
12/01/2021 14:00	8.0	12.9	5.9	137.4	3,278,097.7	2,154.4	1.4	1.1
12/01/2021 15:00	8.0	13.0	6.0	139.1	3,272,620.0	2,150.8	1.4	1.1
12/01/2021 16:00	7.9	12.9	5.8	134.9	3,286,466.4	2,159.9	1.3	1.1
12/01/2021 17:00	7.9	12.9	5.8	135.9	3,298,943.3	2,168.1	1.4	1.1
12/01/2021 18:00	8.0	12.9	5.9	137.5	3,299,095.5	2,168.2	1.4	1.1
12/01/2021 19:00	7.9	13.0	5.9	134.6	3,314,776.3	2,154.3	1.3	1.1
12/01/2021 20:00	7.5	13.1	5.7	123.2	3,383,782.4	2,075.6	1.2	1.0
12/01/2021 21:00	7.5	13.1	5.7	120.4	3,378,353.5	2,047.6	1.2	1.0
12/01/2021 22:00	7.4	13.2	5.7	115.8	3,381,463.8	2,000.1	1.1	0.8
12/01/2021 23:00	7.0	13.4	5.5	106.1	3,383,011.8	1,902.2	1.0	0.8
Average/Sum#:	7.6	13.2	5.8	121.6	3,275,789.7	1,990.7	1.2	0.9
Minimum:	6.5	12.9	5.4	80.7	2,549,511.0	1,284.6	0.9	0.5
Maximum:	8.2	13.8	6.1	144.5	3,433,274.3	2,175.4	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/02/2021 00:00	12.8	14.7	12.2	127.0	2,569,083.6	1,181.9	1.5	0.7
12/02/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/02/2021 04:00	33.8	16.2	42.4	227.1	2,013,053.8	646.8	3.3	0.8
12/02/2021 05:00	6.3	13.8	5.2	87.2	2,677,919.3	1,349.3	1.0	0.5
12/02/2021 06:00	6.6	13.8	5.5	79.8	2,585,433.5	1,302.7	1.0	0.5
12/02/2021 07:00	6.9	13.8	5.7	82.8	2,664,820.5	1,342.7	1.0	0.5
12/02/2021 08:00	6.9	13.9	5.8	79.8	2,460,994.5	1,240.0	1.0	0.5
12/02/2021 09:00	7.0	13.9	5.9	78.7	2,404,431.4	1,211.5	1.0	0.5
12/02/2021 10:00	6.9	13.8	5.7	83.5	2,706,498.6	1,363.7	1.0	0.5
12/02/2021 11:00	6.8	13.8	5.7	86.4	2,852,173.6	1,437.1	1.0	0.6
12/02/2021 12:00	6.8	13.8	5.7	93.5	3,134,592.6	1,579.4	0.9	0.5
12/02/2021 13:00	6.8	13.7	5.6	100.6	3,329,266.3	1,701.8	1.0	0.7
12/02/2021 14:00	7.0	13.7	5.7	102.1	3,324,571.1	1,699.4	1.0	0.7
12/02/2021 15:00	6.8	13.7	5.6	101.3	3,324,375.5	1,699.3	1.0	0.7
12/02/2021 16:00	6.7	13.7	5.5	100.5	3,320,267.2	1,697.2	1.0	0.7
12/02/2021 17:00	6.6	13.8	5.5	100.2	3,318,115.3	1,696.1	1.0	0.7
12/02/2021 18:00	6.6	13.8	5.5	99.9	3,316,941.5	1,695.5	1.0	0.7
12/02/2021 19:00	6.6	13.8	5.5	99.9	3,314,398.3	1,694.2	1.0	0.7
12/02/2021 20:00	7.4	13.6	6.0	106.1	3,334,548.4	1,753.2	1.0	0.7
12/02/2021 21:00	7.6	13.4	6.0	107.5	3,357,046.1	1,887.6	1.0	0.8
12/02/2021 22:00	7.8	13.2	6.0	114.9	3,351,370.3	1,982.3	1.1	0.8
12/02/2021 23:00	7.1	13.4	5.6	107.8	3,292,487.5	1,851.3	1.1	0.7
Average/Sum#:	8.5	13.9	7.7	103.2	2,983,447.1	1,524.4	1.1	0.6
Minimum:	6.3	13.2	5.2	78.7	2,013,053.8	646.8	0.9	0.5
Maximum:	33.8	16.2	42.4	227.1	3,357,046.1	1,982.3	3.3	0.8
%SI	12.50	12.50	12.50	12.50	12.50	12.50	12.50	12.50

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/03/2021 00:00	10.1	14.4	9.2	100.2	2,383,440.3	1,113.9	1.3	0.6
12/03/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/03/2021 03:00	22.5	18.0	45.8	180.7	1,350,966.9	226.9	3.8	0.3
12/03/2021 04:00	34.4	16.0	41.4	234.7	2,039,586.4	714.9	3.4	0.9
12/03/2021 05:00	6.5	13.8	5.4	90.2	2,729,654.1	1,395.3	1.1	0.6
12/03/2021 06:00	6.5	13.7	5.3	94.1	3,132,656.1	1,601.3	1.0	0.6
12/03/2021 07:00	7.4	13.4	5.8	108.3	3,368,236.2	1,844.7	1.0	0.7
12/03/2021 08:00	8.0	13.0	6.0	130.5	3,419,261.6	2,147.3	1.2	1.1
12/03/2021 09:00	7.9	13.0	5.9	135.1	3,395,700.3	2,157.3	1.3	1.1
12/03/2021 10:00	7.9	13.0	5.9	138.4	3,359,135.8	2,158.6	1.3	1.1
12/03/2021 11:00	7.9	13.0	5.9	138.5	3,372,674.4	2,167.3	1.3	1.1
12/03/2021 12:00	7.9	12.9	5.8	137.2	3,369,873.3	2,165.5	1.3	1.1
12/03/2021 13:00	7.9	12.9	5.8	137.0	3,331,855.7	2,165.4	1.3	1.1
12/03/2021 14:00	7.9	12.9	5.8	136.9	3,325,239.4	2,161.1	1.3	1.1
12/03/2021 15:00	7.9	12.9	5.8	136.5	3,324,777.8	2,160.8	1.3	1.1
12/03/2021 16:00	7.0	13.3	5.4	111.8	3,219,014.0	1,857.0	1.1	0.7
12/03/2021 17:00	6.5	13.7	5.3	100.3	3,321,336.3	1,722.0	1.0	0.7
12/03/2021 18:00	6.6	13.7	5.4	99.9	3,259,230.0	1,689.8	1.0	0.7
12/03/2021 19:00	6.7	13.7	5.5	100.2	3,267,716.6	1,694.2	1.0	0.7
12/03/2021 20:00	7.6	13.3	5.9	110.7	3,365,143.7	1,941.3	1.1	0.8
12/03/2021 21:00	7.8	13.1	5.9	121.3	3,342,699.7	2,050.4	1.2	1.0
12/03/2021 22:00	7.6	13.1	5.7	120.2	3,378,353.5	2,047.6	1.2	1.0
12/03/2021 23:00	9.6	14.0	8.2	116.4	2,985,152.3	1,547.7	1.2	0.8
Average/Sum#:	9.6	13.7	9.4	126.3	3,092,804.7	1,760.5	1.4	0.9
Minimum:	6.5	12.9	5.3	90.2	1,350,966.9	226.9	1.0	0.3
Maximum:	34.4	18.0	45.8	234.7	3,419,261.6	2,167.3	3.8	1.1
%SI	8.33	8.33	8.33	8.33	8.33	8.33	8.33	8.33

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/04/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2021 05:00	19.2	18.2	42.0	133.3	1,243,567.8	190.7	3.0	0.2
12/04/2021 06:00	25.1	17.7	46.3	157.1	1,417,843.3	289.9	3.1	0.3
12/04/2021 07:00	25.5	14.5	23.5	177.2	2,805,180.3	1,311.0	1.8	0.9
12/04/2021 08:00	6.7	13.7	5.5	101.2	3,277,553.3	1,699.3	1.0	0.7
12/04/2021 09:00	6.7	13.7	5.5	101.0	3,280,446.5	1,700.8	1.0	0.7
12/04/2021 10:00	6.7	13.7	5.5	103.2	3,386,335.8	1,755.7	1.0	0.7
12/04/2021 11:00	6.7	13.7	5.5	104.0	3,395,593.8	1,760.5	1.0	0.7
12/04/2021 12:00	10.0	14.2	8.8	116.2	2,984,307.7	1,438.3	1.2	0.7
12/04/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/04/2021 15:00	18.0	18.1	37.9	173.2	1,248,230.3	182.3	4.1	0.3
12/04/2021 16:00	32.8	15.7	37.2	225.2	2,084,478.7	776.3	3.2	0.9
12/04/2021 17:00	6.6	13.7	5.4	101.4	3,246,885.9	1,683.4	1.0	0.7
12/04/2021 18:00	7.0	13.4	5.5	106.1	3,402,839.4	1,888.5	1.0	0.8
12/04/2021 19:00	6.8	13.5	5.4	103.3	3,279,230.8	1,819.9	1.0	0.7
12/04/2021 20:00	6.6	13.7	5.4	95.4	3,081,783.5	1,597.8	1.0	0.6
12/04/2021 21:00	6.7	13.7	5.5	94.9	3,048,608.7	1,580.6	1.0	0.6
12/04/2021 22:00	6.7	13.7	5.5	94.4	3,019,098.6	1,565.3	1.0	0.6
12/04/2021 23:00	20.9	16.2	26.2	156.0	1,441,456.1	526.3	3.3	0.7
Average/Sum#:	12.9	14.8	16.3	126.1	2,684,908.3	1,280.4	1.7	0.6
Minimum:	6.6	13.4	5.4	94.4	1,243,567.8	182.3	1.0	0.2
Maximum:	32.8	18.2	46.3	225.2	3,402,839.4	1,888.5	4.1	0.9
%SI	29.17	29.17	29.17	29.17	29.17	29.17	29.17	29.17

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/05/2021 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/05/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/05/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/05/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/05/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/05/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/05/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/05/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/05/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/05/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/05/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/05/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/05/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/05/2021 13:00	30.7	17.6	54.9	0.0	1,463,395.2	309.9	-0.2	0.0
12/05/2021 14:00	28.2	15.2	29.2	163.7	2,262,484.7	925.2	2.2	0.7
12/05/2021 15:00	6.6	13.7	5.4	98.4	3,231,645.9	1,651.9	1.0	0.7
12/05/2021 16:00	7.0	13.7	5.7	95.0	3,050,730.3	1,581.7	1.0	0.6
12/05/2021 17:00	7.6	13.3	5.9	110.2	3,359,250.0	1,937.9	1.1	0.8
12/05/2021 18:00	7.8	13.1	5.9	120.5	3,366,827.7	2,065.2	1.2	1.0
12/05/2021 19:00	7.7	13.1	5.8	123.3	3,403,345.6	2,087.6	1.2	1.0
12/05/2021 20:00	7.9	13.0	5.9	133.2	3,412,227.8	2,167.8	1.3	1.1
12/05/2021 21:00	7.6	13.1	5.7	127.0	3,407,289.0	2,114.9	1.2	1.1
12/05/2021 22:00	7.6	13.0	5.7	125.7	3,405,516.8	2,113.8	1.2	1.1
12/05/2021 23:00	7.4	13.2	5.7	117.7	3,406,359.7	2,039.7	1.1	0.8
Average/Sum#:	11.5	13.8	12.3	110.4	3,069,915.7	1,726.9	1.1	0.8
Minimum:	6.6	13.0	5.4	0.0	1,463,395.2	309.9	-0.2	0.0
Maximum:	30.7	17.6	54.9	163.7	3,412,227.8	2,167.8	2.2	1.1
%SI	54.17	54.17	54.17	54.17	54.17	54.17	54.17	54.17

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/06/2021 00:00	7.1	13.3	5.5	110.3	3,371,037.5	1,944.7	1.1	0.8
12/06/2021 01:00	6.3	13.7	5.2	97.6	3,227,598.3	1,673.4	1.0	0.7
12/06/2021 02:00	6.5	13.7	5.3	100.5	3,332,716.0	1,727.9	1.0	0.7
12/06/2021 03:00	7.3	13.3	5.7	108.0	3,449,348.8	1,939.5	1.0	0.8
12/06/2021 04:00	7.2	13.3	5.6	108.4	3,408,443.9	1,916.5	1.0	0.8
12/06/2021 05:00	6.4	13.7	5.2	95.0	3,102,807.1	1,608.7	1.0	0.6
12/06/2021 06:00	6.9	13.5	5.5	105.5	3,288,041.3	1,848.8	1.0	0.7
12/06/2021 07:00	8.0	13.0	6.0	125.7	3,420,661.0	2,123.2	1.2	1.1
12/06/2021 08:00	7.6	13.0	5.7	126.1	3,418,727.7	2,122.0	1.2	1.1
12/06/2021 09:00	6.3	13.6	5.1	99.2	3,178,002.5	1,694.1	1.0	0.7
12/06/2021 10:00	6.4	13.7	5.2	101.4	3,395,208.1	1,760.3	1.0	0.7
12/06/2021 11:00	7.3	13.3	5.7	110.9	3,451,125.0	1,965.7	1.0	0.8
12/06/2021 12:00	7.7	13.0	5.8	126.2	3,388,847.6	2,128.2	1.2	1.1
12/06/2021 13:00	7.0	13.3	5.4	112.6	3,256,109.8	1,878.4	1.1	0.8
12/06/2021 14:00	6.3	13.7	5.2	94.6	3,103,578.6	1,609.1	1.0	0.6
12/06/2021 15:00	6.9	13.5	5.5	104.4	3,334,733.4	1,802.0	1.0	0.7
12/06/2021 16:00	7.6	13.2	5.8	116.8	3,392,498.4	2,031.4	1.1	0.8
12/06/2021 17:00	7.5	13.1	5.7	120.1	3,411,681.6	2,067.8	1.1	0.8
12/06/2021 18:00	7.6	13.0	5.7	130.0	3,390,820.7	2,154.2	1.3	1.1
12/06/2021 19:00	7.5	13.1	5.7	124.8	3,404,066.8	2,112.9	1.2	1.1
12/06/2021 20:00	7.5	13.0	5.6	127.2	3,402,382.7	2,136.7	1.2	1.1
12/06/2021 21:00	7.3	13.1	5.5	120.4	3,414,486.5	2,069.5	1.1	0.8
12/06/2021 22:00	7.4	13.1	5.6	120.3	3,407,721.8	2,065.4	1.1	0.8
12/06/2021 23:00	7.4	13.1	5.6	120.8	3,413,661.5	2,069.0	1.2	1.0
Average/Sum#:	7.1	13.3	5.5	112.8	3,348,512.8	1,935.4	1.1	0.8
Minimum:	6.3	13.0	5.1	94.6	3,102,807.1	1,608.7	1.0	0.6
Maximum:	8.0	13.7	6.0	130.0	3,451,125.0	2,154.2	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/07/2021 00:00	7.2	13.2	5.5	117.7	3,385,985.3	2,027.5	1.1	0.8
12/07/2021 01:00	6.3	13.7	5.2	88.7	2,895,850.4	1,501.4	1.0	0.6
12/07/2021 02:00	6.5	13.7	5.3	96.4	3,196,738.0	1,657.4	1.0	0.7
12/07/2021 03:00	6.9	13.4	5.4	105.4	3,412,178.7	1,918.6	1.0	0.8
12/07/2021 04:00	7.5	13.1	5.7	118.7	3,392,047.7	2,055.9	1.1	0.8
12/07/2021 05:00	6.3	13.6	5.1	98.8	3,216,435.5	1,691.1	1.0	0.7
12/07/2021 06:00	6.4	13.7	5.2	93.0	3,118,622.9	1,616.9	1.0	0.6
12/07/2021 07:00	7.5	13.3	5.8	110.0	3,389,500.9	1,930.6	1.0	0.8
12/07/2021 08:00	7.9	13.0	5.9	128.8	3,408,115.1	2,140.3	1.2	1.1
12/07/2021 09:00	7.4	13.1	5.6	123.2	3,341,232.5	2,049.5	1.2	1.0
12/07/2021 10:00	6.7	13.6	5.4	103.8	3,376,391.9	1,775.2	1.0	0.7
12/07/2021 11:00	7.9	13.5	6.3	135.8	3,380,386.1	1,777.3	1.3	0.9
12/07/2021 12:00	7.0	13.6	5.7	104.3	3,327,511.1	1,749.5	1.0	0.7
12/07/2021 13:00	7.3	13.6	5.9	105.6	3,321,995.3	1,746.6	1.0	0.7
12/07/2021 14:00	7.8	13.2	6.0	117.1	3,306,582.4	2,004.1	1.1	0.8
12/07/2021 15:00	7.9	13.0	5.9	137.4	3,281,694.7	2,132.8	1.4	1.1
12/07/2021 16:00	7.7	12.9	5.7	137.0	3,331,701.8	2,165.3	1.4	1.1
12/07/2021 17:00	7.6	13.0	5.7	130.7	3,335,948.9	2,143.7	1.3	1.1
12/07/2021 18:00	7.6	13.0	5.7	131.2	3,354,622.9	2,155.7	1.3	1.1
12/07/2021 19:00	7.5	13.0	5.6	128.8	3,372,246.9	2,142.4	1.2	1.1
12/07/2021 20:00	7.6	13.0	5.7	129.3	3,373,348.7	2,143.1	1.3	1.1
12/07/2021 21:00	7.5	13.0	5.6	128.8	3,366,422.9	2,138.7	1.3	1.1
12/07/2021 22:00	7.4	13.1	5.6	121.6	3,383,130.3	2,075.2	1.2	1.0
12/07/2021 23:00	7.4	13.1	5.6	121.0	3,367,642.8	2,065.7	1.2	1.0
Average/Sum#:	7.3	13.3	5.6	117.2	3,318,180.6	1,950.2	1.2	0.9
Minimum:	6.3	12.9	5.1	88.7	2,895,850.4	1,501.4	1.0	0.6
Maximum:	7.9	13.7	6.3	137.4	3,412,178.7	2,165.3	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/08/2021 00:00	7.2	13.2	5.5	116.5	3,335,884.4	1,997.5	1.1	0.8
12/08/2021 01:00	6.3	13.7	5.2	93.0	3,082,183.0	1,575.5	1.0	0.6
12/08/2021 02:00	6.7	13.8	5.6	80.6	2,535,782.7	1,296.2	1.0	0.5
12/08/2021 03:00	6.6	13.7	5.4	99.6	3,292,790.6	1,707.2	1.0	0.7
12/08/2021 04:00	7.0	13.5	5.6	104.8	3,276,210.9	1,794.3	1.0	0.7
12/08/2021 05:00	7.1	13.4	5.6	107.7	3,271,857.2	1,839.7	1.1	0.7
12/08/2021 06:00	6.5	13.6	5.3	97.7	3,337,730.8	1,730.5	0.9	0.5
12/08/2021 07:00	7.7	13.2	5.9	110.5	3,379,878.1	1,949.8	1.0	0.8
12/08/2021 08:00	6.9	13.4	5.4	105.7	3,253,538.9	1,829.4	1.0	0.7
12/08/2021 09:00	6.4	13.8	5.3	80.3	2,637,707.0	1,348.3	1.0	0.5
12/08/2021 10:00	6.7	13.8	5.6	80.4	2,570,213.9	1,313.8	1.0	0.5
12/08/2021 11:00	6.6	13.7	5.4	99.1	3,265,016.3	1,692.8	1.0	0.7
12/08/2021 12:00	6.8	13.5	5.4	103.8	3,316,015.5	1,816.1	1.0	0.7
12/08/2021 13:00	6.9	13.4	5.4	103.8	3,291,548.4	1,802.7	1.0	0.7
12/08/2021 14:00	6.6	13.8	5.5	80.9	2,527,174.9	1,291.8	1.0	0.5
12/08/2021 15:00	6.7	13.8	5.6	83.3	2,670,377.5	1,365.0	1.0	0.5
12/08/2021 16:00	6.6	13.7	5.4	99.3	3,243,607.0	1,681.7	1.0	0.7
12/08/2021 17:00	7.5	13.3	5.8	109.3	3,391,081.0	1,931.5	1.0	0.8
12/08/2021 18:00	7.9	13.1	6.0	124.5	3,368,784.0	2,091.0	1.2	1.0
12/08/2021 19:00	7.7	13.1	5.8	123.6	3,353,156.4	2,081.3	1.2	1.0
12/08/2021 20:00	7.6	13.1	5.7	122.0	3,369,599.1	2,066.9	1.2	1.0
12/08/2021 21:00	7.4	13.1	5.6	116.0	3,358,095.8	2,010.8	1.1	0.8
12/08/2021 22:00	7.4	13.2	5.7	114.1	3,367,262.4	1,991.7	1.1	0.8
12/08/2021 23:00	7.5	13.1	5.7	116.6	3,360,600.8	2,012.3	1.1	0.8
Average/Sum#:	7.0	13.5	5.6	103.0	3,160,670.7	1,759.1	1.0	0.7
Minimum:	6.3	13.1	5.2	80.3	2,527,174.9	1,291.8	0.9	0.5
Maximum:	7.9	13.8	6.0	124.5	3,391,081.0	2,091.0	1.2	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/09/2021 00:00	7.1	13.3	5.5	106.8	3,371,629.5	1,895.8	1.0	0.8
12/09/2021 01:00	6.4	13.7	5.2	87.4	2,872,465.5	1,468.3	1.0	0.6
12/09/2021 02:00	6.8	13.7	5.6	92.2	2,985,538.0	1,547.9	1.0	0.6
12/09/2021 03:00	7.4	13.3	5.7	108.1	3,373,173.2	1,921.3	1.0	0.8
12/09/2021 04:00	7.4	13.2	5.7	110.9	3,327,187.7	1,943.7	1.1	0.8
12/09/2021 05:00	6.4	13.7	5.2	90.3	2,970,281.5	1,518.3	1.0	0.6
12/09/2021 06:00	6.8	13.7	5.6	89.7	3,087,184.0	1,600.6	0.9	0.5
12/09/2021 07:00	7.7	13.3	6.0	109.1	3,408,813.3	1,941.6	1.0	0.8
12/09/2021 08:00	7.6	13.2	5.8	114.9	3,382,985.4	2,001.0	1.1	0.8
12/09/2021 09:00	7.4	13.2	5.7	116.6	3,377,913.5	1,998.0	1.1	0.8
12/09/2021 10:00	6.2	13.7	5.1	92.5	3,043,401.0	1,577.9	1.0	0.6
12/09/2021 11:00	6.8	13.7	5.6	98.9	3,247,464.6	1,683.7	1.0	0.7
12/09/2021 12:00	7.6	13.3	5.9	113.7	3,366,045.1	1,966.4	1.1	0.8
12/09/2021 13:00	7.4	13.3	5.7	114.7	3,357,863.3	1,937.1	1.1	0.8
12/09/2021 14:00	6.3	13.8	5.2	86.2	2,835,899.3	1,428.9	1.0	0.6
12/09/2021 15:00	6.4	13.8	5.3	87.0	2,897,115.1	1,480.9	1.0	0.6
12/09/2021 16:00	7.5	13.3	5.8	109.8	3,414,080.3	1,944.6	1.0	0.8
12/09/2021 17:00	7.6	13.1	5.7	125.5	3,388,184.2	2,078.3	1.2	1.0
12/09/2021 18:00	7.4	13.2	5.7	122.6	3,388,747.9	2,053.9	1.2	1.0
12/09/2021 19:00	7.6	13.1	5.7	128.5	3,388,510.2	2,078.5	1.2	1.0
12/09/2021 20:00	7.5	13.1	5.7	129.1	3,398,617.9	2,084.7	1.2	1.0
12/09/2021 21:00	7.5	13.1	5.7	127.8	3,398,943.9	2,084.9	1.2	1.0
12/09/2021 22:00	7.0	13.3	5.4	112.3	3,415,067.1	1,970.1	1.1	0.8
12/09/2021 23:00	7.4	13.3	5.7	115.4	3,417,227.4	1,996.3	1.1	0.8
Average/Sum#:	7.1	13.4	5.6	107.9	3,254,764.1	1,841.8	1.1	0.8
Minimum:	6.2	13.1	5.1	86.2	2,835,899.3	1,428.9	0.9	0.5
Maximum:	7.7	13.8	6.0	129.1	3,417,227.4	2,084.9	1.2	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/10/2021 00:00	6.7	13.5	5.3	106.3	3,390,837.1	1,906.6	1.0	0.8
12/10/2021 01:00	6.2	13.8	5.2	88.2	2,958,934.8	1,512.5	1.0	0.6
12/10/2021 02:00	6.5	13.7	5.3	90.7	3,094,899.1	1,582.0	0.9	0.5
12/10/2021 03:00	7.0	13.5	5.6	106.3	3,438,898.5	1,883.4	1.0	0.8
12/10/2021 04:00	6.8	13.5	5.4	104.9	3,435,993.9	1,906.9	1.0	0.8
12/10/2021 05:00	6.2	13.8	5.2	92.7	3,105,658.9	1,587.5	1.0	0.6
12/10/2021 06:00	6.3	13.7	5.2	91.7	3,297,998.2	1,709.9	0.9	0.5
12/10/2021 07:00	7.3	13.4	5.7	107.1	3,487,887.9	1,935.7	1.0	0.8
12/10/2021 08:00	6.7	13.4	5.3	104.3	3,431,489.2	1,904.4	1.0	0.8
12/10/2021 09:00	6.2	13.8	5.2	92.2	3,095,486.0	1,582.3	1.0	0.6
12/10/2021 10:00	6.4	13.8	5.3	96.4	3,260,208.2	1,666.5	0.9	0.5
12/10/2021 11:00	6.4	13.8	5.3	93.5	3,127,569.7	1,598.7	1.0	0.6
12/10/2021 12:00	6.4	13.8	5.3	95.7	3,228,124.5	1,650.1	0.9	0.5
12/10/2021 13:00	6.4	13.8	5.3	92.4	3,076,509.7	1,572.6	1.0	0.6
12/10/2021 14:00	6.8	13.9	5.7	80.6	2,560,426.7	1,290.1	1.0	0.5
12/10/2021 15:00	6.7	13.8	5.6	91.0	3,034,057.5	1,550.9	1.0	0.6
12/10/2021 16:00	7.4	13.4	5.8	108.8	3,463,202.2	1,922.0	1.0	0.8
12/10/2021 17:00	8.0	13.1	6.1	135.8	3,424,197.9	2,150.4	1.3	1.1
12/10/2021 18:00	7.7	13.1	5.8	133.4	3,415,505.5	2,120.0	1.3	1.1
12/10/2021 19:00	7.6	13.1	5.7	131.6	3,418,727.7	2,122.0	1.3	1.1
12/10/2021 20:00	7.7	13.1	5.8	136.6	3,419,739.3	2,147.6	1.3	1.1
12/10/2021 21:00	7.5	13.1	5.7	126.8	3,434,646.8	2,106.8	1.2	1.1
12/10/2021 22:00	7.2	13.2	5.5	117.4	3,471,575.3	2,053.4	1.1	0.8
12/10/2021 23:00	7.2	13.2	5.5	115.6	3,519,420.7	2,056.0	1.1	0.8
Average/Sum#:	6.9	13.5	5.5	105.8	3,274,666.5	1,813.3	1.1	0.8
Minimum:	6.2	13.1	5.2	80.6	2,560,426.7	1,290.1	0.9	0.5
Maximum:	8.0	13.9	6.1	136.6	3,519,420.7	2,150.4	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/11/2021 00:00	7.2	13.2	5.5	116.1	3,472,251.6	2,053.8	1.1	0.8
12/11/2021 01:00	7.1	13.3	5.5	110.7	3,503,970.8	1,995.8	1.0	0.8
12/11/2021 02:00	6.3	13.5	5.0	102.1	3,422,299.6	1,899.3	1.0	0.8
12/11/2021 03:00	6.2	13.7	5.1	93.2	3,123,265.8	1,596.5	1.0	0.6
12/11/2021 04:00	6.4	13.7	5.2	96.0	3,211,589.5	1,665.1	1.0	0.7
12/11/2021 05:00	7.2	13.3	5.6	108.8	3,514,796.6	1,976.3	1.0	0.8
12/11/2021 06:00	7.4	13.2	5.7	119.7	3,497,681.1	2,043.3	1.1	0.8
12/11/2021 07:00	7.1	13.3	5.5	111.4	3,480,093.6	1,982.2	1.0	0.8
12/11/2021 08:00	6.3	13.7	5.2	92.1	3,096,072.9	1,582.6	1.0	0.6
12/11/2021 09:00	6.4	13.8	5.3	81.2	2,671,747.0	1,365.7	1.0	0.5
12/11/2021 10:00	6.4	13.8	5.3	81.6	2,736,892.4	1,399.0	1.0	0.6
12/11/2021 11:00	6.6	13.8	5.5	79.5	2,544,781.8	1,300.8	1.0	0.5
12/11/2021 12:00	6.7	13.8	5.6	80.0	2,541,260.4	1,299.0	1.0	0.5
12/11/2021 13:00	6.5	13.7	5.3	87.1	2,894,180.6	1,479.4	1.0	0.6
12/11/2021 14:00	6.6	13.7	5.4	90.0	2,970,085.9	1,518.2	1.0	0.6
12/11/2021 15:00	6.6	13.7	5.4	94.2	3,101,842.7	1,608.2	1.0	0.6
12/11/2021 16:00	7.7	13.2	5.9	118.9	3,475,632.9	2,055.8	1.1	0.8
12/11/2021 17:00	7.7	13.0	5.8	128.8	3,463,193.7	2,149.6	1.2	1.1
12/11/2021 18:00	7.5	13.0	5.6	126.9	3,480,620.3	2,135.0	1.2	1.1
12/11/2021 19:00	7.6	13.0	5.7	130.1	3,453,815.7	2,169.0	1.2	1.1
12/11/2021 20:00	7.4	13.0	5.5	126.4	3,475,729.5	2,132.0	1.2	1.1
12/11/2021 21:00	7.6	13.0	5.7	131.8	3,448,720.2	2,165.8	1.2	1.1
12/11/2021 22:00	7.5	13.0	5.6	127.4	3,467,741.2	2,127.1	1.2	1.1
12/11/2021 23:00	7.3	13.1	5.5	117.8	3,458,050.2	2,045.4	1.1	0.8
Average/Sum#:	7.0	13.4	5.5	106.3	3,229,429.8	1,822.7	1.1	0.8
Minimum:	6.2	13.0	5.0	79.5	2,541,260.4	1,299.0	1.0	0.5
Maximum:	7.7	13.8	5.9	131.8	3,514,796.6	2,169.0	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/12/2021 00:00	7.4	13.1	5.6	117.4	3,441,650.9	2,035.7	1.1	0.8
12/12/2021 01:00	7.4	13.2	5.7	113.8	3,455,803.1	1,993.6	1.1	0.8
12/12/2021 02:00	6.5	13.4	5.1	103.8	3,409,506.3	1,892.2	1.0	0.8
12/12/2021 03:00	6.5	13.7	5.3	93.8	3,080,226.7	1,574.5	1.0	0.6
12/12/2021 04:00	6.6	13.6	5.3	100.1	3,300,505.6	1,711.2	1.0	0.7
12/12/2021 05:00	7.6	13.2	5.8	111.9	3,410,040.1	1,967.2	1.1	0.8
12/12/2021 06:00	7.6	13.1	5.7	116.5	3,460,136.7	1,996.1	1.1	0.8
12/12/2021 07:00	6.6	13.7	5.4	97.3	3,084,676.6	1,599.3	1.0	0.6
12/12/2021 08:00	6.7	13.7	5.5	94.4	3,071,618.9	1,570.1	1.0	0.6
12/12/2021 09:00	6.6	13.8	5.5	82.1	2,688,571.3	1,374.3	1.0	0.5
12/12/2021 10:00	6.8	13.7	5.6	94.0	3,034,528.7	1,573.3	1.0	0.6
12/12/2021 11:00	6.6	13.7	5.4	98.9	3,212,553.9	1,665.6	1.0	0.7
12/12/2021 12:00	6.7	13.7	5.5	95.4	3,059,024.0	1,586.0	1.0	0.6
12/12/2021 13:00	6.7	13.7	5.5	96.7	3,107,629.0	1,611.2	1.0	0.6
12/12/2021 14:00	6.7	13.7	5.5	94.3	3,025,270.6	1,568.5	1.0	0.6
12/12/2021 15:00	7.0	13.6	5.7	93.8	3,015,433.9	1,563.4	1.0	0.6
12/12/2021 16:00	7.9	13.1	6.0	117.7	3,408,007.0	2,015.8	1.1	0.8
12/12/2021 17:00	7.9	13.0	5.9	125.4	3,408,725.5	2,090.9	1.2	1.0
12/12/2021 18:00	7.8	13.0	5.8	124.5	3,398,617.9	2,084.7	1.2	1.0
12/12/2021 19:00	7.9	12.9	5.8	130.2	3,386,936.8	2,127.0	1.3	1.1
12/12/2021 20:00	7.6	13.0	5.7	123.6	3,386,064.8	2,077.0	1.2	1.0
12/12/2021 21:00	7.6	13.0	5.7	124.0	3,391,281.7	2,080.2	1.2	1.0
12/12/2021 22:00	7.5	13.0	5.6	121.2	3,387,757.9	2,053.3	1.2	1.0
12/12/2021 23:00	7.4	13.1	5.6	115.9	3,394,650.9	2,007.9	1.1	0.8
Average/Sum#:	7.2	13.4	5.6	107.8	3,250,800.8	1,825.8	1.1	0.8
Minimum:	6.5	12.9	5.1	82.1	2,688,571.3	1,374.3	1.0	0.5
Maximum:	7.9	13.8	6.0	130.2	3,460,136.7	2,127.0	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/13/2021 00:00	6.9	13.3	5.4	105.9	3,373,763.7	1,897.0	1.0	0.8
12/13/2021 01:00	6.3	13.7	5.2	97.7	3,222,583.5	1,670.8	1.0	0.7
12/13/2021 02:00	6.9	13.6	5.6	98.3	3,176,100.2	1,646.7	1.0	0.7
12/13/2021 03:00	7.7	13.2	5.9	112.9	3,368,784.0	1,968.0	1.1	0.8
12/13/2021 04:00	7.4	13.3	5.7	109.1	3,315,740.5	1,912.8	1.1	0.8
12/13/2021 05:00	6.5	13.7	5.3	93.0	3,068,684.4	1,568.6	1.0	0.6
12/13/2021 06:00	7.2	13.6	5.8	102.4	3,334,928.8	1,753.4	1.0	0.7
12/13/2021 07:00	8.2	13.1	6.2	119.9	3,361,029.4	2,037.1	1.1	0.8
12/13/2021 08:00	8.0	13.0	6.0	132.1	3,350,525.0	2,128.6	1.3	1.1
12/13/2021 09:00	7.7	13.0	5.8	127.6	3,344,261.7	2,100.2	1.2	1.1
12/13/2021 10:00	7.5	13.0	5.6	123.6	3,334,145.6	2,069.5	1.2	1.0
12/13/2021 11:00	7.3	13.2	5.6	113.4	3,324,320.0	1,966.3	1.1	0.8
12/13/2021 12:00	6.3	13.7	5.2	95.4	3,171,000.0	1,620.9	1.0	0.6
12/13/2021 13:00	7.2	13.5	5.7	105.3	3,355,470.1	1,764.2	1.0	0.7
12/13/2021 14:00	7.8	13.1	5.9	116.2	3,371,827.1	1,994.4	1.1	0.8
12/13/2021 15:00	8.0	12.9	5.9	132.5	3,370,987.7	2,141.6	1.3	1.1
12/13/2021 16:00	8.0	12.8	5.8	137.8	3,376,876.0	2,170.0	1.3	1.1
12/13/2021 17:00	7.9	12.8	5.8	138.8	3,354,012.7	2,179.8	1.4	1.1
12/13/2021 18:00	7.9	12.9	5.8	140.7	3,384,501.2	2,174.9	1.4	1.1
12/13/2021 19:00	7.9	12.9	5.8	148.4	3,337,439.4	2,193.4	1.5	1.3
12/13/2021 20:00	7.6	13.0	5.7	131.0	3,331,363.7	2,092.1	1.3	1.0
12/13/2021 21:00	7.5	13.1	5.7	122.8	3,366,144.1	2,040.2	1.2	1.0
12/13/2021 22:00	7.4	13.2	5.7	115.1	3,366,078.9	1,991.0	1.1	0.8
12/13/2021 23:00	7.4	13.2	5.7	115.4	3,376,561.0	1,997.2	1.1	0.8
Average/Sum#:	7.4	13.2	5.7	118.1	3,322,380.4	1,961.6	1.2	0.9
Minimum:	6.3	12.8	5.2	93.0	3,068,684.4	1,568.6	1.0	0.6
Maximum:	8.2	13.7	6.2	148.4	3,384,501.2	2,193.4	1.5	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/14/2021 00:00	6.8	13.5	5.4	103.8	3,254,545.2	1,806.2	1.0	0.7
12/14/2021 01:00	6.5	13.8	5.4	79.5	2,495,678.1	1,275.7	1.0	0.5
12/14/2021 02:00	6.6	13.8	5.5	79.9	2,533,630.7	1,295.1	1.0	0.5
12/14/2021 03:00	6.5	13.7	5.3	99.8	3,308,992.2	1,715.6	1.0	0.7
12/14/2021 04:00	6.9	13.5	5.5	105.4	3,388,770.2	1,831.2	1.0	0.7
12/14/2021 05:00	6.9	13.4	5.4	104.9	3,276,347.8	1,818.3	1.0	0.7
12/14/2021 06:00	6.4	13.7	5.2	93.4	3,252,672.2	1,686.4	0.9	0.5
12/14/2021 07:00	7.7	13.2	5.9	114.6	3,461,733.7	2,022.3	1.1	0.8
12/14/2021 08:00	7.5	13.1	5.7	119.5	3,439,927.3	2,059.8	1.1	0.8
12/14/2021 09:00	7.0	13.3	5.4	108.7	3,397,401.4	1,935.1	1.0	0.8
12/14/2021 10:00	6.2	13.7	5.1	92.5	3,113,484.2	1,591.5	1.0	0.6
12/14/2021 11:00	6.5	13.7	5.3	93.2	3,098,563.8	1,606.5	1.0	0.6
12/14/2021 12:00	7.5	13.2	5.7	112.7	3,447,135.9	1,988.6	1.1	0.8
12/14/2021 13:00	6.7	13.4	5.3	104.6	3,419,056.3	1,897.5	1.0	0.8
12/14/2021 14:00	6.2	13.8	5.2	94.5	3,175,695.1	1,623.3	1.0	0.6
12/14/2021 15:00	6.5	13.8	5.4	89.2	2,954,826.6	1,510.4	1.0	0.6
12/14/2021 16:00	7.5	13.3	5.8	114.1	3,420,751.9	1,948.4	1.1	0.8
12/14/2021 17:00	8.0	12.9	5.9	138.3	3,456,143.8	2,195.7	1.3	1.1
12/14/2021 18:00	7.7	13.0	5.8	134.5	3,473,021.3	2,155.7	1.3	1.1
12/14/2021 19:00	7.7	12.9	5.7	137.5	3,451,264.3	2,192.6	1.3	1.1
12/14/2021 20:00	7.7	12.9	5.7	138.0	3,456,773.4	2,196.1	1.3	1.1
12/14/2021 21:00	7.5	13.0	5.6	129.5	3,468,832.5	2,153.1	1.2	1.1
12/14/2021 22:00	7.2	13.1	5.4	118.9	3,466,480.7	2,075.7	1.1	0.8
12/14/2021 23:00	7.1	13.2	5.4	110.5	3,503,970.8	1,995.8	1.0	0.8
Average/Sum#:	7.0	13.4	5.5	109.1	3,279,820.8	1,857.4	1.1	0.8
Minimum:	6.2	12.9	5.1	79.5	2,495,678.1	1,275.7	0.9	0.5
Maximum:	8.0	13.8	5.9	138.3	3,503,970.8	2,196.1	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/15/2021 00:00	6.9	13.3	5.4	106.8	3,425,161.6	1,925.9	1.0	0.8
12/15/2021 01:00	6.2	13.7	5.1	89.7	2,994,735.5	1,530.8	1.0	0.6
12/15/2021 02:00	6.4	13.7	5.2	94.6	3,155,848.1	1,636.2	1.0	0.7
12/15/2021 03:00	6.6	13.4	5.2	103.9	3,455,994.7	1,918.0	1.0	0.8
12/15/2021 04:00	6.5	13.4	5.1	103.4	3,433,831.6	1,905.7	1.0	0.8
12/15/2021 05:00	6.3	13.7	5.2	91.8	3,045,795.5	1,556.9	1.0	0.6
12/15/2021 06:00	6.9	13.5	5.5	105.2	3,346,981.3	1,857.5	1.0	0.7
12/15/2021 07:00	8.0	13.1	6.1	124.6	3,478,997.9	2,108.6	1.2	1.1
12/15/2021 08:00	7.0	13.3	5.4	109.4	3,428,652.4	1,952.9	1.0	0.8
12/15/2021 09:00	6.2	13.7	5.1	91.3	3,070,053.8	1,569.3	1.0	0.6
12/15/2021 10:00	6.4	13.7	5.2	93.1	3,075,032.8	1,594.3	1.0	0.6
12/15/2021 11:00	6.6	13.7	5.4	92.6	3,057,288.2	1,585.1	1.0	0.6
12/15/2021 12:00	7.6	13.3	5.9	112.1	3,431,708.2	1,979.7	1.0	0.8
12/15/2021 13:00	7.2	13.2	5.5	113.9	3,386,073.0	1,978.1	1.1	0.8
12/15/2021 14:00	6.3	13.7	5.2	90.4	3,008,234.1	1,537.7	1.0	0.6
12/15/2021 15:00	6.8	13.6	5.5	99.6	3,269,066.7	1,694.9	1.0	0.7
12/15/2021 16:00	7.9	13.0	5.9	123.2	3,433,130.4	2,080.8	1.2	1.0
12/15/2021 17:00	8.0	12.9	5.9	138.0	3,415,935.8	2,195.1	1.3	1.1
12/15/2021 18:00	7.8	12.9	5.8	137.6	3,442,921.8	2,187.3	1.3	1.1
12/15/2021 19:00	7.7	12.9	5.7	140.8	3,440,088.5	2,185.5	1.3	1.1
12/15/2021 20:00	7.7	12.9	5.7	136.6	3,443,551.4	2,187.7	1.3	1.1
12/15/2021 21:00	7.6	12.9	5.6	131.4	3,422,764.8	2,149.5	1.3	1.1
12/15/2021 22:00	7.4	13.0	5.5	121.9	3,425,705.8	2,076.3	1.2	1.0
12/15/2021 23:00	7.4	13.1	5.6	119.4	3,423,227.0	2,049.8	1.1	0.8
Average/Sum#:	7.1	13.3	5.5	111.3	3,312,949.2	1,893.5	1.1	0.8
Minimum:	6.2	12.9	5.1	89.7	2,994,735.5	1,530.8	1.0	0.6
Maximum:	8.0	13.7	6.1	140.8	3,478,997.9	2,195.1	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/16/2021 00:00	7.3	13.1	5.5	115.1	3,438,282.3	2,008.6	1.1	0.8
12/16/2021 01:00	7.0	13.3	5.4	107.9	3,386,516.3	1,928.9	1.0	0.8
12/16/2021 02:00	6.3	13.7	5.2	91.1	3,035,622.6	1,551.7	1.0	0.6
12/16/2021 03:00	6.6	13.7	5.4	92.1	3,038,948.3	1,553.4	1.0	0.6
12/16/2021 04:00	6.6	13.7	5.4	93.9	3,073,104.0	1,593.3	1.0	0.6
12/16/2021 05:00	7.5	13.2	5.7	113.7	3,464,470.3	1,998.6	1.1	0.8
12/16/2021 06:00	7.8	12.9	5.8	136.8	3,468,465.3	2,178.2	1.3	1.1
12/16/2021 07:00	8.0	12.9	5.9	133.1	3,447,924.0	2,165.3	1.3	1.1
12/16/2021 08:00	7.3	13.2	5.6	114.5	3,420,650.9	1,998.3	1.1	0.8
12/16/2021 09:00	7.0	13.3	5.4	108.2	3,413,026.9	1,944.0	1.0	0.8
12/16/2021 10:00	6.4	13.7	5.2	88.7	2,802,374.8	1,473.4	1.0	0.6
12/16/2021 11:00	6.5	13.7	5.3	92.6	3,065,196.1	1,589.2	1.0	0.6
12/16/2021 12:00	7.6	13.2	5.8	113.3	3,405,929.6	1,989.7	1.1	0.8
12/16/2021 13:00	6.6	13.4	5.2	104.2	3,389,058.6	1,905.6	1.0	0.8
12/16/2021 14:00	6.3	13.7	5.2	90.2	2,993,953.0	1,530.4	1.0	0.6
12/16/2021 15:00	6.5	13.7	5.3	91.2	3,024,306.2	1,568.0	1.0	0.6
12/16/2021 16:00	7.7	13.1	5.8	123.7	3,424,880.9	2,075.8	1.2	1.0
12/16/2021 17:00	7.8	12.9	5.8	140.8	3,424,805.9	2,200.8	1.3	1.1
12/16/2021 18:00	7.7	12.9	5.7	140.3	3,424,961.5	2,200.9	1.3	1.1
12/16/2021 19:00	7.6	12.9	5.6	141.4	3,424,027.8	2,200.3	1.4	1.1
12/16/2021 20:00	7.6	12.9	5.6	142.8	3,426,673.3	2,202.0	1.4	1.1
12/16/2021 21:00	7.6	13.0	5.7	137.5	3,432,375.6	2,180.6	1.3	1.1
12/16/2021 22:00	7.3	13.2	5.6	121.8	3,459,633.6	2,071.6	1.1	0.8
12/16/2021 23:00	7.3	13.2	5.6	118.2	3,435,395.5	2,032.0	1.1	0.8
Average/Sum#:	7.2	13.3	5.5	114.7	3,305,024.3	1,922.5	1.1	0.8
Minimum:	6.3	12.9	5.2	88.7	2,802,374.8	1,473.4	1.0	0.6
Maximum:	8.0	13.7	5.9	142.8	3,468,465.3	2,202.0	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/17/2021 00:00	6.3	13.4	5.0	102.4	3,412,389.3	1,893.8	1.0	0.8
12/17/2021 01:00	6.2	13.7	5.1	89.7	2,998,452.5	1,532.7	1.0	0.6
12/17/2021 02:00	6.4	13.7	5.2	90.0	2,988,475.3	1,527.6	1.0	0.6
12/17/2021 03:00	6.5	13.7	5.3	96.9	3,232,613.1	1,676.0	1.0	0.7
12/17/2021 04:00	7.4	13.3	5.7	110.5	3,467,452.8	1,975.0	1.0	0.8
12/17/2021 05:00	7.4	13.3	5.7	111.9	3,474,475.5	1,979.0	1.0	0.8
12/17/2021 06:00	7.8	13.0	5.8	148.2	3,433,115.1	2,156.0	1.4	1.1
12/17/2021 07:00	7.9	13.0	5.9	132.3	3,431,133.1	2,129.7	1.3	1.1
12/17/2021 08:00	7.2	13.3	5.6	112.4	3,498,177.0	1,992.5	1.0	0.8
12/17/2021 09:00	6.4	13.4	5.0	102.4	3,434,192.0	1,905.9	1.0	0.8
12/17/2021 10:00	6.2	13.8	5.2	90.1	3,036,796.4	1,552.3	1.0	0.6
12/17/2021 11:00	6.4	13.8	5.3	89.1	2,969,694.6	1,518.0	1.0	0.6
12/17/2021 12:00	6.5	13.8	5.4	82.3	2,712,055.7	1,366.5	1.0	0.5
12/17/2021 13:00	6.4	13.8	5.3	95.2	3,180,585.9	1,625.8	1.0	0.7
12/17/2021 14:00	6.4	13.8	5.3	86.5	2,874,813.0	1,469.5	1.0	0.6
12/17/2021 15:00	6.6	13.7	5.4	92.1	3,081,596.1	1,575.2	1.0	0.6
12/17/2021 16:00	7.6	13.2	5.8	116.6	3,434,858.7	2,006.6	1.1	0.8
12/17/2021 17:00	7.9	12.9	5.8	146.8	3,400,996.6	2,185.5	1.4	1.1
12/17/2021 18:00	7.8	12.9	5.8	147.6	3,404,575.8	2,187.8	1.4	1.1
12/17/2021 19:00	7.7	12.9	5.7	145.8	3,440,718.1	2,185.9	1.4	1.1
12/17/2021 20:00	7.7	12.9	5.7	147.7	3,406,287.5	2,188.9	1.4	1.1
12/17/2021 21:00	7.6	12.9	5.6	144.1	3,429,857.2	2,179.0	1.4	1.1
12/17/2021 22:00	7.2	13.2	5.5	122.7	3,448,444.4	2,064.9	1.2	1.0
12/17/2021 23:00	7.0	13.2	5.4	112.7	3,455,976.4	1,993.7	1.1	0.8
Average/Sum#:	7.0	13.4	5.5	113.2	3,276,988.8	1,869.5	1.1	0.8
Minimum:	6.2	12.9	5.0	82.3	2,712,055.7	1,366.5	1.0	0.5
Maximum:	7.9	13.8	5.9	148.2	3,498,177.0	2,188.9	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/18/2021 00:00	6.3	13.4	5.0	102.4	3,390,837.1	1,906.6	1.0	0.8
12/18/2021 01:00	6.1	13.7	5.0	92.1	3,064,617.5	1,588.9	1.0	0.6
12/18/2021 02:00	6.3	13.7	5.2	97.3	3,268,681.0	1,694.7	1.0	0.7
12/18/2021 03:00	7.1	13.3	5.5	107.3	3,509,690.5	1,947.8	1.0	0.8
12/18/2021 04:00	6.7	13.3	5.2	105.0	3,485,451.8	1,959.8	1.0	0.8
12/18/2021 05:00	6.0	13.7	4.9	94.6	3,188,830.0	1,653.3	1.0	0.7
12/18/2021 06:00	6.1	13.7	5.0	97.3	3,351,810.8	1,737.8	0.9	0.5
12/18/2021 07:00	7.2	13.4	5.7	107.8	3,515,382.6	2,002.3	1.0	0.8
12/18/2021 08:00	7.1	13.3	5.5	108.2	3,507,482.1	1,997.8	1.0	0.8
12/18/2021 09:00	6.7	13.3	5.2	107.2	3,457,796.6	1,969.5	1.0	0.8
12/18/2021 10:00	6.1	13.7	5.0	88.1	2,992,387.9	1,529.6	0.9	0.5
12/18/2021 11:00	6.4	13.7	5.2	92.1	3,061,250.4	1,564.8	1.0	0.6
12/18/2021 12:00	6.5	13.7	5.3	90.4	2,987,497.1	1,527.1	1.0	0.6
12/18/2021 13:00	6.5	13.7	5.3	90.1	2,962,064.9	1,514.1	1.0	0.6
12/18/2021 14:00	6.6	13.7	5.4	90.5	2,985,540.8	1,526.1	1.0	0.6
12/18/2021 15:00	6.6	13.8	5.5	87.8	2,897,310.7	1,481.0	1.0	0.6
12/18/2021 16:00	6.9	13.4	5.4	103.5	3,316,169.3	1,840.4	1.0	0.7
12/18/2021 17:00	7.7	13.0	5.8	129.1	3,442,249.6	2,136.6	1.2	1.1
12/18/2021 18:00	7.3	13.1	5.5	120.9	3,441,710.0	2,086.0	1.1	0.8
12/18/2021 19:00	7.5	13.0	5.6	133.2	3,437,255.2	2,158.6	1.3	1.1
12/18/2021 20:00	7.5	12.9	5.5	137.1	3,430,959.0	2,179.7	1.3	1.1
12/18/2021 21:00	7.2	13.1	5.4	125.3	3,427,962.7	2,102.7	1.2	1.1
12/18/2021 22:00	7.1	13.1	5.4	116.9	3,476,309.2	2,056.2	1.1	0.8
12/18/2021 23:00	7.0	13.2	5.4	109.4	3,445,922.4	1,987.9	1.0	0.8
Average/Sum#:	6.8	13.4	5.3	105.6	3,293,548.7	1,839.6	1.0	0.8
Minimum:	6.0	12.9	4.9	87.8	2,897,310.7	1,481.0	0.9	0.5
Maximum:	7.7	13.8	5.8	137.1	3,515,382.6	2,179.7	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/19/2021 00:00	7.1	13.2	5.4	112.6	3,462,418.4	2,022.7	1.1	0.8
12/19/2021 01:00	6.9	13.3	5.4	109.1	3,448,667.1	1,964.3	1.0	0.8
12/19/2021 02:00	6.2	13.7	5.1	93.0	3,122,483.2	1,596.1	1.0	0.6
12/19/2021 03:00	6.3	13.7	5.2	95.9	3,210,625.1	1,664.6	1.0	0.7
12/19/2021 04:00	7.1	13.3	5.5	108.2	3,486,341.1	1,960.3	1.0	0.8
12/19/2021 05:00	7.1	13.2	5.4	108.9	3,480,269.2	1,982.3	1.0	0.8
12/19/2021 06:00	6.6	13.3	5.1	106.8	3,463,220.9	1,947.3	1.0	0.8
12/19/2021 07:00	7.4	13.2	5.7	109.1	3,482,024.8	1,983.3	1.0	0.8
12/19/2021 08:00	7.2	13.2	5.5	108.7	3,484,307.2	1,984.6	1.0	0.8
12/19/2021 09:00	6.4	13.4	5.0	103.2	3,454,733.4	1,917.3	1.0	0.8
12/19/2021 10:00	6.1	13.8	5.1	85.8	2,898,680.2	1,481.7	0.9	0.4
12/19/2021 11:00	6.3	13.7	5.2	85.7	2,877,356.3	1,470.8	1.0	0.6
12/19/2021 12:00	6.3	13.8	5.2	83.8	2,802,624.8	1,432.6	1.0	0.6
12/19/2021 13:00	6.5	13.7	5.3	93.0	3,082,183.0	1,575.5	1.0	0.6
12/19/2021 14:00	6.4	13.7	5.2	93.1	3,083,943.7	1,576.4	1.0	0.6
12/19/2021 15:00	6.5	13.7	5.3	91.8	3,060,272.2	1,564.3	1.0	0.6
12/19/2021 16:00	7.3	13.3	5.7	112.9	3,438,484.2	1,958.5	1.1	0.8
12/19/2021 17:00	7.7	13.0	5.8	131.3	3,451,755.0	2,142.5	1.2	1.1
12/19/2021 18:00	7.3	13.1	5.5	121.3	3,470,154.8	2,077.9	1.1	0.8
12/19/2021 19:00	7.3	13.1	5.5	125.7	3,465,633.6	2,100.5	1.2	1.1
12/19/2021 20:00	7.3	13.1	5.5	122.9	3,437,090.2	2,083.2	1.2	1.0
12/19/2021 21:00	7.2	13.1	5.4	120.6	3,465,812.7	2,075.3	1.1	0.8
12/19/2021 22:00	7.2	13.1	5.4	120.7	3,457,963.6	2,070.6	1.1	0.8
12/19/2021 23:00	7.1	13.1	5.4	115.2	3,439,960.2	2,034.7	1.1	0.8
Average/Sum#:	6.9	13.4	5.4	106.6	3,313,625.2	1,861.1	1.0	0.8
Minimum:	6.1	13.0	5.0	83.8	2,802,624.8	1,432.6	0.9	0.4
Maximum:	7.7	13.8	5.8	131.3	3,486,341.1	2,142.5	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/20/2021 00:00	7.1	13.2	5.4	114.3	3,478,851.5	2,032.3	1.1	0.8
12/20/2021 01:00	6.7	13.3	5.2	106.6	3,419,347.3	1,947.6	1.0	0.8
12/20/2021 02:00	6.1	13.7	5.0	96.2	3,241,871.1	1,680.8	1.0	0.7
12/20/2021 03:00	6.3	13.7	5.2	98.5	3,306,870.6	1,714.5	1.0	0.7
12/20/2021 04:00	7.0	13.3	5.4	108.6	3,490,803.2	1,988.3	1.0	0.8
12/20/2021 05:00	7.4	13.1	5.6	120.3	3,478,003.9	2,082.6	1.1	0.8
12/20/2021 06:00	7.4	13.0	5.5	138.1	3,429,611.9	2,153.8	1.3	1.1
12/20/2021 07:00	7.5	13.1	5.7	121.2	3,467,816.7	2,076.5	1.1	0.8
12/20/2021 08:00	6.8	13.3	5.3	110.1	3,447,964.8	1,963.9	1.0	0.8
12/20/2021 09:00	6.1	13.7	5.0	94.0	3,206,213.7	1,638.9	0.9	0.5
12/20/2021 10:00	6.4	13.8	5.3	80.3	2,598,971.8	1,328.5	1.0	0.5
12/20/2021 11:00	6.4	13.7	5.2	94.5	3,132,510.1	1,624.1	1.0	0.6
12/20/2021 12:00	6.9	13.5	5.5	106.5	3,368,236.2	1,844.7	1.0	0.7
12/20/2021 13:00	7.7	13.1	5.8	123.3	3,438,575.1	2,084.1	1.2	1.0
12/20/2021 14:00	7.7	13.0	5.8	135.4	3,415,758.4	2,145.1	1.3	1.1
12/20/2021 15:00	7.6	13.0	5.7	135.4	3,407,478.2	2,139.9	1.3	1.1
12/20/2021 16:00	7.6	12.9	5.6	138.9	3,426,079.4	2,176.6	1.3	1.1
12/20/2021 17:00	7.5	12.9	5.5	138.4	3,438,199.6	2,184.3	1.3	1.1
12/20/2021 18:00	7.5	12.9	5.5	139.8	3,439,931.1	2,185.4	1.3	1.1
12/20/2021 19:00	7.6	12.9	5.6	140.8	3,411,422.9	2,192.2	1.4	1.1
12/20/2021 20:00	7.6	12.9	5.6	142.2	3,412,356.6	2,192.8	1.4	1.1
12/20/2021 21:00	7.6	12.9	5.6	143.5	3,415,780.1	2,195.0	1.4	1.1
12/20/2021 22:00	7.7	12.9	5.7	141.9	3,401,152.2	2,185.6	1.4	1.1
12/20/2021 23:00	7.3	13.1	5.5	123.6	3,417,786.3	2,071.5	1.2	1.0
Average/Sum#:	7.1	13.2	5.5	120.5	3,362,149.7	1,992.9	1.2	0.9
Minimum:	6.1	12.9	5.0	80.3	2,598,971.8	1,328.5	0.9	0.5
Maximum:	7.7	13.8	5.8	143.5	3,490,803.2	2,195.0	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/21/2021 00:00	7.2	13.2	5.5	120.4	3,433,704.8	2,031.0	1.1	0.8
12/21/2021 01:00	6.0	13.7	4.9	95.0	3,254,143.6	1,663.4	0.9	0.5
12/21/2021 02:00	6.3	13.7	5.2	101.1	3,430,311.6	1,778.5	0.9	0.5
12/21/2021 03:00	7.2	13.2	5.5	109.1	3,486,940.7	1,986.1	1.0	0.8
12/21/2021 04:00	6.7	13.3	5.2	106.3	3,422,332.0	1,949.3	1.0	0.8
12/21/2021 05:00	6.1	13.7	5.0	95.0	3,176,485.9	1,646.9	1.0	0.7
12/21/2021 06:00	6.3	13.7	5.2	96.9	3,338,309.5	1,730.8	0.9	0.5
12/21/2021 07:00	7.7	13.2	5.9	113.8	3,516,993.8	2,028.9	1.0	0.8
12/21/2021 08:00	7.8	12.9	5.8	130.4	3,487,843.4	2,164.9	1.2	1.1
12/21/2021 09:00	7.1	13.1	5.4	118.1	3,450,273.2	2,040.8	1.1	0.8
12/21/2021 10:00	6.1	13.7	5.0	91.7	3,124,830.8	1,597.3	0.9	0.5
12/21/2021 11:00	6.3	13.7	5.2	100.1	3,419,896.3	1,773.1	0.9	0.5
12/21/2021 12:00	7.2	13.3	5.6	111.5	3,497,405.9	2,017.6	1.0	0.8
12/21/2021 13:00	6.9	13.3	5.4	109.2	3,450,247.2	1,965.2	1.0	0.8
12/21/2021 14:00	6.1	13.7	5.0	93.7	3,152,569.2	1,634.5	1.0	0.7
12/21/2021 15:00	6.3	13.7	5.2	101.2	3,422,017.9	1,774.2	0.9	0.5
12/21/2021 16:00	7.2	13.2	5.5	111.5	3,500,526.1	2,019.4	1.0	0.8
12/21/2021 17:00	7.5	13.0	5.6	133.6	3,475,819.5	2,208.2	1.3	1.1
12/21/2021 18:00	7.4	13.0	5.5	136.9	3,449,393.3	2,216.6	1.3	1.1
12/21/2021 19:00	7.4	13.0	5.5	137.0	3,448,926.4	2,216.3	1.3	1.1
12/21/2021 20:00	7.4	13.0	5.5	137.1	3,443,324.2	2,212.7	1.3	1.1
12/21/2021 21:00	7.3	13.0	5.5	130.5	3,441,236.1	2,161.1	1.2	1.1
12/21/2021 22:00	7.0	13.1	5.3	117.4	3,465,144.7	2,074.9	1.1	0.8
12/21/2021 23:00	7.0	13.2	5.4	112.9	3,477,139.7	2,031.3	1.1	0.8
Average/Sum#:	6.9	13.3	5.4	112.9	3,406,909.0	1,955.1	1.1	0.8
Minimum:	6.0	12.9	4.9	91.7	3,124,830.8	1,597.3	0.9	0.5
Maximum:	7.8	13.7	5.9	137.1	3,516,993.8	2,216.6	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/22/2021 00:00	6.4	13.4	5.0	102.4	3,432,570.3	1,905.0	1.0	0.8
12/22/2021 01:00	6.2	13.7	5.1	92.4	3,126,787.1	1,598.3	0.9	0.5
12/22/2021 02:00	6.4	13.7	5.2	94.8	3,203,681.6	1,661.0	0.9	0.5
12/22/2021 03:00	6.5	13.4	5.1	103.3	3,482,121.9	1,932.5	1.0	0.8
12/22/2021 04:00	6.4	13.4	5.0	102.7	3,449,327.8	1,914.3	1.0	0.8
12/22/2021 05:00	6.2	13.8	5.2	85.8	2,830,991.5	1,447.1	1.0	0.6
12/22/2021 06:00	6.4	13.7	5.2	92.6	3,221,812.0	1,670.4	0.9	0.5
12/22/2021 07:00	7.2	13.3	5.6	107.2	3,443,926.8	1,961.6	1.0	0.8
12/22/2021 08:00	7.0	13.3	5.4	107.0	3,426,018.9	1,951.4	1.0	0.8
12/22/2021 09:00	6.3	13.8	5.2	85.4	2,785,996.1	1,424.1	1.0	0.6
12/22/2021 10:00	6.4	13.7	5.2	87.1	2,894,693.1	1,500.8	1.0	0.6
12/22/2021 11:00	7.1	13.3	5.5	107.9	3,444,453.5	1,961.9	1.0	0.8
12/22/2021 12:00	6.4	13.4	5.0	102.5	3,457,796.6	1,919.0	1.0	0.8
12/22/2021 13:00	6.1	13.7	5.0	92.4	3,096,442.1	1,605.4	1.0	0.6
12/22/2021 14:00	6.4	13.6	5.2	100.2	3,410,638.2	1,768.3	0.9	0.5
12/22/2021 15:00	7.2	13.3	5.6	109.1	3,453,758.5	1,967.2	1.0	0.8
12/22/2021 16:00	7.2	13.2	5.5	113.4	3,415,445.9	2,020.2	1.1	0.8
12/22/2021 17:00	7.3	13.1	5.5	123.2	3,431,223.2	2,104.7	1.2	1.1
12/22/2021 18:00	6.9	13.2	5.3	110.2	3,438,295.3	1,983.5	1.0	0.8
12/22/2021 19:00	6.7	13.3	5.2	105.5	3,415,133.7	1,945.2	1.0	0.8
12/22/2021 20:00	7.0	13.3	5.4	109.7	3,399,812.7	1,961.3	1.0	0.8
12/22/2021 21:00	6.2	13.7	5.1	88.8	2,995,126.8	1,531.0	1.0	0.6
12/22/2021 22:00	6.4	13.6	5.2	99.6	3,333,294.7	1,728.2	1.0	0.7
12/22/2021 23:00	7.3	13.2	5.6	112.6	3,423,903.3	2,000.2	1.1	0.8
Average/Sum#:	6.7	13.5	5.3	101.5	3,292,218.8	1,810.9	1.0	0.7
Minimum:	6.1	13.1	5.0	85.4	2,785,996.1	1,424.1	0.9	0.5
Maximum:	7.3	13.8	5.6	123.2	3,482,121.9	2,104.7	1.2	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/23/2021 00:00	6.7	13.3	5.2	104.7	3,392,971.2	1,907.8	1.0	0.8
12/23/2021 01:00	6.4	13.7	5.2	91.4	3,059,294.1	1,563.8	1.0	0.6
12/23/2021 02:00	6.8	13.6	5.5	94.5	3,082,362.1	1,598.1	1.0	0.6
12/23/2021 03:00	7.1	13.3	5.5	106.2	3,415,202.1	1,920.3	1.0	0.8
12/23/2021 04:00	6.8	13.3	5.3	104.4	3,372,518.8	1,896.3	1.0	0.8
12/23/2021 05:00	6.3	13.7	5.2	94.6	3,135,403.2	1,625.6	1.0	0.7
12/23/2021 06:00	6.8	13.6	5.5	98.9	3,077,400.9	1,618.0	1.0	0.6
12/23/2021 07:00	7.7	13.1	5.8	114.7	3,405,809.2	2,014.5	1.1	0.8
12/23/2021 08:00	7.0	13.3	5.4	106.1	3,351,578.4	1,909.0	1.0	0.8
12/23/2021 09:00	6.3	13.7	5.2	89.8	2,990,431.6	1,528.6	1.0	0.6
12/23/2021 10:00	6.6	13.6	5.3	93.8	3,130,581.3	1,623.1	1.0	0.6
12/23/2021 11:00	7.4	13.2	5.7	107.5	3,367,379.4	1,918.0	1.0	0.8
12/23/2021 12:00	7.3	13.3	5.7	106.5	3,322,083.1	1,892.2	1.0	0.8
12/23/2021 13:00	6.4	13.7	5.2	94.7	3,084,098.0	1,599.0	1.0	0.6
12/23/2021 14:00	6.6	13.8	5.5	79.8	2,543,608.0	1,300.2	1.0	0.5
12/23/2021 15:00	6.6	13.7	5.4	94.4	3,135,394.9	1,602.7	1.0	0.6
12/23/2021 16:00	7.4	13.3	5.7	106.7	3,316,198.1	1,816.2	1.0	0.7
12/23/2021 17:00	7.4	13.2	5.7	107.7	3,321,556.4	1,891.9	1.0	0.8
12/23/2021 18:00	6.8	13.6	5.5	96.7	3,162,598.8	1,639.7	1.0	0.7
12/23/2021 19:00	7.5	13.2	5.7	109.4	3,339,835.4	1,926.7	1.1	0.8
12/23/2021 20:00	7.4	13.2	5.7	107.4	3,317,518.4	1,889.6	1.0	0.8
12/23/2021 21:00	6.4	13.7	5.2	86.2	2,828,252.6	1,445.7	1.0	0.6
12/23/2021 22:00	6.9	13.6	5.6	93.0	3,009,840.5	1,560.5	1.0	0.6
12/23/2021 23:00	7.4	13.2	5.7	110.0	3,369,824.1	1,944.0	1.1	0.8
Average/Sum#:	6.9	13.5	5.5	100.0	3,188,822.5	1,734.6	1.0	0.7
Minimum:	6.3	13.1	5.2	79.8	2,543,608.0	1,300.2	1.0	0.5
Maximum:	7.7	13.8	5.8	114.7	3,415,202.1	2,014.5	1.1	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/24/2021 00:00	7.3	13.2	5.6	106.9	3,335,075.1	1,899.6	1.0	0.8
12/24/2021 01:00	6.4	13.7	5.2	88.8	2,933,307.0	1,499.4	1.0	0.6
12/24/2021 02:00	6.5	13.7	5.3	85.8	2,842,338.1	1,452.9	1.0	0.6
12/24/2021 03:00	6.5	13.8	5.4	79.9	2,619,708.8	1,339.1	1.0	0.5
12/24/2021 04:00	6.6	13.8	5.5	81.5	2,628,903.6	1,343.8	1.0	0.5
12/24/2021 05:00	6.6	13.7	5.4	100.2	3,373,674.8	1,724.5	0.9	0.5
12/24/2021 06:00	7.4	13.4	5.8	107.2	3,263,734.7	1,811.3	1.1	0.7
12/24/2021 07:00	7.1	13.4	5.6	106.4	3,327,160.7	1,846.5	1.0	0.7
12/24/2021 08:00	6.6	13.7	5.4	95.4	3,146,204.3	1,631.2	1.0	0.7
12/24/2021 09:00	7.2	13.3	5.6	107.1	3,390,203.2	1,931.0	1.0	0.8
12/24/2021 10:00	7.3	13.3	5.7	107.8	3,361,761.3	1,914.8	1.0	0.8
12/24/2021 11:00	6.4	13.8	5.3	83.9	2,737,658.0	1,379.4	1.0	0.6
12/24/2021 12:00	6.4	13.8	5.3	92.7	3,126,591.5	1,598.2	0.9	0.5
12/24/2021 13:00	6.5	13.8	5.4	84.6	2,783,702.4	1,402.6	1.0	0.6
12/24/2021 14:00	6.5	13.8	5.4	83.3	2,756,909.3	1,389.1	1.0	0.6
12/24/2021 15:00	6.5	13.8	5.4	87.1	2,877,747.5	1,471.0	1.0	0.6
12/24/2021 16:00	6.7	13.8	5.6	87.8	2,915,308.9	1,490.2	1.0	0.6
12/24/2021 17:00	7.8	13.2	6.0	111.2	3,369,824.1	1,944.0	1.1	0.8
12/24/2021 18:00	7.6	13.2	5.8	112.9	3,358,855.7	1,962.2	1.1	0.8
12/24/2021 19:00	7.5	13.2	5.7	114.0	3,373,234.6	1,970.6	1.1	0.8
12/24/2021 20:00	7.1	13.3	5.5	107.1	3,382,833.9	1,902.1	1.0	0.8
12/24/2021 21:00	6.5	13.8	5.4	84.6	2,751,550.7	1,386.4	1.0	0.6
12/24/2021 22:00	6.8	13.7	5.6	93.0	3,043,786.8	1,578.1	1.0	0.6
12/24/2021 23:00	7.7	13.2	5.9	114.3	3,411,920.9	1,993.2	1.1	0.8
Average/Sum#:	6.9	13.6	5.5	96.8	3,087,999.8	1,660.9	1.0	0.7
Minimum:	6.4	13.2	5.2	79.9	2,619,708.8	1,339.1	0.9	0.5
Maximum:	7.8	13.8	6.0	114.3	3,411,920.9	1,993.2	1.1	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/25/2021 00:00	7.2	13.3	5.6	107.2	3,364,570.4	1,916.4	1.0	0.8
12/25/2021 01:00	6.3	13.8	5.2	89.8	2,998,648.1	1,532.8	1.0	0.6
12/25/2021 02:00	6.4	13.8	5.3	83.2	2,795,386.4	1,428.9	1.0	0.6
12/25/2021 03:00	6.4	13.8	5.3	79.4	2,621,078.3	1,339.8	1.0	0.5
12/25/2021 04:00	6.9	13.7	5.7	92.3	3,003,089.8	1,557.0	1.0	0.6
12/25/2021 05:00	7.5	13.2	5.7	110.8	3,409,693.4	1,967.0	1.0	0.8
12/25/2021 06:00	6.8	13.3	5.3	105.4	3,367,555.0	1,918.1	1.0	0.8
12/25/2021 07:00	6.6	13.7	5.4	94.1	3,006,175.8	1,558.6	1.0	0.6
12/25/2021 08:00	6.5	13.7	5.3	92.9	3,054,202.1	1,583.5	1.0	0.6
12/25/2021 09:00	6.5	13.8	5.4	83.2	2,719,872.5	1,390.3	1.0	0.6
12/25/2021 10:00	6.6	13.7	5.4	94.1	3,103,385.7	1,609.0	1.0	0.6
12/25/2021 11:00	6.5	13.7	5.3	92.6	3,060,467.9	1,564.4	1.0	0.6
12/25/2021 12:00	6.5	13.7	5.3	90.7	2,997,278.7	1,532.1	1.0	0.6
12/25/2021 13:00	6.6	13.8	5.5	88.0	2,882,638.3	1,473.5	1.0	0.6
12/25/2021 14:00	6.6	13.8	5.5	93.7	3,095,877.3	1,582.5	1.0	0.6
12/25/2021 15:00	6.9	13.7	5.7	95.0	3,112,310.4	1,590.9	1.0	0.6
12/25/2021 16:00	7.7	13.3	6.0	111.2	3,351,177.1	1,884.3	1.1	0.8
12/25/2021 17:00	7.7	13.2	5.9	117.9	3,371,456.0	2,018.8	1.1	0.8
12/25/2021 18:00	7.5	13.1	5.7	118.3	3,373,460.1	2,020.0	1.1	0.8
12/25/2021 19:00	7.4	13.1	5.6	118.2	3,402,089.7	2,012.3	1.1	0.8
12/25/2021 20:00	6.8	13.4	5.3	104.8	3,386,390.9	1,904.1	1.0	0.8
12/25/2021 21:00	6.2	13.7	5.1	94.0	3,176,282.0	1,623.6	1.0	0.6
12/25/2021 22:00	6.6	13.7	5.4	92.6	3,071,423.3	1,570.0	1.0	0.6
12/25/2021 23:00	7.4	13.2	5.7	110.1	3,442,697.8	1,960.9	1.0	0.8
Average/Sum#:	6.8	13.6	5.5	98.3	3,131,967.0	1,689.1	1.0	0.7
Minimum:	6.2	13.1	5.1	79.4	2,621,078.3	1,339.8	1.0	0.5
Maximum:	7.7	13.8	6.0	118.3	3,442,697.8	2,020.0	1.1	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/26/2021 00:00	12.7	14.6	11.9	126.5	2,554,713.9	1,212.6	1.5	0.7
12/26/2021 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/26/2021 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/26/2021 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/26/2021 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/26/2021 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/26/2021 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/26/2021 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/26/2021 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/26/2021 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/26/2021 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/26/2021 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/26/2021 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/26/2021 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/26/2021 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
12/26/2021 15:00	22.8	18.0	46.4	0.0	1,268,585.0	203.8	-0.3	0.0
12/26/2021 16:00	36.6	16.0	44.1	140.6	2,034,451.1	713.1	2.1	0.6
12/26/2021 17:00	6.4	13.6	5.2	104.7	3,329,051.4	1,726.0	1.0	0.7
12/26/2021 18:00	6.6	13.6	5.3	100.6	3,338,888.1	1,731.1	1.0	0.7
12/26/2021 19:00	7.4	13.2	5.7	110.4	3,409,173.3	1,966.7	1.0	0.8
12/26/2021 20:00	7.2	13.3	5.6	111.4	3,395,652.4	1,958.9	1.1	0.8
12/26/2021 21:00	6.3	13.7	5.2	93.6	3,139,307.6	1,604.7	1.0	0.6
12/26/2021 22:00	6.5	13.6	5.3	97.6	3,257,301.3	1,688.8	1.0	0.7
12/26/2021 23:00	7.4	13.2	5.7	111.6	3,455,338.6	1,968.1	1.0	0.8
Average/Sum#:	12.0	14.3	14.0	99.7	2,918,246.3	1,477.4	1.0	0.6
Minimum:	6.3	13.2	5.2	0.0	1,268,585.0	203.8	-0.3	0.0
Maximum:	36.6	18.0	46.4	140.6	3,455,338.6	1,968.1	2.1	0.8
%SI	58.33	58.33	58.33	58.33	58.33	58.33	58.33	58.33

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/27/2021 00:00	7.5	13.1	5.7	114.1	3,431,092.8	2,004.4	1.1	0.8
12/27/2021 01:00	7.1	13.2	5.4	109.2	3,416,889.4	1,946.2	1.0	0.8
12/27/2021 02:00	6.2	13.7	5.1	95.2	3,189,976.3	1,630.6	1.0	0.7
12/27/2021 03:00	6.4	13.7	5.2	87.4	2,904,353.5	1,484.6	1.0	0.6
12/27/2021 04:00	6.4	13.8	5.3	88.1	2,926,068.6	1,495.7	1.0	0.6
12/27/2021 05:00	6.6	13.6	5.3	96.1	3,179,186.2	1,648.3	1.0	0.7
12/27/2021 06:00	7.5	13.2	5.7	113.9	3,428,525.1	2,002.9	1.1	0.8
12/27/2021 07:00	8.1	13.0	6.0	126.4	3,432,690.5	2,105.6	1.2	1.1
12/27/2021 08:00	7.7	13.0	5.8	122.9	3,431,480.5	2,079.8	1.2	1.0
12/27/2021 09:00	7.7	13.0	5.8	125.8	3,454,744.2	2,093.9	1.2	1.0
12/27/2021 10:00	7.6	13.1	5.7	120.9	3,420,220.9	2,048.0	1.1	0.8
12/27/2021 11:00	7.5	13.1	5.7	119.2	3,367,769.6	1,992.0	1.1	0.8
12/27/2021 12:00	6.0	13.8	5.0	95.9	3,276,836.9	1,675.0	0.9	0.5
12/27/2021 13:00	6.4	13.7	5.2	93.5	3,162,587.8	1,616.6	0.9	0.5
12/27/2021 14:00	7.4	13.3	5.7	110.9	3,413,553.6	1,944.3	1.0	0.8
12/27/2021 15:00	7.7	13.1	5.8	125.6	3,409,701.7	2,066.6	1.2	1.0
12/27/2021 16:00	7.9	12.9	5.8	147.8	3,403,019.6	2,186.8	1.4	1.1
12/27/2021 17:00	7.8	12.9	5.8	148.4	3,421,849.2	2,198.9	1.4	1.1
12/27/2021 18:00	7.7	12.9	5.7	145.8	3,419,514.9	2,197.4	1.4	1.1
12/27/2021 19:00	7.7	12.9	5.7	144.3	3,424,183.4	2,200.4	1.4	1.1
12/27/2021 20:00	7.7	12.9	5.7	146.1	3,426,984.5	2,202.2	1.4	1.1
12/27/2021 21:00	7.6	12.9	5.6	142.5	3,434,894.1	2,182.2	1.4	1.1
12/27/2021 22:00	7.2	13.1	5.4	120.0	3,458,557.4	2,045.7	1.1	0.8
12/27/2021 23:00	7.2	13.2	5.5	117.7	3,470,463.7	2,027.4	1.1	0.8
Average/Sum#:	7.3	13.2	5.6	119.1	3,346,047.7	1,961.5	1.2	0.9
Minimum:	6.0	12.9	5.0	87.4	2,904,353.5	1,484.6	0.9	0.5
Maximum:	8.1	13.8	6.0	148.4	3,470,463.7	2,202.2	1.4	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/28/2021 00:00	6.3	13.5	5.0	101.8	3,448,607.0	1,913.9	1.0	0.8
12/28/2021 01:00	6.1	13.8	5.1	86.7	2,960,304.3	1,513.2	0.9	0.5
12/28/2021 02:00	6.4	13.7	5.2	91.7	3,128,352.2	1,599.1	0.9	0.5
12/28/2021 03:00	6.6	13.4	5.2	103.8	3,483,563.4	1,933.3	1.0	0.8
12/28/2021 04:00	6.4	13.4	5.0	102.3	3,439,958.0	1,909.1	1.0	0.8
12/28/2021 05:00	6.1	13.8	5.1	90.0	3,030,731.8	1,549.2	1.0	0.6
12/28/2021 06:00	6.3	13.7	5.2	95.3	3,288,933.0	1,705.2	0.9	0.5
12/28/2021 07:00	7.2	13.3	5.6	107.0	3,484,918.3	1,959.5	1.0	0.8
12/28/2021 08:00	7.2	13.2	5.5	109.9	3,498,879.3	1,992.9	1.0	0.8
12/28/2021 09:00	7.0	13.3	5.4	108.9	3,449,018.2	1,964.5	1.0	0.8
12/28/2021 10:00	6.1	13.8	5.1	88.5	2,985,540.8	1,526.1	1.0	0.6
12/28/2021 11:00	6.4	13.8	5.3	83.3	2,774,453.8	1,418.2	1.0	0.6
12/28/2021 12:00	6.4	13.7	5.2	88.1	2,953,652.8	1,509.8	1.0	0.6
12/28/2021 13:00	6.8	13.5	5.4	104.8	3,409,681.7	1,842.5	1.0	0.7
12/28/2021 14:00	7.0	13.3	5.4	107.1	3,373,408.0	1,896.8	1.0	0.8
12/28/2021 15:00	6.3	13.7	5.2	95.3	3,189,408.7	1,653.6	1.0	0.7
12/28/2021 16:00	7.5	13.1	5.7	119.9	3,474,830.9	2,080.7	1.1	0.8
12/28/2021 17:00	7.7	12.9	5.7	138.0	3,491,560.0	2,218.2	1.3	1.1
12/28/2021 18:00	7.4	12.9	5.5	133.2	3,495,057.7	2,194.9	1.3	1.1
12/28/2021 19:00	7.2	13.0	5.4	124.0	3,472,632.0	2,130.1	1.2	1.1
12/28/2021 20:00	7.2	13.1	5.4	119.3	3,507,062.4	2,100.0	1.1	0.8
12/28/2021 21:00	7.0	13.1	5.3	115.3	3,479,183.3	2,057.9	1.1	0.8
12/28/2021 22:00	7.1	13.1	5.4	114.3	3,506,924.7	2,048.7	1.1	0.8
12/28/2021 23:00	7.0	13.2	5.4	109.7	3,459,616.7	1,995.8	1.0	0.8
Average/Sum#:	6.8	13.4	5.3	105.8	3,324,428.3	1,863.1	1.0	0.8
Minimum:	6.1	12.9	5.0	83.3	2,774,453.8	1,418.2	0.9	0.5
Maximum:	7.7	13.8	5.7	138.0	3,507,062.4	2,218.2	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/29/2021 00:00	6.3	13.4	5.0	102.2	3,441,759.9	1,910.1	1.0	0.8
12/29/2021 01:00	6.2	13.7	5.1	87.6	2,942,501.7	1,504.1	1.0	0.6
12/29/2021 02:00	6.4	13.7	5.2	91.0	3,023,727.6	1,567.7	1.0	0.6
12/29/2021 03:00	6.5	13.4	5.1	103.6	3,487,167.1	1,935.3	1.0	0.8
12/29/2021 04:00	6.4	13.4	5.0	102.8	3,463,922.9	1,922.4	1.0	0.8
12/29/2021 05:00	6.1	13.8	5.1	84.1	2,834,904.1	1,449.1	1.0	0.6
12/29/2021 06:00	6.3	13.7	5.2	97.0	3,359,525.9	1,741.8	0.9	0.5
12/29/2021 07:00	7.4	13.2	5.7	109.0	3,492,558.9	1,989.3	1.0	0.8
12/29/2021 08:00	6.9	13.3	5.4	107.6	3,431,285.9	1,954.4	1.0	0.8
12/29/2021 09:00	6.2	13.8	5.2	83.3	2,759,977.0	1,410.8	1.0	0.6
12/29/2021 10:00	6.4	13.7	5.2	92.1	3,107,821.8	1,611.3	0.9	0.5
12/29/2021 11:00	7.2	13.2	5.5	111.1	3,474,697.7	2,004.5	1.0	0.8
12/29/2021 12:00	6.4	13.4	5.0	103.1	3,443,742.0	1,911.2	1.0	0.8
12/29/2021 13:00	6.1	13.7	5.0	95.1	3,231,841.5	1,652.0	0.9	0.5
12/29/2021 14:00	6.4	13.7	5.2	95.7	3,204,067.3	1,661.2	1.0	0.7
12/29/2021 15:00	7.3	13.3	5.7	111.4	3,463,777.0	1,998.2	1.0	0.8
12/29/2021 16:00	7.3	13.2	5.6	118.0	3,447,943.4	2,064.6	1.1	0.8
12/29/2021 17:00	7.5	12.9	5.5	140.3	3,464,021.2	2,226.0	1.3	1.1
12/29/2021 18:00	7.4	12.9	5.5	139.1	3,449,704.5	2,216.8	1.3	1.1
12/29/2021 19:00	7.4	12.9	5.5	141.7	3,470,712.7	2,230.3	1.3	1.1
12/29/2021 20:00	7.4	12.9	5.5	140.9	3,471,179.6	2,230.6	1.3	1.1
12/29/2021 21:00	7.1	13.1	5.4	120.5	3,448,144.6	2,089.9	1.1	0.8
12/29/2021 22:00	6.8	13.3	5.3	106.2	3,450,422.7	1,965.3	1.0	0.8
12/29/2021 23:00	7.0	13.3	5.4	109.4	3,492,558.9	1,989.3	1.0	0.8
Average/Sum#:	6.8	13.4	5.3	108.0	3,327,415.2	1,884.8	1.0	0.8
Minimum:	6.1	12.9	5.0	83.3	2,759,977.0	1,410.8	0.9	0.5
Maximum:	7.5	13.8	5.7	141.7	3,492,558.9	2,230.6	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/30/2021 00:00	6.3	13.5	5.0	101.8	3,437,075.0	1,907.5	1.0	0.8
12/30/2021 01:00	6.1	13.7	5.0	93.6	3,186,650.5	1,628.9	0.9	0.5
12/30/2021 02:00	6.4	13.8	5.3	80.7	2,651,205.6	1,355.2	1.0	0.5
12/30/2021 03:00	6.3	13.7	5.2	98.1	3,328,087.0	1,725.5	0.9	0.5
12/30/2021 04:00	6.5	13.5	5.2	103.4	3,408,386.3	1,841.8	1.0	0.7
12/30/2021 05:00	6.3	13.6	5.1	100.1	3,319,484.7	1,818.0	1.0	0.7
12/30/2021 06:00	6.2	13.7	5.1	91.6	3,249,779.1	1,684.9	0.9	0.5
12/30/2021 07:00	7.4	13.2	5.7	111.1	3,541,366.6	2,017.1	1.0	0.8
12/30/2021 08:00	7.4	13.1	5.6	120.0	3,528,271.8	2,112.7	1.1	0.8
12/30/2021 09:00	6.8	13.2	5.2	112.1	3,479,551.3	2,007.3	1.0	0.8
12/30/2021 10:00	6.1	13.7	5.0	93.4	3,162,979.1	1,616.8	1.0	0.6
12/30/2021 11:00	6.3	13.7	5.2	94.9	3,188,830.0	1,653.3	1.0	0.7
12/30/2021 12:00	7.3	13.3	5.7	111.3	3,486,589.6	1,985.9	1.0	0.8
12/30/2021 13:00	6.4	13.4	5.0	102.9	3,413,650.7	1,894.5	1.0	0.8
12/30/2021 14:00	6.1	13.7	5.0	95.1	3,231,841.5	1,652.0	0.9	0.5
12/30/2021 15:00	6.5	13.7	5.3	93.3	3,129,330.3	1,599.6	1.0	0.6
12/30/2021 16:00	7.0	13.3	5.4	108.9	3,466,048.2	1,974.2	1.0	0.8
12/30/2021 17:00	7.4	13.1	5.6	122.7	3,419,648.3	2,097.6	1.2	1.0
12/30/2021 18:00	7.2	13.1	5.4	119.6	3,419,931.2	2,072.8	1.1	0.8
12/30/2021 19:00	6.7	13.3	5.2	108.6	3,435,175.1	1,981.7	1.0	0.8
12/30/2021 20:00	7.2	13.1	5.4	119.5	3,465,144.7	2,074.9	1.1	0.8
12/30/2021 21:00	7.1	13.1	5.4	119.9	3,420,591.1	2,073.2	1.1	0.8
12/30/2021 22:00	7.0	13.2	5.4	115.7	3,456,021.4	2,044.2	1.1	0.8
12/30/2021 23:00	6.9	13.2	5.3	109.8	3,475,044.4	2,004.7	1.0	0.8
Average/Sum#:	6.7	13.4	5.3	105.3	3,345,861.8	1,867.7	1.0	0.7
Minimum:	6.1	13.1	5.0	80.7	2,651,205.6	1,355.2	0.9	0.5
Maximum:	7.4	13.8	5.7	122.7	3,541,366.6	2,112.7	1.2	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 - NH3 Slip

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:35 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
12/31/2021 00:00	6.4	13.4	5.0	102.8	3,446,444.8	1,912.7	1.0	0.8
12/31/2021 01:00	6.1	13.8	5.1	87.2	2,972,042.2	1,519.2	0.9	0.5
12/31/2021 02:00	6.4	13.8	5.3	80.4	2,588,994.6	1,323.4	1.0	0.5
12/31/2021 03:00	6.3	13.7	5.2	98.4	3,319,986.2	1,721.3	0.9	0.5
12/31/2021 04:00	6.6	13.5	5.3	104.1	3,408,756.4	1,842.0	1.0	0.7
12/31/2021 05:00	6.5	13.5	5.2	101.8	3,324,414.6	1,820.7	1.0	0.7
12/31/2021 06:00	6.2	13.8	5.2	80.7	2,772,106.2	1,417.0	0.9	0.4
12/31/2021 07:00	7.5	13.2	5.7	111.5	3,462,563.6	1,997.5	1.0	0.8
12/31/2021 08:00	7.2	13.2	5.5	111.6	3,478,684.6	2,006.8	1.0	0.8
12/31/2021 09:00	6.3	13.4	5.0	102.4	3,449,868.3	1,914.6	1.0	0.8
12/31/2021 10:00	6.2	13.8	5.2	87.9	2,913,156.9	1,489.1	1.0	0.6
12/31/2021 11:00	6.4	13.8	5.3	85.3	2,838,229.9	1,450.8	1.0	0.6
12/31/2021 12:00	6.3	13.8	5.2	91.5	3,080,031.1	1,574.4	1.0	0.6
12/31/2021 13:00	6.6	13.9	5.6	80.4	2,580,273.4	1,300.1	1.0	0.5
12/31/2021 14:00	6.5	13.8	5.4	85.1	2,855,547.5	1,438.8	1.0	0.6
12/31/2021 15:00	6.8	13.7	5.6	94.8	3,131,159.9	1,623.4	1.0	0.6
12/31/2021 16:00	7.6	13.2	5.8	115.6	3,417,305.6	2,021.3	1.1	0.8
12/31/2021 17:00	7.6	13.1	5.7	128.8	3,416,550.8	2,095.7	1.2	1.0
12/31/2021 18:00	7.5	13.1	5.7	128.6	3,419,159.2	2,097.3	1.2	1.0
12/31/2021 19:00	7.5	13.0	5.6	132.0	3,414,377.8	2,119.3	1.3	1.1
12/31/2021 20:00	7.1	13.2	5.4	119.9	3,392,164.4	2,031.2	1.2	1.0
12/31/2021 21:00	6.0	13.8	5.0	89.7	3,063,989.2	1,566.2	0.9	0.5
12/31/2021 22:00	6.4	13.7	5.2	99.9	3,383,635.5	1,754.3	0.9	0.5
12/31/2021 23:00	7.1	13.4	5.6	107.5	3,490,230.3	1,937.0	1.0	0.8
Average/Sum#:	6.7	13.5	5.4	101.2	3,192,486.4	1,748.9	1.0	0.7
Minimum:	6.0	13.0	5.0	80.4	2,580,273.4	1,300.1	0.9	0.4
Maximum:	7.6	13.9	5.8	132.0	3,490,230.3	2,119.3	1.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Excess Emission Report

CT1 - NH3 LbPerHr 1-Hour Block Average

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 09:36 **Location:** Maxwell, CA

Tag Name: CT1_NH3slip_LbPerHr_1H
Total Operating Time: 1,647.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 561.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,647.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 - NH3 Ppmvdc 1-Hour Block Average

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 09:38 **Location:** Maxwell, CA

Tag Name: CT1_NH3Slip_Ppmvdc_1H
Total Operating Time: 1,647.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 561.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,647.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NH3 LbPerHr 1-Hour Block Average

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 09:39 **Location:** Maxwell, CA

Tag Name: CT2_NH3slip_LbPerHr_1H
Total Operating Time: 1,549.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 659.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,549.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT2 - NH3 Ppmvdc 1-Hour Block Average

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 09:39 **Location:** Maxwell, CA

Tag Name: CT2_NH3Slip_Ppmvdc_1H
Total Operating Time: 1,549.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 659.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,549.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 9
Quarterly/Annual Emissions
(Fuel Use, Hours of Operation, and NH_3 Injection)

FCD: AQ-23, 26
Title V: #6, 14

Emissions Limits per AQ-26

Quarterly and Annual Combustion Emissions from CGS Facility					
Pollutant	1st Quarter Emissions (tons)	2nd Quarter Emissions (tons)	3rd Quarter Emissions (tons)	4th Quarter Emissions (tons)	Annual Emissions (tons)
NO_x	45.56	43.58	51.30	44.27	184.7
CO	54.29	52.49	107.15	53.95	267.9
VOC's	12.30	11.63	11.84	11.76	47.5
PM10	25.54	25.78	26.02	26.02	103.4
SO_2	4.07	3.85	3.89	3.89	15.7

Notes

1. Emissions based on CT1 and CT2.
2. VOC Mass Emissions based on Average Source Test Results (lb/MMBtu). CT1 EF = 0.0009 prior to 10/30/2013 and 0.0007 after 10/30/2013. CT2 EF = 0.0007 prior to 11/01/2014 and 0.0003 after 11/01/2014.
3. PM10 based on 2010 lb/MMBtu Source Test Results. CT1 EF = 0.0025; CT2 EF = 0.003

Quarterly Emissions

Cumulative Emissions Report

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 09:40 **Location:** Maxwell, CA

Month	PlantWide NOx, Tons 1 Day(s)	PlantWide CO, Tons 1 Day(s)	PlantWide VOC, Tons 1 Day(s)	PlantWide PM10, Tons 1 Day(s)	PlantWide SO2, Tons 1 Day(s)
October	2.0	0.9	0.3	1.7	0.0
November	3.0	1.8	0.4	2.3	0.0
December	4.6	2.2	0.7	3.6	0.0
Quarter 4	9.6	4.9	1.4	7.6	0.0
YTD	9.6	4.9	1.4	7.6	0.0

Cumulative Emissions Report

From: 01/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 09:41 **Location:** Maxwell, CA

Month	PlantWide NOx, Tons 1 Day(s)	PlantWide CO, Tons 1 Day(s)	PlantWide VOC, Tons 1 Day(s)	PlantWide PM10, Tons 1 Day(s)	PlantWide SO2, Tons 1 Day(s)
January	3.3	1.3	0.4	2.4	0.0
February	2.9	0.9	0.4	2.1	0.0
March	0.0	0.0	0.0	0.0	0.0
April	0.6	0.4	0.0	0.1	0.0
May	1.0	1.4	0.1	0.2	0.0
June	1.1	1.7	0.1	0.4	0.0
July	3.3	1.5	0.5	2.5	0.0
August	4.6	1.5	0.6	3.5	0.0
September	3.9	1.3	0.6	3.1	0.0
October	2.0	0.9	0.3	1.7	0.0
November	3.0	1.8	0.4	2.3	0.0
December	4.6	2.2	0.7	3.6	0.0
Quarter 1	6.2	2.2	0.8	4.5	0.0
Quarter 2	2.7	3.5	0.2	0.7	0.0
Quarter 3	11.8	4.3	1.7	9.1	0.0
Quarter 4	9.6	4.9	1.4	7.6	0.0
YTD	30.3	14.9	4.1	21.9	0.0

Cumulative Emissions Report

CT1

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:42 **Location:** Maxwell, CA

Month	Unit CT1 GasFlowCT, 100scf 1 Day(s)	Unit CT1 GasFlowDB, 100scf 1 Day(s)	Unit CT1 GasFlow, Total, 100scf 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)
October	6,246,582	187,386	6,433,967.8	407	115.0
November	8,095,921	466,263	8,562,177.7	519	134.6
December	11,948,224	1,005,789	12,954,009.2	721	161.0
Quarter 4	26,290,727	1,659,438	27,950,154.7	1,647	136.9
YTD	26,290,727	1,659,438	27,950,154.7	1,647	136.9

Cumulative Emissions Report

CT2

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:42 **Location:** Maxwell, CA

Month	Unit CT2 GasFlowCT, 100scf 1 Day(s)	Unit CT2 GasFlowDB, 100scf 1 Day(s)	Unit CT2 GasFlow, Total, 100scf 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)
October	5,684,665	175,704	5,860,367.1	378	39,759.5
November	7,254,065	454,830	7,708,889.5	466	49,838.2
December	11,596,821	944,277	12,541,095.9	705	77,230.8
Quarter 4	24,535,551	1,574,811	26,110,352.5	1,549	166,828.5
YTD	24,535,551	1,574,811	26,110,352.5	1,549	166,828.5

Monthly Summary By Day Report

VOC PM10

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:43 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 VOC, Lb 1 Day(s)	Unit CT1 PM10, Lb 1 Day(s)	Unit CT2 VOC, Lb 1 Day(s)	Unit CT2 PM10, Lb 1 Day(s)
10/01/2021	27.1	95.8	4.9	48.4
10/02/2021	26.6	94.7	11.3	111.1
10/03/2021	25.3	91.1	10.8	107.2
10/04/2021	27.5	99.2	12.0	116.2
10/05/2021	27.2	97.1	11.7	113.8
10/06/2021	25.6	91.8	11.1	107.9
10/07/2021	27.4	97.4	11.8	114.0
10/08/2021	23.3	82.3	9.9	96.6
10/09/2021	0.0	0.0	0.0	0.0
10/10/2021	0.0	0.0	0.0	0.0
10/11/2021	0.0	0.0	0.0	0.0
10/12/2021	0.0	0.0	0.0	0.0
10/13/2021	0.0	0.0	0.0	0.0
10/14/2021	0.0	0.0	0.0	0.0
10/15/2021	0.0	0.0	0.0	0.0
10/16/2021	0.0	0.0	0.0	0.0
10/17/2021	0.0	0.0	0.0	0.0
10/18/2021	0.0	0.0	0.0	0.0
10/19/2021	0.0	0.0	0.0	0.0
10/20/2021	10.0	35.9	5.3	54.8
10/21/2021	0.0	0.0	0.0	0.0
10/22/2021	0.0	0.0	0.0	0.0
10/23/2021	22.7	81.0	8.0	77.6
10/24/2021	18.6	67.0	9.4	92.4
10/25/2021	29.2	103.9	9.2	91.3
10/26/2021	28.9	102.4	9.6	94.2
10/27/2021	30.3	108.9	12.8	127.5
10/28/2021	29.5	104.4	6.4	64.7
10/29/2021	32.4	115.0	13.8	133.2
10/30/2021	29.1	103.3	12.6	122.7
10/31/2021	29.8	105.9	12.9	124.5
Monthly Avg/Sum*:	470.5 *	1,677.1 *	183.5 *	1,798.1 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	32.4	115.0	13.8	133.2
Oct 2021 - Oct 2021	470.5	1,677.1	183.5	1,798.1
QTD:	470.5 *	1,677.1 *	183.5 *	1,798.1 *
YTD 2021:	4,297.1 *	15,298.2 *	1,667.7 *	16,761.7 *

Monthly Summary By Day Report

VOC PM10

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:43 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 VOC, Lb 1 Day(s)	Unit CT1 PM10, Lb 1 Day(s)	Unit CT2 VOC, Lb 1 Day(s)	Unit CT2 PM10, Lb 1 Day(s)
11/01/2021	32.6	116.4	13.6	136.2
11/02/2021	31.0	111.1	13.2	130.1
11/03/2021	31.6	111.7	13.1	130.9
11/04/2021	29.1	103.6	11.9	118.7
11/05/2021	28.9	101.8	5.6	55.2
11/06/2021	27.6	99.2	12.0	116.4
11/07/2021	0.0	0.0	0.0	0.0
11/08/2021	0.0	0.0	5.3	52.4
11/09/2021	19.4	69.6	9.9	99.4
11/10/2021	29.9	107.1	12.5	125.6
11/11/2021	18.8	66.0	6.0	60.7
11/12/2021	27.8	98.7	8.4	81.7
11/13/2021	16.2	58.2	4.7	46.9
11/14/2021	15.1	54.1	4.4	43.5
11/15/2021	29.2	102.5	8.8	85.9
11/16/2021	18.3	65.1	5.2	53.0
11/17/2021	33.5	118.7	13.9	138.2
11/18/2021	33.5	118.2	13.8	138.0
11/19/2021	33.4	119.0	14.1	138.3
11/20/2021	29.5	105.0	12.4	123.2
11/21/2021	18.3	65.1	5.9	58.8
11/22/2021	28.8	102.2	6.1	61.8
11/23/2021	30.2	107.1	12.8	125.5
11/24/2021	30.1	108.1	13.0	126.7
11/25/2021	0.1	0.3	0.0	0.4
11/26/2021	0.0	0.0	0.0	0.0
11/27/2021	0.0	0.0	0.0	0.0
11/28/2021	0.0	0.0	0.0	0.0
11/29/2021	15.7	55.3	4.4	43.4
11/30/2021	19.2	69.1	7.3	74.9
Monthly Avg/Sum*:	627.8 *	2,233.2 *	238.3 *	2,365.8 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	33.5	119.0	14.1	138.3
Oct 2021 - Nov 2021	1,098.3	3,910.3	421.8	4,163.9
QTD:	1,098.3 *	3,910.3 *	421.8 *	4,163.9 *
YTD 2021:	4,924.9 *	17,531.4 *	1,906.0 *	19,127.5 *

Monthly Summary By Day Report

VOC PM10

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:43 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 VOC, Lb 1 Day(s)	Unit CT1 PM10, Lb 1 Day(s)	Unit CT2 VOC, Lb 1 Day(s)	Unit CT2 PM10, Lb 1 Day(s)
12/01/2021	35.0	124.1	14.0	143.5
12/02/2021	21.0	74.5	9.5	94.1
12/03/2021	31.9	113.5	11.3	115.4
12/04/2021	22.3	79.1	6.1	62.4
12/05/2021	20.1	71.5	5.6	56.4
12/06/2021	33.5	119.2	13.7	139.2
12/07/2021	34.3	120.5	13.6	140.3
12/08/2021	30.1	108.3	12.5	126.4
12/09/2021	31.8	113.8	13.3	132.6
12/10/2021	31.3	111.9	13.2	130.7
12/11/2021	31.7	112.9	13.0	131.1
12/12/2021	31.4	112.5	13.2	131.4
12/13/2021	34.1	121.4	14.2	141.2
12/14/2021	32.1	114.7	13.4	133.9
12/15/2021	32.7	116.9	14.0	136.4
12/16/2021	33.1	118.8	14.2	138.4
12/17/2021	32.5	115.9	13.8	134.8
12/18/2021	31.8	113.7	13.4	132.5
12/19/2021	32.1	114.8	13.3	133.8
12/20/2021	34.7	124.3	14.5	143.5
12/21/2021	34.0	120.7	14.0	140.6
12/22/2021	31.1	111.0	13.2	130.5
12/23/2021	30.1	106.5	12.9	125.0
12/24/2021	28.6	101.8	11.9	119.5
12/25/2021	29.2	103.5	12.5	121.8
12/26/2021	14.6	52.0	4.2	42.0
12/27/2021	34.2	122.3	14.2	141.0
12/28/2021	32.1	114.8	13.7	134.1
12/29/2021	32.4	116.0	13.8	135.8
12/30/2021	32.1	114.9	13.4	134.6
12/31/2021	30.0	107.5	12.5	126.2
Monthly Avg/Sum*:	945.9 *	3,373.3 *	386.1 *	3,849.1 *
Daily Min:	14.6	52.0	4.2	42.0
Daily Max:	35.0	124.3	14.5	143.5
Oct 2021 - Dec 2021	2,044.2	7,283.6	807.9	8,013.0
QTD:	2,044.2 *	7,283.6 *	807.9 *	8,013.0 *
YTD 2021:	5,870.8 *	20,904.7 *	2,292.1 *	22,976.6 *

Monthly Summary By Day Report

CT1 and CT2 - Pounds

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:45 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)
10/01/2021	27.3	91.20	22.7	72.2	161.92	9.7
10/02/2021	20.1	72.30	22.8	0.0	137.30	22.6
10/03/2021	21.6	74.40	22.0	0.0	123.80	21.7
10/04/2021	29.6	82.70	24.2	0.0	145.70	23.1
10/05/2021	28.8	77.70	23.3	0.0	130.00	23.1
10/06/2021	31.5	83.60	22.2	0.0	122.20	21.7
10/07/2021	26.8	82.80	23.3	0.0	124.20	23.1
10/08/2021	28.3	74.37	19.7	4.9	106.30	19.3
10/09/2021	0.0	0.00	0.0	0.0	0.00	0.0
10/10/2021	0.0	0.00	0.0	0.0	0.00	0.0
10/11/2021	0.0	0.00	0.0	0.0	0.00	0.0
10/12/2021	0.0	0.00	0.0	0.0	0.00	0.0
10/13/2021	0.0	0.00	0.0	0.0	0.00	0.0
10/14/2021	0.0	0.00	0.0	0.0	0.00	0.0
10/15/2021	0.0	0.00	0.0	0.0	0.00	0.0
10/16/2021	0.0	0.00	0.0	0.0	0.00	0.0
10/17/2021	0.0	0.00	0.0	0.0	0.00	0.0
10/18/2021	0.0	0.00	0.0	0.0	0.00	0.0
10/19/2021	0.0	0.00	0.0	0.0	0.00	0.0
10/20/2021	181.2	143.41	8.6	322.1	184.25	11.0
10/21/2021	0.0	0.00	0.0	0.0	0.00	0.0
10/22/2021	0.0	0.00	0.0	0.0	0.00	0.0
10/23/2021	250.8	177.56	19.3	129.3	128.88	15.6
10/24/2021	155.7	101.47	15.8	91.6	89.54	18.4
10/25/2021	43.5	98.60	24.9	78.0	99.38	18.1
10/26/2021	22.6	107.30	24.7	69.9	84.00	18.7
10/27/2021	16.9	164.30	26.3	2.4	85.60	25.5
10/28/2021	15.9	131.90	24.8	76.8	120.73	13.1
10/29/2021	26.3	137.40	28.0	23.7	122.30	26.1
10/30/2021	17.2	124.20	24.9	6.1	82.40	24.4
10/31/2021	14.5	127.20	25.4	8.5	75.70	24.6
Monthly Avg/Sum*:	958.6 *	1,952.41 *	402.9 *	885.5 *	2,124.20 *	359.8 *
Daily Min:	14.5	72.30	8.6	0.0	75.70	9.7
Daily Max:	250.8	177.56	28.0	322.1	184.25	26.1
Oct 2021 - Oct 2021	958.6	1,952.41	402.9	885.5	2,124.20	359.8
QTD:	958.6 *	1,952.41 *	402.9 *	885.5 *	2,124.20 *	359.8 *
YTD 2021:	14,774.6 *	22,101.32 *	3,661.1 *	7,045.4 *	23,348.70 *	3,360.3 *

Monthly Summary By Day Report

CT1 and CT2 - Pounds

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:45 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)
11/01/2021	22.6	139.70	27.8	5.4	118.20	27.3
11/02/2021	20.7	188.30	26.7	8.1	96.90	26.4
11/03/2021	25.5	148.80	26.9	12.9	98.40	26.2
11/04/2021	20.1	124.40	24.8	12.4	79.28	23.7
11/05/2021	29.2	105.30	24.3	62.9	105.99	11.1
11/06/2021	36.6	123.59	23.9	26.6	75.85	23.2
11/07/2021	0.0	0.00	0.0	0.0	0.00	0.0
11/08/2021	0.0	0.00	0.0	200.2	177.99	10.6
11/09/2021	213.3	176.30	16.5	86.5	79.74	19.7
11/10/2021	30.1	128.20	25.9	18.1	81.50	25.1
11/11/2021	232.7	156.68	16.0	111.4	121.62	12.0
11/12/2021	26.7	118.20	23.5	98.4	85.60	16.2
11/13/2021	163.7	115.06	13.9	99.8	89.95	9.3
11/14/2021	175.1	130.17	12.9	92.1	95.96	8.6
11/15/2021	43.0	123.20	24.8	146.9	109.55	17.2
11/16/2021	186.6	132.36	15.6	118.5	141.69	10.6
11/17/2021	50.2	144.50	28.5	16.0	130.80	27.6
11/18/2021	52.6	143.60	28.7	18.5	116.80	27.5
11/19/2021	50.5	142.70	28.8	4.8	129.60	27.6
11/20/2021	19.1	126.00	25.2	1.3	99.50	24.7
11/21/2021	105.5	149.97	15.5	64.2	126.08	11.7
11/22/2021	25.7	122.70	24.3	89.7	130.78	12.3
11/23/2021	31.3	128.50	25.6	3.3	98.00	25.2
11/24/2021	27.1	131.70	26.2	5.0	109.40	25.4
11/25/2021	6.3	2.53	0.1	4.6	3.27	0.1
11/26/2021	0.0	0.00	0.0	0.0	0.00	0.0
11/27/2021	0.0	0.00	0.0	0.0	0.00	0.0
11/28/2021	0.0	0.00	0.0	0.0	0.00	0.0
11/29/2021	365.1	201.14	13.2	115.9	121.47	8.6
11/30/2021	72.8	112.88	16.1	58.7	115.34	14.7
Monthly Avg/Sum*:	2,032.1 *	3,316.48 *	535.7 *	1,482.2 *	2,739.26 *	472.6 *
Daily Min:	6.3	2.53	0.1	1.3	3.27	0.1
Daily Max:	365.1	201.14	28.8	200.2	177.99	27.6
Oct 2021 - Nov 2021	2,990.7	5,268.89	938.6	2,367.7	4,863.46	832.4
QTD:	2,990.7 *	5,268.89 *	938.6 *	2,367.7 *	4,863.46 *	832.4 *
YTD 2021:	16,806.7 *	25,417.80 *	4,196.8 *	8,527.6 *	26,087.96 *	3,832.9 *

Monthly Summary By Day Report

CT1 and CT2 - Pounds

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:45 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)
12/01/2021	50.6	150.60	30.0	15.9	164.20	28.6
12/02/2021	150.4	138.70	18.0	87.1	97.02	18.7
12/03/2021	80.1	153.40	27.6	121.4	164.49	22.9
12/04/2021	117.5	118.26	19.0	187.3	89.99	12.5
12/05/2021	251.0	143.71	17.0	101.4	135.80	11.4
12/06/2021	80.9	154.70	28.7	47.4	165.30	27.9
12/07/2021	69.7	158.10	28.8	40.5	168.50	28.1
12/08/2021	73.7	133.90	25.7	45.9	138.40	25.3
12/09/2021	71.0	146.60	27.3	48.3	160.00	26.7
12/10/2021	66.1	134.50	27.1	44.3	133.50	26.0
12/11/2021	76.2	141.50	27.1	39.3	141.10	26.2
12/12/2021	70.9	140.30	27.1	35.8	151.30	26.1
12/13/2021	74.9	153.10	29.3	41.7	178.60	28.3
12/14/2021	70.5	141.40	27.6	40.7	154.90	26.8
12/15/2021	74.3	144.50	28.2	43.8	154.00	27.2
12/16/2021	77.6	148.50	28.9	48.9	171.90	27.5
12/17/2021	71.2	145.20	27.7	51.8	156.00	26.7
12/18/2021	76.6	148.40	27.0	49.6	149.00	26.5
12/19/2021	81.7	146.30	27.7	46.0	158.30	26.8
12/20/2021	80.9	156.60	29.8	44.7	180.10	28.6
12/21/2021	78.8	154.40	29.2	47.8	174.10	28.1
12/22/2021	79.3	147.10	26.7	73.0	147.60	26.4
12/23/2021	72.8	138.80	25.9	57.2	141.60	25.1
12/24/2021	64.1	130.30	24.5	43.6	124.70	23.8
12/25/2021	64.7	133.70	25.2	40.3	127.50	24.2
12/26/2021	208.3	149.69	12.5	99.9	130.15	8.4
12/27/2021	78.4	159.60	29.2	36.6	175.70	28.2
12/28/2021	80.5	148.20	27.5	43.2	147.70	26.7
12/29/2021	82.1	147.60	28.0	56.3	154.80	27.0
12/30/2021	79.5	150.40	27.5	49.6	157.80	26.8
12/31/2021	70.1	130.90	25.9	40.5	132.10	25.3
Monthly Avg/Sum*:	2,724.4 *	4,488.96 *	811.7 *	1,769.8 *	4,626.15 *	768.8 *
Daily Min:	50.6	118.26	12.5	15.9	89.99	8.4
Daily Max:	251.0	159.60	30.0	187.3	180.10	28.6
Oct 2021 - Dec 2021	5,715.1	9,757.85	1,750.3	4,137.5	9,489.61	1,601.2
QTD:	5,715.1 *	9,757.85 *	1,750.3 *	4,137.5 *	9,489.61 *	1,601.2 *
YTD 2021:	19,531.1 *	29,906.76 *	5,008.5 *	10,297.4 *	30,714.11 *	4,601.7 *

Monthly Summary By Day Report

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 09:47 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 OperatingTime, Hr	Unit CT1 GasFlowCT, 100scf	Unit CT1 DBOn, Hr	Unit CT1 GasFlowDB, 100scf	Unit CT1 GasFlow, Total, 100scf	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/01/2021	24.00	364,781.4	1.49	2,626.3	367,407.7	2,488.2	38,320.600
10/02/2021	24.00	363,118.1	0.00	0.0	363,118.1	2,442.4	37,873.400
10/03/2021	24.00	349,982.5	0.00	0.0	349,982.5	2,384.1	36,503.300
10/04/2021	24.00	380,541.5	0.00	0.0	380,541.5	2,563.6	39,690.500
10/05/2021	24.00	372,015.7	0.00	0.0	372,015.7	2,509.9	38,801.100
10/06/2021	24.00	352,281.0	0.00	0.0	352,281.0	2,413.1	36,743.100
10/07/2021	24.00	372,964.2	0.00	0.0	372,964.2	2,521.8	38,900.400
10/08/2021	21.17	315,732.9	0.00	0.0	315,732.9	2,328.2	32,930.938
10/09/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/10/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/11/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/12/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/13/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/14/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/15/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/16/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/17/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/18/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/19/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/20/2021	8.81	125,824.7	4.94	11,572.3	137,397.0	1,254.5	14,330.500
10/21/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/22/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/23/2021	21.36	305,261.8	3.43	6,367.6	311,629.5	2,533.3	32,503.039
10/24/2021	16.73	249,882.2	3.50	7,343.9	257,226.1	2,004.6	26,828.421
10/25/2021	24.00	384,330.1	7.38	14,712.6	399,042.7	2,635.8	41,619.900
10/26/2021	24.00	376,228.5	8.09	17,626.1	393,854.6	2,863.7	41,078.900
10/27/2021	24.00	391,338.3	13.17	27,177.3	418,515.6	3,027.7	43,651.400
10/28/2021	24.00	369,852.1	10.78	29,839.7	399,691.8	3,155.3	41,687.900
10/29/2021	24.00	404,763.9	21.84	34,539.3	439,303.2	3,334.1	45,819.300
10/30/2021	24.00	377,942.4	9.78	18,497.3	396,439.7	3,060.2	41,348.800
10/31/2021	24.00	389,739.6	10.02	17,084.4	406,824.0	3,069.0	42,431.600
Monthly Avg/Sum*:	404.07 *	6,246,580.9 *	94.42 *	187,386.8 *	6,433,967.8 *	46,589.5 *	671,063.098 *
Daily Min:	8.81	125,824.7	0.00	0.0	137,397.0	1,254.5	14,330.500
Daily Max:	24.00	404,763.9	21.84	34,539.3	439,303.2	3,334.1	45,819.300
Oct 2021 - Oct 2021	404.07	6,246,580.9	94.42	187,386.8	6,433,967.8	46,589.5	671,063.098
QTD:	404.07 *	6,246,580.9 *	94.42 *	187,386.8 *	6,433,967.8 *	46,589.5 *	671,063.098 *
YTD 2021:	3,409.95 *	54,139,910.7 *	1,505.79 *	4,508,632.6 *	58,648,543.9 *	474,303.0 *	6,117,831.864 *

Monthly Summary By Day Report

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 09:47 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 OperatingTime, Hr	Unit CT1 GasFlowCT, 100scf	Unit CT1 DBOn, Hr	Unit CT1 GasFlowDB, 100scf	Unit CT1 GasFlow, Total, 100scf	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/01/2021	24.00	405,513.8	16.07	41,141.1	446,654.9	3,488.2	46,585.800
11/02/2021	24.00	393,597.9	13.24	32,174.8	425,772.7	3,009.8	44,408.000
11/03/2021	24.00	397,865.1	12.29	30,950.1	428,815.2	3,231.1	44,725.300
11/04/2021	24.00	380,027.5	8.97	17,296.9	397,324.4	2,991.0	41,441.000
11/05/2021	24.00	371,764.8	8.70	18,324.8	390,089.6	3,465.0	40,686.400
11/06/2021	22.73	366,042.0	8.66	14,106.8	380,148.8	2,946.5	39,649.498
11/07/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
11/08/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
11/09/2021	16.82	255,742.0	4.60	11,465.3	267,207.3	2,290.8	27,869.668
11/10/2021	24.00	391,819.9	10.81	18,375.6	410,195.5	3,090.7	42,783.600
11/11/2021	15.66	238,775.5	6.59	14,874.2	253,649.7	2,379.6	26,455.746
11/12/2021	24.00	366,981.9	6.59	10,894.4	377,876.3	3,017.0	39,412.600
11/13/2021	14.64	216,080.0	3.77	6,555.4	222,635.3	2,138.9	23,220.934
11/14/2021	14.22	201,645.7	3.79	5,950.8	207,596.5	1,874.3	21,652.498
11/15/2021	24.00	378,342.6	11.07	15,463.0	393,805.6	3,014.6	41,074.200
11/16/2021	15.70	232,810.0	6.80	17,126.6	249,936.6	2,337.8	26,068.315
11/17/2021	24.00	412,126.6	20.76	42,299.2	454,425.8	3,507.9	47,396.700
11/18/2021	24.00	413,774.3	20.69	39,437.9	453,212.2	3,452.3	47,270.400
11/19/2021	24.00	417,174.5	20.91	38,504.7	455,679.2	3,523.3	47,527.100
11/20/2021	24.00	385,190.7	8.78	17,302.5	402,493.2	3,161.6	41,980.000
11/21/2021	16.23	242,094.7	4.70	8,044.0	250,138.7	2,125.7	26,089.647
11/22/2021	24.00	373,357.6	7.96	18,760.2	392,117.8	3,040.2	40,897.900
11/23/2021	24.00	391,952.7	11.06	18,793.8	410,746.5	3,151.2	42,840.900
11/24/2021	24.00	396,295.7	11.05	18,229.8	414,525.5	3,246.2	43,235.300
11/25/2021	0.23	1,272.7	0.00	0.0	1,272.7	174.7	132.733
11/26/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
11/27/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
11/28/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
11/29/2021	15.65	202,726.8	4.14	8,787.8	211,514.6	2,508.9	22,060.881
11/30/2021	18.28	262,941.0	0.98	1,402.1	264,343.1	2,309.7	27,571.132
Monthly Avg/Sum*:	510.16 *	8,095,916.0 *	232.98 *	466,261.8 *	8,562,177.7 *	69,477.0 *	893,036.252 *
Daily Min:	0.23	1,272.7	0.00	0.0	1,272.7	174.7	132.733
Daily Max:	24.00	417,174.5	20.91	42,299.2	455,679.2	3,523.3	47,527.100
Oct 2021 - Nov 2021	914.23	14,342,496.9	327.40	653,648.6	14,996,145.5	116,066.5	1,564,099.350
QTD:	914.23 *	14,342,496.9 *	327.40 *	653,648.6 *	14,996,145.5 *	116,066.5 *	1,564,099.350 *
YTD 2021:	3,920.11 *	62,235,826.7 *	1,738.77 *	4,974,894.4 *	67,210,721.6 *	543,780.0 *	7,010,868.116 *

Monthly Summary By Day Report

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 09:47 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 OperatingTime, Hr	Unit CT1 GasFlowCT, 100scf	Unit CT1 DBOn, Hr	Unit CT1 GasFlowDB, 100scf	Unit CT1 GasFlow, Total, 100scf	Unit CT1 NH3, Inj, LbPerHr	Unit CT1 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/01/2021	24.00	405,499.8	19.75	69,654.4	475,154.2	4,195.6	49,558.800
12/02/2021	18.17	280,764.2	2.79	4,357.0	285,121.2	2,502.8	29,738.161
12/03/2021	24.00	394,703.5	13.04	41,097.7	435,801.2	3,939.0	45,453.900
12/04/2021	19.38	301,213.2	2.44	2,622.8	303,836.0	3,472.6	31,690.172
12/05/2021	16.72	254,239.8	7.02	19,506.4	273,746.2	2,773.3	28,551.500
12/06/2021	24.00	417,563.5	17.04	40,679.6	458,243.1	4,003.3	47,794.700
12/07/2021	24.00	413,572.4	16.30	49,135.1	462,707.5	4,157.1	48,260.500
12/08/2021	24.00	391,390.7	12.43	24,088.0	415,478.7	3,609.7	43,334.400
12/09/2021	24.00	402,430.7	16.22	33,494.9	435,925.6	3,769.8	45,467.100
12/10/2021	24.00	400,950.9	12.55	27,903.0	428,853.9	3,714.1	44,729.500
12/11/2021	24.00	396,635.9	14.03	35,972.9	432,608.8	3,853.2	45,121.400
12/12/2021	24.00	399,112.5	13.26	32,589.5	431,702.0	3,826.5	45,026.600
12/13/2021	24.00	412,078.9	18.09	54,437.6	466,516.5	4,174.5	48,596.800
12/14/2021	24.00	404,096.9	14.81	36,546.6	440,643.5	3,923.2	45,870.900
12/15/2021	24.00	407,715.4	15.53	41,720.1	449,435.5	4,113.7	46,786.100
12/16/2021	24.00	409,743.5	17.12	46,610.4	456,353.9	4,194.4	47,506.500
12/17/2021	24.00	404,782.3	15.05	40,438.1	445,220.4	3,973.5	46,347.400
12/18/2021	24.00	407,672.6	13.90	29,090.7	436,763.3	3,812.0	45,467.000
12/19/2021	24.00	410,065.3	15.72	30,637.4	440,702.7	3,811.8	45,877.200
12/20/2021	24.00	420,342.1	18.52	56,340.8	476,682.9	4,266.8	49,622.800
12/21/2021	24.00	422,947.0	16.03	41,252.7	464,199.7	4,068.6	48,323.300
12/22/2021	24.00	404,573.3	14.12	22,291.2	426,864.5	3,691.0	44,436.700
12/23/2021	24.00	392,863.8	11.60	16,019.9	408,883.7	3,497.8	42,564.700
12/24/2021	24.00	378,108.0	9.24	13,545.6	391,653.6	3,396.0	40,770.900
12/25/2021	24.00	382,960.7	8.92	15,211.6	398,172.3	3,485.5	41,449.800
12/26/2021	13.67	194,895.4	3.22	4,806.3	199,701.7	2,197.6	20,788.987
12/27/2021	24.00	414,610.3	17.84	54,753.7	469,364.0	4,243.9	48,860.600
12/28/2021	24.00	408,890.3	15.55	32,662.1	441,552.4	3,827.6	45,965.700
12/29/2021	24.00	410,640.6	16.14	35,962.9	446,603.5	3,915.6	46,491.300
12/30/2021	24.00	412,066.6	15.25	29,676.1	441,742.7	3,835.8	45,985.400
12/31/2021	24.00	391,092.3	11.29	22,681.7	413,774.0	3,672.4	43,074.100
Monthly Avg/Sum*:	715.94 *	11,948,222.4 *	414.81 *	1,005,786.8 *	12,954,009.2 *	115,918.7 *	1,349,512.920 *
Daily Min:	13.67	194,895.4	2.44	2,622.8	199,701.7	2,197.6	20,788.987
Daily Max:	24.00	422,947.0	19.75	69,654.4	476,682.9	4,266.8	49,622.800
Oct 2021 - Dec 2021	1,630.17	26,290,719.3	742.21	1,659,435.4	27,950,154.7	231,985.2	2,913,612.270
QTD:	1,630.17 *	26,290,719.3 *	742.21 *	1,659,435.4 *	27,950,154.7 *	231,985.2 *	2,913,612.270 *
YTD 2021:	4,636.05 *	74,184,049.1 *	2,153.58 *	5,980,681.2 *	80,164,730.8 *	659,698.7 *	8,360,381.036 *

Monthly Summary By Day Report

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 09:47 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 OperatingTime, Hr	Unit CT2 GasFlowCT, 100scf	Unit CT2 DBOn, Hr	Unit CT2 GasFlowDB, 100scf	Unit CT2 GasFlow, Total, 100scf	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/01/2021	10.55	157,648.6	0.00	0.0	157,648.6	1,244.5	16,127.415
10/02/2021	24.00	361,522.8	0.00	0.0	361,522.8	2,463.9	36,983.600
10/03/2021	24.00	348,869.5	0.00	0.0	348,869.5	2,386.1	35,689.400
10/04/2021	24.00	378,764.8	0.00	0.0	378,764.8	2,629.9	38,747.800
10/05/2021	24.00	370,995.1	0.00	0.0	370,995.1	2,565.8	37,952.600
10/06/2021	24.00	351,307.1	0.00	0.0	351,307.1	2,357.7	35,938.600
10/07/2021	24.00	371,915.0	0.00	0.0	371,915.0	2,522.2	38,046.700
10/08/2021	21.20	315,093.2	0.00	0.0	315,093.2	2,259.5	32,233.840
10/09/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/10/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/11/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/12/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/13/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/14/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/15/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/16/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/17/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/18/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/19/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/20/2021	13.48	167,947.2	4.85	11,069.8	179,017.0	1,840.4	18,313.381
10/21/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/22/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
10/23/2021	16.81	247,173.2	3.48	6,565.3	253,738.7	1,730.2	25,957.573
10/24/2021	19.56	293,997.1	3.41	6,735.0	300,732.1	2,241.3	30,765.140
10/25/2021	17.91	282,805.6	7.52	14,351.1	297,156.7	2,120.1	30,399.115
10/26/2021	18.50	290,732.8	8.09	16,461.1	307,193.9	2,095.4	31,426.050
10/27/2021	24.00	389,595.8	13.00	25,103.6	414,699.4	2,486.5	42,423.600
10/28/2021	12.30	185,393.2	8.05	25,711.7	211,104.9	1,458.5	21,596.082
10/29/2021	24.00	399,955.0	21.86	34,342.8	434,297.8	2,546.9	44,428.600
10/30/2021	24.00	382,055.8	9.80	18,541.5	400,597.3	2,408.1	40,981.100
10/31/2021	24.00	388,892.1	10.00	16,821.1	405,713.2	2,402.5	41,504.400
Monthly Avg/Sum*:	370.31 *	5,684,663.9 *	90.06 *	175,703.0 *	5,860,367.1 *	39,759.5 *	599,514.996 *
Daily Min:	10.55	157,648.6	0.00	0.0	157,648.6	1,244.5	16,127.415
Daily Max:	24.00	399,955.0	21.86	34,342.8	434,297.8	2,629.9	44,428.600
Oct 2021 - Oct 2021	370.31	5,684,663.9	90.06	175,703.0	5,860,367.1	39,759.5	599,514.996
QTD:	370.31 *	5,684,663.9 *	90.06 *	175,703.0 *	5,860,367.1 *	39,759.5 *	599,514.996 *
YTD 2021:	3,144.29 *	50,409,028.2 *	1,498.93 *	4,205,931.7 *	54,614,960.3 *	387,975.3 *	5,587,111.275 *

Monthly Summary By Day Report

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 09:47 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 OperatingTime, Hr	Unit CT2 GasFlowCT, 100scf	Unit CT2 DBOn, Hr	Unit CT2 GasFlowDB, 100scf	Unit CT2 GasFlow, Total, 100scf	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/01/2021	24.00	404,152.5	16.04	39,328.5	443,481.0	2,655.0	45,368.200
11/02/2021	24.00	392,572.9	13.22	31,592.7	424,165.6	2,542.1	43,392.200
11/03/2021	24.00	396,919.5	12.29	29,527.4	426,446.9	2,553.8	43,625.800
11/04/2021	23.38	369,038.1	8.95	17,102.2	386,140.3	2,411.8	39,502.374
11/05/2021	10.68	167,329.7	6.05	12,493.5	179,823.2	1,196.9	18,395.924
11/06/2021	22.73	365,089.5	8.61	13,752.6	378,842.1	2,317.3	38,755.713
11/07/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
11/08/2021	10.94	154,946.4	6.86	16,090.4	171,036.8	1,540.4	17,496.986
11/09/2021	20.35	313,210.8	4.60	11,059.5	324,270.3	2,279.7	33,172.825
11/10/2021	24.00	390,615.7	10.81	17,912.1	408,527.8	2,403.3	41,792.400
11/11/2021	11.78	182,959.6	6.59	14,578.5	197,538.1	1,485.8	20,208.019
11/12/2021	16.83	255,249.3	6.59	10,701.2	265,950.5	1,927.4	27,206.651
11/13/2021	9.91	147,072.9	3.74	6,361.6	153,434.5	1,257.4	15,696.307
11/14/2021	9.22	135,366.8	3.79	5,869.1	141,235.9	950.0	14,448.440
11/15/2021	16.84	264,528.4	11.05	15,231.1	279,759.5	1,953.9	28,619.442
11/16/2021	10.43	157,319.4	6.80	15,805.9	173,125.3	1,380.5	17,710.931
11/17/2021	24.00	411,104.4	20.71	39,358.6	450,463.0	2,658.6	46,082.300
11/18/2021	24.00	412,549.3	20.69	37,213.5	449,762.8	2,616.3	46,010.800
11/19/2021	24.00	415,201.8	20.91	36,078.3	451,280.1	2,651.1	46,165.900
11/20/2021	24.00	384,451.7	8.80	16,720.9	401,172.6	2,420.4	41,040.200
11/21/2021	12.40	184,553.7	4.70	7,753.9	192,307.6	1,375.4	19,672.994
11/22/2021	12.10	187,904.8	5.94	13,979.0	201,883.8	1,469.5	20,652.709
11/23/2021	24.00	390,552.2	11.05	18,353.7	408,905.9	2,410.8	41,831.000
11/24/2021	24.00	394,942.7	11.03	18,027.8	412,970.5	2,458.4	42,246.800
11/25/2021	0.23	1,277.2	0.00	0.0	1,277.2	150.3	130.663
11/26/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
11/27/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
11/28/2021	0.00	0.0	0.00	0.0	0.0	0.0	0.000
11/29/2021	9.17	132,620.7	4.16	8,518.0	141,138.7	1,089.3	14,438.550
11/30/2021	15.38	242,533.0	0.98	1,416.5	243,949.5	1,682.8	24,955.978
Monthly Avg/Sum*:	452.37 *	7,254,063.0 *	234.96 *	454,826.5 *	7,708,889.5 *	49,838.2 *	788,620.106 *
Daily Min:	0.23	1,277.2	0.00	0.0	1,277.2	150.3	130.663
Daily Max:	24.00	415,201.8	20.91	39,358.6	451,280.1	2,658.6	46,165.900
Oct 2021 - Nov 2021	822.68	12,938,726.9	325.02	630,529.5	13,569,256.6	89,597.7	1,388,135.102
QTD:	822.68 *	12,938,726.9 *	325.02 *	630,529.5 *	13,569,256.6 *	89,597.7 *	1,388,135.102 *
YTD 2021:	3,596.66 *	57,663,091.2 *	1,733.89 *	4,660,758.2 *	62,323,849.8 *	437,813.5 *	6,375,731.381 *

Monthly Summary By Day Report

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 09:47 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 OperatingTime, Hr	Unit CT2 GasFlowCT, 100scf	Unit CT2 DBOn, Hr	Unit CT2 GasFlowDB, 100scf	Unit CT2 GasFlow, Total, 100scf	Unit CT2 NH3, Inj, LbPerHr	Unit CT2 HI, MBtu
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/01/2021	24.00	402,884.3	19.75	64,138.3	467,022.6	2,917.3	47,776.300
12/02/2021	20.45	302,551.9	2.79	4,287.3	306,839.2	2,166.6	31,389.710
12/03/2021	21.14	337,334.9	13.02	38,658.3	375,993.2	2,779.1	38,464.206
12/04/2021	13.90	201,236.8	1.62	1,688.8	202,925.6	2,143.1	20,759.238
12/05/2021	10.40	165,208.2	7.05	18,659.7	183,867.9	1,214.7	18,809.660
12/06/2021	24.00	415,024.5	17.00	39,027.5	454,052.0	2,706.8	46,449.400
12/07/2021	24.00	411,052.6	16.32	46,469.0	457,521.6	2,813.1	46,804.500
12/08/2021	24.00	389,283.7	12.43	23,404.1	412,687.8	2,473.1	42,217.800
12/09/2021	24.00	399,281.1	16.22	32,808.3	432,089.4	2,590.0	44,202.700
12/10/2021	24.00	398,539.7	12.53	26,858.0	425,397.7	2,540.0	43,518.300
12/11/2021	24.00	393,945.4	14.03	33,669.8	427,615.2	2,551.8	43,744.900
12/12/2021	24.00	397,709.1	13.26	30,631.0	428,340.1	2,586.7	43,819.000
12/13/2021	24.00	410,009.6	18.09	50,195.4	460,205.0	2,835.3	47,078.700
12/14/2021	24.00	401,858.0	14.81	33,886.3	435,744.3	2,617.5	44,576.600
12/15/2021	24.00	406,217.0	15.50	38,001.5	444,218.5	2,671.3	45,443.600
12/16/2021	24.00	407,175.4	17.30	43,856.3	451,031.7	2,753.1	46,140.600
12/17/2021	24.00	402,072.0	15.03	36,517.4	438,589.4	2,716.0	44,867.800
12/18/2021	24.00	404,940.9	13.79	26,626.6	431,567.5	2,533.6	44,149.300
12/19/2021	24.00	407,233.5	15.72	29,395.3	436,628.8	2,559.3	44,667.300
12/20/2021	24.00	417,357.9	18.48	50,178.7	467,536.6	2,892.4	47,829.000
12/21/2021	24.00	419,664.0	16.06	39,015.9	458,679.9	2,710.4	46,923.000
12/22/2021	24.00	402,662.2	14.10	22,193.7	424,855.9	2,435.8	43,462.600
12/23/2021	24.00	390,963.6	11.58	15,993.6	406,957.2	2,399.1	41,631.500
12/24/2021	24.00	376,214.9	9.24	13,434.7	389,649.6	2,323.5	39,861.200
12/25/2021	24.00	381,442.2	8.90	14,832.2	396,274.4	2,359.5	40,538.800
12/26/2021	8.70	132,176.7	3.24	4,718.6	136,895.3	997.0	14,004.460
12/27/2021	24.00	411,415.1	17.84	48,755.7	460,170.8	2,857.7	47,075.500
12/28/2021	24.00	406,030.4	15.55	31,046.4	437,076.8	2,538.2	44,713.200
12/29/2021	24.00	407,406.6	16.12	34,785.5	442,192.1	2,592.8	45,236.200
12/30/2021	24.00	409,164.0	15.34	29,002.2	438,166.2	2,528.1	44,824.300
12/31/2021	24.00	388,763.2	11.35	21,540.4	410,303.6	2,427.9	41,974.100
Monthly Avg/Sum*:	698.59 *	11,596,819.4 *	414.06 *	944,276.5 *	12,541,095.9 *	77,230.8 *	1,282,953.474 *
Daily Min:	8.70	132,176.7	1.62	1,688.8	136,895.3	997.0	14,004.460
Daily Max:	24.00	419,664.0	19.75	64,138.3	467,536.6	2,917.3	47,829.000
Oct 2021 - Dec 2021	1,521.27	24,535,546.3	739.08	1,574,806.0	26,110,352.5	166,828.5	2,671,088.576
QTD:	1,521.27 *	24,535,546.3 *	739.08 *	1,574,806.0 *	26,110,352.5 *	166,828.5 *	2,671,088.576 *
YTD 2021:	4,295.25 *	69,259,910.6 *	2,147.95 *	5,605,034.7 *	74,864,945.7 *	515,044.3 *	7,658,684.855 *

ATTACHMENT 10
Maximum Emissions

FCD: AQ-25
Title V: #6

AQ-25 Emission Limits

Maximum Emissions Both Turbines (lbs)		
Pollutant	1-Hour Emissions	24-Hour Emissions
NO_x	666.60	2,994.60
CO	967.00	7,659.00
VOC	55.40	630.60
PM10	27.00	648.00
SO_2	14.80	355.20

Monthly Summary By Day Report

AQ-25

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:48 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	PlantWide NOx, Lb 1 Day(s)	PlantWide CO, Lb 1 Day(s)	PlantWide VOC, Lb 1 Day(s)	PlantWide PM10, Lb 1 Day(s)	PlantWide SO2, Lb 1 Day(s)
10/01/2021	253.1	99.5	32.0	144.2	9.7
10/02/2021	209.6	20.1	37.9	205.8	22.6
10/03/2021	198.2	21.6	36.1	198.3	21.7
10/04/2021	228.4	29.6	39.5	215.4	23.1
10/05/2021	207.7	28.8	38.9	210.9	23.1
10/06/2021	205.8	31.5	36.7	199.7	21.7
10/07/2021	207.0	26.8	39.2	211.4	23.1
10/08/2021	180.7	33.2	33.2	178.9	19.3
10/09/2021	0.0	0.0	0.0	0.0	0.0
10/10/2021	0.0	0.0	0.0	0.0	0.0
10/11/2021	0.0	0.0	0.0	0.0	0.0
10/12/2021	0.0	0.0	0.0	0.0	0.0
10/13/2021	0.0	0.0	0.0	0.0	0.0
10/14/2021	0.0	0.0	0.0	0.0	0.0
10/15/2021	0.0	0.0	0.0	0.0	0.0
10/16/2021	0.0	0.0	0.0	0.0	0.0
10/17/2021	0.0	0.0	0.0	0.0	0.0
10/18/2021	0.0	0.0	0.0	0.0	0.0
10/19/2021	0.0	0.0	0.0	0.0	0.0
10/20/2021	327.7	503.3	15.3	90.7	11.0
10/21/2021	0.0	0.0	0.0	0.0	0.0
10/22/2021	0.0	0.0	0.0	0.0	0.0
10/23/2021	306.5	380.1	30.7	158.6	15.6
10/24/2021	191.0	247.3	28.0	159.4	18.4
10/25/2021	198.0	121.5	38.4	195.2	18.1
10/26/2021	191.3	92.5	38.5	196.6	18.7
10/27/2021	249.9	19.3	43.1	236.4	25.5
10/28/2021	252.6	92.7	35.9	169.1	13.1
10/29/2021	259.7	50.0	46.2	248.2	26.1
10/30/2021	206.6	23.3	41.7	226.0	24.4
10/31/2021	202.9	23.0	42.7	230.4	24.6
Monthly Avg/Sum*:	4,076.7 *	1,844.1 *	654.0 *	3,475.2 *	- *
Daily Min:	0.0	0.0	0.0	0.0	-
Daily Max:	327.7	503.3	46.2	248.2	-
Oct 2021 - Oct 2021	4,076.7	1,844.1	654.0	3,475.2	-
QTD:	4,076.7 *	1,844.1 *	654.0 *	3,475.2 *	0.0 *
YTD 2021:	45,450.9 *	21,820.0 *	5,964.8 *	32,059.9 *	7.7 *

Monthly Summary By Day Report

AQ-25

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:48 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	PlantWide NOx, Lb 1 Day(s)	PlantWide CO, Lb 1 Day(s)	PlantWide VOC, Lb 1 Day(s)	PlantWide PM10, Lb 1 Day(s)	PlantWide SO2, Lb 1 Day(s)
11/01/2021	257.9	28.0	46.2	252.6	27.3
11/02/2021	285.2	28.8	44.2	241.2	26.4
11/03/2021	247.2	38.4	44.7	242.6	26.2
11/04/2021	203.7	32.5	41.0	222.3	23.7
11/05/2021	211.3	92.1	34.5	157.0	11.1
11/06/2021	199.5	63.2	39.6	215.6	23.2
11/07/2021	0.0	0.0	0.0	0.0	0.0
11/08/2021	178.0	200.2	5.3	52.4	10.6
11/09/2021	256.0	299.8	29.3	169.0	19.7
11/10/2021	209.7	48.2	42.4	232.7	25.1
11/11/2021	278.3	344.1	24.8	126.7	12.0
11/12/2021	203.8	125.1	36.2	180.4	16.2
11/13/2021	205.1	263.5	20.9	105.1	9.3
11/14/2021	226.2	267.2	19.5	97.6	8.6
11/15/2021	232.8	189.9	38.0	188.4	17.2
11/16/2021	274.1	305.1	23.5	118.1	10.6
11/17/2021	275.3	66.2	47.4	256.9	27.6
11/18/2021	260.4	71.1	47.3	256.2	27.5
11/19/2021	272.3	55.3	47.5	257.3	27.6
11/20/2021	225.5	20.4	41.9	228.2	24.7
11/21/2021	276.1	169.7	24.2	123.9	11.7
11/22/2021	253.5	115.4	34.9	164.0	12.3
11/23/2021	226.5	34.6	43.0	232.6	25.2
11/24/2021	241.1	32.1	43.1	234.8	25.4
11/25/2021	5.8	10.9	0.1	0.7	0.1
11/26/2021	0.0	0.0	0.0	0.0	0.0
11/27/2021	0.0	0.0	0.0	0.0	0.0
11/28/2021	0.0	0.0	0.0	0.0	0.0
11/29/2021	322.6	481.0	20.1	98.7	8.6
11/30/2021	228.2	131.5	26.5	144.0	14.7
Monthly Avg/Sum*:	6,056.1 *	3,514.3 *	866.1 *	4,599.0 *	- *
Daily Min:	0.0	0.0	0.0	0.0	-
Daily Max:	322.6	481.0	47.5	257.3	-
Oct 2021 - Nov 2021	10,132.8	5,358.4	1,520.1	8,074.2	-
QTD:	10,132.8 *	5,358.4 *	1,520.1 *	8,074.2 *	0.0 *
YTD 2021:	51,507.0 *	25,334.3 *	6,830.9 *	36,658.9 *	7.7 *

Monthly Summary By Day Report

AQ-25

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:48 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	PlantWide NOx, Lb 1 Day(s)	PlantWide CO, Lb 1 Day(s)	PlantWide VOC, Lb 1 Day(s)	PlantWide PM10, Lb 1 Day(s)	PlantWide SO2, Lb 1 Day(s)
12/01/2021	314.8	66.5	49.0	267.6	28.6
12/02/2021	235.7	237.5	30.5	168.6	18.7
12/03/2021	317.9	201.5	43.2	228.9	22.9
12/04/2021	208.3	304.8	28.4	141.5	12.5
12/05/2021	279.5	352.4	25.7	127.9	11.4
12/06/2021	320.0	128.3	47.2	258.4	27.9
12/07/2021	326.6	110.2	47.9	260.8	28.1
12/08/2021	272.3	119.6	42.6	234.7	25.3
12/09/2021	306.6	119.3	45.1	246.4	26.7
12/10/2021	268.0	110.4	44.5	242.6	26.0
12/11/2021	282.6	115.5	44.7	244.0	26.2
12/12/2021	291.6	106.7	44.6	243.9	26.1
12/13/2021	331.7	116.6	48.3	262.6	28.3
12/14/2021	296.3	111.2	45.5	248.6	26.8
12/15/2021	298.5	118.1	46.7	253.3	55.4
12/16/2021	320.4	126.5	47.3	257.2	27.5
12/17/2021	301.2	123.0	46.3	250.7	26.7
12/18/2021	297.4	126.2	45.2	246.2	26.5
12/19/2021	304.6	127.7	45.4	248.6	26.8
12/20/2021	336.7	125.6	49.2	267.8	28.6
12/21/2021	328.5	126.6	48.0	261.3	28.1
12/22/2021	294.7	152.3	44.3	241.5	26.4
12/23/2021	280.4	130.0	43.0	231.5	25.1
12/24/2021	255.0	107.7	40.5	221.3	23.8
12/25/2021	261.2	105.0	41.7	225.3	24.2
12/26/2021	279.9	308.2	18.8	94.0	8.4
12/27/2021	335.3	115.0	48.4	263.3	28.2
12/28/2021	295.9	123.7	45.8	248.9	26.7
12/29/2021	302.4	138.4	46.2	251.8	27.0
12/30/2021	308.2	129.1	45.5	249.5	26.8
12/31/2021	263.0	110.6	42.5	233.7	25.3
Monthly Avg/Sum*:	9,115.2 *	4,494.2 *	1,332.0 *	7,222.4 *	55.4 *
Daily Min:	208.3	66.5	18.8	94.0	55.4
Daily Max:	336.7	352.4	49.2	267.8	55.4
Oct 2021 - Dec 2021	19,248.0	9,852.6	2,852.1	15,296.6	55.4
QTD:	19,248.0 *	9,852.6 *	2,852.1 *	15,296.6 *	55.4 *
YTD 2021:	60,622.2 *	29,828.5 *	8,162.9 *	43,881.3 *	63.1 *

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/01/2021 00:00	4.6	1.2	1.1	3.8	0.9
10/01/2021 01:00	3.1	0.9	1.1	3.8	0.9
10/01/2021 02:00	3.1	0.6	1.1	3.8	0.9
10/01/2021 03:00	3.1	0.6	1.1	3.8	0.9
10/01/2021 04:00	3.1	0.6	1.1	3.8	0.9
10/01/2021 05:00	6.0	4.6	1.4	5.0	1.2
10/01/2021 06:00	5.2	2.9	1.2	4.3	1.0
10/01/2021 07:00	2.9	0.8	1.0	3.6	0.9
10/01/2021 08:00	4.1	0.8	0.9	3.4	0.8
10/01/2021 09:00	4.1	0.5	0.9	3.4	0.8
10/01/2021 10:00	4.1	0.5	1.0	3.4	0.8
10/01/2021 11:00	4.1	0.5	1.0	3.4	0.8
10/01/2021 12:00	2.8	0.5	1.0	3.5	0.8
10/01/2021 13:00	41.7	33.6	1.3	4.8	1.1
10/01/2021 14:00	68.4	40.8	1.4	6.8	1.5
10/01/2021 15:00	10.1	1.0	1.7	9.3	2.0
10/01/2021 16:00	10.1	1.0	1.7	9.3	2.0
10/01/2021 17:00	10.5	1.3	1.8	9.7	2.1
10/01/2021 18:00	10.5	1.3	1.7	9.6	2.1
10/01/2021 19:00	11.7	1.3	1.7	9.3	2.0
10/01/2021 20:00	10.0	1.3	1.7	9.1	2.0
10/01/2021 21:00	11.5	1.3	1.7	9.1	2.0
10/01/2021 22:00	10.0	1.0	1.7	9.1	2.0
10/01/2021 23:00	8.3	0.6	1.7	9.1	2.0
Average/Sum#:	253.1 #	99.5 #	32.0 #	144.2 #	32.4 #
Minimum:	2.8	0.5	0.9	3.4	0.8
Maximum:	68.4	40.8	1.8	9.7	2.1
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/02/2021 00:00	8.3	0.6	1.7	9.2	2.0
10/02/2021 01:00	8.3	0.6	1.7	9.1	2.0
10/02/2021 02:00	7.6	0.6	1.6	8.3	1.8
10/02/2021 03:00	8.2	0.6	1.7	9.1	2.0
10/02/2021 04:00	8.3	0.6	1.7	9.1	2.0
10/02/2021 05:00	8.2	1.0	1.7	9.1	2.0
10/02/2021 06:00	8.0	0.6	1.6	8.9	2.0
10/02/2021 07:00	7.2	0.6	1.4	8.0	1.8
10/02/2021 08:00	6.7	0.5	1.3	7.4	1.6
10/02/2021 09:00	7.8	0.5	1.3	7.2	1.6
10/02/2021 10:00	6.4	0.5	1.3	7.0	1.6
10/02/2021 11:00	6.4	0.5	1.3	7.0	1.6
10/02/2021 12:00	6.4	0.5	1.3	7.1	1.6
10/02/2021 13:00	6.7	0.5	1.4	7.4	1.6
10/02/2021 14:00	9.8	0.9	1.7	9.0	2.0
10/02/2021 15:00	10.0	1.0	1.7	9.3	2.0
10/02/2021 16:00	9.5	1.2	1.6	8.9	2.0
10/02/2021 17:00	12.1	1.3	1.7	9.5	2.1
10/02/2021 18:00	10.5	1.3	1.7	9.6	2.1
10/02/2021 19:00	10.0	1.3	1.7	9.2	2.0
10/02/2021 20:00	9.8	1.3	1.7	9.1	2.0
10/02/2021 21:00	11.7	1.3	1.7	9.1	2.0
10/02/2021 22:00	11.7	1.3	1.7	9.1	2.0
10/02/2021 23:00	10.0	1.0	1.7	9.1	2.0
Average/Sum#:	209.6 #	20.1 #	37.9 #	205.8 #	45.4 #
Minimum:	6.4	0.5	1.3	7.0	1.6
Maximum:	12.1	1.3	1.7	9.6	2.1
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/03/2021 00:00	9.7	0.6	1.6	8.9	2.0
10/03/2021 01:00	7.7	0.6	1.6	8.5	1.8
10/03/2021 02:00	7.2	0.6	1.4	7.9	1.8
10/03/2021 03:00	6.9	0.5	1.4	7.6	1.6
10/03/2021 04:00	7.2	0.6	1.4	8.0	1.8
10/03/2021 05:00	7.2	0.6	1.4	7.9	1.8
10/03/2021 06:00	7.2	0.6	1.4	7.9	1.8
10/03/2021 07:00	5.1	0.8	1.3	7.0	1.6
10/03/2021 08:00	8.1	0.8	1.3	7.4	1.6
10/03/2021 09:00	6.4	0.8	1.3	7.0	1.6
10/03/2021 10:00	6.4	0.7	1.3	7.0	1.6
10/03/2021 11:00	6.7	0.5	1.3	7.4	1.6
10/03/2021 12:00	7.0	0.5	1.4	7.7	1.6
10/03/2021 13:00	9.5	0.9	1.6	8.7	1.9
10/03/2021 14:00	10.0	1.3	1.7	9.1	2.0
10/03/2021 15:00	10.0	1.3	1.7	9.2	2.0
10/03/2021 16:00	9.5	1.2	1.6	8.7	1.9
10/03/2021 17:00	7.0	1.1	1.4	7.8	1.7
10/03/2021 18:00	10.3	1.3	1.7	9.5	2.0
10/03/2021 19:00	9.7	1.2	1.6	8.9	2.0
10/03/2021 20:00	10.0	1.3	1.7	9.1	2.0
10/03/2021 21:00	9.6	1.2	1.6	8.9	2.0
10/03/2021 22:00	9.8	1.3	1.7	9.1	2.0
10/03/2021 23:00	10.0	1.3	1.7	9.1	2.0
Average/Sum#:	198.2 #	21.6 #	36.1 #	198.3 #	43.7 #
Minimum:	5.1	0.5	1.3	7.0	1.6
Maximum:	10.3	1.3	1.7	9.5	2.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/04/2021 00:00	9.8	1.3	1.7	9.1	2.0
10/04/2021 01:00	9.1	1.5	1.6	8.3	1.8
10/04/2021 02:00	9.2	1.5	1.6	8.4	1.8
10/04/2021 03:00	11.2	1.2	1.6	8.7	1.9
10/04/2021 04:00	9.8	1.3	1.7	9.1	2.0
10/04/2021 05:00	11.6	1.3	1.7	9.1	2.0
10/04/2021 06:00	9.7	1.2	1.6	8.9	2.0
10/04/2021 07:00	7.9	0.9	1.6	8.7	1.9
10/04/2021 08:00	8.0	1.2	1.6	8.8	2.0
10/04/2021 09:00	7.9	0.9	1.6	8.7	1.9
10/04/2021 10:00	7.6	1.2	1.6	8.4	1.8
10/04/2021 11:00	9.7	1.2	1.6	8.9	2.0
10/04/2021 12:00	9.8	1.3	1.7	9.0	2.0
10/04/2021 13:00	9.5	1.2	1.6	8.7	1.9
10/04/2021 14:00	10.0	1.3	1.7	9.2	2.0
10/04/2021 15:00	9.7	1.2	1.6	8.9	2.0
10/04/2021 16:00	10.4	1.3	1.7	9.5	2.1
10/04/2021 17:00	10.5	1.3	1.7	9.6	2.1
10/04/2021 18:00	10.4	1.3	1.7	9.6	2.1
10/04/2021 19:00	10.3	1.3	1.7	9.5	2.1
10/04/2021 20:00	10.3	1.3	1.7	9.5	2.1
10/04/2021 21:00	10.3	1.3	1.7	9.5	2.0
10/04/2021 22:00	7.8	1.2	1.6	8.6	1.9
10/04/2021 23:00	7.9	0.9	1.6	8.7	1.9
Average/Sum#:	228.4 #	29.6 #	39.5 #	215.4 #	47.3 #
Minimum:	7.6	0.9	1.6	8.3	1.8
Maximum:	11.6	1.5	1.7	9.6	2.1
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/05/2021 00:00	7.7	0.9	1.6	8.5	1.8
10/05/2021 01:00	7.6	0.9	1.6	8.3	1.8
10/05/2021 02:00	7.5	1.2	1.5	8.3	1.8
10/05/2021 03:00	8.0	0.9	1.6	8.8	2.0
10/05/2021 04:00	7.8	1.2	1.6	8.5	1.8
10/05/2021 05:00	8.2	1.2	1.7	9.1	2.0
10/05/2021 06:00	10.0	1.6	1.7	9.1	2.0
10/05/2021 07:00	8.1	1.5	1.6	8.9	2.0
10/05/2021 08:00	7.9	1.5	1.6	8.7	1.9
10/05/2021 09:00	9.7	1.6	1.7	8.9	2.0
10/05/2021 10:00	9.8	1.3	1.7	9.1	2.0
10/05/2021 11:00	9.7	0.9	1.6	8.9	2.0
10/05/2021 12:00	10.1	1.0	1.7	9.3	2.0
10/05/2021 13:00	9.8	0.9	1.7	9.1	2.0
10/05/2021 14:00	8.1	1.2	1.6	8.9	2.0
10/05/2021 15:00	8.3	1.3	1.7	9.1	2.0
10/05/2021 16:00	9.8	1.3	1.7	9.1	2.0
10/05/2021 17:00	9.7	1.2	1.6	8.9	2.0
10/05/2021 18:00	8.1	1.2	1.6	8.9	2.0
10/05/2021 19:00	10.0	1.3	1.7	9.1	2.0
10/05/2021 20:00	9.4	1.5	1.6	8.7	1.9
10/05/2021 21:00	7.4	1.2	1.5	8.2	1.8
10/05/2021 22:00	8.1	0.9	1.6	8.9	2.0
10/05/2021 23:00	6.9	1.1	1.4	7.6	1.6
Average/Sum#:	207.7 #	28.8 #	38.9 #	210.9 #	46.4 #
Minimum:	6.9	0.9	1.4	7.6	1.6
Maximum:	10.1	1.6	1.7	9.3	2.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/06/2021 00:00	6.4	1.5	1.3	7.0	1.6
10/06/2021 01:00	7.7	1.5	1.3	7.0	1.6
10/06/2021 02:00	7.7	1.7	1.3	7.0	1.6
10/06/2021 03:00	7.7	1.7	1.3	7.0	1.6
10/06/2021 04:00	7.9	1.8	1.3	7.2	1.6
10/06/2021 05:00	9.1	1.2	1.5	8.3	1.8
10/06/2021 06:00	7.9	1.2	1.6	8.7	1.9
10/06/2021 07:00	7.7	1.2	1.6	8.5	1.8
10/06/2021 08:00	6.9	1.6	1.4	7.6	1.6
10/06/2021 09:00	7.9	0.9	1.6	8.7	1.9
10/06/2021 10:00	7.7	1.2	1.6	8.5	1.8
10/06/2021 11:00	7.4	1.1	1.5	8.2	1.8
10/06/2021 12:00	7.9	0.9	1.6	8.7	1.9
10/06/2021 13:00	8.1	0.9	1.6	8.9	2.0
10/06/2021 14:00	10.0	1.0	1.7	9.1	2.0
10/06/2021 15:00	9.8	1.3	1.7	9.1	2.0
10/06/2021 16:00	9.7	1.2	1.6	8.9	2.0
10/06/2021 17:00	6.9	1.6	1.4	7.6	1.6
10/06/2021 18:00	11.0	1.5	1.6	8.7	1.9
10/06/2021 19:00	11.2	1.2	1.6	8.9	2.0
10/06/2021 20:00	10.1	1.3	1.7	9.4	2.0
10/06/2021 21:00	9.7	1.2	1.6	8.9	2.0
10/06/2021 22:00	9.4	1.5	1.6	8.6	1.9
10/06/2021 23:00	10.0	1.3	1.7	9.2	2.0
Average/Sum#:	205.8 #	31.5 #	36.7 #	199.7 #	43.9 #
Minimum:	6.4	0.9	1.3	7.0	1.6
Maximum:	11.2	1.8	1.7	9.4	2.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/07/2021 00:00	7.6	1.2	1.6	8.4	1.8
10/07/2021 01:00	7.7	1.2	1.6	8.5	1.8
10/07/2021 02:00	7.6	1.2	1.6	8.4	1.8
10/07/2021 03:00	7.2	1.4	1.4	7.9	1.8
10/07/2021 04:00	8.2	0.9	1.7	9.0	2.0
10/07/2021 05:00	8.1	0.9	1.6	8.9	2.0
10/07/2021 06:00	8.4	1.0	1.7	9.2	2.0
10/07/2021 07:00	8.1	0.9	1.6	8.9	2.0
10/07/2021 08:00	8.0	0.9	1.6	8.8	2.0
10/07/2021 09:00	7.6	0.9	1.6	8.4	1.8
10/07/2021 10:00	7.6	0.9	1.5	8.3	1.8
10/07/2021 11:00	9.1	0.9	1.6	8.4	1.8
10/07/2021 12:00	7.6	0.9	1.6	8.4	1.8
10/07/2021 13:00	7.6	0.9	1.6	8.4	1.8
10/07/2021 14:00	10.0	1.0	1.7	9.1	2.0
10/07/2021 15:00	11.5	1.3	1.7	9.1	2.0
10/07/2021 16:00	11.8	1.3	1.7	9.3	2.0
10/07/2021 17:00	10.6	1.3	1.8	9.8	2.2
10/07/2021 18:00	10.4	1.3	1.7	9.5	2.1
10/07/2021 19:00	8.1	1.6	1.7	8.9	2.0
10/07/2021 20:00	8.1	1.5	1.6	8.9	2.0
10/07/2021 21:00	8.2	1.3	1.7	9.1	2.0
10/07/2021 22:00	10.0	0.9	1.7	9.1	2.0
10/07/2021 23:00	7.9	1.2	1.6	8.7	1.9
Average/Sum#:	207.0 #	26.8 #	39.2 #	211.4 #	46.4 #
Minimum:	7.2	0.9	1.4	7.9	1.8
Maximum:	11.8	1.6	1.8	9.8	2.2
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/08/2021 00:00	7.4	1.1	1.5	8.2	1.8
10/08/2021 01:00	7.4	1.1	1.5	8.2	1.8
10/08/2021 02:00	7.6	1.2	1.5	8.3	1.8
10/08/2021 03:00	7.9	1.2	1.6	8.7	1.9
10/08/2021 04:00	8.2	0.9	1.7	9.1	2.0
10/08/2021 05:00	9.3	1.2	1.6	8.5	1.8
10/08/2021 06:00	9.8	0.9	1.7	9.0	2.0
10/08/2021 07:00	7.6	1.2	1.6	8.3	1.8
10/08/2021 08:00	9.1	1.2	1.6	8.4	1.8
10/08/2021 09:00	8.3	1.3	1.4	7.6	1.6
10/08/2021 10:00	9.8	0.9	1.7	9.0	2.0
10/08/2021 11:00	8.7	1.1	1.4	8.0	1.8
10/08/2021 12:00	7.9	0.9	1.6	8.7	1.9
10/08/2021 13:00	7.7	0.9	1.6	8.5	1.8
10/08/2021 14:00	7.6	1.2	1.6	8.3	1.8
10/08/2021 15:00	9.5	0.9	1.6	8.8	2.0
10/08/2021 16:00	10.0	1.0	1.7	9.1	2.0
10/08/2021 17:00	7.9	0.9	1.6	8.7	1.9
10/08/2021 18:00	9.5	0.9	1.6	8.8	1.9
10/08/2021 19:00	8.1	0.9	1.7	8.9	2.0
10/08/2021 20:00	6.9	1.6	1.4	7.5	1.6
10/08/2021 21:00	4.5	10.7	0.0	0.3	0.0
10/08/2021 22:00	0.0	0.0	0.0	0.0	0.0
10/08/2021 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	180.7 #	33.2 #	33.2 #	178.9 #	39.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	10.0	10.7	1.7	9.1	2.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/09/2021 00:00	0.0	0.0	0.0	0.0	0.0
10/09/2021 01:00	0.0	0.0	0.0	0.0	0.0
10/09/2021 02:00	0.0	0.0	0.0	0.0	0.0
10/09/2021 03:00	0.0	0.0	0.0	0.0	0.0
10/09/2021 04:00	0.0	0.0	0.0	0.0	0.0
10/09/2021 05:00	0.0	0.0	0.0	0.0	0.0
10/09/2021 06:00	0.0	0.0	0.0	0.0	0.0
10/09/2021 07:00	0.0	0.0	0.0	0.0	0.0
10/09/2021 08:00	0.0	0.0	0.0	0.0	0.0
10/09/2021 09:00	0.0	0.0	0.0	0.0	0.0
10/09/2021 10:00	0.0	0.0	0.0	0.0	0.0
10/09/2021 11:00	0.0	0.0	0.0	0.0	0.0
10/09/2021 12:00	0.0	0.0	0.0	0.0	0.0
10/09/2021 13:00	0.0	0.0	0.0	0.0	0.0
10/09/2021 14:00	0.0	0.0	0.0	0.0	0.0
10/09/2021 15:00	0.0	0.0	0.0	0.0	0.0
10/09/2021 16:00	0.0	0.0	0.0	0.0	0.0
10/09/2021 17:00	0.0	0.0	0.0	0.0	0.0
10/09/2021 18:00	0.0	0.0	0.0	0.0	0.0
10/09/2021 19:00	0.0	0.0	0.0	0.0	0.0
10/09/2021 20:00	0.0	0.0	0.0	0.0	0.0
10/09/2021 21:00	0.0	0.0	0.0	0.0	0.0
10/09/2021 22:00	0.0	0.0	0.0	0.0	0.0
10/09/2021 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/10/2021 00:00	0.0	0.0	0.0	0.0	0.0
10/10/2021 01:00	0.0	0.0	0.0	0.0	0.0
10/10/2021 02:00	0.0	0.0	0.0	0.0	0.0
10/10/2021 03:00	0.0	0.0	0.0	0.0	0.0
10/10/2021 04:00	0.0	0.0	0.0	0.0	0.0
10/10/2021 05:00	0.0	0.0	0.0	0.0	0.0
10/10/2021 06:00	0.0	0.0	0.0	0.0	0.0
10/10/2021 07:00	0.0	0.0	0.0	0.0	0.0
10/10/2021 08:00	0.0	0.0	0.0	0.0	0.0
10/10/2021 09:00	0.0	0.0	0.0	0.0	0.0
10/10/2021 10:00	0.0	0.0	0.0	0.0	0.0
10/10/2021 11:00	0.0	0.0	0.0	0.0	0.0
10/10/2021 12:00	0.0	0.0	0.0	0.0	0.0
10/10/2021 13:00	0.0	0.0	0.0	0.0	0.0
10/10/2021 14:00	0.0	0.0	0.0	0.0	0.0
10/10/2021 15:00	0.0	0.0	0.0	0.0	0.0
10/10/2021 16:00	0.0	0.0	0.0	0.0	0.0
10/10/2021 17:00	0.0	0.0	0.0	0.0	0.0
10/10/2021 18:00	0.0	0.0	0.0	0.0	0.0
10/10/2021 19:00	0.0	0.0	0.0	0.0	0.0
10/10/2021 20:00	0.0	0.0	0.0	0.0	0.0
10/10/2021 21:00	0.0	0.0	0.0	0.0	0.0
10/10/2021 22:00	0.0	0.0	0.0	0.0	0.0
10/10/2021 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/11/2021 00:00	0.0	0.0	0.0	0.0	0.0
10/11/2021 01:00	0.0	0.0	0.0	0.0	0.0
10/11/2021 02:00	0.0	0.0	0.0	0.0	0.0
10/11/2021 03:00	0.0	0.0	0.0	0.0	0.0
10/11/2021 04:00	0.0	0.0	0.0	0.0	0.0
10/11/2021 05:00	0.0	0.0	0.0	0.0	0.0
10/11/2021 06:00	0.0	0.0	0.0	0.0	0.0
10/11/2021 07:00	0.0	0.0	0.0	0.0	0.0
10/11/2021 08:00	0.0	0.0	0.0	0.0	0.0
10/11/2021 09:00	0.0	0.0	0.0	0.0	0.0
10/11/2021 10:00	0.0	0.0	0.0	0.0	0.0
10/11/2021 11:00	0.0	0.0	0.0	0.0	0.0
10/11/2021 12:00	0.0	0.0	0.0	0.0	0.0
10/11/2021 13:00	0.0	0.0	0.0	0.0	0.0
10/11/2021 14:00	0.0	0.0	0.0	0.0	0.0
10/11/2021 15:00	0.0	0.0	0.0	0.0	0.0
10/11/2021 16:00	0.0	0.0	0.0	0.0	0.0
10/11/2021 17:00	0.0	0.0	0.0	0.0	0.0
10/11/2021 18:00	0.0	0.0	0.0	0.0	0.0
10/11/2021 19:00	0.0	0.0	0.0	0.0	0.0
10/11/2021 20:00	0.0	0.0	0.0	0.0	0.0
10/11/2021 21:00	0.0	0.0	0.0	0.0	0.0
10/11/2021 22:00	0.0	0.0	0.0	0.0	0.0
10/11/2021 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/12/2021 00:00	0.0	0.0	0.0	0.0	0.0
10/12/2021 01:00	0.0	0.0	0.0	0.0	0.0
10/12/2021 02:00	0.0	0.0	0.0	0.0	0.0
10/12/2021 03:00	0.0	0.0	0.0	0.0	0.0
10/12/2021 04:00	0.0	0.0	0.0	0.0	0.0
10/12/2021 05:00	0.0	0.0	0.0	0.0	0.0
10/12/2021 06:00	0.0	0.0	0.0	0.0	0.0
10/12/2021 07:00	0.0	0.0	0.0	0.0	0.0
10/12/2021 08:00	0.0	0.0	0.0	0.0	0.0
10/12/2021 09:00	0.0	0.0	0.0	0.0	0.0
10/12/2021 10:00	0.0	0.0	0.0	0.0	0.0
10/12/2021 11:00	0.0	0.0	0.0	0.0	0.0
10/12/2021 12:00	0.0	0.0	0.0	0.0	0.0
10/12/2021 13:00	0.0	0.0	0.0	0.0	0.0
10/12/2021 14:00	0.0	0.0	0.0	0.0	0.0
10/12/2021 15:00	0.0	0.0	0.0	0.0	0.0
10/12/2021 16:00	0.0	0.0	0.0	0.0	0.0
10/12/2021 17:00	0.0	0.0	0.0	0.0	0.0
10/12/2021 18:00	0.0	0.0	0.0	0.0	0.0
10/12/2021 19:00	0.0	0.0	0.0	0.0	0.0
10/12/2021 20:00	0.0	0.0	0.0	0.0	0.0
10/12/2021 21:00	0.0	0.0	0.0	0.0	0.0
10/12/2021 22:00	0.0	0.0	0.0	0.0	0.0
10/12/2021 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/13/2021 00:00	0.0	0.0	0.0	0.0	0.0
10/13/2021 01:00	0.0	0.0	0.0	0.0	0.0
10/13/2021 02:00	0.0	0.0	0.0	0.0	0.0
10/13/2021 03:00	0.0	0.0	0.0	0.0	0.0
10/13/2021 04:00	0.0	0.0	0.0	0.0	0.0
10/13/2021 05:00	0.0	0.0	0.0	0.0	0.0
10/13/2021 06:00	0.0	0.0	0.0	0.0	0.0
10/13/2021 07:00	0.0	0.0	0.0	0.0	0.0
10/13/2021 08:00	0.0	0.0	0.0	0.0	0.0
10/13/2021 09:00	0.0	0.0	0.0	0.0	0.0
10/13/2021 10:00	0.0	0.0	0.0	0.0	0.0
10/13/2021 11:00	0.0	0.0	0.0	0.0	0.0
10/13/2021 12:00	0.0	0.0	0.0	0.0	0.0
10/13/2021 13:00	0.0	0.0	0.0	0.0	0.0
10/13/2021 14:00	0.0	0.0	0.0	0.0	0.0
10/13/2021 15:00	0.0	0.0	0.0	0.0	0.0
10/13/2021 16:00	0.0	0.0	0.0	0.0	0.0
10/13/2021 17:00	0.0	0.0	0.0	0.0	0.0
10/13/2021 18:00	0.0	0.0	0.0	0.0	0.0
10/13/2021 19:00	0.0	0.0	0.0	0.0	0.0
10/13/2021 20:00	0.0	0.0	0.0	0.0	0.0
10/13/2021 21:00	0.0	0.0	0.0	0.0	0.0
10/13/2021 22:00	0.0	0.0	0.0	0.0	0.0
10/13/2021 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/14/2021 00:00	0.0	0.0	0.0	0.0	0.0
10/14/2021 01:00	0.0	0.0	0.0	0.0	0.0
10/14/2021 02:00	0.0	0.0	0.0	0.0	0.0
10/14/2021 03:00	0.0	0.0	0.0	0.0	0.0
10/14/2021 04:00	0.0	0.0	0.0	0.0	0.0
10/14/2021 05:00	0.0	0.0	0.0	0.0	0.0
10/14/2021 06:00	0.0	0.0	0.0	0.0	0.0
10/14/2021 07:00	0.0	0.0	0.0	0.0	0.0
10/14/2021 08:00	0.0	0.0	0.0	0.0	0.0
10/14/2021 09:00	0.0	0.0	0.0	0.0	0.0
10/14/2021 10:00	0.0	0.0	0.0	0.0	0.0
10/14/2021 11:00	0.0	0.0	0.0	0.0	0.0
10/14/2021 12:00	0.0	0.0	0.0	0.0	0.0
10/14/2021 13:00	0.0	0.0	0.0	0.0	0.0
10/14/2021 14:00	0.0	0.0	0.0	0.0	0.0
10/14/2021 15:00	0.0	0.0	0.0	0.0	0.0
10/14/2021 16:00	0.0	0.0	0.0	0.0	0.0
10/14/2021 17:00	0.0	0.0	0.0	0.0	0.0
10/14/2021 18:00	0.0	0.0	0.0	0.0	0.0
10/14/2021 19:00	0.0	0.0	0.0	0.0	0.0
10/14/2021 20:00	0.0	0.0	0.0	0.0	0.0
10/14/2021 21:00	0.0	0.0	0.0	0.0	0.0
10/14/2021 22:00	0.0	0.0	0.0	0.0	0.0
10/14/2021 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/15/2021 00:00	0.0	0.0	0.0	0.0	0.0
10/15/2021 01:00	0.0	0.0	0.0	0.0	0.0
10/15/2021 02:00	0.0	0.0	0.0	0.0	0.0
10/15/2021 03:00	0.0	0.0	0.0	0.0	0.0
10/15/2021 04:00	0.0	0.0	0.0	0.0	0.0
10/15/2021 05:00	0.0	0.0	0.0	0.0	0.0
10/15/2021 06:00	0.0	0.0	0.0	0.0	0.0
10/15/2021 07:00	0.0	0.0	0.0	0.0	0.0
10/15/2021 08:00	0.0	0.0	0.0	0.0	0.0
10/15/2021 09:00	0.0	0.0	0.0	0.0	0.0
10/15/2021 10:00	0.0	0.0	0.0	0.0	0.0
10/15/2021 11:00	0.0	0.0	0.0	0.0	0.0
10/15/2021 12:00	0.0	0.0	0.0	0.0	0.0
10/15/2021 13:00	0.0	0.0	0.0	0.0	0.0
10/15/2021 14:00	0.0	0.0	0.0	0.0	0.0
10/15/2021 15:00	0.0	0.0	0.0	0.0	0.0
10/15/2021 16:00	0.0	0.0	0.0	0.0	0.0
10/15/2021 17:00	0.0	0.0	0.0	0.0	0.0
10/15/2021 18:00	0.0	0.0	0.0	0.0	0.0
10/15/2021 19:00	0.0	0.0	0.0	0.0	0.0
10/15/2021 20:00	0.0	0.0	0.0	0.0	0.0
10/15/2021 21:00	0.0	0.0	0.0	0.0	0.0
10/15/2021 22:00	0.0	0.0	0.0	0.0	0.0
10/15/2021 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/16/2021 00:00	0.0	0.0	0.0	0.0	0.0
10/16/2021 01:00	0.0	0.0	0.0	0.0	0.0
10/16/2021 02:00	0.0	0.0	0.0	0.0	0.0
10/16/2021 03:00	0.0	0.0	0.0	0.0	0.0
10/16/2021 04:00	0.0	0.0	0.0	0.0	0.0
10/16/2021 05:00	0.0	0.0	0.0	0.0	0.0
10/16/2021 06:00	0.0	0.0	0.0	0.0	0.0
10/16/2021 07:00	0.0	0.0	0.0	0.0	0.0
10/16/2021 08:00	0.0	0.0	0.0	0.0	0.0
10/16/2021 09:00	0.0	0.0	0.0	0.0	0.0
10/16/2021 10:00	0.0	0.0	0.0	0.0	0.0
10/16/2021 11:00	0.0	0.0	0.0	0.0	0.0
10/16/2021 12:00	0.0	0.0	0.0	0.0	0.0
10/16/2021 13:00	0.0	0.0	0.0	0.0	0.0
10/16/2021 14:00	0.0	0.0	0.0	0.0	0.0
10/16/2021 15:00	0.0	0.0	0.0	0.0	0.0
10/16/2021 16:00	0.0	0.0	0.0	0.0	0.0
10/16/2021 17:00	0.0	0.0	0.0	0.0	0.0
10/16/2021 18:00	0.0	0.0	0.0	0.0	0.0
10/16/2021 19:00	0.0	0.0	0.0	0.0	0.0
10/16/2021 20:00	0.0	0.0	0.0	0.0	0.0
10/16/2021 21:00	0.0	0.0	0.0	0.0	0.0
10/16/2021 22:00	0.0	0.0	0.0	0.0	0.0
10/16/2021 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/17/2021 00:00	0.0	0.0	0.0	0.0	0.0
10/17/2021 01:00	0.0	0.0	0.0	0.0	0.0
10/17/2021 02:00	0.0	0.0	0.0	0.0	0.0
10/17/2021 03:00	0.0	0.0	0.0	0.0	0.0
10/17/2021 04:00	0.0	0.0	0.0	0.0	0.0
10/17/2021 05:00	0.0	0.0	0.0	0.0	0.0
10/17/2021 06:00	0.0	0.0	0.0	0.0	0.0
10/17/2021 07:00	0.0	0.0	0.0	0.0	0.0
10/17/2021 08:00	0.0	0.0	0.0	0.0	0.0
10/17/2021 09:00	0.0	0.0	0.0	0.0	0.0
10/17/2021 10:00	0.0	0.0	0.0	0.0	0.0
10/17/2021 11:00	0.0	0.0	0.0	0.0	0.0
10/17/2021 12:00	0.0	0.0	0.0	0.0	0.0
10/17/2021 13:00	0.0	0.0	0.0	0.0	0.0
10/17/2021 14:00	0.0	0.0	0.0	0.0	0.0
10/17/2021 15:00	0.0	0.0	0.0	0.0	0.0
10/17/2021 16:00	0.0	0.0	0.0	0.0	0.0
10/17/2021 17:00	0.0	0.0	0.0	0.0	0.0
10/17/2021 18:00	0.0	0.0	0.0	0.0	0.0
10/17/2021 19:00	0.0	0.0	0.0	0.0	0.0
10/17/2021 20:00	0.0	0.0	0.0	0.0	0.0
10/17/2021 21:00	0.0	0.0	0.0	0.0	0.0
10/17/2021 22:00	0.0	0.0	0.0	0.0	0.0
10/17/2021 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/18/2021 00:00	0.0	0.0	0.0	0.0	0.0
10/18/2021 01:00	0.0	0.0	0.0	0.0	0.0
10/18/2021 02:00	0.0	0.0	0.0	0.0	0.0
10/18/2021 03:00	0.0	0.0	0.0	0.0	0.0
10/18/2021 04:00	0.0	0.0	0.0	0.0	0.0
10/18/2021 05:00	0.0	0.0	0.0	0.0	0.0
10/18/2021 06:00	0.0	0.0	0.0	0.0	0.0
10/18/2021 07:00	0.0	0.0	0.0	0.0	0.0
10/18/2021 08:00	0.0	0.0	0.0	0.0	0.0
10/18/2021 09:00	0.0	0.0	0.0	0.0	0.0
10/18/2021 10:00	0.0	0.0	0.0	0.0	0.0
10/18/2021 11:00	0.0	0.0	0.0	0.0	0.0
10/18/2021 12:00	0.0	0.0	0.0	0.0	0.0
10/18/2021 13:00	0.0	0.0	0.0	0.0	0.0
10/18/2021 14:00	0.0	0.0	0.0	0.0	0.0
10/18/2021 15:00	0.0	0.0	0.0	0.0	0.0
10/18/2021 16:00	0.0	0.0	0.0	0.0	0.0
10/18/2021 17:00	0.0	0.0	0.0	0.0	0.0
10/18/2021 18:00	0.0	0.0	0.0	0.0	0.0
10/18/2021 19:00	0.0	0.0	0.0	0.0	0.0
10/18/2021 20:00	0.0	0.0	0.0	0.0	0.0
10/18/2021 21:00	0.0	0.0	0.0	0.0	0.0
10/18/2021 22:00	0.0	0.0	0.0	0.0	0.0
10/18/2021 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/19/2021 00:00	0.0	0.0	0.0	0.0	0.0
10/19/2021 01:00	0.0	0.0	0.0	0.0	0.0
10/19/2021 02:00	0.0	0.0	0.0	0.0	0.0
10/19/2021 03:00	0.0	0.0	0.0	0.0	0.0
10/19/2021 04:00	0.0	0.0	0.0	0.0	0.0
10/19/2021 05:00	0.0	0.0	0.0	0.0	0.0
10/19/2021 06:00	0.0	0.0	0.0	0.0	0.0
10/19/2021 07:00	0.0	0.0	0.0	0.0	0.0
10/19/2021 08:00	0.0	0.0	0.0	0.0	0.0
10/19/2021 09:00	0.0	0.0	0.0	0.0	0.0
10/19/2021 10:00	0.0	0.0	0.0	0.0	0.0
10/19/2021 11:00	0.0	0.0	0.0	0.0	0.0
10/19/2021 12:00	0.0	0.0	0.0	0.0	0.0
10/19/2021 13:00	0.0	0.0	0.0	0.0	0.0
10/19/2021 14:00	0.0	0.0	0.0	0.0	0.0
10/19/2021 15:00	0.0	0.0	0.0	0.0	0.0
10/19/2021 16:00	0.0	0.0	0.0	0.0	0.0
10/19/2021 17:00	0.0	0.0	0.0	0.0	0.0
10/19/2021 18:00	0.0	0.0	0.0	0.0	0.0
10/19/2021 19:00	0.0	0.0	0.0	0.0	0.0
10/19/2021 20:00	0.0	0.0	0.0	0.0	0.0
10/19/2021 21:00	0.0	0.0	0.0	0.0	0.0
10/19/2021 22:00	0.0	0.0	0.0	0.0	0.0
10/19/2021 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/20/2021 00:00	0.0	0.0	0.0	0.0	0.0
10/20/2021 01:00	0.0	0.0	0.0	0.0	0.0
10/20/2021 02:00	0.0	0.0	0.0	0.0	0.0
10/20/2021 03:00	0.0	0.0	0.0	0.0	0.0
10/20/2021 04:00	0.0	0.0	0.0	0.0	0.0
10/20/2021 05:00	0.0	0.0	0.0	0.0	0.0
10/20/2021 06:00	0.0	0.0	0.0	0.0	0.0
10/20/2021 07:00	0.0	0.0	0.0	0.0	0.0
10/20/2021 08:00	6.1	40.1	0.0	0.2	0.0
10/20/2021 09:00	72.1	53.6	0.1	1.1	0.2
10/20/2021 10:00	12.0	22.9	0.1	1.2	0.2
10/20/2021 11:00	34.7	125.8	0.2	2.0	0.4
10/20/2021 12:00	18.3	67.9	0.3	3.2	0.6
10/20/2021 13:00	31.4	77.0	0.5	4.4	0.9
10/20/2021 14:00	67.1	74.3	0.8	5.4	1.2
10/20/2021 15:00	13.5	5.1	1.5	8.2	1.8
10/20/2021 16:00	9.1	2.7	1.8	10.0	2.2
10/20/2021 17:00	8.3	1.3	1.7	9.1	2.0
10/20/2021 18:00	11.8	7.9	2.0	10.8	2.4
10/20/2021 19:00	12.1	5.6	2.0	11.1	2.4
10/20/2021 20:00	12.8	2.6	2.1	11.8	2.6
10/20/2021 21:00	12.4	2.3	2.1	11.4	2.5
10/20/2021 22:00	5.9	14.2	0.1	0.8	0.2
10/20/2021 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	327.6 #	503.3 #	15.3 #	90.7 #	19.6 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	72.1	125.8	2.1	11.8	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/21/2021 00:00	0.0	0.0	0.0	0.0	0.0
10/21/2021 01:00	0.0	0.0	0.0	0.0	0.0
10/21/2021 02:00	0.0	0.0	0.0	0.0	0.0
10/21/2021 03:00	0.0	0.0	0.0	0.0	0.0
10/21/2021 04:00	0.0	0.0	0.0	0.0	0.0
10/21/2021 05:00	0.0	0.0	0.0	0.0	0.0
10/21/2021 06:00	0.0	0.0	0.0	0.0	0.0
10/21/2021 07:00	0.0	0.0	0.0	0.0	0.0
10/21/2021 08:00	0.0	0.0	0.0	0.0	0.0
10/21/2021 09:00	0.0	0.0	0.0	0.0	0.0
10/21/2021 10:00	0.0	0.0	0.0	0.0	0.0
10/21/2021 11:00	0.0	0.0	0.0	0.0	0.0
10/21/2021 12:00	0.0	0.0	0.0	0.0	0.0
10/21/2021 13:00	0.0	0.0	0.0	0.0	0.0
10/21/2021 14:00	0.0	0.0	0.0	0.0	0.0
10/21/2021 15:00	0.0	0.0	0.0	0.0	0.0
10/21/2021 16:00	0.0	0.0	0.0	0.0	0.0
10/21/2021 17:00	0.0	0.0	0.0	0.0	0.0
10/21/2021 18:00	0.0	0.0	0.0	0.0	0.0
10/21/2021 19:00	0.0	0.0	0.0	0.0	0.0
10/21/2021 20:00	0.0	0.0	0.0	0.0	0.0
10/21/2021 21:00	0.0	0.0	0.0	0.0	0.0
10/21/2021 22:00	0.0	0.0	0.0	0.0	0.0
10/21/2021 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/22/2021 00:00	0.0	0.0	0.0	0.0	0.0
10/22/2021 01:00	0.0	0.0	0.0	0.0	0.0
10/22/2021 02:00	0.0	0.0	0.0	0.0	0.0
10/22/2021 03:00	0.0	0.0	0.0	0.0	0.0
10/22/2021 04:00	0.0	0.0	0.0	0.0	0.0
10/22/2021 05:00	0.0	0.0	0.0	0.0	0.0
10/22/2021 06:00	0.0	0.0	0.0	0.0	0.0
10/22/2021 07:00	0.0	0.0	0.0	0.0	0.0
10/22/2021 08:00	0.0	0.0	0.0	0.0	0.0
10/22/2021 09:00	0.0	0.0	0.0	0.0	0.0
10/22/2021 10:00	0.0	0.0	0.0	0.0	0.0
10/22/2021 11:00	0.0	0.0	0.0	0.0	0.0
10/22/2021 12:00	0.0	0.0	0.0	0.0	0.0
10/22/2021 13:00	0.0	0.0	0.0	0.0	0.0
10/22/2021 14:00	0.0	0.0	0.0	0.0	0.0
10/22/2021 15:00	0.0	0.0	0.0	0.0	0.0
10/22/2021 16:00	0.0	0.0	0.0	0.0	0.0
10/22/2021 17:00	0.0	0.0	0.0	0.0	0.0
10/22/2021 18:00	0.0	0.0	0.0	0.0	0.0
10/22/2021 19:00	0.0	0.0	0.0	0.0	0.0
10/22/2021 20:00	0.0	0.0	0.0	0.0	0.0
10/22/2021 21:00	0.0	0.0	0.0	0.0	0.0
10/22/2021 22:00	0.0	0.0	0.0	0.0	0.0
10/22/2021 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/23/2021 00:00	0.0	0.0	0.0	0.0	0.0
10/23/2021 01:00	42.8	74.2	0.1	0.5	0.1
10/23/2021 02:00	35.7	34.8	0.3	0.9	0.2
10/23/2021 03:00	25.1	103.2	0.5	1.8	0.4
10/23/2021 04:00	1.5	1.4	1.1	3.8	0.9
10/23/2021 05:00	3.2	1.3	1.1	3.9	0.9
10/23/2021 06:00	59.0	83.3	1.3	5.5	1.3
10/23/2021 07:00	20.9	35.8	1.4	7.5	1.7
10/23/2021 08:00	6.5	0.9	1.7	8.9	2.0
10/23/2021 09:00	4.2	1.3	1.4	7.6	1.6
10/23/2021 10:00	7.9	0.9	1.6	8.7	1.9
10/23/2021 11:00	6.2	0.9	1.6	8.5	1.8
10/23/2021 12:00	6.4	0.9	1.6	8.7	1.9
10/23/2021 13:00	6.3	0.9	1.6	8.5	1.8
10/23/2021 14:00	6.6	0.9	1.7	9.1	2.0
10/23/2021 15:00	6.5	0.9	1.6	8.9	2.0
10/23/2021 16:00	6.6	0.9	1.7	9.1	2.0
10/23/2021 17:00	9.8	4.2	2.0	10.7	2.4
10/23/2021 18:00	12.2	2.6	2.0	11.1	2.4
10/23/2021 19:00	6.5	0.9	1.7	9.0	2.0
10/23/2021 20:00	6.7	0.9	1.7	9.1	2.0
10/23/2021 21:00	12.0	3.6	2.0	11.0	2.4
10/23/2021 22:00	13.8	25.4	1.0	5.8	1.2
10/23/2021 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	306.4 #	380.1 #	30.7 #	158.6 #	34.9 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	59.0	103.2	2.0	11.1	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/24/2021 00:00	0.0	0.0	0.0	0.0	0.0
10/24/2021 01:00	0.0	0.0	0.0	0.0	0.0
10/24/2021 02:00	0.0	0.0	0.0	0.0	0.0
10/24/2021 03:00	0.2	2.1	0.0	0.1	0.0
10/24/2021 04:00	25.8	81.7	0.3	2.7	0.5
10/24/2021 05:00	1.4	0.0	0.4	4.2	0.8
10/24/2021 06:00	2.8	0.0	0.4	4.1	0.8
10/24/2021 07:00	24.6	30.7	0.6	5.7	1.1
10/24/2021 08:00	23.2	105.0	1.2	7.3	1.5
10/24/2021 09:00	6.2	0.9	1.6	8.5	1.8
10/24/2021 10:00	6.3	0.9	1.6	8.6	1.8
10/24/2021 11:00	6.2	1.2	1.6	8.5	1.8
10/24/2021 12:00	6.4	0.9	1.6	8.8	2.0
10/24/2021 13:00	6.0	1.1	1.5	8.3	1.8
10/24/2021 14:00	6.5	0.9	1.6	8.9	2.0
10/24/2021 15:00	6.5	0.9	1.7	9.0	2.0
10/24/2021 16:00	6.9	1.0	1.7	9.6	2.1
10/24/2021 17:00	9.9	2.9	2.0	10.9	2.4
10/24/2021 18:00	12.0	2.5	2.0	11.0	2.4
10/24/2021 19:00	6.7	0.6	1.7	9.2	2.0
10/24/2021 20:00	6.9	1.0	1.7	9.4	2.0
10/24/2021 21:00	12.0	2.3	2.0	11.0	2.4
10/24/2021 22:00	8.4	1.5	1.7	9.1	2.0
10/24/2021 23:00	6.2	9.2	1.1	4.5	1.0
Average/Sum#:	191.1 #	247.3 #	28.0 #	159.4 #	34.2 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	25.8	105.0	2.0	11.0	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/25/2021 00:00	3.1	1.2	1.1	3.9	0.9
10/25/2021 01:00	3.1	1.2	1.1	3.8	0.9
10/25/2021 02:00	3.0	1.4	1.0	3.7	0.9
10/25/2021 03:00	3.1	1.2	1.1	3.9	0.9
10/25/2021 04:00	3.1	1.2	1.1	3.9	0.9
10/25/2021 05:00	10.6	23.4	1.3	5.1	1.2
10/25/2021 06:00	24.1	43.7	1.5	8.3	1.8
10/25/2021 07:00	7.1	1.0	1.8	9.7	2.1
10/25/2021 08:00	6.7	0.6	1.7	9.2	2.0
10/25/2021 09:00	7.1	1.3	1.8	9.8	2.2
10/25/2021 10:00	9.8	3.7	2.0	10.8	2.4
10/25/2021 11:00	12.2	3.3	2.0	11.1	2.4
10/25/2021 12:00	11.6	4.2	2.0	10.6	2.3
10/25/2021 13:00	8.1	1.2	1.6	8.9	2.0
10/25/2021 14:00	6.1	1.2	1.6	8.5	1.8
10/25/2021 15:00	6.2	1.2	1.6	8.5	1.8
10/25/2021 16:00	12.4	4.0	2.1	11.3	2.5
10/25/2021 17:00	12.6	2.7	2.1	11.5	2.5
10/25/2021 18:00	12.3	2.3	2.0	11.3	2.4
10/25/2021 19:00	6.5	3.7	1.7	9.0	2.0
10/25/2021 20:00	4.5	4.5	1.4	8.1	1.8
10/25/2021 21:00	11.6	4.0	2.0	10.6	2.3
10/25/2021 22:00	6.7	1.5	1.7	9.3	2.0
10/25/2021 23:00	6.4	7.8	1.1	4.4	1.0
Average/Sum#:	198.0 #	121.5 #	38.4 #	195.2 #	43.0 #
Minimum:	3.0	0.6	1.0	3.7	0.9
Maximum:	24.1	43.7	2.1	11.5	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/26/2021 00:00	4.1	1.6	1.0	3.4	0.8
10/26/2021 01:00	4.1	1.3	1.0	3.4	0.8
10/26/2021 02:00	4.1	1.3	1.0	3.4	0.8
10/26/2021 03:00	4.1	1.3	1.0	3.4	0.8
10/26/2021 04:00	3.1	1.2	1.1	3.8	0.9
10/26/2021 05:00	10.7	20.3	1.4	5.1	1.2
10/26/2021 06:00	23.7	51.1	1.4	7.3	1.6
10/26/2021 07:00	6.4	1.2	1.6	8.7	1.9
10/26/2021 08:00	3.1	0.0	1.6	8.7	1.9
10/26/2021 09:00	3.1	0.0	1.6	8.7	1.9
10/26/2021 10:00	10.1	1.6	2.0	11.1	2.4
10/26/2021 11:00	5.9	1.3	2.0	10.6	2.3
10/26/2021 12:00	8.4	0.0	1.7	9.2	2.0
10/26/2021 13:00	5.8	0.3	1.4	8.0	1.8
10/26/2021 14:00	5.8	0.3	1.4	7.9	1.8
10/26/2021 15:00	6.2	0.3	1.6	8.5	1.8
10/26/2021 16:00	10.1	1.6	2.0	11.0	2.4
10/26/2021 17:00	12.6	1.3	2.1	11.5	2.5
10/26/2021 18:00	12.4	1.3	2.1	11.3	2.5
10/26/2021 19:00	12.0	1.3	2.0	11.0	2.4
10/26/2021 20:00	6.4	0.0	1.6	8.7	1.9
10/26/2021 21:00	8.9	0.0	1.8	9.8	2.2
10/26/2021 22:00	10.2	2.0	2.1	11.2	2.4
10/26/2021 23:00	10.0	1.9	2.0	10.9	2.4
Average/Sum#:	179.2 #	91.2 #	38.5 #	196.6 #	43.4 #
Minimum:	3.1	0.0	1.0	3.4	0.8
Maximum:	23.7	51.1	2.1	11.5	2.5
%SI	12.50	12.50	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/27/2021 00:00	6.2	0.3	1.6	8.5	1.8
10/27/2021 01:00	6.4	0.6	1.6	8.7	1.9
10/27/2021 02:00	9.7	2.0	2.0	10.6	2.3
10/27/2021 03:00	9.6	1.7	2.0	10.5	2.3
10/27/2021 04:00	6.4	0.0	1.6	8.7	1.9
10/27/2021 05:00	6.5	0.0	1.6	8.8	2.0
10/27/2021 06:00	12.0	2.4	2.0	10.8	2.4
10/27/2021 07:00	12.2	1.7	2.0	11.1	2.4
10/27/2021 08:00	13.6	1.3	2.0	10.7	2.4
10/27/2021 09:00	7.5	0.3	1.4	8.1	1.8
10/27/2021 10:00	7.2	0.3	1.4	7.9	1.8
10/27/2021 11:00	8.0	0.0	1.6	8.7	1.9
10/27/2021 12:00	6.7	0.3	1.3	7.2	1.6
10/27/2021 13:00	7.5	0.0	1.4	8.1	1.8
10/27/2021 14:00	11.0	0.6	1.8	10.0	2.2
10/27/2021 15:00	11.3	0.9	1.9	10.4	2.2
10/27/2021 16:00	10.1	0.0	1.7	9.3	2.0
10/27/2021 17:00	11.8	1.3	2.0	10.8	2.4
10/27/2021 18:00	14.7	1.3	2.1	11.5	2.5
10/27/2021 19:00	15.0	1.0	2.1	11.8	2.6
10/27/2021 20:00	14.7	1.0	2.1	11.5	2.5
10/27/2021 21:00	14.8	1.0	2.1	11.6	2.5
10/27/2021 22:00	14.2	0.7	2.0	11.1	2.4
10/27/2021 23:00	12.8	0.6	1.8	10.0	2.2
Average/Sum#:	249.9 #	19.3 #	43.1 #	236.4 #	51.8 #
Minimum:	6.2	0.0	1.3	7.2	1.6
Maximum:	15.0	2.4	2.1	11.8	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/28/2021 00:00	8.4	9.3	1.3	6.4	1.4
10/28/2021 01:00	5.4	0.5	0.9	3.4	0.8
10/28/2021 02:00	5.4	0.5	1.0	3.4	0.8
10/28/2021 03:00	5.4	0.5	1.0	3.4	0.8
10/28/2021 04:00	6.2	0.3	1.1	3.9	0.9
10/28/2021 05:00	6.0	1.6	1.4	5.0	1.2
10/28/2021 06:00	6.0	1.7	1.4	5.0	1.2
10/28/2021 07:00	5.5	1.0	1.3	4.6	1.1
10/28/2021 08:00	4.1	0.5	1.0	3.4	0.8
10/28/2021 09:00	4.1	0.5	1.0	3.4	0.8
10/28/2021 10:00	4.1	0.3	1.0	3.4	0.8
10/28/2021 11:00	4.1	0.3	1.0	3.5	0.8
10/28/2021 12:00	20.3	15.9	1.2	4.7	1.1
10/28/2021 13:00	48.8	52.5	1.4	6.6	1.5
10/28/2021 14:00	6.1	0.0	1.6	8.3	1.8
10/28/2021 15:00	7.8	0.0	1.6	8.6	1.8
10/28/2021 16:00	12.3	1.3	2.1	11.2	2.5
10/28/2021 17:00	15.1	1.0	2.1	11.9	2.6
10/28/2021 18:00	13.0	0.7	2.1	11.9	2.6
10/28/2021 19:00	15.1	0.6	2.1	11.9	2.6
10/28/2021 20:00	12.8	0.7	2.1	11.7	2.6
10/28/2021 21:00	12.4	1.0	2.1	11.4	2.5
10/28/2021 22:00	12.3	1.0	2.1	11.2	2.5
10/28/2021 23:00	11.9	1.0	2.0	10.9	2.4
Average/Sum#:	252.6 #	92.7 #	35.9 #	169.1 #	37.9 #
Minimum:	4.1	0.0	0.9	3.4	0.8
Maximum:	48.8	52.5	2.1	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/29/2021 00:00	11.5	2.6	2.0	10.6	2.3
10/29/2021 01:00	11.6	3.3	2.0	10.6	2.3
10/29/2021 02:00	11.5	3.3	2.0	10.6	2.3
10/29/2021 03:00	11.5	3.3	2.0	10.6	2.3
10/29/2021 04:00	11.5	3.9	2.0	10.6	2.3
10/29/2021 05:00	11.6	4.2	2.0	10.6	2.3
10/29/2021 06:00	11.6	4.6	2.0	10.6	2.3
10/29/2021 07:00	11.5	4.2	2.0	10.6	2.3
10/29/2021 08:00	11.5	3.9	2.0	10.6	2.3
10/29/2021 09:00	8.7	1.5	1.7	9.5	2.1
10/29/2021 10:00	5.7	0.5	1.4	7.8	1.7
10/29/2021 11:00	11.6	0.6	2.0	10.7	2.3
10/29/2021 12:00	8.7	0.6	1.7	9.5	2.1
10/29/2021 13:00	5.7	0.5	1.4	7.8	1.7
10/29/2021 14:00	11.8	1.3	2.0	10.8	2.4
10/29/2021 15:00	11.8	1.3	2.0	10.8	2.4
10/29/2021 16:00	11.8	1.3	2.0	10.8	2.4
10/29/2021 17:00	11.8	1.3	2.0	10.8	2.4
10/29/2021 18:00	11.7	1.3	2.0	10.7	2.3
10/29/2021 19:00	11.7	1.3	2.0	10.7	2.3
10/29/2021 20:00	11.6	1.3	2.0	10.7	2.3
10/29/2021 21:00	11.6	1.3	2.0	10.6	2.3
10/29/2021 22:00	9.7	1.3	2.0	10.6	2.3
10/29/2021 23:00	12.0	1.3	2.0	11.0	2.4
Average/Sum#:	259.7 #	50.0 #	46.2 #	248.2 #	54.1 #
Minimum:	5.7	0.5	1.4	7.8	1.7
Maximum:	12.0	4.6	2.0	11.0	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/30/2021 00:00	8.3	0.0	1.7	9.0	2.0
10/30/2021 01:00	5.8	0.3	1.4	8.0	1.8
10/30/2021 02:00	8.9	0.9	1.8	9.7	2.1
10/30/2021 03:00	11.5	2.3	2.0	10.5	2.3
10/30/2021 04:00	8.1	0.0	1.6	8.9	2.0
10/30/2021 05:00	8.4	0.0	1.7	9.2	2.0
10/30/2021 06:00	10.1	2.6	2.0	11.0	2.4
10/30/2021 07:00	11.5	2.9	2.0	10.6	2.3
10/30/2021 08:00	6.1	0.3	1.6	8.3	1.8
10/30/2021 09:00	5.6	1.0	1.4	7.9	1.7
10/30/2021 10:00	5.6	0.8	1.4	7.9	1.7
10/30/2021 11:00	6.1	0.0	1.5	8.4	1.8
10/30/2021 12:00	5.6	0.0	1.4	7.6	1.6
10/30/2021 13:00	5.6	0.3	1.4	7.7	1.6
10/30/2021 14:00	6.1	0.0	1.6	8.3	1.8
10/30/2021 15:00	8.1	0.0	1.6	8.8	1.9
10/30/2021 16:00	12.1	1.9	2.0	11.1	2.4
10/30/2021 17:00	12.5	1.6	2.1	11.5	2.5
10/30/2021 18:00	12.4	2.0	2.1	11.3	2.5
10/30/2021 19:00	11.9	1.6	2.0	10.9	2.4
10/30/2021 20:00	8.3	0.0	1.7	9.1	2.0
10/30/2021 21:00	6.5	0.0	1.7	8.9	2.0
10/30/2021 22:00	10.0	2.2	2.0	10.9	2.4
10/30/2021 23:00	11.5	2.6	2.0	10.5	2.3
Average/Sum#:	206.6 #	23.3 #	41.7 #	226.0 #	49.3 #
Minimum:	5.6	0.0	1.4	7.6	1.6
Maximum:	12.5	2.9	2.1	11.5	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
10/31/2021 00:00	6.6	0.0	1.7	9.1	2.0
10/31/2021 01:00	6.2	0.3	1.6	8.5	1.8
10/31/2021 02:00	9.7	4.3	2.0	10.7	2.4
10/31/2021 03:00	11.5	2.7	2.0	10.5	2.3
10/31/2021 04:00	6.8	0.0	1.7	9.3	2.0
10/31/2021 05:00	6.2	0.0	1.6	8.5	1.8
10/31/2021 06:00	12.1	2.0	2.0	11.1	2.4
10/31/2021 07:00	9.6	2.6	2.0	10.6	2.3
10/31/2021 08:00	6.6	0.0	1.7	9.0	2.0
10/31/2021 09:00	6.4	0.0	1.6	8.7	1.9
10/31/2021 10:00	5.6	0.5	1.4	7.7	1.6
10/31/2021 11:00	6.2	0.0	1.6	8.5	1.8
10/31/2021 12:00	6.4	0.0	1.6	8.7	1.9
10/31/2021 13:00	6.8	0.0	1.7	9.2	2.0
10/31/2021 14:00	6.2	0.0	1.6	8.5	1.8
10/31/2021 15:00	8.0	0.3	1.6	8.7	1.9
10/31/2021 16:00	9.9	1.6	2.0	10.9	2.4
10/31/2021 17:00	12.2	1.6	2.0	11.1	2.4
10/31/2021 18:00	12.2	1.3	2.0	11.2	2.4
10/31/2021 19:00	11.6	1.3	2.0	10.6	2.3
10/31/2021 20:00	8.4	0.0	1.7	9.2	2.0
10/31/2021 21:00	6.3	0.3	1.6	8.6	1.9
10/31/2021 22:00	9.9	1.9	2.0	10.9	2.4
10/31/2021 23:00	11.5	2.3	2.0	10.6	2.3
Average/Sum#:	202.9 #	23.0 #	42.7 #	230.4 #	50.0 #
Minimum:	5.6	0.0	1.4	7.7	1.6
Maximum:	12.2	4.3	2.0	11.2	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/01/2021 00:00	8.1	0.0	1.6	8.9	2.0
11/01/2021 01:00	8.4	0.0	1.7	9.2	2.0
11/01/2021 02:00	11.6	3.9	2.0	10.6	2.3
11/01/2021 03:00	11.9	1.9	2.0	10.9	2.4
11/01/2021 04:00	7.9	0.0	1.6	8.7	1.9
11/01/2021 05:00	8.4	0.0	1.7	9.2	2.0
11/01/2021 06:00	12.2	2.2	2.0	11.2	2.4
11/01/2021 07:00	12.6	1.6	2.1	11.5	2.5
11/01/2021 08:00	11.7	1.9	2.0	10.7	2.4
11/01/2021 09:00	6.2	0.3	1.6	8.5	1.8
11/01/2021 10:00	6.1	0.3	1.6	8.3	1.8
11/01/2021 11:00	12.1	1.6	2.0	11.1	2.4
11/01/2021 12:00	12.1	1.6	2.0	11.1	2.4
11/01/2021 13:00	8.5	0.0	1.7	9.3	2.0
11/01/2021 14:00	8.9	0.0	1.8	9.8	2.2
11/01/2021 15:00	10.1	1.9	2.0	11.0	2.4
11/01/2021 16:00	12.3	1.3	2.1	11.3	2.4
11/01/2021 17:00	13.0	1.0	2.1	11.9	2.6
11/01/2021 18:00	12.8	1.3	2.1	11.7	2.6
11/01/2021 19:00	13.0	1.0	2.1	11.9	2.6
11/01/2021 20:00	13.1	1.0	2.2	12.0	2.6
11/01/2021 21:00	13.0	1.0	2.1	11.9	2.6
11/01/2021 22:00	12.4	1.3	2.1	11.4	2.5
11/01/2021 23:00	11.5	2.9	2.0	10.5	2.3
Average/Sum#:	257.9 #	28.0 #	46.2 #	252.6 #	55.1 #
Minimum:	6.1	0.0	1.6	8.3	1.8
Maximum:	13.1	3.9	2.2	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/02/2021 00:00	7.8	0.3	1.6	8.5	1.8
11/02/2021 01:00	6.4	0.6	1.6	8.7	1.9
11/02/2021 02:00	9.7	4.3	2.0	10.7	2.4
11/02/2021 03:00	11.6	3.6	2.0	10.7	2.4
11/02/2021 04:00	8.2	0.0	1.7	9.1	2.0
11/02/2021 05:00	6.5	0.0	1.6	8.9	2.0
11/02/2021 06:00	12.2	1.9	2.0	11.2	2.4
11/02/2021 07:00	12.2	1.3	2.0	11.2	2.4
11/02/2021 08:00	9.6	2.3	2.0	10.6	2.3
11/02/2021 09:00	6.1	0.0	1.6	8.3	1.8
11/02/2021 10:00	6.5	0.0	1.6	8.9	2.0
11/02/2021 11:00	5.3	0.5	1.3	7.2	1.6
11/02/2021 12:00	7.6	0.0	1.5	8.3	1.8
11/02/2021 13:00	8.1	0.0	1.6	8.9	2.0
11/02/2021 14:00	8.1	0.0	1.6	8.9	2.0
11/02/2021 15:00	11.4	0.0	1.7	8.9	2.0
11/02/2021 16:00	16.3	1.9	2.0	11.1	2.4
11/02/2021 17:00	19.3	1.3	2.1	11.7	2.6
11/02/2021 18:00	19.3	1.0	2.1	11.7	2.6
11/02/2021 19:00	19.9	1.6	2.3	12.1	2.6
11/02/2021 20:00	19.3	2.0	2.1	11.7	2.6
11/02/2021 21:00	19.2	2.0	2.1	11.7	2.6
11/02/2021 22:00	19.0	1.3	2.1	11.5	2.5
11/02/2021 23:00	15.6	2.9	2.0	10.7	2.4
Average/Sum#:	285.2 #	28.8 #	44.2 #	241.2 #	53.1 #
Minimum:	5.3	0.0	1.3	7.2	1.6
Maximum:	19.9	4.3	2.3	12.1	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/03/2021 00:00	10.1	0.0	1.7	9.2	2.0
11/03/2021 01:00	9.8	0.0	1.7	8.9	2.0
11/03/2021 02:00	15.4	5.3	2.0	10.6	2.3
11/03/2021 03:00	13.5	4.9	2.0	10.5	2.3
11/03/2021 04:00	9.9	0.3	1.7	9.0	2.0
11/03/2021 05:00	8.9	0.0	1.8	9.8	2.2
11/03/2021 06:00	11.9	3.9	2.0	10.9	2.4
11/03/2021 07:00	11.8	3.6	2.0	10.8	2.4
11/03/2021 08:00	8.3	0.0	1.7	9.1	2.0
11/03/2021 09:00	6.8	0.0	1.7	9.2	2.0
11/03/2021 10:00	6.4	0.0	1.6	8.7	1.9
11/03/2021 11:00	6.8	0.0	1.7	9.3	2.0
11/03/2021 12:00	6.1	0.0	1.6	8.3	1.8
11/03/2021 13:00	6.8	0.0	1.7	9.3	2.0
11/03/2021 14:00	6.1	0.0	1.5	8.3	1.8
11/03/2021 15:00	7.9	0.0	1.6	8.7	1.9
11/03/2021 16:00	12.2	3.5	2.0	11.1	2.4
11/03/2021 17:00	13.0	1.9	2.1	11.9	2.6
11/03/2021 18:00	12.8	2.6	2.1	11.7	2.6
11/03/2021 19:00	13.1	2.3	2.2	12.0	2.6
11/03/2021 20:00	13.0	2.2	2.1	11.9	2.6
11/03/2021 21:00	12.7	1.9	2.1	11.6	2.5
11/03/2021 22:00	12.4	1.6	2.1	11.3	2.5
11/03/2021 23:00	11.5	4.4	2.0	10.5	2.3
Average/Sum#:	247.2 #	38.4 #	44.7 #	242.6 #	53.1 #
Minimum:	6.1	0.0	1.5	8.3	1.8
Maximum:	15.4	5.3	2.2	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/04/2021 00:00	5.9	0.0	1.4	8.1	1.8
11/04/2021 01:00	7.9	0.6	1.6	8.7	1.9
11/04/2021 02:00	11.6	5.2	2.0	10.6	2.3
11/04/2021 03:00	11.8	1.9	2.0	10.8	2.4
11/04/2021 04:00	8.4	0.0	1.7	9.2	2.0
11/04/2021 05:00	8.8	0.0	1.7	9.6	2.1
11/04/2021 06:00	12.0	5.2	2.0	11.0	2.4
11/04/2021 07:00	11.9	2.2	2.0	10.9	2.4
11/04/2021 08:00	6.4	0.0	1.6	8.7	1.9
11/04/2021 09:00	6.1	0.0	1.5	8.3	1.8
11/04/2021 10:00	6.1	0.0	1.5	8.3	1.8
11/04/2021 11:00	6.0	0.0	1.4	8.1	1.8
11/04/2021 12:00	5.6	0.3	1.4	7.6	1.6
11/04/2021 13:00	6.1	0.0	1.6	8.5	1.8
11/04/2021 14:00	6.6	0.0	1.7	9.1	2.0
11/04/2021 15:00	6.2	0.0	1.6	8.5	1.8
11/04/2021 16:00	9.9	2.6	2.0	10.9	2.4
11/04/2021 17:00	12.4	2.3	2.1	11.3	2.5
11/04/2021 18:00	12.2	1.9	2.0	11.2	2.4
11/04/2021 19:00	8.4	0.0	1.7	9.3	2.0
11/04/2021 20:00	6.5	0.0	1.7	8.9	2.0
11/04/2021 21:00	12.1	2.3	2.0	11.1	2.4
11/04/2021 22:00	8.4	0.9	1.7	9.2	2.0
11/04/2021 23:00	6.4	7.1	1.1	4.4	1.0
Average/Sum#:	203.7 #	32.5 #	41.0 #	222.3 #	48.5 #
Minimum:	5.6	0.0	1.1	4.4	1.0
Maximum:	12.4	7.1	2.1	11.3	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/05/2021 00:00	4.1	0.5	0.9	3.4	0.8
11/05/2021 01:00	4.1	0.3	1.0	3.4	0.8
11/05/2021 02:00	4.1	0.5	1.0	3.4	0.8
11/05/2021 03:00	4.2	0.3	1.0	3.5	0.8
11/05/2021 04:00	4.8	0.0	1.1	4.0	1.0
11/05/2021 05:00	6.3	3.2	1.5	5.2	1.3
11/05/2021 06:00	6.2	2.6	1.4	5.2	1.2
11/05/2021 07:00	5.6	2.4	1.3	4.7	1.1
11/05/2021 08:00	2.7	1.0	1.0	3.4	0.8
11/05/2021 09:00	0.0	0.0	1.0	3.4	0.8
11/05/2021 10:00	1.4	0.3	1.0	3.4	0.8
11/05/2021 11:00	1.4	0.8	1.0	3.4	0.8
11/05/2021 12:00	1.4	0.5	1.0	3.6	0.9
11/05/2021 13:00	40.7	21.2	1.4	5.2	1.2
11/05/2021 14:00	32.0	39.3	1.5	7.8	1.7
11/05/2021 15:00	6.3	0.6	1.6	8.5	1.8
11/05/2021 16:00	10.3	3.9	2.1	11.3	2.4
11/05/2021 17:00	12.5	2.3	2.1	11.5	2.5
11/05/2021 18:00	12.4	1.9	2.1	11.3	2.5
11/05/2021 19:00	11.8	3.2	2.0	10.8	2.4
11/05/2021 20:00	8.3	0.0	1.7	9.1	2.0
11/05/2021 21:00	8.9	0.0	1.8	9.8	2.2
11/05/2021 22:00	10.1	4.3	2.0	11.0	2.4
11/05/2021 23:00	11.7	3.0	2.0	10.7	2.4
Average/Sum#:	211.3 #	92.1 #	34.5 #	157.0 #	35.4 #
Minimum:	1.4	0.0	0.9	3.4	0.8
Maximum:	40.7	39.3	2.1	11.5	2.5
%SI	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/06/2021 00:00	8.4	0.0	1.7	9.2	2.0
11/06/2021 01:00	6.4	0.3	1.6	8.7	1.9
11/06/2021 02:00	9.7	6.3	2.0	10.6	2.3
11/06/2021 03:00	9.7	6.2	2.0	10.6	2.3
11/06/2021 04:00	6.8	0.0	1.7	9.2	2.0
11/06/2021 05:00	6.5	0.0	1.6	8.9	2.0
11/06/2021 06:00	12.0	5.5	2.0	11.0	2.4
11/06/2021 07:00	11.5	3.2	2.0	10.6	2.3
11/06/2021 08:00	6.5	0.0	1.6	8.9	2.0
11/06/2021 09:00	6.5	0.0	1.6	8.8	2.0
11/06/2021 10:00	6.5	0.0	1.6	8.9	2.0
11/06/2021 11:00	6.2	0.0	1.6	8.5	1.8
11/06/2021 12:00	6.2	0.0	1.6	8.5	1.8
11/06/2021 13:00	6.3	0.0	1.6	8.7	1.8
11/06/2021 14:00	6.0	0.3	1.4	8.1	1.8
11/06/2021 15:00	7.9	0.3	1.6	8.7	1.9
11/06/2021 16:00	10.0	4.9	2.0	10.9	2.4
11/06/2021 17:00	12.4	2.3	2.1	11.4	2.5
11/06/2021 18:00	11.5	3.5	1.9	10.5	2.3
11/06/2021 19:00	8.3	0.0	1.7	9.1	2.0
11/06/2021 20:00	8.4	0.3	1.7	9.2	2.0
11/06/2021 21:00	11.8	6.3	2.0	10.8	2.4
11/06/2021 22:00	13.9	23.8	1.0	5.8	1.2
11/06/2021 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	199.4 #	63.2 #	39.6 #	215.6 #	47.1 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	13.9	23.8	2.1	11.4	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/07/2021 00:00	0.0	0.0	0.0	0.0	0.0
11/07/2021 01:00	0.0	0.0	0.0	0.0	0.0
11/07/2021 02:00	0.0	0.0	0.0	0.0	0.0
11/07/2021 03:00	0.0	0.0	0.0	0.0	0.0
11/07/2021 04:00	0.0	0.0	0.0	0.0	0.0
11/07/2021 05:00	0.0	0.0	0.0	0.0	0.0
11/07/2021 06:00	0.0	0.0	0.0	0.0	0.0
11/07/2021 07:00	0.0	0.0	0.0	0.0	0.0
11/07/2021 08:00	0.0	0.0	0.0	0.0	0.0
11/07/2021 09:00	0.0	0.0	0.0	0.0	0.0
11/07/2021 10:00	0.0	0.0	0.0	0.0	0.0
11/07/2021 11:00	0.0	0.0	0.0	0.0	0.0
11/07/2021 12:00	0.0	0.0	0.0	0.0	0.0
11/07/2021 13:00	0.0	0.0	0.0	0.0	0.0
11/07/2021 14:00	0.0	0.0	0.0	0.0	0.0
11/07/2021 15:00	0.0	0.0	0.0	0.0	0.0
11/07/2021 16:00	0.0	0.0	0.0	0.0	0.0
11/07/2021 17:00	0.0	0.0	0.0	0.0	0.0
11/07/2021 18:00	0.0	0.0	0.0	0.0	0.0
11/07/2021 19:00	0.0	0.0	0.0	0.0	0.0
11/07/2021 20:00	0.0	0.0	0.0	0.0	0.0
11/07/2021 21:00	0.0	0.0	0.0	0.0	0.0
11/07/2021 22:00	0.0	0.0	0.0	0.0	0.0
11/07/2021 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/08/2021 00:00	0.0	0.0	0.0	0.0	0.0
11/08/2021 01:00	0.0	0.0	0.0	0.0	0.0
11/08/2021 02:00	0.0	0.0	0.0	0.0	0.0
11/08/2021 03:00	0.0	0.0	0.0	0.0	0.0
11/08/2021 04:00	0.0	0.0	0.0	0.0	0.0
11/08/2021 05:00	0.0	0.0	0.0	0.0	0.0
11/08/2021 06:00	0.0	0.0	0.0	0.0	0.0
11/08/2021 07:00	0.0	0.0	0.0	0.0	0.0
11/08/2021 08:00	0.0	0.0	0.0	0.0	0.0
11/08/2021 09:00	0.0	0.0	0.0	0.0	0.0
11/08/2021 10:00	0.0	0.0	0.0	0.0	0.0
11/08/2021 11:00	0.0	0.0	0.0	0.0	0.0
11/08/2021 12:00	40.8	57.9	0.1	0.6	0.1
11/08/2021 13:00	39.9	45.7	0.2	1.5	0.3
11/08/2021 14:00	57.7	83.7	0.3	2.8	0.6
11/08/2021 15:00	1.6	0.0	0.5	4.9	1.0
11/08/2021 16:00	0.0	0.0	0.6	6.0	1.2
11/08/2021 17:00	6.4	0.0	0.6	6.4	1.3
11/08/2021 18:00	5.9	1.0	0.6	5.9	1.2
11/08/2021 19:00	5.8	2.0	0.6	5.8	1.2
11/08/2021 20:00	8.4	0.0	0.6	6.3	1.3
11/08/2021 21:00	6.2	0.3	0.6	6.2	1.2
11/08/2021 22:00	3.8	3.6	0.6	5.6	1.1
11/08/2021 23:00	1.5	6.0	0.0	0.4	0.1
Average/Sum#:	178.0 #	200.2 #	5.3 #	52.4 #	10.6 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	57.7	83.7	0.6	6.4	1.3
%SI	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/09/2021 00:00	0.0	0.0	0.0	0.0	0.0
11/09/2021 01:00	0.0	0.0	0.0	0.0	0.0
11/09/2021 02:00	0.0	0.0	0.0	0.0	0.0
11/09/2021 03:00	2.2	8.6	0.0	0.3	0.1
11/09/2021 04:00	20.8	73.7	0.3	2.7	0.5
11/09/2021 05:00	1.5	0.0	0.4	4.5	0.9
11/09/2021 06:00	1.5	0.0	0.5	4.6	0.9
11/09/2021 07:00	62.7	81.0	0.7	5.9	1.2
11/09/2021 08:00	38.9	118.0	1.2	7.2	1.5
11/09/2021 09:00	8.6	0.0	1.7	9.3	2.0
11/09/2021 10:00	6.1	0.3	1.5	8.3	1.8
11/09/2021 11:00	6.2	0.3	1.6	8.6	1.8
11/09/2021 12:00	6.2	0.3	1.6	8.5	1.8
11/09/2021 13:00	8.4	0.0	1.7	9.1	2.0
11/09/2021 14:00	6.5	0.0	1.6	8.9	2.0
11/09/2021 15:00	6.1	0.6	1.5	8.3	1.8
11/09/2021 16:00	6.2	0.3	1.6	8.5	1.8
11/09/2021 17:00	9.2	4.5	1.8	10.2	2.2
11/09/2021 18:00	12.6	2.6	2.1	11.6	2.5
11/09/2021 19:00	13.0	2.3	2.1	11.9	2.6
11/09/2021 20:00	12.6	2.0	2.1	11.5	2.5
11/09/2021 21:00	8.1	0.0	1.6	8.8	1.9
11/09/2021 22:00	8.6	0.0	1.7	9.4	2.0
11/09/2021 23:00	10.0	5.3	2.0	10.9	2.4
Average/Sum#:	256.0 #	299.8 #	29.3 #	169.0 #	36.2 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	62.7	118.0	2.1	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/10/2021 00:00	9.1	2.9	1.8	10.0	2.2
11/10/2021 01:00	8.9	0.0	1.8	9.8	2.2
11/10/2021 02:00	6.4	0.3	1.6	8.7	1.9
11/10/2021 03:00	9.8	8.0	2.0	10.7	2.4
11/10/2021 04:00	9.6	5.9	2.0	10.6	2.3
11/10/2021 05:00	8.5	0.0	1.7	9.3	2.0
11/10/2021 06:00	8.9	0.0	1.8	9.8	2.2
11/10/2021 07:00	9.9	7.7	2.0	10.9	2.4
11/10/2021 08:00	9.6	5.2	2.0	10.6	2.3
11/10/2021 09:00	6.2	0.0	1.6	8.5	1.8
11/10/2021 10:00	5.9	0.3	1.4	8.1	1.8
11/10/2021 11:00	5.7	0.3	1.4	7.8	1.7
11/10/2021 12:00	5.9	0.3	1.4	8.1	1.8
11/10/2021 13:00	5.4	0.5	1.3	7.4	1.6
11/10/2021 14:00	6.0	0.3	1.4	8.1	1.8
11/10/2021 15:00	7.9	0.3	1.6	8.7	1.9
11/10/2021 16:00	10.0	3.9	2.0	11.0	2.4
11/10/2021 17:00	12.0	2.0	2.0	11.0	2.4
11/10/2021 18:00	12.4	2.3	2.1	11.3	2.5
11/10/2021 19:00	12.4	2.0	2.1	11.3	2.5
11/10/2021 20:00	11.9	2.0	2.0	10.9	2.4
11/10/2021 21:00	8.4	0.0	1.7	9.3	2.0
11/10/2021 22:00	8.8	0.0	1.7	9.7	2.1
11/10/2021 23:00	10.1	4.0	2.0	11.1	2.4
Average/Sum#:	209.7 #	48.2 #	42.4 #	232.7 #	51.0 #
Minimum:	5.4	0.0	1.3	7.4	1.6
Maximum:	12.4	8.0	2.1	11.3	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/11/2021 00:00	11.6	3.9	2.0	10.6	2.3
11/11/2021 01:00	4.6	12.9	0.1	0.7	0.2
11/11/2021 02:00	0.0	0.0	0.0	0.0	0.0
11/11/2021 03:00	0.0	0.0	0.0	0.0	0.0
11/11/2021 04:00	0.0	0.0	0.0	0.0	0.0
11/11/2021 05:00	0.0	0.0	0.0	0.0	0.0
11/11/2021 06:00	0.0	0.0	0.0	0.0	0.0
11/11/2021 07:00	0.0	0.0	0.0	0.0	0.0
11/11/2021 08:00	0.0	0.0	0.0	0.0	0.0
11/11/2021 09:00	20.9	20.6	0.1	0.3	0.1
11/11/2021 10:00	49.0	188.6	0.6	2.0	0.5
11/11/2021 11:00	4.2	0.5	1.0	3.5	0.8
11/11/2021 12:00	6.8	0.5	1.0	3.4	0.8
11/11/2021 13:00	39.2	21.6	1.3	4.9	1.1
11/11/2021 14:00	45.4	81.5	1.4	6.9	1.5
11/11/2021 15:00	8.3	0.0	1.7	9.1	2.0
11/11/2021 16:00	9.1	2.2	1.8	9.9	2.2
11/11/2021 17:00	12.5	1.9	2.1	11.4	2.5
11/11/2021 18:00	12.6	2.0	2.1	11.5	2.5
11/11/2021 19:00	12.6	2.3	2.1	11.5	2.5
11/11/2021 20:00	12.4	2.3	2.1	11.3	2.5
11/11/2021 21:00	8.4	0.3	1.7	9.2	2.0
11/11/2021 22:00	8.8	0.0	1.7	9.6	2.1
11/11/2021 23:00	11.9	3.0	2.0	10.9	2.4
Average/Sum#:	278.3 #	344.1 #	24.8 #	126.7 #	28.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	49.0	188.6	2.1	11.5	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/12/2021 00:00	9.6	3.6	2.0	10.5	2.3
11/12/2021 01:00	6.3	0.3	1.6	8.6	1.8
11/12/2021 02:00	6.1	0.3	1.6	8.5	1.8
11/12/2021 03:00	6.1	0.3	1.6	8.5	1.8
11/12/2021 04:00	6.3	0.9	1.6	8.6	1.9
11/12/2021 05:00	10.1	3.0	2.0	11.1	2.4
11/12/2021 06:00	12.3	2.3	2.1	11.3	2.4
11/12/2021 07:00	8.4	1.2	1.7	9.2	2.0
11/12/2021 08:00	6.4	9.4	1.1	4.6	1.1
11/12/2021 09:00	4.1	0.8	1.0	3.4	0.8
11/12/2021 10:00	4.1	0.8	1.0	3.4	0.8
11/12/2021 11:00	4.1	0.8	1.0	3.5	0.8
11/12/2021 12:00	4.2	1.0	1.0	3.5	0.8
11/12/2021 13:00	4.2	1.0	1.0	3.5	0.8
11/12/2021 14:00	4.2	1.0	1.0	3.5	0.8
11/12/2021 15:00	15.2	13.7	1.2	4.5	1.1
11/12/2021 16:00	29.9	74.1	1.4	6.5	1.5
11/12/2021 17:00	5.7	0.8	1.4	7.8	1.7
11/12/2021 18:00	7.9	0.9	1.6	8.7	1.9
11/12/2021 19:00	10.2	3.3	2.0	11.2	2.4
11/12/2021 20:00	11.8	2.3	2.0	10.8	2.4
11/12/2021 21:00	8.1	0.0	1.6	8.9	2.0
11/12/2021 22:00	8.4	0.3	1.7	9.2	2.0
11/12/2021 23:00	10.1	3.0	2.0	11.1	2.4
Average/Sum#:	203.8 #	125.1 #	36.2 #	180.4 #	39.7 #
Minimum:	4.1	0.0	1.0	3.4	0.8
Maximum:	29.9	74.1	2.1	11.3	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/13/2021 00:00	7.6	22.2	0.6	3.2	0.7
11/13/2021 01:00	0.0	0.0	0.0	0.0	0.0
11/13/2021 02:00	0.0	0.0	0.0	0.0	0.0
11/13/2021 03:00	0.0	0.0	0.0	0.0	0.0
11/13/2021 04:00	0.0	0.0	0.0	0.0	0.0
11/13/2021 05:00	0.0	0.0	0.0	0.0	0.0
11/13/2021 06:00	0.0	0.0	0.0	0.0	0.0
11/13/2021 07:00	0.0	0.0	0.0	0.0	0.0
11/13/2021 08:00	16.9	22.2	0.1	0.3	0.1
11/13/2021 09:00	26.6	98.7	0.7	2.4	0.6
11/13/2021 10:00	4.2	1.3	1.0	3.5	0.8
11/13/2021 11:00	4.1	1.0	1.0	3.4	0.8
11/13/2021 12:00	4.2	0.8	1.0	3.5	0.8
11/13/2021 13:00	37.1	22.3	1.3	5.1	1.1
11/13/2021 14:00	24.6	55.7	1.3	6.9	1.5
11/13/2021 15:00	8.4	0.0	1.7	9.3	2.0
11/13/2021 16:00	8.9	0.3	1.7	9.7	2.1
11/13/2021 17:00	10.1	2.9	2.0	11.0	2.4
11/13/2021 18:00	11.8	2.2	2.0	10.8	2.4
11/13/2021 19:00	8.5	0.0	1.7	9.3	2.0
11/13/2021 20:00	8.9	0.0	1.8	9.8	2.2
11/13/2021 21:00	10.1	4.4	2.0	11.0	2.4
11/13/2021 22:00	13.0	29.5	1.0	5.9	1.3
11/13/2021 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	205.0 #	263.5 #	20.9 #	105.1 #	23.2 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	37.1	98.7	2.0	11.0	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/14/2021 00:00	0.0	0.0	0.0	0.0	0.0
11/14/2021 01:00	0.0	0.0	0.0	0.0	0.0
11/14/2021 02:00	0.0	0.0	0.0	0.0	0.0
11/14/2021 03:00	0.0	0.0	0.0	0.0	0.0
11/14/2021 04:00	0.0	0.0	0.0	0.0	0.0
11/14/2021 05:00	0.0	0.0	0.0	0.0	0.0
11/14/2021 06:00	0.0	0.0	0.0	0.0	0.0
11/14/2021 07:00	0.0	0.0	0.0	0.0	0.0
11/14/2021 08:00	0.0	0.0	0.0	0.0	0.0
11/14/2021 09:00	5.2	19.8	0.0	0.1	0.0
11/14/2021 10:00	46.9	52.8	0.3	1.0	0.2
11/14/2021 11:00	18.0	84.4	0.8	3.0	0.7
11/14/2021 12:00	4.1	1.5	1.0	3.4	0.8
11/14/2021 13:00	4.1	1.3	1.0	3.5	0.8
11/14/2021 14:00	10.3	23.2	1.2	4.3	1.0
11/14/2021 15:00	70.9	66.9	1.3	6.2	1.4
11/14/2021 16:00	5.3	1.2	1.3	7.2	1.6
11/14/2021 17:00	7.9	0.9	1.6	8.7	1.9
11/14/2021 18:00	10.2	4.0	2.0	11.2	2.4
11/14/2021 19:00	9.8	3.2	2.0	10.7	2.4
11/14/2021 20:00	8.6	0.6	1.7	9.4	2.0
11/14/2021 21:00	6.4	0.6	1.6	8.7	1.9
11/14/2021 22:00	10.2	5.0	2.0	11.1	2.4
11/14/2021 23:00	8.3	1.8	1.7	9.1	2.0
Average/Sum#:	226.2 #	267.2 #	19.5 #	97.6 #	21.5 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	70.9	84.4	2.0	11.2	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/15/2021 00:00	6.4	10.8	1.1	4.5	1.0
11/15/2021 01:00	4.1	1.0	1.0	3.4	0.8
11/15/2021 02:00	4.1	1.0	1.0	3.4	0.8
11/15/2021 03:00	4.1	1.0	1.0	3.4	0.8
11/15/2021 04:00	4.1	1.0	1.0	3.4	0.8
11/15/2021 05:00	4.3	0.8	1.0	3.6	0.9
11/15/2021 06:00	4.7	0.6	1.1	3.9	0.9
11/15/2021 07:00	19.0	16.3	1.2	4.8	1.1
11/15/2021 08:00	37.3	87.7	1.3	6.4	1.5
11/15/2021 09:00	5.6	1.1	1.4	7.7	1.6
11/15/2021 10:00	8.1	0.9	1.6	8.9	2.0
11/15/2021 11:00	9.8	11.2	2.0	10.7	2.4
11/15/2021 12:00	9.8	10.6	2.0	10.7	2.4
11/15/2021 13:00	7.6	2.2	1.6	8.3	1.8
11/15/2021 14:00	7.9	0.6	1.6	8.7	1.9
11/15/2021 15:00	9.7	3.6	2.0	10.6	2.3
11/15/2021 16:00	9.9	3.6	2.0	10.9	2.4
11/15/2021 17:00	9.7	5.9	2.0	10.7	2.4
11/15/2021 18:00	9.8	5.3	2.0	10.7	2.4
11/15/2021 19:00	12.4	2.3	2.1	11.3	2.5
11/15/2021 20:00	11.7	5.0	2.0	10.7	2.4
11/15/2021 21:00	11.6	5.3	2.0	10.6	2.3
11/15/2021 22:00	9.6	5.9	2.0	10.6	2.3
11/15/2021 23:00	11.5	6.2	2.0	10.5	2.3
Average/Sum#:	232.8 #	189.9 #	38.0 #	188.4 #	42.0 #
Minimum:	4.1	0.6	1.0	3.4	0.8
Maximum:	37.3	87.7	2.1	11.3	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/16/2021 00:00	4.6	17.9	0.1	0.9	0.2
11/16/2021 01:00	0.0	0.0	0.0	0.0	0.0
11/16/2021 02:00	0.0	0.0	0.0	0.0	0.0
11/16/2021 03:00	0.0	0.0	0.0	0.0	0.0
11/16/2021 04:00	0.0	0.0	0.0	0.0	0.0
11/16/2021 05:00	0.0	0.0	0.0	0.0	0.0
11/16/2021 06:00	0.0	0.0	0.0	0.0	0.0
11/16/2021 07:00	0.0	0.0	0.0	0.0	0.0
11/16/2021 08:00	19.9	24.4	0.1	0.3	0.1
11/16/2021 09:00	32.4	132.2	0.5	1.9	0.5
11/16/2021 10:00	4.2	1.0	1.0	3.5	0.8
11/16/2021 11:00	6.9	0.5	1.0	3.4	0.8
11/16/2021 12:00	4.1	0.3	1.0	3.5	0.8
11/16/2021 13:00	8.1	12.2	1.1	4.0	0.9
11/16/2021 14:00	70.7	66.0	1.4	6.0	1.3
11/16/2021 15:00	27.4	30.0	1.4	7.7	1.7
11/16/2021 16:00	7.5	0.3	1.5	8.2	1.8
11/16/2021 17:00	11.6	4.3	2.0	10.6	2.3
11/16/2021 18:00	12.2	4.0	2.0	11.1	2.4
11/16/2021 19:00	11.7	4.0	2.0	10.7	2.4
11/16/2021 20:00	12.7	2.3	2.1	11.6	2.6
11/16/2021 21:00	12.9	2.0	2.1	11.8	2.6
11/16/2021 22:00	12.4	1.7	2.1	11.3	2.5
11/16/2021 23:00	14.8	2.0	2.1	11.6	2.5
Average/Sum#:	274.1 #	305.1 #	23.5 #	118.1 #	26.2 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	70.7	132.2	2.1	11.8	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/17/2021 00:00	11.8	1.7	2.0	10.8	2.4
11/17/2021 01:00	11.6	2.7	2.0	10.6	2.3
11/17/2021 02:00	11.6	3.3	2.0	10.6	2.3
11/17/2021 03:00	11.6	3.6	2.0	10.6	2.3
11/17/2021 04:00	12.0	3.1	2.0	11.0	2.4
11/17/2021 05:00	12.1	3.0	2.0	11.1	2.4
11/17/2021 06:00	13.1	2.3	2.2	12.0	2.6
11/17/2021 07:00	12.6	2.0	2.1	11.5	2.5
11/17/2021 08:00	9.7	6.4	2.0	10.7	2.4
11/17/2021 09:00	11.5	6.3	2.0	10.6	2.3
11/17/2021 10:00	7.7	0.6	1.6	8.5	1.8
11/17/2021 11:00	9.4	3.0	1.9	10.2	2.2
11/17/2021 12:00	11.7	4.7	2.0	10.7	2.4
11/17/2021 13:00	7.5	1.1	1.5	8.2	1.8
11/17/2021 14:00	5.8	0.6	1.4	8.0	1.8
11/17/2021 15:00	13.5	2.9	2.0	10.6	2.3
11/17/2021 16:00	12.3	2.3	2.0	11.3	2.4
11/17/2021 17:00	12.8	2.0	2.1	11.7	2.6
11/17/2021 18:00	12.8	2.0	2.1	11.7	2.6
11/17/2021 19:00	15.2	2.0	2.2	11.9	2.6
11/17/2021 20:00	15.2	1.7	2.2	12.0	2.6
11/17/2021 21:00	12.5	2.0	2.1	11.4	2.5
11/17/2021 22:00	11.6	3.3	2.0	10.6	2.3
11/17/2021 23:00	9.7	3.6	2.0	10.6	2.3
Average/Sum#:	275.3 #	66.2 #	47.4 #	256.9 #	56.1 #
Minimum:	5.8	0.6	1.4	8.0	1.8
Maximum:	15.2	6.4	2.2	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/18/2021 00:00	9.7	4.4	2.0	10.6	2.3
11/18/2021 01:00	9.7	4.7	2.0	10.6	2.3
11/18/2021 02:00	9.7	4.7	2.0	10.6	2.3
11/18/2021 03:00	9.7	4.7	2.0	10.6	2.3
11/18/2021 04:00	9.7	4.7	2.0	10.6	2.3
11/18/2021 05:00	10.1	3.6	2.0	11.1	2.4
11/18/2021 06:00	12.8	2.3	2.1	11.7	2.6
11/18/2021 07:00	12.6	2.0	2.1	11.5	2.5
11/18/2021 08:00	12.0	2.3	2.0	11.0	2.4
11/18/2021 09:00	9.6	4.3	2.0	10.5	2.3
11/18/2021 10:00	8.3	0.3	1.7	9.1	2.0
11/18/2021 11:00	11.7	4.3	2.0	10.7	2.4
11/18/2021 12:00	11.7	3.3	2.0	10.7	2.4
11/18/2021 13:00	7.6	1.1	1.5	8.3	1.8
11/18/2021 14:00	6.0	0.6	1.5	8.2	1.8
11/18/2021 15:00	10.9	1.3	1.8	10.0	2.2
11/18/2021 16:00	12.6	2.6	2.1	11.5	2.5
11/18/2021 17:00	12.8	2.3	2.1	11.7	2.6
11/18/2021 18:00	13.3	2.0	2.2	12.2	2.7
11/18/2021 19:00	12.8	2.0	2.1	11.7	2.6
11/18/2021 20:00	12.4	2.0	2.1	11.4	2.5
11/18/2021 21:00	11.7	3.0	2.0	10.7	2.4
11/18/2021 22:00	11.5	4.3	2.0	10.6	2.3
11/18/2021 23:00	11.5	4.3	2.0	10.6	2.3
Average/Sum#:	260.4 #	71.1 #	47.3 #	256.2 #	56.2 #
Minimum:	6.0	0.3	1.5	8.2	1.8
Maximum:	13.3	4.7	2.2	12.2	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/19/2021 00:00	11.5	5.0	2.0	10.6	2.3
11/19/2021 01:00	11.4	4.9	1.9	10.4	2.3
11/19/2021 02:00	8.1	0.3	1.6	8.9	2.0
11/19/2021 03:00	9.7	4.0	2.0	10.6	2.3
11/19/2021 04:00	12.0	2.3	2.0	11.0	2.4
11/19/2021 05:00	12.3	2.3	2.1	11.2	2.5
11/19/2021 06:00	12.6	2.3	2.1	11.6	2.5
11/19/2021 07:00	12.5	2.3	2.1	11.4	2.5
11/19/2021 08:00	11.8	2.3	2.0	10.8	2.4
11/19/2021 09:00	9.7	2.6	2.0	10.6	2.3
11/19/2021 10:00	11.6	2.9	2.0	10.6	2.3
11/19/2021 11:00	11.7	2.3	2.0	10.8	2.4
11/19/2021 12:00	11.7	2.3	2.0	10.7	2.4
11/19/2021 13:00	12.5	2.3	2.1	11.4	2.5
11/19/2021 14:00	12.4	2.0	2.1	11.4	2.5
11/19/2021 15:00	12.0	2.0	2.0	11.0	2.4
11/19/2021 16:00	12.2	2.0	2.0	11.1	2.4
11/19/2021 17:00	12.2	2.0	2.0	11.2	2.4
11/19/2021 18:00	12.2	2.0	2.1	11.2	2.4
11/19/2021 19:00	11.5	2.3	2.0	10.6	2.3
11/19/2021 20:00	8.4	0.0	1.7	9.1	2.0
11/19/2021 21:00	8.8	0.0	1.7	9.6	2.1
11/19/2021 22:00	11.8	2.6	2.0	10.8	2.4
11/19/2021 23:00	11.7	2.3	2.0	10.7	2.4
Average/Sum#:	272.3 #	55.3 #	47.5 #	257.3 #	56.4 #
Minimum:	8.1	0.0	1.6	8.9	2.0
Maximum:	12.6	5.0	2.1	11.6	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/20/2021 00:00	11.5	3.0	2.0	10.5	2.3
11/20/2021 01:00	7.9	0.0	1.6	8.6	1.9
11/20/2021 02:00	6.2	0.0	1.6	8.5	1.8
11/20/2021 03:00	6.1	0.0	1.6	8.5	1.8
11/20/2021 04:00	8.4	0.3	1.7	9.3	2.0
11/20/2021 05:00	12.2	2.6	2.0	11.1	2.4
11/20/2021 06:00	11.9	2.3	2.0	10.9	2.4
11/20/2021 07:00	8.1	0.0	1.7	8.9	2.0
11/20/2021 08:00	8.3	0.0	1.7	9.1	2.0
11/20/2021 09:00	5.9	0.3	1.4	8.1	1.8
11/20/2021 10:00	6.1	0.0	1.5	8.3	1.8
11/20/2021 11:00	6.4	0.0	1.6	8.7	1.9
11/20/2021 12:00	5.8	0.0	1.4	7.9	1.8
11/20/2021 13:00	6.0	0.0	1.4	8.1	1.8
11/20/2021 14:00	6.0	0.0	1.5	8.2	1.8
11/20/2021 15:00	8.1	0.3	1.6	8.8	2.0
11/20/2021 16:00	14.0	2.3	2.0	11.0	2.4
11/20/2021 17:00	14.2	2.0	2.1	11.2	2.4
11/20/2021 18:00	13.5	1.6	2.0	10.6	2.3
11/20/2021 19:00	8.5	0.0	1.7	9.3	2.0
11/20/2021 20:00	10.7	0.0	1.8	9.8	2.2
11/20/2021 21:00	14.0	2.7	2.0	11.1	2.4
11/20/2021 22:00	14.6	2.0	2.1	11.5	2.5
11/20/2021 23:00	11.1	1.0	1.9	10.2	2.2
Average/Sum#:	225.5 #	20.4 #	41.9 #	228.2 #	49.9 #
Minimum:	5.8	0.0	1.4	7.9	1.8
Maximum:	14.6	3.0	2.1	11.5	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/21/2021 00:00	8.6	0.0	1.7	9.5	2.0
11/21/2021 01:00	11.6	3.0	2.0	10.6	2.3
11/21/2021 02:00	14.6	22.2	1.4	7.2	1.6
11/21/2021 03:00	0.0	0.0	0.0	0.0	0.0
11/21/2021 04:00	0.0	0.0	0.0	0.0	0.0
11/21/2021 05:00	0.0	0.0	0.0	0.0	0.0
11/21/2021 06:00	0.0	0.0	0.0	0.0	0.0
11/21/2021 07:00	0.0	0.0	0.0	0.0	0.0
11/21/2021 08:00	0.0	0.0	0.0	0.0	0.0
11/21/2021 09:00	0.0	0.0	0.0	0.0	0.0
11/21/2021 10:00	10.4	9.7	0.1	0.2	0.0
11/21/2021 11:00	53.5	71.0	0.5	1.8	0.4
11/21/2021 12:00	4.2	0.0	1.0	3.5	0.8
11/21/2021 13:00	6.9	0.0	1.0	3.4	0.8
11/21/2021 14:00	36.1	11.9	1.1	4.5	1.1
11/21/2021 15:00	49.5	42.2	1.3	6.2	1.4
11/21/2021 16:00	5.3	0.3	1.3	7.2	1.6
11/21/2021 17:00	7.9	0.0	1.6	8.6	1.9
11/21/2021 18:00	14.1	2.6	2.0	11.1	2.4
11/21/2021 19:00	14.2	1.9	2.0	11.2	2.4
11/21/2021 20:00	8.4	0.0	1.7	9.2	2.0
11/21/2021 21:00	10.6	0.0	1.8	9.7	2.1
11/21/2021 22:00	11.8	3.7	2.0	10.8	2.4
11/21/2021 23:00	8.4	1.2	1.7	9.2	2.0
Average/Sum#:	276.1 #	169.7 #	24.2 #	123.9 #	27.2 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	53.5	71.0	2.0	11.2	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/22/2021 00:00	7.7	9.1	1.1	4.8	1.1
11/22/2021 01:00	4.1	0.5	1.0	3.4	0.8
11/22/2021 02:00	4.1	0.5	1.0	3.4	0.8
11/22/2021 03:00	4.5	0.6	1.0	3.7	0.9
11/22/2021 04:00	4.3	0.5	1.0	3.6	0.9
11/22/2021 05:00	4.5	0.6	1.0	3.7	0.9
11/22/2021 06:00	6.0	4.8	1.4	5.0	1.2
11/22/2021 07:00	6.0	2.7	1.4	5.0	1.2
11/22/2021 08:00	4.4	0.8	1.0	3.7	0.9
11/22/2021 09:00	4.2	0.8	1.0	3.5	0.8
11/22/2021 10:00	4.1	0.5	1.0	3.4	0.8
11/22/2021 11:00	4.2	0.5	1.0	3.5	0.8
11/22/2021 12:00	41.8	23.2	1.3	5.0	1.1
11/22/2021 13:00	43.6	58.2	1.4	7.2	1.6
11/22/2021 14:00	8.4	0.0	1.7	9.3	2.0
11/22/2021 15:00	8.6	0.0	1.7	9.5	2.0
11/22/2021 16:00	11.6	1.6	2.0	10.6	2.3
11/22/2021 17:00	12.2	2.3	2.1	11.2	2.4
11/22/2021 18:00	14.9	1.9	2.1	11.7	2.5
11/22/2021 19:00	12.7	2.0	2.1	11.6	2.5
11/22/2021 20:00	12.5	1.6	2.1	11.4	2.5
11/22/2021 21:00	8.1	0.0	1.7	8.9	2.0
11/22/2021 22:00	8.9	0.0	1.8	9.8	2.2
11/22/2021 23:00	12.1	2.7	2.0	11.1	2.4
Average/Sum#:	253.5 #	115.4 #	34.9 #	164.0 #	36.6 #
Minimum:	4.1	0.0	1.0	3.4	0.8
Maximum:	43.6	58.2	2.1	11.7	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/23/2021 00:00	11.6	2.6	2.0	10.6	2.3
11/23/2021 01:00	6.0	0.6	1.5	8.2	1.8
11/23/2021 02:00	8.4	0.3	1.7	9.3	2.0
11/23/2021 03:00	9.7	7.0	2.0	10.7	2.4
11/23/2021 04:00	9.6	3.3	2.0	10.5	2.3
11/23/2021 05:00	8.4	0.0	1.7	9.1	2.0
11/23/2021 06:00	8.1	0.3	1.6	8.9	2.0
11/23/2021 07:00	11.9	4.4	2.0	10.9	2.4
11/23/2021 08:00	11.8	2.0	2.0	10.8	2.4
11/23/2021 09:00	8.1	0.0	1.6	8.9	2.0
11/23/2021 10:00	6.2	0.0	1.6	8.5	1.8
11/23/2021 11:00	6.0	0.0	1.5	8.3	1.8
11/23/2021 12:00	5.6	0.3	1.4	7.6	1.6
11/23/2021 13:00	6.2	0.0	1.6	8.5	1.8
11/23/2021 14:00	8.3	0.0	1.7	9.1	2.0
11/23/2021 15:00	8.1	0.6	1.6	8.9	2.0
11/23/2021 16:00	12.2	2.3	2.0	11.1	2.4
11/23/2021 17:00	14.2	2.3	2.1	11.2	2.4
11/23/2021 18:00	14.4	2.0	2.1	11.3	2.5
11/23/2021 19:00	11.5	2.0	2.0	10.6	2.3
11/23/2021 20:00	8.5	0.0	1.7	9.3	2.0
11/23/2021 21:00	7.8	0.3	1.6	8.5	1.8
11/23/2021 22:00	12.2	2.3	2.0	11.1	2.4
11/23/2021 23:00	11.7	2.0	2.0	10.7	2.4
Average/Sum#:	226.5 #	34.6 #	43.0 #	232.6 #	50.8 #
Minimum:	5.6	0.0	1.4	7.6	1.6
Maximum:	14.4	7.0	2.1	11.3	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/24/2021 00:00	11.5	2.3	2.0	10.6	2.3
11/24/2021 01:00	6.0	0.3	1.5	8.3	1.8
11/24/2021 02:00	7.9	0.6	1.6	8.7	1.9
11/24/2021 03:00	11.7	5.1	2.0	10.7	2.4
11/24/2021 04:00	11.7	3.0	2.0	10.7	2.4
11/24/2021 05:00	8.3	0.0	1.7	9.1	2.0
11/24/2021 06:00	7.9	0.9	1.6	8.7	1.9
11/24/2021 07:00	11.9	2.3	2.0	10.9	2.4
11/24/2021 08:00	11.6	2.3	2.0	10.6	2.3
11/24/2021 09:00	8.3	0.0	1.7	9.1	2.0
11/24/2021 10:00	6.5	0.0	1.6	8.9	2.0
11/24/2021 11:00	8.4	0.0	1.7	9.2	2.0
11/24/2021 12:00	6.4	0.0	1.6	8.7	1.9
11/24/2021 13:00	8.1	0.0	1.6	8.9	2.0
11/24/2021 14:00	6.5	0.0	1.6	8.9	2.0
11/24/2021 15:00	8.4	0.0	1.7	9.1	2.0
11/24/2021 16:00	13.9	3.0	2.0	10.9	2.4
11/24/2021 17:00	14.2	2.3	2.0	11.1	2.4
11/24/2021 18:00	14.2	2.0	2.0	11.2	2.4
11/24/2021 19:00	14.0	2.0	2.0	11.0	2.4
11/24/2021 20:00	8.0	0.0	1.6	8.7	1.9
11/24/2021 21:00	8.7	0.0	1.7	9.6	2.1
11/24/2021 22:00	13.7	2.7	2.0	10.8	2.4
11/24/2021 23:00	13.3	3.3	1.9	10.4	2.3
Average/Sum#:	241.1 #	32.1 #	43.1 #	234.8 #	51.6 #
Minimum:	6.0	0.0	1.5	8.3	1.8
Maximum:	14.2	5.1	2.0	11.2	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/25/2021 00:00	5.8	10.9	0.1	0.7	0.2
11/25/2021 01:00	0.0	0.0	0.0	0.0	0.0
11/25/2021 02:00	0.0	0.0	0.0	0.0	0.0
11/25/2021 03:00	0.0	0.0	0.0	0.0	0.0
11/25/2021 04:00	0.0	0.0	0.0	0.0	0.0
11/25/2021 05:00	0.0	0.0	0.0	0.0	0.0
11/25/2021 06:00	0.0	0.0	0.0	0.0	0.0
11/25/2021 07:00	0.0	0.0	0.0	0.0	0.0
11/25/2021 08:00	0.0	0.0	0.0	0.0	0.0
11/25/2021 09:00	0.0	0.0	0.0	0.0	0.0
11/25/2021 10:00	0.0	0.0	0.0	0.0	0.0
11/25/2021 11:00	0.0	0.0	0.0	0.0	0.0
11/25/2021 12:00	0.0	0.0	0.0	0.0	0.0
11/25/2021 13:00	0.0	0.0	0.0	0.0	0.0
11/25/2021 14:00	0.0	0.0	0.0	0.0	0.0
11/25/2021 15:00	0.0	0.0	0.0	0.0	0.0
11/25/2021 16:00	0.0	0.0	0.0	0.0	0.0
11/25/2021 17:00	0.0	0.0	0.0	0.0	0.0
11/25/2021 18:00	0.0	0.0	0.0	0.0	0.0
11/25/2021 19:00	0.0	0.0	0.0	0.0	0.0
11/25/2021 20:00	0.0	0.0	0.0	0.0	0.0
11/25/2021 21:00	0.0	0.0	0.0	0.0	0.0
11/25/2021 22:00	0.0	0.0	0.0	0.0	0.0
11/25/2021 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	5.8 #	10.9 #	0.1 #	0.7 #	0.2 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	5.8	10.9	0.1	0.7	0.2
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/26/2021 00:00	0.0	0.0	0.0	0.0	0.0
11/26/2021 01:00	0.0	0.0	0.0	0.0	0.0
11/26/2021 02:00	0.0	0.0	0.0	0.0	0.0
11/26/2021 03:00	0.0	0.0	0.0	0.0	0.0
11/26/2021 04:00	0.0	0.0	0.0	0.0	0.0
11/26/2021 05:00	0.0	0.0	0.0	0.0	0.0
11/26/2021 06:00	0.0	0.0	0.0	0.0	0.0
11/26/2021 07:00	0.0	0.0	0.0	0.0	0.0
11/26/2021 08:00	0.0	0.0	0.0	0.0	0.0
11/26/2021 09:00	0.0	0.0	0.0	0.0	0.0
11/26/2021 10:00	0.0	0.0	0.0	0.0	0.0
11/26/2021 11:00	0.0	0.0	0.0	0.0	0.0
11/26/2021 12:00	0.0	0.0	0.0	0.0	0.0
11/26/2021 13:00	0.0	0.0	0.0	0.0	0.0
11/26/2021 14:00	0.0	0.0	0.0	0.0	0.0
11/26/2021 15:00	0.0	0.0	0.0	0.0	0.0
11/26/2021 16:00	0.0	0.0	0.0	0.0	0.0
11/26/2021 17:00	0.0	0.0	0.0	0.0	0.0
11/26/2021 18:00	0.0	0.0	0.0	0.0	0.0
11/26/2021 19:00	0.0	0.0	0.0	0.0	0.0
11/26/2021 20:00	0.0	0.0	0.0	0.0	0.0
11/26/2021 21:00	0.0	0.0	0.0	0.0	0.0
11/26/2021 22:00	0.0	0.0	0.0	0.0	0.0
11/26/2021 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/27/2021 00:00	0.0	0.0	0.0	0.0	0.0
11/27/2021 01:00	0.0	0.0	0.0	0.0	0.0
11/27/2021 02:00	0.0	0.0	0.0	0.0	0.0
11/27/2021 03:00	0.0	0.0	0.0	0.0	0.0
11/27/2021 04:00	0.0	0.0	0.0	0.0	0.0
11/27/2021 05:00	0.0	0.0	0.0	0.0	0.0
11/27/2021 06:00	0.0	0.0	0.0	0.0	0.0
11/27/2021 07:00	0.0	0.0	0.0	0.0	0.0
11/27/2021 08:00	0.0	0.0	0.0	0.0	0.0
11/27/2021 09:00	0.0	0.0	0.0	0.0	0.0
11/27/2021 10:00	0.0	0.0	0.0	0.0	0.0
11/27/2021 11:00	0.0	0.0	0.0	0.0	0.0
11/27/2021 12:00	0.0	0.0	0.0	0.0	0.0
11/27/2021 13:00	0.0	0.0	0.0	0.0	0.0
11/27/2021 14:00	0.0	0.0	0.0	0.0	0.0
11/27/2021 15:00	0.0	0.0	0.0	0.0	0.0
11/27/2021 16:00	0.0	0.0	0.0	0.0	0.0
11/27/2021 17:00	0.0	0.0	0.0	0.0	0.0
11/27/2021 18:00	0.0	0.0	0.0	0.0	0.0
11/27/2021 19:00	0.0	0.0	0.0	0.0	0.0
11/27/2021 20:00	0.0	0.0	0.0	0.0	0.0
11/27/2021 21:00	0.0	0.0	0.0	0.0	0.0
11/27/2021 22:00	0.0	0.0	0.0	0.0	0.0
11/27/2021 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/28/2021 00:00	0.0	0.0	0.0	0.0	0.0
11/28/2021 01:00	0.0	0.0	0.0	0.0	0.0
11/28/2021 02:00	0.0	0.0	0.0	0.0	0.0
11/28/2021 03:00	0.0	0.0	0.0	0.0	0.0
11/28/2021 04:00	0.0	0.0	0.0	0.0	0.0
11/28/2021 05:00	0.0	0.0	0.0	0.0	0.0
11/28/2021 06:00	0.0	0.0	0.0	0.0	0.0
11/28/2021 07:00	0.0	0.0	0.0	0.0	0.0
11/28/2021 08:00	0.0	0.0	0.0	0.0	0.0
11/28/2021 09:00	0.0	0.0	0.0	0.0	0.0
11/28/2021 10:00	0.0	0.0	0.0	0.0	0.0
11/28/2021 11:00	0.0	0.0	0.0	0.0	0.0
11/28/2021 12:00	0.0	0.0	0.0	0.0	0.0
11/28/2021 13:00	0.0	0.0	0.0	0.0	0.0
11/28/2021 14:00	0.0	0.0	0.0	0.0	0.0
11/28/2021 15:00	0.0	0.0	0.0	0.0	0.0
11/28/2021 16:00	0.0	0.0	0.0	0.0	0.0
11/28/2021 17:00	0.0	0.0	0.0	0.0	0.0
11/28/2021 18:00	0.0	0.0	0.0	0.0	0.0
11/28/2021 19:00	0.0	0.0	0.0	0.0	0.0
11/28/2021 20:00	0.0	0.0	0.0	0.0	0.0
11/28/2021 21:00	0.0	0.0	0.0	0.0	0.0
11/28/2021 22:00	0.0	0.0	0.0	0.0	0.0
11/28/2021 23:00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0 #	0.0 #	0.0 #	0.0 #	0.0 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/29/2021 00:00	0.0	0.0	0.0	0.0	0.0
11/29/2021 01:00	0.0	0.0	0.0	0.0	0.0
11/29/2021 02:00	0.0	0.0	0.0	0.0	0.0
11/29/2021 03:00	0.0	0.0	0.0	0.0	0.0
11/29/2021 04:00	0.0	0.0	0.0	0.0	0.0
11/29/2021 05:00	0.0	0.0	0.0	0.0	0.0
11/29/2021 06:00	0.0	0.0	0.0	0.0	0.0
11/29/2021 07:00	2.6	20.4	0.0	0.1	0.0
11/29/2021 08:00	67.7	55.8	0.3	0.9	0.2
11/29/2021 09:00	10.8	26.5	0.3	1.0	0.2
11/29/2021 10:00	21.7	111.6	0.4	1.4	0.3
11/29/2021 11:00	35.5	127.2	0.7	2.3	0.6
11/29/2021 12:00	4.1	0.0	1.0	3.4	0.8
11/29/2021 13:00	4.1	0.0	1.0	3.4	0.8
11/29/2021 14:00	47.4	67.7	1.2	4.8	1.1
11/29/2021 15:00	45.0	38.7	1.3	6.2	1.4
11/29/2021 16:00	8.4	0.0	1.7	9.3	2.0
11/29/2021 17:00	11.6	1.9	2.0	10.6	2.3
11/29/2021 18:00	12.4	2.2	2.1	11.4	2.5
11/29/2021 19:00	12.1	2.6	2.0	11.1	2.4
11/29/2021 20:00	8.3	0.3	1.7	9.1	2.0
11/29/2021 21:00	8.9	0.3	1.8	9.8	2.2
11/29/2021 22:00	11.8	2.3	2.0	10.8	2.4
11/29/2021 23:00	10.3	23.5	0.6	3.1	0.6
Average/Sum#:	322.7 #	481.0 #	20.1 #	98.7 #	21.8 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	67.7	127.2	2.1	11.4	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
11/30/2021 00:00	0.0	0.0	0.0	0.0	0.0
11/30/2021 01:00	0.0	0.0	0.0	0.0	0.0
11/30/2021 02:00	0.0	0.0	0.0	0.0	0.0
11/30/2021 03:00	0.0	0.0	0.0	0.0	0.0
11/30/2021 04:00	0.0	0.0	0.0	0.0	0.0
11/30/2021 05:00	4.3	7.9	0.1	0.2	0.0
11/30/2021 06:00	28.5	59.8	0.5	1.8	0.4
11/30/2021 07:00	4.0	0.8	0.9	3.3	0.8
11/30/2021 08:00	22.4	11.1	0.9	3.6	0.9
11/30/2021 09:00	39.9	47.7	1.2	5.9	1.3
11/30/2021 10:00	7.2	0.9	1.4	8.4	1.8
11/30/2021 11:00	7.3	0.7	1.4	8.4	1.8
11/30/2021 12:00	7.7	0.3	1.5	8.7	1.8
11/30/2021 13:00	9.6	0.0	1.5	8.9	1.9
11/30/2021 14:00	10.0	0.0	1.6	9.2	2.0
11/30/2021 15:00	10.4	0.0	1.7	9.6	2.0
11/30/2021 16:00	10.4	0.0	1.7	9.6	2.0
11/30/2021 17:00	10.4	0.0	1.7	9.6	2.0
11/30/2021 18:00	10.4	0.0	1.7	9.6	2.0
11/30/2021 19:00	8.6	0.0	1.7	9.5	2.0
11/30/2021 20:00	8.6	0.0	1.7	9.4	2.0
11/30/2021 21:00	6.5	0.0	1.6	8.1	1.8
11/30/2021 22:00	10.4	0.0	1.7	9.6	2.0
11/30/2021 23:00	11.6	2.3	2.0	10.6	2.3
Average/Sum#:	228.2 #	131.5 #	26.5 #	144.0 #	30.8 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	39.9	59.8	2.0	10.6	2.3
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/01/2021 00:00	11.6	2.3	2.0	10.6	2.3
12/01/2021 01:00	7.5	0.3	1.5	8.3	1.8
12/01/2021 02:00	5.2	0.7	1.3	7.2	1.6
12/01/2021 03:00	8.6	0.3	1.7	9.4	2.0
12/01/2021 04:00	11.0	2.0	1.8	10.0	2.2
12/01/2021 05:00	11.0	1.3	1.8	10.0	2.2
12/01/2021 06:00	8.4	1.2	1.7	9.3	2.0
12/01/2021 07:00	15.3	2.6	2.2	12.1	2.6
12/01/2021 08:00	15.5	1.6	2.2	12.1	2.7
12/01/2021 09:00	15.3	2.0	2.2	12.1	2.6
12/01/2021 10:00	15.4	1.6	2.2	12.1	2.6
12/01/2021 11:00	15.5	2.6	2.3	12.1	2.7
12/01/2021 12:00	15.5	3.6	2.3	12.2	2.7
12/01/2021 13:00	15.4	3.2	2.2	12.2	2.7
12/01/2021 14:00	15.4	3.2	2.2	12.2	2.7
12/01/2021 15:00	15.4	3.1	2.2	12.2	2.7
12/01/2021 16:00	15.4	3.1	2.2	12.2	2.7
12/01/2021 17:00	15.5	3.6	2.3	12.2	2.7
12/01/2021 18:00	15.5	3.6	2.3	12.2	2.7
12/01/2021 19:00	15.4	3.6	2.2	12.1	2.7
12/01/2021 20:00	14.8	4.9	2.1	11.6	2.5
12/01/2021 21:00	12.5	4.6	2.1	11.4	2.5
12/01/2021 22:00	12.2	4.6	2.0	11.2	2.4
12/01/2021 23:00	11.5	6.9	2.0	10.6	2.3
Average/Sum#:	314.8 #	66.5 #	49.0 #	267.6 #	58.6 #
Minimum:	5.2	0.3	1.3	7.2	1.6
Maximum:	15.5	6.9	2.3	12.2	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/02/2021 00:00	10.2	23.8	0.6	3.3	0.8
12/02/2021 01:00	0.0	0.0	0.0	0.0	0.0
12/02/2021 02:00	0.0	0.0	0.0	0.0	0.0
12/02/2021 03:00	0.0	0.0	0.0	0.0	0.0
12/02/2021 04:00	19.7	56.1	0.2	1.8	0.4
12/02/2021 05:00	1.3	0.8	0.4	4.0	0.8
12/02/2021 06:00	14.3	45.1	0.6	4.6	1.0
12/02/2021 07:00	20.1	62.4	1.2	6.9	1.5
12/02/2021 08:00	6.6	2.2	1.3	7.1	1.5
12/02/2021 09:00	9.5	2.1	1.4	7.1	1.5
12/02/2021 10:00	10.5	2.5	1.5	7.9	1.7
12/02/2021 11:00	10.9	2.1	1.5	8.3	1.8
12/02/2021 12:00	11.7	2.5	1.7	8.9	1.9
12/02/2021 13:00	12.4	2.6	1.8	9.6	2.1
12/02/2021 14:00	5.1	1.9	1.8	9.6	2.1
12/02/2021 15:00	10.5	2.6	1.8	9.6	2.1
12/02/2021 16:00	10.5	2.6	1.8	9.6	2.1
12/02/2021 17:00	10.5	2.6	1.8	9.6	2.1
12/02/2021 18:00	10.5	2.6	1.8	9.6	2.1
12/02/2021 19:00	10.5	2.6	1.8	9.6	2.1
12/02/2021 20:00	12.4	2.9	1.7	9.7	2.2
12/02/2021 21:00	11.5	7.5	1.9	10.5	2.3
12/02/2021 22:00	14.0	5.8	2.0	11.0	2.4
12/02/2021 23:00	13.1	4.8	1.9	10.3	2.2
Average/Sum#:	230.7 #	236.2 #	30.5 #	168.6 #	36.7 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	20.1	62.4	2.0	11.0	2.4
%SI	4.17	4.17	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/03/2021 00:00	9.3	11.9	1.2	6.4	1.4
12/03/2021 01:00	4.0	1.5	0.9	3.4	0.8
12/03/2021 02:00	4.1	1.8	1.0	3.4	0.8
12/03/2021 03:00	5.1	4.5	1.1	4.3	1.0
12/03/2021 04:00	27.1	66.8	1.3	6.2	1.4
12/03/2021 05:00	8.5	2.7	1.4	7.8	1.7
12/03/2021 06:00	8.1	3.0	1.6	8.9	2.0
12/03/2021 07:00	11.2	4.4	1.9	10.2	2.2
12/03/2021 08:00	15.3	5.9	2.2	11.9	2.6
12/03/2021 09:00	15.3	4.9	2.2	12.1	2.6
12/03/2021 10:00	15.3	4.6	2.2	12.1	2.6
12/03/2021 11:00	15.5	4.5	2.3	12.1	2.7
12/03/2021 12:00	15.5	4.5	2.2	12.1	2.7
12/03/2021 13:00	17.7	4.5	2.2	12.1	2.7
12/03/2021 14:00	17.6	4.5	2.2	12.1	2.7
12/03/2021 15:00	15.4	4.5	2.2	12.1	2.7
12/03/2021 16:00	13.2	4.7	1.9	10.4	2.3
12/03/2021 17:00	12.5	2.6	1.8	9.7	2.1
12/03/2021 18:00	12.4	2.5	1.8	9.6	2.1
12/03/2021 19:00	12.4	2.9	1.8	9.7	2.1
12/03/2021 20:00	13.8	8.1	2.0	10.8	2.4
12/03/2021 21:00	14.6	5.8	2.1	11.5	2.5
12/03/2021 22:00	16.7	5.9	2.1	11.4	2.5
12/03/2021 23:00	17.3	34.5	1.6	8.6	1.9
Average/Sum#:	317.9 #	201.5 #	43.2 #	228.9 #	50.5 #
Minimum:	4.0	1.5	0.9	3.4	0.8
Maximum:	27.1	66.8	2.3	12.1	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/04/2021 00:00	0.0	0.0	0.0	0.0	0.0
12/04/2021 01:00	0.0	0.0	0.0	0.0	0.0
12/04/2021 02:00	0.0	0.0	0.0	0.0	0.0
12/04/2021 03:00	0.1	2.1	0.0	0.1	0.0
12/04/2021 04:00	14.5	67.9	0.6	2.1	0.5
12/04/2021 05:00	5.2	4.2	1.1	4.1	1.0
12/04/2021 06:00	8.2	16.6	1.3	4.9	1.2
12/04/2021 07:00	25.9	65.8	1.7	8.6	1.9
12/04/2021 08:00	10.8	2.6	1.8	9.8	2.1
12/04/2021 09:00	12.5	3.0	1.8	9.7	2.1
12/04/2021 10:00	10.7	2.7	1.8	9.8	2.2
12/04/2021 11:00	12.5	2.7	1.8	9.8	2.2
12/04/2021 12:00	13.2	17.7	1.6	8.1	1.8
12/04/2021 13:00	4.4	1.6	1.0	3.7	0.9
12/04/2021 14:00	4.1	1.8	1.0	3.4	0.8
12/04/2021 15:00	5.0	3.7	1.2	4.2	1.0
12/04/2021 16:00	21.8	69.1	1.3	6.2	1.4
12/04/2021 17:00	8.6	2.8	1.7	9.4	2.0
12/04/2021 18:00	11.5	10.2	2.0	10.5	2.3
12/04/2021 19:00	11.1	7.3	1.8	10.1	2.2
12/04/2021 20:00	9.7	2.7	1.6	8.9	2.0
12/04/2021 21:00	8.1	2.7	1.6	8.8	1.9
12/04/2021 22:00	7.9	3.0	1.6	8.7	1.9
12/04/2021 23:00	2.5	14.6	0.1	0.6	0.1
Average/Sum#:	208.3 #	304.8 #	28.4 #	141.5 #	31.5 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	25.9	69.1	2.0	10.5	2.3
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/05/2021 00:00	0.0	0.0	0.0	0.0	0.0
12/05/2021 01:00	0.0	0.0	0.0	0.0	0.0
12/05/2021 02:00	0.0	0.0	0.0	0.0	0.0
12/05/2021 03:00	0.0	0.0	0.0	0.0	0.0
12/05/2021 04:00	0.0	0.0	0.0	0.0	0.0
12/05/2021 05:00	0.0	0.0	0.0	0.0	0.0
12/05/2021 06:00	0.0	0.0	0.0	0.0	0.0
12/05/2021 07:00	24.9	33.3	0.2	0.6	0.2
12/05/2021 08:00	32.9	175.2	0.6	2.2	0.5
12/05/2021 09:00	4.7	2.3	1.1	3.9	0.9
12/05/2021 10:00	4.6	2.3	1.1	3.9	0.9
12/05/2021 11:00	4.1	2.1	1.0	3.5	0.8
12/05/2021 12:00	4.1	2.0	1.0	3.4	0.8
12/05/2021 13:00	26.6	28.3	1.2	4.8	1.1
12/05/2021 14:00	52.7	60.6	1.4	6.6	1.5
12/05/2021 15:00	10.0	2.5	1.7	9.2	2.0
12/05/2021 16:00	9.5	2.7	1.6	8.7	1.9
12/05/2021 17:00	15.8	7.5	2.0	10.8	2.4
12/05/2021 18:00	14.7	6.2	2.1	11.5	2.5
12/05/2021 19:00	14.9	5.9	2.1	11.7	2.6
12/05/2021 20:00	15.4	5.2	2.3	12.1	2.6
12/05/2021 21:00	15.1	5.2	2.1	11.8	2.6
12/05/2021 22:00	15.0	5.5	2.1	11.8	2.6
12/05/2021 23:00	14.5	5.6	2.1	11.4	2.5
Average/Sum#:	279.5 #	352.4 #	25.7 #	127.9 #	28.4 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	52.7	175.2	2.3	12.1	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/06/2021 00:00	15.8	6.9	2.0	10.8	2.4
12/06/2021 01:00	8.4	2.5	1.7	9.3	2.0
12/06/2021 02:00	12.3	3.2	1.7	9.6	2.1
12/06/2021 03:00	11.7	7.7	2.0	10.8	2.4
12/06/2021 04:00	15.6	6.9	2.0	10.6	2.3
12/06/2021 05:00	9.8	2.7	1.7	8.9	2.0
12/06/2021 06:00	11.2	6.5	1.9	10.2	2.2
12/06/2021 07:00	15.1	6.0	2.1	11.9	2.6
12/06/2021 08:00	15.1	5.5	2.1	11.9	2.6
12/06/2021 09:00	12.1	4.0	1.7	9.4	2.0
12/06/2021 10:00	10.7	2.7	1.8	9.8	2.2
12/06/2021 11:00	16.0	7.3	2.0	10.9	2.4
12/06/2021 12:00	15.1	5.6	2.1	11.9	2.6
12/06/2021 13:00	13.3	5.1	2.0	10.4	2.3
12/06/2021 14:00	8.2	2.4	1.7	8.9	2.0
12/06/2021 15:00	11.0	7.1	1.8	10.0	2.2
12/06/2021 16:00	14.4	6.3	2.1	11.3	2.5
12/06/2021 17:00	14.7	6.0	2.1	11.5	2.5
12/06/2021 18:00	15.3	5.5	2.2	12.1	2.6
12/06/2021 19:00	15.0	5.5	2.1	11.8	2.6
12/06/2021 20:00	15.1	5.2	2.1	11.9	2.6
12/06/2021 21:00	14.7	5.9	2.1	11.5	2.5
12/06/2021 22:00	14.7	5.9	2.1	11.5	2.5
12/06/2021 23:00	14.7	5.9	2.1	11.5	2.5
Average/Sum#:	320.0 #	128.3 #	47.2 #	258.4 #	56.6 #
Minimum:	8.2	2.4	1.7	8.9	2.0
Maximum:	16.0	7.7	2.2	12.1	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/07/2021 00:00	14.4	5.9	2.1	11.3	2.5
12/07/2021 01:00	7.6	2.8	1.6	8.3	1.8
12/07/2021 02:00	10.1	3.4	1.7	9.2	2.0
12/07/2021 03:00	11.7	7.0	2.0	10.7	2.4
12/07/2021 04:00	14.6	6.0	2.1	11.5	2.5
12/07/2021 05:00	10.3	3.2	1.7	9.4	2.0
12/07/2021 06:00	9.9	2.7	1.7	9.0	2.0
12/07/2021 07:00	13.7	7.9	2.0	10.8	2.4
12/07/2021 08:00	15.2	5.5	2.2	11.9	2.6
12/07/2021 09:00	16.6	5.5	2.1	11.4	2.5
12/07/2021 10:00	12.6	2.6	1.8	9.9	2.2
12/07/2021 11:00	12.5	2.7	1.8	9.8	2.2
12/07/2021 12:00	12.4	2.6	1.8	9.7	2.1
12/07/2021 13:00	12.4	3.2	1.8	9.7	2.1
12/07/2021 14:00	14.2	5.5	2.1	11.2	2.4
12/07/2021 15:00	15.1	4.5	2.1	11.9	2.6
12/07/2021 16:00	15.4	4.2	2.2	12.1	2.6
12/07/2021 17:00	15.3	4.5	2.2	12.0	2.6
12/07/2021 18:00	15.3	4.9	2.2	12.1	2.6
12/07/2021 19:00	15.3	5.2	2.2	12.0	2.6
12/07/2021 20:00	15.3	4.9	2.2	12.0	2.6
12/07/2021 21:00	15.2	4.8	2.1	11.9	2.6
12/07/2021 22:00	14.7	5.2	2.1	11.5	2.5
12/07/2021 23:00	16.8	5.5	2.1	11.5	2.5
Average/Sum#:	326.6 #	110.2 #	47.9 #	260.8 #	56.9 #
Minimum:	7.6	2.6	1.6	8.3	1.8
Maximum:	16.8	7.9	2.2	12.1	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/08/2021 00:00	14.2	5.9	2.0	11.1	2.4
12/08/2021 01:00	8.0	2.4	1.6	8.7	1.9
12/08/2021 02:00	6.6	2.9	1.3	7.2	1.6
12/08/2021 03:00	10.3	2.9	1.7	9.5	2.0
12/08/2021 04:00	10.9	5.7	1.8	10.0	2.2
12/08/2021 05:00	13.1	5.2	1.9	10.2	2.2
12/08/2021 06:00	10.5	2.6	1.7	9.6	2.1
12/08/2021 07:00	15.8	8.9	2.0	10.8	2.4
12/08/2021 08:00	11.1	6.0	1.8	10.2	2.2
12/08/2021 09:00	6.8	3.1	1.4	7.4	1.6
12/08/2021 10:00	6.6	2.9	1.3	7.3	1.6
12/08/2021 11:00	10.3	2.9	1.7	9.4	2.0
12/08/2021 12:00	11.0	7.1	1.8	10.1	2.2
12/08/2021 13:00	10.9	7.0	1.8	10.0	2.2
12/08/2021 14:00	6.6	2.7	1.3	7.2	1.6
12/08/2021 15:00	6.9	2.9	1.4	7.6	1.6
12/08/2021 16:00	10.2	3.2	1.7	9.3	2.0
12/08/2021 17:00	15.6	10.2	2.0	10.8	2.4
12/08/2021 18:00	14.9	6.1	2.1	11.7	2.6
12/08/2021 19:00	14.7	6.1	2.1	11.6	2.5
12/08/2021 20:00	14.7	5.8	2.1	11.5	2.5
12/08/2021 21:00	14.2	5.8	2.0	11.2	2.4
12/08/2021 22:00	14.2	5.5	2.0	11.1	2.4
12/08/2021 23:00	14.2	5.8	2.1	11.2	2.4
Average/Sum#:	272.3 #	119.6 #	42.6 #	234.7 #	51.0 #
Minimum:	6.6	2.4	1.3	7.2	1.6
Maximum:	15.8	10.2	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/09/2021 00:00	13.4	8.5	2.0	10.6	2.3
12/09/2021 01:00	7.4	3.1	1.5	8.2	1.8
12/09/2021 02:00	9.4	3.5	1.6	8.6	1.9
12/09/2021 03:00	15.6	8.9	2.0	10.7	2.4
12/09/2021 04:00	13.8	6.8	2.0	10.8	2.4
12/09/2021 05:00	7.7	3.1	1.6	8.5	1.8
12/09/2021 06:00	9.7	3.3	1.6	8.9	2.0
12/09/2021 07:00	15.8	8.3	2.0	10.8	2.4
12/09/2021 08:00	14.2	5.0	2.0	11.1	2.4
12/09/2021 09:00	14.1	4.9	2.0	11.1	2.4
12/09/2021 10:00	9.5	2.7	1.6	8.7	1.9
12/09/2021 11:00	10.2	2.5	1.7	9.4	2.0
12/09/2021 12:00	14.0	5.5	2.0	11.0	2.4
12/09/2021 13:00	13.7	5.1	2.0	10.8	2.4
12/09/2021 14:00	8.7	1.9	1.4	7.9	1.8
12/09/2021 15:00	7.5	2.2	1.5	8.2	1.8
12/09/2021 16:00	15.8	6.2	2.0	10.8	2.4
12/09/2021 17:00	16.9	5.6	2.1	11.6	2.5
12/09/2021 18:00	14.6	5.2	2.1	11.5	2.5
12/09/2021 19:00	14.8	5.2	2.1	11.6	2.5
12/09/2021 20:00	14.8	5.3	2.1	11.7	2.6
12/09/2021 21:00	14.8	5.3	2.1	11.7	2.6
12/09/2021 22:00	16.0	6.3	2.0	11.0	2.4
12/09/2021 23:00	14.2	4.9	2.1	11.2	2.4
Average/Sum#:	306.6 #	119.3 #	45.1 #	246.4 #	54.0 #
Minimum:	7.4	1.9	1.4	7.9	1.8
Maximum:	16.9	8.9	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/10/2021 00:00	13.5	7.3	2.0	10.6	2.3
12/10/2021 01:00	7.6	2.6	1.6	8.4	1.8
12/10/2021 02:00	8.0	2.7	1.6	8.7	1.9
12/10/2021 03:00	11.5	6.4	2.0	10.5	2.3
12/10/2021 04:00	11.6	6.7	2.0	10.6	2.3
12/10/2021 05:00	8.1	2.7	1.6	8.9	2.0
12/10/2021 06:00	10.4	3.0	1.7	9.5	2.1
12/10/2021 07:00	11.8	7.7	2.0	10.8	2.4
12/10/2021 08:00	11.6	7.0	2.0	10.6	2.3
12/10/2021 09:00	8.1	2.4	1.6	8.7	1.9
12/10/2021 10:00	8.4	2.5	1.7	9.3	2.0
12/10/2021 11:00	8.1	2.4	1.6	8.9	2.0
12/10/2021 12:00	8.4	2.5	1.7	9.2	2.0
12/10/2021 13:00	7.9	2.4	1.6	8.7	1.9
12/10/2021 14:00	6.6	2.4	1.3	7.2	1.6
12/10/2021 15:00	7.9	2.7	1.6	8.7	1.9
12/10/2021 16:00	13.6	9.0	2.0	10.7	2.4
12/10/2021 17:00	15.3	5.3	2.2	12.1	2.6
12/10/2021 18:00	15.1	5.3	2.1	11.9	2.6
12/10/2021 19:00	15.1	5.3	2.1	11.9	2.6
12/10/2021 20:00	15.3	5.3	2.2	12.0	2.6
12/10/2021 21:00	14.9	5.4	2.1	11.7	2.6
12/10/2021 22:00	14.6	5.7	2.1	11.5	2.5
12/10/2021 23:00	14.6	5.7	2.1	11.5	2.5
Average/Sum#:	268.0 #	110.4 #	44.5 #	242.6 #	53.1 #
Minimum:	6.6	2.4	1.3	7.2	1.6
Maximum:	15.3	9.0	2.2	12.1	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/11/2021 00:00	14.6	6.1	2.1	11.5	2.5
12/11/2021 01:00	16.2	6.1	2.0	11.1	2.4
12/11/2021 02:00	11.6	8.6	2.0	10.6	2.3
12/11/2021 03:00	8.1	2.7	1.6	8.9	2.0
12/11/2021 04:00	10.1	3.1	1.7	9.3	2.0
12/11/2021 05:00	14.0	6.8	2.0	11.0	2.4
12/11/2021 06:00	14.5	5.7	2.1	11.4	2.5
12/11/2021 07:00	16.0	5.7	2.0	11.0	2.4
12/11/2021 08:00	8.0	3.0	1.6	8.7	1.9
12/11/2021 09:00	6.9	3.6	1.4	7.6	1.6
12/11/2021 10:00	7.1	3.8	1.4	7.8	1.7
12/11/2021 11:00	6.6	3.8	1.3	7.2	1.6
12/11/2021 12:00	6.6	3.8	1.3	7.2	1.6
12/11/2021 13:00	7.6	3.4	1.5	8.2	1.8
12/11/2021 14:00	7.7	3.1	1.6	8.5	1.8
12/11/2021 15:00	8.1	3.3	1.7	8.9	2.0
12/11/2021 16:00	12.6	7.4	2.1	11.5	2.5
12/11/2021 17:00	15.3	5.3	2.2	12.0	2.6
12/11/2021 18:00	15.2	5.0	2.2	11.9	2.6
12/11/2021 19:00	15.5	5.0	2.3	12.2	2.7
12/11/2021 20:00	15.2	5.0	2.2	12.0	2.6
12/11/2021 21:00	15.5	4.9	2.2	12.2	2.7
12/11/2021 22:00	15.1	4.9	2.1	11.9	2.6
12/11/2021 23:00	14.5	5.4	2.1	11.4	2.5
Average/Sum#:	282.6 #	115.5 #	44.7 #	244.0 #	53.3 #
Minimum:	6.6	2.7	1.3	7.2	1.6
Maximum:	16.2	8.6	2.3	12.2	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/12/2021 00:00	14.4	5.3	2.1	11.3	2.5
12/12/2021 01:00	14.2	5.3	2.0	11.1	2.4
12/12/2021 02:00	11.5	7.0	2.0	10.5	2.3
12/12/2021 03:00	9.5	3.0	1.6	8.7	1.9
12/12/2021 04:00	10.3	3.2	1.7	9.5	2.0
12/12/2021 05:00	16.0	5.9	2.0	10.9	2.4
12/12/2021 06:00	14.1	6.0	2.0	11.1	2.4
12/12/2021 07:00	9.7	3.3	1.6	8.9	2.0
12/12/2021 08:00	9.5	3.0	1.6	8.7	1.9
12/12/2021 09:00	6.9	3.4	1.4	7.6	1.6
12/12/2021 10:00	9.5	3.3	1.6	8.7	1.9
12/12/2021 11:00	11.8	3.1	1.7	9.3	2.0
12/12/2021 12:00	8.1	3.0	1.6	8.9	2.0
12/12/2021 13:00	9.7	3.0	1.7	8.9	2.0
12/12/2021 14:00	9.5	3.3	1.6	8.7	1.9
12/12/2021 15:00	9.5	4.4	1.6	8.7	1.9
12/12/2021 16:00	14.3	6.5	2.1	11.2	2.4
12/12/2021 17:00	14.9	5.2	2.1	11.7	2.6
12/12/2021 18:00	14.8	5.2	2.1	11.7	2.6
12/12/2021 19:00	15.1	4.5	2.2	11.9	2.6
12/12/2021 20:00	14.7	4.8	2.1	11.6	2.5
12/12/2021 21:00	14.8	4.9	2.1	11.6	2.5
12/12/2021 22:00	14.6	4.9	2.1	11.5	2.5
12/12/2021 23:00	14.2	5.2	2.0	11.2	2.4
Average/Sum#:	291.6 #	106.7 #	44.6 #	243.9 #	53.2 #
Minimum:	6.9	3.0	1.4	7.6	1.6
Maximum:	16.0	7.0	2.2	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/13/2021 00:00	13.4	6.8	2.0	10.5	2.3
12/13/2021 01:00	11.8	2.8	1.7	9.3	2.0
12/13/2021 02:00	10.0	3.4	1.7	9.1	2.0
12/13/2021 03:00	14.0	6.8	2.0	10.9	2.4
12/13/2021 04:00	15.5	7.4	2.0	10.6	2.3
12/13/2021 05:00	11.1	3.3	1.6	8.7	1.9
12/13/2021 06:00	10.7	3.9	1.8	9.8	2.2
12/13/2021 07:00	16.5	7.1	2.1	11.3	2.5
12/13/2021 08:00	15.1	5.1	2.1	11.9	2.6
12/13/2021 09:00	14.9	5.1	2.1	11.7	2.6
12/13/2021 10:00	14.7	5.1	2.1	11.5	2.5
12/13/2021 11:00	13.9	5.7	2.0	10.9	2.4
12/13/2021 12:00	9.8	2.4	1.7	9.0	2.0
12/13/2021 13:00	10.7	3.3	1.8	9.8	2.2
12/13/2021 14:00	14.1	5.9	2.0	11.1	2.4
12/13/2021 15:00	15.3	4.8	2.2	12.0	2.6
12/13/2021 16:00	15.6	4.2	2.3	12.2	2.7
12/13/2021 17:00	15.6	3.9	2.3	12.3	2.7
12/13/2021 18:00	15.6	3.9	2.3	12.3	2.7
12/13/2021 19:00	15.7	4.2	2.3	12.4	2.7
12/13/2021 20:00	14.9	4.8	2.1	11.7	2.6
12/13/2021 21:00	14.5	5.2	2.1	11.4	2.5
12/13/2021 22:00	14.1	5.9	2.0	11.1	2.4
12/13/2021 23:00	14.2	5.6	2.0	11.1	2.4
Average/Sum#:	331.7 #	116.6 #	48.3 #	262.6 #	57.6 #
Minimum:	9.8	2.4	1.6	8.7	1.9
Maximum:	16.5	7.4	2.3	12.4	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/14/2021 00:00	12.7	6.3	1.8	10.0	2.2
12/14/2021 01:00	6.5	2.9	1.3	7.1	1.6
12/14/2021 02:00	6.6	3.2	1.3	7.2	1.6
12/14/2021 03:00	10.4	2.9	1.7	9.5	2.1
12/14/2021 04:00	11.1	7.2	1.8	10.2	2.2
12/14/2021 05:00	11.1	5.8	1.8	10.2	2.2
12/14/2021 06:00	10.3	3.2	1.7	9.4	2.0
12/14/2021 07:00	14.4	5.7	2.1	11.3	2.5
12/14/2021 08:00	14.5	5.3	2.1	11.5	2.5
12/14/2021 09:00	15.6	5.2	2.0	10.7	2.4
12/14/2021 10:00	9.7	2.7	1.6	8.9	2.0
12/14/2021 11:00	8.1	3.3	1.6	8.9	2.0
12/14/2021 12:00	14.1	6.0	2.0	11.1	2.4
12/14/2021 13:00	11.5	6.2	2.0	10.5	2.3
12/14/2021 14:00	9.8	2.4	1.7	9.0	2.0
12/14/2021 15:00	7.6	2.9	1.6	8.3	1.8
12/14/2021 16:00	15.8	6.0	2.0	10.8	2.4
12/14/2021 17:00	15.7	4.6	2.3	12.4	2.7
12/14/2021 18:00	15.3	4.9	2.2	12.1	2.6
12/14/2021 19:00	15.7	4.6	2.3	12.3	2.7
12/14/2021 20:00	15.7	4.6	2.3	12.4	2.7
12/14/2021 21:00	15.3	5.0	2.2	12.1	2.6
12/14/2021 22:00	14.7	5.0	2.1	11.6	2.5
12/14/2021 23:00	14.1	5.3	2.0	11.1	2.4
Average/Sum#:	296.3 #	111.2 #	45.5 #	248.6 #	54.4 #
Minimum:	6.5	2.4	1.3	7.1	1.6
Maximum:	15.8	7.2	2.3	12.4	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/15/2021 00:00	13.6	7.3	2.0	10.7	2.4
12/15/2021 01:00	7.8	2.9	1.6	8.5	1.8
12/15/2021 02:00	9.9	3.7	1.7	9.1	2.0
12/15/2021 03:00	11.7	7.3	2.0	10.7	2.4
12/15/2021 04:00	11.5	7.6	2.0	10.6	2.3
12/15/2021 05:00	7.9	3.6	1.6	8.7	1.9
12/15/2021 06:00	11.3	5.6	1.9	10.3	2.2
12/15/2021 07:00	15.0	5.7	2.1	11.8	2.6
12/15/2021 08:00	15.8	6.9	2.0	10.9	2.4
12/15/2021 09:00	7.9	3.0	1.6	8.7	1.9
12/15/2021 10:00	8.1	3.0	1.6	8.9	2.0
12/15/2021 11:00	8.1	3.3	1.6	8.8	2.0
12/15/2021 12:00	14.0	6.6	2.0	11.0	2.4
12/15/2021 13:00	13.9	6.1	2.0	10.9	2.4
12/15/2021 14:00	7.8	2.6	1.6	8.5	1.8
12/15/2021 15:00	10.3	3.2	1.7	9.4	2.0
12/15/2021 16:00	16.9	5.7	2.1	11.6	2.5
12/15/2021 17:00	15.7	4.5	2.3	12.3	2.7
12/15/2021 18:00	13.3	4.6	2.3	12.3	2.7
12/15/2021 19:00	15.6	4.5	2.3	12.3	2.7
12/15/2021 20:00	15.7	4.6	2.3	12.3	2.7
12/15/2021 21:00	15.3	4.6	2.2	12.0	2.6
12/15/2021 22:00	16.9	5.6	2.1	11.6	2.5
12/15/2021 23:00	14.5	5.6	2.1	11.4	2.5
Average/Sum#:	298.5 #	118.1 #	46.7 #	253.3 #	55.4 #
Minimum:	7.8	2.6	1.6	8.5	1.8
Maximum:	16.9	7.6	2.3	12.3	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/16/2021 00:00	14.2	5.3	2.0	11.2	2.4
12/16/2021 01:00	15.6	5.9	2.0	10.7	2.4
12/16/2021 02:00	9.5	3.0	1.6	8.7	1.9
12/16/2021 03:00	9.5	3.0	1.6	8.7	1.9
12/16/2021 04:00	9.7	3.0	1.6	8.9	2.0
12/16/2021 05:00	16.2	6.2	2.0	11.1	2.4
12/16/2021 06:00	15.5	5.3	2.3	12.2	2.7
12/16/2021 07:00	15.5	4.9	2.2	12.1	2.7
12/16/2021 08:00	14.2	5.2	2.0	11.2	2.4
12/16/2021 09:00	15.7	6.9	2.0	10.8	2.4
12/16/2021 10:00	8.9	3.3	1.4	8.1	1.8
12/16/2021 11:00	9.7	3.3	1.6	8.9	2.0
12/16/2021 12:00	14.1	8.3	2.0	11.1	2.4
12/16/2021 13:00	11.5	7.3	2.0	10.6	2.3
12/16/2021 14:00	9.3	2.9	1.6	8.5	1.8
12/16/2021 15:00	9.5	3.6	1.6	8.7	1.9
12/16/2021 16:00	14.7	9.6	2.1	11.5	2.5
12/16/2021 17:00	15.6	5.6	2.3	12.3	2.7
12/16/2021 18:00	15.6	5.6	2.3	12.3	2.7
12/16/2021 19:00	15.6	5.3	2.3	12.3	2.7
12/16/2021 20:00	15.7	5.3	2.3	12.3	2.7
12/16/2021 21:00	15.5	5.3	2.3	12.2	2.7
12/16/2021 22:00	14.7	6.0	2.1	11.5	2.5
12/16/2021 23:00	14.4	6.4	2.1	11.3	2.5
Average/Sum#:	320.4 #	126.5 #	47.3 #	257.2 #	56.4 #
Minimum:	8.9	2.9	1.4	8.1	1.8
Maximum:	16.2	9.6	2.3	12.3	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/17/2021 00:00	11.5	8.0	2.0	10.6	2.3
12/17/2021 01:00	7.8	2.9	1.6	8.5	1.8
12/17/2021 02:00	7.8	2.9	1.6	8.5	1.8
12/17/2021 03:00	10.2	3.1	1.7	9.3	2.0
12/17/2021 04:00	16.0	8.3	2.0	11.0	2.4
12/17/2021 05:00	16.0	7.7	2.0	11.0	2.4
12/17/2021 06:00	15.3	6.0	2.2	12.1	2.6
12/17/2021 07:00	15.2	5.7	2.2	12.0	2.6
12/17/2021 08:00	14.1	6.7	2.0	11.1	2.4
12/17/2021 09:00	11.5	7.3	2.0	10.6	2.3
12/17/2021 10:00	9.5	3.0	1.6	8.7	1.9
12/17/2021 11:00	9.3	2.8	1.6	8.5	1.8
12/17/2021 12:00	6.9	2.8	1.4	7.6	1.6
12/17/2021 13:00	9.9	2.7	1.7	9.0	2.0
12/17/2021 14:00	7.4	2.8	1.5	8.2	1.8
12/17/2021 15:00	9.5	3.3	1.6	8.7	1.9
12/17/2021 16:00	14.2	9.3	2.0	11.2	2.4
12/17/2021 17:00	15.6	5.2	2.3	12.3	2.7
12/17/2021 18:00	15.7	4.9	2.3	12.3	2.7
12/17/2021 19:00	15.6	5.0	2.3	12.3	2.7
12/17/2021 20:00	15.7	4.9	2.3	12.4	2.7
12/17/2021 21:00	15.6	5.0	2.3	12.2	2.7
12/17/2021 22:00	14.7	6.0	2.1	11.5	2.5
12/17/2021 23:00	16.2	6.7	2.0	11.1	2.4
Average/Sum#:	301.2 #	123.0 #	46.3 #	250.7 #	54.4 #
Minimum:	6.9	2.7	1.4	7.6	1.6
Maximum:	16.2	9.3	2.3	12.4	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/18/2021 00:00	11.6	7.6	2.0	10.6	2.3
12/18/2021 01:00	9.7	3.3	1.6	8.9	2.0
12/18/2021 02:00	10.3	3.2	1.7	9.5	2.0
12/18/2021 03:00	14.1	6.8	2.0	11.0	2.4
12/18/2021 04:00	13.9	6.8	2.0	11.0	2.4
12/18/2021 05:00	11.8	3.1	1.7	9.2	2.0
12/18/2021 06:00	12.4	3.3	1.8	9.7	2.1
12/18/2021 07:00	16.2	8.2	2.0	11.1	2.4
12/18/2021 08:00	16.2	7.8	2.0	11.1	2.4
12/18/2021 09:00	13.9	7.3	2.0	10.9	2.4
12/18/2021 10:00	7.8	3.2	1.6	8.5	1.8
12/18/2021 11:00	9.5	3.3	1.6	8.7	1.9
12/18/2021 12:00	7.8	3.2	1.6	8.5	1.8
12/18/2021 13:00	7.6	3.1	1.6	8.4	1.8
12/18/2021 14:00	9.3	3.2	1.6	8.5	1.8
12/18/2021 15:00	7.5	3.3	1.5	8.2	1.8
12/18/2021 16:00	11.2	6.8	1.9	10.2	2.2
12/18/2021 17:00	15.2	6.3	2.2	11.9	2.6
12/18/2021 18:00	14.8	6.3	2.1	11.7	2.6
12/18/2021 19:00	15.3	6.0	2.2	12.1	2.6
12/18/2021 20:00	15.5	5.7	2.3	12.2	2.7
12/18/2021 21:00	17.1	5.7	2.1	11.7	2.6
12/18/2021 22:00	14.6	6.0	2.1	11.5	2.5
12/18/2021 23:00	14.1	6.7	2.0	11.1	2.4
Average/Sum#:	297.4 #	126.2 #	45.2 #	246.2 #	53.5 #
Minimum:	7.5	3.1	1.5	8.2	1.8
Maximum:	17.1	8.2	2.3	12.2	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/19/2021 00:00	14.4	6.0	2.1	11.3	2.5
12/19/2021 01:00	13.9	7.3	2.0	10.9	2.4
12/19/2021 02:00	11.3	3.0	1.6	8.9	2.0
12/19/2021 03:00	10.1	3.1	1.7	9.3	2.0
12/19/2021 04:00	13.8	6.4	2.0	10.9	2.4
12/19/2021 05:00	16.0	6.1	2.0	11.0	2.4
12/19/2021 06:00	13.8	6.3	2.0	10.8	2.4
12/19/2021 07:00	14.0	6.8	2.0	11.0	2.4
12/19/2021 08:00	14.0	6.8	2.0	11.1	2.4
12/19/2021 09:00	11.7	7.1	2.0	10.7	2.4
12/19/2021 10:00	7.5	3.3	1.5	8.2	1.8
12/19/2021 11:00	8.9	3.3	1.5	8.2	1.8
12/19/2021 12:00	7.3	3.6	1.4	8.0	1.8
12/19/2021 13:00	9.5	3.0	1.6	8.7	1.9
12/19/2021 14:00	11.2	3.0	1.6	8.7	1.9
12/19/2021 15:00	7.9	3.3	1.6	8.7	1.9
12/19/2021 16:00	15.8	7.0	2.0	10.9	2.4
12/19/2021 17:00	15.3	6.0	2.2	12.0	2.6
12/19/2021 18:00	14.7	6.0	2.1	11.6	2.5
12/19/2021 19:00	14.9	6.0	2.1	11.7	2.6
12/19/2021 20:00	14.8	6.3	2.1	11.6	2.5
12/19/2021 21:00	14.7	6.0	2.1	11.6	2.5
12/19/2021 22:00	14.7	6.0	2.1	11.5	2.5
12/19/2021 23:00	14.4	6.0	2.1	11.3	2.5
Average/Sum#:	304.6 #	127.7 #	45.4 #	248.6 #	54.5 #
Minimum:	7.3	3.0	1.4	8.0	1.8
Maximum:	16.0	7.3	2.2	12.0	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/20/2021 00:00	14.4	6.0	2.1	11.3	2.5
12/20/2021 01:00	13.8	7.3	2.0	10.8	2.4
12/20/2021 02:00	11.9	3.2	1.7	9.3	2.0
12/20/2021 03:00	12.1	3.2	1.7	9.5	2.1
12/20/2021 04:00	14.1	7.1	2.0	11.1	2.4
12/20/2021 05:00	16.9	6.6	2.1	11.6	2.5
12/20/2021 06:00	15.3	6.0	2.2	12.1	2.6
12/20/2021 07:00	14.7	5.7	2.1	11.6	2.5
12/20/2021 08:00	16.0	6.7	2.0	10.9	2.4
12/20/2021 09:00	9.9	2.8	1.7	9.1	2.0
12/20/2021 10:00	6.8	3.5	1.3	7.4	1.6
12/20/2021 11:00	9.9	3.1	1.7	9.1	2.0
12/20/2021 12:00	11.2	6.3	1.9	10.2	2.2
12/20/2021 13:00	14.8	6.0	2.1	11.7	2.6
12/20/2021 14:00	15.3	6.0	2.2	12.0	2.6
12/20/2021 15:00	15.3	5.2	2.2	12.0	2.6
12/20/2021 16:00	15.6	5.3	2.3	12.2	2.7
12/20/2021 17:00	15.6	5.3	2.3	12.3	2.7
12/20/2021 18:00	15.6	5.0	2.3	12.4	2.7
12/20/2021 19:00	15.7	4.9	2.3	12.4	2.7
12/20/2021 20:00	15.7	4.9	2.3	12.4	2.7
12/20/2021 21:00	15.8	4.9	2.3	12.4	2.7
12/20/2021 22:00	15.6	4.9	2.3	12.4	2.7
12/20/2021 23:00	14.7	5.7	2.1	11.6	2.5
Average/Sum#:	336.7 #	125.6 #	49.2 #	267.8 #	58.4 #
Minimum:	6.8	2.8	1.3	7.4	1.6
Maximum:	16.9	7.3	2.3	12.4	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/21/2021 00:00	14.4	5.9	2.1	11.3	2.5
12/21/2021 01:00	10.1	2.5	1.7	9.3	2.0
12/21/2021 02:00	10.8	3.3	1.8	9.8	2.2
12/21/2021 03:00	16.0	6.5	2.0	11.1	2.4
12/21/2021 04:00	13.8	7.0	2.0	10.8	2.4
12/21/2021 05:00	11.6	3.1	1.7	9.1	2.0
12/21/2021 06:00	10.5	3.3	1.7	9.6	2.1
12/21/2021 07:00	14.4	6.8	2.1	11.3	2.5
12/21/2021 08:00	15.5	5.7	2.2	12.2	2.7
12/21/2021 09:00	14.6	5.4	2.1	11.4	2.5
12/21/2021 10:00	9.7	2.7	1.6	8.9	2.0
12/21/2021 11:00	12.6	3.0	1.8	9.9	2.2
12/21/2021 12:00	14.3	7.8	2.1	11.3	2.4
12/21/2021 13:00	16.0	7.7	2.0	10.9	2.4
12/21/2021 14:00	9.9	2.8	1.7	9.1	2.0
12/21/2021 15:00	12.6	3.0	1.8	9.9	2.2
12/21/2021 16:00	14.3	10.8	2.0	11.3	2.4
12/21/2021 17:00	15.6	6.1	2.3	12.3	2.7
12/21/2021 18:00	15.8	5.4	2.3	12.3	2.7
12/21/2021 19:00	15.8	5.4	2.3	12.3	2.7
12/21/2021 20:00	15.8	5.4	2.3	12.3	2.7
12/21/2021 21:00	15.3	5.3	2.2	12.1	2.6
12/21/2021 22:00	14.7	5.7	2.1	11.5	2.5
12/21/2021 23:00	14.4	6.0	2.1	11.3	2.5
Average/Sum#:	328.5 #	126.6 #	48.0 #	261.3 #	57.3 #
Minimum:	9.7	2.5	1.6	8.9	2.0
Maximum:	16.0	10.8	2.3	12.3	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/22/2021 00:00	13.5	9.6	2.0	10.6	2.3
12/22/2021 01:00	9.7	2.7	1.6	8.9	2.0
12/22/2021 02:00	10.1	3.4	1.7	9.2	2.0
12/22/2021 03:00	11.7	13.1	2.0	10.7	2.4
12/22/2021 04:00	11.6	11.3	2.0	10.6	2.3
12/22/2021 05:00	7.3	3.5	1.4	8.0	1.8
12/22/2021 06:00	10.1	3.4	1.7	9.3	2.0
12/22/2021 07:00	15.8	9.6	2.0	10.9	2.4
12/22/2021 08:00	15.8	9.0	2.0	10.9	2.4
12/22/2021 09:00	7.2	3.3	1.4	7.9	1.8
12/22/2021 10:00	7.6	3.6	1.6	8.3	1.8
12/22/2021 11:00	13.8	7.7	2.0	10.9	2.4
12/22/2021 12:00	11.7	7.7	2.0	10.7	2.4
12/22/2021 13:00	11.3	3.0	1.6	8.9	2.0
12/22/2021 14:00	12.5	3.0	1.8	9.8	2.2
12/22/2021 15:00	16.0	9.0	2.0	10.9	2.4
12/22/2021 16:00	14.3	6.6	2.1	11.3	2.4
12/22/2021 17:00	17.1	6.3	2.1	11.7	2.6
12/22/2021 18:00	14.0	6.9	2.0	11.1	2.4
12/22/2021 19:00	15.8	8.0	2.0	10.8	2.4
12/22/2021 20:00	13.8	6.6	2.0	10.9	2.4
12/22/2021 21:00	9.3	3.2	1.6	8.5	1.8
12/22/2021 22:00	10.5	3.5	1.7	9.6	2.1
12/22/2021 23:00	14.2	8.3	2.0	11.1	2.4
Average/Sum#:	294.7 #	152.3 #	44.3 #	241.5 #	53.1 #
Minimum:	7.2	2.7	1.4	7.9	1.8
Maximum:	17.1	13.1	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/23/2021 00:00	13.4	8.9	2.0	10.6	2.3
12/23/2021 01:00	9.5	3.3	1.6	8.7	1.9
12/23/2021 02:00	9.7	3.6	1.6	8.9	2.0
12/23/2021 03:00	13.6	7.3	2.0	10.7	2.4
12/23/2021 04:00	13.4	6.9	2.0	10.5	2.3
12/23/2021 05:00	11.5	3.3	1.7	9.1	2.0
12/23/2021 06:00	9.9	4.5	1.7	9.0	2.0
12/23/2021 07:00	14.3	7.2	2.1	11.2	2.4
12/23/2021 08:00	13.5	8.1	2.0	10.6	2.3
12/23/2021 09:00	9.3	3.2	1.6	8.5	1.8
12/23/2021 10:00	9.9	3.3	1.7	9.0	2.0
12/23/2021 11:00	13.6	6.8	2.0	10.7	2.4
12/23/2021 12:00	15.3	6.8	2.0	10.5	2.3
12/23/2021 13:00	9.7	3.0	1.6	8.9	2.0
12/23/2021 14:00	6.6	3.2	1.3	7.2	1.6
12/23/2021 15:00	11.3	3.0	1.6	8.9	2.0
12/23/2021 16:00	11.0	6.1	1.8	10.0	2.2
12/23/2021 17:00	15.3	6.4	2.0	10.5	2.3
12/23/2021 18:00	9.9	3.0	1.7	9.1	2.0
12/23/2021 19:00	13.7	11.0	2.0	10.8	2.4
12/23/2021 20:00	15.4	7.1	2.0	10.6	2.3
12/23/2021 21:00	7.3	3.0	1.4	8.0	1.8
12/23/2021 22:00	9.5	3.5	1.6	8.7	1.9
12/23/2021 23:00	13.8	7.5	2.0	10.8	2.4
Average/Sum#:	280.4 #	130.0 #	43.0 #	231.5 #	51.0 #
Minimum:	6.6	3.0	1.3	7.2	1.6
Maximum:	15.4	11.0	2.1	11.2	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/24/2021 00:00	15.4	7.1	2.0	10.6	2.3
12/24/2021 01:00	9.1	2.5	1.5	8.3	1.8
12/24/2021 02:00	7.4	3.0	1.4	8.1	1.8
12/24/2021 03:00	6.8	3.3	1.4	7.4	1.6
12/24/2021 04:00	6.8	3.3	1.4	7.4	1.6
12/24/2021 05:00	10.5	3.3	1.7	9.6	2.1
12/24/2021 06:00	11.0	6.4	1.8	10.1	2.2
12/24/2021 07:00	11.2	6.1	1.9	10.2	2.2
12/24/2021 08:00	9.9	3.3	1.7	9.1	2.0
12/24/2021 09:00	13.7	8.2	2.0	10.7	2.4
12/24/2021 10:00	15.5	7.1	2.0	10.6	2.3
12/24/2021 11:00	8.3	2.7	1.4	7.6	1.6
12/24/2021 12:00	9.7	2.4	1.6	8.9	2.0
12/24/2021 13:00	7.1	2.4	1.4	7.8	1.7
12/24/2021 14:00	8.5	2.7	1.4	7.7	1.7
12/24/2021 15:00	7.4	2.8	1.4	8.1	1.8
12/24/2021 16:00	7.6	3.1	1.5	8.3	1.8
12/24/2021 17:00	15.8	6.5	2.0	10.8	2.4
12/24/2021 18:00	13.9	6.3	2.0	11.0	2.4
12/24/2021 19:00	14.0	5.9	2.0	11.0	2.4
12/24/2021 20:00	13.4	6.8	2.0	10.5	2.3
12/24/2021 21:00	8.4	3.0	1.4	7.7	1.6
12/24/2021 22:00	9.5	3.3	1.6	8.7	1.9
12/24/2021 23:00	14.1	6.2	2.0	11.1	2.4
Average/Sum#:	255.0 #	107.7 #	40.5 #	221.3 #	48.3 #
Minimum:	6.8	2.4	1.4	7.4	1.6
Maximum:	15.8	8.2	2.0	11.1	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/25/2021 00:00	13.6	6.9	2.0	10.6	2.3
12/25/2021 01:00	9.3	2.9	1.6	8.5	1.8
12/25/2021 02:00	7.2	3.0	1.4	7.9	1.8
12/25/2021 03:00	6.8	3.3	1.4	7.4	1.6
12/25/2021 04:00	11.1	3.2	1.6	8.7	1.9
12/25/2021 05:00	16.0	6.9	2.0	10.9	2.4
12/25/2021 06:00	13.6	7.5	2.0	10.7	2.4
12/25/2021 07:00	9.5	3.2	1.6	8.7	1.9
12/25/2021 08:00	11.3	3.3	1.6	8.8	2.0
12/25/2021 09:00	7.1	3.1	1.4	7.7	1.7
12/25/2021 10:00	9.7	3.0	1.6	8.9	2.0
12/25/2021 11:00	7.9	3.0	1.6	8.7	1.9
12/25/2021 12:00	7.8	2.9	1.6	8.5	1.8
12/25/2021 13:00	7.4	2.8	1.5	8.2	1.8
12/25/2021 14:00	8.0	3.0	1.6	8.7	1.9
12/25/2021 15:00	9.7	3.0	1.6	8.9	2.0
12/25/2021 16:00	15.2	5.9	2.0	10.5	2.3
12/25/2021 17:00	14.3	6.6	2.1	11.3	2.4
12/25/2021 18:00	14.4	5.9	2.1	11.3	2.5
12/25/2021 19:00	14.2	6.0	2.1	11.2	2.4
12/25/2021 20:00	13.4	6.9	2.0	10.6	2.3
12/25/2021 21:00	9.9	3.1	1.7	9.0	2.0
12/25/2021 22:00	7.9	3.3	1.6	8.7	1.9
12/25/2021 23:00	15.9	6.3	2.0	10.9	2.4
Average/Sum#:	261.2 #	105.0 #	41.7 #	225.3 #	49.4 #
Minimum:	6.8	2.8	1.4	7.4	1.6
Maximum:	16.0	7.5	2.1	11.3	2.5
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/26/2021 00:00	10.4	23.6	0.7	3.4	0.8
12/26/2021 01:00	0.0	0.0	0.0	0.0	0.0
12/26/2021 02:00	0.0	0.0	0.0	0.0	0.0
12/26/2021 03:00	0.0	0.0	0.0	0.0	0.0
12/26/2021 04:00	0.0	0.0	0.0	0.0	0.0
12/26/2021 05:00	0.0	0.0	0.0	0.0	0.0
12/26/2021 06:00	0.0	0.0	0.0	0.0	0.0
12/26/2021 07:00	0.0	0.0	0.0	0.0	0.0
12/26/2021 08:00	0.0	0.0	0.0	0.0	0.0
12/26/2021 09:00	0.0	0.0	0.0	0.0	0.0
12/26/2021 10:00	1.1	10.4	0.0	0.1	0.0
12/26/2021 11:00	46.1	37.1	0.3	1.0	0.2
12/26/2021 12:00	39.3	119.4	0.5	1.9	0.5
12/26/2021 13:00	4.2	2.1	1.0	3.5	0.8
12/26/2021 14:00	4.1	2.0	1.0	3.4	0.8
12/26/2021 15:00	9.5	18.9	1.2	4.2	1.0
12/26/2021 16:00	80.5	63.6	1.4	6.2	1.4
12/26/2021 17:00	10.5	3.2	1.7	9.6	2.1
12/26/2021 18:00	10.5	3.2	1.7	9.6	2.1
12/26/2021 19:00	15.9	6.6	2.0	10.9	2.4
12/26/2021 20:00	13.8	6.2	2.0	10.9	2.4
12/26/2021 21:00	9.7	2.7	1.6	8.9	2.0
12/26/2021 22:00	10.3	3.2	1.7	9.4	2.0
12/26/2021 23:00	14.0	6.0	2.0	11.0	2.4
Average/Sum#:	279.9 #	308.2 #	18.8 #	94.0 #	20.9 #
Minimum:	0.0	0.0	0.0	0.0	0.0
Maximum:	80.5	119.4	2.0	11.0	2.4
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/27/2021 00:00	14.2	5.7	2.0	11.2	2.4
12/27/2021 01:00	15.8	5.5	2.0	10.8	2.4
12/27/2021 02:00	9.9	2.5	1.7	9.1	2.0
12/27/2021 03:00	7.6	3.1	1.5	8.3	1.8
12/27/2021 04:00	7.6	3.1	1.5	8.3	1.8
12/27/2021 05:00	10.0	3.1	1.7	9.1	2.0
12/27/2021 06:00	14.2	6.4	2.0	11.2	2.4
12/27/2021 07:00	15.0	6.0	2.1	11.8	2.6
12/27/2021 08:00	16.9	6.0	2.1	11.6	2.5
12/27/2021 09:00	15.0	5.2	2.1	11.8	2.6
12/27/2021 10:00	16.7	5.2	2.1	11.4	2.5
12/27/2021 11:00	14.2	4.8	2.1	11.2	2.4
12/27/2021 12:00	10.1	2.5	1.7	9.3	2.0
12/27/2021 13:00	9.7	2.7	1.7	8.9	2.0
12/27/2021 14:00	15.8	6.0	2.0	10.8	2.4
12/27/2021 15:00	14.7	6.0	2.1	11.6	2.5
12/27/2021 16:00	15.7	5.3	2.3	12.4	2.7
12/27/2021 17:00	18.1	4.6	2.3	12.4	2.7
12/27/2021 18:00	15.8	4.9	2.3	12.4	2.7
12/27/2021 19:00	15.8	5.0	2.3	12.4	2.7
12/27/2021 20:00	18.1	5.0	2.3	12.4	2.7
12/27/2021 21:00	15.6	5.0	2.3	12.2	2.7
12/27/2021 22:00	14.5	5.7	2.1	11.4	2.5
12/27/2021 23:00	14.3	5.7	2.1	11.3	2.4
Average/Sum#:	335.3 #	115.0 #	48.4 #	263.3 #	57.4 #
Minimum:	7.6	2.5	1.5	8.3	1.8
Maximum:	18.1	6.4	2.3	12.4	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/28/2021 00:00	11.6	7.7	2.0	10.6	2.3
12/28/2021 01:00	7.6	2.6	1.6	8.3	1.8
12/28/2021 02:00	8.1	3.3	1.6	8.9	2.0
12/28/2021 03:00	11.8	7.4	2.0	10.8	2.4
12/28/2021 04:00	11.6	6.7	2.0	10.6	2.3
12/28/2021 05:00	7.8	3.0	1.6	8.6	1.8
12/28/2021 06:00	10.3	3.8	1.7	9.5	2.0
12/28/2021 07:00	11.9	7.4	2.0	10.9	2.4
12/28/2021 08:00	16.2	6.7	2.0	11.1	2.4
12/28/2021 09:00	15.9	6.3	2.0	10.9	2.4
12/28/2021 10:00	7.8	2.9	1.6	8.5	1.8
12/28/2021 11:00	7.1	3.3	1.4	7.9	1.8
12/28/2021 12:00	7.6	3.1	1.6	8.4	1.8
12/28/2021 13:00	11.1	6.3	1.9	10.2	2.2
12/28/2021 14:00	15.4	5.6	2.0	10.5	2.3
12/28/2021 15:00	10.1	3.4	1.7	9.2	2.0
12/28/2021 16:00	16.9	6.3	2.1	11.6	2.5
12/28/2021 17:00	15.9	4.9	2.3	12.5	2.7
12/28/2021 18:00	15.7	4.9	2.3	12.3	2.7
12/28/2021 19:00	15.1	5.3	2.1	11.9	2.6
12/28/2021 20:00	17.1	5.7	2.1	11.7	2.6
12/28/2021 21:00	14.6	5.7	2.1	11.5	2.5
12/28/2021 22:00	14.5	5.7	2.1	11.4	2.5
12/28/2021 23:00	14.2	5.7	2.0	11.1	2.4
Average/Sum#:	295.9 #	123.7 #	45.8 #	248.9 #	54.2 #
Minimum:	7.1	2.6	1.4	7.9	1.8
Maximum:	17.1	7.7	2.3	12.5	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/29/2021 00:00	11.6	6.7	2.0	10.6	2.3
12/29/2021 01:00	7.6	3.2	1.6	8.3	1.8
12/29/2021 02:00	9.5	3.6	1.6	8.7	1.9
12/29/2021 03:00	11.8	9.4	2.0	10.8	2.4
12/29/2021 04:00	11.7	8.6	2.0	10.7	2.4
12/29/2021 05:00	7.3	3.9	1.4	8.0	1.8
12/29/2021 06:00	10.5	3.3	1.7	9.7	2.1
12/29/2021 07:00	16.2	8.1	2.0	11.1	2.4
12/29/2021 08:00	15.8	7.3	2.0	10.9	2.4
12/29/2021 09:00	7.1	3.5	1.4	7.8	1.7
12/29/2021 10:00	8.2	3.6	1.7	8.9	2.0
12/29/2021 11:00	14.2	7.4	2.0	11.1	2.4
12/29/2021 12:00	11.6	8.0	2.0	10.6	2.3
12/29/2021 13:00	10.1	2.8	1.7	9.2	2.0
12/29/2021 14:00	10.1	3.1	1.7	9.2	2.0
12/29/2021 15:00	14.1	7.0	2.0	11.1	2.4
12/29/2021 16:00	14.7	6.3	2.1	11.5	2.5
12/29/2021 17:00	15.8	5.7	2.3	12.5	2.7
12/29/2021 18:00	15.8	5.4	2.3	12.4	2.7
12/29/2021 19:00	15.8	5.4	2.3	12.5	2.7
12/29/2021 20:00	15.8	5.4	2.3	12.5	2.7
12/29/2021 21:00	14.9	6.0	2.1	11.7	2.6
12/29/2021 22:00	16.0	8.0	2.0	10.9	2.4
12/29/2021 23:00	16.2	6.7	2.0	11.1	2.4
Average/Sum#:	302.4 #	138.4 #	46.2 #	251.8 #	55.0 #
Minimum:	7.1	2.8	1.4	7.8	1.7
Maximum:	16.2	9.4	2.3	12.5	2.7
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/30/2021 00:00	11.6	8.0	2.0	10.6	2.3
12/30/2021 01:00	9.9	2.4	1.7	9.1	2.0
12/30/2021 02:00	6.9	3.3	1.4	7.6	1.6
12/30/2021 03:00	10.5	2.9	1.7	9.6	2.1
12/30/2021 04:00	13.1	6.4	1.9	10.2	2.2
12/30/2021 05:00	11.1	6.5	1.8	10.2	2.2
12/30/2021 06:00	10.3	3.2	1.7	9.4	2.0
12/30/2021 07:00	16.4	7.5	2.0	11.3	2.4
12/30/2021 08:00	17.2	6.1	2.1	11.7	2.6
12/30/2021 09:00	14.2	6.0	2.0	11.2	2.4
12/30/2021 10:00	9.9	2.7	1.7	9.0	2.0
12/30/2021 11:00	10.1	3.4	1.7	9.2	2.0
12/30/2021 12:00	14.0	6.7	2.0	11.1	2.4
12/30/2021 13:00	11.5	6.3	2.0	10.5	2.3
12/30/2021 14:00	10.0	2.5	1.7	9.2	2.0
12/30/2021 15:00	9.7	3.3	1.6	8.9	2.0
12/30/2021 16:00	16.0	8.0	2.0	11.0	2.4
12/30/2021 17:00	17.0	6.3	2.1	11.7	2.6
12/30/2021 18:00	14.7	6.0	2.1	11.5	2.5
12/30/2021 19:00	16.0	7.0	2.0	11.0	2.4
12/30/2021 20:00	14.7	6.3	2.1	11.6	2.5
12/30/2021 21:00	14.7	6.0	2.1	11.5	2.5
12/30/2021 22:00	14.5	6.3	2.1	11.3	2.5
12/30/2021 23:00	14.2	6.0	2.0	11.1	2.4
Average/Sum#:	308.2 #	129.1 #	45.5 #	249.5 #	54.3 #
Minimum:	6.9	2.4	1.4	7.6	1.6
Maximum:	17.2	8.0	2.1	11.7	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

AQ-25 Hourly

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 09:51 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	PlantWide NOx, Lb 1 Hour(s)	PlantWide CO, Lb 1 Hour(s)	PlantWide VOC, Lb 1 Hour(s)	PlantWide PM10, Lb 1 Hour(s)	PlantWide SO2, Lb 1 Hour(s)
12/31/2021 00:00	13.6	7.0	2.0	10.6	2.3
12/31/2021 01:00	7.6	2.6	1.6	8.5	1.8
12/31/2021 02:00	6.7	3.3	1.3	7.4	1.6
12/31/2021 03:00	10.5	2.9	1.7	9.6	2.1
12/31/2021 04:00	13.0	6.0	1.9	10.2	2.2
12/31/2021 05:00	11.1	6.2	1.8	10.1	2.2
12/31/2021 06:00	7.1	3.3	1.4	7.9	1.8
12/31/2021 07:00	14.1	6.7	2.0	11.1	2.4
12/31/2021 08:00	14.2	6.3	2.0	11.1	2.4
12/31/2021 09:00	11.6	7.4	2.0	10.6	2.3
12/31/2021 10:00	7.5	2.8	1.5	8.3	1.8
12/31/2021 11:00	7.3	2.7	1.4	8.1	1.8
12/31/2021 12:00	7.9	2.7	1.6	8.7	1.9
12/31/2021 13:00	6.6	2.7	1.3	7.2	1.6
12/31/2021 14:00	8.7	2.7	1.4	8.0	1.8
12/31/2021 15:00	9.9	3.3	1.7	9.0	2.0
12/31/2021 16:00	14.3	6.6	2.1	11.3	2.4
12/31/2021 17:00	14.9	6.3	2.1	11.7	2.6
12/31/2021 18:00	14.9	6.0	2.1	11.7	2.6
12/31/2021 19:00	15.1	5.6	2.1	11.9	2.6
12/31/2021 20:00	14.4	6.0	2.1	11.4	2.5
12/31/2021 21:00	9.5	2.4	1.6	8.7	1.9
12/31/2021 22:00	10.7	2.7	1.8	9.8	2.2
12/31/2021 23:00	11.8	6.4	2.0	10.8	2.4
Average/Sum#:	263.0 #	110.6 #	42.5 #	233.7 #	51.2 #
Minimum:	6.6	2.4	1.3	7.2	1.6
Maximum:	15.1	7.4	2.1	11.9	2.6
%SI	0.00	0.00	0.00	0.00	0.00

Excess Emission Report

CT1 and CT2 CO Lb/Day

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 09:52 **Location:** Maxwell, CA

Tag Name: ALL_CO_Lb_1D
Total Operating Time: 75.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 17.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**75.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 CO Lb/Hr

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 09:53 **Location:** Maxwell, CA

Tag Name: ALL_CO_Lb_1H
Total Operating Time: 1,674.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 534.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,674.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 NOx Lb/Day

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 09:54 **Location:** Maxwell, CA

Tag Name: ALL_NOx_Lb_1D
Total Operating Time: 75.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 17.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**75.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 NOx Lb/Hr

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 09:56 **Location:** Maxwell, CA

Tag Name: ALL_NOx_Lb_1H
Total Operating Time: 1,674.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 534.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,674.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 PM10 Lb/Day

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 09:58 **Location:** Maxwell, CA

Tag Name: ALL_PM10_Lb_1D
Total Operating Time: 75.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 17.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**75.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 PM10 Lb/Hr

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 09:58 **Location:** Maxwell, CA

Tag Name: ALL_PM10_Lb_1H
Total Operating Time: 1,674.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 534.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,674.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 SO2 Lb/Day

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 09:59 **Location:** Maxwell, CA

Tag Name: ALL_SO2_Lb_1D
Total Operating Time: 75.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 17.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**75.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 SO2 Lb/Hr

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 09:59 **Location:** Maxwell, CA

Tag Name: ALL_SO2_Lb_1H
Total Operating Time: 1,674.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 534.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,674.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 VOC Lb/Day

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:00 **Location:** Maxwell, CA

Tag Name: ALL_VOC_Lb_1D
Total Operating Time: 75.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 17.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**75.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

CT1 and CT2 VOC Lb/Hr

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:00 **Location:** Maxwell, CA

Tag Name: ALL_VOC_Lb_1H
Total Operating Time: 1,674.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 534.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,674.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

ATTACHMENT 11
Linearity

FCD: AQ-19
Title V: #13

Linearity Report

11/08/2021

ORIS Code:	56298	Facility Name:	COLUSA GENERATION		
EDR Site ID:	CT1	Component ID:	A11	ReasonForTest:	QA
		Component Type:	NOXA	Grace Period:	0
Instrument Name:	CT1_NOXDualRg_P_Instrume	Test End Date/Time:	11/05/2021	Scale:	High
Performance Spec:	5 %	Test No.:	107	Highest Error:	2.5
		Status (Pass/Fail):	**Passed**		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
11/05/2021	0738	L	200.0	50.2	51.3		25.1 %
11/05/2021	0744	M	200.0	111.4	111.6		55.7 %
11/05/2021	0750	H	200.0	183.3	183.3		91.7 %
11/05/2021	0759	L	200.0	50.2	51.1		25.1 %
11/05/2021	0805	M	200.0	111.4	112.1		55.7 %
11/05/2021	0811	H	200.0	183.3	184.8		91.7 %
11/05/2021	0819	L	200.0	50.2	52.0		25.1 %
11/05/2021	0825	M	200.0	111.4	111.8		55.7 %
11/05/2021	0831	H	200.0	183.3	184.8		91.7 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	50.200	51.467	No	**2.5**
M	111.400	111.833	No	**0.4**
H	183.300	184.300	No	**0.5**

Linearity Report

ORIS Code:	56298	Facility Name:	COLUSA GENERATION		
EDR Site ID:	CT1	Component ID:	A12	ReasonForTest:	QA
		Component Type:	O2D	Grace Period:	0
Instrument Name:	CT1_O2D_P_Instrument	Test End Date/Time:	11/05/2021	Scale:	High
Performance Spec:	5 %	Test No.:	108	Highest Error:	3.6
		Status (Pass/Fail):	**Passed**		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
11/05/2021	0911	L	25.0	5.5	5.3		22.0 %
11/05/2021	0917	M	25.0	13.0	12.8		52.0 %
11/05/2021	0923	H	25.0	21.1	20.9		84.4 %
11/05/2021	0932	L	25.0	5.5	5.3		22.0 %
11/05/2021	0938	M	25.0	13.0	12.8		52.0 %
11/05/2021	0944	H	25.0	21.1	20.9		84.4 %
11/05/2021	0952	L	25.0	5.5	5.3		22.0 %
11/05/2021	0958	M	25.0	13.0	12.8		52.0 %
11/05/2021	1004	H	25.0	21.1	20.9		84.4 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.500	5.300	No	**3.6**
M	13.000	12.800	No	**1.5**
H	21.100	20.900	No	**0.9**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT1
Parameter/Scale: O2D / High
Test Date: 11/05/2021
Test Result: **Pass**
Instrument Name: CT1_O2DInlet_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 0 Pct

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
11/05/2021	14:49	L	25	5.500	5.300	22.0 %
11/05/2021	14:55	M	25	13.000	12.900	52.0 %
11/05/2021	15:04	L	25	5.500	5.300	22.0 %
11/05/2021	15:10	M	25	13.000	12.900	52.0 %
11/05/2021	15:18	L	25	5.500	5.300	22.0 %
11/05/2021	15:24	M	25	13.000	12.900	52.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	5.500	5.300	Std	**3.6**
M	13.000	12.900	Std	**0.8**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT1
Parameter/Scale: CO / Low
Test Date: 11/05/2021
Test Result: **Pass**
Instrument Name: CT1_CODualRg_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
11/05/2021	11:46	L	20	4.700	4.600	23.5 %
11/05/2021	11:52	M	20	11.100	11.000	55.5 %
11/05/2021	12:01	L	20	4.700	4.600	23.5 %
11/05/2021	12:07	M	20	11.100	10.900	55.5 %
11/05/2021	12:15	L	20	4.700	4.500	23.5 %
11/05/2021	12:21	M	20	11.100	10.900	55.5 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	4.700	4.567	Std	**2.8**
M	11.100	10.933	Std	**1.5**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT1
Parameter/Scale: NOX / Low
Test Date: 11/05/2021
Test Result: **Pass**
Instrument Name: CT1_NOXDualRg_P_Instru
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
11/05/2021	10:38	L	10	2.600	3.700	26.0 %
11/05/2021	10:44	M	10	5.500	6.800	55.0 %
11/05/2021	10:52	L	10	2.600	3.800	26.0 %
11/05/2021	10:58	M	10	5.500	6.800	55.0 %
11/05/2021	11:06	L	10	2.600	3.800	26.0 %
11/05/2021	11:12	M	10	5.500	6.700	55.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	2.600	3.767	Alt	**1.2**
M	5.500	6.767	Alt	**1.3**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT1
Parameter/Scale: CO / High
Test Date: 11/05/2021
Test Result: **Pass**
Instrument Name: CT1_CODualRg_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
11/05/2021	12:50	L	2000	499.400	469.700	25.0 %
11/05/2021	12:56	M	2000	1160.000	1145.600	58.0 %
11/05/2021	13:05	L	2000	499.400	469.700	25.0 %
11/05/2021	13:11	M	2000	1160.000	1146.100	58.0 %
11/05/2021	13:19	L	2000	499.400	469.400	25.0 %
11/05/2021	13:25	M	2000	1160.000	1146.100	58.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	499.400	469.600	Std	**6.0**
M	1160.000	1145.933	Std	**1.2**

Cylinder Gas Audit

11/08/2021

Facility: COLUSA GENERATION
Unit/Stack: CT1
Parameter/Scale: NOX / High

Test Date: 11/05/2021
Test Result: **Pass**

Instrument Name: CT1_NOXInlet_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
11/05/2021	13:57	L	200	50.200	49.500	25.1 %
11/05/2021	14:03	M	200	111.400	110.700	55.7 %
11/05/2021	14:12	L	200	50.200	50.100	25.1 %
11/05/2021	14:18	M	200	111.400	111.400	55.7 %
11/05/2021	14:26	L	200	50.200	50.300	25.1 %
11/05/2021	14:32	M	200	111.400	111.800	55.7 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	50.200	49.967	Std	**0.5**
M	111.400	111.300	Std	**0.1**

Airgas
an Air Liquide company

In Service 11/4/2021

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15A42D0	Reference Number:	153-402066788-1 CT1
Cylinder Number:	CC365543	Cylinder Volume:	144.4 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG CV1
PGVP Number:	B72021	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Mar 31, 2021

Expiration Date: Mar 31, 2029

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	180.0 PPM	183.3 PPM	G1	+/- 0.6% NIST Traceable	03/24/2021, 03/31/2021
NITRIC OXIDE	180.0 PPM	183.1 PPM	G1	+/- 0.6% NIST Traceable	03/24/2021, 03/31/2021
CARBON MONOXIDE	1150 PPM	1160 PPM	G1	+/- 0.9% NIST Traceable	03/24/2021
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	18060115	KAL004110	249.9 PPM NITRIC OXIDE/NITROGEN	0.4%	Nov 08, 2023
PRM	12386	D685025	9.91 PPM NITROGEN DIOXIDE/AIR	2.0%	Feb 20, 2020
GMIS	401648675102	CC500959	5.074 PPM NITROGEN DIOXIDE/NITROGEN	2.1%	Feb 01, 2023
NTRM	09010335	KAL004570	970.0 PPM CARBON MONOXIDE/NITROGEN	0.4%	May 14, 2021

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet iS50 AUP2010228 CO HCO	FTIR	Mar 18, 2021
Nicolet iS50 AUP2010228 NO MNO	FTIR	Mar 17, 2021
Nicolet iS50 AUP2010228 NO2 impurity	FTIR NO2 impurity	Mar 18, 2021

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

In Service 11/4/2021

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI79E15AC046	Reference Number:	153-402065039-1
Cylinder Number:	SG9153011BAL	Cylinder Volume:	146.2 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72021	Valve Outlet:	590
		Certification Date:	Mar 29, 2021

CT1
CV2

Expiration Date: Mar 29, 2029

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	21.00 %	21.08 %	G1	+/- 0.3% NIST Traceable	03/29/2021
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	12062008	CC367433	22.883 % OXYGEN/NITROGEN	0.2%	May 14, 2024

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 W603MM58 O2	O2 Paramagnetic (Mason)	Mar 19, 2021

Triad Data Available Upon Request

PERMANENT NOTES:-NA-

NOTES:NO: <0.01PPM
CO: <0.01PPM
CO2: <0.01PPM

Approved for Release

In Service 10/22/2021

Airgas
an Air Liquide company

Airgas Specialty Gases
Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15A7635	Reference Number:	153-402189293-1
Cylinder Number:	CC428241	Cylinder Volume:	144.3 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72021	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Aug 25, 2021

CT 1
CV 3

Expiration Date: Aug 25, 2024

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	9.000 PPM	9.138 PPM	G1	+/- 1.1% NIST Traceable	08/18/2021, 08/25/2021
NITRIC OXIDE	9.000 PPM	9.096 PPM	G1	+/- 1.0% NIST Traceable	08/18/2021, 08/25/2021
CARBON MONOXIDE	11.00 PPM	11.14 PPM	G1	+/- 1.1% NIST Traceable	08/18/2021
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	12010210	AAL073499	10.04 PPM NITRIC OXIDE/NITROGEN	1.0%	Oct 16, 2022
NTRM	12010210	AAL073499-NOX	10.04 PPM NOx/NITROGEN	1.0%	Oct 16, 2022
NTRM	12062857	CC401933	9.82 PPM CARBON MONOXIDE/NITROGEN	1.0%	Feb 12, 2024

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Thermo 48i-TLE 1163640031 CO	CO NDIR (Mason)	Aug 17, 2021
Thermo 42i-LS 1123749327 NO	Chemiluminescence (Mason)	Jul 29, 2021
Thermo 42i-LS 1123749327 NOx	Chemiluminescence (Mason)	Jul 29, 2021

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

In Service 8/17/2021

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

CTI
CV4

Part Number:	E02NI99E15A0093	Reference Number:	153-401144291-1
Cylinder Number:	CC476209	Cylinder Volume:	144.3 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72018	Valve Outlet:	660
Gas Code:	NO,NOX,BALN	Certification Date:	Mar 12, 2018

Expiration Date: Mar 12, 2026

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	110.0 PPM	111.4 PPM	G1	+/- 1.1% NIST Traceable	03/05/2018, 03/12/2018
NITRIC OXIDE	110.0 PPM	111.1 PPM	G1	+/- 1.1% NIST Traceable	03/05/2018, 03/12/2018
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	13010413	KAL004013	97.6 PPM NITRIC OXIDE/NITROGEN	0.8%	May 09, 2019
PRM	12367	APEX1099237	9.82 PPM NITROGEN DIOXIDE/NITROGEN	1.6%	May 29, 2016
GMIS	1114201604	CC507567	4.955 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Nov 14, 2019

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801550 NO LNO	FTIR	Mar 07, 2018
Nicolet 6700 AHR0801550 NO2 impurity	FTIR NO2 impurity	Mar 07, 2018

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

In service 6/1/2021

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

CTI
CVS

Part Number:	E02NI99E15A0147	Reference Number:	153-401707980-1
Cylinder Number:	CC178727	Cylinder Volume:	144.3 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72020	Valve Outlet:	660
Gas Code:	NO,NOX,BALN	Certification Date:	Jan 28, 2020

Expiration Date: Jan 28, 2028

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	50.00 PPM	50.17 PPM	G1	+/- 1.0% NIST Traceable	01/21/2020, 01/28/2020
NITRIC OXIDE	50.00 PPM	50.17 PPM	G1	+/- 1.0% NIST Traceable	01/21/2020, 01/28/2020
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	12010719	KAL004397	50.03 PPM NITRIC OXIDE/NITROGEN	0.8%	Mar 12, 2024
PRM	12376	D562879	10.01 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Aug 17, 2018
GMIS	7301017103	CC506597	4.451 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Dec 18, 2020

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AMP0900119 NO LNO	FTIR	Jan 22, 2020
Nicolet 6700 AMP0900119 NO2 impurity	FTIR NO2 impurity	Jan 22, 2020

Triad Data Available Upon Request

mlg

Approved for Release

In Service 6/1/2021

Airgas
an Air Liquide company

Airgas Specialty Gases
Airgas USA, LLC
11711 S. Alameda Street
Los Angeles, CA 90059
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15A42C9	Reference Number:	48-402028993-1
Cylinder Number:	CC347523	Cylinder Volume:	144.3 CF
Laboratory:	124 - Los Angeles (SAP) - CA	Cylinder Pressure:	2015 PSIG
PGVP Number:	B32021	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Feb 22, 2021

CT1
CV6

Expiration Date: Feb 22, 2024

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	5.500 PPM	5.504 PPM	G1	+/- 1.1% NIST Traceable	02/15/2021, 02/22/2021
NITRIC OXIDE	5.500 PPM	5.456 PPM	G1	+/- 1.2% NIST Traceable	02/15/2021, 02/22/2021
CARBON MONOXIDE	500.0 PPM	499.4 PPM	G1	+/- 0.7% NIST Traceable	02/16/2021
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	08012106A	KAL004222	5.08 PPM NITRIC OXIDE/NITROGEN	+/- 1.0%	Jul 05, 2021
NTRM	08012106A	KAL004222-NOx	5.08 PPM NOx/NITROGEN	+/- 1.0%	Jul 05, 2021
NTRM	13010114	ND47902	495.4 PPM CARBON MONOXIDE/NITROGEN	+/- 0.6%	Jul 03, 2024

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
SIEMENS 6E CO LOW	NDIR	Feb 04, 2021
Thermo 42-iLS 1115848421 NO	Chemiluminescence	Jan 22, 2021
Thermo 42-iLS 1115848421 NOx	Chemiluminescence	Jan 22, 2021

Triad Data Available Upon Request

Approved for Release

In Service 6/1/2021

Airgas
an Air Liquide company

Airgas Specialty Gases
Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15A73F4	Reference Number:	153-402028992-1	CTI
Cylinder Number:	CC739556	Cylinder Volume:	144.3 CF	
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG	CV-7
PGVP Number:	B72021	Valve Outlet:	660	
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Feb 23, 2021	

Expiration Date: Feb 23, 2024

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	2.500 PPM	2.613 PPM	G1	+/- 1.4% NIST Traceable	02/10/2021, 02/23/2021
NITRIC OXIDE	2.500 PPM	2.495 PPM	G1	+/- 1.1% NIST Traceable	02/10/2021, 02/23/2021
CARBON MONOXIDE	4.750 PPM	4.714 PPM	G1	+/- 0.7% NIST Traceable	02/10/2021
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	08012126	KAL004291	5.08 PPM NITRIC OXIDE/NITROGEN	1.0%	Jul 05, 2021
NTRM	08012126	KAL004291-NOX	5.08 PPM NOx/NITROGEN	1.0%	Jul 05, 2021
NTRM	08011130	KAL004049	9.855 PPM CARBON MONOXIDE/NITROGEN	0.5%	Jun 05, 2024

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Thermo 48i-TLE 1163640031 CO	CO NDIR (Mason)	Feb 01, 2021
Thermo 42i-LS 1123749327 NO	Chemiluminescence (Mason)	Feb 19, 2021
Thermo 42i-LS 1123749327 NOx	Chemiluminescence (Mason)	Feb 19, 2021

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

IN SERVICE 14 JUN 21 -5

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CT/
CV 8

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI87E15A0080	Reference Number:	153-402028995-1
Cylinder Number:	EB0088907	Cylinder Volume:	145.5 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72021	Valve Outlet:	590
Gas Code:	O2,BALN	Certification Date:	Feb 15, 2021

Expiration Date: Feb 15, 2029

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	13.00 %	13.03 %	G1	+/- 0.8% NIST Traceable	02/15/2021
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	98051010	SG9161286BAL	12.05 % OXYGEN/NITROGEN	0.7%	Dec 14, 2023

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 W603MM58 O2	O2 Paramagnetic (Mason)	Feb 01, 2021

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

In service 11/4/2021

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

CT1
CV9

Part Number:	E02NI94E15AC040	Reference Number:	153-402028994-1
Cylinder Number:	CC222116	Cylinder Volume:	144.8 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72021	Valve Outlet:	590
Gas Code:	O2,BALN	Certification Date:	Feb 16, 2021

Expiration Date: Feb 16, 2029

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	5.500 %	5.501 %	G1	+/- 0.5% NIST Traceable	02/16/2021
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	11060717	CC338451	4.861 % OXYGEN/NITROGEN	0.4%	Dec 13, 2022

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 W603MM58 O2	O2 Paramagnetic (Mason)	Feb 01, 2021

Triad Data Available Upon Request

PERMANENT NOTES:-NA-

NOTES:NO: 0.01PPM
CO: 0.03PPM
CO2: 0.01PPM

Approved for Release

Linearity Report

ORIS Code:	56298	Facility Name:	COLUSA GENERATION		
EDR Site ID:	CT2	Component ID:	A21	ReasonForTest:	QA
		Component Type:	NOXA	Grace Period:	0
Instrument Name:	CT2_NOXDualRg_P_Instrume	Test End Date/Time:	11/08/2021	Scale:	High
Performance Spec:	5 %	Test No.:	108	Highest Error:	2.7
		Status (Pass/Fail):	**Passed**		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
11/08/2021	1601	L	200.0	50.3	49.9		25.2 %
11/08/2021	1607	M	200.0	110.4	112.5		55.2 %
11/08/2021	1613	H	200.0	180.6	186.3		90.3 %
11/08/2021	1622	L	200.0	50.3	49.9		25.2 %
11/08/2021	1628	M	200.0	110.4	113.3		55.2 %
11/08/2021	1634	H	200.0	180.6	185.4		90.3 %
11/08/2021	1642	L	200.0	50.3	49.9		25.2 %
11/08/2021	1648	M	200.0	110.4	113.6		55.2 %
11/08/2021	1654	H	200.0	180.6	184.8		90.3 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	50.300	49.900	No	**0.8**
M	110.400	113.133	No	**2.5**
H	180.600	185.500	No	**2.7**

Linearity Report

ORIS Code: 56298
EDR Site ID: CT2
Facility Name: COLUSA GENERATION
Component ID: A22
Component Type: O2D
ReasonForTest: QA
Grace Period: 0
Instrument Name: CT2_O2D_P_Instrument
Performance Spec: 5 %
Test End Date/Time: 11/09/2021
Test No.: 109
Status (Pass/Fail): **Passed**
Scale: High
Highest Error: 1.8

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
11/09/2021	1128	L	25.0	5.5	5.6		22.0 %
11/09/2021	1134	M	25.0	13.0	13.0		52.0 %
11/09/2021	1140	H	25.0	21.0	21.0		84.0 %
11/09/2021	1149	L	25.0	5.5	5.6		22.0 %
11/09/2021	1155	M	25.0	13.0	13.0		52.0 %
11/09/2021	1201	H	25.0	21.0	21.0		84.0 %
11/09/2021	1209	L	25.0	5.5	5.6		22.0 %
11/09/2021	1215	M	25.0	13.0	13.0		52.0 %
11/09/2021	1221	H	25.0	21.0	21.0		84.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.500	5.600	No	**1.8**
M	13.000	13.000	No	**0.0**
H	21.000	21.000	No	**0.0**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT2
Parameter/Scale: NOX / Low
Test Date: 11/05/2021
Test Result: **Pass**
Instrument Name: CT2_NOXDualRg_P_Instru
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
11/05/2021	09:23	L	10	2.500	1.900	25.0 %
11/05/2021	09:29	M	10	5.500	5.100	55.0 %
11/05/2021	09:38	L	10	2.500	1.900	25.0 %
11/05/2021	09:44	M	10	5.500	5.200	55.0 %
11/05/2021	09:52	L	10	2.500	1.900	25.0 %
11/05/2021	09:58	M	10	5.500	5.100	55.0 %

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Specification Used	Results
L	2.500		1.900	Alt	**0.6**
M	5.500		5.133	Std	**6.7**

Cylinder Gas Audit

11/09/2021

Facility: COLUSA GENERATION
Unit/Stack: CT2
Parameter/Scale: CO / Low
Test Date: 11/05/2021
Test Result: **Pass**
Instrument Name: CT2_CODualRg_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
11/05/2021	10:22	L	20	4.600	4.200	23.0 %
11/05/2021	10:28	M	20	11.100	10.900	55.5 %
11/05/2021	10:37	L	20	4.600	4.200	23.0 %
11/05/2021	10:43	M	20	11.100	10.900	55.5 %
11/05/2021	10:51	L	20	4.600	4.100	23.0 %
11/05/2021	10:57	M	20	11.100	11.000	55.5 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	4.600	4.167	Std	**9.4**
M	11.100	10.933	Std	**1.5**

Cylinder Gas Audit

11/09/2021

Facility: COLUSA GENERATION
Unit/Stack: CT2
Parameter/Scale: CO / High
Test Date: 11/05/2021
Test Result: **Pass**
Instrument Name: CT2_CODualRg_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
11/05/2021	11:48	L	2000	511.100	508.300	25.6 %
11/05/2021	11:54	M	2000	1150.000	1157.800	57.5 %
11/05/2021	12:03	L	2000	511.100	508.300	25.6 %
11/05/2021	12:09	M	2000	1150.000	1158.100	57.5 %
11/05/2021	12:17	L	2000	511.100	508.100	25.6 %
11/05/2021	12:23	M	2000	1150.000	1158.100	57.5 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	511.100	508.233	Std	**0.6**
M	1150.000	1158.000	Std	**0.7**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT2
Parameter/Scale: O2D / High
Test Date: 11/08/2021
Test Result: **Pass**
Instrument Name: CT2_O2DInlet_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 0 Pct

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
11/08/2021	11:10	L	25	5.500	5.200	22.0 %
11/08/2021	11:16	M	25	13.000	12.900	52.0 %
11/08/2021	11:25	L	25	5.500	5.200	22.0 %
11/08/2021	11:31	M	25	13.000	12.900	52.0 %
11/08/2021	11:39	L	25	5.500	5.200	22.0 %
11/08/2021	11:45	M	25	13.000	12.900	52.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	5.500	5.200	Std	**5.5**
M	13.000	12.900	Std	**0.8**

Cylinder Gas Audit

Facility: COLUSA GENERATION
Unit/Stack: CT2
Parameter/Scale: NOX / High

Test Date: 11/09/2021
Test Result: **Pass**

Instrument Name: CT2_NOXInlet_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
11/09/2021	09:48	L	200	50.300	48.800	25.2 %
11/09/2021	09:54	M	200	110.400	110.200	55.2 %
11/09/2021	10:03	L	200	50.300	48.800	25.2 %
11/09/2021	10:09	M	200	110.400	110.100	55.2 %
11/09/2021	10:17	L	200	50.300	49.200	25.2 %
11/09/2021	10:23	M	200	110.400	110.100	55.2 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	50.300	48.933	Std	**2.7**
M	110.400	110.133	Std	**0.2**

Airgas
an Air Liquide company

In Service 10/22/2021

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

CTZ
CV1

Part Number:	E03Ni99E15A42D0	Reference Number:	153-401995003-1
Cylinder Number:	CC124115	Cylinder Volume:	144.4 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72021	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Jan 05, 2021

Expiration Date: Jan 05, 2029

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	180.0 PPM	180.6 PPM	G1	+/- 0.9% NIST Traceable	12/29/2020, 01/05/2021
NITRIC OXIDE	180.0 PPM	180.3 PPM	G1	+/- 0.9% NIST Traceable	12/29/2020, 01/05/2021
CARBON MONOXIDE	1150 PPM	1150 PPM	G1	+/- 1.4% NIST Traceable	12/29/2020
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	13010322	KAL003863	243.4 PPM NITRIC OXIDE/NITROGEN	0.5%	May 04, 2026
PRM	12386	D685025	9.91 PPM NITROGEN DIOXIDE/AIR	2.0%	Feb 20, 2020
GMIS	401203436105	CC513880	4.732 PPM NITROGEN DIOXIDE/NITROGEN	2.1%	May 02, 2022
NTRM	08012251	KAL004695	2466 PPM CARBON MONOXIDE/NITROGEN	0.5%	May 09, 2024

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801550 CO HCO	FTIR	Dec 23, 2020
Nicolet 6700 AHR0801550 NO MNO	FTIR	Dec 29, 2020
Nicolet 6700 AHR0801550 NO2 impurity	FTIR NO2 impurity	Dec 30, 2020

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

IN SERVICE 01NOV21

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CT 2
CV 2

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI79E15AC046	Reference Number:	153-402189187-1
Cylinder Number:	CC87587	Cylinder Volume:	146.2 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72021	Valve Outlet:	590
		Certification Date:	Aug 16, 2021

Expiration Date: Aug 16, 2029

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	21.00 %	21.01 %	G1	+/- 0.7% NIST Traceable	08/16/2021
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	12062008	CC367433	22.883 % OXYGEN/NITROGEN	0.2%	May 14, 2024

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 W603M[illegible]58 O2	O2 Paramagnetic (Mason)	Aug 12, 2021

Triad Data Available Upon Request

PERMANENT NOTES:-NA-

Approved for Release

In Service 10/22/2021

Airgas
an Air Liquide company

Airgas Specialty Gases
Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

CT2
CV3

Part Number:	E03NI99E15A7635	Reference Number:	153-402066793-1A
Cylinder Number:	CC709732	Cylinder Volume:	144.3 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72021	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Apr 13, 2021

Expiration Date: Apr 13, 2024

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	9.000 PPM	9.093 PPM	G1	+/- 1.1% NIST Traceable	04/06/2021, 04/13/2021
NITRIC OXIDE	9.000 PPM	8.979 PPM	G1	+/- 1.2% NIST Traceable	04/06/2021, 04/13/2021
CARBON MONOXIDE	11.00 PPM	11.11 PPM	G1	+/- 0.5% NIST Traceable	04/06/2021
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	120102	AAL073426	10.04 PPM NITRIC OXIDE/NITROGEN	1.0%	Oct 16, 2022
NTRM	120102	AAL073426-NOX	10.04 PPM NOx/NITROGEN	1.0%	Oct 16, 2022
NTRM	15010203	KAL003073	24.35 PPM CARBON MONOXIDE/NITROGEN	0.3%	Sep 04, 2021

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Thermo 48i-TLE 1163640031 CO	CO NDIR (Mason)	Apr 05, 2021
Thermo 42i-LS 1123749327 NO	Chemiluminescence (Mason)	Mar 22, 2021
Thermo 42i-LS 1123749327 NOx	Chemiluminescence (Mason)	Mar 22, 2021

Triad Data Available Upon Request

Approved for Release

IN SERVICE 03 APR 2020

Airgas
an Air Liquide company

Airgas Specialty Gases
Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CT2 - CV4

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI99E15A0093	Reference Number:	153-400996726-1
Cylinder Number:	CC205834	Cylinder Volume:	144.3 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72017	Valve Outlet:	660
Gas Code:	NO,NOX,BALN	Certification Date:	Sep 19, 2017

Expiration Date: Sep 19, 2025

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	110.0 PPM	110.4 PPM	G1	+/- 1.0% NIST Traceable	09/12/2017, 09/19/2017
NITRIC OXIDE	110.0 PPM	110.2 PPM	G1	+/- 1.0% NIST Traceable	09/12/2017, 09/19/2017
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	13010428	KAL004053	97.6 PPM NITRIC OXIDE/NITROGEN	0.8	May 09, 2019
PRM	12367	APEX1099237	10.00 PPM NITROGEN DIOXIDE/NITROGEN	1.6%	May 29, 2016
GMIS	1114201604	CC507567	4.955 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Nov 14, 2019

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801550 NO LNO	FTIR	Sep 07, 2017
Nicolet 6700 AHR0801550 NO2 impurity	FTIR NO2 impurity	Sep 07, 2017

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

In Service 8/17/2021

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

CT2
CV5

Part Number:	E02NI99E15A0147	Reference Number:	153-401144292-1
Cylinder Number:	CC215825	Cylinder Volume:	144.3 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72018	Valve Outlet:	660
Gas Code:	NO,NOX,BALN	Certification Date:	Mar 13, 2018

Expiration Date: Mar 13, 2026

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	50.00 PPM	50.34 PPM	G1	+/- 1.4% NIST Traceable	03/06/2018, 03/13/2018
NITRIC OXIDE	50.00 PPM	50.31 PPM	G1	+/- 1.4% NIST Traceable	03/06/2018, 03/13/2018
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	16060619	CC442576	50.42 PPM NITRIC OXIDE/NITROGEN	0.8%	Jun 27, 2020
PRM	12367	APEX1099237	9.82 PPM NITROGEN DIOXIDE/NITROGEN	1.6%	May 29, 2016
GMIS	1114201604	CC507567	4.955 PPM NITROGEN DIOXIDE/NITROGEN	2.0%	Nov 14, 2019

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Nicolet 6700 AHR0801550 NO LNO	FTIR	Mar 07, 2018
Nicolet 6700 AHR0801550 NO2 impurity	FTIR NO2 impurity	Mar 07, 2018

Triad Data Available Upon Request

Approved for Release

In service 6/1/2021

Airgas
an Air Liquide company

Airgas Specialty Gases
Airgas USA, LLC
11711 S. Alameda Street
Los Angeles, CA 90059
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

CTZ
CVG

Part Number:	E03NI99E15A42C9	Reference Number:	48-401707982-1
Cylinder Number:	EB0102482	Cylinder Volume:	144.3 CF
Laboratory:	124 - Los Angeles (SAP) - CA	Cylinder Pressure:	2015 PSIG
PGVP Number:	B32020	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Feb 12, 2020

Expiration Date: Feb 12, 2023

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	5.500 PPM	5.476 PPM	G1	+/- 1.2% NIST Traceable	02/03/2020, 02/12/2020
NITRIC OXIDE	5.500 PPM	5.410 PPM	G1	+/- 1.1% NIST Traceable	02/03/2020, 02/12/2020
CARBON MONOXIDE	500.0 PPM	511.1 PPM	G1	+/- 0.6% NIST Traceable	02/04/2020
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	08012106A	KAL004222	5.08 PPM NITRIC OXIDE/NITROGEN	+/- 1.0%	Jul 05, 2021
NTRM	08012106A	KAL004222-NOx	5.08 PPM NOx/NITROGEN	+/- 1.0%	Jul 05, 2021
NTRM	15060524	CC450548	491.9 PPM CARBON MONOXIDE/NITROGEN	+/- 0.6%	Jan 08, 2021

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
SIEMENS 6E CO HIGH	NDIR	Jan 15, 2020
Thermo 42-iLS 1115848421 NO	Chemiluminescence	Feb 02, 2020
Thermo 42-iLS 1115848421 NOx	Chemiluminescence	Feb 02, 2020

Triad Data Available Upon Request

Approved for Release

IN SERVICE: 05 APR 2020

Airgas
an Air Liquide company

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CT2
CV7

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI99E15A73F4	Reference Number:	153-401707981-1
Cylinder Number:	CC472917	Cylinder Volume:	144.3 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72020	Valve Outlet:	660
Gas Code:	CO,NO,NOX,BALN	Certification Date:	Jan 28, 2020

Expiration Date: Jan 28, 2023

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	2.500 PPM	2.507 PPM	G1	+/- 1.3% NIST Traceable	01/21/2020, 01/28/2020
NITRIC OXIDE	2.500 PPM	2.502 PPM	G1	+/- 1.4% NIST Traceable	01/21/2020, 01/28/2020
CARBON MONOXIDE	4.750 PPM	4.637 PPM	G1	+/- 0.6% NIST Traceable	01/21/2020
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	08012121A	KAL004278	5.08 PPM NITRIC OXIDE/NITROGEN	1.0%	Jun 05, 2021
NTRM	08012126	KAL004291	5.08 PPM NITRIC OXIDE/NITROGEN	1.0%	Jul 05, 2021
NTRM	08012121A	KAL004278-NOX	5.08 PPM NOx/NITROGEN	1.0%	Jun 05, 2021
NTRM	08012126	KAL004291-NOX	5.08 PPM NOx/NITROGEN	1.0%	Jul 05, 2021
NTRM	08011130	KAL004049	9.855 PPM CARBON MONOXIDE/NITROGEN	0.5%	Jun 05, 2024

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Thermo 48i-TLE 1163640031 CO	CO NDIR (Mason)	Jan 06, 2020
Thermo 42i-LS 1123749327 NO	Chemiluminescence (Mason)	Jan 16, 2020
Thermo 42i-LS 1123749327 NOx	Chemiluminescence (Mason)	Jan 16, 2020

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

In Service 8/17/2021

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

CTZ
CV8

Part Number:	E02NI87E15A0080	Reference Number:	153-402028995-1
Cylinder Number:	CC203622	Cylinder Volume:	145.5 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72021	Valve Outlet:	590
Gas Code:	O2,BALN	Certification Date:	Feb 15, 2021

Expiration Date: Feb 15, 2029

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	13.00 %	13.02 %	G1	+/- 0.7% NIST Traceable	02/15/2021
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	98051010	SG9161286BAL	12.05 % OXYGEN/NITROGEN	0.7%	Dec 14, 2023

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 W603MM58 O2	O2 Paramagnetic (Mason)	Feb 01, 2021

Triad Data Available Upon Request

Approved for Release

Airgas
an Air Liquide company

In Service 11/4/2021

Airgas USA, LLC
525 North Industrial Loop Road
Tooele, UT 84074
Airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E02NI94E15AC040	Reference Number:	153-401825995-1
Cylinder Number:	CC415540	Cylinder Volume:	144.8 CF
Laboratory:	124 - Tooele (SAP) - UT	Cylinder Pressure:	2015 PSIG
PGVP Number:	B72020	Valve Outlet:	590
Gas Code:	O2,BALN	Certification Date:	Jun 02, 2020

CTZ
CV9

Expiration Date: Jun 02, 2028

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	5.500 %	5.495 %	G1	+/- 0.5% NIST Traceable	06/02/2020
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	11060717	CC338451	4.861 % OXYGEN/NITROGEN	0.4%	Dec 13, 2022

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
Horiba MPA-510 W603MM58 O2	O2 Paramagnetic (Mason)	May 21, 2020

Triad Data Available Upon Request

PERMANENT NOTES:-NA-

NOTES:
NO: 0.01 ppm
CO: 0.02 ppm
CO2: 0.00 ppm

Approved for Release

ATTACHMENT 12
Startup/Shutdown Emissions

FCD: AQ-22
Title V: #13, #14

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:11 **Location:** Maxwell, CA
Tag Name: CT1_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission
Total Operating Time: 1,630.20 Hours
Non-Operating Time: 577.80 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
10/08/2021 21:04 10/08/2021 21:09 Shut Down - Gas	6	0.6		
10/20/2021 13:25 10/20/2021 15:09 Cold Start - Gas	105	161.4		
10/20/2021 22:09 10/20/2021 22:13 Shut Down - Gas	5	0.4		
10/23/2021 01:22 10/23/2021 03:56 Warm Start - Gas	155	199.8		
10/23/2021 22:38 10/23/2021 22:43 Shut Down - Gas	6	0.9		
10/24/2021 07:16 10/24/2021 08:40 Warm Start - Gas	85	128.6		
11/06/2021 22:39 11/06/2021 22:43 Shut Down - Gas	5	0.4		
11/09/2021 07:11 11/09/2021 08:44 Warm Start - Gas	94	153.0		
11/11/2021 01:08 11/11/2021 01:13 Shut Down - Gas	6	0.7		
11/11/2021 09:34 11/11/2021 10:59 Warm Start - Gas	86	148.2		
11/13/2021 00:23 11/13/2021 00:28 Shut Down - Gas	6	0.7		
11/13/2021 08:34 11/13/2021 09:44 Warm Start - Gas	71	112.1		
11/13/2021 22:38 11/13/2021 22:43 Shut Down - Gas	6	0.6		

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:11 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,630.20 Hours

Non-Operating Time: 577.80 Hours Report Time: 2,208.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
11/14/2021 09:47 11/14/2021 11:27 Warm Start - Gas	101	144.7		
11/16/2021 00:10 11/16/2021 00:15 Shut Down - Gas	6	0.9		
11/16/2021 08:34 11/16/2021 09:54 Warm Start - Gas	81	123.2		
11/21/2021 02:51 11/21/2021 02:56 Shut Down - Gas	6	0.5		
11/21/2021 10:43 11/21/2021 11:53 Hot Start - Gas	71	106.5		
11/25/2021 00:08 11/25/2021 00:13 Shut Down - Gas	6	0.7		
11/29/2021 07:49 11/29/2021 11:48 Cold Start - Gas	240	325.7		
11/29/2021 23:22 11/29/2021 23:27 Shut Down - Gas	6	1.0		
11/30/2021 05:43 11/30/2021 06:51 Hot Start - Gas	69	99.1		
12/02/2021 00:24 12/02/2021 00:29 Shut Down - Gas	6	0.5		
12/02/2021 06:20 12/02/2021 07:20 Hot Start - Gas	61	99.4		
12/03/2021 23:56 12/04/2021 00:00 Shut Down - Gas	5	0.3		
12/04/2021 03:49 12/04/2021 04:46 Hot Start - Gas	58	94.4		
12/04/2021 23:05 12/04/2021 23:10 Shut Down - Gas	6	1.1		

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:11 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,630.20 Hours

Non-Operating Time: 577.80 Hours Report Time: 2,208.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
12/05/2021 07:17 12/05/2021 08:53 Warm Start - Gas	97	157.1		
12/26/2021 00:24 12/26/2021 00:29 Shut Down - Gas	6	0.8		
12/26/2021 10:50 12/26/2021 12:58 Warm Start - Gas	129	186.9		

No excess emissions were found in the reporting period.

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:11 **Location:** Maxwell, CA
Tag Name: CT1_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission
Total Operating Time: 1,630.20 Hours
Non-Operating Time: 577.80 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:11 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,630.20 Hours

Non-Operating Time: 577.80 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/01/2021 00:00	0.0	0	0	0	0	1
10/01/2021 01:00	0.0	0	0	0	0	1
10/01/2021 02:00	0.0	0	0	0	0	1
10/01/2021 03:00	0.0	0	0	0	0	1
10/01/2021 04:00	0.0	0	0	0	0	1
10/01/2021 05:00	0.0	0	0	0	0	1
10/01/2021 06:00	0.0	0	0	0	0	1
10/01/2021 07:00	0.0	0	0	0	0	1
10/01/2021 08:00	0.0	0	0	0	0	1
10/01/2021 09:00	0.0	0	0	0	0	1
10/01/2021 10:00	0.0	0	0	0	0	1
10/01/2021 11:00	0.0	0	0	0	0	1
10/01/2021 12:00	0.0	0	0	0	0	1
10/01/2021 13:00	0.0	0	0	0	0	1
10/01/2021 14:00	0.0	0	0	0	0	1
10/01/2021 15:00	0.0	0	0	0	0	1
10/01/2021 16:00	0.0	0	0	0	0	1
10/01/2021 17:00	0.0	0	0	0	0	1
10/01/2021 18:00	0.0	0	0	0	0	1
10/01/2021 19:00	0.0	0	0	0	0	1
10/01/2021 20:00	0.0	0	0	0	0	1
10/01/2021 21:00	0.0	0	0	0	0	1
10/01/2021 22:00	0.0	0	0	0	0	1
10/01/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/02/2021 00:00	0.0	0	0	0	0	1
10/02/2021 01:00	0.0	0	0	0	0	1
10/02/2021 02:00	0.0	0	0	0	0	1
10/02/2021 03:00	0.0	0	0	0	0	1
10/02/2021 04:00	0.0	0	0	0	0	1
10/02/2021 05:00	0.0	0	0	0	0	1
10/02/2021 06:00	0.0	0	0	0	0	1
10/02/2021 07:00	0.0	0	0	0	0	1
10/02/2021 08:00	0.0	0	0	0	0	1
10/02/2021 09:00	0.0	0	0	0	0	1
10/02/2021 10:00	0.0	0	0	0	0	1
10/02/2021 11:00	0.0	0	0	0	0	1
10/02/2021 12:00	0.0	0	0	0	0	1
10/02/2021 13:00	0.0	0	0	0	0	1
10/02/2021 14:00	0.0	0	0	0	0	1
10/02/2021 15:00	0.0	0	0	0	0	1
10/02/2021 16:00	0.0	0	0	0	0	1
10/02/2021 17:00	0.0	0	0	0	0	1
10/02/2021 18:00	0.0	0	0	0	0	1
10/02/2021 19:00	0.0	0	0	0	0	1
10/02/2021 20:00	0.0	0	0	0	0	1
10/02/2021 21:00	0.0	0	0	0	0	1
10/02/2021 22:00	0.0	0	0	0	0	1
10/02/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/03/2021 00:00	0.0	0	0	0	0	1
10/03/2021 01:00	0.0	0	0	0	0	1
10/03/2021 02:00	0.0	0	0	0	0	1
10/03/2021 03:00	0.0	0	0	0	0	1
10/03/2021 04:00	0.0	0	0	0	0	1
10/03/2021 05:00	0.0	0	0	0	0	1
10/03/2021 06:00	0.0	0	0	0	0	1
10/03/2021 07:00	0.0	0	0	0	0	1
10/03/2021 08:00	0.0	0	0	0	0	1
10/03/2021 09:00	0.0	0	0	0	0	1
10/03/2021 10:00	0.0	0	0	0	0	1
10/03/2021 11:00	0.0	0	0	0	0	1
10/03/2021 12:00	0.0	0	0	0	0	1
10/03/2021 13:00	0.0	0	0	0	0	1
10/03/2021 14:00	0.0	0	0	0	0	1
10/03/2021 15:00	0.0	0	0	0	0	1
10/03/2021 16:00	0.0	0	0	0	0	1
10/03/2021 17:00	0.0	0	0	0	0	1
10/03/2021 18:00	0.0	0	0	0	0	1
10/03/2021 19:00	0.0	0	0	0	0	1
10/03/2021 20:00	0.0	0	0	0	0	1
10/03/2021 21:00	0.0	0	0	0	0	1
10/03/2021 22:00	0.0	0	0	0	0	1
10/03/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/04/2021 00:00	0.0	0	0	0	0	1
10/04/2021 01:00	0.0	0	0	0	0	1
10/04/2021 02:00	0.0	0	0	0	0	1
10/04/2021 03:00	0.0	0	0	0	0	1
10/04/2021 04:00	0.0	0	0	0	0	1
10/04/2021 05:00	0.0	0	0	0	0	1
10/04/2021 06:00	0.0	0	0	0	0	1
10/04/2021 07:00	0.0	0	0	0	0	1
10/04/2021 08:00	0.0	0	0	0	0	1
10/04/2021 09:00	0.0	0	0	0	0	1
10/04/2021 10:00	0.0	0	0	0	0	1
10/04/2021 11:00	0.0	0	0	0	0	1
10/04/2021 12:00	0.0	0	0	0	0	1
10/04/2021 13:00	0.0	0	0	0	0	1
10/04/2021 14:00	0.0	0	0	0	0	1
10/04/2021 15:00	0.0	0	0	0	0	1
10/04/2021 16:00	0.0	0	0	0	0	1
10/04/2021 17:00	0.0	0	0	0	0	1
10/04/2021 18:00	0.0	0	0	0	0	1
10/04/2021 19:00	0.0	0	0	0	0	1
10/04/2021 20:00	0.0	0	0	0	0	1
10/04/2021 21:00	0.0	0	0	0	0	1
10/04/2021 22:00	0.0	0	0	0	0	1
10/04/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/05/2021 00:00	0.0	0	0	0	0	1
10/05/2021 01:00	0.0	0	0	0	0	1
10/05/2021 02:00	0.0	0	0	0	0	1
10/05/2021 03:00	0.0	0	0	0	0	1
10/05/2021 04:00	0.0	0	0	0	0	1
10/05/2021 05:00	0.0	0	0	0	0	1
10/05/2021 06:00	0.0	0	0	0	0	1
10/05/2021 07:00	0.0	0	0	0	0	1
10/05/2021 08:00	0.0	0	0	0	0	1
10/05/2021 09:00	0.0	0	0	0	0	1
10/05/2021 10:00	0.0	0	0	0	0	1
10/05/2021 11:00	0.0	0	0	0	0	1
10/05/2021 12:00	0.0	0	0	0	0	1
10/05/2021 13:00	0.0	0	0	0	0	1
10/05/2021 14:00	0.0	0	0	0	0	1
10/05/2021 15:00	0.0	0	0	0	0	1
10/05/2021 16:00	0.0	0	0	0	0	1
10/05/2021 17:00	0.0	0	0	0	0	1
10/05/2021 18:00	0.0	0	0	0	0	1
10/05/2021 19:00	0.0	0	0	0	0	1
10/05/2021 20:00	0.0	0	0	0	0	1
10/05/2021 21:00	0.0	0	0	0	0	1
10/05/2021 22:00	0.0	0	0	0	0	1
10/05/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/06/2021 00:00	0.0	0	0	0	0	1
10/06/2021 01:00	0.0	0	0	0	0	1
10/06/2021 02:00	0.0	0	0	0	0	1
10/06/2021 03:00	0.0	0	0	0	0	1
10/06/2021 04:00	0.0	0	0	0	0	1
10/06/2021 05:00	0.0	0	0	0	0	1
10/06/2021 06:00	0.0	0	0	0	0	1
10/06/2021 07:00	0.0	0	0	0	0	1
10/06/2021 08:00	0.0	0	0	0	0	1
10/06/2021 09:00	0.0	0	0	0	0	1
10/06/2021 10:00	0.0	0	0	0	0	1
10/06/2021 11:00	0.0	0	0	0	0	1
10/06/2021 12:00	0.0	0	0	0	0	1
10/06/2021 13:00	0.0	0	0	0	0	1
10/06/2021 14:00	0.0	0	0	0	0	1
10/06/2021 15:00	0.0	0	0	0	0	1
10/06/2021 16:00	0.0	0	0	0	0	1
10/06/2021 17:00	0.0	0	0	0	0	1
10/06/2021 18:00	0.0	0	0	0	0	1
10/06/2021 19:00	0.0	0	0	0	0	1
10/06/2021 20:00	0.0	0	0	0	0	1
10/06/2021 21:00	0.0	0	0	0	0	1
10/06/2021 22:00	0.0	0	0	0	0	1
10/06/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/07/2021 00:00	0.0	0	0	0	0	1
10/07/2021 01:00	0.0	0	0	0	0	1
10/07/2021 02:00	0.0	0	0	0	0	1
10/07/2021 03:00	0.0	0	0	0	0	1
10/07/2021 04:00	0.0	0	0	0	0	1
10/07/2021 05:00	0.0	0	0	0	0	1
10/07/2021 06:00	0.0	0	0	0	0	1
10/07/2021 07:00	0.0	0	0	0	0	1
10/07/2021 08:00	0.0	0	0	0	0	1
10/07/2021 09:00	0.0	0	0	0	0	1
10/07/2021 10:00	0.0	0	0	0	0	1
10/07/2021 11:00	0.0	0	0	0	0	1
10/07/2021 12:00	0.0	0	0	0	0	1
10/07/2021 13:00	0.0	0	0	0	0	1
10/07/2021 14:00	0.0	0	0	0	0	1
10/07/2021 15:00	0.0	0	0	0	0	1
10/07/2021 16:00	0.0	0	0	0	0	1
10/07/2021 17:00	0.0	0	0	0	0	1
10/07/2021 18:00	0.0	0	0	0	0	1
10/07/2021 19:00	0.0	0	0	0	0	1
10/07/2021 20:00	0.0	0	0	0	0	1
10/07/2021 21:00	0.0	0	0	0	0	1
10/07/2021 22:00	0.0	0	0	0	0	1
10/07/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/08/2021 00:00	0.0	0	0	0	0	1
10/08/2021 01:00	0.0	0	0	0	0	1
10/08/2021 02:00	0.0	0	0	0	0	1
10/08/2021 03:00	0.0	0	0	0	0	1
10/08/2021 04:00	0.0	0	0	0	0	1
10/08/2021 05:00	0.0	0	0	0	0	1
10/08/2021 06:00	0.0	0	0	0	0	1
10/08/2021 07:00	0.0	0	0	0	0	1
10/08/2021 08:00	0.0	0	0	0	0	1
10/08/2021 09:00	0.0	0	0	0	0	1
10/08/2021 10:00	0.0	0	0	0	0	1
10/08/2021 11:00	0.0	0	0	0	0	1
10/08/2021 12:00	0.0	0	0	0	0	1
10/08/2021 13:00	0.0	0	0	0	0	1
10/08/2021 14:00	0.0	0	0	0	0	1
10/08/2021 15:00	0.0	0	0	0	0	1
10/08/2021 16:00	0.0	0	0	0	0	1
10/08/2021 17:00	0.0	0	0	0	0	1
10/08/2021 18:00	0.0	0	0	0	0	1
10/08/2021 19:00	0.0	0	0	0	0	1
10/08/2021 20:00	0.0	0	0	0	0	1
10/08/2021 21:00	3.4	0	0	0	1	0
10/08/2021 22:00	0.0	0	0	0	0	0
10/08/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	3.4 #	0 #	0 #	0 #	1 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3.4	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/09/2021 00:00	0.0	0	0	0	0	0
10/09/2021 01:00	0.0	0	0	0	0	0
10/09/2021 02:00	0.0	0	0	0	0	0
10/09/2021 03:00	0.0	0	0	0	0	0
10/09/2021 04:00	0.0	0	0	0	0	0
10/09/2021 05:00	0.0	0	0	0	0	0
10/09/2021 06:00	0.0	0	0	0	0	0
10/09/2021 07:00	0.0	0	0	0	0	0
10/09/2021 08:00	0.0	0	0	0	0	0
10/09/2021 09:00	0.0	0	0	0	0	0
10/09/2021 10:00	0.0	0	0	0	0	0
10/09/2021 11:00	0.0	0	0	0	0	0
10/09/2021 12:00	0.0	0	0	0	0	0
10/09/2021 13:00	0.0	0	0	0	0	0
10/09/2021 14:00	0.0	0	0	0	0	0
10/09/2021 15:00	0.0	0	0	0	0	0
10/09/2021 16:00	0.0	0	0	0	0	0
10/09/2021 17:00	0.0	0	0	0	0	0
10/09/2021 18:00	0.0	0	0	0	0	0
10/09/2021 19:00	0.0	0	0	0	0	0
10/09/2021 20:00	0.0	0	0	0	0	0
10/09/2021 21:00	0.0	0	0	0	0	0
10/09/2021 22:00	0.0	0	0	0	0	0
10/09/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/10/2021 00:00	0.0	0	0	0	0	0
10/10/2021 01:00	0.0	0	0	0	0	0
10/10/2021 02:00	0.0	0	0	0	0	0
10/10/2021 03:00	0.0	0	0	0	0	0
10/10/2021 04:00	0.0	0	0	0	0	0
10/10/2021 05:00	0.0	0	0	0	0	0
10/10/2021 06:00	0.0	0	0	0	0	0
10/10/2021 07:00	0.0	0	0	0	0	0
10/10/2021 08:00	0.0	0	0	0	0	0
10/10/2021 09:00	0.0	0	0	0	0	0
10/10/2021 10:00	0.0	0	0	0	0	0
10/10/2021 11:00	0.0	0	0	0	0	0
10/10/2021 12:00	0.0	0	0	0	0	0
10/10/2021 13:00	0.0	0	0	0	0	0
10/10/2021 14:00	0.0	0	0	0	0	0
10/10/2021 15:00	0.0	0	0	0	0	0
10/10/2021 16:00	0.0	0	0	0	0	0
10/10/2021 17:00	0.0	0	0	0	0	0
10/10/2021 18:00	0.0	0	0	0	0	0
10/10/2021 19:00	0.0	0	0	0	0	0
10/10/2021 20:00	0.0	0	0	0	0	0
10/10/2021 21:00	0.0	0	0	0	0	0
10/10/2021 22:00	0.0	0	0	0	0	0
10/10/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/11/2021 00:00	0.0	0	0	0	0	0
10/11/2021 01:00	0.0	0	0	0	0	0
10/11/2021 02:00	0.0	0	0	0	0	0
10/11/2021 03:00	0.0	0	0	0	0	0
10/11/2021 04:00	0.0	0	0	0	0	0
10/11/2021 05:00	0.0	0	0	0	0	0
10/11/2021 06:00	0.0	0	0	0	0	0
10/11/2021 07:00	0.0	0	0	0	0	0
10/11/2021 08:00	0.0	0	0	0	0	0
10/11/2021 09:00	0.0	0	0	0	0	0
10/11/2021 10:00	0.0	0	0	0	0	0
10/11/2021 11:00	0.0	0	0	0	0	0
10/11/2021 12:00	0.0	0	0	0	0	0
10/11/2021 13:00	0.0	0	0	0	0	0
10/11/2021 14:00	0.0	0	0	0	0	0
10/11/2021 15:00	0.0	0	0	0	0	0
10/11/2021 16:00	0.0	0	0	0	0	0
10/11/2021 17:00	0.0	0	0	0	0	0
10/11/2021 18:00	0.0	0	0	0	0	0
10/11/2021 19:00	0.0	0	0	0	0	0
10/11/2021 20:00	0.0	0	0	0	0	0
10/11/2021 21:00	0.0	0	0	0	0	0
10/11/2021 22:00	0.0	0	0	0	0	0
10/11/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/12/2021 00:00	0.0	0	0	0	0	0
10/12/2021 01:00	0.0	0	0	0	0	0
10/12/2021 02:00	0.0	0	0	0	0	0
10/12/2021 03:00	0.0	0	0	0	0	0
10/12/2021 04:00	0.0	0	0	0	0	0
10/12/2021 05:00	0.0	0	0	0	0	0
10/12/2021 06:00	0.0	0	0	0	0	0
10/12/2021 07:00	0.0	0	0	0	0	0
10/12/2021 08:00	0.0	0	0	0	0	0
10/12/2021 09:00	0.0	0	0	0	0	0
10/12/2021 10:00	0.0	0	0	0	0	0
10/12/2021 11:00	0.0	0	0	0	0	0
10/12/2021 12:00	0.0	0	0	0	0	0
10/12/2021 13:00	0.0	0	0	0	0	0
10/12/2021 14:00	0.0	0	0	0	0	0
10/12/2021 15:00	0.0	0	0	0	0	0
10/12/2021 16:00	0.0	0	0	0	0	0
10/12/2021 17:00	0.0	0	0	0	0	0
10/12/2021 18:00	0.0	0	0	0	0	0
10/12/2021 19:00	0.0	0	0	0	0	0
10/12/2021 20:00	0.0	0	0	0	0	0
10/12/2021 21:00	0.0	0	0	0	0	0
10/12/2021 22:00	0.0	0	0	0	0	0
10/12/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/13/2021 00:00	0.0	0	0	0	0	0
10/13/2021 01:00	0.0	0	0	0	0	0
10/13/2021 02:00	0.0	0	0	0	0	0
10/13/2021 03:00	0.0	0	0	0	0	0
10/13/2021 04:00	0.0	0	0	0	0	0
10/13/2021 05:00	0.0	0	0	0	0	0
10/13/2021 06:00	0.0	0	0	0	0	0
10/13/2021 07:00	0.0	0	0	0	0	0
10/13/2021 08:00	0.0	0	0	0	0	0
10/13/2021 09:00	0.0	0	0	0	0	0
10/13/2021 10:00	0.0	0	0	0	0	0
10/13/2021 11:00	0.0	0	0	0	0	0
10/13/2021 12:00	0.0	0	0	0	0	0
10/13/2021 13:00	0.0	0	0	0	0	0
10/13/2021 14:00	0.0	0	0	0	0	0
10/13/2021 15:00	0.0	0	0	0	0	0
10/13/2021 16:00	0.0	0	0	0	0	0
10/13/2021 17:00	0.0	0	0	0	0	0
10/13/2021 18:00	0.0	0	0	0	0	0
10/13/2021 19:00	0.0	0	0	0	0	0
10/13/2021 20:00	0.0	0	0	0	0	0
10/13/2021 21:00	0.0	0	0	0	0	0
10/13/2021 22:00	0.0	0	0	0	0	0
10/13/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/14/2021 00:00	0.0	0	0	0	0	0
10/14/2021 01:00	0.0	0	0	0	0	0
10/14/2021 02:00	0.0	0	0	0	0	0
10/14/2021 03:00	0.0	0	0	0	0	0
10/14/2021 04:00	0.0	0	0	0	0	0
10/14/2021 05:00	0.0	0	0	0	0	0
10/14/2021 06:00	0.0	0	0	0	0	0
10/14/2021 07:00	0.0	0	0	0	0	0
10/14/2021 08:00	0.0	0	0	0	0	0
10/14/2021 09:00	0.0	0	0	0	0	0
10/14/2021 10:00	0.0	0	0	0	0	0
10/14/2021 11:00	0.0	0	0	0	0	0
10/14/2021 12:00	0.0	0	0	0	0	0
10/14/2021 13:00	0.0	0	0	0	0	0
10/14/2021 14:00	0.0	0	0	0	0	0
10/14/2021 15:00	0.0	0	0	0	0	0
10/14/2021 16:00	0.0	0	0	0	0	0
10/14/2021 17:00	0.0	0	0	0	0	0
10/14/2021 18:00	0.0	0	0	0	0	0
10/14/2021 19:00	0.0	0	0	0	0	0
10/14/2021 20:00	0.0	0	0	0	0	0
10/14/2021 21:00	0.0	0	0	0	0	0
10/14/2021 22:00	0.0	0	0	0	0	0
10/14/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/15/2021 00:00	0.0	0	0	0	0	0
10/15/2021 01:00	0.0	0	0	0	0	0
10/15/2021 02:00	0.0	0	0	0	0	0
10/15/2021 03:00	0.0	0	0	0	0	0
10/15/2021 04:00	0.0	0	0	0	0	0
10/15/2021 05:00	0.0	0	0	0	0	0
10/15/2021 06:00	0.0	0	0	0	0	0
10/15/2021 07:00	0.0	0	0	0	0	0
10/15/2021 08:00	0.0	0	0	0	0	0
10/15/2021 09:00	0.0	0	0	0	0	0
10/15/2021 10:00	0.0	0	0	0	0	0
10/15/2021 11:00	0.0	0	0	0	0	0
10/15/2021 12:00	0.0	0	0	0	0	0
10/15/2021 13:00	0.0	0	0	0	0	0
10/15/2021 14:00	0.0	0	0	0	0	0
10/15/2021 15:00	0.0	0	0	0	0	0
10/15/2021 16:00	0.0	0	0	0	0	0
10/15/2021 17:00	0.0	0	0	0	0	0
10/15/2021 18:00	0.0	0	0	0	0	0
10/15/2021 19:00	0.0	0	0	0	0	0
10/15/2021 20:00	0.0	0	0	0	0	0
10/15/2021 21:00	0.0	0	0	0	0	0
10/15/2021 22:00	0.0	0	0	0	0	0
10/15/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/16/2021 00:00	0.0	0	0	0	0	0
10/16/2021 01:00	0.0	0	0	0	0	0
10/16/2021 02:00	0.0	0	0	0	0	0
10/16/2021 03:00	0.0	0	0	0	0	0
10/16/2021 04:00	0.0	0	0	0	0	0
10/16/2021 05:00	0.0	0	0	0	0	0
10/16/2021 06:00	0.0	0	0	0	0	0
10/16/2021 07:00	0.0	0	0	0	0	0
10/16/2021 08:00	0.0	0	0	0	0	0
10/16/2021 09:00	0.0	0	0	0	0	0
10/16/2021 10:00	0.0	0	0	0	0	0
10/16/2021 11:00	0.0	0	0	0	0	0
10/16/2021 12:00	0.0	0	0	0	0	0
10/16/2021 13:00	0.0	0	0	0	0	0
10/16/2021 14:00	0.0	0	0	0	0	0
10/16/2021 15:00	0.0	0	0	0	0	0
10/16/2021 16:00	0.0	0	0	0	0	0
10/16/2021 17:00	0.0	0	0	0	0	0
10/16/2021 18:00	0.0	0	0	0	0	0
10/16/2021 19:00	0.0	0	0	0	0	0
10/16/2021 20:00	0.0	0	0	0	0	0
10/16/2021 21:00	0.0	0	0	0	0	0
10/16/2021 22:00	0.0	0	0	0	0	0
10/16/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/17/2021 00:00	0.0	0	0	0	0	0
10/17/2021 01:00	0.0	0	0	0	0	0
10/17/2021 02:00	0.0	0	0	0	0	0
10/17/2021 03:00	0.0	0	0	0	0	0
10/17/2021 04:00	0.0	0	0	0	0	0
10/17/2021 05:00	0.0	0	0	0	0	0
10/17/2021 06:00	0.0	0	0	0	0	0
10/17/2021 07:00	0.0	0	0	0	0	0
10/17/2021 08:00	0.0	0	0	0	0	0
10/17/2021 09:00	0.0	0	0	0	0	0
10/17/2021 10:00	0.0	0	0	0	0	0
10/17/2021 11:00	0.0	0	0	0	0	0
10/17/2021 12:00	0.0	0	0	0	0	0
10/17/2021 13:00	0.0	0	0	0	0	0
10/17/2021 14:00	0.0	0	0	0	0	0
10/17/2021 15:00	0.0	0	0	0	0	0
10/17/2021 16:00	0.0	0	0	0	0	0
10/17/2021 17:00	0.0	0	0	0	0	0
10/17/2021 18:00	0.0	0	0	0	0	0
10/17/2021 19:00	0.0	0	0	0	0	0
10/17/2021 20:00	0.0	0	0	0	0	0
10/17/2021 21:00	0.0	0	0	0	0	0
10/17/2021 22:00	0.0	0	0	0	0	0
10/17/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/18/2021 00:00	0.0	0	0	0	0	0
10/18/2021 01:00	0.0	0	0	0	0	0
10/18/2021 02:00	0.0	0	0	0	0	0
10/18/2021 03:00	0.0	0	0	0	0	0
10/18/2021 04:00	0.0	0	0	0	0	0
10/18/2021 05:00	0.0	0	0	0	0	0
10/18/2021 06:00	0.0	0	0	0	0	0
10/18/2021 07:00	0.0	0	0	0	0	0
10/18/2021 08:00	0.0	0	0	0	0	0
10/18/2021 09:00	0.0	0	0	0	0	0
10/18/2021 10:00	0.0	0	0	0	0	0
10/18/2021 11:00	0.0	0	0	0	0	0
10/18/2021 12:00	0.0	0	0	0	0	0
10/18/2021 13:00	0.0	0	0	0	0	0
10/18/2021 14:00	0.0	0	0	0	0	0
10/18/2021 15:00	0.0	0	0	0	0	0
10/18/2021 16:00	0.0	0	0	0	0	0
10/18/2021 17:00	0.0	0	0	0	0	0
10/18/2021 18:00	0.0	0	0	0	0	0
10/18/2021 19:00	0.0	0	0	0	0	0
10/18/2021 20:00	0.0	0	0	0	0	0
10/18/2021 21:00	0.0	0	0	0	0	0
10/18/2021 22:00	0.0	0	0	0	0	0
10/18/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/19/2021 00:00	0.0	0	0	0	0	0
10/19/2021 01:00	0.0	0	0	0	0	0
10/19/2021 02:00	0.0	0	0	0	0	0
10/19/2021 03:00	0.0	0	0	0	0	0
10/19/2021 04:00	0.0	0	0	0	0	0
10/19/2021 05:00	0.0	0	0	0	0	0
10/19/2021 06:00	0.0	0	0	0	0	0
10/19/2021 07:00	0.0	0	0	0	0	0
10/19/2021 08:00	0.0	0	0	0	0	0
10/19/2021 09:00	0.0	0	0	0	0	0
10/19/2021 10:00	0.0	0	0	0	0	0
10/19/2021 11:00	0.0	0	0	0	0	0
10/19/2021 12:00	0.0	0	0	0	0	0
10/19/2021 13:00	0.0	0	0	0	0	0
10/19/2021 14:00	0.0	0	0	0	0	0
10/19/2021 15:00	0.0	0	0	0	0	0
10/19/2021 16:00	0.0	0	0	0	0	0
10/19/2021 17:00	0.0	0	0	0	0	0
10/19/2021 18:00	0.0	0	0	0	0	0
10/19/2021 19:00	0.0	0	0	0	0	0
10/19/2021 20:00	0.0	0	0	0	0	0
10/19/2021 21:00	0.0	0	0	0	0	0
10/19/2021 22:00	0.0	0	0	0	0	0
10/19/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/20/2021 00:00	0.0	0	0	0	0	0
10/20/2021 01:00	0.0	0	0	0	0	0
10/20/2021 02:00	0.0	0	0	0	0	0
10/20/2021 03:00	0.0	0	0	0	0	0
10/20/2021 04:00	0.0	0	0	0	0	0
10/20/2021 05:00	0.0	0	0	0	0	0
10/20/2021 06:00	0.0	0	0	0	0	0
10/20/2021 07:00	0.0	0	0	0	0	0
10/20/2021 08:00	0.0	0	0	0	0	0
10/20/2021 09:00	0.0	0	0	0	0	0
10/20/2021 10:00	0.0	0	0	0	0	0
10/20/2021 11:00	0.0	0	0	0	0	0
10/20/2021 12:00	0.0	0	0	0	0	0
10/20/2021 13:00	77.0	1	0	0	0	0
10/20/2021 14:00	74.3	1	0	0	0	0
10/20/2021 15:00	0.9	1	0	0	0	0
10/20/2021 16:00	0.0	0	0	0	0	1
10/20/2021 17:00	0.0	0	0	0	0	1
10/20/2021 18:00	0.0	0	0	0	0	1
10/20/2021 19:00	0.0	0	0	0	0	1
10/20/2021 20:00	0.0	0	0	0	0	1
10/20/2021 21:00	0.0	0	0	0	0	1
10/20/2021 22:00	2.9	0	0	0	1	0
10/20/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	155.1 #	3 #	0 #	0 #	1 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	77.0	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/21/2021 00:00	0.0	0	0	0	0	0
10/21/2021 01:00	0.0	0	0	0	0	0
10/21/2021 02:00	0.0	0	0	0	0	0
10/21/2021 03:00	0.0	0	0	0	0	0
10/21/2021 04:00	0.0	0	0	0	0	0
10/21/2021 05:00	0.0	0	0	0	0	0
10/21/2021 06:00	0.0	0	0	0	0	0
10/21/2021 07:00	0.0	0	0	0	0	0
10/21/2021 08:00	0.0	0	0	0	0	0
10/21/2021 09:00	0.0	0	0	0	0	0
10/21/2021 10:00	0.0	0	0	0	0	0
10/21/2021 11:00	0.0	0	0	0	0	0
10/21/2021 12:00	0.0	0	0	0	0	0
10/21/2021 13:00	0.0	0	0	0	0	0
10/21/2021 14:00	0.0	0	0	0	0	0
10/21/2021 15:00	0.0	0	0	0	0	0
10/21/2021 16:00	0.0	0	0	0	0	0
10/21/2021 17:00	0.0	0	0	0	0	0
10/21/2021 18:00	0.0	0	0	0	0	0
10/21/2021 19:00	0.0	0	0	0	0	0
10/21/2021 20:00	0.0	0	0	0	0	0
10/21/2021 21:00	0.0	0	0	0	0	0
10/21/2021 22:00	0.0	0	0	0	0	0
10/21/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/22/2021 00:00	0.0	0	0	0	0	0
10/22/2021 01:00	0.0	0	0	0	0	0
10/22/2021 02:00	0.0	0	0	0	0	0
10/22/2021 03:00	0.0	0	0	0	0	0
10/22/2021 04:00	0.0	0	0	0	0	0
10/22/2021 05:00	0.0	0	0	0	0	0
10/22/2021 06:00	0.0	0	0	0	0	0
10/22/2021 07:00	0.0	0	0	0	0	0
10/22/2021 08:00	0.0	0	0	0	0	0
10/22/2021 09:00	0.0	0	0	0	0	0
10/22/2021 10:00	0.0	0	0	0	0	0
10/22/2021 11:00	0.0	0	0	0	0	0
10/22/2021 12:00	0.0	0	0	0	0	0
10/22/2021 13:00	0.0	0	0	0	0	0
10/22/2021 14:00	0.0	0	0	0	0	0
10/22/2021 15:00	0.0	0	0	0	0	0
10/22/2021 16:00	0.0	0	0	0	0	0
10/22/2021 17:00	0.0	0	0	0	0	0
10/22/2021 18:00	0.0	0	0	0	0	0
10/22/2021 19:00	0.0	0	0	0	0	0
10/22/2021 20:00	0.0	0	0	0	0	0
10/22/2021 21:00	0.0	0	0	0	0	0
10/22/2021 22:00	0.0	0	0	0	0	0
10/22/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/23/2021 00:00	0.0	0	0	0	0	0
10/23/2021 01:00	74.2	0	1	0	0	0
10/23/2021 02:00	34.8	0	1	0	0	0
10/23/2021 03:00	98.0	0	1	0	0	0
10/23/2021 04:00	0.0	0	0	0	0	1
10/23/2021 05:00	0.0	0	0	0	0	1
10/23/2021 06:00	0.0	0	0	0	0	1
10/23/2021 07:00	0.0	0	0	0	0	1
10/23/2021 08:00	0.0	0	0	0	0	1
10/23/2021 09:00	0.0	0	0	0	0	1
10/23/2021 10:00	0.0	0	0	0	0	1
10/23/2021 11:00	0.0	0	0	0	0	1
10/23/2021 12:00	0.0	0	0	0	0	1
10/23/2021 13:00	0.0	0	0	0	0	1
10/23/2021 14:00	0.0	0	0	0	0	1
10/23/2021 15:00	0.0	0	0	0	0	1
10/23/2021 16:00	0.0	0	0	0	0	1
10/23/2021 17:00	0.0	0	0	0	0	1
10/23/2021 18:00	0.0	0	0	0	0	1
10/23/2021 19:00	0.0	0	0	0	0	1
10/23/2021 20:00	0.0	0	0	0	0	1
10/23/2021 21:00	0.0	0	0	0	0	1
10/23/2021 22:00	2.2	0	0	0	1	0
10/23/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	209.2 #	0 #	3 #	0 #	1 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	98.0	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/24/2021 00:00	0.0	0	0	0	0	0
10/24/2021 01:00	0.0	0	0	0	0	0
10/24/2021 02:00	0.0	0	0	0	0	0
10/24/2021 03:00	0.0	0	0	0	0	0
10/24/2021 04:00	0.0	0	0	0	0	0
10/24/2021 05:00	0.0	0	0	0	0	0
10/24/2021 06:00	0.0	0	0	0	0	0
10/24/2021 07:00	30.7	0	1	0	0	0
10/24/2021 08:00	71.4	0	1	0	0	0
10/24/2021 09:00	0.0	0	0	0	0	1
10/24/2021 10:00	0.0	0	0	0	0	1
10/24/2021 11:00	0.0	0	0	0	0	1
10/24/2021 12:00	0.0	0	0	0	0	1
10/24/2021 13:00	0.0	0	0	0	0	1
10/24/2021 14:00	0.0	0	0	0	0	1
10/24/2021 15:00	0.0	0	0	0	0	1
10/24/2021 16:00	0.0	0	0	0	0	1
10/24/2021 17:00	0.0	0	0	0	0	1
10/24/2021 18:00	0.0	0	0	0	0	1
10/24/2021 19:00	0.0	0	0	0	0	1
10/24/2021 20:00	0.0	0	0	0	0	1
10/24/2021 21:00	0.0	0	0	0	0	1
10/24/2021 22:00	0.0	0	0	0	0	1
10/24/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	102.1 #	0 #	2 #	0 #	0 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	71.4	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/25/2021 00:00	0.0	0	0	0	0	1
10/25/2021 01:00	0.0	0	0	0	0	1
10/25/2021 02:00	0.0	0	0	0	0	1
10/25/2021 03:00	0.0	0	0	0	0	1
10/25/2021 04:00	0.0	0	0	0	0	1
10/25/2021 05:00	0.0	0	0	0	0	1
10/25/2021 06:00	0.0	0	0	0	0	1
10/25/2021 07:00	0.0	0	0	0	0	1
10/25/2021 08:00	0.0	0	0	0	0	1
10/25/2021 09:00	0.0	0	0	0	0	1
10/25/2021 10:00	0.0	0	0	0	0	1
10/25/2021 11:00	0.0	0	0	0	0	1
10/25/2021 12:00	0.0	0	0	0	0	1
10/25/2021 13:00	0.0	0	0	0	0	1
10/25/2021 14:00	0.0	0	0	0	0	1
10/25/2021 15:00	0.0	0	0	0	0	1
10/25/2021 16:00	0.0	0	0	0	0	1
10/25/2021 17:00	0.0	0	0	0	0	1
10/25/2021 18:00	0.0	0	0	0	0	1
10/25/2021 19:00	0.0	0	0	0	0	1
10/25/2021 20:00	0.0	0	0	0	0	1
10/25/2021 21:00	0.0	0	0	0	0	1
10/25/2021 22:00	0.0	0	0	0	0	1
10/25/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/26/2021 00:00	0.0	0	0	0	0	1
10/26/2021 01:00	0.0	0	0	0	0	1
10/26/2021 02:00	0.0	0	0	0	0	1
10/26/2021 03:00	0.0	0	0	0	0	1
10/26/2021 04:00	0.0	0	0	0	0	1
10/26/2021 05:00	0.0	0	0	0	0	1
10/26/2021 06:00	0.0	0	0	0	0	1
10/26/2021 07:00	0.0	0	0	0	0	1
10/26/2021 08:00	0.0	0	0	0	0	1
10/26/2021 09:00	0.0	0	0	0	0	1
10/26/2021 10:00	0.0	0	0	0	0	1
10/26/2021 11:00	0.0	0	0	0	0	1
10/26/2021 12:00	0.0	0	0	0	0	1
10/26/2021 13:00	0.0	0	0	0	0	1
10/26/2021 14:00	0.0	0	0	0	0	1
10/26/2021 15:00	0.0	0	0	0	0	1
10/26/2021 16:00	0.0	0	0	0	0	1
10/26/2021 17:00	0.0	0	0	0	0	1
10/26/2021 18:00	0.0	0	0	0	0	1
10/26/2021 19:00	0.0	0	0	0	0	1
10/26/2021 20:00	0.0	0	0	0	0	1
10/26/2021 21:00	0.0	0	0	0	0	1
10/26/2021 22:00	0.0	0	0	0	0	1
10/26/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/27/2021 00:00	0.0	0	0	0	0	1
10/27/2021 01:00	0.0	0	0	0	0	1
10/27/2021 02:00	0.0	0	0	0	0	1
10/27/2021 03:00	0.0	0	0	0	0	1
10/27/2021 04:00	0.0	0	0	0	0	1
10/27/2021 05:00	0.0	0	0	0	0	1
10/27/2021 06:00	0.0	0	0	0	0	1
10/27/2021 07:00	0.0	0	0	0	0	1
10/27/2021 08:00	0.0	0	0	0	0	1
10/27/2021 09:00	0.0	0	0	0	0	1
10/27/2021 10:00	0.0	0	0	0	0	1
10/27/2021 11:00	0.0	0	0	0	0	1
10/27/2021 12:00	0.0	0	0	0	0	1
10/27/2021 13:00	0.0	0	0	0	0	1
10/27/2021 14:00	0.0	0	0	0	0	1
10/27/2021 15:00	0.0	0	0	0	0	1
10/27/2021 16:00	0.0	0	0	0	0	1
10/27/2021 17:00	0.0	0	0	0	0	1
10/27/2021 18:00	0.0	0	0	0	0	1
10/27/2021 19:00	0.0	0	0	0	0	1
10/27/2021 20:00	0.0	0	0	0	0	1
10/27/2021 21:00	0.0	0	0	0	0	1
10/27/2021 22:00	0.0	0	0	0	0	1
10/27/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/28/2021 00:00	0.0	0	0	0	0	1
10/28/2021 01:00	0.0	0	0	0	0	1
10/28/2021 02:00	0.0	0	0	0	0	1
10/28/2021 03:00	0.0	0	0	0	0	1
10/28/2021 04:00	0.0	0	0	0	0	1
10/28/2021 05:00	0.0	0	0	0	0	1
10/28/2021 06:00	0.0	0	0	0	0	1
10/28/2021 07:00	0.0	0	0	0	0	1
10/28/2021 08:00	0.0	0	0	0	0	1
10/28/2021 09:00	0.0	0	0	0	0	1
10/28/2021 10:00	0.0	0	0	0	0	1
10/28/2021 11:00	0.0	0	0	0	0	1
10/28/2021 12:00	0.0	0	0	0	0	1
10/28/2021 13:00	0.0	0	0	0	0	1
10/28/2021 14:00	0.0	0	0	0	0	1
10/28/2021 15:00	0.0	0	0	0	0	1
10/28/2021 16:00	0.0	0	0	0	0	1
10/28/2021 17:00	0.0	0	0	0	0	1
10/28/2021 18:00	0.0	0	0	0	0	1
10/28/2021 19:00	0.0	0	0	0	0	1
10/28/2021 20:00	0.0	0	0	0	0	1
10/28/2021 21:00	0.0	0	0	0	0	1
10/28/2021 22:00	0.0	0	0	0	0	1
10/28/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/29/2021 00:00	0.0	0	0	0	0	1
10/29/2021 01:00	0.0	0	0	0	0	1
10/29/2021 02:00	0.0	0	0	0	0	1
10/29/2021 03:00	0.0	0	0	0	0	1
10/29/2021 04:00	0.0	0	0	0	0	1
10/29/2021 05:00	0.0	0	0	0	0	1
10/29/2021 06:00	0.0	0	0	0	0	1
10/29/2021 07:00	0.0	0	0	0	0	1
10/29/2021 08:00	0.0	0	0	0	0	1
10/29/2021 09:00	0.0	0	0	0	0	1
10/29/2021 10:00	0.0	0	0	0	0	1
10/29/2021 11:00	0.0	0	0	0	0	1
10/29/2021 12:00	0.0	0	0	0	0	1
10/29/2021 13:00	0.0	0	0	0	0	1
10/29/2021 14:00	0.0	0	0	0	0	1
10/29/2021 15:00	0.0	0	0	0	0	1
10/29/2021 16:00	0.0	0	0	0	0	1
10/29/2021 17:00	0.0	0	0	0	0	1
10/29/2021 18:00	0.0	0	0	0	0	1
10/29/2021 19:00	0.0	0	0	0	0	1
10/29/2021 20:00	0.0	0	0	0	0	1
10/29/2021 21:00	0.0	0	0	0	0	1
10/29/2021 22:00	0.0	0	0	0	0	1
10/29/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/30/2021 00:00	0.0	0	0	0	0	1
10/30/2021 01:00	0.0	0	0	0	0	1
10/30/2021 02:00	0.0	0	0	0	0	1
10/30/2021 03:00	0.0	0	0	0	0	1
10/30/2021 04:00	0.0	0	0	0	0	1
10/30/2021 05:00	0.0	0	0	0	0	1
10/30/2021 06:00	0.0	0	0	0	0	1
10/30/2021 07:00	0.0	0	0	0	0	1
10/30/2021 08:00	0.0	0	0	0	0	1
10/30/2021 09:00	0.0	0	0	0	0	1
10/30/2021 10:00	0.0	0	0	0	0	1
10/30/2021 11:00	0.0	0	0	0	0	1
10/30/2021 12:00	0.0	0	0	0	0	1
10/30/2021 13:00	0.0	0	0	0	0	1
10/30/2021 14:00	0.0	0	0	0	0	1
10/30/2021 15:00	0.0	0	0	0	0	1
10/30/2021 16:00	0.0	0	0	0	0	1
10/30/2021 17:00	0.0	0	0	0	0	1
10/30/2021 18:00	0.0	0	0	0	0	1
10/30/2021 19:00	0.0	0	0	0	0	1
10/30/2021 20:00	0.0	0	0	0	0	1
10/30/2021 21:00	0.0	0	0	0	0	1
10/30/2021 22:00	0.0	0	0	0	0	1
10/30/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/31/2021 00:00	0.0	0	0	0	0	1
10/31/2021 01:00	0.0	0	0	0	0	1
10/31/2021 02:00	0.0	0	0	0	0	1
10/31/2021 03:00	0.0	0	0	0	0	1
10/31/2021 04:00	0.0	0	0	0	0	1
10/31/2021 05:00	0.0	0	0	0	0	1
10/31/2021 06:00	0.0	0	0	0	0	1
10/31/2021 07:00	0.0	0	0	0	0	1
10/31/2021 08:00	0.0	0	0	0	0	1
10/31/2021 09:00	0.0	0	0	0	0	1
10/31/2021 10:00	0.0	0	0	0	0	1
10/31/2021 11:00	0.0	0	0	0	0	1
10/31/2021 12:00	0.0	0	0	0	0	1
10/31/2021 13:00	0.0	0	0	0	0	1
10/31/2021 14:00	0.0	0	0	0	0	1
10/31/2021 15:00	0.0	0	0	0	0	1
10/31/2021 16:00	0.0	0	0	0	0	1
10/31/2021 17:00	0.0	0	0	0	0	1
10/31/2021 18:00	0.0	0	0	0	0	1
10/31/2021 19:00	0.0	0	0	0	0	1
10/31/2021 20:00	0.0	0	0	0	0	1
10/31/2021 21:00	0.0	0	0	0	0	1
10/31/2021 22:00	0.0	0	0	0	0	1
10/31/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/01/2021 00:00	0.0	0	0	0	0	1
11/01/2021 01:00	0.0	0	0	0	0	1
11/01/2021 02:00	0.0	0	0	0	0	1
11/01/2021 03:00	0.0	0	0	0	0	1
11/01/2021 04:00	0.0	0	0	0	0	1
11/01/2021 05:00	0.0	0	0	0	0	1
11/01/2021 06:00	0.0	0	0	0	0	1
11/01/2021 07:00	0.0	0	0	0	0	1
11/01/2021 08:00	0.0	0	0	0	0	1
11/01/2021 09:00	0.0	0	0	0	0	1
11/01/2021 10:00	0.0	0	0	0	0	1
11/01/2021 11:00	0.0	0	0	0	0	1
11/01/2021 12:00	0.0	0	0	0	0	1
11/01/2021 13:00	0.0	0	0	0	0	1
11/01/2021 14:00	0.0	0	0	0	0	1
11/01/2021 15:00	0.0	0	0	0	0	1
11/01/2021 16:00	0.0	0	0	0	0	1
11/01/2021 17:00	0.0	0	0	0	0	1
11/01/2021 18:00	0.0	0	0	0	0	1
11/01/2021 19:00	0.0	0	0	0	0	1
11/01/2021 20:00	0.0	0	0	0	0	1
11/01/2021 21:00	0.0	0	0	0	0	1
11/01/2021 22:00	0.0	0	0	0	0	1
11/01/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/02/2021 00:00	0.0	0	0	0	0	1
11/02/2021 01:00	0.0	0	0	0	0	1
11/02/2021 02:00	0.0	0	0	0	0	1
11/02/2021 03:00	0.0	0	0	0	0	1
11/02/2021 04:00	0.0	0	0	0	0	1
11/02/2021 05:00	0.0	0	0	0	0	1
11/02/2021 06:00	0.0	0	0	0	0	1
11/02/2021 07:00	0.0	0	0	0	0	1
11/02/2021 08:00	0.0	0	0	0	0	1
11/02/2021 09:00	0.0	0	0	0	0	1
11/02/2021 10:00	0.0	0	0	0	0	1
11/02/2021 11:00	0.0	0	0	0	0	1
11/02/2021 12:00	0.0	0	0	0	0	1
11/02/2021 13:00	0.0	0	0	0	0	1
11/02/2021 14:00	0.0	0	0	0	0	1
11/02/2021 15:00	0.0	0	0	0	0	1
11/02/2021 16:00	0.0	0	0	0	0	1
11/02/2021 17:00	0.0	0	0	0	0	1
11/02/2021 18:00	0.0	0	0	0	0	1
11/02/2021 19:00	0.0	0	0	0	0	1
11/02/2021 20:00	0.0	0	0	0	0	1
11/02/2021 21:00	0.0	0	0	0	0	1
11/02/2021 22:00	0.0	0	0	0	0	1
11/02/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/03/2021 00:00	0.0	0	0	0	0	1
11/03/2021 01:00	0.0	0	0	0	0	1
11/03/2021 02:00	0.0	0	0	0	0	1
11/03/2021 03:00	0.0	0	0	0	0	1
11/03/2021 04:00	0.0	0	0	0	0	1
11/03/2021 05:00	0.0	0	0	0	0	1
11/03/2021 06:00	0.0	0	0	0	0	1
11/03/2021 07:00	0.0	0	0	0	0	1
11/03/2021 08:00	0.0	0	0	0	0	1
11/03/2021 09:00	0.0	0	0	0	0	1
11/03/2021 10:00	0.0	0	0	0	0	1
11/03/2021 11:00	0.0	0	0	0	0	1
11/03/2021 12:00	0.0	0	0	0	0	1
11/03/2021 13:00	0.0	0	0	0	0	1
11/03/2021 14:00	0.0	0	0	0	0	1
11/03/2021 15:00	0.0	0	0	0	0	1
11/03/2021 16:00	0.0	0	0	0	0	1
11/03/2021 17:00	0.0	0	0	0	0	1
11/03/2021 18:00	0.0	0	0	0	0	1
11/03/2021 19:00	0.0	0	0	0	0	1
11/03/2021 20:00	0.0	0	0	0	0	1
11/03/2021 21:00	0.0	0	0	0	0	1
11/03/2021 22:00	0.0	0	0	0	0	1
11/03/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/04/2021 00:00	0.0	0	0	0	0	1
11/04/2021 01:00	0.0	0	0	0	0	1
11/04/2021 02:00	0.0	0	0	0	0	1
11/04/2021 03:00	0.0	0	0	0	0	1
11/04/2021 04:00	0.0	0	0	0	0	1
11/04/2021 05:00	0.0	0	0	0	0	1
11/04/2021 06:00	0.0	0	0	0	0	1
11/04/2021 07:00	0.0	0	0	0	0	1
11/04/2021 08:00	0.0	0	0	0	0	1
11/04/2021 09:00	0.0	0	0	0	0	1
11/04/2021 10:00	0.0	0	0	0	0	1
11/04/2021 11:00	0.0	0	0	0	0	1
11/04/2021 12:00	0.0	0	0	0	0	1
11/04/2021 13:00	0.0	0	0	0	0	1
11/04/2021 14:00	0.0	0	0	0	0	1
11/04/2021 15:00	0.0	0	0	0	0	1
11/04/2021 16:00	0.0	0	0	0	0	1
11/04/2021 17:00	0.0	0	0	0	0	1
11/04/2021 18:00	0.0	0	0	0	0	1
11/04/2021 19:00	0.0	0	0	0	0	1
11/04/2021 20:00	0.0	0	0	0	0	1
11/04/2021 21:00	0.0	0	0	0	0	1
11/04/2021 22:00	0.0	0	0	0	0	1
11/04/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/05/2021 00:00	0.0	0	0	0	0	1
11/05/2021 01:00	0.0	0	0	0	0	1
11/05/2021 02:00	0.0	0	0	0	0	1
11/05/2021 03:00	0.0	0	0	0	0	1
11/05/2021 04:00	0.0	0	0	0	0	1
11/05/2021 05:00	0.0	0	0	0	0	1
11/05/2021 06:00	0.0	0	0	0	0	1
11/05/2021 07:00	0.0	0	0	0	0	1
11/05/2021 08:00	0.0	0	0	0	0	1
11/05/2021 09:00	0.0	0	0	0	0	1
11/05/2021 10:00	0.0	0	0	0	0	1
11/05/2021 11:00	0.0	0	0	0	0	1
11/05/2021 12:00	0.0	0	0	0	0	1
11/05/2021 13:00	0.0	0	0	0	0	1
11/05/2021 14:00	0.0	0	0	0	0	1
11/05/2021 15:00	0.0	0	0	0	0	1
11/05/2021 16:00	0.0	0	0	0	0	1
11/05/2021 17:00	0.0	0	0	0	0	1
11/05/2021 18:00	0.0	0	0	0	0	1
11/05/2021 19:00	0.0	0	0	0	0	1
11/05/2021 20:00	0.0	0	0	0	0	1
11/05/2021 21:00	0.0	0	0	0	0	1
11/05/2021 22:00	0.0	0	0	0	0	1
11/05/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/06/2021 00:00	0.0	0	0	0	0	1
11/06/2021 01:00	0.0	0	0	0	0	1
11/06/2021 02:00	0.0	0	0	0	0	1
11/06/2021 03:00	0.0	0	0	0	0	1
11/06/2021 04:00	0.0	0	0	0	0	1
11/06/2021 05:00	0.0	0	0	0	0	1
11/06/2021 06:00	0.0	0	0	0	0	1
11/06/2021 07:00	0.0	0	0	0	0	1
11/06/2021 08:00	0.0	0	0	0	0	1
11/06/2021 09:00	0.0	0	0	0	0	1
11/06/2021 10:00	0.0	0	0	0	0	1
11/06/2021 11:00	0.0	0	0	0	0	1
11/06/2021 12:00	0.0	0	0	0	0	1
11/06/2021 13:00	0.0	0	0	0	0	1
11/06/2021 14:00	0.0	0	0	0	0	1
11/06/2021 15:00	0.0	0	0	0	0	1
11/06/2021 16:00	0.0	0	0	0	0	1
11/06/2021 17:00	0.0	0	0	0	0	1
11/06/2021 18:00	0.0	0	0	0	0	1
11/06/2021 19:00	0.0	0	0	0	0	1
11/06/2021 20:00	0.0	0	0	0	0	1
11/06/2021 21:00	0.0	0	0	0	0	1
11/06/2021 22:00	1.5	0	0	0	1	0
11/06/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.5 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.5	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/07/2021 00:00	0.0	0	0	0	0	0
11/07/2021 01:00	0.0	0	0	0	0	0
11/07/2021 02:00	0.0	0	0	0	0	0
11/07/2021 03:00	0.0	0	0	0	0	0
11/07/2021 04:00	0.0	0	0	0	0	0
11/07/2021 05:00	0.0	0	0	0	0	0
11/07/2021 06:00	0.0	0	0	0	0	0
11/07/2021 07:00	0.0	0	0	0	0	0
11/07/2021 08:00	0.0	0	0	0	0	0
11/07/2021 09:00	0.0	0	0	0	0	0
11/07/2021 10:00	0.0	0	0	0	0	0
11/07/2021 11:00	0.0	0	0	0	0	0
11/07/2021 12:00	0.0	0	0	0	0	0
11/07/2021 13:00	0.0	0	0	0	0	0
11/07/2021 14:00	0.0	0	0	0	0	0
11/07/2021 15:00	0.0	0	0	0	0	0
11/07/2021 16:00	0.0	0	0	0	0	0
11/07/2021 17:00	0.0	0	0	0	0	0
11/07/2021 18:00	0.0	0	0	0	0	0
11/07/2021 19:00	0.0	0	0	0	0	0
11/07/2021 20:00	0.0	0	0	0	0	0
11/07/2021 21:00	0.0	0	0	0	0	0
11/07/2021 22:00	0.0	0	0	0	0	0
11/07/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/08/2021 00:00	0.0	0	0	0	0	0
11/08/2021 01:00	0.0	0	0	0	0	0
11/08/2021 02:00	0.0	0	0	0	0	0
11/08/2021 03:00	0.0	0	0	0	0	0
11/08/2021 04:00	0.0	0	0	0	0	0
11/08/2021 05:00	0.0	0	0	0	0	0
11/08/2021 06:00	0.0	0	0	0	0	0
11/08/2021 07:00	0.0	0	0	0	0	0
11/08/2021 08:00	0.0	0	0	0	0	0
11/08/2021 09:00	0.0	0	0	0	0	0
11/08/2021 10:00	0.0	0	0	0	0	0
11/08/2021 11:00	0.0	0	0	0	0	0
11/08/2021 12:00	0.0	0	0	0	0	0
11/08/2021 13:00	0.0	0	0	0	0	0
11/08/2021 14:00	0.0	0	0	0	0	0
11/08/2021 15:00	0.0	0	0	0	0	0
11/08/2021 16:00	0.0	0	0	0	0	0
11/08/2021 17:00	0.0	0	0	0	0	0
11/08/2021 18:00	0.0	0	0	0	0	0
11/08/2021 19:00	0.0	0	0	0	0	0
11/08/2021 20:00	0.0	0	0	0	0	0
11/08/2021 21:00	0.0	0	0	0	0	0
11/08/2021 22:00	0.0	0	0	0	0	0
11/08/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/09/2021 00:00	0.0	0	0	0	0	0
11/09/2021 01:00	0.0	0	0	0	0	0
11/09/2021 02:00	0.0	0	0	0	0	0
11/09/2021 03:00	0.0	0	0	0	0	0
11/09/2021 04:00	0.0	0	0	0	0	0
11/09/2021 05:00	0.0	0	0	0	0	0
11/09/2021 06:00	0.0	0	0	0	0	0
11/09/2021 07:00	81.0	0	1	0	0	0
11/09/2021 08:00	88.5	0	1	0	0	0
11/09/2021 09:00	0.0	0	0	0	0	1
11/09/2021 10:00	0.0	0	0	0	0	1
11/09/2021 11:00	0.0	0	0	0	0	1
11/09/2021 12:00	0.0	0	0	0	0	1
11/09/2021 13:00	0.0	0	0	0	0	1
11/09/2021 14:00	0.0	0	0	0	0	1
11/09/2021 15:00	0.0	0	0	0	0	1
11/09/2021 16:00	0.0	0	0	0	0	1
11/09/2021 17:00	0.0	0	0	0	0	1
11/09/2021 18:00	0.0	0	0	0	0	1
11/09/2021 19:00	0.0	0	0	0	0	1
11/09/2021 20:00	0.0	0	0	0	0	1
11/09/2021 21:00	0.0	0	0	0	0	1
11/09/2021 22:00	0.0	0	0	0	0	1
11/09/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	169.5 #	0 #	2 #	0 #	0 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	88.5	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/10/2021 00:00	0.0	0	0	0	0	1
11/10/2021 01:00	0.0	0	0	0	0	1
11/10/2021 02:00	0.0	0	0	0	0	1
11/10/2021 03:00	0.0	0	0	0	0	1
11/10/2021 04:00	0.0	0	0	0	0	1
11/10/2021 05:00	0.0	0	0	0	0	1
11/10/2021 06:00	0.0	0	0	0	0	1
11/10/2021 07:00	0.0	0	0	0	0	1
11/10/2021 08:00	0.0	0	0	0	0	1
11/10/2021 09:00	0.0	0	0	0	0	1
11/10/2021 10:00	0.0	0	0	0	0	1
11/10/2021 11:00	0.0	0	0	0	0	1
11/10/2021 12:00	0.0	0	0	0	0	1
11/10/2021 13:00	0.0	0	0	0	0	1
11/10/2021 14:00	0.0	0	0	0	0	1
11/10/2021 15:00	0.0	0	0	0	0	1
11/10/2021 16:00	0.0	0	0	0	0	1
11/10/2021 17:00	0.0	0	0	0	0	1
11/10/2021 18:00	0.0	0	0	0	0	1
11/10/2021 19:00	0.0	0	0	0	0	1
11/10/2021 20:00	0.0	0	0	0	0	1
11/10/2021 21:00	0.0	0	0	0	0	1
11/10/2021 22:00	0.0	0	0	0	0	1
11/10/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/11/2021 00:00	0.0	0	0	0	0	1
11/11/2021 01:00	3.3	0	0	0	1	0
11/11/2021 02:00	0.0	0	0	0	0	0
11/11/2021 03:00	0.0	0	0	0	0	0
11/11/2021 04:00	0.0	0	0	0	0	0
11/11/2021 05:00	0.0	0	0	0	0	0
11/11/2021 06:00	0.0	0	0	0	0	0
11/11/2021 07:00	0.0	0	0	0	0	0
11/11/2021 08:00	0.0	0	0	0	0	0
11/11/2021 09:00	20.6	0	1	0	0	0
11/11/2021 10:00	188.6	0	1	0	0	0
11/11/2021 11:00	0.0	0	0	0	0	1
11/11/2021 12:00	0.0	0	0	0	0	1
11/11/2021 13:00	0.0	0	0	0	0	1
11/11/2021 14:00	0.0	0	0	0	0	1
11/11/2021 15:00	0.0	0	0	0	0	1
11/11/2021 16:00	0.0	0	0	0	0	1
11/11/2021 17:00	0.0	0	0	0	0	1
11/11/2021 18:00	0.0	0	0	0	0	1
11/11/2021 19:00	0.0	0	0	0	0	1
11/11/2021 20:00	0.0	0	0	0	0	1
11/11/2021 21:00	0.0	0	0	0	0	1
11/11/2021 22:00	0.0	0	0	0	0	1
11/11/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	212.5 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	188.6	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/12/2021 00:00	0.0	0	0	0	0	1
11/12/2021 01:00	0.0	0	0	0	0	1
11/12/2021 02:00	0.0	0	0	0	0	1
11/12/2021 03:00	0.0	0	0	0	0	1
11/12/2021 04:00	0.0	0	0	0	0	1
11/12/2021 05:00	0.0	0	0	0	0	1
11/12/2021 06:00	0.0	0	0	0	0	1
11/12/2021 07:00	0.0	0	0	0	0	1
11/12/2021 08:00	0.0	0	0	0	0	1
11/12/2021 09:00	0.0	0	0	0	0	1
11/12/2021 10:00	0.0	0	0	0	0	1
11/12/2021 11:00	0.0	0	0	0	0	1
11/12/2021 12:00	0.0	0	0	0	0	1
11/12/2021 13:00	0.0	0	0	0	0	1
11/12/2021 14:00	0.0	0	0	0	0	1
11/12/2021 15:00	0.0	0	0	0	0	1
11/12/2021 16:00	0.0	0	0	0	0	1
11/12/2021 17:00	0.0	0	0	0	0	1
11/12/2021 18:00	0.0	0	0	0	0	1
11/12/2021 19:00	0.0	0	0	0	0	1
11/12/2021 20:00	0.0	0	0	0	0	1
11/12/2021 21:00	0.0	0	0	0	0	1
11/12/2021 22:00	0.0	0	0	0	0	1
11/12/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/13/2021 00:00	2.6	0	0	0	1	0
11/13/2021 01:00	0.0	0	0	0	0	0
11/13/2021 02:00	0.0	0	0	0	0	0
11/13/2021 03:00	0.0	0	0	0	0	0
11/13/2021 04:00	0.0	0	0	0	0	0
11/13/2021 05:00	0.0	0	0	0	0	0
11/13/2021 06:00	0.0	0	0	0	0	0
11/13/2021 07:00	0.0	0	0	0	0	0
11/13/2021 08:00	22.2	0	1	0	0	0
11/13/2021 09:00	74.0	0	1	0	0	0
11/13/2021 10:00	0.0	0	0	0	0	1
11/13/2021 11:00	0.0	0	0	0	0	1
11/13/2021 12:00	0.0	0	0	0	0	1
11/13/2021 13:00	0.0	0	0	0	0	1
11/13/2021 14:00	0.0	0	0	0	0	1
11/13/2021 15:00	0.0	0	0	0	0	1
11/13/2021 16:00	0.0	0	0	0	0	1
11/13/2021 17:00	0.0	0	0	0	0	1
11/13/2021 18:00	0.0	0	0	0	0	1
11/13/2021 19:00	0.0	0	0	0	0	1
11/13/2021 20:00	0.0	0	0	0	0	1
11/13/2021 21:00	0.0	0	0	0	0	1
11/13/2021 22:00	2.5	0	0	0	1	0
11/13/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	101.3 #	0 #	2 #	0 #	2 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	74.0	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/14/2021 00:00	0.0	0	0	0	0	0
11/14/2021 01:00	0.0	0	0	0	0	0
11/14/2021 02:00	0.0	0	0	0	0	0
11/14/2021 03:00	0.0	0	0	0	0	0
11/14/2021 04:00	0.0	0	0	0	0	0
11/14/2021 05:00	0.0	0	0	0	0	0
11/14/2021 06:00	0.0	0	0	0	0	0
11/14/2021 07:00	0.0	0	0	0	0	0
11/14/2021 08:00	0.0	0	0	0	0	0
11/14/2021 09:00	19.8	0	1	0	0	0
11/14/2021 10:00	52.8	0	1	0	0	0
11/14/2021 11:00	39.7	0	1	0	0	0
11/14/2021 12:00	0.0	0	0	0	0	1
11/14/2021 13:00	0.0	0	0	0	0	1
11/14/2021 14:00	0.0	0	0	0	0	1
11/14/2021 15:00	0.0	0	0	0	0	1
11/14/2021 16:00	0.0	0	0	0	0	1
11/14/2021 17:00	0.0	0	0	0	0	1
11/14/2021 18:00	0.0	0	0	0	0	1
11/14/2021 19:00	0.0	0	0	0	0	1
11/14/2021 20:00	0.0	0	0	0	0	1
11/14/2021 21:00	0.0	0	0	0	0	1
11/14/2021 22:00	0.0	0	0	0	0	1
11/14/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	112.3 #	0 #	3 #	0 #	0 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	52.8	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/15/2021 00:00	0.0	0	0	0	0	1
11/15/2021 01:00	0.0	0	0	0	0	1
11/15/2021 02:00	0.0	0	0	0	0	1
11/15/2021 03:00	0.0	0	0	0	0	1
11/15/2021 04:00	0.0	0	0	0	0	1
11/15/2021 05:00	0.0	0	0	0	0	1
11/15/2021 06:00	0.0	0	0	0	0	1
11/15/2021 07:00	0.0	0	0	0	0	1
11/15/2021 08:00	0.0	0	0	0	0	1
11/15/2021 09:00	0.0	0	0	0	0	1
11/15/2021 10:00	0.0	0	0	0	0	1
11/15/2021 11:00	0.0	0	0	0	0	1
11/15/2021 12:00	0.0	0	0	0	0	1
11/15/2021 13:00	0.0	0	0	0	0	1
11/15/2021 14:00	0.0	0	0	0	0	1
11/15/2021 15:00	0.0	0	0	0	0	1
11/15/2021 16:00	0.0	0	0	0	0	1
11/15/2021 17:00	0.0	0	0	0	0	1
11/15/2021 18:00	0.0	0	0	0	0	1
11/15/2021 19:00	0.0	0	0	0	0	1
11/15/2021 20:00	0.0	0	0	0	0	1
11/15/2021 21:00	0.0	0	0	0	0	1
11/15/2021 22:00	0.0	0	0	0	0	1
11/15/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/16/2021 00:00	3.8	0	0	0	1	0
11/16/2021 01:00	0.0	0	0	0	0	0
11/16/2021 02:00	0.0	0	0	0	0	0
11/16/2021 03:00	0.0	0	0	0	0	0
11/16/2021 04:00	0.0	0	0	0	0	0
11/16/2021 05:00	0.0	0	0	0	0	0
11/16/2021 06:00	0.0	0	0	0	0	0
11/16/2021 07:00	0.0	0	0	0	0	0
11/16/2021 08:00	24.4	0	1	0	0	0
11/16/2021 09:00	121.6	0	1	0	0	0
11/16/2021 10:00	0.0	0	0	0	0	1
11/16/2021 11:00	0.0	0	0	0	0	1
11/16/2021 12:00	0.0	0	0	0	0	1
11/16/2021 13:00	0.0	0	0	0	0	1
11/16/2021 14:00	0.0	0	0	0	0	1
11/16/2021 15:00	0.0	0	0	0	0	1
11/16/2021 16:00	0.0	0	0	0	0	1
11/16/2021 17:00	0.0	0	0	0	0	1
11/16/2021 18:00	0.0	0	0	0	0	1
11/16/2021 19:00	0.0	0	0	0	0	1
11/16/2021 20:00	0.0	0	0	0	0	1
11/16/2021 21:00	0.0	0	0	0	0	1
11/16/2021 22:00	0.0	0	0	0	0	1
11/16/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	149.8 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	121.6	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/17/2021 00:00	0.0	0	0	0	0	1
11/17/2021 01:00	0.0	0	0	0	0	1
11/17/2021 02:00	0.0	0	0	0	0	1
11/17/2021 03:00	0.0	0	0	0	0	1
11/17/2021 04:00	0.0	0	0	0	0	1
11/17/2021 05:00	0.0	0	0	0	0	1
11/17/2021 06:00	0.0	0	0	0	0	1
11/17/2021 07:00	0.0	0	0	0	0	1
11/17/2021 08:00	0.0	0	0	0	0	1
11/17/2021 09:00	0.0	0	0	0	0	1
11/17/2021 10:00	0.0	0	0	0	0	1
11/17/2021 11:00	0.0	0	0	0	0	1
11/17/2021 12:00	0.0	0	0	0	0	1
11/17/2021 13:00	0.0	0	0	0	0	1
11/17/2021 14:00	0.0	0	0	0	0	1
11/17/2021 15:00	0.0	0	0	0	0	1
11/17/2021 16:00	0.0	0	0	0	0	1
11/17/2021 17:00	0.0	0	0	0	0	1
11/17/2021 18:00	0.0	0	0	0	0	1
11/17/2021 19:00	0.0	0	0	0	0	1
11/17/2021 20:00	0.0	0	0	0	0	1
11/17/2021 21:00	0.0	0	0	0	0	1
11/17/2021 22:00	0.0	0	0	0	0	1
11/17/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/18/2021 00:00	0.0	0	0	0	0	1
11/18/2021 01:00	0.0	0	0	0	0	1
11/18/2021 02:00	0.0	0	0	0	0	1
11/18/2021 03:00	0.0	0	0	0	0	1
11/18/2021 04:00	0.0	0	0	0	0	1
11/18/2021 05:00	0.0	0	0	0	0	1
11/18/2021 06:00	0.0	0	0	0	0	1
11/18/2021 07:00	0.0	0	0	0	0	1
11/18/2021 08:00	0.0	0	0	0	0	1
11/18/2021 09:00	0.0	0	0	0	0	1
11/18/2021 10:00	0.0	0	0	0	0	1
11/18/2021 11:00	0.0	0	0	0	0	1
11/18/2021 12:00	0.0	0	0	0	0	1
11/18/2021 13:00	0.0	0	0	0	0	1
11/18/2021 14:00	0.0	0	0	0	0	1
11/18/2021 15:00	0.0	0	0	0	0	1
11/18/2021 16:00	0.0	0	0	0	0	1
11/18/2021 17:00	0.0	0	0	0	0	1
11/18/2021 18:00	0.0	0	0	0	0	1
11/18/2021 19:00	0.0	0	0	0	0	1
11/18/2021 20:00	0.0	0	0	0	0	1
11/18/2021 21:00	0.0	0	0	0	0	1
11/18/2021 22:00	0.0	0	0	0	0	1
11/18/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/19/2021 00:00	0.0	0	0	0	0	1
11/19/2021 01:00	0.0	0	0	0	0	1
11/19/2021 02:00	0.0	0	0	0	0	1
11/19/2021 03:00	0.0	0	0	0	0	1
11/19/2021 04:00	0.0	0	0	0	0	1
11/19/2021 05:00	0.0	0	0	0	0	1
11/19/2021 06:00	0.0	0	0	0	0	1
11/19/2021 07:00	0.0	0	0	0	0	1
11/19/2021 08:00	0.0	0	0	0	0	1
11/19/2021 09:00	0.0	0	0	0	0	1
11/19/2021 10:00	0.0	0	0	0	0	1
11/19/2021 11:00	0.0	0	0	0	0	1
11/19/2021 12:00	0.0	0	0	0	0	1
11/19/2021 13:00	0.0	0	0	0	0	1
11/19/2021 14:00	0.0	0	0	0	0	1
11/19/2021 15:00	0.0	0	0	0	0	1
11/19/2021 16:00	0.0	0	0	0	0	1
11/19/2021 17:00	0.0	0	0	0	0	1
11/19/2021 18:00	0.0	0	0	0	0	1
11/19/2021 19:00	0.0	0	0	0	0	1
11/19/2021 20:00	0.0	0	0	0	0	1
11/19/2021 21:00	0.0	0	0	0	0	1
11/19/2021 22:00	0.0	0	0	0	0	1
11/19/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/20/2021 00:00	0.0	0	0	0	0	1
11/20/2021 01:00	0.0	0	0	0	0	1
11/20/2021 02:00	0.0	0	0	0	0	1
11/20/2021 03:00	0.0	0	0	0	0	1
11/20/2021 04:00	0.0	0	0	0	0	1
11/20/2021 05:00	0.0	0	0	0	0	1
11/20/2021 06:00	0.0	0	0	0	0	1
11/20/2021 07:00	0.0	0	0	0	0	1
11/20/2021 08:00	0.0	0	0	0	0	1
11/20/2021 09:00	0.0	0	0	0	0	1
11/20/2021 10:00	0.0	0	0	0	0	1
11/20/2021 11:00	0.0	0	0	0	0	1
11/20/2021 12:00	0.0	0	0	0	0	1
11/20/2021 13:00	0.0	0	0	0	0	1
11/20/2021 14:00	0.0	0	0	0	0	1
11/20/2021 15:00	0.0	0	0	0	0	1
11/20/2021 16:00	0.0	0	0	0	0	1
11/20/2021 17:00	0.0	0	0	0	0	1
11/20/2021 18:00	0.0	0	0	0	0	1
11/20/2021 19:00	0.0	0	0	0	0	1
11/20/2021 20:00	0.0	0	0	0	0	1
11/20/2021 21:00	0.0	0	0	0	0	1
11/20/2021 22:00	0.0	0	0	0	0	1
11/20/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/21/2021 00:00	0.0	0	0	0	0	1
11/21/2021 01:00	0.0	0	0	0	0	1
11/21/2021 02:00	1.4	0	0	0	1	0
11/21/2021 03:00	0.0	0	0	0	0	0
11/21/2021 04:00	0.0	0	0	0	0	0
11/21/2021 05:00	0.0	0	0	0	0	0
11/21/2021 06:00	0.0	0	0	0	0	0
11/21/2021 07:00	0.0	0	0	0	0	0
11/21/2021 08:00	0.0	0	0	0	0	0
11/21/2021 09:00	0.0	0	0	0	0	0
11/21/2021 10:00	9.7	0	0	1	0	0
11/21/2021 11:00	63.9	0	0	1	0	0
11/21/2021 12:00	0.0	0	0	0	0	1
11/21/2021 13:00	0.0	0	0	0	0	1
11/21/2021 14:00	0.0	0	0	0	0	1
11/21/2021 15:00	0.0	0	0	0	0	1
11/21/2021 16:00	0.0	0	0	0	0	1
11/21/2021 17:00	0.0	0	0	0	0	1
11/21/2021 18:00	0.0	0	0	0	0	1
11/21/2021 19:00	0.0	0	0	0	0	1
11/21/2021 20:00	0.0	0	0	0	0	1
11/21/2021 21:00	0.0	0	0	0	0	1
11/21/2021 22:00	0.0	0	0	0	0	1
11/21/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	75.0 #	0 #	0 #	2 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	63.9	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/22/2021 00:00	0.0	0	0	0	0	1
11/22/2021 01:00	0.0	0	0	0	0	1
11/22/2021 02:00	0.0	0	0	0	0	1
11/22/2021 03:00	0.0	0	0	0	0	1
11/22/2021 04:00	0.0	0	0	0	0	1
11/22/2021 05:00	0.0	0	0	0	0	1
11/22/2021 06:00	0.0	0	0	0	0	1
11/22/2021 07:00	0.0	0	0	0	0	1
11/22/2021 08:00	0.0	0	0	0	0	1
11/22/2021 09:00	0.0	0	0	0	0	1
11/22/2021 10:00	0.0	0	0	0	0	1
11/22/2021 11:00	0.0	0	0	0	0	1
11/22/2021 12:00	0.0	0	0	0	0	1
11/22/2021 13:00	0.0	0	0	0	0	1
11/22/2021 14:00	0.0	0	0	0	0	1
11/22/2021 15:00	0.0	0	0	0	0	1
11/22/2021 16:00	0.0	0	0	0	0	1
11/22/2021 17:00	0.0	0	0	0	0	1
11/22/2021 18:00	0.0	0	0	0	0	1
11/22/2021 19:00	0.0	0	0	0	0	1
11/22/2021 20:00	0.0	0	0	0	0	1
11/22/2021 21:00	0.0	0	0	0	0	1
11/22/2021 22:00	0.0	0	0	0	0	1
11/22/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/23/2021 00:00	0.0	0	0	0	0	1
11/23/2021 01:00	0.0	0	0	0	0	1
11/23/2021 02:00	0.0	0	0	0	0	1
11/23/2021 03:00	0.0	0	0	0	0	1
11/23/2021 04:00	0.0	0	0	0	0	1
11/23/2021 05:00	0.0	0	0	0	0	1
11/23/2021 06:00	0.0	0	0	0	0	1
11/23/2021 07:00	0.0	0	0	0	0	1
11/23/2021 08:00	0.0	0	0	0	0	1
11/23/2021 09:00	0.0	0	0	0	0	1
11/23/2021 10:00	0.0	0	0	0	0	1
11/23/2021 11:00	0.0	0	0	0	0	1
11/23/2021 12:00	0.0	0	0	0	0	1
11/23/2021 13:00	0.0	0	0	0	0	1
11/23/2021 14:00	0.0	0	0	0	0	1
11/23/2021 15:00	0.0	0	0	0	0	1
11/23/2021 16:00	0.0	0	0	0	0	1
11/23/2021 17:00	0.0	0	0	0	0	1
11/23/2021 18:00	0.0	0	0	0	0	1
11/23/2021 19:00	0.0	0	0	0	0	1
11/23/2021 20:00	0.0	0	0	0	0	1
11/23/2021 21:00	0.0	0	0	0	0	1
11/23/2021 22:00	0.0	0	0	0	0	1
11/23/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/24/2021 00:00	0.0	0	0	0	0	1
11/24/2021 01:00	0.0	0	0	0	0	1
11/24/2021 02:00	0.0	0	0	0	0	1
11/24/2021 03:00	0.0	0	0	0	0	1
11/24/2021 04:00	0.0	0	0	0	0	1
11/24/2021 05:00	0.0	0	0	0	0	1
11/24/2021 06:00	0.0	0	0	0	0	1
11/24/2021 07:00	0.0	0	0	0	0	1
11/24/2021 08:00	0.0	0	0	0	0	1
11/24/2021 09:00	0.0	0	0	0	0	1
11/24/2021 10:00	0.0	0	0	0	0	1
11/24/2021 11:00	0.0	0	0	0	0	1
11/24/2021 12:00	0.0	0	0	0	0	1
11/24/2021 13:00	0.0	0	0	0	0	1
11/24/2021 14:00	0.0	0	0	0	0	1
11/24/2021 15:00	0.0	0	0	0	0	1
11/24/2021 16:00	0.0	0	0	0	0	1
11/24/2021 17:00	0.0	0	0	0	0	1
11/24/2021 18:00	0.0	0	0	0	0	1
11/24/2021 19:00	0.0	0	0	0	0	1
11/24/2021 20:00	0.0	0	0	0	0	1
11/24/2021 21:00	0.0	0	0	0	0	1
11/24/2021 22:00	0.0	0	0	0	0	1
11/24/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/25/2021 00:00	2.8	0	0	0	1	0
11/25/2021 01:00	0.0	0	0	0	0	0
11/25/2021 02:00	0.0	0	0	0	0	0
11/25/2021 03:00	0.0	0	0	0	0	0
11/25/2021 04:00	0.0	0	0	0	0	0
11/25/2021 05:00	0.0	0	0	0	0	0
11/25/2021 06:00	0.0	0	0	0	0	0
11/25/2021 07:00	0.0	0	0	0	0	0
11/25/2021 08:00	0.0	0	0	0	0	0
11/25/2021 09:00	0.0	0	0	0	0	0
11/25/2021 10:00	0.0	0	0	0	0	0
11/25/2021 11:00	0.0	0	0	0	0	0
11/25/2021 12:00	0.0	0	0	0	0	0
11/25/2021 13:00	0.0	0	0	0	0	0
11/25/2021 14:00	0.0	0	0	0	0	0
11/25/2021 15:00	0.0	0	0	0	0	0
11/25/2021 16:00	0.0	0	0	0	0	0
11/25/2021 17:00	0.0	0	0	0	0	0
11/25/2021 18:00	0.0	0	0	0	0	0
11/25/2021 19:00	0.0	0	0	0	0	0
11/25/2021 20:00	0.0	0	0	0	0	0
11/25/2021 21:00	0.0	0	0	0	0	0
11/25/2021 22:00	0.0	0	0	0	0	0
11/25/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	2.8 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.8	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/26/2021 00:00	0.0	0	0	0	0	0
11/26/2021 01:00	0.0	0	0	0	0	0
11/26/2021 02:00	0.0	0	0	0	0	0
11/26/2021 03:00	0.0	0	0	0	0	0
11/26/2021 04:00	0.0	0	0	0	0	0
11/26/2021 05:00	0.0	0	0	0	0	0
11/26/2021 06:00	0.0	0	0	0	0	0
11/26/2021 07:00	0.0	0	0	0	0	0
11/26/2021 08:00	0.0	0	0	0	0	0
11/26/2021 09:00	0.0	0	0	0	0	0
11/26/2021 10:00	0.0	0	0	0	0	0
11/26/2021 11:00	0.0	0	0	0	0	0
11/26/2021 12:00	0.0	0	0	0	0	0
11/26/2021 13:00	0.0	0	0	0	0	0
11/26/2021 14:00	0.0	0	0	0	0	0
11/26/2021 15:00	0.0	0	0	0	0	0
11/26/2021 16:00	0.0	0	0	0	0	0
11/26/2021 17:00	0.0	0	0	0	0	0
11/26/2021 18:00	0.0	0	0	0	0	0
11/26/2021 19:00	0.0	0	0	0	0	0
11/26/2021 20:00	0.0	0	0	0	0	0
11/26/2021 21:00	0.0	0	0	0	0	0
11/26/2021 22:00	0.0	0	0	0	0	0
11/26/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/27/2021 00:00	0.0	0	0	0	0	0
11/27/2021 01:00	0.0	0	0	0	0	0
11/27/2021 02:00	0.0	0	0	0	0	0
11/27/2021 03:00	0.0	0	0	0	0	0
11/27/2021 04:00	0.0	0	0	0	0	0
11/27/2021 05:00	0.0	0	0	0	0	0
11/27/2021 06:00	0.0	0	0	0	0	0
11/27/2021 07:00	0.0	0	0	0	0	0
11/27/2021 08:00	0.0	0	0	0	0	0
11/27/2021 09:00	0.0	0	0	0	0	0
11/27/2021 10:00	0.0	0	0	0	0	0
11/27/2021 11:00	0.0	0	0	0	0	0
11/27/2021 12:00	0.0	0	0	0	0	0
11/27/2021 13:00	0.0	0	0	0	0	0
11/27/2021 14:00	0.0	0	0	0	0	0
11/27/2021 15:00	0.0	0	0	0	0	0
11/27/2021 16:00	0.0	0	0	0	0	0
11/27/2021 17:00	0.0	0	0	0	0	0
11/27/2021 18:00	0.0	0	0	0	0	0
11/27/2021 19:00	0.0	0	0	0	0	0
11/27/2021 20:00	0.0	0	0	0	0	0
11/27/2021 21:00	0.0	0	0	0	0	0
11/27/2021 22:00	0.0	0	0	0	0	0
11/27/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/28/2021 00:00	0.0	0	0	0	0	0
11/28/2021 01:00	0.0	0	0	0	0	0
11/28/2021 02:00	0.0	0	0	0	0	0
11/28/2021 03:00	0.0	0	0	0	0	0
11/28/2021 04:00	0.0	0	0	0	0	0
11/28/2021 05:00	0.0	0	0	0	0	0
11/28/2021 06:00	0.0	0	0	0	0	0
11/28/2021 07:00	0.0	0	0	0	0	0
11/28/2021 08:00	0.0	0	0	0	0	0
11/28/2021 09:00	0.0	0	0	0	0	0
11/28/2021 10:00	0.0	0	0	0	0	0
11/28/2021 11:00	0.0	0	0	0	0	0
11/28/2021 12:00	0.0	0	0	0	0	0
11/28/2021 13:00	0.0	0	0	0	0	0
11/28/2021 14:00	0.0	0	0	0	0	0
11/28/2021 15:00	0.0	0	0	0	0	0
11/28/2021 16:00	0.0	0	0	0	0	0
11/28/2021 17:00	0.0	0	0	0	0	0
11/28/2021 18:00	0.0	0	0	0	0	0
11/28/2021 19:00	0.0	0	0	0	0	0
11/28/2021 20:00	0.0	0	0	0	0	0
11/28/2021 21:00	0.0	0	0	0	0	0
11/28/2021 22:00	0.0	0	0	0	0	0
11/28/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/29/2021 00:00	0.0	0	0	0	0	0
11/29/2021 01:00	0.0	0	0	0	0	0
11/29/2021 02:00	0.0	0	0	0	0	0
11/29/2021 03:00	0.0	0	0	0	0	0
11/29/2021 04:00	0.0	0	0	0	0	0
11/29/2021 05:00	0.0	0	0	0	0	0
11/29/2021 06:00	0.0	0	0	0	0	0
11/29/2021 07:00	20.4	1	0	0	0	0
11/29/2021 08:00	55.8	1	0	0	0	0
11/29/2021 09:00	26.5	1	0	0	0	0
11/29/2021 10:00	111.6	1	0	0	0	0
11/29/2021 11:00	104.3	1	0	0	0	0
11/29/2021 12:00	0.0	0	0	0	0	1
11/29/2021 13:00	0.0	0	0	0	0	1
11/29/2021 14:00	0.0	0	0	0	0	1
11/29/2021 15:00	0.0	0	0	0	0	1
11/29/2021 16:00	0.0	0	0	0	0	1
11/29/2021 17:00	0.0	0	0	0	0	1
11/29/2021 18:00	0.0	0	0	0	0	1
11/29/2021 19:00	0.0	0	0	0	0	1
11/29/2021 20:00	0.0	0	0	0	0	1
11/29/2021 21:00	0.0	0	0	0	0	1
11/29/2021 22:00	0.0	0	0	0	0	1
11/29/2021 23:00	3.0	0	0	0	1	0
Average/Sum#:	321.6 #	5 #	0 #	0 #	1 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	111.6	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/30/2021 00:00	0.0	0	0	0	0	0
11/30/2021 01:00	0.0	0	0	0	0	0
11/30/2021 02:00	0.0	0	0	0	0	0
11/30/2021 03:00	0.0	0	0	0	0	0
11/30/2021 04:00	0.0	0	0	0	0	0
11/30/2021 05:00	7.9	0	0	1	0	0
11/30/2021 06:00	52.0	0	0	1	0	0
11/30/2021 07:00	0.0	0	0	0	0	1
11/30/2021 08:00	0.0	0	0	0	0	1
11/30/2021 09:00	0.0	0	0	0	0	1
11/30/2021 10:00	0.0	0	0	0	0	1
11/30/2021 11:00	0.0	0	0	0	0	1
11/30/2021 12:00	0.0	0	0	0	0	1
11/30/2021 13:00	0.0	0	0	0	0	1
11/30/2021 14:00	0.0	0	0	0	0	1
11/30/2021 15:00	0.0	0	0	0	0	1
11/30/2021 16:00	0.0	0	0	0	0	1
11/30/2021 17:00	0.0	0	0	0	0	1
11/30/2021 18:00	0.0	0	0	0	0	1
11/30/2021 19:00	0.0	0	0	0	0	1
11/30/2021 20:00	0.0	0	0	0	0	1
11/30/2021 21:00	0.0	0	0	0	0	1
11/30/2021 22:00	0.0	0	0	0	0	1
11/30/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	59.9 #	0 #	0 #	2 #	0 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	52.0	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/01/2021 00:00	0.0	0	0	0	0	1
12/01/2021 01:00	0.0	0	0	0	0	1
12/01/2021 02:00	0.0	0	0	0	0	1
12/01/2021 03:00	0.0	0	0	0	0	1
12/01/2021 04:00	0.0	0	0	0	0	1
12/01/2021 05:00	0.0	0	0	0	0	1
12/01/2021 06:00	0.0	0	0	0	0	1
12/01/2021 07:00	0.0	0	0	0	0	1
12/01/2021 08:00	0.0	0	0	0	0	1
12/01/2021 09:00	0.0	0	0	0	0	1
12/01/2021 10:00	0.0	0	0	0	0	1
12/01/2021 11:00	0.0	0	0	0	0	1
12/01/2021 12:00	0.0	0	0	0	0	1
12/01/2021 13:00	0.0	0	0	0	0	1
12/01/2021 14:00	0.0	0	0	0	0	1
12/01/2021 15:00	0.0	0	0	0	0	1
12/01/2021 16:00	0.0	0	0	0	0	1
12/01/2021 17:00	0.0	0	0	0	0	1
12/01/2021 18:00	0.0	0	0	0	0	1
12/01/2021 19:00	0.0	0	0	0	0	1
12/01/2021 20:00	0.0	0	0	0	0	1
12/01/2021 21:00	0.0	0	0	0	0	1
12/01/2021 22:00	0.0	0	0	0	0	1
12/01/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/02/2021 00:00	2.8	0	0	0	1	0
12/02/2021 01:00	0.0	0	0	0	0	0
12/02/2021 02:00	0.0	0	0	0	0	0
12/02/2021 03:00	0.0	0	0	0	0	0
12/02/2021 04:00	0.0	0	0	0	0	0
12/02/2021 05:00	0.0	0	0	0	0	0
12/02/2021 06:00	44.6	0	0	1	0	0
12/02/2021 07:00	21.7	0	0	1	0	0
12/02/2021 08:00	0.0	0	0	0	0	1
12/02/2021 09:00	0.0	0	0	0	0	1
12/02/2021 10:00	0.0	0	0	0	0	1
12/02/2021 11:00	0.0	0	0	0	0	1
12/02/2021 12:00	0.0	0	0	0	0	1
12/02/2021 13:00	0.0	0	0	0	0	1
12/02/2021 14:00	0.0	0	0	0	0	1
12/02/2021 15:00	0.0	0	0	0	0	1
12/02/2021 16:00	0.0	0	0	0	0	1
12/02/2021 17:00	0.0	0	0	0	0	1
12/02/2021 18:00	0.0	0	0	0	0	1
12/02/2021 19:00	0.0	0	0	0	0	1
12/02/2021 20:00	0.0	0	0	0	0	1
12/02/2021 21:00	0.0	0	0	0	0	1
12/02/2021 22:00	0.0	0	0	0	0	1
12/02/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	69.1 #	0 #	0 #	2 #	1 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	44.6	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/03/2021 00:00	0.0	0	0	0	0	1
12/03/2021 01:00	0.0	0	0	0	0	1
12/03/2021 02:00	0.0	0	0	0	0	1
12/03/2021 03:00	0.0	0	0	0	0	1
12/03/2021 04:00	0.0	0	0	0	0	1
12/03/2021 05:00	0.0	0	0	0	0	1
12/03/2021 06:00	0.0	0	0	0	0	1
12/03/2021 07:00	0.0	0	0	0	0	1
12/03/2021 08:00	0.0	0	0	0	0	1
12/03/2021 09:00	0.0	0	0	0	0	1
12/03/2021 10:00	0.0	0	0	0	0	1
12/03/2021 11:00	0.0	0	0	0	0	1
12/03/2021 12:00	0.0	0	0	0	0	1
12/03/2021 13:00	0.0	0	0	0	0	1
12/03/2021 14:00	0.0	0	0	0	0	1
12/03/2021 15:00	0.0	0	0	0	0	1
12/03/2021 16:00	0.0	0	0	0	0	1
12/03/2021 17:00	0.0	0	0	0	0	1
12/03/2021 18:00	0.0	0	0	0	0	1
12/03/2021 19:00	0.0	0	0	0	0	1
12/03/2021 20:00	0.0	0	0	0	0	1
12/03/2021 21:00	0.0	0	0	0	0	1
12/03/2021 22:00	0.0	0	0	0	0	1
12/03/2021 23:00	1.3	0	0	0	1	0
Average/Sum#:	1.3 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.3	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/04/2021 00:00	0.0	0	0	0	1	0
12/04/2021 01:00	0.0	0	0	0	0	0
12/04/2021 02:00	0.0	0	0	0	0	0
12/04/2021 03:00	2.1	0	0	1	0	0
12/04/2021 04:00	53.0	0	0	1	0	0
12/04/2021 05:00	0.0	0	0	0	0	1
12/04/2021 06:00	0.0	0	0	0	0	1
12/04/2021 07:00	0.0	0	0	0	0	1
12/04/2021 08:00	0.0	0	0	0	0	1
12/04/2021 09:00	0.0	0	0	0	0	1
12/04/2021 10:00	0.0	0	0	0	0	1
12/04/2021 11:00	0.0	0	0	0	0	1
12/04/2021 12:00	0.0	0	0	0	0	1
12/04/2021 13:00	0.0	0	0	0	0	1
12/04/2021 14:00	0.0	0	0	0	0	1
12/04/2021 15:00	0.0	0	0	0	0	1
12/04/2021 16:00	0.0	0	0	0	0	1
12/04/2021 17:00	0.0	0	0	0	0	1
12/04/2021 18:00	0.0	0	0	0	0	1
12/04/2021 19:00	0.0	0	0	0	0	1
12/04/2021 20:00	0.0	0	0	0	0	1
12/04/2021 21:00	0.0	0	0	0	0	1
12/04/2021 22:00	0.0	0	0	0	0	1
12/04/2021 23:00	4.5	0	0	0	1	0
Average/Sum#:	59.6 #	0 #	0 #	2 #	2 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	53.0	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/05/2021 00:00	0.0	0	0	0	0	0
12/05/2021 01:00	0.0	0	0	0	0	0
12/05/2021 02:00	0.0	0	0	0	0	0
12/05/2021 03:00	0.0	0	0	0	0	0
12/05/2021 04:00	0.0	0	0	0	0	0
12/05/2021 05:00	0.0	0	0	0	0	0
12/05/2021 06:00	0.0	0	0	0	0	0
12/05/2021 07:00	33.3	0	1	0	0	0
12/05/2021 08:00	157.7	0	1	0	0	0
12/05/2021 09:00	0.0	0	0	0	0	1
12/05/2021 10:00	0.0	0	0	0	0	1
12/05/2021 11:00	0.0	0	0	0	0	1
12/05/2021 12:00	0.0	0	0	0	0	1
12/05/2021 13:00	0.0	0	0	0	0	1
12/05/2021 14:00	0.0	0	0	0	0	1
12/05/2021 15:00	0.0	0	0	0	0	1
12/05/2021 16:00	0.0	0	0	0	0	1
12/05/2021 17:00	0.0	0	0	0	0	1
12/05/2021 18:00	0.0	0	0	0	0	1
12/05/2021 19:00	0.0	0	0	0	0	1
12/05/2021 20:00	0.0	0	0	0	0	1
12/05/2021 21:00	0.0	0	0	0	0	1
12/05/2021 22:00	0.0	0	0	0	0	1
12/05/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	191.0 #	0 #	2 #	0 #	0 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	157.7	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/06/2021 00:00	0.0	0	0	0	0	1
12/06/2021 01:00	0.0	0	0	0	0	1
12/06/2021 02:00	0.0	0	0	0	0	1
12/06/2021 03:00	0.0	0	0	0	0	1
12/06/2021 04:00	0.0	0	0	0	0	1
12/06/2021 05:00	0.0	0	0	0	0	1
12/06/2021 06:00	0.0	0	0	0	0	1
12/06/2021 07:00	0.0	0	0	0	0	1
12/06/2021 08:00	0.0	0	0	0	0	1
12/06/2021 09:00	0.0	0	0	0	0	1
12/06/2021 10:00	0.0	0	0	0	0	1
12/06/2021 11:00	0.0	0	0	0	0	1
12/06/2021 12:00	0.0	0	0	0	0	1
12/06/2021 13:00	0.0	0	0	0	0	1
12/06/2021 14:00	0.0	0	0	0	0	1
12/06/2021 15:00	0.0	0	0	0	0	1
12/06/2021 16:00	0.0	0	0	0	0	1
12/06/2021 17:00	0.0	0	0	0	0	1
12/06/2021 18:00	0.0	0	0	0	0	1
12/06/2021 19:00	0.0	0	0	0	0	1
12/06/2021 20:00	0.0	0	0	0	0	1
12/06/2021 21:00	0.0	0	0	0	0	1
12/06/2021 22:00	0.0	0	0	0	0	1
12/06/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/07/2021 00:00	0.0	0	0	0	0	1
12/07/2021 01:00	0.0	0	0	0	0	1
12/07/2021 02:00	0.0	0	0	0	0	1
12/07/2021 03:00	0.0	0	0	0	0	1
12/07/2021 04:00	0.0	0	0	0	0	1
12/07/2021 05:00	0.0	0	0	0	0	1
12/07/2021 06:00	0.0	0	0	0	0	1
12/07/2021 07:00	0.0	0	0	0	0	1
12/07/2021 08:00	0.0	0	0	0	0	1
12/07/2021 09:00	0.0	0	0	0	0	1
12/07/2021 10:00	0.0	0	0	0	0	1
12/07/2021 11:00	0.0	0	0	0	0	1
12/07/2021 12:00	0.0	0	0	0	0	1
12/07/2021 13:00	0.0	0	0	0	0	1
12/07/2021 14:00	0.0	0	0	0	0	1
12/07/2021 15:00	0.0	0	0	0	0	1
12/07/2021 16:00	0.0	0	0	0	0	1
12/07/2021 17:00	0.0	0	0	0	0	1
12/07/2021 18:00	0.0	0	0	0	0	1
12/07/2021 19:00	0.0	0	0	0	0	1
12/07/2021 20:00	0.0	0	0	0	0	1
12/07/2021 21:00	0.0	0	0	0	0	1
12/07/2021 22:00	0.0	0	0	0	0	1
12/07/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/08/2021 00:00	0.0	0	0	0	0	1
12/08/2021 01:00	0.0	0	0	0	0	1
12/08/2021 02:00	0.0	0	0	0	0	1
12/08/2021 03:00	0.0	0	0	0	0	1
12/08/2021 04:00	0.0	0	0	0	0	1
12/08/2021 05:00	0.0	0	0	0	0	1
12/08/2021 06:00	0.0	0	0	0	0	1
12/08/2021 07:00	0.0	0	0	0	0	1
12/08/2021 08:00	0.0	0	0	0	0	1
12/08/2021 09:00	0.0	0	0	0	0	1
12/08/2021 10:00	0.0	0	0	0	0	1
12/08/2021 11:00	0.0	0	0	0	0	1
12/08/2021 12:00	0.0	0	0	0	0	1
12/08/2021 13:00	0.0	0	0	0	0	1
12/08/2021 14:00	0.0	0	0	0	0	1
12/08/2021 15:00	0.0	0	0	0	0	1
12/08/2021 16:00	0.0	0	0	0	0	1
12/08/2021 17:00	0.0	0	0	0	0	1
12/08/2021 18:00	0.0	0	0	0	0	1
12/08/2021 19:00	0.0	0	0	0	0	1
12/08/2021 20:00	0.0	0	0	0	0	1
12/08/2021 21:00	0.0	0	0	0	0	1
12/08/2021 22:00	0.0	0	0	0	0	1
12/08/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/09/2021 00:00	0.0	0	0	0	0	1
12/09/2021 01:00	0.0	0	0	0	0	1
12/09/2021 02:00	0.0	0	0	0	0	1
12/09/2021 03:00	0.0	0	0	0	0	1
12/09/2021 04:00	0.0	0	0	0	0	1
12/09/2021 05:00	0.0	0	0	0	0	1
12/09/2021 06:00	0.0	0	0	0	0	1
12/09/2021 07:00	0.0	0	0	0	0	1
12/09/2021 08:00	0.0	0	0	0	0	1
12/09/2021 09:00	0.0	0	0	0	0	1
12/09/2021 10:00	0.0	0	0	0	0	1
12/09/2021 11:00	0.0	0	0	0	0	1
12/09/2021 12:00	0.0	0	0	0	0	1
12/09/2021 13:00	0.0	0	0	0	0	1
12/09/2021 14:00	0.0	0	0	0	0	1
12/09/2021 15:00	0.0	0	0	0	0	1
12/09/2021 16:00	0.0	0	0	0	0	1
12/09/2021 17:00	0.0	0	0	0	0	1
12/09/2021 18:00	0.0	0	0	0	0	1
12/09/2021 19:00	0.0	0	0	0	0	1
12/09/2021 20:00	0.0	0	0	0	0	1
12/09/2021 21:00	0.0	0	0	0	0	1
12/09/2021 22:00	0.0	0	0	0	0	1
12/09/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/10/2021 00:00	0.0	0	0	0	0	1
12/10/2021 01:00	0.0	0	0	0	0	1
12/10/2021 02:00	0.0	0	0	0	0	1
12/10/2021 03:00	0.0	0	0	0	0	1
12/10/2021 04:00	0.0	0	0	0	0	1
12/10/2021 05:00	0.0	0	0	0	0	1
12/10/2021 06:00	0.0	0	0	0	0	1
12/10/2021 07:00	0.0	0	0	0	0	1
12/10/2021 08:00	0.0	0	0	0	0	1
12/10/2021 09:00	0.0	0	0	0	0	1
12/10/2021 10:00	0.0	0	0	0	0	1
12/10/2021 11:00	0.0	0	0	0	0	1
12/10/2021 12:00	0.0	0	0	0	0	1
12/10/2021 13:00	0.0	0	0	0	0	1
12/10/2021 14:00	0.0	0	0	0	0	1
12/10/2021 15:00	0.0	0	0	0	0	1
12/10/2021 16:00	0.0	0	0	0	0	1
12/10/2021 17:00	0.0	0	0	0	0	1
12/10/2021 18:00	0.0	0	0	0	0	1
12/10/2021 19:00	0.0	0	0	0	0	1
12/10/2021 20:00	0.0	0	0	0	0	1
12/10/2021 21:00	0.0	0	0	0	0	1
12/10/2021 22:00	0.0	0	0	0	0	1
12/10/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/11/2021 00:00	0.0	0	0	0	0	1
12/11/2021 01:00	0.0	0	0	0	0	1
12/11/2021 02:00	0.0	0	0	0	0	1
12/11/2021 03:00	0.0	0	0	0	0	1
12/11/2021 04:00	0.0	0	0	0	0	1
12/11/2021 05:00	0.0	0	0	0	0	1
12/11/2021 06:00	0.0	0	0	0	0	1
12/11/2021 07:00	0.0	0	0	0	0	1
12/11/2021 08:00	0.0	0	0	0	0	1
12/11/2021 09:00	0.0	0	0	0	0	1
12/11/2021 10:00	0.0	0	0	0	0	1
12/11/2021 11:00	0.0	0	0	0	0	1
12/11/2021 12:00	0.0	0	0	0	0	1
12/11/2021 13:00	0.0	0	0	0	0	1
12/11/2021 14:00	0.0	0	0	0	0	1
12/11/2021 15:00	0.0	0	0	0	0	1
12/11/2021 16:00	0.0	0	0	0	0	1
12/11/2021 17:00	0.0	0	0	0	0	1
12/11/2021 18:00	0.0	0	0	0	0	1
12/11/2021 19:00	0.0	0	0	0	0	1
12/11/2021 20:00	0.0	0	0	0	0	1
12/11/2021 21:00	0.0	0	0	0	0	1
12/11/2021 22:00	0.0	0	0	0	0	1
12/11/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/12/2021 00:00	0.0	0	0	0	0	1
12/12/2021 01:00	0.0	0	0	0	0	1
12/12/2021 02:00	0.0	0	0	0	0	1
12/12/2021 03:00	0.0	0	0	0	0	1
12/12/2021 04:00	0.0	0	0	0	0	1
12/12/2021 05:00	0.0	0	0	0	0	1
12/12/2021 06:00	0.0	0	0	0	0	1
12/12/2021 07:00	0.0	0	0	0	0	1
12/12/2021 08:00	0.0	0	0	0	0	1
12/12/2021 09:00	0.0	0	0	0	0	1
12/12/2021 10:00	0.0	0	0	0	0	1
12/12/2021 11:00	0.0	0	0	0	0	1
12/12/2021 12:00	0.0	0	0	0	0	1
12/12/2021 13:00	0.0	0	0	0	0	1
12/12/2021 14:00	0.0	0	0	0	0	1
12/12/2021 15:00	0.0	0	0	0	0	1
12/12/2021 16:00	0.0	0	0	0	0	1
12/12/2021 17:00	0.0	0	0	0	0	1
12/12/2021 18:00	0.0	0	0	0	0	1
12/12/2021 19:00	0.0	0	0	0	0	1
12/12/2021 20:00	0.0	0	0	0	0	1
12/12/2021 21:00	0.0	0	0	0	0	1
12/12/2021 22:00	0.0	0	0	0	0	1
12/12/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/13/2021 00:00	0.0	0	0	0	0	1
12/13/2021 01:00	0.0	0	0	0	0	1
12/13/2021 02:00	0.0	0	0	0	0	1
12/13/2021 03:00	0.0	0	0	0	0	1
12/13/2021 04:00	0.0	0	0	0	0	1
12/13/2021 05:00	0.0	0	0	0	0	1
12/13/2021 06:00	0.0	0	0	0	0	1
12/13/2021 07:00	0.0	0	0	0	0	1
12/13/2021 08:00	0.0	0	0	0	0	1
12/13/2021 09:00	0.0	0	0	0	0	1
12/13/2021 10:00	0.0	0	0	0	0	1
12/13/2021 11:00	0.0	0	0	0	0	1
12/13/2021 12:00	0.0	0	0	0	0	1
12/13/2021 13:00	0.0	0	0	0	0	1
12/13/2021 14:00	0.0	0	0	0	0	1
12/13/2021 15:00	0.0	0	0	0	0	1
12/13/2021 16:00	0.0	0	0	0	0	1
12/13/2021 17:00	0.0	0	0	0	0	1
12/13/2021 18:00	0.0	0	0	0	0	1
12/13/2021 19:00	0.0	0	0	0	0	1
12/13/2021 20:00	0.0	0	0	0	0	1
12/13/2021 21:00	0.0	0	0	0	0	1
12/13/2021 22:00	0.0	0	0	0	0	1
12/13/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/14/2021 00:00	0.0	0	0	0	0	1
12/14/2021 01:00	0.0	0	0	0	0	1
12/14/2021 02:00	0.0	0	0	0	0	1
12/14/2021 03:00	0.0	0	0	0	0	1
12/14/2021 04:00	0.0	0	0	0	0	1
12/14/2021 05:00	0.0	0	0	0	0	1
12/14/2021 06:00	0.0	0	0	0	0	1
12/14/2021 07:00	0.0	0	0	0	0	1
12/14/2021 08:00	0.0	0	0	0	0	1
12/14/2021 09:00	0.0	0	0	0	0	1
12/14/2021 10:00	0.0	0	0	0	0	1
12/14/2021 11:00	0.0	0	0	0	0	1
12/14/2021 12:00	0.0	0	0	0	0	1
12/14/2021 13:00	0.0	0	0	0	0	1
12/14/2021 14:00	0.0	0	0	0	0	1
12/14/2021 15:00	0.0	0	0	0	0	1
12/14/2021 16:00	0.0	0	0	0	0	1
12/14/2021 17:00	0.0	0	0	0	0	1
12/14/2021 18:00	0.0	0	0	0	0	1
12/14/2021 19:00	0.0	0	0	0	0	1
12/14/2021 20:00	0.0	0	0	0	0	1
12/14/2021 21:00	0.0	0	0	0	0	1
12/14/2021 22:00	0.0	0	0	0	0	1
12/14/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/15/2021 00:00	0.0	0	0	0	0	1
12/15/2021 01:00	0.0	0	0	0	0	1
12/15/2021 02:00	0.0	0	0	0	0	1
12/15/2021 03:00	0.0	0	0	0	0	1
12/15/2021 04:00	0.0	0	0	0	0	1
12/15/2021 05:00	0.0	0	0	0	0	1
12/15/2021 06:00	0.0	0	0	0	0	1
12/15/2021 07:00	0.0	0	0	0	0	1
12/15/2021 08:00	0.0	0	0	0	0	1
12/15/2021 09:00	0.0	0	0	0	0	1
12/15/2021 10:00	0.0	0	0	0	0	1
12/15/2021 11:00	0.0	0	0	0	0	1
12/15/2021 12:00	0.0	0	0	0	0	1
12/15/2021 13:00	0.0	0	0	0	0	1
12/15/2021 14:00	0.0	0	0	0	0	1
12/15/2021 15:00	0.0	0	0	0	0	1
12/15/2021 16:00	0.0	0	0	0	0	1
12/15/2021 17:00	0.0	0	0	0	0	1
12/15/2021 18:00	0.0	0	0	0	0	1
12/15/2021 19:00	0.0	0	0	0	0	1
12/15/2021 20:00	0.0	0	0	0	0	1
12/15/2021 21:00	0.0	0	0	0	0	1
12/15/2021 22:00	0.0	0	0	0	0	1
12/15/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/16/2021 00:00	0.0	0	0	0	0	1
12/16/2021 01:00	0.0	0	0	0	0	1
12/16/2021 02:00	0.0	0	0	0	0	1
12/16/2021 03:00	0.0	0	0	0	0	1
12/16/2021 04:00	0.0	0	0	0	0	1
12/16/2021 05:00	0.0	0	0	0	0	1
12/16/2021 06:00	0.0	0	0	0	0	1
12/16/2021 07:00	0.0	0	0	0	0	1
12/16/2021 08:00	0.0	0	0	0	0	1
12/16/2021 09:00	0.0	0	0	0	0	1
12/16/2021 10:00	0.0	0	0	0	0	1
12/16/2021 11:00	0.0	0	0	0	0	1
12/16/2021 12:00	0.0	0	0	0	0	1
12/16/2021 13:00	0.0	0	0	0	0	1
12/16/2021 14:00	0.0	0	0	0	0	1
12/16/2021 15:00	0.0	0	0	0	0	1
12/16/2021 16:00	0.0	0	0	0	0	1
12/16/2021 17:00	0.0	0	0	0	0	1
12/16/2021 18:00	0.0	0	0	0	0	1
12/16/2021 19:00	0.0	0	0	0	0	1
12/16/2021 20:00	0.0	0	0	0	0	1
12/16/2021 21:00	0.0	0	0	0	0	1
12/16/2021 22:00	0.0	0	0	0	0	1
12/16/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/17/2021 00:00	0.0	0	0	0	0	1
12/17/2021 01:00	0.0	0	0	0	0	1
12/17/2021 02:00	0.0	0	0	0	0	1
12/17/2021 03:00	0.0	0	0	0	0	1
12/17/2021 04:00	0.0	0	0	0	0	1
12/17/2021 05:00	0.0	0	0	0	0	1
12/17/2021 06:00	0.0	0	0	0	0	1
12/17/2021 07:00	0.0	0	0	0	0	1
12/17/2021 08:00	0.0	0	0	0	0	1
12/17/2021 09:00	0.0	0	0	0	0	1
12/17/2021 10:00	0.0	0	0	0	0	1
12/17/2021 11:00	0.0	0	0	0	0	1
12/17/2021 12:00	0.0	0	0	0	0	1
12/17/2021 13:00	0.0	0	0	0	0	1
12/17/2021 14:00	0.0	0	0	0	0	1
12/17/2021 15:00	0.0	0	0	0	0	1
12/17/2021 16:00	0.0	0	0	0	0	1
12/17/2021 17:00	0.0	0	0	0	0	1
12/17/2021 18:00	0.0	0	0	0	0	1
12/17/2021 19:00	0.0	0	0	0	0	1
12/17/2021 20:00	0.0	0	0	0	0	1
12/17/2021 21:00	0.0	0	0	0	0	1
12/17/2021 22:00	0.0	0	0	0	0	1
12/17/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/18/2021 00:00	0.0	0	0	0	0	1
12/18/2021 01:00	0.0	0	0	0	0	1
12/18/2021 02:00	0.0	0	0	0	0	1
12/18/2021 03:00	0.0	0	0	0	0	1
12/18/2021 04:00	0.0	0	0	0	0	1
12/18/2021 05:00	0.0	0	0	0	0	1
12/18/2021 06:00	0.0	0	0	0	0	1
12/18/2021 07:00	0.0	0	0	0	0	1
12/18/2021 08:00	0.0	0	0	0	0	1
12/18/2021 09:00	0.0	0	0	0	0	1
12/18/2021 10:00	0.0	0	0	0	0	1
12/18/2021 11:00	0.0	0	0	0	0	1
12/18/2021 12:00	0.0	0	0	0	0	1
12/18/2021 13:00	0.0	0	0	0	0	1
12/18/2021 14:00	0.0	0	0	0	0	1
12/18/2021 15:00	0.0	0	0	0	0	1
12/18/2021 16:00	0.0	0	0	0	0	1
12/18/2021 17:00	0.0	0	0	0	0	1
12/18/2021 18:00	0.0	0	0	0	0	1
12/18/2021 19:00	0.0	0	0	0	0	1
12/18/2021 20:00	0.0	0	0	0	0	1
12/18/2021 21:00	0.0	0	0	0	0	1
12/18/2021 22:00	0.0	0	0	0	0	1
12/18/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/19/2021 00:00	0.0	0	0	0	0	1
12/19/2021 01:00	0.0	0	0	0	0	1
12/19/2021 02:00	0.0	0	0	0	0	1
12/19/2021 03:00	0.0	0	0	0	0	1
12/19/2021 04:00	0.0	0	0	0	0	1
12/19/2021 05:00	0.0	0	0	0	0	1
12/19/2021 06:00	0.0	0	0	0	0	1
12/19/2021 07:00	0.0	0	0	0	0	1
12/19/2021 08:00	0.0	0	0	0	0	1
12/19/2021 09:00	0.0	0	0	0	0	1
12/19/2021 10:00	0.0	0	0	0	0	1
12/19/2021 11:00	0.0	0	0	0	0	1
12/19/2021 12:00	0.0	0	0	0	0	1
12/19/2021 13:00	0.0	0	0	0	0	1
12/19/2021 14:00	0.0	0	0	0	0	1
12/19/2021 15:00	0.0	0	0	0	0	1
12/19/2021 16:00	0.0	0	0	0	0	1
12/19/2021 17:00	0.0	0	0	0	0	1
12/19/2021 18:00	0.0	0	0	0	0	1
12/19/2021 19:00	0.0	0	0	0	0	1
12/19/2021 20:00	0.0	0	0	0	0	1
12/19/2021 21:00	0.0	0	0	0	0	1
12/19/2021 22:00	0.0	0	0	0	0	1
12/19/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/20/2021 00:00	0.0	0	0	0	0	1
12/20/2021 01:00	0.0	0	0	0	0	1
12/20/2021 02:00	0.0	0	0	0	0	1
12/20/2021 03:00	0.0	0	0	0	0	1
12/20/2021 04:00	0.0	0	0	0	0	1
12/20/2021 05:00	0.0	0	0	0	0	1
12/20/2021 06:00	0.0	0	0	0	0	1
12/20/2021 07:00	0.0	0	0	0	0	1
12/20/2021 08:00	0.0	0	0	0	0	1
12/20/2021 09:00	0.0	0	0	0	0	1
12/20/2021 10:00	0.0	0	0	0	0	1
12/20/2021 11:00	0.0	0	0	0	0	1
12/20/2021 12:00	0.0	0	0	0	0	1
12/20/2021 13:00	0.0	0	0	0	0	1
12/20/2021 14:00	0.0	0	0	0	0	1
12/20/2021 15:00	0.0	0	0	0	0	1
12/20/2021 16:00	0.0	0	0	0	0	1
12/20/2021 17:00	0.0	0	0	0	0	1
12/20/2021 18:00	0.0	0	0	0	0	1
12/20/2021 19:00	0.0	0	0	0	0	1
12/20/2021 20:00	0.0	0	0	0	0	1
12/20/2021 21:00	0.0	0	0	0	0	1
12/20/2021 22:00	0.0	0	0	0	0	1
12/20/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/21/2021 00:00	0.0	0	0	0	0	1
12/21/2021 01:00	0.0	0	0	0	0	1
12/21/2021 02:00	0.0	0	0	0	0	1
12/21/2021 03:00	0.0	0	0	0	0	1
12/21/2021 04:00	0.0	0	0	0	0	1
12/21/2021 05:00	0.0	0	0	0	0	1
12/21/2021 06:00	0.0	0	0	0	0	1
12/21/2021 07:00	0.0	0	0	0	0	1
12/21/2021 08:00	0.0	0	0	0	0	1
12/21/2021 09:00	0.0	0	0	0	0	1
12/21/2021 10:00	0.0	0	0	0	0	1
12/21/2021 11:00	0.0	0	0	0	0	1
12/21/2021 12:00	0.0	0	0	0	0	1
12/21/2021 13:00	0.0	0	0	0	0	1
12/21/2021 14:00	0.0	0	0	0	0	1
12/21/2021 15:00	0.0	0	0	0	0	1
12/21/2021 16:00	0.0	0	0	0	0	1
12/21/2021 17:00	0.0	0	0	0	0	1
12/21/2021 18:00	0.0	0	0	0	0	1
12/21/2021 19:00	0.0	0	0	0	0	1
12/21/2021 20:00	0.0	0	0	0	0	1
12/21/2021 21:00	0.0	0	0	0	0	1
12/21/2021 22:00	0.0	0	0	0	0	1
12/21/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/22/2021 00:00	0.0	0	0	0	0	1
12/22/2021 01:00	0.0	0	0	0	0	1
12/22/2021 02:00	0.0	0	0	0	0	1
12/22/2021 03:00	0.0	0	0	0	0	1
12/22/2021 04:00	0.0	0	0	0	0	1
12/22/2021 05:00	0.0	0	0	0	0	1
12/22/2021 06:00	0.0	0	0	0	0	1
12/22/2021 07:00	0.0	0	0	0	0	1
12/22/2021 08:00	0.0	0	0	0	0	1
12/22/2021 09:00	0.0	0	0	0	0	1
12/22/2021 10:00	0.0	0	0	0	0	1
12/22/2021 11:00	0.0	0	0	0	0	1
12/22/2021 12:00	0.0	0	0	0	0	1
12/22/2021 13:00	0.0	0	0	0	0	1
12/22/2021 14:00	0.0	0	0	0	0	1
12/22/2021 15:00	0.0	0	0	0	0	1
12/22/2021 16:00	0.0	0	0	0	0	1
12/22/2021 17:00	0.0	0	0	0	0	1
12/22/2021 18:00	0.0	0	0	0	0	1
12/22/2021 19:00	0.0	0	0	0	0	1
12/22/2021 20:00	0.0	0	0	0	0	1
12/22/2021 21:00	0.0	0	0	0	0	1
12/22/2021 22:00	0.0	0	0	0	0	1
12/22/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/23/2021 00:00	0.0	0	0	0	0	1
12/23/2021 01:00	0.0	0	0	0	0	1
12/23/2021 02:00	0.0	0	0	0	0	1
12/23/2021 03:00	0.0	0	0	0	0	1
12/23/2021 04:00	0.0	0	0	0	0	1
12/23/2021 05:00	0.0	0	0	0	0	1
12/23/2021 06:00	0.0	0	0	0	0	1
12/23/2021 07:00	0.0	0	0	0	0	1
12/23/2021 08:00	0.0	0	0	0	0	1
12/23/2021 09:00	0.0	0	0	0	0	1
12/23/2021 10:00	0.0	0	0	0	0	1
12/23/2021 11:00	0.0	0	0	0	0	1
12/23/2021 12:00	0.0	0	0	0	0	1
12/23/2021 13:00	0.0	0	0	0	0	1
12/23/2021 14:00	0.0	0	0	0	0	1
12/23/2021 15:00	0.0	0	0	0	0	1
12/23/2021 16:00	0.0	0	0	0	0	1
12/23/2021 17:00	0.0	0	0	0	0	1
12/23/2021 18:00	0.0	0	0	0	0	1
12/23/2021 19:00	0.0	0	0	0	0	1
12/23/2021 20:00	0.0	0	0	0	0	1
12/23/2021 21:00	0.0	0	0	0	0	1
12/23/2021 22:00	0.0	0	0	0	0	1
12/23/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/24/2021 00:00	0.0	0	0	0	0	1
12/24/2021 01:00	0.0	0	0	0	0	1
12/24/2021 02:00	0.0	0	0	0	0	1
12/24/2021 03:00	0.0	0	0	0	0	1
12/24/2021 04:00	0.0	0	0	0	0	1
12/24/2021 05:00	0.0	0	0	0	0	1
12/24/2021 06:00	0.0	0	0	0	0	1
12/24/2021 07:00	0.0	0	0	0	0	1
12/24/2021 08:00	0.0	0	0	0	0	1
12/24/2021 09:00	0.0	0	0	0	0	1
12/24/2021 10:00	0.0	0	0	0	0	1
12/24/2021 11:00	0.0	0	0	0	0	1
12/24/2021 12:00	0.0	0	0	0	0	1
12/24/2021 13:00	0.0	0	0	0	0	1
12/24/2021 14:00	0.0	0	0	0	0	1
12/24/2021 15:00	0.0	0	0	0	0	1
12/24/2021 16:00	0.0	0	0	0	0	1
12/24/2021 17:00	0.0	0	0	0	0	1
12/24/2021 18:00	0.0	0	0	0	0	1
12/24/2021 19:00	0.0	0	0	0	0	1
12/24/2021 20:00	0.0	0	0	0	0	1
12/24/2021 21:00	0.0	0	0	0	0	1
12/24/2021 22:00	0.0	0	0	0	0	1
12/24/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/25/2021 00:00	0.0	0	0	0	0	1
12/25/2021 01:00	0.0	0	0	0	0	1
12/25/2021 02:00	0.0	0	0	0	0	1
12/25/2021 03:00	0.0	0	0	0	0	1
12/25/2021 04:00	0.0	0	0	0	0	1
12/25/2021 05:00	0.0	0	0	0	0	1
12/25/2021 06:00	0.0	0	0	0	0	1
12/25/2021 07:00	0.0	0	0	0	0	1
12/25/2021 08:00	0.0	0	0	0	0	1
12/25/2021 09:00	0.0	0	0	0	0	1
12/25/2021 10:00	0.0	0	0	0	0	1
12/25/2021 11:00	0.0	0	0	0	0	1
12/25/2021 12:00	0.0	0	0	0	0	1
12/25/2021 13:00	0.0	0	0	0	0	1
12/25/2021 14:00	0.0	0	0	0	0	1
12/25/2021 15:00	0.0	0	0	0	0	1
12/25/2021 16:00	0.0	0	0	0	0	1
12/25/2021 17:00	0.0	0	0	0	0	1
12/25/2021 18:00	0.0	0	0	0	0	1
12/25/2021 19:00	0.0	0	0	0	0	1
12/25/2021 20:00	0.0	0	0	0	0	1
12/25/2021 21:00	0.0	0	0	0	0	1
12/25/2021 22:00	0.0	0	0	0	0	1
12/25/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/26/2021 00:00	2.8	0	0	0	1	0
12/26/2021 01:00	0.0	0	0	0	0	0
12/26/2021 02:00	0.0	0	0	0	0	0
12/26/2021 03:00	0.0	0	0	0	0	0
12/26/2021 04:00	0.0	0	0	0	0	0
12/26/2021 05:00	0.0	0	0	0	0	0
12/26/2021 06:00	0.0	0	0	0	0	0
12/26/2021 07:00	0.0	0	0	0	0	0
12/26/2021 08:00	0.0	0	0	0	0	0
12/26/2021 09:00	0.0	0	0	0	0	0
12/26/2021 10:00	10.4	0	1	0	0	0
12/26/2021 11:00	37.1	0	1	0	0	0
12/26/2021 12:00	119.4	0	1	0	0	0
12/26/2021 13:00	0.0	0	0	0	0	1
12/26/2021 14:00	0.0	0	0	0	0	1
12/26/2021 15:00	0.0	0	0	0	0	1
12/26/2021 16:00	0.0	0	0	0	0	1
12/26/2021 17:00	0.0	0	0	0	0	1
12/26/2021 18:00	0.0	0	0	0	0	1
12/26/2021 19:00	0.0	0	0	0	0	1
12/26/2021 20:00	0.0	0	0	0	0	1
12/26/2021 21:00	0.0	0	0	0	0	1
12/26/2021 22:00	0.0	0	0	0	0	1
12/26/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	169.7 #	0 #	3 #	0 #	1 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	119.4	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/27/2021 00:00	0.0	0	0	0	0	1
12/27/2021 01:00	0.0	0	0	0	0	1
12/27/2021 02:00	0.0	0	0	0	0	1
12/27/2021 03:00	0.0	0	0	0	0	1
12/27/2021 04:00	0.0	0	0	0	0	1
12/27/2021 05:00	0.0	0	0	0	0	1
12/27/2021 06:00	0.0	0	0	0	0	1
12/27/2021 07:00	0.0	0	0	0	0	1
12/27/2021 08:00	0.0	0	0	0	0	1
12/27/2021 09:00	0.0	0	0	0	0	1
12/27/2021 10:00	0.0	0	0	0	0	1
12/27/2021 11:00	0.0	0	0	0	0	1
12/27/2021 12:00	0.0	0	0	0	0	1
12/27/2021 13:00	0.0	0	0	0	0	1
12/27/2021 14:00	0.0	0	0	0	0	1
12/27/2021 15:00	0.0	0	0	0	0	1
12/27/2021 16:00	0.0	0	0	0	0	1
12/27/2021 17:00	0.0	0	0	0	0	1
12/27/2021 18:00	0.0	0	0	0	0	1
12/27/2021 19:00	0.0	0	0	0	0	1
12/27/2021 20:00	0.0	0	0	0	0	1
12/27/2021 21:00	0.0	0	0	0	0	1
12/27/2021 22:00	0.0	0	0	0	0	1
12/27/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/28/2021 00:00	0.0	0	0	0	0	1
12/28/2021 01:00	0.0	0	0	0	0	1
12/28/2021 02:00	0.0	0	0	0	0	1
12/28/2021 03:00	0.0	0	0	0	0	1
12/28/2021 04:00	0.0	0	0	0	0	1
12/28/2021 05:00	0.0	0	0	0	0	1
12/28/2021 06:00	0.0	0	0	0	0	1
12/28/2021 07:00	0.0	0	0	0	0	1
12/28/2021 08:00	0.0	0	0	0	0	1
12/28/2021 09:00	0.0	0	0	0	0	1
12/28/2021 10:00	0.0	0	0	0	0	1
12/28/2021 11:00	0.0	0	0	0	0	1
12/28/2021 12:00	0.0	0	0	0	0	1
12/28/2021 13:00	0.0	0	0	0	0	1
12/28/2021 14:00	0.0	0	0	0	0	1
12/28/2021 15:00	0.0	0	0	0	0	1
12/28/2021 16:00	0.0	0	0	0	0	1
12/28/2021 17:00	0.0	0	0	0	0	1
12/28/2021 18:00	0.0	0	0	0	0	1
12/28/2021 19:00	0.0	0	0	0	0	1
12/28/2021 20:00	0.0	0	0	0	0	1
12/28/2021 21:00	0.0	0	0	0	0	1
12/28/2021 22:00	0.0	0	0	0	0	1
12/28/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/29/2021 00:00	0.0	0	0	0	0	1
12/29/2021 01:00	0.0	0	0	0	0	1
12/29/2021 02:00	0.0	0	0	0	0	1
12/29/2021 03:00	0.0	0	0	0	0	1
12/29/2021 04:00	0.0	0	0	0	0	1
12/29/2021 05:00	0.0	0	0	0	0	1
12/29/2021 06:00	0.0	0	0	0	0	1
12/29/2021 07:00	0.0	0	0	0	0	1
12/29/2021 08:00	0.0	0	0	0	0	1
12/29/2021 09:00	0.0	0	0	0	0	1
12/29/2021 10:00	0.0	0	0	0	0	1
12/29/2021 11:00	0.0	0	0	0	0	1
12/29/2021 12:00	0.0	0	0	0	0	1
12/29/2021 13:00	0.0	0	0	0	0	1
12/29/2021 14:00	0.0	0	0	0	0	1
12/29/2021 15:00	0.0	0	0	0	0	1
12/29/2021 16:00	0.0	0	0	0	0	1
12/29/2021 17:00	0.0	0	0	0	0	1
12/29/2021 18:00	0.0	0	0	0	0	1
12/29/2021 19:00	0.0	0	0	0	0	1
12/29/2021 20:00	0.0	0	0	0	0	1
12/29/2021 21:00	0.0	0	0	0	0	1
12/29/2021 22:00	0.0	0	0	0	0	1
12/29/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/30/2021 00:00	0.0	0	0	0	0	1
12/30/2021 01:00	0.0	0	0	0	0	1
12/30/2021 02:00	0.0	0	0	0	0	1
12/30/2021 03:00	0.0	0	0	0	0	1
12/30/2021 04:00	0.0	0	0	0	0	1
12/30/2021 05:00	0.0	0	0	0	0	1
12/30/2021 06:00	0.0	0	0	0	0	1
12/30/2021 07:00	0.0	0	0	0	0	1
12/30/2021 08:00	0.0	0	0	0	0	1
12/30/2021 09:00	0.0	0	0	0	0	1
12/30/2021 10:00	0.0	0	0	0	0	1
12/30/2021 11:00	0.0	0	0	0	0	1
12/30/2021 12:00	0.0	0	0	0	0	1
12/30/2021 13:00	0.0	0	0	0	0	1
12/30/2021 14:00	0.0	0	0	0	0	1
12/30/2021 15:00	0.0	0	0	0	0	1
12/30/2021 16:00	0.0	0	0	0	0	1
12/30/2021 17:00	0.0	0	0	0	0	1
12/30/2021 18:00	0.0	0	0	0	0	1
12/30/2021 19:00	0.0	0	0	0	0	1
12/30/2021 20:00	0.0	0	0	0	0	1
12/30/2021 21:00	0.0	0	0	0	0	1
12/30/2021 22:00	0.0	0	0	0	0	1
12/30/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/31/2021 00:00	0.0	0	0	0	0	1
12/31/2021 01:00	0.0	0	0	0	0	1
12/31/2021 02:00	0.0	0	0	0	0	1
12/31/2021 03:00	0.0	0	0	0	0	1
12/31/2021 04:00	0.0	0	0	0	0	1
12/31/2021 05:00	0.0	0	0	0	0	1
12/31/2021 06:00	0.0	0	0	0	0	1
12/31/2021 07:00	0.0	0	0	0	0	1
12/31/2021 08:00	0.0	0	0	0	0	1
12/31/2021 09:00	0.0	0	0	0	0	1
12/31/2021 10:00	0.0	0	0	0	0	1
12/31/2021 11:00	0.0	0	0	0	0	1
12/31/2021 12:00	0.0	0	0	0	0	1
12/31/2021 13:00	0.0	0	0	0	0	1
12/31/2021 14:00	0.0	0	0	0	0	1
12/31/2021 15:00	0.0	0	0	0	0	1
12/31/2021 16:00	0.0	0	0	0	0	1
12/31/2021 17:00	0.0	0	0	0	0	1
12/31/2021 18:00	0.0	0	0	0	0	1
12/31/2021 19:00	0.0	0	0	0	0	1
12/31/2021 20:00	0.0	0	0	0	0	1
12/31/2021 21:00	0.0	0	0	0	0	1
12/31/2021 22:00	0.0	0	0	0	0	1
12/31/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/01/2021 00:00	0.0	0	0	0	0	1
10/01/2021 01:00	0.0	0	0	0	0	1
10/01/2021 02:00	0.0	0	0	0	0	1
10/01/2021 03:00	0.0	0	0	0	0	1
10/01/2021 04:00	0.0	0	0	0	0	1
10/01/2021 05:00	0.0	0	0	0	0	1
10/01/2021 06:00	0.0	0	0	0	0	1
10/01/2021 07:00	0.0	0	0	0	0	1
10/01/2021 08:00	0.0	0	0	0	0	1
10/01/2021 09:00	0.0	0	0	0	0	1
10/01/2021 10:00	0.0	0	0	0	0	1
10/01/2021 11:00	0.0	0	0	0	0	1
10/01/2021 12:00	0.0	0	0	0	0	1
10/01/2021 13:00	0.0	0	0	0	0	1
10/01/2021 14:00	0.0	0	0	0	0	1
10/01/2021 15:00	0.0	0	0	0	0	1
10/01/2021 16:00	0.0	0	0	0	0	1
10/01/2021 17:00	0.0	0	0	0	0	1
10/01/2021 18:00	0.0	0	0	0	0	1
10/01/2021 19:00	0.0	0	0	0	0	1
10/01/2021 20:00	0.0	0	0	0	0	1
10/01/2021 21:00	0.0	0	0	0	0	1
10/01/2021 22:00	0.0	0	0	0	0	1
10/01/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/02/2021 00:00	0.0	0	0	0	0	1
10/02/2021 01:00	0.0	0	0	0	0	1
10/02/2021 02:00	0.0	0	0	0	0	1
10/02/2021 03:00	0.0	0	0	0	0	1
10/02/2021 04:00	0.0	0	0	0	0	1
10/02/2021 05:00	0.0	0	0	0	0	1
10/02/2021 06:00	0.0	0	0	0	0	1
10/02/2021 07:00	0.0	0	0	0	0	1
10/02/2021 08:00	0.0	0	0	0	0	1
10/02/2021 09:00	0.0	0	0	0	0	1
10/02/2021 10:00	0.0	0	0	0	0	1
10/02/2021 11:00	0.0	0	0	0	0	1
10/02/2021 12:00	0.0	0	0	0	0	1
10/02/2021 13:00	0.0	0	0	0	0	1
10/02/2021 14:00	0.0	0	0	0	0	1
10/02/2021 15:00	0.0	0	0	0	0	1
10/02/2021 16:00	0.0	0	0	0	0	1
10/02/2021 17:00	0.0	0	0	0	0	1
10/02/2021 18:00	0.0	0	0	0	0	1
10/02/2021 19:00	0.0	0	0	0	0	1
10/02/2021 20:00	0.0	0	0	0	0	1
10/02/2021 21:00	0.0	0	0	0	0	1
10/02/2021 22:00	0.0	0	0	0	0	1
10/02/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/03/2021 00:00	0.0	0	0	0	0	1
10/03/2021 01:00	0.0	0	0	0	0	1
10/03/2021 02:00	0.0	0	0	0	0	1
10/03/2021 03:00	0.0	0	0	0	0	1
10/03/2021 04:00	0.0	0	0	0	0	1
10/03/2021 05:00	0.0	0	0	0	0	1
10/03/2021 06:00	0.0	0	0	0	0	1
10/03/2021 07:00	0.0	0	0	0	0	1
10/03/2021 08:00	0.0	0	0	0	0	1
10/03/2021 09:00	0.0	0	0	0	0	1
10/03/2021 10:00	0.0	0	0	0	0	1
10/03/2021 11:00	0.0	0	0	0	0	1
10/03/2021 12:00	0.0	0	0	0	0	1
10/03/2021 13:00	0.0	0	0	0	0	1
10/03/2021 14:00	0.0	0	0	0	0	1
10/03/2021 15:00	0.0	0	0	0	0	1
10/03/2021 16:00	0.0	0	0	0	0	1
10/03/2021 17:00	0.0	0	0	0	0	1
10/03/2021 18:00	0.0	0	0	0	0	1
10/03/2021 19:00	0.0	0	0	0	0	1
10/03/2021 20:00	0.0	0	0	0	0	1
10/03/2021 21:00	0.0	0	0	0	0	1
10/03/2021 22:00	0.0	0	0	0	0	1
10/03/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/04/2021 00:00	0.0	0	0	0	0	1
10/04/2021 01:00	0.0	0	0	0	0	1
10/04/2021 02:00	0.0	0	0	0	0	1
10/04/2021 03:00	0.0	0	0	0	0	1
10/04/2021 04:00	0.0	0	0	0	0	1
10/04/2021 05:00	0.0	0	0	0	0	1
10/04/2021 06:00	0.0	0	0	0	0	1
10/04/2021 07:00	0.0	0	0	0	0	1
10/04/2021 08:00	0.0	0	0	0	0	1
10/04/2021 09:00	0.0	0	0	0	0	1
10/04/2021 10:00	0.0	0	0	0	0	1
10/04/2021 11:00	0.0	0	0	0	0	1
10/04/2021 12:00	0.0	0	0	0	0	1
10/04/2021 13:00	0.0	0	0	0	0	1
10/04/2021 14:00	0.0	0	0	0	0	1
10/04/2021 15:00	0.0	0	0	0	0	1
10/04/2021 16:00	0.0	0	0	0	0	1
10/04/2021 17:00	0.0	0	0	0	0	1
10/04/2021 18:00	0.0	0	0	0	0	1
10/04/2021 19:00	0.0	0	0	0	0	1
10/04/2021 20:00	0.0	0	0	0	0	1
10/04/2021 21:00	0.0	0	0	0	0	1
10/04/2021 22:00	0.0	0	0	0	0	1
10/04/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/05/2021 00:00	0.0	0	0	0	0	1
10/05/2021 01:00	0.0	0	0	0	0	1
10/05/2021 02:00	0.0	0	0	0	0	1
10/05/2021 03:00	0.0	0	0	0	0	1
10/05/2021 04:00	0.0	0	0	0	0	1
10/05/2021 05:00	0.0	0	0	0	0	1
10/05/2021 06:00	0.0	0	0	0	0	1
10/05/2021 07:00	0.0	0	0	0	0	1
10/05/2021 08:00	0.0	0	0	0	0	1
10/05/2021 09:00	0.0	0	0	0	0	1
10/05/2021 10:00	0.0	0	0	0	0	1
10/05/2021 11:00	0.0	0	0	0	0	1
10/05/2021 12:00	0.0	0	0	0	0	1
10/05/2021 13:00	0.0	0	0	0	0	1
10/05/2021 14:00	0.0	0	0	0	0	1
10/05/2021 15:00	0.0	0	0	0	0	1
10/05/2021 16:00	0.0	0	0	0	0	1
10/05/2021 17:00	0.0	0	0	0	0	1
10/05/2021 18:00	0.0	0	0	0	0	1
10/05/2021 19:00	0.0	0	0	0	0	1
10/05/2021 20:00	0.0	0	0	0	0	1
10/05/2021 21:00	0.0	0	0	0	0	1
10/05/2021 22:00	0.0	0	0	0	0	1
10/05/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/06/2021 00:00	0.0	0	0	0	0	1
10/06/2021 01:00	0.0	0	0	0	0	1
10/06/2021 02:00	0.0	0	0	0	0	1
10/06/2021 03:00	0.0	0	0	0	0	1
10/06/2021 04:00	0.0	0	0	0	0	1
10/06/2021 05:00	0.0	0	0	0	0	1
10/06/2021 06:00	0.0	0	0	0	0	1
10/06/2021 07:00	0.0	0	0	0	0	1
10/06/2021 08:00	0.0	0	0	0	0	1
10/06/2021 09:00	0.0	0	0	0	0	1
10/06/2021 10:00	0.0	0	0	0	0	1
10/06/2021 11:00	0.0	0	0	0	0	1
10/06/2021 12:00	0.0	0	0	0	0	1
10/06/2021 13:00	0.0	0	0	0	0	1
10/06/2021 14:00	0.0	0	0	0	0	1
10/06/2021 15:00	0.0	0	0	0	0	1
10/06/2021 16:00	0.0	0	0	0	0	1
10/06/2021 17:00	0.0	0	0	0	0	1
10/06/2021 18:00	0.0	0	0	0	0	1
10/06/2021 19:00	0.0	0	0	0	0	1
10/06/2021 20:00	0.0	0	0	0	0	1
10/06/2021 21:00	0.0	0	0	0	0	1
10/06/2021 22:00	0.0	0	0	0	0	1
10/06/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/07/2021 00:00	0.0	0	0	0	0	1
10/07/2021 01:00	0.0	0	0	0	0	1
10/07/2021 02:00	0.0	0	0	0	0	1
10/07/2021 03:00	0.0	0	0	0	0	1
10/07/2021 04:00	0.0	0	0	0	0	1
10/07/2021 05:00	0.0	0	0	0	0	1
10/07/2021 06:00	0.0	0	0	0	0	1
10/07/2021 07:00	0.0	0	0	0	0	1
10/07/2021 08:00	0.0	0	0	0	0	1
10/07/2021 09:00	0.0	0	0	0	0	1
10/07/2021 10:00	0.0	0	0	0	0	1
10/07/2021 11:00	0.0	0	0	0	0	1
10/07/2021 12:00	0.0	0	0	0	0	1
10/07/2021 13:00	0.0	0	0	0	0	1
10/07/2021 14:00	0.0	0	0	0	0	1
10/07/2021 15:00	0.0	0	0	0	0	1
10/07/2021 16:00	0.0	0	0	0	0	1
10/07/2021 17:00	0.0	0	0	0	0	1
10/07/2021 18:00	0.0	0	0	0	0	1
10/07/2021 19:00	0.0	0	0	0	0	1
10/07/2021 20:00	0.0	0	0	0	0	1
10/07/2021 21:00	0.0	0	0	0	0	1
10/07/2021 22:00	0.0	0	0	0	0	1
10/07/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/08/2021 00:00	0.0	0	0	0	0	1
10/08/2021 01:00	0.0	0	0	0	0	1
10/08/2021 02:00	0.0	0	0	0	0	1
10/08/2021 03:00	0.0	0	0	0	0	1
10/08/2021 04:00	0.0	0	0	0	0	1
10/08/2021 05:00	0.0	0	0	0	0	1
10/08/2021 06:00	0.0	0	0	0	0	1
10/08/2021 07:00	0.0	0	0	0	0	1
10/08/2021 08:00	0.0	0	0	0	0	1
10/08/2021 09:00	0.0	0	0	0	0	1
10/08/2021 10:00	0.0	0	0	0	0	1
10/08/2021 11:00	0.0	0	0	0	0	1
10/08/2021 12:00	0.0	0	0	0	0	1
10/08/2021 13:00	0.0	0	0	0	0	1
10/08/2021 14:00	0.0	0	0	0	0	1
10/08/2021 15:00	0.0	0	0	0	0	1
10/08/2021 16:00	0.0	0	0	0	0	1
10/08/2021 17:00	0.0	0	0	0	0	1
10/08/2021 18:00	0.0	0	0	0	0	1
10/08/2021 19:00	0.0	0	0	0	0	1
10/08/2021 20:00	0.0	0	0	0	0	1
10/08/2021 21:00	35.8	0	0	0	1	0
10/08/2021 22:00	0.0	0	0	0	0	0
10/08/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	35.8 #	0 #	0 #	0 #	1 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	35.8	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/09/2021 00:00	0.0	0	0	0	0	0
10/09/2021 01:00	0.0	0	0	0	0	0
10/09/2021 02:00	0.0	0	0	0	0	0
10/09/2021 03:00	0.0	0	0	0	0	0
10/09/2021 04:00	0.0	0	0	0	0	0
10/09/2021 05:00	0.0	0	0	0	0	0
10/09/2021 06:00	0.0	0	0	0	0	0
10/09/2021 07:00	0.0	0	0	0	0	0
10/09/2021 08:00	0.0	0	0	0	0	0
10/09/2021 09:00	0.0	0	0	0	0	0
10/09/2021 10:00	0.0	0	0	0	0	0
10/09/2021 11:00	0.0	0	0	0	0	0
10/09/2021 12:00	0.0	0	0	0	0	0
10/09/2021 13:00	0.0	0	0	0	0	0
10/09/2021 14:00	0.0	0	0	0	0	0
10/09/2021 15:00	0.0	0	0	0	0	0
10/09/2021 16:00	0.0	0	0	0	0	0
10/09/2021 17:00	0.0	0	0	0	0	0
10/09/2021 18:00	0.0	0	0	0	0	0
10/09/2021 19:00	0.0	0	0	0	0	0
10/09/2021 20:00	0.0	0	0	0	0	0
10/09/2021 21:00	0.0	0	0	0	0	0
10/09/2021 22:00	0.0	0	0	0	0	0
10/09/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/10/2021 00:00	0.0	0	0	0	0	0
10/10/2021 01:00	0.0	0	0	0	0	0
10/10/2021 02:00	0.0	0	0	0	0	0
10/10/2021 03:00	0.0	0	0	0	0	0
10/10/2021 04:00	0.0	0	0	0	0	0
10/10/2021 05:00	0.0	0	0	0	0	0
10/10/2021 06:00	0.0	0	0	0	0	0
10/10/2021 07:00	0.0	0	0	0	0	0
10/10/2021 08:00	0.0	0	0	0	0	0
10/10/2021 09:00	0.0	0	0	0	0	0
10/10/2021 10:00	0.0	0	0	0	0	0
10/10/2021 11:00	0.0	0	0	0	0	0
10/10/2021 12:00	0.0	0	0	0	0	0
10/10/2021 13:00	0.0	0	0	0	0	0
10/10/2021 14:00	0.0	0	0	0	0	0
10/10/2021 15:00	0.0	0	0	0	0	0
10/10/2021 16:00	0.0	0	0	0	0	0
10/10/2021 17:00	0.0	0	0	0	0	0
10/10/2021 18:00	0.0	0	0	0	0	0
10/10/2021 19:00	0.0	0	0	0	0	0
10/10/2021 20:00	0.0	0	0	0	0	0
10/10/2021 21:00	0.0	0	0	0	0	0
10/10/2021 22:00	0.0	0	0	0	0	0
10/10/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/11/2021 00:00	0.0	0	0	0	0	0
10/11/2021 01:00	0.0	0	0	0	0	0
10/11/2021 02:00	0.0	0	0	0	0	0
10/11/2021 03:00	0.0	0	0	0	0	0
10/11/2021 04:00	0.0	0	0	0	0	0
10/11/2021 05:00	0.0	0	0	0	0	0
10/11/2021 06:00	0.0	0	0	0	0	0
10/11/2021 07:00	0.0	0	0	0	0	0
10/11/2021 08:00	0.0	0	0	0	0	0
10/11/2021 09:00	0.0	0	0	0	0	0
10/11/2021 10:00	0.0	0	0	0	0	0
10/11/2021 11:00	0.0	0	0	0	0	0
10/11/2021 12:00	0.0	0	0	0	0	0
10/11/2021 13:00	0.0	0	0	0	0	0
10/11/2021 14:00	0.0	0	0	0	0	0
10/11/2021 15:00	0.0	0	0	0	0	0
10/11/2021 16:00	0.0	0	0	0	0	0
10/11/2021 17:00	0.0	0	0	0	0	0
10/11/2021 18:00	0.0	0	0	0	0	0
10/11/2021 19:00	0.0	0	0	0	0	0
10/11/2021 20:00	0.0	0	0	0	0	0
10/11/2021 21:00	0.0	0	0	0	0	0
10/11/2021 22:00	0.0	0	0	0	0	0
10/11/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/12/2021 00:00	0.0	0	0	0	0	0
10/12/2021 01:00	0.0	0	0	0	0	0
10/12/2021 02:00	0.0	0	0	0	0	0
10/12/2021 03:00	0.0	0	0	0	0	0
10/12/2021 04:00	0.0	0	0	0	0	0
10/12/2021 05:00	0.0	0	0	0	0	0
10/12/2021 06:00	0.0	0	0	0	0	0
10/12/2021 07:00	0.0	0	0	0	0	0
10/12/2021 08:00	0.0	0	0	0	0	0
10/12/2021 09:00	0.0	0	0	0	0	0
10/12/2021 10:00	0.0	0	0	0	0	0
10/12/2021 11:00	0.0	0	0	0	0	0
10/12/2021 12:00	0.0	0	0	0	0	0
10/12/2021 13:00	0.0	0	0	0	0	0
10/12/2021 14:00	0.0	0	0	0	0	0
10/12/2021 15:00	0.0	0	0	0	0	0
10/12/2021 16:00	0.0	0	0	0	0	0
10/12/2021 17:00	0.0	0	0	0	0	0
10/12/2021 18:00	0.0	0	0	0	0	0
10/12/2021 19:00	0.0	0	0	0	0	0
10/12/2021 20:00	0.0	0	0	0	0	0
10/12/2021 21:00	0.0	0	0	0	0	0
10/12/2021 22:00	0.0	0	0	0	0	0
10/12/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/13/2021 00:00	0.0	0	0	0	0	0
10/13/2021 01:00	0.0	0	0	0	0	0
10/13/2021 02:00	0.0	0	0	0	0	0
10/13/2021 03:00	0.0	0	0	0	0	0
10/13/2021 04:00	0.0	0	0	0	0	0
10/13/2021 05:00	0.0	0	0	0	0	0
10/13/2021 06:00	0.0	0	0	0	0	0
10/13/2021 07:00	0.0	0	0	0	0	0
10/13/2021 08:00	0.0	0	0	0	0	0
10/13/2021 09:00	0.0	0	0	0	0	0
10/13/2021 10:00	0.0	0	0	0	0	0
10/13/2021 11:00	0.0	0	0	0	0	0
10/13/2021 12:00	0.0	0	0	0	0	0
10/13/2021 13:00	0.0	0	0	0	0	0
10/13/2021 14:00	0.0	0	0	0	0	0
10/13/2021 15:00	0.0	0	0	0	0	0
10/13/2021 16:00	0.0	0	0	0	0	0
10/13/2021 17:00	0.0	0	0	0	0	0
10/13/2021 18:00	0.0	0	0	0	0	0
10/13/2021 19:00	0.0	0	0	0	0	0
10/13/2021 20:00	0.0	0	0	0	0	0
10/13/2021 21:00	0.0	0	0	0	0	0
10/13/2021 22:00	0.0	0	0	0	0	0
10/13/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/14/2021 00:00	0.0	0	0	0	0	0
10/14/2021 01:00	0.0	0	0	0	0	0
10/14/2021 02:00	0.0	0	0	0	0	0
10/14/2021 03:00	0.0	0	0	0	0	0
10/14/2021 04:00	0.0	0	0	0	0	0
10/14/2021 05:00	0.0	0	0	0	0	0
10/14/2021 06:00	0.0	0	0	0	0	0
10/14/2021 07:00	0.0	0	0	0	0	0
10/14/2021 08:00	0.0	0	0	0	0	0
10/14/2021 09:00	0.0	0	0	0	0	0
10/14/2021 10:00	0.0	0	0	0	0	0
10/14/2021 11:00	0.0	0	0	0	0	0
10/14/2021 12:00	0.0	0	0	0	0	0
10/14/2021 13:00	0.0	0	0	0	0	0
10/14/2021 14:00	0.0	0	0	0	0	0
10/14/2021 15:00	0.0	0	0	0	0	0
10/14/2021 16:00	0.0	0	0	0	0	0
10/14/2021 17:00	0.0	0	0	0	0	0
10/14/2021 18:00	0.0	0	0	0	0	0
10/14/2021 19:00	0.0	0	0	0	0	0
10/14/2021 20:00	0.0	0	0	0	0	0
10/14/2021 21:00	0.0	0	0	0	0	0
10/14/2021 22:00	0.0	0	0	0	0	0
10/14/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/15/2021 00:00	0.0	0	0	0	0	0
10/15/2021 01:00	0.0	0	0	0	0	0
10/15/2021 02:00	0.0	0	0	0	0	0
10/15/2021 03:00	0.0	0	0	0	0	0
10/15/2021 04:00	0.0	0	0	0	0	0
10/15/2021 05:00	0.0	0	0	0	0	0
10/15/2021 06:00	0.0	0	0	0	0	0
10/15/2021 07:00	0.0	0	0	0	0	0
10/15/2021 08:00	0.0	0	0	0	0	0
10/15/2021 09:00	0.0	0	0	0	0	0
10/15/2021 10:00	0.0	0	0	0	0	0
10/15/2021 11:00	0.0	0	0	0	0	0
10/15/2021 12:00	0.0	0	0	0	0	0
10/15/2021 13:00	0.0	0	0	0	0	0
10/15/2021 14:00	0.0	0	0	0	0	0
10/15/2021 15:00	0.0	0	0	0	0	0
10/15/2021 16:00	0.0	0	0	0	0	0
10/15/2021 17:00	0.0	0	0	0	0	0
10/15/2021 18:00	0.0	0	0	0	0	0
10/15/2021 19:00	0.0	0	0	0	0	0
10/15/2021 20:00	0.0	0	0	0	0	0
10/15/2021 21:00	0.0	0	0	0	0	0
10/15/2021 22:00	0.0	0	0	0	0	0
10/15/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/16/2021 00:00	0.0	0	0	0	0	0
10/16/2021 01:00	0.0	0	0	0	0	0
10/16/2021 02:00	0.0	0	0	0	0	0
10/16/2021 03:00	0.0	0	0	0	0	0
10/16/2021 04:00	0.0	0	0	0	0	0
10/16/2021 05:00	0.0	0	0	0	0	0
10/16/2021 06:00	0.0	0	0	0	0	0
10/16/2021 07:00	0.0	0	0	0	0	0
10/16/2021 08:00	0.0	0	0	0	0	0
10/16/2021 09:00	0.0	0	0	0	0	0
10/16/2021 10:00	0.0	0	0	0	0	0
10/16/2021 11:00	0.0	0	0	0	0	0
10/16/2021 12:00	0.0	0	0	0	0	0
10/16/2021 13:00	0.0	0	0	0	0	0
10/16/2021 14:00	0.0	0	0	0	0	0
10/16/2021 15:00	0.0	0	0	0	0	0
10/16/2021 16:00	0.0	0	0	0	0	0
10/16/2021 17:00	0.0	0	0	0	0	0
10/16/2021 18:00	0.0	0	0	0	0	0
10/16/2021 19:00	0.0	0	0	0	0	0
10/16/2021 20:00	0.0	0	0	0	0	0
10/16/2021 21:00	0.0	0	0	0	0	0
10/16/2021 22:00	0.0	0	0	0	0	0
10/16/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/17/2021 00:00	0.0	0	0	0	0	0
10/17/2021 01:00	0.0	0	0	0	0	0
10/17/2021 02:00	0.0	0	0	0	0	0
10/17/2021 03:00	0.0	0	0	0	0	0
10/17/2021 04:00	0.0	0	0	0	0	0
10/17/2021 05:00	0.0	0	0	0	0	0
10/17/2021 06:00	0.0	0	0	0	0	0
10/17/2021 07:00	0.0	0	0	0	0	0
10/17/2021 08:00	0.0	0	0	0	0	0
10/17/2021 09:00	0.0	0	0	0	0	0
10/17/2021 10:00	0.0	0	0	0	0	0
10/17/2021 11:00	0.0	0	0	0	0	0
10/17/2021 12:00	0.0	0	0	0	0	0
10/17/2021 13:00	0.0	0	0	0	0	0
10/17/2021 14:00	0.0	0	0	0	0	0
10/17/2021 15:00	0.0	0	0	0	0	0
10/17/2021 16:00	0.0	0	0	0	0	0
10/17/2021 17:00	0.0	0	0	0	0	0
10/17/2021 18:00	0.0	0	0	0	0	0
10/17/2021 19:00	0.0	0	0	0	0	0
10/17/2021 20:00	0.0	0	0	0	0	0
10/17/2021 21:00	0.0	0	0	0	0	0
10/17/2021 22:00	0.0	0	0	0	0	0
10/17/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/18/2021 00:00	0.0	0	0	0	0	0
10/18/2021 01:00	0.0	0	0	0	0	0
10/18/2021 02:00	0.0	0	0	0	0	0
10/18/2021 03:00	0.0	0	0	0	0	0
10/18/2021 04:00	0.0	0	0	0	0	0
10/18/2021 05:00	0.0	0	0	0	0	0
10/18/2021 06:00	0.0	0	0	0	0	0
10/18/2021 07:00	0.0	0	0	0	0	0
10/18/2021 08:00	0.0	0	0	0	0	0
10/18/2021 09:00	0.0	0	0	0	0	0
10/18/2021 10:00	0.0	0	0	0	0	0
10/18/2021 11:00	0.0	0	0	0	0	0
10/18/2021 12:00	0.0	0	0	0	0	0
10/18/2021 13:00	0.0	0	0	0	0	0
10/18/2021 14:00	0.0	0	0	0	0	0
10/18/2021 15:00	0.0	0	0	0	0	0
10/18/2021 16:00	0.0	0	0	0	0	0
10/18/2021 17:00	0.0	0	0	0	0	0
10/18/2021 18:00	0.0	0	0	0	0	0
10/18/2021 19:00	0.0	0	0	0	0	0
10/18/2021 20:00	0.0	0	0	0	0	0
10/18/2021 21:00	0.0	0	0	0	0	0
10/18/2021 22:00	0.0	0	0	0	0	0
10/18/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/19/2021 00:00	0.0	0	0	0	0	0
10/19/2021 01:00	0.0	0	0	0	0	0
10/19/2021 02:00	0.0	0	0	0	0	0
10/19/2021 03:00	0.0	0	0	0	0	0
10/19/2021 04:00	0.0	0	0	0	0	0
10/19/2021 05:00	0.0	0	0	0	0	0
10/19/2021 06:00	0.0	0	0	0	0	0
10/19/2021 07:00	0.0	0	0	0	0	0
10/19/2021 08:00	0.0	0	0	0	0	0
10/19/2021 09:00	0.0	0	0	0	0	0
10/19/2021 10:00	0.0	0	0	0	0	0
10/19/2021 11:00	0.0	0	0	0	0	0
10/19/2021 12:00	0.0	0	0	0	0	0
10/19/2021 13:00	0.0	0	0	0	0	0
10/19/2021 14:00	0.0	0	0	0	0	0
10/19/2021 15:00	0.0	0	0	0	0	0
10/19/2021 16:00	0.0	0	0	0	0	0
10/19/2021 17:00	0.0	0	0	0	0	0
10/19/2021 18:00	0.0	0	0	0	0	0
10/19/2021 19:00	0.0	0	0	0	0	0
10/19/2021 20:00	0.0	0	0	0	0	0
10/19/2021 21:00	0.0	0	0	0	0	0
10/19/2021 22:00	0.0	0	0	0	0	0
10/19/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/20/2021 00:00	0.0	0	0	0	0	0
10/20/2021 01:00	0.0	0	0	0	0	0
10/20/2021 02:00	0.0	0	0	0	0	0
10/20/2021 03:00	0.0	0	0	0	0	0
10/20/2021 04:00	0.0	0	0	0	0	0
10/20/2021 05:00	0.0	0	0	0	0	0
10/20/2021 06:00	0.0	0	0	0	0	0
10/20/2021 07:00	0.0	0	0	0	0	0
10/20/2021 08:00	0.0	0	0	0	0	0
10/20/2021 09:00	0.0	0	0	0	0	0
10/20/2021 10:00	0.0	0	0	0	0	0
10/20/2021 11:00	0.0	0	0	0	0	0
10/20/2021 12:00	0.0	0	0	0	0	0
10/20/2021 13:00	1,613.9	1	0	0	0	0
10/20/2021 14:00	5,953.9	1	0	0	0	0
10/20/2021 15:00	2,115.6	1	0	0	0	0
10/20/2021 16:00	0.0	0	0	0	0	1
10/20/2021 17:00	0.0	0	0	0	0	1
10/20/2021 18:00	0.0	0	0	0	0	1
10/20/2021 19:00	0.0	0	0	0	0	1
10/20/2021 20:00	0.0	0	0	0	0	1
10/20/2021 21:00	0.0	0	0	0	0	1
10/20/2021 22:00	26.6	0	0	0	1	0
10/20/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	9,710.0 #	3 #	0 #	0 #	1 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,953.9	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/21/2021 00:00	0.0	0	0	0	0	0
10/21/2021 01:00	0.0	0	0	0	0	0
10/21/2021 02:00	0.0	0	0	0	0	0
10/21/2021 03:00	0.0	0	0	0	0	0
10/21/2021 04:00	0.0	0	0	0	0	0
10/21/2021 05:00	0.0	0	0	0	0	0
10/21/2021 06:00	0.0	0	0	0	0	0
10/21/2021 07:00	0.0	0	0	0	0	0
10/21/2021 08:00	0.0	0	0	0	0	0
10/21/2021 09:00	0.0	0	0	0	0	0
10/21/2021 10:00	0.0	0	0	0	0	0
10/21/2021 11:00	0.0	0	0	0	0	0
10/21/2021 12:00	0.0	0	0	0	0	0
10/21/2021 13:00	0.0	0	0	0	0	0
10/21/2021 14:00	0.0	0	0	0	0	0
10/21/2021 15:00	0.0	0	0	0	0	0
10/21/2021 16:00	0.0	0	0	0	0	0
10/21/2021 17:00	0.0	0	0	0	0	0
10/21/2021 18:00	0.0	0	0	0	0	0
10/21/2021 19:00	0.0	0	0	0	0	0
10/21/2021 20:00	0.0	0	0	0	0	0
10/21/2021 21:00	0.0	0	0	0	0	0
10/21/2021 22:00	0.0	0	0	0	0	0
10/21/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/22/2021 00:00	0.0	0	0	0	0	0
10/22/2021 01:00	0.0	0	0	0	0	0
10/22/2021 02:00	0.0	0	0	0	0	0
10/22/2021 03:00	0.0	0	0	0	0	0
10/22/2021 04:00	0.0	0	0	0	0	0
10/22/2021 05:00	0.0	0	0	0	0	0
10/22/2021 06:00	0.0	0	0	0	0	0
10/22/2021 07:00	0.0	0	0	0	0	0
10/22/2021 08:00	0.0	0	0	0	0	0
10/22/2021 09:00	0.0	0	0	0	0	0
10/22/2021 10:00	0.0	0	0	0	0	0
10/22/2021 11:00	0.0	0	0	0	0	0
10/22/2021 12:00	0.0	0	0	0	0	0
10/22/2021 13:00	0.0	0	0	0	0	0
10/22/2021 14:00	0.0	0	0	0	0	0
10/22/2021 15:00	0.0	0	0	0	0	0
10/22/2021 16:00	0.0	0	0	0	0	0
10/22/2021 17:00	0.0	0	0	0	0	0
10/22/2021 18:00	0.0	0	0	0	0	0
10/22/2021 19:00	0.0	0	0	0	0	0
10/22/2021 20:00	0.0	0	0	0	0	0
10/22/2021 21:00	0.0	0	0	0	0	0
10/22/2021 22:00	0.0	0	0	0	0	0
10/22/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/23/2021 00:00	0.0	0	0	0	0	0
10/23/2021 01:00	1,948.8	0	1	0	0	0
10/23/2021 02:00	3,642.2	0	1	0	0	0
10/23/2021 03:00	6,395.4	0	1	0	0	0
10/23/2021 04:00	0.0	0	0	0	0	1
10/23/2021 05:00	0.0	0	0	0	0	1
10/23/2021 06:00	0.0	0	0	0	0	1
10/23/2021 07:00	0.0	0	0	0	0	1
10/23/2021 08:00	0.0	0	0	0	0	1
10/23/2021 09:00	0.0	0	0	0	0	1
10/23/2021 10:00	0.0	0	0	0	0	1
10/23/2021 11:00	0.0	0	0	0	0	1
10/23/2021 12:00	0.0	0	0	0	0	1
10/23/2021 13:00	0.0	0	0	0	0	1
10/23/2021 14:00	0.0	0	0	0	0	1
10/23/2021 15:00	0.0	0	0	0	0	1
10/23/2021 16:00	0.0	0	0	0	0	1
10/23/2021 17:00	0.0	0	0	0	0	1
10/23/2021 18:00	0.0	0	0	0	0	1
10/23/2021 19:00	0.0	0	0	0	0	1
10/23/2021 20:00	0.0	0	0	0	0	1
10/23/2021 21:00	0.0	0	0	0	0	1
10/23/2021 22:00	54.4	0	0	0	1	0
10/23/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	12,040.8 #	0 #	3 #	0 #	1 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,395.4	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/24/2021 00:00	0.0	0	0	0	0	0
10/24/2021 01:00	0.0	0	0	0	0	0
10/24/2021 02:00	0.0	0	0	0	0	0
10/24/2021 03:00	0.0	0	0	0	0	0
10/24/2021 04:00	0.0	0	0	0	0	0
10/24/2021 05:00	0.0	0	0	0	0	0
10/24/2021 06:00	0.0	0	0	0	0	0
10/24/2021 07:00	2,374.1	0	1	0	0	0
10/24/2021 08:00	5,340.1	0	1	0	0	0
10/24/2021 09:00	0.0	0	0	0	0	1
10/24/2021 10:00	0.0	0	0	0	0	1
10/24/2021 11:00	0.0	0	0	0	0	1
10/24/2021 12:00	0.0	0	0	0	0	1
10/24/2021 13:00	0.0	0	0	0	0	1
10/24/2021 14:00	0.0	0	0	0	0	1
10/24/2021 15:00	0.0	0	0	0	0	1
10/24/2021 16:00	0.0	0	0	0	0	1
10/24/2021 17:00	0.0	0	0	0	0	1
10/24/2021 18:00	0.0	0	0	0	0	1
10/24/2021 19:00	0.0	0	0	0	0	1
10/24/2021 20:00	0.0	0	0	0	0	1
10/24/2021 21:00	0.0	0	0	0	0	1
10/24/2021 22:00	0.0	0	0	0	0	1
10/24/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,714.2 #	0 #	2 #	0 #	0 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,340.1	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/25/2021 00:00	0.0	0	0	0	0	1
10/25/2021 01:00	0.0	0	0	0	0	1
10/25/2021 02:00	0.0	0	0	0	0	1
10/25/2021 03:00	0.0	0	0	0	0	1
10/25/2021 04:00	0.0	0	0	0	0	1
10/25/2021 05:00	0.0	0	0	0	0	1
10/25/2021 06:00	0.0	0	0	0	0	1
10/25/2021 07:00	0.0	0	0	0	0	1
10/25/2021 08:00	0.0	0	0	0	0	1
10/25/2021 09:00	0.0	0	0	0	0	1
10/25/2021 10:00	0.0	0	0	0	0	1
10/25/2021 11:00	0.0	0	0	0	0	1
10/25/2021 12:00	0.0	0	0	0	0	1
10/25/2021 13:00	0.0	0	0	0	0	1
10/25/2021 14:00	0.0	0	0	0	0	1
10/25/2021 15:00	0.0	0	0	0	0	1
10/25/2021 16:00	0.0	0	0	0	0	1
10/25/2021 17:00	0.0	0	0	0	0	1
10/25/2021 18:00	0.0	0	0	0	0	1
10/25/2021 19:00	0.0	0	0	0	0	1
10/25/2021 20:00	0.0	0	0	0	0	1
10/25/2021 21:00	0.0	0	0	0	0	1
10/25/2021 22:00	0.0	0	0	0	0	1
10/25/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/26/2021 00:00	0.0	0	0	0	0	1
10/26/2021 01:00	0.0	0	0	0	0	1
10/26/2021 02:00	0.0	0	0	0	0	1
10/26/2021 03:00	0.0	0	0	0	0	1
10/26/2021 04:00	0.0	0	0	0	0	1
10/26/2021 05:00	0.0	0	0	0	0	1
10/26/2021 06:00	0.0	0	0	0	0	1
10/26/2021 07:00	0.0	0	0	0	0	1
10/26/2021 08:00	0.0	0	0	0	0	1
10/26/2021 09:00	0.0	0	0	0	0	1
10/26/2021 10:00	0.0	0	0	0	0	1
10/26/2021 11:00	0.0	0	0	0	0	1
10/26/2021 12:00	0.0	0	0	0	0	1
10/26/2021 13:00	0.0	0	0	0	0	1
10/26/2021 14:00	0.0	0	0	0	0	1
10/26/2021 15:00	0.0	0	0	0	0	1
10/26/2021 16:00	0.0	0	0	0	0	1
10/26/2021 17:00	0.0	0	0	0	0	1
10/26/2021 18:00	0.0	0	0	0	0	1
10/26/2021 19:00	0.0	0	0	0	0	1
10/26/2021 20:00	0.0	0	0	0	0	1
10/26/2021 21:00	0.0	0	0	0	0	1
10/26/2021 22:00	0.0	0	0	0	0	1
10/26/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/27/2021 00:00	0.0	0	0	0	0	1
10/27/2021 01:00	0.0	0	0	0	0	1
10/27/2021 02:00	0.0	0	0	0	0	1
10/27/2021 03:00	0.0	0	0	0	0	1
10/27/2021 04:00	0.0	0	0	0	0	1
10/27/2021 05:00	0.0	0	0	0	0	1
10/27/2021 06:00	0.0	0	0	0	0	1
10/27/2021 07:00	0.0	0	0	0	0	1
10/27/2021 08:00	0.0	0	0	0	0	1
10/27/2021 09:00	0.0	0	0	0	0	1
10/27/2021 10:00	0.0	0	0	0	0	1
10/27/2021 11:00	0.0	0	0	0	0	1
10/27/2021 12:00	0.0	0	0	0	0	1
10/27/2021 13:00	0.0	0	0	0	0	1
10/27/2021 14:00	0.0	0	0	0	0	1
10/27/2021 15:00	0.0	0	0	0	0	1
10/27/2021 16:00	0.0	0	0	0	0	1
10/27/2021 17:00	0.0	0	0	0	0	1
10/27/2021 18:00	0.0	0	0	0	0	1
10/27/2021 19:00	0.0	0	0	0	0	1
10/27/2021 20:00	0.0	0	0	0	0	1
10/27/2021 21:00	0.0	0	0	0	0	1
10/27/2021 22:00	0.0	0	0	0	0	1
10/27/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/28/2021 00:00	0.0	0	0	0	0	1
10/28/2021 01:00	0.0	0	0	0	0	1
10/28/2021 02:00	0.0	0	0	0	0	1
10/28/2021 03:00	0.0	0	0	0	0	1
10/28/2021 04:00	0.0	0	0	0	0	1
10/28/2021 05:00	0.0	0	0	0	0	1
10/28/2021 06:00	0.0	0	0	0	0	1
10/28/2021 07:00	0.0	0	0	0	0	1
10/28/2021 08:00	0.0	0	0	0	0	1
10/28/2021 09:00	0.0	0	0	0	0	1
10/28/2021 10:00	0.0	0	0	0	0	1
10/28/2021 11:00	0.0	0	0	0	0	1
10/28/2021 12:00	0.0	0	0	0	0	1
10/28/2021 13:00	0.0	0	0	0	0	1
10/28/2021 14:00	0.0	0	0	0	0	1
10/28/2021 15:00	0.0	0	0	0	0	1
10/28/2021 16:00	0.0	0	0	0	0	1
10/28/2021 17:00	0.0	0	0	0	0	1
10/28/2021 18:00	0.0	0	0	0	0	1
10/28/2021 19:00	0.0	0	0	0	0	1
10/28/2021 20:00	0.0	0	0	0	0	1
10/28/2021 21:00	0.0	0	0	0	0	1
10/28/2021 22:00	0.0	0	0	0	0	1
10/28/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/29/2021 00:00	0.0	0	0	0	0	1
10/29/2021 01:00	0.0	0	0	0	0	1
10/29/2021 02:00	0.0	0	0	0	0	1
10/29/2021 03:00	0.0	0	0	0	0	1
10/29/2021 04:00	0.0	0	0	0	0	1
10/29/2021 05:00	0.0	0	0	0	0	1
10/29/2021 06:00	0.0	0	0	0	0	1
10/29/2021 07:00	0.0	0	0	0	0	1
10/29/2021 08:00	0.0	0	0	0	0	1
10/29/2021 09:00	0.0	0	0	0	0	1
10/29/2021 10:00	0.0	0	0	0	0	1
10/29/2021 11:00	0.0	0	0	0	0	1
10/29/2021 12:00	0.0	0	0	0	0	1
10/29/2021 13:00	0.0	0	0	0	0	1
10/29/2021 14:00	0.0	0	0	0	0	1
10/29/2021 15:00	0.0	0	0	0	0	1
10/29/2021 16:00	0.0	0	0	0	0	1
10/29/2021 17:00	0.0	0	0	0	0	1
10/29/2021 18:00	0.0	0	0	0	0	1
10/29/2021 19:00	0.0	0	0	0	0	1
10/29/2021 20:00	0.0	0	0	0	0	1
10/29/2021 21:00	0.0	0	0	0	0	1
10/29/2021 22:00	0.0	0	0	0	0	1
10/29/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/30/2021 00:00	0.0	0	0	0	0	1
10/30/2021 01:00	0.0	0	0	0	0	1
10/30/2021 02:00	0.0	0	0	0	0	1
10/30/2021 03:00	0.0	0	0	0	0	1
10/30/2021 04:00	0.0	0	0	0	0	1
10/30/2021 05:00	0.0	0	0	0	0	1
10/30/2021 06:00	0.0	0	0	0	0	1
10/30/2021 07:00	0.0	0	0	0	0	1
10/30/2021 08:00	0.0	0	0	0	0	1
10/30/2021 09:00	0.0	0	0	0	0	1
10/30/2021 10:00	0.0	0	0	0	0	1
10/30/2021 11:00	0.0	0	0	0	0	1
10/30/2021 12:00	0.0	0	0	0	0	1
10/30/2021 13:00	0.0	0	0	0	0	1
10/30/2021 14:00	0.0	0	0	0	0	1
10/30/2021 15:00	0.0	0	0	0	0	1
10/30/2021 16:00	0.0	0	0	0	0	1
10/30/2021 17:00	0.0	0	0	0	0	1
10/30/2021 18:00	0.0	0	0	0	0	1
10/30/2021 19:00	0.0	0	0	0	0	1
10/30/2021 20:00	0.0	0	0	0	0	1
10/30/2021 21:00	0.0	0	0	0	0	1
10/30/2021 22:00	0.0	0	0	0	0	1
10/30/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/31/2021 00:00	0.0	0	0	0	0	1
10/31/2021 01:00	0.0	0	0	0	0	1
10/31/2021 02:00	0.0	0	0	0	0	1
10/31/2021 03:00	0.0	0	0	0	0	1
10/31/2021 04:00	0.0	0	0	0	0	1
10/31/2021 05:00	0.0	0	0	0	0	1
10/31/2021 06:00	0.0	0	0	0	0	1
10/31/2021 07:00	0.0	0	0	0	0	1
10/31/2021 08:00	0.0	0	0	0	0	1
10/31/2021 09:00	0.0	0	0	0	0	1
10/31/2021 10:00	0.0	0	0	0	0	1
10/31/2021 11:00	0.0	0	0	0	0	1
10/31/2021 12:00	0.0	0	0	0	0	1
10/31/2021 13:00	0.0	0	0	0	0	1
10/31/2021 14:00	0.0	0	0	0	0	1
10/31/2021 15:00	0.0	0	0	0	0	1
10/31/2021 16:00	0.0	0	0	0	0	1
10/31/2021 17:00	0.0	0	0	0	0	1
10/31/2021 18:00	0.0	0	0	0	0	1
10/31/2021 19:00	0.0	0	0	0	0	1
10/31/2021 20:00	0.0	0	0	0	0	1
10/31/2021 21:00	0.0	0	0	0	0	1
10/31/2021 22:00	0.0	0	0	0	0	1
10/31/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/01/2021 00:00	0.0	0	0	0	0	1
11/01/2021 01:00	0.0	0	0	0	0	1
11/01/2021 02:00	0.0	0	0	0	0	1
11/01/2021 03:00	0.0	0	0	0	0	1
11/01/2021 04:00	0.0	0	0	0	0	1
11/01/2021 05:00	0.0	0	0	0	0	1
11/01/2021 06:00	0.0	0	0	0	0	1
11/01/2021 07:00	0.0	0	0	0	0	1
11/01/2021 08:00	0.0	0	0	0	0	1
11/01/2021 09:00	0.0	0	0	0	0	1
11/01/2021 10:00	0.0	0	0	0	0	1
11/01/2021 11:00	0.0	0	0	0	0	1
11/01/2021 12:00	0.0	0	0	0	0	1
11/01/2021 13:00	0.0	0	0	0	0	1
11/01/2021 14:00	0.0	0	0	0	0	1
11/01/2021 15:00	0.0	0	0	0	0	1
11/01/2021 16:00	0.0	0	0	0	0	1
11/01/2021 17:00	0.0	0	0	0	0	1
11/01/2021 18:00	0.0	0	0	0	0	1
11/01/2021 19:00	0.0	0	0	0	0	1
11/01/2021 20:00	0.0	0	0	0	0	1
11/01/2021 21:00	0.0	0	0	0	0	1
11/01/2021 22:00	0.0	0	0	0	0	1
11/01/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/02/2021 00:00	0.0	0	0	0	0	1
11/02/2021 01:00	0.0	0	0	0	0	1
11/02/2021 02:00	0.0	0	0	0	0	1
11/02/2021 03:00	0.0	0	0	0	0	1
11/02/2021 04:00	0.0	0	0	0	0	1
11/02/2021 05:00	0.0	0	0	0	0	1
11/02/2021 06:00	0.0	0	0	0	0	1
11/02/2021 07:00	0.0	0	0	0	0	1
11/02/2021 08:00	0.0	0	0	0	0	1
11/02/2021 09:00	0.0	0	0	0	0	1
11/02/2021 10:00	0.0	0	0	0	0	1
11/02/2021 11:00	0.0	0	0	0	0	1
11/02/2021 12:00	0.0	0	0	0	0	1
11/02/2021 13:00	0.0	0	0	0	0	1
11/02/2021 14:00	0.0	0	0	0	0	1
11/02/2021 15:00	0.0	0	0	0	0	1
11/02/2021 16:00	0.0	0	0	0	0	1
11/02/2021 17:00	0.0	0	0	0	0	1
11/02/2021 18:00	0.0	0	0	0	0	1
11/02/2021 19:00	0.0	0	0	0	0	1
11/02/2021 20:00	0.0	0	0	0	0	1
11/02/2021 21:00	0.0	0	0	0	0	1
11/02/2021 22:00	0.0	0	0	0	0	1
11/02/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/03/2021 00:00	0.0	0	0	0	0	1
11/03/2021 01:00	0.0	0	0	0	0	1
11/03/2021 02:00	0.0	0	0	0	0	1
11/03/2021 03:00	0.0	0	0	0	0	1
11/03/2021 04:00	0.0	0	0	0	0	1
11/03/2021 05:00	0.0	0	0	0	0	1
11/03/2021 06:00	0.0	0	0	0	0	1
11/03/2021 07:00	0.0	0	0	0	0	1
11/03/2021 08:00	0.0	0	0	0	0	1
11/03/2021 09:00	0.0	0	0	0	0	1
11/03/2021 10:00	0.0	0	0	0	0	1
11/03/2021 11:00	0.0	0	0	0	0	1
11/03/2021 12:00	0.0	0	0	0	0	1
11/03/2021 13:00	0.0	0	0	0	0	1
11/03/2021 14:00	0.0	0	0	0	0	1
11/03/2021 15:00	0.0	0	0	0	0	1
11/03/2021 16:00	0.0	0	0	0	0	1
11/03/2021 17:00	0.0	0	0	0	0	1
11/03/2021 18:00	0.0	0	0	0	0	1
11/03/2021 19:00	0.0	0	0	0	0	1
11/03/2021 20:00	0.0	0	0	0	0	1
11/03/2021 21:00	0.0	0	0	0	0	1
11/03/2021 22:00	0.0	0	0	0	0	1
11/03/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/04/2021 00:00	0.0	0	0	0	0	1
11/04/2021 01:00	0.0	0	0	0	0	1
11/04/2021 02:00	0.0	0	0	0	0	1
11/04/2021 03:00	0.0	0	0	0	0	1
11/04/2021 04:00	0.0	0	0	0	0	1
11/04/2021 05:00	0.0	0	0	0	0	1
11/04/2021 06:00	0.0	0	0	0	0	1
11/04/2021 07:00	0.0	0	0	0	0	1
11/04/2021 08:00	0.0	0	0	0	0	1
11/04/2021 09:00	0.0	0	0	0	0	1
11/04/2021 10:00	0.0	0	0	0	0	1
11/04/2021 11:00	0.0	0	0	0	0	1
11/04/2021 12:00	0.0	0	0	0	0	1
11/04/2021 13:00	0.0	0	0	0	0	1
11/04/2021 14:00	0.0	0	0	0	0	1
11/04/2021 15:00	0.0	0	0	0	0	1
11/04/2021 16:00	0.0	0	0	0	0	1
11/04/2021 17:00	0.0	0	0	0	0	1
11/04/2021 18:00	0.0	0	0	0	0	1
11/04/2021 19:00	0.0	0	0	0	0	1
11/04/2021 20:00	0.0	0	0	0	0	1
11/04/2021 21:00	0.0	0	0	0	0	1
11/04/2021 22:00	0.0	0	0	0	0	1
11/04/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/05/2021 00:00	0.0	0	0	0	0	1
11/05/2021 01:00	0.0	0	0	0	0	1
11/05/2021 02:00	0.0	0	0	0	0	1
11/05/2021 03:00	0.0	0	0	0	0	1
11/05/2021 04:00	0.0	0	0	0	0	1
11/05/2021 05:00	0.0	0	0	0	0	1
11/05/2021 06:00	0.0	0	0	0	0	1
11/05/2021 07:00	0.0	0	0	0	0	1
11/05/2021 08:00	0.0	0	0	0	0	1
11/05/2021 09:00	0.0	0	0	0	0	1
11/05/2021 10:00	0.0	0	0	0	0	1
11/05/2021 11:00	0.0	0	0	0	0	1
11/05/2021 12:00	0.0	0	0	0	0	1
11/05/2021 13:00	0.0	0	0	0	0	1
11/05/2021 14:00	0.0	0	0	0	0	1
11/05/2021 15:00	0.0	0	0	0	0	1
11/05/2021 16:00	0.0	0	0	0	0	1
11/05/2021 17:00	0.0	0	0	0	0	1
11/05/2021 18:00	0.0	0	0	0	0	1
11/05/2021 19:00	0.0	0	0	0	0	1
11/05/2021 20:00	0.0	0	0	0	0	1
11/05/2021 21:00	0.0	0	0	0	0	1
11/05/2021 22:00	0.0	0	0	0	0	1
11/05/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/06/2021 00:00	0.0	0	0	0	0	1
11/06/2021 01:00	0.0	0	0	0	0	1
11/06/2021 02:00	0.0	0	0	0	0	1
11/06/2021 03:00	0.0	0	0	0	0	1
11/06/2021 04:00	0.0	0	0	0	0	1
11/06/2021 05:00	0.0	0	0	0	0	1
11/06/2021 06:00	0.0	0	0	0	0	1
11/06/2021 07:00	0.0	0	0	0	0	1
11/06/2021 08:00	0.0	0	0	0	0	1
11/06/2021 09:00	0.0	0	0	0	0	1
11/06/2021 10:00	0.0	0	0	0	0	1
11/06/2021 11:00	0.0	0	0	0	0	1
11/06/2021 12:00	0.0	0	0	0	0	1
11/06/2021 13:00	0.0	0	0	0	0	1
11/06/2021 14:00	0.0	0	0	0	0	1
11/06/2021 15:00	0.0	0	0	0	0	1
11/06/2021 16:00	0.0	0	0	0	0	1
11/06/2021 17:00	0.0	0	0	0	0	1
11/06/2021 18:00	0.0	0	0	0	0	1
11/06/2021 19:00	0.0	0	0	0	0	1
11/06/2021 20:00	0.0	0	0	0	0	1
11/06/2021 21:00	0.0	0	0	0	0	1
11/06/2021 22:00	26.1	0	0	0	1	0
11/06/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	26.1 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	26.1	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/07/2021 00:00	0.0	0	0	0	0	0
11/07/2021 01:00	0.0	0	0	0	0	0
11/07/2021 02:00	0.0	0	0	0	0	0
11/07/2021 03:00	0.0	0	0	0	0	0
11/07/2021 04:00	0.0	0	0	0	0	0
11/07/2021 05:00	0.0	0	0	0	0	0
11/07/2021 06:00	0.0	0	0	0	0	0
11/07/2021 07:00	0.0	0	0	0	0	0
11/07/2021 08:00	0.0	0	0	0	0	0
11/07/2021 09:00	0.0	0	0	0	0	0
11/07/2021 10:00	0.0	0	0	0	0	0
11/07/2021 11:00	0.0	0	0	0	0	0
11/07/2021 12:00	0.0	0	0	0	0	0
11/07/2021 13:00	0.0	0	0	0	0	0
11/07/2021 14:00	0.0	0	0	0	0	0
11/07/2021 15:00	0.0	0	0	0	0	0
11/07/2021 16:00	0.0	0	0	0	0	0
11/07/2021 17:00	0.0	0	0	0	0	0
11/07/2021 18:00	0.0	0	0	0	0	0
11/07/2021 19:00	0.0	0	0	0	0	0
11/07/2021 20:00	0.0	0	0	0	0	0
11/07/2021 21:00	0.0	0	0	0	0	0
11/07/2021 22:00	0.0	0	0	0	0	0
11/07/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/08/2021 00:00	0.0	0	0	0	0	0
11/08/2021 01:00	0.0	0	0	0	0	0
11/08/2021 02:00	0.0	0	0	0	0	0
11/08/2021 03:00	0.0	0	0	0	0	0
11/08/2021 04:00	0.0	0	0	0	0	0
11/08/2021 05:00	0.0	0	0	0	0	0
11/08/2021 06:00	0.0	0	0	0	0	0
11/08/2021 07:00	0.0	0	0	0	0	0
11/08/2021 08:00	0.0	0	0	0	0	0
11/08/2021 09:00	0.0	0	0	0	0	0
11/08/2021 10:00	0.0	0	0	0	0	0
11/08/2021 11:00	0.0	0	0	0	0	0
11/08/2021 12:00	0.0	0	0	0	0	0
11/08/2021 13:00	0.0	0	0	0	0	0
11/08/2021 14:00	0.0	0	0	0	0	0
11/08/2021 15:00	0.0	0	0	0	0	0
11/08/2021 16:00	0.0	0	0	0	0	0
11/08/2021 17:00	0.0	0	0	0	0	0
11/08/2021 18:00	0.0	0	0	0	0	0
11/08/2021 19:00	0.0	0	0	0	0	0
11/08/2021 20:00	0.0	0	0	0	0	0
11/08/2021 21:00	0.0	0	0	0	0	0
11/08/2021 22:00	0.0	0	0	0	0	0
11/08/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/09/2021 00:00	0.0	0	0	0	0	0
11/09/2021 01:00	0.0	0	0	0	0	0
11/09/2021 02:00	0.0	0	0	0	0	0
11/09/2021 03:00	0.0	0	0	0	0	0
11/09/2021 04:00	0.0	0	0	0	0	0
11/09/2021 05:00	0.0	0	0	0	0	0
11/09/2021 06:00	0.0	0	0	0	0	0
11/09/2021 07:00	2,915.6	0	1	0	0	0
11/09/2021 08:00	6,264.5	0	1	0	0	0
11/09/2021 09:00	0.0	0	0	0	0	1
11/09/2021 10:00	0.0	0	0	0	0	1
11/09/2021 11:00	0.0	0	0	0	0	1
11/09/2021 12:00	0.0	0	0	0	0	1
11/09/2021 13:00	0.0	0	0	0	0	1
11/09/2021 14:00	0.0	0	0	0	0	1
11/09/2021 15:00	0.0	0	0	0	0	1
11/09/2021 16:00	0.0	0	0	0	0	1
11/09/2021 17:00	0.0	0	0	0	0	1
11/09/2021 18:00	0.0	0	0	0	0	1
11/09/2021 19:00	0.0	0	0	0	0	1
11/09/2021 20:00	0.0	0	0	0	0	1
11/09/2021 21:00	0.0	0	0	0	0	1
11/09/2021 22:00	0.0	0	0	0	0	1
11/09/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	9,180.1 #	0 #	2 #	0 #	0 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,264.5	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/10/2021 00:00	0.0	0	0	0	0	1
11/10/2021 01:00	0.0	0	0	0	0	1
11/10/2021 02:00	0.0	0	0	0	0	1
11/10/2021 03:00	0.0	0	0	0	0	1
11/10/2021 04:00	0.0	0	0	0	0	1
11/10/2021 05:00	0.0	0	0	0	0	1
11/10/2021 06:00	0.0	0	0	0	0	1
11/10/2021 07:00	0.0	0	0	0	0	1
11/10/2021 08:00	0.0	0	0	0	0	1
11/10/2021 09:00	0.0	0	0	0	0	1
11/10/2021 10:00	0.0	0	0	0	0	1
11/10/2021 11:00	0.0	0	0	0	0	1
11/10/2021 12:00	0.0	0	0	0	0	1
11/10/2021 13:00	0.0	0	0	0	0	1
11/10/2021 14:00	0.0	0	0	0	0	1
11/10/2021 15:00	0.0	0	0	0	0	1
11/10/2021 16:00	0.0	0	0	0	0	1
11/10/2021 17:00	0.0	0	0	0	0	1
11/10/2021 18:00	0.0	0	0	0	0	1
11/10/2021 19:00	0.0	0	0	0	0	1
11/10/2021 20:00	0.0	0	0	0	0	1
11/10/2021 21:00	0.0	0	0	0	0	1
11/10/2021 22:00	0.0	0	0	0	0	1
11/10/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/11/2021 00:00	0.0	0	0	0	0	1
11/11/2021 01:00	43.7	0	0	0	1	0
11/11/2021 02:00	0.0	0	0	0	0	0
11/11/2021 03:00	0.0	0	0	0	0	0
11/11/2021 04:00	0.0	0	0	0	0	0
11/11/2021 05:00	0.0	0	0	0	0	0
11/11/2021 06:00	0.0	0	0	0	0	0
11/11/2021 07:00	0.0	0	0	0	0	0
11/11/2021 08:00	0.0	0	0	0	0	0
11/11/2021 09:00	1,310.6	0	1	0	0	0
11/11/2021 10:00	7,581.7	0	1	0	0	0
11/11/2021 11:00	0.0	0	0	0	0	1
11/11/2021 12:00	0.0	0	0	0	0	1
11/11/2021 13:00	0.0	0	0	0	0	1
11/11/2021 14:00	0.0	0	0	0	0	1
11/11/2021 15:00	0.0	0	0	0	0	1
11/11/2021 16:00	0.0	0	0	0	0	1
11/11/2021 17:00	0.0	0	0	0	0	1
11/11/2021 18:00	0.0	0	0	0	0	1
11/11/2021 19:00	0.0	0	0	0	0	1
11/11/2021 20:00	0.0	0	0	0	0	1
11/11/2021 21:00	0.0	0	0	0	0	1
11/11/2021 22:00	0.0	0	0	0	0	1
11/11/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	8,936.0 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	7,581.7	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/12/2021 00:00	0.0	0	0	0	0	1
11/12/2021 01:00	0.0	0	0	0	0	1
11/12/2021 02:00	0.0	0	0	0	0	1
11/12/2021 03:00	0.0	0	0	0	0	1
11/12/2021 04:00	0.0	0	0	0	0	1
11/12/2021 05:00	0.0	0	0	0	0	1
11/12/2021 06:00	0.0	0	0	0	0	1
11/12/2021 07:00	0.0	0	0	0	0	1
11/12/2021 08:00	0.0	0	0	0	0	1
11/12/2021 09:00	0.0	0	0	0	0	1
11/12/2021 10:00	0.0	0	0	0	0	1
11/12/2021 11:00	0.0	0	0	0	0	1
11/12/2021 12:00	0.0	0	0	0	0	1
11/12/2021 13:00	0.0	0	0	0	0	1
11/12/2021 14:00	0.0	0	0	0	0	1
11/12/2021 15:00	0.0	0	0	0	0	1
11/12/2021 16:00	0.0	0	0	0	0	1
11/12/2021 17:00	0.0	0	0	0	0	1
11/12/2021 18:00	0.0	0	0	0	0	1
11/12/2021 19:00	0.0	0	0	0	0	1
11/12/2021 20:00	0.0	0	0	0	0	1
11/12/2021 21:00	0.0	0	0	0	0	1
11/12/2021 22:00	0.0	0	0	0	0	1
11/12/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/13/2021 00:00	42.3	0	0	0	1	0
11/13/2021 01:00	0.0	0	0	0	0	0
11/13/2021 02:00	0.0	0	0	0	0	0
11/13/2021 03:00	0.0	0	0	0	0	0
11/13/2021 04:00	0.0	0	0	0	0	0
11/13/2021 05:00	0.0	0	0	0	0	0
11/13/2021 06:00	0.0	0	0	0	0	0
11/13/2021 07:00	0.0	0	0	0	0	0
11/13/2021 08:00	1,319.6	0	1	0	0	0
11/13/2021 09:00	5,405.2	0	1	0	0	0
11/13/2021 10:00	0.0	0	0	0	0	1
11/13/2021 11:00	0.0	0	0	0	0	1
11/13/2021 12:00	0.0	0	0	0	0	1
11/13/2021 13:00	0.0	0	0	0	0	1
11/13/2021 14:00	0.0	0	0	0	0	1
11/13/2021 15:00	0.0	0	0	0	0	1
11/13/2021 16:00	0.0	0	0	0	0	1
11/13/2021 17:00	0.0	0	0	0	0	1
11/13/2021 18:00	0.0	0	0	0	0	1
11/13/2021 19:00	0.0	0	0	0	0	1
11/13/2021 20:00	0.0	0	0	0	0	1
11/13/2021 21:00	0.0	0	0	0	0	1
11/13/2021 22:00	36.2	0	0	0	1	0
11/13/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	6,803.3 #	0 #	2 #	0 #	2 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,405.2	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/14/2021 00:00	0.0	0	0	0	0	0
11/14/2021 01:00	0.0	0	0	0	0	0
11/14/2021 02:00	0.0	0	0	0	0	0
11/14/2021 03:00	0.0	0	0	0	0	0
11/14/2021 04:00	0.0	0	0	0	0	0
11/14/2021 05:00	0.0	0	0	0	0	0
11/14/2021 06:00	0.0	0	0	0	0	0
11/14/2021 07:00	0.0	0	0	0	0	0
11/14/2021 08:00	0.0	0	0	0	0	0
11/14/2021 09:00	469.3	0	1	0	0	0
11/14/2021 10:00	3,940.5	0	1	0	0	0
11/14/2021 11:00	4,269.2	0	1	0	0	0
11/14/2021 12:00	0.0	0	0	0	0	1
11/14/2021 13:00	0.0	0	0	0	0	1
11/14/2021 14:00	0.0	0	0	0	0	1
11/14/2021 15:00	0.0	0	0	0	0	1
11/14/2021 16:00	0.0	0	0	0	0	1
11/14/2021 17:00	0.0	0	0	0	0	1
11/14/2021 18:00	0.0	0	0	0	0	1
11/14/2021 19:00	0.0	0	0	0	0	1
11/14/2021 20:00	0.0	0	0	0	0	1
11/14/2021 21:00	0.0	0	0	0	0	1
11/14/2021 22:00	0.0	0	0	0	0	1
11/14/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	8,679.0 #	0 #	3 #	0 #	0 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,269.2	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/15/2021 00:00	0.0	0	0	0	0	1
11/15/2021 01:00	0.0	0	0	0	0	1
11/15/2021 02:00	0.0	0	0	0	0	1
11/15/2021 03:00	0.0	0	0	0	0	1
11/15/2021 04:00	0.0	0	0	0	0	1
11/15/2021 05:00	0.0	0	0	0	0	1
11/15/2021 06:00	0.0	0	0	0	0	1
11/15/2021 07:00	0.0	0	0	0	0	1
11/15/2021 08:00	0.0	0	0	0	0	1
11/15/2021 09:00	0.0	0	0	0	0	1
11/15/2021 10:00	0.0	0	0	0	0	1
11/15/2021 11:00	0.0	0	0	0	0	1
11/15/2021 12:00	0.0	0	0	0	0	1
11/15/2021 13:00	0.0	0	0	0	0	1
11/15/2021 14:00	0.0	0	0	0	0	1
11/15/2021 15:00	0.0	0	0	0	0	1
11/15/2021 16:00	0.0	0	0	0	0	1
11/15/2021 17:00	0.0	0	0	0	0	1
11/15/2021 18:00	0.0	0	0	0	0	1
11/15/2021 19:00	0.0	0	0	0	0	1
11/15/2021 20:00	0.0	0	0	0	0	1
11/15/2021 21:00	0.0	0	0	0	0	1
11/15/2021 22:00	0.0	0	0	0	0	1
11/15/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/16/2021 00:00	52.4	0	0	0	1	0
11/16/2021 01:00	0.0	0	0	0	0	0
11/16/2021 02:00	0.0	0	0	0	0	0
11/16/2021 03:00	0.0	0	0	0	0	0
11/16/2021 04:00	0.0	0	0	0	0	0
11/16/2021 05:00	0.0	0	0	0	0	0
11/16/2021 06:00	0.0	0	0	0	0	0
11/16/2021 07:00	0.0	0	0	0	0	0
11/16/2021 08:00	1,298.9	0	1	0	0	0
11/16/2021 09:00	6,093.2	0	1	0	0	0
11/16/2021 10:00	0.0	0	0	0	0	1
11/16/2021 11:00	0.0	0	0	0	0	1
11/16/2021 12:00	0.0	0	0	0	0	1
11/16/2021 13:00	0.0	0	0	0	0	1
11/16/2021 14:00	0.0	0	0	0	0	1
11/16/2021 15:00	0.0	0	0	0	0	1
11/16/2021 16:00	0.0	0	0	0	0	1
11/16/2021 17:00	0.0	0	0	0	0	1
11/16/2021 18:00	0.0	0	0	0	0	1
11/16/2021 19:00	0.0	0	0	0	0	1
11/16/2021 20:00	0.0	0	0	0	0	1
11/16/2021 21:00	0.0	0	0	0	0	1
11/16/2021 22:00	0.0	0	0	0	0	1
11/16/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,444.5 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,093.2	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/17/2021 00:00	0.0	0	0	0	0	1
11/17/2021 01:00	0.0	0	0	0	0	1
11/17/2021 02:00	0.0	0	0	0	0	1
11/17/2021 03:00	0.0	0	0	0	0	1
11/17/2021 04:00	0.0	0	0	0	0	1
11/17/2021 05:00	0.0	0	0	0	0	1
11/17/2021 06:00	0.0	0	0	0	0	1
11/17/2021 07:00	0.0	0	0	0	0	1
11/17/2021 08:00	0.0	0	0	0	0	1
11/17/2021 09:00	0.0	0	0	0	0	1
11/17/2021 10:00	0.0	0	0	0	0	1
11/17/2021 11:00	0.0	0	0	0	0	1
11/17/2021 12:00	0.0	0	0	0	0	1
11/17/2021 13:00	0.0	0	0	0	0	1
11/17/2021 14:00	0.0	0	0	0	0	1
11/17/2021 15:00	0.0	0	0	0	0	1
11/17/2021 16:00	0.0	0	0	0	0	1
11/17/2021 17:00	0.0	0	0	0	0	1
11/17/2021 18:00	0.0	0	0	0	0	1
11/17/2021 19:00	0.0	0	0	0	0	1
11/17/2021 20:00	0.0	0	0	0	0	1
11/17/2021 21:00	0.0	0	0	0	0	1
11/17/2021 22:00	0.0	0	0	0	0	1
11/17/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/18/2021 00:00	0.0	0	0	0	0	1
11/18/2021 01:00	0.0	0	0	0	0	1
11/18/2021 02:00	0.0	0	0	0	0	1
11/18/2021 03:00	0.0	0	0	0	0	1
11/18/2021 04:00	0.0	0	0	0	0	1
11/18/2021 05:00	0.0	0	0	0	0	1
11/18/2021 06:00	0.0	0	0	0	0	1
11/18/2021 07:00	0.0	0	0	0	0	1
11/18/2021 08:00	0.0	0	0	0	0	1
11/18/2021 09:00	0.0	0	0	0	0	1
11/18/2021 10:00	0.0	0	0	0	0	1
11/18/2021 11:00	0.0	0	0	0	0	1
11/18/2021 12:00	0.0	0	0	0	0	1
11/18/2021 13:00	0.0	0	0	0	0	1
11/18/2021 14:00	0.0	0	0	0	0	1
11/18/2021 15:00	0.0	0	0	0	0	1
11/18/2021 16:00	0.0	0	0	0	0	1
11/18/2021 17:00	0.0	0	0	0	0	1
11/18/2021 18:00	0.0	0	0	0	0	1
11/18/2021 19:00	0.0	0	0	0	0	1
11/18/2021 20:00	0.0	0	0	0	0	1
11/18/2021 21:00	0.0	0	0	0	0	1
11/18/2021 22:00	0.0	0	0	0	0	1
11/18/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/19/2021 00:00	0.0	0	0	0	0	1
11/19/2021 01:00	0.0	0	0	0	0	1
11/19/2021 02:00	0.0	0	0	0	0	1
11/19/2021 03:00	0.0	0	0	0	0	1
11/19/2021 04:00	0.0	0	0	0	0	1
11/19/2021 05:00	0.0	0	0	0	0	1
11/19/2021 06:00	0.0	0	0	0	0	1
11/19/2021 07:00	0.0	0	0	0	0	1
11/19/2021 08:00	0.0	0	0	0	0	1
11/19/2021 09:00	0.0	0	0	0	0	1
11/19/2021 10:00	0.0	0	0	0	0	1
11/19/2021 11:00	0.0	0	0	0	0	1
11/19/2021 12:00	0.0	0	0	0	0	1
11/19/2021 13:00	0.0	0	0	0	0	1
11/19/2021 14:00	0.0	0	0	0	0	1
11/19/2021 15:00	0.0	0	0	0	0	1
11/19/2021 16:00	0.0	0	0	0	0	1
11/19/2021 17:00	0.0	0	0	0	0	1
11/19/2021 18:00	0.0	0	0	0	0	1
11/19/2021 19:00	0.0	0	0	0	0	1
11/19/2021 20:00	0.0	0	0	0	0	1
11/19/2021 21:00	0.0	0	0	0	0	1
11/19/2021 22:00	0.0	0	0	0	0	1
11/19/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/20/2021 00:00	0.0	0	0	0	0	1
11/20/2021 01:00	0.0	0	0	0	0	1
11/20/2021 02:00	0.0	0	0	0	0	1
11/20/2021 03:00	0.0	0	0	0	0	1
11/20/2021 04:00	0.0	0	0	0	0	1
11/20/2021 05:00	0.0	0	0	0	0	1
11/20/2021 06:00	0.0	0	0	0	0	1
11/20/2021 07:00	0.0	0	0	0	0	1
11/20/2021 08:00	0.0	0	0	0	0	1
11/20/2021 09:00	0.0	0	0	0	0	1
11/20/2021 10:00	0.0	0	0	0	0	1
11/20/2021 11:00	0.0	0	0	0	0	1
11/20/2021 12:00	0.0	0	0	0	0	1
11/20/2021 13:00	0.0	0	0	0	0	1
11/20/2021 14:00	0.0	0	0	0	0	1
11/20/2021 15:00	0.0	0	0	0	0	1
11/20/2021 16:00	0.0	0	0	0	0	1
11/20/2021 17:00	0.0	0	0	0	0	1
11/20/2021 18:00	0.0	0	0	0	0	1
11/20/2021 19:00	0.0	0	0	0	0	1
11/20/2021 20:00	0.0	0	0	0	0	1
11/20/2021 21:00	0.0	0	0	0	0	1
11/20/2021 22:00	0.0	0	0	0	0	1
11/20/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/21/2021 00:00	0.0	0	0	0	0	1
11/21/2021 01:00	0.0	0	0	0	0	1
11/21/2021 02:00	29.6	0	0	0	1	0
11/21/2021 03:00	0.0	0	0	0	0	0
11/21/2021 04:00	0.0	0	0	0	0	0
11/21/2021 05:00	0.0	0	0	0	0	0
11/21/2021 06:00	0.0	0	0	0	0	0
11/21/2021 07:00	0.0	0	0	0	0	0
11/21/2021 08:00	0.0	0	0	0	0	0
11/21/2021 09:00	0.0	0	0	0	0	0
11/21/2021 10:00	689.6	0	0	1	0	0
11/21/2021 11:00	5,702.9	0	0	1	0	0
11/21/2021 12:00	0.0	0	0	0	0	1
11/21/2021 13:00	0.0	0	0	0	0	1
11/21/2021 14:00	0.0	0	0	0	0	1
11/21/2021 15:00	0.0	0	0	0	0	1
11/21/2021 16:00	0.0	0	0	0	0	1
11/21/2021 17:00	0.0	0	0	0	0	1
11/21/2021 18:00	0.0	0	0	0	0	1
11/21/2021 19:00	0.0	0	0	0	0	1
11/21/2021 20:00	0.0	0	0	0	0	1
11/21/2021 21:00	0.0	0	0	0	0	1
11/21/2021 22:00	0.0	0	0	0	0	1
11/21/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,422.1 #	0 #	0 #	2 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,702.9	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/22/2021 00:00	0.0	0	0	0	0	1
11/22/2021 01:00	0.0	0	0	0	0	1
11/22/2021 02:00	0.0	0	0	0	0	1
11/22/2021 03:00	0.0	0	0	0	0	1
11/22/2021 04:00	0.0	0	0	0	0	1
11/22/2021 05:00	0.0	0	0	0	0	1
11/22/2021 06:00	0.0	0	0	0	0	1
11/22/2021 07:00	0.0	0	0	0	0	1
11/22/2021 08:00	0.0	0	0	0	0	1
11/22/2021 09:00	0.0	0	0	0	0	1
11/22/2021 10:00	0.0	0	0	0	0	1
11/22/2021 11:00	0.0	0	0	0	0	1
11/22/2021 12:00	0.0	0	0	0	0	1
11/22/2021 13:00	0.0	0	0	0	0	1
11/22/2021 14:00	0.0	0	0	0	0	1
11/22/2021 15:00	0.0	0	0	0	0	1
11/22/2021 16:00	0.0	0	0	0	0	1
11/22/2021 17:00	0.0	0	0	0	0	1
11/22/2021 18:00	0.0	0	0	0	0	1
11/22/2021 19:00	0.0	0	0	0	0	1
11/22/2021 20:00	0.0	0	0	0	0	1
11/22/2021 21:00	0.0	0	0	0	0	1
11/22/2021 22:00	0.0	0	0	0	0	1
11/22/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/23/2021 00:00	0.0	0	0	0	0	1
11/23/2021 01:00	0.0	0	0	0	0	1
11/23/2021 02:00	0.0	0	0	0	0	1
11/23/2021 03:00	0.0	0	0	0	0	1
11/23/2021 04:00	0.0	0	0	0	0	1
11/23/2021 05:00	0.0	0	0	0	0	1
11/23/2021 06:00	0.0	0	0	0	0	1
11/23/2021 07:00	0.0	0	0	0	0	1
11/23/2021 08:00	0.0	0	0	0	0	1
11/23/2021 09:00	0.0	0	0	0	0	1
11/23/2021 10:00	0.0	0	0	0	0	1
11/23/2021 11:00	0.0	0	0	0	0	1
11/23/2021 12:00	0.0	0	0	0	0	1
11/23/2021 13:00	0.0	0	0	0	0	1
11/23/2021 14:00	0.0	0	0	0	0	1
11/23/2021 15:00	0.0	0	0	0	0	1
11/23/2021 16:00	0.0	0	0	0	0	1
11/23/2021 17:00	0.0	0	0	0	0	1
11/23/2021 18:00	0.0	0	0	0	0	1
11/23/2021 19:00	0.0	0	0	0	0	1
11/23/2021 20:00	0.0	0	0	0	0	1
11/23/2021 21:00	0.0	0	0	0	0	1
11/23/2021 22:00	0.0	0	0	0	0	1
11/23/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/24/2021 00:00	0.0	0	0	0	0	1
11/24/2021 01:00	0.0	0	0	0	0	1
11/24/2021 02:00	0.0	0	0	0	0	1
11/24/2021 03:00	0.0	0	0	0	0	1
11/24/2021 04:00	0.0	0	0	0	0	1
11/24/2021 05:00	0.0	0	0	0	0	1
11/24/2021 06:00	0.0	0	0	0	0	1
11/24/2021 07:00	0.0	0	0	0	0	1
11/24/2021 08:00	0.0	0	0	0	0	1
11/24/2021 09:00	0.0	0	0	0	0	1
11/24/2021 10:00	0.0	0	0	0	0	1
11/24/2021 11:00	0.0	0	0	0	0	1
11/24/2021 12:00	0.0	0	0	0	0	1
11/24/2021 13:00	0.0	0	0	0	0	1
11/24/2021 14:00	0.0	0	0	0	0	1
11/24/2021 15:00	0.0	0	0	0	0	1
11/24/2021 16:00	0.0	0	0	0	0	1
11/24/2021 17:00	0.0	0	0	0	0	1
11/24/2021 18:00	0.0	0	0	0	0	1
11/24/2021 19:00	0.0	0	0	0	0	1
11/24/2021 20:00	0.0	0	0	0	0	1
11/24/2021 21:00	0.0	0	0	0	0	1
11/24/2021 22:00	0.0	0	0	0	0	1
11/24/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/25/2021 00:00	42.0	0	0	0	1	0
11/25/2021 01:00	0.0	0	0	0	0	0
11/25/2021 02:00	0.0	0	0	0	0	0
11/25/2021 03:00	0.0	0	0	0	0	0
11/25/2021 04:00	0.0	0	0	0	0	0
11/25/2021 05:00	0.0	0	0	0	0	0
11/25/2021 06:00	0.0	0	0	0	0	0
11/25/2021 07:00	0.0	0	0	0	0	0
11/25/2021 08:00	0.0	0	0	0	0	0
11/25/2021 09:00	0.0	0	0	0	0	0
11/25/2021 10:00	0.0	0	0	0	0	0
11/25/2021 11:00	0.0	0	0	0	0	0
11/25/2021 12:00	0.0	0	0	0	0	0
11/25/2021 13:00	0.0	0	0	0	0	0
11/25/2021 14:00	0.0	0	0	0	0	0
11/25/2021 15:00	0.0	0	0	0	0	0
11/25/2021 16:00	0.0	0	0	0	0	0
11/25/2021 17:00	0.0	0	0	0	0	0
11/25/2021 18:00	0.0	0	0	0	0	0
11/25/2021 19:00	0.0	0	0	0	0	0
11/25/2021 20:00	0.0	0	0	0	0	0
11/25/2021 21:00	0.0	0	0	0	0	0
11/25/2021 22:00	0.0	0	0	0	0	0
11/25/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	42.0 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	42.0	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/26/2021 00:00	0.0	0	0	0	0	0
11/26/2021 01:00	0.0	0	0	0	0	0
11/26/2021 02:00	0.0	0	0	0	0	0
11/26/2021 03:00	0.0	0	0	0	0	0
11/26/2021 04:00	0.0	0	0	0	0	0
11/26/2021 05:00	0.0	0	0	0	0	0
11/26/2021 06:00	0.0	0	0	0	0	0
11/26/2021 07:00	0.0	0	0	0	0	0
11/26/2021 08:00	0.0	0	0	0	0	0
11/26/2021 09:00	0.0	0	0	0	0	0
11/26/2021 10:00	0.0	0	0	0	0	0
11/26/2021 11:00	0.0	0	0	0	0	0
11/26/2021 12:00	0.0	0	0	0	0	0
11/26/2021 13:00	0.0	0	0	0	0	0
11/26/2021 14:00	0.0	0	0	0	0	0
11/26/2021 15:00	0.0	0	0	0	0	0
11/26/2021 16:00	0.0	0	0	0	0	0
11/26/2021 17:00	0.0	0	0	0	0	0
11/26/2021 18:00	0.0	0	0	0	0	0
11/26/2021 19:00	0.0	0	0	0	0	0
11/26/2021 20:00	0.0	0	0	0	0	0
11/26/2021 21:00	0.0	0	0	0	0	0
11/26/2021 22:00	0.0	0	0	0	0	0
11/26/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/27/2021 00:00	0.0	0	0	0	0	0
11/27/2021 01:00	0.0	0	0	0	0	0
11/27/2021 02:00	0.0	0	0	0	0	0
11/27/2021 03:00	0.0	0	0	0	0	0
11/27/2021 04:00	0.0	0	0	0	0	0
11/27/2021 05:00	0.0	0	0	0	0	0
11/27/2021 06:00	0.0	0	0	0	0	0
11/27/2021 07:00	0.0	0	0	0	0	0
11/27/2021 08:00	0.0	0	0	0	0	0
11/27/2021 09:00	0.0	0	0	0	0	0
11/27/2021 10:00	0.0	0	0	0	0	0
11/27/2021 11:00	0.0	0	0	0	0	0
11/27/2021 12:00	0.0	0	0	0	0	0
11/27/2021 13:00	0.0	0	0	0	0	0
11/27/2021 14:00	0.0	0	0	0	0	0
11/27/2021 15:00	0.0	0	0	0	0	0
11/27/2021 16:00	0.0	0	0	0	0	0
11/27/2021 17:00	0.0	0	0	0	0	0
11/27/2021 18:00	0.0	0	0	0	0	0
11/27/2021 19:00	0.0	0	0	0	0	0
11/27/2021 20:00	0.0	0	0	0	0	0
11/27/2021 21:00	0.0	0	0	0	0	0
11/27/2021 22:00	0.0	0	0	0	0	0
11/27/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/28/2021 00:00	0.0	0	0	0	0	0
11/28/2021 01:00	0.0	0	0	0	0	0
11/28/2021 02:00	0.0	0	0	0	0	0
11/28/2021 03:00	0.0	0	0	0	0	0
11/28/2021 04:00	0.0	0	0	0	0	0
11/28/2021 05:00	0.0	0	0	0	0	0
11/28/2021 06:00	0.0	0	0	0	0	0
11/28/2021 07:00	0.0	0	0	0	0	0
11/28/2021 08:00	0.0	0	0	0	0	0
11/28/2021 09:00	0.0	0	0	0	0	0
11/28/2021 10:00	0.0	0	0	0	0	0
11/28/2021 11:00	0.0	0	0	0	0	0
11/28/2021 12:00	0.0	0	0	0	0	0
11/28/2021 13:00	0.0	0	0	0	0	0
11/28/2021 14:00	0.0	0	0	0	0	0
11/28/2021 15:00	0.0	0	0	0	0	0
11/28/2021 16:00	0.0	0	0	0	0	0
11/28/2021 17:00	0.0	0	0	0	0	0
11/28/2021 18:00	0.0	0	0	0	0	0
11/28/2021 19:00	0.0	0	0	0	0	0
11/28/2021 20:00	0.0	0	0	0	0	0
11/28/2021 21:00	0.0	0	0	0	0	0
11/28/2021 22:00	0.0	0	0	0	0	0
11/28/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/29/2021 00:00	0.0	0	0	0	0	0
11/29/2021 01:00	0.0	0	0	0	0	0
11/29/2021 02:00	0.0	0	0	0	0	0
11/29/2021 03:00	0.0	0	0	0	0	0
11/29/2021 04:00	0.0	0	0	0	0	0
11/29/2021 05:00	0.0	0	0	0	0	0
11/29/2021 06:00	0.0	0	0	0	0	0
11/29/2021 07:00	232.9	1	0	0	0	0
11/29/2021 08:00	3,584.1	1	0	0	0	0
11/29/2021 09:00	3,704.4	1	0	0	0	0
11/29/2021 10:00	5,476.9	1	0	0	0	0
11/29/2021 11:00	6,541.0	1	0	0	0	0
11/29/2021 12:00	0.0	0	0	0	0	1
11/29/2021 13:00	0.0	0	0	0	0	1
11/29/2021 14:00	0.0	0	0	0	0	1
11/29/2021 15:00	0.0	0	0	0	0	1
11/29/2021 16:00	0.0	0	0	0	0	1
11/29/2021 17:00	0.0	0	0	0	0	1
11/29/2021 18:00	0.0	0	0	0	0	1
11/29/2021 19:00	0.0	0	0	0	0	1
11/29/2021 20:00	0.0	0	0	0	0	1
11/29/2021 21:00	0.0	0	0	0	0	1
11/29/2021 22:00	0.0	0	0	0	0	1
11/29/2021 23:00	60.8	0	0	0	1	0
Average/Sum#:	19,600.1 #	5 #	0 #	0 #	1 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,541.0	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/30/2021 00:00	0.0	0	0	0	0	0
11/30/2021 01:00	0.0	0	0	0	0	0
11/30/2021 02:00	0.0	0	0	0	0	0
11/30/2021 03:00	0.0	0	0	0	0	0
11/30/2021 04:00	0.0	0	0	0	0	0
11/30/2021 05:00	704.5	0	0	1	0	0
11/30/2021 06:00	5,240.6	0	0	1	0	0
11/30/2021 07:00	0.0	0	0	0	0	1
11/30/2021 08:00	0.0	0	0	0	0	1
11/30/2021 09:00	0.0	0	0	0	0	1
11/30/2021 10:00	0.0	0	0	0	0	1
11/30/2021 11:00	0.0	0	0	0	0	1
11/30/2021 12:00	0.0	0	0	0	0	1
11/30/2021 13:00	0.0	0	0	0	0	1
11/30/2021 14:00	0.0	0	0	0	0	1
11/30/2021 15:00	0.0	0	0	0	0	1
11/30/2021 16:00	0.0	0	0	0	0	1
11/30/2021 17:00	0.0	0	0	0	0	1
11/30/2021 18:00	0.0	0	0	0	0	1
11/30/2021 19:00	0.0	0	0	0	0	1
11/30/2021 20:00	0.0	0	0	0	0	1
11/30/2021 21:00	0.0	0	0	0	0	1
11/30/2021 22:00	0.0	0	0	0	0	1
11/30/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	5,945.1 #	0 #	0 #	2 #	0 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,240.6	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/01/2021 00:00	0.0	0	0	0	0	1
12/01/2021 01:00	0.0	0	0	0	0	1
12/01/2021 02:00	0.0	0	0	0	0	1
12/01/2021 03:00	0.0	0	0	0	0	1
12/01/2021 04:00	0.0	0	0	0	0	1
12/01/2021 05:00	0.0	0	0	0	0	1
12/01/2021 06:00	0.0	0	0	0	0	1
12/01/2021 07:00	0.0	0	0	0	0	1
12/01/2021 08:00	0.0	0	0	0	0	1
12/01/2021 09:00	0.0	0	0	0	0	1
12/01/2021 10:00	0.0	0	0	0	0	1
12/01/2021 11:00	0.0	0	0	0	0	1
12/01/2021 12:00	0.0	0	0	0	0	1
12/01/2021 13:00	0.0	0	0	0	0	1
12/01/2021 14:00	0.0	0	0	0	0	1
12/01/2021 15:00	0.0	0	0	0	0	1
12/01/2021 16:00	0.0	0	0	0	0	1
12/01/2021 17:00	0.0	0	0	0	0	1
12/01/2021 18:00	0.0	0	0	0	0	1
12/01/2021 19:00	0.0	0	0	0	0	1
12/01/2021 20:00	0.0	0	0	0	0	1
12/01/2021 21:00	0.0	0	0	0	0	1
12/01/2021 22:00	0.0	0	0	0	0	1
12/01/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/02/2021 00:00	30.7	0	0	0	1	0
12/02/2021 01:00	0.0	0	0	0	0	0
12/02/2021 02:00	0.0	0	0	0	0	0
12/02/2021 03:00	0.0	0	0	0	0	0
12/02/2021 04:00	0.0	0	0	0	0	0
12/02/2021 05:00	0.0	0	0	0	0	0
12/02/2021 06:00	2,642.1	0	0	1	0	0
12/02/2021 07:00	3,319.4	0	0	1	0	0
12/02/2021 08:00	0.0	0	0	0	0	1
12/02/2021 09:00	0.0	0	0	0	0	1
12/02/2021 10:00	0.0	0	0	0	0	1
12/02/2021 11:00	0.0	0	0	0	0	1
12/02/2021 12:00	0.0	0	0	0	0	1
12/02/2021 13:00	0.0	0	0	0	0	1
12/02/2021 14:00	0.0	0	0	0	0	1
12/02/2021 15:00	0.0	0	0	0	0	1
12/02/2021 16:00	0.0	0	0	0	0	1
12/02/2021 17:00	0.0	0	0	0	0	1
12/02/2021 18:00	0.0	0	0	0	0	1
12/02/2021 19:00	0.0	0	0	0	0	1
12/02/2021 20:00	0.0	0	0	0	0	1
12/02/2021 21:00	0.0	0	0	0	0	1
12/02/2021 22:00	0.0	0	0	0	0	1
12/02/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	5,992.2 #	0 #	0 #	2 #	1 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3,319.4	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/03/2021 00:00	0.0	0	0	0	0	1
12/03/2021 01:00	0.0	0	0	0	0	1
12/03/2021 02:00	0.0	0	0	0	0	1
12/03/2021 03:00	0.0	0	0	0	0	1
12/03/2021 04:00	0.0	0	0	0	0	1
12/03/2021 05:00	0.0	0	0	0	0	1
12/03/2021 06:00	0.0	0	0	0	0	1
12/03/2021 07:00	0.0	0	0	0	0	1
12/03/2021 08:00	0.0	0	0	0	0	1
12/03/2021 09:00	0.0	0	0	0	0	1
12/03/2021 10:00	0.0	0	0	0	0	1
12/03/2021 11:00	0.0	0	0	0	0	1
12/03/2021 12:00	0.0	0	0	0	0	1
12/03/2021 13:00	0.0	0	0	0	0	1
12/03/2021 14:00	0.0	0	0	0	0	1
12/03/2021 15:00	0.0	0	0	0	0	1
12/03/2021 16:00	0.0	0	0	0	0	1
12/03/2021 17:00	0.0	0	0	0	0	1
12/03/2021 18:00	0.0	0	0	0	0	1
12/03/2021 19:00	0.0	0	0	0	0	1
12/03/2021 20:00	0.0	0	0	0	0	1
12/03/2021 21:00	0.0	0	0	0	0	1
12/03/2021 22:00	0.0	0	0	0	0	1
12/03/2021 23:00	16.3	0	0	0	1	0
Average/Sum#:	16.3 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	16.3	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/04/2021 00:00	0.0	0	0	0	1	0
12/04/2021 01:00	0.0	0	0	0	0	0
12/04/2021 02:00	0.0	0	0	0	0	0
12/04/2021 03:00	348.3	0	0	1	0	0
12/04/2021 04:00	5,315.2	0	0	1	0	0
12/04/2021 05:00	0.0	0	0	0	0	1
12/04/2021 06:00	0.0	0	0	0	0	1
12/04/2021 07:00	0.0	0	0	0	0	1
12/04/2021 08:00	0.0	0	0	0	0	1
12/04/2021 09:00	0.0	0	0	0	0	1
12/04/2021 10:00	0.0	0	0	0	0	1
12/04/2021 11:00	0.0	0	0	0	0	1
12/04/2021 12:00	0.0	0	0	0	0	1
12/04/2021 13:00	0.0	0	0	0	0	1
12/04/2021 14:00	0.0	0	0	0	0	1
12/04/2021 15:00	0.0	0	0	0	0	1
12/04/2021 16:00	0.0	0	0	0	0	1
12/04/2021 17:00	0.0	0	0	0	0	1
12/04/2021 18:00	0.0	0	0	0	0	1
12/04/2021 19:00	0.0	0	0	0	0	1
12/04/2021 20:00	0.0	0	0	0	0	1
12/04/2021 21:00	0.0	0	0	0	0	1
12/04/2021 22:00	0.0	0	0	0	0	1
12/04/2021 23:00	63.4	0	0	0	1	0
Average/Sum#:	5,726.9 #	0 #	0 #	2 #	2 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,315.2	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/05/2021 00:00	0.0	0	0	0	0	0
12/05/2021 01:00	0.0	0	0	0	0	0
12/05/2021 02:00	0.0	0	0	0	0	0
12/05/2021 03:00	0.0	0	0	0	0	0
12/05/2021 04:00	0.0	0	0	0	0	0
12/05/2021 05:00	0.0	0	0	0	0	0
12/05/2021 06:00	0.0	0	0	0	0	0
12/05/2021 07:00	2,473.8	0	1	0	0	0
12/05/2021 08:00	6,954.0	0	1	0	0	0
12/05/2021 09:00	0.0	0	0	0	0	1
12/05/2021 10:00	0.0	0	0	0	0	1
12/05/2021 11:00	0.0	0	0	0	0	1
12/05/2021 12:00	0.0	0	0	0	0	1
12/05/2021 13:00	0.0	0	0	0	0	1
12/05/2021 14:00	0.0	0	0	0	0	1
12/05/2021 15:00	0.0	0	0	0	0	1
12/05/2021 16:00	0.0	0	0	0	0	1
12/05/2021 17:00	0.0	0	0	0	0	1
12/05/2021 18:00	0.0	0	0	0	0	1
12/05/2021 19:00	0.0	0	0	0	0	1
12/05/2021 20:00	0.0	0	0	0	0	1
12/05/2021 21:00	0.0	0	0	0	0	1
12/05/2021 22:00	0.0	0	0	0	0	1
12/05/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	9,427.8 #	0 #	2 #	0 #	0 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,954.0	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/06/2021 00:00	0.0	0	0	0	0	1
12/06/2021 01:00	0.0	0	0	0	0	1
12/06/2021 02:00	0.0	0	0	0	0	1
12/06/2021 03:00	0.0	0	0	0	0	1
12/06/2021 04:00	0.0	0	0	0	0	1
12/06/2021 05:00	0.0	0	0	0	0	1
12/06/2021 06:00	0.0	0	0	0	0	1
12/06/2021 07:00	0.0	0	0	0	0	1
12/06/2021 08:00	0.0	0	0	0	0	1
12/06/2021 09:00	0.0	0	0	0	0	1
12/06/2021 10:00	0.0	0	0	0	0	1
12/06/2021 11:00	0.0	0	0	0	0	1
12/06/2021 12:00	0.0	0	0	0	0	1
12/06/2021 13:00	0.0	0	0	0	0	1
12/06/2021 14:00	0.0	0	0	0	0	1
12/06/2021 15:00	0.0	0	0	0	0	1
12/06/2021 16:00	0.0	0	0	0	0	1
12/06/2021 17:00	0.0	0	0	0	0	1
12/06/2021 18:00	0.0	0	0	0	0	1
12/06/2021 19:00	0.0	0	0	0	0	1
12/06/2021 20:00	0.0	0	0	0	0	1
12/06/2021 21:00	0.0	0	0	0	0	1
12/06/2021 22:00	0.0	0	0	0	0	1
12/06/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/07/2021 00:00	0.0	0	0	0	0	1
12/07/2021 01:00	0.0	0	0	0	0	1
12/07/2021 02:00	0.0	0	0	0	0	1
12/07/2021 03:00	0.0	0	0	0	0	1
12/07/2021 04:00	0.0	0	0	0	0	1
12/07/2021 05:00	0.0	0	0	0	0	1
12/07/2021 06:00	0.0	0	0	0	0	1
12/07/2021 07:00	0.0	0	0	0	0	1
12/07/2021 08:00	0.0	0	0	0	0	1
12/07/2021 09:00	0.0	0	0	0	0	1
12/07/2021 10:00	0.0	0	0	0	0	1
12/07/2021 11:00	0.0	0	0	0	0	1
12/07/2021 12:00	0.0	0	0	0	0	1
12/07/2021 13:00	0.0	0	0	0	0	1
12/07/2021 14:00	0.0	0	0	0	0	1
12/07/2021 15:00	0.0	0	0	0	0	1
12/07/2021 16:00	0.0	0	0	0	0	1
12/07/2021 17:00	0.0	0	0	0	0	1
12/07/2021 18:00	0.0	0	0	0	0	1
12/07/2021 19:00	0.0	0	0	0	0	1
12/07/2021 20:00	0.0	0	0	0	0	1
12/07/2021 21:00	0.0	0	0	0	0	1
12/07/2021 22:00	0.0	0	0	0	0	1
12/07/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/08/2021 00:00	0.0	0	0	0	0	1
12/08/2021 01:00	0.0	0	0	0	0	1
12/08/2021 02:00	0.0	0	0	0	0	1
12/08/2021 03:00	0.0	0	0	0	0	1
12/08/2021 04:00	0.0	0	0	0	0	1
12/08/2021 05:00	0.0	0	0	0	0	1
12/08/2021 06:00	0.0	0	0	0	0	1
12/08/2021 07:00	0.0	0	0	0	0	1
12/08/2021 08:00	0.0	0	0	0	0	1
12/08/2021 09:00	0.0	0	0	0	0	1
12/08/2021 10:00	0.0	0	0	0	0	1
12/08/2021 11:00	0.0	0	0	0	0	1
12/08/2021 12:00	0.0	0	0	0	0	1
12/08/2021 13:00	0.0	0	0	0	0	1
12/08/2021 14:00	0.0	0	0	0	0	1
12/08/2021 15:00	0.0	0	0	0	0	1
12/08/2021 16:00	0.0	0	0	0	0	1
12/08/2021 17:00	0.0	0	0	0	0	1
12/08/2021 18:00	0.0	0	0	0	0	1
12/08/2021 19:00	0.0	0	0	0	0	1
12/08/2021 20:00	0.0	0	0	0	0	1
12/08/2021 21:00	0.0	0	0	0	0	1
12/08/2021 22:00	0.0	0	0	0	0	1
12/08/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/09/2021 00:00	0.0	0	0	0	0	1
12/09/2021 01:00	0.0	0	0	0	0	1
12/09/2021 02:00	0.0	0	0	0	0	1
12/09/2021 03:00	0.0	0	0	0	0	1
12/09/2021 04:00	0.0	0	0	0	0	1
12/09/2021 05:00	0.0	0	0	0	0	1
12/09/2021 06:00	0.0	0	0	0	0	1
12/09/2021 07:00	0.0	0	0	0	0	1
12/09/2021 08:00	0.0	0	0	0	0	1
12/09/2021 09:00	0.0	0	0	0	0	1
12/09/2021 10:00	0.0	0	0	0	0	1
12/09/2021 11:00	0.0	0	0	0	0	1
12/09/2021 12:00	0.0	0	0	0	0	1
12/09/2021 13:00	0.0	0	0	0	0	1
12/09/2021 14:00	0.0	0	0	0	0	1
12/09/2021 15:00	0.0	0	0	0	0	1
12/09/2021 16:00	0.0	0	0	0	0	1
12/09/2021 17:00	0.0	0	0	0	0	1
12/09/2021 18:00	0.0	0	0	0	0	1
12/09/2021 19:00	0.0	0	0	0	0	1
12/09/2021 20:00	0.0	0	0	0	0	1
12/09/2021 21:00	0.0	0	0	0	0	1
12/09/2021 22:00	0.0	0	0	0	0	1
12/09/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/10/2021 00:00	0.0	0	0	0	0	1
12/10/2021 01:00	0.0	0	0	0	0	1
12/10/2021 02:00	0.0	0	0	0	0	1
12/10/2021 03:00	0.0	0	0	0	0	1
12/10/2021 04:00	0.0	0	0	0	0	1
12/10/2021 05:00	0.0	0	0	0	0	1
12/10/2021 06:00	0.0	0	0	0	0	1
12/10/2021 07:00	0.0	0	0	0	0	1
12/10/2021 08:00	0.0	0	0	0	0	1
12/10/2021 09:00	0.0	0	0	0	0	1
12/10/2021 10:00	0.0	0	0	0	0	1
12/10/2021 11:00	0.0	0	0	0	0	1
12/10/2021 12:00	0.0	0	0	0	0	1
12/10/2021 13:00	0.0	0	0	0	0	1
12/10/2021 14:00	0.0	0	0	0	0	1
12/10/2021 15:00	0.0	0	0	0	0	1
12/10/2021 16:00	0.0	0	0	0	0	1
12/10/2021 17:00	0.0	0	0	0	0	1
12/10/2021 18:00	0.0	0	0	0	0	1
12/10/2021 19:00	0.0	0	0	0	0	1
12/10/2021 20:00	0.0	0	0	0	0	1
12/10/2021 21:00	0.0	0	0	0	0	1
12/10/2021 22:00	0.0	0	0	0	0	1
12/10/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/11/2021 00:00	0.0	0	0	0	0	1
12/11/2021 01:00	0.0	0	0	0	0	1
12/11/2021 02:00	0.0	0	0	0	0	1
12/11/2021 03:00	0.0	0	0	0	0	1
12/11/2021 04:00	0.0	0	0	0	0	1
12/11/2021 05:00	0.0	0	0	0	0	1
12/11/2021 06:00	0.0	0	0	0	0	1
12/11/2021 07:00	0.0	0	0	0	0	1
12/11/2021 08:00	0.0	0	0	0	0	1
12/11/2021 09:00	0.0	0	0	0	0	1
12/11/2021 10:00	0.0	0	0	0	0	1
12/11/2021 11:00	0.0	0	0	0	0	1
12/11/2021 12:00	0.0	0	0	0	0	1
12/11/2021 13:00	0.0	0	0	0	0	1
12/11/2021 14:00	0.0	0	0	0	0	1
12/11/2021 15:00	0.0	0	0	0	0	1
12/11/2021 16:00	0.0	0	0	0	0	1
12/11/2021 17:00	0.0	0	0	0	0	1
12/11/2021 18:00	0.0	0	0	0	0	1
12/11/2021 19:00	0.0	0	0	0	0	1
12/11/2021 20:00	0.0	0	0	0	0	1
12/11/2021 21:00	0.0	0	0	0	0	1
12/11/2021 22:00	0.0	0	0	0	0	1
12/11/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/12/2021 00:00	0.0	0	0	0	0	1
12/12/2021 01:00	0.0	0	0	0	0	1
12/12/2021 02:00	0.0	0	0	0	0	1
12/12/2021 03:00	0.0	0	0	0	0	1
12/12/2021 04:00	0.0	0	0	0	0	1
12/12/2021 05:00	0.0	0	0	0	0	1
12/12/2021 06:00	0.0	0	0	0	0	1
12/12/2021 07:00	0.0	0	0	0	0	1
12/12/2021 08:00	0.0	0	0	0	0	1
12/12/2021 09:00	0.0	0	0	0	0	1
12/12/2021 10:00	0.0	0	0	0	0	1
12/12/2021 11:00	0.0	0	0	0	0	1
12/12/2021 12:00	0.0	0	0	0	0	1
12/12/2021 13:00	0.0	0	0	0	0	1
12/12/2021 14:00	0.0	0	0	0	0	1
12/12/2021 15:00	0.0	0	0	0	0	1
12/12/2021 16:00	0.0	0	0	0	0	1
12/12/2021 17:00	0.0	0	0	0	0	1
12/12/2021 18:00	0.0	0	0	0	0	1
12/12/2021 19:00	0.0	0	0	0	0	1
12/12/2021 20:00	0.0	0	0	0	0	1
12/12/2021 21:00	0.0	0	0	0	0	1
12/12/2021 22:00	0.0	0	0	0	0	1
12/12/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/13/2021 00:00	0.0	0	0	0	0	1
12/13/2021 01:00	0.0	0	0	0	0	1
12/13/2021 02:00	0.0	0	0	0	0	1
12/13/2021 03:00	0.0	0	0	0	0	1
12/13/2021 04:00	0.0	0	0	0	0	1
12/13/2021 05:00	0.0	0	0	0	0	1
12/13/2021 06:00	0.0	0	0	0	0	1
12/13/2021 07:00	0.0	0	0	0	0	1
12/13/2021 08:00	0.0	0	0	0	0	1
12/13/2021 09:00	0.0	0	0	0	0	1
12/13/2021 10:00	0.0	0	0	0	0	1
12/13/2021 11:00	0.0	0	0	0	0	1
12/13/2021 12:00	0.0	0	0	0	0	1
12/13/2021 13:00	0.0	0	0	0	0	1
12/13/2021 14:00	0.0	0	0	0	0	1
12/13/2021 15:00	0.0	0	0	0	0	1
12/13/2021 16:00	0.0	0	0	0	0	1
12/13/2021 17:00	0.0	0	0	0	0	1
12/13/2021 18:00	0.0	0	0	0	0	1
12/13/2021 19:00	0.0	0	0	0	0	1
12/13/2021 20:00	0.0	0	0	0	0	1
12/13/2021 21:00	0.0	0	0	0	0	1
12/13/2021 22:00	0.0	0	0	0	0	1
12/13/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/14/2021 00:00	0.0	0	0	0	0	1
12/14/2021 01:00	0.0	0	0	0	0	1
12/14/2021 02:00	0.0	0	0	0	0	1
12/14/2021 03:00	0.0	0	0	0	0	1
12/14/2021 04:00	0.0	0	0	0	0	1
12/14/2021 05:00	0.0	0	0	0	0	1
12/14/2021 06:00	0.0	0	0	0	0	1
12/14/2021 07:00	0.0	0	0	0	0	1
12/14/2021 08:00	0.0	0	0	0	0	1
12/14/2021 09:00	0.0	0	0	0	0	1
12/14/2021 10:00	0.0	0	0	0	0	1
12/14/2021 11:00	0.0	0	0	0	0	1
12/14/2021 12:00	0.0	0	0	0	0	1
12/14/2021 13:00	0.0	0	0	0	0	1
12/14/2021 14:00	0.0	0	0	0	0	1
12/14/2021 15:00	0.0	0	0	0	0	1
12/14/2021 16:00	0.0	0	0	0	0	1
12/14/2021 17:00	0.0	0	0	0	0	1
12/14/2021 18:00	0.0	0	0	0	0	1
12/14/2021 19:00	0.0	0	0	0	0	1
12/14/2021 20:00	0.0	0	0	0	0	1
12/14/2021 21:00	0.0	0	0	0	0	1
12/14/2021 22:00	0.0	0	0	0	0	1
12/14/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/15/2021 00:00	0.0	0	0	0	0	1
12/15/2021 01:00	0.0	0	0	0	0	1
12/15/2021 02:00	0.0	0	0	0	0	1
12/15/2021 03:00	0.0	0	0	0	0	1
12/15/2021 04:00	0.0	0	0	0	0	1
12/15/2021 05:00	0.0	0	0	0	0	1
12/15/2021 06:00	0.0	0	0	0	0	1
12/15/2021 07:00	0.0	0	0	0	0	1
12/15/2021 08:00	0.0	0	0	0	0	1
12/15/2021 09:00	0.0	0	0	0	0	1
12/15/2021 10:00	0.0	0	0	0	0	1
12/15/2021 11:00	0.0	0	0	0	0	1
12/15/2021 12:00	0.0	0	0	0	0	1
12/15/2021 13:00	0.0	0	0	0	0	1
12/15/2021 14:00	0.0	0	0	0	0	1
12/15/2021 15:00	0.0	0	0	0	0	1
12/15/2021 16:00	0.0	0	0	0	0	1
12/15/2021 17:00	0.0	0	0	0	0	1
12/15/2021 18:00	0.0	0	0	0	0	1
12/15/2021 19:00	0.0	0	0	0	0	1
12/15/2021 20:00	0.0	0	0	0	0	1
12/15/2021 21:00	0.0	0	0	0	0	1
12/15/2021 22:00	0.0	0	0	0	0	1
12/15/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/16/2021 00:00	0.0	0	0	0	0	1
12/16/2021 01:00	0.0	0	0	0	0	1
12/16/2021 02:00	0.0	0	0	0	0	1
12/16/2021 03:00	0.0	0	0	0	0	1
12/16/2021 04:00	0.0	0	0	0	0	1
12/16/2021 05:00	0.0	0	0	0	0	1
12/16/2021 06:00	0.0	0	0	0	0	1
12/16/2021 07:00	0.0	0	0	0	0	1
12/16/2021 08:00	0.0	0	0	0	0	1
12/16/2021 09:00	0.0	0	0	0	0	1
12/16/2021 10:00	0.0	0	0	0	0	1
12/16/2021 11:00	0.0	0	0	0	0	1
12/16/2021 12:00	0.0	0	0	0	0	1
12/16/2021 13:00	0.0	0	0	0	0	1
12/16/2021 14:00	0.0	0	0	0	0	1
12/16/2021 15:00	0.0	0	0	0	0	1
12/16/2021 16:00	0.0	0	0	0	0	1
12/16/2021 17:00	0.0	0	0	0	0	1
12/16/2021 18:00	0.0	0	0	0	0	1
12/16/2021 19:00	0.0	0	0	0	0	1
12/16/2021 20:00	0.0	0	0	0	0	1
12/16/2021 21:00	0.0	0	0	0	0	1
12/16/2021 22:00	0.0	0	0	0	0	1
12/16/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/17/2021 00:00	0.0	0	0	0	0	1
12/17/2021 01:00	0.0	0	0	0	0	1
12/17/2021 02:00	0.0	0	0	0	0	1
12/17/2021 03:00	0.0	0	0	0	0	1
12/17/2021 04:00	0.0	0	0	0	0	1
12/17/2021 05:00	0.0	0	0	0	0	1
12/17/2021 06:00	0.0	0	0	0	0	1
12/17/2021 07:00	0.0	0	0	0	0	1
12/17/2021 08:00	0.0	0	0	0	0	1
12/17/2021 09:00	0.0	0	0	0	0	1
12/17/2021 10:00	0.0	0	0	0	0	1
12/17/2021 11:00	0.0	0	0	0	0	1
12/17/2021 12:00	0.0	0	0	0	0	1
12/17/2021 13:00	0.0	0	0	0	0	1
12/17/2021 14:00	0.0	0	0	0	0	1
12/17/2021 15:00	0.0	0	0	0	0	1
12/17/2021 16:00	0.0	0	0	0	0	1
12/17/2021 17:00	0.0	0	0	0	0	1
12/17/2021 18:00	0.0	0	0	0	0	1
12/17/2021 19:00	0.0	0	0	0	0	1
12/17/2021 20:00	0.0	0	0	0	0	1
12/17/2021 21:00	0.0	0	0	0	0	1
12/17/2021 22:00	0.0	0	0	0	0	1
12/17/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/18/2021 00:00	0.0	0	0	0	0	1
12/18/2021 01:00	0.0	0	0	0	0	1
12/18/2021 02:00	0.0	0	0	0	0	1
12/18/2021 03:00	0.0	0	0	0	0	1
12/18/2021 04:00	0.0	0	0	0	0	1
12/18/2021 05:00	0.0	0	0	0	0	1
12/18/2021 06:00	0.0	0	0	0	0	1
12/18/2021 07:00	0.0	0	0	0	0	1
12/18/2021 08:00	0.0	0	0	0	0	1
12/18/2021 09:00	0.0	0	0	0	0	1
12/18/2021 10:00	0.0	0	0	0	0	1
12/18/2021 11:00	0.0	0	0	0	0	1
12/18/2021 12:00	0.0	0	0	0	0	1
12/18/2021 13:00	0.0	0	0	0	0	1
12/18/2021 14:00	0.0	0	0	0	0	1
12/18/2021 15:00	0.0	0	0	0	0	1
12/18/2021 16:00	0.0	0	0	0	0	1
12/18/2021 17:00	0.0	0	0	0	0	1
12/18/2021 18:00	0.0	0	0	0	0	1
12/18/2021 19:00	0.0	0	0	0	0	1
12/18/2021 20:00	0.0	0	0	0	0	1
12/18/2021 21:00	0.0	0	0	0	0	1
12/18/2021 22:00	0.0	0	0	0	0	1
12/18/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/19/2021 00:00	0.0	0	0	0	0	1
12/19/2021 01:00	0.0	0	0	0	0	1
12/19/2021 02:00	0.0	0	0	0	0	1
12/19/2021 03:00	0.0	0	0	0	0	1
12/19/2021 04:00	0.0	0	0	0	0	1
12/19/2021 05:00	0.0	0	0	0	0	1
12/19/2021 06:00	0.0	0	0	0	0	1
12/19/2021 07:00	0.0	0	0	0	0	1
12/19/2021 08:00	0.0	0	0	0	0	1
12/19/2021 09:00	0.0	0	0	0	0	1
12/19/2021 10:00	0.0	0	0	0	0	1
12/19/2021 11:00	0.0	0	0	0	0	1
12/19/2021 12:00	0.0	0	0	0	0	1
12/19/2021 13:00	0.0	0	0	0	0	1
12/19/2021 14:00	0.0	0	0	0	0	1
12/19/2021 15:00	0.0	0	0	0	0	1
12/19/2021 16:00	0.0	0	0	0	0	1
12/19/2021 17:00	0.0	0	0	0	0	1
12/19/2021 18:00	0.0	0	0	0	0	1
12/19/2021 19:00	0.0	0	0	0	0	1
12/19/2021 20:00	0.0	0	0	0	0	1
12/19/2021 21:00	0.0	0	0	0	0	1
12/19/2021 22:00	0.0	0	0	0	0	1
12/19/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/20/2021 00:00	0.0	0	0	0	0	1
12/20/2021 01:00	0.0	0	0	0	0	1
12/20/2021 02:00	0.0	0	0	0	0	1
12/20/2021 03:00	0.0	0	0	0	0	1
12/20/2021 04:00	0.0	0	0	0	0	1
12/20/2021 05:00	0.0	0	0	0	0	1
12/20/2021 06:00	0.0	0	0	0	0	1
12/20/2021 07:00	0.0	0	0	0	0	1
12/20/2021 08:00	0.0	0	0	0	0	1
12/20/2021 09:00	0.0	0	0	0	0	1
12/20/2021 10:00	0.0	0	0	0	0	1
12/20/2021 11:00	0.0	0	0	0	0	1
12/20/2021 12:00	0.0	0	0	0	0	1
12/20/2021 13:00	0.0	0	0	0	0	1
12/20/2021 14:00	0.0	0	0	0	0	1
12/20/2021 15:00	0.0	0	0	0	0	1
12/20/2021 16:00	0.0	0	0	0	0	1
12/20/2021 17:00	0.0	0	0	0	0	1
12/20/2021 18:00	0.0	0	0	0	0	1
12/20/2021 19:00	0.0	0	0	0	0	1
12/20/2021 20:00	0.0	0	0	0	0	1
12/20/2021 21:00	0.0	0	0	0	0	1
12/20/2021 22:00	0.0	0	0	0	0	1
12/20/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/21/2021 00:00	0.0	0	0	0	0	1
12/21/2021 01:00	0.0	0	0	0	0	1
12/21/2021 02:00	0.0	0	0	0	0	1
12/21/2021 03:00	0.0	0	0	0	0	1
12/21/2021 04:00	0.0	0	0	0	0	1
12/21/2021 05:00	0.0	0	0	0	0	1
12/21/2021 06:00	0.0	0	0	0	0	1
12/21/2021 07:00	0.0	0	0	0	0	1
12/21/2021 08:00	0.0	0	0	0	0	1
12/21/2021 09:00	0.0	0	0	0	0	1
12/21/2021 10:00	0.0	0	0	0	0	1
12/21/2021 11:00	0.0	0	0	0	0	1
12/21/2021 12:00	0.0	0	0	0	0	1
12/21/2021 13:00	0.0	0	0	0	0	1
12/21/2021 14:00	0.0	0	0	0	0	1
12/21/2021 15:00	0.0	0	0	0	0	1
12/21/2021 16:00	0.0	0	0	0	0	1
12/21/2021 17:00	0.0	0	0	0	0	1
12/21/2021 18:00	0.0	0	0	0	0	1
12/21/2021 19:00	0.0	0	0	0	0	1
12/21/2021 20:00	0.0	0	0	0	0	1
12/21/2021 21:00	0.0	0	0	0	0	1
12/21/2021 22:00	0.0	0	0	0	0	1
12/21/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/22/2021 00:00	0.0	0	0	0	0	1
12/22/2021 01:00	0.0	0	0	0	0	1
12/22/2021 02:00	0.0	0	0	0	0	1
12/22/2021 03:00	0.0	0	0	0	0	1
12/22/2021 04:00	0.0	0	0	0	0	1
12/22/2021 05:00	0.0	0	0	0	0	1
12/22/2021 06:00	0.0	0	0	0	0	1
12/22/2021 07:00	0.0	0	0	0	0	1
12/22/2021 08:00	0.0	0	0	0	0	1
12/22/2021 09:00	0.0	0	0	0	0	1
12/22/2021 10:00	0.0	0	0	0	0	1
12/22/2021 11:00	0.0	0	0	0	0	1
12/22/2021 12:00	0.0	0	0	0	0	1
12/22/2021 13:00	0.0	0	0	0	0	1
12/22/2021 14:00	0.0	0	0	0	0	1
12/22/2021 15:00	0.0	0	0	0	0	1
12/22/2021 16:00	0.0	0	0	0	0	1
12/22/2021 17:00	0.0	0	0	0	0	1
12/22/2021 18:00	0.0	0	0	0	0	1
12/22/2021 19:00	0.0	0	0	0	0	1
12/22/2021 20:00	0.0	0	0	0	0	1
12/22/2021 21:00	0.0	0	0	0	0	1
12/22/2021 22:00	0.0	0	0	0	0	1
12/22/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/23/2021 00:00	0.0	0	0	0	0	1
12/23/2021 01:00	0.0	0	0	0	0	1
12/23/2021 02:00	0.0	0	0	0	0	1
12/23/2021 03:00	0.0	0	0	0	0	1
12/23/2021 04:00	0.0	0	0	0	0	1
12/23/2021 05:00	0.0	0	0	0	0	1
12/23/2021 06:00	0.0	0	0	0	0	1
12/23/2021 07:00	0.0	0	0	0	0	1
12/23/2021 08:00	0.0	0	0	0	0	1
12/23/2021 09:00	0.0	0	0	0	0	1
12/23/2021 10:00	0.0	0	0	0	0	1
12/23/2021 11:00	0.0	0	0	0	0	1
12/23/2021 12:00	0.0	0	0	0	0	1
12/23/2021 13:00	0.0	0	0	0	0	1
12/23/2021 14:00	0.0	0	0	0	0	1
12/23/2021 15:00	0.0	0	0	0	0	1
12/23/2021 16:00	0.0	0	0	0	0	1
12/23/2021 17:00	0.0	0	0	0	0	1
12/23/2021 18:00	0.0	0	0	0	0	1
12/23/2021 19:00	0.0	0	0	0	0	1
12/23/2021 20:00	0.0	0	0	0	0	1
12/23/2021 21:00	0.0	0	0	0	0	1
12/23/2021 22:00	0.0	0	0	0	0	1
12/23/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/24/2021 00:00	0.0	0	0	0	0	1
12/24/2021 01:00	0.0	0	0	0	0	1
12/24/2021 02:00	0.0	0	0	0	0	1
12/24/2021 03:00	0.0	0	0	0	0	1
12/24/2021 04:00	0.0	0	0	0	0	1
12/24/2021 05:00	0.0	0	0	0	0	1
12/24/2021 06:00	0.0	0	0	0	0	1
12/24/2021 07:00	0.0	0	0	0	0	1
12/24/2021 08:00	0.0	0	0	0	0	1
12/24/2021 09:00	0.0	0	0	0	0	1
12/24/2021 10:00	0.0	0	0	0	0	1
12/24/2021 11:00	0.0	0	0	0	0	1
12/24/2021 12:00	0.0	0	0	0	0	1
12/24/2021 13:00	0.0	0	0	0	0	1
12/24/2021 14:00	0.0	0	0	0	0	1
12/24/2021 15:00	0.0	0	0	0	0	1
12/24/2021 16:00	0.0	0	0	0	0	1
12/24/2021 17:00	0.0	0	0	0	0	1
12/24/2021 18:00	0.0	0	0	0	0	1
12/24/2021 19:00	0.0	0	0	0	0	1
12/24/2021 20:00	0.0	0	0	0	0	1
12/24/2021 21:00	0.0	0	0	0	0	1
12/24/2021 22:00	0.0	0	0	0	0	1
12/24/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/25/2021 00:00	0.0	0	0	0	0	1
12/25/2021 01:00	0.0	0	0	0	0	1
12/25/2021 02:00	0.0	0	0	0	0	1
12/25/2021 03:00	0.0	0	0	0	0	1
12/25/2021 04:00	0.0	0	0	0	0	1
12/25/2021 05:00	0.0	0	0	0	0	1
12/25/2021 06:00	0.0	0	0	0	0	1
12/25/2021 07:00	0.0	0	0	0	0	1
12/25/2021 08:00	0.0	0	0	0	0	1
12/25/2021 09:00	0.0	0	0	0	0	1
12/25/2021 10:00	0.0	0	0	0	0	1
12/25/2021 11:00	0.0	0	0	0	0	1
12/25/2021 12:00	0.0	0	0	0	0	1
12/25/2021 13:00	0.0	0	0	0	0	1
12/25/2021 14:00	0.0	0	0	0	0	1
12/25/2021 15:00	0.0	0	0	0	0	1
12/25/2021 16:00	0.0	0	0	0	0	1
12/25/2021 17:00	0.0	0	0	0	0	1
12/25/2021 18:00	0.0	0	0	0	0	1
12/25/2021 19:00	0.0	0	0	0	0	1
12/25/2021 20:00	0.0	0	0	0	0	1
12/25/2021 21:00	0.0	0	0	0	0	1
12/25/2021 22:00	0.0	0	0	0	0	1
12/25/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/26/2021 00:00	49.2	0	0	0	1	0
12/26/2021 01:00	0.0	0	0	0	0	0
12/26/2021 02:00	0.0	0	0	0	0	0
12/26/2021 03:00	0.0	0	0	0	0	0
12/26/2021 04:00	0.0	0	0	0	0	0
12/26/2021 05:00	0.0	0	0	0	0	0
12/26/2021 06:00	0.0	0	0	0	0	0
12/26/2021 07:00	0.0	0	0	0	0	0
12/26/2021 08:00	0.0	0	0	0	0	0
12/26/2021 09:00	0.0	0	0	0	0	0
12/26/2021 10:00	218.0	0	1	0	0	0
12/26/2021 11:00	3,815.8	0	1	0	0	0
12/26/2021 12:00	7,180.7	0	1	0	0	0
12/26/2021 13:00	0.0	0	0	0	0	1
12/26/2021 14:00	0.0	0	0	0	0	1
12/26/2021 15:00	0.0	0	0	0	0	1
12/26/2021 16:00	0.0	0	0	0	0	1
12/26/2021 17:00	0.0	0	0	0	0	1
12/26/2021 18:00	0.0	0	0	0	0	1
12/26/2021 19:00	0.0	0	0	0	0	1
12/26/2021 20:00	0.0	0	0	0	0	1
12/26/2021 21:00	0.0	0	0	0	0	1
12/26/2021 22:00	0.0	0	0	0	0	1
12/26/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	11,263.7 #	0 #	3 #	0 #	1 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	7,180.7	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/27/2021 00:00	0.0	0	0	0	0	1
12/27/2021 01:00	0.0	0	0	0	0	1
12/27/2021 02:00	0.0	0	0	0	0	1
12/27/2021 03:00	0.0	0	0	0	0	1
12/27/2021 04:00	0.0	0	0	0	0	1
12/27/2021 05:00	0.0	0	0	0	0	1
12/27/2021 06:00	0.0	0	0	0	0	1
12/27/2021 07:00	0.0	0	0	0	0	1
12/27/2021 08:00	0.0	0	0	0	0	1
12/27/2021 09:00	0.0	0	0	0	0	1
12/27/2021 10:00	0.0	0	0	0	0	1
12/27/2021 11:00	0.0	0	0	0	0	1
12/27/2021 12:00	0.0	0	0	0	0	1
12/27/2021 13:00	0.0	0	0	0	0	1
12/27/2021 14:00	0.0	0	0	0	0	1
12/27/2021 15:00	0.0	0	0	0	0	1
12/27/2021 16:00	0.0	0	0	0	0	1
12/27/2021 17:00	0.0	0	0	0	0	1
12/27/2021 18:00	0.0	0	0	0	0	1
12/27/2021 19:00	0.0	0	0	0	0	1
12/27/2021 20:00	0.0	0	0	0	0	1
12/27/2021 21:00	0.0	0	0	0	0	1
12/27/2021 22:00	0.0	0	0	0	0	1
12/27/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/28/2021 00:00	0.0	0	0	0	0	1
12/28/2021 01:00	0.0	0	0	0	0	1
12/28/2021 02:00	0.0	0	0	0	0	1
12/28/2021 03:00	0.0	0	0	0	0	1
12/28/2021 04:00	0.0	0	0	0	0	1
12/28/2021 05:00	0.0	0	0	0	0	1
12/28/2021 06:00	0.0	0	0	0	0	1
12/28/2021 07:00	0.0	0	0	0	0	1
12/28/2021 08:00	0.0	0	0	0	0	1
12/28/2021 09:00	0.0	0	0	0	0	1
12/28/2021 10:00	0.0	0	0	0	0	1
12/28/2021 11:00	0.0	0	0	0	0	1
12/28/2021 12:00	0.0	0	0	0	0	1
12/28/2021 13:00	0.0	0	0	0	0	1
12/28/2021 14:00	0.0	0	0	0	0	1
12/28/2021 15:00	0.0	0	0	0	0	1
12/28/2021 16:00	0.0	0	0	0	0	1
12/28/2021 17:00	0.0	0	0	0	0	1
12/28/2021 18:00	0.0	0	0	0	0	1
12/28/2021 19:00	0.0	0	0	0	0	1
12/28/2021 20:00	0.0	0	0	0	0	1
12/28/2021 21:00	0.0	0	0	0	0	1
12/28/2021 22:00	0.0	0	0	0	0	1
12/28/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/29/2021 00:00	0.0	0	0	0	0	1
12/29/2021 01:00	0.0	0	0	0	0	1
12/29/2021 02:00	0.0	0	0	0	0	1
12/29/2021 03:00	0.0	0	0	0	0	1
12/29/2021 04:00	0.0	0	0	0	0	1
12/29/2021 05:00	0.0	0	0	0	0	1
12/29/2021 06:00	0.0	0	0	0	0	1
12/29/2021 07:00	0.0	0	0	0	0	1
12/29/2021 08:00	0.0	0	0	0	0	1
12/29/2021 09:00	0.0	0	0	0	0	1
12/29/2021 10:00	0.0	0	0	0	0	1
12/29/2021 11:00	0.0	0	0	0	0	1
12/29/2021 12:00	0.0	0	0	0	0	1
12/29/2021 13:00	0.0	0	0	0	0	1
12/29/2021 14:00	0.0	0	0	0	0	1
12/29/2021 15:00	0.0	0	0	0	0	1
12/29/2021 16:00	0.0	0	0	0	0	1
12/29/2021 17:00	0.0	0	0	0	0	1
12/29/2021 18:00	0.0	0	0	0	0	1
12/29/2021 19:00	0.0	0	0	0	0	1
12/29/2021 20:00	0.0	0	0	0	0	1
12/29/2021 21:00	0.0	0	0	0	0	1
12/29/2021 22:00	0.0	0	0	0	0	1
12/29/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/30/2021 00:00	0.0	0	0	0	0	1
12/30/2021 01:00	0.0	0	0	0	0	1
12/30/2021 02:00	0.0	0	0	0	0	1
12/30/2021 03:00	0.0	0	0	0	0	1
12/30/2021 04:00	0.0	0	0	0	0	1
12/30/2021 05:00	0.0	0	0	0	0	1
12/30/2021 06:00	0.0	0	0	0	0	1
12/30/2021 07:00	0.0	0	0	0	0	1
12/30/2021 08:00	0.0	0	0	0	0	1
12/30/2021 09:00	0.0	0	0	0	0	1
12/30/2021 10:00	0.0	0	0	0	0	1
12/30/2021 11:00	0.0	0	0	0	0	1
12/30/2021 12:00	0.0	0	0	0	0	1
12/30/2021 13:00	0.0	0	0	0	0	1
12/30/2021 14:00	0.0	0	0	0	0	1
12/30/2021 15:00	0.0	0	0	0	0	1
12/30/2021 16:00	0.0	0	0	0	0	1
12/30/2021 17:00	0.0	0	0	0	0	1
12/30/2021 18:00	0.0	0	0	0	0	1
12/30/2021 19:00	0.0	0	0	0	0	1
12/30/2021 20:00	0.0	0	0	0	0	1
12/30/2021 21:00	0.0	0	0	0	0	1
12/30/2021 22:00	0.0	0	0	0	0	1
12/30/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:12 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/31/2021 00:00	0.0	0	0	0	0	1
12/31/2021 01:00	0.0	0	0	0	0	1
12/31/2021 02:00	0.0	0	0	0	0	1
12/31/2021 03:00	0.0	0	0	0	0	1
12/31/2021 04:00	0.0	0	0	0	0	1
12/31/2021 05:00	0.0	0	0	0	0	1
12/31/2021 06:00	0.0	0	0	0	0	1
12/31/2021 07:00	0.0	0	0	0	0	1
12/31/2021 08:00	0.0	0	0	0	0	1
12/31/2021 09:00	0.0	0	0	0	0	1
12/31/2021 10:00	0.0	0	0	0	0	1
12/31/2021 11:00	0.0	0	0	0	0	1
12/31/2021 12:00	0.0	0	0	0	0	1
12/31/2021 13:00	0.0	0	0	0	0	1
12/31/2021 14:00	0.0	0	0	0	0	1
12/31/2021 15:00	0.0	0	0	0	0	1
12/31/2021 16:00	0.0	0	0	0	0	1
12/31/2021 17:00	0.0	0	0	0	0	1
12/31/2021 18:00	0.0	0	0	0	0	1
12/31/2021 19:00	0.0	0	0	0	0	1
12/31/2021 20:00	0.0	0	0	0	0	1
12/31/2021 21:00	0.0	0	0	0	0	1
12/31/2021 22:00	0.0	0	0	0	0	1
12/31/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/01/2021 00:00	0.0	0	0	0	0	1
10/01/2021 01:00	0.0	0	0	0	0	1
10/01/2021 02:00	0.0	0	0	0	0	1
10/01/2021 03:00	0.0	0	0	0	0	1
10/01/2021 04:00	0.0	0	0	0	0	1
10/01/2021 05:00	0.0	0	0	0	0	1
10/01/2021 06:00	0.0	0	0	0	0	1
10/01/2021 07:00	0.0	0	0	0	0	1
10/01/2021 08:00	0.0	0	0	0	0	1
10/01/2021 09:00	0.0	0	0	0	0	1
10/01/2021 10:00	0.0	0	0	0	0	1
10/01/2021 11:00	0.0	0	0	0	0	1
10/01/2021 12:00	0.0	0	0	0	0	1
10/01/2021 13:00	0.0	0	0	0	0	1
10/01/2021 14:00	0.0	0	0	0	0	1
10/01/2021 15:00	0.0	0	0	0	0	1
10/01/2021 16:00	0.0	0	0	0	0	1
10/01/2021 17:00	0.0	0	0	0	0	1
10/01/2021 18:00	0.0	0	0	0	0	1
10/01/2021 19:00	0.0	0	0	0	0	1
10/01/2021 20:00	0.0	0	0	0	0	1
10/01/2021 21:00	0.0	0	0	0	0	1
10/01/2021 22:00	0.0	0	0	0	0	1
10/01/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/02/2021 00:00	0.0	0	0	0	0	1
10/02/2021 01:00	0.0	0	0	0	0	1
10/02/2021 02:00	0.0	0	0	0	0	1
10/02/2021 03:00	0.0	0	0	0	0	1
10/02/2021 04:00	0.0	0	0	0	0	1
10/02/2021 05:00	0.0	0	0	0	0	1
10/02/2021 06:00	0.0	0	0	0	0	1
10/02/2021 07:00	0.0	0	0	0	0	1
10/02/2021 08:00	0.0	0	0	0	0	1
10/02/2021 09:00	0.0	0	0	0	0	1
10/02/2021 10:00	0.0	0	0	0	0	1
10/02/2021 11:00	0.0	0	0	0	0	1
10/02/2021 12:00	0.0	0	0	0	0	1
10/02/2021 13:00	0.0	0	0	0	0	1
10/02/2021 14:00	0.0	0	0	0	0	1
10/02/2021 15:00	0.0	0	0	0	0	1
10/02/2021 16:00	0.0	0	0	0	0	1
10/02/2021 17:00	0.0	0	0	0	0	1
10/02/2021 18:00	0.0	0	0	0	0	1
10/02/2021 19:00	0.0	0	0	0	0	1
10/02/2021 20:00	0.0	0	0	0	0	1
10/02/2021 21:00	0.0	0	0	0	0	1
10/02/2021 22:00	0.0	0	0	0	0	1
10/02/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/03/2021 00:00	0.0	0	0	0	0	1
10/03/2021 01:00	0.0	0	0	0	0	1
10/03/2021 02:00	0.0	0	0	0	0	1
10/03/2021 03:00	0.0	0	0	0	0	1
10/03/2021 04:00	0.0	0	0	0	0	1
10/03/2021 05:00	0.0	0	0	0	0	1
10/03/2021 06:00	0.0	0	0	0	0	1
10/03/2021 07:00	0.0	0	0	0	0	1
10/03/2021 08:00	0.0	0	0	0	0	1
10/03/2021 09:00	0.0	0	0	0	0	1
10/03/2021 10:00	0.0	0	0	0	0	1
10/03/2021 11:00	0.0	0	0	0	0	1
10/03/2021 12:00	0.0	0	0	0	0	1
10/03/2021 13:00	0.0	0	0	0	0	1
10/03/2021 14:00	0.0	0	0	0	0	1
10/03/2021 15:00	0.0	0	0	0	0	1
10/03/2021 16:00	0.0	0	0	0	0	1
10/03/2021 17:00	0.0	0	0	0	0	1
10/03/2021 18:00	0.0	0	0	0	0	1
10/03/2021 19:00	0.0	0	0	0	0	1
10/03/2021 20:00	0.0	0	0	0	0	1
10/03/2021 21:00	0.0	0	0	0	0	1
10/03/2021 22:00	0.0	0	0	0	0	1
10/03/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/04/2021 00:00	0.0	0	0	0	0	1
10/04/2021 01:00	0.0	0	0	0	0	1
10/04/2021 02:00	0.0	0	0	0	0	1
10/04/2021 03:00	0.0	0	0	0	0	1
10/04/2021 04:00	0.0	0	0	0	0	1
10/04/2021 05:00	0.0	0	0	0	0	1
10/04/2021 06:00	0.0	0	0	0	0	1
10/04/2021 07:00	0.0	0	0	0	0	1
10/04/2021 08:00	0.0	0	0	0	0	1
10/04/2021 09:00	0.0	0	0	0	0	1
10/04/2021 10:00	0.0	0	0	0	0	1
10/04/2021 11:00	0.0	0	0	0	0	1
10/04/2021 12:00	0.0	0	0	0	0	1
10/04/2021 13:00	0.0	0	0	0	0	1
10/04/2021 14:00	0.0	0	0	0	0	1
10/04/2021 15:00	0.0	0	0	0	0	1
10/04/2021 16:00	0.0	0	0	0	0	1
10/04/2021 17:00	0.0	0	0	0	0	1
10/04/2021 18:00	0.0	0	0	0	0	1
10/04/2021 19:00	0.0	0	0	0	0	1
10/04/2021 20:00	0.0	0	0	0	0	1
10/04/2021 21:00	0.0	0	0	0	0	1
10/04/2021 22:00	0.0	0	0	0	0	1
10/04/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/05/2021 00:00	0.0	0	0	0	0	1
10/05/2021 01:00	0.0	0	0	0	0	1
10/05/2021 02:00	0.0	0	0	0	0	1
10/05/2021 03:00	0.0	0	0	0	0	1
10/05/2021 04:00	0.0	0	0	0	0	1
10/05/2021 05:00	0.0	0	0	0	0	1
10/05/2021 06:00	0.0	0	0	0	0	1
10/05/2021 07:00	0.0	0	0	0	0	1
10/05/2021 08:00	0.0	0	0	0	0	1
10/05/2021 09:00	0.0	0	0	0	0	1
10/05/2021 10:00	0.0	0	0	0	0	1
10/05/2021 11:00	0.0	0	0	0	0	1
10/05/2021 12:00	0.0	0	0	0	0	1
10/05/2021 13:00	0.0	0	0	0	0	1
10/05/2021 14:00	0.0	0	0	0	0	1
10/05/2021 15:00	0.0	0	0	0	0	1
10/05/2021 16:00	0.0	0	0	0	0	1
10/05/2021 17:00	0.0	0	0	0	0	1
10/05/2021 18:00	0.0	0	0	0	0	1
10/05/2021 19:00	0.0	0	0	0	0	1
10/05/2021 20:00	0.0	0	0	0	0	1
10/05/2021 21:00	0.0	0	0	0	0	1
10/05/2021 22:00	0.0	0	0	0	0	1
10/05/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/06/2021 00:00	0.0	0	0	0	0	1
10/06/2021 01:00	0.0	0	0	0	0	1
10/06/2021 02:00	0.0	0	0	0	0	1
10/06/2021 03:00	0.0	0	0	0	0	1
10/06/2021 04:00	0.0	0	0	0	0	1
10/06/2021 05:00	0.0	0	0	0	0	1
10/06/2021 06:00	0.0	0	0	0	0	1
10/06/2021 07:00	0.0	0	0	0	0	1
10/06/2021 08:00	0.0	0	0	0	0	1
10/06/2021 09:00	0.0	0	0	0	0	1
10/06/2021 10:00	0.0	0	0	0	0	1
10/06/2021 11:00	0.0	0	0	0	0	1
10/06/2021 12:00	0.0	0	0	0	0	1
10/06/2021 13:00	0.0	0	0	0	0	1
10/06/2021 14:00	0.0	0	0	0	0	1
10/06/2021 15:00	0.0	0	0	0	0	1
10/06/2021 16:00	0.0	0	0	0	0	1
10/06/2021 17:00	0.0	0	0	0	0	1
10/06/2021 18:00	0.0	0	0	0	0	1
10/06/2021 19:00	0.0	0	0	0	0	1
10/06/2021 20:00	0.0	0	0	0	0	1
10/06/2021 21:00	0.0	0	0	0	0	1
10/06/2021 22:00	0.0	0	0	0	0	1
10/06/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/07/2021 00:00	0.0	0	0	0	0	1
10/07/2021 01:00	0.0	0	0	0	0	1
10/07/2021 02:00	0.0	0	0	0	0	1
10/07/2021 03:00	0.0	0	0	0	0	1
10/07/2021 04:00	0.0	0	0	0	0	1
10/07/2021 05:00	0.0	0	0	0	0	1
10/07/2021 06:00	0.0	0	0	0	0	1
10/07/2021 07:00	0.0	0	0	0	0	1
10/07/2021 08:00	0.0	0	0	0	0	1
10/07/2021 09:00	0.0	0	0	0	0	1
10/07/2021 10:00	0.0	0	0	0	0	1
10/07/2021 11:00	0.0	0	0	0	0	1
10/07/2021 12:00	0.0	0	0	0	0	1
10/07/2021 13:00	0.0	0	0	0	0	1
10/07/2021 14:00	0.0	0	0	0	0	1
10/07/2021 15:00	0.0	0	0	0	0	1
10/07/2021 16:00	0.0	0	0	0	0	1
10/07/2021 17:00	0.0	0	0	0	0	1
10/07/2021 18:00	0.0	0	0	0	0	1
10/07/2021 19:00	0.0	0	0	0	0	1
10/07/2021 20:00	0.0	0	0	0	0	1
10/07/2021 21:00	0.0	0	0	0	0	1
10/07/2021 22:00	0.0	0	0	0	0	1
10/07/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/08/2021 00:00	0.0	0	0	0	0	1
10/08/2021 01:00	0.0	0	0	0	0	1
10/08/2021 02:00	0.0	0	0	0	0	1
10/08/2021 03:00	0.0	0	0	0	0	1
10/08/2021 04:00	0.0	0	0	0	0	1
10/08/2021 05:00	0.0	0	0	0	0	1
10/08/2021 06:00	0.0	0	0	0	0	1
10/08/2021 07:00	0.0	0	0	0	0	1
10/08/2021 08:00	0.0	0	0	0	0	1
10/08/2021 09:00	0.0	0	0	0	0	1
10/08/2021 10:00	0.0	0	0	0	0	1
10/08/2021 11:00	0.0	0	0	0	0	1
10/08/2021 12:00	0.0	0	0	0	0	1
10/08/2021 13:00	0.0	0	0	0	0	1
10/08/2021 14:00	0.0	0	0	0	0	1
10/08/2021 15:00	0.0	0	0	0	0	1
10/08/2021 16:00	0.0	0	0	0	0	1
10/08/2021 17:00	0.0	0	0	0	0	1
10/08/2021 18:00	0.0	0	0	0	0	1
10/08/2021 19:00	0.0	0	0	0	0	1
10/08/2021 20:00	0.0	0	0	0	0	1
10/08/2021 21:00	1.6	0	0	0	1	0
10/08/2021 22:00	0.0	0	0	0	0	0
10/08/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.6 #	0 #	0 #	0 #	1 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.6	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/09/2021 00:00	0.0	0	0	0	0	0
10/09/2021 01:00	0.0	0	0	0	0	0
10/09/2021 02:00	0.0	0	0	0	0	0
10/09/2021 03:00	0.0	0	0	0	0	0
10/09/2021 04:00	0.0	0	0	0	0	0
10/09/2021 05:00	0.0	0	0	0	0	0
10/09/2021 06:00	0.0	0	0	0	0	0
10/09/2021 07:00	0.0	0	0	0	0	0
10/09/2021 08:00	0.0	0	0	0	0	0
10/09/2021 09:00	0.0	0	0	0	0	0
10/09/2021 10:00	0.0	0	0	0	0	0
10/09/2021 11:00	0.0	0	0	0	0	0
10/09/2021 12:00	0.0	0	0	0	0	0
10/09/2021 13:00	0.0	0	0	0	0	0
10/09/2021 14:00	0.0	0	0	0	0	0
10/09/2021 15:00	0.0	0	0	0	0	0
10/09/2021 16:00	0.0	0	0	0	0	0
10/09/2021 17:00	0.0	0	0	0	0	0
10/09/2021 18:00	0.0	0	0	0	0	0
10/09/2021 19:00	0.0	0	0	0	0	0
10/09/2021 20:00	0.0	0	0	0	0	0
10/09/2021 21:00	0.0	0	0	0	0	0
10/09/2021 22:00	0.0	0	0	0	0	0
10/09/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/10/2021 00:00	0.0	0	0	0	0	0
10/10/2021 01:00	0.0	0	0	0	0	0
10/10/2021 02:00	0.0	0	0	0	0	0
10/10/2021 03:00	0.0	0	0	0	0	0
10/10/2021 04:00	0.0	0	0	0	0	0
10/10/2021 05:00	0.0	0	0	0	0	0
10/10/2021 06:00	0.0	0	0	0	0	0
10/10/2021 07:00	0.0	0	0	0	0	0
10/10/2021 08:00	0.0	0	0	0	0	0
10/10/2021 09:00	0.0	0	0	0	0	0
10/10/2021 10:00	0.0	0	0	0	0	0
10/10/2021 11:00	0.0	0	0	0	0	0
10/10/2021 12:00	0.0	0	0	0	0	0
10/10/2021 13:00	0.0	0	0	0	0	0
10/10/2021 14:00	0.0	0	0	0	0	0
10/10/2021 15:00	0.0	0	0	0	0	0
10/10/2021 16:00	0.0	0	0	0	0	0
10/10/2021 17:00	0.0	0	0	0	0	0
10/10/2021 18:00	0.0	0	0	0	0	0
10/10/2021 19:00	0.0	0	0	0	0	0
10/10/2021 20:00	0.0	0	0	0	0	0
10/10/2021 21:00	0.0	0	0	0	0	0
10/10/2021 22:00	0.0	0	0	0	0	0
10/10/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/11/2021 00:00	0.0	0	0	0	0	0
10/11/2021 01:00	0.0	0	0	0	0	0
10/11/2021 02:00	0.0	0	0	0	0	0
10/11/2021 03:00	0.0	0	0	0	0	0
10/11/2021 04:00	0.0	0	0	0	0	0
10/11/2021 05:00	0.0	0	0	0	0	0
10/11/2021 06:00	0.0	0	0	0	0	0
10/11/2021 07:00	0.0	0	0	0	0	0
10/11/2021 08:00	0.0	0	0	0	0	0
10/11/2021 09:00	0.0	0	0	0	0	0
10/11/2021 10:00	0.0	0	0	0	0	0
10/11/2021 11:00	0.0	0	0	0	0	0
10/11/2021 12:00	0.0	0	0	0	0	0
10/11/2021 13:00	0.0	0	0	0	0	0
10/11/2021 14:00	0.0	0	0	0	0	0
10/11/2021 15:00	0.0	0	0	0	0	0
10/11/2021 16:00	0.0	0	0	0	0	0
10/11/2021 17:00	0.0	0	0	0	0	0
10/11/2021 18:00	0.0	0	0	0	0	0
10/11/2021 19:00	0.0	0	0	0	0	0
10/11/2021 20:00	0.0	0	0	0	0	0
10/11/2021 21:00	0.0	0	0	0	0	0
10/11/2021 22:00	0.0	0	0	0	0	0
10/11/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/12/2021 00:00	0.0	0	0	0	0	0
10/12/2021 01:00	0.0	0	0	0	0	0
10/12/2021 02:00	0.0	0	0	0	0	0
10/12/2021 03:00	0.0	0	0	0	0	0
10/12/2021 04:00	0.0	0	0	0	0	0
10/12/2021 05:00	0.0	0	0	0	0	0
10/12/2021 06:00	0.0	0	0	0	0	0
10/12/2021 07:00	0.0	0	0	0	0	0
10/12/2021 08:00	0.0	0	0	0	0	0
10/12/2021 09:00	0.0	0	0	0	0	0
10/12/2021 10:00	0.0	0	0	0	0	0
10/12/2021 11:00	0.0	0	0	0	0	0
10/12/2021 12:00	0.0	0	0	0	0	0
10/12/2021 13:00	0.0	0	0	0	0	0
10/12/2021 14:00	0.0	0	0	0	0	0
10/12/2021 15:00	0.0	0	0	0	0	0
10/12/2021 16:00	0.0	0	0	0	0	0
10/12/2021 17:00	0.0	0	0	0	0	0
10/12/2021 18:00	0.0	0	0	0	0	0
10/12/2021 19:00	0.0	0	0	0	0	0
10/12/2021 20:00	0.0	0	0	0	0	0
10/12/2021 21:00	0.0	0	0	0	0	0
10/12/2021 22:00	0.0	0	0	0	0	0
10/12/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/13/2021 00:00	0.0	0	0	0	0	0
10/13/2021 01:00	0.0	0	0	0	0	0
10/13/2021 02:00	0.0	0	0	0	0	0
10/13/2021 03:00	0.0	0	0	0	0	0
10/13/2021 04:00	0.0	0	0	0	0	0
10/13/2021 05:00	0.0	0	0	0	0	0
10/13/2021 06:00	0.0	0	0	0	0	0
10/13/2021 07:00	0.0	0	0	0	0	0
10/13/2021 08:00	0.0	0	0	0	0	0
10/13/2021 09:00	0.0	0	0	0	0	0
10/13/2021 10:00	0.0	0	0	0	0	0
10/13/2021 11:00	0.0	0	0	0	0	0
10/13/2021 12:00	0.0	0	0	0	0	0
10/13/2021 13:00	0.0	0	0	0	0	0
10/13/2021 14:00	0.0	0	0	0	0	0
10/13/2021 15:00	0.0	0	0	0	0	0
10/13/2021 16:00	0.0	0	0	0	0	0
10/13/2021 17:00	0.0	0	0	0	0	0
10/13/2021 18:00	0.0	0	0	0	0	0
10/13/2021 19:00	0.0	0	0	0	0	0
10/13/2021 20:00	0.0	0	0	0	0	0
10/13/2021 21:00	0.0	0	0	0	0	0
10/13/2021 22:00	0.0	0	0	0	0	0
10/13/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/14/2021 00:00	0.0	0	0	0	0	0
10/14/2021 01:00	0.0	0	0	0	0	0
10/14/2021 02:00	0.0	0	0	0	0	0
10/14/2021 03:00	0.0	0	0	0	0	0
10/14/2021 04:00	0.0	0	0	0	0	0
10/14/2021 05:00	0.0	0	0	0	0	0
10/14/2021 06:00	0.0	0	0	0	0	0
10/14/2021 07:00	0.0	0	0	0	0	0
10/14/2021 08:00	0.0	0	0	0	0	0
10/14/2021 09:00	0.0	0	0	0	0	0
10/14/2021 10:00	0.0	0	0	0	0	0
10/14/2021 11:00	0.0	0	0	0	0	0
10/14/2021 12:00	0.0	0	0	0	0	0
10/14/2021 13:00	0.0	0	0	0	0	0
10/14/2021 14:00	0.0	0	0	0	0	0
10/14/2021 15:00	0.0	0	0	0	0	0
10/14/2021 16:00	0.0	0	0	0	0	0
10/14/2021 17:00	0.0	0	0	0	0	0
10/14/2021 18:00	0.0	0	0	0	0	0
10/14/2021 19:00	0.0	0	0	0	0	0
10/14/2021 20:00	0.0	0	0	0	0	0
10/14/2021 21:00	0.0	0	0	0	0	0
10/14/2021 22:00	0.0	0	0	0	0	0
10/14/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/15/2021 00:00	0.0	0	0	0	0	0
10/15/2021 01:00	0.0	0	0	0	0	0
10/15/2021 02:00	0.0	0	0	0	0	0
10/15/2021 03:00	0.0	0	0	0	0	0
10/15/2021 04:00	0.0	0	0	0	0	0
10/15/2021 05:00	0.0	0	0	0	0	0
10/15/2021 06:00	0.0	0	0	0	0	0
10/15/2021 07:00	0.0	0	0	0	0	0
10/15/2021 08:00	0.0	0	0	0	0	0
10/15/2021 09:00	0.0	0	0	0	0	0
10/15/2021 10:00	0.0	0	0	0	0	0
10/15/2021 11:00	0.0	0	0	0	0	0
10/15/2021 12:00	0.0	0	0	0	0	0
10/15/2021 13:00	0.0	0	0	0	0	0
10/15/2021 14:00	0.0	0	0	0	0	0
10/15/2021 15:00	0.0	0	0	0	0	0
10/15/2021 16:00	0.0	0	0	0	0	0
10/15/2021 17:00	0.0	0	0	0	0	0
10/15/2021 18:00	0.0	0	0	0	0	0
10/15/2021 19:00	0.0	0	0	0	0	0
10/15/2021 20:00	0.0	0	0	0	0	0
10/15/2021 21:00	0.0	0	0	0	0	0
10/15/2021 22:00	0.0	0	0	0	0	0
10/15/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/16/2021 00:00	0.0	0	0	0	0	0
10/16/2021 01:00	0.0	0	0	0	0	0
10/16/2021 02:00	0.0	0	0	0	0	0
10/16/2021 03:00	0.0	0	0	0	0	0
10/16/2021 04:00	0.0	0	0	0	0	0
10/16/2021 05:00	0.0	0	0	0	0	0
10/16/2021 06:00	0.0	0	0	0	0	0
10/16/2021 07:00	0.0	0	0	0	0	0
10/16/2021 08:00	0.0	0	0	0	0	0
10/16/2021 09:00	0.0	0	0	0	0	0
10/16/2021 10:00	0.0	0	0	0	0	0
10/16/2021 11:00	0.0	0	0	0	0	0
10/16/2021 12:00	0.0	0	0	0	0	0
10/16/2021 13:00	0.0	0	0	0	0	0
10/16/2021 14:00	0.0	0	0	0	0	0
10/16/2021 15:00	0.0	0	0	0	0	0
10/16/2021 16:00	0.0	0	0	0	0	0
10/16/2021 17:00	0.0	0	0	0	0	0
10/16/2021 18:00	0.0	0	0	0	0	0
10/16/2021 19:00	0.0	0	0	0	0	0
10/16/2021 20:00	0.0	0	0	0	0	0
10/16/2021 21:00	0.0	0	0	0	0	0
10/16/2021 22:00	0.0	0	0	0	0	0
10/16/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/17/2021 00:00	0.0	0	0	0	0	0
10/17/2021 01:00	0.0	0	0	0	0	0
10/17/2021 02:00	0.0	0	0	0	0	0
10/17/2021 03:00	0.0	0	0	0	0	0
10/17/2021 04:00	0.0	0	0	0	0	0
10/17/2021 05:00	0.0	0	0	0	0	0
10/17/2021 06:00	0.0	0	0	0	0	0
10/17/2021 07:00	0.0	0	0	0	0	0
10/17/2021 08:00	0.0	0	0	0	0	0
10/17/2021 09:00	0.0	0	0	0	0	0
10/17/2021 10:00	0.0	0	0	0	0	0
10/17/2021 11:00	0.0	0	0	0	0	0
10/17/2021 12:00	0.0	0	0	0	0	0
10/17/2021 13:00	0.0	0	0	0	0	0
10/17/2021 14:00	0.0	0	0	0	0	0
10/17/2021 15:00	0.0	0	0	0	0	0
10/17/2021 16:00	0.0	0	0	0	0	0
10/17/2021 17:00	0.0	0	0	0	0	0
10/17/2021 18:00	0.0	0	0	0	0	0
10/17/2021 19:00	0.0	0	0	0	0	0
10/17/2021 20:00	0.0	0	0	0	0	0
10/17/2021 21:00	0.0	0	0	0	0	0
10/17/2021 22:00	0.0	0	0	0	0	0
10/17/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/18/2021 00:00	0.0	0	0	0	0	0
10/18/2021 01:00	0.0	0	0	0	0	0
10/18/2021 02:00	0.0	0	0	0	0	0
10/18/2021 03:00	0.0	0	0	0	0	0
10/18/2021 04:00	0.0	0	0	0	0	0
10/18/2021 05:00	0.0	0	0	0	0	0
10/18/2021 06:00	0.0	0	0	0	0	0
10/18/2021 07:00	0.0	0	0	0	0	0
10/18/2021 08:00	0.0	0	0	0	0	0
10/18/2021 09:00	0.0	0	0	0	0	0
10/18/2021 10:00	0.0	0	0	0	0	0
10/18/2021 11:00	0.0	0	0	0	0	0
10/18/2021 12:00	0.0	0	0	0	0	0
10/18/2021 13:00	0.0	0	0	0	0	0
10/18/2021 14:00	0.0	0	0	0	0	0
10/18/2021 15:00	0.0	0	0	0	0	0
10/18/2021 16:00	0.0	0	0	0	0	0
10/18/2021 17:00	0.0	0	0	0	0	0
10/18/2021 18:00	0.0	0	0	0	0	0
10/18/2021 19:00	0.0	0	0	0	0	0
10/18/2021 20:00	0.0	0	0	0	0	0
10/18/2021 21:00	0.0	0	0	0	0	0
10/18/2021 22:00	0.0	0	0	0	0	0
10/18/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/19/2021 00:00	0.0	0	0	0	0	0
10/19/2021 01:00	0.0	0	0	0	0	0
10/19/2021 02:00	0.0	0	0	0	0	0
10/19/2021 03:00	0.0	0	0	0	0	0
10/19/2021 04:00	0.0	0	0	0	0	0
10/19/2021 05:00	0.0	0	0	0	0	0
10/19/2021 06:00	0.0	0	0	0	0	0
10/19/2021 07:00	0.0	0	0	0	0	0
10/19/2021 08:00	0.0	0	0	0	0	0
10/19/2021 09:00	0.0	0	0	0	0	0
10/19/2021 10:00	0.0	0	0	0	0	0
10/19/2021 11:00	0.0	0	0	0	0	0
10/19/2021 12:00	0.0	0	0	0	0	0
10/19/2021 13:00	0.0	0	0	0	0	0
10/19/2021 14:00	0.0	0	0	0	0	0
10/19/2021 15:00	0.0	0	0	0	0	0
10/19/2021 16:00	0.0	0	0	0	0	0
10/19/2021 17:00	0.0	0	0	0	0	0
10/19/2021 18:00	0.0	0	0	0	0	0
10/19/2021 19:00	0.0	0	0	0	0	0
10/19/2021 20:00	0.0	0	0	0	0	0
10/19/2021 21:00	0.0	0	0	0	0	0
10/19/2021 22:00	0.0	0	0	0	0	0
10/19/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/20/2021 00:00	0.0	0	0	0	0	0
10/20/2021 01:00	0.0	0	0	0	0	0
10/20/2021 02:00	0.0	0	0	0	0	0
10/20/2021 03:00	0.0	0	0	0	0	0
10/20/2021 04:00	0.0	0	0	0	0	0
10/20/2021 05:00	0.0	0	0	0	0	0
10/20/2021 06:00	0.0	0	0	0	0	0
10/20/2021 07:00	0.0	0	0	0	0	0
10/20/2021 08:00	0.0	0	0	0	0	0
10/20/2021 09:00	0.0	0	0	0	0	0
10/20/2021 10:00	0.0	0	0	0	0	0
10/20/2021 11:00	0.0	0	0	0	0	0
10/20/2021 12:00	0.0	0	0	0	0	0
10/20/2021 13:00	30.1	1	0	0	0	0
10/20/2021 14:00	65.8	1	0	0	0	0
10/20/2021 15:00	1.8	1	0	0	0	0
10/20/2021 16:00	0.0	0	0	0	0	1
10/20/2021 17:00	0.0	0	0	0	0	1
10/20/2021 18:00	0.0	0	0	0	0	1
10/20/2021 19:00	0.0	0	0	0	0	1
10/20/2021 20:00	0.0	0	0	0	0	1
10/20/2021 21:00	0.0	0	0	0	0	1
10/20/2021 22:00	1.2	0	0	0	1	0
10/20/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	98.9 #	3 #	0 #	0 #	1 #	6 #
Minimum:	0.0	0	0	0	0	0
Maximum:	65.8	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/21/2021 00:00	0.0	0	0	0	0	0
10/21/2021 01:00	0.0	0	0	0	0	0
10/21/2021 02:00	0.0	0	0	0	0	0
10/21/2021 03:00	0.0	0	0	0	0	0
10/21/2021 04:00	0.0	0	0	0	0	0
10/21/2021 05:00	0.0	0	0	0	0	0
10/21/2021 06:00	0.0	0	0	0	0	0
10/21/2021 07:00	0.0	0	0	0	0	0
10/21/2021 08:00	0.0	0	0	0	0	0
10/21/2021 09:00	0.0	0	0	0	0	0
10/21/2021 10:00	0.0	0	0	0	0	0
10/21/2021 11:00	0.0	0	0	0	0	0
10/21/2021 12:00	0.0	0	0	0	0	0
10/21/2021 13:00	0.0	0	0	0	0	0
10/21/2021 14:00	0.0	0	0	0	0	0
10/21/2021 15:00	0.0	0	0	0	0	0
10/21/2021 16:00	0.0	0	0	0	0	0
10/21/2021 17:00	0.0	0	0	0	0	0
10/21/2021 18:00	0.0	0	0	0	0	0
10/21/2021 19:00	0.0	0	0	0	0	0
10/21/2021 20:00	0.0	0	0	0	0	0
10/21/2021 21:00	0.0	0	0	0	0	0
10/21/2021 22:00	0.0	0	0	0	0	0
10/21/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/22/2021 00:00	0.0	0	0	0	0	0
10/22/2021 01:00	0.0	0	0	0	0	0
10/22/2021 02:00	0.0	0	0	0	0	0
10/22/2021 03:00	0.0	0	0	0	0	0
10/22/2021 04:00	0.0	0	0	0	0	0
10/22/2021 05:00	0.0	0	0	0	0	0
10/22/2021 06:00	0.0	0	0	0	0	0
10/22/2021 07:00	0.0	0	0	0	0	0
10/22/2021 08:00	0.0	0	0	0	0	0
10/22/2021 09:00	0.0	0	0	0	0	0
10/22/2021 10:00	0.0	0	0	0	0	0
10/22/2021 11:00	0.0	0	0	0	0	0
10/22/2021 12:00	0.0	0	0	0	0	0
10/22/2021 13:00	0.0	0	0	0	0	0
10/22/2021 14:00	0.0	0	0	0	0	0
10/22/2021 15:00	0.0	0	0	0	0	0
10/22/2021 16:00	0.0	0	0	0	0	0
10/22/2021 17:00	0.0	0	0	0	0	0
10/22/2021 18:00	0.0	0	0	0	0	0
10/22/2021 19:00	0.0	0	0	0	0	0
10/22/2021 20:00	0.0	0	0	0	0	0
10/22/2021 21:00	0.0	0	0	0	0	0
10/22/2021 22:00	0.0	0	0	0	0	0
10/22/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/23/2021 00:00	0.0	0	0	0	0	0
10/23/2021 01:00	42.8	0	1	0	0	0
10/23/2021 02:00	35.7	0	1	0	0	0
10/23/2021 03:00	23.8	0	1	0	0	0
10/23/2021 04:00	0.0	0	0	0	0	1
10/23/2021 05:00	0.0	0	0	0	0	1
10/23/2021 06:00	0.0	0	0	0	0	1
10/23/2021 07:00	0.0	0	0	0	0	1
10/23/2021 08:00	0.0	0	0	0	0	1
10/23/2021 09:00	0.0	0	0	0	0	1
10/23/2021 10:00	0.0	0	0	0	0	1
10/23/2021 11:00	0.0	0	0	0	0	1
10/23/2021 12:00	0.0	0	0	0	0	1
10/23/2021 13:00	0.0	0	0	0	0	1
10/23/2021 14:00	0.0	0	0	0	0	1
10/23/2021 15:00	0.0	0	0	0	0	1
10/23/2021 16:00	0.0	0	0	0	0	1
10/23/2021 17:00	0.0	0	0	0	0	1
10/23/2021 18:00	0.0	0	0	0	0	1
10/23/2021 19:00	0.0	0	0	0	0	1
10/23/2021 20:00	0.0	0	0	0	0	1
10/23/2021 21:00	0.0	0	0	0	0	1
10/23/2021 22:00	1.0	0	0	0	1	0
10/23/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	103.3 #	0 #	3 #	0 #	1 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	42.8	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/24/2021 00:00	0.0	0	0	0	0	0
10/24/2021 01:00	0.0	0	0	0	0	0
10/24/2021 02:00	0.0	0	0	0	0	0
10/24/2021 03:00	0.0	0	0	0	0	0
10/24/2021 04:00	0.0	0	0	0	0	0
10/24/2021 05:00	0.0	0	0	0	0	0
10/24/2021 06:00	0.0	0	0	0	0	0
10/24/2021 07:00	21.2	0	1	0	0	0
10/24/2021 08:00	13.7	0	1	0	0	0
10/24/2021 09:00	0.0	0	0	0	0	1
10/24/2021 10:00	0.0	0	0	0	0	1
10/24/2021 11:00	0.0	0	0	0	0	1
10/24/2021 12:00	0.0	0	0	0	0	1
10/24/2021 13:00	0.0	0	0	0	0	1
10/24/2021 14:00	0.0	0	0	0	0	1
10/24/2021 15:00	0.0	0	0	0	0	1
10/24/2021 16:00	0.0	0	0	0	0	1
10/24/2021 17:00	0.0	0	0	0	0	1
10/24/2021 18:00	0.0	0	0	0	0	1
10/24/2021 19:00	0.0	0	0	0	0	1
10/24/2021 20:00	0.0	0	0	0	0	1
10/24/2021 21:00	0.0	0	0	0	0	1
10/24/2021 22:00	0.0	0	0	0	0	1
10/24/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	34.9 #	0 #	2 #	0 #	0 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	21.2	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/25/2021 00:00	0.0	0	0	0	0	1
10/25/2021 01:00	0.0	0	0	0	0	1
10/25/2021 02:00	0.0	0	0	0	0	1
10/25/2021 03:00	0.0	0	0	0	0	1
10/25/2021 04:00	0.0	0	0	0	0	1
10/25/2021 05:00	0.0	0	0	0	0	1
10/25/2021 06:00	0.0	0	0	0	0	1
10/25/2021 07:00	0.0	0	0	0	0	1
10/25/2021 08:00	0.0	0	0	0	0	1
10/25/2021 09:00	0.0	0	0	0	0	1
10/25/2021 10:00	0.0	0	0	0	0	1
10/25/2021 11:00	0.0	0	0	0	0	1
10/25/2021 12:00	0.0	0	0	0	0	1
10/25/2021 13:00	0.0	0	0	0	0	1
10/25/2021 14:00	0.0	0	0	0	0	1
10/25/2021 15:00	0.0	0	0	0	0	1
10/25/2021 16:00	0.0	0	0	0	0	1
10/25/2021 17:00	0.0	0	0	0	0	1
10/25/2021 18:00	0.0	0	0	0	0	1
10/25/2021 19:00	0.0	0	0	0	0	1
10/25/2021 20:00	0.0	0	0	0	0	1
10/25/2021 21:00	0.0	0	0	0	0	1
10/25/2021 22:00	0.0	0	0	0	0	1
10/25/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/26/2021 00:00	0.0	0	0	0	0	1
10/26/2021 01:00	0.0	0	0	0	0	1
10/26/2021 02:00	0.0	0	0	0	0	1
10/26/2021 03:00	0.0	0	0	0	0	1
10/26/2021 04:00	0.0	0	0	0	0	1
10/26/2021 05:00	0.0	0	0	0	0	1
10/26/2021 06:00	0.0	0	0	0	0	1
10/26/2021 07:00	0.0	0	0	0	0	1
10/26/2021 08:00	0.0	0	0	0	0	1
10/26/2021 09:00	0.0	0	0	0	0	1
10/26/2021 10:00	0.0	0	0	0	0	1
10/26/2021 11:00	0.0	0	0	0	0	1
10/26/2021 12:00	0.0	0	0	0	0	1
10/26/2021 13:00	0.0	0	0	0	0	1
10/26/2021 14:00	0.0	0	0	0	0	1
10/26/2021 15:00	0.0	0	0	0	0	1
10/26/2021 16:00	0.0	0	0	0	0	1
10/26/2021 17:00	0.0	0	0	0	0	1
10/26/2021 18:00	0.0	0	0	0	0	1
10/26/2021 19:00	0.0	0	0	0	0	1
10/26/2021 20:00	0.0	0	0	0	0	1
10/26/2021 21:00	0.0	0	0	0	0	1
10/26/2021 22:00	0.0	0	0	0	0	1
10/26/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/27/2021 00:00	0.0	0	0	0	0	1
10/27/2021 01:00	0.0	0	0	0	0	1
10/27/2021 02:00	0.0	0	0	0	0	1
10/27/2021 03:00	0.0	0	0	0	0	1
10/27/2021 04:00	0.0	0	0	0	0	1
10/27/2021 05:00	0.0	0	0	0	0	1
10/27/2021 06:00	0.0	0	0	0	0	1
10/27/2021 07:00	0.0	0	0	0	0	1
10/27/2021 08:00	0.0	0	0	0	0	1
10/27/2021 09:00	0.0	0	0	0	0	1
10/27/2021 10:00	0.0	0	0	0	0	1
10/27/2021 11:00	0.0	0	0	0	0	1
10/27/2021 12:00	0.0	0	0	0	0	1
10/27/2021 13:00	0.0	0	0	0	0	1
10/27/2021 14:00	0.0	0	0	0	0	1
10/27/2021 15:00	0.0	0	0	0	0	1
10/27/2021 16:00	0.0	0	0	0	0	1
10/27/2021 17:00	0.0	0	0	0	0	1
10/27/2021 18:00	0.0	0	0	0	0	1
10/27/2021 19:00	0.0	0	0	0	0	1
10/27/2021 20:00	0.0	0	0	0	0	1
10/27/2021 21:00	0.0	0	0	0	0	1
10/27/2021 22:00	0.0	0	0	0	0	1
10/27/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/28/2021 00:00	0.0	0	0	0	0	1
10/28/2021 01:00	0.0	0	0	0	0	1
10/28/2021 02:00	0.0	0	0	0	0	1
10/28/2021 03:00	0.0	0	0	0	0	1
10/28/2021 04:00	0.0	0	0	0	0	1
10/28/2021 05:00	0.0	0	0	0	0	1
10/28/2021 06:00	0.0	0	0	0	0	1
10/28/2021 07:00	0.0	0	0	0	0	1
10/28/2021 08:00	0.0	0	0	0	0	1
10/28/2021 09:00	0.0	0	0	0	0	1
10/28/2021 10:00	0.0	0	0	0	0	1
10/28/2021 11:00	0.0	0	0	0	0	1
10/28/2021 12:00	0.0	0	0	0	0	1
10/28/2021 13:00	0.0	0	0	0	0	1
10/28/2021 14:00	0.0	0	0	0	0	1
10/28/2021 15:00	0.0	0	0	0	0	1
10/28/2021 16:00	0.0	0	0	0	0	1
10/28/2021 17:00	0.0	0	0	0	0	1
10/28/2021 18:00	0.0	0	0	0	0	1
10/28/2021 19:00	0.0	0	0	0	0	1
10/28/2021 20:00	0.0	0	0	0	0	1
10/28/2021 21:00	0.0	0	0	0	0	1
10/28/2021 22:00	0.0	0	0	0	0	1
10/28/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/29/2021 00:00	0.0	0	0	0	0	1
10/29/2021 01:00	0.0	0	0	0	0	1
10/29/2021 02:00	0.0	0	0	0	0	1
10/29/2021 03:00	0.0	0	0	0	0	1
10/29/2021 04:00	0.0	0	0	0	0	1
10/29/2021 05:00	0.0	0	0	0	0	1
10/29/2021 06:00	0.0	0	0	0	0	1
10/29/2021 07:00	0.0	0	0	0	0	1
10/29/2021 08:00	0.0	0	0	0	0	1
10/29/2021 09:00	0.0	0	0	0	0	1
10/29/2021 10:00	0.0	0	0	0	0	1
10/29/2021 11:00	0.0	0	0	0	0	1
10/29/2021 12:00	0.0	0	0	0	0	1
10/29/2021 13:00	0.0	0	0	0	0	1
10/29/2021 14:00	0.0	0	0	0	0	1
10/29/2021 15:00	0.0	0	0	0	0	1
10/29/2021 16:00	0.0	0	0	0	0	1
10/29/2021 17:00	0.0	0	0	0	0	1
10/29/2021 18:00	0.0	0	0	0	0	1
10/29/2021 19:00	0.0	0	0	0	0	1
10/29/2021 20:00	0.0	0	0	0	0	1
10/29/2021 21:00	0.0	0	0	0	0	1
10/29/2021 22:00	0.0	0	0	0	0	1
10/29/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/30/2021 00:00	0.0	0	0	0	0	1
10/30/2021 01:00	0.0	0	0	0	0	1
10/30/2021 02:00	0.0	0	0	0	0	1
10/30/2021 03:00	0.0	0	0	0	0	1
10/30/2021 04:00	0.0	0	0	0	0	1
10/30/2021 05:00	0.0	0	0	0	0	1
10/30/2021 06:00	0.0	0	0	0	0	1
10/30/2021 07:00	0.0	0	0	0	0	1
10/30/2021 08:00	0.0	0	0	0	0	1
10/30/2021 09:00	0.0	0	0	0	0	1
10/30/2021 10:00	0.0	0	0	0	0	1
10/30/2021 11:00	0.0	0	0	0	0	1
10/30/2021 12:00	0.0	0	0	0	0	1
10/30/2021 13:00	0.0	0	0	0	0	1
10/30/2021 14:00	0.0	0	0	0	0	1
10/30/2021 15:00	0.0	0	0	0	0	1
10/30/2021 16:00	0.0	0	0	0	0	1
10/30/2021 17:00	0.0	0	0	0	0	1
10/30/2021 18:00	0.0	0	0	0	0	1
10/30/2021 19:00	0.0	0	0	0	0	1
10/30/2021 20:00	0.0	0	0	0	0	1
10/30/2021 21:00	0.0	0	0	0	0	1
10/30/2021 22:00	0.0	0	0	0	0	1
10/30/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
10/31/2021 00:00	0.0	0	0	0	0	1
10/31/2021 01:00	0.0	0	0	0	0	1
10/31/2021 02:00	0.0	0	0	0	0	1
10/31/2021 03:00	0.0	0	0	0	0	1
10/31/2021 04:00	0.0	0	0	0	0	1
10/31/2021 05:00	0.0	0	0	0	0	1
10/31/2021 06:00	0.0	0	0	0	0	1
10/31/2021 07:00	0.0	0	0	0	0	1
10/31/2021 08:00	0.0	0	0	0	0	1
10/31/2021 09:00	0.0	0	0	0	0	1
10/31/2021 10:00	0.0	0	0	0	0	1
10/31/2021 11:00	0.0	0	0	0	0	1
10/31/2021 12:00	0.0	0	0	0	0	1
10/31/2021 13:00	0.0	0	0	0	0	1
10/31/2021 14:00	0.0	0	0	0	0	1
10/31/2021 15:00	0.0	0	0	0	0	1
10/31/2021 16:00	0.0	0	0	0	0	1
10/31/2021 17:00	0.0	0	0	0	0	1
10/31/2021 18:00	0.0	0	0	0	0	1
10/31/2021 19:00	0.0	0	0	0	0	1
10/31/2021 20:00	0.0	0	0	0	0	1
10/31/2021 21:00	0.0	0	0	0	0	1
10/31/2021 22:00	0.0	0	0	0	0	1
10/31/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/01/2021 00:00	0.0	0	0	0	0	1
11/01/2021 01:00	0.0	0	0	0	0	1
11/01/2021 02:00	0.0	0	0	0	0	1
11/01/2021 03:00	0.0	0	0	0	0	1
11/01/2021 04:00	0.0	0	0	0	0	1
11/01/2021 05:00	0.0	0	0	0	0	1
11/01/2021 06:00	0.0	0	0	0	0	1
11/01/2021 07:00	0.0	0	0	0	0	1
11/01/2021 08:00	0.0	0	0	0	0	1
11/01/2021 09:00	0.0	0	0	0	0	1
11/01/2021 10:00	0.0	0	0	0	0	1
11/01/2021 11:00	0.0	0	0	0	0	1
11/01/2021 12:00	0.0	0	0	0	0	1
11/01/2021 13:00	0.0	0	0	0	0	1
11/01/2021 14:00	0.0	0	0	0	0	1
11/01/2021 15:00	0.0	0	0	0	0	1
11/01/2021 16:00	0.0	0	0	0	0	1
11/01/2021 17:00	0.0	0	0	0	0	1
11/01/2021 18:00	0.0	0	0	0	0	1
11/01/2021 19:00	0.0	0	0	0	0	1
11/01/2021 20:00	0.0	0	0	0	0	1
11/01/2021 21:00	0.0	0	0	0	0	1
11/01/2021 22:00	0.0	0	0	0	0	1
11/01/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/02/2021 00:00	0.0	0	0	0	0	1
11/02/2021 01:00	0.0	0	0	0	0	1
11/02/2021 02:00	0.0	0	0	0	0	1
11/02/2021 03:00	0.0	0	0	0	0	1
11/02/2021 04:00	0.0	0	0	0	0	1
11/02/2021 05:00	0.0	0	0	0	0	1
11/02/2021 06:00	0.0	0	0	0	0	1
11/02/2021 07:00	0.0	0	0	0	0	1
11/02/2021 08:00	0.0	0	0	0	0	1
11/02/2021 09:00	0.0	0	0	0	0	1
11/02/2021 10:00	0.0	0	0	0	0	1
11/02/2021 11:00	0.0	0	0	0	0	1
11/02/2021 12:00	0.0	0	0	0	0	1
11/02/2021 13:00	0.0	0	0	0	0	1
11/02/2021 14:00	0.0	0	0	0	0	1
11/02/2021 15:00	0.0	0	0	0	0	1
11/02/2021 16:00	0.0	0	0	0	0	1
11/02/2021 17:00	0.0	0	0	0	0	1
11/02/2021 18:00	0.0	0	0	0	0	1
11/02/2021 19:00	0.0	0	0	0	0	1
11/02/2021 20:00	0.0	0	0	0	0	1
11/02/2021 21:00	0.0	0	0	0	0	1
11/02/2021 22:00	0.0	0	0	0	0	1
11/02/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/03/2021 00:00	0.0	0	0	0	0	1
11/03/2021 01:00	0.0	0	0	0	0	1
11/03/2021 02:00	0.0	0	0	0	0	1
11/03/2021 03:00	0.0	0	0	0	0	1
11/03/2021 04:00	0.0	0	0	0	0	1
11/03/2021 05:00	0.0	0	0	0	0	1
11/03/2021 06:00	0.0	0	0	0	0	1
11/03/2021 07:00	0.0	0	0	0	0	1
11/03/2021 08:00	0.0	0	0	0	0	1
11/03/2021 09:00	0.0	0	0	0	0	1
11/03/2021 10:00	0.0	0	0	0	0	1
11/03/2021 11:00	0.0	0	0	0	0	1
11/03/2021 12:00	0.0	0	0	0	0	1
11/03/2021 13:00	0.0	0	0	0	0	1
11/03/2021 14:00	0.0	0	0	0	0	1
11/03/2021 15:00	0.0	0	0	0	0	1
11/03/2021 16:00	0.0	0	0	0	0	1
11/03/2021 17:00	0.0	0	0	0	0	1
11/03/2021 18:00	0.0	0	0	0	0	1
11/03/2021 19:00	0.0	0	0	0	0	1
11/03/2021 20:00	0.0	0	0	0	0	1
11/03/2021 21:00	0.0	0	0	0	0	1
11/03/2021 22:00	0.0	0	0	0	0	1
11/03/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/04/2021 00:00	0.0	0	0	0	0	1
11/04/2021 01:00	0.0	0	0	0	0	1
11/04/2021 02:00	0.0	0	0	0	0	1
11/04/2021 03:00	0.0	0	0	0	0	1
11/04/2021 04:00	0.0	0	0	0	0	1
11/04/2021 05:00	0.0	0	0	0	0	1
11/04/2021 06:00	0.0	0	0	0	0	1
11/04/2021 07:00	0.0	0	0	0	0	1
11/04/2021 08:00	0.0	0	0	0	0	1
11/04/2021 09:00	0.0	0	0	0	0	1
11/04/2021 10:00	0.0	0	0	0	0	1
11/04/2021 11:00	0.0	0	0	0	0	1
11/04/2021 12:00	0.0	0	0	0	0	1
11/04/2021 13:00	0.0	0	0	0	0	1
11/04/2021 14:00	0.0	0	0	0	0	1
11/04/2021 15:00	0.0	0	0	0	0	1
11/04/2021 16:00	0.0	0	0	0	0	1
11/04/2021 17:00	0.0	0	0	0	0	1
11/04/2021 18:00	0.0	0	0	0	0	1
11/04/2021 19:00	0.0	0	0	0	0	1
11/04/2021 20:00	0.0	0	0	0	0	1
11/04/2021 21:00	0.0	0	0	0	0	1
11/04/2021 22:00	0.0	0	0	0	0	1
11/04/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/05/2021 00:00	0.0	0	0	0	0	1
11/05/2021 01:00	0.0	0	0	0	0	1
11/05/2021 02:00	0.0	0	0	0	0	1
11/05/2021 03:00	0.0	0	0	0	0	1
11/05/2021 04:00	0.0	0	0	0	0	1
11/05/2021 05:00	0.0	0	0	0	0	1
11/05/2021 06:00	0.0	0	0	0	0	1
11/05/2021 07:00	0.0	0	0	0	0	1
11/05/2021 08:00	0.0	0	0	0	0	1
11/05/2021 09:00	0.0	0	0	0	0	1
11/05/2021 10:00	0.0	0	0	0	0	1
11/05/2021 11:00	0.0	0	0	0	0	1
11/05/2021 12:00	0.0	0	0	0	0	1
11/05/2021 13:00	0.0	0	0	0	0	1
11/05/2021 14:00	0.0	0	0	0	0	1
11/05/2021 15:00	0.0	0	0	0	0	1
11/05/2021 16:00	0.0	0	0	0	0	1
11/05/2021 17:00	0.0	0	0	0	0	1
11/05/2021 18:00	0.0	0	0	0	0	1
11/05/2021 19:00	0.0	0	0	0	0	1
11/05/2021 20:00	0.0	0	0	0	0	1
11/05/2021 21:00	0.0	0	0	0	0	1
11/05/2021 22:00	0.0	0	0	0	0	1
11/05/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/06/2021 00:00	0.0	0	0	0	0	1
11/06/2021 01:00	0.0	0	0	0	0	1
11/06/2021 02:00	0.0	0	0	0	0	1
11/06/2021 03:00	0.0	0	0	0	0	1
11/06/2021 04:00	0.0	0	0	0	0	1
11/06/2021 05:00	0.0	0	0	0	0	1
11/06/2021 06:00	0.0	0	0	0	0	1
11/06/2021 07:00	0.0	0	0	0	0	1
11/06/2021 08:00	0.0	0	0	0	0	1
11/06/2021 09:00	0.0	0	0	0	0	1
11/06/2021 10:00	0.0	0	0	0	0	1
11/06/2021 11:00	0.0	0	0	0	0	1
11/06/2021 12:00	0.0	0	0	0	0	1
11/06/2021 13:00	0.0	0	0	0	0	1
11/06/2021 14:00	0.0	0	0	0	0	1
11/06/2021 15:00	0.0	0	0	0	0	1
11/06/2021 16:00	0.0	0	0	0	0	1
11/06/2021 17:00	0.0	0	0	0	0	1
11/06/2021 18:00	0.0	0	0	0	0	1
11/06/2021 19:00	0.0	0	0	0	0	1
11/06/2021 20:00	0.0	0	0	0	0	1
11/06/2021 21:00	0.0	0	0	0	0	1
11/06/2021 22:00	0.8	0	0	0	1	0
11/06/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.8 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.8	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/07/2021 00:00	0.0	0	0	0	0	0
11/07/2021 01:00	0.0	0	0	0	0	0
11/07/2021 02:00	0.0	0	0	0	0	0
11/07/2021 03:00	0.0	0	0	0	0	0
11/07/2021 04:00	0.0	0	0	0	0	0
11/07/2021 05:00	0.0	0	0	0	0	0
11/07/2021 06:00	0.0	0	0	0	0	0
11/07/2021 07:00	0.0	0	0	0	0	0
11/07/2021 08:00	0.0	0	0	0	0	0
11/07/2021 09:00	0.0	0	0	0	0	0
11/07/2021 10:00	0.0	0	0	0	0	0
11/07/2021 11:00	0.0	0	0	0	0	0
11/07/2021 12:00	0.0	0	0	0	0	0
11/07/2021 13:00	0.0	0	0	0	0	0
11/07/2021 14:00	0.0	0	0	0	0	0
11/07/2021 15:00	0.0	0	0	0	0	0
11/07/2021 16:00	0.0	0	0	0	0	0
11/07/2021 17:00	0.0	0	0	0	0	0
11/07/2021 18:00	0.0	0	0	0	0	0
11/07/2021 19:00	0.0	0	0	0	0	0
11/07/2021 20:00	0.0	0	0	0	0	0
11/07/2021 21:00	0.0	0	0	0	0	0
11/07/2021 22:00	0.0	0	0	0	0	0
11/07/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/08/2021 00:00	0.0	0	0	0	0	0
11/08/2021 01:00	0.0	0	0	0	0	0
11/08/2021 02:00	0.0	0	0	0	0	0
11/08/2021 03:00	0.0	0	0	0	0	0
11/08/2021 04:00	0.0	0	0	0	0	0
11/08/2021 05:00	0.0	0	0	0	0	0
11/08/2021 06:00	0.0	0	0	0	0	0
11/08/2021 07:00	0.0	0	0	0	0	0
11/08/2021 08:00	0.0	0	0	0	0	0
11/08/2021 09:00	0.0	0	0	0	0	0
11/08/2021 10:00	0.0	0	0	0	0	0
11/08/2021 11:00	0.0	0	0	0	0	0
11/08/2021 12:00	0.0	0	0	0	0	0
11/08/2021 13:00	0.0	0	0	0	0	0
11/08/2021 14:00	0.0	0	0	0	0	0
11/08/2021 15:00	0.0	0	0	0	0	0
11/08/2021 16:00	0.0	0	0	0	0	0
11/08/2021 17:00	0.0	0	0	0	0	0
11/08/2021 18:00	0.0	0	0	0	0	0
11/08/2021 19:00	0.0	0	0	0	0	0
11/08/2021 20:00	0.0	0	0	0	0	0
11/08/2021 21:00	0.0	0	0	0	0	0
11/08/2021 22:00	0.0	0	0	0	0	0
11/08/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/09/2021 00:00	0.0	0	0	0	0	0
11/09/2021 01:00	0.0	0	0	0	0	0
11/09/2021 02:00	0.0	0	0	0	0	0
11/09/2021 03:00	0.0	0	0	0	0	0
11/09/2021 04:00	0.0	0	0	0	0	0
11/09/2021 05:00	0.0	0	0	0	0	0
11/09/2021 06:00	0.0	0	0	0	0	0
11/09/2021 07:00	59.2	0	1	0	0	0
11/09/2021 08:00	28.1	0	1	0	0	0
11/09/2021 09:00	0.0	0	0	0	0	1
11/09/2021 10:00	0.0	0	0	0	0	1
11/09/2021 11:00	0.0	0	0	0	0	1
11/09/2021 12:00	0.0	0	0	0	0	1
11/09/2021 13:00	0.0	0	0	0	0	1
11/09/2021 14:00	0.0	0	0	0	0	1
11/09/2021 15:00	0.0	0	0	0	0	1
11/09/2021 16:00	0.0	0	0	0	0	1
11/09/2021 17:00	0.0	0	0	0	0	1
11/09/2021 18:00	0.0	0	0	0	0	1
11/09/2021 19:00	0.0	0	0	0	0	1
11/09/2021 20:00	0.0	0	0	0	0	1
11/09/2021 21:00	0.0	0	0	0	0	1
11/09/2021 22:00	0.0	0	0	0	0	1
11/09/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	87.3 #	0 #	2 #	0 #	0 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	59.2	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/10/2021 00:00	0.0	0	0	0	0	1
11/10/2021 01:00	0.0	0	0	0	0	1
11/10/2021 02:00	0.0	0	0	0	0	1
11/10/2021 03:00	0.0	0	0	0	0	1
11/10/2021 04:00	0.0	0	0	0	0	1
11/10/2021 05:00	0.0	0	0	0	0	1
11/10/2021 06:00	0.0	0	0	0	0	1
11/10/2021 07:00	0.0	0	0	0	0	1
11/10/2021 08:00	0.0	0	0	0	0	1
11/10/2021 09:00	0.0	0	0	0	0	1
11/10/2021 10:00	0.0	0	0	0	0	1
11/10/2021 11:00	0.0	0	0	0	0	1
11/10/2021 12:00	0.0	0	0	0	0	1
11/10/2021 13:00	0.0	0	0	0	0	1
11/10/2021 14:00	0.0	0	0	0	0	1
11/10/2021 15:00	0.0	0	0	0	0	1
11/10/2021 16:00	0.0	0	0	0	0	1
11/10/2021 17:00	0.0	0	0	0	0	1
11/10/2021 18:00	0.0	0	0	0	0	1
11/10/2021 19:00	0.0	0	0	0	0	1
11/10/2021 20:00	0.0	0	0	0	0	1
11/10/2021 21:00	0.0	0	0	0	0	1
11/10/2021 22:00	0.0	0	0	0	0	1
11/10/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/11/2021 00:00	0.0	0	0	0	0	1
11/11/2021 01:00	1.0	0	0	0	1	0
11/11/2021 02:00	0.0	0	0	0	0	0
11/11/2021 03:00	0.0	0	0	0	0	0
11/11/2021 04:00	0.0	0	0	0	0	0
11/11/2021 05:00	0.0	0	0	0	0	0
11/11/2021 06:00	0.0	0	0	0	0	0
11/11/2021 07:00	0.0	0	0	0	0	0
11/11/2021 08:00	0.0	0	0	0	0	0
11/11/2021 09:00	20.9	0	1	0	0	0
11/11/2021 10:00	49.0	0	1	0	0	0
11/11/2021 11:00	0.0	0	0	0	0	1
11/11/2021 12:00	0.0	0	0	0	0	1
11/11/2021 13:00	0.0	0	0	0	0	1
11/11/2021 14:00	0.0	0	0	0	0	1
11/11/2021 15:00	0.0	0	0	0	0	1
11/11/2021 16:00	0.0	0	0	0	0	1
11/11/2021 17:00	0.0	0	0	0	0	1
11/11/2021 18:00	0.0	0	0	0	0	1
11/11/2021 19:00	0.0	0	0	0	0	1
11/11/2021 20:00	0.0	0	0	0	0	1
11/11/2021 21:00	0.0	0	0	0	0	1
11/11/2021 22:00	0.0	0	0	0	0	1
11/11/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	70.9 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	49.0	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/12/2021 00:00	0.0	0	0	0	0	1
11/12/2021 01:00	0.0	0	0	0	0	1
11/12/2021 02:00	0.0	0	0	0	0	1
11/12/2021 03:00	0.0	0	0	0	0	1
11/12/2021 04:00	0.0	0	0	0	0	1
11/12/2021 05:00	0.0	0	0	0	0	1
11/12/2021 06:00	0.0	0	0	0	0	1
11/12/2021 07:00	0.0	0	0	0	0	1
11/12/2021 08:00	0.0	0	0	0	0	1
11/12/2021 09:00	0.0	0	0	0	0	1
11/12/2021 10:00	0.0	0	0	0	0	1
11/12/2021 11:00	0.0	0	0	0	0	1
11/12/2021 12:00	0.0	0	0	0	0	1
11/12/2021 13:00	0.0	0	0	0	0	1
11/12/2021 14:00	0.0	0	0	0	0	1
11/12/2021 15:00	0.0	0	0	0	0	1
11/12/2021 16:00	0.0	0	0	0	0	1
11/12/2021 17:00	0.0	0	0	0	0	1
11/12/2021 18:00	0.0	0	0	0	0	1
11/12/2021 19:00	0.0	0	0	0	0	1
11/12/2021 20:00	0.0	0	0	0	0	1
11/12/2021 21:00	0.0	0	0	0	0	1
11/12/2021 22:00	0.0	0	0	0	0	1
11/12/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/13/2021 00:00	0.7	0	0	0	1	0
11/13/2021 01:00	0.0	0	0	0	0	0
11/13/2021 02:00	0.0	0	0	0	0	0
11/13/2021 03:00	0.0	0	0	0	0	0
11/13/2021 04:00	0.0	0	0	0	0	0
11/13/2021 05:00	0.0	0	0	0	0	0
11/13/2021 06:00	0.0	0	0	0	0	0
11/13/2021 07:00	0.0	0	0	0	0	0
11/13/2021 08:00	16.9	0	1	0	0	0
11/13/2021 09:00	20.0	0	1	0	0	0
11/13/2021 10:00	0.0	0	0	0	0	1
11/13/2021 11:00	0.0	0	0	0	0	1
11/13/2021 12:00	0.0	0	0	0	0	1
11/13/2021 13:00	0.0	0	0	0	0	1
11/13/2021 14:00	0.0	0	0	0	0	1
11/13/2021 15:00	0.0	0	0	0	0	1
11/13/2021 16:00	0.0	0	0	0	0	1
11/13/2021 17:00	0.0	0	0	0	0	1
11/13/2021 18:00	0.0	0	0	0	0	1
11/13/2021 19:00	0.0	0	0	0	0	1
11/13/2021 20:00	0.0	0	0	0	0	1
11/13/2021 21:00	0.0	0	0	0	0	1
11/13/2021 22:00	0.9	0	0	0	1	0
11/13/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	38.5 #	0 #	2 #	0 #	2 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	20.0	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/14/2021 00:00	0.0	0	0	0	0	0
11/14/2021 01:00	0.0	0	0	0	0	0
11/14/2021 02:00	0.0	0	0	0	0	0
11/14/2021 03:00	0.0	0	0	0	0	0
11/14/2021 04:00	0.0	0	0	0	0	0
11/14/2021 05:00	0.0	0	0	0	0	0
11/14/2021 06:00	0.0	0	0	0	0	0
11/14/2021 07:00	0.0	0	0	0	0	0
11/14/2021 08:00	0.0	0	0	0	0	0
11/14/2021 09:00	5.2	0	1	0	0	0
11/14/2021 10:00	46.9	0	1	0	0	0
11/14/2021 11:00	8.5	0	1	0	0	0
11/14/2021 12:00	0.0	0	0	0	0	1
11/14/2021 13:00	0.0	0	0	0	0	1
11/14/2021 14:00	0.0	0	0	0	0	1
11/14/2021 15:00	0.0	0	0	0	0	1
11/14/2021 16:00	0.0	0	0	0	0	1
11/14/2021 17:00	0.0	0	0	0	0	1
11/14/2021 18:00	0.0	0	0	0	0	1
11/14/2021 19:00	0.0	0	0	0	0	1
11/14/2021 20:00	0.0	0	0	0	0	1
11/14/2021 21:00	0.0	0	0	0	0	1
11/14/2021 22:00	0.0	0	0	0	0	1
11/14/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	60.6 #	0 #	3 #	0 #	0 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	46.9	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/15/2021 00:00	0.0	0	0	0	0	1
11/15/2021 01:00	0.0	0	0	0	0	1
11/15/2021 02:00	0.0	0	0	0	0	1
11/15/2021 03:00	0.0	0	0	0	0	1
11/15/2021 04:00	0.0	0	0	0	0	1
11/15/2021 05:00	0.0	0	0	0	0	1
11/15/2021 06:00	0.0	0	0	0	0	1
11/15/2021 07:00	0.0	0	0	0	0	1
11/15/2021 08:00	0.0	0	0	0	0	1
11/15/2021 09:00	0.0	0	0	0	0	1
11/15/2021 10:00	0.0	0	0	0	0	1
11/15/2021 11:00	0.0	0	0	0	0	1
11/15/2021 12:00	0.0	0	0	0	0	1
11/15/2021 13:00	0.0	0	0	0	0	1
11/15/2021 14:00	0.0	0	0	0	0	1
11/15/2021 15:00	0.0	0	0	0	0	1
11/15/2021 16:00	0.0	0	0	0	0	1
11/15/2021 17:00	0.0	0	0	0	0	1
11/15/2021 18:00	0.0	0	0	0	0	1
11/15/2021 19:00	0.0	0	0	0	0	1
11/15/2021 20:00	0.0	0	0	0	0	1
11/15/2021 21:00	0.0	0	0	0	0	1
11/15/2021 22:00	0.0	0	0	0	0	1
11/15/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/16/2021 00:00	0.9	0	0	0	1	0
11/16/2021 01:00	0.0	0	0	0	0	0
11/16/2021 02:00	0.0	0	0	0	0	0
11/16/2021 03:00	0.0	0	0	0	0	0
11/16/2021 04:00	0.0	0	0	0	0	0
11/16/2021 05:00	0.0	0	0	0	0	0
11/16/2021 06:00	0.0	0	0	0	0	0
11/16/2021 07:00	0.0	0	0	0	0	0
11/16/2021 08:00	19.9	0	1	0	0	0
11/16/2021 09:00	29.8	0	1	0	0	0
11/16/2021 10:00	0.0	0	0	0	0	1
11/16/2021 11:00	0.0	0	0	0	0	1
11/16/2021 12:00	0.0	0	0	0	0	1
11/16/2021 13:00	0.0	0	0	0	0	1
11/16/2021 14:00	0.0	0	0	0	0	1
11/16/2021 15:00	0.0	0	0	0	0	1
11/16/2021 16:00	0.0	0	0	0	0	1
11/16/2021 17:00	0.0	0	0	0	0	1
11/16/2021 18:00	0.0	0	0	0	0	1
11/16/2021 19:00	0.0	0	0	0	0	1
11/16/2021 20:00	0.0	0	0	0	0	1
11/16/2021 21:00	0.0	0	0	0	0	1
11/16/2021 22:00	0.0	0	0	0	0	1
11/16/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	50.6 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	29.8	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/17/2021 00:00	0.0	0	0	0	0	1
11/17/2021 01:00	0.0	0	0	0	0	1
11/17/2021 02:00	0.0	0	0	0	0	1
11/17/2021 03:00	0.0	0	0	0	0	1
11/17/2021 04:00	0.0	0	0	0	0	1
11/17/2021 05:00	0.0	0	0	0	0	1
11/17/2021 06:00	0.0	0	0	0	0	1
11/17/2021 07:00	0.0	0	0	0	0	1
11/17/2021 08:00	0.0	0	0	0	0	1
11/17/2021 09:00	0.0	0	0	0	0	1
11/17/2021 10:00	0.0	0	0	0	0	1
11/17/2021 11:00	0.0	0	0	0	0	1
11/17/2021 12:00	0.0	0	0	0	0	1
11/17/2021 13:00	0.0	0	0	0	0	1
11/17/2021 14:00	0.0	0	0	0	0	1
11/17/2021 15:00	0.0	0	0	0	0	1
11/17/2021 16:00	0.0	0	0	0	0	1
11/17/2021 17:00	0.0	0	0	0	0	1
11/17/2021 18:00	0.0	0	0	0	0	1
11/17/2021 19:00	0.0	0	0	0	0	1
11/17/2021 20:00	0.0	0	0	0	0	1
11/17/2021 21:00	0.0	0	0	0	0	1
11/17/2021 22:00	0.0	0	0	0	0	1
11/17/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/18/2021 00:00	0.0	0	0	0	0	1
11/18/2021 01:00	0.0	0	0	0	0	1
11/18/2021 02:00	0.0	0	0	0	0	1
11/18/2021 03:00	0.0	0	0	0	0	1
11/18/2021 04:00	0.0	0	0	0	0	1
11/18/2021 05:00	0.0	0	0	0	0	1
11/18/2021 06:00	0.0	0	0	0	0	1
11/18/2021 07:00	0.0	0	0	0	0	1
11/18/2021 08:00	0.0	0	0	0	0	1
11/18/2021 09:00	0.0	0	0	0	0	1
11/18/2021 10:00	0.0	0	0	0	0	1
11/18/2021 11:00	0.0	0	0	0	0	1
11/18/2021 12:00	0.0	0	0	0	0	1
11/18/2021 13:00	0.0	0	0	0	0	1
11/18/2021 14:00	0.0	0	0	0	0	1
11/18/2021 15:00	0.0	0	0	0	0	1
11/18/2021 16:00	0.0	0	0	0	0	1
11/18/2021 17:00	0.0	0	0	0	0	1
11/18/2021 18:00	0.0	0	0	0	0	1
11/18/2021 19:00	0.0	0	0	0	0	1
11/18/2021 20:00	0.0	0	0	0	0	1
11/18/2021 21:00	0.0	0	0	0	0	1
11/18/2021 22:00	0.0	0	0	0	0	1
11/18/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/19/2021 00:00	0.0	0	0	0	0	1
11/19/2021 01:00	0.0	0	0	0	0	1
11/19/2021 02:00	0.0	0	0	0	0	1
11/19/2021 03:00	0.0	0	0	0	0	1
11/19/2021 04:00	0.0	0	0	0	0	1
11/19/2021 05:00	0.0	0	0	0	0	1
11/19/2021 06:00	0.0	0	0	0	0	1
11/19/2021 07:00	0.0	0	0	0	0	1
11/19/2021 08:00	0.0	0	0	0	0	1
11/19/2021 09:00	0.0	0	0	0	0	1
11/19/2021 10:00	0.0	0	0	0	0	1
11/19/2021 11:00	0.0	0	0	0	0	1
11/19/2021 12:00	0.0	0	0	0	0	1
11/19/2021 13:00	0.0	0	0	0	0	1
11/19/2021 14:00	0.0	0	0	0	0	1
11/19/2021 15:00	0.0	0	0	0	0	1
11/19/2021 16:00	0.0	0	0	0	0	1
11/19/2021 17:00	0.0	0	0	0	0	1
11/19/2021 18:00	0.0	0	0	0	0	1
11/19/2021 19:00	0.0	0	0	0	0	1
11/19/2021 20:00	0.0	0	0	0	0	1
11/19/2021 21:00	0.0	0	0	0	0	1
11/19/2021 22:00	0.0	0	0	0	0	1
11/19/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/20/2021 00:00	0.0	0	0	0	0	1
11/20/2021 01:00	0.0	0	0	0	0	1
11/20/2021 02:00	0.0	0	0	0	0	1
11/20/2021 03:00	0.0	0	0	0	0	1
11/20/2021 04:00	0.0	0	0	0	0	1
11/20/2021 05:00	0.0	0	0	0	0	1
11/20/2021 06:00	0.0	0	0	0	0	1
11/20/2021 07:00	0.0	0	0	0	0	1
11/20/2021 08:00	0.0	0	0	0	0	1
11/20/2021 09:00	0.0	0	0	0	0	1
11/20/2021 10:00	0.0	0	0	0	0	1
11/20/2021 11:00	0.0	0	0	0	0	1
11/20/2021 12:00	0.0	0	0	0	0	1
11/20/2021 13:00	0.0	0	0	0	0	1
11/20/2021 14:00	0.0	0	0	0	0	1
11/20/2021 15:00	0.0	0	0	0	0	1
11/20/2021 16:00	0.0	0	0	0	0	1
11/20/2021 17:00	0.0	0	0	0	0	1
11/20/2021 18:00	0.0	0	0	0	0	1
11/20/2021 19:00	0.0	0	0	0	0	1
11/20/2021 20:00	0.0	0	0	0	0	1
11/20/2021 21:00	0.0	0	0	0	0	1
11/20/2021 22:00	0.0	0	0	0	0	1
11/20/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/21/2021 00:00	0.0	0	0	0	0	1
11/21/2021 01:00	0.0	0	0	0	0	1
11/21/2021 02:00	0.9	0	0	0	1	0
11/21/2021 03:00	0.0	0	0	0	0	0
11/21/2021 04:00	0.0	0	0	0	0	0
11/21/2021 05:00	0.0	0	0	0	0	0
11/21/2021 06:00	0.0	0	0	0	0	0
11/21/2021 07:00	0.0	0	0	0	0	0
11/21/2021 08:00	0.0	0	0	0	0	0
11/21/2021 09:00	0.0	0	0	0	0	0
11/21/2021 10:00	10.4	0	0	1	0	0
11/21/2021 11:00	48.2	0	0	1	0	0
11/21/2021 12:00	0.0	0	0	0	0	1
11/21/2021 13:00	0.0	0	0	0	0	1
11/21/2021 14:00	0.0	0	0	0	0	1
11/21/2021 15:00	0.0	0	0	0	0	1
11/21/2021 16:00	0.0	0	0	0	0	1
11/21/2021 17:00	0.0	0	0	0	0	1
11/21/2021 18:00	0.0	0	0	0	0	1
11/21/2021 19:00	0.0	0	0	0	0	1
11/21/2021 20:00	0.0	0	0	0	0	1
11/21/2021 21:00	0.0	0	0	0	0	1
11/21/2021 22:00	0.0	0	0	0	0	1
11/21/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	59.5 #	0 #	0 #	2 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	48.2	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/22/2021 00:00	0.0	0	0	0	0	1
11/22/2021 01:00	0.0	0	0	0	0	1
11/22/2021 02:00	0.0	0	0	0	0	1
11/22/2021 03:00	0.0	0	0	0	0	1
11/22/2021 04:00	0.0	0	0	0	0	1
11/22/2021 05:00	0.0	0	0	0	0	1
11/22/2021 06:00	0.0	0	0	0	0	1
11/22/2021 07:00	0.0	0	0	0	0	1
11/22/2021 08:00	0.0	0	0	0	0	1
11/22/2021 09:00	0.0	0	0	0	0	1
11/22/2021 10:00	0.0	0	0	0	0	1
11/22/2021 11:00	0.0	0	0	0	0	1
11/22/2021 12:00	0.0	0	0	0	0	1
11/22/2021 13:00	0.0	0	0	0	0	1
11/22/2021 14:00	0.0	0	0	0	0	1
11/22/2021 15:00	0.0	0	0	0	0	1
11/22/2021 16:00	0.0	0	0	0	0	1
11/22/2021 17:00	0.0	0	0	0	0	1
11/22/2021 18:00	0.0	0	0	0	0	1
11/22/2021 19:00	0.0	0	0	0	0	1
11/22/2021 20:00	0.0	0	0	0	0	1
11/22/2021 21:00	0.0	0	0	0	0	1
11/22/2021 22:00	0.0	0	0	0	0	1
11/22/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/23/2021 00:00	0.0	0	0	0	0	1
11/23/2021 01:00	0.0	0	0	0	0	1
11/23/2021 02:00	0.0	0	0	0	0	1
11/23/2021 03:00	0.0	0	0	0	0	1
11/23/2021 04:00	0.0	0	0	0	0	1
11/23/2021 05:00	0.0	0	0	0	0	1
11/23/2021 06:00	0.0	0	0	0	0	1
11/23/2021 07:00	0.0	0	0	0	0	1
11/23/2021 08:00	0.0	0	0	0	0	1
11/23/2021 09:00	0.0	0	0	0	0	1
11/23/2021 10:00	0.0	0	0	0	0	1
11/23/2021 11:00	0.0	0	0	0	0	1
11/23/2021 12:00	0.0	0	0	0	0	1
11/23/2021 13:00	0.0	0	0	0	0	1
11/23/2021 14:00	0.0	0	0	0	0	1
11/23/2021 15:00	0.0	0	0	0	0	1
11/23/2021 16:00	0.0	0	0	0	0	1
11/23/2021 17:00	0.0	0	0	0	0	1
11/23/2021 18:00	0.0	0	0	0	0	1
11/23/2021 19:00	0.0	0	0	0	0	1
11/23/2021 20:00	0.0	0	0	0	0	1
11/23/2021 21:00	0.0	0	0	0	0	1
11/23/2021 22:00	0.0	0	0	0	0	1
11/23/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/24/2021 00:00	0.0	0	0	0	0	1
11/24/2021 01:00	0.0	0	0	0	0	1
11/24/2021 02:00	0.0	0	0	0	0	1
11/24/2021 03:00	0.0	0	0	0	0	1
11/24/2021 04:00	0.0	0	0	0	0	1
11/24/2021 05:00	0.0	0	0	0	0	1
11/24/2021 06:00	0.0	0	0	0	0	1
11/24/2021 07:00	0.0	0	0	0	0	1
11/24/2021 08:00	0.0	0	0	0	0	1
11/24/2021 09:00	0.0	0	0	0	0	1
11/24/2021 10:00	0.0	0	0	0	0	1
11/24/2021 11:00	0.0	0	0	0	0	1
11/24/2021 12:00	0.0	0	0	0	0	1
11/24/2021 13:00	0.0	0	0	0	0	1
11/24/2021 14:00	0.0	0	0	0	0	1
11/24/2021 15:00	0.0	0	0	0	0	1
11/24/2021 16:00	0.0	0	0	0	0	1
11/24/2021 17:00	0.0	0	0	0	0	1
11/24/2021 18:00	0.0	0	0	0	0	1
11/24/2021 19:00	0.0	0	0	0	0	1
11/24/2021 20:00	0.0	0	0	0	0	1
11/24/2021 21:00	0.0	0	0	0	0	1
11/24/2021 22:00	0.0	0	0	0	0	1
11/24/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/25/2021 00:00	1.1	0	0	0	1	0
11/25/2021 01:00	0.0	0	0	0	0	0
11/25/2021 02:00	0.0	0	0	0	0	0
11/25/2021 03:00	0.0	0	0	0	0	0
11/25/2021 04:00	0.0	0	0	0	0	0
11/25/2021 05:00	0.0	0	0	0	0	0
11/25/2021 06:00	0.0	0	0	0	0	0
11/25/2021 07:00	0.0	0	0	0	0	0
11/25/2021 08:00	0.0	0	0	0	0	0
11/25/2021 09:00	0.0	0	0	0	0	0
11/25/2021 10:00	0.0	0	0	0	0	0
11/25/2021 11:00	0.0	0	0	0	0	0
11/25/2021 12:00	0.0	0	0	0	0	0
11/25/2021 13:00	0.0	0	0	0	0	0
11/25/2021 14:00	0.0	0	0	0	0	0
11/25/2021 15:00	0.0	0	0	0	0	0
11/25/2021 16:00	0.0	0	0	0	0	0
11/25/2021 17:00	0.0	0	0	0	0	0
11/25/2021 18:00	0.0	0	0	0	0	0
11/25/2021 19:00	0.0	0	0	0	0	0
11/25/2021 20:00	0.0	0	0	0	0	0
11/25/2021 21:00	0.0	0	0	0	0	0
11/25/2021 22:00	0.0	0	0	0	0	0
11/25/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.1 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.1	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/26/2021 00:00	0.0	0	0	0	0	0
11/26/2021 01:00	0.0	0	0	0	0	0
11/26/2021 02:00	0.0	0	0	0	0	0
11/26/2021 03:00	0.0	0	0	0	0	0
11/26/2021 04:00	0.0	0	0	0	0	0
11/26/2021 05:00	0.0	0	0	0	0	0
11/26/2021 06:00	0.0	0	0	0	0	0
11/26/2021 07:00	0.0	0	0	0	0	0
11/26/2021 08:00	0.0	0	0	0	0	0
11/26/2021 09:00	0.0	0	0	0	0	0
11/26/2021 10:00	0.0	0	0	0	0	0
11/26/2021 11:00	0.0	0	0	0	0	0
11/26/2021 12:00	0.0	0	0	0	0	0
11/26/2021 13:00	0.0	0	0	0	0	0
11/26/2021 14:00	0.0	0	0	0	0	0
11/26/2021 15:00	0.0	0	0	0	0	0
11/26/2021 16:00	0.0	0	0	0	0	0
11/26/2021 17:00	0.0	0	0	0	0	0
11/26/2021 18:00	0.0	0	0	0	0	0
11/26/2021 19:00	0.0	0	0	0	0	0
11/26/2021 20:00	0.0	0	0	0	0	0
11/26/2021 21:00	0.0	0	0	0	0	0
11/26/2021 22:00	0.0	0	0	0	0	0
11/26/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/27/2021 00:00	0.0	0	0	0	0	0
11/27/2021 01:00	0.0	0	0	0	0	0
11/27/2021 02:00	0.0	0	0	0	0	0
11/27/2021 03:00	0.0	0	0	0	0	0
11/27/2021 04:00	0.0	0	0	0	0	0
11/27/2021 05:00	0.0	0	0	0	0	0
11/27/2021 06:00	0.0	0	0	0	0	0
11/27/2021 07:00	0.0	0	0	0	0	0
11/27/2021 08:00	0.0	0	0	0	0	0
11/27/2021 09:00	0.0	0	0	0	0	0
11/27/2021 10:00	0.0	0	0	0	0	0
11/27/2021 11:00	0.0	0	0	0	0	0
11/27/2021 12:00	0.0	0	0	0	0	0
11/27/2021 13:00	0.0	0	0	0	0	0
11/27/2021 14:00	0.0	0	0	0	0	0
11/27/2021 15:00	0.0	0	0	0	0	0
11/27/2021 16:00	0.0	0	0	0	0	0
11/27/2021 17:00	0.0	0	0	0	0	0
11/27/2021 18:00	0.0	0	0	0	0	0
11/27/2021 19:00	0.0	0	0	0	0	0
11/27/2021 20:00	0.0	0	0	0	0	0
11/27/2021 21:00	0.0	0	0	0	0	0
11/27/2021 22:00	0.0	0	0	0	0	0
11/27/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/28/2021 00:00	0.0	0	0	0	0	0
11/28/2021 01:00	0.0	0	0	0	0	0
11/28/2021 02:00	0.0	0	0	0	0	0
11/28/2021 03:00	0.0	0	0	0	0	0
11/28/2021 04:00	0.0	0	0	0	0	0
11/28/2021 05:00	0.0	0	0	0	0	0
11/28/2021 06:00	0.0	0	0	0	0	0
11/28/2021 07:00	0.0	0	0	0	0	0
11/28/2021 08:00	0.0	0	0	0	0	0
11/28/2021 09:00	0.0	0	0	0	0	0
11/28/2021 10:00	0.0	0	0	0	0	0
11/28/2021 11:00	0.0	0	0	0	0	0
11/28/2021 12:00	0.0	0	0	0	0	0
11/28/2021 13:00	0.0	0	0	0	0	0
11/28/2021 14:00	0.0	0	0	0	0	0
11/28/2021 15:00	0.0	0	0	0	0	0
11/28/2021 16:00	0.0	0	0	0	0	0
11/28/2021 17:00	0.0	0	0	0	0	0
11/28/2021 18:00	0.0	0	0	0	0	0
11/28/2021 19:00	0.0	0	0	0	0	0
11/28/2021 20:00	0.0	0	0	0	0	0
11/28/2021 21:00	0.0	0	0	0	0	0
11/28/2021 22:00	0.0	0	0	0	0	0
11/28/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/29/2021 00:00	0.0	0	0	0	0	0
11/29/2021 01:00	0.0	0	0	0	0	0
11/29/2021 02:00	0.0	0	0	0	0	0
11/29/2021 03:00	0.0	0	0	0	0	0
11/29/2021 04:00	0.0	0	0	0	0	0
11/29/2021 05:00	0.0	0	0	0	0	0
11/29/2021 06:00	0.0	0	0	0	0	0
11/29/2021 07:00	2.6	1	0	0	0	0
11/29/2021 08:00	67.7	1	0	0	0	0
11/29/2021 09:00	10.8	1	0	0	0	0
11/29/2021 10:00	21.7	1	0	0	0	0
11/29/2021 11:00	29.1	1	0	0	0	0
11/29/2021 12:00	0.0	0	0	0	0	1
11/29/2021 13:00	0.0	0	0	0	0	1
11/29/2021 14:00	0.0	0	0	0	0	1
11/29/2021 15:00	0.0	0	0	0	0	1
11/29/2021 16:00	0.0	0	0	0	0	1
11/29/2021 17:00	0.0	0	0	0	0	1
11/29/2021 18:00	0.0	0	0	0	0	1
11/29/2021 19:00	0.0	0	0	0	0	1
11/29/2021 20:00	0.0	0	0	0	0	1
11/29/2021 21:00	0.0	0	0	0	0	1
11/29/2021 22:00	0.0	0	0	0	0	1
11/29/2021 23:00	1.1	0	0	0	1	0
Average/Sum#:	133.0 #	5 #	0 #	0 #	1 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	67.7	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
11/30/2021 00:00	0.0	0	0	0	0	0
11/30/2021 01:00	0.0	0	0	0	0	0
11/30/2021 02:00	0.0	0	0	0	0	0
11/30/2021 03:00	0.0	0	0	0	0	0
11/30/2021 04:00	0.0	0	0	0	0	0
11/30/2021 05:00	4.3	0	0	1	0	0
11/30/2021 06:00	24.8	0	0	1	0	0
11/30/2021 07:00	0.0	0	0	0	0	1
11/30/2021 08:00	0.0	0	0	0	0	1
11/30/2021 09:00	0.0	0	0	0	0	1
11/30/2021 10:00	0.0	0	0	0	0	1
11/30/2021 11:00	0.0	0	0	0	0	1
11/30/2021 12:00	0.0	0	0	0	0	1
11/30/2021 13:00	0.0	0	0	0	0	1
11/30/2021 14:00	0.0	0	0	0	0	1
11/30/2021 15:00	0.0	0	0	0	0	1
11/30/2021 16:00	0.0	0	0	0	0	1
11/30/2021 17:00	0.0	0	0	0	0	1
11/30/2021 18:00	0.0	0	0	0	0	1
11/30/2021 19:00	0.0	0	0	0	0	1
11/30/2021 20:00	0.0	0	0	0	0	1
11/30/2021 21:00	0.0	0	0	0	0	1
11/30/2021 22:00	0.0	0	0	0	0	1
11/30/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	29.1 #	0 #	0 #	2 #	0 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	24.8	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/01/2021 00:00	0.0	0	0	0	0	1
12/01/2021 01:00	0.0	0	0	0	0	1
12/01/2021 02:00	0.0	0	0	0	0	1
12/01/2021 03:00	0.0	0	0	0	0	1
12/01/2021 04:00	0.0	0	0	0	0	1
12/01/2021 05:00	0.0	0	0	0	0	1
12/01/2021 06:00	0.0	0	0	0	0	1
12/01/2021 07:00	0.0	0	0	0	0	1
12/01/2021 08:00	0.0	0	0	0	0	1
12/01/2021 09:00	0.0	0	0	0	0	1
12/01/2021 10:00	0.0	0	0	0	0	1
12/01/2021 11:00	0.0	0	0	0	0	1
12/01/2021 12:00	0.0	0	0	0	0	1
12/01/2021 13:00	0.0	0	0	0	0	1
12/01/2021 14:00	0.0	0	0	0	0	1
12/01/2021 15:00	0.0	0	0	0	0	1
12/01/2021 16:00	0.0	0	0	0	0	1
12/01/2021 17:00	0.0	0	0	0	0	1
12/01/2021 18:00	0.0	0	0	0	0	1
12/01/2021 19:00	0.0	0	0	0	0	1
12/01/2021 20:00	0.0	0	0	0	0	1
12/01/2021 21:00	0.0	0	0	0	0	1
12/01/2021 22:00	0.0	0	0	0	0	1
12/01/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/02/2021 00:00	1.1	0	0	0	1	0
12/02/2021 01:00	0.0	0	0	0	0	0
12/02/2021 02:00	0.0	0	0	0	0	0
12/02/2021 03:00	0.0	0	0	0	0	0
12/02/2021 04:00	0.0	0	0	0	0	0
12/02/2021 05:00	0.0	0	0	0	0	0
12/02/2021 06:00	13.0	0	0	1	0	0
12/02/2021 07:00	6.6	0	0	1	0	0
12/02/2021 08:00	0.0	0	0	0	0	1
12/02/2021 09:00	0.0	0	0	0	0	1
12/02/2021 10:00	0.0	0	0	0	0	1
12/02/2021 11:00	0.0	0	0	0	0	1
12/02/2021 12:00	0.0	0	0	0	0	1
12/02/2021 13:00	0.0	0	0	0	0	1
12/02/2021 14:00	0.0	0	0	0	0	1
12/02/2021 15:00	0.0	0	0	0	0	1
12/02/2021 16:00	0.0	0	0	0	0	1
12/02/2021 17:00	0.0	0	0	0	0	1
12/02/2021 18:00	0.0	0	0	0	0	1
12/02/2021 19:00	0.0	0	0	0	0	1
12/02/2021 20:00	0.0	0	0	0	0	1
12/02/2021 21:00	0.0	0	0	0	0	1
12/02/2021 22:00	0.0	0	0	0	0	1
12/02/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	20.7 #	0 #	0 #	2 #	1 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	13.0	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/03/2021 00:00	0.0	0	0	0	0	1
12/03/2021 01:00	0.0	0	0	0	0	1
12/03/2021 02:00	0.0	0	0	0	0	1
12/03/2021 03:00	0.0	0	0	0	0	1
12/03/2021 04:00	0.0	0	0	0	0	1
12/03/2021 05:00	0.0	0	0	0	0	1
12/03/2021 06:00	0.0	0	0	0	0	1
12/03/2021 07:00	0.0	0	0	0	0	1
12/03/2021 08:00	0.0	0	0	0	0	1
12/03/2021 09:00	0.0	0	0	0	0	1
12/03/2021 10:00	0.0	0	0	0	0	1
12/03/2021 11:00	0.0	0	0	0	0	1
12/03/2021 12:00	0.0	0	0	0	0	1
12/03/2021 13:00	0.0	0	0	0	0	1
12/03/2021 14:00	0.0	0	0	0	0	1
12/03/2021 15:00	0.0	0	0	0	0	1
12/03/2021 16:00	0.0	0	0	0	0	1
12/03/2021 17:00	0.0	0	0	0	0	1
12/03/2021 18:00	0.0	0	0	0	0	1
12/03/2021 19:00	0.0	0	0	0	0	1
12/03/2021 20:00	0.0	0	0	0	0	1
12/03/2021 21:00	0.0	0	0	0	0	1
12/03/2021 22:00	0.0	0	0	0	0	1
12/03/2021 23:00	0.6	0	0	0	1	0
Average/Sum#:	0.6 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.6	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/04/2021 00:00	0.0	0	0	0	1	0
12/04/2021 01:00	0.0	0	0	0	0	0
12/04/2021 02:00	0.0	0	0	0	0	0
12/04/2021 03:00	0.1	0	0	1	0	0
12/04/2021 04:00	11.3	0	0	1	0	0
12/04/2021 05:00	0.0	0	0	0	0	1
12/04/2021 06:00	0.0	0	0	0	0	1
12/04/2021 07:00	0.0	0	0	0	0	1
12/04/2021 08:00	0.0	0	0	0	0	1
12/04/2021 09:00	0.0	0	0	0	0	1
12/04/2021 10:00	0.0	0	0	0	0	1
12/04/2021 11:00	0.0	0	0	0	0	1
12/04/2021 12:00	0.0	0	0	0	0	1
12/04/2021 13:00	0.0	0	0	0	0	1
12/04/2021 14:00	0.0	0	0	0	0	1
12/04/2021 15:00	0.0	0	0	0	0	1
12/04/2021 16:00	0.0	0	0	0	0	1
12/04/2021 17:00	0.0	0	0	0	0	1
12/04/2021 18:00	0.0	0	0	0	0	1
12/04/2021 19:00	0.0	0	0	0	0	1
12/04/2021 20:00	0.0	0	0	0	0	1
12/04/2021 21:00	0.0	0	0	0	0	1
12/04/2021 22:00	0.0	0	0	0	0	1
12/04/2021 23:00	0.6	0	0	0	1	0
Average/Sum#:	12.0 #	0 #	0 #	2 #	2 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	11.3	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/05/2021 00:00	0.0	0	0	0	0	0
12/05/2021 01:00	0.0	0	0	0	0	0
12/05/2021 02:00	0.0	0	0	0	0	0
12/05/2021 03:00	0.0	0	0	0	0	0
12/05/2021 04:00	0.0	0	0	0	0	0
12/05/2021 05:00	0.0	0	0	0	0	0
12/05/2021 06:00	0.0	0	0	0	0	0
12/05/2021 07:00	24.9	0	1	0	0	0
12/05/2021 08:00	29.6	0	1	0	0	0
12/05/2021 09:00	0.0	0	0	0	0	1
12/05/2021 10:00	0.0	0	0	0	0	1
12/05/2021 11:00	0.0	0	0	0	0	1
12/05/2021 12:00	0.0	0	0	0	0	1
12/05/2021 13:00	0.0	0	0	0	0	1
12/05/2021 14:00	0.0	0	0	0	0	1
12/05/2021 15:00	0.0	0	0	0	0	1
12/05/2021 16:00	0.0	0	0	0	0	1
12/05/2021 17:00	0.0	0	0	0	0	1
12/05/2021 18:00	0.0	0	0	0	0	1
12/05/2021 19:00	0.0	0	0	0	0	1
12/05/2021 20:00	0.0	0	0	0	0	1
12/05/2021 21:00	0.0	0	0	0	0	1
12/05/2021 22:00	0.0	0	0	0	0	1
12/05/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	54.5 #	0 #	2 #	0 #	0 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	29.6	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/06/2021 00:00	0.0	0	0	0	0	1
12/06/2021 01:00	0.0	0	0	0	0	1
12/06/2021 02:00	0.0	0	0	0	0	1
12/06/2021 03:00	0.0	0	0	0	0	1
12/06/2021 04:00	0.0	0	0	0	0	1
12/06/2021 05:00	0.0	0	0	0	0	1
12/06/2021 06:00	0.0	0	0	0	0	1
12/06/2021 07:00	0.0	0	0	0	0	1
12/06/2021 08:00	0.0	0	0	0	0	1
12/06/2021 09:00	0.0	0	0	0	0	1
12/06/2021 10:00	0.0	0	0	0	0	1
12/06/2021 11:00	0.0	0	0	0	0	1
12/06/2021 12:00	0.0	0	0	0	0	1
12/06/2021 13:00	0.0	0	0	0	0	1
12/06/2021 14:00	0.0	0	0	0	0	1
12/06/2021 15:00	0.0	0	0	0	0	1
12/06/2021 16:00	0.0	0	0	0	0	1
12/06/2021 17:00	0.0	0	0	0	0	1
12/06/2021 18:00	0.0	0	0	0	0	1
12/06/2021 19:00	0.0	0	0	0	0	1
12/06/2021 20:00	0.0	0	0	0	0	1
12/06/2021 21:00	0.0	0	0	0	0	1
12/06/2021 22:00	0.0	0	0	0	0	1
12/06/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/07/2021 00:00	0.0	0	0	0	0	1
12/07/2021 01:00	0.0	0	0	0	0	1
12/07/2021 02:00	0.0	0	0	0	0	1
12/07/2021 03:00	0.0	0	0	0	0	1
12/07/2021 04:00	0.0	0	0	0	0	1
12/07/2021 05:00	0.0	0	0	0	0	1
12/07/2021 06:00	0.0	0	0	0	0	1
12/07/2021 07:00	0.0	0	0	0	0	1
12/07/2021 08:00	0.0	0	0	0	0	1
12/07/2021 09:00	0.0	0	0	0	0	1
12/07/2021 10:00	0.0	0	0	0	0	1
12/07/2021 11:00	0.0	0	0	0	0	1
12/07/2021 12:00	0.0	0	0	0	0	1
12/07/2021 13:00	0.0	0	0	0	0	1
12/07/2021 14:00	0.0	0	0	0	0	1
12/07/2021 15:00	0.0	0	0	0	0	1
12/07/2021 16:00	0.0	0	0	0	0	1
12/07/2021 17:00	0.0	0	0	0	0	1
12/07/2021 18:00	0.0	0	0	0	0	1
12/07/2021 19:00	0.0	0	0	0	0	1
12/07/2021 20:00	0.0	0	0	0	0	1
12/07/2021 21:00	0.0	0	0	0	0	1
12/07/2021 22:00	0.0	0	0	0	0	1
12/07/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/08/2021 00:00	0.0	0	0	0	0	1
12/08/2021 01:00	0.0	0	0	0	0	1
12/08/2021 02:00	0.0	0	0	0	0	1
12/08/2021 03:00	0.0	0	0	0	0	1
12/08/2021 04:00	0.0	0	0	0	0	1
12/08/2021 05:00	0.0	0	0	0	0	1
12/08/2021 06:00	0.0	0	0	0	0	1
12/08/2021 07:00	0.0	0	0	0	0	1
12/08/2021 08:00	0.0	0	0	0	0	1
12/08/2021 09:00	0.0	0	0	0	0	1
12/08/2021 10:00	0.0	0	0	0	0	1
12/08/2021 11:00	0.0	0	0	0	0	1
12/08/2021 12:00	0.0	0	0	0	0	1
12/08/2021 13:00	0.0	0	0	0	0	1
12/08/2021 14:00	0.0	0	0	0	0	1
12/08/2021 15:00	0.0	0	0	0	0	1
12/08/2021 16:00	0.0	0	0	0	0	1
12/08/2021 17:00	0.0	0	0	0	0	1
12/08/2021 18:00	0.0	0	0	0	0	1
12/08/2021 19:00	0.0	0	0	0	0	1
12/08/2021 20:00	0.0	0	0	0	0	1
12/08/2021 21:00	0.0	0	0	0	0	1
12/08/2021 22:00	0.0	0	0	0	0	1
12/08/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/09/2021 00:00	0.0	0	0	0	0	1
12/09/2021 01:00	0.0	0	0	0	0	1
12/09/2021 02:00	0.0	0	0	0	0	1
12/09/2021 03:00	0.0	0	0	0	0	1
12/09/2021 04:00	0.0	0	0	0	0	1
12/09/2021 05:00	0.0	0	0	0	0	1
12/09/2021 06:00	0.0	0	0	0	0	1
12/09/2021 07:00	0.0	0	0	0	0	1
12/09/2021 08:00	0.0	0	0	0	0	1
12/09/2021 09:00	0.0	0	0	0	0	1
12/09/2021 10:00	0.0	0	0	0	0	1
12/09/2021 11:00	0.0	0	0	0	0	1
12/09/2021 12:00	0.0	0	0	0	0	1
12/09/2021 13:00	0.0	0	0	0	0	1
12/09/2021 14:00	0.0	0	0	0	0	1
12/09/2021 15:00	0.0	0	0	0	0	1
12/09/2021 16:00	0.0	0	0	0	0	1
12/09/2021 17:00	0.0	0	0	0	0	1
12/09/2021 18:00	0.0	0	0	0	0	1
12/09/2021 19:00	0.0	0	0	0	0	1
12/09/2021 20:00	0.0	0	0	0	0	1
12/09/2021 21:00	0.0	0	0	0	0	1
12/09/2021 22:00	0.0	0	0	0	0	1
12/09/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/10/2021 00:00	0.0	0	0	0	0	1
12/10/2021 01:00	0.0	0	0	0	0	1
12/10/2021 02:00	0.0	0	0	0	0	1
12/10/2021 03:00	0.0	0	0	0	0	1
12/10/2021 04:00	0.0	0	0	0	0	1
12/10/2021 05:00	0.0	0	0	0	0	1
12/10/2021 06:00	0.0	0	0	0	0	1
12/10/2021 07:00	0.0	0	0	0	0	1
12/10/2021 08:00	0.0	0	0	0	0	1
12/10/2021 09:00	0.0	0	0	0	0	1
12/10/2021 10:00	0.0	0	0	0	0	1
12/10/2021 11:00	0.0	0	0	0	0	1
12/10/2021 12:00	0.0	0	0	0	0	1
12/10/2021 13:00	0.0	0	0	0	0	1
12/10/2021 14:00	0.0	0	0	0	0	1
12/10/2021 15:00	0.0	0	0	0	0	1
12/10/2021 16:00	0.0	0	0	0	0	1
12/10/2021 17:00	0.0	0	0	0	0	1
12/10/2021 18:00	0.0	0	0	0	0	1
12/10/2021 19:00	0.0	0	0	0	0	1
12/10/2021 20:00	0.0	0	0	0	0	1
12/10/2021 21:00	0.0	0	0	0	0	1
12/10/2021 22:00	0.0	0	0	0	0	1
12/10/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/11/2021 00:00	0.0	0	0	0	0	1
12/11/2021 01:00	0.0	0	0	0	0	1
12/11/2021 02:00	0.0	0	0	0	0	1
12/11/2021 03:00	0.0	0	0	0	0	1
12/11/2021 04:00	0.0	0	0	0	0	1
12/11/2021 05:00	0.0	0	0	0	0	1
12/11/2021 06:00	0.0	0	0	0	0	1
12/11/2021 07:00	0.0	0	0	0	0	1
12/11/2021 08:00	0.0	0	0	0	0	1
12/11/2021 09:00	0.0	0	0	0	0	1
12/11/2021 10:00	0.0	0	0	0	0	1
12/11/2021 11:00	0.0	0	0	0	0	1
12/11/2021 12:00	0.0	0	0	0	0	1
12/11/2021 13:00	0.0	0	0	0	0	1
12/11/2021 14:00	0.0	0	0	0	0	1
12/11/2021 15:00	0.0	0	0	0	0	1
12/11/2021 16:00	0.0	0	0	0	0	1
12/11/2021 17:00	0.0	0	0	0	0	1
12/11/2021 18:00	0.0	0	0	0	0	1
12/11/2021 19:00	0.0	0	0	0	0	1
12/11/2021 20:00	0.0	0	0	0	0	1
12/11/2021 21:00	0.0	0	0	0	0	1
12/11/2021 22:00	0.0	0	0	0	0	1
12/11/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/12/2021 00:00	0.0	0	0	0	0	1
12/12/2021 01:00	0.0	0	0	0	0	1
12/12/2021 02:00	0.0	0	0	0	0	1
12/12/2021 03:00	0.0	0	0	0	0	1
12/12/2021 04:00	0.0	0	0	0	0	1
12/12/2021 05:00	0.0	0	0	0	0	1
12/12/2021 06:00	0.0	0	0	0	0	1
12/12/2021 07:00	0.0	0	0	0	0	1
12/12/2021 08:00	0.0	0	0	0	0	1
12/12/2021 09:00	0.0	0	0	0	0	1
12/12/2021 10:00	0.0	0	0	0	0	1
12/12/2021 11:00	0.0	0	0	0	0	1
12/12/2021 12:00	0.0	0	0	0	0	1
12/12/2021 13:00	0.0	0	0	0	0	1
12/12/2021 14:00	0.0	0	0	0	0	1
12/12/2021 15:00	0.0	0	0	0	0	1
12/12/2021 16:00	0.0	0	0	0	0	1
12/12/2021 17:00	0.0	0	0	0	0	1
12/12/2021 18:00	0.0	0	0	0	0	1
12/12/2021 19:00	0.0	0	0	0	0	1
12/12/2021 20:00	0.0	0	0	0	0	1
12/12/2021 21:00	0.0	0	0	0	0	1
12/12/2021 22:00	0.0	0	0	0	0	1
12/12/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/13/2021 00:00	0.0	0	0	0	0	1
12/13/2021 01:00	0.0	0	0	0	0	1
12/13/2021 02:00	0.0	0	0	0	0	1
12/13/2021 03:00	0.0	0	0	0	0	1
12/13/2021 04:00	0.0	0	0	0	0	1
12/13/2021 05:00	0.0	0	0	0	0	1
12/13/2021 06:00	0.0	0	0	0	0	1
12/13/2021 07:00	0.0	0	0	0	0	1
12/13/2021 08:00	0.0	0	0	0	0	1
12/13/2021 09:00	0.0	0	0	0	0	1
12/13/2021 10:00	0.0	0	0	0	0	1
12/13/2021 11:00	0.0	0	0	0	0	1
12/13/2021 12:00	0.0	0	0	0	0	1
12/13/2021 13:00	0.0	0	0	0	0	1
12/13/2021 14:00	0.0	0	0	0	0	1
12/13/2021 15:00	0.0	0	0	0	0	1
12/13/2021 16:00	0.0	0	0	0	0	1
12/13/2021 17:00	0.0	0	0	0	0	1
12/13/2021 18:00	0.0	0	0	0	0	1
12/13/2021 19:00	0.0	0	0	0	0	1
12/13/2021 20:00	0.0	0	0	0	0	1
12/13/2021 21:00	0.0	0	0	0	0	1
12/13/2021 22:00	0.0	0	0	0	0	1
12/13/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/14/2021 00:00	0.0	0	0	0	0	1
12/14/2021 01:00	0.0	0	0	0	0	1
12/14/2021 02:00	0.0	0	0	0	0	1
12/14/2021 03:00	0.0	0	0	0	0	1
12/14/2021 04:00	0.0	0	0	0	0	1
12/14/2021 05:00	0.0	0	0	0	0	1
12/14/2021 06:00	0.0	0	0	0	0	1
12/14/2021 07:00	0.0	0	0	0	0	1
12/14/2021 08:00	0.0	0	0	0	0	1
12/14/2021 09:00	0.0	0	0	0	0	1
12/14/2021 10:00	0.0	0	0	0	0	1
12/14/2021 11:00	0.0	0	0	0	0	1
12/14/2021 12:00	0.0	0	0	0	0	1
12/14/2021 13:00	0.0	0	0	0	0	1
12/14/2021 14:00	0.0	0	0	0	0	1
12/14/2021 15:00	0.0	0	0	0	0	1
12/14/2021 16:00	0.0	0	0	0	0	1
12/14/2021 17:00	0.0	0	0	0	0	1
12/14/2021 18:00	0.0	0	0	0	0	1
12/14/2021 19:00	0.0	0	0	0	0	1
12/14/2021 20:00	0.0	0	0	0	0	1
12/14/2021 21:00	0.0	0	0	0	0	1
12/14/2021 22:00	0.0	0	0	0	0	1
12/14/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/15/2021 00:00	0.0	0	0	0	0	1
12/15/2021 01:00	0.0	0	0	0	0	1
12/15/2021 02:00	0.0	0	0	0	0	1
12/15/2021 03:00	0.0	0	0	0	0	1
12/15/2021 04:00	0.0	0	0	0	0	1
12/15/2021 05:00	0.0	0	0	0	0	1
12/15/2021 06:00	0.0	0	0	0	0	1
12/15/2021 07:00	0.0	0	0	0	0	1
12/15/2021 08:00	0.0	0	0	0	0	1
12/15/2021 09:00	0.0	0	0	0	0	1
12/15/2021 10:00	0.0	0	0	0	0	1
12/15/2021 11:00	0.0	0	0	0	0	1
12/15/2021 12:00	0.0	0	0	0	0	1
12/15/2021 13:00	0.0	0	0	0	0	1
12/15/2021 14:00	0.0	0	0	0	0	1
12/15/2021 15:00	0.0	0	0	0	0	1
12/15/2021 16:00	0.0	0	0	0	0	1
12/15/2021 17:00	0.0	0	0	0	0	1
12/15/2021 18:00	0.0	0	0	0	0	1
12/15/2021 19:00	0.0	0	0	0	0	1
12/15/2021 20:00	0.0	0	0	0	0	1
12/15/2021 21:00	0.0	0	0	0	0	1
12/15/2021 22:00	0.0	0	0	0	0	1
12/15/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/16/2021 00:00	0.0	0	0	0	0	1
12/16/2021 01:00	0.0	0	0	0	0	1
12/16/2021 02:00	0.0	0	0	0	0	1
12/16/2021 03:00	0.0	0	0	0	0	1
12/16/2021 04:00	0.0	0	0	0	0	1
12/16/2021 05:00	0.0	0	0	0	0	1
12/16/2021 06:00	0.0	0	0	0	0	1
12/16/2021 07:00	0.0	0	0	0	0	1
12/16/2021 08:00	0.0	0	0	0	0	1
12/16/2021 09:00	0.0	0	0	0	0	1
12/16/2021 10:00	0.0	0	0	0	0	1
12/16/2021 11:00	0.0	0	0	0	0	1
12/16/2021 12:00	0.0	0	0	0	0	1
12/16/2021 13:00	0.0	0	0	0	0	1
12/16/2021 14:00	0.0	0	0	0	0	1
12/16/2021 15:00	0.0	0	0	0	0	1
12/16/2021 16:00	0.0	0	0	0	0	1
12/16/2021 17:00	0.0	0	0	0	0	1
12/16/2021 18:00	0.0	0	0	0	0	1
12/16/2021 19:00	0.0	0	0	0	0	1
12/16/2021 20:00	0.0	0	0	0	0	1
12/16/2021 21:00	0.0	0	0	0	0	1
12/16/2021 22:00	0.0	0	0	0	0	1
12/16/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/17/2021 00:00	0.0	0	0	0	0	1
12/17/2021 01:00	0.0	0	0	0	0	1
12/17/2021 02:00	0.0	0	0	0	0	1
12/17/2021 03:00	0.0	0	0	0	0	1
12/17/2021 04:00	0.0	0	0	0	0	1
12/17/2021 05:00	0.0	0	0	0	0	1
12/17/2021 06:00	0.0	0	0	0	0	1
12/17/2021 07:00	0.0	0	0	0	0	1
12/17/2021 08:00	0.0	0	0	0	0	1
12/17/2021 09:00	0.0	0	0	0	0	1
12/17/2021 10:00	0.0	0	0	0	0	1
12/17/2021 11:00	0.0	0	0	0	0	1
12/17/2021 12:00	0.0	0	0	0	0	1
12/17/2021 13:00	0.0	0	0	0	0	1
12/17/2021 14:00	0.0	0	0	0	0	1
12/17/2021 15:00	0.0	0	0	0	0	1
12/17/2021 16:00	0.0	0	0	0	0	1
12/17/2021 17:00	0.0	0	0	0	0	1
12/17/2021 18:00	0.0	0	0	0	0	1
12/17/2021 19:00	0.0	0	0	0	0	1
12/17/2021 20:00	0.0	0	0	0	0	1
12/17/2021 21:00	0.0	0	0	0	0	1
12/17/2021 22:00	0.0	0	0	0	0	1
12/17/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/18/2021 00:00	0.0	0	0	0	0	1
12/18/2021 01:00	0.0	0	0	0	0	1
12/18/2021 02:00	0.0	0	0	0	0	1
12/18/2021 03:00	0.0	0	0	0	0	1
12/18/2021 04:00	0.0	0	0	0	0	1
12/18/2021 05:00	0.0	0	0	0	0	1
12/18/2021 06:00	0.0	0	0	0	0	1
12/18/2021 07:00	0.0	0	0	0	0	1
12/18/2021 08:00	0.0	0	0	0	0	1
12/18/2021 09:00	0.0	0	0	0	0	1
12/18/2021 10:00	0.0	0	0	0	0	1
12/18/2021 11:00	0.0	0	0	0	0	1
12/18/2021 12:00	0.0	0	0	0	0	1
12/18/2021 13:00	0.0	0	0	0	0	1
12/18/2021 14:00	0.0	0	0	0	0	1
12/18/2021 15:00	0.0	0	0	0	0	1
12/18/2021 16:00	0.0	0	0	0	0	1
12/18/2021 17:00	0.0	0	0	0	0	1
12/18/2021 18:00	0.0	0	0	0	0	1
12/18/2021 19:00	0.0	0	0	0	0	1
12/18/2021 20:00	0.0	0	0	0	0	1
12/18/2021 21:00	0.0	0	0	0	0	1
12/18/2021 22:00	0.0	0	0	0	0	1
12/18/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/19/2021 00:00	0.0	0	0	0	0	1
12/19/2021 01:00	0.0	0	0	0	0	1
12/19/2021 02:00	0.0	0	0	0	0	1
12/19/2021 03:00	0.0	0	0	0	0	1
12/19/2021 04:00	0.0	0	0	0	0	1
12/19/2021 05:00	0.0	0	0	0	0	1
12/19/2021 06:00	0.0	0	0	0	0	1
12/19/2021 07:00	0.0	0	0	0	0	1
12/19/2021 08:00	0.0	0	0	0	0	1
12/19/2021 09:00	0.0	0	0	0	0	1
12/19/2021 10:00	0.0	0	0	0	0	1
12/19/2021 11:00	0.0	0	0	0	0	1
12/19/2021 12:00	0.0	0	0	0	0	1
12/19/2021 13:00	0.0	0	0	0	0	1
12/19/2021 14:00	0.0	0	0	0	0	1
12/19/2021 15:00	0.0	0	0	0	0	1
12/19/2021 16:00	0.0	0	0	0	0	1
12/19/2021 17:00	0.0	0	0	0	0	1
12/19/2021 18:00	0.0	0	0	0	0	1
12/19/2021 19:00	0.0	0	0	0	0	1
12/19/2021 20:00	0.0	0	0	0	0	1
12/19/2021 21:00	0.0	0	0	0	0	1
12/19/2021 22:00	0.0	0	0	0	0	1
12/19/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/20/2021 00:00	0.0	0	0	0	0	1
12/20/2021 01:00	0.0	0	0	0	0	1
12/20/2021 02:00	0.0	0	0	0	0	1
12/20/2021 03:00	0.0	0	0	0	0	1
12/20/2021 04:00	0.0	0	0	0	0	1
12/20/2021 05:00	0.0	0	0	0	0	1
12/20/2021 06:00	0.0	0	0	0	0	1
12/20/2021 07:00	0.0	0	0	0	0	1
12/20/2021 08:00	0.0	0	0	0	0	1
12/20/2021 09:00	0.0	0	0	0	0	1
12/20/2021 10:00	0.0	0	0	0	0	1
12/20/2021 11:00	0.0	0	0	0	0	1
12/20/2021 12:00	0.0	0	0	0	0	1
12/20/2021 13:00	0.0	0	0	0	0	1
12/20/2021 14:00	0.0	0	0	0	0	1
12/20/2021 15:00	0.0	0	0	0	0	1
12/20/2021 16:00	0.0	0	0	0	0	1
12/20/2021 17:00	0.0	0	0	0	0	1
12/20/2021 18:00	0.0	0	0	0	0	1
12/20/2021 19:00	0.0	0	0	0	0	1
12/20/2021 20:00	0.0	0	0	0	0	1
12/20/2021 21:00	0.0	0	0	0	0	1
12/20/2021 22:00	0.0	0	0	0	0	1
12/20/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/21/2021 00:00	0.0	0	0	0	0	1
12/21/2021 01:00	0.0	0	0	0	0	1
12/21/2021 02:00	0.0	0	0	0	0	1
12/21/2021 03:00	0.0	0	0	0	0	1
12/21/2021 04:00	0.0	0	0	0	0	1
12/21/2021 05:00	0.0	0	0	0	0	1
12/21/2021 06:00	0.0	0	0	0	0	1
12/21/2021 07:00	0.0	0	0	0	0	1
12/21/2021 08:00	0.0	0	0	0	0	1
12/21/2021 09:00	0.0	0	0	0	0	1
12/21/2021 10:00	0.0	0	0	0	0	1
12/21/2021 11:00	0.0	0	0	0	0	1
12/21/2021 12:00	0.0	0	0	0	0	1
12/21/2021 13:00	0.0	0	0	0	0	1
12/21/2021 14:00	0.0	0	0	0	0	1
12/21/2021 15:00	0.0	0	0	0	0	1
12/21/2021 16:00	0.0	0	0	0	0	1
12/21/2021 17:00	0.0	0	0	0	0	1
12/21/2021 18:00	0.0	0	0	0	0	1
12/21/2021 19:00	0.0	0	0	0	0	1
12/21/2021 20:00	0.0	0	0	0	0	1
12/21/2021 21:00	0.0	0	0	0	0	1
12/21/2021 22:00	0.0	0	0	0	0	1
12/21/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/22/2021 00:00	0.0	0	0	0	0	1
12/22/2021 01:00	0.0	0	0	0	0	1
12/22/2021 02:00	0.0	0	0	0	0	1
12/22/2021 03:00	0.0	0	0	0	0	1
12/22/2021 04:00	0.0	0	0	0	0	1
12/22/2021 05:00	0.0	0	0	0	0	1
12/22/2021 06:00	0.0	0	0	0	0	1
12/22/2021 07:00	0.0	0	0	0	0	1
12/22/2021 08:00	0.0	0	0	0	0	1
12/22/2021 09:00	0.0	0	0	0	0	1
12/22/2021 10:00	0.0	0	0	0	0	1
12/22/2021 11:00	0.0	0	0	0	0	1
12/22/2021 12:00	0.0	0	0	0	0	1
12/22/2021 13:00	0.0	0	0	0	0	1
12/22/2021 14:00	0.0	0	0	0	0	1
12/22/2021 15:00	0.0	0	0	0	0	1
12/22/2021 16:00	0.0	0	0	0	0	1
12/22/2021 17:00	0.0	0	0	0	0	1
12/22/2021 18:00	0.0	0	0	0	0	1
12/22/2021 19:00	0.0	0	0	0	0	1
12/22/2021 20:00	0.0	0	0	0	0	1
12/22/2021 21:00	0.0	0	0	0	0	1
12/22/2021 22:00	0.0	0	0	0	0	1
12/22/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/23/2021 00:00	0.0	0	0	0	0	1
12/23/2021 01:00	0.0	0	0	0	0	1
12/23/2021 02:00	0.0	0	0	0	0	1
12/23/2021 03:00	0.0	0	0	0	0	1
12/23/2021 04:00	0.0	0	0	0	0	1
12/23/2021 05:00	0.0	0	0	0	0	1
12/23/2021 06:00	0.0	0	0	0	0	1
12/23/2021 07:00	0.0	0	0	0	0	1
12/23/2021 08:00	0.0	0	0	0	0	1
12/23/2021 09:00	0.0	0	0	0	0	1
12/23/2021 10:00	0.0	0	0	0	0	1
12/23/2021 11:00	0.0	0	0	0	0	1
12/23/2021 12:00	0.0	0	0	0	0	1
12/23/2021 13:00	0.0	0	0	0	0	1
12/23/2021 14:00	0.0	0	0	0	0	1
12/23/2021 15:00	0.0	0	0	0	0	1
12/23/2021 16:00	0.0	0	0	0	0	1
12/23/2021 17:00	0.0	0	0	0	0	1
12/23/2021 18:00	0.0	0	0	0	0	1
12/23/2021 19:00	0.0	0	0	0	0	1
12/23/2021 20:00	0.0	0	0	0	0	1
12/23/2021 21:00	0.0	0	0	0	0	1
12/23/2021 22:00	0.0	0	0	0	0	1
12/23/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/24/2021 00:00	0.0	0	0	0	0	1
12/24/2021 01:00	0.0	0	0	0	0	1
12/24/2021 02:00	0.0	0	0	0	0	1
12/24/2021 03:00	0.0	0	0	0	0	1
12/24/2021 04:00	0.0	0	0	0	0	1
12/24/2021 05:00	0.0	0	0	0	0	1
12/24/2021 06:00	0.0	0	0	0	0	1
12/24/2021 07:00	0.0	0	0	0	0	1
12/24/2021 08:00	0.0	0	0	0	0	1
12/24/2021 09:00	0.0	0	0	0	0	1
12/24/2021 10:00	0.0	0	0	0	0	1
12/24/2021 11:00	0.0	0	0	0	0	1
12/24/2021 12:00	0.0	0	0	0	0	1
12/24/2021 13:00	0.0	0	0	0	0	1
12/24/2021 14:00	0.0	0	0	0	0	1
12/24/2021 15:00	0.0	0	0	0	0	1
12/24/2021 16:00	0.0	0	0	0	0	1
12/24/2021 17:00	0.0	0	0	0	0	1
12/24/2021 18:00	0.0	0	0	0	0	1
12/24/2021 19:00	0.0	0	0	0	0	1
12/24/2021 20:00	0.0	0	0	0	0	1
12/24/2021 21:00	0.0	0	0	0	0	1
12/24/2021 22:00	0.0	0	0	0	0	1
12/24/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/25/2021 00:00	0.0	0	0	0	0	1
12/25/2021 01:00	0.0	0	0	0	0	1
12/25/2021 02:00	0.0	0	0	0	0	1
12/25/2021 03:00	0.0	0	0	0	0	1
12/25/2021 04:00	0.0	0	0	0	0	1
12/25/2021 05:00	0.0	0	0	0	0	1
12/25/2021 06:00	0.0	0	0	0	0	1
12/25/2021 07:00	0.0	0	0	0	0	1
12/25/2021 08:00	0.0	0	0	0	0	1
12/25/2021 09:00	0.0	0	0	0	0	1
12/25/2021 10:00	0.0	0	0	0	0	1
12/25/2021 11:00	0.0	0	0	0	0	1
12/25/2021 12:00	0.0	0	0	0	0	1
12/25/2021 13:00	0.0	0	0	0	0	1
12/25/2021 14:00	0.0	0	0	0	0	1
12/25/2021 15:00	0.0	0	0	0	0	1
12/25/2021 16:00	0.0	0	0	0	0	1
12/25/2021 17:00	0.0	0	0	0	0	1
12/25/2021 18:00	0.0	0	0	0	0	1
12/25/2021 19:00	0.0	0	0	0	0	1
12/25/2021 20:00	0.0	0	0	0	0	1
12/25/2021 21:00	0.0	0	0	0	0	1
12/25/2021 22:00	0.0	0	0	0	0	1
12/25/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/26/2021 00:00	0.9	0	0	0	1	0
12/26/2021 01:00	0.0	0	0	0	0	0
12/26/2021 02:00	0.0	0	0	0	0	0
12/26/2021 03:00	0.0	0	0	0	0	0
12/26/2021 04:00	0.0	0	0	0	0	0
12/26/2021 05:00	0.0	0	0	0	0	0
12/26/2021 06:00	0.0	0	0	0	0	0
12/26/2021 07:00	0.0	0	0	0	0	0
12/26/2021 08:00	0.0	0	0	0	0	0
12/26/2021 09:00	0.0	0	0	0	0	0
12/26/2021 10:00	1.1	0	1	0	0	0
12/26/2021 11:00	46.1	0	1	0	0	0
12/26/2021 12:00	39.3	0	1	0	0	0
12/26/2021 13:00	0.0	0	0	0	0	1
12/26/2021 14:00	0.0	0	0	0	0	1
12/26/2021 15:00	0.0	0	0	0	0	1
12/26/2021 16:00	0.0	0	0	0	0	1
12/26/2021 17:00	0.0	0	0	0	0	1
12/26/2021 18:00	0.0	0	0	0	0	1
12/26/2021 19:00	0.0	0	0	0	0	1
12/26/2021 20:00	0.0	0	0	0	0	1
12/26/2021 21:00	0.0	0	0	0	0	1
12/26/2021 22:00	0.0	0	0	0	0	1
12/26/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	87.4 #	0 #	3 #	0 #	1 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	46.1	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/27/2021 00:00	0.0	0	0	0	0	1
12/27/2021 01:00	0.0	0	0	0	0	1
12/27/2021 02:00	0.0	0	0	0	0	1
12/27/2021 03:00	0.0	0	0	0	0	1
12/27/2021 04:00	0.0	0	0	0	0	1
12/27/2021 05:00	0.0	0	0	0	0	1
12/27/2021 06:00	0.0	0	0	0	0	1
12/27/2021 07:00	0.0	0	0	0	0	1
12/27/2021 08:00	0.0	0	0	0	0	1
12/27/2021 09:00	0.0	0	0	0	0	1
12/27/2021 10:00	0.0	0	0	0	0	1
12/27/2021 11:00	0.0	0	0	0	0	1
12/27/2021 12:00	0.0	0	0	0	0	1
12/27/2021 13:00	0.0	0	0	0	0	1
12/27/2021 14:00	0.0	0	0	0	0	1
12/27/2021 15:00	0.0	0	0	0	0	1
12/27/2021 16:00	0.0	0	0	0	0	1
12/27/2021 17:00	0.0	0	0	0	0	1
12/27/2021 18:00	0.0	0	0	0	0	1
12/27/2021 19:00	0.0	0	0	0	0	1
12/27/2021 20:00	0.0	0	0	0	0	1
12/27/2021 21:00	0.0	0	0	0	0	1
12/27/2021 22:00	0.0	0	0	0	0	1
12/27/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/28/2021 00:00	0.0	0	0	0	0	1
12/28/2021 01:00	0.0	0	0	0	0	1
12/28/2021 02:00	0.0	0	0	0	0	1
12/28/2021 03:00	0.0	0	0	0	0	1
12/28/2021 04:00	0.0	0	0	0	0	1
12/28/2021 05:00	0.0	0	0	0	0	1
12/28/2021 06:00	0.0	0	0	0	0	1
12/28/2021 07:00	0.0	0	0	0	0	1
12/28/2021 08:00	0.0	0	0	0	0	1
12/28/2021 09:00	0.0	0	0	0	0	1
12/28/2021 10:00	0.0	0	0	0	0	1
12/28/2021 11:00	0.0	0	0	0	0	1
12/28/2021 12:00	0.0	0	0	0	0	1
12/28/2021 13:00	0.0	0	0	0	0	1
12/28/2021 14:00	0.0	0	0	0	0	1
12/28/2021 15:00	0.0	0	0	0	0	1
12/28/2021 16:00	0.0	0	0	0	0	1
12/28/2021 17:00	0.0	0	0	0	0	1
12/28/2021 18:00	0.0	0	0	0	0	1
12/28/2021 19:00	0.0	0	0	0	0	1
12/28/2021 20:00	0.0	0	0	0	0	1
12/28/2021 21:00	0.0	0	0	0	0	1
12/28/2021 22:00	0.0	0	0	0	0	1
12/28/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/29/2021 00:00	0.0	0	0	0	0	1
12/29/2021 01:00	0.0	0	0	0	0	1
12/29/2021 02:00	0.0	0	0	0	0	1
12/29/2021 03:00	0.0	0	0	0	0	1
12/29/2021 04:00	0.0	0	0	0	0	1
12/29/2021 05:00	0.0	0	0	0	0	1
12/29/2021 06:00	0.0	0	0	0	0	1
12/29/2021 07:00	0.0	0	0	0	0	1
12/29/2021 08:00	0.0	0	0	0	0	1
12/29/2021 09:00	0.0	0	0	0	0	1
12/29/2021 10:00	0.0	0	0	0	0	1
12/29/2021 11:00	0.0	0	0	0	0	1
12/29/2021 12:00	0.0	0	0	0	0	1
12/29/2021 13:00	0.0	0	0	0	0	1
12/29/2021 14:00	0.0	0	0	0	0	1
12/29/2021 15:00	0.0	0	0	0	0	1
12/29/2021 16:00	0.0	0	0	0	0	1
12/29/2021 17:00	0.0	0	0	0	0	1
12/29/2021 18:00	0.0	0	0	0	0	1
12/29/2021 19:00	0.0	0	0	0	0	1
12/29/2021 20:00	0.0	0	0	0	0	1
12/29/2021 21:00	0.0	0	0	0	0	1
12/29/2021 22:00	0.0	0	0	0	0	1
12/29/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/30/2021 00:00	0.0	0	0	0	0	1
12/30/2021 01:00	0.0	0	0	0	0	1
12/30/2021 02:00	0.0	0	0	0	0	1
12/30/2021 03:00	0.0	0	0	0	0	1
12/30/2021 04:00	0.0	0	0	0	0	1
12/30/2021 05:00	0.0	0	0	0	0	1
12/30/2021 06:00	0.0	0	0	0	0	1
12/30/2021 07:00	0.0	0	0	0	0	1
12/30/2021 08:00	0.0	0	0	0	0	1
12/30/2021 09:00	0.0	0	0	0	0	1
12/30/2021 10:00	0.0	0	0	0	0	1
12/30/2021 11:00	0.0	0	0	0	0	1
12/30/2021 12:00	0.0	0	0	0	0	1
12/30/2021 13:00	0.0	0	0	0	0	1
12/30/2021 14:00	0.0	0	0	0	0	1
12/30/2021 15:00	0.0	0	0	0	0	1
12/30/2021 16:00	0.0	0	0	0	0	1
12/30/2021 17:00	0.0	0	0	0	0	1
12/30/2021 18:00	0.0	0	0	0	0	1
12/30/2021 19:00	0.0	0	0	0	0	1
12/30/2021 20:00	0.0	0	0	0	0	1
12/30/2021 21:00	0.0	0	0	0	0	1
12/30/2021 22:00	0.0	0	0	0	0	1
12/30/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT1 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:14 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
12/31/2021 00:00	0.0	0	0	0	0	1
12/31/2021 01:00	0.0	0	0	0	0	1
12/31/2021 02:00	0.0	0	0	0	0	1
12/31/2021 03:00	0.0	0	0	0	0	1
12/31/2021 04:00	0.0	0	0	0	0	1
12/31/2021 05:00	0.0	0	0	0	0	1
12/31/2021 06:00	0.0	0	0	0	0	1
12/31/2021 07:00	0.0	0	0	0	0	1
12/31/2021 08:00	0.0	0	0	0	0	1
12/31/2021 09:00	0.0	0	0	0	0	1
12/31/2021 10:00	0.0	0	0	0	0	1
12/31/2021 11:00	0.0	0	0	0	0	1
12/31/2021 12:00	0.0	0	0	0	0	1
12/31/2021 13:00	0.0	0	0	0	0	1
12/31/2021 14:00	0.0	0	0	0	0	1
12/31/2021 15:00	0.0	0	0	0	0	1
12/31/2021 16:00	0.0	0	0	0	0	1
12/31/2021 17:00	0.0	0	0	0	0	1
12/31/2021 18:00	0.0	0	0	0	0	1
12/31/2021 19:00	0.0	0	0	0	0	1
12/31/2021 20:00	0.0	0	0	0	0	1
12/31/2021 21:00	0.0	0	0	0	0	1
12/31/2021 22:00	0.0	0	0	0	0	1
12/31/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Pound Per Event Report

CT1 - CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:15 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,630.20 Hours

Non-Operating Time: 577.80 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
10/08/2021 21:04 10/08/2021 21:09 Shut Down - Gas	6	1.0	483.5		
10/20/2021 13:25 10/20/2021 15:09 Cold Start - Gas	105	142.4	1,355.6		
10/20/2021 22:09 10/20/2021 22:13 Shut Down - Gas	5	0.7	483.5		
10/23/2021 01:22 10/23/2021 03:56 Warm Start - Gas	155	189.8	790.5		
10/23/2021 22:38 10/23/2021 22:43 Shut Down - Gas	6	1.4	483.5		
10/24/2021 07:16 10/24/2021 08:40 Warm Start - Gas	85	113.4	790.5		
11/06/2021 22:39 11/06/2021 22:43 Shut Down - Gas	5	0.5	483.5		
11/09/2021 07:11 11/09/2021 08:44 Warm Start - Gas	94	160.7	790.5		
11/11/2021 01:08 11/11/2021 01:13 Shut Down - Gas	6	1.1	483.5		
11/11/2021 09:34 11/11/2021 10:59 Warm Start - Gas	86	198.9	790.5		
11/13/2021 00:23 11/13/2021 00:28 Shut Down - Gas	6	1.0	483.5		
11/13/2021 08:34 11/13/2021 09:44 Warm Start - Gas	71	103.3	790.5		
11/13/2021 22:38 11/13/2021 22:43 Shut Down - Gas	6	1.2	483.5		

Pound Per Event Report

CT1 - CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:15 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,630.20 Hours

Non-Operating Time: 577.80 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
11/14/2021 09:47 11/14/2021 11:27 Warm Start - Gas	101	134.9	790.5		
11/16/2021 00:10 11/16/2021 00:15 Shut Down - Gas	6	1.6	483.5		
11/16/2021 08:34 11/16/2021 09:54 Warm Start - Gas	81	145.4	790.5		
11/21/2021 02:51 11/21/2021 02:56 Shut Down - Gas	6	0.7	483.5		
11/21/2021 10:43 11/21/2021 11:53 Hot Start - Gas	71	73.1	679.6		
11/25/2021 00:08 11/25/2021 00:13 Shut Down - Gas	6	0.9	483.5		
11/29/2021 07:49 11/29/2021 11:48 Cold Start - Gas	240	330.8	1,355.6		
11/29/2021 23:22 11/29/2021 23:27 Shut Down - Gas	6	1.6	483.5		
11/30/2021 05:43 11/30/2021 06:51 Hot Start - Gas	69	61.2	679.6		
12/02/2021 00:24 12/02/2021 00:29 Shut Down - Gas	6	0.8	483.5		
12/02/2021 06:20 12/02/2021 07:20 Hot Start - Gas	61	96.0	679.6		
12/03/2021 23:56 12/04/2021 00:00 Shut Down - Gas	5	0.4	483.5		
12/04/2021 03:49 12/04/2021 04:46 Hot Start - Gas	58	60.4	679.6		
12/04/2021 23:05 12/04/2021 23:10 Shut Down - Gas	6	2.2	483.5		

Pound Per Event Report

CT1 - CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:15 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,630.20 Hours

Non-Operating Time: 577.80 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
12/05/2021 07:17 12/05/2021 08:53 Warm Start - Gas	97	193.0	790.5		
12/26/2021 00:24 12/26/2021 00:29 Shut Down - Gas	6	1.2	483.5		
12/26/2021 10:50 12/26/2021 12:58 Warm Start - Gas	129	157.3	790.5		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT1 - CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:15 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,630.20 Hours

Non-Operating Time: 577.80 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Pound Per Event Report

CT1 - CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:15 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,630.20 Hours

Non-Operating Time: 577.80 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Pound Per Event Report

CT1 - NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:16 **Location:** Maxwell, CA
Tag Name: CT1_NOx_Event_Lbs_1M
SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,630.20 Hours
Non-Operating Time: 577.80 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
10/08/2021 21:04 10/08/2021 21:09 Shut Down - Gas	6	0.18	115.00		
10/20/2021 13:25 10/20/2021 15:09 Cold Start - Gas	105	97.44	779.10		
10/20/2021 22:09 10/20/2021 22:13 Shut Down - Gas	5	0.14	115.00		
10/23/2021 01:22 10/23/2021 03:56 Warm Start - Gas	155	103.00	456.20		
10/23/2021 22:38 10/23/2021 22:43 Shut Down - Gas	6	0.27	115.00		
10/24/2021 07:16 10/24/2021 08:40 Warm Start - Gas	85	39.11	456.20		
11/06/2021 22:39 11/06/2021 22:43 Shut Down - Gas	5	0.12	115.00		
11/09/2021 07:11 11/09/2021 08:44 Warm Start - Gas	94	89.21	456.20		
11/11/2021 01:08 11/11/2021 01:13 Shut Down - Gas	6	0.21	115.00		
11/11/2021 09:34 11/11/2021 10:59 Warm Start - Gas	86	69.70	456.20		
11/13/2021 00:23 11/13/2021 00:28 Shut Down - Gas	6	0.13	115.00		
11/13/2021 08:34 11/13/2021 09:44 Warm Start - Gas	71	39.32	456.20		
11/13/2021 22:38 11/13/2021 22:43 Shut Down - Gas	6	0.15	115.00		

Pound Per Event Report

CT1 - NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:16 **Location:** Maxwell, CA
Tag Name: CT1_NOx_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission
Total Operating Time: 1,630.20 Hours
Non-Operating Time: 577.80 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
11/14/2021 09:47 11/14/2021 11:27 Warm Start - Gas	101	66.39	456.20		
11/16/2021 00:10 11/16/2021 00:15 Shut Down - Gas	6	0.21	115.00		
11/16/2021 08:34 11/16/2021 09:54 Warm Start - Gas	81	50.13	456.20		
11/21/2021 02:51 11/21/2021 02:56 Shut Down - Gas	6	0.14	115.00		
11/21/2021 10:43 11/21/2021 11:53 Hot Start - Gas	71	57.26	259.90		
11/25/2021 00:08 11/25/2021 00:13 Shut Down - Gas	6	0.22	115.00		
11/29/2021 07:49 11/29/2021 11:48 Cold Start - Gas	240	137.00	779.10		
11/29/2021 23:22 11/29/2021 23:27 Shut Down - Gas	6	0.28	115.00		
11/30/2021 05:43 11/30/2021 06:51 Hot Start - Gas	69	29.89	259.90		
12/02/2021 00:24 12/02/2021 00:29 Shut Down - Gas	6	0.12	115.00		
12/02/2021 06:20 12/02/2021 07:20 Hot Start - Gas	61	29.33	259.90		
12/03/2021 23:56 12/04/2021 00:00 Shut Down - Gas	5	0.05	115.00		
12/04/2021 03:49 12/04/2021 04:46 Hot Start - Gas	58	13.36	259.90		
12/04/2021 23:05 12/04/2021 23:10 Shut Down - Gas	6	0.16	115.00		

Pound Per Event Report

CT1 - NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:16 **Location:** Maxwell, CA
Tag Name: CT1_NOx_Event_Lbs_1M
SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,630.20 Hours
Non-Operating Time: 577.80 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
12/05/2021 07:17 12/05/2021 08:53 Warm Start - Gas	97	56.92	456.20		
12/26/2021 00:24 12/26/2021 00:29 Shut Down - Gas	6	0.19	115.00		
12/26/2021 10:50 12/26/2021 12:58 Warm Start - Gas	129	86.92	456.20		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT1 - NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:16 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,630.20 Hours

Non-Operating Time: 577.80 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Pound Per Event Report

CT1 - NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:16 **Location:** Maxwell, CA
Tag Name: CT1_NOx_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission
Total Operating Time: 1,630.20 Hours
Non-Operating Time: 577.80 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:17 **Location:** Maxwell, CA
Tag Name: CT2_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission
Total Operating Time: 1,521.27 Hours
Non-Operating Time: 686.73 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
10/01/2021 13:27 10/01/2021 14:42 Warm Start - Gas	76	116.2		
10/08/2021 21:06 10/08/2021 21:11 Shut Down - Gas	6	0.4		
10/20/2021 08:45 10/20/2021 12:33 Cold Start - Gas	229	321.4		
10/20/2021 22:09 10/20/2021 22:13 Shut Down - Gas	5	0.4		
10/23/2021 05:55 10/23/2021 07:24 Warm Start - Gas	90	125.8		
10/23/2021 22:38 10/23/2021 22:43 Shut Down - Gas	6	1.0		
10/24/2021 03:49 10/24/2021 04:48 Hot Start - Gas	60	109.1		
10/24/2021 23:18 10/24/2021 23:22 Shut Down - Gas	5	0.3		
10/25/2021 05:28 10/25/2021 06:24 Hot Start - Gas	57	99.5		
10/25/2021 23:18 10/25/2021 23:22 Shut Down - Gas	5	0.2		
10/26/2021 05:30 10/26/2021 06:27 Hot Start - Gas	58	101.5		
10/28/2021 00:49 10/28/2021 00:54 Shut Down - Gas	6	0.6		
10/28/2021 12:37 10/28/2021 13:40 Warm Start - Gas	64	103.5		

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:17 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,521.27 Hours

Non-Operating Time: 686.73 Hours Report Time: 2,208.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
11/04/2021 23:17 11/04/2021 23:22 Shut Down - Gas	6	1.1		
11/05/2021 13:19 11/05/2021 14:29 Warm Start - Gas	71	111.0		
11/06/2021 22:39 11/06/2021 22:43 Shut Down - Gas	5	0.4		
11/08/2021 12:17 11/08/2021 14:50 Warm Start - Gas	154	232.0		
11/08/2021 23:08 11/08/2021 23:12 Shut Down - Gas	5	0.3		
11/09/2021 03:39 11/09/2021 04:44 Hot Start - Gas	66	109.8		
11/11/2021 01:08 11/11/2021 01:13 Shut Down - Gas	6	0.9		
11/11/2021 13:27 11/11/2021 14:39 Warm Start - Gas	73	119.9		
11/12/2021 08:18 11/12/2021 08:23 Shut Down - Gas	6	0.8		
11/12/2021 15:34 11/12/2021 16:50 Hot Start - Gas	77	125.1		
11/13/2021 00:23 11/13/2021 00:28 Shut Down - Gas	6	0.8		
11/13/2021 13:18 11/13/2021 14:35 Warm Start - Gas	78	121.2		
11/13/2021 22:38 11/13/2021 22:43 Shut Down - Gas	6	0.7		
11/14/2021 14:47 11/14/2021 15:56 Warm Start - Gas	70	113.9		

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:17 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,521.27 Hours

Non-Operating Time: 686.73 Hours Report Time: 2,208.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
11/15/2021 00:20 11/15/2021 00:24 Shut Down - Gas	5	0.3		
11/15/2021 07:35 11/15/2021 08:54 Hot Start - Gas	80	132.7		
11/16/2021 00:08 11/16/2021 00:13 Shut Down - Gas	6	1.1		
11/16/2021 13:48 11/16/2021 15:18 Warm Start - Gas	91	145.7		
11/21/2021 02:51 11/21/2021 02:55 Shut Down - Gas	5	0.5		
11/21/2021 14:32 11/21/2021 15:53 Warm Start - Gas	82	120.8		
11/22/2021 00:22 11/22/2021 00:27 Shut Down - Gas	6	0.7		
11/22/2021 12:22 11/22/2021 13:31 Warm Start - Gas	70	114.3		
11/25/2021 00:08 11/25/2021 00:13 Shut Down - Gas	6	0.7		
11/29/2021 14:18 11/29/2021 15:52 Cold Start - Gas	95	132.0		
11/29/2021 23:23 11/29/2021 23:27 Shut Down - Gas	5	0.3		
11/30/2021 08:37 11/30/2021 09:45 Warm Start - Gas	69	109.3		
12/02/2021 00:24 12/02/2021 00:29 Shut Down - Gas	6	0.7		
12/02/2021 04:03 12/02/2021 04:59 Hot Start - Gas	57	100.1		

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:17 **Location:** Maxwell, CA
Tag Name: CT2_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission
Total Operating Time: 1,521.27 Hours
Non-Operating Time: 686.73 Hours Report Time: 2,208.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
12/03/2021 00:49 12/03/2021 00:54 Shut Down - Gas	6	0.6		
12/03/2021 03:47 12/03/2021 04:55 Hot Start - Gas	69	110.0		
12/03/2021 23:53 12/03/2021 23:58 Shut Down - Gas	6	0.9		
12/04/2021 05:48 12/04/2021 06:02 Hot Start - Gas	15	9.7		
12/04/2021 06:03 12/04/2021 06:08 Shut Down - Gas	6	1.0		
12/04/2021 06:46 12/04/2021 07:27 Hot Start - Gas	42	82.0		
12/04/2021 12:50 12/04/2021 12:54 Shut Down - Gas	5	0.4		
12/04/2021 15:49 12/04/2021 16:51 Hot Start - Gas	63	104.1		
12/04/2021 23:07 12/04/2021 23:12 Shut Down - Gas	6	1.0		
12/05/2021 13:36 12/05/2021 14:41 Warm Start - Gas	66	103.8		
12/26/2021 00:24 12/26/2021 00:29 Shut Down - Gas	6	1.0		
12/26/2021 15:48 12/26/2021 16:55 Warm Start - Gas	68	107.9		

No excess emissions were found in the reporting period.

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:17 **Location:** Maxwell, CA
Tag Name: CT2_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission
Total Operating Time: 1,521.27 Hours
Non-Operating Time: 686.73 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:17 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,521.27 Hours

Non-Operating Time: 686.73 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/01/2021 00:00	0.0	0	0	0	0	0
10/01/2021 01:00	0.0	0	0	0	0	0
10/01/2021 02:00	0.0	0	0	0	0	0
10/01/2021 03:00	0.0	0	0	0	0	0
10/01/2021 04:00	0.0	0	0	0	0	0
10/01/2021 05:00	0.0	0	0	0	0	0
10/01/2021 06:00	0.0	0	0	0	0	0
10/01/2021 07:00	0.0	0	0	0	0	0
10/01/2021 08:00	0.0	0	0	0	0	0
10/01/2021 09:00	0.0	0	0	0	0	0
10/01/2021 10:00	0.0	0	0	0	0	0
10/01/2021 11:00	0.0	0	0	0	0	0
10/01/2021 12:00	0.0	0	0	0	0	0
10/01/2021 13:00	32.6	0	1	0	0	0
10/01/2021 14:00	28.5	0	1	0	0	0
10/01/2021 15:00	0.0	0	0	0	0	1
10/01/2021 16:00	0.0	0	0	0	0	1
10/01/2021 17:00	0.0	0	0	0	0	1
10/01/2021 18:00	0.0	0	0	0	0	1
10/01/2021 19:00	0.0	0	0	0	0	1
10/01/2021 20:00	0.0	0	0	0	0	1
10/01/2021 21:00	0.0	0	0	0	0	1
10/01/2021 22:00	0.0	0	0	0	0	1
10/01/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	61.1 #	0 #	2 #	0 #	0 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	32.6	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/02/2021 00:00	0.0	0	0	0	0	1
10/02/2021 01:00	0.0	0	0	0	0	1
10/02/2021 02:00	0.0	0	0	0	0	1
10/02/2021 03:00	0.0	0	0	0	0	1
10/02/2021 04:00	0.0	0	0	0	0	1
10/02/2021 05:00	0.0	0	0	0	0	1
10/02/2021 06:00	0.0	0	0	0	0	1
10/02/2021 07:00	0.0	0	0	0	0	1
10/02/2021 08:00	0.0	0	0	0	0	1
10/02/2021 09:00	0.0	0	0	0	0	1
10/02/2021 10:00	0.0	0	0	0	0	1
10/02/2021 11:00	0.0	0	0	0	0	1
10/02/2021 12:00	0.0	0	0	0	0	1
10/02/2021 13:00	0.0	0	0	0	0	1
10/02/2021 14:00	0.0	0	0	0	0	1
10/02/2021 15:00	0.0	0	0	0	0	1
10/02/2021 16:00	0.0	0	0	0	0	1
10/02/2021 17:00	0.0	0	0	0	0	1
10/02/2021 18:00	0.0	0	0	0	0	1
10/02/2021 19:00	0.0	0	0	0	0	1
10/02/2021 20:00	0.0	0	0	0	0	1
10/02/2021 21:00	0.0	0	0	0	0	1
10/02/2021 22:00	0.0	0	0	0	0	1
10/02/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/03/2021 00:00	0.0	0	0	0	0	1
10/03/2021 01:00	0.0	0	0	0	0	1
10/03/2021 02:00	0.0	0	0	0	0	1
10/03/2021 03:00	0.0	0	0	0	0	1
10/03/2021 04:00	0.0	0	0	0	0	1
10/03/2021 05:00	0.0	0	0	0	0	1
10/03/2021 06:00	0.0	0	0	0	0	1
10/03/2021 07:00	0.0	0	0	0	0	1
10/03/2021 08:00	0.0	0	0	0	0	1
10/03/2021 09:00	0.0	0	0	0	0	1
10/03/2021 10:00	0.0	0	0	0	0	1
10/03/2021 11:00	0.0	0	0	0	0	1
10/03/2021 12:00	0.0	0	0	0	0	1
10/03/2021 13:00	0.0	0	0	0	0	1
10/03/2021 14:00	0.0	0	0	0	0	1
10/03/2021 15:00	0.0	0	0	0	0	1
10/03/2021 16:00	0.0	0	0	0	0	1
10/03/2021 17:00	0.0	0	0	0	0	1
10/03/2021 18:00	0.0	0	0	0	0	1
10/03/2021 19:00	0.0	0	0	0	0	1
10/03/2021 20:00	0.0	0	0	0	0	1
10/03/2021 21:00	0.0	0	0	0	0	1
10/03/2021 22:00	0.0	0	0	0	0	1
10/03/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/04/2021 00:00	0.0	0	0	0	0	1
10/04/2021 01:00	0.0	0	0	0	0	1
10/04/2021 02:00	0.0	0	0	0	0	1
10/04/2021 03:00	0.0	0	0	0	0	1
10/04/2021 04:00	0.0	0	0	0	0	1
10/04/2021 05:00	0.0	0	0	0	0	1
10/04/2021 06:00	0.0	0	0	0	0	1
10/04/2021 07:00	0.0	0	0	0	0	1
10/04/2021 08:00	0.0	0	0	0	0	1
10/04/2021 09:00	0.0	0	0	0	0	1
10/04/2021 10:00	0.0	0	0	0	0	1
10/04/2021 11:00	0.0	0	0	0	0	1
10/04/2021 12:00	0.0	0	0	0	0	1
10/04/2021 13:00	0.0	0	0	0	0	1
10/04/2021 14:00	0.0	0	0	0	0	1
10/04/2021 15:00	0.0	0	0	0	0	1
10/04/2021 16:00	0.0	0	0	0	0	1
10/04/2021 17:00	0.0	0	0	0	0	1
10/04/2021 18:00	0.0	0	0	0	0	1
10/04/2021 19:00	0.0	0	0	0	0	1
10/04/2021 20:00	0.0	0	0	0	0	1
10/04/2021 21:00	0.0	0	0	0	0	1
10/04/2021 22:00	0.0	0	0	0	0	1
10/04/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/05/2021 00:00	0.0	0	0	0	0	1
10/05/2021 01:00	0.0	0	0	0	0	1
10/05/2021 02:00	0.0	0	0	0	0	1
10/05/2021 03:00	0.0	0	0	0	0	1
10/05/2021 04:00	0.0	0	0	0	0	1
10/05/2021 05:00	0.0	0	0	0	0	1
10/05/2021 06:00	0.0	0	0	0	0	1
10/05/2021 07:00	0.0	0	0	0	0	1
10/05/2021 08:00	0.0	0	0	0	0	1
10/05/2021 09:00	0.0	0	0	0	0	1
10/05/2021 10:00	0.0	0	0	0	0	1
10/05/2021 11:00	0.0	0	0	0	0	1
10/05/2021 12:00	0.0	0	0	0	0	1
10/05/2021 13:00	0.0	0	0	0	0	1
10/05/2021 14:00	0.0	0	0	0	0	1
10/05/2021 15:00	0.0	0	0	0	0	1
10/05/2021 16:00	0.0	0	0	0	0	1
10/05/2021 17:00	0.0	0	0	0	0	1
10/05/2021 18:00	0.0	0	0	0	0	1
10/05/2021 19:00	0.0	0	0	0	0	1
10/05/2021 20:00	0.0	0	0	0	0	1
10/05/2021 21:00	0.0	0	0	0	0	1
10/05/2021 22:00	0.0	0	0	0	0	1
10/05/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/06/2021 00:00	0.0	0	0	0	0	1
10/06/2021 01:00	0.0	0	0	0	0	1
10/06/2021 02:00	0.0	0	0	0	0	1
10/06/2021 03:00	0.0	0	0	0	0	1
10/06/2021 04:00	0.0	0	0	0	0	1
10/06/2021 05:00	0.0	0	0	0	0	1
10/06/2021 06:00	0.0	0	0	0	0	1
10/06/2021 07:00	0.0	0	0	0	0	1
10/06/2021 08:00	0.0	0	0	0	0	1
10/06/2021 09:00	0.0	0	0	0	0	1
10/06/2021 10:00	0.0	0	0	0	0	1
10/06/2021 11:00	0.0	0	0	0	0	1
10/06/2021 12:00	0.0	0	0	0	0	1
10/06/2021 13:00	0.0	0	0	0	0	1
10/06/2021 14:00	0.0	0	0	0	0	1
10/06/2021 15:00	0.0	0	0	0	0	1
10/06/2021 16:00	0.0	0	0	0	0	1
10/06/2021 17:00	0.0	0	0	0	0	1
10/06/2021 18:00	0.0	0	0	0	0	1
10/06/2021 19:00	0.0	0	0	0	0	1
10/06/2021 20:00	0.0	0	0	0	0	1
10/06/2021 21:00	0.0	0	0	0	0	1
10/06/2021 22:00	0.0	0	0	0	0	1
10/06/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/07/2021 00:00	0.0	0	0	0	0	1
10/07/2021 01:00	0.0	0	0	0	0	1
10/07/2021 02:00	0.0	0	0	0	0	1
10/07/2021 03:00	0.0	0	0	0	0	1
10/07/2021 04:00	0.0	0	0	0	0	1
10/07/2021 05:00	0.0	0	0	0	0	1
10/07/2021 06:00	0.0	0	0	0	0	1
10/07/2021 07:00	0.0	0	0	0	0	1
10/07/2021 08:00	0.0	0	0	0	0	1
10/07/2021 09:00	0.0	0	0	0	0	1
10/07/2021 10:00	0.0	0	0	0	0	1
10/07/2021 11:00	0.0	0	0	0	0	1
10/07/2021 12:00	0.0	0	0	0	0	1
10/07/2021 13:00	0.0	0	0	0	0	1
10/07/2021 14:00	0.0	0	0	0	0	1
10/07/2021 15:00	0.0	0	0	0	0	1
10/07/2021 16:00	0.0	0	0	0	0	1
10/07/2021 17:00	0.0	0	0	0	0	1
10/07/2021 18:00	0.0	0	0	0	0	1
10/07/2021 19:00	0.0	0	0	0	0	1
10/07/2021 20:00	0.0	0	0	0	0	1
10/07/2021 21:00	0.0	0	0	0	0	1
10/07/2021 22:00	0.0	0	0	0	0	1
10/07/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/08/2021 00:00	0.0	0	0	0	0	1
10/08/2021 01:00	0.0	0	0	0	0	1
10/08/2021 02:00	0.0	0	0	0	0	1
10/08/2021 03:00	0.0	0	0	0	0	1
10/08/2021 04:00	0.0	0	0	0	0	1
10/08/2021 05:00	0.0	0	0	0	0	1
10/08/2021 06:00	0.0	0	0	0	0	1
10/08/2021 07:00	0.0	0	0	0	0	1
10/08/2021 08:00	0.0	0	0	0	0	1
10/08/2021 09:00	0.0	0	0	0	0	1
10/08/2021 10:00	0.0	0	0	0	0	1
10/08/2021 11:00	0.0	0	0	0	0	1
10/08/2021 12:00	0.0	0	0	0	0	1
10/08/2021 13:00	0.0	0	0	0	0	1
10/08/2021 14:00	0.0	0	0	0	0	1
10/08/2021 15:00	0.0	0	0	0	0	1
10/08/2021 16:00	0.0	0	0	0	0	1
10/08/2021 17:00	0.0	0	0	0	0	1
10/08/2021 18:00	0.0	0	0	0	0	1
10/08/2021 19:00	0.0	0	0	0	0	1
10/08/2021 20:00	0.0	0	0	0	0	1
10/08/2021 21:00	2.5	0	0	0	1	0
10/08/2021 22:00	0.0	0	0	0	0	0
10/08/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	2.5 #	0 #	0 #	0 #	1 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.5	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/09/2021 00:00	0.0	0	0	0	0	0
10/09/2021 01:00	0.0	0	0	0	0	0
10/09/2021 02:00	0.0	0	0	0	0	0
10/09/2021 03:00	0.0	0	0	0	0	0
10/09/2021 04:00	0.0	0	0	0	0	0
10/09/2021 05:00	0.0	0	0	0	0	0
10/09/2021 06:00	0.0	0	0	0	0	0
10/09/2021 07:00	0.0	0	0	0	0	0
10/09/2021 08:00	0.0	0	0	0	0	0
10/09/2021 09:00	0.0	0	0	0	0	0
10/09/2021 10:00	0.0	0	0	0	0	0
10/09/2021 11:00	0.0	0	0	0	0	0
10/09/2021 12:00	0.0	0	0	0	0	0
10/09/2021 13:00	0.0	0	0	0	0	0
10/09/2021 14:00	0.0	0	0	0	0	0
10/09/2021 15:00	0.0	0	0	0	0	0
10/09/2021 16:00	0.0	0	0	0	0	0
10/09/2021 17:00	0.0	0	0	0	0	0
10/09/2021 18:00	0.0	0	0	0	0	0
10/09/2021 19:00	0.0	0	0	0	0	0
10/09/2021 20:00	0.0	0	0	0	0	0
10/09/2021 21:00	0.0	0	0	0	0	0
10/09/2021 22:00	0.0	0	0	0	0	0
10/09/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/10/2021 00:00	0.0	0	0	0	0	0
10/10/2021 01:00	0.0	0	0	0	0	0
10/10/2021 02:00	0.0	0	0	0	0	0
10/10/2021 03:00	0.0	0	0	0	0	0
10/10/2021 04:00	0.0	0	0	0	0	0
10/10/2021 05:00	0.0	0	0	0	0	0
10/10/2021 06:00	0.0	0	0	0	0	0
10/10/2021 07:00	0.0	0	0	0	0	0
10/10/2021 08:00	0.0	0	0	0	0	0
10/10/2021 09:00	0.0	0	0	0	0	0
10/10/2021 10:00	0.0	0	0	0	0	0
10/10/2021 11:00	0.0	0	0	0	0	0
10/10/2021 12:00	0.0	0	0	0	0	0
10/10/2021 13:00	0.0	0	0	0	0	0
10/10/2021 14:00	0.0	0	0	0	0	0
10/10/2021 15:00	0.0	0	0	0	0	0
10/10/2021 16:00	0.0	0	0	0	0	0
10/10/2021 17:00	0.0	0	0	0	0	0
10/10/2021 18:00	0.0	0	0	0	0	0
10/10/2021 19:00	0.0	0	0	0	0	0
10/10/2021 20:00	0.0	0	0	0	0	0
10/10/2021 21:00	0.0	0	0	0	0	0
10/10/2021 22:00	0.0	0	0	0	0	0
10/10/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/11/2021 00:00	0.0	0	0	0	0	0
10/11/2021 01:00	0.0	0	0	0	0	0
10/11/2021 02:00	0.0	0	0	0	0	0
10/11/2021 03:00	0.0	0	0	0	0	0
10/11/2021 04:00	0.0	0	0	0	0	0
10/11/2021 05:00	0.0	0	0	0	0	0
10/11/2021 06:00	0.0	0	0	0	0	0
10/11/2021 07:00	0.0	0	0	0	0	0
10/11/2021 08:00	0.0	0	0	0	0	0
10/11/2021 09:00	0.0	0	0	0	0	0
10/11/2021 10:00	0.0	0	0	0	0	0
10/11/2021 11:00	0.0	0	0	0	0	0
10/11/2021 12:00	0.0	0	0	0	0	0
10/11/2021 13:00	0.0	0	0	0	0	0
10/11/2021 14:00	0.0	0	0	0	0	0
10/11/2021 15:00	0.0	0	0	0	0	0
10/11/2021 16:00	0.0	0	0	0	0	0
10/11/2021 17:00	0.0	0	0	0	0	0
10/11/2021 18:00	0.0	0	0	0	0	0
10/11/2021 19:00	0.0	0	0	0	0	0
10/11/2021 20:00	0.0	0	0	0	0	0
10/11/2021 21:00	0.0	0	0	0	0	0
10/11/2021 22:00	0.0	0	0	0	0	0
10/11/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/12/2021 00:00	0.0	0	0	0	0	0
10/12/2021 01:00	0.0	0	0	0	0	0
10/12/2021 02:00	0.0	0	0	0	0	0
10/12/2021 03:00	0.0	0	0	0	0	0
10/12/2021 04:00	0.0	0	0	0	0	0
10/12/2021 05:00	0.0	0	0	0	0	0
10/12/2021 06:00	0.0	0	0	0	0	0
10/12/2021 07:00	0.0	0	0	0	0	0
10/12/2021 08:00	0.0	0	0	0	0	0
10/12/2021 09:00	0.0	0	0	0	0	0
10/12/2021 10:00	0.0	0	0	0	0	0
10/12/2021 11:00	0.0	0	0	0	0	0
10/12/2021 12:00	0.0	0	0	0	0	0
10/12/2021 13:00	0.0	0	0	0	0	0
10/12/2021 14:00	0.0	0	0	0	0	0
10/12/2021 15:00	0.0	0	0	0	0	0
10/12/2021 16:00	0.0	0	0	0	0	0
10/12/2021 17:00	0.0	0	0	0	0	0
10/12/2021 18:00	0.0	0	0	0	0	0
10/12/2021 19:00	0.0	0	0	0	0	0
10/12/2021 20:00	0.0	0	0	0	0	0
10/12/2021 21:00	0.0	0	0	0	0	0
10/12/2021 22:00	0.0	0	0	0	0	0
10/12/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/13/2021 00:00	0.0	0	0	0	0	0
10/13/2021 01:00	0.0	0	0	0	0	0
10/13/2021 02:00	0.0	0	0	0	0	0
10/13/2021 03:00	0.0	0	0	0	0	0
10/13/2021 04:00	0.0	0	0	0	0	0
10/13/2021 05:00	0.0	0	0	0	0	0
10/13/2021 06:00	0.0	0	0	0	0	0
10/13/2021 07:00	0.0	0	0	0	0	0
10/13/2021 08:00	0.0	0	0	0	0	0
10/13/2021 09:00	0.0	0	0	0	0	0
10/13/2021 10:00	0.0	0	0	0	0	0
10/13/2021 11:00	0.0	0	0	0	0	0
10/13/2021 12:00	0.0	0	0	0	0	0
10/13/2021 13:00	0.0	0	0	0	0	0
10/13/2021 14:00	0.0	0	0	0	0	0
10/13/2021 15:00	0.0	0	0	0	0	0
10/13/2021 16:00	0.0	0	0	0	0	0
10/13/2021 17:00	0.0	0	0	0	0	0
10/13/2021 18:00	0.0	0	0	0	0	0
10/13/2021 19:00	0.0	0	0	0	0	0
10/13/2021 20:00	0.0	0	0	0	0	0
10/13/2021 21:00	0.0	0	0	0	0	0
10/13/2021 22:00	0.0	0	0	0	0	0
10/13/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/14/2021 00:00	0.0	0	0	0	0	0
10/14/2021 01:00	0.0	0	0	0	0	0
10/14/2021 02:00	0.0	0	0	0	0	0
10/14/2021 03:00	0.0	0	0	0	0	0
10/14/2021 04:00	0.0	0	0	0	0	0
10/14/2021 05:00	0.0	0	0	0	0	0
10/14/2021 06:00	0.0	0	0	0	0	0
10/14/2021 07:00	0.0	0	0	0	0	0
10/14/2021 08:00	0.0	0	0	0	0	0
10/14/2021 09:00	0.0	0	0	0	0	0
10/14/2021 10:00	0.0	0	0	0	0	0
10/14/2021 11:00	0.0	0	0	0	0	0
10/14/2021 12:00	0.0	0	0	0	0	0
10/14/2021 13:00	0.0	0	0	0	0	0
10/14/2021 14:00	0.0	0	0	0	0	0
10/14/2021 15:00	0.0	0	0	0	0	0
10/14/2021 16:00	0.0	0	0	0	0	0
10/14/2021 17:00	0.0	0	0	0	0	0
10/14/2021 18:00	0.0	0	0	0	0	0
10/14/2021 19:00	0.0	0	0	0	0	0
10/14/2021 20:00	0.0	0	0	0	0	0
10/14/2021 21:00	0.0	0	0	0	0	0
10/14/2021 22:00	0.0	0	0	0	0	0
10/14/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/15/2021 00:00	0.0	0	0	0	0	0
10/15/2021 01:00	0.0	0	0	0	0	0
10/15/2021 02:00	0.0	0	0	0	0	0
10/15/2021 03:00	0.0	0	0	0	0	0
10/15/2021 04:00	0.0	0	0	0	0	0
10/15/2021 05:00	0.0	0	0	0	0	0
10/15/2021 06:00	0.0	0	0	0	0	0
10/15/2021 07:00	0.0	0	0	0	0	0
10/15/2021 08:00	0.0	0	0	0	0	0
10/15/2021 09:00	0.0	0	0	0	0	0
10/15/2021 10:00	0.0	0	0	0	0	0
10/15/2021 11:00	0.0	0	0	0	0	0
10/15/2021 12:00	0.0	0	0	0	0	0
10/15/2021 13:00	0.0	0	0	0	0	0
10/15/2021 14:00	0.0	0	0	0	0	0
10/15/2021 15:00	0.0	0	0	0	0	0
10/15/2021 16:00	0.0	0	0	0	0	0
10/15/2021 17:00	0.0	0	0	0	0	0
10/15/2021 18:00	0.0	0	0	0	0	0
10/15/2021 19:00	0.0	0	0	0	0	0
10/15/2021 20:00	0.0	0	0	0	0	0
10/15/2021 21:00	0.0	0	0	0	0	0
10/15/2021 22:00	0.0	0	0	0	0	0
10/15/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/16/2021 00:00	0.0	0	0	0	0	0
10/16/2021 01:00	0.0	0	0	0	0	0
10/16/2021 02:00	0.0	0	0	0	0	0
10/16/2021 03:00	0.0	0	0	0	0	0
10/16/2021 04:00	0.0	0	0	0	0	0
10/16/2021 05:00	0.0	0	0	0	0	0
10/16/2021 06:00	0.0	0	0	0	0	0
10/16/2021 07:00	0.0	0	0	0	0	0
10/16/2021 08:00	0.0	0	0	0	0	0
10/16/2021 09:00	0.0	0	0	0	0	0
10/16/2021 10:00	0.0	0	0	0	0	0
10/16/2021 11:00	0.0	0	0	0	0	0
10/16/2021 12:00	0.0	0	0	0	0	0
10/16/2021 13:00	0.0	0	0	0	0	0
10/16/2021 14:00	0.0	0	0	0	0	0
10/16/2021 15:00	0.0	0	0	0	0	0
10/16/2021 16:00	0.0	0	0	0	0	0
10/16/2021 17:00	0.0	0	0	0	0	0
10/16/2021 18:00	0.0	0	0	0	0	0
10/16/2021 19:00	0.0	0	0	0	0	0
10/16/2021 20:00	0.0	0	0	0	0	0
10/16/2021 21:00	0.0	0	0	0	0	0
10/16/2021 22:00	0.0	0	0	0	0	0
10/16/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/17/2021 00:00	0.0	0	0	0	0	0
10/17/2021 01:00	0.0	0	0	0	0	0
10/17/2021 02:00	0.0	0	0	0	0	0
10/17/2021 03:00	0.0	0	0	0	0	0
10/17/2021 04:00	0.0	0	0	0	0	0
10/17/2021 05:00	0.0	0	0	0	0	0
10/17/2021 06:00	0.0	0	0	0	0	0
10/17/2021 07:00	0.0	0	0	0	0	0
10/17/2021 08:00	0.0	0	0	0	0	0
10/17/2021 09:00	0.0	0	0	0	0	0
10/17/2021 10:00	0.0	0	0	0	0	0
10/17/2021 11:00	0.0	0	0	0	0	0
10/17/2021 12:00	0.0	0	0	0	0	0
10/17/2021 13:00	0.0	0	0	0	0	0
10/17/2021 14:00	0.0	0	0	0	0	0
10/17/2021 15:00	0.0	0	0	0	0	0
10/17/2021 16:00	0.0	0	0	0	0	0
10/17/2021 17:00	0.0	0	0	0	0	0
10/17/2021 18:00	0.0	0	0	0	0	0
10/17/2021 19:00	0.0	0	0	0	0	0
10/17/2021 20:00	0.0	0	0	0	0	0
10/17/2021 21:00	0.0	0	0	0	0	0
10/17/2021 22:00	0.0	0	0	0	0	0
10/17/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/18/2021 00:00	0.0	0	0	0	0	0
10/18/2021 01:00	0.0	0	0	0	0	0
10/18/2021 02:00	0.0	0	0	0	0	0
10/18/2021 03:00	0.0	0	0	0	0	0
10/18/2021 04:00	0.0	0	0	0	0	0
10/18/2021 05:00	0.0	0	0	0	0	0
10/18/2021 06:00	0.0	0	0	0	0	0
10/18/2021 07:00	0.0	0	0	0	0	0
10/18/2021 08:00	0.0	0	0	0	0	0
10/18/2021 09:00	0.0	0	0	0	0	0
10/18/2021 10:00	0.0	0	0	0	0	0
10/18/2021 11:00	0.0	0	0	0	0	0
10/18/2021 12:00	0.0	0	0	0	0	0
10/18/2021 13:00	0.0	0	0	0	0	0
10/18/2021 14:00	0.0	0	0	0	0	0
10/18/2021 15:00	0.0	0	0	0	0	0
10/18/2021 16:00	0.0	0	0	0	0	0
10/18/2021 17:00	0.0	0	0	0	0	0
10/18/2021 18:00	0.0	0	0	0	0	0
10/18/2021 19:00	0.0	0	0	0	0	0
10/18/2021 20:00	0.0	0	0	0	0	0
10/18/2021 21:00	0.0	0	0	0	0	0
10/18/2021 22:00	0.0	0	0	0	0	0
10/18/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/19/2021 00:00	0.0	0	0	0	0	0
10/19/2021 01:00	0.0	0	0	0	0	0
10/19/2021 02:00	0.0	0	0	0	0	0
10/19/2021 03:00	0.0	0	0	0	0	0
10/19/2021 04:00	0.0	0	0	0	0	0
10/19/2021 05:00	0.0	0	0	0	0	0
10/19/2021 06:00	0.0	0	0	0	0	0
10/19/2021 07:00	0.0	0	0	0	0	0
10/19/2021 08:00	0.0	0	0	0	0	0
10/19/2021 09:00	0.0	0	0	0	0	0
10/19/2021 10:00	0.0	0	0	0	0	0
10/19/2021 11:00	0.0	0	0	0	0	0
10/19/2021 12:00	0.0	0	0	0	0	0
10/19/2021 13:00	0.0	0	0	0	0	0
10/19/2021 14:00	0.0	0	0	0	0	0
10/19/2021 15:00	0.0	0	0	0	0	0
10/19/2021 16:00	0.0	0	0	0	0	0
10/19/2021 17:00	0.0	0	0	0	0	0
10/19/2021 18:00	0.0	0	0	0	0	0
10/19/2021 19:00	0.0	0	0	0	0	0
10/19/2021 20:00	0.0	0	0	0	0	0
10/19/2021 21:00	0.0	0	0	0	0	0
10/19/2021 22:00	0.0	0	0	0	0	0
10/19/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/20/2021 00:00	0.0	0	0	0	0	0
10/20/2021 01:00	0.0	0	0	0	0	0
10/20/2021 02:00	0.0	0	0	0	0	0
10/20/2021 03:00	0.0	0	0	0	0	0
10/20/2021 04:00	0.0	0	0	0	0	0
10/20/2021 05:00	0.0	0	0	0	0	0
10/20/2021 06:00	0.0	0	0	0	0	0
10/20/2021 07:00	0.0	0	0	0	0	0
10/20/2021 08:00	40.1	1	0	0	0	0
10/20/2021 09:00	53.6	1	0	0	0	0
10/20/2021 10:00	22.9	1	0	0	0	0
10/20/2021 11:00	125.8	1	0	0	0	0
10/20/2021 12:00	38.7	1	0	0	0	0
10/20/2021 13:00	0.0	0	0	0	0	1
10/20/2021 14:00	0.0	0	0	0	0	1
10/20/2021 15:00	0.0	0	0	0	0	1
10/20/2021 16:00	0.0	0	0	0	0	1
10/20/2021 17:00	0.0	0	0	0	0	1
10/20/2021 18:00	0.0	0	0	0	0	1
10/20/2021 19:00	0.0	0	0	0	0	1
10/20/2021 20:00	0.0	0	0	0	0	1
10/20/2021 21:00	0.0	0	0	0	0	1
10/20/2021 22:00	2.0	0	0	0	1	0
10/20/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	283.1 #	5 #	0 #	0 #	1 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	125.8	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/21/2021 00:00	0.0	0	0	0	0	0
10/21/2021 01:00	0.0	0	0	0	0	0
10/21/2021 02:00	0.0	0	0	0	0	0
10/21/2021 03:00	0.0	0	0	0	0	0
10/21/2021 04:00	0.0	0	0	0	0	0
10/21/2021 05:00	0.0	0	0	0	0	0
10/21/2021 06:00	0.0	0	0	0	0	0
10/21/2021 07:00	0.0	0	0	0	0	0
10/21/2021 08:00	0.0	0	0	0	0	0
10/21/2021 09:00	0.0	0	0	0	0	0
10/21/2021 10:00	0.0	0	0	0	0	0
10/21/2021 11:00	0.0	0	0	0	0	0
10/21/2021 12:00	0.0	0	0	0	0	0
10/21/2021 13:00	0.0	0	0	0	0	0
10/21/2021 14:00	0.0	0	0	0	0	0
10/21/2021 15:00	0.0	0	0	0	0	0
10/21/2021 16:00	0.0	0	0	0	0	0
10/21/2021 17:00	0.0	0	0	0	0	0
10/21/2021 18:00	0.0	0	0	0	0	0
10/21/2021 19:00	0.0	0	0	0	0	0
10/21/2021 20:00	0.0	0	0	0	0	0
10/21/2021 21:00	0.0	0	0	0	0	0
10/21/2021 22:00	0.0	0	0	0	0	0
10/21/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/22/2021 00:00	0.0	0	0	0	0	0
10/22/2021 01:00	0.0	0	0	0	0	0
10/22/2021 02:00	0.0	0	0	0	0	0
10/22/2021 03:00	0.0	0	0	0	0	0
10/22/2021 04:00	0.0	0	0	0	0	0
10/22/2021 05:00	0.0	0	0	0	0	0
10/22/2021 06:00	0.0	0	0	0	0	0
10/22/2021 07:00	0.0	0	0	0	0	0
10/22/2021 08:00	0.0	0	0	0	0	0
10/22/2021 09:00	0.0	0	0	0	0	0
10/22/2021 10:00	0.0	0	0	0	0	0
10/22/2021 11:00	0.0	0	0	0	0	0
10/22/2021 12:00	0.0	0	0	0	0	0
10/22/2021 13:00	0.0	0	0	0	0	0
10/22/2021 14:00	0.0	0	0	0	0	0
10/22/2021 15:00	0.0	0	0	0	0	0
10/22/2021 16:00	0.0	0	0	0	0	0
10/22/2021 17:00	0.0	0	0	0	0	0
10/22/2021 18:00	0.0	0	0	0	0	0
10/22/2021 19:00	0.0	0	0	0	0	0
10/22/2021 20:00	0.0	0	0	0	0	0
10/22/2021 21:00	0.0	0	0	0	0	0
10/22/2021 22:00	0.0	0	0	0	0	0
10/22/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/23/2021 00:00	0.0	0	0	0	0	0
10/23/2021 01:00	0.0	0	0	0	0	0
10/23/2021 02:00	0.0	0	0	0	0	0
10/23/2021 03:00	0.0	0	0	0	0	0
10/23/2021 04:00	0.0	0	0	0	0	0
10/23/2021 05:00	0.1	0	1	0	0	0
10/23/2021 06:00	82.3	0	1	0	0	0
10/23/2021 07:00	14.6	0	1	0	0	0
10/23/2021 08:00	0.0	0	0	0	0	1
10/23/2021 09:00	0.0	0	0	0	0	1
10/23/2021 10:00	0.0	0	0	0	0	1
10/23/2021 11:00	0.0	0	0	0	0	1
10/23/2021 12:00	0.0	0	0	0	0	1
10/23/2021 13:00	0.0	0	0	0	0	1
10/23/2021 14:00	0.0	0	0	0	0	1
10/23/2021 15:00	0.0	0	0	0	0	1
10/23/2021 16:00	0.0	0	0	0	0	1
10/23/2021 17:00	0.0	0	0	0	0	1
10/23/2021 18:00	0.0	0	0	0	0	1
10/23/2021 19:00	0.0	0	0	0	0	1
10/23/2021 20:00	0.0	0	0	0	0	1
10/23/2021 21:00	0.0	0	0	0	0	1
10/23/2021 22:00	1.3	0	0	0	1	0
10/23/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	98.3 #	0 #	3 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	82.3	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/24/2021 00:00	0.0	0	0	0	0	0
10/24/2021 01:00	0.0	0	0	0	0	0
10/24/2021 02:00	0.0	0	0	0	0	0
10/24/2021 03:00	2.1	0	0	1	0	0
10/24/2021 04:00	67.0	0	0	1	0	0
10/24/2021 05:00	0.0	0	0	0	0	1
10/24/2021 06:00	0.0	0	0	0	0	1
10/24/2021 07:00	0.0	0	0	0	0	1
10/24/2021 08:00	0.0	0	0	0	0	1
10/24/2021 09:00	0.0	0	0	0	0	1
10/24/2021 10:00	0.0	0	0	0	0	1
10/24/2021 11:00	0.0	0	0	0	0	1
10/24/2021 12:00	0.0	0	0	0	0	1
10/24/2021 13:00	0.0	0	0	0	0	1
10/24/2021 14:00	0.0	0	0	0	0	1
10/24/2021 15:00	0.0	0	0	0	0	1
10/24/2021 16:00	0.0	0	0	0	0	1
10/24/2021 17:00	0.0	0	0	0	0	1
10/24/2021 18:00	0.0	0	0	0	0	1
10/24/2021 19:00	0.0	0	0	0	0	1
10/24/2021 20:00	0.0	0	0	0	0	1
10/24/2021 21:00	0.0	0	0	0	0	1
10/24/2021 22:00	0.0	0	0	0	0	1
10/24/2021 23:00	1.6	0	0	0	1	0
Average/Sum#:	70.7 #	0 #	0 #	2 #	1 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	67.0	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/25/2021 00:00	0.0	0	0	0	0	0
10/25/2021 01:00	0.0	0	0	0	0	0
10/25/2021 02:00	0.0	0	0	0	0	0
10/25/2021 03:00	0.0	0	0	0	0	0
10/25/2021 04:00	0.0	0	0	0	0	0
10/25/2021 05:00	22.4	0	0	1	0	0
10/25/2021 06:00	17.9	0	0	1	0	0
10/25/2021 07:00	0.0	0	0	0	0	1
10/25/2021 08:00	0.0	0	0	0	0	1
10/25/2021 09:00	0.0	0	0	0	0	1
10/25/2021 10:00	0.0	0	0	0	0	1
10/25/2021 11:00	0.0	0	0	0	0	1
10/25/2021 12:00	0.0	0	0	0	0	1
10/25/2021 13:00	0.0	0	0	0	0	1
10/25/2021 14:00	0.0	0	0	0	0	1
10/25/2021 15:00	0.0	0	0	0	0	1
10/25/2021 16:00	0.0	0	0	0	0	1
10/25/2021 17:00	0.0	0	0	0	0	1
10/25/2021 18:00	0.0	0	0	0	0	1
10/25/2021 19:00	0.0	0	0	0	0	1
10/25/2021 20:00	0.0	0	0	0	0	1
10/25/2021 21:00	0.0	0	0	0	0	1
10/25/2021 22:00	0.0	0	0	0	0	1
10/25/2021 23:00	1.4	0	0	0	1	0
Average/Sum#:	41.7 #	0 #	0 #	2 #	1 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	22.4	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/26/2021 00:00	0.0	0	0	0	0	0
10/26/2021 01:00	0.0	0	0	0	0	0
10/26/2021 02:00	0.0	0	0	0	0	0
10/26/2021 03:00	0.0	0	0	0	0	0
10/26/2021 04:00	0.0	0	0	0	0	0
10/26/2021 05:00	19.3	0	0	1	0	0
10/26/2021 06:00	23.4	0	0	1	0	0
10/26/2021 07:00	0.0	0	0	0	0	1
10/26/2021 08:00	0.0	0	0	0	0	1
10/26/2021 09:00	0.0	0	0	0	0	1
10/26/2021 10:00	0.0	0	0	0	0	1
10/26/2021 11:00	0.0	0	0	0	0	1
10/26/2021 12:00	0.0	0	0	0	0	1
10/26/2021 13:00	0.0	0	0	0	0	1
10/26/2021 14:00	0.0	0	0	0	0	1
10/26/2021 15:00	0.0	0	0	0	0	1
10/26/2021 16:00	0.0	0	0	0	0	1
10/26/2021 17:00	0.0	0	0	0	0	1
10/26/2021 18:00	0.0	0	0	0	0	1
10/26/2021 19:00	0.0	0	0	0	0	1
10/26/2021 20:00	0.0	0	0	0	0	1
10/26/2021 21:00	0.0	0	0	0	0	1
10/26/2021 22:00	0.0	0	0	0	0	1
10/26/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	42.7 #	0 #	0 #	2 #	0 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	23.4	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/27/2021 00:00	0.0	0	0	0	0	1
10/27/2021 01:00	0.0	0	0	0	0	1
10/27/2021 02:00	0.0	0	0	0	0	1
10/27/2021 03:00	0.0	0	0	0	0	1
10/27/2021 04:00	0.0	0	0	0	0	1
10/27/2021 05:00	0.0	0	0	0	0	1
10/27/2021 06:00	0.0	0	0	0	0	1
10/27/2021 07:00	0.0	0	0	0	0	1
10/27/2021 08:00	0.0	0	0	0	0	1
10/27/2021 09:00	0.0	0	0	0	0	1
10/27/2021 10:00	0.0	0	0	0	0	1
10/27/2021 11:00	0.0	0	0	0	0	1
10/27/2021 12:00	0.0	0	0	0	0	1
10/27/2021 13:00	0.0	0	0	0	0	1
10/27/2021 14:00	0.0	0	0	0	0	1
10/27/2021 15:00	0.0	0	0	0	0	1
10/27/2021 16:00	0.0	0	0	0	0	1
10/27/2021 17:00	0.0	0	0	0	0	1
10/27/2021 18:00	0.0	0	0	0	0	1
10/27/2021 19:00	0.0	0	0	0	0	1
10/27/2021 20:00	0.0	0	0	0	0	1
10/27/2021 21:00	0.0	0	0	0	0	1
10/27/2021 22:00	0.0	0	0	0	0	1
10/27/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/28/2021 00:00	1.0	0	0	0	1	0
10/28/2021 01:00	0.0	0	0	0	0	0
10/28/2021 02:00	0.0	0	0	0	0	0
10/28/2021 03:00	0.0	0	0	0	0	0
10/28/2021 04:00	0.0	0	0	0	0	0
10/28/2021 05:00	0.0	0	0	0	0	0
10/28/2021 06:00	0.0	0	0	0	0	0
10/28/2021 07:00	0.0	0	0	0	0	0
10/28/2021 08:00	0.0	0	0	0	0	0
10/28/2021 09:00	0.0	0	0	0	0	0
10/28/2021 10:00	0.0	0	0	0	0	0
10/28/2021 11:00	0.0	0	0	0	0	0
10/28/2021 12:00	15.9	0	1	0	0	0
10/28/2021 13:00	35.3	0	1	0	0	0
10/28/2021 14:00	0.0	0	0	0	0	1
10/28/2021 15:00	0.0	0	0	0	0	1
10/28/2021 16:00	0.0	0	0	0	0	1
10/28/2021 17:00	0.0	0	0	0	0	1
10/28/2021 18:00	0.0	0	0	0	0	1
10/28/2021 19:00	0.0	0	0	0	0	1
10/28/2021 20:00	0.0	0	0	0	0	1
10/28/2021 21:00	0.0	0	0	0	0	1
10/28/2021 22:00	0.0	0	0	0	0	1
10/28/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	52.2 #	0 #	2 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	35.3	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/29/2021 00:00	0.0	0	0	0	0	1
10/29/2021 01:00	0.0	0	0	0	0	1
10/29/2021 02:00	0.0	0	0	0	0	1
10/29/2021 03:00	0.0	0	0	0	0	1
10/29/2021 04:00	0.0	0	0	0	0	1
10/29/2021 05:00	0.0	0	0	0	0	1
10/29/2021 06:00	0.0	0	0	0	0	1
10/29/2021 07:00	0.0	0	0	0	0	1
10/29/2021 08:00	0.0	0	0	0	0	1
10/29/2021 09:00	0.0	0	0	0	0	1
10/29/2021 10:00	0.0	0	0	0	0	1
10/29/2021 11:00	0.0	0	0	0	0	1
10/29/2021 12:00	0.0	0	0	0	0	1
10/29/2021 13:00	0.0	0	0	0	0	1
10/29/2021 14:00	0.0	0	0	0	0	1
10/29/2021 15:00	0.0	0	0	0	0	1
10/29/2021 16:00	0.0	0	0	0	0	1
10/29/2021 17:00	0.0	0	0	0	0	1
10/29/2021 18:00	0.0	0	0	0	0	1
10/29/2021 19:00	0.0	0	0	0	0	1
10/29/2021 20:00	0.0	0	0	0	0	1
10/29/2021 21:00	0.0	0	0	0	0	1
10/29/2021 22:00	0.0	0	0	0	0	1
10/29/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/30/2021 00:00	0.0	0	0	0	0	1
10/30/2021 01:00	0.0	0	0	0	0	1
10/30/2021 02:00	0.0	0	0	0	0	1
10/30/2021 03:00	0.0	0	0	0	0	1
10/30/2021 04:00	0.0	0	0	0	0	1
10/30/2021 05:00	0.0	0	0	0	0	1
10/30/2021 06:00	0.0	0	0	0	0	1
10/30/2021 07:00	0.0	0	0	0	0	1
10/30/2021 08:00	0.0	0	0	0	0	1
10/30/2021 09:00	0.0	0	0	0	0	1
10/30/2021 10:00	0.0	0	0	0	0	1
10/30/2021 11:00	0.0	0	0	0	0	1
10/30/2021 12:00	0.0	0	0	0	0	1
10/30/2021 13:00	0.0	0	0	0	0	1
10/30/2021 14:00	0.0	0	0	0	0	1
10/30/2021 15:00	0.0	0	0	0	0	1
10/30/2021 16:00	0.0	0	0	0	0	1
10/30/2021 17:00	0.0	0	0	0	0	1
10/30/2021 18:00	0.0	0	0	0	0	1
10/30/2021 19:00	0.0	0	0	0	0	1
10/30/2021 20:00	0.0	0	0	0	0	1
10/30/2021 21:00	0.0	0	0	0	0	1
10/30/2021 22:00	0.0	0	0	0	0	1
10/30/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/31/2021 00:00	0.0	0	0	0	0	1
10/31/2021 01:00	0.0	0	0	0	0	1
10/31/2021 02:00	0.0	0	0	0	0	1
10/31/2021 03:00	0.0	0	0	0	0	1
10/31/2021 04:00	0.0	0	0	0	0	1
10/31/2021 05:00	0.0	0	0	0	0	1
10/31/2021 06:00	0.0	0	0	0	0	1
10/31/2021 07:00	0.0	0	0	0	0	1
10/31/2021 08:00	0.0	0	0	0	0	1
10/31/2021 09:00	0.0	0	0	0	0	1
10/31/2021 10:00	0.0	0	0	0	0	1
10/31/2021 11:00	0.0	0	0	0	0	1
10/31/2021 12:00	0.0	0	0	0	0	1
10/31/2021 13:00	0.0	0	0	0	0	1
10/31/2021 14:00	0.0	0	0	0	0	1
10/31/2021 15:00	0.0	0	0	0	0	1
10/31/2021 16:00	0.0	0	0	0	0	1
10/31/2021 17:00	0.0	0	0	0	0	1
10/31/2021 18:00	0.0	0	0	0	0	1
10/31/2021 19:00	0.0	0	0	0	0	1
10/31/2021 20:00	0.0	0	0	0	0	1
10/31/2021 21:00	0.0	0	0	0	0	1
10/31/2021 22:00	0.0	0	0	0	0	1
10/31/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/01/2021 00:00	0.0	0	0	0	0	1
11/01/2021 01:00	0.0	0	0	0	0	1
11/01/2021 02:00	0.0	0	0	0	0	1
11/01/2021 03:00	0.0	0	0	0	0	1
11/01/2021 04:00	0.0	0	0	0	0	1
11/01/2021 05:00	0.0	0	0	0	0	1
11/01/2021 06:00	0.0	0	0	0	0	1
11/01/2021 07:00	0.0	0	0	0	0	1
11/01/2021 08:00	0.0	0	0	0	0	1
11/01/2021 09:00	0.0	0	0	0	0	1
11/01/2021 10:00	0.0	0	0	0	0	1
11/01/2021 11:00	0.0	0	0	0	0	1
11/01/2021 12:00	0.0	0	0	0	0	1
11/01/2021 13:00	0.0	0	0	0	0	1
11/01/2021 14:00	0.0	0	0	0	0	1
11/01/2021 15:00	0.0	0	0	0	0	1
11/01/2021 16:00	0.0	0	0	0	0	1
11/01/2021 17:00	0.0	0	0	0	0	1
11/01/2021 18:00	0.0	0	0	0	0	1
11/01/2021 19:00	0.0	0	0	0	0	1
11/01/2021 20:00	0.0	0	0	0	0	1
11/01/2021 21:00	0.0	0	0	0	0	1
11/01/2021 22:00	0.0	0	0	0	0	1
11/01/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/02/2021 00:00	0.0	0	0	0	0	1
11/02/2021 01:00	0.0	0	0	0	0	1
11/02/2021 02:00	0.0	0	0	0	0	1
11/02/2021 03:00	0.0	0	0	0	0	1
11/02/2021 04:00	0.0	0	0	0	0	1
11/02/2021 05:00	0.0	0	0	0	0	1
11/02/2021 06:00	0.0	0	0	0	0	1
11/02/2021 07:00	0.0	0	0	0	0	1
11/02/2021 08:00	0.0	0	0	0	0	1
11/02/2021 09:00	0.0	0	0	0	0	1
11/02/2021 10:00	0.0	0	0	0	0	1
11/02/2021 11:00	0.0	0	0	0	0	1
11/02/2021 12:00	0.0	0	0	0	0	1
11/02/2021 13:00	0.0	0	0	0	0	1
11/02/2021 14:00	0.0	0	0	0	0	1
11/02/2021 15:00	0.0	0	0	0	0	1
11/02/2021 16:00	0.0	0	0	0	0	1
11/02/2021 17:00	0.0	0	0	0	0	1
11/02/2021 18:00	0.0	0	0	0	0	1
11/02/2021 19:00	0.0	0	0	0	0	1
11/02/2021 20:00	0.0	0	0	0	0	1
11/02/2021 21:00	0.0	0	0	0	0	1
11/02/2021 22:00	0.0	0	0	0	0	1
11/02/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/03/2021 00:00	0.0	0	0	0	0	1
11/03/2021 01:00	0.0	0	0	0	0	1
11/03/2021 02:00	0.0	0	0	0	0	1
11/03/2021 03:00	0.0	0	0	0	0	1
11/03/2021 04:00	0.0	0	0	0	0	1
11/03/2021 05:00	0.0	0	0	0	0	1
11/03/2021 06:00	0.0	0	0	0	0	1
11/03/2021 07:00	0.0	0	0	0	0	1
11/03/2021 08:00	0.0	0	0	0	0	1
11/03/2021 09:00	0.0	0	0	0	0	1
11/03/2021 10:00	0.0	0	0	0	0	1
11/03/2021 11:00	0.0	0	0	0	0	1
11/03/2021 12:00	0.0	0	0	0	0	1
11/03/2021 13:00	0.0	0	0	0	0	1
11/03/2021 14:00	0.0	0	0	0	0	1
11/03/2021 15:00	0.0	0	0	0	0	1
11/03/2021 16:00	0.0	0	0	0	0	1
11/03/2021 17:00	0.0	0	0	0	0	1
11/03/2021 18:00	0.0	0	0	0	0	1
11/03/2021 19:00	0.0	0	0	0	0	1
11/03/2021 20:00	0.0	0	0	0	0	1
11/03/2021 21:00	0.0	0	0	0	0	1
11/03/2021 22:00	0.0	0	0	0	0	1
11/03/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/04/2021 00:00	0.0	0	0	0	0	1
11/04/2021 01:00	0.0	0	0	0	0	1
11/04/2021 02:00	0.0	0	0	0	0	1
11/04/2021 03:00	0.0	0	0	0	0	1
11/04/2021 04:00	0.0	0	0	0	0	1
11/04/2021 05:00	0.0	0	0	0	0	1
11/04/2021 06:00	0.0	0	0	0	0	1
11/04/2021 07:00	0.0	0	0	0	0	1
11/04/2021 08:00	0.0	0	0	0	0	1
11/04/2021 09:00	0.0	0	0	0	0	1
11/04/2021 10:00	0.0	0	0	0	0	1
11/04/2021 11:00	0.0	0	0	0	0	1
11/04/2021 12:00	0.0	0	0	0	0	1
11/04/2021 13:00	0.0	0	0	0	0	1
11/04/2021 14:00	0.0	0	0	0	0	1
11/04/2021 15:00	0.0	0	0	0	0	1
11/04/2021 16:00	0.0	0	0	0	0	1
11/04/2021 17:00	0.0	0	0	0	0	1
11/04/2021 18:00	0.0	0	0	0	0	1
11/04/2021 19:00	0.0	0	0	0	0	1
11/04/2021 20:00	0.0	0	0	0	0	1
11/04/2021 21:00	0.0	0	0	0	0	1
11/04/2021 22:00	0.0	0	0	0	0	1
11/04/2021 23:00	1.7	0	0	0	1	0
Average/Sum#:	1.7 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.7	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/05/2021 00:00	0.0	0	0	0	0	0
11/05/2021 01:00	0.0	0	0	0	0	0
11/05/2021 02:00	0.0	0	0	0	0	0
11/05/2021 03:00	0.0	0	0	0	0	0
11/05/2021 04:00	0.0	0	0	0	0	0
11/05/2021 05:00	0.0	0	0	0	0	0
11/05/2021 06:00	0.0	0	0	0	0	0
11/05/2021 07:00	0.0	0	0	0	0	0
11/05/2021 08:00	0.0	0	0	0	0	0
11/05/2021 09:00	0.0	0	0	0	0	0
11/05/2021 10:00	0.0	0	0	0	0	0
11/05/2021 11:00	0.0	0	0	0	0	0
11/05/2021 12:00	0.0	0	0	0	0	0
11/05/2021 13:00	20.5	0	1	0	0	0
11/05/2021 14:00	19.4	0	1	0	0	0
11/05/2021 15:00	0.0	0	0	0	0	1
11/05/2021 16:00	0.0	0	0	0	0	1
11/05/2021 17:00	0.0	0	0	0	0	1
11/05/2021 18:00	0.0	0	0	0	0	1
11/05/2021 19:00	0.0	0	0	0	0	1
11/05/2021 20:00	0.0	0	0	0	0	1
11/05/2021 21:00	0.0	0	0	0	0	1
11/05/2021 22:00	0.0	0	0	0	0	1
11/05/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	39.9 #	0 #	2 #	0 #	0 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	20.5	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/06/2021 00:00	0.0	0	0	0	0	1
11/06/2021 01:00	0.0	0	0	0	0	1
11/06/2021 02:00	0.0	0	0	0	0	1
11/06/2021 03:00	0.0	0	0	0	0	1
11/06/2021 04:00	0.0	0	0	0	0	1
11/06/2021 05:00	0.0	0	0	0	0	1
11/06/2021 06:00	0.0	0	0	0	0	1
11/06/2021 07:00	0.0	0	0	0	0	1
11/06/2021 08:00	0.0	0	0	0	0	1
11/06/2021 09:00	0.0	0	0	0	0	1
11/06/2021 10:00	0.0	0	0	0	0	1
11/06/2021 11:00	0.0	0	0	0	0	1
11/06/2021 12:00	0.0	0	0	0	0	1
11/06/2021 13:00	0.0	0	0	0	0	1
11/06/2021 14:00	0.0	0	0	0	0	1
11/06/2021 15:00	0.0	0	0	0	0	1
11/06/2021 16:00	0.0	0	0	0	0	1
11/06/2021 17:00	0.0	0	0	0	0	1
11/06/2021 18:00	0.0	0	0	0	0	1
11/06/2021 19:00	0.0	0	0	0	0	1
11/06/2021 20:00	0.0	0	0	0	0	1
11/06/2021 21:00	0.0	0	0	0	0	1
11/06/2021 22:00	1.1	0	0	0	1	0
11/06/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.1 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.1	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/07/2021 00:00	0.0	0	0	0	0	0
11/07/2021 01:00	0.0	0	0	0	0	0
11/07/2021 02:00	0.0	0	0	0	0	0
11/07/2021 03:00	0.0	0	0	0	0	0
11/07/2021 04:00	0.0	0	0	0	0	0
11/07/2021 05:00	0.0	0	0	0	0	0
11/07/2021 06:00	0.0	0	0	0	0	0
11/07/2021 07:00	0.0	0	0	0	0	0
11/07/2021 08:00	0.0	0	0	0	0	0
11/07/2021 09:00	0.0	0	0	0	0	0
11/07/2021 10:00	0.0	0	0	0	0	0
11/07/2021 11:00	0.0	0	0	0	0	0
11/07/2021 12:00	0.0	0	0	0	0	0
11/07/2021 13:00	0.0	0	0	0	0	0
11/07/2021 14:00	0.0	0	0	0	0	0
11/07/2021 15:00	0.0	0	0	0	0	0
11/07/2021 16:00	0.0	0	0	0	0	0
11/07/2021 17:00	0.0	0	0	0	0	0
11/07/2021 18:00	0.0	0	0	0	0	0
11/07/2021 19:00	0.0	0	0	0	0	0
11/07/2021 20:00	0.0	0	0	0	0	0
11/07/2021 21:00	0.0	0	0	0	0	0
11/07/2021 22:00	0.0	0	0	0	0	0
11/07/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/08/2021 00:00	0.0	0	0	0	0	0
11/08/2021 01:00	0.0	0	0	0	0	0
11/08/2021 02:00	0.0	0	0	0	0	0
11/08/2021 03:00	0.0	0	0	0	0	0
11/08/2021 04:00	0.0	0	0	0	0	0
11/08/2021 05:00	0.0	0	0	0	0	0
11/08/2021 06:00	0.0	0	0	0	0	0
11/08/2021 07:00	0.0	0	0	0	0	0
11/08/2021 08:00	0.0	0	0	0	0	0
11/08/2021 09:00	0.0	0	0	0	0	0
11/08/2021 10:00	0.0	0	0	0	0	0
11/08/2021 11:00	0.0	0	0	0	0	0
11/08/2021 12:00	57.9	0	1	0	0	0
11/08/2021 13:00	45.7	0	1	0	0	0
11/08/2021 14:00	71.1	0	1	0	0	0
11/08/2021 15:00	0.0	0	0	0	0	1
11/08/2021 16:00	0.0	0	0	0	0	1
11/08/2021 17:00	0.0	0	0	0	0	1
11/08/2021 18:00	0.0	0	0	0	0	1
11/08/2021 19:00	0.0	0	0	0	0	1
11/08/2021 20:00	0.0	0	0	0	0	1
11/08/2021 21:00	0.0	0	0	0	0	1
11/08/2021 22:00	0.0	0	0	0	0	1
11/08/2021 23:00	2.2	0	0	0	1	0
Average/Sum#:	176.9 #	0 #	3 #	0 #	1 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	71.1	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/09/2021 00:00	0.0	0	0	0	0	0
11/09/2021 01:00	0.0	0	0	0	0	0
11/09/2021 02:00	0.0	0	0	0	0	0
11/09/2021 03:00	8.6	0	0	1	0	0
11/09/2021 04:00	55.3	0	0	1	0	0
11/09/2021 05:00	0.0	0	0	0	0	1
11/09/2021 06:00	0.0	0	0	0	0	1
11/09/2021 07:00	0.0	0	0	0	0	1
11/09/2021 08:00	0.0	0	0	0	0	1
11/09/2021 09:00	0.0	0	0	0	0	1
11/09/2021 10:00	0.0	0	0	0	0	1
11/09/2021 11:00	0.0	0	0	0	0	1
11/09/2021 12:00	0.0	0	0	0	0	1
11/09/2021 13:00	0.0	0	0	0	0	1
11/09/2021 14:00	0.0	0	0	0	0	1
11/09/2021 15:00	0.0	0	0	0	0	1
11/09/2021 16:00	0.0	0	0	0	0	1
11/09/2021 17:00	0.0	0	0	0	0	1
11/09/2021 18:00	0.0	0	0	0	0	1
11/09/2021 19:00	0.0	0	0	0	0	1
11/09/2021 20:00	0.0	0	0	0	0	1
11/09/2021 21:00	0.0	0	0	0	0	1
11/09/2021 22:00	0.0	0	0	0	0	1
11/09/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	63.9 #	0 #	0 #	2 #	0 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	55.3	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/10/2021 00:00	0.0	0	0	0	0	1
11/10/2021 01:00	0.0	0	0	0	0	1
11/10/2021 02:00	0.0	0	0	0	0	1
11/10/2021 03:00	0.0	0	0	0	0	1
11/10/2021 04:00	0.0	0	0	0	0	1
11/10/2021 05:00	0.0	0	0	0	0	1
11/10/2021 06:00	0.0	0	0	0	0	1
11/10/2021 07:00	0.0	0	0	0	0	1
11/10/2021 08:00	0.0	0	0	0	0	1
11/10/2021 09:00	0.0	0	0	0	0	1
11/10/2021 10:00	0.0	0	0	0	0	1
11/10/2021 11:00	0.0	0	0	0	0	1
11/10/2021 12:00	0.0	0	0	0	0	1
11/10/2021 13:00	0.0	0	0	0	0	1
11/10/2021 14:00	0.0	0	0	0	0	1
11/10/2021 15:00	0.0	0	0	0	0	1
11/10/2021 16:00	0.0	0	0	0	0	1
11/10/2021 17:00	0.0	0	0	0	0	1
11/10/2021 18:00	0.0	0	0	0	0	1
11/10/2021 19:00	0.0	0	0	0	0	1
11/10/2021 20:00	0.0	0	0	0	0	1
11/10/2021 21:00	0.0	0	0	0	0	1
11/10/2021 22:00	0.0	0	0	0	0	1
11/10/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/11/2021 00:00	0.0	0	0	0	0	1
11/11/2021 01:00	2.3	0	0	0	1	0
11/11/2021 02:00	0.0	0	0	0	0	0
11/11/2021 03:00	0.0	0	0	0	0	0
11/11/2021 04:00	0.0	0	0	0	0	0
11/11/2021 05:00	0.0	0	0	0	0	0
11/11/2021 06:00	0.0	0	0	0	0	0
11/11/2021 07:00	0.0	0	0	0	0	0
11/11/2021 08:00	0.0	0	0	0	0	0
11/11/2021 09:00	0.0	0	0	0	0	0
11/11/2021 10:00	0.0	0	0	0	0	0
11/11/2021 11:00	0.0	0	0	0	0	0
11/11/2021 12:00	0.0	0	0	0	0	0
11/11/2021 13:00	21.6	0	1	0	0	0
11/11/2021 14:00	54.4	0	1	0	0	0
11/11/2021 15:00	0.0	0	0	0	0	1
11/11/2021 16:00	0.0	0	0	0	0	1
11/11/2021 17:00	0.0	0	0	0	0	1
11/11/2021 18:00	0.0	0	0	0	0	1
11/11/2021 19:00	0.0	0	0	0	0	1
11/11/2021 20:00	0.0	0	0	0	0	1
11/11/2021 21:00	0.0	0	0	0	0	1
11/11/2021 22:00	0.0	0	0	0	0	1
11/11/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	78.3 #	0 #	2 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	54.4	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/12/2021 00:00	0.0	0	0	0	0	1
11/12/2021 01:00	0.0	0	0	0	0	1
11/12/2021 02:00	0.0	0	0	0	0	1
11/12/2021 03:00	0.0	0	0	0	0	1
11/12/2021 04:00	0.0	0	0	0	0	1
11/12/2021 05:00	0.0	0	0	0	0	1
11/12/2021 06:00	0.0	0	0	0	0	1
11/12/2021 07:00	0.0	0	0	0	0	1
11/12/2021 08:00	2.2	0	0	0	1	0
11/12/2021 09:00	0.0	0	0	0	0	0
11/12/2021 10:00	0.0	0	0	0	0	0
11/12/2021 11:00	0.0	0	0	0	0	0
11/12/2021 12:00	0.0	0	0	0	0	0
11/12/2021 13:00	0.0	0	0	0	0	0
11/12/2021 14:00	0.0	0	0	0	0	0
11/12/2021 15:00	13.4	0	0	1	0	0
11/12/2021 16:00	62.7	0	0	1	0	0
11/12/2021 17:00	0.0	0	0	0	0	1
11/12/2021 18:00	0.0	0	0	0	0	1
11/12/2021 19:00	0.0	0	0	0	0	1
11/12/2021 20:00	0.0	0	0	0	0	1
11/12/2021 21:00	0.0	0	0	0	0	1
11/12/2021 22:00	0.0	0	0	0	0	1
11/12/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	78.3 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	62.7	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/13/2021 00:00	2.0	0	0	0	1	0
11/13/2021 01:00	0.0	0	0	0	0	0
11/13/2021 02:00	0.0	0	0	0	0	0
11/13/2021 03:00	0.0	0	0	0	0	0
11/13/2021 04:00	0.0	0	0	0	0	0
11/13/2021 05:00	0.0	0	0	0	0	0
11/13/2021 06:00	0.0	0	0	0	0	0
11/13/2021 07:00	0.0	0	0	0	0	0
11/13/2021 08:00	0.0	0	0	0	0	0
11/13/2021 09:00	0.0	0	0	0	0	0
11/13/2021 10:00	0.0	0	0	0	0	0
11/13/2021 11:00	0.0	0	0	0	0	0
11/13/2021 12:00	0.0	0	0	0	0	0
11/13/2021 13:00	22.3	0	1	0	0	0
11/13/2021 14:00	33.2	0	1	0	0	0
11/13/2021 15:00	0.0	0	0	0	0	1
11/13/2021 16:00	0.0	0	0	0	0	1
11/13/2021 17:00	0.0	0	0	0	0	1
11/13/2021 18:00	0.0	0	0	0	0	1
11/13/2021 19:00	0.0	0	0	0	0	1
11/13/2021 20:00	0.0	0	0	0	0	1
11/13/2021 21:00	0.0	0	0	0	0	1
11/13/2021 22:00	1.6	0	0	0	1	0
11/13/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	59.1 #	0 #	2 #	0 #	2 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	33.2	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/14/2021 00:00	0.0	0	0	0	0	0
11/14/2021 01:00	0.0	0	0	0	0	0
11/14/2021 02:00	0.0	0	0	0	0	0
11/14/2021 03:00	0.0	0	0	0	0	0
11/14/2021 04:00	0.0	0	0	0	0	0
11/14/2021 05:00	0.0	0	0	0	0	0
11/14/2021 06:00	0.0	0	0	0	0	0
11/14/2021 07:00	0.0	0	0	0	0	0
11/14/2021 08:00	0.0	0	0	0	0	0
11/14/2021 09:00	0.0	0	0	0	0	0
11/14/2021 10:00	0.0	0	0	0	0	0
11/14/2021 11:00	0.0	0	0	0	0	0
11/14/2021 12:00	0.0	0	0	0	0	0
11/14/2021 13:00	0.0	0	0	0	0	0
11/14/2021 14:00	22.6	0	1	0	0	0
11/14/2021 15:00	63.3	0	1	0	0	0
11/14/2021 16:00	0.0	0	0	0	0	1
11/14/2021 17:00	0.0	0	0	0	0	1
11/14/2021 18:00	0.0	0	0	0	0	1
11/14/2021 19:00	0.0	0	0	0	0	1
11/14/2021 20:00	0.0	0	0	0	0	1
11/14/2021 21:00	0.0	0	0	0	0	1
11/14/2021 22:00	0.0	0	0	0	0	1
11/14/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	85.9 #	0 #	2 #	0 #	0 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	63.3	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/15/2021 00:00	1.8	0	0	0	1	0
11/15/2021 01:00	0.0	0	0	0	0	0
11/15/2021 02:00	0.0	0	0	0	0	0
11/15/2021 03:00	0.0	0	0	0	0	0
11/15/2021 04:00	0.0	0	0	0	0	0
11/15/2021 05:00	0.0	0	0	0	0	0
11/15/2021 06:00	0.0	0	0	0	0	0
11/15/2021 07:00	16.0	0	0	1	0	0
11/15/2021 08:00	80.1	0	0	1	0	0
11/15/2021 09:00	0.0	0	0	0	0	1
11/15/2021 10:00	0.0	0	0	0	0	1
11/15/2021 11:00	0.0	0	0	0	0	1
11/15/2021 12:00	0.0	0	0	0	0	1
11/15/2021 13:00	0.0	0	0	0	0	1
11/15/2021 14:00	0.0	0	0	0	0	1
11/15/2021 15:00	0.0	0	0	0	0	1
11/15/2021 16:00	0.0	0	0	0	0	1
11/15/2021 17:00	0.0	0	0	0	0	1
11/15/2021 18:00	0.0	0	0	0	0	1
11/15/2021 19:00	0.0	0	0	0	0	1
11/15/2021 20:00	0.0	0	0	0	0	1
11/15/2021 21:00	0.0	0	0	0	0	1
11/15/2021 22:00	0.0	0	0	0	0	1
11/15/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	97.9 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	80.1	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/16/2021 00:00	3.3	0	0	0	1	0
11/16/2021 01:00	0.0	0	0	0	0	0
11/16/2021 02:00	0.0	0	0	0	0	0
11/16/2021 03:00	0.0	0	0	0	0	0
11/16/2021 04:00	0.0	0	0	0	0	0
11/16/2021 05:00	0.0	0	0	0	0	0
11/16/2021 06:00	0.0	0	0	0	0	0
11/16/2021 07:00	0.0	0	0	0	0	0
11/16/2021 08:00	0.0	0	0	0	0	0
11/16/2021 09:00	0.0	0	0	0	0	0
11/16/2021 10:00	0.0	0	0	0	0	0
11/16/2021 11:00	0.0	0	0	0	0	0
11/16/2021 12:00	0.0	0	0	0	0	0
11/16/2021 13:00	12.2	0	1	0	0	0
11/16/2021 14:00	66.0	0	1	0	0	0
11/16/2021 15:00	9.5	0	1	0	0	0
11/16/2021 16:00	0.0	0	0	0	0	1
11/16/2021 17:00	0.0	0	0	0	0	1
11/16/2021 18:00	0.0	0	0	0	0	1
11/16/2021 19:00	0.0	0	0	0	0	1
11/16/2021 20:00	0.0	0	0	0	0	1
11/16/2021 21:00	0.0	0	0	0	0	1
11/16/2021 22:00	0.0	0	0	0	0	1
11/16/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	91.0 #	0 #	3 #	0 #	1 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	66.0	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/17/2021 00:00	0.0	0	0	0	0	1
11/17/2021 01:00	0.0	0	0	0	0	1
11/17/2021 02:00	0.0	0	0	0	0	1
11/17/2021 03:00	0.0	0	0	0	0	1
11/17/2021 04:00	0.0	0	0	0	0	1
11/17/2021 05:00	0.0	0	0	0	0	1
11/17/2021 06:00	0.0	0	0	0	0	1
11/17/2021 07:00	0.0	0	0	0	0	1
11/17/2021 08:00	0.0	0	0	0	0	1
11/17/2021 09:00	0.0	0	0	0	0	1
11/17/2021 10:00	0.0	0	0	0	0	1
11/17/2021 11:00	0.0	0	0	0	0	1
11/17/2021 12:00	0.0	0	0	0	0	1
11/17/2021 13:00	0.0	0	0	0	0	1
11/17/2021 14:00	0.0	0	0	0	0	1
11/17/2021 15:00	0.0	0	0	0	0	1
11/17/2021 16:00	0.0	0	0	0	0	1
11/17/2021 17:00	0.0	0	0	0	0	1
11/17/2021 18:00	0.0	0	0	0	0	1
11/17/2021 19:00	0.0	0	0	0	0	1
11/17/2021 20:00	0.0	0	0	0	0	1
11/17/2021 21:00	0.0	0	0	0	0	1
11/17/2021 22:00	0.0	0	0	0	0	1
11/17/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/18/2021 00:00	0.0	0	0	0	0	1
11/18/2021 01:00	0.0	0	0	0	0	1
11/18/2021 02:00	0.0	0	0	0	0	1
11/18/2021 03:00	0.0	0	0	0	0	1
11/18/2021 04:00	0.0	0	0	0	0	1
11/18/2021 05:00	0.0	0	0	0	0	1
11/18/2021 06:00	0.0	0	0	0	0	1
11/18/2021 07:00	0.0	0	0	0	0	1
11/18/2021 08:00	0.0	0	0	0	0	1
11/18/2021 09:00	0.0	0	0	0	0	1
11/18/2021 10:00	0.0	0	0	0	0	1
11/18/2021 11:00	0.0	0	0	0	0	1
11/18/2021 12:00	0.0	0	0	0	0	1
11/18/2021 13:00	0.0	0	0	0	0	1
11/18/2021 14:00	0.0	0	0	0	0	1
11/18/2021 15:00	0.0	0	0	0	0	1
11/18/2021 16:00	0.0	0	0	0	0	1
11/18/2021 17:00	0.0	0	0	0	0	1
11/18/2021 18:00	0.0	0	0	0	0	1
11/18/2021 19:00	0.0	0	0	0	0	1
11/18/2021 20:00	0.0	0	0	0	0	1
11/18/2021 21:00	0.0	0	0	0	0	1
11/18/2021 22:00	0.0	0	0	0	0	1
11/18/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/19/2021 00:00	0.0	0	0	0	0	1
11/19/2021 01:00	0.0	0	0	0	0	1
11/19/2021 02:00	0.0	0	0	0	0	1
11/19/2021 03:00	0.0	0	0	0	0	1
11/19/2021 04:00	0.0	0	0	0	0	1
11/19/2021 05:00	0.0	0	0	0	0	1
11/19/2021 06:00	0.0	0	0	0	0	1
11/19/2021 07:00	0.0	0	0	0	0	1
11/19/2021 08:00	0.0	0	0	0	0	1
11/19/2021 09:00	0.0	0	0	0	0	1
11/19/2021 10:00	0.0	0	0	0	0	1
11/19/2021 11:00	0.0	0	0	0	0	1
11/19/2021 12:00	0.0	0	0	0	0	1
11/19/2021 13:00	0.0	0	0	0	0	1
11/19/2021 14:00	0.0	0	0	0	0	1
11/19/2021 15:00	0.0	0	0	0	0	1
11/19/2021 16:00	0.0	0	0	0	0	1
11/19/2021 17:00	0.0	0	0	0	0	1
11/19/2021 18:00	0.0	0	0	0	0	1
11/19/2021 19:00	0.0	0	0	0	0	1
11/19/2021 20:00	0.0	0	0	0	0	1
11/19/2021 21:00	0.0	0	0	0	0	1
11/19/2021 22:00	0.0	0	0	0	0	1
11/19/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/20/2021 00:00	0.0	0	0	0	0	1
11/20/2021 01:00	0.0	0	0	0	0	1
11/20/2021 02:00	0.0	0	0	0	0	1
11/20/2021 03:00	0.0	0	0	0	0	1
11/20/2021 04:00	0.0	0	0	0	0	1
11/20/2021 05:00	0.0	0	0	0	0	1
11/20/2021 06:00	0.0	0	0	0	0	1
11/20/2021 07:00	0.0	0	0	0	0	1
11/20/2021 08:00	0.0	0	0	0	0	1
11/20/2021 09:00	0.0	0	0	0	0	1
11/20/2021 10:00	0.0	0	0	0	0	1
11/20/2021 11:00	0.0	0	0	0	0	1
11/20/2021 12:00	0.0	0	0	0	0	1
11/20/2021 13:00	0.0	0	0	0	0	1
11/20/2021 14:00	0.0	0	0	0	0	1
11/20/2021 15:00	0.0	0	0	0	0	1
11/20/2021 16:00	0.0	0	0	0	0	1
11/20/2021 17:00	0.0	0	0	0	0	1
11/20/2021 18:00	0.0	0	0	0	0	1
11/20/2021 19:00	0.0	0	0	0	0	1
11/20/2021 20:00	0.0	0	0	0	0	1
11/20/2021 21:00	0.0	0	0	0	0	1
11/20/2021 22:00	0.0	0	0	0	0	1
11/20/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/21/2021 00:00	0.0	0	0	0	0	1
11/21/2021 01:00	0.0	0	0	0	0	1
11/21/2021 02:00	0.8	0	0	0	1	0
11/21/2021 03:00	0.0	0	0	0	0	0
11/21/2021 04:00	0.0	0	0	0	0	0
11/21/2021 05:00	0.0	0	0	0	0	0
11/21/2021 06:00	0.0	0	0	0	0	0
11/21/2021 07:00	0.0	0	0	0	0	0
11/21/2021 08:00	0.0	0	0	0	0	0
11/21/2021 09:00	0.0	0	0	0	0	0
11/21/2021 10:00	0.0	0	0	0	0	0
11/21/2021 11:00	0.0	0	0	0	0	0
11/21/2021 12:00	0.0	0	0	0	0	0
11/21/2021 13:00	0.0	0	0	0	0	0
11/21/2021 14:00	11.9	0	1	0	0	0
11/21/2021 15:00	38.0	0	1	0	0	0
11/21/2021 16:00	0.0	0	0	0	0	1
11/21/2021 17:00	0.0	0	0	0	0	1
11/21/2021 18:00	0.0	0	0	0	0	1
11/21/2021 19:00	0.0	0	0	0	0	1
11/21/2021 20:00	0.0	0	0	0	0	1
11/21/2021 21:00	0.0	0	0	0	0	1
11/21/2021 22:00	0.0	0	0	0	0	1
11/21/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	50.7 #	0 #	2 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	38.0	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/22/2021 00:00	1.8	0	0	0	1	0
11/22/2021 01:00	0.0	0	0	0	0	0
11/22/2021 02:00	0.0	0	0	0	0	0
11/22/2021 03:00	0.0	0	0	0	0	0
11/22/2021 04:00	0.0	0	0	0	0	0
11/22/2021 05:00	0.0	0	0	0	0	0
11/22/2021 06:00	0.0	0	0	0	0	0
11/22/2021 07:00	0.0	0	0	0	0	0
11/22/2021 08:00	0.0	0	0	0	0	0
11/22/2021 09:00	0.0	0	0	0	0	0
11/22/2021 10:00	0.0	0	0	0	0	0
11/22/2021 11:00	0.0	0	0	0	0	0
11/22/2021 12:00	23.2	0	1	0	0	0
11/22/2021 13:00	30.8	0	1	0	0	0
11/22/2021 14:00	0.0	0	0	0	0	1
11/22/2021 15:00	0.0	0	0	0	0	1
11/22/2021 16:00	0.0	0	0	0	0	1
11/22/2021 17:00	0.0	0	0	0	0	1
11/22/2021 18:00	0.0	0	0	0	0	1
11/22/2021 19:00	0.0	0	0	0	0	1
11/22/2021 20:00	0.0	0	0	0	0	1
11/22/2021 21:00	0.0	0	0	0	0	1
11/22/2021 22:00	0.0	0	0	0	0	1
11/22/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	55.8 #	0 #	2 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	30.8	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/23/2021 00:00	0.0	0	0	0	0	1
11/23/2021 01:00	0.0	0	0	0	0	1
11/23/2021 02:00	0.0	0	0	0	0	1
11/23/2021 03:00	0.0	0	0	0	0	1
11/23/2021 04:00	0.0	0	0	0	0	1
11/23/2021 05:00	0.0	0	0	0	0	1
11/23/2021 06:00	0.0	0	0	0	0	1
11/23/2021 07:00	0.0	0	0	0	0	1
11/23/2021 08:00	0.0	0	0	0	0	1
11/23/2021 09:00	0.0	0	0	0	0	1
11/23/2021 10:00	0.0	0	0	0	0	1
11/23/2021 11:00	0.0	0	0	0	0	1
11/23/2021 12:00	0.0	0	0	0	0	1
11/23/2021 13:00	0.0	0	0	0	0	1
11/23/2021 14:00	0.0	0	0	0	0	1
11/23/2021 15:00	0.0	0	0	0	0	1
11/23/2021 16:00	0.0	0	0	0	0	1
11/23/2021 17:00	0.0	0	0	0	0	1
11/23/2021 18:00	0.0	0	0	0	0	1
11/23/2021 19:00	0.0	0	0	0	0	1
11/23/2021 20:00	0.0	0	0	0	0	1
11/23/2021 21:00	0.0	0	0	0	0	1
11/23/2021 22:00	0.0	0	0	0	0	1
11/23/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/24/2021 00:00	0.0	0	0	0	0	1
11/24/2021 01:00	0.0	0	0	0	0	1
11/24/2021 02:00	0.0	0	0	0	0	1
11/24/2021 03:00	0.0	0	0	0	0	1
11/24/2021 04:00	0.0	0	0	0	0	1
11/24/2021 05:00	0.0	0	0	0	0	1
11/24/2021 06:00	0.0	0	0	0	0	1
11/24/2021 07:00	0.0	0	0	0	0	1
11/24/2021 08:00	0.0	0	0	0	0	1
11/24/2021 09:00	0.0	0	0	0	0	1
11/24/2021 10:00	0.0	0	0	0	0	1
11/24/2021 11:00	0.0	0	0	0	0	1
11/24/2021 12:00	0.0	0	0	0	0	1
11/24/2021 13:00	0.0	0	0	0	0	1
11/24/2021 14:00	0.0	0	0	0	0	1
11/24/2021 15:00	0.0	0	0	0	0	1
11/24/2021 16:00	0.0	0	0	0	0	1
11/24/2021 17:00	0.0	0	0	0	0	1
11/24/2021 18:00	0.0	0	0	0	0	1
11/24/2021 19:00	0.0	0	0	0	0	1
11/24/2021 20:00	0.0	0	0	0	0	1
11/24/2021 21:00	0.0	0	0	0	0	1
11/24/2021 22:00	0.0	0	0	0	0	1
11/24/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/25/2021 00:00	2.0	0	0	0	1	0
11/25/2021 01:00	0.0	0	0	0	0	0
11/25/2021 02:00	0.0	0	0	0	0	0
11/25/2021 03:00	0.0	0	0	0	0	0
11/25/2021 04:00	0.0	0	0	0	0	0
11/25/2021 05:00	0.0	0	0	0	0	0
11/25/2021 06:00	0.0	0	0	0	0	0
11/25/2021 07:00	0.0	0	0	0	0	0
11/25/2021 08:00	0.0	0	0	0	0	0
11/25/2021 09:00	0.0	0	0	0	0	0
11/25/2021 10:00	0.0	0	0	0	0	0
11/25/2021 11:00	0.0	0	0	0	0	0
11/25/2021 12:00	0.0	0	0	0	0	0
11/25/2021 13:00	0.0	0	0	0	0	0
11/25/2021 14:00	0.0	0	0	0	0	0
11/25/2021 15:00	0.0	0	0	0	0	0
11/25/2021 16:00	0.0	0	0	0	0	0
11/25/2021 17:00	0.0	0	0	0	0	0
11/25/2021 18:00	0.0	0	0	0	0	0
11/25/2021 19:00	0.0	0	0	0	0	0
11/25/2021 20:00	0.0	0	0	0	0	0
11/25/2021 21:00	0.0	0	0	0	0	0
11/25/2021 22:00	0.0	0	0	0	0	0
11/25/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	2.0 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.0	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/26/2021 00:00	0.0	0	0	0	0	0
11/26/2021 01:00	0.0	0	0	0	0	0
11/26/2021 02:00	0.0	0	0	0	0	0
11/26/2021 03:00	0.0	0	0	0	0	0
11/26/2021 04:00	0.0	0	0	0	0	0
11/26/2021 05:00	0.0	0	0	0	0	0
11/26/2021 06:00	0.0	0	0	0	0	0
11/26/2021 07:00	0.0	0	0	0	0	0
11/26/2021 08:00	0.0	0	0	0	0	0
11/26/2021 09:00	0.0	0	0	0	0	0
11/26/2021 10:00	0.0	0	0	0	0	0
11/26/2021 11:00	0.0	0	0	0	0	0
11/26/2021 12:00	0.0	0	0	0	0	0
11/26/2021 13:00	0.0	0	0	0	0	0
11/26/2021 14:00	0.0	0	0	0	0	0
11/26/2021 15:00	0.0	0	0	0	0	0
11/26/2021 16:00	0.0	0	0	0	0	0
11/26/2021 17:00	0.0	0	0	0	0	0
11/26/2021 18:00	0.0	0	0	0	0	0
11/26/2021 19:00	0.0	0	0	0	0	0
11/26/2021 20:00	0.0	0	0	0	0	0
11/26/2021 21:00	0.0	0	0	0	0	0
11/26/2021 22:00	0.0	0	0	0	0	0
11/26/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/27/2021 00:00	0.0	0	0	0	0	0
11/27/2021 01:00	0.0	0	0	0	0	0
11/27/2021 02:00	0.0	0	0	0	0	0
11/27/2021 03:00	0.0	0	0	0	0	0
11/27/2021 04:00	0.0	0	0	0	0	0
11/27/2021 05:00	0.0	0	0	0	0	0
11/27/2021 06:00	0.0	0	0	0	0	0
11/27/2021 07:00	0.0	0	0	0	0	0
11/27/2021 08:00	0.0	0	0	0	0	0
11/27/2021 09:00	0.0	0	0	0	0	0
11/27/2021 10:00	0.0	0	0	0	0	0
11/27/2021 11:00	0.0	0	0	0	0	0
11/27/2021 12:00	0.0	0	0	0	0	0
11/27/2021 13:00	0.0	0	0	0	0	0
11/27/2021 14:00	0.0	0	0	0	0	0
11/27/2021 15:00	0.0	0	0	0	0	0
11/27/2021 16:00	0.0	0	0	0	0	0
11/27/2021 17:00	0.0	0	0	0	0	0
11/27/2021 18:00	0.0	0	0	0	0	0
11/27/2021 19:00	0.0	0	0	0	0	0
11/27/2021 20:00	0.0	0	0	0	0	0
11/27/2021 21:00	0.0	0	0	0	0	0
11/27/2021 22:00	0.0	0	0	0	0	0
11/27/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/28/2021 00:00	0.0	0	0	0	0	0
11/28/2021 01:00	0.0	0	0	0	0	0
11/28/2021 02:00	0.0	0	0	0	0	0
11/28/2021 03:00	0.0	0	0	0	0	0
11/28/2021 04:00	0.0	0	0	0	0	0
11/28/2021 05:00	0.0	0	0	0	0	0
11/28/2021 06:00	0.0	0	0	0	0	0
11/28/2021 07:00	0.0	0	0	0	0	0
11/28/2021 08:00	0.0	0	0	0	0	0
11/28/2021 09:00	0.0	0	0	0	0	0
11/28/2021 10:00	0.0	0	0	0	0	0
11/28/2021 11:00	0.0	0	0	0	0	0
11/28/2021 12:00	0.0	0	0	0	0	0
11/28/2021 13:00	0.0	0	0	0	0	0
11/28/2021 14:00	0.0	0	0	0	0	0
11/28/2021 15:00	0.0	0	0	0	0	0
11/28/2021 16:00	0.0	0	0	0	0	0
11/28/2021 17:00	0.0	0	0	0	0	0
11/28/2021 18:00	0.0	0	0	0	0	0
11/28/2021 19:00	0.0	0	0	0	0	0
11/28/2021 20:00	0.0	0	0	0	0	0
11/28/2021 21:00	0.0	0	0	0	0	0
11/28/2021 22:00	0.0	0	0	0	0	0
11/28/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/29/2021 00:00	0.0	0	0	0	0	0
11/29/2021 01:00	0.0	0	0	0	0	0
11/29/2021 02:00	0.0	0	0	0	0	0
11/29/2021 03:00	0.0	0	0	0	0	0
11/29/2021 04:00	0.0	0	0	0	0	0
11/29/2021 05:00	0.0	0	0	0	0	0
11/29/2021 06:00	0.0	0	0	0	0	0
11/29/2021 07:00	0.0	0	0	0	0	0
11/29/2021 08:00	0.0	0	0	0	0	0
11/29/2021 09:00	0.0	0	0	0	0	0
11/29/2021 10:00	0.0	0	0	0	0	0
11/29/2021 11:00	0.0	0	0	0	0	0
11/29/2021 12:00	0.0	0	0	0	0	0
11/29/2021 13:00	0.0	0	0	0	0	0
11/29/2021 14:00	67.7	1	0	0	0	0
11/29/2021 15:00	34.1	1	0	0	0	0
11/29/2021 16:00	0.0	0	0	0	0	1
11/29/2021 17:00	0.0	0	0	0	0	1
11/29/2021 18:00	0.0	0	0	0	0	1
11/29/2021 19:00	0.0	0	0	0	0	1
11/29/2021 20:00	0.0	0	0	0	0	1
11/29/2021 21:00	0.0	0	0	0	0	1
11/29/2021 22:00	0.0	0	0	0	0	1
11/29/2021 23:00	1.6	0	0	0	1	0
Average/Sum#:	103.4 #	2 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	67.7	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/30/2021 00:00	0.0	0	0	0	0	0
11/30/2021 01:00	0.0	0	0	0	0	0
11/30/2021 02:00	0.0	0	0	0	0	0
11/30/2021 03:00	0.0	0	0	0	0	0
11/30/2021 04:00	0.0	0	0	0	0	0
11/30/2021 05:00	0.0	0	0	0	0	0
11/30/2021 06:00	0.0	0	0	0	0	0
11/30/2021 07:00	0.0	0	0	0	0	0
11/30/2021 08:00	10.4	0	1	0	0	0
11/30/2021 09:00	36.2	0	1	0	0	0
11/30/2021 10:00	0.0	0	0	0	0	1
11/30/2021 11:00	0.0	0	0	0	0	1
11/30/2021 12:00	0.0	0	0	0	0	1
11/30/2021 13:00	0.0	0	0	0	0	1
11/30/2021 14:00	0.0	0	0	0	0	1
11/30/2021 15:00	0.0	0	0	0	0	1
11/30/2021 16:00	0.0	0	0	0	0	1
11/30/2021 17:00	0.0	0	0	0	0	1
11/30/2021 18:00	0.0	0	0	0	0	1
11/30/2021 19:00	0.0	0	0	0	0	1
11/30/2021 20:00	0.0	0	0	0	0	1
11/30/2021 21:00	0.0	0	0	0	0	1
11/30/2021 22:00	0.0	0	0	0	0	1
11/30/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	46.6 #	0 #	2 #	0 #	0 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	36.2	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/01/2021 00:00	0.0	0	0	0	0	1
12/01/2021 01:00	0.0	0	0	0	0	1
12/01/2021 02:00	0.0	0	0	0	0	1
12/01/2021 03:00	0.0	0	0	0	0	1
12/01/2021 04:00	0.0	0	0	0	0	1
12/01/2021 05:00	0.0	0	0	0	0	1
12/01/2021 06:00	0.0	0	0	0	0	1
12/01/2021 07:00	0.0	0	0	0	0	1
12/01/2021 08:00	0.0	0	0	0	0	1
12/01/2021 09:00	0.0	0	0	0	0	1
12/01/2021 10:00	0.0	0	0	0	0	1
12/01/2021 11:00	0.0	0	0	0	0	1
12/01/2021 12:00	0.0	0	0	0	0	1
12/01/2021 13:00	0.0	0	0	0	0	1
12/01/2021 14:00	0.0	0	0	0	0	1
12/01/2021 15:00	0.0	0	0	0	0	1
12/01/2021 16:00	0.0	0	0	0	0	1
12/01/2021 17:00	0.0	0	0	0	0	1
12/01/2021 18:00	0.0	0	0	0	0	1
12/01/2021 19:00	0.0	0	0	0	0	1
12/01/2021 20:00	0.0	0	0	0	0	1
12/01/2021 21:00	0.0	0	0	0	0	1
12/01/2021 22:00	0.0	0	0	0	0	1
12/01/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/02/2021 00:00	1.9	0	0	0	1	0
12/02/2021 01:00	0.0	0	0	0	0	0
12/02/2021 02:00	0.0	0	0	0	0	0
12/02/2021 03:00	0.0	0	0	0	0	0
12/02/2021 04:00	56.1	0	0	1	0	0
12/02/2021 05:00	0.0	0	0	0	0	1
12/02/2021 06:00	0.0	0	0	0	0	1
12/02/2021 07:00	0.0	0	0	0	0	1
12/02/2021 08:00	0.0	0	0	0	0	1
12/02/2021 09:00	0.0	0	0	0	0	1
12/02/2021 10:00	0.0	0	0	0	0	1
12/02/2021 11:00	0.0	0	0	0	0	1
12/02/2021 12:00	0.0	0	0	0	0	1
12/02/2021 13:00	0.0	0	0	0	0	1
12/02/2021 14:00	0.0	0	0	0	0	1
12/02/2021 15:00	0.0	0	0	0	0	1
12/02/2021 16:00	0.0	0	0	0	0	1
12/02/2021 17:00	0.0	0	0	0	0	1
12/02/2021 18:00	0.0	0	0	0	0	1
12/02/2021 19:00	0.0	0	0	0	0	1
12/02/2021 20:00	0.0	0	0	0	0	1
12/02/2021 21:00	0.0	0	0	0	0	1
12/02/2021 22:00	0.0	0	0	0	0	1
12/02/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	58.0 #	0 #	0 #	1 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	56.1	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/03/2021 00:00	1.1	0	0	0	1	0
12/03/2021 01:00	0.0	0	0	0	0	0
12/03/2021 02:00	0.0	0	0	0	0	0
12/03/2021 03:00	2.4	0	0	1	0	0
12/03/2021 04:00	60.2	0	0	1	0	0
12/03/2021 05:00	0.0	0	0	0	0	1
12/03/2021 06:00	0.0	0	0	0	0	1
12/03/2021 07:00	0.0	0	0	0	0	1
12/03/2021 08:00	0.0	0	0	0	0	1
12/03/2021 09:00	0.0	0	0	0	0	1
12/03/2021 10:00	0.0	0	0	0	0	1
12/03/2021 11:00	0.0	0	0	0	0	1
12/03/2021 12:00	0.0	0	0	0	0	1
12/03/2021 13:00	0.0	0	0	0	0	1
12/03/2021 14:00	0.0	0	0	0	0	1
12/03/2021 15:00	0.0	0	0	0	0	1
12/03/2021 16:00	0.0	0	0	0	0	1
12/03/2021 17:00	0.0	0	0	0	0	1
12/03/2021 18:00	0.0	0	0	0	0	1
12/03/2021 19:00	0.0	0	0	0	0	1
12/03/2021 20:00	0.0	0	0	0	0	1
12/03/2021 21:00	0.0	0	0	0	0	1
12/03/2021 22:00	0.0	0	0	0	0	1
12/03/2021 23:00	1.5	0	0	0	1	0
Average/Sum#:	65.2 #	0 #	0 #	2 #	2 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	60.2	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/04/2021 00:00	0.0	0	0	0	0	0
12/04/2021 01:00	0.0	0	0	0	0	0
12/04/2021 02:00	0.0	0	0	0	0	0
12/04/2021 03:00	0.0	0	0	0	0	0
12/04/2021 04:00	0.0	0	0	0	0	0
12/04/2021 05:00	2.4	0	0	1	0	0
12/04/2021 06:00	3.4	0	0	1	1	0
12/04/2021 07:00	29.8	0	0	1	0	0
12/04/2021 08:00	0.0	0	0	0	0	1
12/04/2021 09:00	0.0	0	0	0	0	1
12/04/2021 10:00	0.0	0	0	0	0	1
12/04/2021 11:00	0.0	0	0	0	0	1
12/04/2021 12:00	1.4	0	0	0	1	0
12/04/2021 13:00	0.0	0	0	0	0	0
12/04/2021 14:00	0.0	0	0	0	0	0
12/04/2021 15:00	1.9	0	0	1	0	0
12/04/2021 16:00	58.6	0	0	1	0	0
12/04/2021 17:00	0.0	0	0	0	0	1
12/04/2021 18:00	0.0	0	0	0	0	1
12/04/2021 19:00	0.0	0	0	0	0	1
12/04/2021 20:00	0.0	0	0	0	0	1
12/04/2021 21:00	0.0	0	0	0	0	1
12/04/2021 22:00	0.0	0	0	0	0	1
12/04/2021 23:00	3.0	0	0	0	1	0
Average/Sum#:	100.5 #	0 #	0 #	5 #	3 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	58.6	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/05/2021 00:00	0.0	0	0	0	0	0
12/05/2021 01:00	0.0	0	0	0	0	0
12/05/2021 02:00	0.0	0	0	0	0	0
12/05/2021 03:00	0.0	0	0	0	0	0
12/05/2021 04:00	0.0	0	0	0	0	0
12/05/2021 05:00	0.0	0	0	0	0	0
12/05/2021 06:00	0.0	0	0	0	0	0
12/05/2021 07:00	0.0	0	0	0	0	0
12/05/2021 08:00	0.0	0	0	0	0	0
12/05/2021 09:00	0.0	0	0	0	0	0
12/05/2021 10:00	0.0	0	0	0	0	0
12/05/2021 11:00	0.0	0	0	0	0	0
12/05/2021 12:00	0.0	0	0	0	0	0
12/05/2021 13:00	26.4	0	1	0	0	0
12/05/2021 14:00	41.2	0	1	0	0	0
12/05/2021 15:00	0.0	0	0	0	0	1
12/05/2021 16:00	0.0	0	0	0	0	1
12/05/2021 17:00	0.0	0	0	0	0	1
12/05/2021 18:00	0.0	0	0	0	0	1
12/05/2021 19:00	0.0	0	0	0	0	1
12/05/2021 20:00	0.0	0	0	0	0	1
12/05/2021 21:00	0.0	0	0	0	0	1
12/05/2021 22:00	0.0	0	0	0	0	1
12/05/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	67.6 #	0 #	2 #	0 #	0 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	41.2	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/06/2021 00:00	0.0	0	0	0	0	1
12/06/2021 01:00	0.0	0	0	0	0	1
12/06/2021 02:00	0.0	0	0	0	0	1
12/06/2021 03:00	0.0	0	0	0	0	1
12/06/2021 04:00	0.0	0	0	0	0	1
12/06/2021 05:00	0.0	0	0	0	0	1
12/06/2021 06:00	0.0	0	0	0	0	1
12/06/2021 07:00	0.0	0	0	0	0	1
12/06/2021 08:00	0.0	0	0	0	0	1
12/06/2021 09:00	0.0	0	0	0	0	1
12/06/2021 10:00	0.0	0	0	0	0	1
12/06/2021 11:00	0.0	0	0	0	0	1
12/06/2021 12:00	0.0	0	0	0	0	1
12/06/2021 13:00	0.0	0	0	0	0	1
12/06/2021 14:00	0.0	0	0	0	0	1
12/06/2021 15:00	0.0	0	0	0	0	1
12/06/2021 16:00	0.0	0	0	0	0	1
12/06/2021 17:00	0.0	0	0	0	0	1
12/06/2021 18:00	0.0	0	0	0	0	1
12/06/2021 19:00	0.0	0	0	0	0	1
12/06/2021 20:00	0.0	0	0	0	0	1
12/06/2021 21:00	0.0	0	0	0	0	1
12/06/2021 22:00	0.0	0	0	0	0	1
12/06/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/07/2021 00:00	0.0	0	0	0	0	1
12/07/2021 01:00	0.0	0	0	0	0	1
12/07/2021 02:00	0.0	0	0	0	0	1
12/07/2021 03:00	0.0	0	0	0	0	1
12/07/2021 04:00	0.0	0	0	0	0	1
12/07/2021 05:00	0.0	0	0	0	0	1
12/07/2021 06:00	0.0	0	0	0	0	1
12/07/2021 07:00	0.0	0	0	0	0	1
12/07/2021 08:00	0.0	0	0	0	0	1
12/07/2021 09:00	0.0	0	0	0	0	1
12/07/2021 10:00	0.0	0	0	0	0	1
12/07/2021 11:00	0.0	0	0	0	0	1
12/07/2021 12:00	0.0	0	0	0	0	1
12/07/2021 13:00	0.0	0	0	0	0	1
12/07/2021 14:00	0.0	0	0	0	0	1
12/07/2021 15:00	0.0	0	0	0	0	1
12/07/2021 16:00	0.0	0	0	0	0	1
12/07/2021 17:00	0.0	0	0	0	0	1
12/07/2021 18:00	0.0	0	0	0	0	1
12/07/2021 19:00	0.0	0	0	0	0	1
12/07/2021 20:00	0.0	0	0	0	0	1
12/07/2021 21:00	0.0	0	0	0	0	1
12/07/2021 22:00	0.0	0	0	0	0	1
12/07/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/08/2021 00:00	0.0	0	0	0	0	1
12/08/2021 01:00	0.0	0	0	0	0	1
12/08/2021 02:00	0.0	0	0	0	0	1
12/08/2021 03:00	0.0	0	0	0	0	1
12/08/2021 04:00	0.0	0	0	0	0	1
12/08/2021 05:00	0.0	0	0	0	0	1
12/08/2021 06:00	0.0	0	0	0	0	1
12/08/2021 07:00	0.0	0	0	0	0	1
12/08/2021 08:00	0.0	0	0	0	0	1
12/08/2021 09:00	0.0	0	0	0	0	1
12/08/2021 10:00	0.0	0	0	0	0	1
12/08/2021 11:00	0.0	0	0	0	0	1
12/08/2021 12:00	0.0	0	0	0	0	1
12/08/2021 13:00	0.0	0	0	0	0	1
12/08/2021 14:00	0.0	0	0	0	0	1
12/08/2021 15:00	0.0	0	0	0	0	1
12/08/2021 16:00	0.0	0	0	0	0	1
12/08/2021 17:00	0.0	0	0	0	0	1
12/08/2021 18:00	0.0	0	0	0	0	1
12/08/2021 19:00	0.0	0	0	0	0	1
12/08/2021 20:00	0.0	0	0	0	0	1
12/08/2021 21:00	0.0	0	0	0	0	1
12/08/2021 22:00	0.0	0	0	0	0	1
12/08/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/09/2021 00:00	0.0	0	0	0	0	1
12/09/2021 01:00	0.0	0	0	0	0	1
12/09/2021 02:00	0.0	0	0	0	0	1
12/09/2021 03:00	0.0	0	0	0	0	1
12/09/2021 04:00	0.0	0	0	0	0	1
12/09/2021 05:00	0.0	0	0	0	0	1
12/09/2021 06:00	0.0	0	0	0	0	1
12/09/2021 07:00	0.0	0	0	0	0	1
12/09/2021 08:00	0.0	0	0	0	0	1
12/09/2021 09:00	0.0	0	0	0	0	1
12/09/2021 10:00	0.0	0	0	0	0	1
12/09/2021 11:00	0.0	0	0	0	0	1
12/09/2021 12:00	0.0	0	0	0	0	1
12/09/2021 13:00	0.0	0	0	0	0	1
12/09/2021 14:00	0.0	0	0	0	0	1
12/09/2021 15:00	0.0	0	0	0	0	1
12/09/2021 16:00	0.0	0	0	0	0	1
12/09/2021 17:00	0.0	0	0	0	0	1
12/09/2021 18:00	0.0	0	0	0	0	1
12/09/2021 19:00	0.0	0	0	0	0	1
12/09/2021 20:00	0.0	0	0	0	0	1
12/09/2021 21:00	0.0	0	0	0	0	1
12/09/2021 22:00	0.0	0	0	0	0	1
12/09/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/10/2021 00:00	0.0	0	0	0	0	1
12/10/2021 01:00	0.0	0	0	0	0	1
12/10/2021 02:00	0.0	0	0	0	0	1
12/10/2021 03:00	0.0	0	0	0	0	1
12/10/2021 04:00	0.0	0	0	0	0	1
12/10/2021 05:00	0.0	0	0	0	0	1
12/10/2021 06:00	0.0	0	0	0	0	1
12/10/2021 07:00	0.0	0	0	0	0	1
12/10/2021 08:00	0.0	0	0	0	0	1
12/10/2021 09:00	0.0	0	0	0	0	1
12/10/2021 10:00	0.0	0	0	0	0	1
12/10/2021 11:00	0.0	0	0	0	0	1
12/10/2021 12:00	0.0	0	0	0	0	1
12/10/2021 13:00	0.0	0	0	0	0	1
12/10/2021 14:00	0.0	0	0	0	0	1
12/10/2021 15:00	0.0	0	0	0	0	1
12/10/2021 16:00	0.0	0	0	0	0	1
12/10/2021 17:00	0.0	0	0	0	0	1
12/10/2021 18:00	0.0	0	0	0	0	1
12/10/2021 19:00	0.0	0	0	0	0	1
12/10/2021 20:00	0.0	0	0	0	0	1
12/10/2021 21:00	0.0	0	0	0	0	1
12/10/2021 22:00	0.0	0	0	0	0	1
12/10/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/11/2021 00:00	0.0	0	0	0	0	1
12/11/2021 01:00	0.0	0	0	0	0	1
12/11/2021 02:00	0.0	0	0	0	0	1
12/11/2021 03:00	0.0	0	0	0	0	1
12/11/2021 04:00	0.0	0	0	0	0	1
12/11/2021 05:00	0.0	0	0	0	0	1
12/11/2021 06:00	0.0	0	0	0	0	1
12/11/2021 07:00	0.0	0	0	0	0	1
12/11/2021 08:00	0.0	0	0	0	0	1
12/11/2021 09:00	0.0	0	0	0	0	1
12/11/2021 10:00	0.0	0	0	0	0	1
12/11/2021 11:00	0.0	0	0	0	0	1
12/11/2021 12:00	0.0	0	0	0	0	1
12/11/2021 13:00	0.0	0	0	0	0	1
12/11/2021 14:00	0.0	0	0	0	0	1
12/11/2021 15:00	0.0	0	0	0	0	1
12/11/2021 16:00	0.0	0	0	0	0	1
12/11/2021 17:00	0.0	0	0	0	0	1
12/11/2021 18:00	0.0	0	0	0	0	1
12/11/2021 19:00	0.0	0	0	0	0	1
12/11/2021 20:00	0.0	0	0	0	0	1
12/11/2021 21:00	0.0	0	0	0	0	1
12/11/2021 22:00	0.0	0	0	0	0	1
12/11/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/12/2021 00:00	0.0	0	0	0	0	1
12/12/2021 01:00	0.0	0	0	0	0	1
12/12/2021 02:00	0.0	0	0	0	0	1
12/12/2021 03:00	0.0	0	0	0	0	1
12/12/2021 04:00	0.0	0	0	0	0	1
12/12/2021 05:00	0.0	0	0	0	0	1
12/12/2021 06:00	0.0	0	0	0	0	1
12/12/2021 07:00	0.0	0	0	0	0	1
12/12/2021 08:00	0.0	0	0	0	0	1
12/12/2021 09:00	0.0	0	0	0	0	1
12/12/2021 10:00	0.0	0	0	0	0	1
12/12/2021 11:00	0.0	0	0	0	0	1
12/12/2021 12:00	0.0	0	0	0	0	1
12/12/2021 13:00	0.0	0	0	0	0	1
12/12/2021 14:00	0.0	0	0	0	0	1
12/12/2021 15:00	0.0	0	0	0	0	1
12/12/2021 16:00	0.0	0	0	0	0	1
12/12/2021 17:00	0.0	0	0	0	0	1
12/12/2021 18:00	0.0	0	0	0	0	1
12/12/2021 19:00	0.0	0	0	0	0	1
12/12/2021 20:00	0.0	0	0	0	0	1
12/12/2021 21:00	0.0	0	0	0	0	1
12/12/2021 22:00	0.0	0	0	0	0	1
12/12/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/13/2021 00:00	0.0	0	0	0	0	1
12/13/2021 01:00	0.0	0	0	0	0	1
12/13/2021 02:00	0.0	0	0	0	0	1
12/13/2021 03:00	0.0	0	0	0	0	1
12/13/2021 04:00	0.0	0	0	0	0	1
12/13/2021 05:00	0.0	0	0	0	0	1
12/13/2021 06:00	0.0	0	0	0	0	1
12/13/2021 07:00	0.0	0	0	0	0	1
12/13/2021 08:00	0.0	0	0	0	0	1
12/13/2021 09:00	0.0	0	0	0	0	1
12/13/2021 10:00	0.0	0	0	0	0	1
12/13/2021 11:00	0.0	0	0	0	0	1
12/13/2021 12:00	0.0	0	0	0	0	1
12/13/2021 13:00	0.0	0	0	0	0	1
12/13/2021 14:00	0.0	0	0	0	0	1
12/13/2021 15:00	0.0	0	0	0	0	1
12/13/2021 16:00	0.0	0	0	0	0	1
12/13/2021 17:00	0.0	0	0	0	0	1
12/13/2021 18:00	0.0	0	0	0	0	1
12/13/2021 19:00	0.0	0	0	0	0	1
12/13/2021 20:00	0.0	0	0	0	0	1
12/13/2021 21:00	0.0	0	0	0	0	1
12/13/2021 22:00	0.0	0	0	0	0	1
12/13/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/14/2021 00:00	0.0	0	0	0	0	1
12/14/2021 01:00	0.0	0	0	0	0	1
12/14/2021 02:00	0.0	0	0	0	0	1
12/14/2021 03:00	0.0	0	0	0	0	1
12/14/2021 04:00	0.0	0	0	0	0	1
12/14/2021 05:00	0.0	0	0	0	0	1
12/14/2021 06:00	0.0	0	0	0	0	1
12/14/2021 07:00	0.0	0	0	0	0	1
12/14/2021 08:00	0.0	0	0	0	0	1
12/14/2021 09:00	0.0	0	0	0	0	1
12/14/2021 10:00	0.0	0	0	0	0	1
12/14/2021 11:00	0.0	0	0	0	0	1
12/14/2021 12:00	0.0	0	0	0	0	1
12/14/2021 13:00	0.0	0	0	0	0	1
12/14/2021 14:00	0.0	0	0	0	0	1
12/14/2021 15:00	0.0	0	0	0	0	1
12/14/2021 16:00	0.0	0	0	0	0	1
12/14/2021 17:00	0.0	0	0	0	0	1
12/14/2021 18:00	0.0	0	0	0	0	1
12/14/2021 19:00	0.0	0	0	0	0	1
12/14/2021 20:00	0.0	0	0	0	0	1
12/14/2021 21:00	0.0	0	0	0	0	1
12/14/2021 22:00	0.0	0	0	0	0	1
12/14/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/15/2021 00:00	0.0	0	0	0	0	1
12/15/2021 01:00	0.0	0	0	0	0	1
12/15/2021 02:00	0.0	0	0	0	0	1
12/15/2021 03:00	0.0	0	0	0	0	1
12/15/2021 04:00	0.0	0	0	0	0	1
12/15/2021 05:00	0.0	0	0	0	0	1
12/15/2021 06:00	0.0	0	0	0	0	1
12/15/2021 07:00	0.0	0	0	0	0	1
12/15/2021 08:00	0.0	0	0	0	0	1
12/15/2021 09:00	0.0	0	0	0	0	1
12/15/2021 10:00	0.0	0	0	0	0	1
12/15/2021 11:00	0.0	0	0	0	0	1
12/15/2021 12:00	0.0	0	0	0	0	1
12/15/2021 13:00	0.0	0	0	0	0	1
12/15/2021 14:00	0.0	0	0	0	0	1
12/15/2021 15:00	0.0	0	0	0	0	1
12/15/2021 16:00	0.0	0	0	0	0	1
12/15/2021 17:00	0.0	0	0	0	0	1
12/15/2021 18:00	0.0	0	0	0	0	1
12/15/2021 19:00	0.0	0	0	0	0	1
12/15/2021 20:00	0.0	0	0	0	0	1
12/15/2021 21:00	0.0	0	0	0	0	1
12/15/2021 22:00	0.0	0	0	0	0	1
12/15/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/16/2021 00:00	0.0	0	0	0	0	1
12/16/2021 01:00	0.0	0	0	0	0	1
12/16/2021 02:00	0.0	0	0	0	0	1
12/16/2021 03:00	0.0	0	0	0	0	1
12/16/2021 04:00	0.0	0	0	0	0	1
12/16/2021 05:00	0.0	0	0	0	0	1
12/16/2021 06:00	0.0	0	0	0	0	1
12/16/2021 07:00	0.0	0	0	0	0	1
12/16/2021 08:00	0.0	0	0	0	0	1
12/16/2021 09:00	0.0	0	0	0	0	1
12/16/2021 10:00	0.0	0	0	0	0	1
12/16/2021 11:00	0.0	0	0	0	0	1
12/16/2021 12:00	0.0	0	0	0	0	1
12/16/2021 13:00	0.0	0	0	0	0	1
12/16/2021 14:00	0.0	0	0	0	0	1
12/16/2021 15:00	0.0	0	0	0	0	1
12/16/2021 16:00	0.0	0	0	0	0	1
12/16/2021 17:00	0.0	0	0	0	0	1
12/16/2021 18:00	0.0	0	0	0	0	1
12/16/2021 19:00	0.0	0	0	0	0	1
12/16/2021 20:00	0.0	0	0	0	0	1
12/16/2021 21:00	0.0	0	0	0	0	1
12/16/2021 22:00	0.0	0	0	0	0	1
12/16/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/17/2021 00:00	0.0	0	0	0	0	1
12/17/2021 01:00	0.0	0	0	0	0	1
12/17/2021 02:00	0.0	0	0	0	0	1
12/17/2021 03:00	0.0	0	0	0	0	1
12/17/2021 04:00	0.0	0	0	0	0	1
12/17/2021 05:00	0.0	0	0	0	0	1
12/17/2021 06:00	0.0	0	0	0	0	1
12/17/2021 07:00	0.0	0	0	0	0	1
12/17/2021 08:00	0.0	0	0	0	0	1
12/17/2021 09:00	0.0	0	0	0	0	1
12/17/2021 10:00	0.0	0	0	0	0	1
12/17/2021 11:00	0.0	0	0	0	0	1
12/17/2021 12:00	0.0	0	0	0	0	1
12/17/2021 13:00	0.0	0	0	0	0	1
12/17/2021 14:00	0.0	0	0	0	0	1
12/17/2021 15:00	0.0	0	0	0	0	1
12/17/2021 16:00	0.0	0	0	0	0	1
12/17/2021 17:00	0.0	0	0	0	0	1
12/17/2021 18:00	0.0	0	0	0	0	1
12/17/2021 19:00	0.0	0	0	0	0	1
12/17/2021 20:00	0.0	0	0	0	0	1
12/17/2021 21:00	0.0	0	0	0	0	1
12/17/2021 22:00	0.0	0	0	0	0	1
12/17/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/18/2021 00:00	0.0	0	0	0	0	1
12/18/2021 01:00	0.0	0	0	0	0	1
12/18/2021 02:00	0.0	0	0	0	0	1
12/18/2021 03:00	0.0	0	0	0	0	1
12/18/2021 04:00	0.0	0	0	0	0	1
12/18/2021 05:00	0.0	0	0	0	0	1
12/18/2021 06:00	0.0	0	0	0	0	1
12/18/2021 07:00	0.0	0	0	0	0	1
12/18/2021 08:00	0.0	0	0	0	0	1
12/18/2021 09:00	0.0	0	0	0	0	1
12/18/2021 10:00	0.0	0	0	0	0	1
12/18/2021 11:00	0.0	0	0	0	0	1
12/18/2021 12:00	0.0	0	0	0	0	1
12/18/2021 13:00	0.0	0	0	0	0	1
12/18/2021 14:00	0.0	0	0	0	0	1
12/18/2021 15:00	0.0	0	0	0	0	1
12/18/2021 16:00	0.0	0	0	0	0	1
12/18/2021 17:00	0.0	0	0	0	0	1
12/18/2021 18:00	0.0	0	0	0	0	1
12/18/2021 19:00	0.0	0	0	0	0	1
12/18/2021 20:00	0.0	0	0	0	0	1
12/18/2021 21:00	0.0	0	0	0	0	1
12/18/2021 22:00	0.0	0	0	0	0	1
12/18/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/19/2021 00:00	0.0	0	0	0	0	1
12/19/2021 01:00	0.0	0	0	0	0	1
12/19/2021 02:00	0.0	0	0	0	0	1
12/19/2021 03:00	0.0	0	0	0	0	1
12/19/2021 04:00	0.0	0	0	0	0	1
12/19/2021 05:00	0.0	0	0	0	0	1
12/19/2021 06:00	0.0	0	0	0	0	1
12/19/2021 07:00	0.0	0	0	0	0	1
12/19/2021 08:00	0.0	0	0	0	0	1
12/19/2021 09:00	0.0	0	0	0	0	1
12/19/2021 10:00	0.0	0	0	0	0	1
12/19/2021 11:00	0.0	0	0	0	0	1
12/19/2021 12:00	0.0	0	0	0	0	1
12/19/2021 13:00	0.0	0	0	0	0	1
12/19/2021 14:00	0.0	0	0	0	0	1
12/19/2021 15:00	0.0	0	0	0	0	1
12/19/2021 16:00	0.0	0	0	0	0	1
12/19/2021 17:00	0.0	0	0	0	0	1
12/19/2021 18:00	0.0	0	0	0	0	1
12/19/2021 19:00	0.0	0	0	0	0	1
12/19/2021 20:00	0.0	0	0	0	0	1
12/19/2021 21:00	0.0	0	0	0	0	1
12/19/2021 22:00	0.0	0	0	0	0	1
12/19/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/20/2021 00:00	0.0	0	0	0	0	1
12/20/2021 01:00	0.0	0	0	0	0	1
12/20/2021 02:00	0.0	0	0	0	0	1
12/20/2021 03:00	0.0	0	0	0	0	1
12/20/2021 04:00	0.0	0	0	0	0	1
12/20/2021 05:00	0.0	0	0	0	0	1
12/20/2021 06:00	0.0	0	0	0	0	1
12/20/2021 07:00	0.0	0	0	0	0	1
12/20/2021 08:00	0.0	0	0	0	0	1
12/20/2021 09:00	0.0	0	0	0	0	1
12/20/2021 10:00	0.0	0	0	0	0	1
12/20/2021 11:00	0.0	0	0	0	0	1
12/20/2021 12:00	0.0	0	0	0	0	1
12/20/2021 13:00	0.0	0	0	0	0	1
12/20/2021 14:00	0.0	0	0	0	0	1
12/20/2021 15:00	0.0	0	0	0	0	1
12/20/2021 16:00	0.0	0	0	0	0	1
12/20/2021 17:00	0.0	0	0	0	0	1
12/20/2021 18:00	0.0	0	0	0	0	1
12/20/2021 19:00	0.0	0	0	0	0	1
12/20/2021 20:00	0.0	0	0	0	0	1
12/20/2021 21:00	0.0	0	0	0	0	1
12/20/2021 22:00	0.0	0	0	0	0	1
12/20/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/21/2021 00:00	0.0	0	0	0	0	1
12/21/2021 01:00	0.0	0	0	0	0	1
12/21/2021 02:00	0.0	0	0	0	0	1
12/21/2021 03:00	0.0	0	0	0	0	1
12/21/2021 04:00	0.0	0	0	0	0	1
12/21/2021 05:00	0.0	0	0	0	0	1
12/21/2021 06:00	0.0	0	0	0	0	1
12/21/2021 07:00	0.0	0	0	0	0	1
12/21/2021 08:00	0.0	0	0	0	0	1
12/21/2021 09:00	0.0	0	0	0	0	1
12/21/2021 10:00	0.0	0	0	0	0	1
12/21/2021 11:00	0.0	0	0	0	0	1
12/21/2021 12:00	0.0	0	0	0	0	1
12/21/2021 13:00	0.0	0	0	0	0	1
12/21/2021 14:00	0.0	0	0	0	0	1
12/21/2021 15:00	0.0	0	0	0	0	1
12/21/2021 16:00	0.0	0	0	0	0	1
12/21/2021 17:00	0.0	0	0	0	0	1
12/21/2021 18:00	0.0	0	0	0	0	1
12/21/2021 19:00	0.0	0	0	0	0	1
12/21/2021 20:00	0.0	0	0	0	0	1
12/21/2021 21:00	0.0	0	0	0	0	1
12/21/2021 22:00	0.0	0	0	0	0	1
12/21/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/22/2021 00:00	0.0	0	0	0	0	1
12/22/2021 01:00	0.0	0	0	0	0	1
12/22/2021 02:00	0.0	0	0	0	0	1
12/22/2021 03:00	0.0	0	0	0	0	1
12/22/2021 04:00	0.0	0	0	0	0	1
12/22/2021 05:00	0.0	0	0	0	0	1
12/22/2021 06:00	0.0	0	0	0	0	1
12/22/2021 07:00	0.0	0	0	0	0	1
12/22/2021 08:00	0.0	0	0	0	0	1
12/22/2021 09:00	0.0	0	0	0	0	1
12/22/2021 10:00	0.0	0	0	0	0	1
12/22/2021 11:00	0.0	0	0	0	0	1
12/22/2021 12:00	0.0	0	0	0	0	1
12/22/2021 13:00	0.0	0	0	0	0	1
12/22/2021 14:00	0.0	0	0	0	0	1
12/22/2021 15:00	0.0	0	0	0	0	1
12/22/2021 16:00	0.0	0	0	0	0	1
12/22/2021 17:00	0.0	0	0	0	0	1
12/22/2021 18:00	0.0	0	0	0	0	1
12/22/2021 19:00	0.0	0	0	0	0	1
12/22/2021 20:00	0.0	0	0	0	0	1
12/22/2021 21:00	0.0	0	0	0	0	1
12/22/2021 22:00	0.0	0	0	0	0	1
12/22/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/23/2021 00:00	0.0	0	0	0	0	1
12/23/2021 01:00	0.0	0	0	0	0	1
12/23/2021 02:00	0.0	0	0	0	0	1
12/23/2021 03:00	0.0	0	0	0	0	1
12/23/2021 04:00	0.0	0	0	0	0	1
12/23/2021 05:00	0.0	0	0	0	0	1
12/23/2021 06:00	0.0	0	0	0	0	1
12/23/2021 07:00	0.0	0	0	0	0	1
12/23/2021 08:00	0.0	0	0	0	0	1
12/23/2021 09:00	0.0	0	0	0	0	1
12/23/2021 10:00	0.0	0	0	0	0	1
12/23/2021 11:00	0.0	0	0	0	0	1
12/23/2021 12:00	0.0	0	0	0	0	1
12/23/2021 13:00	0.0	0	0	0	0	1
12/23/2021 14:00	0.0	0	0	0	0	1
12/23/2021 15:00	0.0	0	0	0	0	1
12/23/2021 16:00	0.0	0	0	0	0	1
12/23/2021 17:00	0.0	0	0	0	0	1
12/23/2021 18:00	0.0	0	0	0	0	1
12/23/2021 19:00	0.0	0	0	0	0	1
12/23/2021 20:00	0.0	0	0	0	0	1
12/23/2021 21:00	0.0	0	0	0	0	1
12/23/2021 22:00	0.0	0	0	0	0	1
12/23/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/24/2021 00:00	0.0	0	0	0	0	1
12/24/2021 01:00	0.0	0	0	0	0	1
12/24/2021 02:00	0.0	0	0	0	0	1
12/24/2021 03:00	0.0	0	0	0	0	1
12/24/2021 04:00	0.0	0	0	0	0	1
12/24/2021 05:00	0.0	0	0	0	0	1
12/24/2021 06:00	0.0	0	0	0	0	1
12/24/2021 07:00	0.0	0	0	0	0	1
12/24/2021 08:00	0.0	0	0	0	0	1
12/24/2021 09:00	0.0	0	0	0	0	1
12/24/2021 10:00	0.0	0	0	0	0	1
12/24/2021 11:00	0.0	0	0	0	0	1
12/24/2021 12:00	0.0	0	0	0	0	1
12/24/2021 13:00	0.0	0	0	0	0	1
12/24/2021 14:00	0.0	0	0	0	0	1
12/24/2021 15:00	0.0	0	0	0	0	1
12/24/2021 16:00	0.0	0	0	0	0	1
12/24/2021 17:00	0.0	0	0	0	0	1
12/24/2021 18:00	0.0	0	0	0	0	1
12/24/2021 19:00	0.0	0	0	0	0	1
12/24/2021 20:00	0.0	0	0	0	0	1
12/24/2021 21:00	0.0	0	0	0	0	1
12/24/2021 22:00	0.0	0	0	0	0	1
12/24/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/25/2021 00:00	0.0	0	0	0	0	1
12/25/2021 01:00	0.0	0	0	0	0	1
12/25/2021 02:00	0.0	0	0	0	0	1
12/25/2021 03:00	0.0	0	0	0	0	1
12/25/2021 04:00	0.0	0	0	0	0	1
12/25/2021 05:00	0.0	0	0	0	0	1
12/25/2021 06:00	0.0	0	0	0	0	1
12/25/2021 07:00	0.0	0	0	0	0	1
12/25/2021 08:00	0.0	0	0	0	0	1
12/25/2021 09:00	0.0	0	0	0	0	1
12/25/2021 10:00	0.0	0	0	0	0	1
12/25/2021 11:00	0.0	0	0	0	0	1
12/25/2021 12:00	0.0	0	0	0	0	1
12/25/2021 13:00	0.0	0	0	0	0	1
12/25/2021 14:00	0.0	0	0	0	0	1
12/25/2021 15:00	0.0	0	0	0	0	1
12/25/2021 16:00	0.0	0	0	0	0	1
12/25/2021 17:00	0.0	0	0	0	0	1
12/25/2021 18:00	0.0	0	0	0	0	1
12/25/2021 19:00	0.0	0	0	0	0	1
12/25/2021 20:00	0.0	0	0	0	0	1
12/25/2021 21:00	0.0	0	0	0	0	1
12/25/2021 22:00	0.0	0	0	0	0	1
12/25/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/26/2021 00:00	1.9	0	0	0	1	0
12/26/2021 01:00	0.0	0	0	0	0	0
12/26/2021 02:00	0.0	0	0	0	0	0
12/26/2021 03:00	0.0	0	0	0	0	0
12/26/2021 04:00	0.0	0	0	0	0	0
12/26/2021 05:00	0.0	0	0	0	0	0
12/26/2021 06:00	0.0	0	0	0	0	0
12/26/2021 07:00	0.0	0	0	0	0	0
12/26/2021 08:00	0.0	0	0	0	0	0
12/26/2021 09:00	0.0	0	0	0	0	0
12/26/2021 10:00	0.0	0	0	0	0	0
12/26/2021 11:00	0.0	0	0	0	0	0
12/26/2021 12:00	0.0	0	0	0	0	0
12/26/2021 13:00	0.0	0	0	0	0	0
12/26/2021 14:00	0.0	0	0	0	0	0
12/26/2021 15:00	16.8	0	1	0	0	0
12/26/2021 16:00	57.5	0	1	0	0	0
12/26/2021 17:00	0.0	0	0	0	0	1
12/26/2021 18:00	0.0	0	0	0	0	1
12/26/2021 19:00	0.0	0	0	0	0	1
12/26/2021 20:00	0.0	0	0	0	0	1
12/26/2021 21:00	0.0	0	0	0	0	1
12/26/2021 22:00	0.0	0	0	0	0	1
12/26/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	76.2 #	0 #	2 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	57.5	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/27/2021 00:00	0.0	0	0	0	0	1
12/27/2021 01:00	0.0	0	0	0	0	1
12/27/2021 02:00	0.0	0	0	0	0	1
12/27/2021 03:00	0.0	0	0	0	0	1
12/27/2021 04:00	0.0	0	0	0	0	1
12/27/2021 05:00	0.0	0	0	0	0	1
12/27/2021 06:00	0.0	0	0	0	0	1
12/27/2021 07:00	0.0	0	0	0	0	1
12/27/2021 08:00	0.0	0	0	0	0	1
12/27/2021 09:00	0.0	0	0	0	0	1
12/27/2021 10:00	0.0	0	0	0	0	1
12/27/2021 11:00	0.0	0	0	0	0	1
12/27/2021 12:00	0.0	0	0	0	0	1
12/27/2021 13:00	0.0	0	0	0	0	1
12/27/2021 14:00	0.0	0	0	0	0	1
12/27/2021 15:00	0.0	0	0	0	0	1
12/27/2021 16:00	0.0	0	0	0	0	1
12/27/2021 17:00	0.0	0	0	0	0	1
12/27/2021 18:00	0.0	0	0	0	0	1
12/27/2021 19:00	0.0	0	0	0	0	1
12/27/2021 20:00	0.0	0	0	0	0	1
12/27/2021 21:00	0.0	0	0	0	0	1
12/27/2021 22:00	0.0	0	0	0	0	1
12/27/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/28/2021 00:00	0.0	0	0	0	0	1
12/28/2021 01:00	0.0	0	0	0	0	1
12/28/2021 02:00	0.0	0	0	0	0	1
12/28/2021 03:00	0.0	0	0	0	0	1
12/28/2021 04:00	0.0	0	0	0	0	1
12/28/2021 05:00	0.0	0	0	0	0	1
12/28/2021 06:00	0.0	0	0	0	0	1
12/28/2021 07:00	0.0	0	0	0	0	1
12/28/2021 08:00	0.0	0	0	0	0	1
12/28/2021 09:00	0.0	0	0	0	0	1
12/28/2021 10:00	0.0	0	0	0	0	1
12/28/2021 11:00	0.0	0	0	0	0	1
12/28/2021 12:00	0.0	0	0	0	0	1
12/28/2021 13:00	0.0	0	0	0	0	1
12/28/2021 14:00	0.0	0	0	0	0	1
12/28/2021 15:00	0.0	0	0	0	0	1
12/28/2021 16:00	0.0	0	0	0	0	1
12/28/2021 17:00	0.0	0	0	0	0	1
12/28/2021 18:00	0.0	0	0	0	0	1
12/28/2021 19:00	0.0	0	0	0	0	1
12/28/2021 20:00	0.0	0	0	0	0	1
12/28/2021 21:00	0.0	0	0	0	0	1
12/28/2021 22:00	0.0	0	0	0	0	1
12/28/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/29/2021 00:00	0.0	0	0	0	0	1
12/29/2021 01:00	0.0	0	0	0	0	1
12/29/2021 02:00	0.0	0	0	0	0	1
12/29/2021 03:00	0.0	0	0	0	0	1
12/29/2021 04:00	0.0	0	0	0	0	1
12/29/2021 05:00	0.0	0	0	0	0	1
12/29/2021 06:00	0.0	0	0	0	0	1
12/29/2021 07:00	0.0	0	0	0	0	1
12/29/2021 08:00	0.0	0	0	0	0	1
12/29/2021 09:00	0.0	0	0	0	0	1
12/29/2021 10:00	0.0	0	0	0	0	1
12/29/2021 11:00	0.0	0	0	0	0	1
12/29/2021 12:00	0.0	0	0	0	0	1
12/29/2021 13:00	0.0	0	0	0	0	1
12/29/2021 14:00	0.0	0	0	0	0	1
12/29/2021 15:00	0.0	0	0	0	0	1
12/29/2021 16:00	0.0	0	0	0	0	1
12/29/2021 17:00	0.0	0	0	0	0	1
12/29/2021 18:00	0.0	0	0	0	0	1
12/29/2021 19:00	0.0	0	0	0	0	1
12/29/2021 20:00	0.0	0	0	0	0	1
12/29/2021 21:00	0.0	0	0	0	0	1
12/29/2021 22:00	0.0	0	0	0	0	1
12/29/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/30/2021 00:00	0.0	0	0	0	0	1
12/30/2021 01:00	0.0	0	0	0	0	1
12/30/2021 02:00	0.0	0	0	0	0	1
12/30/2021 03:00	0.0	0	0	0	0	1
12/30/2021 04:00	0.0	0	0	0	0	1
12/30/2021 05:00	0.0	0	0	0	0	1
12/30/2021 06:00	0.0	0	0	0	0	1
12/30/2021 07:00	0.0	0	0	0	0	1
12/30/2021 08:00	0.0	0	0	0	0	1
12/30/2021 09:00	0.0	0	0	0	0	1
12/30/2021 10:00	0.0	0	0	0	0	1
12/30/2021 11:00	0.0	0	0	0	0	1
12/30/2021 12:00	0.0	0	0	0	0	1
12/30/2021 13:00	0.0	0	0	0	0	1
12/30/2021 14:00	0.0	0	0	0	0	1
12/30/2021 15:00	0.0	0	0	0	0	1
12/30/2021 16:00	0.0	0	0	0	0	1
12/30/2021 17:00	0.0	0	0	0	0	1
12/30/2021 18:00	0.0	0	0	0	0	1
12/30/2021 19:00	0.0	0	0	0	0	1
12/30/2021 20:00	0.0	0	0	0	0	1
12/30/2021 21:00	0.0	0	0	0	0	1
12/30/2021 22:00	0.0	0	0	0	0	1
12/30/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/31/2021 00:00	0.0	0	0	0	0	1
12/31/2021 01:00	0.0	0	0	0	0	1
12/31/2021 02:00	0.0	0	0	0	0	1
12/31/2021 03:00	0.0	0	0	0	0	1
12/31/2021 04:00	0.0	0	0	0	0	1
12/31/2021 05:00	0.0	0	0	0	0	1
12/31/2021 06:00	0.0	0	0	0	0	1
12/31/2021 07:00	0.0	0	0	0	0	1
12/31/2021 08:00	0.0	0	0	0	0	1
12/31/2021 09:00	0.0	0	0	0	0	1
12/31/2021 10:00	0.0	0	0	0	0	1
12/31/2021 11:00	0.0	0	0	0	0	1
12/31/2021 12:00	0.0	0	0	0	0	1
12/31/2021 13:00	0.0	0	0	0	0	1
12/31/2021 14:00	0.0	0	0	0	0	1
12/31/2021 15:00	0.0	0	0	0	0	1
12/31/2021 16:00	0.0	0	0	0	0	1
12/31/2021 17:00	0.0	0	0	0	0	1
12/31/2021 18:00	0.0	0	0	0	0	1
12/31/2021 19:00	0.0	0	0	0	0	1
12/31/2021 20:00	0.0	0	0	0	0	1
12/31/2021 21:00	0.0	0	0	0	0	1
12/31/2021 22:00	0.0	0	0	0	0	1
12/31/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/01/2021 00:00	0.0	0	0	0	0	0
10/01/2021 01:00	0.0	0	0	0	0	0
10/01/2021 02:00	0.0	0	0	0	0	0
10/01/2021 03:00	0.0	0	0	0	0	0
10/01/2021 04:00	0.0	0	0	0	0	0
10/01/2021 05:00	0.0	0	0	0	0	0
10/01/2021 06:00	0.0	0	0	0	0	0
10/01/2021 07:00	0.0	0	0	0	0	0
10/01/2021 08:00	0.0	0	0	0	0	0
10/01/2021 09:00	0.0	0	0	0	0	0
10/01/2021 10:00	0.0	0	0	0	0	0
10/01/2021 11:00	0.0	0	0	0	0	0
10/01/2021 12:00	0.0	0	0	0	0	0
10/01/2021 13:00	1,630.5	0	1	0	0	0
10/01/2021 14:00	5,338.9	0	1	0	0	0
10/01/2021 15:00	0.0	0	0	0	0	1
10/01/2021 16:00	0.0	0	0	0	0	1
10/01/2021 17:00	0.0	0	0	0	0	1
10/01/2021 18:00	0.0	0	0	0	0	1
10/01/2021 19:00	0.0	0	0	0	0	1
10/01/2021 20:00	0.0	0	0	0	0	1
10/01/2021 21:00	0.0	0	0	0	0	1
10/01/2021 22:00	0.0	0	0	0	0	1
10/01/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,969.4 #	0 #	2 #	0 #	0 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,338.9	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/02/2021 00:00	0.0	0	0	0	0	1
10/02/2021 01:00	0.0	0	0	0	0	1
10/02/2021 02:00	0.0	0	0	0	0	1
10/02/2021 03:00	0.0	0	0	0	0	1
10/02/2021 04:00	0.0	0	0	0	0	1
10/02/2021 05:00	0.0	0	0	0	0	1
10/02/2021 06:00	0.0	0	0	0	0	1
10/02/2021 07:00	0.0	0	0	0	0	1
10/02/2021 08:00	0.0	0	0	0	0	1
10/02/2021 09:00	0.0	0	0	0	0	1
10/02/2021 10:00	0.0	0	0	0	0	1
10/02/2021 11:00	0.0	0	0	0	0	1
10/02/2021 12:00	0.0	0	0	0	0	1
10/02/2021 13:00	0.0	0	0	0	0	1
10/02/2021 14:00	0.0	0	0	0	0	1
10/02/2021 15:00	0.0	0	0	0	0	1
10/02/2021 16:00	0.0	0	0	0	0	1
10/02/2021 17:00	0.0	0	0	0	0	1
10/02/2021 18:00	0.0	0	0	0	0	1
10/02/2021 19:00	0.0	0	0	0	0	1
10/02/2021 20:00	0.0	0	0	0	0	1
10/02/2021 21:00	0.0	0	0	0	0	1
10/02/2021 22:00	0.0	0	0	0	0	1
10/02/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/03/2021 00:00	0.0	0	0	0	0	1
10/03/2021 01:00	0.0	0	0	0	0	1
10/03/2021 02:00	0.0	0	0	0	0	1
10/03/2021 03:00	0.0	0	0	0	0	1
10/03/2021 04:00	0.0	0	0	0	0	1
10/03/2021 05:00	0.0	0	0	0	0	1
10/03/2021 06:00	0.0	0	0	0	0	1
10/03/2021 07:00	0.0	0	0	0	0	1
10/03/2021 08:00	0.0	0	0	0	0	1
10/03/2021 09:00	0.0	0	0	0	0	1
10/03/2021 10:00	0.0	0	0	0	0	1
10/03/2021 11:00	0.0	0	0	0	0	1
10/03/2021 12:00	0.0	0	0	0	0	1
10/03/2021 13:00	0.0	0	0	0	0	1
10/03/2021 14:00	0.0	0	0	0	0	1
10/03/2021 15:00	0.0	0	0	0	0	1
10/03/2021 16:00	0.0	0	0	0	0	1
10/03/2021 17:00	0.0	0	0	0	0	1
10/03/2021 18:00	0.0	0	0	0	0	1
10/03/2021 19:00	0.0	0	0	0	0	1
10/03/2021 20:00	0.0	0	0	0	0	1
10/03/2021 21:00	0.0	0	0	0	0	1
10/03/2021 22:00	0.0	0	0	0	0	1
10/03/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/04/2021 00:00	0.0	0	0	0	0	1
10/04/2021 01:00	0.0	0	0	0	0	1
10/04/2021 02:00	0.0	0	0	0	0	1
10/04/2021 03:00	0.0	0	0	0	0	1
10/04/2021 04:00	0.0	0	0	0	0	1
10/04/2021 05:00	0.0	0	0	0	0	1
10/04/2021 06:00	0.0	0	0	0	0	1
10/04/2021 07:00	0.0	0	0	0	0	1
10/04/2021 08:00	0.0	0	0	0	0	1
10/04/2021 09:00	0.0	0	0	0	0	1
10/04/2021 10:00	0.0	0	0	0	0	1
10/04/2021 11:00	0.0	0	0	0	0	1
10/04/2021 12:00	0.0	0	0	0	0	1
10/04/2021 13:00	0.0	0	0	0	0	1
10/04/2021 14:00	0.0	0	0	0	0	1
10/04/2021 15:00	0.0	0	0	0	0	1
10/04/2021 16:00	0.0	0	0	0	0	1
10/04/2021 17:00	0.0	0	0	0	0	1
10/04/2021 18:00	0.0	0	0	0	0	1
10/04/2021 19:00	0.0	0	0	0	0	1
10/04/2021 20:00	0.0	0	0	0	0	1
10/04/2021 21:00	0.0	0	0	0	0	1
10/04/2021 22:00	0.0	0	0	0	0	1
10/04/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/05/2021 00:00	0.0	0	0	0	0	1
10/05/2021 01:00	0.0	0	0	0	0	1
10/05/2021 02:00	0.0	0	0	0	0	1
10/05/2021 03:00	0.0	0	0	0	0	1
10/05/2021 04:00	0.0	0	0	0	0	1
10/05/2021 05:00	0.0	0	0	0	0	1
10/05/2021 06:00	0.0	0	0	0	0	1
10/05/2021 07:00	0.0	0	0	0	0	1
10/05/2021 08:00	0.0	0	0	0	0	1
10/05/2021 09:00	0.0	0	0	0	0	1
10/05/2021 10:00	0.0	0	0	0	0	1
10/05/2021 11:00	0.0	0	0	0	0	1
10/05/2021 12:00	0.0	0	0	0	0	1
10/05/2021 13:00	0.0	0	0	0	0	1
10/05/2021 14:00	0.0	0	0	0	0	1
10/05/2021 15:00	0.0	0	0	0	0	1
10/05/2021 16:00	0.0	0	0	0	0	1
10/05/2021 17:00	0.0	0	0	0	0	1
10/05/2021 18:00	0.0	0	0	0	0	1
10/05/2021 19:00	0.0	0	0	0	0	1
10/05/2021 20:00	0.0	0	0	0	0	1
10/05/2021 21:00	0.0	0	0	0	0	1
10/05/2021 22:00	0.0	0	0	0	0	1
10/05/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/06/2021 00:00	0.0	0	0	0	0	1
10/06/2021 01:00	0.0	0	0	0	0	1
10/06/2021 02:00	0.0	0	0	0	0	1
10/06/2021 03:00	0.0	0	0	0	0	1
10/06/2021 04:00	0.0	0	0	0	0	1
10/06/2021 05:00	0.0	0	0	0	0	1
10/06/2021 06:00	0.0	0	0	0	0	1
10/06/2021 07:00	0.0	0	0	0	0	1
10/06/2021 08:00	0.0	0	0	0	0	1
10/06/2021 09:00	0.0	0	0	0	0	1
10/06/2021 10:00	0.0	0	0	0	0	1
10/06/2021 11:00	0.0	0	0	0	0	1
10/06/2021 12:00	0.0	0	0	0	0	1
10/06/2021 13:00	0.0	0	0	0	0	1
10/06/2021 14:00	0.0	0	0	0	0	1
10/06/2021 15:00	0.0	0	0	0	0	1
10/06/2021 16:00	0.0	0	0	0	0	1
10/06/2021 17:00	0.0	0	0	0	0	1
10/06/2021 18:00	0.0	0	0	0	0	1
10/06/2021 19:00	0.0	0	0	0	0	1
10/06/2021 20:00	0.0	0	0	0	0	1
10/06/2021 21:00	0.0	0	0	0	0	1
10/06/2021 22:00	0.0	0	0	0	0	1
10/06/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/07/2021 00:00	0.0	0	0	0	0	1
10/07/2021 01:00	0.0	0	0	0	0	1
10/07/2021 02:00	0.0	0	0	0	0	1
10/07/2021 03:00	0.0	0	0	0	0	1
10/07/2021 04:00	0.0	0	0	0	0	1
10/07/2021 05:00	0.0	0	0	0	0	1
10/07/2021 06:00	0.0	0	0	0	0	1
10/07/2021 07:00	0.0	0	0	0	0	1
10/07/2021 08:00	0.0	0	0	0	0	1
10/07/2021 09:00	0.0	0	0	0	0	1
10/07/2021 10:00	0.0	0	0	0	0	1
10/07/2021 11:00	0.0	0	0	0	0	1
10/07/2021 12:00	0.0	0	0	0	0	1
10/07/2021 13:00	0.0	0	0	0	0	1
10/07/2021 14:00	0.0	0	0	0	0	1
10/07/2021 15:00	0.0	0	0	0	0	1
10/07/2021 16:00	0.0	0	0	0	0	1
10/07/2021 17:00	0.0	0	0	0	0	1
10/07/2021 18:00	0.0	0	0	0	0	1
10/07/2021 19:00	0.0	0	0	0	0	1
10/07/2021 20:00	0.0	0	0	0	0	1
10/07/2021 21:00	0.0	0	0	0	0	1
10/07/2021 22:00	0.0	0	0	0	0	1
10/07/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/08/2021 00:00	0.0	0	0	0	0	1
10/08/2021 01:00	0.0	0	0	0	0	1
10/08/2021 02:00	0.0	0	0	0	0	1
10/08/2021 03:00	0.0	0	0	0	0	1
10/08/2021 04:00	0.0	0	0	0	0	1
10/08/2021 05:00	0.0	0	0	0	0	1
10/08/2021 06:00	0.0	0	0	0	0	1
10/08/2021 07:00	0.0	0	0	0	0	1
10/08/2021 08:00	0.0	0	0	0	0	1
10/08/2021 09:00	0.0	0	0	0	0	1
10/08/2021 10:00	0.0	0	0	0	0	1
10/08/2021 11:00	0.0	0	0	0	0	1
10/08/2021 12:00	0.0	0	0	0	0	1
10/08/2021 13:00	0.0	0	0	0	0	1
10/08/2021 14:00	0.0	0	0	0	0	1
10/08/2021 15:00	0.0	0	0	0	0	1
10/08/2021 16:00	0.0	0	0	0	0	1
10/08/2021 17:00	0.0	0	0	0	0	1
10/08/2021 18:00	0.0	0	0	0	0	1
10/08/2021 19:00	0.0	0	0	0	0	1
10/08/2021 20:00	0.0	0	0	0	0	1
10/08/2021 21:00	22.2	0	0	0	1	0
10/08/2021 22:00	0.0	0	0	0	0	0
10/08/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	22.2 #	0 #	0 #	0 #	1 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	22.2	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/09/2021 00:00	0.0	0	0	0	0	0
10/09/2021 01:00	0.0	0	0	0	0	0
10/09/2021 02:00	0.0	0	0	0	0	0
10/09/2021 03:00	0.0	0	0	0	0	0
10/09/2021 04:00	0.0	0	0	0	0	0
10/09/2021 05:00	0.0	0	0	0	0	0
10/09/2021 06:00	0.0	0	0	0	0	0
10/09/2021 07:00	0.0	0	0	0	0	0
10/09/2021 08:00	0.0	0	0	0	0	0
10/09/2021 09:00	0.0	0	0	0	0	0
10/09/2021 10:00	0.0	0	0	0	0	0
10/09/2021 11:00	0.0	0	0	0	0	0
10/09/2021 12:00	0.0	0	0	0	0	0
10/09/2021 13:00	0.0	0	0	0	0	0
10/09/2021 14:00	0.0	0	0	0	0	0
10/09/2021 15:00	0.0	0	0	0	0	0
10/09/2021 16:00	0.0	0	0	0	0	0
10/09/2021 17:00	0.0	0	0	0	0	0
10/09/2021 18:00	0.0	0	0	0	0	0
10/09/2021 19:00	0.0	0	0	0	0	0
10/09/2021 20:00	0.0	0	0	0	0	0
10/09/2021 21:00	0.0	0	0	0	0	0
10/09/2021 22:00	0.0	0	0	0	0	0
10/09/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/10/2021 00:00	0.0	0	0	0	0	0
10/10/2021 01:00	0.0	0	0	0	0	0
10/10/2021 02:00	0.0	0	0	0	0	0
10/10/2021 03:00	0.0	0	0	0	0	0
10/10/2021 04:00	0.0	0	0	0	0	0
10/10/2021 05:00	0.0	0	0	0	0	0
10/10/2021 06:00	0.0	0	0	0	0	0
10/10/2021 07:00	0.0	0	0	0	0	0
10/10/2021 08:00	0.0	0	0	0	0	0
10/10/2021 09:00	0.0	0	0	0	0	0
10/10/2021 10:00	0.0	0	0	0	0	0
10/10/2021 11:00	0.0	0	0	0	0	0
10/10/2021 12:00	0.0	0	0	0	0	0
10/10/2021 13:00	0.0	0	0	0	0	0
10/10/2021 14:00	0.0	0	0	0	0	0
10/10/2021 15:00	0.0	0	0	0	0	0
10/10/2021 16:00	0.0	0	0	0	0	0
10/10/2021 17:00	0.0	0	0	0	0	0
10/10/2021 18:00	0.0	0	0	0	0	0
10/10/2021 19:00	0.0	0	0	0	0	0
10/10/2021 20:00	0.0	0	0	0	0	0
10/10/2021 21:00	0.0	0	0	0	0	0
10/10/2021 22:00	0.0	0	0	0	0	0
10/10/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/11/2021 00:00	0.0	0	0	0	0	0
10/11/2021 01:00	0.0	0	0	0	0	0
10/11/2021 02:00	0.0	0	0	0	0	0
10/11/2021 03:00	0.0	0	0	0	0	0
10/11/2021 04:00	0.0	0	0	0	0	0
10/11/2021 05:00	0.0	0	0	0	0	0
10/11/2021 06:00	0.0	0	0	0	0	0
10/11/2021 07:00	0.0	0	0	0	0	0
10/11/2021 08:00	0.0	0	0	0	0	0
10/11/2021 09:00	0.0	0	0	0	0	0
10/11/2021 10:00	0.0	0	0	0	0	0
10/11/2021 11:00	0.0	0	0	0	0	0
10/11/2021 12:00	0.0	0	0	0	0	0
10/11/2021 13:00	0.0	0	0	0	0	0
10/11/2021 14:00	0.0	0	0	0	0	0
10/11/2021 15:00	0.0	0	0	0	0	0
10/11/2021 16:00	0.0	0	0	0	0	0
10/11/2021 17:00	0.0	0	0	0	0	0
10/11/2021 18:00	0.0	0	0	0	0	0
10/11/2021 19:00	0.0	0	0	0	0	0
10/11/2021 20:00	0.0	0	0	0	0	0
10/11/2021 21:00	0.0	0	0	0	0	0
10/11/2021 22:00	0.0	0	0	0	0	0
10/11/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/12/2021 00:00	0.0	0	0	0	0	0
10/12/2021 01:00	0.0	0	0	0	0	0
10/12/2021 02:00	0.0	0	0	0	0	0
10/12/2021 03:00	0.0	0	0	0	0	0
10/12/2021 04:00	0.0	0	0	0	0	0
10/12/2021 05:00	0.0	0	0	0	0	0
10/12/2021 06:00	0.0	0	0	0	0	0
10/12/2021 07:00	0.0	0	0	0	0	0
10/12/2021 08:00	0.0	0	0	0	0	0
10/12/2021 09:00	0.0	0	0	0	0	0
10/12/2021 10:00	0.0	0	0	0	0	0
10/12/2021 11:00	0.0	0	0	0	0	0
10/12/2021 12:00	0.0	0	0	0	0	0
10/12/2021 13:00	0.0	0	0	0	0	0
10/12/2021 14:00	0.0	0	0	0	0	0
10/12/2021 15:00	0.0	0	0	0	0	0
10/12/2021 16:00	0.0	0	0	0	0	0
10/12/2021 17:00	0.0	0	0	0	0	0
10/12/2021 18:00	0.0	0	0	0	0	0
10/12/2021 19:00	0.0	0	0	0	0	0
10/12/2021 20:00	0.0	0	0	0	0	0
10/12/2021 21:00	0.0	0	0	0	0	0
10/12/2021 22:00	0.0	0	0	0	0	0
10/12/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/13/2021 00:00	0.0	0	0	0	0	0
10/13/2021 01:00	0.0	0	0	0	0	0
10/13/2021 02:00	0.0	0	0	0	0	0
10/13/2021 03:00	0.0	0	0	0	0	0
10/13/2021 04:00	0.0	0	0	0	0	0
10/13/2021 05:00	0.0	0	0	0	0	0
10/13/2021 06:00	0.0	0	0	0	0	0
10/13/2021 07:00	0.0	0	0	0	0	0
10/13/2021 08:00	0.0	0	0	0	0	0
10/13/2021 09:00	0.0	0	0	0	0	0
10/13/2021 10:00	0.0	0	0	0	0	0
10/13/2021 11:00	0.0	0	0	0	0	0
10/13/2021 12:00	0.0	0	0	0	0	0
10/13/2021 13:00	0.0	0	0	0	0	0
10/13/2021 14:00	0.0	0	0	0	0	0
10/13/2021 15:00	0.0	0	0	0	0	0
10/13/2021 16:00	0.0	0	0	0	0	0
10/13/2021 17:00	0.0	0	0	0	0	0
10/13/2021 18:00	0.0	0	0	0	0	0
10/13/2021 19:00	0.0	0	0	0	0	0
10/13/2021 20:00	0.0	0	0	0	0	0
10/13/2021 21:00	0.0	0	0	0	0	0
10/13/2021 22:00	0.0	0	0	0	0	0
10/13/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/14/2021 00:00	0.0	0	0	0	0	0
10/14/2021 01:00	0.0	0	0	0	0	0
10/14/2021 02:00	0.0	0	0	0	0	0
10/14/2021 03:00	0.0	0	0	0	0	0
10/14/2021 04:00	0.0	0	0	0	0	0
10/14/2021 05:00	0.0	0	0	0	0	0
10/14/2021 06:00	0.0	0	0	0	0	0
10/14/2021 07:00	0.0	0	0	0	0	0
10/14/2021 08:00	0.0	0	0	0	0	0
10/14/2021 09:00	0.0	0	0	0	0	0
10/14/2021 10:00	0.0	0	0	0	0	0
10/14/2021 11:00	0.0	0	0	0	0	0
10/14/2021 12:00	0.0	0	0	0	0	0
10/14/2021 13:00	0.0	0	0	0	0	0
10/14/2021 14:00	0.0	0	0	0	0	0
10/14/2021 15:00	0.0	0	0	0	0	0
10/14/2021 16:00	0.0	0	0	0	0	0
10/14/2021 17:00	0.0	0	0	0	0	0
10/14/2021 18:00	0.0	0	0	0	0	0
10/14/2021 19:00	0.0	0	0	0	0	0
10/14/2021 20:00	0.0	0	0	0	0	0
10/14/2021 21:00	0.0	0	0	0	0	0
10/14/2021 22:00	0.0	0	0	0	0	0
10/14/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/15/2021 00:00	0.0	0	0	0	0	0
10/15/2021 01:00	0.0	0	0	0	0	0
10/15/2021 02:00	0.0	0	0	0	0	0
10/15/2021 03:00	0.0	0	0	0	0	0
10/15/2021 04:00	0.0	0	0	0	0	0
10/15/2021 05:00	0.0	0	0	0	0	0
10/15/2021 06:00	0.0	0	0	0	0	0
10/15/2021 07:00	0.0	0	0	0	0	0
10/15/2021 08:00	0.0	0	0	0	0	0
10/15/2021 09:00	0.0	0	0	0	0	0
10/15/2021 10:00	0.0	0	0	0	0	0
10/15/2021 11:00	0.0	0	0	0	0	0
10/15/2021 12:00	0.0	0	0	0	0	0
10/15/2021 13:00	0.0	0	0	0	0	0
10/15/2021 14:00	0.0	0	0	0	0	0
10/15/2021 15:00	0.0	0	0	0	0	0
10/15/2021 16:00	0.0	0	0	0	0	0
10/15/2021 17:00	0.0	0	0	0	0	0
10/15/2021 18:00	0.0	0	0	0	0	0
10/15/2021 19:00	0.0	0	0	0	0	0
10/15/2021 20:00	0.0	0	0	0	0	0
10/15/2021 21:00	0.0	0	0	0	0	0
10/15/2021 22:00	0.0	0	0	0	0	0
10/15/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/16/2021 00:00	0.0	0	0	0	0	0
10/16/2021 01:00	0.0	0	0	0	0	0
10/16/2021 02:00	0.0	0	0	0	0	0
10/16/2021 03:00	0.0	0	0	0	0	0
10/16/2021 04:00	0.0	0	0	0	0	0
10/16/2021 05:00	0.0	0	0	0	0	0
10/16/2021 06:00	0.0	0	0	0	0	0
10/16/2021 07:00	0.0	0	0	0	0	0
10/16/2021 08:00	0.0	0	0	0	0	0
10/16/2021 09:00	0.0	0	0	0	0	0
10/16/2021 10:00	0.0	0	0	0	0	0
10/16/2021 11:00	0.0	0	0	0	0	0
10/16/2021 12:00	0.0	0	0	0	0	0
10/16/2021 13:00	0.0	0	0	0	0	0
10/16/2021 14:00	0.0	0	0	0	0	0
10/16/2021 15:00	0.0	0	0	0	0	0
10/16/2021 16:00	0.0	0	0	0	0	0
10/16/2021 17:00	0.0	0	0	0	0	0
10/16/2021 18:00	0.0	0	0	0	0	0
10/16/2021 19:00	0.0	0	0	0	0	0
10/16/2021 20:00	0.0	0	0	0	0	0
10/16/2021 21:00	0.0	0	0	0	0	0
10/16/2021 22:00	0.0	0	0	0	0	0
10/16/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/17/2021 00:00	0.0	0	0	0	0	0
10/17/2021 01:00	0.0	0	0	0	0	0
10/17/2021 02:00	0.0	0	0	0	0	0
10/17/2021 03:00	0.0	0	0	0	0	0
10/17/2021 04:00	0.0	0	0	0	0	0
10/17/2021 05:00	0.0	0	0	0	0	0
10/17/2021 06:00	0.0	0	0	0	0	0
10/17/2021 07:00	0.0	0	0	0	0	0
10/17/2021 08:00	0.0	0	0	0	0	0
10/17/2021 09:00	0.0	0	0	0	0	0
10/17/2021 10:00	0.0	0	0	0	0	0
10/17/2021 11:00	0.0	0	0	0	0	0
10/17/2021 12:00	0.0	0	0	0	0	0
10/17/2021 13:00	0.0	0	0	0	0	0
10/17/2021 14:00	0.0	0	0	0	0	0
10/17/2021 15:00	0.0	0	0	0	0	0
10/17/2021 16:00	0.0	0	0	0	0	0
10/17/2021 17:00	0.0	0	0	0	0	0
10/17/2021 18:00	0.0	0	0	0	0	0
10/17/2021 19:00	0.0	0	0	0	0	0
10/17/2021 20:00	0.0	0	0	0	0	0
10/17/2021 21:00	0.0	0	0	0	0	0
10/17/2021 22:00	0.0	0	0	0	0	0
10/17/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/18/2021 00:00	0.0	0	0	0	0	0
10/18/2021 01:00	0.0	0	0	0	0	0
10/18/2021 02:00	0.0	0	0	0	0	0
10/18/2021 03:00	0.0	0	0	0	0	0
10/18/2021 04:00	0.0	0	0	0	0	0
10/18/2021 05:00	0.0	0	0	0	0	0
10/18/2021 06:00	0.0	0	0	0	0	0
10/18/2021 07:00	0.0	0	0	0	0	0
10/18/2021 08:00	0.0	0	0	0	0	0
10/18/2021 09:00	0.0	0	0	0	0	0
10/18/2021 10:00	0.0	0	0	0	0	0
10/18/2021 11:00	0.0	0	0	0	0	0
10/18/2021 12:00	0.0	0	0	0	0	0
10/18/2021 13:00	0.0	0	0	0	0	0
10/18/2021 14:00	0.0	0	0	0	0	0
10/18/2021 15:00	0.0	0	0	0	0	0
10/18/2021 16:00	0.0	0	0	0	0	0
10/18/2021 17:00	0.0	0	0	0	0	0
10/18/2021 18:00	0.0	0	0	0	0	0
10/18/2021 19:00	0.0	0	0	0	0	0
10/18/2021 20:00	0.0	0	0	0	0	0
10/18/2021 21:00	0.0	0	0	0	0	0
10/18/2021 22:00	0.0	0	0	0	0	0
10/18/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/19/2021 00:00	0.0	0	0	0	0	0
10/19/2021 01:00	0.0	0	0	0	0	0
10/19/2021 02:00	0.0	0	0	0	0	0
10/19/2021 03:00	0.0	0	0	0	0	0
10/19/2021 04:00	0.0	0	0	0	0	0
10/19/2021 05:00	0.0	0	0	0	0	0
10/19/2021 06:00	0.0	0	0	0	0	0
10/19/2021 07:00	0.0	0	0	0	0	0
10/19/2021 08:00	0.0	0	0	0	0	0
10/19/2021 09:00	0.0	0	0	0	0	0
10/19/2021 10:00	0.0	0	0	0	0	0
10/19/2021 11:00	0.0	0	0	0	0	0
10/19/2021 12:00	0.0	0	0	0	0	0
10/19/2021 13:00	0.0	0	0	0	0	0
10/19/2021 14:00	0.0	0	0	0	0	0
10/19/2021 15:00	0.0	0	0	0	0	0
10/19/2021 16:00	0.0	0	0	0	0	0
10/19/2021 17:00	0.0	0	0	0	0	0
10/19/2021 18:00	0.0	0	0	0	0	0
10/19/2021 19:00	0.0	0	0	0	0	0
10/19/2021 20:00	0.0	0	0	0	0	0
10/19/2021 21:00	0.0	0	0	0	0	0
10/19/2021 22:00	0.0	0	0	0	0	0
10/19/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/20/2021 00:00	0.0	0	0	0	0	0
10/20/2021 01:00	0.0	0	0	0	0	0
10/20/2021 02:00	0.0	0	0	0	0	0
10/20/2021 03:00	0.0	0	0	0	0	0
10/20/2021 04:00	0.0	0	0	0	0	0
10/20/2021 05:00	0.0	0	0	0	0	0
10/20/2021 06:00	0.0	0	0	0	0	0
10/20/2021 07:00	0.0	0	0	0	0	0
10/20/2021 08:00	503.3	1	0	0	0	0
10/20/2021 09:00	3,672.0	1	0	0	0	0
10/20/2021 10:00	3,904.0	1	0	0	0	0
10/20/2021 11:00	6,398.3	1	0	0	0	0
10/20/2021 12:00	4,807.3	1	0	0	0	0
10/20/2021 13:00	0.0	0	0	0	0	1
10/20/2021 14:00	0.0	0	0	0	0	1
10/20/2021 15:00	0.0	0	0	0	0	1
10/20/2021 16:00	0.0	0	0	0	0	1
10/20/2021 17:00	0.0	0	0	0	0	1
10/20/2021 18:00	0.0	0	0	0	0	1
10/20/2021 19:00	0.0	0	0	0	0	1
10/20/2021 20:00	0.0	0	0	0	0	1
10/20/2021 21:00	0.0	0	0	0	0	1
10/20/2021 22:00	24.1	0	0	0	1	0
10/20/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	19,309.0 #	5 #	0 #	0 #	1 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,398.3	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/21/2021 00:00	0.0	0	0	0	0	0
10/21/2021 01:00	0.0	0	0	0	0	0
10/21/2021 02:00	0.0	0	0	0	0	0
10/21/2021 03:00	0.0	0	0	0	0	0
10/21/2021 04:00	0.0	0	0	0	0	0
10/21/2021 05:00	0.0	0	0	0	0	0
10/21/2021 06:00	0.0	0	0	0	0	0
10/21/2021 07:00	0.0	0	0	0	0	0
10/21/2021 08:00	0.0	0	0	0	0	0
10/21/2021 09:00	0.0	0	0	0	0	0
10/21/2021 10:00	0.0	0	0	0	0	0
10/21/2021 11:00	0.0	0	0	0	0	0
10/21/2021 12:00	0.0	0	0	0	0	0
10/21/2021 13:00	0.0	0	0	0	0	0
10/21/2021 14:00	0.0	0	0	0	0	0
10/21/2021 15:00	0.0	0	0	0	0	0
10/21/2021 16:00	0.0	0	0	0	0	0
10/21/2021 17:00	0.0	0	0	0	0	0
10/21/2021 18:00	0.0	0	0	0	0	0
10/21/2021 19:00	0.0	0	0	0	0	0
10/21/2021 20:00	0.0	0	0	0	0	0
10/21/2021 21:00	0.0	0	0	0	0	0
10/21/2021 22:00	0.0	0	0	0	0	0
10/21/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/22/2021 00:00	0.0	0	0	0	0	0
10/22/2021 01:00	0.0	0	0	0	0	0
10/22/2021 02:00	0.0	0	0	0	0	0
10/22/2021 03:00	0.0	0	0	0	0	0
10/22/2021 04:00	0.0	0	0	0	0	0
10/22/2021 05:00	0.0	0	0	0	0	0
10/22/2021 06:00	0.0	0	0	0	0	0
10/22/2021 07:00	0.0	0	0	0	0	0
10/22/2021 08:00	0.0	0	0	0	0	0
10/22/2021 09:00	0.0	0	0	0	0	0
10/22/2021 10:00	0.0	0	0	0	0	0
10/22/2021 11:00	0.0	0	0	0	0	0
10/22/2021 12:00	0.0	0	0	0	0	0
10/22/2021 13:00	0.0	0	0	0	0	0
10/22/2021 14:00	0.0	0	0	0	0	0
10/22/2021 15:00	0.0	0	0	0	0	0
10/22/2021 16:00	0.0	0	0	0	0	0
10/22/2021 17:00	0.0	0	0	0	0	0
10/22/2021 18:00	0.0	0	0	0	0	0
10/22/2021 19:00	0.0	0	0	0	0	0
10/22/2021 20:00	0.0	0	0	0	0	0
10/22/2021 21:00	0.0	0	0	0	0	0
10/22/2021 22:00	0.0	0	0	0	0	0
10/22/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/23/2021 00:00	0.0	0	0	0	0	0
10/23/2021 01:00	0.0	0	0	0	0	0
10/23/2021 02:00	0.0	0	0	0	0	0
10/23/2021 03:00	0.0	0	0	0	0	0
10/23/2021 04:00	0.0	0	0	0	0	0
10/23/2021 05:00	0.0	0	1	0	0	0
10/23/2021 06:00	3,643.9	0	1	0	0	0
10/23/2021 07:00	3,902.6	0	1	0	0	0
10/23/2021 08:00	0.0	0	0	0	0	1
10/23/2021 09:00	0.0	0	0	0	0	1
10/23/2021 10:00	0.0	0	0	0	0	1
10/23/2021 11:00	0.0	0	0	0	0	1
10/23/2021 12:00	0.0	0	0	0	0	1
10/23/2021 13:00	0.0	0	0	0	0	1
10/23/2021 14:00	0.0	0	0	0	0	1
10/23/2021 15:00	0.0	0	0	0	0	1
10/23/2021 16:00	0.0	0	0	0	0	1
10/23/2021 17:00	0.0	0	0	0	0	1
10/23/2021 18:00	0.0	0	0	0	0	1
10/23/2021 19:00	0.0	0	0	0	0	1
10/23/2021 20:00	0.0	0	0	0	0	1
10/23/2021 21:00	0.0	0	0	0	0	1
10/23/2021 22:00	62.0	0	0	0	1	0
10/23/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	7,608.5 #	0 #	3 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3,902.6	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/24/2021 00:00	0.0	0	0	0	0	0
10/24/2021 01:00	0.0	0	0	0	0	0
10/24/2021 02:00	0.0	0	0	0	0	0
10/24/2021 03:00	326.0	0	0	1	0	0
10/24/2021 04:00	6,221.1	0	0	1	0	0
10/24/2021 05:00	0.0	0	0	0	0	1
10/24/2021 06:00	0.0	0	0	0	0	1
10/24/2021 07:00	0.0	0	0	0	0	1
10/24/2021 08:00	0.0	0	0	0	0	1
10/24/2021 09:00	0.0	0	0	0	0	1
10/24/2021 10:00	0.0	0	0	0	0	1
10/24/2021 11:00	0.0	0	0	0	0	1
10/24/2021 12:00	0.0	0	0	0	0	1
10/24/2021 13:00	0.0	0	0	0	0	1
10/24/2021 14:00	0.0	0	0	0	0	1
10/24/2021 15:00	0.0	0	0	0	0	1
10/24/2021 16:00	0.0	0	0	0	0	1
10/24/2021 17:00	0.0	0	0	0	0	1
10/24/2021 18:00	0.0	0	0	0	0	1
10/24/2021 19:00	0.0	0	0	0	0	1
10/24/2021 20:00	0.0	0	0	0	0	1
10/24/2021 21:00	0.0	0	0	0	0	1
10/24/2021 22:00	0.0	0	0	0	0	1
10/24/2021 23:00	19.9	0	0	0	1	0
Average/Sum#:	6,567.0 #	0 #	0 #	2 #	1 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,221.1	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/25/2021 00:00	0.0	0	0	0	0	0
10/25/2021 01:00	0.0	0	0	0	0	0
10/25/2021 02:00	0.0	0	0	0	0	0
10/25/2021 03:00	0.0	0	0	0	0	0
10/25/2021 04:00	0.0	0	0	0	0	0
10/25/2021 05:00	2,089.8	0	0	1	0	0
10/25/2021 06:00	3,879.6	0	0	1	0	0
10/25/2021 07:00	0.0	0	0	0	0	1
10/25/2021 08:00	0.0	0	0	0	0	1
10/25/2021 09:00	0.0	0	0	0	0	1
10/25/2021 10:00	0.0	0	0	0	0	1
10/25/2021 11:00	0.0	0	0	0	0	1
10/25/2021 12:00	0.0	0	0	0	0	1
10/25/2021 13:00	0.0	0	0	0	0	1
10/25/2021 14:00	0.0	0	0	0	0	1
10/25/2021 15:00	0.0	0	0	0	0	1
10/25/2021 16:00	0.0	0	0	0	0	1
10/25/2021 17:00	0.0	0	0	0	0	1
10/25/2021 18:00	0.0	0	0	0	0	1
10/25/2021 19:00	0.0	0	0	0	0	1
10/25/2021 20:00	0.0	0	0	0	0	1
10/25/2021 21:00	0.0	0	0	0	0	1
10/25/2021 22:00	0.0	0	0	0	0	1
10/25/2021 23:00	12.5	0	0	0	1	0
Average/Sum#:	5,981.9 #	0 #	0 #	2 #	1 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3,879.6	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/26/2021 00:00	0.0	0	0	0	0	0
10/26/2021 01:00	0.0	0	0	0	0	0
10/26/2021 02:00	0.0	0	0	0	0	0
10/26/2021 03:00	0.0	0	0	0	0	0
10/26/2021 04:00	0.0	0	0	0	0	0
10/26/2021 05:00	1,879.2	0	0	1	0	0
10/26/2021 06:00	4,212.7	0	0	1	0	0
10/26/2021 07:00	0.0	0	0	0	0	1
10/26/2021 08:00	0.0	0	0	0	0	1
10/26/2021 09:00	0.0	0	0	0	0	1
10/26/2021 10:00	0.0	0	0	0	0	1
10/26/2021 11:00	0.0	0	0	0	0	1
10/26/2021 12:00	0.0	0	0	0	0	1
10/26/2021 13:00	0.0	0	0	0	0	1
10/26/2021 14:00	0.0	0	0	0	0	1
10/26/2021 15:00	0.0	0	0	0	0	1
10/26/2021 16:00	0.0	0	0	0	0	1
10/26/2021 17:00	0.0	0	0	0	0	1
10/26/2021 18:00	0.0	0	0	0	0	1
10/26/2021 19:00	0.0	0	0	0	0	1
10/26/2021 20:00	0.0	0	0	0	0	1
10/26/2021 21:00	0.0	0	0	0	0	1
10/26/2021 22:00	0.0	0	0	0	0	1
10/26/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,091.9 #	0 #	0 #	2 #	0 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,212.7	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/27/2021 00:00	0.0	0	0	0	0	1
10/27/2021 01:00	0.0	0	0	0	0	1
10/27/2021 02:00	0.0	0	0	0	0	1
10/27/2021 03:00	0.0	0	0	0	0	1
10/27/2021 04:00	0.0	0	0	0	0	1
10/27/2021 05:00	0.0	0	0	0	0	1
10/27/2021 06:00	0.0	0	0	0	0	1
10/27/2021 07:00	0.0	0	0	0	0	1
10/27/2021 08:00	0.0	0	0	0	0	1
10/27/2021 09:00	0.0	0	0	0	0	1
10/27/2021 10:00	0.0	0	0	0	0	1
10/27/2021 11:00	0.0	0	0	0	0	1
10/27/2021 12:00	0.0	0	0	0	0	1
10/27/2021 13:00	0.0	0	0	0	0	1
10/27/2021 14:00	0.0	0	0	0	0	1
10/27/2021 15:00	0.0	0	0	0	0	1
10/27/2021 16:00	0.0	0	0	0	0	1
10/27/2021 17:00	0.0	0	0	0	0	1
10/27/2021 18:00	0.0	0	0	0	0	1
10/27/2021 19:00	0.0	0	0	0	0	1
10/27/2021 20:00	0.0	0	0	0	0	1
10/27/2021 21:00	0.0	0	0	0	0	1
10/27/2021 22:00	0.0	0	0	0	0	1
10/27/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/28/2021 00:00	34.8	0	0	0	1	0
10/28/2021 01:00	0.0	0	0	0	0	0
10/28/2021 02:00	0.0	0	0	0	0	0
10/28/2021 03:00	0.0	0	0	0	0	0
10/28/2021 04:00	0.0	0	0	0	0	0
10/28/2021 05:00	0.0	0	0	0	0	0
10/28/2021 06:00	0.0	0	0	0	0	0
10/28/2021 07:00	0.0	0	0	0	0	0
10/28/2021 08:00	0.0	0	0	0	0	0
10/28/2021 09:00	0.0	0	0	0	0	0
10/28/2021 10:00	0.0	0	0	0	0	0
10/28/2021 11:00	0.0	0	0	0	0	0
10/28/2021 12:00	1,055.0	0	1	0	0	0
10/28/2021 13:00	5,154.7	0	1	0	0	0
10/28/2021 14:00	0.0	0	0	0	0	1
10/28/2021 15:00	0.0	0	0	0	0	1
10/28/2021 16:00	0.0	0	0	0	0	1
10/28/2021 17:00	0.0	0	0	0	0	1
10/28/2021 18:00	0.0	0	0	0	0	1
10/28/2021 19:00	0.0	0	0	0	0	1
10/28/2021 20:00	0.0	0	0	0	0	1
10/28/2021 21:00	0.0	0	0	0	0	1
10/28/2021 22:00	0.0	0	0	0	0	1
10/28/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,244.5 #	0 #	2 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,154.7	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/29/2021 00:00	0.0	0	0	0	0	1
10/29/2021 01:00	0.0	0	0	0	0	1
10/29/2021 02:00	0.0	0	0	0	0	1
10/29/2021 03:00	0.0	0	0	0	0	1
10/29/2021 04:00	0.0	0	0	0	0	1
10/29/2021 05:00	0.0	0	0	0	0	1
10/29/2021 06:00	0.0	0	0	0	0	1
10/29/2021 07:00	0.0	0	0	0	0	1
10/29/2021 08:00	0.0	0	0	0	0	1
10/29/2021 09:00	0.0	0	0	0	0	1
10/29/2021 10:00	0.0	0	0	0	0	1
10/29/2021 11:00	0.0	0	0	0	0	1
10/29/2021 12:00	0.0	0	0	0	0	1
10/29/2021 13:00	0.0	0	0	0	0	1
10/29/2021 14:00	0.0	0	0	0	0	1
10/29/2021 15:00	0.0	0	0	0	0	1
10/29/2021 16:00	0.0	0	0	0	0	1
10/29/2021 17:00	0.0	0	0	0	0	1
10/29/2021 18:00	0.0	0	0	0	0	1
10/29/2021 19:00	0.0	0	0	0	0	1
10/29/2021 20:00	0.0	0	0	0	0	1
10/29/2021 21:00	0.0	0	0	0	0	1
10/29/2021 22:00	0.0	0	0	0	0	1
10/29/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/30/2021 00:00	0.0	0	0	0	0	1
10/30/2021 01:00	0.0	0	0	0	0	1
10/30/2021 02:00	0.0	0	0	0	0	1
10/30/2021 03:00	0.0	0	0	0	0	1
10/30/2021 04:00	0.0	0	0	0	0	1
10/30/2021 05:00	0.0	0	0	0	0	1
10/30/2021 06:00	0.0	0	0	0	0	1
10/30/2021 07:00	0.0	0	0	0	0	1
10/30/2021 08:00	0.0	0	0	0	0	1
10/30/2021 09:00	0.0	0	0	0	0	1
10/30/2021 10:00	0.0	0	0	0	0	1
10/30/2021 11:00	0.0	0	0	0	0	1
10/30/2021 12:00	0.0	0	0	0	0	1
10/30/2021 13:00	0.0	0	0	0	0	1
10/30/2021 14:00	0.0	0	0	0	0	1
10/30/2021 15:00	0.0	0	0	0	0	1
10/30/2021 16:00	0.0	0	0	0	0	1
10/30/2021 17:00	0.0	0	0	0	0	1
10/30/2021 18:00	0.0	0	0	0	0	1
10/30/2021 19:00	0.0	0	0	0	0	1
10/30/2021 20:00	0.0	0	0	0	0	1
10/30/2021 21:00	0.0	0	0	0	0	1
10/30/2021 22:00	0.0	0	0	0	0	1
10/30/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/31/2021 00:00	0.0	0	0	0	0	1
10/31/2021 01:00	0.0	0	0	0	0	1
10/31/2021 02:00	0.0	0	0	0	0	1
10/31/2021 03:00	0.0	0	0	0	0	1
10/31/2021 04:00	0.0	0	0	0	0	1
10/31/2021 05:00	0.0	0	0	0	0	1
10/31/2021 06:00	0.0	0	0	0	0	1
10/31/2021 07:00	0.0	0	0	0	0	1
10/31/2021 08:00	0.0	0	0	0	0	1
10/31/2021 09:00	0.0	0	0	0	0	1
10/31/2021 10:00	0.0	0	0	0	0	1
10/31/2021 11:00	0.0	0	0	0	0	1
10/31/2021 12:00	0.0	0	0	0	0	1
10/31/2021 13:00	0.0	0	0	0	0	1
10/31/2021 14:00	0.0	0	0	0	0	1
10/31/2021 15:00	0.0	0	0	0	0	1
10/31/2021 16:00	0.0	0	0	0	0	1
10/31/2021 17:00	0.0	0	0	0	0	1
10/31/2021 18:00	0.0	0	0	0	0	1
10/31/2021 19:00	0.0	0	0	0	0	1
10/31/2021 20:00	0.0	0	0	0	0	1
10/31/2021 21:00	0.0	0	0	0	0	1
10/31/2021 22:00	0.0	0	0	0	0	1
10/31/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/01/2021 00:00	0.0	0	0	0	0	1
11/01/2021 01:00	0.0	0	0	0	0	1
11/01/2021 02:00	0.0	0	0	0	0	1
11/01/2021 03:00	0.0	0	0	0	0	1
11/01/2021 04:00	0.0	0	0	0	0	1
11/01/2021 05:00	0.0	0	0	0	0	1
11/01/2021 06:00	0.0	0	0	0	0	1
11/01/2021 07:00	0.0	0	0	0	0	1
11/01/2021 08:00	0.0	0	0	0	0	1
11/01/2021 09:00	0.0	0	0	0	0	1
11/01/2021 10:00	0.0	0	0	0	0	1
11/01/2021 11:00	0.0	0	0	0	0	1
11/01/2021 12:00	0.0	0	0	0	0	1
11/01/2021 13:00	0.0	0	0	0	0	1
11/01/2021 14:00	0.0	0	0	0	0	1
11/01/2021 15:00	0.0	0	0	0	0	1
11/01/2021 16:00	0.0	0	0	0	0	1
11/01/2021 17:00	0.0	0	0	0	0	1
11/01/2021 18:00	0.0	0	0	0	0	1
11/01/2021 19:00	0.0	0	0	0	0	1
11/01/2021 20:00	0.0	0	0	0	0	1
11/01/2021 21:00	0.0	0	0	0	0	1
11/01/2021 22:00	0.0	0	0	0	0	1
11/01/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/02/2021 00:00	0.0	0	0	0	0	1
11/02/2021 01:00	0.0	0	0	0	0	1
11/02/2021 02:00	0.0	0	0	0	0	1
11/02/2021 03:00	0.0	0	0	0	0	1
11/02/2021 04:00	0.0	0	0	0	0	1
11/02/2021 05:00	0.0	0	0	0	0	1
11/02/2021 06:00	0.0	0	0	0	0	1
11/02/2021 07:00	0.0	0	0	0	0	1
11/02/2021 08:00	0.0	0	0	0	0	1
11/02/2021 09:00	0.0	0	0	0	0	1
11/02/2021 10:00	0.0	0	0	0	0	1
11/02/2021 11:00	0.0	0	0	0	0	1
11/02/2021 12:00	0.0	0	0	0	0	1
11/02/2021 13:00	0.0	0	0	0	0	1
11/02/2021 14:00	0.0	0	0	0	0	1
11/02/2021 15:00	0.0	0	0	0	0	1
11/02/2021 16:00	0.0	0	0	0	0	1
11/02/2021 17:00	0.0	0	0	0	0	1
11/02/2021 18:00	0.0	0	0	0	0	1
11/02/2021 19:00	0.0	0	0	0	0	1
11/02/2021 20:00	0.0	0	0	0	0	1
11/02/2021 21:00	0.0	0	0	0	0	1
11/02/2021 22:00	0.0	0	0	0	0	1
11/02/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/03/2021 00:00	0.0	0	0	0	0	1
11/03/2021 01:00	0.0	0	0	0	0	1
11/03/2021 02:00	0.0	0	0	0	0	1
11/03/2021 03:00	0.0	0	0	0	0	1
11/03/2021 04:00	0.0	0	0	0	0	1
11/03/2021 05:00	0.0	0	0	0	0	1
11/03/2021 06:00	0.0	0	0	0	0	1
11/03/2021 07:00	0.0	0	0	0	0	1
11/03/2021 08:00	0.0	0	0	0	0	1
11/03/2021 09:00	0.0	0	0	0	0	1
11/03/2021 10:00	0.0	0	0	0	0	1
11/03/2021 11:00	0.0	0	0	0	0	1
11/03/2021 12:00	0.0	0	0	0	0	1
11/03/2021 13:00	0.0	0	0	0	0	1
11/03/2021 14:00	0.0	0	0	0	0	1
11/03/2021 15:00	0.0	0	0	0	0	1
11/03/2021 16:00	0.0	0	0	0	0	1
11/03/2021 17:00	0.0	0	0	0	0	1
11/03/2021 18:00	0.0	0	0	0	0	1
11/03/2021 19:00	0.0	0	0	0	0	1
11/03/2021 20:00	0.0	0	0	0	0	1
11/03/2021 21:00	0.0	0	0	0	0	1
11/03/2021 22:00	0.0	0	0	0	0	1
11/03/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/04/2021 00:00	0.0	0	0	0	0	1
11/04/2021 01:00	0.0	0	0	0	0	1
11/04/2021 02:00	0.0	0	0	0	0	1
11/04/2021 03:00	0.0	0	0	0	0	1
11/04/2021 04:00	0.0	0	0	0	0	1
11/04/2021 05:00	0.0	0	0	0	0	1
11/04/2021 06:00	0.0	0	0	0	0	1
11/04/2021 07:00	0.0	0	0	0	0	1
11/04/2021 08:00	0.0	0	0	0	0	1
11/04/2021 09:00	0.0	0	0	0	0	1
11/04/2021 10:00	0.0	0	0	0	0	1
11/04/2021 11:00	0.0	0	0	0	0	1
11/04/2021 12:00	0.0	0	0	0	0	1
11/04/2021 13:00	0.0	0	0	0	0	1
11/04/2021 14:00	0.0	0	0	0	0	1
11/04/2021 15:00	0.0	0	0	0	0	1
11/04/2021 16:00	0.0	0	0	0	0	1
11/04/2021 17:00	0.0	0	0	0	0	1
11/04/2021 18:00	0.0	0	0	0	0	1
11/04/2021 19:00	0.0	0	0	0	0	1
11/04/2021 20:00	0.0	0	0	0	0	1
11/04/2021 21:00	0.0	0	0	0	0	1
11/04/2021 22:00	0.0	0	0	0	0	1
11/04/2021 23:00	66.9	0	0	0	1	0
Average/Sum#:	66.9 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	66.9	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/05/2021 00:00	0.0	0	0	0	0	0
11/05/2021 01:00	0.0	0	0	0	0	0
11/05/2021 02:00	0.0	0	0	0	0	0
11/05/2021 03:00	0.0	0	0	0	0	0
11/05/2021 04:00	0.0	0	0	0	0	0
11/05/2021 05:00	0.0	0	0	0	0	0
11/05/2021 06:00	0.0	0	0	0	0	0
11/05/2021 07:00	0.0	0	0	0	0	0
11/05/2021 08:00	0.0	0	0	0	0	0
11/05/2021 09:00	0.0	0	0	0	0	0
11/05/2021 10:00	0.0	0	0	0	0	0
11/05/2021 11:00	0.0	0	0	0	0	0
11/05/2021 12:00	0.0	0	0	0	0	0
11/05/2021 13:00	2,265.9	0	1	0	0	0
11/05/2021 14:00	4,394.2	0	1	0	0	0
11/05/2021 15:00	0.0	0	0	0	0	1
11/05/2021 16:00	0.0	0	0	0	0	1
11/05/2021 17:00	0.0	0	0	0	0	1
11/05/2021 18:00	0.0	0	0	0	0	1
11/05/2021 19:00	0.0	0	0	0	0	1
11/05/2021 20:00	0.0	0	0	0	0	1
11/05/2021 21:00	0.0	0	0	0	0	1
11/05/2021 22:00	0.0	0	0	0	0	1
11/05/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,660.1 #	0 #	2 #	0 #	0 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,394.2	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/06/2021 00:00	0.0	0	0	0	0	1
11/06/2021 01:00	0.0	0	0	0	0	1
11/06/2021 02:00	0.0	0	0	0	0	1
11/06/2021 03:00	0.0	0	0	0	0	1
11/06/2021 04:00	0.0	0	0	0	0	1
11/06/2021 05:00	0.0	0	0	0	0	1
11/06/2021 06:00	0.0	0	0	0	0	1
11/06/2021 07:00	0.0	0	0	0	0	1
11/06/2021 08:00	0.0	0	0	0	0	1
11/06/2021 09:00	0.0	0	0	0	0	1
11/06/2021 10:00	0.0	0	0	0	0	1
11/06/2021 11:00	0.0	0	0	0	0	1
11/06/2021 12:00	0.0	0	0	0	0	1
11/06/2021 13:00	0.0	0	0	0	0	1
11/06/2021 14:00	0.0	0	0	0	0	1
11/06/2021 15:00	0.0	0	0	0	0	1
11/06/2021 16:00	0.0	0	0	0	0	1
11/06/2021 17:00	0.0	0	0	0	0	1
11/06/2021 18:00	0.0	0	0	0	0	1
11/06/2021 19:00	0.0	0	0	0	0	1
11/06/2021 20:00	0.0	0	0	0	0	1
11/06/2021 21:00	0.0	0	0	0	0	1
11/06/2021 22:00	25.8	0	0	0	1	0
11/06/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	25.8 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	25.8	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/07/2021 00:00	0.0	0	0	0	0	0
11/07/2021 01:00	0.0	0	0	0	0	0
11/07/2021 02:00	0.0	0	0	0	0	0
11/07/2021 03:00	0.0	0	0	0	0	0
11/07/2021 04:00	0.0	0	0	0	0	0
11/07/2021 05:00	0.0	0	0	0	0	0
11/07/2021 06:00	0.0	0	0	0	0	0
11/07/2021 07:00	0.0	0	0	0	0	0
11/07/2021 08:00	0.0	0	0	0	0	0
11/07/2021 09:00	0.0	0	0	0	0	0
11/07/2021 10:00	0.0	0	0	0	0	0
11/07/2021 11:00	0.0	0	0	0	0	0
11/07/2021 12:00	0.0	0	0	0	0	0
11/07/2021 13:00	0.0	0	0	0	0	0
11/07/2021 14:00	0.0	0	0	0	0	0
11/07/2021 15:00	0.0	0	0	0	0	0
11/07/2021 16:00	0.0	0	0	0	0	0
11/07/2021 17:00	0.0	0	0	0	0	0
11/07/2021 18:00	0.0	0	0	0	0	0
11/07/2021 19:00	0.0	0	0	0	0	0
11/07/2021 20:00	0.0	0	0	0	0	0
11/07/2021 21:00	0.0	0	0	0	0	0
11/07/2021 22:00	0.0	0	0	0	0	0
11/07/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/08/2021 00:00	0.0	0	0	0	0	0
11/08/2021 01:00	0.0	0	0	0	0	0
11/08/2021 02:00	0.0	0	0	0	0	0
11/08/2021 03:00	0.0	0	0	0	0	0
11/08/2021 04:00	0.0	0	0	0	0	0
11/08/2021 05:00	0.0	0	0	0	0	0
11/08/2021 06:00	0.0	0	0	0	0	0
11/08/2021 07:00	0.0	0	0	0	0	0
11/08/2021 08:00	0.0	0	0	0	0	0
11/08/2021 09:00	0.0	0	0	0	0	0
11/08/2021 10:00	0.0	0	0	0	0	0
11/08/2021 11:00	0.0	0	0	0	0	0
11/08/2021 12:00	1,978.0	0	1	0	0	0
11/08/2021 13:00	4,935.1	0	1	0	0	0
11/08/2021 14:00	7,004.5	0	1	0	0	0
11/08/2021 15:00	0.0	0	0	0	0	1
11/08/2021 16:00	0.0	0	0	0	0	1
11/08/2021 17:00	0.0	0	0	0	0	1
11/08/2021 18:00	0.0	0	0	0	0	1
11/08/2021 19:00	0.0	0	0	0	0	1
11/08/2021 20:00	0.0	0	0	0	0	1
11/08/2021 21:00	0.0	0	0	0	0	1
11/08/2021 22:00	0.0	0	0	0	0	1
11/08/2021 23:00	18.8	0	0	0	1	0
Average/Sum#:	13,936.4 #	0 #	3 #	0 #	1 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	7,004.5	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/09/2021 00:00	0.0	0	0	0	0	0
11/09/2021 01:00	0.0	0	0	0	0	0
11/09/2021 02:00	0.0	0	0	0	0	0
11/09/2021 03:00	1,038.3	0	0	1	0	0
11/09/2021 04:00	5,548.6	0	0	1	0	0
11/09/2021 05:00	0.0	0	0	0	0	1
11/09/2021 06:00	0.0	0	0	0	0	1
11/09/2021 07:00	0.0	0	0	0	0	1
11/09/2021 08:00	0.0	0	0	0	0	1
11/09/2021 09:00	0.0	0	0	0	0	1
11/09/2021 10:00	0.0	0	0	0	0	1
11/09/2021 11:00	0.0	0	0	0	0	1
11/09/2021 12:00	0.0	0	0	0	0	1
11/09/2021 13:00	0.0	0	0	0	0	1
11/09/2021 14:00	0.0	0	0	0	0	1
11/09/2021 15:00	0.0	0	0	0	0	1
11/09/2021 16:00	0.0	0	0	0	0	1
11/09/2021 17:00	0.0	0	0	0	0	1
11/09/2021 18:00	0.0	0	0	0	0	1
11/09/2021 19:00	0.0	0	0	0	0	1
11/09/2021 20:00	0.0	0	0	0	0	1
11/09/2021 21:00	0.0	0	0	0	0	1
11/09/2021 22:00	0.0	0	0	0	0	1
11/09/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,586.9 #	0 #	0 #	2 #	0 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,548.6	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/10/2021 00:00	0.0	0	0	0	0	1
11/10/2021 01:00	0.0	0	0	0	0	1
11/10/2021 02:00	0.0	0	0	0	0	1
11/10/2021 03:00	0.0	0	0	0	0	1
11/10/2021 04:00	0.0	0	0	0	0	1
11/10/2021 05:00	0.0	0	0	0	0	1
11/10/2021 06:00	0.0	0	0	0	0	1
11/10/2021 07:00	0.0	0	0	0	0	1
11/10/2021 08:00	0.0	0	0	0	0	1
11/10/2021 09:00	0.0	0	0	0	0	1
11/10/2021 10:00	0.0	0	0	0	0	1
11/10/2021 11:00	0.0	0	0	0	0	1
11/10/2021 12:00	0.0	0	0	0	0	1
11/10/2021 13:00	0.0	0	0	0	0	1
11/10/2021 14:00	0.0	0	0	0	0	1
11/10/2021 15:00	0.0	0	0	0	0	1
11/10/2021 16:00	0.0	0	0	0	0	1
11/10/2021 17:00	0.0	0	0	0	0	1
11/10/2021 18:00	0.0	0	0	0	0	1
11/10/2021 19:00	0.0	0	0	0	0	1
11/10/2021 20:00	0.0	0	0	0	0	1
11/10/2021 21:00	0.0	0	0	0	0	1
11/10/2021 22:00	0.0	0	0	0	0	1
11/10/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/11/2021 00:00	0.0	0	0	0	0	1
11/11/2021 01:00	54.4	0	0	0	1	0
11/11/2021 02:00	0.0	0	0	0	0	0
11/11/2021 03:00	0.0	0	0	0	0	0
11/11/2021 04:00	0.0	0	0	0	0	0
11/11/2021 05:00	0.0	0	0	0	0	0
11/11/2021 06:00	0.0	0	0	0	0	0
11/11/2021 07:00	0.0	0	0	0	0	0
11/11/2021 08:00	0.0	0	0	0	0	0
11/11/2021 09:00	0.0	0	0	0	0	0
11/11/2021 10:00	0.0	0	0	0	0	0
11/11/2021 11:00	0.0	0	0	0	0	0
11/11/2021 12:00	0.0	0	0	0	0	0
11/11/2021 13:00	1,741.7	0	1	0	0	0
11/11/2021 14:00	5,452.6	0	1	0	0	0
11/11/2021 15:00	0.0	0	0	0	0	1
11/11/2021 16:00	0.0	0	0	0	0	1
11/11/2021 17:00	0.0	0	0	0	0	1
11/11/2021 18:00	0.0	0	0	0	0	1
11/11/2021 19:00	0.0	0	0	0	0	1
11/11/2021 20:00	0.0	0	0	0	0	1
11/11/2021 21:00	0.0	0	0	0	0	1
11/11/2021 22:00	0.0	0	0	0	0	1
11/11/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,248.7 #	0 #	2 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,452.6	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/12/2021 00:00	0.0	0	0	0	0	1
11/12/2021 01:00	0.0	0	0	0	0	1
11/12/2021 02:00	0.0	0	0	0	0	1
11/12/2021 03:00	0.0	0	0	0	0	1
11/12/2021 04:00	0.0	0	0	0	0	1
11/12/2021 05:00	0.0	0	0	0	0	1
11/12/2021 06:00	0.0	0	0	0	0	1
11/12/2021 07:00	0.0	0	0	0	0	1
11/12/2021 08:00	50.6	0	0	0	1	0
11/12/2021 09:00	0.0	0	0	0	0	0
11/12/2021 10:00	0.0	0	0	0	0	0
11/12/2021 11:00	0.0	0	0	0	0	0
11/12/2021 12:00	0.0	0	0	0	0	0
11/12/2021 13:00	0.0	0	0	0	0	0
11/12/2021 14:00	0.0	0	0	0	0	0
11/12/2021 15:00	1,337.3	0	0	1	0	0
11/12/2021 16:00	6,165.9	0	0	1	0	0
11/12/2021 17:00	0.0	0	0	0	0	1
11/12/2021 18:00	0.0	0	0	0	0	1
11/12/2021 19:00	0.0	0	0	0	0	1
11/12/2021 20:00	0.0	0	0	0	0	1
11/12/2021 21:00	0.0	0	0	0	0	1
11/12/2021 22:00	0.0	0	0	0	0	1
11/12/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,553.8 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,165.9	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/13/2021 00:00	45.1	0	0	0	1	0
11/13/2021 01:00	0.0	0	0	0	0	0
11/13/2021 02:00	0.0	0	0	0	0	0
11/13/2021 03:00	0.0	0	0	0	0	0
11/13/2021 04:00	0.0	0	0	0	0	0
11/13/2021 05:00	0.0	0	0	0	0	0
11/13/2021 06:00	0.0	0	0	0	0	0
11/13/2021 07:00	0.0	0	0	0	0	0
11/13/2021 08:00	0.0	0	0	0	0	0
11/13/2021 09:00	0.0	0	0	0	0	0
11/13/2021 10:00	0.0	0	0	0	0	0
11/13/2021 11:00	0.0	0	0	0	0	0
11/13/2021 12:00	0.0	0	0	0	0	0
11/13/2021 13:00	2,378.3	0	1	0	0	0
11/13/2021 14:00	4,892.4	0	1	0	0	0
11/13/2021 15:00	0.0	0	0	0	0	1
11/13/2021 16:00	0.0	0	0	0	0	1
11/13/2021 17:00	0.0	0	0	0	0	1
11/13/2021 18:00	0.0	0	0	0	0	1
11/13/2021 19:00	0.0	0	0	0	0	1
11/13/2021 20:00	0.0	0	0	0	0	1
11/13/2021 21:00	0.0	0	0	0	0	1
11/13/2021 22:00	42.8	0	0	0	1	0
11/13/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	7,358.6 #	0 #	2 #	0 #	2 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,892.4	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/14/2021 00:00	0.0	0	0	0	0	0
11/14/2021 01:00	0.0	0	0	0	0	0
11/14/2021 02:00	0.0	0	0	0	0	0
11/14/2021 03:00	0.0	0	0	0	0	0
11/14/2021 04:00	0.0	0	0	0	0	0
11/14/2021 05:00	0.0	0	0	0	0	0
11/14/2021 06:00	0.0	0	0	0	0	0
11/14/2021 07:00	0.0	0	0	0	0	0
11/14/2021 08:00	0.0	0	0	0	0	0
11/14/2021 09:00	0.0	0	0	0	0	0
11/14/2021 10:00	0.0	0	0	0	0	0
11/14/2021 11:00	0.0	0	0	0	0	0
11/14/2021 12:00	0.0	0	0	0	0	0
11/14/2021 13:00	0.0	0	0	0	0	0
11/14/2021 14:00	459.5	0	1	0	0	0
11/14/2021 15:00	6,374.3	0	1	0	0	0
11/14/2021 16:00	0.0	0	0	0	0	1
11/14/2021 17:00	0.0	0	0	0	0	1
11/14/2021 18:00	0.0	0	0	0	0	1
11/14/2021 19:00	0.0	0	0	0	0	1
11/14/2021 20:00	0.0	0	0	0	0	1
11/14/2021 21:00	0.0	0	0	0	0	1
11/14/2021 22:00	0.0	0	0	0	0	1
11/14/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,833.8 #	0 #	2 #	0 #	0 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,374.3	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/15/2021 00:00	17.2	0	0	0	1	0
11/15/2021 01:00	0.0	0	0	0	0	0
11/15/2021 02:00	0.0	0	0	0	0	0
11/15/2021 03:00	0.0	0	0	0	0	0
11/15/2021 04:00	0.0	0	0	0	0	0
11/15/2021 05:00	0.0	0	0	0	0	0
11/15/2021 06:00	0.0	0	0	0	0	0
11/15/2021 07:00	1,321.9	0	0	1	0	0
11/15/2021 08:00	6,639.3	0	0	1	0	0
11/15/2021 09:00	0.0	0	0	0	0	1
11/15/2021 10:00	0.0	0	0	0	0	1
11/15/2021 11:00	0.0	0	0	0	0	1
11/15/2021 12:00	0.0	0	0	0	0	1
11/15/2021 13:00	0.0	0	0	0	0	1
11/15/2021 14:00	0.0	0	0	0	0	1
11/15/2021 15:00	0.0	0	0	0	0	1
11/15/2021 16:00	0.0	0	0	0	0	1
11/15/2021 17:00	0.0	0	0	0	0	1
11/15/2021 18:00	0.0	0	0	0	0	1
11/15/2021 19:00	0.0	0	0	0	0	1
11/15/2021 20:00	0.0	0	0	0	0	1
11/15/2021 21:00	0.0	0	0	0	0	1
11/15/2021 22:00	0.0	0	0	0	0	1
11/15/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,978.4 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,639.3	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/16/2021 00:00	66.5	0	0	0	1	0
11/16/2021 01:00	0.0	0	0	0	0	0
11/16/2021 02:00	0.0	0	0	0	0	0
11/16/2021 03:00	0.0	0	0	0	0	0
11/16/2021 04:00	0.0	0	0	0	0	0
11/16/2021 05:00	0.0	0	0	0	0	0
11/16/2021 06:00	0.0	0	0	0	0	0
11/16/2021 07:00	0.0	0	0	0	0	0
11/16/2021 08:00	0.0	0	0	0	0	0
11/16/2021 09:00	0.0	0	0	0	0	0
11/16/2021 10:00	0.0	0	0	0	0	0
11/16/2021 11:00	0.0	0	0	0	0	0
11/16/2021 12:00	0.0	0	0	0	0	0
11/16/2021 13:00	378.0	0	1	0	0	0
11/16/2021 14:00	5,243.6	0	1	0	0	0
11/16/2021 15:00	3,118.7	0	1	0	0	0
11/16/2021 16:00	0.0	0	0	0	0	1
11/16/2021 17:00	0.0	0	0	0	0	1
11/16/2021 18:00	0.0	0	0	0	0	1
11/16/2021 19:00	0.0	0	0	0	0	1
11/16/2021 20:00	0.0	0	0	0	0	1
11/16/2021 21:00	0.0	0	0	0	0	1
11/16/2021 22:00	0.0	0	0	0	0	1
11/16/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	8,806.8 #	0 #	3 #	0 #	1 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,243.6	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/17/2021 00:00	0.0	0	0	0	0	1
11/17/2021 01:00	0.0	0	0	0	0	1
11/17/2021 02:00	0.0	0	0	0	0	1
11/17/2021 03:00	0.0	0	0	0	0	1
11/17/2021 04:00	0.0	0	0	0	0	1
11/17/2021 05:00	0.0	0	0	0	0	1
11/17/2021 06:00	0.0	0	0	0	0	1
11/17/2021 07:00	0.0	0	0	0	0	1
11/17/2021 08:00	0.0	0	0	0	0	1
11/17/2021 09:00	0.0	0	0	0	0	1
11/17/2021 10:00	0.0	0	0	0	0	1
11/17/2021 11:00	0.0	0	0	0	0	1
11/17/2021 12:00	0.0	0	0	0	0	1
11/17/2021 13:00	0.0	0	0	0	0	1
11/17/2021 14:00	0.0	0	0	0	0	1
11/17/2021 15:00	0.0	0	0	0	0	1
11/17/2021 16:00	0.0	0	0	0	0	1
11/17/2021 17:00	0.0	0	0	0	0	1
11/17/2021 18:00	0.0	0	0	0	0	1
11/17/2021 19:00	0.0	0	0	0	0	1
11/17/2021 20:00	0.0	0	0	0	0	1
11/17/2021 21:00	0.0	0	0	0	0	1
11/17/2021 22:00	0.0	0	0	0	0	1
11/17/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/18/2021 00:00	0.0	0	0	0	0	1
11/18/2021 01:00	0.0	0	0	0	0	1
11/18/2021 02:00	0.0	0	0	0	0	1
11/18/2021 03:00	0.0	0	0	0	0	1
11/18/2021 04:00	0.0	0	0	0	0	1
11/18/2021 05:00	0.0	0	0	0	0	1
11/18/2021 06:00	0.0	0	0	0	0	1
11/18/2021 07:00	0.0	0	0	0	0	1
11/18/2021 08:00	0.0	0	0	0	0	1
11/18/2021 09:00	0.0	0	0	0	0	1
11/18/2021 10:00	0.0	0	0	0	0	1
11/18/2021 11:00	0.0	0	0	0	0	1
11/18/2021 12:00	0.0	0	0	0	0	1
11/18/2021 13:00	0.0	0	0	0	0	1
11/18/2021 14:00	0.0	0	0	0	0	1
11/18/2021 15:00	0.0	0	0	0	0	1
11/18/2021 16:00	0.0	0	0	0	0	1
11/18/2021 17:00	0.0	0	0	0	0	1
11/18/2021 18:00	0.0	0	0	0	0	1
11/18/2021 19:00	0.0	0	0	0	0	1
11/18/2021 20:00	0.0	0	0	0	0	1
11/18/2021 21:00	0.0	0	0	0	0	1
11/18/2021 22:00	0.0	0	0	0	0	1
11/18/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/19/2021 00:00	0.0	0	0	0	0	1
11/19/2021 01:00	0.0	0	0	0	0	1
11/19/2021 02:00	0.0	0	0	0	0	1
11/19/2021 03:00	0.0	0	0	0	0	1
11/19/2021 04:00	0.0	0	0	0	0	1
11/19/2021 05:00	0.0	0	0	0	0	1
11/19/2021 06:00	0.0	0	0	0	0	1
11/19/2021 07:00	0.0	0	0	0	0	1
11/19/2021 08:00	0.0	0	0	0	0	1
11/19/2021 09:00	0.0	0	0	0	0	1
11/19/2021 10:00	0.0	0	0	0	0	1
11/19/2021 11:00	0.0	0	0	0	0	1
11/19/2021 12:00	0.0	0	0	0	0	1
11/19/2021 13:00	0.0	0	0	0	0	1
11/19/2021 14:00	0.0	0	0	0	0	1
11/19/2021 15:00	0.0	0	0	0	0	1
11/19/2021 16:00	0.0	0	0	0	0	1
11/19/2021 17:00	0.0	0	0	0	0	1
11/19/2021 18:00	0.0	0	0	0	0	1
11/19/2021 19:00	0.0	0	0	0	0	1
11/19/2021 20:00	0.0	0	0	0	0	1
11/19/2021 21:00	0.0	0	0	0	0	1
11/19/2021 22:00	0.0	0	0	0	0	1
11/19/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/20/2021 00:00	0.0	0	0	0	0	1
11/20/2021 01:00	0.0	0	0	0	0	1
11/20/2021 02:00	0.0	0	0	0	0	1
11/20/2021 03:00	0.0	0	0	0	0	1
11/20/2021 04:00	0.0	0	0	0	0	1
11/20/2021 05:00	0.0	0	0	0	0	1
11/20/2021 06:00	0.0	0	0	0	0	1
11/20/2021 07:00	0.0	0	0	0	0	1
11/20/2021 08:00	0.0	0	0	0	0	1
11/20/2021 09:00	0.0	0	0	0	0	1
11/20/2021 10:00	0.0	0	0	0	0	1
11/20/2021 11:00	0.0	0	0	0	0	1
11/20/2021 12:00	0.0	0	0	0	0	1
11/20/2021 13:00	0.0	0	0	0	0	1
11/20/2021 14:00	0.0	0	0	0	0	1
11/20/2021 15:00	0.0	0	0	0	0	1
11/20/2021 16:00	0.0	0	0	0	0	1
11/20/2021 17:00	0.0	0	0	0	0	1
11/20/2021 18:00	0.0	0	0	0	0	1
11/20/2021 19:00	0.0	0	0	0	0	1
11/20/2021 20:00	0.0	0	0	0	0	1
11/20/2021 21:00	0.0	0	0	0	0	1
11/20/2021 22:00	0.0	0	0	0	0	1
11/20/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/21/2021 00:00	0.0	0	0	0	0	1
11/21/2021 01:00	0.0	0	0	0	0	1
11/21/2021 02:00	31.3	0	0	0	1	0
11/21/2021 03:00	0.0	0	0	0	0	0
11/21/2021 04:00	0.0	0	0	0	0	0
11/21/2021 05:00	0.0	0	0	0	0	0
11/21/2021 06:00	0.0	0	0	0	0	0
11/21/2021 07:00	0.0	0	0	0	0	0
11/21/2021 08:00	0.0	0	0	0	0	0
11/21/2021 09:00	0.0	0	0	0	0	0
11/21/2021 10:00	0.0	0	0	0	0	0
11/21/2021 11:00	0.0	0	0	0	0	0
11/21/2021 12:00	0.0	0	0	0	0	0
11/21/2021 13:00	0.0	0	0	0	0	0
11/21/2021 14:00	1,387.4	0	1	0	0	0
11/21/2021 15:00	5,859.5	0	1	0	0	0
11/21/2021 16:00	0.0	0	0	0	0	1
11/21/2021 17:00	0.0	0	0	0	0	1
11/21/2021 18:00	0.0	0	0	0	0	1
11/21/2021 19:00	0.0	0	0	0	0	1
11/21/2021 20:00	0.0	0	0	0	0	1
11/21/2021 21:00	0.0	0	0	0	0	1
11/21/2021 22:00	0.0	0	0	0	0	1
11/21/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,278.2 #	0 #	2 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,859.5	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/22/2021 00:00	41.2	0	0	0	1	0
11/22/2021 01:00	0.0	0	0	0	0	0
11/22/2021 02:00	0.0	0	0	0	0	0
11/22/2021 03:00	0.0	0	0	0	0	0
11/22/2021 04:00	0.0	0	0	0	0	0
11/22/2021 05:00	0.0	0	0	0	0	0
11/22/2021 06:00	0.0	0	0	0	0	0
11/22/2021 07:00	0.0	0	0	0	0	0
11/22/2021 08:00	0.0	0	0	0	0	0
11/22/2021 09:00	0.0	0	0	0	0	0
11/22/2021 10:00	0.0	0	0	0	0	0
11/22/2021 11:00	0.0	0	0	0	0	0
11/22/2021 12:00	2,335.5	0	1	0	0	0
11/22/2021 13:00	4,520.7	0	1	0	0	0
11/22/2021 14:00	0.0	0	0	0	0	1
11/22/2021 15:00	0.0	0	0	0	0	1
11/22/2021 16:00	0.0	0	0	0	0	1
11/22/2021 17:00	0.0	0	0	0	0	1
11/22/2021 18:00	0.0	0	0	0	0	1
11/22/2021 19:00	0.0	0	0	0	0	1
11/22/2021 20:00	0.0	0	0	0	0	1
11/22/2021 21:00	0.0	0	0	0	0	1
11/22/2021 22:00	0.0	0	0	0	0	1
11/22/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,897.4 #	0 #	2 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,520.7	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/23/2021 00:00	0.0	0	0	0	0	1
11/23/2021 01:00	0.0	0	0	0	0	1
11/23/2021 02:00	0.0	0	0	0	0	1
11/23/2021 03:00	0.0	0	0	0	0	1
11/23/2021 04:00	0.0	0	0	0	0	1
11/23/2021 05:00	0.0	0	0	0	0	1
11/23/2021 06:00	0.0	0	0	0	0	1
11/23/2021 07:00	0.0	0	0	0	0	1
11/23/2021 08:00	0.0	0	0	0	0	1
11/23/2021 09:00	0.0	0	0	0	0	1
11/23/2021 10:00	0.0	0	0	0	0	1
11/23/2021 11:00	0.0	0	0	0	0	1
11/23/2021 12:00	0.0	0	0	0	0	1
11/23/2021 13:00	0.0	0	0	0	0	1
11/23/2021 14:00	0.0	0	0	0	0	1
11/23/2021 15:00	0.0	0	0	0	0	1
11/23/2021 16:00	0.0	0	0	0	0	1
11/23/2021 17:00	0.0	0	0	0	0	1
11/23/2021 18:00	0.0	0	0	0	0	1
11/23/2021 19:00	0.0	0	0	0	0	1
11/23/2021 20:00	0.0	0	0	0	0	1
11/23/2021 21:00	0.0	0	0	0	0	1
11/23/2021 22:00	0.0	0	0	0	0	1
11/23/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/24/2021 00:00	0.0	0	0	0	0	1
11/24/2021 01:00	0.0	0	0	0	0	1
11/24/2021 02:00	0.0	0	0	0	0	1
11/24/2021 03:00	0.0	0	0	0	0	1
11/24/2021 04:00	0.0	0	0	0	0	1
11/24/2021 05:00	0.0	0	0	0	0	1
11/24/2021 06:00	0.0	0	0	0	0	1
11/24/2021 07:00	0.0	0	0	0	0	1
11/24/2021 08:00	0.0	0	0	0	0	1
11/24/2021 09:00	0.0	0	0	0	0	1
11/24/2021 10:00	0.0	0	0	0	0	1
11/24/2021 11:00	0.0	0	0	0	0	1
11/24/2021 12:00	0.0	0	0	0	0	1
11/24/2021 13:00	0.0	0	0	0	0	1
11/24/2021 14:00	0.0	0	0	0	0	1
11/24/2021 15:00	0.0	0	0	0	0	1
11/24/2021 16:00	0.0	0	0	0	0	1
11/24/2021 17:00	0.0	0	0	0	0	1
11/24/2021 18:00	0.0	0	0	0	0	1
11/24/2021 19:00	0.0	0	0	0	0	1
11/24/2021 20:00	0.0	0	0	0	0	1
11/24/2021 21:00	0.0	0	0	0	0	1
11/24/2021 22:00	0.0	0	0	0	0	1
11/24/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/25/2021 00:00	44.4	0	0	0	1	0
11/25/2021 01:00	0.0	0	0	0	0	0
11/25/2021 02:00	0.0	0	0	0	0	0
11/25/2021 03:00	0.0	0	0	0	0	0
11/25/2021 04:00	0.0	0	0	0	0	0
11/25/2021 05:00	0.0	0	0	0	0	0
11/25/2021 06:00	0.0	0	0	0	0	0
11/25/2021 07:00	0.0	0	0	0	0	0
11/25/2021 08:00	0.0	0	0	0	0	0
11/25/2021 09:00	0.0	0	0	0	0	0
11/25/2021 10:00	0.0	0	0	0	0	0
11/25/2021 11:00	0.0	0	0	0	0	0
11/25/2021 12:00	0.0	0	0	0	0	0
11/25/2021 13:00	0.0	0	0	0	0	0
11/25/2021 14:00	0.0	0	0	0	0	0
11/25/2021 15:00	0.0	0	0	0	0	0
11/25/2021 16:00	0.0	0	0	0	0	0
11/25/2021 17:00	0.0	0	0	0	0	0
11/25/2021 18:00	0.0	0	0	0	0	0
11/25/2021 19:00	0.0	0	0	0	0	0
11/25/2021 20:00	0.0	0	0	0	0	0
11/25/2021 21:00	0.0	0	0	0	0	0
11/25/2021 22:00	0.0	0	0	0	0	0
11/25/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	44.4 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	44.4	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/26/2021 00:00	0.0	0	0	0	0	0
11/26/2021 01:00	0.0	0	0	0	0	0
11/26/2021 02:00	0.0	0	0	0	0	0
11/26/2021 03:00	0.0	0	0	0	0	0
11/26/2021 04:00	0.0	0	0	0	0	0
11/26/2021 05:00	0.0	0	0	0	0	0
11/26/2021 06:00	0.0	0	0	0	0	0
11/26/2021 07:00	0.0	0	0	0	0	0
11/26/2021 08:00	0.0	0	0	0	0	0
11/26/2021 09:00	0.0	0	0	0	0	0
11/26/2021 10:00	0.0	0	0	0	0	0
11/26/2021 11:00	0.0	0	0	0	0	0
11/26/2021 12:00	0.0	0	0	0	0	0
11/26/2021 13:00	0.0	0	0	0	0	0
11/26/2021 14:00	0.0	0	0	0	0	0
11/26/2021 15:00	0.0	0	0	0	0	0
11/26/2021 16:00	0.0	0	0	0	0	0
11/26/2021 17:00	0.0	0	0	0	0	0
11/26/2021 18:00	0.0	0	0	0	0	0
11/26/2021 19:00	0.0	0	0	0	0	0
11/26/2021 20:00	0.0	0	0	0	0	0
11/26/2021 21:00	0.0	0	0	0	0	0
11/26/2021 22:00	0.0	0	0	0	0	0
11/26/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/27/2021 00:00	0.0	0	0	0	0	0
11/27/2021 01:00	0.0	0	0	0	0	0
11/27/2021 02:00	0.0	0	0	0	0	0
11/27/2021 03:00	0.0	0	0	0	0	0
11/27/2021 04:00	0.0	0	0	0	0	0
11/27/2021 05:00	0.0	0	0	0	0	0
11/27/2021 06:00	0.0	0	0	0	0	0
11/27/2021 07:00	0.0	0	0	0	0	0
11/27/2021 08:00	0.0	0	0	0	0	0
11/27/2021 09:00	0.0	0	0	0	0	0
11/27/2021 10:00	0.0	0	0	0	0	0
11/27/2021 11:00	0.0	0	0	0	0	0
11/27/2021 12:00	0.0	0	0	0	0	0
11/27/2021 13:00	0.0	0	0	0	0	0
11/27/2021 14:00	0.0	0	0	0	0	0
11/27/2021 15:00	0.0	0	0	0	0	0
11/27/2021 16:00	0.0	0	0	0	0	0
11/27/2021 17:00	0.0	0	0	0	0	0
11/27/2021 18:00	0.0	0	0	0	0	0
11/27/2021 19:00	0.0	0	0	0	0	0
11/27/2021 20:00	0.0	0	0	0	0	0
11/27/2021 21:00	0.0	0	0	0	0	0
11/27/2021 22:00	0.0	0	0	0	0	0
11/27/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/28/2021 00:00	0.0	0	0	0	0	0
11/28/2021 01:00	0.0	0	0	0	0	0
11/28/2021 02:00	0.0	0	0	0	0	0
11/28/2021 03:00	0.0	0	0	0	0	0
11/28/2021 04:00	0.0	0	0	0	0	0
11/28/2021 05:00	0.0	0	0	0	0	0
11/28/2021 06:00	0.0	0	0	0	0	0
11/28/2021 07:00	0.0	0	0	0	0	0
11/28/2021 08:00	0.0	0	0	0	0	0
11/28/2021 09:00	0.0	0	0	0	0	0
11/28/2021 10:00	0.0	0	0	0	0	0
11/28/2021 11:00	0.0	0	0	0	0	0
11/28/2021 12:00	0.0	0	0	0	0	0
11/28/2021 13:00	0.0	0	0	0	0	0
11/28/2021 14:00	0.0	0	0	0	0	0
11/28/2021 15:00	0.0	0	0	0	0	0
11/28/2021 16:00	0.0	0	0	0	0	0
11/28/2021 17:00	0.0	0	0	0	0	0
11/28/2021 18:00	0.0	0	0	0	0	0
11/28/2021 19:00	0.0	0	0	0	0	0
11/28/2021 20:00	0.0	0	0	0	0	0
11/28/2021 21:00	0.0	0	0	0	0	0
11/28/2021 22:00	0.0	0	0	0	0	0
11/28/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/29/2021 00:00	0.0	0	0	0	0	0
11/29/2021 01:00	0.0	0	0	0	0	0
11/29/2021 02:00	0.0	0	0	0	0	0
11/29/2021 03:00	0.0	0	0	0	0	0
11/29/2021 04:00	0.0	0	0	0	0	0
11/29/2021 05:00	0.0	0	0	0	0	0
11/29/2021 06:00	0.0	0	0	0	0	0
11/29/2021 07:00	0.0	0	0	0	0	0
11/29/2021 08:00	0.0	0	0	0	0	0
11/29/2021 09:00	0.0	0	0	0	0	0
11/29/2021 10:00	0.0	0	0	0	0	0
11/29/2021 11:00	0.0	0	0	0	0	0
11/29/2021 12:00	0.0	0	0	0	0	0
11/29/2021 13:00	0.0	0	0	0	0	0
11/29/2021 14:00	2,187.4	1	0	0	0	0
11/29/2021 15:00	5,732.7	1	0	0	0	0
11/29/2021 16:00	0.0	0	0	0	0	1
11/29/2021 17:00	0.0	0	0	0	0	1
11/29/2021 18:00	0.0	0	0	0	0	1
11/29/2021 19:00	0.0	0	0	0	0	1
11/29/2021 20:00	0.0	0	0	0	0	1
11/29/2021 21:00	0.0	0	0	0	0	1
11/29/2021 22:00	0.0	0	0	0	0	1
11/29/2021 23:00	15.4	0	0	0	1	0
Average/Sum#:	7,935.5 #	2 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,732.7	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/30/2021 00:00	0.0	0	0	0	0	0
11/30/2021 01:00	0.0	0	0	0	0	0
11/30/2021 02:00	0.0	0	0	0	0	0
11/30/2021 03:00	0.0	0	0	0	0	0
11/30/2021 04:00	0.0	0	0	0	0	0
11/30/2021 05:00	0.0	0	0	0	0	0
11/30/2021 06:00	0.0	0	0	0	0	0
11/30/2021 07:00	0.0	0	0	0	0	0
11/30/2021 08:00	1,135.7	0	1	0	0	0
11/30/2021 09:00	5,422.4	0	1	0	0	0
11/30/2021 10:00	0.0	0	0	0	0	1
11/30/2021 11:00	0.0	0	0	0	0	1
11/30/2021 12:00	0.0	0	0	0	0	1
11/30/2021 13:00	0.0	0	0	0	0	1
11/30/2021 14:00	0.0	0	0	0	0	1
11/30/2021 15:00	0.0	0	0	0	0	1
11/30/2021 16:00	0.0	0	0	0	0	1
11/30/2021 17:00	0.0	0	0	0	0	1
11/30/2021 18:00	0.0	0	0	0	0	1
11/30/2021 19:00	0.0	0	0	0	0	1
11/30/2021 20:00	0.0	0	0	0	0	1
11/30/2021 21:00	0.0	0	0	0	0	1
11/30/2021 22:00	0.0	0	0	0	0	1
11/30/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,558.1 #	0 #	2 #	0 #	0 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,422.4	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/01/2021 00:00	0.0	0	0	0	0	1
12/01/2021 01:00	0.0	0	0	0	0	1
12/01/2021 02:00	0.0	0	0	0	0	1
12/01/2021 03:00	0.0	0	0	0	0	1
12/01/2021 04:00	0.0	0	0	0	0	1
12/01/2021 05:00	0.0	0	0	0	0	1
12/01/2021 06:00	0.0	0	0	0	0	1
12/01/2021 07:00	0.0	0	0	0	0	1
12/01/2021 08:00	0.0	0	0	0	0	1
12/01/2021 09:00	0.0	0	0	0	0	1
12/01/2021 10:00	0.0	0	0	0	0	1
12/01/2021 11:00	0.0	0	0	0	0	1
12/01/2021 12:00	0.0	0	0	0	0	1
12/01/2021 13:00	0.0	0	0	0	0	1
12/01/2021 14:00	0.0	0	0	0	0	1
12/01/2021 15:00	0.0	0	0	0	0	1
12/01/2021 16:00	0.0	0	0	0	0	1
12/01/2021 17:00	0.0	0	0	0	0	1
12/01/2021 18:00	0.0	0	0	0	0	1
12/01/2021 19:00	0.0	0	0	0	0	1
12/01/2021 20:00	0.0	0	0	0	0	1
12/01/2021 21:00	0.0	0	0	0	0	1
12/01/2021 22:00	0.0	0	0	0	0	1
12/01/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/02/2021 00:00	40.0	0	0	0	1	0
12/02/2021 01:00	0.0	0	0	0	0	0
12/02/2021 02:00	0.0	0	0	0	0	0
12/02/2021 03:00	0.0	0	0	0	0	0
12/02/2021 04:00	6,006.8	0	0	1	0	0
12/02/2021 05:00	0.0	0	0	0	0	1
12/02/2021 06:00	0.0	0	0	0	0	1
12/02/2021 07:00	0.0	0	0	0	0	1
12/02/2021 08:00	0.0	0	0	0	0	1
12/02/2021 09:00	0.0	0	0	0	0	1
12/02/2021 10:00	0.0	0	0	0	0	1
12/02/2021 11:00	0.0	0	0	0	0	1
12/02/2021 12:00	0.0	0	0	0	0	1
12/02/2021 13:00	0.0	0	0	0	0	1
12/02/2021 14:00	0.0	0	0	0	0	1
12/02/2021 15:00	0.0	0	0	0	0	1
12/02/2021 16:00	0.0	0	0	0	0	1
12/02/2021 17:00	0.0	0	0	0	0	1
12/02/2021 18:00	0.0	0	0	0	0	1
12/02/2021 19:00	0.0	0	0	0	0	1
12/02/2021 20:00	0.0	0	0	0	0	1
12/02/2021 21:00	0.0	0	0	0	0	1
12/02/2021 22:00	0.0	0	0	0	0	1
12/02/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,046.8 #	0 #	0 #	1 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,006.8	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/03/2021 00:00	36.9	0	0	0	1	0
12/03/2021 01:00	0.0	0	0	0	0	0
12/03/2021 02:00	0.0	0	0	0	0	0
12/03/2021 03:00	480.6	0	0	1	0	0
12/03/2021 04:00	6,121.8	0	0	1	0	0
12/03/2021 05:00	0.0	0	0	0	0	1
12/03/2021 06:00	0.0	0	0	0	0	1
12/03/2021 07:00	0.0	0	0	0	0	1
12/03/2021 08:00	0.0	0	0	0	0	1
12/03/2021 09:00	0.0	0	0	0	0	1
12/03/2021 10:00	0.0	0	0	0	0	1
12/03/2021 11:00	0.0	0	0	0	0	1
12/03/2021 12:00	0.0	0	0	0	0	1
12/03/2021 13:00	0.0	0	0	0	0	1
12/03/2021 14:00	0.0	0	0	0	0	1
12/03/2021 15:00	0.0	0	0	0	0	1
12/03/2021 16:00	0.0	0	0	0	0	1
12/03/2021 17:00	0.0	0	0	0	0	1
12/03/2021 18:00	0.0	0	0	0	0	1
12/03/2021 19:00	0.0	0	0	0	0	1
12/03/2021 20:00	0.0	0	0	0	0	1
12/03/2021 21:00	0.0	0	0	0	0	1
12/03/2021 22:00	0.0	0	0	0	0	1
12/03/2021 23:00	51.0	0	0	0	1	0
Average/Sum#:	6,690.3 #	0 #	0 #	2 #	2 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,121.8	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/04/2021 00:00	0.0	0	0	0	0	0
12/04/2021 01:00	0.0	0	0	0	0	0
12/04/2021 02:00	0.0	0	0	0	0	0
12/04/2021 03:00	0.0	0	0	0	0	0
12/04/2021 04:00	0.0	0	0	0	0	0
12/04/2021 05:00	372.9	0	0	1	0	0
12/04/2021 06:00	1,086.4	0	0	1	1	0
12/04/2021 07:00	4,104.9	0	0	1	0	0
12/04/2021 08:00	0.0	0	0	0	0	1
12/04/2021 09:00	0.0	0	0	0	0	1
12/04/2021 10:00	0.0	0	0	0	0	1
12/04/2021 11:00	0.0	0	0	0	0	1
12/04/2021 12:00	21.0	0	0	0	1	0
12/04/2021 13:00	0.0	0	0	0	0	0
12/04/2021 14:00	0.0	0	0	0	0	0
12/04/2021 15:00	326.6	0	0	1	0	0
12/04/2021 16:00	5,919.4	0	0	1	0	0
12/04/2021 17:00	0.0	0	0	0	0	1
12/04/2021 18:00	0.0	0	0	0	0	1
12/04/2021 19:00	0.0	0	0	0	0	1
12/04/2021 20:00	0.0	0	0	0	0	1
12/04/2021 21:00	0.0	0	0	0	0	1
12/04/2021 22:00	0.0	0	0	0	0	1
12/04/2021 23:00	59.1	0	0	0	1	0
Average/Sum#:	11,890.3 #	0 #	0 #	5 #	3 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,919.4	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/05/2021 00:00	0.0	0	0	0	0	0
12/05/2021 01:00	0.0	0	0	0	0	0
12/05/2021 02:00	0.0	0	0	0	0	0
12/05/2021 03:00	0.0	0	0	0	0	0
12/05/2021 04:00	0.0	0	0	0	0	0
12/05/2021 05:00	0.0	0	0	0	0	0
12/05/2021 06:00	0.0	0	0	0	0	0
12/05/2021 07:00	0.0	0	0	0	0	0
12/05/2021 08:00	0.0	0	0	0	0	0
12/05/2021 09:00	0.0	0	0	0	0	0
12/05/2021 10:00	0.0	0	0	0	0	0
12/05/2021 11:00	0.0	0	0	0	0	0
12/05/2021 12:00	0.0	0	0	0	0	0
12/05/2021 13:00	1,211.6	0	1	0	0	0
12/05/2021 14:00	5,014.5	0	1	0	0	0
12/05/2021 15:00	0.0	0	0	0	0	1
12/05/2021 16:00	0.0	0	0	0	0	1
12/05/2021 17:00	0.0	0	0	0	0	1
12/05/2021 18:00	0.0	0	0	0	0	1
12/05/2021 19:00	0.0	0	0	0	0	1
12/05/2021 20:00	0.0	0	0	0	0	1
12/05/2021 21:00	0.0	0	0	0	0	1
12/05/2021 22:00	0.0	0	0	0	0	1
12/05/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,226.1 #	0 #	2 #	0 #	0 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,014.5	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/06/2021 00:00	0.0	0	0	0	0	1
12/06/2021 01:00	0.0	0	0	0	0	1
12/06/2021 02:00	0.0	0	0	0	0	1
12/06/2021 03:00	0.0	0	0	0	0	1
12/06/2021 04:00	0.0	0	0	0	0	1
12/06/2021 05:00	0.0	0	0	0	0	1
12/06/2021 06:00	0.0	0	0	0	0	1
12/06/2021 07:00	0.0	0	0	0	0	1
12/06/2021 08:00	0.0	0	0	0	0	1
12/06/2021 09:00	0.0	0	0	0	0	1
12/06/2021 10:00	0.0	0	0	0	0	1
12/06/2021 11:00	0.0	0	0	0	0	1
12/06/2021 12:00	0.0	0	0	0	0	1
12/06/2021 13:00	0.0	0	0	0	0	1
12/06/2021 14:00	0.0	0	0	0	0	1
12/06/2021 15:00	0.0	0	0	0	0	1
12/06/2021 16:00	0.0	0	0	0	0	1
12/06/2021 17:00	0.0	0	0	0	0	1
12/06/2021 18:00	0.0	0	0	0	0	1
12/06/2021 19:00	0.0	0	0	0	0	1
12/06/2021 20:00	0.0	0	0	0	0	1
12/06/2021 21:00	0.0	0	0	0	0	1
12/06/2021 22:00	0.0	0	0	0	0	1
12/06/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/07/2021 00:00	0.0	0	0	0	0	1
12/07/2021 01:00	0.0	0	0	0	0	1
12/07/2021 02:00	0.0	0	0	0	0	1
12/07/2021 03:00	0.0	0	0	0	0	1
12/07/2021 04:00	0.0	0	0	0	0	1
12/07/2021 05:00	0.0	0	0	0	0	1
12/07/2021 06:00	0.0	0	0	0	0	1
12/07/2021 07:00	0.0	0	0	0	0	1
12/07/2021 08:00	0.0	0	0	0	0	1
12/07/2021 09:00	0.0	0	0	0	0	1
12/07/2021 10:00	0.0	0	0	0	0	1
12/07/2021 11:00	0.0	0	0	0	0	1
12/07/2021 12:00	0.0	0	0	0	0	1
12/07/2021 13:00	0.0	0	0	0	0	1
12/07/2021 14:00	0.0	0	0	0	0	1
12/07/2021 15:00	0.0	0	0	0	0	1
12/07/2021 16:00	0.0	0	0	0	0	1
12/07/2021 17:00	0.0	0	0	0	0	1
12/07/2021 18:00	0.0	0	0	0	0	1
12/07/2021 19:00	0.0	0	0	0	0	1
12/07/2021 20:00	0.0	0	0	0	0	1
12/07/2021 21:00	0.0	0	0	0	0	1
12/07/2021 22:00	0.0	0	0	0	0	1
12/07/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/08/2021 00:00	0.0	0	0	0	0	1
12/08/2021 01:00	0.0	0	0	0	0	1
12/08/2021 02:00	0.0	0	0	0	0	1
12/08/2021 03:00	0.0	0	0	0	0	1
12/08/2021 04:00	0.0	0	0	0	0	1
12/08/2021 05:00	0.0	0	0	0	0	1
12/08/2021 06:00	0.0	0	0	0	0	1
12/08/2021 07:00	0.0	0	0	0	0	1
12/08/2021 08:00	0.0	0	0	0	0	1
12/08/2021 09:00	0.0	0	0	0	0	1
12/08/2021 10:00	0.0	0	0	0	0	1
12/08/2021 11:00	0.0	0	0	0	0	1
12/08/2021 12:00	0.0	0	0	0	0	1
12/08/2021 13:00	0.0	0	0	0	0	1
12/08/2021 14:00	0.0	0	0	0	0	1
12/08/2021 15:00	0.0	0	0	0	0	1
12/08/2021 16:00	0.0	0	0	0	0	1
12/08/2021 17:00	0.0	0	0	0	0	1
12/08/2021 18:00	0.0	0	0	0	0	1
12/08/2021 19:00	0.0	0	0	0	0	1
12/08/2021 20:00	0.0	0	0	0	0	1
12/08/2021 21:00	0.0	0	0	0	0	1
12/08/2021 22:00	0.0	0	0	0	0	1
12/08/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/09/2021 00:00	0.0	0	0	0	0	1
12/09/2021 01:00	0.0	0	0	0	0	1
12/09/2021 02:00	0.0	0	0	0	0	1
12/09/2021 03:00	0.0	0	0	0	0	1
12/09/2021 04:00	0.0	0	0	0	0	1
12/09/2021 05:00	0.0	0	0	0	0	1
12/09/2021 06:00	0.0	0	0	0	0	1
12/09/2021 07:00	0.0	0	0	0	0	1
12/09/2021 08:00	0.0	0	0	0	0	1
12/09/2021 09:00	0.0	0	0	0	0	1
12/09/2021 10:00	0.0	0	0	0	0	1
12/09/2021 11:00	0.0	0	0	0	0	1
12/09/2021 12:00	0.0	0	0	0	0	1
12/09/2021 13:00	0.0	0	0	0	0	1
12/09/2021 14:00	0.0	0	0	0	0	1
12/09/2021 15:00	0.0	0	0	0	0	1
12/09/2021 16:00	0.0	0	0	0	0	1
12/09/2021 17:00	0.0	0	0	0	0	1
12/09/2021 18:00	0.0	0	0	0	0	1
12/09/2021 19:00	0.0	0	0	0	0	1
12/09/2021 20:00	0.0	0	0	0	0	1
12/09/2021 21:00	0.0	0	0	0	0	1
12/09/2021 22:00	0.0	0	0	0	0	1
12/09/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/10/2021 00:00	0.0	0	0	0	0	1
12/10/2021 01:00	0.0	0	0	0	0	1
12/10/2021 02:00	0.0	0	0	0	0	1
12/10/2021 03:00	0.0	0	0	0	0	1
12/10/2021 04:00	0.0	0	0	0	0	1
12/10/2021 05:00	0.0	0	0	0	0	1
12/10/2021 06:00	0.0	0	0	0	0	1
12/10/2021 07:00	0.0	0	0	0	0	1
12/10/2021 08:00	0.0	0	0	0	0	1
12/10/2021 09:00	0.0	0	0	0	0	1
12/10/2021 10:00	0.0	0	0	0	0	1
12/10/2021 11:00	0.0	0	0	0	0	1
12/10/2021 12:00	0.0	0	0	0	0	1
12/10/2021 13:00	0.0	0	0	0	0	1
12/10/2021 14:00	0.0	0	0	0	0	1
12/10/2021 15:00	0.0	0	0	0	0	1
12/10/2021 16:00	0.0	0	0	0	0	1
12/10/2021 17:00	0.0	0	0	0	0	1
12/10/2021 18:00	0.0	0	0	0	0	1
12/10/2021 19:00	0.0	0	0	0	0	1
12/10/2021 20:00	0.0	0	0	0	0	1
12/10/2021 21:00	0.0	0	0	0	0	1
12/10/2021 22:00	0.0	0	0	0	0	1
12/10/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/11/2021 00:00	0.0	0	0	0	0	1
12/11/2021 01:00	0.0	0	0	0	0	1
12/11/2021 02:00	0.0	0	0	0	0	1
12/11/2021 03:00	0.0	0	0	0	0	1
12/11/2021 04:00	0.0	0	0	0	0	1
12/11/2021 05:00	0.0	0	0	0	0	1
12/11/2021 06:00	0.0	0	0	0	0	1
12/11/2021 07:00	0.0	0	0	0	0	1
12/11/2021 08:00	0.0	0	0	0	0	1
12/11/2021 09:00	0.0	0	0	0	0	1
12/11/2021 10:00	0.0	0	0	0	0	1
12/11/2021 11:00	0.0	0	0	0	0	1
12/11/2021 12:00	0.0	0	0	0	0	1
12/11/2021 13:00	0.0	0	0	0	0	1
12/11/2021 14:00	0.0	0	0	0	0	1
12/11/2021 15:00	0.0	0	0	0	0	1
12/11/2021 16:00	0.0	0	0	0	0	1
12/11/2021 17:00	0.0	0	0	0	0	1
12/11/2021 18:00	0.0	0	0	0	0	1
12/11/2021 19:00	0.0	0	0	0	0	1
12/11/2021 20:00	0.0	0	0	0	0	1
12/11/2021 21:00	0.0	0	0	0	0	1
12/11/2021 22:00	0.0	0	0	0	0	1
12/11/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/12/2021 00:00	0.0	0	0	0	0	1
12/12/2021 01:00	0.0	0	0	0	0	1
12/12/2021 02:00	0.0	0	0	0	0	1
12/12/2021 03:00	0.0	0	0	0	0	1
12/12/2021 04:00	0.0	0	0	0	0	1
12/12/2021 05:00	0.0	0	0	0	0	1
12/12/2021 06:00	0.0	0	0	0	0	1
12/12/2021 07:00	0.0	0	0	0	0	1
12/12/2021 08:00	0.0	0	0	0	0	1
12/12/2021 09:00	0.0	0	0	0	0	1
12/12/2021 10:00	0.0	0	0	0	0	1
12/12/2021 11:00	0.0	0	0	0	0	1
12/12/2021 12:00	0.0	0	0	0	0	1
12/12/2021 13:00	0.0	0	0	0	0	1
12/12/2021 14:00	0.0	0	0	0	0	1
12/12/2021 15:00	0.0	0	0	0	0	1
12/12/2021 16:00	0.0	0	0	0	0	1
12/12/2021 17:00	0.0	0	0	0	0	1
12/12/2021 18:00	0.0	0	0	0	0	1
12/12/2021 19:00	0.0	0	0	0	0	1
12/12/2021 20:00	0.0	0	0	0	0	1
12/12/2021 21:00	0.0	0	0	0	0	1
12/12/2021 22:00	0.0	0	0	0	0	1
12/12/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/13/2021 00:00	0.0	0	0	0	0	1
12/13/2021 01:00	0.0	0	0	0	0	1
12/13/2021 02:00	0.0	0	0	0	0	1
12/13/2021 03:00	0.0	0	0	0	0	1
12/13/2021 04:00	0.0	0	0	0	0	1
12/13/2021 05:00	0.0	0	0	0	0	1
12/13/2021 06:00	0.0	0	0	0	0	1
12/13/2021 07:00	0.0	0	0	0	0	1
12/13/2021 08:00	0.0	0	0	0	0	1
12/13/2021 09:00	0.0	0	0	0	0	1
12/13/2021 10:00	0.0	0	0	0	0	1
12/13/2021 11:00	0.0	0	0	0	0	1
12/13/2021 12:00	0.0	0	0	0	0	1
12/13/2021 13:00	0.0	0	0	0	0	1
12/13/2021 14:00	0.0	0	0	0	0	1
12/13/2021 15:00	0.0	0	0	0	0	1
12/13/2021 16:00	0.0	0	0	0	0	1
12/13/2021 17:00	0.0	0	0	0	0	1
12/13/2021 18:00	0.0	0	0	0	0	1
12/13/2021 19:00	0.0	0	0	0	0	1
12/13/2021 20:00	0.0	0	0	0	0	1
12/13/2021 21:00	0.0	0	0	0	0	1
12/13/2021 22:00	0.0	0	0	0	0	1
12/13/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/14/2021 00:00	0.0	0	0	0	0	1
12/14/2021 01:00	0.0	0	0	0	0	1
12/14/2021 02:00	0.0	0	0	0	0	1
12/14/2021 03:00	0.0	0	0	0	0	1
12/14/2021 04:00	0.0	0	0	0	0	1
12/14/2021 05:00	0.0	0	0	0	0	1
12/14/2021 06:00	0.0	0	0	0	0	1
12/14/2021 07:00	0.0	0	0	0	0	1
12/14/2021 08:00	0.0	0	0	0	0	1
12/14/2021 09:00	0.0	0	0	0	0	1
12/14/2021 10:00	0.0	0	0	0	0	1
12/14/2021 11:00	0.0	0	0	0	0	1
12/14/2021 12:00	0.0	0	0	0	0	1
12/14/2021 13:00	0.0	0	0	0	0	1
12/14/2021 14:00	0.0	0	0	0	0	1
12/14/2021 15:00	0.0	0	0	0	0	1
12/14/2021 16:00	0.0	0	0	0	0	1
12/14/2021 17:00	0.0	0	0	0	0	1
12/14/2021 18:00	0.0	0	0	0	0	1
12/14/2021 19:00	0.0	0	0	0	0	1
12/14/2021 20:00	0.0	0	0	0	0	1
12/14/2021 21:00	0.0	0	0	0	0	1
12/14/2021 22:00	0.0	0	0	0	0	1
12/14/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/15/2021 00:00	0.0	0	0	0	0	1
12/15/2021 01:00	0.0	0	0	0	0	1
12/15/2021 02:00	0.0	0	0	0	0	1
12/15/2021 03:00	0.0	0	0	0	0	1
12/15/2021 04:00	0.0	0	0	0	0	1
12/15/2021 05:00	0.0	0	0	0	0	1
12/15/2021 06:00	0.0	0	0	0	0	1
12/15/2021 07:00	0.0	0	0	0	0	1
12/15/2021 08:00	0.0	0	0	0	0	1
12/15/2021 09:00	0.0	0	0	0	0	1
12/15/2021 10:00	0.0	0	0	0	0	1
12/15/2021 11:00	0.0	0	0	0	0	1
12/15/2021 12:00	0.0	0	0	0	0	1
12/15/2021 13:00	0.0	0	0	0	0	1
12/15/2021 14:00	0.0	0	0	0	0	1
12/15/2021 15:00	0.0	0	0	0	0	1
12/15/2021 16:00	0.0	0	0	0	0	1
12/15/2021 17:00	0.0	0	0	0	0	1
12/15/2021 18:00	0.0	0	0	0	0	1
12/15/2021 19:00	0.0	0	0	0	0	1
12/15/2021 20:00	0.0	0	0	0	0	1
12/15/2021 21:00	0.0	0	0	0	0	1
12/15/2021 22:00	0.0	0	0	0	0	1
12/15/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/16/2021 00:00	0.0	0	0	0	0	1
12/16/2021 01:00	0.0	0	0	0	0	1
12/16/2021 02:00	0.0	0	0	0	0	1
12/16/2021 03:00	0.0	0	0	0	0	1
12/16/2021 04:00	0.0	0	0	0	0	1
12/16/2021 05:00	0.0	0	0	0	0	1
12/16/2021 06:00	0.0	0	0	0	0	1
12/16/2021 07:00	0.0	0	0	0	0	1
12/16/2021 08:00	0.0	0	0	0	0	1
12/16/2021 09:00	0.0	0	0	0	0	1
12/16/2021 10:00	0.0	0	0	0	0	1
12/16/2021 11:00	0.0	0	0	0	0	1
12/16/2021 12:00	0.0	0	0	0	0	1
12/16/2021 13:00	0.0	0	0	0	0	1
12/16/2021 14:00	0.0	0	0	0	0	1
12/16/2021 15:00	0.0	0	0	0	0	1
12/16/2021 16:00	0.0	0	0	0	0	1
12/16/2021 17:00	0.0	0	0	0	0	1
12/16/2021 18:00	0.0	0	0	0	0	1
12/16/2021 19:00	0.0	0	0	0	0	1
12/16/2021 20:00	0.0	0	0	0	0	1
12/16/2021 21:00	0.0	0	0	0	0	1
12/16/2021 22:00	0.0	0	0	0	0	1
12/16/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/17/2021 00:00	0.0	0	0	0	0	1
12/17/2021 01:00	0.0	0	0	0	0	1
12/17/2021 02:00	0.0	0	0	0	0	1
12/17/2021 03:00	0.0	0	0	0	0	1
12/17/2021 04:00	0.0	0	0	0	0	1
12/17/2021 05:00	0.0	0	0	0	0	1
12/17/2021 06:00	0.0	0	0	0	0	1
12/17/2021 07:00	0.0	0	0	0	0	1
12/17/2021 08:00	0.0	0	0	0	0	1
12/17/2021 09:00	0.0	0	0	0	0	1
12/17/2021 10:00	0.0	0	0	0	0	1
12/17/2021 11:00	0.0	0	0	0	0	1
12/17/2021 12:00	0.0	0	0	0	0	1
12/17/2021 13:00	0.0	0	0	0	0	1
12/17/2021 14:00	0.0	0	0	0	0	1
12/17/2021 15:00	0.0	0	0	0	0	1
12/17/2021 16:00	0.0	0	0	0	0	1
12/17/2021 17:00	0.0	0	0	0	0	1
12/17/2021 18:00	0.0	0	0	0	0	1
12/17/2021 19:00	0.0	0	0	0	0	1
12/17/2021 20:00	0.0	0	0	0	0	1
12/17/2021 21:00	0.0	0	0	0	0	1
12/17/2021 22:00	0.0	0	0	0	0	1
12/17/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/18/2021 00:00	0.0	0	0	0	0	1
12/18/2021 01:00	0.0	0	0	0	0	1
12/18/2021 02:00	0.0	0	0	0	0	1
12/18/2021 03:00	0.0	0	0	0	0	1
12/18/2021 04:00	0.0	0	0	0	0	1
12/18/2021 05:00	0.0	0	0	0	0	1
12/18/2021 06:00	0.0	0	0	0	0	1
12/18/2021 07:00	0.0	0	0	0	0	1
12/18/2021 08:00	0.0	0	0	0	0	1
12/18/2021 09:00	0.0	0	0	0	0	1
12/18/2021 10:00	0.0	0	0	0	0	1
12/18/2021 11:00	0.0	0	0	0	0	1
12/18/2021 12:00	0.0	0	0	0	0	1
12/18/2021 13:00	0.0	0	0	0	0	1
12/18/2021 14:00	0.0	0	0	0	0	1
12/18/2021 15:00	0.0	0	0	0	0	1
12/18/2021 16:00	0.0	0	0	0	0	1
12/18/2021 17:00	0.0	0	0	0	0	1
12/18/2021 18:00	0.0	0	0	0	0	1
12/18/2021 19:00	0.0	0	0	0	0	1
12/18/2021 20:00	0.0	0	0	0	0	1
12/18/2021 21:00	0.0	0	0	0	0	1
12/18/2021 22:00	0.0	0	0	0	0	1
12/18/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/19/2021 00:00	0.0	0	0	0	0	1
12/19/2021 01:00	0.0	0	0	0	0	1
12/19/2021 02:00	0.0	0	0	0	0	1
12/19/2021 03:00	0.0	0	0	0	0	1
12/19/2021 04:00	0.0	0	0	0	0	1
12/19/2021 05:00	0.0	0	0	0	0	1
12/19/2021 06:00	0.0	0	0	0	0	1
12/19/2021 07:00	0.0	0	0	0	0	1
12/19/2021 08:00	0.0	0	0	0	0	1
12/19/2021 09:00	0.0	0	0	0	0	1
12/19/2021 10:00	0.0	0	0	0	0	1
12/19/2021 11:00	0.0	0	0	0	0	1
12/19/2021 12:00	0.0	0	0	0	0	1
12/19/2021 13:00	0.0	0	0	0	0	1
12/19/2021 14:00	0.0	0	0	0	0	1
12/19/2021 15:00	0.0	0	0	0	0	1
12/19/2021 16:00	0.0	0	0	0	0	1
12/19/2021 17:00	0.0	0	0	0	0	1
12/19/2021 18:00	0.0	0	0	0	0	1
12/19/2021 19:00	0.0	0	0	0	0	1
12/19/2021 20:00	0.0	0	0	0	0	1
12/19/2021 21:00	0.0	0	0	0	0	1
12/19/2021 22:00	0.0	0	0	0	0	1
12/19/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/20/2021 00:00	0.0	0	0	0	0	1
12/20/2021 01:00	0.0	0	0	0	0	1
12/20/2021 02:00	0.0	0	0	0	0	1
12/20/2021 03:00	0.0	0	0	0	0	1
12/20/2021 04:00	0.0	0	0	0	0	1
12/20/2021 05:00	0.0	0	0	0	0	1
12/20/2021 06:00	0.0	0	0	0	0	1
12/20/2021 07:00	0.0	0	0	0	0	1
12/20/2021 08:00	0.0	0	0	0	0	1
12/20/2021 09:00	0.0	0	0	0	0	1
12/20/2021 10:00	0.0	0	0	0	0	1
12/20/2021 11:00	0.0	0	0	0	0	1
12/20/2021 12:00	0.0	0	0	0	0	1
12/20/2021 13:00	0.0	0	0	0	0	1
12/20/2021 14:00	0.0	0	0	0	0	1
12/20/2021 15:00	0.0	0	0	0	0	1
12/20/2021 16:00	0.0	0	0	0	0	1
12/20/2021 17:00	0.0	0	0	0	0	1
12/20/2021 18:00	0.0	0	0	0	0	1
12/20/2021 19:00	0.0	0	0	0	0	1
12/20/2021 20:00	0.0	0	0	0	0	1
12/20/2021 21:00	0.0	0	0	0	0	1
12/20/2021 22:00	0.0	0	0	0	0	1
12/20/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/21/2021 00:00	0.0	0	0	0	0	1
12/21/2021 01:00	0.0	0	0	0	0	1
12/21/2021 02:00	0.0	0	0	0	0	1
12/21/2021 03:00	0.0	0	0	0	0	1
12/21/2021 04:00	0.0	0	0	0	0	1
12/21/2021 05:00	0.0	0	0	0	0	1
12/21/2021 06:00	0.0	0	0	0	0	1
12/21/2021 07:00	0.0	0	0	0	0	1
12/21/2021 08:00	0.0	0	0	0	0	1
12/21/2021 09:00	0.0	0	0	0	0	1
12/21/2021 10:00	0.0	0	0	0	0	1
12/21/2021 11:00	0.0	0	0	0	0	1
12/21/2021 12:00	0.0	0	0	0	0	1
12/21/2021 13:00	0.0	0	0	0	0	1
12/21/2021 14:00	0.0	0	0	0	0	1
12/21/2021 15:00	0.0	0	0	0	0	1
12/21/2021 16:00	0.0	0	0	0	0	1
12/21/2021 17:00	0.0	0	0	0	0	1
12/21/2021 18:00	0.0	0	0	0	0	1
12/21/2021 19:00	0.0	0	0	0	0	1
12/21/2021 20:00	0.0	0	0	0	0	1
12/21/2021 21:00	0.0	0	0	0	0	1
12/21/2021 22:00	0.0	0	0	0	0	1
12/21/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/22/2021 00:00	0.0	0	0	0	0	1
12/22/2021 01:00	0.0	0	0	0	0	1
12/22/2021 02:00	0.0	0	0	0	0	1
12/22/2021 03:00	0.0	0	0	0	0	1
12/22/2021 04:00	0.0	0	0	0	0	1
12/22/2021 05:00	0.0	0	0	0	0	1
12/22/2021 06:00	0.0	0	0	0	0	1
12/22/2021 07:00	0.0	0	0	0	0	1
12/22/2021 08:00	0.0	0	0	0	0	1
12/22/2021 09:00	0.0	0	0	0	0	1
12/22/2021 10:00	0.0	0	0	0	0	1
12/22/2021 11:00	0.0	0	0	0	0	1
12/22/2021 12:00	0.0	0	0	0	0	1
12/22/2021 13:00	0.0	0	0	0	0	1
12/22/2021 14:00	0.0	0	0	0	0	1
12/22/2021 15:00	0.0	0	0	0	0	1
12/22/2021 16:00	0.0	0	0	0	0	1
12/22/2021 17:00	0.0	0	0	0	0	1
12/22/2021 18:00	0.0	0	0	0	0	1
12/22/2021 19:00	0.0	0	0	0	0	1
12/22/2021 20:00	0.0	0	0	0	0	1
12/22/2021 21:00	0.0	0	0	0	0	1
12/22/2021 22:00	0.0	0	0	0	0	1
12/22/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/23/2021 00:00	0.0	0	0	0	0	1
12/23/2021 01:00	0.0	0	0	0	0	1
12/23/2021 02:00	0.0	0	0	0	0	1
12/23/2021 03:00	0.0	0	0	0	0	1
12/23/2021 04:00	0.0	0	0	0	0	1
12/23/2021 05:00	0.0	0	0	0	0	1
12/23/2021 06:00	0.0	0	0	0	0	1
12/23/2021 07:00	0.0	0	0	0	0	1
12/23/2021 08:00	0.0	0	0	0	0	1
12/23/2021 09:00	0.0	0	0	0	0	1
12/23/2021 10:00	0.0	0	0	0	0	1
12/23/2021 11:00	0.0	0	0	0	0	1
12/23/2021 12:00	0.0	0	0	0	0	1
12/23/2021 13:00	0.0	0	0	0	0	1
12/23/2021 14:00	0.0	0	0	0	0	1
12/23/2021 15:00	0.0	0	0	0	0	1
12/23/2021 16:00	0.0	0	0	0	0	1
12/23/2021 17:00	0.0	0	0	0	0	1
12/23/2021 18:00	0.0	0	0	0	0	1
12/23/2021 19:00	0.0	0	0	0	0	1
12/23/2021 20:00	0.0	0	0	0	0	1
12/23/2021 21:00	0.0	0	0	0	0	1
12/23/2021 22:00	0.0	0	0	0	0	1
12/23/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/24/2021 00:00	0.0	0	0	0	0	1
12/24/2021 01:00	0.0	0	0	0	0	1
12/24/2021 02:00	0.0	0	0	0	0	1
12/24/2021 03:00	0.0	0	0	0	0	1
12/24/2021 04:00	0.0	0	0	0	0	1
12/24/2021 05:00	0.0	0	0	0	0	1
12/24/2021 06:00	0.0	0	0	0	0	1
12/24/2021 07:00	0.0	0	0	0	0	1
12/24/2021 08:00	0.0	0	0	0	0	1
12/24/2021 09:00	0.0	0	0	0	0	1
12/24/2021 10:00	0.0	0	0	0	0	1
12/24/2021 11:00	0.0	0	0	0	0	1
12/24/2021 12:00	0.0	0	0	0	0	1
12/24/2021 13:00	0.0	0	0	0	0	1
12/24/2021 14:00	0.0	0	0	0	0	1
12/24/2021 15:00	0.0	0	0	0	0	1
12/24/2021 16:00	0.0	0	0	0	0	1
12/24/2021 17:00	0.0	0	0	0	0	1
12/24/2021 18:00	0.0	0	0	0	0	1
12/24/2021 19:00	0.0	0	0	0	0	1
12/24/2021 20:00	0.0	0	0	0	0	1
12/24/2021 21:00	0.0	0	0	0	0	1
12/24/2021 22:00	0.0	0	0	0	0	1
12/24/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/25/2021 00:00	0.0	0	0	0	0	1
12/25/2021 01:00	0.0	0	0	0	0	1
12/25/2021 02:00	0.0	0	0	0	0	1
12/25/2021 03:00	0.0	0	0	0	0	1
12/25/2021 04:00	0.0	0	0	0	0	1
12/25/2021 05:00	0.0	0	0	0	0	1
12/25/2021 06:00	0.0	0	0	0	0	1
12/25/2021 07:00	0.0	0	0	0	0	1
12/25/2021 08:00	0.0	0	0	0	0	1
12/25/2021 09:00	0.0	0	0	0	0	1
12/25/2021 10:00	0.0	0	0	0	0	1
12/25/2021 11:00	0.0	0	0	0	0	1
12/25/2021 12:00	0.0	0	0	0	0	1
12/25/2021 13:00	0.0	0	0	0	0	1
12/25/2021 14:00	0.0	0	0	0	0	1
12/25/2021 15:00	0.0	0	0	0	0	1
12/25/2021 16:00	0.0	0	0	0	0	1
12/25/2021 17:00	0.0	0	0	0	0	1
12/25/2021 18:00	0.0	0	0	0	0	1
12/25/2021 19:00	0.0	0	0	0	0	1
12/25/2021 20:00	0.0	0	0	0	0	1
12/25/2021 21:00	0.0	0	0	0	0	1
12/25/2021 22:00	0.0	0	0	0	0	1
12/25/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/26/2021 00:00	60.5	0	0	0	1	0
12/26/2021 01:00	0.0	0	0	0	0	0
12/26/2021 02:00	0.0	0	0	0	0	0
12/26/2021 03:00	0.0	0	0	0	0	0
12/26/2021 04:00	0.0	0	0	0	0	0
12/26/2021 05:00	0.0	0	0	0	0	0
12/26/2021 06:00	0.0	0	0	0	0	0
12/26/2021 07:00	0.0	0	0	0	0	0
12/26/2021 08:00	0.0	0	0	0	0	0
12/26/2021 09:00	0.0	0	0	0	0	0
12/26/2021 10:00	0.0	0	0	0	0	0
12/26/2021 11:00	0.0	0	0	0	0	0
12/26/2021 12:00	0.0	0	0	0	0	0
12/26/2021 13:00	0.0	0	0	0	0	0
12/26/2021 14:00	0.0	0	0	0	0	0
12/26/2021 15:00	398.4	0	1	0	0	0
12/26/2021 16:00	6,073.8	0	1	0	0	0
12/26/2021 17:00	0.0	0	0	0	0	1
12/26/2021 18:00	0.0	0	0	0	0	1
12/26/2021 19:00	0.0	0	0	0	0	1
12/26/2021 20:00	0.0	0	0	0	0	1
12/26/2021 21:00	0.0	0	0	0	0	1
12/26/2021 22:00	0.0	0	0	0	0	1
12/26/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,532.7 #	0 #	2 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,073.8	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/27/2021 00:00	0.0	0	0	0	0	1
12/27/2021 01:00	0.0	0	0	0	0	1
12/27/2021 02:00	0.0	0	0	0	0	1
12/27/2021 03:00	0.0	0	0	0	0	1
12/27/2021 04:00	0.0	0	0	0	0	1
12/27/2021 05:00	0.0	0	0	0	0	1
12/27/2021 06:00	0.0	0	0	0	0	1
12/27/2021 07:00	0.0	0	0	0	0	1
12/27/2021 08:00	0.0	0	0	0	0	1
12/27/2021 09:00	0.0	0	0	0	0	1
12/27/2021 10:00	0.0	0	0	0	0	1
12/27/2021 11:00	0.0	0	0	0	0	1
12/27/2021 12:00	0.0	0	0	0	0	1
12/27/2021 13:00	0.0	0	0	0	0	1
12/27/2021 14:00	0.0	0	0	0	0	1
12/27/2021 15:00	0.0	0	0	0	0	1
12/27/2021 16:00	0.0	0	0	0	0	1
12/27/2021 17:00	0.0	0	0	0	0	1
12/27/2021 18:00	0.0	0	0	0	0	1
12/27/2021 19:00	0.0	0	0	0	0	1
12/27/2021 20:00	0.0	0	0	0	0	1
12/27/2021 21:00	0.0	0	0	0	0	1
12/27/2021 22:00	0.0	0	0	0	0	1
12/27/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/28/2021 00:00	0.0	0	0	0	0	1
12/28/2021 01:00	0.0	0	0	0	0	1
12/28/2021 02:00	0.0	0	0	0	0	1
12/28/2021 03:00	0.0	0	0	0	0	1
12/28/2021 04:00	0.0	0	0	0	0	1
12/28/2021 05:00	0.0	0	0	0	0	1
12/28/2021 06:00	0.0	0	0	0	0	1
12/28/2021 07:00	0.0	0	0	0	0	1
12/28/2021 08:00	0.0	0	0	0	0	1
12/28/2021 09:00	0.0	0	0	0	0	1
12/28/2021 10:00	0.0	0	0	0	0	1
12/28/2021 11:00	0.0	0	0	0	0	1
12/28/2021 12:00	0.0	0	0	0	0	1
12/28/2021 13:00	0.0	0	0	0	0	1
12/28/2021 14:00	0.0	0	0	0	0	1
12/28/2021 15:00	0.0	0	0	0	0	1
12/28/2021 16:00	0.0	0	0	0	0	1
12/28/2021 17:00	0.0	0	0	0	0	1
12/28/2021 18:00	0.0	0	0	0	0	1
12/28/2021 19:00	0.0	0	0	0	0	1
12/28/2021 20:00	0.0	0	0	0	0	1
12/28/2021 21:00	0.0	0	0	0	0	1
12/28/2021 22:00	0.0	0	0	0	0	1
12/28/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/29/2021 00:00	0.0	0	0	0	0	1
12/29/2021 01:00	0.0	0	0	0	0	1
12/29/2021 02:00	0.0	0	0	0	0	1
12/29/2021 03:00	0.0	0	0	0	0	1
12/29/2021 04:00	0.0	0	0	0	0	1
12/29/2021 05:00	0.0	0	0	0	0	1
12/29/2021 06:00	0.0	0	0	0	0	1
12/29/2021 07:00	0.0	0	0	0	0	1
12/29/2021 08:00	0.0	0	0	0	0	1
12/29/2021 09:00	0.0	0	0	0	0	1
12/29/2021 10:00	0.0	0	0	0	0	1
12/29/2021 11:00	0.0	0	0	0	0	1
12/29/2021 12:00	0.0	0	0	0	0	1
12/29/2021 13:00	0.0	0	0	0	0	1
12/29/2021 14:00	0.0	0	0	0	0	1
12/29/2021 15:00	0.0	0	0	0	0	1
12/29/2021 16:00	0.0	0	0	0	0	1
12/29/2021 17:00	0.0	0	0	0	0	1
12/29/2021 18:00	0.0	0	0	0	0	1
12/29/2021 19:00	0.0	0	0	0	0	1
12/29/2021 20:00	0.0	0	0	0	0	1
12/29/2021 21:00	0.0	0	0	0	0	1
12/29/2021 22:00	0.0	0	0	0	0	1
12/29/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/30/2021 00:00	0.0	0	0	0	0	1
12/30/2021 01:00	0.0	0	0	0	0	1
12/30/2021 02:00	0.0	0	0	0	0	1
12/30/2021 03:00	0.0	0	0	0	0	1
12/30/2021 04:00	0.0	0	0	0	0	1
12/30/2021 05:00	0.0	0	0	0	0	1
12/30/2021 06:00	0.0	0	0	0	0	1
12/30/2021 07:00	0.0	0	0	0	0	1
12/30/2021 08:00	0.0	0	0	0	0	1
12/30/2021 09:00	0.0	0	0	0	0	1
12/30/2021 10:00	0.0	0	0	0	0	1
12/30/2021 11:00	0.0	0	0	0	0	1
12/30/2021 12:00	0.0	0	0	0	0	1
12/30/2021 13:00	0.0	0	0	0	0	1
12/30/2021 14:00	0.0	0	0	0	0	1
12/30/2021 15:00	0.0	0	0	0	0	1
12/30/2021 16:00	0.0	0	0	0	0	1
12/30/2021 17:00	0.0	0	0	0	0	1
12/30/2021 18:00	0.0	0	0	0	0	1
12/30/2021 19:00	0.0	0	0	0	0	1
12/30/2021 20:00	0.0	0	0	0	0	1
12/30/2021 21:00	0.0	0	0	0	0	1
12/30/2021 22:00	0.0	0	0	0	0	1
12/30/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/31/2021 00:00	0.0	0	0	0	0	1
12/31/2021 01:00	0.0	0	0	0	0	1
12/31/2021 02:00	0.0	0	0	0	0	1
12/31/2021 03:00	0.0	0	0	0	0	1
12/31/2021 04:00	0.0	0	0	0	0	1
12/31/2021 05:00	0.0	0	0	0	0	1
12/31/2021 06:00	0.0	0	0	0	0	1
12/31/2021 07:00	0.0	0	0	0	0	1
12/31/2021 08:00	0.0	0	0	0	0	1
12/31/2021 09:00	0.0	0	0	0	0	1
12/31/2021 10:00	0.0	0	0	0	0	1
12/31/2021 11:00	0.0	0	0	0	0	1
12/31/2021 12:00	0.0	0	0	0	0	1
12/31/2021 13:00	0.0	0	0	0	0	1
12/31/2021 14:00	0.0	0	0	0	0	1
12/31/2021 15:00	0.0	0	0	0	0	1
12/31/2021 16:00	0.0	0	0	0	0	1
12/31/2021 17:00	0.0	0	0	0	0	1
12/31/2021 18:00	0.0	0	0	0	0	1
12/31/2021 19:00	0.0	0	0	0	0	1
12/31/2021 20:00	0.0	0	0	0	0	1
12/31/2021 21:00	0.0	0	0	0	0	1
12/31/2021 22:00	0.0	0	0	0	0	1
12/31/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/01/2021 00:00	0.0	0	0	0	0	0
10/01/2021 01:00	0.0	0	0	0	0	0
10/01/2021 02:00	0.0	0	0	0	0	0
10/01/2021 03:00	0.0	0	0	0	0	0
10/01/2021 04:00	0.0	0	0	0	0	0
10/01/2021 05:00	0.0	0	0	0	0	0
10/01/2021 06:00	0.0	0	0	0	0	0
10/01/2021 07:00	0.0	0	0	0	0	0
10/01/2021 08:00	0.0	0	0	0	0	0
10/01/2021 09:00	0.0	0	0	0	0	0
10/01/2021 10:00	0.0	0	0	0	0	0
10/01/2021 11:00	0.0	0	0	0	0	0
10/01/2021 12:00	0.0	0	0	0	0	0
10/01/2021 13:00	36.5	0	1	0	0	0
10/01/2021 14:00	47.0	0	1	0	0	0
10/01/2021 15:00	0.0	0	0	0	0	1
10/01/2021 16:00	0.0	0	0	0	0	1
10/01/2021 17:00	0.0	0	0	0	0	1
10/01/2021 18:00	0.0	0	0	0	0	1
10/01/2021 19:00	0.0	0	0	0	0	1
10/01/2021 20:00	0.0	0	0	0	0	1
10/01/2021 21:00	0.0	0	0	0	0	1
10/01/2021 22:00	0.0	0	0	0	0	1
10/01/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	83.5 #	0 #	2 #	0 #	0 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	47.0	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/02/2021 00:00	0.0	0	0	0	0	1
10/02/2021 01:00	0.0	0	0	0	0	1
10/02/2021 02:00	0.0	0	0	0	0	1
10/02/2021 03:00	0.0	0	0	0	0	1
10/02/2021 04:00	0.0	0	0	0	0	1
10/02/2021 05:00	0.0	0	0	0	0	1
10/02/2021 06:00	0.0	0	0	0	0	1
10/02/2021 07:00	0.0	0	0	0	0	1
10/02/2021 08:00	0.0	0	0	0	0	1
10/02/2021 09:00	0.0	0	0	0	0	1
10/02/2021 10:00	0.0	0	0	0	0	1
10/02/2021 11:00	0.0	0	0	0	0	1
10/02/2021 12:00	0.0	0	0	0	0	1
10/02/2021 13:00	0.0	0	0	0	0	1
10/02/2021 14:00	0.0	0	0	0	0	1
10/02/2021 15:00	0.0	0	0	0	0	1
10/02/2021 16:00	0.0	0	0	0	0	1
10/02/2021 17:00	0.0	0	0	0	0	1
10/02/2021 18:00	0.0	0	0	0	0	1
10/02/2021 19:00	0.0	0	0	0	0	1
10/02/2021 20:00	0.0	0	0	0	0	1
10/02/2021 21:00	0.0	0	0	0	0	1
10/02/2021 22:00	0.0	0	0	0	0	1
10/02/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/03/2021 00:00	0.0	0	0	0	0	1
10/03/2021 01:00	0.0	0	0	0	0	1
10/03/2021 02:00	0.0	0	0	0	0	1
10/03/2021 03:00	0.0	0	0	0	0	1
10/03/2021 04:00	0.0	0	0	0	0	1
10/03/2021 05:00	0.0	0	0	0	0	1
10/03/2021 06:00	0.0	0	0	0	0	1
10/03/2021 07:00	0.0	0	0	0	0	1
10/03/2021 08:00	0.0	0	0	0	0	1
10/03/2021 09:00	0.0	0	0	0	0	1
10/03/2021 10:00	0.0	0	0	0	0	1
10/03/2021 11:00	0.0	0	0	0	0	1
10/03/2021 12:00	0.0	0	0	0	0	1
10/03/2021 13:00	0.0	0	0	0	0	1
10/03/2021 14:00	0.0	0	0	0	0	1
10/03/2021 15:00	0.0	0	0	0	0	1
10/03/2021 16:00	0.0	0	0	0	0	1
10/03/2021 17:00	0.0	0	0	0	0	1
10/03/2021 18:00	0.0	0	0	0	0	1
10/03/2021 19:00	0.0	0	0	0	0	1
10/03/2021 20:00	0.0	0	0	0	0	1
10/03/2021 21:00	0.0	0	0	0	0	1
10/03/2021 22:00	0.0	0	0	0	0	1
10/03/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/04/2021 00:00	0.0	0	0	0	0	1
10/04/2021 01:00	0.0	0	0	0	0	1
10/04/2021 02:00	0.0	0	0	0	0	1
10/04/2021 03:00	0.0	0	0	0	0	1
10/04/2021 04:00	0.0	0	0	0	0	1
10/04/2021 05:00	0.0	0	0	0	0	1
10/04/2021 06:00	0.0	0	0	0	0	1
10/04/2021 07:00	0.0	0	0	0	0	1
10/04/2021 08:00	0.0	0	0	0	0	1
10/04/2021 09:00	0.0	0	0	0	0	1
10/04/2021 10:00	0.0	0	0	0	0	1
10/04/2021 11:00	0.0	0	0	0	0	1
10/04/2021 12:00	0.0	0	0	0	0	1
10/04/2021 13:00	0.0	0	0	0	0	1
10/04/2021 14:00	0.0	0	0	0	0	1
10/04/2021 15:00	0.0	0	0	0	0	1
10/04/2021 16:00	0.0	0	0	0	0	1
10/04/2021 17:00	0.0	0	0	0	0	1
10/04/2021 18:00	0.0	0	0	0	0	1
10/04/2021 19:00	0.0	0	0	0	0	1
10/04/2021 20:00	0.0	0	0	0	0	1
10/04/2021 21:00	0.0	0	0	0	0	1
10/04/2021 22:00	0.0	0	0	0	0	1
10/04/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/05/2021 00:00	0.0	0	0	0	0	1
10/05/2021 01:00	0.0	0	0	0	0	1
10/05/2021 02:00	0.0	0	0	0	0	1
10/05/2021 03:00	0.0	0	0	0	0	1
10/05/2021 04:00	0.0	0	0	0	0	1
10/05/2021 05:00	0.0	0	0	0	0	1
10/05/2021 06:00	0.0	0	0	0	0	1
10/05/2021 07:00	0.0	0	0	0	0	1
10/05/2021 08:00	0.0	0	0	0	0	1
10/05/2021 09:00	0.0	0	0	0	0	1
10/05/2021 10:00	0.0	0	0	0	0	1
10/05/2021 11:00	0.0	0	0	0	0	1
10/05/2021 12:00	0.0	0	0	0	0	1
10/05/2021 13:00	0.0	0	0	0	0	1
10/05/2021 14:00	0.0	0	0	0	0	1
10/05/2021 15:00	0.0	0	0	0	0	1
10/05/2021 16:00	0.0	0	0	0	0	1
10/05/2021 17:00	0.0	0	0	0	0	1
10/05/2021 18:00	0.0	0	0	0	0	1
10/05/2021 19:00	0.0	0	0	0	0	1
10/05/2021 20:00	0.0	0	0	0	0	1
10/05/2021 21:00	0.0	0	0	0	0	1
10/05/2021 22:00	0.0	0	0	0	0	1
10/05/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/06/2021 00:00	0.0	0	0	0	0	1
10/06/2021 01:00	0.0	0	0	0	0	1
10/06/2021 02:00	0.0	0	0	0	0	1
10/06/2021 03:00	0.0	0	0	0	0	1
10/06/2021 04:00	0.0	0	0	0	0	1
10/06/2021 05:00	0.0	0	0	0	0	1
10/06/2021 06:00	0.0	0	0	0	0	1
10/06/2021 07:00	0.0	0	0	0	0	1
10/06/2021 08:00	0.0	0	0	0	0	1
10/06/2021 09:00	0.0	0	0	0	0	1
10/06/2021 10:00	0.0	0	0	0	0	1
10/06/2021 11:00	0.0	0	0	0	0	1
10/06/2021 12:00	0.0	0	0	0	0	1
10/06/2021 13:00	0.0	0	0	0	0	1
10/06/2021 14:00	0.0	0	0	0	0	1
10/06/2021 15:00	0.0	0	0	0	0	1
10/06/2021 16:00	0.0	0	0	0	0	1
10/06/2021 17:00	0.0	0	0	0	0	1
10/06/2021 18:00	0.0	0	0	0	0	1
10/06/2021 19:00	0.0	0	0	0	0	1
10/06/2021 20:00	0.0	0	0	0	0	1
10/06/2021 21:00	0.0	0	0	0	0	1
10/06/2021 22:00	0.0	0	0	0	0	1
10/06/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/07/2021 00:00	0.0	0	0	0	0	1
10/07/2021 01:00	0.0	0	0	0	0	1
10/07/2021 02:00	0.0	0	0	0	0	1
10/07/2021 03:00	0.0	0	0	0	0	1
10/07/2021 04:00	0.0	0	0	0	0	1
10/07/2021 05:00	0.0	0	0	0	0	1
10/07/2021 06:00	0.0	0	0	0	0	1
10/07/2021 07:00	0.0	0	0	0	0	1
10/07/2021 08:00	0.0	0	0	0	0	1
10/07/2021 09:00	0.0	0	0	0	0	1
10/07/2021 10:00	0.0	0	0	0	0	1
10/07/2021 11:00	0.0	0	0	0	0	1
10/07/2021 12:00	0.0	0	0	0	0	1
10/07/2021 13:00	0.0	0	0	0	0	1
10/07/2021 14:00	0.0	0	0	0	0	1
10/07/2021 15:00	0.0	0	0	0	0	1
10/07/2021 16:00	0.0	0	0	0	0	1
10/07/2021 17:00	0.0	0	0	0	0	1
10/07/2021 18:00	0.0	0	0	0	0	1
10/07/2021 19:00	0.0	0	0	0	0	1
10/07/2021 20:00	0.0	0	0	0	0	1
10/07/2021 21:00	0.0	0	0	0	0	1
10/07/2021 22:00	0.0	0	0	0	0	1
10/07/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/08/2021 00:00	0.0	0	0	0	0	1
10/08/2021 01:00	0.0	0	0	0	0	1
10/08/2021 02:00	0.0	0	0	0	0	1
10/08/2021 03:00	0.0	0	0	0	0	1
10/08/2021 04:00	0.0	0	0	0	0	1
10/08/2021 05:00	0.0	0	0	0	0	1
10/08/2021 06:00	0.0	0	0	0	0	1
10/08/2021 07:00	0.0	0	0	0	0	1
10/08/2021 08:00	0.0	0	0	0	0	1
10/08/2021 09:00	0.0	0	0	0	0	1
10/08/2021 10:00	0.0	0	0	0	0	1
10/08/2021 11:00	0.0	0	0	0	0	1
10/08/2021 12:00	0.0	0	0	0	0	1
10/08/2021 13:00	0.0	0	0	0	0	1
10/08/2021 14:00	0.0	0	0	0	0	1
10/08/2021 15:00	0.0	0	0	0	0	1
10/08/2021 16:00	0.0	0	0	0	0	1
10/08/2021 17:00	0.0	0	0	0	0	1
10/08/2021 18:00	0.0	0	0	0	0	1
10/08/2021 19:00	0.0	0	0	0	0	1
10/08/2021 20:00	0.0	0	0	0	0	1
10/08/2021 21:00	0.9	0	0	0	1	0
10/08/2021 22:00	0.0	0	0	0	0	0
10/08/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.9 #	0 #	0 #	0 #	1 #	21 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.9	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/09/2021 00:00	0.0	0	0	0	0	0
10/09/2021 01:00	0.0	0	0	0	0	0
10/09/2021 02:00	0.0	0	0	0	0	0
10/09/2021 03:00	0.0	0	0	0	0	0
10/09/2021 04:00	0.0	0	0	0	0	0
10/09/2021 05:00	0.0	0	0	0	0	0
10/09/2021 06:00	0.0	0	0	0	0	0
10/09/2021 07:00	0.0	0	0	0	0	0
10/09/2021 08:00	0.0	0	0	0	0	0
10/09/2021 09:00	0.0	0	0	0	0	0
10/09/2021 10:00	0.0	0	0	0	0	0
10/09/2021 11:00	0.0	0	0	0	0	0
10/09/2021 12:00	0.0	0	0	0	0	0
10/09/2021 13:00	0.0	0	0	0	0	0
10/09/2021 14:00	0.0	0	0	0	0	0
10/09/2021 15:00	0.0	0	0	0	0	0
10/09/2021 16:00	0.0	0	0	0	0	0
10/09/2021 17:00	0.0	0	0	0	0	0
10/09/2021 18:00	0.0	0	0	0	0	0
10/09/2021 19:00	0.0	0	0	0	0	0
10/09/2021 20:00	0.0	0	0	0	0	0
10/09/2021 21:00	0.0	0	0	0	0	0
10/09/2021 22:00	0.0	0	0	0	0	0
10/09/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/10/2021 00:00	0.0	0	0	0	0	0
10/10/2021 01:00	0.0	0	0	0	0	0
10/10/2021 02:00	0.0	0	0	0	0	0
10/10/2021 03:00	0.0	0	0	0	0	0
10/10/2021 04:00	0.0	0	0	0	0	0
10/10/2021 05:00	0.0	0	0	0	0	0
10/10/2021 06:00	0.0	0	0	0	0	0
10/10/2021 07:00	0.0	0	0	0	0	0
10/10/2021 08:00	0.0	0	0	0	0	0
10/10/2021 09:00	0.0	0	0	0	0	0
10/10/2021 10:00	0.0	0	0	0	0	0
10/10/2021 11:00	0.0	0	0	0	0	0
10/10/2021 12:00	0.0	0	0	0	0	0
10/10/2021 13:00	0.0	0	0	0	0	0
10/10/2021 14:00	0.0	0	0	0	0	0
10/10/2021 15:00	0.0	0	0	0	0	0
10/10/2021 16:00	0.0	0	0	0	0	0
10/10/2021 17:00	0.0	0	0	0	0	0
10/10/2021 18:00	0.0	0	0	0	0	0
10/10/2021 19:00	0.0	0	0	0	0	0
10/10/2021 20:00	0.0	0	0	0	0	0
10/10/2021 21:00	0.0	0	0	0	0	0
10/10/2021 22:00	0.0	0	0	0	0	0
10/10/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/11/2021 00:00	0.0	0	0	0	0	0
10/11/2021 01:00	0.0	0	0	0	0	0
10/11/2021 02:00	0.0	0	0	0	0	0
10/11/2021 03:00	0.0	0	0	0	0	0
10/11/2021 04:00	0.0	0	0	0	0	0
10/11/2021 05:00	0.0	0	0	0	0	0
10/11/2021 06:00	0.0	0	0	0	0	0
10/11/2021 07:00	0.0	0	0	0	0	0
10/11/2021 08:00	0.0	0	0	0	0	0
10/11/2021 09:00	0.0	0	0	0	0	0
10/11/2021 10:00	0.0	0	0	0	0	0
10/11/2021 11:00	0.0	0	0	0	0	0
10/11/2021 12:00	0.0	0	0	0	0	0
10/11/2021 13:00	0.0	0	0	0	0	0
10/11/2021 14:00	0.0	0	0	0	0	0
10/11/2021 15:00	0.0	0	0	0	0	0
10/11/2021 16:00	0.0	0	0	0	0	0
10/11/2021 17:00	0.0	0	0	0	0	0
10/11/2021 18:00	0.0	0	0	0	0	0
10/11/2021 19:00	0.0	0	0	0	0	0
10/11/2021 20:00	0.0	0	0	0	0	0
10/11/2021 21:00	0.0	0	0	0	0	0
10/11/2021 22:00	0.0	0	0	0	0	0
10/11/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/12/2021 00:00	0.0	0	0	0	0	0
10/12/2021 01:00	0.0	0	0	0	0	0
10/12/2021 02:00	0.0	0	0	0	0	0
10/12/2021 03:00	0.0	0	0	0	0	0
10/12/2021 04:00	0.0	0	0	0	0	0
10/12/2021 05:00	0.0	0	0	0	0	0
10/12/2021 06:00	0.0	0	0	0	0	0
10/12/2021 07:00	0.0	0	0	0	0	0
10/12/2021 08:00	0.0	0	0	0	0	0
10/12/2021 09:00	0.0	0	0	0	0	0
10/12/2021 10:00	0.0	0	0	0	0	0
10/12/2021 11:00	0.0	0	0	0	0	0
10/12/2021 12:00	0.0	0	0	0	0	0
10/12/2021 13:00	0.0	0	0	0	0	0
10/12/2021 14:00	0.0	0	0	0	0	0
10/12/2021 15:00	0.0	0	0	0	0	0
10/12/2021 16:00	0.0	0	0	0	0	0
10/12/2021 17:00	0.0	0	0	0	0	0
10/12/2021 18:00	0.0	0	0	0	0	0
10/12/2021 19:00	0.0	0	0	0	0	0
10/12/2021 20:00	0.0	0	0	0	0	0
10/12/2021 21:00	0.0	0	0	0	0	0
10/12/2021 22:00	0.0	0	0	0	0	0
10/12/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/13/2021 00:00	0.0	0	0	0	0	0
10/13/2021 01:00	0.0	0	0	0	0	0
10/13/2021 02:00	0.0	0	0	0	0	0
10/13/2021 03:00	0.0	0	0	0	0	0
10/13/2021 04:00	0.0	0	0	0	0	0
10/13/2021 05:00	0.0	0	0	0	0	0
10/13/2021 06:00	0.0	0	0	0	0	0
10/13/2021 07:00	0.0	0	0	0	0	0
10/13/2021 08:00	0.0	0	0	0	0	0
10/13/2021 09:00	0.0	0	0	0	0	0
10/13/2021 10:00	0.0	0	0	0	0	0
10/13/2021 11:00	0.0	0	0	0	0	0
10/13/2021 12:00	0.0	0	0	0	0	0
10/13/2021 13:00	0.0	0	0	0	0	0
10/13/2021 14:00	0.0	0	0	0	0	0
10/13/2021 15:00	0.0	0	0	0	0	0
10/13/2021 16:00	0.0	0	0	0	0	0
10/13/2021 17:00	0.0	0	0	0	0	0
10/13/2021 18:00	0.0	0	0	0	0	0
10/13/2021 19:00	0.0	0	0	0	0	0
10/13/2021 20:00	0.0	0	0	0	0	0
10/13/2021 21:00	0.0	0	0	0	0	0
10/13/2021 22:00	0.0	0	0	0	0	0
10/13/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/14/2021 00:00	0.0	0	0	0	0	0
10/14/2021 01:00	0.0	0	0	0	0	0
10/14/2021 02:00	0.0	0	0	0	0	0
10/14/2021 03:00	0.0	0	0	0	0	0
10/14/2021 04:00	0.0	0	0	0	0	0
10/14/2021 05:00	0.0	0	0	0	0	0
10/14/2021 06:00	0.0	0	0	0	0	0
10/14/2021 07:00	0.0	0	0	0	0	0
10/14/2021 08:00	0.0	0	0	0	0	0
10/14/2021 09:00	0.0	0	0	0	0	0
10/14/2021 10:00	0.0	0	0	0	0	0
10/14/2021 11:00	0.0	0	0	0	0	0
10/14/2021 12:00	0.0	0	0	0	0	0
10/14/2021 13:00	0.0	0	0	0	0	0
10/14/2021 14:00	0.0	0	0	0	0	0
10/14/2021 15:00	0.0	0	0	0	0	0
10/14/2021 16:00	0.0	0	0	0	0	0
10/14/2021 17:00	0.0	0	0	0	0	0
10/14/2021 18:00	0.0	0	0	0	0	0
10/14/2021 19:00	0.0	0	0	0	0	0
10/14/2021 20:00	0.0	0	0	0	0	0
10/14/2021 21:00	0.0	0	0	0	0	0
10/14/2021 22:00	0.0	0	0	0	0	0
10/14/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/15/2021 00:00	0.0	0	0	0	0	0
10/15/2021 01:00	0.0	0	0	0	0	0
10/15/2021 02:00	0.0	0	0	0	0	0
10/15/2021 03:00	0.0	0	0	0	0	0
10/15/2021 04:00	0.0	0	0	0	0	0
10/15/2021 05:00	0.0	0	0	0	0	0
10/15/2021 06:00	0.0	0	0	0	0	0
10/15/2021 07:00	0.0	0	0	0	0	0
10/15/2021 08:00	0.0	0	0	0	0	0
10/15/2021 09:00	0.0	0	0	0	0	0
10/15/2021 10:00	0.0	0	0	0	0	0
10/15/2021 11:00	0.0	0	0	0	0	0
10/15/2021 12:00	0.0	0	0	0	0	0
10/15/2021 13:00	0.0	0	0	0	0	0
10/15/2021 14:00	0.0	0	0	0	0	0
10/15/2021 15:00	0.0	0	0	0	0	0
10/15/2021 16:00	0.0	0	0	0	0	0
10/15/2021 17:00	0.0	0	0	0	0	0
10/15/2021 18:00	0.0	0	0	0	0	0
10/15/2021 19:00	0.0	0	0	0	0	0
10/15/2021 20:00	0.0	0	0	0	0	0
10/15/2021 21:00	0.0	0	0	0	0	0
10/15/2021 22:00	0.0	0	0	0	0	0
10/15/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/16/2021 00:00	0.0	0	0	0	0	0
10/16/2021 01:00	0.0	0	0	0	0	0
10/16/2021 02:00	0.0	0	0	0	0	0
10/16/2021 03:00	0.0	0	0	0	0	0
10/16/2021 04:00	0.0	0	0	0	0	0
10/16/2021 05:00	0.0	0	0	0	0	0
10/16/2021 06:00	0.0	0	0	0	0	0
10/16/2021 07:00	0.0	0	0	0	0	0
10/16/2021 08:00	0.0	0	0	0	0	0
10/16/2021 09:00	0.0	0	0	0	0	0
10/16/2021 10:00	0.0	0	0	0	0	0
10/16/2021 11:00	0.0	0	0	0	0	0
10/16/2021 12:00	0.0	0	0	0	0	0
10/16/2021 13:00	0.0	0	0	0	0	0
10/16/2021 14:00	0.0	0	0	0	0	0
10/16/2021 15:00	0.0	0	0	0	0	0
10/16/2021 16:00	0.0	0	0	0	0	0
10/16/2021 17:00	0.0	0	0	0	0	0
10/16/2021 18:00	0.0	0	0	0	0	0
10/16/2021 19:00	0.0	0	0	0	0	0
10/16/2021 20:00	0.0	0	0	0	0	0
10/16/2021 21:00	0.0	0	0	0	0	0
10/16/2021 22:00	0.0	0	0	0	0	0
10/16/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/17/2021 00:00	0.0	0	0	0	0	0
10/17/2021 01:00	0.0	0	0	0	0	0
10/17/2021 02:00	0.0	0	0	0	0	0
10/17/2021 03:00	0.0	0	0	0	0	0
10/17/2021 04:00	0.0	0	0	0	0	0
10/17/2021 05:00	0.0	0	0	0	0	0
10/17/2021 06:00	0.0	0	0	0	0	0
10/17/2021 07:00	0.0	0	0	0	0	0
10/17/2021 08:00	0.0	0	0	0	0	0
10/17/2021 09:00	0.0	0	0	0	0	0
10/17/2021 10:00	0.0	0	0	0	0	0
10/17/2021 11:00	0.0	0	0	0	0	0
10/17/2021 12:00	0.0	0	0	0	0	0
10/17/2021 13:00	0.0	0	0	0	0	0
10/17/2021 14:00	0.0	0	0	0	0	0
10/17/2021 15:00	0.0	0	0	0	0	0
10/17/2021 16:00	0.0	0	0	0	0	0
10/17/2021 17:00	0.0	0	0	0	0	0
10/17/2021 18:00	0.0	0	0	0	0	0
10/17/2021 19:00	0.0	0	0	0	0	0
10/17/2021 20:00	0.0	0	0	0	0	0
10/17/2021 21:00	0.0	0	0	0	0	0
10/17/2021 22:00	0.0	0	0	0	0	0
10/17/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/18/2021 00:00	0.0	0	0	0	0	0
10/18/2021 01:00	0.0	0	0	0	0	0
10/18/2021 02:00	0.0	0	0	0	0	0
10/18/2021 03:00	0.0	0	0	0	0	0
10/18/2021 04:00	0.0	0	0	0	0	0
10/18/2021 05:00	0.0	0	0	0	0	0
10/18/2021 06:00	0.0	0	0	0	0	0
10/18/2021 07:00	0.0	0	0	0	0	0
10/18/2021 08:00	0.0	0	0	0	0	0
10/18/2021 09:00	0.0	0	0	0	0	0
10/18/2021 10:00	0.0	0	0	0	0	0
10/18/2021 11:00	0.0	0	0	0	0	0
10/18/2021 12:00	0.0	0	0	0	0	0
10/18/2021 13:00	0.0	0	0	0	0	0
10/18/2021 14:00	0.0	0	0	0	0	0
10/18/2021 15:00	0.0	0	0	0	0	0
10/18/2021 16:00	0.0	0	0	0	0	0
10/18/2021 17:00	0.0	0	0	0	0	0
10/18/2021 18:00	0.0	0	0	0	0	0
10/18/2021 19:00	0.0	0	0	0	0	0
10/18/2021 20:00	0.0	0	0	0	0	0
10/18/2021 21:00	0.0	0	0	0	0	0
10/18/2021 22:00	0.0	0	0	0	0	0
10/18/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/19/2021 00:00	0.0	0	0	0	0	0
10/19/2021 01:00	0.0	0	0	0	0	0
10/19/2021 02:00	0.0	0	0	0	0	0
10/19/2021 03:00	0.0	0	0	0	0	0
10/19/2021 04:00	0.0	0	0	0	0	0
10/19/2021 05:00	0.0	0	0	0	0	0
10/19/2021 06:00	0.0	0	0	0	0	0
10/19/2021 07:00	0.0	0	0	0	0	0
10/19/2021 08:00	0.0	0	0	0	0	0
10/19/2021 09:00	0.0	0	0	0	0	0
10/19/2021 10:00	0.0	0	0	0	0	0
10/19/2021 11:00	0.0	0	0	0	0	0
10/19/2021 12:00	0.0	0	0	0	0	0
10/19/2021 13:00	0.0	0	0	0	0	0
10/19/2021 14:00	0.0	0	0	0	0	0
10/19/2021 15:00	0.0	0	0	0	0	0
10/19/2021 16:00	0.0	0	0	0	0	0
10/19/2021 17:00	0.0	0	0	0	0	0
10/19/2021 18:00	0.0	0	0	0	0	0
10/19/2021 19:00	0.0	0	0	0	0	0
10/19/2021 20:00	0.0	0	0	0	0	0
10/19/2021 21:00	0.0	0	0	0	0	0
10/19/2021 22:00	0.0	0	0	0	0	0
10/19/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/20/2021 00:00	0.0	0	0	0	0	0
10/20/2021 01:00	0.0	0	0	0	0	0
10/20/2021 02:00	0.0	0	0	0	0	0
10/20/2021 03:00	0.0	0	0	0	0	0
10/20/2021 04:00	0.0	0	0	0	0	0
10/20/2021 05:00	0.0	0	0	0	0	0
10/20/2021 06:00	0.0	0	0	0	0	0
10/20/2021 07:00	0.0	0	0	0	0	0
10/20/2021 08:00	6.1	1	0	0	0	0
10/20/2021 09:00	72.1	1	0	0	0	0
10/20/2021 10:00	12.0	1	0	0	0	0
10/20/2021 11:00	34.7	1	0	0	0	0
10/20/2021 12:00	10.4	1	0	0	0	0
10/20/2021 13:00	0.0	0	0	0	0	1
10/20/2021 14:00	0.0	0	0	0	0	1
10/20/2021 15:00	0.0	0	0	0	0	1
10/20/2021 16:00	0.0	0	0	0	0	1
10/20/2021 17:00	0.0	0	0	0	0	1
10/20/2021 18:00	0.0	0	0	0	0	1
10/20/2021 19:00	0.0	0	0	0	0	1
10/20/2021 20:00	0.0	0	0	0	0	1
10/20/2021 21:00	0.0	0	0	0	0	1
10/20/2021 22:00	0.9	0	0	0	1	0
10/20/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	136.2 #	5 #	0 #	0 #	1 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	72.1	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/21/2021 00:00	0.0	0	0	0	0	0
10/21/2021 01:00	0.0	0	0	0	0	0
10/21/2021 02:00	0.0	0	0	0	0	0
10/21/2021 03:00	0.0	0	0	0	0	0
10/21/2021 04:00	0.0	0	0	0	0	0
10/21/2021 05:00	0.0	0	0	0	0	0
10/21/2021 06:00	0.0	0	0	0	0	0
10/21/2021 07:00	0.0	0	0	0	0	0
10/21/2021 08:00	0.0	0	0	0	0	0
10/21/2021 09:00	0.0	0	0	0	0	0
10/21/2021 10:00	0.0	0	0	0	0	0
10/21/2021 11:00	0.0	0	0	0	0	0
10/21/2021 12:00	0.0	0	0	0	0	0
10/21/2021 13:00	0.0	0	0	0	0	0
10/21/2021 14:00	0.0	0	0	0	0	0
10/21/2021 15:00	0.0	0	0	0	0	0
10/21/2021 16:00	0.0	0	0	0	0	0
10/21/2021 17:00	0.0	0	0	0	0	0
10/21/2021 18:00	0.0	0	0	0	0	0
10/21/2021 19:00	0.0	0	0	0	0	0
10/21/2021 20:00	0.0	0	0	0	0	0
10/21/2021 21:00	0.0	0	0	0	0	0
10/21/2021 22:00	0.0	0	0	0	0	0
10/21/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/22/2021 00:00	0.0	0	0	0	0	0
10/22/2021 01:00	0.0	0	0	0	0	0
10/22/2021 02:00	0.0	0	0	0	0	0
10/22/2021 03:00	0.0	0	0	0	0	0
10/22/2021 04:00	0.0	0	0	0	0	0
10/22/2021 05:00	0.0	0	0	0	0	0
10/22/2021 06:00	0.0	0	0	0	0	0
10/22/2021 07:00	0.0	0	0	0	0	0
10/22/2021 08:00	0.0	0	0	0	0	0
10/22/2021 09:00	0.0	0	0	0	0	0
10/22/2021 10:00	0.0	0	0	0	0	0
10/22/2021 11:00	0.0	0	0	0	0	0
10/22/2021 12:00	0.0	0	0	0	0	0
10/22/2021 13:00	0.0	0	0	0	0	0
10/22/2021 14:00	0.0	0	0	0	0	0
10/22/2021 15:00	0.0	0	0	0	0	0
10/22/2021 16:00	0.0	0	0	0	0	0
10/22/2021 17:00	0.0	0	0	0	0	0
10/22/2021 18:00	0.0	0	0	0	0	0
10/22/2021 19:00	0.0	0	0	0	0	0
10/22/2021 20:00	0.0	0	0	0	0	0
10/22/2021 21:00	0.0	0	0	0	0	0
10/22/2021 22:00	0.0	0	0	0	0	0
10/22/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/23/2021 00:00	0.0	0	0	0	0	0
10/23/2021 01:00	0.0	0	0	0	0	0
10/23/2021 02:00	0.0	0	0	0	0	0
10/23/2021 03:00	0.0	0	0	0	0	0
10/23/2021 04:00	0.0	0	0	0	0	0
10/23/2021 05:00	0.0	0	1	0	0	0
10/23/2021 06:00	55.5	0	1	0	0	0
10/23/2021 07:00	7.5	0	1	0	0	0
10/23/2021 08:00	0.0	0	0	0	0	1
10/23/2021 09:00	0.0	0	0	0	0	1
10/23/2021 10:00	0.0	0	0	0	0	1
10/23/2021 11:00	0.0	0	0	0	0	1
10/23/2021 12:00	0.0	0	0	0	0	1
10/23/2021 13:00	0.0	0	0	0	0	1
10/23/2021 14:00	0.0	0	0	0	0	1
10/23/2021 15:00	0.0	0	0	0	0	1
10/23/2021 16:00	0.0	0	0	0	0	1
10/23/2021 17:00	0.0	0	0	0	0	1
10/23/2021 18:00	0.0	0	0	0	0	1
10/23/2021 19:00	0.0	0	0	0	0	1
10/23/2021 20:00	0.0	0	0	0	0	1
10/23/2021 21:00	0.0	0	0	0	0	1
10/23/2021 22:00	0.9	0	0	0	1	0
10/23/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	63.9 #	0 #	3 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	55.5	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/24/2021 00:00	0.0	0	0	0	0	0
10/24/2021 01:00	0.0	0	0	0	0	0
10/24/2021 02:00	0.0	0	0	0	0	0
10/24/2021 03:00	0.2	0	0	1	0	0
10/24/2021 04:00	21.2	0	0	1	0	0
10/24/2021 05:00	0.0	0	0	0	0	1
10/24/2021 06:00	0.0	0	0	0	0	1
10/24/2021 07:00	0.0	0	0	0	0	1
10/24/2021 08:00	0.0	0	0	0	0	1
10/24/2021 09:00	0.0	0	0	0	0	1
10/24/2021 10:00	0.0	0	0	0	0	1
10/24/2021 11:00	0.0	0	0	0	0	1
10/24/2021 12:00	0.0	0	0	0	0	1
10/24/2021 13:00	0.0	0	0	0	0	1
10/24/2021 14:00	0.0	0	0	0	0	1
10/24/2021 15:00	0.0	0	0	0	0	1
10/24/2021 16:00	0.0	0	0	0	0	1
10/24/2021 17:00	0.0	0	0	0	0	1
10/24/2021 18:00	0.0	0	0	0	0	1
10/24/2021 19:00	0.0	0	0	0	0	1
10/24/2021 20:00	0.0	0	0	0	0	1
10/24/2021 21:00	0.0	0	0	0	0	1
10/24/2021 22:00	0.0	0	0	0	0	1
10/24/2021 23:00	0.4	0	0	0	1	0
Average/Sum#:	21.8 #	0 #	0 #	2 #	1 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	21.2	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/25/2021 00:00	0.0	0	0	0	0	0
10/25/2021 01:00	0.0	0	0	0	0	0
10/25/2021 02:00	0.0	0	0	0	0	0
10/25/2021 03:00	0.0	0	0	0	0	0
10/25/2021 04:00	0.0	0	0	0	0	0
10/25/2021 05:00	7.0	0	0	1	0	0
10/25/2021 06:00	8.7	0	0	1	0	0
10/25/2021 07:00	0.0	0	0	0	0	1
10/25/2021 08:00	0.0	0	0	0	0	1
10/25/2021 09:00	0.0	0	0	0	0	1
10/25/2021 10:00	0.0	0	0	0	0	1
10/25/2021 11:00	0.0	0	0	0	0	1
10/25/2021 12:00	0.0	0	0	0	0	1
10/25/2021 13:00	0.0	0	0	0	0	1
10/25/2021 14:00	0.0	0	0	0	0	1
10/25/2021 15:00	0.0	0	0	0	0	1
10/25/2021 16:00	0.0	0	0	0	0	1
10/25/2021 17:00	0.0	0	0	0	0	1
10/25/2021 18:00	0.0	0	0	0	0	1
10/25/2021 19:00	0.0	0	0	0	0	1
10/25/2021 20:00	0.0	0	0	0	0	1
10/25/2021 21:00	0.0	0	0	0	0	1
10/25/2021 22:00	0.0	0	0	0	0	1
10/25/2021 23:00	0.5	0	0	0	1	0
Average/Sum#:	16.2 #	0 #	0 #	2 #	1 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	8.7	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/26/2021 00:00	0.0	0	0	0	0	0
10/26/2021 01:00	0.0	0	0	0	0	0
10/26/2021 02:00	0.0	0	0	0	0	0
10/26/2021 03:00	0.0	0	0	0	0	0
10/26/2021 04:00	0.0	0	0	0	0	0
10/26/2021 05:00	7.1	0	0	1	0	0
10/26/2021 06:00	9.7	0	0	1	0	0
10/26/2021 07:00	0.0	0	0	0	0	1
10/26/2021 08:00	0.0	0	0	0	0	1
10/26/2021 09:00	0.0	0	0	0	0	1
10/26/2021 10:00	0.0	0	0	0	0	1
10/26/2021 11:00	0.0	0	0	0	0	1
10/26/2021 12:00	0.0	0	0	0	0	1
10/26/2021 13:00	0.0	0	0	0	0	1
10/26/2021 14:00	0.0	0	0	0	0	1
10/26/2021 15:00	0.0	0	0	0	0	1
10/26/2021 16:00	0.0	0	0	0	0	1
10/26/2021 17:00	0.0	0	0	0	0	1
10/26/2021 18:00	0.0	0	0	0	0	1
10/26/2021 19:00	0.0	0	0	0	0	1
10/26/2021 20:00	0.0	0	0	0	0	1
10/26/2021 21:00	0.0	0	0	0	0	1
10/26/2021 22:00	0.0	0	0	0	0	1
10/26/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	16.8 #	0 #	0 #	2 #	0 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	9.7	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/27/2021 00:00	0.0	0	0	0	0	1
10/27/2021 01:00	0.0	0	0	0	0	1
10/27/2021 02:00	0.0	0	0	0	0	1
10/27/2021 03:00	0.0	0	0	0	0	1
10/27/2021 04:00	0.0	0	0	0	0	1
10/27/2021 05:00	0.0	0	0	0	0	1
10/27/2021 06:00	0.0	0	0	0	0	1
10/27/2021 07:00	0.0	0	0	0	0	1
10/27/2021 08:00	0.0	0	0	0	0	1
10/27/2021 09:00	0.0	0	0	0	0	1
10/27/2021 10:00	0.0	0	0	0	0	1
10/27/2021 11:00	0.0	0	0	0	0	1
10/27/2021 12:00	0.0	0	0	0	0	1
10/27/2021 13:00	0.0	0	0	0	0	1
10/27/2021 14:00	0.0	0	0	0	0	1
10/27/2021 15:00	0.0	0	0	0	0	1
10/27/2021 16:00	0.0	0	0	0	0	1
10/27/2021 17:00	0.0	0	0	0	0	1
10/27/2021 18:00	0.0	0	0	0	0	1
10/27/2021 19:00	0.0	0	0	0	0	1
10/27/2021 20:00	0.0	0	0	0	0	1
10/27/2021 21:00	0.0	0	0	0	0	1
10/27/2021 22:00	0.0	0	0	0	0	1
10/27/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/28/2021 00:00	0.3	0	0	0	1	0
10/28/2021 01:00	0.0	0	0	0	0	0
10/28/2021 02:00	0.0	0	0	0	0	0
10/28/2021 03:00	0.0	0	0	0	0	0
10/28/2021 04:00	0.0	0	0	0	0	0
10/28/2021 05:00	0.0	0	0	0	0	0
10/28/2021 06:00	0.0	0	0	0	0	0
10/28/2021 07:00	0.0	0	0	0	0	0
10/28/2021 08:00	0.0	0	0	0	0	0
10/28/2021 09:00	0.0	0	0	0	0	0
10/28/2021 10:00	0.0	0	0	0	0	0
10/28/2021 11:00	0.0	0	0	0	0	0
10/28/2021 12:00	15.1	0	1	0	0	0
10/28/2021 13:00	30.1	0	1	0	0	0
10/28/2021 14:00	0.0	0	0	0	0	1
10/28/2021 15:00	0.0	0	0	0	0	1
10/28/2021 16:00	0.0	0	0	0	0	1
10/28/2021 17:00	0.0	0	0	0	0	1
10/28/2021 18:00	0.0	0	0	0	0	1
10/28/2021 19:00	0.0	0	0	0	0	1
10/28/2021 20:00	0.0	0	0	0	0	1
10/28/2021 21:00	0.0	0	0	0	0	1
10/28/2021 22:00	0.0	0	0	0	0	1
10/28/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	45.5 #	0 #	2 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	30.1	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/29/2021 00:00	0.0	0	0	0	0	1
10/29/2021 01:00	0.0	0	0	0	0	1
10/29/2021 02:00	0.0	0	0	0	0	1
10/29/2021 03:00	0.0	0	0	0	0	1
10/29/2021 04:00	0.0	0	0	0	0	1
10/29/2021 05:00	0.0	0	0	0	0	1
10/29/2021 06:00	0.0	0	0	0	0	1
10/29/2021 07:00	0.0	0	0	0	0	1
10/29/2021 08:00	0.0	0	0	0	0	1
10/29/2021 09:00	0.0	0	0	0	0	1
10/29/2021 10:00	0.0	0	0	0	0	1
10/29/2021 11:00	0.0	0	0	0	0	1
10/29/2021 12:00	0.0	0	0	0	0	1
10/29/2021 13:00	0.0	0	0	0	0	1
10/29/2021 14:00	0.0	0	0	0	0	1
10/29/2021 15:00	0.0	0	0	0	0	1
10/29/2021 16:00	0.0	0	0	0	0	1
10/29/2021 17:00	0.0	0	0	0	0	1
10/29/2021 18:00	0.0	0	0	0	0	1
10/29/2021 19:00	0.0	0	0	0	0	1
10/29/2021 20:00	0.0	0	0	0	0	1
10/29/2021 21:00	0.0	0	0	0	0	1
10/29/2021 22:00	0.0	0	0	0	0	1
10/29/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/30/2021 00:00	0.0	0	0	0	0	1
10/30/2021 01:00	0.0	0	0	0	0	1
10/30/2021 02:00	0.0	0	0	0	0	1
10/30/2021 03:00	0.0	0	0	0	0	1
10/30/2021 04:00	0.0	0	0	0	0	1
10/30/2021 05:00	0.0	0	0	0	0	1
10/30/2021 06:00	0.0	0	0	0	0	1
10/30/2021 07:00	0.0	0	0	0	0	1
10/30/2021 08:00	0.0	0	0	0	0	1
10/30/2021 09:00	0.0	0	0	0	0	1
10/30/2021 10:00	0.0	0	0	0	0	1
10/30/2021 11:00	0.0	0	0	0	0	1
10/30/2021 12:00	0.0	0	0	0	0	1
10/30/2021 13:00	0.0	0	0	0	0	1
10/30/2021 14:00	0.0	0	0	0	0	1
10/30/2021 15:00	0.0	0	0	0	0	1
10/30/2021 16:00	0.0	0	0	0	0	1
10/30/2021 17:00	0.0	0	0	0	0	1
10/30/2021 18:00	0.0	0	0	0	0	1
10/30/2021 19:00	0.0	0	0	0	0	1
10/30/2021 20:00	0.0	0	0	0	0	1
10/30/2021 21:00	0.0	0	0	0	0	1
10/30/2021 22:00	0.0	0	0	0	0	1
10/30/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
10/31/2021 00:00	0.0	0	0	0	0	1
10/31/2021 01:00	0.0	0	0	0	0	1
10/31/2021 02:00	0.0	0	0	0	0	1
10/31/2021 03:00	0.0	0	0	0	0	1
10/31/2021 04:00	0.0	0	0	0	0	1
10/31/2021 05:00	0.0	0	0	0	0	1
10/31/2021 06:00	0.0	0	0	0	0	1
10/31/2021 07:00	0.0	0	0	0	0	1
10/31/2021 08:00	0.0	0	0	0	0	1
10/31/2021 09:00	0.0	0	0	0	0	1
10/31/2021 10:00	0.0	0	0	0	0	1
10/31/2021 11:00	0.0	0	0	0	0	1
10/31/2021 12:00	0.0	0	0	0	0	1
10/31/2021 13:00	0.0	0	0	0	0	1
10/31/2021 14:00	0.0	0	0	0	0	1
10/31/2021 15:00	0.0	0	0	0	0	1
10/31/2021 16:00	0.0	0	0	0	0	1
10/31/2021 17:00	0.0	0	0	0	0	1
10/31/2021 18:00	0.0	0	0	0	0	1
10/31/2021 19:00	0.0	0	0	0	0	1
10/31/2021 20:00	0.0	0	0	0	0	1
10/31/2021 21:00	0.0	0	0	0	0	1
10/31/2021 22:00	0.0	0	0	0	0	1
10/31/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/01/2021 00:00	0.0	0	0	0	0	1
11/01/2021 01:00	0.0	0	0	0	0	1
11/01/2021 02:00	0.0	0	0	0	0	1
11/01/2021 03:00	0.0	0	0	0	0	1
11/01/2021 04:00	0.0	0	0	0	0	1
11/01/2021 05:00	0.0	0	0	0	0	1
11/01/2021 06:00	0.0	0	0	0	0	1
11/01/2021 07:00	0.0	0	0	0	0	1
11/01/2021 08:00	0.0	0	0	0	0	1
11/01/2021 09:00	0.0	0	0	0	0	1
11/01/2021 10:00	0.0	0	0	0	0	1
11/01/2021 11:00	0.0	0	0	0	0	1
11/01/2021 12:00	0.0	0	0	0	0	1
11/01/2021 13:00	0.0	0	0	0	0	1
11/01/2021 14:00	0.0	0	0	0	0	1
11/01/2021 15:00	0.0	0	0	0	0	1
11/01/2021 16:00	0.0	0	0	0	0	1
11/01/2021 17:00	0.0	0	0	0	0	1
11/01/2021 18:00	0.0	0	0	0	0	1
11/01/2021 19:00	0.0	0	0	0	0	1
11/01/2021 20:00	0.0	0	0	0	0	1
11/01/2021 21:00	0.0	0	0	0	0	1
11/01/2021 22:00	0.0	0	0	0	0	1
11/01/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/02/2021 00:00	0.0	0	0	0	0	1
11/02/2021 01:00	0.0	0	0	0	0	1
11/02/2021 02:00	0.0	0	0	0	0	1
11/02/2021 03:00	0.0	0	0	0	0	1
11/02/2021 04:00	0.0	0	0	0	0	1
11/02/2021 05:00	0.0	0	0	0	0	1
11/02/2021 06:00	0.0	0	0	0	0	1
11/02/2021 07:00	0.0	0	0	0	0	1
11/02/2021 08:00	0.0	0	0	0	0	1
11/02/2021 09:00	0.0	0	0	0	0	1
11/02/2021 10:00	0.0	0	0	0	0	1
11/02/2021 11:00	0.0	0	0	0	0	1
11/02/2021 12:00	0.0	0	0	0	0	1
11/02/2021 13:00	0.0	0	0	0	0	1
11/02/2021 14:00	0.0	0	0	0	0	1
11/02/2021 15:00	0.0	0	0	0	0	1
11/02/2021 16:00	0.0	0	0	0	0	1
11/02/2021 17:00	0.0	0	0	0	0	1
11/02/2021 18:00	0.0	0	0	0	0	1
11/02/2021 19:00	0.0	0	0	0	0	1
11/02/2021 20:00	0.0	0	0	0	0	1
11/02/2021 21:00	0.0	0	0	0	0	1
11/02/2021 22:00	0.0	0	0	0	0	1
11/02/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/03/2021 00:00	0.0	0	0	0	0	1
11/03/2021 01:00	0.0	0	0	0	0	1
11/03/2021 02:00	0.0	0	0	0	0	1
11/03/2021 03:00	0.0	0	0	0	0	1
11/03/2021 04:00	0.0	0	0	0	0	1
11/03/2021 05:00	0.0	0	0	0	0	1
11/03/2021 06:00	0.0	0	0	0	0	1
11/03/2021 07:00	0.0	0	0	0	0	1
11/03/2021 08:00	0.0	0	0	0	0	1
11/03/2021 09:00	0.0	0	0	0	0	1
11/03/2021 10:00	0.0	0	0	0	0	1
11/03/2021 11:00	0.0	0	0	0	0	1
11/03/2021 12:00	0.0	0	0	0	0	1
11/03/2021 13:00	0.0	0	0	0	0	1
11/03/2021 14:00	0.0	0	0	0	0	1
11/03/2021 15:00	0.0	0	0	0	0	1
11/03/2021 16:00	0.0	0	0	0	0	1
11/03/2021 17:00	0.0	0	0	0	0	1
11/03/2021 18:00	0.0	0	0	0	0	1
11/03/2021 19:00	0.0	0	0	0	0	1
11/03/2021 20:00	0.0	0	0	0	0	1
11/03/2021 21:00	0.0	0	0	0	0	1
11/03/2021 22:00	0.0	0	0	0	0	1
11/03/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/04/2021 00:00	0.0	0	0	0	0	1
11/04/2021 01:00	0.0	0	0	0	0	1
11/04/2021 02:00	0.0	0	0	0	0	1
11/04/2021 03:00	0.0	0	0	0	0	1
11/04/2021 04:00	0.0	0	0	0	0	1
11/04/2021 05:00	0.0	0	0	0	0	1
11/04/2021 06:00	0.0	0	0	0	0	1
11/04/2021 07:00	0.0	0	0	0	0	1
11/04/2021 08:00	0.0	0	0	0	0	1
11/04/2021 09:00	0.0	0	0	0	0	1
11/04/2021 10:00	0.0	0	0	0	0	1
11/04/2021 11:00	0.0	0	0	0	0	1
11/04/2021 12:00	0.0	0	0	0	0	1
11/04/2021 13:00	0.0	0	0	0	0	1
11/04/2021 14:00	0.0	0	0	0	0	1
11/04/2021 15:00	0.0	0	0	0	0	1
11/04/2021 16:00	0.0	0	0	0	0	1
11/04/2021 17:00	0.0	0	0	0	0	1
11/04/2021 18:00	0.0	0	0	0	0	1
11/04/2021 19:00	0.0	0	0	0	0	1
11/04/2021 20:00	0.0	0	0	0	0	1
11/04/2021 21:00	0.0	0	0	0	0	1
11/04/2021 22:00	0.0	0	0	0	0	1
11/04/2021 23:00	0.6	0	0	0	1	0
Average/Sum#:	0.6 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.6	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/05/2021 00:00	0.0	0	0	0	0	0
11/05/2021 01:00	0.0	0	0	0	0	0
11/05/2021 02:00	0.0	0	0	0	0	0
11/05/2021 03:00	0.0	0	0	0	0	0
11/05/2021 04:00	0.0	0	0	0	0	0
11/05/2021 05:00	0.0	0	0	0	0	0
11/05/2021 06:00	0.0	0	0	0	0	0
11/05/2021 07:00	0.0	0	0	0	0	0
11/05/2021 08:00	0.0	0	0	0	0	0
11/05/2021 09:00	0.0	0	0	0	0	0
11/05/2021 10:00	0.0	0	0	0	0	0
11/05/2021 11:00	0.0	0	0	0	0	0
11/05/2021 12:00	0.0	0	0	0	0	0
11/05/2021 13:00	35.3	0	1	0	0	0
11/05/2021 14:00	14.4	0	1	0	0	0
11/05/2021 15:00	0.0	0	0	0	0	1
11/05/2021 16:00	0.0	0	0	0	0	1
11/05/2021 17:00	0.0	0	0	0	0	1
11/05/2021 18:00	0.0	0	0	0	0	1
11/05/2021 19:00	0.0	0	0	0	0	1
11/05/2021 20:00	0.0	0	0	0	0	1
11/05/2021 21:00	0.0	0	0	0	0	1
11/05/2021 22:00	0.0	0	0	0	0	1
11/05/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	49.7 #	0 #	2 #	0 #	0 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	35.3	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/06/2021 00:00	0.0	0	0	0	0	1
11/06/2021 01:00	0.0	0	0	0	0	1
11/06/2021 02:00	0.0	0	0	0	0	1
11/06/2021 03:00	0.0	0	0	0	0	1
11/06/2021 04:00	0.0	0	0	0	0	1
11/06/2021 05:00	0.0	0	0	0	0	1
11/06/2021 06:00	0.0	0	0	0	0	1
11/06/2021 07:00	0.0	0	0	0	0	1
11/06/2021 08:00	0.0	0	0	0	0	1
11/06/2021 09:00	0.0	0	0	0	0	1
11/06/2021 10:00	0.0	0	0	0	0	1
11/06/2021 11:00	0.0	0	0	0	0	1
11/06/2021 12:00	0.0	0	0	0	0	1
11/06/2021 13:00	0.0	0	0	0	0	1
11/06/2021 14:00	0.0	0	0	0	0	1
11/06/2021 15:00	0.0	0	0	0	0	1
11/06/2021 16:00	0.0	0	0	0	0	1
11/06/2021 17:00	0.0	0	0	0	0	1
11/06/2021 18:00	0.0	0	0	0	0	1
11/06/2021 19:00	0.0	0	0	0	0	1
11/06/2021 20:00	0.0	0	0	0	0	1
11/06/2021 21:00	0.0	0	0	0	0	1
11/06/2021 22:00	0.7	0	0	0	1	0
11/06/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.7 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.7	0	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/07/2021 00:00	0.0	0	0	0	0	0
11/07/2021 01:00	0.0	0	0	0	0	0
11/07/2021 02:00	0.0	0	0	0	0	0
11/07/2021 03:00	0.0	0	0	0	0	0
11/07/2021 04:00	0.0	0	0	0	0	0
11/07/2021 05:00	0.0	0	0	0	0	0
11/07/2021 06:00	0.0	0	0	0	0	0
11/07/2021 07:00	0.0	0	0	0	0	0
11/07/2021 08:00	0.0	0	0	0	0	0
11/07/2021 09:00	0.0	0	0	0	0	0
11/07/2021 10:00	0.0	0	0	0	0	0
11/07/2021 11:00	0.0	0	0	0	0	0
11/07/2021 12:00	0.0	0	0	0	0	0
11/07/2021 13:00	0.0	0	0	0	0	0
11/07/2021 14:00	0.0	0	0	0	0	0
11/07/2021 15:00	0.0	0	0	0	0	0
11/07/2021 16:00	0.0	0	0	0	0	0
11/07/2021 17:00	0.0	0	0	0	0	0
11/07/2021 18:00	0.0	0	0	0	0	0
11/07/2021 19:00	0.0	0	0	0	0	0
11/07/2021 20:00	0.0	0	0	0	0	0
11/07/2021 21:00	0.0	0	0	0	0	0
11/07/2021 22:00	0.0	0	0	0	0	0
11/07/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/08/2021 00:00	0.0	0	0	0	0	0
11/08/2021 01:00	0.0	0	0	0	0	0
11/08/2021 02:00	0.0	0	0	0	0	0
11/08/2021 03:00	0.0	0	0	0	0	0
11/08/2021 04:00	0.0	0	0	0	0	0
11/08/2021 05:00	0.0	0	0	0	0	0
11/08/2021 06:00	0.0	0	0	0	0	0
11/08/2021 07:00	0.0	0	0	0	0	0
11/08/2021 08:00	0.0	0	0	0	0	0
11/08/2021 09:00	0.0	0	0	0	0	0
11/08/2021 10:00	0.0	0	0	0	0	0
11/08/2021 11:00	0.0	0	0	0	0	0
11/08/2021 12:00	40.8	0	1	0	0	0
11/08/2021 13:00	39.9	0	1	0	0	0
11/08/2021 14:00	49.0	0	1	0	0	0
11/08/2021 15:00	0.0	0	0	0	0	1
11/08/2021 16:00	0.0	0	0	0	0	1
11/08/2021 17:00	0.0	0	0	0	0	1
11/08/2021 18:00	0.0	0	0	0	0	1
11/08/2021 19:00	0.0	0	0	0	0	1
11/08/2021 20:00	0.0	0	0	0	0	1
11/08/2021 21:00	0.0	0	0	0	0	1
11/08/2021 22:00	0.0	0	0	0	0	1
11/08/2021 23:00	0.5	0	0	0	1	0
Average/Sum#:	130.2 #	0 #	3 #	0 #	1 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	49.0	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/09/2021 00:00	0.0	0	0	0	0	0
11/09/2021 01:00	0.0	0	0	0	0	0
11/09/2021 02:00	0.0	0	0	0	0	0
11/09/2021 03:00	2.2	0	0	1	0	0
11/09/2021 04:00	15.6	0	0	1	0	0
11/09/2021 05:00	0.0	0	0	0	0	1
11/09/2021 06:00	0.0	0	0	0	0	1
11/09/2021 07:00	0.0	0	0	0	0	1
11/09/2021 08:00	0.0	0	0	0	0	1
11/09/2021 09:00	0.0	0	0	0	0	1
11/09/2021 10:00	0.0	0	0	0	0	1
11/09/2021 11:00	0.0	0	0	0	0	1
11/09/2021 12:00	0.0	0	0	0	0	1
11/09/2021 13:00	0.0	0	0	0	0	1
11/09/2021 14:00	0.0	0	0	0	0	1
11/09/2021 15:00	0.0	0	0	0	0	1
11/09/2021 16:00	0.0	0	0	0	0	1
11/09/2021 17:00	0.0	0	0	0	0	1
11/09/2021 18:00	0.0	0	0	0	0	1
11/09/2021 19:00	0.0	0	0	0	0	1
11/09/2021 20:00	0.0	0	0	0	0	1
11/09/2021 21:00	0.0	0	0	0	0	1
11/09/2021 22:00	0.0	0	0	0	0	1
11/09/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	17.8 #	0 #	0 #	2 #	0 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	15.6	0	0	1	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/10/2021 00:00	0.0	0	0	0	0	1
11/10/2021 01:00	0.0	0	0	0	0	1
11/10/2021 02:00	0.0	0	0	0	0	1
11/10/2021 03:00	0.0	0	0	0	0	1
11/10/2021 04:00	0.0	0	0	0	0	1
11/10/2021 05:00	0.0	0	0	0	0	1
11/10/2021 06:00	0.0	0	0	0	0	1
11/10/2021 07:00	0.0	0	0	0	0	1
11/10/2021 08:00	0.0	0	0	0	0	1
11/10/2021 09:00	0.0	0	0	0	0	1
11/10/2021 10:00	0.0	0	0	0	0	1
11/10/2021 11:00	0.0	0	0	0	0	1
11/10/2021 12:00	0.0	0	0	0	0	1
11/10/2021 13:00	0.0	0	0	0	0	1
11/10/2021 14:00	0.0	0	0	0	0	1
11/10/2021 15:00	0.0	0	0	0	0	1
11/10/2021 16:00	0.0	0	0	0	0	1
11/10/2021 17:00	0.0	0	0	0	0	1
11/10/2021 18:00	0.0	0	0	0	0	1
11/10/2021 19:00	0.0	0	0	0	0	1
11/10/2021 20:00	0.0	0	0	0	0	1
11/10/2021 21:00	0.0	0	0	0	0	1
11/10/2021 22:00	0.0	0	0	0	0	1
11/10/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/11/2021 00:00	0.0	0	0	0	0	1
11/11/2021 01:00	1.0	0	0	0	1	0
11/11/2021 02:00	0.0	0	0	0	0	0
11/11/2021 03:00	0.0	0	0	0	0	0
11/11/2021 04:00	0.0	0	0	0	0	0
11/11/2021 05:00	0.0	0	0	0	0	0
11/11/2021 06:00	0.0	0	0	0	0	0
11/11/2021 07:00	0.0	0	0	0	0	0
11/11/2021 08:00	0.0	0	0	0	0	0
11/11/2021 09:00	0.0	0	0	0	0	0
11/11/2021 10:00	0.0	0	0	0	0	0
11/11/2021 11:00	0.0	0	0	0	0	0
11/11/2021 12:00	0.0	0	0	0	0	0
11/11/2021 13:00	30.6	0	1	0	0	0
11/11/2021 14:00	27.3	0	1	0	0	0
11/11/2021 15:00	0.0	0	0	0	0	1
11/11/2021 16:00	0.0	0	0	0	0	1
11/11/2021 17:00	0.0	0	0	0	0	1
11/11/2021 18:00	0.0	0	0	0	0	1
11/11/2021 19:00	0.0	0	0	0	0	1
11/11/2021 20:00	0.0	0	0	0	0	1
11/11/2021 21:00	0.0	0	0	0	0	1
11/11/2021 22:00	0.0	0	0	0	0	1
11/11/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	58.9 #	0 #	2 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	30.6	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/12/2021 00:00	0.0	0	0	0	0	1
11/12/2021 01:00	0.0	0	0	0	0	1
11/12/2021 02:00	0.0	0	0	0	0	1
11/12/2021 03:00	0.0	0	0	0	0	1
11/12/2021 04:00	0.0	0	0	0	0	1
11/12/2021 05:00	0.0	0	0	0	0	1
11/12/2021 06:00	0.0	0	0	0	0	1
11/12/2021 07:00	0.0	0	0	0	0	1
11/12/2021 08:00	0.5	0	0	0	1	0
11/12/2021 09:00	0.0	0	0	0	0	0
11/12/2021 10:00	0.0	0	0	0	0	0
11/12/2021 11:00	0.0	0	0	0	0	0
11/12/2021 12:00	0.0	0	0	0	0	0
11/12/2021 13:00	0.0	0	0	0	0	0
11/12/2021 14:00	0.0	0	0	0	0	0
11/12/2021 15:00	10.3	0	0	1	0	0
11/12/2021 16:00	21.3	0	0	1	0	0
11/12/2021 17:00	0.0	0	0	0	0	1
11/12/2021 18:00	0.0	0	0	0	0	1
11/12/2021 19:00	0.0	0	0	0	0	1
11/12/2021 20:00	0.0	0	0	0	0	1
11/12/2021 21:00	0.0	0	0	0	0	1
11/12/2021 22:00	0.0	0	0	0	0	1
11/12/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	32.1 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	21.3	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/13/2021 00:00	0.9	0	0	0	1	0
11/13/2021 01:00	0.0	0	0	0	0	0
11/13/2021 02:00	0.0	0	0	0	0	0
11/13/2021 03:00	0.0	0	0	0	0	0
11/13/2021 04:00	0.0	0	0	0	0	0
11/13/2021 05:00	0.0	0	0	0	0	0
11/13/2021 06:00	0.0	0	0	0	0	0
11/13/2021 07:00	0.0	0	0	0	0	0
11/13/2021 08:00	0.0	0	0	0	0	0
11/13/2021 09:00	0.0	0	0	0	0	0
11/13/2021 10:00	0.0	0	0	0	0	0
11/13/2021 11:00	0.0	0	0	0	0	0
11/13/2021 12:00	0.0	0	0	0	0	0
11/13/2021 13:00	31.9	0	1	0	0	0
11/13/2021 14:00	12.1	0	1	0	0	0
11/13/2021 15:00	0.0	0	0	0	0	1
11/13/2021 16:00	0.0	0	0	0	0	1
11/13/2021 17:00	0.0	0	0	0	0	1
11/13/2021 18:00	0.0	0	0	0	0	1
11/13/2021 19:00	0.0	0	0	0	0	1
11/13/2021 20:00	0.0	0	0	0	0	1
11/13/2021 21:00	0.0	0	0	0	0	1
11/13/2021 22:00	0.9	0	0	0	1	0
11/13/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	45.8 #	0 #	2 #	0 #	2 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	31.9	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/14/2021 00:00	0.0	0	0	0	0	0
11/14/2021 01:00	0.0	0	0	0	0	0
11/14/2021 02:00	0.0	0	0	0	0	0
11/14/2021 03:00	0.0	0	0	0	0	0
11/14/2021 04:00	0.0	0	0	0	0	0
11/14/2021 05:00	0.0	0	0	0	0	0
11/14/2021 06:00	0.0	0	0	0	0	0
11/14/2021 07:00	0.0	0	0	0	0	0
11/14/2021 08:00	0.0	0	0	0	0	0
11/14/2021 09:00	0.0	0	0	0	0	0
11/14/2021 10:00	0.0	0	0	0	0	0
11/14/2021 11:00	0.0	0	0	0	0	0
11/14/2021 12:00	0.0	0	0	0	0	0
11/14/2021 13:00	0.0	0	0	0	0	0
11/14/2021 14:00	5.3	0	1	0	0	0
11/14/2021 15:00	62.8	0	1	0	0	0
11/14/2021 16:00	0.0	0	0	0	0	1
11/14/2021 17:00	0.0	0	0	0	0	1
11/14/2021 18:00	0.0	0	0	0	0	1
11/14/2021 19:00	0.0	0	0	0	0	1
11/14/2021 20:00	0.0	0	0	0	0	1
11/14/2021 21:00	0.0	0	0	0	0	1
11/14/2021 22:00	0.0	0	0	0	0	1
11/14/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	68.1 #	0 #	2 #	0 #	0 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	62.8	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/15/2021 00:00	0.4	0	0	0	1	0
11/15/2021 01:00	0.0	0	0	0	0	0
11/15/2021 02:00	0.0	0	0	0	0	0
11/15/2021 03:00	0.0	0	0	0	0	0
11/15/2021 04:00	0.0	0	0	0	0	0
11/15/2021 05:00	0.0	0	0	0	0	0
11/15/2021 06:00	0.0	0	0	0	0	0
11/15/2021 07:00	13.8	0	0	1	0	0
11/15/2021 08:00	29.9	0	0	1	0	0
11/15/2021 09:00	0.0	0	0	0	0	1
11/15/2021 10:00	0.0	0	0	0	0	1
11/15/2021 11:00	0.0	0	0	0	0	1
11/15/2021 12:00	0.0	0	0	0	0	1
11/15/2021 13:00	0.0	0	0	0	0	1
11/15/2021 14:00	0.0	0	0	0	0	1
11/15/2021 15:00	0.0	0	0	0	0	1
11/15/2021 16:00	0.0	0	0	0	0	1
11/15/2021 17:00	0.0	0	0	0	0	1
11/15/2021 18:00	0.0	0	0	0	0	1
11/15/2021 19:00	0.0	0	0	0	0	1
11/15/2021 20:00	0.0	0	0	0	0	1
11/15/2021 21:00	0.0	0	0	0	0	1
11/15/2021 22:00	0.0	0	0	0	0	1
11/15/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	44.1 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	29.9	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/16/2021 00:00	1.0	0	0	0	1	0
11/16/2021 01:00	0.0	0	0	0	0	0
11/16/2021 02:00	0.0	0	0	0	0	0
11/16/2021 03:00	0.0	0	0	0	0	0
11/16/2021 04:00	0.0	0	0	0	0	0
11/16/2021 05:00	0.0	0	0	0	0	0
11/16/2021 06:00	0.0	0	0	0	0	0
11/16/2021 07:00	0.0	0	0	0	0	0
11/16/2021 08:00	0.0	0	0	0	0	0
11/16/2021 09:00	0.0	0	0	0	0	0
11/16/2021 10:00	0.0	0	0	0	0	0
11/16/2021 11:00	0.0	0	0	0	0	0
11/16/2021 12:00	0.0	0	0	0	0	0
11/16/2021 13:00	3.5	0	1	0	0	0
11/16/2021 14:00	65.5	0	1	0	0	0
11/16/2021 15:00	7.3	0	1	0	0	0
11/16/2021 16:00	0.0	0	0	0	0	1
11/16/2021 17:00	0.0	0	0	0	0	1
11/16/2021 18:00	0.0	0	0	0	0	1
11/16/2021 19:00	0.0	0	0	0	0	1
11/16/2021 20:00	0.0	0	0	0	0	1
11/16/2021 21:00	0.0	0	0	0	0	1
11/16/2021 22:00	0.0	0	0	0	0	1
11/16/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	77.3 #	0 #	3 #	0 #	1 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	65.5	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/17/2021 00:00	0.0	0	0	0	0	1
11/17/2021 01:00	0.0	0	0	0	0	1
11/17/2021 02:00	0.0	0	0	0	0	1
11/17/2021 03:00	0.0	0	0	0	0	1
11/17/2021 04:00	0.0	0	0	0	0	1
11/17/2021 05:00	0.0	0	0	0	0	1
11/17/2021 06:00	0.0	0	0	0	0	1
11/17/2021 07:00	0.0	0	0	0	0	1
11/17/2021 08:00	0.0	0	0	0	0	1
11/17/2021 09:00	0.0	0	0	0	0	1
11/17/2021 10:00	0.0	0	0	0	0	1
11/17/2021 11:00	0.0	0	0	0	0	1
11/17/2021 12:00	0.0	0	0	0	0	1
11/17/2021 13:00	0.0	0	0	0	0	1
11/17/2021 14:00	0.0	0	0	0	0	1
11/17/2021 15:00	0.0	0	0	0	0	1
11/17/2021 16:00	0.0	0	0	0	0	1
11/17/2021 17:00	0.0	0	0	0	0	1
11/17/2021 18:00	0.0	0	0	0	0	1
11/17/2021 19:00	0.0	0	0	0	0	1
11/17/2021 20:00	0.0	0	0	0	0	1
11/17/2021 21:00	0.0	0	0	0	0	1
11/17/2021 22:00	0.0	0	0	0	0	1
11/17/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/18/2021 00:00	0.0	0	0	0	0	1
11/18/2021 01:00	0.0	0	0	0	0	1
11/18/2021 02:00	0.0	0	0	0	0	1
11/18/2021 03:00	0.0	0	0	0	0	1
11/18/2021 04:00	0.0	0	0	0	0	1
11/18/2021 05:00	0.0	0	0	0	0	1
11/18/2021 06:00	0.0	0	0	0	0	1
11/18/2021 07:00	0.0	0	0	0	0	1
11/18/2021 08:00	0.0	0	0	0	0	1
11/18/2021 09:00	0.0	0	0	0	0	1
11/18/2021 10:00	0.0	0	0	0	0	1
11/18/2021 11:00	0.0	0	0	0	0	1
11/18/2021 12:00	0.0	0	0	0	0	1
11/18/2021 13:00	0.0	0	0	0	0	1
11/18/2021 14:00	0.0	0	0	0	0	1
11/18/2021 15:00	0.0	0	0	0	0	1
11/18/2021 16:00	0.0	0	0	0	0	1
11/18/2021 17:00	0.0	0	0	0	0	1
11/18/2021 18:00	0.0	0	0	0	0	1
11/18/2021 19:00	0.0	0	0	0	0	1
11/18/2021 20:00	0.0	0	0	0	0	1
11/18/2021 21:00	0.0	0	0	0	0	1
11/18/2021 22:00	0.0	0	0	0	0	1
11/18/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/19/2021 00:00	0.0	0	0	0	0	1
11/19/2021 01:00	0.0	0	0	0	0	1
11/19/2021 02:00	0.0	0	0	0	0	1
11/19/2021 03:00	0.0	0	0	0	0	1
11/19/2021 04:00	0.0	0	0	0	0	1
11/19/2021 05:00	0.0	0	0	0	0	1
11/19/2021 06:00	0.0	0	0	0	0	1
11/19/2021 07:00	0.0	0	0	0	0	1
11/19/2021 08:00	0.0	0	0	0	0	1
11/19/2021 09:00	0.0	0	0	0	0	1
11/19/2021 10:00	0.0	0	0	0	0	1
11/19/2021 11:00	0.0	0	0	0	0	1
11/19/2021 12:00	0.0	0	0	0	0	1
11/19/2021 13:00	0.0	0	0	0	0	1
11/19/2021 14:00	0.0	0	0	0	0	1
11/19/2021 15:00	0.0	0	0	0	0	1
11/19/2021 16:00	0.0	0	0	0	0	1
11/19/2021 17:00	0.0	0	0	0	0	1
11/19/2021 18:00	0.0	0	0	0	0	1
11/19/2021 19:00	0.0	0	0	0	0	1
11/19/2021 20:00	0.0	0	0	0	0	1
11/19/2021 21:00	0.0	0	0	0	0	1
11/19/2021 22:00	0.0	0	0	0	0	1
11/19/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/20/2021 00:00	0.0	0	0	0	0	1
11/20/2021 01:00	0.0	0	0	0	0	1
11/20/2021 02:00	0.0	0	0	0	0	1
11/20/2021 03:00	0.0	0	0	0	0	1
11/20/2021 04:00	0.0	0	0	0	0	1
11/20/2021 05:00	0.0	0	0	0	0	1
11/20/2021 06:00	0.0	0	0	0	0	1
11/20/2021 07:00	0.0	0	0	0	0	1
11/20/2021 08:00	0.0	0	0	0	0	1
11/20/2021 09:00	0.0	0	0	0	0	1
11/20/2021 10:00	0.0	0	0	0	0	1
11/20/2021 11:00	0.0	0	0	0	0	1
11/20/2021 12:00	0.0	0	0	0	0	1
11/20/2021 13:00	0.0	0	0	0	0	1
11/20/2021 14:00	0.0	0	0	0	0	1
11/20/2021 15:00	0.0	0	0	0	0	1
11/20/2021 16:00	0.0	0	0	0	0	1
11/20/2021 17:00	0.0	0	0	0	0	1
11/20/2021 18:00	0.0	0	0	0	0	1
11/20/2021 19:00	0.0	0	0	0	0	1
11/20/2021 20:00	0.0	0	0	0	0	1
11/20/2021 21:00	0.0	0	0	0	0	1
11/20/2021 22:00	0.0	0	0	0	0	1
11/20/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/21/2021 00:00	0.0	0	0	0	0	1
11/21/2021 01:00	0.0	0	0	0	0	1
11/21/2021 02:00	0.6	0	0	0	1	0
11/21/2021 03:00	0.0	0	0	0	0	0
11/21/2021 04:00	0.0	0	0	0	0	0
11/21/2021 05:00	0.0	0	0	0	0	0
11/21/2021 06:00	0.0	0	0	0	0	0
11/21/2021 07:00	0.0	0	0	0	0	0
11/21/2021 08:00	0.0	0	0	0	0	0
11/21/2021 09:00	0.0	0	0	0	0	0
11/21/2021 10:00	0.0	0	0	0	0	0
11/21/2021 11:00	0.0	0	0	0	0	0
11/21/2021 12:00	0.0	0	0	0	0	0
11/21/2021 13:00	0.0	0	0	0	0	0
11/21/2021 14:00	27.9	0	1	0	0	0
11/21/2021 15:00	40.2	0	1	0	0	0
11/21/2021 16:00	0.0	0	0	0	0	1
11/21/2021 17:00	0.0	0	0	0	0	1
11/21/2021 18:00	0.0	0	0	0	0	1
11/21/2021 19:00	0.0	0	0	0	0	1
11/21/2021 20:00	0.0	0	0	0	0	1
11/21/2021 21:00	0.0	0	0	0	0	1
11/21/2021 22:00	0.0	0	0	0	0	1
11/21/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	68.7 #	0 #	2 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	40.2	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/22/2021 00:00	0.7	0	0	0	1	0
11/22/2021 01:00	0.0	0	0	0	0	0
11/22/2021 02:00	0.0	0	0	0	0	0
11/22/2021 03:00	0.0	0	0	0	0	0
11/22/2021 04:00	0.0	0	0	0	0	0
11/22/2021 05:00	0.0	0	0	0	0	0
11/22/2021 06:00	0.0	0	0	0	0	0
11/22/2021 07:00	0.0	0	0	0	0	0
11/22/2021 08:00	0.0	0	0	0	0	0
11/22/2021 09:00	0.0	0	0	0	0	0
11/22/2021 10:00	0.0	0	0	0	0	0
11/22/2021 11:00	0.0	0	0	0	0	0
11/22/2021 12:00	36.6	0	1	0	0	0
11/22/2021 13:00	20.7	0	1	0	0	0
11/22/2021 14:00	0.0	0	0	0	0	1
11/22/2021 15:00	0.0	0	0	0	0	1
11/22/2021 16:00	0.0	0	0	0	0	1
11/22/2021 17:00	0.0	0	0	0	0	1
11/22/2021 18:00	0.0	0	0	0	0	1
11/22/2021 19:00	0.0	0	0	0	0	1
11/22/2021 20:00	0.0	0	0	0	0	1
11/22/2021 21:00	0.0	0	0	0	0	1
11/22/2021 22:00	0.0	0	0	0	0	1
11/22/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	58.0 #	0 #	2 #	0 #	1 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	36.6	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/23/2021 00:00	0.0	0	0	0	0	1
11/23/2021 01:00	0.0	0	0	0	0	1
11/23/2021 02:00	0.0	0	0	0	0	1
11/23/2021 03:00	0.0	0	0	0	0	1
11/23/2021 04:00	0.0	0	0	0	0	1
11/23/2021 05:00	0.0	0	0	0	0	1
11/23/2021 06:00	0.0	0	0	0	0	1
11/23/2021 07:00	0.0	0	0	0	0	1
11/23/2021 08:00	0.0	0	0	0	0	1
11/23/2021 09:00	0.0	0	0	0	0	1
11/23/2021 10:00	0.0	0	0	0	0	1
11/23/2021 11:00	0.0	0	0	0	0	1
11/23/2021 12:00	0.0	0	0	0	0	1
11/23/2021 13:00	0.0	0	0	0	0	1
11/23/2021 14:00	0.0	0	0	0	0	1
11/23/2021 15:00	0.0	0	0	0	0	1
11/23/2021 16:00	0.0	0	0	0	0	1
11/23/2021 17:00	0.0	0	0	0	0	1
11/23/2021 18:00	0.0	0	0	0	0	1
11/23/2021 19:00	0.0	0	0	0	0	1
11/23/2021 20:00	0.0	0	0	0	0	1
11/23/2021 21:00	0.0	0	0	0	0	1
11/23/2021 22:00	0.0	0	0	0	0	1
11/23/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/24/2021 00:00	0.0	0	0	0	0	1
11/24/2021 01:00	0.0	0	0	0	0	1
11/24/2021 02:00	0.0	0	0	0	0	1
11/24/2021 03:00	0.0	0	0	0	0	1
11/24/2021 04:00	0.0	0	0	0	0	1
11/24/2021 05:00	0.0	0	0	0	0	1
11/24/2021 06:00	0.0	0	0	0	0	1
11/24/2021 07:00	0.0	0	0	0	0	1
11/24/2021 08:00	0.0	0	0	0	0	1
11/24/2021 09:00	0.0	0	0	0	0	1
11/24/2021 10:00	0.0	0	0	0	0	1
11/24/2021 11:00	0.0	0	0	0	0	1
11/24/2021 12:00	0.0	0	0	0	0	1
11/24/2021 13:00	0.0	0	0	0	0	1
11/24/2021 14:00	0.0	0	0	0	0	1
11/24/2021 15:00	0.0	0	0	0	0	1
11/24/2021 16:00	0.0	0	0	0	0	1
11/24/2021 17:00	0.0	0	0	0	0	1
11/24/2021 18:00	0.0	0	0	0	0	1
11/24/2021 19:00	0.0	0	0	0	0	1
11/24/2021 20:00	0.0	0	0	0	0	1
11/24/2021 21:00	0.0	0	0	0	0	1
11/24/2021 22:00	0.0	0	0	0	0	1
11/24/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/25/2021 00:00	1.4	0	0	0	1	0
11/25/2021 01:00	0.0	0	0	0	0	0
11/25/2021 02:00	0.0	0	0	0	0	0
11/25/2021 03:00	0.0	0	0	0	0	0
11/25/2021 04:00	0.0	0	0	0	0	0
11/25/2021 05:00	0.0	0	0	0	0	0
11/25/2021 06:00	0.0	0	0	0	0	0
11/25/2021 07:00	0.0	0	0	0	0	0
11/25/2021 08:00	0.0	0	0	0	0	0
11/25/2021 09:00	0.0	0	0	0	0	0
11/25/2021 10:00	0.0	0	0	0	0	0
11/25/2021 11:00	0.0	0	0	0	0	0
11/25/2021 12:00	0.0	0	0	0	0	0
11/25/2021 13:00	0.0	0	0	0	0	0
11/25/2021 14:00	0.0	0	0	0	0	0
11/25/2021 15:00	0.0	0	0	0	0	0
11/25/2021 16:00	0.0	0	0	0	0	0
11/25/2021 17:00	0.0	0	0	0	0	0
11/25/2021 18:00	0.0	0	0	0	0	0
11/25/2021 19:00	0.0	0	0	0	0	0
11/25/2021 20:00	0.0	0	0	0	0	0
11/25/2021 21:00	0.0	0	0	0	0	0
11/25/2021 22:00	0.0	0	0	0	0	0
11/25/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.4 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.4	0	0	0	1	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/26/2021 00:00	0.0	0	0	0	0	0
11/26/2021 01:00	0.0	0	0	0	0	0
11/26/2021 02:00	0.0	0	0	0	0	0
11/26/2021 03:00	0.0	0	0	0	0	0
11/26/2021 04:00	0.0	0	0	0	0	0
11/26/2021 05:00	0.0	0	0	0	0	0
11/26/2021 06:00	0.0	0	0	0	0	0
11/26/2021 07:00	0.0	0	0	0	0	0
11/26/2021 08:00	0.0	0	0	0	0	0
11/26/2021 09:00	0.0	0	0	0	0	0
11/26/2021 10:00	0.0	0	0	0	0	0
11/26/2021 11:00	0.0	0	0	0	0	0
11/26/2021 12:00	0.0	0	0	0	0	0
11/26/2021 13:00	0.0	0	0	0	0	0
11/26/2021 14:00	0.0	0	0	0	0	0
11/26/2021 15:00	0.0	0	0	0	0	0
11/26/2021 16:00	0.0	0	0	0	0	0
11/26/2021 17:00	0.0	0	0	0	0	0
11/26/2021 18:00	0.0	0	0	0	0	0
11/26/2021 19:00	0.0	0	0	0	0	0
11/26/2021 20:00	0.0	0	0	0	0	0
11/26/2021 21:00	0.0	0	0	0	0	0
11/26/2021 22:00	0.0	0	0	0	0	0
11/26/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/27/2021 00:00	0.0	0	0	0	0	0
11/27/2021 01:00	0.0	0	0	0	0	0
11/27/2021 02:00	0.0	0	0	0	0	0
11/27/2021 03:00	0.0	0	0	0	0	0
11/27/2021 04:00	0.0	0	0	0	0	0
11/27/2021 05:00	0.0	0	0	0	0	0
11/27/2021 06:00	0.0	0	0	0	0	0
11/27/2021 07:00	0.0	0	0	0	0	0
11/27/2021 08:00	0.0	0	0	0	0	0
11/27/2021 09:00	0.0	0	0	0	0	0
11/27/2021 10:00	0.0	0	0	0	0	0
11/27/2021 11:00	0.0	0	0	0	0	0
11/27/2021 12:00	0.0	0	0	0	0	0
11/27/2021 13:00	0.0	0	0	0	0	0
11/27/2021 14:00	0.0	0	0	0	0	0
11/27/2021 15:00	0.0	0	0	0	0	0
11/27/2021 16:00	0.0	0	0	0	0	0
11/27/2021 17:00	0.0	0	0	0	0	0
11/27/2021 18:00	0.0	0	0	0	0	0
11/27/2021 19:00	0.0	0	0	0	0	0
11/27/2021 20:00	0.0	0	0	0	0	0
11/27/2021 21:00	0.0	0	0	0	0	0
11/27/2021 22:00	0.0	0	0	0	0	0
11/27/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/28/2021 00:00	0.0	0	0	0	0	0
11/28/2021 01:00	0.0	0	0	0	0	0
11/28/2021 02:00	0.0	0	0	0	0	0
11/28/2021 03:00	0.0	0	0	0	0	0
11/28/2021 04:00	0.0	0	0	0	0	0
11/28/2021 05:00	0.0	0	0	0	0	0
11/28/2021 06:00	0.0	0	0	0	0	0
11/28/2021 07:00	0.0	0	0	0	0	0
11/28/2021 08:00	0.0	0	0	0	0	0
11/28/2021 09:00	0.0	0	0	0	0	0
11/28/2021 10:00	0.0	0	0	0	0	0
11/28/2021 11:00	0.0	0	0	0	0	0
11/28/2021 12:00	0.0	0	0	0	0	0
11/28/2021 13:00	0.0	0	0	0	0	0
11/28/2021 14:00	0.0	0	0	0	0	0
11/28/2021 15:00	0.0	0	0	0	0	0
11/28/2021 16:00	0.0	0	0	0	0	0
11/28/2021 17:00	0.0	0	0	0	0	0
11/28/2021 18:00	0.0	0	0	0	0	0
11/28/2021 19:00	0.0	0	0	0	0	0
11/28/2021 20:00	0.0	0	0	0	0	0
11/28/2021 21:00	0.0	0	0	0	0	0
11/28/2021 22:00	0.0	0	0	0	0	0
11/28/2021 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/29/2021 00:00	0.0	0	0	0	0	0
11/29/2021 01:00	0.0	0	0	0	0	0
11/29/2021 02:00	0.0	0	0	0	0	0
11/29/2021 03:00	0.0	0	0	0	0	0
11/29/2021 04:00	0.0	0	0	0	0	0
11/29/2021 05:00	0.0	0	0	0	0	0
11/29/2021 06:00	0.0	0	0	0	0	0
11/29/2021 07:00	0.0	0	0	0	0	0
11/29/2021 08:00	0.0	0	0	0	0	0
11/29/2021 09:00	0.0	0	0	0	0	0
11/29/2021 10:00	0.0	0	0	0	0	0
11/29/2021 11:00	0.0	0	0	0	0	0
11/29/2021 12:00	0.0	0	0	0	0	0
11/29/2021 13:00	0.0	0	0	0	0	0
11/29/2021 14:00	42.5	1	0	0	0	0
11/29/2021 15:00	35.4	1	0	0	0	0
11/29/2021 16:00	0.0	0	0	0	0	1
11/29/2021 17:00	0.0	0	0	0	0	1
11/29/2021 18:00	0.0	0	0	0	0	1
11/29/2021 19:00	0.0	0	0	0	0	1
11/29/2021 20:00	0.0	0	0	0	0	1
11/29/2021 21:00	0.0	0	0	0	0	1
11/29/2021 22:00	0.0	0	0	0	0	1
11/29/2021 23:00	0.9	0	0	0	1	0
Average/Sum#:	78.8 #	2 #	0 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	42.5	1	0	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
11/30/2021 00:00	0.0	0	0	0	0	0
11/30/2021 01:00	0.0	0	0	0	0	0
11/30/2021 02:00	0.0	0	0	0	0	0
11/30/2021 03:00	0.0	0	0	0	0	0
11/30/2021 04:00	0.0	0	0	0	0	0
11/30/2021 05:00	0.0	0	0	0	0	0
11/30/2021 06:00	0.0	0	0	0	0	0
11/30/2021 07:00	0.0	0	0	0	0	0
11/30/2021 08:00	18.5	0	1	0	0	0
11/30/2021 09:00	27.7	0	1	0	0	0
11/30/2021 10:00	0.0	0	0	0	0	1
11/30/2021 11:00	0.0	0	0	0	0	1
11/30/2021 12:00	0.0	0	0	0	0	1
11/30/2021 13:00	0.0	0	0	0	0	1
11/30/2021 14:00	0.0	0	0	0	0	1
11/30/2021 15:00	0.0	0	0	0	0	1
11/30/2021 16:00	0.0	0	0	0	0	1
11/30/2021 17:00	0.0	0	0	0	0	1
11/30/2021 18:00	0.0	0	0	0	0	1
11/30/2021 19:00	0.0	0	0	0	0	1
11/30/2021 20:00	0.0	0	0	0	0	1
11/30/2021 21:00	0.0	0	0	0	0	1
11/30/2021 22:00	0.0	0	0	0	0	1
11/30/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	46.2 #	0 #	2 #	0 #	0 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	27.7	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/01/2021 00:00	0.0	0	0	0	0	1
12/01/2021 01:00	0.0	0	0	0	0	1
12/01/2021 02:00	0.0	0	0	0	0	1
12/01/2021 03:00	0.0	0	0	0	0	1
12/01/2021 04:00	0.0	0	0	0	0	1
12/01/2021 05:00	0.0	0	0	0	0	1
12/01/2021 06:00	0.0	0	0	0	0	1
12/01/2021 07:00	0.0	0	0	0	0	1
12/01/2021 08:00	0.0	0	0	0	0	1
12/01/2021 09:00	0.0	0	0	0	0	1
12/01/2021 10:00	0.0	0	0	0	0	1
12/01/2021 11:00	0.0	0	0	0	0	1
12/01/2021 12:00	0.0	0	0	0	0	1
12/01/2021 13:00	0.0	0	0	0	0	1
12/01/2021 14:00	0.0	0	0	0	0	1
12/01/2021 15:00	0.0	0	0	0	0	1
12/01/2021 16:00	0.0	0	0	0	0	1
12/01/2021 17:00	0.0	0	0	0	0	1
12/01/2021 18:00	0.0	0	0	0	0	1
12/01/2021 19:00	0.0	0	0	0	0	1
12/01/2021 20:00	0.0	0	0	0	0	1
12/01/2021 21:00	0.0	0	0	0	0	1
12/01/2021 22:00	0.0	0	0	0	0	1
12/01/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/02/2021 00:00	1.0	0	0	0	1	0
12/02/2021 01:00	0.0	0	0	0	0	0
12/02/2021 02:00	0.0	0	0	0	0	0
12/02/2021 03:00	0.0	0	0	0	0	0
12/02/2021 04:00	19.7	0	0	1	0	0
12/02/2021 05:00	0.0	0	0	0	0	1
12/02/2021 06:00	0.0	0	0	0	0	1
12/02/2021 07:00	0.0	0	0	0	0	1
12/02/2021 08:00	0.0	0	0	0	0	1
12/02/2021 09:00	0.0	0	0	0	0	1
12/02/2021 10:00	0.0	0	0	0	0	1
12/02/2021 11:00	0.0	0	0	0	0	1
12/02/2021 12:00	0.0	0	0	0	0	1
12/02/2021 13:00	0.0	0	0	0	0	1
12/02/2021 14:00	0.0	0	0	0	0	1
12/02/2021 15:00	0.0	0	0	0	0	1
12/02/2021 16:00	0.0	0	0	0	0	1
12/02/2021 17:00	0.0	0	0	0	0	1
12/02/2021 18:00	0.0	0	0	0	0	1
12/02/2021 19:00	0.0	0	0	0	0	1
12/02/2021 20:00	0.0	0	0	0	0	1
12/02/2021 21:00	0.0	0	0	0	0	1
12/02/2021 22:00	0.0	0	0	0	0	1
12/02/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	20.7 #	0 #	0 #	1 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	19.7	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/03/2021 00:00	0.6	0	0	0	1	0
12/03/2021 01:00	0.0	0	0	0	0	0
12/03/2021 02:00	0.0	0	0	0	0	0
12/03/2021 03:00	0.2	0	0	1	0	0
12/03/2021 04:00	20.6	0	0	1	0	0
12/03/2021 05:00	0.0	0	0	0	0	1
12/03/2021 06:00	0.0	0	0	0	0	1
12/03/2021 07:00	0.0	0	0	0	0	1
12/03/2021 08:00	0.0	0	0	0	0	1
12/03/2021 09:00	0.0	0	0	0	0	1
12/03/2021 10:00	0.0	0	0	0	0	1
12/03/2021 11:00	0.0	0	0	0	0	1
12/03/2021 12:00	0.0	0	0	0	0	1
12/03/2021 13:00	0.0	0	0	0	0	1
12/03/2021 14:00	0.0	0	0	0	0	1
12/03/2021 15:00	0.0	0	0	0	0	1
12/03/2021 16:00	0.0	0	0	0	0	1
12/03/2021 17:00	0.0	0	0	0	0	1
12/03/2021 18:00	0.0	0	0	0	0	1
12/03/2021 19:00	0.0	0	0	0	0	1
12/03/2021 20:00	0.0	0	0	0	0	1
12/03/2021 21:00	0.0	0	0	0	0	1
12/03/2021 22:00	0.0	0	0	0	0	1
12/03/2021 23:00	0.9	0	0	0	1	0
Average/Sum#:	22.3 #	0 #	0 #	2 #	2 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	20.6	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/04/2021 00:00	0.0	0	0	0	0	0
12/04/2021 01:00	0.0	0	0	0	0	0
12/04/2021 02:00	0.0	0	0	0	0	0
12/04/2021 03:00	0.0	0	0	0	0	0
12/04/2021 04:00	0.0	0	0	0	0	0
12/04/2021 05:00	0.4	0	0	1	0	0
12/04/2021 06:00	0.7	0	0	1	1	0
12/04/2021 07:00	8.6	0	0	1	0	0
12/04/2021 08:00	0.0	0	0	0	0	1
12/04/2021 09:00	0.0	0	0	0	0	1
12/04/2021 10:00	0.0	0	0	0	0	1
12/04/2021 11:00	0.0	0	0	0	0	1
12/04/2021 12:00	0.6	0	0	0	1	0
12/04/2021 13:00	0.0	0	0	0	0	0
12/04/2021 14:00	0.0	0	0	0	0	0
12/04/2021 15:00	0.1	0	0	1	0	0
12/04/2021 16:00	14.9	0	0	1	0	0
12/04/2021 17:00	0.0	0	0	0	0	1
12/04/2021 18:00	0.0	0	0	0	0	1
12/04/2021 19:00	0.0	0	0	0	0	1
12/04/2021 20:00	0.0	0	0	0	0	1
12/04/2021 21:00	0.0	0	0	0	0	1
12/04/2021 22:00	0.0	0	0	0	0	1
12/04/2021 23:00	0.7	0	0	0	1	0
Average/Sum#:	26.0 #	0 #	0 #	5 #	3 #	10 #
Minimum:	0.0	0	0	0	0	0
Maximum:	14.9	0	0	1	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/05/2021 00:00	0.0	0	0	0	0	0
12/05/2021 01:00	0.0	0	0	0	0	0
12/05/2021 02:00	0.0	0	0	0	0	0
12/05/2021 03:00	0.0	0	0	0	0	0
12/05/2021 04:00	0.0	0	0	0	0	0
12/05/2021 05:00	0.0	0	0	0	0	0
12/05/2021 06:00	0.0	0	0	0	0	0
12/05/2021 07:00	0.0	0	0	0	0	0
12/05/2021 08:00	0.0	0	0	0	0	0
12/05/2021 09:00	0.0	0	0	0	0	0
12/05/2021 10:00	0.0	0	0	0	0	0
12/05/2021 11:00	0.0	0	0	0	0	0
12/05/2021 12:00	0.0	0	0	0	0	0
12/05/2021 13:00	19.6	0	1	0	0	0
12/05/2021 14:00	33.7	0	1	0	0	0
12/05/2021 15:00	0.0	0	0	0	0	1
12/05/2021 16:00	0.0	0	0	0	0	1
12/05/2021 17:00	0.0	0	0	0	0	1
12/05/2021 18:00	0.0	0	0	0	0	1
12/05/2021 19:00	0.0	0	0	0	0	1
12/05/2021 20:00	0.0	0	0	0	0	1
12/05/2021 21:00	0.0	0	0	0	0	1
12/05/2021 22:00	0.0	0	0	0	0	1
12/05/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	53.3 #	0 #	2 #	0 #	0 #	9 #
Minimum:	0.0	0	0	0	0	0
Maximum:	33.7	0	1	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/06/2021 00:00	0.0	0	0	0	0	1
12/06/2021 01:00	0.0	0	0	0	0	1
12/06/2021 02:00	0.0	0	0	0	0	1
12/06/2021 03:00	0.0	0	0	0	0	1
12/06/2021 04:00	0.0	0	0	0	0	1
12/06/2021 05:00	0.0	0	0	0	0	1
12/06/2021 06:00	0.0	0	0	0	0	1
12/06/2021 07:00	0.0	0	0	0	0	1
12/06/2021 08:00	0.0	0	0	0	0	1
12/06/2021 09:00	0.0	0	0	0	0	1
12/06/2021 10:00	0.0	0	0	0	0	1
12/06/2021 11:00	0.0	0	0	0	0	1
12/06/2021 12:00	0.0	0	0	0	0	1
12/06/2021 13:00	0.0	0	0	0	0	1
12/06/2021 14:00	0.0	0	0	0	0	1
12/06/2021 15:00	0.0	0	0	0	0	1
12/06/2021 16:00	0.0	0	0	0	0	1
12/06/2021 17:00	0.0	0	0	0	0	1
12/06/2021 18:00	0.0	0	0	0	0	1
12/06/2021 19:00	0.0	0	0	0	0	1
12/06/2021 20:00	0.0	0	0	0	0	1
12/06/2021 21:00	0.0	0	0	0	0	1
12/06/2021 22:00	0.0	0	0	0	0	1
12/06/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/07/2021 00:00	0.0	0	0	0	0	1
12/07/2021 01:00	0.0	0	0	0	0	1
12/07/2021 02:00	0.0	0	0	0	0	1
12/07/2021 03:00	0.0	0	0	0	0	1
12/07/2021 04:00	0.0	0	0	0	0	1
12/07/2021 05:00	0.0	0	0	0	0	1
12/07/2021 06:00	0.0	0	0	0	0	1
12/07/2021 07:00	0.0	0	0	0	0	1
12/07/2021 08:00	0.0	0	0	0	0	1
12/07/2021 09:00	0.0	0	0	0	0	1
12/07/2021 10:00	0.0	0	0	0	0	1
12/07/2021 11:00	0.0	0	0	0	0	1
12/07/2021 12:00	0.0	0	0	0	0	1
12/07/2021 13:00	0.0	0	0	0	0	1
12/07/2021 14:00	0.0	0	0	0	0	1
12/07/2021 15:00	0.0	0	0	0	0	1
12/07/2021 16:00	0.0	0	0	0	0	1
12/07/2021 17:00	0.0	0	0	0	0	1
12/07/2021 18:00	0.0	0	0	0	0	1
12/07/2021 19:00	0.0	0	0	0	0	1
12/07/2021 20:00	0.0	0	0	0	0	1
12/07/2021 21:00	0.0	0	0	0	0	1
12/07/2021 22:00	0.0	0	0	0	0	1
12/07/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/08/2021 00:00	0.0	0	0	0	0	1
12/08/2021 01:00	0.0	0	0	0	0	1
12/08/2021 02:00	0.0	0	0	0	0	1
12/08/2021 03:00	0.0	0	0	0	0	1
12/08/2021 04:00	0.0	0	0	0	0	1
12/08/2021 05:00	0.0	0	0	0	0	1
12/08/2021 06:00	0.0	0	0	0	0	1
12/08/2021 07:00	0.0	0	0	0	0	1
12/08/2021 08:00	0.0	0	0	0	0	1
12/08/2021 09:00	0.0	0	0	0	0	1
12/08/2021 10:00	0.0	0	0	0	0	1
12/08/2021 11:00	0.0	0	0	0	0	1
12/08/2021 12:00	0.0	0	0	0	0	1
12/08/2021 13:00	0.0	0	0	0	0	1
12/08/2021 14:00	0.0	0	0	0	0	1
12/08/2021 15:00	0.0	0	0	0	0	1
12/08/2021 16:00	0.0	0	0	0	0	1
12/08/2021 17:00	0.0	0	0	0	0	1
12/08/2021 18:00	0.0	0	0	0	0	1
12/08/2021 19:00	0.0	0	0	0	0	1
12/08/2021 20:00	0.0	0	0	0	0	1
12/08/2021 21:00	0.0	0	0	0	0	1
12/08/2021 22:00	0.0	0	0	0	0	1
12/08/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/09/2021 00:00	0.0	0	0	0	0	1
12/09/2021 01:00	0.0	0	0	0	0	1
12/09/2021 02:00	0.0	0	0	0	0	1
12/09/2021 03:00	0.0	0	0	0	0	1
12/09/2021 04:00	0.0	0	0	0	0	1
12/09/2021 05:00	0.0	0	0	0	0	1
12/09/2021 06:00	0.0	0	0	0	0	1
12/09/2021 07:00	0.0	0	0	0	0	1
12/09/2021 08:00	0.0	0	0	0	0	1
12/09/2021 09:00	0.0	0	0	0	0	1
12/09/2021 10:00	0.0	0	0	0	0	1
12/09/2021 11:00	0.0	0	0	0	0	1
12/09/2021 12:00	0.0	0	0	0	0	1
12/09/2021 13:00	0.0	0	0	0	0	1
12/09/2021 14:00	0.0	0	0	0	0	1
12/09/2021 15:00	0.0	0	0	0	0	1
12/09/2021 16:00	0.0	0	0	0	0	1
12/09/2021 17:00	0.0	0	0	0	0	1
12/09/2021 18:00	0.0	0	0	0	0	1
12/09/2021 19:00	0.0	0	0	0	0	1
12/09/2021 20:00	0.0	0	0	0	0	1
12/09/2021 21:00	0.0	0	0	0	0	1
12/09/2021 22:00	0.0	0	0	0	0	1
12/09/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/10/2021 00:00	0.0	0	0	0	0	1
12/10/2021 01:00	0.0	0	0	0	0	1
12/10/2021 02:00	0.0	0	0	0	0	1
12/10/2021 03:00	0.0	0	0	0	0	1
12/10/2021 04:00	0.0	0	0	0	0	1
12/10/2021 05:00	0.0	0	0	0	0	1
12/10/2021 06:00	0.0	0	0	0	0	1
12/10/2021 07:00	0.0	0	0	0	0	1
12/10/2021 08:00	0.0	0	0	0	0	1
12/10/2021 09:00	0.0	0	0	0	0	1
12/10/2021 10:00	0.0	0	0	0	0	1
12/10/2021 11:00	0.0	0	0	0	0	1
12/10/2021 12:00	0.0	0	0	0	0	1
12/10/2021 13:00	0.0	0	0	0	0	1
12/10/2021 14:00	0.0	0	0	0	0	1
12/10/2021 15:00	0.0	0	0	0	0	1
12/10/2021 16:00	0.0	0	0	0	0	1
12/10/2021 17:00	0.0	0	0	0	0	1
12/10/2021 18:00	0.0	0	0	0	0	1
12/10/2021 19:00	0.0	0	0	0	0	1
12/10/2021 20:00	0.0	0	0	0	0	1
12/10/2021 21:00	0.0	0	0	0	0	1
12/10/2021 22:00	0.0	0	0	0	0	1
12/10/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/11/2021 00:00	0.0	0	0	0	0	1
12/11/2021 01:00	0.0	0	0	0	0	1
12/11/2021 02:00	0.0	0	0	0	0	1
12/11/2021 03:00	0.0	0	0	0	0	1
12/11/2021 04:00	0.0	0	0	0	0	1
12/11/2021 05:00	0.0	0	0	0	0	1
12/11/2021 06:00	0.0	0	0	0	0	1
12/11/2021 07:00	0.0	0	0	0	0	1
12/11/2021 08:00	0.0	0	0	0	0	1
12/11/2021 09:00	0.0	0	0	0	0	1
12/11/2021 10:00	0.0	0	0	0	0	1
12/11/2021 11:00	0.0	0	0	0	0	1
12/11/2021 12:00	0.0	0	0	0	0	1
12/11/2021 13:00	0.0	0	0	0	0	1
12/11/2021 14:00	0.0	0	0	0	0	1
12/11/2021 15:00	0.0	0	0	0	0	1
12/11/2021 16:00	0.0	0	0	0	0	1
12/11/2021 17:00	0.0	0	0	0	0	1
12/11/2021 18:00	0.0	0	0	0	0	1
12/11/2021 19:00	0.0	0	0	0	0	1
12/11/2021 20:00	0.0	0	0	0	0	1
12/11/2021 21:00	0.0	0	0	0	0	1
12/11/2021 22:00	0.0	0	0	0	0	1
12/11/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/12/2021 00:00	0.0	0	0	0	0	1
12/12/2021 01:00	0.0	0	0	0	0	1
12/12/2021 02:00	0.0	0	0	0	0	1
12/12/2021 03:00	0.0	0	0	0	0	1
12/12/2021 04:00	0.0	0	0	0	0	1
12/12/2021 05:00	0.0	0	0	0	0	1
12/12/2021 06:00	0.0	0	0	0	0	1
12/12/2021 07:00	0.0	0	0	0	0	1
12/12/2021 08:00	0.0	0	0	0	0	1
12/12/2021 09:00	0.0	0	0	0	0	1
12/12/2021 10:00	0.0	0	0	0	0	1
12/12/2021 11:00	0.0	0	0	0	0	1
12/12/2021 12:00	0.0	0	0	0	0	1
12/12/2021 13:00	0.0	0	0	0	0	1
12/12/2021 14:00	0.0	0	0	0	0	1
12/12/2021 15:00	0.0	0	0	0	0	1
12/12/2021 16:00	0.0	0	0	0	0	1
12/12/2021 17:00	0.0	0	0	0	0	1
12/12/2021 18:00	0.0	0	0	0	0	1
12/12/2021 19:00	0.0	0	0	0	0	1
12/12/2021 20:00	0.0	0	0	0	0	1
12/12/2021 21:00	0.0	0	0	0	0	1
12/12/2021 22:00	0.0	0	0	0	0	1
12/12/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/13/2021 00:00	0.0	0	0	0	0	1
12/13/2021 01:00	0.0	0	0	0	0	1
12/13/2021 02:00	0.0	0	0	0	0	1
12/13/2021 03:00	0.0	0	0	0	0	1
12/13/2021 04:00	0.0	0	0	0	0	1
12/13/2021 05:00	0.0	0	0	0	0	1
12/13/2021 06:00	0.0	0	0	0	0	1
12/13/2021 07:00	0.0	0	0	0	0	1
12/13/2021 08:00	0.0	0	0	0	0	1
12/13/2021 09:00	0.0	0	0	0	0	1
12/13/2021 10:00	0.0	0	0	0	0	1
12/13/2021 11:00	0.0	0	0	0	0	1
12/13/2021 12:00	0.0	0	0	0	0	1
12/13/2021 13:00	0.0	0	0	0	0	1
12/13/2021 14:00	0.0	0	0	0	0	1
12/13/2021 15:00	0.0	0	0	0	0	1
12/13/2021 16:00	0.0	0	0	0	0	1
12/13/2021 17:00	0.0	0	0	0	0	1
12/13/2021 18:00	0.0	0	0	0	0	1
12/13/2021 19:00	0.0	0	0	0	0	1
12/13/2021 20:00	0.0	0	0	0	0	1
12/13/2021 21:00	0.0	0	0	0	0	1
12/13/2021 22:00	0.0	0	0	0	0	1
12/13/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/14/2021 00:00	0.0	0	0	0	0	1
12/14/2021 01:00	0.0	0	0	0	0	1
12/14/2021 02:00	0.0	0	0	0	0	1
12/14/2021 03:00	0.0	0	0	0	0	1
12/14/2021 04:00	0.0	0	0	0	0	1
12/14/2021 05:00	0.0	0	0	0	0	1
12/14/2021 06:00	0.0	0	0	0	0	1
12/14/2021 07:00	0.0	0	0	0	0	1
12/14/2021 08:00	0.0	0	0	0	0	1
12/14/2021 09:00	0.0	0	0	0	0	1
12/14/2021 10:00	0.0	0	0	0	0	1
12/14/2021 11:00	0.0	0	0	0	0	1
12/14/2021 12:00	0.0	0	0	0	0	1
12/14/2021 13:00	0.0	0	0	0	0	1
12/14/2021 14:00	0.0	0	0	0	0	1
12/14/2021 15:00	0.0	0	0	0	0	1
12/14/2021 16:00	0.0	0	0	0	0	1
12/14/2021 17:00	0.0	0	0	0	0	1
12/14/2021 18:00	0.0	0	0	0	0	1
12/14/2021 19:00	0.0	0	0	0	0	1
12/14/2021 20:00	0.0	0	0	0	0	1
12/14/2021 21:00	0.0	0	0	0	0	1
12/14/2021 22:00	0.0	0	0	0	0	1
12/14/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/15/2021 00:00	0.0	0	0	0	0	1
12/15/2021 01:00	0.0	0	0	0	0	1
12/15/2021 02:00	0.0	0	0	0	0	1
12/15/2021 03:00	0.0	0	0	0	0	1
12/15/2021 04:00	0.0	0	0	0	0	1
12/15/2021 05:00	0.0	0	0	0	0	1
12/15/2021 06:00	0.0	0	0	0	0	1
12/15/2021 07:00	0.0	0	0	0	0	1
12/15/2021 08:00	0.0	0	0	0	0	1
12/15/2021 09:00	0.0	0	0	0	0	1
12/15/2021 10:00	0.0	0	0	0	0	1
12/15/2021 11:00	0.0	0	0	0	0	1
12/15/2021 12:00	0.0	0	0	0	0	1
12/15/2021 13:00	0.0	0	0	0	0	1
12/15/2021 14:00	0.0	0	0	0	0	1
12/15/2021 15:00	0.0	0	0	0	0	1
12/15/2021 16:00	0.0	0	0	0	0	1
12/15/2021 17:00	0.0	0	0	0	0	1
12/15/2021 18:00	0.0	0	0	0	0	1
12/15/2021 19:00	0.0	0	0	0	0	1
12/15/2021 20:00	0.0	0	0	0	0	1
12/15/2021 21:00	0.0	0	0	0	0	1
12/15/2021 22:00	0.0	0	0	0	0	1
12/15/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/16/2021 00:00	0.0	0	0	0	0	1
12/16/2021 01:00	0.0	0	0	0	0	1
12/16/2021 02:00	0.0	0	0	0	0	1
12/16/2021 03:00	0.0	0	0	0	0	1
12/16/2021 04:00	0.0	0	0	0	0	1
12/16/2021 05:00	0.0	0	0	0	0	1
12/16/2021 06:00	0.0	0	0	0	0	1
12/16/2021 07:00	0.0	0	0	0	0	1
12/16/2021 08:00	0.0	0	0	0	0	1
12/16/2021 09:00	0.0	0	0	0	0	1
12/16/2021 10:00	0.0	0	0	0	0	1
12/16/2021 11:00	0.0	0	0	0	0	1
12/16/2021 12:00	0.0	0	0	0	0	1
12/16/2021 13:00	0.0	0	0	0	0	1
12/16/2021 14:00	0.0	0	0	0	0	1
12/16/2021 15:00	0.0	0	0	0	0	1
12/16/2021 16:00	0.0	0	0	0	0	1
12/16/2021 17:00	0.0	0	0	0	0	1
12/16/2021 18:00	0.0	0	0	0	0	1
12/16/2021 19:00	0.0	0	0	0	0	1
12/16/2021 20:00	0.0	0	0	0	0	1
12/16/2021 21:00	0.0	0	0	0	0	1
12/16/2021 22:00	0.0	0	0	0	0	1
12/16/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/17/2021 00:00	0.0	0	0	0	0	1
12/17/2021 01:00	0.0	0	0	0	0	1
12/17/2021 02:00	0.0	0	0	0	0	1
12/17/2021 03:00	0.0	0	0	0	0	1
12/17/2021 04:00	0.0	0	0	0	0	1
12/17/2021 05:00	0.0	0	0	0	0	1
12/17/2021 06:00	0.0	0	0	0	0	1
12/17/2021 07:00	0.0	0	0	0	0	1
12/17/2021 08:00	0.0	0	0	0	0	1
12/17/2021 09:00	0.0	0	0	0	0	1
12/17/2021 10:00	0.0	0	0	0	0	1
12/17/2021 11:00	0.0	0	0	0	0	1
12/17/2021 12:00	0.0	0	0	0	0	1
12/17/2021 13:00	0.0	0	0	0	0	1
12/17/2021 14:00	0.0	0	0	0	0	1
12/17/2021 15:00	0.0	0	0	0	0	1
12/17/2021 16:00	0.0	0	0	0	0	1
12/17/2021 17:00	0.0	0	0	0	0	1
12/17/2021 18:00	0.0	0	0	0	0	1
12/17/2021 19:00	0.0	0	0	0	0	1
12/17/2021 20:00	0.0	0	0	0	0	1
12/17/2021 21:00	0.0	0	0	0	0	1
12/17/2021 22:00	0.0	0	0	0	0	1
12/17/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/18/2021 00:00	0.0	0	0	0	0	1
12/18/2021 01:00	0.0	0	0	0	0	1
12/18/2021 02:00	0.0	0	0	0	0	1
12/18/2021 03:00	0.0	0	0	0	0	1
12/18/2021 04:00	0.0	0	0	0	0	1
12/18/2021 05:00	0.0	0	0	0	0	1
12/18/2021 06:00	0.0	0	0	0	0	1
12/18/2021 07:00	0.0	0	0	0	0	1
12/18/2021 08:00	0.0	0	0	0	0	1
12/18/2021 09:00	0.0	0	0	0	0	1
12/18/2021 10:00	0.0	0	0	0	0	1
12/18/2021 11:00	0.0	0	0	0	0	1
12/18/2021 12:00	0.0	0	0	0	0	1
12/18/2021 13:00	0.0	0	0	0	0	1
12/18/2021 14:00	0.0	0	0	0	0	1
12/18/2021 15:00	0.0	0	0	0	0	1
12/18/2021 16:00	0.0	0	0	0	0	1
12/18/2021 17:00	0.0	0	0	0	0	1
12/18/2021 18:00	0.0	0	0	0	0	1
12/18/2021 19:00	0.0	0	0	0	0	1
12/18/2021 20:00	0.0	0	0	0	0	1
12/18/2021 21:00	0.0	0	0	0	0	1
12/18/2021 22:00	0.0	0	0	0	0	1
12/18/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/19/2021 00:00	0.0	0	0	0	0	1
12/19/2021 01:00	0.0	0	0	0	0	1
12/19/2021 02:00	0.0	0	0	0	0	1
12/19/2021 03:00	0.0	0	0	0	0	1
12/19/2021 04:00	0.0	0	0	0	0	1
12/19/2021 05:00	0.0	0	0	0	0	1
12/19/2021 06:00	0.0	0	0	0	0	1
12/19/2021 07:00	0.0	0	0	0	0	1
12/19/2021 08:00	0.0	0	0	0	0	1
12/19/2021 09:00	0.0	0	0	0	0	1
12/19/2021 10:00	0.0	0	0	0	0	1
12/19/2021 11:00	0.0	0	0	0	0	1
12/19/2021 12:00	0.0	0	0	0	0	1
12/19/2021 13:00	0.0	0	0	0	0	1
12/19/2021 14:00	0.0	0	0	0	0	1
12/19/2021 15:00	0.0	0	0	0	0	1
12/19/2021 16:00	0.0	0	0	0	0	1
12/19/2021 17:00	0.0	0	0	0	0	1
12/19/2021 18:00	0.0	0	0	0	0	1
12/19/2021 19:00	0.0	0	0	0	0	1
12/19/2021 20:00	0.0	0	0	0	0	1
12/19/2021 21:00	0.0	0	0	0	0	1
12/19/2021 22:00	0.0	0	0	0	0	1
12/19/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/20/2021 00:00	0.0	0	0	0	0	1
12/20/2021 01:00	0.0	0	0	0	0	1
12/20/2021 02:00	0.0	0	0	0	0	1
12/20/2021 03:00	0.0	0	0	0	0	1
12/20/2021 04:00	0.0	0	0	0	0	1
12/20/2021 05:00	0.0	0	0	0	0	1
12/20/2021 06:00	0.0	0	0	0	0	1
12/20/2021 07:00	0.0	0	0	0	0	1
12/20/2021 08:00	0.0	0	0	0	0	1
12/20/2021 09:00	0.0	0	0	0	0	1
12/20/2021 10:00	0.0	0	0	0	0	1
12/20/2021 11:00	0.0	0	0	0	0	1
12/20/2021 12:00	0.0	0	0	0	0	1
12/20/2021 13:00	0.0	0	0	0	0	1
12/20/2021 14:00	0.0	0	0	0	0	1
12/20/2021 15:00	0.0	0	0	0	0	1
12/20/2021 16:00	0.0	0	0	0	0	1
12/20/2021 17:00	0.0	0	0	0	0	1
12/20/2021 18:00	0.0	0	0	0	0	1
12/20/2021 19:00	0.0	0	0	0	0	1
12/20/2021 20:00	0.0	0	0	0	0	1
12/20/2021 21:00	0.0	0	0	0	0	1
12/20/2021 22:00	0.0	0	0	0	0	1
12/20/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/21/2021 00:00	0.0	0	0	0	0	1
12/21/2021 01:00	0.0	0	0	0	0	1
12/21/2021 02:00	0.0	0	0	0	0	1
12/21/2021 03:00	0.0	0	0	0	0	1
12/21/2021 04:00	0.0	0	0	0	0	1
12/21/2021 05:00	0.0	0	0	0	0	1
12/21/2021 06:00	0.0	0	0	0	0	1
12/21/2021 07:00	0.0	0	0	0	0	1
12/21/2021 08:00	0.0	0	0	0	0	1
12/21/2021 09:00	0.0	0	0	0	0	1
12/21/2021 10:00	0.0	0	0	0	0	1
12/21/2021 11:00	0.0	0	0	0	0	1
12/21/2021 12:00	0.0	0	0	0	0	1
12/21/2021 13:00	0.0	0	0	0	0	1
12/21/2021 14:00	0.0	0	0	0	0	1
12/21/2021 15:00	0.0	0	0	0	0	1
12/21/2021 16:00	0.0	0	0	0	0	1
12/21/2021 17:00	0.0	0	0	0	0	1
12/21/2021 18:00	0.0	0	0	0	0	1
12/21/2021 19:00	0.0	0	0	0	0	1
12/21/2021 20:00	0.0	0	0	0	0	1
12/21/2021 21:00	0.0	0	0	0	0	1
12/21/2021 22:00	0.0	0	0	0	0	1
12/21/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/22/2021 00:00	0.0	0	0	0	0	1
12/22/2021 01:00	0.0	0	0	0	0	1
12/22/2021 02:00	0.0	0	0	0	0	1
12/22/2021 03:00	0.0	0	0	0	0	1
12/22/2021 04:00	0.0	0	0	0	0	1
12/22/2021 05:00	0.0	0	0	0	0	1
12/22/2021 06:00	0.0	0	0	0	0	1
12/22/2021 07:00	0.0	0	0	0	0	1
12/22/2021 08:00	0.0	0	0	0	0	1
12/22/2021 09:00	0.0	0	0	0	0	1
12/22/2021 10:00	0.0	0	0	0	0	1
12/22/2021 11:00	0.0	0	0	0	0	1
12/22/2021 12:00	0.0	0	0	0	0	1
12/22/2021 13:00	0.0	0	0	0	0	1
12/22/2021 14:00	0.0	0	0	0	0	1
12/22/2021 15:00	0.0	0	0	0	0	1
12/22/2021 16:00	0.0	0	0	0	0	1
12/22/2021 17:00	0.0	0	0	0	0	1
12/22/2021 18:00	0.0	0	0	0	0	1
12/22/2021 19:00	0.0	0	0	0	0	1
12/22/2021 20:00	0.0	0	0	0	0	1
12/22/2021 21:00	0.0	0	0	0	0	1
12/22/2021 22:00	0.0	0	0	0	0	1
12/22/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/23/2021 00:00	0.0	0	0	0	0	1
12/23/2021 01:00	0.0	0	0	0	0	1
12/23/2021 02:00	0.0	0	0	0	0	1
12/23/2021 03:00	0.0	0	0	0	0	1
12/23/2021 04:00	0.0	0	0	0	0	1
12/23/2021 05:00	0.0	0	0	0	0	1
12/23/2021 06:00	0.0	0	0	0	0	1
12/23/2021 07:00	0.0	0	0	0	0	1
12/23/2021 08:00	0.0	0	0	0	0	1
12/23/2021 09:00	0.0	0	0	0	0	1
12/23/2021 10:00	0.0	0	0	0	0	1
12/23/2021 11:00	0.0	0	0	0	0	1
12/23/2021 12:00	0.0	0	0	0	0	1
12/23/2021 13:00	0.0	0	0	0	0	1
12/23/2021 14:00	0.0	0	0	0	0	1
12/23/2021 15:00	0.0	0	0	0	0	1
12/23/2021 16:00	0.0	0	0	0	0	1
12/23/2021 17:00	0.0	0	0	0	0	1
12/23/2021 18:00	0.0	0	0	0	0	1
12/23/2021 19:00	0.0	0	0	0	0	1
12/23/2021 20:00	0.0	0	0	0	0	1
12/23/2021 21:00	0.0	0	0	0	0	1
12/23/2021 22:00	0.0	0	0	0	0	1
12/23/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/24/2021 00:00	0.0	0	0	0	0	1
12/24/2021 01:00	0.0	0	0	0	0	1
12/24/2021 02:00	0.0	0	0	0	0	1
12/24/2021 03:00	0.0	0	0	0	0	1
12/24/2021 04:00	0.0	0	0	0	0	1
12/24/2021 05:00	0.0	0	0	0	0	1
12/24/2021 06:00	0.0	0	0	0	0	1
12/24/2021 07:00	0.0	0	0	0	0	1
12/24/2021 08:00	0.0	0	0	0	0	1
12/24/2021 09:00	0.0	0	0	0	0	1
12/24/2021 10:00	0.0	0	0	0	0	1
12/24/2021 11:00	0.0	0	0	0	0	1
12/24/2021 12:00	0.0	0	0	0	0	1
12/24/2021 13:00	0.0	0	0	0	0	1
12/24/2021 14:00	0.0	0	0	0	0	1
12/24/2021 15:00	0.0	0	0	0	0	1
12/24/2021 16:00	0.0	0	0	0	0	1
12/24/2021 17:00	0.0	0	0	0	0	1
12/24/2021 18:00	0.0	0	0	0	0	1
12/24/2021 19:00	0.0	0	0	0	0	1
12/24/2021 20:00	0.0	0	0	0	0	1
12/24/2021 21:00	0.0	0	0	0	0	1
12/24/2021 22:00	0.0	0	0	0	0	1
12/24/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/25/2021 00:00	0.0	0	0	0	0	1
12/25/2021 01:00	0.0	0	0	0	0	1
12/25/2021 02:00	0.0	0	0	0	0	1
12/25/2021 03:00	0.0	0	0	0	0	1
12/25/2021 04:00	0.0	0	0	0	0	1
12/25/2021 05:00	0.0	0	0	0	0	1
12/25/2021 06:00	0.0	0	0	0	0	1
12/25/2021 07:00	0.0	0	0	0	0	1
12/25/2021 08:00	0.0	0	0	0	0	1
12/25/2021 09:00	0.0	0	0	0	0	1
12/25/2021 10:00	0.0	0	0	0	0	1
12/25/2021 11:00	0.0	0	0	0	0	1
12/25/2021 12:00	0.0	0	0	0	0	1
12/25/2021 13:00	0.0	0	0	0	0	1
12/25/2021 14:00	0.0	0	0	0	0	1
12/25/2021 15:00	0.0	0	0	0	0	1
12/25/2021 16:00	0.0	0	0	0	0	1
12/25/2021 17:00	0.0	0	0	0	0	1
12/25/2021 18:00	0.0	0	0	0	0	1
12/25/2021 19:00	0.0	0	0	0	0	1
12/25/2021 20:00	0.0	0	0	0	0	1
12/25/2021 21:00	0.0	0	0	0	0	1
12/25/2021 22:00	0.0	0	0	0	0	1
12/25/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/26/2021 00:00	1.2	0	0	0	1	0
12/26/2021 01:00	0.0	0	0	0	0	0
12/26/2021 02:00	0.0	0	0	0	0	0
12/26/2021 03:00	0.0	0	0	0	0	0
12/26/2021 04:00	0.0	0	0	0	0	0
12/26/2021 05:00	0.0	0	0	0	0	0
12/26/2021 06:00	0.0	0	0	0	0	0
12/26/2021 07:00	0.0	0	0	0	0	0
12/26/2021 08:00	0.0	0	0	0	0	0
12/26/2021 09:00	0.0	0	0	0	0	0
12/26/2021 10:00	0.0	0	0	0	0	0
12/26/2021 11:00	0.0	0	0	0	0	0
12/26/2021 12:00	0.0	0	0	0	0	0
12/26/2021 13:00	0.0	0	0	0	0	0
12/26/2021 14:00	0.0	0	0	0	0	0
12/26/2021 15:00	4.6	0	1	0	0	0
12/26/2021 16:00	70.3	0	1	0	0	0
12/26/2021 17:00	0.0	0	0	0	0	1
12/26/2021 18:00	0.0	0	0	0	0	1
12/26/2021 19:00	0.0	0	0	0	0	1
12/26/2021 20:00	0.0	0	0	0	0	1
12/26/2021 21:00	0.0	0	0	0	0	1
12/26/2021 22:00	0.0	0	0	0	0	1
12/26/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	76.1 #	0 #	2 #	0 #	1 #	7 #
Minimum:	0.0	0	0	0	0	0
Maximum:	70.3	0	1	0	1	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/27/2021 00:00	0.0	0	0	0	0	1
12/27/2021 01:00	0.0	0	0	0	0	1
12/27/2021 02:00	0.0	0	0	0	0	1
12/27/2021 03:00	0.0	0	0	0	0	1
12/27/2021 04:00	0.0	0	0	0	0	1
12/27/2021 05:00	0.0	0	0	0	0	1
12/27/2021 06:00	0.0	0	0	0	0	1
12/27/2021 07:00	0.0	0	0	0	0	1
12/27/2021 08:00	0.0	0	0	0	0	1
12/27/2021 09:00	0.0	0	0	0	0	1
12/27/2021 10:00	0.0	0	0	0	0	1
12/27/2021 11:00	0.0	0	0	0	0	1
12/27/2021 12:00	0.0	0	0	0	0	1
12/27/2021 13:00	0.0	0	0	0	0	1
12/27/2021 14:00	0.0	0	0	0	0	1
12/27/2021 15:00	0.0	0	0	0	0	1
12/27/2021 16:00	0.0	0	0	0	0	1
12/27/2021 17:00	0.0	0	0	0	0	1
12/27/2021 18:00	0.0	0	0	0	0	1
12/27/2021 19:00	0.0	0	0	0	0	1
12/27/2021 20:00	0.0	0	0	0	0	1
12/27/2021 21:00	0.0	0	0	0	0	1
12/27/2021 22:00	0.0	0	0	0	0	1
12/27/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/28/2021 00:00	0.0	0	0	0	0	1
12/28/2021 01:00	0.0	0	0	0	0	1
12/28/2021 02:00	0.0	0	0	0	0	1
12/28/2021 03:00	0.0	0	0	0	0	1
12/28/2021 04:00	0.0	0	0	0	0	1
12/28/2021 05:00	0.0	0	0	0	0	1
12/28/2021 06:00	0.0	0	0	0	0	1
12/28/2021 07:00	0.0	0	0	0	0	1
12/28/2021 08:00	0.0	0	0	0	0	1
12/28/2021 09:00	0.0	0	0	0	0	1
12/28/2021 10:00	0.0	0	0	0	0	1
12/28/2021 11:00	0.0	0	0	0	0	1
12/28/2021 12:00	0.0	0	0	0	0	1
12/28/2021 13:00	0.0	0	0	0	0	1
12/28/2021 14:00	0.0	0	0	0	0	1
12/28/2021 15:00	0.0	0	0	0	0	1
12/28/2021 16:00	0.0	0	0	0	0	1
12/28/2021 17:00	0.0	0	0	0	0	1
12/28/2021 18:00	0.0	0	0	0	0	1
12/28/2021 19:00	0.0	0	0	0	0	1
12/28/2021 20:00	0.0	0	0	0	0	1
12/28/2021 21:00	0.0	0	0	0	0	1
12/28/2021 22:00	0.0	0	0	0	0	1
12/28/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/29/2021 00:00	0.0	0	0	0	0	1
12/29/2021 01:00	0.0	0	0	0	0	1
12/29/2021 02:00	0.0	0	0	0	0	1
12/29/2021 03:00	0.0	0	0	0	0	1
12/29/2021 04:00	0.0	0	0	0	0	1
12/29/2021 05:00	0.0	0	0	0	0	1
12/29/2021 06:00	0.0	0	0	0	0	1
12/29/2021 07:00	0.0	0	0	0	0	1
12/29/2021 08:00	0.0	0	0	0	0	1
12/29/2021 09:00	0.0	0	0	0	0	1
12/29/2021 10:00	0.0	0	0	0	0	1
12/29/2021 11:00	0.0	0	0	0	0	1
12/29/2021 12:00	0.0	0	0	0	0	1
12/29/2021 13:00	0.0	0	0	0	0	1
12/29/2021 14:00	0.0	0	0	0	0	1
12/29/2021 15:00	0.0	0	0	0	0	1
12/29/2021 16:00	0.0	0	0	0	0	1
12/29/2021 17:00	0.0	0	0	0	0	1
12/29/2021 18:00	0.0	0	0	0	0	1
12/29/2021 19:00	0.0	0	0	0	0	1
12/29/2021 20:00	0.0	0	0	0	0	1
12/29/2021 21:00	0.0	0	0	0	0	1
12/29/2021 22:00	0.0	0	0	0	0	1
12/29/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/30/2021 00:00	0.0	0	0	0	0	1
12/30/2021 01:00	0.0	0	0	0	0	1
12/30/2021 02:00	0.0	0	0	0	0	1
12/30/2021 03:00	0.0	0	0	0	0	1
12/30/2021 04:00	0.0	0	0	0	0	1
12/30/2021 05:00	0.0	0	0	0	0	1
12/30/2021 06:00	0.0	0	0	0	0	1
12/30/2021 07:00	0.0	0	0	0	0	1
12/30/2021 08:00	0.0	0	0	0	0	1
12/30/2021 09:00	0.0	0	0	0	0	1
12/30/2021 10:00	0.0	0	0	0	0	1
12/30/2021 11:00	0.0	0	0	0	0	1
12/30/2021 12:00	0.0	0	0	0	0	1
12/30/2021 13:00	0.0	0	0	0	0	1
12/30/2021 14:00	0.0	0	0	0	0	1
12/30/2021 15:00	0.0	0	0	0	0	1
12/30/2021 16:00	0.0	0	0	0	0	1
12/30/2021 17:00	0.0	0	0	0	0	1
12/30/2021 18:00	0.0	0	0	0	0	1
12/30/2021 19:00	0.0	0	0	0	0	1
12/30/2021 20:00	0.0	0	0	0	0	1
12/30/2021 21:00	0.0	0	0	0	0	1
12/30/2021 22:00	0.0	0	0	0	0	1
12/30/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Daily Summary Report

CT2 Event NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
12/31/2021 00:00	0.0	0	0	0	0	1
12/31/2021 01:00	0.0	0	0	0	0	1
12/31/2021 02:00	0.0	0	0	0	0	1
12/31/2021 03:00	0.0	0	0	0	0	1
12/31/2021 04:00	0.0	0	0	0	0	1
12/31/2021 05:00	0.0	0	0	0	0	1
12/31/2021 06:00	0.0	0	0	0	0	1
12/31/2021 07:00	0.0	0	0	0	0	1
12/31/2021 08:00	0.0	0	0	0	0	1
12/31/2021 09:00	0.0	0	0	0	0	1
12/31/2021 10:00	0.0	0	0	0	0	1
12/31/2021 11:00	0.0	0	0	0	0	1
12/31/2021 12:00	0.0	0	0	0	0	1
12/31/2021 13:00	0.0	0	0	0	0	1
12/31/2021 14:00	0.0	0	0	0	0	1
12/31/2021 15:00	0.0	0	0	0	0	1
12/31/2021 16:00	0.0	0	0	0	0	1
12/31/2021 17:00	0.0	0	0	0	0	1
12/31/2021 18:00	0.0	0	0	0	0	1
12/31/2021 19:00	0.0	0	0	0	0	1
12/31/2021 20:00	0.0	0	0	0	0	1
12/31/2021 21:00	0.0	0	0	0	0	1
12/31/2021 22:00	0.0	0	0	0	0	1
12/31/2021 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Pound Per Event Report

CT1 - CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:20 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,630.20 Hours

Non-Operating Time: 577.80 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
10/08/2021 21:04 10/08/2021 21:09 Shut Down - Gas	6	1.0	483.5		
10/20/2021 13:25 10/20/2021 15:09 Cold Start - Gas	105	142.4	1,355.6		
10/20/2021 22:09 10/20/2021 22:13 Shut Down - Gas	5	0.7	483.5		
10/23/2021 01:22 10/23/2021 03:56 Warm Start - Gas	155	189.8	790.5		
10/23/2021 22:38 10/23/2021 22:43 Shut Down - Gas	6	1.4	483.5		
10/24/2021 07:16 10/24/2021 08:40 Warm Start - Gas	85	113.4	790.5		
11/06/2021 22:39 11/06/2021 22:43 Shut Down - Gas	5	0.5	483.5		
11/09/2021 07:11 11/09/2021 08:44 Warm Start - Gas	94	160.7	790.5		
11/11/2021 01:08 11/11/2021 01:13 Shut Down - Gas	6	1.1	483.5		
11/11/2021 09:34 11/11/2021 10:59 Warm Start - Gas	86	198.9	790.5		
11/13/2021 00:23 11/13/2021 00:28 Shut Down - Gas	6	1.0	483.5		
11/13/2021 08:34 11/13/2021 09:44 Warm Start - Gas	71	103.3	790.5		
11/13/2021 22:38 11/13/2021 22:43 Shut Down - Gas	6	1.2	483.5		

Pound Per Event Report

CT1 - CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:20 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,630.20 Hours

Non-Operating Time: 577.80 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
11/14/2021 09:47 11/14/2021 11:27 Warm Start - Gas	101	134.9	790.5		
11/16/2021 00:10 11/16/2021 00:15 Shut Down - Gas	6	1.6	483.5		
11/16/2021 08:34 11/16/2021 09:54 Warm Start - Gas	81	145.4	790.5		
11/21/2021 02:51 11/21/2021 02:56 Shut Down - Gas	6	0.7	483.5		
11/21/2021 10:43 11/21/2021 11:53 Hot Start - Gas	71	73.1	679.6		
11/25/2021 00:08 11/25/2021 00:13 Shut Down - Gas	6	0.9	483.5		
11/29/2021 07:49 11/29/2021 11:48 Cold Start - Gas	240	330.8	1,355.6		
11/29/2021 23:22 11/29/2021 23:27 Shut Down - Gas	6	1.6	483.5		
11/30/2021 05:43 11/30/2021 06:51 Hot Start - Gas	69	61.2	679.6		
12/02/2021 00:24 12/02/2021 00:29 Shut Down - Gas	6	0.8	483.5		
12/02/2021 06:20 12/02/2021 07:20 Hot Start - Gas	61	96.0	679.6		
12/03/2021 23:56 12/04/2021 00:00 Shut Down - Gas	5	0.4	483.5		
12/04/2021 03:49 12/04/2021 04:46 Hot Start - Gas	58	60.4	679.6		
12/04/2021 23:05 12/04/2021 23:10 Shut Down - Gas	6	2.2	483.5		

Pound Per Event Report

CT1 - CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:20 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,630.20 Hours

Non-Operating Time: 577.80 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
12/05/2021 07:17 12/05/2021 08:53 Warm Start - Gas	97	193.0	790.5		
12/26/2021 00:24 12/26/2021 00:29 Shut Down - Gas	6	1.2	483.5		
12/26/2021 10:50 12/26/2021 12:58 Warm Start - Gas	129	157.3	790.5		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT1 - CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:20 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,630.20 Hours

Non-Operating Time: 577.80 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Pound Per Event Report

CT1 - CO Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:20 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,630.20 Hours

Non-Operating Time: 577.80 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Pound Per Event Report

CT2 - NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:21 **Location:** Maxwell, CA
Tag Name: CT2_NOx_Event_Lbs_1M
SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,521.27 Hours
Non-Operating Time: 686.73 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
10/01/2021 13:27 10/01/2021 14:42 Warm Start - Gas	76	89.81	456.20		
10/08/2021 21:06 10/08/2021 21:11 Shut Down - Gas	6	0.12	115.00		
10/20/2021 08:45 10/20/2021 12:33 Cold Start - Gas	229	144.22	779.10		
10/20/2021 22:09 10/20/2021 22:13 Shut Down - Gas	5	0.12	115.00		
10/23/2021 05:55 10/23/2021 07:24 Warm Start - Gas	90	65.70	456.20		
10/23/2021 22:38 10/23/2021 22:43 Shut Down - Gas	6	0.26	115.00		
10/24/2021 03:49 10/24/2021 04:48 Hot Start - Gas	60	24.21	259.90		
10/24/2021 23:18 10/24/2021 23:22 Shut Down - Gas	5	0.06	115.00		
10/25/2021 05:28 10/25/2021 06:24 Hot Start - Gas	57	22.53	259.90		
10/25/2021 23:18 10/25/2021 23:22 Shut Down - Gas	5	0.04	115.00		
10/26/2021 05:30 10/26/2021 06:27 Hot Start - Gas	58	24.03	259.90		
10/28/2021 00:49 10/28/2021 00:54 Shut Down - Gas	6	0.12	115.00		
10/28/2021 12:37 10/28/2021 13:40 Warm Start - Gas	64	53.75	456.20		

Pound Per Event Report

CT2 - NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:21 **Location:** Maxwell, CA
Tag Name: CT2_NOx_Event_Lbs_1M
SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,521.27 Hours
Non-Operating Time: 686.73 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
11/04/2021 23:17 11/04/2021 23:22 Shut Down - Gas	6	0.25	115.00		
11/05/2021 13:19 11/05/2021 14:29 Warm Start - Gas	71	59.85	456.20		
11/06/2021 22:39 11/06/2021 22:43 Shut Down - Gas	5	0.12	115.00		
11/08/2021 12:17 11/08/2021 14:50 Warm Start - Gas	154	130.78	456.20		
11/08/2021 23:08 11/08/2021 23:12 Shut Down - Gas	5	0.05	115.00		
11/09/2021 03:39 11/09/2021 04:44 Hot Start - Gas	66	20.78	259.90		
11/11/2021 01:08 11/11/2021 01:13 Shut Down - Gas	6	0.27	115.00		
11/11/2021 13:27 11/11/2021 14:39 Warm Start - Gas	73	68.02	456.20		
11/12/2021 08:18 11/12/2021 08:23 Shut Down - Gas	6	0.17	115.00		
11/12/2021 15:34 11/12/2021 16:50 Hot Start - Gas	77	33.46	259.90		
11/13/2021 00:23 11/13/2021 00:28 Shut Down - Gas	6	0.20	115.00		
11/13/2021 13:18 11/13/2021 14:35 Warm Start - Gas	78	50.60	456.20		
11/13/2021 22:38 11/13/2021 22:43 Shut Down - Gas	6	0.20	115.00		
11/14/2021 14:47 11/14/2021 15:56 Warm Start - Gas	70	62.08	456.20		

Pound Per Event Report

CT2 - NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:21 **Location:** Maxwell, CA
Tag Name: CT2_NOx_Event_Lbs_1M
SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,521.27 Hours
Non-Operating Time: 686.73 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
11/15/2021 00:20 11/15/2021 00:24 Shut Down - Gas	5	0.05	115.00		
11/15/2021 07:35 11/15/2021 08:54 Hot Start - Gas	80	44.44	259.90		
11/16/2021 00:08 11/16/2021 00:13 Shut Down - Gas	6	0.30	115.00		
11/16/2021 13:48 11/16/2021 15:18 Warm Start - Gas	91	83.68	456.20		
11/21/2021 02:51 11/21/2021 02:55 Shut Down - Gas	5	0.16	115.00		
11/21/2021 14:32 11/21/2021 15:53 Warm Start - Gas	82	70.13	456.20		
11/22/2021 00:22 11/22/2021 00:27 Shut Down - Gas	6	0.17	115.00		
11/22/2021 12:22 11/22/2021 13:31 Warm Start - Gas	70	69.76	456.20		
11/25/2021 00:08 11/25/2021 00:13 Shut Down - Gas	6	0.32	115.00		
11/29/2021 14:18 11/29/2021 15:52 Cold Start - Gas	95	77.00	779.10		
11/29/2021 23:23 11/29/2021 23:27 Shut Down - Gas	5	0.08	115.00		
11/30/2021 08:37 11/30/2021 09:45 Warm Start - Gas	69	51.05	456.20		
12/02/2021 00:24 12/02/2021 00:29 Shut Down - Gas	6	0.21	115.00		
12/02/2021 04:03 12/02/2021 04:59 Hot Start - Gas	57	20.16	259.90		

Pound Per Event Report

CT2 - NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:21 **Location:** Maxwell, CA
Tag Name: CT2_NOx_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission
Total Operating Time: 1,521.27 Hours
Non-Operating Time: 686.73 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
12/03/2021 00:49 12/03/2021 00:54 Shut Down - Gas	6	0.16	115.00		
12/03/2021 03:47 12/03/2021 04:55 Hot Start - Gas	69	21.80	259.90		
12/03/2021 23:53 12/03/2021 23:58 Shut Down - Gas	6	0.27	115.00		
12/04/2021 05:48 12/04/2021 06:02 Hot Start - Gas	15	1.48	259.90		
12/04/2021 06:03 12/04/2021 06:08 Shut Down - Gas	6	0.32	115.00		
12/04/2021 06:46 12/04/2021 07:27 Hot Start - Gas	42	14.35	259.90		
12/04/2021 12:50 12/04/2021 12:54 Shut Down - Gas	5	0.06	115.00		
12/04/2021 15:49 12/04/2021 16:51 Hot Start - Gas	63	16.96	259.90		
12/04/2021 23:07 12/04/2021 23:12 Shut Down - Gas	6	0.19	115.00		
12/05/2021 13:36 12/05/2021 14:41 Warm Start - Gas	66	59.54	456.20		
12/26/2021 00:24 12/26/2021 00:29 Shut Down - Gas	6	0.34	115.00		
12/26/2021 15:48 12/26/2021 16:55 Warm Start - Gas	68	70.12	456.20		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT2 - NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 01/10/2022 10:21 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,521.27 Hours

Non-Operating Time: 686.73 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Pound Per Event Report

CT2 - NOx Lbs

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:21 **Location:** Maxwell, CA
Tag Name: CT2_NOx_Event_Lbs_1M SI = SampleInvalid, * = Excess Emission
Total Operating Time: 1,521.27 Hours
Non-Operating Time: 686.73 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

CT1 Process Event Report

CT1 Cold and Hot Startup Events

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:21 **Location:** Maxwell, CA

Unit Offline

Tag Name: CT1_UnitOn_TF_1H

Offline Periods		
Start Time	**End Time**	**Duration in Hour(s)**
10/08/2021 22:00	10/20/2021 12:00	279
10/20/2021 23:00	10/23/2021 00:00	50
10/23/2021 23:00	10/24/2021 06:00	8
11/06/2021 23:00	11/09/2021 06:00	56
11/11/2021 02:00	11/11/2021 08:00	7
11/13/2021 01:00	11/13/2021 07:00	7
11/13/2021 23:00	11/14/2021 08:00	10
11/16/2021 01:00	11/16/2021 07:00	7
11/21/2021 03:00	11/21/2021 09:00	7
11/25/2021 01:00	11/29/2021 06:00	102
11/30/2021 00:00	11/30/2021 04:00	5
12/02/2021 01:00	12/02/2021 05:00	5
12/04/2021 01:00	12/04/2021 02:00	2
12/05/2021 00:00	12/05/2021 06:00	7
12/26/2021 01:00	12/26/2021 09:00	9

CT1 Process Event Report

CT1 Cold and Hot Startup Events

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:21 **Location:** Maxwell, CA

Operating Time Summary	
Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	561.00 Hour(s)
Offline Percentage:	25.41 %
Total Online:	1,647.00 Hour(s)
Online Percentage:	74.59 %

CT1 Process Event Report

CT1 Cold and Hot Startup Events

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:21 **Location:** Maxwell, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	10/20/2021 13:00	10/20/2021 15:00	Cold Startup	3
2	10/23/2021 01:00	10/23/2021 03:00	Warm Startup	3
3	10/24/2021 07:00	10/24/2021 08:00	Warm Startup	2
4	11/09/2021 07:00	11/09/2021 08:00	Warm Startup	2
5	11/11/2021 09:00	11/11/2021 10:00	Warm Startup	2
6	11/13/2021 08:00	11/13/2021 09:00	Warm Startup	2
7	11/14/2021 09:00	11/14/2021 11:00	Warm Startup	3
8	11/16/2021 08:00	11/16/2021 09:00	Warm Startup	2
9	11/21/2021 10:00	11/21/2021 11:00	Hot Startup	2
10	11/29/2021 07:00	11/29/2021 11:00	Cold Startup	5
11	11/30/2021 05:00	11/30/2021 06:00	Hot Startup	2
12	12/02/2021 06:00	12/02/2021 07:00	Hot Startup	2
13	12/04/2021 03:00	12/04/2021 04:00	Hot Startup	2
14	12/05/2021 07:00	12/05/2021 08:00	Warm Startup	2
15	12/26/2021 10:00	12/26/2021 12:00	Warm Startup	3

CT1 Process Event Report

CT1 Cold and Hot Startup Events

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:21 **Location:** Maxwell, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	2	8	0.49
Hot Startup/Startup Shutdown Event Text 02 Add	4	8	0.49
Warm Startup	9	21	1.28
Total Process Events:	15	37	2.25

Total Report Time:	2,208 Hour(s)
Total Operating Time:	1,647 Hour(s)
Total Startup Time:	37 Hour(s)
Total Shutdown Time:	0 Hour(s)
Total Startup/Shutdown Time:	37 Hour(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	2.25 %

CT2 Process Event Report

CT2 Cold and Hot Startup Events

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:22 **Location:** Maxwell, CA

Unit Offline

Tag Name: CT2_UnitOn_TF_1H

Offline Periods		
Start Time	**End Time**	**Duration in Hour(s)**
10/01/2021 00:00	10/01/2021 12:00	13
10/08/2021 22:00	10/20/2021 07:00	274
10/20/2021 23:00	10/23/2021 04:00	54
10/23/2021 23:00	10/24/2021 02:00	4
10/25/2021 00:00	10/25/2021 04:00	5
10/26/2021 00:00	10/26/2021 04:00	5
10/28/2021 01:00	10/28/2021 11:00	11
11/05/2021 00:00	11/05/2021 12:00	13
11/06/2021 23:00	11/08/2021 11:00	37
11/09/2021 00:00	11/09/2021 02:00	3
11/11/2021 02:00	11/11/2021 12:00	11
11/12/2021 09:00	11/12/2021 14:00	6
11/13/2021 01:00	11/13/2021 12:00	12
11/13/2021 23:00	11/14/2021 13:00	15
11/15/2021 01:00	11/15/2021 06:00	6
11/16/2021 01:00	11/16/2021 12:00	12
11/21/2021 03:00	11/21/2021 13:00	11
11/22/2021 01:00	11/22/2021 11:00	11
11/25/2021 01:00	11/29/2021 13:00	109
11/30/2021 00:00	11/30/2021 07:00	8
12/02/2021 01:00	12/02/2021 03:00	3
12/03/2021 01:00	12/03/2021 02:00	2
12/04/2021 00:00	12/04/2021 04:00	5
12/04/2021 13:00	12/04/2021 14:00	2
12/05/2021 00:00	12/05/2021 12:00	13
12/26/2021 01:00	12/26/2021 14:00	14

CT2 Process Event Report

CT2 Cold and Hot Startup Events

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:22 **Location:** Maxwell, CA

Operating Time Summary	
Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	659.00 Hour(s)
Offline Percentage:	29.85 %
Total Online:	1,549.00 Hour(s)
Online Percentage:	70.15 %

CT2 Process Event Report

CT2 Cold and Hot Startup Events

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:22 **Location:** Maxwell, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	10/01/2021 13:00	10/01/2021 14:00	Warm startup	2
2	10/20/2021 08:00	10/20/2021 12:00	Cold Startup	5
3	10/23/2021 05:00	10/23/2021 07:00	Warm startup	3
4	10/24/2021 03:00	10/24/2021 04:00	Hot Startup	2
5	10/25/2021 05:00	10/25/2021 06:00	Hot Startup	2
6	10/26/2021 05:00	10/26/2021 06:00	Hot Startup	2
7	10/28/2021 12:00	10/28/2021 13:00	Warm startup	2
8	11/05/2021 13:00	11/05/2021 14:00	Warm startup	2
9	11/08/2021 12:00	11/08/2021 14:00	Warm startup	3
10	11/09/2021 03:00	11/09/2021 04:00	Hot Startup	2
11	11/11/2021 13:00	11/11/2021 14:00	Warm startup	2
12	11/12/2021 15:00	11/12/2021 16:00	Hot Startup	2
13	11/13/2021 13:00	11/13/2021 14:00	Warm startup	2
14	11/14/2021 14:00	11/14/2021 15:00	Warm startup	2
15	11/15/2021 07:00	11/15/2021 08:00	Hot Startup	2
16	11/16/2021 13:00	11/16/2021 15:00	Warm startup	3
17	11/21/2021 14:00	11/21/2021 15:00	Warm startup	2
18	11/22/2021 12:00	11/22/2021 13:00	Warm startup	2
19	11/29/2021 14:00	11/29/2021 15:00	Cold Startup	2
20	11/30/2021 08:00	11/30/2021 09:00	Warm startup	2
21	12/02/2021 04:00	12/02/2021 04:00	Hot Startup	1
22	12/03/2021 03:00	12/03/2021 04:00	Hot Startup	2

CT2 Process Event Report

CT2 Cold and Hot Startup Events

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:22 **Location:** Maxwell, CA

Number	Start Time	End Time	Event Type	Duration
23	12/04/2021 05:00	12/04/2021 07:00	Hot Startup	3
24	12/04/2021 15:00	12/04/2021 16:00	Hot Startup	2
25	12/05/2021 13:00	12/05/2021 14:00	Warm startup	2
26	12/26/2021 15:00	12/26/2021 16:00	Warm startup	2

CT2 Process Event Report

CT2 Cold and Hot Startup Events

From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 01/10/2022 10:22 **Location:** Maxwell, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	2	7	0.45
Hot Startup	10	20	1.29
Warm startup	14	31	2.00
Total Process Events:	26	58	3.74

Total Report Time:	2,208 Hour(s)
Total Operating Time:	1,549 Hour(s)
Total Startup Time:	58 Hour(s)
Total Shutdown Time:	0 Hour(s)
Total Startup/Shutdown Time:	58 Hour(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	3.74 %

ATTACHMENT 13
Water Bath Heater Operations
FCD: AQ-17
Title V: #6

The Natural Gas Fired Water Bath Heater did not operate in the 4th Quarter of 2021.

ATTACHMENT 14
Certification Report

FCD: AQ-22
Title V: #13

CERTIFICATION REPORT
(FORM 3.17-K1)

DISTRICT:	▸ DISTRICT USE ONLY ◂
Colusa County Air Pollution Control District	DISTRICT ID:
COMPANY NAME: Pacific Gas and Electric	FACILITY NAME: Colusa Generating Station

I. FACILITY INFORMATION

1. Company Name: Pacif ic Gas and Electric
2. Facility Name (if different than Company Name): Colusa Generating Station
3. Mailing Address: 4780 Dirks Rd , Maxwell CA 95955
4. Street Address or Source Location: Same
5. Facility Permit Number: 21006-0259

II. GENERAL INFORMATION

1. Reporting period (specify dates): October 1 - December 31, 2021
2. Due date for submittal of report: January 30, 2022

3. Type of submittal: [X] Monitoring Report (complete Section III below)
   [ ] Compliance Schedule Progress Report (complete Section IV of Form 3.17-K2)
   [ ] Compliance Certification (complete Section V of Form 3.17-K2)

III. MONITORING REPORT INFORMATION

1. Were deviations from monitoring requirements encountered during the reporting period?[X] No [ ] Yes (If Yes, complete Form 3.17-L)

TOXICS TRACKING AND COMPLIANCE PLAN

PG&E Colusa Generating Station

Reporting/Tracking Year: 2021

Combustion Turbines/HRSGs

	CAS #	Emissions Factors lb/mmbtu	Emissions Factors lb/mmscf	EF Source	Source Test Results lb/hr	Max Hourly Emissions lbs	Annual Emissions lbs	Annual Emissions tons
Ammonia Unit #1	7664417	0.00E+00	0.00E+00	Test*	13.9	13.9	64440.40	32.220
Formaldehyde Unit #1	50000	7.00E-05	9.19E-02	Test*	0.046	0.046	213.26	0.107
Ammonia Unit #2	7664417	0.00E+00	0.00E+00	Test*	3.85	3.85	16535.75	8.268
Formaldehyde Unit #2	50000	7.00E-05	9.19E-02	Test*	0.048	0.048	206.16	0.103
1-3 Butadiene	106990	1.24E-07	1.27E-04	CATEF	0	0.001	1.97	0.001
Acetaldehyde	75070	1.34E-04	1.37E-01	CATEF	0	0.580	2123.88	1.062
Acrolein	107028	1.85E-05	1.89E-02	CATEF	0	0.080	293.00	0.147
Benzene	71432	1.30E-05	1.33E-02	CATEF	0	0.056	206.19	0.103
Ethylbenzene	100414	1.75E-05	1.79E-02	CATEF	0	0.076	277.50	0.139
Hexane	110543	2.53E-04	2.59E-01	CATEF	0	1.097	4015.23	2.008
Propylene	115071	7.53E-04	7.71E-01	CATEF	0	3.264	11952.66	5.976
Propylene Oxide	75569	4.67E-05	4.78E-02	CATEF	0	0.202	741.03	0.371
Toluene	108883	6.93E-05	7.10E-02	CATEF	0	0.301	1100.70	0.550
Xylenes	1330207	2.55E-05	2.61E-02	CATEF	0	0.111	404.62	0.202
Naphthalene	91203	1.62E-06	1.66E-03	CATEF	0	0.007	25.73	0.013
Total PAH w/o Naph	1151	1.30E-07	1.31E-04	CATEF	0	0.001	2.03	0.001

Total Turbines/HRSGs

Fuel Use Rate Data

NG HHV	1049	btu/scf	
Fuel Meter Data			
Max Hourly Fuel Use	4.2338	mmscf	(for both units)
Annual Fuel Use	15502.80	mmscf	(for both units)
Calculated Heat Rate Data			
Max Hourly Heat Rate	4441.26	mmbtu	(for both units)
Annual Heat Rate	16262437.2	mmbtu	(for both units)
DAHS/Op Log Data			
Unit #1 Annual Ops Hrs	4636	Hrs/Yr	
Unit #2 Annual Ops Hrs	4295	Hrs/Yr	
Total Hrs, All Units	8931	Hrs/Yr	(for both units)
CT1 Annual Fuel Use	8016.4	mmscf	
CT2 Annual Fuel Use	7486.4	mmscf	

Fuel Gas Heater (10 mmbtu/hr)

	CAS #	Emissions Factors lb/mmbtu	Emissions Factors lb/mmscf	EF Source	Source Test Results lb/hr	Max Hourly Emissions lbs	Annual Emissions lbs	Annual Emissions tons
Acetaldehyde	75070	8.66E-06	8.87E-03	CATEF	0	0.0000	0.000	0.0000
Benzene	71432	4.21E-06	4.31E-03	CATEF	0	0.0000	0.000	0.0000
Formaldehyde	50000	2.16E-04	2.21E-01	CATEF	0	0.0000	0.000	0.0000

Total FG Heater

Fuel Use Rate Data

NG HHV	1049	btu/scf
Fuel Use Data		
Max Hourly Fuel Use	0.00000	mmscf
Annual Fuel Use	0.00	mmscf
Calculated Heat Rate Data		
Max Hourly Heat Rate	0.00	mmbtu
Annual Heat Rate	0.00	mmbtu

*Testing conducted Nov-21

Reporting Quarter 4

TOXICS AND GHG TRACKING AND COMPLIANCE PLAN

PG&E Colusa Generating Station

Toxics Plan:

1. perform annual testing for ammonia per CCAPCD Permit Condition #9 (3-2-09)
2. perform annual testing for formaldehyde per CCAPCD Permit Condition #9 (3-2-09)
3. comply with all other provisions of CCAPCD Permit Condition #9 (3-2-09)
4. quantify other identified toxic pollutants via the emissions factors delineated in the AFC Appendix L (Public Health)
5. report toxic emissions to the CCAPCD annually and show compliance with CCAPCD Permit Condition #28 (3-2-09)

Data and Source References:

1. CGS plant and operational data (CEMS, DAHS, purchase records, and ops logs)
2. CCAR General Protocol, Version 3.1, January 2009.
3. CCAR Power Sector Protocol, Version 1.1, May 2009.
4. Other references as noted on the calculation tab.