

DOCKETED

Docket Number:	03-AFC-01C
Project Title:	Roseville Energy Park Compliance
TN #:	241352
Document Title:	Roseville Energy Park Quarterly Air Quality Report - Q4 2021
Description:	Roseville Energy Park hereby submits the Quarterly Air Quality Report for the Fourth Quarter 2021.
Filer:	Roseville Electric Compliance
Organization:	Roseville Electric
Submitter Role:	Public Agency
Submission Date:	2/1/2022 9:33:47 AM
Docketed Date:	2/1/2022



Roseville Electric Utility
2090 Hilltop Circle
Roseville, California 95747-9704
Reliable Energy. Dependable Service.

City of Roseville

Roseville Energy Park

(03-AFC-1)

California Energy Commission

Quarterly Operational Report

Fourth Quarter 2021

List of Attachments

AQ15 - SCR Installed before commissioning in 2007

AQ20 - The gas turbine engine shall be fired exclusively on pipeline quality natural gas with sulfur content no greater than 0.50 grains of sulfur compounds per 100 dry scf of natural gas

AQ21 – Startups and Shutdowns

AQ32 – All hourly, quarter NOx and CO emissions AQ-SC6

AQ33 – All hourly, daily, and quarterly SOx AQ-SC6

AQ34 – Startups and Shutdowns

AQ36 – Breakdown condition

AQ37 – Violations of Emissions

AQ40 – CEMS quality assurance test failures

AQ41 – Excess Emissions

AQ42 – Running 12-month summary

AQ47 – All nuisance violations

N/A for this report period

AQ48 – Nuisance complaints and stack emission opacity as dark as Ringlemann No. 1 (20% opacity) for periods aggregating more than 3 min.

N/A for this report period

AQ51 – Ammonia slip exceedances

AQ55 – Emission rates from each gas turbine and heat recovery steam generator exhaust during startup and shutdown – NOx and CO

AQ57 – Emission exceedance rates during startup and shutdown – CO, NOx, PM-10, SOx, and VOC

AQ59 – Emission limit exceedances – NOx, CO, VOC, PM-10, SO₂

AQ60 – Quarterly emission exceedances for Alstom GTX100 turbine – NOx, CO, VOCs, PM₁₀, SOx

AQ63 – Total facility emission exceedances – NOx, CO, VOC, PM-10, SO₂

AQ68 – Annual water sample analysis of cooling tower water

AQ69 – Nuisance complaints

N/A for this report period

AQ70 – PM-10 quarterly emission rate exceedances from cooling tower

AQ71 – Exceedance of cooling tower PM-10 emission limit – PM-10 = cooling water recirculation rate*total dissolved solids concentration in the blow own water* design drift rate

AQ86 – Limits for operation for maintenance and testing of emergency diesel engine and generator limited to 50 hours per year

AQ87 – Operation for maintenance and testing purposes shall be limited to involuntary interruptions of electrical power. Operation shall not exceed 24 hours

AQ88 – Sulfur content of diesel fuel used shall not exceed 15 ppm by weight

N/A for this report period

AQ89 – Records of hours of operation engine run for maintenance and testing, during interruption of electrical power, records of sulfur content of diesel used for five years

AQ90 – No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance

N/A for this report period

AQ91 – Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited and is in violation of PCAPCD Rule 202, Visible Emissions

N/A for this report period

AQ99 – Operation for maintenance and testing of the emergency diesel engine and generator shall be limited to 50 hours per year.

AQ100 – Emergency diesel Generator; Operation for other than maintenance and testing purposes shall be limited to involuntary interruptions of electrical power

AQ101 - The sulfur content of the diesel used shall not exceed 15ppm by weight

N/A for this report period

AQ102 – Records of operation and maintenance shall be kept by the owner or operator for a period of five years

AQ103 – No emissions are permitted, from any source, which are a nuisance

N/A for this report period

AQ104 – Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited

N/A for this report period

AQ-15

AQ-15 The Project owner shall install a selective catalytic reduction (SCR) system and an oxidation catalyst on the gas turbine. The SCR and oxidation catalyst equipment shall be operated whenever the gas turbine is operated.

Verification: The Project owner shall submit to the CPM a written statement by a California registered Professional Engineer stating that said engineer has reviewed the as built designs or inspected the identified equipment and certifies that it is operational and air tight. The Project owner shall include the operational status of the SCR and oxidation catalyst during all hours of operation as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

This document is on file from the 2007 4Q QAQR.

AQ-20

AQ-20 The gas turbine engine shall be fired exclusively on pipeline quality natural gas with sulfur content no greater than 0.50 grains of sulfur compounds per 100 dry scf of natural gas.

Verification: The Project owner shall submit to the CPM the most recent fuel testing analysis performed as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

AQ20 ROSEVILLE ENERGY PARK

4Q21

Fuel Quality Analysis BTU values

<http://www.pge.com/pij>

	OCT	NOV	DEC
1	1062.38	1041.33	1054.03
2	1062.28	1044.22	1054.43
3	1061.92	1042.84	1055.77
4	1062.97	1043.92	1054.07
5	1060.68	1045.95	1054.37
6	1058.97	1042.44	1050.77
7	1053.60	1044.31	1050.15
8	1051.77	1064.17	1048.43
9	1047.10	1060.12	1049.15
10	1040.96	1042.98	1050.47
11	1037.54	1039.63	1048.73
12	1037.23	1040.41	1045.42
13	1042.83	1,040.45	1047.48
14	1045.60	1037.96	1049.19
15	1047.71	1038.91	1048.53
16	1047.66	1038.48	1048.42
17	1045.63	1038.76	1048.31
18	1041.90	1039.23	1049.65
19	1041.80	1042.28	1048.88
20	1040.88	1045.44	1046.84
21	1041.98	1044.04	1046.57
22	1040.40	1043.34	1044.94
23	1039.75	1041.71	1043.51
24	1044.75	1042.78	1043.13
25	1043.02	1044.64	1042.99
26	1040.29	1052.45	1043.40
27	1040.76	1053.32	1042.89
28	1042.44	1053.60	1043.67
29	1041.59	1053.03	1044.35
30	1041.87	1055.18	1043.49
31	1040.06	N/A	1041.17

odeline/operations/gas_quality/p01_2_weeks.shtml



Gas System Sulfur Survey Results

Date	Total Sulfur Maximum		Total Sulfur Average all sites	
	PPMv	gr/100 scf	PPMv	gr/100 scf
2021				
Fourth Quarter	4.4	0.26	3.2	0.19
Third Quarter	6.7	0.40	3.1	0.18
Second Quarter	4.9	0.29	3.4	0.20
First Quarter	4.2	0.26	3.5	0.22

AQ-21

AQ-21 Startup is defined as the period beginning with the turbine light-off until the unit meets the lb/hr and ppmv emission limits in Conditions of Certification AQ-52, -54 and -55. Shutdown is defined as the period beginning with initiation of turbine shutdown sequence and ending with cessation of firing of the gas turbine engine. Startup and shutdown durations shall not exceed 3.0 hours and one hour, respectively, per occurrence.

Verification: The Project owner shall identify and submit to the CPM as part of the Quarterly Air Quality Report all startups and shutdowns for all units including the maximum hourly emission rate, total emissions and duration.

Monthly Summary By Day Report



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 09:11 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr	Unit CT1 NOX_SUSD, LbPerHr	Unit CT2 CO_SUSD, LbPerHr	Unit CT2 NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/01/2021	0.0	0.0	0.0	0.0
10/02/2021	0.0	0.0	0.0	0.0
10/03/2021	0.0	0.0	0.0	0.0
10/04/2021	0.0	0.0	0.0	0.0
10/05/2021	0.0	0.0	0.0	0.0
10/06/2021	0.0	0.0	0.0	0.0
10/07/2021	0.0	0.0	0.0	0.0
10/08/2021	0.0	0.0	0.0	0.0
10/09/2021	0.0	0.0	0.0	0.0
10/10/2021	0.0	0.0	0.0	0.0
10/11/2021	0.0	0.0	0.0	0.0
10/12/2021	0.0	0.0	0.0	0.0
10/13/2021	0.0	0.0	0.0	0.0
10/14/2021	11.8	1.5	0.0	0.0
10/15/2021	0.0	0.0	0.0	0.0
10/16/2021	0.0	0.0	0.0	0.0
10/17/2021	0.0	0.0	0.0	0.0
10/18/2021	0.0	0.0	0.0	0.0
10/19/2021	0.0	0.0	0.0	0.0
10/20/2021	50.5	11.5	0.0	0.0
10/21/2021	0.0	0.0	0.0	0.0
10/22/2021	0.0	0.0	0.0	0.0
10/23/2021	0.0	0.0	0.0	0.0
10/24/2021	0.0	0.0	0.0	0.0
10/25/2021	0.0	0.0	0.0	0.0
10/26/2021	0.0	0.0	0.0	0.0
10/27/2021	0.0	0.0	0.0	0.0
10/28/2021	0.0	0.0	0.0	0.0
10/29/2021	0.0	0.0	0.0	0.0
10/30/2021	0.0	0.0	0.0	0.0
10/31/2021	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	62.3 *	13.0 *	0.0 *	0.0 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	50.5	11.5	0.0	0.0
Oct 2021 - Oct 2021	62.3	13.0	0.0	0.0
QTD:	62.3 *	13.0 *	0.0 *	0.0 *
YTD 2021:	1,302.3 *	224.4 *	2,463.4 *	525.9 *

Monthly Summary By Day Report



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 09:11 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr	Unit CT1 NOX_SUSD, LbPerHr	Unit CT2 CO_SUSD, LbPerHr	Unit CT2 NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/01/2021	0.0	0.0	0.0	0.0
11/02/2021	0.0	0.0	0.0	0.0
11/03/2021	0.0	0.0	0.0	0.0
11/04/2021	0.0	0.0	0.0	0.0
11/05/2021	0.0	0.0	0.0	0.0
11/06/2021	0.0	0.0	0.0	0.0
11/07/2021	0.0	0.0	0.0	0.0
11/08/2021	0.0	0.0	0.0	0.0
11/09/2021	0.0	0.0	0.0	0.0
11/10/2021	0.0	0.0	0.0	0.0
11/11/2021	0.0	0.0	0.0	0.0
11/12/2021	0.0	0.0	0.0	0.0
11/13/2021	0.0	0.0	0.0	0.0
11/14/2021	0.0	0.0	0.0	0.0
11/15/2021	0.0	0.0	0.0	0.0
11/16/2021	0.0	0.0	0.0	0.0
11/17/2021	0.0	0.0	0.0	0.0
11/18/2021	0.0	0.0	0.0	0.0
11/19/2021	57.3	6.5	0.0	0.0
11/20/2021	0.0	0.0	0.0	0.0
11/21/2021	0.0	0.0	0.0	0.0
11/22/2021	0.0	0.0	0.0	0.0
11/23/2021	0.0	0.0	0.0	0.0
11/24/2021	0.0	0.0	0.0	0.0
11/25/2021	0.0	0.0	0.0	0.0
11/26/2021	0.0	0.0	0.0	0.0
11/27/2021	0.0	0.0	0.0	0.0
11/28/2021	0.0	0.0	0.0	0.0
11/29/2021	0.0	0.0	0.0	0.0
11/30/2021	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	57.3 *	6.5 *	0.0 *	0.0 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	57.3	6.5	0.0	0.0
Oct 2021 - Nov 2021	119.6	19.5	0.0	0.0
QTD:	119.6 *	19.5 *	0.0 *	0.0 *
YTD 2021:	1,359.6 *	230.9 *	2,463.4 *	525.9 *

Monthly Summary By Day Report



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 09:11 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr	Unit CT1 NOX_SUSD, LbPerHr	Unit CT2 CO_SUSD, LbPerHr	Unit CT2 NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/01/2021	0.0	0.0	0.0	0.0
12/02/2021	0.0	0.0	0.0	0.0
12/03/2021	0.0	0.0	0.0	0.0
12/04/2021	0.0	0.0	0.0	0.0
12/05/2021	0.0	0.0	0.0	0.0
12/06/2021	0.0	0.0	0.0	0.0
12/07/2021	0.0	0.0	0.0	0.0
12/08/2021	0.0	0.0	0.0	0.0
12/09/2021	0.0	0.0	0.0	0.0
12/10/2021	0.0	0.0	0.0	0.0
12/11/2021	0.0	0.0	0.0	0.0
12/12/2021	0.0	0.0	0.0	0.0
12/13/2021	0.0	0.0	0.0	0.0
12/14/2021	0.0	0.0	0.0	0.0
12/15/2021	0.0	0.0	0.0	0.0
12/16/2021	0.0	0.0	0.0	0.0
12/17/2021	0.0	0.0	0.0	0.0
12/18/2021	0.0	0.0	0.0	0.0
12/19/2021	0.0	0.0	0.0	0.0
12/20/2021	0.0	0.0	0.0	0.0
12/21/2021	0.0	0.0	0.0	0.0
12/22/2021	0.0	0.0	0.0	0.0
12/23/2021	0.0	0.0	0.0	0.0
12/24/2021	0.0	0.0	0.0	0.0
12/25/2021	0.0	0.0	0.0	0.0
12/26/2021	0.0	0.0	0.0	0.0
12/27/2021	0.0	0.0	0.0	0.0
12/28/2021	0.0	0.0	0.0	0.0
12/29/2021	0.0	0.0	0.0	0.0
12/30/2021	0.0	0.0	0.0	0.0
12/31/2021	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	0.0 *	0.0 *	0.0 *	0.0 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	0.0	0.0	0.0	0.0
Oct 2021 - Dec 2021	119.6	19.5	0.0	0.0
QTD:	119.6 *	19.5 *	0.0 *	0.0 *
YTD 2021:	1,359.6 *	230.9 *	2,463.4 *	525.9 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:12 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
10/01/2021	31.14	95.43	10.69	21.43	35.67
10/02/2021	31.78	97.53	10.92	21.89	36.49
10/03/2021	34.65	95.47	10.47	20.87	34.84
10/04/2021	42.63	120.31	13.02	26.07	43.46
10/05/2021	27.06	91.83	10.30	20.63	34.39
10/06/2021	28.47	98.15	10.75	21.54	35.87
10/07/2021	24.82	95.33	10.40	20.78	34.59
10/08/2021	22.44	90.56	9.84	19.69	32.78
10/09/2021	19.16	83.76	9.05	18.14	30.18
10/10/2021	20.10	83.78	9.06	18.15	30.18
10/11/2021	35.42	115.46	12.41	24.80	41.36
10/12/2021	32.76	113.00	12.21	24.46	40.75
10/13/2021	35.65	115.97	12.52	25.08	41.77
10/14/2021	43.28	95.07	9.98	19.96	33.28
10/15/2021	41.50	67.51	7.22	14.53	24.27
10/16/2021	39.83	68.11	7.32	14.70	24.53
10/17/2021	39.39	68.86	7.44	14.91	24.88
10/18/2021	40.80	63.27	6.79	13.74	22.82
10/19/2021	37.83	60.82	6.59	13.21	22.03
10/20/2021	70.65	59.18	5.39	10.79	18.03
10/21/2021	32.60	107.48	11.65	23.38	38.93
10/22/2021	24.50	92.09	9.95	19.95	33.24
10/23/2021	28.55	99.92	10.73	21.54	35.88
10/24/2021	28.76	103.19	11.05	22.11	36.82
10/25/2021	25.98	96.04	10.37	20.67	34.51
10/26/2021	22.52	89.10	9.55	19.08	31.81
10/27/2021	22.68	92.98	9.96	19.87	33.15
10/28/2021	24.69	92.24	9.96	19.94	33.22
10/29/2021	27.29	92.31	10.00	20.00	33.30
10/30/2021	17.56	79.86	8.59	17.24	28.66
10/31/2021	16.39	78.68	8.39	16.85	28.06
Monthly Avg/Sum*:	970.88 *	2,803.29 *	302.57 *	606.00 *	1,009.75 *
Daily Min:	16.39	59.18	5.39	10.79	18.03
Daily Max:	70.65	120.31	13.02	26.07	43.46
Oct 2021 - Oct 2021	970.88	2,803.29	302.57	606.00	1,009.75
QTD:	970.88 *	2,803.29 *	302.57 *	606.00 *	1,009.75 *
YTD 2021:	9,666.48 *	18,740.02 *	1,944.32 *	3,891.10 *	6,487.29 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:12 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
11/01/2021	28.41	99.20	10.77	21.49	35.84
11/02/2021	23.49	93.52	10.04	20.10	33.48
11/03/2021	27.27	98.14	10.55	21.10	35.20
11/04/2021	18.58	82.26	9.18	18.39	30.60
11/05/2021	23.32	91.25	9.83	19.78	32.95
11/06/2021	23.80	93.67	10.06	20.15	33.57
11/07/2021	18.76	81.39	9.16	18.28	30.51
11/08/2021	32.51	99.29	10.91	21.84	36.41
11/09/2021	20.76	89.36	9.60	19.14	31.91
11/10/2021	17.13	82.62	8.88	17.66	29.45
11/11/2021	33.97	92.96	10.08	20.18	33.60
11/12/2021	16.91	79.41	8.54	17.03	28.36
11/13/2021	26.38	94.87	10.31	20.61	34.33
11/14/2021	15.50	79.31	8.45	16.77	28.00
11/15/2021	20.13	82.35	8.90	17.84	29.67
11/16/2021	25.97	93.14	10.22	20.51	34.10
11/17/2021	30.31	91.61	10.59	21.22	35.34
11/18/2021	28.17	86.86	10.39	20.80	34.59
11/19/2021	79.61	67.97	8.00	16.01	26.64
11/20/2021	18.53	73.79	9.04	18.14	30.20
11/21/2021	28.32	83.94	10.32	20.62	34.40
11/22/2021	26.92	83.63	10.24	20.51	34.16
11/23/2021	17.37	71.45	8.63	17.31	28.84
11/24/2021	18.86	81.07	8.86	17.77	29.57
11/25/2021	21.62	80.43	8.75	17.56	29.23
11/26/2021	22.63	79.33	8.70	17.28	28.87
11/27/2021	22.88	82.60	9.02	18.05	30.05
11/28/2021	22.16	78.92	8.68	17.36	28.92
11/29/2021	27.54	88.61	9.58	19.12	31.89
11/30/2021	31.88	101.30	11.52	23.02	38.41
Monthly Avg/Sum*:	769.69 *	2,584.25 *	287.80 *	575.64 *	959.09 *
Daily Min:	15.50	67.97	8.00	16.01	26.64
Daily Max:	79.61	101.30	11.52	23.02	38.41
Oct 2021 - Nov 2021	1,740.57	5,387.54	590.37	1,181.64	1,968.84
QTD:	1,740.57 *	5,387.54 *	590.37 *	1,181.64 *	1,968.84 *
YTD 2021:	10,436.17 *	21,324.27 *	2,232.12 *	4,466.74 *	7,446.38 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:12 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
12/01/2021	27.64	87.64	9.68	19.36	32.27
12/02/2021	45.56	102.79	11.60	23.18	38.64
12/03/2021	40.38	104.30	11.24	22.49	37.45
12/04/2021	39.54	94.06	10.90	21.80	36.32
12/05/2021	31.56	94.48	10.98	22.01	36.62
12/06/2021	47.16	120.73	13.04	26.12	43.50
12/07/2021	45.31	117.03	12.86	25.72	42.85
12/08/2021	32.93	99.40	10.64	21.30	35.55
12/09/2021	27.55	90.20	9.76	19.53	32.53
12/10/2021	33.18	104.62	11.22	22.43	37.41
12/11/2021	28.48	95.52	10.25	20.54	34.20
12/12/2021	29.29	94.92	10.29	20.63	34.32
12/13/2021	39.59	112.51	12.17	24.32	40.56
12/14/2021	27.99	93.84	10.08	20.17	33.56
12/15/2021	29.09	103.71	11.26	22.56	37.57
12/16/2021	52.58	119.63	13.11	26.25	43.77
12/17/2021	50.49	109.96	11.94	23.87	39.86
12/18/2021	49.72	108.92	12.07	24.19	40.30
12/19/2021	45.78	101.63	12.00	23.99	40.01
12/20/2021	45.18	121.48	13.79	27.62	46.05
12/21/2021	57.28	131.55	14.32	28.59	47.65
12/22/2021	50.49	110.20	11.96	24.02	39.94
12/23/2021	20.42	80.10	8.80	17.64	29.37
12/24/2021	19.18	79.17	8.65	17.31	28.84
12/25/2021	19.43	80.13	8.66	17.41	28.96
12/26/2021	25.14	87.08	9.49	19.04	31.70
12/27/2021	48.45	116.39	12.51	25.06	41.73
12/28/2021	26.27	91.78	9.98	19.98	33.30
12/29/2021	25.32	90.79	9.98	20.01	33.32
12/30/2021	50.85	105.13	11.55	23.22	38.63
12/31/2021	25.48	86.45	9.70	19.49	32.39
Monthly Avg/Sum*:	1,137.31 *	3,136.14 *	344.48 *	689.85 *	1,149.17 *
Daily Min:	19.18	79.17	8.65	17.31	28.84
Daily Max:	57.28	131.55	14.32	28.59	47.65
Oct 2021 - Dec 2021	2,877.88	8,523.68	934.85	1,871.49	3,118.01
QTD:	2,877.88 *	8,523.68 *	934.85 *	1,871.49 *	3,118.01 *
YTD 2021:	11,573.48 *	24,460.41 *	2,576.60 *	5,156.59 *	8,595.55 *

Startup / Shutdown Events

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 09:13 **Location:** Roseville, CA

Unit offline

Tag Name: CT1_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
10/14/2021 22:00	10/20/2021 21:00	144
11/19/2021 01:00	11/19/2021 06:00	6

Startup / Shutdown Events

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:13 Location: Roseville, CA

Operating Time Summary

Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	150.00 Hour(s)
Offline Percentage:	6.79 %
Total Online:	2,058.00 Hour(s)
Online Percentage:	93.21 %

Startup / Shutdown Events

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 09:13 **Location:** Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	10/14/2021 21:00	10/14/2021 21:13	Shutdown	14
2	10/20/2021 22:49	10/20/2021 23:52	cold Startup	64
3	11/19/2021 00:10	11/19/2021 00:17	Shutdown	8
4	11/19/2021 07:55	11/19/2021 08:39	cold Startup	45

Startup / Shutdown Events

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 09:13 **Location:** Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	2	109	0.09
Warm Startup	0		0.00
Shutdown	2	22	0.02
Total Process Events:	4	131	0.11

Total Report Time:	2,207.98 Hour(s)
Total Operating Time:	2,054.80 Hour(s)
Total Startup Time:	109 Minute(s)
Total Shutdown Time:	22 Minute(s)
Total Startup/Shutdown Time:	131 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	0.11 %

Startup / Shutdown Events

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 09:15 **Location:** Roseville, CA

No source downtime records found.

Startup / Shutdown Events

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 09:15 **Location:** Roseville, CA

No startup/shutdown events found.

CT1 SUSD EVENT 1

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/14/21 20:55	412112.5			0.6			1.66			0.62			2.64			0		
10/14/21 20:56	412728.6			0.7			1.54			0.7			2.46			0		
10/14/21 20:57	411650.4			0.7			1.45			0.7			2.31			0		
10/14/21 20:58	404641.9			0.7			1.36			0.69			2.13			0		
10/14/21 20:59	401869.3			0.7			1.36			0.69			2.11			0		
10/14/21 21:00	399019.8			0.7			1.36			0.68			2.1			1		
10/14/21 21:01	384078.7			0.7			1.36			0.65			2.02			1		
10/14/21 21:02	365286.8			0.7			1.43			0.61			2.02			1		
10/14/21 21:03	344723.5			0.8			1.85			0.64			2.46			1		
10/14/21 21:04	320848.5			0.8			2.29			0.6			2.84			1		
10/14/21 21:05	298051.8			0.9			2.29			0.62			2.64			1		
10/14/21 21:06	275948.2			0.8			2.32			0.52			2.48			1		
10/14/21 21:07	253998.7			0.7			2.67			0.44			2.62			1		
10/14/21 21:08	230585.8			0.6			4.84			0.31			4.31			1		
10/14/21 21:09	210330.6			0.4			8.9			0.2			7.23			1		
10/14/21 21:10	185377.4			1.6			21.52			0.71			15.42			1		
10/14/21 21:11	164198			1.8			24.65			0.71			15.64			1		
10/14/21 21:12	147716.6			653.7			27.44			226.82			15.67			1		
10/14/21 21:13	94036.5			1695.2			26.97			374.14			9.8			1		
10/14/21 21:14	17713.7			0			31.32			97.38			2.15			0		
10/14/21 21:15	17559.6			0			0.5			0			0			0		
10/14/21 21:16	18021.7			0			0.2			0			0			0		
10/14/21 21:17	18560.8			0			0.2			0			0			0		
10/14/21 21:18	18868.9			0			0.1			0			0			0		

CT1 SUSD EVENT 2

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/20/21 22:44	0			0			0			0			0			0		
10/20/21 22:45	0			0			0			0			0			0		
10/20/21 22:46	0			0			0			0			0			0		
10/20/21 22:47	0			0			0			0			0			0		
10/20/21 22:48	4543.9			0			0			0			0			0		
10/20/21 22:49	11629.4			0.1			0			0			0			1		
10/20/21 22:50	25646.3			0.1			0			0			0			1		
10/20/21 22:51	37352.7			82.6			29.5			7.25			4.26			1		
10/20/21 22:52	49367.2			1219			12.25			141.35			2.34			1		
10/20/21 22:53	61458.7			996			16.59			143.8			3.94			1		
10/20/21 22:54	80712.7			579.8			21.43			109.92			6.69			1		
10/20/21 22:55	124457.8			400.6			24.72			117.12			11.9			1		
10/20/21 22:56	142864.6			269.7			33.04			90.51			18.25			1		
10/20/21 22:57	148794.9			455.7			39.73			159.22			22.85			1		
10/20/21 22:58	160655.3			1927.8			30.61			727.14			19			1		
10/20/21 22:59	178908.1			1836.1			30.71			771.46			21.24			1		
10/20/21 23:00	201242.7			1211.7			37.42			572.56			29.1			1		
10/20/21 23:01	222807.2			256.4			43.91			134.15			37.8			1		
10/20/21 23:02	244140.6			27			49.04			15.5			46.27			1		
10/20/21 23:03	267091.4			3.5			73.31			2.19			75.68			1		
10/20/21 23:04	277411.5			2.5			60.9			1.63			65.29			1		
10/20/21 23:05	288347.8			2.3			28.95			1.56			32.26			1		
10/20/21 23:06	300285.3			2.1			16.36			1.51			18.98			1		
10/20/21 23:07	299823.2			2			11.97			1.4			13.87			1		
10/20/21 23:08	300439.3			1.9			9.63			1.35			11.18			1		
10/20/21 23:09	300054.2			1.8			8.76			1.28			10.16			1		
10/20/21 23:10	302980.8			1.7			7.66			1.19			8.97			1		
10/20/21 23:11	320001.4			1.5			6.69			1.12			8.28			1		
10/20/21 23:12	324853.4			1.4			6.16			1.06			7.73			1		
10/20/21 23:13	325469.5			1.3			6.07			0.98			7.64			1		
10/20/21 23:14	325392.5			1.3			5.9			0.98			7.42			1		
10/20/21 23:15	319308.2			1.3			5.81			0.98			7.17			1		
10/20/21 23:16	305522.4			1.2			5.64			0.87			6.66			1		
10/20/21 23:17	314841.3			1.2			4.93			0.91			6			1		
10/20/21 23:18	316997.8			1.1			5.11			0.85			6.26			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/20/21 23:19	318923.2			1.1			5.46			0.79			6.73			1		
10/20/21 23:20	319077.2			1.1			5.46			0.79			6.73			1		
10/20/21 23:21	317305.8			1			5.47			0.78			6.7			1		
10/20/21 23:22	315842.5			1			5.55			0.77			6.78			1		
10/20/21 23:23	315765.5			1.1			5.64			0.78			6.88			1		
10/20/21 23:24	315765.5			1			5.55			0.72			6.77			1		
10/20/21 23:25	315149.3			1			5.55			0.72			6.76			1		
10/20/21 23:26	320540.5			1			5.64			0.73			6.98			1		
10/20/21 23:27	318230			1.1			5.64			0.79			6.93			1		
10/20/21 23:28	307216.7			1			5.99			0.75			7.11			1		
10/20/21 23:29	309219.1			1.1			5.37			0.77			6.42			1		
10/20/21 23:30	307601.8			1.1			5.27			0.77			6.27			1		
10/20/21 23:31	298051.8			1			5.55			0.68			6.39			1		
10/20/21 23:32	292506.7			1			5.27			0.68			5.96			1		
10/20/21 23:33	288039.8			1			5.36			0.68			5.96			1		
10/20/21 23:34	284805.1			0.9			5.54			0.61			6.09			1		
10/20/21 23:35	284497			0.8			6.08			0.55			6.69			1		
10/20/21 23:36	284574			0.8			6.27			0.55			6.89			1		
10/20/21 23:37	284497			0.7			6.36			0.49			6.99			1		
10/20/21 23:38	284574			0.7			6.36			0.49			6.99			1		
10/20/21 23:39	284574			0.7			5.53			0.49			6.08			1		
10/20/21 23:40	284420			0.7			3.78			0.49			4.16			1		
10/20/21 23:41	284343			0.7			3.5			0.49			3.85			1		
10/20/21 23:42	284266			0.7			3.32			0.49			3.65			1		
10/20/21 23:43	285344.2			0.7			3.04			0.49			3.35			1		
10/20/21 23:44	286576.4			0.7			2.95			0.5			3.27			1		
10/20/21 23:45	284651			0.7			2.81			0.49			3.1			1		
10/20/21 23:46	283726.8			0.7			2.63			0.48			2.89			1		
10/20/21 23:47	283418.8			0.7			2.49			0.49			2.73			1		
10/20/21 23:48	283649.8			0.7			2.3			0.49			2.53			1		
10/20/21 23:49	283803.8			0.7			2.12			0.49			2.33			1		
10/20/21 23:50	283572.8			0.7			2.03			0.49			2.22			1		
10/20/21 23:51	283880.9			0.7			1.94			0.49			2.12			1		
10/20/21 23:52	283187.7			0.7			1.94			0.49			2.12			1		
10/20/21 23:53	283341.8			0.7			1.84			0.49			2.02			0		
10/20/21 23:54	281108.3			0.7			1.84			0.49			2			0		
10/20/21 23:55	280800.3			0.7			1.75			0.49			1.9			0		
10/20/21 23:56	280800.3			0.7			1.75			0.49			1.9			0		

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/20/21 23:57	280184.1			0.7			1.75			0.49			1.9			0		

CT1 SUSD EVENT 3

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/19/21 0:05	263548.7			0.5			1.84			0.3			1.87			0		
11/19/21 0:06	263240.6			0.5			1.84			0.3			1.87			0		
11/19/21 0:07	263394.6			0.5			1.84			0.3			1.87			0		
11/19/21 0:08	263779.7			0.5			1.84			0.3			1.87			0		
11/19/21 0:09	266013.2			0.5			1.74			0.3			1.79			0		
11/19/21 0:10	263856.7			0.5			1.74			0.3			1.77			1		
11/19/21 0:11	242754.3			0.5			1.71			0.27			1.6			1		
11/19/21 0:12	221806			0.5			4.7			0.26			4.02			1		
11/19/21 0:13	196082.7			0.5			10.05			0.25			7.6			1		
11/19/21 0:14	173440			7.1			11.31			2.9			7.57			1		
11/19/21 0:15	155880.3			513.7			14.47	X		187.67			8.7	X		1		
11/19/21 0:16	137165.5			1491.1			16.11			479.31			8.52			1		
11/19/21 0:17	35735.4			1947			18.44			163			2.54			1		
11/19/21 0:18	17251.6			0			24.91			149.24			1.66			0		
11/19/21 0:19	17405.6			0			0.1			0			0			0		
11/19/21 0:20	17713.7			0			0.1			0			0			0		
11/19/21 0:21	17790.7			0			0.1			0			0			0		
11/19/21 0:22	18021.7			0			0.1			0			0			0		

CT1 SUSD EVENT 4

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/19/21 7:50	0			0			0			0			0			0		
11/19/21 7:51	0			0			0			0			0			0		
11/19/21 7:52	0			0			0			0			0			0		
11/19/21 7:53	0			0			0			0			0			0		
11/19/21 7:54	0			0			0			0			0			0		
11/19/21 7:55	0			0.1			0			0			0			1		
11/19/21 7:56	11398.4			0.1			0			0			0			1		
11/19/21 7:57	27340.7			1.3			0.1			0			0			1		
11/19/21 7:58	40895.5			1246.5			6.44			119.42			1.01			1		
11/19/21 7:59	54296.3			1080.8			7.38			137.66			1.55			1		
11/19/21 8:00	68775.3			618.6			10.25			99.69			2.72			1		
11/19/21 8:01	104048.6			422.3			12.92			102.94			5.18			1		
11/19/21 8:02	140169.1			300.6			19.24			98.79			10.4			1		
11/19/21 8:03	151952.5			208.3			15.26			74.19			8.94			1		
11/19/21 8:04	167201.7			1603.3			26			628.43			16.77			1		
11/19/21 8:05	186070.6			1733.4			27.48			755.86			19.72			1		
11/19/21 8:06	207481			711.2			28.17			345.8			22.54			1		
11/19/21 8:07	229122.5			112.4			28.98			60.34			25.61			1		
11/19/21 8:08	248761.6			9.8			29.03			5.71			27.86			1		
11/19/21 8:09	275024			2			29.07			1.31			30.83			1		
11/19/21 8:10	299438.1			1.6			14.12			1.15			16.31			1		
11/19/21 8:11	318692.1			1.5			9.48			1.14			11.65			1		
11/19/21 8:12	326239.7			1.5			7.25			1.16			9.12			1		
11/19/21 8:13	326701.8			1.6			7			1.23			8.82			1		
11/19/21 8:14	326547.7			1.5			6.91			1.16			8.71			1		
11/19/21 8:15	324314.3			1.5			6.41			1.11			8.02			1		
11/19/21 8:16	323159			1.3			6.16			0.97			7.67			1		
11/19/21 8:17	322003.8			1.2			5.73			0.9			7.11			1		
11/19/21 8:18	321695.7			1.2			5.64			0.9			7			1		
11/19/21 8:19	321387.7			1.1			5.64			0.85			6.99			1		
11/19/21 8:20	321387.7			1			5.47			0.78			6.78			1		
11/19/21 8:21	320540.5			1			5.47			0.78			6.76			1		
11/19/21 8:22	320001.4			1			5.47			0.72			6.75			1		
11/19/21 8:23	320848.5			1			5.47			0.72			6.76			1		
11/19/21 8:24	322619.9			1			5.47			0.72			6.8			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/19/21 8:25	322696.9			1			5.55			0.72			6.91			1		
11/19/21 8:26	322851			1			5.64			0.72			7.02			1		
11/19/21 8:27	322388.9			1			5.73			0.72			7.12			1		
11/19/21 8:28	321310.6			1			5.29			0.72			6.56			1		
11/19/21 8:29	319462.3			1			3.56			0.71			4.38			1		
11/19/21 8:30	317382.8			1			2.99			0.72			3.67			1		
11/19/21 8:31	316689.7			0.9			2.91			0.65			3.55			1		
11/19/21 8:32	316150.6			0.9			2.82			0.65			3.44			1		
11/19/21 8:33	315688.5			0.9			2.73			0.65			3.32			1		
11/19/21 8:34	317305.8			0.9			2.64			0.65			3.23			1		
11/19/21 8:35	308603			0.9			2.55			0.64			3.04			1		
11/19/21 8:36	300670.3			0.9			2.29			0.62			2.66			1		
11/19/21 8:37	296665.5			0.9			1.79			0.62			2.05			1		
11/19/21 8:38	291043.3			0.9			1.7			0.61			1.91			1		
11/19/21 8:39	285652.3			0.8			1.72			0.55			1.9			1		
11/19/21 8:40	281493.4			0.7			1.72			0.48			1.87			0		
11/19/21 8:41	275563.2			0.7			1.84			0.48			1.96			0		
11/19/21 8:42	271327.3			0.7			2.03			0.47			2.12			0		
11/19/21 8:43	267168.4			0.6			2.21			0.4			2.28			0		
11/19/21 8:44	266706.3			0.7			2.53			0.41			2.6			0		

AQ-32

AQ-32 The Project owner shall maintain hourly records of NO_x and CO emission concentrations (ppmv @ 15% O₂), and hourly, daily, and quarterly records of NO_x and CO emissions. Ongoing compliance with the CO emission limits during normal operation shall be deemed compliance with the VOC emission limits during normal operation.

Verification: The project owner shall submit to the CPM all concentration, hourly, daily, and quarter NO_x and CO emissions as part of the Quarterly Air Quality Report required by Condition of Certification AQ-SC6

AQ32 HOURLY NOX CO

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/01/21 0:00	0.7			1.3			14.5		1	0.9			1.3			14.5		1
10/01/21 1:00	0.6			1.6			14.5		1	0.8			1.6			14.6		1
10/01/21 2:00	0.6			1.5			14.6		1	0.7			1.5			14.7		1
10/01/21 3:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
10/01/21 4:00	0.7			1.2			14.5		1	0.7			1			14.5		1
10/01/21 5:00	0.8			1.6			14.3		1	0.8			1.5			14.4		1
10/01/21 6:00	0.7			1.6			14.4		1	0.8			1.4			14.5		1
10/01/21 7:00	0.7			1.3			14.5		1	0.8			1.1			14.5		1
10/01/21 8:00	0.7			1.5			14.6		1	0.7			1.5			14.7		1
10/01/21 9:00	0.5			1.5			14.7		1	0.6			1.5			14.8		1
10/01/21 10:00	0.6			1.5			14.7		1	0.7			1.5			14.7		1
10/01/21 11:00	0.6			1.5			14.5		1	0.8			1.5			14.6		1
10/01/21 12:00	0.6			1.3			14.5		1	0.8			1.4			14.5		1
10/01/21 13:00	1.1			1.5			13.9		1	1.2			1.5			14		1
10/01/21 14:00	1			1.5			14.3		1	1.2			1.5			14.4		1
10/01/21 15:00	0.6			1.2			14.5		1	0.8			1.2			14.6		1
10/01/21 16:00	0.6			1.3			14.4		1	0.8			1.4			14.5		1
10/01/21 17:00	0.6			1.5			14.4		1	0.8			1.5			14.5		1
10/01/21 18:00	0.7			1.5			14.4		1	0.8			1.5			14.4		1
10/01/21 19:00	0.7			1.5			14.3		1	0.9			1.5			14.3		1
10/01/21 20:00	0.8			1.5			14.4		1	1			1.5			14.5		1
10/01/21 21:00	0.8			1.5			14.3		1	0.9			1.5			14.4		1
10/01/21 22:00	0.8			1.6			14.4		1	0.9			1.6			14.4		1
10/01/21 23:00	0.7			1.5			14.6		1	0.8			1.5			14.7		1
10/02/21 0:00	0.7			1.5			14.4		1	0.9			1.5			14.4		1
10/02/21 1:00	0.7			1.5			14.4		1	0.9			1.4			14.5		1
10/02/21 2:00	0.7			1.4			14.4		1	0.9			1.4			14.4		1
10/02/21 3:00	0.7			1.5			14.4		1	0.9			1.4			14.4		1
10/02/21 4:00	0.7			1.1			14.3		1	0.9			1.1			14.4		1
10/02/21 5:00	0.7			1.4			14.4		1	0.8			1.2			14.5		1
10/02/21 6:00	0.8			1.5			14.3		1	1			1.4			14.4		1
10/02/21 7:00	0.8			1.7			14.4		1	1			1.7			14.4		1
10/02/21 8:00	0.6			1.5			14.7		1	0.7			1.5			14.8		1
10/02/21 9:00	0.5			1.5			14.8		1	0.7			1.5			14.8		1
10/02/21 10:00	0.5			1.5			14.8		1	0.6			1.5			14.8		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/02/21 11:00	0.6			1.5			14.7		1	0.7			1.5			14.8		1
10/02/21 12:00	0.6			1.5			14.7		1	0.7			1.5			14.8		1
10/02/21 13:00	0.6			1.3			14.5		1	0.8			1.4			14.5		1
10/02/21 14:00	0.7			1.4			14.4		1	0.8			1.5			14.4		1
10/02/21 15:00	0.6			1.4			14.5		1	0.8			1.4			14.5		1
10/02/21 16:00	0.6			1.4			14.4		1	0.8			1.5			14.5		1
10/02/21 17:00	0.6			1.5			14.5		1	0.8			1.5			14.5		1
10/02/21 18:00	0.7			1.5			14.5		1	0.8			1.5			14.5		1
10/02/21 19:00	0.7			1.5			14.5		1	0.9			1.5			14.5		1
10/02/21 20:00	0.8			1.5			14.4		1	0.9			1.5			14.5		1
10/02/21 21:00	0.8			1.5			14.4		1	0.9			1.5			14.4		1
10/02/21 22:00	0.8			1.5			14.3		1	1			1.5			14.4		1
10/02/21 23:00	0.8			1.5			14.3		1	1			1.5			14.4		1
10/03/21 0:00	0.7			1.6			14.4		1	0.9			1.5			14.5		1
10/03/21 1:00	0.6			1.5			14.6		1	0.8			1.5			14.7		1
10/03/21 2:00	0.7			1.5			14.6		1	0.8			1.5			14.7		1
10/03/21 3:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
10/03/21 4:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
10/03/21 5:00	0.7			1.5			14.6		1	0.7			1.5			14.6		1
10/03/21 6:00	0.7			1.5			14.5		1	0.8			1.5			14.6		1
10/03/21 7:00	0.7			1.6			14.7		1	0.8			1.5			14.7		1
10/03/21 8:00	0.6			1.4			14.7		1	0.8			1.5			14.7		1
10/03/21 9:00	0.6			1.5			14.7		1	0.7			1.5			14.8		1
10/03/21 10:00	0.5			1.5			14.8		1	0.6			1.5			14.8		1
10/03/21 11:00	0.5			1.4			14.8		1	0.7			1.5			14.8		1
10/03/21 12:00	0.6			1.6			14.7		1	0.7			1.5			14.8		1
10/03/21 13:00	0.6			1.4			14.6		1	0.8			1.4			14.7		1
10/03/21 14:00	0.7			1.4			14.5		1	0.8			1.3			14.6		1
10/03/21 15:00	0.6			1.4			14.5		1	0.8			1.4			14.5		1
10/03/21 16:00	0.7			1.5			13.9		1	0.8			1.5			13.9		1
10/03/21 17:00	1.2			1.5			14		1	1.1			1.5			14		1
10/03/21 18:00	1.3			1.5			14		1	1.2			1.5			14.1		1
10/03/21 19:00	1.4			1.5			14.1		1	1.3			1.5			14.1		1
10/03/21 20:00	1.4			1.5			14		1	1.3			1.5			14		1
10/03/21 21:00	1.4			1.5			14		1	1.3			1.5			14		1
10/03/21 22:00	1.2			1.6			14.2		1	1.2			1.6			14.3		1
10/03/21 23:00	0.8			1.4			14.5		1	0.9			1.3			14.5		1
10/04/21 0:00	0.7			1.5			14.5		1	0.8			1.5			14.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/04/21 1:00	0.7			1.3			14.4		1	0.9			1.3			14.5		1
10/04/21 2:00	0.7			1.5			14.5		1	0.9			1.5			14.6		1
10/04/21 3:00	0.7			1.4			14.4		1	0.9			1.4			14.4		1
10/04/21 4:00	0.7			1.5			14.3		1	0.9			1.5			14.3		1
10/04/21 5:00	0.8			1.5			14.3		1	0.9			1.5			14.4		1
10/04/21 6:00	0.7			1.5			14.3		1	0.9			1.5			14.4		1
10/04/21 7:00	0.8			1.5			14.3		1	0.9			1.5			14.4		1
10/04/21 8:00	0.7			1.5			14.4		1	0.9			1.5			14.4		1
10/04/21 9:00	0.8			1.5			14.3		1	0.9			1.5			14.3		1
10/04/21 10:00	0.7			1.5			14.4		1	0.9			1.5			14.5		1
10/04/21 11:00	0.6			1.5			14.4		1	0.8			1.5			14.5		1
10/04/21 12:00	0.6			1.5			14.5		1	0.8			1.5			14.5		1
10/04/21 13:00	0.6			1.5			14.5		1	0.8			1.5			14.5		1
10/04/21 14:00	0.6			1.5			14.5		1	0.8			1.5			14.5		1
10/04/21 15:00	0.8			1.6			14.2		1	1.1			1.5			14.2		1
10/04/21 16:00	0.4			1.5			12.8		1	0.5			1.5			12.9		1
10/04/21 17:00	0.6			1.5			13.3		1	0.7			1.5			13.4		1
10/04/21 18:00	0.9			1.5			13.5		1	1			1.5			13.6		1
10/04/21 19:00	1.2			1.5			13.8		1	1.2			1.5			13.8		1
10/04/21 20:00	1.5			1.5			14		1	1.3			1.5			14		1
10/04/21 21:00	1.5			1.5			14		1	1.4			1.5			14		1
10/04/21 22:00	1.1			1.6			14.3		1	1.2			1.6			14.3		1
10/04/21 23:00	0.8			1.5			14.4		1	0.9			1.4			14.5		1
10/05/21 0:00	0.7			1.5			14.5		1	0.8			1.5			14.6		1
10/05/21 1:00	0.7			1.5			14.4		1	0.8			1.5			14.5		1
10/05/21 2:00	0.7			1.4			14.6		1	0.8			1.5			14.7		1
10/05/21 3:00	0.7			1.4			14.5		1	0.9			1.4			14.6		1
10/05/21 4:00	0.7			1.4			14.4		1	0.9			1.3			14.4		1
10/05/21 5:00	0.7			1.4			14.4		1	0.8			1.3			14.5		1
10/05/21 6:00	0.7			1.6			14.3		1	0.8			1.5			14.4		1
10/05/21 7:00	0.7			1.6			14.3		1	0.9			1.5			14.4		1
10/05/21 8:00	0.6			1.5			14.6		1	0.7			1.4			14.6		1
10/05/21 9:00	0.6			1.4			14.6		1	0.7			1.5			14.6		1
10/05/21 10:00	0.6			1.4			14.4		1	0.7			1.4			14.5		1
10/05/21 11:00	0.5			1.6			14.6		1	0.7			1.6			14.6		1
10/05/21 12:00	0.5			1.5			14.7		1	0.6			1.5			14.8		1
10/05/21 13:00	0.5			1.4			14.6		1	0.7			1.4			14.7		1
10/05/21 14:00	0.6			1.4			14.5		1	0.7			1.2			14.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/05/21 15:00	0.6			1.4			14.5		1	0.7			1.4			14.6		1
10/05/21 16:00	0.6			1.4			14.5		1	0.7			1.4			14.5		1
10/05/21 17:00	0.6			1.5			14.3		1	0.7			1.6			14.4		1
10/05/21 18:00	0.6			1.5			14.4		1	0.7			1.5			14.4		1
10/05/21 19:00	0.6			1.5			14.4		1	0.7			1.5			14.4		1
10/05/21 20:00	0.6			1.4			14.4		1	0.7			1.3			14.5		1
10/05/21 21:00	0.7			1.3			14.3		1	0.8			1.3			14.3		1
10/05/21 22:00	0.6			1.5			14.3		1	0.8			1.5			14.4		1
10/05/21 23:00	0.6			1.5			14.3		1	0.8			1.5			14.4		1
10/06/21 0:00	0.6			1.7			14.5		1	0.6			1.7			14.6		1
10/06/21 1:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
10/06/21 2:00	0.5			1.5			14.5		1	0.6			1.5			14.6		1
10/06/21 3:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
10/06/21 4:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
10/06/21 5:00	0.6			1.4			14.5		1	0.7			1.3			14.5		1
10/06/21 6:00	0.6			1.7			14.5		1	0.7			1.6			14.5		1
10/06/21 7:00	0.5			1.5			14.6		1	0.6			1.3			14.6		1
10/06/21 8:00	0.5			1.3			14.6		1	0.6			1.3			14.6		1
10/06/21 9:00	0.6			1.4			14.4		1	0.7			1.4			14.4		1
10/06/21 10:00	0.7			1.5			14.4		1	0.8			1.5			14.4		1
10/06/21 11:00	1.1			1.5			14.4		1	1.3			1.5			14.2		1
10/06/21 12:00	1.3			1.5			14.4		1	1.3			1.5			14.3		1
10/06/21 13:00	0.8			1.5			14.3		1	0.9			1.4			14.3		1
10/06/21 14:00	0.6			1.5			14.4		1	0.7			1.5			14.5		1
10/06/21 15:00	0.6			1.4			14.4		1	0.7			1.4			14.4		1
10/06/21 16:00	0.6			1.5			14.4		1	0.8			1.5			14.4		1
10/06/21 17:00	0.6			1.6			14.5		1	0.7			1.6			14.6		1
10/06/21 18:00	0.7			1.5			14.3		1	0.8			1.5			14.4		1
10/06/21 19:00	0.6			1.5			14.5		1	0.7			1.4			14.5		1
10/06/21 20:00	0.7			1.4			14.3		1	0.8			1.3			14.4		1
10/06/21 21:00	0.6			1.5			14.4		1	0.7			1.5			14.5		1
10/06/21 22:00	0.6			1.7			14.4		1	0.7			1.6			14.5		1
10/06/21 23:00	0.5			1.5			14.6		1	0.7			1.5			14.6		1
10/07/21 0:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
10/07/21 1:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
10/07/21 2:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
10/07/21 3:00	0.7			1.2			14.4		1	0.8			1.1			14.4		1
10/07/21 4:00	0.7			1.6			14.3		1	0.8			1.5			14.4		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/07/21 5:00	0.7			1.5			14.3		1	0.8			1.5			14.4		1
10/07/21 6:00	0.6			1.5			14.4		1	0.7			1.5			14.4		1
10/07/21 7:00	0.6			1.5			14.4		1	0.7			1.5			14.4		1
10/07/21 8:00	0.7			1.5			14.3		1	0.8			1.5			14.4		1
10/07/21 9:00	0.6			1.5			14.4		1	0.7			1.5			14.5		1
10/07/21 10:00	0.6			1.7			14.5		1	0.7			1.6			14.5		1
10/07/21 11:00	0.6			1.4			14.5		1	0.7			1.4			14.5		1
10/07/21 12:00	0.5			1.5			14.6		1	0.6			1.5			14.7		1
10/07/21 13:00	0.5			1.5			14.7		1	0.6			1.5			14.7		1
10/07/21 14:00	0.5			1.5			14.7		1	0.6			1.5			14.8		1
10/07/21 15:00	0.5			1.5			14.7		1	0.6			1.5			14.7		1
10/07/21 16:00	0.5			1.4			14.6		1	0.6			1.4			14.6		1
10/07/21 17:00	0.6			1.5			14.4		1	0.7			1.5			14.5		1
10/07/21 18:00	0.6			1.6			14.4		1	0.7			1.6			14.5		1
10/07/21 19:00	0.5			1.5			14.6		1	0.6			1.5			14.6		1
10/07/21 20:00	0.6			1.5			14.5		1	0.7			1.5			14.5		1
10/07/21 21:00	0.6			1.5			14.6		1	0.6			1.5			14.6		1
10/07/21 22:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
10/07/21 23:00	0.7			1.5			14.3		1	0.8			1.5			14.3		1
10/08/21 0:00	0.6			1.6			14.5		1	0.6			1.5			14.6		1
10/08/21 1:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
10/08/21 2:00	0.6			1.5			14.5		1	0.6			1.4			14.6		1
10/08/21 3:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
10/08/21 4:00	0.6			1.5			14.5		1	0.7			1.4			14.5		1
10/08/21 5:00	0.5			1.7			14.7		1	0.6			1.6			14.7		1
10/08/21 6:00	0.6			1.5			14.5		1	0.7			1.4			14.6		1
10/08/21 7:00	0.6			1.5			14.4		1	0.7			1.4			14.4		1
10/08/21 8:00	0.7			1.5			14.3		1	0.8			1.5			14.4		1
10/08/21 9:00	0.6			1.5			14.4		1	0.7			1.5			14.5		1
10/08/21 10:00	0.6			1.6			14.5		1	0.7			1.6			14.5		1
10/08/21 11:00	0.7			1.3			14.3		1	0.7			1.2			14.4		1
10/08/21 12:00	0.7			1.5			14.3		1	0.8			1.5			14.3		1
10/08/21 13:00	0.7			1.5			14.3		1	0.8			1.5			14.4		1
10/08/21 14:00	0.6			1.5			14.4		1	0.7			1.5			14.5		1
10/08/21 15:00	0.5			1.7			14.6		1	0.6			1.7			14.7		1
10/08/21 16:00	0.5			1.3			14.6		1	0.6			1.3			14.6		1
10/08/21 17:00	0.5			1.7			14.6		1	0.6			1.7			14.7		1
10/08/21 18:00	0.5			1.5			14.6		1	0.6			1.5			14.7		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/08/21 19:00	0.5			1.5			14.7		1	0.5			1.5			14.7		1
10/08/21 20:00	0.5			1.6			14.6		1	0.6			1.5			14.7		1
10/08/21 21:00	0.6			1.5			14.6		1	0.6			1.5			14.6		1
10/08/21 22:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
10/08/21 23:00	0.5			1.6			14.7		1	0.5			1.5			14.7		1
10/09/21 0:00	0.5			1.6			14.7		1	0.5			1.5			14.7		1
10/09/21 1:00	0.4			1.5			14.8		1	0.5			1.5			14.8		1
10/09/21 2:00	0.4			1.5			14.8		1	0.5			1.5			14.8		1
10/09/21 3:00	0.4			1.5			14.8		1	0.5			1.5			14.8		1
10/09/21 4:00	0.5			1.5			14.6		1	0.6			1.5			14.6		1
10/09/21 5:00	0.7			1.4			14.4		1	0.8			1.2			14.4		1
10/09/21 6:00	0.7			1.6			14.4		1	0.8			1.4			14.5		1
10/09/21 7:00	0.8			1.6			14.3		1	0.8			1.5			14.4		1
10/09/21 8:00	0.6			1.7			14.4		1	0.7			1.6			14.5		1
10/09/21 9:00	0.4			1.6			14.7		1	0.5			1.5			14.7		1
10/09/21 10:00	0.4			1.5			14.8		1	0.5			1.5			14.8		1
10/09/21 11:00	0.4			1.5			14.8		1	0.5			1.5			14.8		1
10/09/21 12:00	0.4			1.5			14.7		1	0.5			1.5			14.8		1
10/09/21 13:00	0.5			1.5			14.7		1	0.5			1.5			14.8		1
10/09/21 14:00	0.4			1.5			14.8		1	0.5			1.5			14.8		1
10/09/21 15:00	0.5			1.4			14.7		1	0.6			1.4			14.8		1
10/09/21 16:00	0.6			1.4			14.6		1	0.6			1.3			14.7		1
10/09/21 17:00	0.7			1.5			14.5		1	0.7			1.5			14.5		1
10/09/21 18:00	0.6			1.6			14.6		1	0.7			1.6			14.7		1
10/09/21 19:00	0.5			1.5			14.7		1	0.6			1.4			14.7		1
10/09/21 20:00	0.5			1.6			14.7		1	0.5			1.6			14.8		1
10/09/21 21:00	0.6			1.5			14.6		1	0.7			1.5			14.7		1
10/09/21 22:00	0.6			1.6			14.6		1	0.8			1.5			14.7		1
10/09/21 23:00	0.6			1.5			14.6		1	0.7			1.5			14.7		1
10/10/21 0:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
10/10/21 1:00	0.6			1.6			14.6		1	0.6			1.5			14.6		1
10/10/21 2:00	0.6			1.5			14.6		1	0.7			1.6			14.6		1
10/10/21 3:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
10/10/21 4:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
10/10/21 5:00	0.7			1.4			14.4		1	0.8			1.4			14.5		1
10/10/21 6:00	0.7			1.6			14.4		1	0.8			1.5			14.4		1
10/10/21 7:00	0.7			1.6			14.3		1	0.8			1.6			14.4		1
10/10/21 8:00	0.5			1.6			14.7		1	0.6			1.5			14.7		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/10/21 9:00	0.4			1.5			14.8		1	0.5			1.5			14.8		1
10/10/21 10:00	0.5			1.5			14.7		1	0.6			1.5			14.8		1
10/10/21 11:00	0.5			1.5			14.7		1	0.6			1.5			14.8		1
10/10/21 12:00	0.5			1.5			14.7		1	0.5			1.5			14.8		1
10/10/21 13:00	0.5			1.5			14.8		1	0.5			1.5			14.8		1
10/10/21 14:00	0.5			1.5			14.8		1	0.6			1.5			14.8		1
10/10/21 15:00	0.5			1.4			14.6		1	0.6			1.5			14.7		1
10/10/21 16:00	0.6			1.4			14.5		1	0.7			1.4			14.6		1
10/10/21 17:00	0.6			1.6			14.6		1	0.7			1.6			14.6		1
10/10/21 18:00	0.5			1.5			14.7		1	0.6			1.5			14.8		1
10/10/21 19:00	0.6			1.4			14.6		1	0.7			1.5			14.7		1
10/10/21 20:00	0.6			1.6			14.5		1	0.7			1.5			14.5		1
10/10/21 21:00	0.6			1.5			14.6		1	0.7			1.5			14.7		1
10/10/21 22:00	0.5			1.5			14.7		1	0.6			1.5			14.7		1
10/10/21 23:00	0.4			1.5			14.7		1	0.6			1.5			14.7		1
10/11/21 0:00	0.5			1.5			14.6		1	0.6			1.5			14.7		1
10/11/21 1:00	0.4			1.6			14.8		1	0.5			1.5			14.8		1
10/11/21 2:00	0.5			1.5			14.7		1	0.6			1.5			14.7		1
10/11/21 3:00	0.5			1.5			14.6		1	0.6			1.5			14.7		1
10/11/21 4:00	0.6			1.4			14.3		1	0.8			1.4			14.4		1
10/11/21 5:00	0.6			1.5			14.3		1	0.8			1.5			14.4		1
10/11/21 6:00	0.6			1.5			14.3		1	0.8			1.5			14.4		1
10/11/21 7:00	0.6			1.5			14.4		1	0.8			1.5			14.4		1
10/11/21 8:00	0.5			1.5			13.1		1	0.7			1.5			12.9		1
10/11/21 9:00	0.8			1.5			13.5		1	0.8			1.5			13.4		1
10/11/21 10:00	0.5			1.5			13		1	0.6			1.5			13.1		1
10/11/21 11:00	1.3			1.5			14.1		1	1.8			1.5			14.1		1
10/11/21 12:00	1			1.5			13.6		1	1.1			1.5			13.7		1
10/11/21 13:00	1			1.5			13.6		1	1			1.5			13.7		1
10/11/21 14:00	1.1			1.5			13.7		1	1.2			1.5			13.8		1
10/11/21 15:00	0.9			1.5			14.3		1	1			1.5			14.3		1
10/11/21 16:00	0.6			1.5			14.4		1	0.7			1.5			14.5		1
10/11/21 17:00	0.6			1.5			14.3		1	0.8			1.5			14.4		1
10/11/21 18:00	0.6			1.6			14.4		1	0.7			1.5			14.5		1
10/11/21 19:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
10/11/21 20:00	0.6			1.6			14.4		1	0.8			1.5			14.4		1
10/11/21 21:00	0.6			1.6			14.4		1	0.8			1.4			14.4		1
10/11/21 22:00	0.5			1.7			14.6		1	0.7			1.5			14.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/11/21 23:00	0.6			1.6			14.5		1	0.8			1.5			14.6		1
10/12/21 0:00	0.5			1.5			14.6		1	0.7			1.5			14.6		1
10/12/21 1:00	0.5			1.6			14.7		1	0.6			1.5			14.7		1
10/12/21 2:00	0.4			1.8			14.7		1	0.6			1.9			14.8		1
10/12/21 3:00	0.5			1.5			14.7		1	0.6			1.5			14.7		1
10/12/21 4:00	0.4			1.7			14.8		1	0.6			1.5			14.8		1
10/12/21 5:00	0.6			1.4			14.4		1	0.8			1.4			14.5		1
10/12/21 6:00	0.6			1.5			14.4		1	0.8			1.5			14.5		1
10/12/21 7:00	0.6			1.5			14.4		1	0.8			1.5			14.5		1
10/12/21 8:00	0.6			1.5			14.4		1	0.8			1.5			14.5		1
10/12/21 9:00	0.6			1.5			14.5		1	0.8			1.5			14.6		1
10/12/21 10:00	0.6			1.5			14.5		1	0.8			1.5			14.6		1
10/12/21 11:00	0.6			1.5			14.5		1	0.8			1.5			14.6		1
10/12/21 12:00	0.6			1.5			14.5		1	0.8			1.5			14.6		1
10/12/21 13:00	0.7			1.5			14.4		1	0.8			1.5			14.5		1
10/12/21 14:00	0.6			1.5			14.5		1	0.8			1.5			14.6		1
10/12/21 15:00	0.6			1.5			14.5		1	0.8			1.5			14.6		1
10/12/21 16:00	0.7			1.5			14.5		1	0.8			1.5			14.6		1
10/12/21 17:00	0.6			1.5			14.5		1	0.8			1.5			14.6		1
10/12/21 18:00	0.6			1.5			14.5		1	0.8			1.5			14.6		1
10/12/21 19:00	0.7			1.5			14.4		1	0.8			1.5			14.5		1
10/12/21 20:00	0.6			1.5			14.4		1	0.8			1.6			14.5		1
10/12/21 21:00	0.6			1.5			14.5		1	0.8			1.4			14.5		1
10/12/21 22:00	0.6			1.5			14.4		1	0.9			1.5			14.5		1
10/12/21 23:00	0.7			1.5			14.4		1	0.9			1.4			14.5		1
10/13/21 0:00	0.7			1.5			14.5		1	0.8			1.6			14.5		1
10/13/21 1:00	0.7			1.6			14.5		1	0.8			1.5			14.5		1
10/13/21 2:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
10/13/21 3:00	0.7			1.4			14.5		1	0.8			1.4			14.5		1
10/13/21 4:00	0.7			1.5			14.5		1	0.8			1.5			14.5		1
10/13/21 5:00	0.7			1.5			14.4		1	0.9			1.5			14.5		1
10/13/21 6:00	0.7			1.5			14.4		1	0.9			1.5			14.4		1
10/13/21 7:00	0.7			1.5			14.5		1	0.8			1.5			14.5		1
10/13/21 8:00	0.6			1.5			14.5		1	0.8			1.5			14.6		1
10/13/21 9:00	0.6			1.5			14.5		1	0.8			1.5			14.6		1
10/13/21 10:00	0.6			1.5			14.5		1	0.8			1.5			14.6		1
10/13/21 11:00	0.6			1.5			14.5		1	0.8			1.5			14.6		1
10/13/21 12:00	0.6			1.5			14.5		1	0.8			1.5			14.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/13/21 13:00	0.6			1.5			14.4		1	0.8			1.5			14.5		1
10/13/21 14:00	0.6			1.5			14.4		1	0.8			1.5			14.5		1
10/13/21 15:00	0.7			1.5			14.3		1	0.9			1.6			14.4		1
10/13/21 16:00	0.5			1.5			14.6		1	0.7			1.4			14.7		1
10/13/21 17:00	0.6			1.6			14.4		1	0.8			1.5			14.5		1
10/13/21 18:00	0.7			1.5			14.3		1	0.9			1.5			14.4		1
10/13/21 19:00	0.7			1.6			14.3		1	0.8			1.5			14.4		1
10/13/21 20:00	0.7			1.5			14.3		1	0.9			1.5			14.4		1
10/13/21 21:00	0.8			1.6			14.3		1	1			1.5			14.4		1
10/13/21 22:00	0.6			1.6			14.4		1	0.8			1.6			14.4		1
10/13/21 23:00	0.6			1.7			14.7		1	0.7			1.5			14.7		1
10/14/21 0:00	0.8			1.5			14.6		1	0.9			1.6			14.6		1
10/14/21 1:00	0.7			1.7			14.7		1	0.9			1.5			14.7		1
10/14/21 2:00	0.7			1.7			14.6		1	0.8			1.7			14.6		1
10/14/21 3:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
10/14/21 4:00	0.6			1.7			14.6		1	0.7			1.5			14.7		1
10/14/21 5:00	0.7			1.4			14.4		1	1			1.4			14.5		1
10/14/21 6:00	0.8			1.5			14.4		1	1			1.5			14.4		1
10/14/21 7:00	0.7			1.6			14.4		1	0.9			1.5			14.4		1
10/14/21 8:00	0.6			1.7			14.6		1	0.7			1.6			14.7		1
10/14/21 9:00	0.5			1.6			14.6		1	0.7			1.5			14.7		1
10/14/21 10:00	0.5			1.5			14.7		1	0.6			1.5			14.8		1
10/14/21 11:00	0.5			1.5			14.7		1	0.6			1.5			14.8		1
10/14/21 12:00	0.5			1.6			14.7		1	0.6			1.5			14.8		1
10/14/21 13:00	0.5			1.5			14.7		1	0.7			1.5			14.7		1
10/14/21 14:00	0.5			1.5			14.7		1	0.7			1.5			14.8		1
10/14/21 15:00	0.6			1.5			14.6		1	0.7			1.5			14.7		1
10/14/21 16:00	0.6			1.5			14.6		1	0.7			1.4			14.7		1
10/14/21 17:00	0.6			1.5			14.5		1	0.8			1.5			14.6		1
10/14/21 18:00	0.7			1.5			14.3		1	0.9			1.5			14.4		1
10/14/21 19:00	0.6			1.5			14.4		1	0.8			1.5			14.5		1
10/14/21 20:00	0.6			1.5			14.4		1	0.9			1.5			14.5		1
10/14/21 21:00	0			0			15.1		1	0.9			1.5			13		1
10/14/21 22:00	0	X		0	X		0	X	1	1.3			1.5			14.1		1
10/14/21 23:00	0	X		0	X		0	X	1	1.4			1.5			14.3		1
10/15/21 0:00	0	X		0	X		0	X	1	1.4			1.5			14.3		1
10/15/21 1:00	0	X		0	X		0	X	1	1.5			1.5			14.3		1
10/15/21 2:00	0	X		0	X		0	X	1	1.7			1.4			14.3		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/15/21 3:00	0	X		0	X		0	X	1	1.6			1.5			14.3		1
10/15/21 4:00	0	X		0	X		0	X	1	1.5			1.5			14.3		1
10/15/21 5:00	0	X		0	X		0	X	1	1.6			1.5			14.3		1
10/15/21 6:00	0	X		0	X		0	X	1	1.6			1.5			14.3		1
10/15/21 7:00	0	X		0	X		0	X	1	1.7			1.5			14.3		1
10/15/21 8:00	0	X		0	X		0	X	1	1.5			1.5			14.3		1
10/15/21 9:00	0	X		0	X		0	X	1	1.4			1.5			14.3		1
10/15/21 10:00	0	X		0	X		0	X	1	1.4			1.5			14.3		1
10/15/21 11:00	0	X		0	X		0	X	1	1.4			1.5			14.3		1
10/15/21 12:00	0	X		0	X		0	X	1	1.4			1.5			14.3		1
10/15/21 13:00	0	X		0	X		0	X	1	1.4			1.5			14.3		1
10/15/21 14:00	0	X		0	X		0	X	1	1.4			1.5			14.3		1
10/15/21 15:00	0	X		0	X		0	X	1	1.4			1.5			14.3		1
10/15/21 16:00	0	X		0	X		0	X	1	1.3			1.5			14.1		1
10/15/21 17:00	0	X		0	X		0	X	1	1.4			1.5			14.1		1
10/15/21 18:00	0	X		0	X		0	X	1	1.5			1.5			14.3		1
10/15/21 19:00	0	X		0	X		0	X	1	1.6			1.5			14.2		1
10/15/21 20:00	0	X		0	X		0	X	1	1.7			1.5			14.2		1
10/15/21 21:00	0	X		0	X		0	X	1	1.7			1.5			14.2		1
10/15/21 22:00	0	X		0	X		0	X	1	1.7			1.5			14.2		1
10/15/21 23:00	0	X		0	X		0	X	1	1.7			1.5			14.2		1
10/16/21 0:00	0	X		0	X		0	X	1	2			1.5			14.3		1
10/16/21 1:00	0	X		0	X		0	X	1	1.9			1.5			14.3		1
10/16/21 2:00	0	X		0	X		0	X	1	1.8			1.5			14.3		1
10/16/21 3:00	0	X		0	X		0	X	1	2.1			1.5			14.3		1
10/16/21 4:00	0	X		0	X		0	X	1	2.3			1.5			14.2		1
10/16/21 5:00	0	X		0	X		0	X	1	1.6			1.5			14.2		1
10/16/21 6:00	0	X		0	X		0	X	1	1.8			1.5			14.2		1
10/16/21 7:00	0	X		0	X		0	X	1	1.6			1.5			14.2		1
10/16/21 8:00	0	X		0	X		0	X	1	1.5			1.5			14.3		1
10/16/21 9:00	0	X		0	X		0	X	1	1.4			1.5			14.3		1
10/16/21 10:00	0	X		0	X		0	X	1	1.2			1.5			14.2		1
10/16/21 11:00	0	X		0	X		0	X	1	1.1			1.5			14.1		1
10/16/21 12:00	0	X		0	X		0	X	1	1.1			1.5			14		1
10/16/21 13:00	0	X		0	X		0	X	1	1.1			1.5			14		1
10/16/21 14:00	0	X		0	X		0	X	1	1			1.5			13.9		1
10/16/21 15:00	0	X		0	X		0	X	1	1			1.5			13.9		1
10/16/21 16:00	0	X		0	X		0	X	1	1.1			1.5			14		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/16/21 17:00	0	X		0	X		0	X	1	1.1			1.5			14		1
10/16/21 18:00	0	X		0	X		0	X	1	1.2			1.5			14.1		1
10/16/21 19:00	0	X		0	X		0	X	1	1.2			1.5			14.1		1
10/16/21 20:00	0	X		0	X		0	X	1	1.3			1.5			14.1		1
10/16/21 21:00	0	X		0	X		0	X	1	1.4			1.5			14.2		1
10/16/21 22:00	0	X		0	X		0	X	1	1.4			1.5			14.2		1
10/16/21 23:00	0	X		0	X		0	X	1	1.5			1.5			14.3		1
10/17/21 0:00	0	X		0	X		0	X	1	1.5			1.5			14.3		1
10/17/21 1:00	0	X		0	X		0	X	1	1.5			1.5			14.3		1
10/17/21 2:00	0	X		0	X		0	X	1	1.5			1.5			14.3		1
10/17/21 3:00	0	X		0	X		0	X	1	1.5			1.5			14.3		1
10/17/21 4:00	0	X		0	X		0	X	1	1.5			1.5			14.3		1
10/17/21 5:00	0	X		0	X		0	X	1	1.5			1.5			14.3		1
10/17/21 6:00	0	X		0	X		0	X	1	1.5			1.5			14.3		1
10/17/21 7:00	0	X		0	X		0	X	1	1.1			1.5			13.7		1
10/17/21 8:00	0	X		0	X		0	X	1	0.4			1.5			12.3		1
10/17/21 9:00	0	X		0	X		0	X	1	0.9			1.5			13.2		1
10/17/21 10:00	0	X		0	X		0	X	1	1.6			1.5			14.2		1
10/17/21 11:00	0	X		0	X		0	X	1	1.5			1.5			14.2		1
10/17/21 12:00	0	X		0	X		0	X	1	1.5			1.5			14.2		1
10/17/21 13:00	0	X		0	X		0	X	1	1.5			1.5			14.2		1
10/17/21 14:00	0	X		0	X		0	X	1	1.5			1.5			14.2		1
10/17/21 15:00	0	X		0	X		0	X	1	1.5			1.5			14.2		1
10/17/21 16:00	0	X		0	X		0	X	1	1.5			1.5			14.1		1
10/17/21 17:00	0	X		0	X		0	X	1	1.6			1.5			14.2		1
10/17/21 18:00	0	X		0	X		0	X	1	1.5			1.5			14.2		1
10/17/21 19:00	0	X		0	X		0	X	1	1.6			1.5			14.2		1
10/17/21 20:00	0	X		0	X		0	X	1	1.6			1.5			14.2		1
10/17/21 21:00	0	X		0	X		0	X	1	1.6			1.5			14.2		1
10/17/21 22:00	0	X		0	X		0	X	1	1.6			1.5			14.2		1
10/17/21 23:00	0	X		0	X		0	X	1	1.6			1.5			14.2		1
10/18/21 0:00	0	X		0	X		0	X	1	1.6			1.5			14.2		1
10/18/21 1:00	0	X		0	X		0	X	1	1.6			1.5			14.2		1
10/18/21 2:00	0	X		0	X		0	X	1	1.6			1.5			14.2		1
10/18/21 3:00	0	X		0	X		0	X	1	1.6			1.5			14.2		1
10/18/21 4:00	0	X		0	X		0	X	1	1.6			1.5			14.2		1
10/18/21 5:00	0	X		0	X		0	X	1	1.6			1.5			14.2		1
10/18/21 6:00	0	X		0	X		0	X	1	1.6			1.5			14.2		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/18/21 7:00	0	X		0	X		0	X	1	1.3			1.4			14.3		1
10/18/21 8:00	0	X		0	X		0	X	1	1.4			1.4			14.4		1
10/18/21 9:00	0	X		0	X		0	X	1	1.8			1.5			14.2		1
10/18/21 10:00	0	X		0	X		0	X	1	1.8			1.5			14.3		1
10/18/21 11:00	0	X		0	X		0	X	1	1.8			1.5			14.3		1
10/18/21 12:00	0	X		0	X		0	X	1	1.8			1.5			14.3		1
10/18/21 13:00	0	X		0	X		0	X	1	1.7			1.5			14.3		1
10/18/21 14:00	0	X		0	X		0	X	1	1.4			1.5			14.2		1
10/18/21 15:00	0	X		0	X		0	X	1	1.5			1.5			14.3		1
10/18/21 16:00	0	X		0	X		0	X	1	1.1			1.5			14.5		1
10/18/21 17:00	0	X		0	X		0	X	1	1.8			1.5			14.3		1
10/18/21 18:00	0	X		0	X		0	X	1	1.9			1.5			14.3		1
10/18/21 19:00	0	X		0	X		0	X	1	2.1			1.5			14.3		1
10/18/21 20:00	0	X		0	X		0	X	1	1.9			1.5			14.2		1
10/18/21 21:00	0	X		0	X		0	X	1	1.5			1.5			14.4		1
10/18/21 22:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
10/18/21 23:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
10/19/21 0:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
10/19/21 1:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
10/19/21 2:00	0	X		0	X		0	X	1	0.9			1.5			14.6		1
10/19/21 3:00	0	X		0	X		0	X	1	2.4			1.3			14.4		1
10/19/21 4:00	0	X		0	X		0	X	1	2.2			1.5			14.2		1
10/19/21 5:00	0	X		0	X		0	X	1	2			1.5			14.2		1
10/19/21 6:00	0	X		0	X		0	X	1	1.9			1.5			14.2		1
10/19/21 7:00	0	X		0	X		0	X	1	1.9			1.5			14.2		1
10/19/21 8:00	0	X		0	X		0	X	1	1.9			1.5			14.2		1
10/19/21 9:00	0	X		0	X		0	X	1	1.8			1.5			14.2		1
10/19/21 10:00	0	X		0	X		0	X	1	1.6			1.5			14.2		1
10/19/21 11:00	0	X		0	X		0	X	1	1.4			1.5			14.3		1
10/19/21 12:00	0	X		0	X		0	X	1	1.4			1.5			14.3		1
10/19/21 13:00	0	X		0	X		0	X	1	1.2			1.5			14.4		1
10/19/21 14:00	0	X		0	X		0	X	1	1.5			1.5			14.2		1
10/19/21 15:00	0	X		0	X		0	X	1	1.4			1.5			14.2		1
10/19/21 16:00	0	X		0	X		0	X	1	1.3			1.5			14		1
10/19/21 17:00	0	X		0	X		0	X	1	1.4			1.5			14.1		1
10/19/21 18:00	0	X		0	X		0	X	1	1.5			1.5			14.3		1
10/19/21 19:00	0	X		0	X		0	X	1	1.5			1.5			14.3		1
10/19/21 20:00	0	X		0	X		0	X	1	1.5			1.5			14.3		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/19/21 21:00	0	X		0	X		0	X	1	1.4			1.5			14.3		1
10/19/21 22:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
10/19/21 23:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
10/20/21 0:00	0	X		0	X		0	X	1	0.8			1.5			14.7		1
10/20/21 1:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
10/20/21 2:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
10/20/21 3:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
10/20/21 4:00	0	X		0	X		0	X	1	1.4			1.4			14.4		1
10/20/21 5:00	0	X		0	X		0	X	1	1.8			1.5			14.3		1
10/20/21 6:00	0	X		0	X		0	X	1	1.4			1.5			14.4		1
10/20/21 7:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
10/20/21 8:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
10/20/21 9:00	0	X		0	X		0	X	1	0.8			1.5			14.5		1
10/20/21 10:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
10/20/21 11:00	0	X		0	X		0	X	1	0.9			1.4			14.4		1
10/20/21 12:00	0	X		0	X		0	X	1	0.9			1.6			14.5		1
10/20/21 13:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
10/20/21 14:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
10/20/21 15:00	0	X		0	X		0	X	1	0.8			1.4			14.6		1
10/20/21 16:00	0	X		0	X		0	X	1	0.8			1.5			14.5		1
10/20/21 17:00	0	X		0	X		0	X	1	0.9			1.5			14.5		1
10/20/21 18:00	0	X		0	X		0	X	1	0.8			1.6			14.6		1
10/20/21 19:00	0	X		0	X		0	X	1	0.7			1.5			14.7		1
10/20/21 20:00	0	X		0	X		0	X	1	0.8			1.5			14.6		1
10/20/21 21:00	0	X		0	X		0	X	1	0.8			1.5			14.5		1
10/20/21 22:00	0			0			19.2		1	1.1			1.4			14.5		1
10/20/21 23:00	0.7			1.8			14.5		1	1			1.6			14.4		1
10/21/21 0:00	0.8			1.5			14.5		1	0.7			1.5			14.6		1
10/21/21 1:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
10/21/21 2:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
10/21/21 3:00	0.7			1.4			14.4		1	0.9			1.2			14.5		1
10/21/21 4:00	0.7			1.5			14.4		1	0.8			1.5			14.5		1
10/21/21 5:00	0.7			1.5			14.4		1	0.9			1.5			14.4		1
10/21/21 6:00	0.7			1.5			14.3		1	0.9			1.5			14.4		1
10/21/21 7:00	0.7			1.5			14.3		1	0.9			1.4			14.4		1
10/21/21 8:00	0.6			1.5			14.4		1	0.9			1.5			14.4		1
10/21/21 9:00	0.7			1.5			14.4		1	0.8			1.5			14.4		1
10/21/21 10:00	0.7			1.5			14.4		1	0.8			1.5			14.4		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/21/21 11:00	0.7			1.6			14.3		1	0.9			1.6			14.4		1
10/21/21 12:00	0.6			1.4			14.5		1	0.7			1.4			14.6		1
10/21/21 13:00	0.6			1.5			14.5		1	0.8			1.5			14.5		1
10/21/21 14:00	0.7			1.5			14.4		1	0.9			1.4			14.4		1
10/21/21 15:00	0.5			1.4			14.6		1	0.7			1.4			14.6		1
10/21/21 16:00	0.6			1.4			14.4		1	0.8			1.5			14.5		1
10/21/21 17:00	0.6			1.5			14.4		1	0.8			1.5			14.4		1
10/21/21 18:00	0.6			1.5			14.4		1	0.8			1.5			14.4		1
10/21/21 19:00	0.6			1.5			14.4		1	0.8			1.5			14.4		1
10/21/21 20:00	0.6			1.5			14.4		1	0.8			1.5			14.4		1
10/21/21 21:00	0.6			1.5			14.3		1	0.9			1.6			14.4		1
10/21/21 22:00	0.6			1.6			14.4		1	0.8			1.5			14.5		1
10/21/21 23:00	0.5			1.5			14.6		1	0.6			1.5			14.7		1
10/22/21 0:00	0.5			1.5			14.6		1	0.6			1.5			14.7		1
10/22/21 1:00	0.5			1.5			14.6		1	0.6			1.5			14.7		1
10/22/21 2:00	0.5			1.5			14.6		1	0.6			1.5			14.7		1
10/22/21 3:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
10/22/21 4:00	0.5			1.5			14.5		1	0.7			1.5			14.6		1
10/22/21 5:00	0.5			1.5			14.6		1	0.7			1.5			14.6		1
10/22/21 6:00	0.4			1.7			14.7		1	0.7			1.4			14.6		1
10/22/21 7:00	0.6			1.1			14.3		1	0.9			1.5			14.3		1
10/22/21 8:00	0.6			1.5			14.4		1	0.9			1.3			14.4		1
10/22/21 9:00	0.6			1.5			14.3		1	0.8			1.5			14.4		1
10/22/21 10:00	0.6			1.5			14.4		1	0.8			1.5			14.4		1
10/22/21 11:00	0.6			1.5			14.4		1	0.8			1.5			14.4		1
10/22/21 12:00	0.6			1.5			14.3		1	0.9			1.6			14.4		1
10/22/21 13:00	0.6			1.5			14.3		1	0.8			1.5			14.4		1
10/22/21 14:00	0.6			1.5			14.3		1	0.8			1.5			14.4		1
10/22/21 15:00	0.6			1.5			14.3		1	0.8			1.5			14.4		1
10/22/21 16:00	0.6			1.5			14.3		1	0.8			1.4			14.4		1
10/22/21 17:00	0.6			1.6			14.4		1	0.8			1.6			14.4		1
10/22/21 18:00	0.4			1.5			14.7		1	0.6			1.5			14.7		1
10/22/21 19:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
10/22/21 20:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
10/22/21 21:00	0.5			1.6			14.6		1	0.7			1.5			14.6		1
10/22/21 22:00	0.5			1.6			14.6		1	0.7			1.5			14.7		1
10/22/21 23:00	0.6			1.4			14.4		1	0.8			1.5			14.5		1
10/23/21 0:00	0.7			1.7			14.4		1	0.8			1.5			14.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/23/21 1:00	0.5			1.6			14.7		1	0.6			1.5			14.8		1
10/23/21 2:00	0.6			1.3			14.5		1	0.7			1.4			14.6		1
10/23/21 3:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
10/23/21 4:00	0.6			1.6			14.5		1	0.7			1.5			14.6		1
10/23/21 5:00	0.6			1.4			14.4		1	0.8			1.4			14.5		1
10/23/21 6:00	0.7			1.6			14.3		1	0.9			1.5			14.4		1
10/23/21 7:00	0.7			1.7			14.4		1	0.8			1.6			14.4		1
10/23/21 8:00	0.7			1.4			14.4		1	0.8			1.4			14.4		1
10/23/21 9:00	0.7			1.6			14.3		1	0.9			1.6			14.3		1
10/23/21 10:00	0.6			1.6			14.4		1	0.8			1.5			14.5		1
10/23/21 11:00	0.6			1.6			14.4		1	0.8			1.5			14.5		1
10/23/21 12:00	0.6			1.4			14.4		1	0.8			1.5			14.5		1
10/23/21 13:00	0.7			1.6			14.3		1	0.9			1.4			14.4		1
10/23/21 14:00	0.6			1.5			14.4		1	0.8			1.5			14.5		1
10/23/21 15:00	0.6			1.5			14.4		1	0.8			1.5			14.4		1
10/23/21 16:00	0.6			1.5			14.4		1	0.8			1.5			14.4		1
10/23/21 17:00	0.6			1.5			14.4		1	0.8			1.5			14.4		1
10/23/21 18:00	0.6			1.8			14.5		1	0.7			1.6			14.6		1
10/23/21 19:00	0.7			1.5			14.4		1	0.8			1.5			14.5		1
10/23/21 20:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
10/23/21 21:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
10/23/21 22:00	0.6			1.5			14.4		1	0.7			1.5			14.5		1
10/23/21 23:00	0.7			1.5			14.4		1	0.8			1.5			14.4		1
10/24/21 0:00	0.7			1.6			14.2		1	0.9			1.5			14.3		1
10/24/21 1:00	0.5			1.7			14.6		1	0.6			1.6			14.7		1
10/24/21 2:00	0.5			1.4			14.6		1	0.6			1.5			14.7		1
10/24/21 3:00	0.5			1.6			14.6		1	0.6			1.6			14.6		1
10/24/21 4:00	0.5			1.5			14.6		1	0.6			1.5			14.7		1
10/24/21 5:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
10/24/21 6:00	0.6			1.6			14.5		1	0.7			1.5			14.6		1
10/24/21 7:00	0.6			1.4			14.4		1	0.8			1.4			14.5		1
10/24/21 8:00	0.6			1.5			14.4		1	0.8			1.5			14.4		1
10/24/21 9:00	0.6			1.5			14.4		1	0.8			1.5			14.4		1
10/24/21 10:00	0.7			1.5			14.3		1	0.8			1.5			14.4		1
10/24/21 11:00	0.7			1.5			14.3		1	0.8			1.5			14.4		1
10/24/21 12:00	0.7			1.5			14.3		1	0.8			1.5			14.4		1
10/24/21 13:00	0.7			1.5			14.3		1	0.8			1.5			14.4		1
10/24/21 14:00	0.7			1.5			14.4		1	0.8			1.5			14.4		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/24/21 15:00	0.7			1.5			14.3		1	0.8			1.5			14.4		1
10/24/21 16:00	0.6			1.5			14.3		1	0.8			1.5			14.4		1
10/24/21 17:00	0.6			1.5			14.3		1	0.8			1.5			14.4		1
10/24/21 18:00	0.6			1.6			14.3		1	0.8			1.5			14.4		1
10/24/21 19:00	0.6			1.6			14.3		1	0.8			1.5			14.4		1
10/24/21 20:00	0.6			1.5			14.3		1	0.7			1.5			14.4		1
10/24/21 21:00	0.6			1.5			14.3		1	0.8			1.5			14.4		1
10/24/21 22:00	0.6			1.6			14.4		1	0.7			1.6			14.5		1
10/24/21 23:00	0.5			1.5			14.4		1	0.6			1.5			14.5		1
10/25/21 0:00	0.7			1.4			14.3		1	0.8			1.5			14.4		1
10/25/21 1:00	0.6			1.6			14.4		1	0.7			1.5			14.5		1
10/25/21 2:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
10/25/21 3:00	0.6			1.5			14.5		1	0.7			1.5			14.5		1
10/25/21 4:00	0.7			1.4			14.3		1	0.8			1.5			14.4		1
10/25/21 5:00	0.6			1.5			14.4		1	0.8			1.5			14.4		1
10/25/21 6:00	0.6			1.5			14.3		1	0.8			1.5			14.4		1
10/25/21 7:00	0.7			1.5			14.3		1	0.9			1.5			14.4		1
10/25/21 8:00	0.6			1.5			14.3		1	0.8			1.5			14.4		1
10/25/21 9:00	0.6			1.7			14.4		1	0.8			1.6			14.4		1
10/25/21 10:00	0.5			1.5			14.6		1	0.6			1.5			14.7		1
10/25/21 11:00	0.5			1.5			14.6		1	0.6			1.5			14.7		1
10/25/21 12:00	0.5			1.5			14.6		1	0.6			1.5			14.7		1
10/25/21 13:00	0.5			1.5			14.6		1	0.6			1.5			14.7		1
10/25/21 14:00	0.5			1.5			14.7		1	0.6			1.5			14.7		1
10/25/21 15:00	0.5			1.5			14.7		1	0.6			1.5			14.7		1
10/25/21 16:00	0.6			1.3			14.5		1	0.7			1.4			14.5		1
10/25/21 17:00	0.6			1.5			14.3		1	0.8			1.5			14.4		1
10/25/21 18:00	0.7			1.7			14.3		1	0.9			1.6			14.4		1
10/25/21 19:00	0.7			1.4			14.3		1	0.9			1.4			14.4		1
10/25/21 20:00	0.7			1.5			14.3		1	0.8			1.6			14.4		1
10/25/21 21:00	0.7			1.7			14.4		1	0.8			1.5			14.5		1
10/25/21 22:00	0.5			1.6			14.7		1	0.6			1.5			14.7		1
10/25/21 23:00	0.6			1.6			14.6		1	0.6			1.5			14.7		1
10/26/21 0:00	0.5			1.5			14.7		1	0.6			1.5			14.8		1
10/26/21 1:00	0.5			1.6			14.7		1	0.6			1.5			14.7		1
10/26/21 2:00	0.5			1.7			14.7		1	0.6			1.7			14.7		1
10/26/21 3:00	0.6			1.7			14.6		1	0.6			1.6			14.7		1
10/26/21 4:00	0.5			1.5			14.7		1	0.5			1.5			14.8		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/26/21 5:00	0.6			1.4			14.4		1	0.8			1.4			14.4		1
10/26/21 6:00	0.6			1.7			14.4		1	0.7			1.6			14.5		1
10/26/21 7:00	0.6			1.4			14.4		1	0.8			1.4			14.5		1
10/26/21 8:00	0.6			1.7			14.5		1	0.7			1.5			14.6		1
10/26/21 9:00	0.5			1.5			14.6		1	0.6			1.5			14.6		1
10/26/21 10:00	0.5			1.5			14.6		1	0.6			1.5			14.6		1
10/26/21 11:00	0.6			1.6			14.5		1	0.7			1.6			14.6		1
10/26/21 12:00	0.5			1.5			14.6		1	0.6			1.5			14.7		1
10/26/21 13:00	0.5			1.6			14.7		1	0.6			1.5			14.7		1
10/26/21 14:00	0.6			1.5			14.5		1	0.7			1.5			14.5		1
10/26/21 15:00	0.5			1.6			14.6		1	0.6			1.5			14.7		1
10/26/21 16:00	0.6			1.5			14.5		1	0.7			1.5			14.5		1
10/26/21 17:00	0.5			1.7			14.6		1	0.6			1.5			14.6		1
10/26/21 18:00	0.6			1.4			14.3		1	0.8			1.4			14.4		1
10/26/21 19:00	0.7			1.5			14.3		1	0.8			1.4			14.3		1
10/26/21 20:00	0.7			1.5			14.3		1	0.9			1.5			14.3		1
10/26/21 21:00	0.7			1.6			14.3		1	0.8			1.4			14.4		1
10/26/21 22:00	0.7			1.5			14.3		1	0.9			1.5			14.4		1
10/26/21 23:00	0.6			1.6			14.5		1	0.7			1.5			14.6		1
10/27/21 0:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
10/27/21 1:00	0.5			1.6			14.7		1	0.6			1.5			14.7		1
10/27/21 2:00	0.5			1.5			14.7		1	0.6			1.5			14.7		1
10/27/21 3:00	0.6			1.5			14.6		1	0.6			1.5			14.6		1
10/27/21 4:00	0.6			1.6			14.6		1	0.6			1.5			14.7		1
10/27/21 5:00	0.6			1.5			14.6		1	0.7			1.4			14.6		1
10/27/21 6:00	0.7			1.6			14.3		1	0.8			1.6			14.4		1
10/27/21 7:00	0.6			1.8			14.5		1	0.7			1.4			14.6		1
10/27/21 8:00	0.4			1.5			14.8		1	0.5			1.5			14.8		1
10/27/21 9:00	0.4			1.5			14.8		1	0.5			1.5			14.8		1
10/27/21 10:00	0.4			1.5			14.8		1	0.5			1.5			14.8		1
10/27/21 11:00	0.4			1.5			14.7		1	0.5			1.5			14.8		1
10/27/21 12:00	0.4			1.5			14.7		1	0.5			1.5			14.8		1
10/27/21 13:00	0.5			1.5			14.7		1	0.6			1.5			14.8		1
10/27/21 14:00	0.5			1.5			14.7		1	0.5			1.5			14.8		1
10/27/21 15:00	0.5			1.3			14.6		1	0.6			1.4			14.7		1
10/27/21 16:00	0.6			1.4			14.4		1	0.7			1.5			14.5		1
10/27/21 17:00	0.6			1.5			14.4		1	0.7			1.5			14.5		1
10/27/21 18:00	0.7			1.5			14.3		1	0.8			1.5			14.4		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/27/21 19:00	0.6			1.5			14.3		1	0.8			1.5			14.4		1
10/27/21 20:00	0.7			1.5			14.3		1	0.8			1.5			14.3		1
10/27/21 21:00	0.7			1.5			14.3		1	0.8			1.5			14.4		1
10/27/21 22:00	0.6			1.7			14.4		1	0.7			1.6			14.5		1
10/27/21 23:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
10/28/21 0:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
10/28/21 1:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
10/28/21 2:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
10/28/21 3:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
10/28/21 4:00	0.6			1.4			14.4		1	0.8			1.4			14.5		1
10/28/21 5:00	0.7			1.6			14.4		1	0.8			1.5			14.4		1
10/28/21 6:00	0.8			1.6			14.3		1	0.8			1.6			14.3		1
10/28/21 7:00	0.6			1.7			14.5		1	0.6			1.6			14.6		1
10/28/21 8:00	0.5			1.5			14.7		1	0.5			1.5			14.7		1
10/28/21 9:00	0.5			1.5			14.7		1	0.6			1.5			14.7		1
10/28/21 10:00	0.5			1.5			14.6		1	0.6			1.5			14.7		1
10/28/21 11:00	0.6			1.6			14.6		1	0.6			1.5			14.6		1
10/28/21 12:00	0.6			1.5			14.6		1	0.6			1.5			14.6		1
10/28/21 13:00	0.5			1.5			14.7		1	0.5			1.5			14.8		1
10/28/21 14:00	0.5			1.5			14.7		1	0.6			1.5			14.8		1
10/28/21 15:00	0.5			1.5			14.7		1	0.6			1.5			14.7		1
10/28/21 16:00	0.6			1.4			14.4		1	0.7			1.4			14.5		1
10/28/21 17:00	0.6			1.5			14.4		1	0.8			1.5			14.4		1
10/28/21 18:00	0.8			1.5			14.3		1	0.9			1.5			14.4		1
10/28/21 19:00	0.7			1.5			14.4		1	0.8			1.5			14.4		1
10/28/21 20:00	0.7			1.5			14.3		1	0.8			1.5			14.4		1
10/28/21 21:00	0.7			1.7			14.3		1	0.9			1.6			14.4		1
10/28/21 22:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
10/28/21 23:00	0.6			1.6			14.6		1	0.7			1.5			14.6		1
10/29/21 0:00	0.6			1.6			14.6		1	0.7			1.5			14.6		1
10/29/21 1:00	0.6			1.6			14.6		1	0.7			1.5			14.6		1
10/29/21 2:00	0.6			1.4			14.6		1	0.7			1.5			14.7		1
10/29/21 3:00	0.6			1.6			14.5		1	0.7			1.5			14.6		1
10/29/21 4:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
10/29/21 5:00	0.7			1.4			14.4		1	0.8			1.4			14.5		1
10/29/21 6:00	0.8			1.8			14.3		1	0.9			1.5			14.4		1
10/29/21 7:00	0.8			1.8			14.6		1	0.9			1.5			14.6		1
10/29/21 8:00	0.7			1.5			14.7		1	0.7			1.5			14.7		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/29/21 9:00	0.6			1.5			14.7		1	0.7			1.5			14.7		1
10/29/21 10:00	0.5			1.5			14.6		1	0.6			1.5			14.7		1
10/29/21 11:00	0.5			1.5			14.6		1	0.6			1.5			14.7		1
10/29/21 12:00	0.5			1.5			14.7		1	0.6			1.5			14.7		1
10/29/21 13:00	0.5			1.4			14.7		1	0.6			1.5			14.7		1
10/29/21 14:00	0.5			1.6			14.7		1	0.6			1.5			14.7		1
10/29/21 15:00	0.6			1.3			14.5		1	0.9			1.4			14.5		1
10/29/21 16:00	0.7			1.4			14.4		1	0.9			1.5			14.4		1
10/29/21 17:00	0.7			1.5			14.4		1	0.8			1.5			14.5		1
10/29/21 18:00	0.8			1.5			14.3		1	0.9			1.4			14.3		1
10/29/21 19:00	0.8			1.5			14.4		1	0.9			1.5			14.4		1
10/29/21 20:00	0.8			1.5			14.4		1	0.9			1.5			14.4		1
10/29/21 21:00	0.8			1.6			14.3		1	0.9			1.6			14.3		1
10/29/21 22:00	0.8			1.5			14.3		1	1			1.5			14.3		1
10/29/21 23:00	0.7			1.6			14.4		1	0.8			1.5			14.5		1
10/30/21 0:00	0.7			1.5			14.4		1	0.8			1.5			14.4		1
10/30/21 1:00	0.6			1.5			14.5		1	0.7			1.6			14.6		1
10/30/21 2:00	0.5			1.4			14.6		1	0.6			1.4			14.7		1
10/30/21 3:00	0.6			1.6			14.5		1	0.7			1.5			14.6		1
10/30/21 4:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
10/30/21 5:00	0.6			1.4			14.4		1	0.7			1.4			14.5		1
10/30/21 6:00	0.5			1.7			14.6		1	0.6			1.5			14.6		1
10/30/21 7:00	0.5			1.5			14.6		1	0.6			1.5			14.7		1
10/30/21 8:00	0.5			1.5			14.7		1	0.6			1.5			14.7		1
10/30/21 9:00	0.5			1.5			14.7		1	0.5			1.5			14.7		1
10/30/21 10:00	0.5			1.5			14.7		1	0.5			1.5			14.7		1
10/30/21 11:00	0.5			1.5			14.7		1	0.5			1.5			14.7		1
10/30/21 12:00	0.5			1.5			14.7		1	0.5			1.5			14.7		1
10/30/21 13:00	0.5			1.5			14.7		1	0.5			1.5			14.7		1
10/30/21 14:00	0.4			1.5			14.7		1	0.5			1.5			14.7		1
10/30/21 15:00	0.5			1.3			14.6		1	0.6			1.4			14.6		1
10/30/21 16:00	0.5			1.5			14.5		1	0.6			1.5			14.5		1
10/30/21 17:00	0.5			1.6			14.5		1	0.6			1.6			14.6		1
10/30/21 18:00	0.5			1.5			14.7		1	0.5			1.5			14.7		1
10/30/21 19:00	0.5			1.6			14.6		1	0.6			1.5			14.7		1
10/30/21 20:00	0.5			1.4			14.6		1	0.6			1.5			14.7		1
10/30/21 21:00	0.5			1.6			14.6		1	0.6			1.6			14.7		1
10/30/21 22:00	0.5			1.5			14.6		1	0.6			1.5			14.7		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/30/21 23:00	0.6			1.6			14.6		1	0.6			1.5			14.6		1
10/31/21 0:00	0.5			1.5			14.6		1	0.6			1.5			14.7		1
10/31/21 1:00	0.5			1.5			14.6		1	0.6			1.5			14.7		1
10/31/21 2:00	0.5			1.5			14.6		1	0.6			1.5			14.7		1
10/31/21 3:00	0.6			1.5			14.6		1	0.6			1.5			14.7		1
10/31/21 4:00	0.5			1.5			14.6		1	0.6			1.5			14.7		1
10/31/21 5:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
10/31/21 6:00	0.6			1.6			14.4		1	0.7			1.6			14.5		1
10/31/21 7:00	0.5			1.8			14.7		1	0.6			1.5			14.7		1
10/31/21 8:00	0.5			1.6			14.7		1	0.6			1.5			14.7		1
10/31/21 9:00	0.5			1.6			14.6		1	0.6			1.5			14.7		1
10/31/21 10:00	0.4			1.5			14.7		1	0.5			1.5			14.7		1
10/31/21 11:00	0.4			1.5			14.7		1	0.5			1.5			14.7		1
10/31/21 12:00	0.4			1.5			14.7		1	0.5			1.5			14.7		1
10/31/21 13:00	0.4			1.5			14.7		1	0.5			1.5			14.7		1
10/31/21 14:00	0.4			1.5			14.7		1	0.5			1.5			14.7		1
10/31/21 15:00	0.5			1.4			14.6		1	0.6			1.4			14.6		1
10/31/21 16:00	0.4			1.5			14.7		1	0.5			1.6			14.7		1
10/31/21 17:00	0.4			1.5			14.7		1	0.5			1.5			14.8		1
10/31/21 18:00	0.4			1.5			14.7		1	0.5			1.5			14.7		1
10/31/21 19:00	0.5			1.5			14.7		1	0.6			1.5			14.7		1
10/31/21 20:00	0.6			1.5			14.7		1	0.7			1.5			14.7		1
10/31/21 21:00	0.6			1.5			14.7		1	0.7			1.5			14.7		1
10/31/21 22:00	0.6			1.5			14.7		1	0.7			1.5			14.8		1
10/31/21 23:00	0.6			1.6			14.6		1	0.7			1.5			14.7		1
11/01/21 0:00	0.5			1.6			14.6		1	0.6			1.5			14.7		1
11/01/21 1:00	0.6			1.5			14.6		1	0.7			1.5			14.7		1
11/01/21 2:00	0.5			1.5			14.7		1	0.6			1.5			14.7		1
11/01/21 3:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/01/21 4:00	0.6			1.5			14.5		1	0.8			1.4			14.5		1
11/01/21 5:00	0.6			1.7			14.5		1	0.7			1.6			14.6		1
11/01/21 6:00	0.7			1.4			14.4		1	0.8			1.3			14.4		1
11/01/21 7:00	0.7			1.6			14.5		1	0.7			1.6			14.5		1
11/01/21 8:00	0.6			1.5			14.6		1	0.6			1.5			14.6		1
11/01/21 9:00	0.7			1.4			14.4		1	0.8			1.4			14.4		1
11/01/21 10:00	0.7			1.6			14.5		1	0.7			1.6			14.5		1
11/01/21 11:00	0.7			1.4			14.3		1	0.9			1.3			14.3		1
11/01/21 12:00	0.7			1.5			14.4		1	0.8			1.5			14.4		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/01/21 13:00	0.7			1.5			14.4		1	0.8			1.5			14.4		1
11/01/21 14:00	0.7			1.5			14.3		1	0.8			1.4			14.4		1
11/01/21 15:00	0.7			1.5			14.4		1	0.8			1.5			14.5		1
11/01/21 16:00	0.7			1.5			14.4		1	0.8			1.5			14.5		1
11/01/21 17:00	0.7			1.5			14.4		1	0.8			1.5			14.4		1
11/01/21 18:00	0.7			1.5			14.4		1	0.8			1.5			14.4		1
11/01/21 19:00	0.7			1.5			14.4		1	0.8			1.5			14.4		1
11/01/21 20:00	0.6			1.5			14.4		1	0.8			1.5			14.4		1
11/01/21 21:00	0.7			1.5			14.3		1	0.8			1.5			14.4		1
11/01/21 22:00	0.7			1.6			14.4		1	0.7			1.5			14.5		1
11/01/21 23:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/02/21 0:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/02/21 1:00	0.6			1.6			14.5		1	0.6			1.6			14.6		1
11/02/21 2:00	0.5			1.4			14.6		1	0.6			1.4			14.7		1
11/02/21 3:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/02/21 4:00	0.6			1.6			14.5		1	0.6			1.5			14.6		1
11/02/21 5:00	0.6			1.4			14.5		1	0.7			1.5			14.6		1
11/02/21 6:00	0.7			1.5			14.3		1	0.8			1.5			14.3		1
11/02/21 7:00	0.6			1.8			14.5		1	0.7			1.5			14.5		1
11/02/21 8:00	0.5			1.5			14.7		1	0.6			1.5			14.7		1
11/02/21 9:00	0.5			1.5			14.7		1	0.6			1.5			14.7		1
11/02/21 10:00	0.5			1.5			14.6		1	0.6			1.5			14.7		1
11/02/21 11:00	0.5			1.5			14.7		1	0.5			1.5			14.7		1
11/02/21 12:00	0.5			1.5			14.6		1	0.5			1.5			14.7		1
11/02/21 13:00	0.5			1.5			14.7		1	0.5			1.5			14.7		1
11/02/21 14:00	0.5			1.5			14.7		1	0.5			1.5			14.7		1
11/02/21 15:00	0.5			1.5			14.7		1	0.5			1.5			14.7		1
11/02/21 16:00	0.6			1.4			14.5		1	0.7			1.4			14.5		1
11/02/21 17:00	0.6			1.5			14.4		1	0.7			1.5			14.4		1
11/02/21 18:00	0.6			1.5			14.3		1	0.8			1.5			14.4		1
11/02/21 19:00	0.6			1.5			14.4		1	0.7			1.5			14.4		1
11/02/21 20:00	0.6			1.5			14.4		1	0.7			1.5			14.4		1
11/02/21 21:00	0.7			1.5			14.4		1	0.8			1.5			14.4		1
11/02/21 22:00	0.7			1.5			14.3		1	0.8			1.5			14.4		1
11/02/21 23:00	0.8			1.5			14.2		1	0.9			1.5			14.2		1
11/03/21 0:00	0.8			1.5			14.2		1	0.9			1.5			14.2		1
11/03/21 1:00	0.8			1.5			14.2		1	0.9			1.5			14.2		1
11/03/21 2:00	0.8			1.5			14.2		1	1			1.5			14.2		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/03/21 3:00	0.9			1.5			14.2		1	1			1.5			14.2		1
11/03/21 4:00	0.8			1.5			14.2		1	0.9			1.5			14.3		1
11/03/21 5:00	0.7			1.5			14.3		1	0.9			1.5			14.3		1
11/03/21 6:00	0.8			1.5			14.3		1	0.9			1.5			14.3		1
11/03/21 7:00	0.7			1.8			14.5		1	0.7			1.6			14.5		1
11/03/21 8:00	0.6			1.6			14.6		1	0.6			1.5			14.7		1
11/03/21 9:00	0.5			1.5			14.7		1	0.5			1.5			14.7		1
11/03/21 10:00	0.5			1.5			14.7		1	0.5			1.5			14.7		1
11/03/21 11:00	0.5			1.5			14.7		1	0.5			1.5			14.7		1
11/03/21 12:00	0.5			1.5			14.7		1	0.5			1.5			14.7		1
11/03/21 13:00	0.5			1.5			14.7		1	0.5			1.5			14.7		1
11/03/21 14:00	0.5			1.5			14.7		1	0.5			1.6			14.7		1
11/03/21 15:00	0.6			1.3			14.6		1	0.6			1.4			14.6		1
11/03/21 16:00	0.6			1.5			14.4		1	0.7			1.5			14.5		1
11/03/21 17:00	0.6			1.5			14.4		1	0.7			1.5			14.5		1
11/03/21 18:00	0.6			1.5			14.3		1	0.7			1.5			14.4		1
11/03/21 19:00	0.6			1.5			14.4		1	0.7			1.5			14.4		1
11/03/21 20:00	0.7			1.5			14.4		1	0.7			1.5			14.4		1
11/03/21 21:00	0.8			1.5			14.3		1	0.8			1.5			14.3		1
11/03/21 22:00	0.7			1.6			14.3		1	0.7			1.5			14.4		1
11/03/21 23:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
11/04/21 0:00	0.6			1.6			14.5		1	0.6			1.5			14.6		1
11/04/21 1:00	0.5			1.5			14.7		1	0.5			1.5			14.7		1
11/04/21 2:00	0.6			1.6			14.5		1	0.6			1.7			14.6		1
11/04/21 3:00	0.8			1.2			14.3		1	0.8			1.2			14.4		1
11/04/21 4:00	0.7			1.5			14.4		1	0.7			1.5			14.5		1
11/04/21 5:00	0.7			1.6			14.3		1	0.8			1.5			14.4		1
11/04/21 6:00	0.6			1.5			14.3		1	0.7			1.5			14.4		1
11/04/21 7:00	0.5			1.8			14.5		1	0	X		0	X		0	X	0
11/04/21 8:00	0.5			1.5			14.6		1	0.5			1.8			14.7		1
11/04/21 9:00	0.6			1.5			14.5		1	0.6			1.2			14.5		1
11/04/21 10:00	0.4			1.4			14.7		1	0.5			1.5			14.8		1
11/04/21 11:00	0.4			1.5			14.7		1	0.5			1.5			14.8		1
11/04/21 12:00	0.4			1.5			14.7		1	0.5			1.5			14.8		1
11/04/21 13:00	0.4			1.5			14.7		1	0.5			1.5			14.8		1
11/04/21 14:00	0.4			1.6			14.7		1	0.5			1.5			14.8		1
11/04/21 15:00	0.5			1.3			14.6		1	0.6			1.3			14.6		1
11/04/21 16:00	0.6			1.6			14.5		1	0.6			1.6			14.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/04/21 17:00	0.5			1.6			14.6		1	0.5			1.5			14.7		1
11/04/21 18:00	0.5			1.5			14.6		1	0.6			1.5			14.7		1
11/04/21 19:00	0.6			1.6			14.6		1	0.6			1.5			14.6		1
11/04/21 20:00	0.6			1.6			14.6		1	0.7			1.5			14.7		1
11/04/21 21:00	0.6			1.5			14.7		1	0.6			1.5			14.8		1
11/04/21 22:00	0.5			1.5			14.7		1	0.5			1.5			14.8		1
11/04/21 23:00	0.5			1.5			14.8		1	0.5			1.5			14.8		1
11/05/21 0:00	0.5			1.5			14.7		1	0.4			1.5			14.8		1
11/05/21 1:00	0.4			1.6			14.8		1	0.5			1.5			14.8		1
11/05/21 2:00	0.5			1.5			14.8		1	0.5			1.5			14.8		1
11/05/21 3:00	0.6			1.5			14.6		1	0.6			1.5			14.7		1
11/05/21 4:00	0.6			1.5			14.4		1	0.7			1.5			14.5		1
11/05/21 5:00	0.7			1.6			14.4		1	0.7			1.4			14.5		1
11/05/21 6:00	0.7			1.5			14.3		1	0.8			1.5			14.4		1
11/05/21 7:00	0.7			1.8			14.4		1	0.7			1.5			14.5		1
11/05/21 8:00	0.6			1.6			14.6		1	0.7			1.5			14.7		1
11/05/21 9:00	0.6			1.6			14.8		1	0.6			1.4			14.8		1
11/05/21 10:00	0.5			1.5			14.8		1	0.5			1.5			14.8		1
11/05/21 11:00	0.5			1.5			14.7		1	0.5			1.5			14.8		1
11/05/21 12:00	0.4			1.5			14.7		1	0.5			1.5			14.7		1
11/05/21 13:00	0.4			1.5			14.7		1	0.5			1.5			14.7		1
11/05/21 14:00	0.6			1.3			14.5		1	0.6			1.3			14.6		1
11/05/21 15:00	0.6			1.5			14.4		1	0.7			1.5			14.5		1
11/05/21 16:00	0.7			1.5			14.4		1	0.7			1.5			14.5		1
11/05/21 17:00	0.7			1.5			14.3		1	0.8			1.5			14.4		1
11/05/21 18:00	0.6			1.6			14.4		1	0.7			1.4			14.5		1
11/05/21 19:00	0.7			1.4			14.3		1	0.8			1.4			14.4		1
11/05/21 20:00	0.7			1.6			14.4		1	0.7			1.4			14.5		1
11/05/21 21:00	0.7			1.6			14.4		1	0.7			1.6			14.4		1
11/05/21 22:00	0.7			1.6			14.4		1	0.7			1.4			14.5		1
11/05/21 23:00	0.7			1.5			14.3		1	0.8			1.5			14.4		1
11/06/21 0:00	0.6			1.6			14.5		1	0.6			1.4			14.6		1
11/06/21 1:00	0.8			1.4			14.2		1	0.9			1.5			14.3		1
11/06/21 2:00	0.6			1.7			14.4		1	0.7			1.5			14.5		1
11/06/21 3:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
11/06/21 4:00	0.7			1.4			14.4		1	0.7			1.5			14.5		1
11/06/21 5:00	0.8			1.5			14.3		1	0.8			1.4			14.4		1
11/06/21 6:00	0.7			1.5			14.3		1	0.7			1.5			14.4		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/06/21 7:00	0.6			1.7			14.4		1	0.7			1.6			14.5		1
11/06/21 8:00	0.6			1.7			14.4		1	0.7			1.6			14.5		1
11/06/21 9:00	0.5			1.6			14.7		1	0.5			1.4			14.7		1
11/06/21 10:00	0.5			1.5			14.7		1	0.5			1.5			14.7		1
11/06/21 11:00	0.5			1.5			14.7		1	0.5			1.5			14.7		1
11/06/21 12:00	0.5			1.5			14.8		1	0.5			1.5			14.8		1
11/06/21 13:00	0.5			1.5			14.8		1	0.5			1.5			14.8		1
11/06/21 14:00	0.4			1.5			14.8		1	0.5			1.5			14.8		1
11/06/21 15:00	0.5			1.3			14.7		1	0.6			1.3			14.7		1
11/06/21 16:00	0.6			1.5			14.5		1	0.7			1.5			14.5		1
11/06/21 17:00	0.6			1.5			14.4		1	0.7			1.5			14.4		1
11/06/21 18:00	0.6			1.6			14.4		1	0.7			1.5			14.5		1
11/06/21 19:00	0.6			1.5			14.4		1	0.7			1.5			14.5		1
11/06/21 20:00	0.7			1.5			14.3		1	0.8			1.5			14.3		1
11/06/21 21:00	0.7			1.7			14.3		1	0.8			1.6			14.4		1
11/06/21 22:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
11/06/21 23:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
11/07/21 0:00	0.4			1.6			14.8		1	0.4			1.5			14.8		1
11/07/21 1:00	0.4			1.5			14.8		1	0.4			1.5			14.8		1
11/07/21 2:00	0.5			1.4			14.8		1	0.5			1.5			14.8		1
11/07/21 3:00	0.5			1.6			14.8		1	0	X		0	X		0	X	0
11/07/21 4:00	0.4			1.5			14.8		1	0	X		0	X		0	X	0
11/07/21 5:00	0.4			1.5			14.8		1	0.5			1.2			14.8		1
11/07/21 6:00	0.6			1.5			14.4		1	0.7			0.9			14.5		1
11/07/21 7:00	0.7			1.9			14.4		1	0.8			1.7			14.4		1
11/07/21 8:00	0.4			2			14.8		1	0.4			1.4			14.9		1
11/07/21 9:00	0.4			1.6			14.8		1	0.4			1.5			14.8		1
11/07/21 10:00	0.4			1.5			14.8		1	0.4			1.5			14.8		1
11/07/21 11:00	0.4			1.5			14.8		1	0.4			1.5			14.8		1
11/07/21 12:00	0.4			1.5			14.8		1	0.5			1.5			14.8		1
11/07/21 13:00	0.4			1.5			14.8		1	0.5			1.4			14.8		1
11/07/21 14:00	0.5			1.5			14.7		1	0.5			1.5			14.7		1
11/07/21 15:00	0.6			1.3			14.5		1	0.7			1.2			14.6		1
11/07/21 16:00	0.7			1.5			14.4		1	0.7			1.4			14.5		1
11/07/21 17:00	0.7			1.7			14.3		1	0.8			1.5			14.3		1
11/07/21 18:00	0.6			1.5			14.4		1	0.7			1.3			14.5		1
11/07/21 19:00	0.7			1.6			14.3		1	0.8			1.5			14.3		1
11/07/21 20:00	0.7			1.8			14.5		1	0.8			1.5			14.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/07/21 21:00	0.8			1.5			14.6		1	0.8			1.4			14.6		1
11/07/21 22:00	0.7			1.5			14.5		1	0.7			1.5			14.6		1
11/07/21 23:00	0.5			1.7			14.8		1	0.5			1.5			14.9		1
11/08/21 0:00	0.5			1.6			14.8		1	0.6			1.4			14.8		1
11/08/21 1:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/08/21 2:00	0.7			1.4			14.4		1	0.8			1.4			14.5		1
11/08/21 3:00	0.8			1.6			14.3		1	0.9			1.5			14.4		1
11/08/21 4:00	0.8			1.5			14.4		1	0.8			1.5			14.4		1
11/08/21 5:00	0.7			1.5			14.4		1	0.8			1.5			14.4		1
11/08/21 6:00	0.7			1.5			14.3		1	0.8			1.4			14.4		1
11/08/21 7:00	0.6			1.9			14.5		1	0.8			1.5			14.5		1
11/08/21 8:00	0.5			1.6			14.8		1	0.6			1.2			14.8		1
11/08/21 9:00	0.5			1.4			14.8		1	0.5			1.4			14.8		1
11/08/21 10:00	0.5			1.3			14.8		1	0.6			1.4			14.8		1
11/08/21 11:00	0.5			1.4			14.7		1	0.5			1.4			14.8		1
11/08/21 12:00	0.5			1.4			14.7		1	0.5			1.4			14.7		1
11/08/21 13:00	0.5			1.4			14.7		1	0.5			1.4			14.8		1
11/08/21 14:00	0.5			1.4			14.7		1	0.5			1.4			14.8		1
11/08/21 15:00	0.6			1.3			14.5		1	0.7			1.3			14.5		1
11/08/21 16:00	1			1.6			14.3		1	1.2			1.5			14.3		1
11/08/21 17:00	1.3			1.5			14.1		1	1.5			1.5			14.2		1
11/08/21 18:00	1.3			1.5			14.1		1	1.4			1.5			14.2		1
11/08/21 19:00	1.2			1.5			14.2		1	1.3			1.5			14.3		1
11/08/21 20:00	0.7			1.5			14.4		1	0.8			1.5			14.4		1
11/08/21 21:00	0.7			1.6			14.3		1	0.8			1.5			14.4		1
11/08/21 22:00	0.7			1.6			14.4		1	0.7			1.5			14.5		1
11/08/21 23:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
11/09/21 0:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
11/09/21 1:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
11/09/21 2:00	0.5			1.5			14.5		1	0.6			1.5			14.6		1
11/09/21 3:00	0.5			1.5			14.7		1	0.5			1.4			14.7		1
11/09/21 4:00	0.6			1.5			14.5		1	0.6			1.6			14.6		1
11/09/21 5:00	0.6			1.4			14.4		1	0.6			1.4			14.5		1
11/09/21 6:00	0.6			1.6			14.4		1	0.7			1.5			14.5		1
11/09/21 7:00	0.6			1.8			14.5		1	0.6			1.6			14.6		1
11/09/21 8:00	0.5			1.6			14.7		1	0.5			1.5			14.7		1
11/09/21 9:00	0.5			1.5			14.7		1	0.5			1.5			14.7		1
11/09/21 10:00	0.5			1.6			14.6		1	0.6			1.5			14.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/09/21 11:00	0.5			1.6			14.7		1	0.5			1.5			14.7		1
11/09/21 12:00	0.5			1.5			14.7		1	0.5			1.5			14.7		1
11/09/21 13:00	0.5			1.5			14.7		1	0.5			1.5			14.7		1
11/09/21 14:00	0.5			1.5			14.6		1	0.6			1.5			14.6		1
11/09/21 15:00	0.6			1.5			14.5		1	0.6			1.4			14.6		1
11/09/21 16:00	0.6			1.5			14.4		1	0.6			1.4			14.5		1
11/09/21 17:00	0.7			1.5			14.3		1	0.7			1.5			14.4		1
11/09/21 18:00	0.6			1.5			14.4		1	0.7			1.5			14.5		1
11/09/21 19:00	0.6			1.5			14.4		1	0.7			1.5			14.5		1
11/09/21 20:00	0.7			1.5			14.4		1	0.7			1.5			14.4		1
11/09/21 21:00	0.6			1.7			14.4		1	0.6			1.6			14.5		1
11/09/21 22:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
11/09/21 23:00	0.6			1.6			14.6		1	0.6			1.5			14.7		1
11/10/21 0:00	0.5			1.7			14.7		1	0.6			1.5			14.7		1
11/10/21 1:00	0.5			1.5			14.8		1	0.5			1.5			14.8		1
11/10/21 2:00	0.4			1.5			14.8		1	0.5			1.5			14.8		1
11/10/21 3:00	0.5			1.5			14.8		1	0.5			1.5			14.8		1
11/10/21 4:00	0.4			1.5			14.8		1	0.5			1.5			14.8		1
11/10/21 5:00	0.6			1.3			14.5		1	0.6			1.4			14.6		1
11/10/21 6:00	0.7			1.5			14.3		1	0.7			1.4			14.4		1
11/10/21 7:00	0.6			1.8			14.5		1	0.7			1.6			14.5		1
11/10/21 8:00	0.4			1.5			14.8		1	0.5			1.5			14.8		1
11/10/21 9:00	0.5			1.6			14.7		1	0.5			1.6			14.7		1
11/10/21 10:00	0.5			1.6			14.6		1	0.5			1.5			14.7		1
11/10/21 11:00	0.4			1.5			14.8		1	0.5			1.5			14.8		1
11/10/21 12:00	0.4			1.6			14.8		1	0.5			1.5			14.8		1
11/10/21 13:00	0.4			1.5			14.8		1	0.5			1.5			14.8		1
11/10/21 14:00	0.4			1.5			14.7		1	0.5			1.5			14.7		1
11/10/21 15:00	0.4			1.5			14.7		1	0.5			1.5			14.7		1
11/10/21 16:00	0.5			1.5			14.6		1	0.6			1.5			14.6		1
11/10/21 17:00	0.5			1.6			14.6		1	0.6			1.5			14.6		1
11/10/21 18:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
11/10/21 19:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
11/10/21 20:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
11/10/21 21:00	0.6			1.8			14.5		1	0.7			1.4			14.6		1
11/10/21 22:00	0.6			1.6			14.5		1	0.6			1.5			14.6		1
11/10/21 23:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
11/11/21 0:00	0.5			1.7			14.7		1	0.6			1.5			14.7		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/11/21 1:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
11/11/21 2:00	0.5			1.7			14.8		1	0.6			1.5			14.8		1
11/11/21 3:00	0.7			1.7			14.8		1	0.7			1.5			14.8		1
11/11/21 4:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
11/11/21 5:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/11/21 6:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
11/11/21 7:00	0.6			1.6			14.6		1	0.7			1.5			14.6		1
11/11/21 8:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
11/11/21 9:00	0.5			1.5			14.5		1	0.6			1.5			14.6		1
11/11/21 10:00	0.5			1.5			14.5		1	0.6			1.5			14.6		1
11/11/21 11:00	0.4			1.6			14.8		1	0.5			1.5			14.8		1
11/11/21 12:00	0.4			1.5			14.8		1	0.5			1.5			14.8		1
11/11/21 13:00	0.5			1.5			14.7		1	0.5			1.5			14.7		1
11/11/21 14:00	0.5			1.5			14.7		1	0.5			1.5			14.7		1
11/11/21 15:00	0.6			1.3			14.6		1	0.6			1.3			14.6		1
11/11/21 16:00	0.9			1.5			14.4		1	1.1			1.4			14.4		1
11/11/21 17:00	1.5			1.5			14.2		1	1.8			1.5			14.2		1
11/11/21 18:00	1.5			1.5			14.1		1	1.4			1.5			14.2		1
11/11/21 19:00	1.5			1.5			14.1		1	1.4			1.5			14.2		1
11/11/21 20:00	1.6			1.5			14.1		1	1.5			1.5			14.2		1
11/11/21 21:00	1.6			1.5			14.1		1	1.5			1.5			14.2		1
11/11/21 22:00	1.2			1.6			14.2		1	1.3			1.6			14.3		1
11/11/21 23:00	0.6			1.5			14.5		1	0.7			1.5			14.5		1
11/12/21 0:00	0.5			1.6			14.7		1	0.6			1.5			14.7		1
11/12/21 1:00	0.5			1.5			14.8		1	0.5			1.5			14.8		1
11/12/21 2:00	0.5			1.5			14.8		1	0.5			1.5			14.8		1
11/12/21 3:00	0.6			1.6			14.8		1	0.6			1.5			14.8		1
11/12/21 4:00	0.5			1.5			14.8		1	0.5			1.5			14.8		1
11/12/21 5:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/12/21 6:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/12/21 7:00	0.5			1.7			14.7		1	0.6			1.5			14.8		1
11/12/21 8:00	0.5			1.6			14.7		1	0.6			1.5			14.7		1
11/12/21 9:00	0.5			1.5			14.8		1	0.5			1.5			14.8		1
11/12/21 10:00	0.4			1.5			14.8		1	0.5			1.5			14.8		1
11/12/21 11:00	0.4			1.5			14.8		1	0.5			1.5			14.8		1
11/12/21 12:00	0.4			1.6			14.8		1	0.5			1.5			14.8		1
11/12/21 13:00	0.4			1.5			14.8		1	0.5			1.5			14.8		1
11/12/21 14:00	0.5			1.5			14.7		1	0.5			1.5			14.7		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/12/21 15:00	0.6			1.5			14.5		1	0.6			1.4			14.6		1
11/12/21 16:00	0.5			1.7			14.6		1	0.6			1.6			14.6		1
11/12/21 17:00	0.6			1.6			14.5		1	0.6			1.6			14.6		1
11/12/21 18:00	0.5			1.6			14.8		1	0.6			1.5			14.8		1
11/12/21 19:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/12/21 20:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/12/21 21:00	0.7			1.5			14.4		1	0.7			1.2			14.4		1
11/12/21 22:00	0.6			1.7			14.6		1	0.6			1.6			14.7		1
11/12/21 23:00	0.5			1.6			14.8		1	0.5			1.5			14.8		1
11/13/21 0:00	0.5			1.6			14.7		1	0.6			1.5			14.7		1
11/13/21 1:00	0.5			1.6			14.7		1	0.6			1.5			14.7		1
11/13/21 2:00	0.6			1.5			14.5		1	0.7			1.4			14.6		1
11/13/21 3:00	0.6			1.5			14.5		1	0.7			1.3			14.6		1
11/13/21 4:00	0.7			1.6			14.4		1	0.8			1.2			14.5		1
11/13/21 5:00	0.7			1.4			14.4		1	0.8			1.3			14.5		1
11/13/21 6:00	0.7			1.5			14.4		1	0.8			1.5			14.4		1
11/13/21 7:00	0.7			1.5			14.3		1	0.8			1.5			14.4		1
11/13/21 8:00	0.7			1.5			14.3		1	0.8			1.5			14.4		1
11/13/21 9:00	0.7			1.5			14.4		1	0.8			1.5			14.4		1
11/13/21 10:00	0.7			1.6			14.4		1	0.8			1.5			14.4		1
11/13/21 11:00	0.6			1.6			14.6		1	0.6			1.4			14.6		1
11/13/21 12:00	0.5			1.4			14.7		1	0.5			1.5			14.7		1
11/13/21 13:00	0.5			1.6			14.7		1	0.5			1.6			14.7		1
11/13/21 14:00	0.5			1.5			14.7		1	0.5			1.5			14.7		1
11/13/21 15:00	0.6			1.4			14.5		1	0.7			1.5			14.5		1
11/13/21 16:00	0.7			1.5			14.4		1	0.7			1.4			14.5		1
11/13/21 17:00	0.7			1.6			14.3		1	0.8			1.6			14.4		1
11/13/21 18:00	0.7			1.5			14.4		1	0.8			1.4			14.4		1
11/13/21 19:00	0.8			1.4			14.3		1	0.9			1.3			14.3		1
11/13/21 20:00	0.8			1.5			14.3		1	0.8			1.6			14.3		1
11/13/21 21:00	0.7			1.7			14.4		1	0.7			1.6			14.5		1
11/13/21 22:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
11/13/21 23:00	0.5			1.7			14.7		1	0.5			1.5			14.8		1
11/14/21 0:00	0.4			1.5			14.8		1	0.5			1.5			14.8		1
11/14/21 1:00	0.4			1.5			14.8		1	0.5			1.5			14.8		1
11/14/21 2:00	0.4			1.5			14.8		1	0.5			1.5			14.8		1
11/14/21 3:00	0.5			1.6			14.8		1	0.5			1.5			14.8		1
11/14/21 4:00	0.4			1.5			14.8		1	0.5			1.5			14.8		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/14/21 5:00	0.4			1.5			14.8		1	0.5			1.5			14.8		1
11/14/21 6:00	0.5			1.5			14.8		1	0.5			1.5			14.8		1
11/14/21 7:00	0.5			1.6			14.7		1	0.6			1.5			14.7		1
11/14/21 8:00	0.5			1.5			14.7		1	0.5			1.5			14.7		1
11/14/21 9:00	0.5			1.5			14.8		1	0.5			1.5			14.8		1
11/14/21 10:00	0.4			1.5			14.8		1	0.5			1.5			14.8		1
11/14/21 11:00	0.5			1.5			14.8		1	0.5			1.5			14.7		1
11/14/21 12:00	0.4			1.5			14.8		1	0.5			1.5			14.7		1
11/14/21 13:00	0.5			1.5			14.7		1	0.5			1.5			14.8		1
11/14/21 14:00	0.5			1.5			14.8		1	0.5			1.5			14.8		1
11/14/21 15:00	0.6			1.3			14.6		1	0.6			1.3			14.6		1
11/14/21 16:00	0.5			1.6			14.7		1	0.6			1.6			14.7		1
11/14/21 17:00	0.5			1.6			14.7		1	0.5			1.6			14.8		1
11/14/21 18:00	0.5			1.5			14.7		1	0.5			1.5			14.8		1
11/14/21 19:00	0.5			1.7			14.7		1	0.6			1.5			14.7		1
11/14/21 20:00	0.6			1.5			14.5		1	0.7			1.4			14.6		1
11/14/21 21:00	0.6			1.6			14.5		1	0.7			1.6			14.6		1
11/14/21 22:00	0.5			1.7			14.7		1	0.6			1.5			14.7		1
11/14/21 23:00	0.5			1.6			14.8		1	0.5			1.5			14.8		1
11/15/21 0:00	0.5			1.5			14.8		1	0.6			1.5			14.8		1
11/15/21 1:00	0.5			1.5			14.8		1	0.5			1.5			14.8		1
11/15/21 2:00	0.5			1.5			14.8		1	0.5			1.6			14.8		1
11/15/21 3:00	0.6			1.6			14.7		1	0.6			1.5			14.8		1
11/15/21 4:00	0.5			1.6			14.7		1	0.6			1.5			14.7		1
11/15/21 5:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/15/21 6:00	0.7			1.5			14.4		1	0.7			1.4			14.5		1
11/15/21 7:00	0.7			1.6			14.5		1	0.7			1.4			14.5		1
11/15/21 8:00	0.5			1.6			14.7		1	0.6			1.4			14.7		1
11/15/21 9:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
11/15/21 10:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
11/15/21 11:00	0.5			1.6			14.6		1	0.6			1.6			14.7		1
11/15/21 12:00	0.5			1.6			14.8		1	0.5			1.5			14.8		1
11/15/21 13:00	0.5			1.5			14.7		1	0.6			1.5			14.7		1
11/15/21 14:00	0.6			1.4			14.4		1	0.7			1.3			14.5		1
11/15/21 15:00	0.7			1.5			14.4		1	0.7			1.4			14.5		1
11/15/21 16:00	0.7			1.5			14.4		1	0.7			1.5			14.5		1
11/15/21 17:00	0.6			1.6			14.5		1	0.7			1.6			14.6		1
11/15/21 18:00	0.7			1.5			14.5		1	0.7			1.5			14.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/15/21 19:00	0.8			1.6			14.3		1	0.9			1.5			14.4		1
11/15/21 20:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
11/15/21 21:00	0.7			1.5			14.4		1	0.8			1.4			14.5		1
11/15/21 22:00	0.6			1.5			14.5		1	0.7			1.6			14.6		1
11/15/21 23:00	0.6			1.6			14.7		1	0.6			1.5			14.8		1
11/16/21 0:00	0.6			1.5			14.5		1	0.7			1.6			14.6		1
11/16/21 1:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
11/16/21 2:00	0.5			1.7			14.7		1	0.6			1.6			14.7		1
11/16/21 3:00	0.5			1.6			14.8		1	0.5			1.5			14.8		1
11/16/21 4:00	0.6			1.5			14.6		1	0.6			1.5			14.6		1
11/16/21 5:00	0.7			1.4			14.4		1	0.7			1.3			14.5		1
11/16/21 6:00	0.7			1.5			14.4		1	0.7			1.5			14.4		1
11/16/21 7:00	0.7			1.5			14.4		1	0.7			1.5			14.4		1
11/16/21 8:00	0.7			1.7			14.4		1	0.7			1.6			14.4		1
11/16/21 9:00	0.7			1.2			14.4		1	0.7			1.2			14.5		1
11/16/21 10:00	0.6			1.6			14.6		1	0.6			1.3			14.7		1
11/16/21 11:00	0.5			1.6			14.6		1	0.6			1.4			14.7		1
11/16/21 12:00	0.5			1.5			14.7		1	0.5			1.4			14.7		1
11/16/21 13:00	0.5			1.5			14.7		1	0.6			1.5			14.7		1
11/16/21 14:00	0.5			1.5			14.7		1	0.6			1.5			14.7		1
11/16/21 15:00	0.6			1.4			14.5		1	0.7			1.4			14.6		1
11/16/21 16:00	0.6			1.6			14.5		1	0.7			1.6			14.6		1
11/16/21 17:00	0.7			1.4			14.4		1	0.8			1.3			14.4		1
11/16/21 18:00	0.8			1.6			14.3		1	0.9			1.6			14.3		1
11/16/21 19:00	0.8			1.5			14.3		1	0.8			1.3			14.4		1
11/16/21 20:00	0.8			1.5			14.3		1	0.8			1.5			14.4		1
11/16/21 21:00	0.8			1.5			14.3		1	0.8			1.5			14.4		1
11/16/21 22:00	0.8			1.6			14.3		1	0.8			1.6			14.4		1
11/16/21 23:00	0.9			1.5			14.2		1	0.9			1.4			14.2		1
11/17/21 0:00	1.5			1.5			14.2		1	1.9			1.5			14.3		1
11/17/21 1:00	1.4			1.6			14.2		1	1.4			1.6			14.3		1
11/17/21 2:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/17/21 3:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/17/21 4:00	0.7			1.4			14.4		1	0.8			1.3			14.5		1
11/17/21 5:00	0.7			1.6			14.4		1	0.7			1.5			14.5		1
11/17/21 6:00	0.7			1.5			14.3		1	0.8			1.5			14.4		1
11/17/21 7:00	0.7			1.7			14.4		1	0.8			1.6			14.5		1
11/17/21 8:00	0.6			1.5			14.5		1	0.6			1.3			14.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/17/21 9:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/17/21 10:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
11/17/21 11:00	0.5			1.5			14.7		1	0.5			1.3			14.8		1
11/17/21 12:00	0.5			1.3			14.8		1	0.5			1.3			14.8		1
11/17/21 13:00	0.5			1.4			14.8		1	0.5			1.3			14.8		1
11/17/21 14:00	0.5			1.3			14.8		1	0.5			1.3			14.8		1
11/17/21 15:00	0.6			1.2			14.6		1	0.6			1.2			14.6		1
11/17/21 16:00	0.7			1.4			14.4		1	0.7			1.3			14.5		1
11/17/21 17:00	0.7			1.3			14.3		1	0.7			1.3			14.4		1
11/17/21 18:00	0.7			1.3			14.4		1	0.7			1.3			14.5		1
11/17/21 19:00	0.8			1.3			14.4		1	0.8			1.3			14.4		1
11/17/21 20:00	0.8			1.3			14.3		1	0.8			1.3			14.4		1
11/17/21 21:00	0.9			1.3			14.3		1	0.9			1.3			14.3		1
11/17/21 22:00	0.7			1.6			14.4		1	0.8			1.4			14.5		1
11/17/21 23:00	0.6			1.3			14.5		1	0.7			1.3			14.6		1
11/18/21 0:00	0.6			1.3			14.5		1	0.7			1.3			14.6		1
11/18/21 1:00	0.6			1.3			14.5		1	0.7			1.3			14.6		1
11/18/21 2:00	0.6			1.4			14.5		1	0.7			1.4			14.6		1
11/18/21 3:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/18/21 4:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/18/21 5:00	0.6			1.4			14.4		1	0.7			1.3			14.5		1
11/18/21 6:00	0.9			1.6			14.3		1	0.9			1.5			14.4		1
11/18/21 7:00	0.8			1.6			14.3		1	0.9			1.6			14.3		1
11/18/21 8:00	0.8			1.4			14.3		1	0.9			1.3			14.4		1
11/18/21 9:00	0.6			1.5			14.5		1	0.7			1.2			14.6		1
11/18/21 10:00	0.5			1.3			14.7		1	0.5			1.2			14.8		1
11/18/21 11:00	0.5			1.2			14.7		1	0.5			1.2			14.7		1
11/18/21 12:00	0.5			1.2			14.7		1	0.5			1.2			14.8		1
11/18/21 13:00	0.6			1.3			14.5		1	0.7			1.3			14.6		1
11/18/21 14:00	0.7			1.4			14.4		1	0.7			1.4			14.5		1
11/18/21 15:00	0.7			1.2			14.4		1	0.7			1.2			14.5		1
11/18/21 16:00	0.8			1.2			14.3		1	0.8			1.2			14.4		1
11/18/21 17:00	0.9			1.2			14.3		1	0.9			1.2			14.4		1
11/18/21 18:00	0.7			1.4			14.4		1	0.7			1.4			14.5		1
11/18/21 19:00	0.7			1.5			14.4		1	0.7			1.5			14.4		1
11/18/21 20:00	0.7			1.6			14.3		1	0.8			1.6			14.4		1
11/18/21 21:00	1			1.3			14.2		1	1			1.1			14.3		1
11/18/21 22:00	0.7			1.5			14.4		1	0.8			1.3			14.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/18/21 23:00	0.7			1.4			14.4		1	0.8			1.2			14.5		1
11/19/21 0:00	0.5			1.8			15.3		1	0.7			1.2			14.6		1
11/19/21 1:00	0	X		0	X		0	X	1	0.7			1.3			14.6		1
11/19/21 2:00	0	X		0	X		0	X	1	0.7			1.4			14.6		1
11/19/21 3:00	0	X		0	X		0	X	1	0.8			1.4			14.5		1
11/19/21 4:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
11/19/21 5:00	0	X		0	X		0	X	1	0.7			1.5			14.6		1
11/19/21 6:00	0	X		0	X		0	X	1	0.7			1.4			14.6		1
11/19/21 7:00	0			0			20.4		1	0.8			1.3			14.4		1
11/19/21 8:00	0.6			2.1			14.9		1	0.8			1.7			14.4		1
11/19/21 9:00	0.5			1.3			14.7		1	0.6			1.2			14.7		1
11/19/21 10:00	0.5			1.3			14.7		1	0.6			1.2			14.7		1
11/19/21 11:00	0.6			1.3			14.6		1	0.6			1.2			14.7		1
11/19/21 12:00	0.6			1.2			14.5		1	0.6			1.2			14.6		1
11/19/21 13:00	0.7			1.1			14.4		1	0.7			1			14.5		1
11/19/21 14:00	0.6			1.2			14.4		1	0.7			1.2			14.5		1
11/19/21 15:00	0.6			1.2			14.4		1	0.7			1.2			14.4		1
11/19/21 16:00	0.5			1.4			14.5		1	0.6			1.3			14.6		1
11/19/21 17:00	0.6			1.3			14.4		1	0.7			1.2			14.5		1
11/19/21 18:00	0.6			1.2			14.4		1	0.6			1.2			14.5		1
11/19/21 19:00	0.5			1.2			14.5		1	0.6			1.2			14.6		1
11/19/21 20:00	0.6			1.3			14.3		1	0.7			1.2			14.4		1
11/19/21 21:00	0.6			1.3			14.4		1	0.7			1.2			14.4		1
11/19/21 22:00	0.6			1.3			14.4		1	0.7			1.1			14.5		1
11/19/21 23:00	0.4			1.4			14.7		1	0.5			1.2			14.7		1
11/20/21 0:00	0.4			1.4			14.8		1	0.4			1.2			14.8		1
11/20/21 1:00	0.4			1.3			14.8		1	0.5			1.2			14.8		1
11/20/21 2:00	0.4			1.3			14.8		1	0.5			1.2			14.8		1
11/20/21 3:00	0.5			1.3			14.8		1	0.5			1.2			14.8		1
11/20/21 4:00	0.6			1.2			14.5		1	0.6			1.2			14.6		1
11/20/21 5:00	0.4			1.4			14.7		1	0.5			1.2			14.8		1
11/20/21 6:00	0.6			1.5			14.5		1	0.6			1.4			14.6		1
11/20/21 7:00	0.6			1.8			14.5		1	0.7			1.4			14.5		1
11/20/21 8:00	0.4			1.7			14.9		1	0.4			1.3			14.9		1
11/20/21 9:00	0.4			1.6			14.9		1	0.4			1.3			14.9		1
11/20/21 10:00	0.4			1.4			14.8		1	0.4			1.3			14.8		1
11/20/21 11:00	0.4			1.4			14.8		1	0.5			1.3			14.8		1
11/20/21 12:00	0.4			1.3			14.8		1	0.5			1.3			14.8		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/20/21 13:00	0.4			1.3			14.8		1	0.5			1.3			14.8		1
11/20/21 14:00	0.4			1.3			14.8		1	0.5			1.3			14.8		1
11/20/21 15:00	0.5			1.1			14.6		1	0.6			1			14.6		1
11/20/21 16:00	0.5			1.3			14.6		1	0.6			1.2			14.6		1
11/20/21 17:00	0.5			1.4			14.5		1	0.6			1.3			14.6		1
11/20/21 18:00	0.5			1.3			14.6		1	0.6			1.3			14.7		1
11/20/21 19:00	0.6			1.2			14.4		1	0.7			1.2			14.5		1
11/20/21 20:00	0.7			1.4			14.3		1	0.8			1.3			14.4		1
11/20/21 21:00	0.8			1.3			14.3		1	0.8			1.3			14.4		1
11/20/21 22:00	0.8			1.6			14.4		1	0.9			1.5			14.4		1
11/20/21 23:00	0.6			1.5			14.6		1	0.7			1.2			14.6		1
11/21/21 0:00	0.7			1.5			14.4		1	0.8			1.3			14.5		1
11/21/21 1:00	0.7			1.5			14.5		1	0.7			1.3			14.6		1
11/21/21 2:00	0.5			1.5			14.8		1	0.6			1.2			14.8		1
11/21/21 3:00	0.6			1.5			14.5		1	0.7			1.4			14.6		1
11/21/21 4:00	0.6			1.3			14.5		1	0.7			1.3			14.6		1
11/21/21 5:00	0.7			1.2			14.3		1	0.8			1.1			14.3		1
11/21/21 6:00	0.8			1.3			14.3		1	0.8			1.3			14.3		1
11/21/21 7:00	0.7			1.3			14.3		1	0.8			1.3			14.3		1
11/21/21 8:00	0.7			1.3			14.4		1	0.7			1.3			14.4		1
11/21/21 9:00	0.7			1.6			14.4		1	0.7			1.5			14.5		1
11/21/21 10:00	0.7			1.3			14.3		1	0.8			1			14.4		1
11/21/21 11:00	0.6			1.5			14.5		1	0.7			1.4			14.5		1
11/21/21 12:00	0.4			1.4			14.8		1	0.5			1.3			14.8		1
11/21/21 13:00	0.4			1.3			14.8		1	0.5			1.3			14.8		1
11/21/21 14:00	0.4			1.3			14.8		1	0.5			1.3			14.8		1
11/21/21 15:00	0.6			1.1			14.6		1	0.6			1.1			14.6		1
11/21/21 16:00	0.7			1.4			14.4		1	0.7			1.2			14.5		1
11/21/21 17:00	0.6			1.5			14.6		1	0.6			1.5			14.7		1
11/21/21 18:00	0.6			1.3			14.6		1	0.6			1.3			14.6		1
11/21/21 19:00	0.9			1.2			14.5		1	0.9			1.1			14.5		1
11/21/21 20:00	1.2			1.4			14.4		1	1.3			1.3			14.5		1
11/21/21 21:00	1.1			1.5			14.4		1	1.2			1.4			14.4		1
11/21/21 22:00	0.9			1.4			14.3		1	1			1.3			14.4		1
11/21/21 23:00	0.6			1.5			14.5		1	0.7			1.3			14.6		1
11/22/21 0:00	0.6			1.3			14.5		1	0.7			1.3			14.6		1
11/22/21 1:00	0.6			1.3			14.5		1	0.7			1.3			14.6		1
11/22/21 2:00	0.6			1.3			14.5		1	0.6			1.3			14.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/22/21 3:00	0.6			1.4			14.5		1	0.6			1.3			14.6		1
11/22/21 4:00	0.6			1.3			14.5		1	0.7			1.3			14.6		1
11/22/21 5:00	0.7			1.3			14.5		1	0.7			1.3			14.6		1
11/22/21 6:00	0.9			1.2			14.4		1	0.9			1.1			14.5		1
11/22/21 7:00	0.8			1.7			14.5		1	0.9			1.4			14.5		1
11/22/21 8:00	0.8			1.7			14.6		1	0.9			1.4			14.6		1
11/22/21 9:00	0.5			1.6			14.8		1	0.5			1.3			14.8		1
11/22/21 10:00	0.4			1.3			14.8		1	0.5			1.3			14.8		1
11/22/21 11:00	0.5			1.3			14.8		1	0.5			1.3			14.8		1
11/22/21 12:00	0.5			1.3			14.6		1	0.6			1.3			14.7		1
11/22/21 13:00	0.6			1.3			14.6		1	0.6			1.3			14.6		1
11/22/21 14:00	0.6			1.2			14.5		1	0.7			1.1			14.5		1
11/22/21 15:00	0.6			1.3			14.4		1	0.7			1.3			14.5		1
11/22/21 16:00	0.7			1.3			14.3		1	0.7			1.2			14.4		1
11/22/21 17:00	0.7			1.5			14.4		1	0.7			1.4			14.5		1
11/22/21 18:00	0.8			1.3			14.3		1	0.8			1.2			14.4		1
11/22/21 19:00	0.8			1.3			14.3		1	0.9			1.3			14.3		1
11/22/21 20:00	0.8			1.3			14.3		1	0.9			1.3			14.3		1
11/22/21 21:00	0.8			1.3			14.3		1	0.9			1.3			14.4		1
11/22/21 22:00	0.8			1.3			14.3		1	0.8			1.3			14.4		1
11/22/21 23:00	0.7			1.6			14.4		1	0.8			1.4			14.5		1
11/23/21 0:00	0.6			1.4			14.5		1	0.7			1.3			14.6		1
11/23/21 1:00	0.6			1.3			14.5		1	0.6			1.3			14.6		1
11/23/21 2:00	0.6			1.3			14.5		1	0.6			1.3			14.6		1
11/23/21 3:00	0.6			1.4			14.5		1	0.6			1.4			14.6		1
11/23/21 4:00	0.5			1.4			14.7		1	0.5			1.3			14.8		1
11/23/21 5:00	0.5			1.4			14.8		1	0.5			1.2			14.8		1
11/23/21 6:00	0.5			1.3			14.6		1	0.6			1.3			14.7		1
11/23/21 7:00	0.6			1.7			14.5		1	0.7			1.4			14.6		1
11/23/21 8:00	0.5			1.6			14.8		1	0.6			1.3			14.8		1
11/23/21 9:00	0.5			1.5			14.8		1	0.5			1.3			14.9		1
11/23/21 10:00	0.5			1.3			14.8		1	0.5			1.3			14.8		1
11/23/21 11:00	0.5			1.3			14.8		1	0.5			1.3			14.8		1
11/23/21 12:00	0.5			1.3			14.8		1	0.5			1.3			14.7		1
11/23/21 13:00	0.5			1.3			14.7		1	0.6			1.3			14.7		1
11/23/21 14:00	0.5			1.3			14.7		1	0.5			1.3			14.7		1
11/23/21 15:00	0.6			1.2			14.5		1	0.6			1.1			14.6		1
11/23/21 16:00	0.6			1.3			14.5		1	0.7			1.3			14.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/23/21 17:00	0.6			1.4			14.5		1	0.6			1.4			14.6		1
11/23/21 18:00	0.6			1.3			14.5		1	0.6			1.3			14.6		1
11/23/21 19:00	0.6			1.3			14.5		1	0.6			1.3			14.6		1
11/23/21 20:00	0.5			1.5			14.7		1	0.6			1.3			14.7		1
11/23/21 21:00	0.5			1.4			14.6		1	0.6			1.3			14.7		1
11/23/21 22:00	0.6			1.3			14.5		1	0.6			1.3			14.6		1
11/23/21 23:00	0.5			1.5			14.7		1	0.5			1.3			14.8		1
11/24/21 0:00	0.6			1.4			14.5		1	0.6			1.4			14.6		1
11/24/21 1:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
11/24/21 2:00	0.4			1.8			14.8		1	0.5			1.7			14.9		1
11/24/21 3:00	0.4			1.6			14.8		1	0.5			1.6			14.8		1
11/24/21 4:00	0.4			1.6			14.8		1	0.5			1.5			14.8		1
11/24/21 5:00	0.4			1.7			14.7		1	0.5			1.7			14.7		1
11/24/21 6:00	0.6			1.6			14.5		1	0.7			1.5			14.5		1
11/24/21 7:00	0.6			1.8			14.5		1	0.7			1.5			14.5		1
11/24/21 8:00	0.5			1.5			14.6		1	0.6			0.7			14.6		1
11/24/21 9:00	0.6			1.5			14.5		1	0.7			1.2			14.6		1
11/24/21 10:00	0.5			1.6			14.6		1	0.6			1.5			14.6		1
11/24/21 11:00	0.5			1.5			14.6		1	0.6			1.5			14.7		1
11/24/21 12:00	0.5			1.5			14.6		1	0.6			1.5			14.7		1
11/24/21 13:00	0.5			1.5			14.6		1	0.6			1.5			14.7		1
11/24/21 14:00	0.5			1.5			14.6		1	0.6			1.5			14.7		1
11/24/21 15:00	0.6			1.4			14.5		1	0.7			1.3			14.6		1
11/24/21 16:00	0.7			1.5			14.5		1	0.8			1.3			14.5		1
11/24/21 17:00	0.6			1.6			14.6		1	0.7			1.6			14.7		1
11/24/21 18:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
11/24/21 19:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/24/21 20:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/24/21 21:00	0.7			1.6			14.4		1	0.8			1.4			14.5		1
11/24/21 22:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/24/21 23:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
11/25/21 0:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
11/25/21 1:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
11/25/21 2:00	0.6			1.5			14.6		1	0.7			1.4			14.6		1
11/25/21 3:00	0.6			1.6			14.6		1	0.7			1.5			14.6		1
11/25/21 4:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
11/25/21 5:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
11/25/21 6:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/25/21 7:00	0.7			1.7			14.4		1	0.8			1.4			14.5		1
11/25/21 8:00	0.6			1.7			14.5		1	0.7			1.4			14.6		1
11/25/21 9:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
11/25/21 10:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
11/25/21 11:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
11/25/21 12:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
11/25/21 13:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
11/25/21 14:00	0.6			1.5			14.6		1	0.7			1.5			14.7		1
11/25/21 15:00	0.6			1.4			14.5		1	0.7			1.4			14.6		1
11/25/21 16:00	0.7			1.5			14.5		1	0.7			1.5			14.6		1
11/25/21 17:00	0.6			1.6			14.6		1	0.7			1.6			14.6		1
11/25/21 18:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
11/25/21 19:00	0.7			1.5			14.6		1	0.8			1.5			14.6		1
11/25/21 20:00	0.7			1.5			14.6		1	0.7			1.5			14.6		1
11/25/21 21:00	0.7			1.5			14.6		1	0.8			1.5			14.6		1
11/25/21 22:00	0.7			1.5			14.6		1	0.8			1.5			14.6		1
11/25/21 23:00	0.7			1.5			14.5		1	0.8			1.5			14.6		1
11/26/21 0:00	0.7			1.5			14.6		1	0.8			1.5			14.6		1
11/26/21 1:00	0.7			1.5			14.6		1	0.8			1.5			14.6		1
11/26/21 2:00	0.7			1.5			14.6		1	0.8			1.5			14.6		1
11/26/21 3:00	0.7			1.5			14.6		1	0.7			1.5			14.6		1
11/26/21 4:00	0.7			1.5			14.6		1	0.7			1.5			14.6		1
11/26/21 5:00	0.7			1.5			14.6		1	0.8			1.5			14.6		1
11/26/21 6:00	0.8			1.5			14.6		1	1			1.5			14.6		1
11/26/21 7:00	0.7			1.5			14.6		1	0.8			1.5			14.6		1
11/26/21 8:00	0.7			1.5			14.6		1	0.7			1.5			14.6		1
11/26/21 9:00	0.7			1.5			14.6		1	0.8			1.5			14.6		1
11/26/21 10:00	0.7			1.5			14.6		1	0.7			1.5			14.6		1
11/26/21 11:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
11/26/21 12:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
11/26/21 13:00	0.6			1.5			14.6		1	0.7			1.5			14.7		1
11/26/21 14:00	0.6			1.5			14.6		1	0.7			1.5			14.7		1
11/26/21 15:00	0.6			1.3			14.5		1	0.7			1.3			14.6		1
11/26/21 16:00	0.6			1.5			14.6		1	0.7			1.5			14.7		1
11/26/21 17:00	0.6			1.5			14.6		1	0.7			1.5			14.7		1
11/26/21 18:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
11/26/21 19:00	0.7			1.5			14.6		1	0.7			1.5			14.6		1
11/26/21 20:00	0.7			1.5			14.6		1	0.7			1.5			14.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/26/21 21:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/26/21 22:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/26/21 23:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/27/21 0:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/27/21 1:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/27/21 2:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/27/21 3:00	0.6			1.6			14.5		1	0.7			1.5			14.6		1
11/27/21 4:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
11/27/21 5:00	0.7			1.4			14.4		1	0.8			1.5			14.5		1
11/27/21 6:00	0.7			1.6			14.5		1	0.8			1.4			14.5		1
11/27/21 7:00	0.8			1.8			14.4		1	0.8			1.4			14.4		1
11/27/21 8:00	0.6			1.6			14.6		1	0.7			1.5			14.6		1
11/27/21 9:00	0.6			1.4			14.5		1	0.7			1.3			14.5		1
11/27/21 10:00	0.7			1.6			14.3		1	0.9			1.6			14.4		1
11/27/21 11:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
11/27/21 12:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
11/27/21 13:00	0.6			1.5			14.6		1	0.7			1.5			14.7		1
11/27/21 14:00	0.6			1.5			14.6		1	0.7			1.5			14.7		1
11/27/21 15:00	0.6			1.3			14.5		1	0.7			1.3			14.6		1
11/27/21 16:00	0.7			1.4			14.4		1	0.8			1.3			14.5		1
11/27/21 17:00	0.6			1.7			14.5		1	0.7			1.6			14.6		1
11/27/21 18:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
11/27/21 19:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/27/21 20:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/27/21 21:00	0.8			1.5			14.4		1	0.8			1.5			14.5		1
11/27/21 22:00	0.6			1.6			14.5		1	0.7			1.5			14.6		1
11/27/21 23:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/28/21 0:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/28/21 1:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/28/21 2:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/28/21 3:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/28/21 4:00	0.7			1.5			14.5		1	0.8			1.5			14.6		1
11/28/21 5:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/28/21 6:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
11/28/21 7:00	0.7			1.6			14.5		1	0.8			1.4			14.5		1
11/28/21 8:00	0.6			1.6			14.5		1	0.7			1.5			14.6		1
11/28/21 9:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/28/21 10:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/28/21 11:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
11/28/21 12:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
11/28/21 13:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
11/28/21 14:00	0.6			1.5			14.6		1	0.7			1.5			14.7		1
11/28/21 15:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
11/28/21 16:00	0.6			1.4			14.5		1	0.7			1.4			14.6		1
11/28/21 17:00	0.6			1.4			14.6		1	0.7			1.4			14.6		1
11/28/21 18:00	0.7			1.5			14.6		1	0.7			1.5			14.6		1
11/28/21 19:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
11/28/21 20:00	0.8			1.5			14.5		1	1			1.5			14.6		1
11/28/21 21:00	0.6			1.5			14.5		1	0.8			1.5			14.6		1
11/28/21 22:00	0.6			1.5			14.5		1	0.8			1.5			14.6		1
11/28/21 23:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/29/21 0:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/29/21 1:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/29/21 2:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/29/21 3:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/29/21 4:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/29/21 5:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/29/21 6:00	0.8			1.4			14.3		1	0.9			1.3			14.4		1
11/29/21 7:00	1			1.8			14.4		1	1.1			1.6			14.5		1
11/29/21 8:00	0.8			1.7			14.5		1	1			1.5			14.6		1
11/29/21 9:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/29/21 10:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/29/21 11:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
11/29/21 12:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
11/29/21 13:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
11/29/21 14:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
11/29/21 15:00	0.6			1.3			14.5		1	0.7			1.4			14.6		1
11/29/21 16:00	0.7			1.4			14.4		1	0.8			1.3			14.4		1
11/29/21 17:00	0.8			1.6			14.2		1	0.9			1.5			14.3		1
11/29/21 18:00	0.7			1.5			14.3		1	0.9			1.3			14.4		1
11/29/21 19:00	1			1.6			14.3		1	1.2			1.5			14.3		1
11/29/21 20:00	0.8			1.5			14.4		1	1			1.5			14.4		1
11/29/21 21:00	0.8			1.7			14.4		1	0.9			1.6			14.4		1
11/29/21 22:00	0.7			1.6			14.4		1	0.8			1.5			14.5		1
11/29/21 23:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/30/21 0:00	0.7			1.4			14.4		1	0.8			1.4			14.4		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/30/21 1:00	0.7			1.8			14.4		1	0.8			1.5			14.5		1
11/30/21 2:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/30/21 3:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/30/21 4:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
11/30/21 5:00	0.6			1.4			14.5		1	0.7			1.3			14.5		1
11/30/21 6:00	0.7			1.5			14.3		1	0.9			1.5			14.4		1
11/30/21 7:00	0.7			1.6			14.3		1	0.9			1.6			14.4		1
11/30/21 8:00	0.6			1.8			14.4		1	0.8			1.5			14.5		1
11/30/21 9:00	0.6			1.4			14.5		1	0.7			1.4			14.6		1
11/30/21 10:00	0.6			1.1			14.5		1	0.7			1.4			14.6		1
11/30/21 11:00	0.6			1.3			14.5		1	0.7			1.4			14.6		1
11/30/21 12:00	0.6			1.4			14.5		1	0.7			1.4			14.6		1
11/30/21 13:00	0.6			1.4			14.6		1	0.7			1.4			14.6		1
11/30/21 14:00	0.6			1.4			14.6		1	0.7			1.4			14.6		1
11/30/21 15:00	0.6			1.3			14.5		1	0.8			1.3			14.5		1
11/30/21 16:00	0.7			1.3			14.4		1	0.8			1.3			14.4		1
11/30/21 17:00	0.8			1.5			13.9		1	0.9			1.4			13.9		1
11/30/21 18:00	0.3			1.4			12.3		1	0.4			1.4			12.4		1
11/30/21 19:00	0.3			1.4			12.3		1	0.4			1.4			12.4		1
11/30/21 20:00	1.2			1.4			13.9		1	1.6			1.4			13.9		1
11/30/21 21:00	0.5			1.4			12.7		1	0.6			1.4			12.8		1
11/30/21 22:00	1.2			1.4			14		1	1.5			1.4			14.3		1
11/30/21 23:00	1.2			1.6			14.3		1	1.9			1.5			14.3		1
12/01/21 0:00	0.6			1.6			14.5		1	0.7			1.4			14.6		1
12/01/21 1:00	0.6			1.5			14.5		1	0.7			1.4			14.6		1
12/01/21 2:00	0.6			1.4			14.5		1	0.7			1.4			14.6		1
12/01/21 3:00	0.7			1.5			14.5		1	0.8			1.5			14.6		1
12/01/21 4:00	0.6			1.5			14.5		1	0.8			1.5			14.6		1
12/01/21 5:00	0.6			1.5			14.5		1	0.8			1.5			14.6		1
12/01/21 6:00	0.9			1.6			14.5		1	1			1.5			14.6		1
12/01/21 7:00	0.8			1.6			14.5		1	1			1.5			14.6		1
12/01/21 8:00	0.7			1.5			14.5		1	0.8			1.5			14.6		1
12/01/21 9:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/01/21 10:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/01/21 11:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
12/01/21 12:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
12/01/21 13:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
12/01/21 14:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/01/21 15:00	0.6			1.4			14.5		1	0.7			1.4			14.6		1
12/01/21 16:00	0.7			1.4			14.4		1	0.8			1.3			14.5		1
12/01/21 17:00	0.8			1.6			14.3		1	0.9			1.5			14.4		1
12/01/21 18:00	0.8			1.5			14.4		1	0.9			1.5			14.4		1
12/01/21 19:00	0.8			1.5			14.4		1	0.8			1.5			14.5		1
12/01/21 20:00	0.9			1.5			14.3		1	1			1.5			14.4		1
12/01/21 21:00	0.9			1.5			14.4		1	0.9			1.5			14.4		1
12/01/21 22:00	0.7			1.5			14.4		1	0.8			1.4			14.5		1
12/01/21 23:00	0.6			1.3			14.5		1	0.7			1.2			14.6		1
12/02/21 0:00	0.6			1.3			14.5		1	0.7			1.2			14.6		1
12/02/21 1:00	0.7			1.2			14.4		1	0.8			1.1			14.5		1
12/02/21 2:00	0.6			1.5			14.4		1	0.8			1.1			14.5		1
12/02/21 3:00	0.9			1.3			14.2		1	1			1.3			14.3		1
12/02/21 4:00	0.8			1.5			14.3		1	0.9			1.5			14.4		1
12/02/21 5:00	1.3			1.5			14.2		1	1.7			1.5			14.3		1
12/02/21 6:00	1.6			1.5			14		1	1.7			1.5			14		1
12/02/21 7:00	1.2			1.5			13.8		1	1.5			1.5			14.1		1
12/02/21 8:00	1.1			1.6			14.3		1	1.4			1.5			14.4		1
12/02/21 9:00	0.7			1.6			14.5		1	0.8			1.3			14.6		1
12/02/21 10:00	0.6			1.3			14.5		1	0.7			1.3			14.6		1
12/02/21 11:00	0.6			1.3			14.5		1	0.7			1.3			14.6		1
12/02/21 12:00	0.6			1.3			14.6		1	0.7			1.3			14.6		1
12/02/21 13:00	0.6			1.3			14.6		1	0.7			1.3			14.6		1
12/02/21 14:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
12/02/21 15:00	0.6			1.4			14.5		1	0.7			1.3			14.6		1
12/02/21 16:00	0.9			1.5			14.3		1	1.1			1.5			14.3		1
12/02/21 17:00	0.7			1.5			13.2		1	0.8			1.5			13.3		1
12/02/21 18:00	1.3			1.5			13.9		1	1.4			1.5			13.9		1
12/02/21 19:00	1.5			1.5			14		1	1.7			1.5			14		1
12/02/21 20:00	1.3			1.5			13.8		1	1.3			1.5			13.8		1
12/02/21 21:00	1.3			1.5			13.8		1	1.3			1.5			13.9		1
12/02/21 22:00	1.1			1.6			14.1		1	1.2			1.6			14.2		1
12/02/21 23:00	0.7			1.6			14.5		1	0.7			1.5			14.6		1
12/03/21 0:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/03/21 1:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/03/21 2:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/03/21 3:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/03/21 4:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/03/21 5:00	0.6			1.5			14.4		1	0.7			1.4			14.5		1
12/03/21 6:00	0.6			1.6			14.5		1	0.7			1.5			14.5		1
12/03/21 7:00	0.7			1.8			14.4		1	0.8			1.5			14.5		1
12/03/21 8:00	0.6			1.6			14.5		1	0.7			1.5			14.6		1
12/03/21 9:00	0.7			1.4			14.4		1	0.8			1.3			14.4		1
12/03/21 10:00	0.8			1.5			14.3		1	0.9			1.5			14.4		1
12/03/21 11:00	0.7			1.6			14.4		1	0.8			1.4			14.4		1
12/03/21 12:00	0.7			1.7			14.3		1	0.8			1.7			14.4		1
12/03/21 13:00	0.6			1.5			14.5		1	0.7			1.4			14.6		1
12/03/21 14:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/03/21 15:00	0.6			1.4			14.4		1	0.7			1.3			14.5		1
12/03/21 16:00	1			1.6			14.2		1	1.1			1.5			14.1		1
12/03/21 17:00	1.3			1.5			13.9		1	1.2			1.5			14		1
12/03/21 18:00	1.4			1.5			14		1	1.3			1.5			14		1
12/03/21 19:00	1.4			1.5			14		1	1.4			1.5			14		1
12/03/21 20:00	1.5			1.5			14		1	1.4			1.5			14		1
12/03/21 21:00	1.5			1.5			14		1	1.4			1.5			14		1
12/03/21 22:00	1.5			1.5			14		1	1.3			1.5			14		1
12/03/21 23:00	1.2			1.5			14.2		1	1.1			1.4			14.2		1
12/04/21 0:00	0.6			1.4			14.5		1	0.7			1.2			14.6		1
12/04/21 1:00	0.6			1.3			14.5		1	0.7			1.2			14.6		1
12/04/21 2:00	0.6			1.2			14.5		1	0.7			1.2			14.6		1
12/04/21 3:00	0.7			1.3			14.4		1	0.8			1.3			14.5		1
12/04/21 4:00	0.7			1.3			14.4		1	0.8			1.1			14.5		1
12/04/21 5:00	0.7			1.7			14.4		1	0.8			1.4			14.5		1
12/04/21 6:00	0.8			1.8			14.3		1	0.9			1.5			14.4		1
12/04/21 7:00	0.9			1.7			14.3		1	1			1.5			14.4		1
12/04/21 8:00	0.8			1.7			14.4		1	0.9			1.3			14.5		1
12/04/21 9:00	0.7			1.4			14.4		1	0.8			1.2			14.4		1
12/04/21 10:00	0.7			1.7			14.4		1	0.8			1.5			14.5		1
12/04/21 11:00	0.7			1.5			14.3		1	0.8			1.4			14.4		1
12/04/21 12:00	0.6			1.6			14.5		1	0.7			1.4			14.6		1
12/04/21 13:00	0.6			1.2			14.4		1	0.7			1.2			14.5		1
12/04/21 14:00	0.7			1.6			14.4		1	0.8			1.4			14.5		1
12/04/21 15:00	0.7			1.3			14.4		1	0.8			1.2			14.5		1
12/04/21 16:00	0.7			1.4			14.4		1	0.8			1.4			14.4		1
12/04/21 17:00	1.2			1.3			14.2		1	1.6			1.4			14.3		1
12/04/21 18:00	1.5			1.5			14.1		1	1.8			1.5			14.1		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/04/21 19:00	1.5			1.5			14.1		1	1.8			1.5			14.1		1
12/04/21 20:00	1.5			1.5			14.1		1	1.7			1.5			14.1		1
12/04/21 21:00	1.5			1.5			14.1		1	1.6			1.5			14.1		1
12/04/21 22:00	0.7			1.6			14.4		1	0.8			1.3			14.5		1
12/04/21 23:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/05/21 0:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/05/21 1:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/05/21 2:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/05/21 3:00	0.6			1.6			14.6		1	0.7			1.5			14.6		1
12/05/21 4:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/05/21 5:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/05/21 6:00	0.7			1.4			14.4		1	0.8			1.3			14.5		1
12/05/21 7:00	0.7			1.9			14.4		1	0.8			1.6			14.5		1
12/05/21 8:00	0.8			1.3			14.3		1	0.9			1.3			14.4		1
12/05/21 9:00	0.7			1.4			14.4		1	0.8			1.4			14.4		1
12/05/21 10:00	0.7			1.4			14.4		1	0.8			1.4			14.4		1
12/05/21 11:00	0.7			1.4			14.3		1	0.8			1.3			14.4		1
12/05/21 12:00	0.6			1.7			14.5		1	0.7			1.5			14.6		1
12/05/21 13:00	0.7			1.3			14.4		1	0.8			1.2			14.5		1
12/05/21 14:00	0.7			1.7			14.4		1	0.8			1.5			14.5		1
12/05/21 15:00	0.7			1.3			14.4		1	0.8			1.2			14.5		1
12/05/21 16:00	0.7			1.4			14.5		1	0.8			1.2			14.5		1
12/05/21 17:00	0.9			1.5			14.2		1	0.9			1.4			14.3		1
12/05/21 18:00	0.8			1.3			14.3		1	0.9			1.4			14.4		1
12/05/21 19:00	0.8			1.4			14.4		1	0.9			1.4			14.4		1
12/05/21 20:00	0.8			1.3			14.3		1	0.9			1.4			14.4		1
12/05/21 21:00	0.8			1.4			14.3		1	0.9			1.4			14.4		1
12/05/21 22:00	0.8			1.4			14.3		1	0.9			1.4			14.4		1
12/05/21 23:00	0.9			1.4			14.2		1	1			1.4			14.3		1
12/06/21 0:00	0.7			1.7			14.4		1	0.8			1.4			14.5		1
12/06/21 1:00	0.6			1.6			14.5		1	0.7			1.4			14.6		1
12/06/21 2:00	0.6			1.5			14.5		1	0.7			1.3			14.6		1
12/06/21 3:00	0.6			1.4			14.5		1	0.7			1.4			14.6		1
12/06/21 4:00	0.6			1.4			14.5		1	0.7			1.4			14.6		1
12/06/21 5:00	0.7			1.2			14.4		1	0.8			1.2			14.5		1
12/06/21 6:00	0.7			1.5			14.4		1	0.8			1.5			14.4		1
12/06/21 7:00	0.7			1.5			14.3		1	0.8			1.5			14.4		1
12/06/21 8:00	0.7			1.5			14.3		1	0.9			1.5			14.4		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/06/21 9:00	0.7			1.5			14.4		1	0.8			1.5			14.4		1
12/06/21 10:00	0.8			1.5			14.4		1	0.9			1.5			14.4		1
12/06/21 11:00	0.7			1.5			14.4		1	0.8			1.5			14.4		1
12/06/21 12:00	0.7			1.5			14.4		1	0.8			1.5			14.4		1
12/06/21 13:00	0.7			1.5			14.4		1	0.8			1.5			14.4		1
12/06/21 14:00	0.7			1.5			14.4		1	0.8			1.5			14.4		1
12/06/21 15:00	0.7			1.5			14.4		1	0.8			1.5			14.4		1
12/06/21 16:00	1.1			1.5			14		1	1.4			1.5			14.1		1
12/06/21 17:00	1.4			1.5			14		1	1.4			1.5			14		1
12/06/21 18:00	1.3			1.5			13.8		1	1.3			1.5			13.9		1
12/06/21 19:00	1.5			1.5			14		1	1.4			1.5			14.1		1
12/06/21 20:00	1.3			1.5			13.9		1	1.4			1.5			14		1
12/06/21 21:00	1.4			1.5			14		1	1.4			1.5			14.1		1
12/06/21 22:00	1.4			1.5			14.1		1	1.4			1.5			14.2		1
12/06/21 23:00	0.8			1.5			14.4		1	0.9			1.5			14.4		1
12/07/21 0:00	0.8			1.5			14.2		1	0.9			1.5			14.3		1
12/07/21 1:00	0.7			1.4			14.3		1	0.9			1.2			14.4		1
12/07/21 2:00	0.6			1.4			14.5		1	0.7			1.2			14.6		1
12/07/21 3:00	0.6			1.3			14.5		1	0.7			1.2			14.6		1
12/07/21 4:00	0.8			1.3			14.3		1	0.9			1.1			14.4		1
12/07/21 5:00	0.6			1.8			14.5		1	0.7			1.6			14.6		1
12/07/21 6:00	0.7			1.4			14.4		1	0.8			1.4			14.5		1
12/07/21 7:00	0.7			1.5			14.4		1	0.8			1.5			14.4		1
12/07/21 8:00	0.7			1.5			14.4		1	0.8			1.5			14.4		1
12/07/21 9:00	0.7			1.5			14.4		1	0.8			1.5			14.4		1
12/07/21 10:00	0.7			1.7			14.3		1	0.8			1.6			14.4		1
12/07/21 11:00	0.8			1.6			14.3		1	0.9			1.4			14.4		1
12/07/21 12:00	0.7			1.4			14.3		1	0.9			1.4			14.4		1
12/07/21 13:00	0.7			1.5			14.4		1	0.8			1.5			14.5		1
12/07/21 14:00	0.7			1.5			14.4		1	0.8			1.5			14.5		1
12/07/21 15:00	0.7			1.5			14.4		1	0.8			1.5			14.4		1
12/07/21 16:00	1			1.5			14.2		1	1.2			1.5			14.1		1
12/07/21 17:00	1.4			1.5			14		1	1.4			1.5			14		1
12/07/21 18:00	1.2			1.5			13.8		1	1.2			1.5			13.8		1
12/07/21 19:00	0.8			1.5			13.4		1	0.9			1.5			13.5		1
12/07/21 20:00	1.3			1.5			13.9		1	1.3			1.5			14		1
12/07/21 21:00	1.3			1.5			13.9		1	1.3			1.5			14		1
12/07/21 22:00	1.3			1.5			13.9		1	1.3			1.5			13.9		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/07/21 23:00	1.3			1.5			14.1		1	1.3			1.5			14.1		1
12/08/21 0:00	0.8			1.6			14.3		1	0.9			1.6			14.4		1
12/08/21 1:00	0.8			1.6			14.3		1	0.9			1.5			14.4		1
12/08/21 2:00	0.6			1.6			14.5		1	0.7			1.5			14.6		1
12/08/21 3:00	0.7			1.5			14.5		1	0.7			1.5			14.6		1
12/08/21 4:00	0.6			1.5			14.5		1	0.7			1.5			14.5		1
12/08/21 5:00	0.6			1.5			14.5		1	0.7			1.5			14.5		1
12/08/21 6:00	0.8			1.4			14.4		1	0.9			1.4			14.4		1
12/08/21 7:00	0.9			1.6			14.3		1	1			1.6			14.4		1
12/08/21 8:00	0.7			1.8			14.4		1	0.8			1.5			14.5		1
12/08/21 9:00	0.6			1.5			14.5		1	0.8			1.5			14.6		1
12/08/21 10:00	0.6			1.5			14.5		1	0.8			1.5			14.6		1
12/08/21 11:00	1.1			1.4			14.2		1	1.3			1.4			14.2		1
12/08/21 12:00	1.1			1.5			14.2		1	1.2			1.5			14.3		1
12/08/21 13:00	0.6			1.7			14.5		1	0.7			1.6			14.6		1
12/08/21 14:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/08/21 15:00	0.7			1.4			14.5		1	0.8			1.4			14.5		1
12/08/21 16:00	0.7			1.5			14.4		1	0.8			1.4			14.5		1
12/08/21 17:00	0.7			1.5			14.4		1	0.9			1.5			14.4		1
12/08/21 18:00	0.8			1.5			14.3		1	0.9			1.5			14.4		1
12/08/21 19:00	0.7			1.5			14.4		1	0.9			1.5			14.4		1
12/08/21 20:00	0.8			1.5			14.3		1	0.9			1.5			14.4		1
12/08/21 21:00	0.8			1.7			14.3		1	0.9			1.6			14.4		1
12/08/21 22:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/08/21 23:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/09/21 0:00	0.6			1.5			14.5		1	0.7			1.5			14.5		1
12/09/21 1:00	0.6			1.5			14.5		1	0.7			1.5			14.5		1
12/09/21 2:00	0.6			1.5			14.5		1	0.7			1.5			14.5		1
12/09/21 3:00	0.6			1.5			14.5		1	0.7			1.5			14.5		1
12/09/21 4:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
12/09/21 5:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
12/09/21 6:00	0.7			1.4			14.4		1	0.9			1.3			14.4		1
12/09/21 7:00	0.8			1.8			14.3		1	0.9			1.6			14.4		1
12/09/21 8:00	0.7			1.6			14.4		1	0.8			1.4			14.5		1
12/09/21 9:00	0.8			1.4			14.3		1	0.9			1.4			14.3		1
12/09/21 10:00	0.7			1.6			14.4		1	0.8			1.4			14.4		1
12/09/21 11:00	0.6			1.8			14.5		1	0.7			1.6			14.6		1
12/09/21 12:00	0.6			1.5			14.4		1	0.8			1.5			14.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/09/21 13:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/09/21 14:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
12/09/21 15:00	0.6			1.4			14.5		1	0.8			1.4			14.6		1
12/09/21 16:00	0.7			1.5			14.4		1	0.8			1.4			14.5		1
12/09/21 17:00	0.8			1.6			14.3		1	0.9			1.5			14.4		1
12/09/21 18:00	0.8			1.7			14.3		1	0.9			1.4			14.4		1
12/09/21 19:00	0.8			1.6			14.3		1	1			1.5			14.3		1
12/09/21 20:00	0.8			1.5			14.3		1	0.9			1.5			14.3		1
12/09/21 21:00	0.8			1.6			14.3		1	1			1.6			14.3		1
12/09/21 22:00	0.8			1.7			14.4		1	0.9			1.5			14.5		1
12/09/21 23:00	0.6			1.8			14.6		1	0.7			1.5			14.6		1
12/10/21 0:00	0.6			1.6			14.5		1	0.7			1.5			14.6		1
12/10/21 1:00	0.6			1.6			14.5		1	0.7			1.5			14.6		1
12/10/21 2:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
12/10/21 3:00	0.7			1.6			14.5		1	0.8			1.5			14.6		1
12/10/21 4:00	0.7			1.5			14.6		1	0.8			1.5			14.6		1
12/10/21 5:00	0.7			1.4			14.4		1	0.8			1.3			14.5		1
12/10/21 6:00	0.7			1.6			14.4		1	0.9			1.4			14.4		1
12/10/21 7:00	0.8			1.5			14.3		1	1			1.5			14.4		1
12/10/21 8:00	0.7			1.8			14.5		1	0.8			1.5			14.5		1
12/10/21 9:00	0.6			1.7			14.6		1	0.7			1.5			14.7		1
12/10/21 10:00	0.6			1.5			14.5		1	0.8			1.4			14.5		1
12/10/21 11:00	0.7			1.5			14.3		1	0.9			1.5			14.4		1
12/10/21 12:00	0.7			1.6			14.3		1	0.9			1.5			14.4		1
12/10/21 13:00	0.6			1.6			14.6		1	0.7			1.4			14.6		1
12/10/21 14:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
12/10/21 15:00	0.6			1.4			14.5		1	0.8			1.3			14.6		1
12/10/21 16:00	0.7			1.5			14.4		1	0.9			1.5			14.5		1
12/10/21 17:00	0.7			1.5			14.4		1	0.8			1.5			14.5		1
12/10/21 18:00	0.7			1.5			14.4		1	0.9			1.5			14.5		1
12/10/21 19:00	0.8			1.5			14.3		1	1			1.5			14.4		1
12/10/21 20:00	0.9			1.5			14.3		1	1			1.5			14.4		1
12/10/21 21:00	0.8			1.5			14.3		1	1			1.5			14.4		1
12/10/21 22:00	0.8			1.5			14.3		1	1			1.5			14.4		1
12/10/21 23:00	0.8			1.5			14.3		1	1			1.5			14.4		1
12/11/21 0:00	0.8			1.6			14.3		1	1			1.3			14.4		1
12/11/21 1:00	0.6			1.6			14.5		1	0.7			1.4			14.6		1
12/11/21 2:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/11/21 3:00	0.6			1.6			14.6		1	0.7			1.5			14.6		1
12/11/21 4:00	0.6			1.6			14.6		1	0.7			1.5			14.6		1
12/11/21 5:00	0.6			1.6			14.5		1	0.7			1.5			14.6		1
12/11/21 6:00	0.7			1.5			14.3		1	0.9			1.5			14.4		1
12/11/21 7:00	0.6			1.8			14.5		1	0.8			1.5			14.5		1
12/11/21 8:00	0.5			1.7			14.6		1	0.7			1.5			14.6		1
12/11/21 9:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
12/11/21 10:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
12/11/21 11:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
12/11/21 12:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
12/11/21 13:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
12/11/21 14:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
12/11/21 15:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
12/11/21 16:00	0.7			1.4			14.5		1	0.8			1.4			14.5		1
12/11/21 17:00	0.8			1.5			14.3		1	0.9			1.5			14.4		1
12/11/21 18:00	0.8			1.6			14.3		1	1			1.5			14.4		1
12/11/21 19:00	0.8			1.4			14.4		1	0.9			1.5			14.5		1
12/11/21 20:00	0.8			1.5			14.4		1	0.9			1.5			14.4		1
12/11/21 21:00	0.8			1.5			14.4		1	0.9			1.5			14.4		1
12/11/21 22:00	0.8			1.5			14.4		1	0.9			1.5			14.4		1
12/11/21 23:00	0.8			1.6			14.3		1	0.9			1.5			14.4		1
12/12/21 0:00	0.8			1.6			14.4		1	0.9			1.6			14.4		1
12/12/21 1:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/12/21 2:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/12/21 3:00	0.8			1.5			14.3		1	1			1.4			14.4		1
12/12/21 4:00	0.9			1.6			14.2		1	1			1.5			14.3		1
12/12/21 5:00	0.6			1.6			14.5		1	0.7			1.6			14.6		1
12/12/21 6:00	0.7			1.5			14.4		1	0.9			1.4			14.4		1
12/12/21 7:00	0.7			1.6			14.4		1	0.8			1.5			14.5		1
12/12/21 8:00	0.7			1.6			14.4		1	0.8			1.4			14.5		1
12/12/21 9:00	0.6			1.5			14.5		1	0.8			1.5			14.5		1
12/12/21 10:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/12/21 11:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/12/21 12:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/12/21 13:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/12/21 14:00	0.6			1.4			14.5		1	0.7			1.5			14.6		1
12/12/21 15:00	0.7			1.5			14.4		1	0.8			1.4			14.5		1
12/12/21 16:00	0.7			1.6			14.4		1	0.8			1.4			14.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/12/21 17:00	0.8			1.5			14.3		1	0.9			1.5			14.3		1
12/12/21 18:00	0.7			1.5			14.3		1	0.9			1.5			14.3		1
12/12/21 19:00	0.7			1.5			14.3		1	0.8			1.5			14.4		1
12/12/21 20:00	0.7			1.5			14.3		1	0.9			1.5			14.4		1
12/12/21 21:00	0.7			1.5			14.2		1	0.9			1.5			14.3		1
12/12/21 22:00	0.7			1.5			14.3		1	0.8			1.4			14.4		1
12/12/21 23:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/13/21 0:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/13/21 1:00	0.6			1.5			14.5		1	0.7			1.5			14.5		1
12/13/21 2:00	0.6			1.5			14.5		1	0.7			1.5			14.5		1
12/13/21 3:00	0.6			1.6			14.5		1	0.7			1.5			14.5		1
12/13/21 4:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/13/21 5:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/13/21 6:00	0.7			1.4			14.4		1	0.8			1.4			14.5		1
12/13/21 7:00	0.7			1.5			14.3		1	0.8			1.5			14.4		1
12/13/21 8:00	0.7			1.5			14.3		1	0.9			1.5			14.4		1
12/13/21 9:00	0.7			1.5			14.3		1	0.8			1.5			14.4		1
12/13/21 10:00	0.7			1.7			14.4		1	0.8			1.6			14.4		1
12/13/21 11:00	0.7			1.6			14.3		1	0.8			1.5			14.4		1
12/13/21 12:00	0.7			1.5			14.4		1	0.8			1.4			14.4		1
12/13/21 13:00	0.7			1.5			14.3		1	0.8			1.5			14.4		1
12/13/21 14:00	0.7			1.5			14.4		1	0.8			1.5			14.4		1
12/13/21 15:00	0.7			1.5			14.4		1	0.8			1.5			14.4		1
12/13/21 16:00	0.8			1.5			14		1	1			1.5			13.8		1
12/13/21 17:00	1.1			1.5			13.6		1	1.1			1.5			13.7		1
12/13/21 18:00	1.2			1.5			13.8		1	1.3			1.5			13.9		1
12/13/21 19:00	1.2			1.5			13.8		1	1.2			1.5			13.9		1
12/13/21 20:00	1.2			1.5			13.8		1	1.2			1.5			13.8		1
12/13/21 21:00	1.2			1.5			13.8		1	1.3			1.5			13.9		1
12/13/21 22:00	1.1			1.7			14.1		1	1.2			1.6			14.2		1
12/13/21 23:00	0.6			1.7			14.5		1	0.7			1.5			14.5		1
12/14/21 0:00	0.6			1.6			14.5		1	0.7			1.5			14.5		1
12/14/21 1:00	0.6			1.5			14.5		1	0.7			1.5			14.5		1
12/14/21 2:00	0.6			1.5			14.5		1	0.7			1.5			14.5		1
12/14/21 3:00	0.6			1.6			14.5		1	0.7			1.5			14.5		1
12/14/21 4:00	0.6			1.6			14.5		1	0.7			1.5			14.5		1
12/14/21 5:00	0.7			1.4			14.4		1	0.8			1.3			14.4		1
12/14/21 6:00	0.8			1.6			14.2		1	0.9			1.5			14.3		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/14/21 7:00	0.7			1.8			14.4		1	0.8			1.5			14.4		1
12/14/21 8:00	0.6			1.8			14.5		1	0.7			1.6			14.5		1
12/14/21 9:00	0.6			1.6			14.5		1	0.7			1.5			14.6		1
12/14/21 10:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/14/21 11:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/14/21 12:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/14/21 13:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/14/21 14:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/14/21 15:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/14/21 16:00	0.6			1.4			14.5		1	0.7			1.4			14.5		1
12/14/21 17:00	0.7			1.6			14.3		1	0.9			1.5			14.4		1
12/14/21 18:00	0.8			1.5			14.3		1	0.9			1.5			14.4		1
12/14/21 19:00	0.8			1.5			14.3		1	0.9			1.5			14.4		1
12/14/21 20:00	0.8			1.5			14.3		1	1			1.5			14.4		1
12/14/21 21:00	0.8			1.5			14.3		1	1			1.5			14.4		1
12/14/21 22:00	0.8			1.5			14.2		1	1			1.5			14.3		1
12/14/21 23:00	0.6			1.8			14.5		1	0.7			1.4			14.6		1
12/15/21 0:00	0.6			1.5			14.5		1	0.8			1.3			14.5		1
12/15/21 1:00	0.6			1.6			14.6		1	0.7			1.6			14.6		1
12/15/21 2:00	0.6			1.5			14.6		1	0.7			1.5			14.6		1
12/15/21 3:00	0.6			1.6			14.6		1	0.7			1.5			14.6		1
12/15/21 4:00	0.7			1.4			14.4		1	0.8			1.4			14.5		1
12/15/21 5:00	0.7			1.5			14.3		1	0.9			1.5			14.4		1
12/15/21 6:00	0.7			1.5			14.3		1	0.9			1.5			14.4		1
12/15/21 7:00	0.7			1.6			14.3		1	0.9			1.5			14.4		1
12/15/21 8:00	0.6			1.7			14.5		1	0.8			1.5			14.5		1
12/15/21 9:00	0.6			1.6			14.5		1	0.7			1.4			14.6		1
12/15/21 10:00	0.6			1.4			14.5		1	0.7			1.4			14.6		1
12/15/21 11:00	0.6			1.2			14.4		1	0.8			1.4			14.5		1
12/15/21 12:00	0.6			1.4			14.4		1	0.8			1.2			14.5		1
12/15/21 13:00	0.6			1.7			14.4		1	0.7			1.6			14.5		1
12/15/21 14:00	0.5			1.5			14.5		1	0.6			1.5			14.6		1
12/15/21 15:00	0.6			1.4			14.5		1	0.7			1.3			14.5		1
12/15/21 16:00	0.7			1.5			14.4		1	0.7			1.3			14.4		1
12/15/21 17:00	0.6			1.5			14.4		1	0.7			1.5			14.5		1
12/15/21 18:00	0.6			1.5			14.4		1	0.7			1.5			14.5		1
12/15/21 19:00	0.6			1.5			14.4		1	0.7			1.5			14.4		1
12/15/21 20:00	0.6			1.5			14.4		1	0.7			1.5			14.4		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/15/21 21:00	0.6			1.5			14.3		1	0.7			1.5			14.4		1
12/15/21 22:00	0.6			1.5			14.3		1	0.7			1.5			14.4		1
12/15/21 23:00	0.7			1.5			14.3		1	0.8			1.5			14.3		1
12/16/21 0:00	0.7			1.5			14.3		1	0.8			1.5			14.3		1
12/16/21 1:00	0.7			1.7			14.2		1	0.8			1.6			14.3		1
12/16/21 2:00	0.5			1.6			14.5		1	0.6			1.4			14.6		1
12/16/21 3:00	0.6			1.5			14.5		1	0.6			1.5			14.6		1
12/16/21 4:00	0.9			1.4			14.3		1	1			1.4			14.3		1
12/16/21 5:00	1.5			1.5			14		1	1.5			1.5			14.1		1
12/16/21 6:00	1.3			1.5			13.9		1	1.3			1.5			14		1
12/16/21 7:00	1.2			1.5			13.9		1	1.3			1.5			14		1
12/16/21 8:00	1.3			1.5			14.1		1	1.3			1.5			14.1		1
12/16/21 9:00	1.2			1.5			14.2		1	1.4			1.5			14.2		1
12/16/21 10:00	1.4			1.5			14		1	1.5			1.5			14.1		1
12/16/21 11:00	0.9			1.6			14.3		1	1.1			1.6			14.3		1
12/16/21 12:00	0.5			1.5			14.5		1	0.6			1.5			14.6		1
12/16/21 13:00	0.5			1.5			14.5		1	0.6			1.5			14.6		1
12/16/21 14:00	0.6			1.6			14.4		1	0.7			1.4			14.5		1
12/16/21 15:00	0.8			1.1			14.1		1	1			1.3			14.2		1
12/16/21 16:00	1.3			1.4			14		1	1.3			1.4			14.1		1
12/16/21 17:00	1.4			1.4			14.1		1	1.4			1.4			14.2		1
12/16/21 18:00	1.4			1.4			14.1		1	1.4			1.4			14.2		1
12/16/21 19:00	1.2			1.5			14		1	1.3			1.5			14.1		1
12/16/21 20:00	1.5			1.5			14.1		1	1.4			1.5			14.2		1
12/16/21 21:00	0.5			1.5			12.9		1	0.6			1.5			13		1
12/16/21 22:00	1.2			1.5			13.8		1	1.2			1.5			13.9		1
12/16/21 23:00	0.9			1.7			14.3		1	1			1.5			14.4		1
12/17/21 0:00	0.5			1.5			14.6		1	0.6			1.5			14.6		1
12/17/21 1:00	0.6			1.6			14.5		1	0.6			1.5			14.6		1
12/17/21 2:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/17/21 3:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/17/21 4:00	1.1			1.4			14.3		1	1.3			1.4			14.3		1
12/17/21 5:00	1.6			1.4			14.1		1	1.8			1.5			14.2		1
12/17/21 6:00	1.4			1.4			14		1	1.6			1.5			14		1
12/17/21 7:00	1.2			1.4			13.9		1	1.5			1.5			14		1
12/17/21 8:00	1.1			1.5			14.2		1	1.4			1.5			14.3		1
12/17/21 9:00	0.6			1.7			14.5		1	0.6			1.4			14.6		1
12/17/21 10:00	0.5			1.6			14.6		1	0.6			1.5			14.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/17/21 11:00	0.5			1.6			14.6		1	0.6			1.5			14.6		1
12/17/21 12:00	0.5			1.6			14.6		1	0.6			1.5			14.6		1
12/17/21 13:00	0.5			1.5			14.6		1	0.6			1.5			14.6		1
12/17/21 14:00	0.5			1.6			14.6		1	0.6			1.5			14.6		1
12/17/21 15:00	0.9			1.4			14.3		1	1			1.5			14.3		1
12/17/21 16:00	1.4			1.5			14		1	1.3			1.5			14.1		1
12/17/21 17:00	1.5			1.5			14.1		1	1.5			1.5			14.2		1
12/17/21 18:00	1.5			1.5			14.1		1	1.5			1.5			14.2		1
12/17/21 19:00	1.5			1.5			14.1		1	1.4			1.5			14.2		1
12/17/21 20:00	1.5			1.5			14.1		1	1.4			1.5			14.2		1
12/17/21 21:00	1.5			1.5			14.1		1	1.4			1.5			14.2		1
12/17/21 22:00	1.6			1.5			14.1		1	1.5			1.5			14.2		1
12/17/21 23:00	1.2			1.6			14.2		1	1.2			1.5			14.3		1
12/18/21 0:00	0.7			1.5			14.3		1	0.9			1.4			14.3		1
12/18/21 1:00	0.9			1.5			14.3		1	1			1.5			14.3		1
12/18/21 2:00	0.9			1.6			14.3		1	1			1.6			14.3		1
12/18/21 3:00	0.9			1.5			14.2		1	1			1.3			14.2		1
12/18/21 4:00	0.8			1.5			14.3		1	0.9			1.5			14.3		1
12/18/21 5:00	1			1.6			14.2		1	1.2			1.6			14.3		1
12/18/21 6:00	1.5			1.5			14.1		1	1.5			1.5			14.2		1
12/18/21 7:00	0.9			1.7			14.3		1	1			1.6			14.3		1
12/18/21 8:00	0.6			1.8			14.5		1	0.7			1.5			14.5		1
12/18/21 9:00	0.6			1.7			14.5		1	0.7			1.3			14.6		1
12/18/21 10:00	0.6			1.4			14.3		1	0.8			1.4			14.4		1
12/18/21 11:00	0.6			1.7			14.4		1	0.7			1.5			14.5		1
12/18/21 12:00	0.5			1.7			14.6		1	0.6			1.4			14.6		1
12/18/21 13:00	0.5			1.6			14.6		1	0.6			1.4			14.6		1
12/18/21 14:00	0.5			1.6			14.6		1	0.6			1.4			14.6		1
12/18/21 15:00	0.5			1.4			14.5		1	0.6			1.3			14.5		1
12/18/21 16:00	1			1.5			14.2		1	1.3			1.4			14.3		1
12/18/21 17:00	1.5			1.4			14.1		1	1.8			1.4			14.2		1
12/18/21 18:00	1.5			1.4			14.1		1	1.8			1.4			14.2		1
12/18/21 19:00	1.6			1.4			14.1		1	1.8			1.4			14.2		1
12/18/21 20:00	1.6			1.4			14.1		1	1.8			1.4			14.2		1
12/18/21 21:00	1.6			1.4			14.1		1	1.7			1.4			14.2		1
12/18/21 22:00	1.5			1.4			14.1		1	1.7			1.4			14.2		1
12/18/21 23:00	0.9			1.6			14.3		1	1.1			1.4			14.4		1
12/19/21 0:00	0.7			1.3			14.3		1	0.8			1.4			14.3		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/19/21 1:00	0.7			1.3			14.3		1	0.8			1.4			14.3		1
12/19/21 2:00	0.7			1.6			14.2		1	0.9			1.5			14.3		1
12/19/21 3:00	0.6			1.7			14.5		1	0.6			1.3			14.6		1
12/19/21 4:00	0.5			1.6			14.6		1	0.6			1.3			14.6		1
12/19/21 5:00	0.9			1.3			14.3		1	1.2			1.3			14.3		1
12/19/21 6:00	1.2			1.4			14.2		1	1.2			1.3			14.3		1
12/19/21 7:00	0.6			1.6			14.4		1	0.7			1.3			14.5		1
12/19/21 8:00	0.5			1.6			14.6		1	0.7			1.3			14.6		1
12/19/21 9:00	0.7			1.3			14.4		1	0.8			1.2			14.4		1
12/19/21 10:00	0.7			1.3			14.3		1	0.8			1.3			14.4		1
12/19/21 11:00	0.6			1.7			14.4		1	0.8			1.3			14.5		1
12/19/21 12:00	0.5			1.6			14.6		1	0.7			1.3			14.6		1
12/19/21 13:00	0.5			1.4			14.5		1	0.7			1.3			14.6		1
12/19/21 14:00	0.6			1.3			14.4		1	0.7			1.3			14.4		1
12/19/21 15:00	0.8			1.4			14.3		1	1			1.3			14.2		1
12/19/21 16:00	1.6			1.3			14.1		1	1.4			1.3			14.2		1
12/19/21 17:00	1.6			1.3			14.1		1	1.5			1.3			14.2		1
12/19/21 18:00	1.6			1.3			14.1		1	1.5			1.3			14.2		1
12/19/21 19:00	1.4			1.4			14.1		1	1.6			1.4			14.2		1
12/19/21 20:00	1.3			1.4			14.1		1	1.4			1.4			14.2		1
12/19/21 21:00	1.4			1.4			14.1		1	1.5			1.4			14.2		1
12/19/21 22:00	1.3			1.4			14.2		1	1.4			1.4			14.2		1
12/19/21 23:00	0.9			1.5			14.2		1	1			1.4			14.3		1
12/20/21 0:00	0.7			1.7			14.4		1	0.8			1.3			14.5		1
12/20/21 1:00	0.9			1.3			14.2		1	1			1.4			14.3		1
12/20/21 2:00	0.8			1.3			14.2		1	1			1.2			14.3		1
12/20/21 3:00	0.9			1.5			14.2		1	1.1			1.3			14.2		1
12/20/21 4:00	0.9			1.6			14.3		1	1.1			1.4			14.4		1
12/20/21 5:00	1.2			1.3			14.1		1	1.5			1.4			14.1		1
12/20/21 6:00	1.4			1.5			14		1	1.5			1.5			14.1		1
12/20/21 7:00	1.2			1.5			14.1		1	1.3			1.5			14.1		1
12/20/21 8:00	0.7			1.6			14.4		1	0.9			1.4			14.4		1
12/20/21 9:00	0.7			1.6			14.4		1	0.9			1.3			14.5		1
12/20/21 10:00	0.6			1.9			14.5		1	0.7			1.4			14.6		1
12/20/21 11:00	0.7			1.4			14.4		1	0.8			1.4			14.4		1
12/20/21 12:00	0.7			1.1			14.4		1	0.8			1.5			14.4		1
12/20/21 13:00	0.6			1.1			14.4		1	0.8			1.5			14.4		1
12/20/21 14:00	0.8			1.3			13.5		1	1			1.5			13.4		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/20/21 15:00	0.5			1.4			13		1	0.6			1.5			13.1		1
12/20/21 16:00	1.1			1.4			13.7		1	1.3			1.5			13.7		1
12/20/21 17:00	0.5			1.4			12.9		1	0.6			1.5			13		1
12/20/21 18:00	0.8			1.4			13.4		1	1			1.5			13.5		1
12/20/21 19:00	0.7			1.4			13.3		1	0.9			1.5			13.3		1
12/20/21 20:00	0.4			1.4			12.8		1	0.5			1.5			12.9		1
12/20/21 21:00	0.7			1.4			13.3		1	0.9			1.5			13.4		1
12/20/21 22:00	0.8			1.4			13.5		1	1			1.5			13.5		1
12/20/21 23:00	1.1			1.4			13.9		1	1.1			1.5			13.8		1
12/21/21 0:00	0.7			1.4			14.3		1	0.9			1.5			14.4		1
12/21/21 1:00	0.7			1.4			14.3		1	0.9			1.5			14.3		1
12/21/21 2:00	0.8			1.4			14.3		1	1			1.5			14.3		1
12/21/21 3:00	0.9			1.4			14.2		1	1			1.5			14.3		1
12/21/21 4:00	0.8			1.4			14.2		1	1			1.5			14.3		1
12/21/21 5:00	0.8			1.5			14.3		1	1			1.5			14.3		1
12/21/21 6:00	0.7			1.5			14.3		1	0.8			1.5			14.4		1
12/21/21 7:00	0.9			1.5			14.2		1	1.3			1.6			14.3		1
12/21/21 8:00	0.4			1.5			12.5		1	0.5			1.5			12.6		1
12/21/21 9:00	0.3			1.5			12.5		1	0.5			1.5			12.6		1
12/21/21 10:00	1.6			1.5			14.2		1	1.9			1.5			14.2		1
12/21/21 11:00	0.8			1.7			14.3		1	0.9			1.6			14.3		1
12/21/21 12:00	0.6			1.6			14.4		1	0.8			1.4			14.5		1
12/21/21 13:00	0.6			1.5			14.3		1	0.8			1.5			14.4		1
12/21/21 14:00	1			1.5			14.2		1	1.3			1.5			14.2		1
12/21/21 15:00	1.5			1.5			14.1		1	1.7			1.5			14.1		1
12/21/21 16:00	1.3			1.5			14		1	1.4			1.5			14.1		1
12/21/21 17:00	1.5			1.5			14.1		1	1.5			1.5			14.2		1
12/21/21 18:00	1.4			1.5			14.1		1	1.5			1.5			14.1		1
12/21/21 19:00	1.3			1.5			14.1		1	1.5			1.5			14.1		1
12/21/21 20:00	1.3			1.5			14.1		1	1.5			1.5			14.2		1
12/21/21 21:00	1.4			1.5			14.1		1	1.6			1.5			14.1		1
12/21/21 22:00	1.5			1.5			14.1		1	1.5			1.5			14.1		1
12/21/21 23:00	1.1			1.7			14.2		1	1.2			1.6			14.3		1
12/22/21 0:00	0.5			1.7			14.6		1	0.7			1.5			14.6		1
12/22/21 1:00	0.5			1.6			14.6		1	0.7			1.5			14.6		1
12/22/21 2:00	0.5			1.6			14.5		1	0.7			1.5			14.6		1
12/22/21 3:00	0.6			1.6			14.5		1	0.7			1.5			14.6		1
12/22/21 4:00	0.5			1.6			14.5		1	0.7			1.5			14.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/22/21 5:00	1.3			1.4			14.2		1	1.4			1.4			14.1		1
12/22/21 6:00	1.6			1.4			14.1		1	1.6			1.5			14.1		1
12/22/21 7:00	1.6			1.4			14.1		1	1.6			1.5			14.1		1
12/22/21 8:00	1.6			1.4			14.1		1	1.6			1.5			14.1		1
12/22/21 9:00	1.6			1.4			14.1		1	1.6			1.5			14.1		1
12/22/21 10:00	1.2			1.5			14.2		1	1.3			1.6			14.2		1
12/22/21 11:00	0.6			1.7			14.5		1	0.7			1.5			14.6		1
12/22/21 12:00	0.6			1.5			14.5		1	0.7			1.5			14.5		1
12/22/21 13:00	0.9			1.4			14.2		1	1.1			1.4			14.2		1
12/22/21 14:00	1.3			1.5			13.9		1	1.4			1.5			13.9		1
12/22/21 15:00	1.3			1.5			13.9		1	1.3			1.5			13.9		1
12/22/21 16:00	1.3			1.5			13.9		1	1.3			1.5			13.9		1
12/22/21 17:00	1.2			1.5			13.9		1	1.3			1.5			13.9		1
12/22/21 18:00	1.2			1.5			13.9		1	1.3			1.5			13.9		1
12/22/21 19:00	1.3			1.5			13.9		1	1.4			1.5			14		1
12/22/21 20:00	0.7			1.7			14.4		1	0.8			1.5			14.5		1
12/22/21 21:00	0.6			1.5			14.5		1	0.8			1.5			14.5		1
12/22/21 22:00	0.7			1.6			14.4		1	0.7			1.4			14.4		1
12/22/21 23:00	0.6			1.5			14.4		1	0.7			1.5			14.5		1
12/23/21 0:00	0.7			1.5			14.3		1	0.9			1.4			14.3		1
12/23/21 1:00	0.7			1.5			14.3		1	0.8			1.5			14.4		1
12/23/21 2:00	0.6			1.4			14.5		1	0.6			1.4			14.5		1
12/23/21 3:00	0.6			1.6			14.5		1	0.6			1.5			14.5		1
12/23/21 4:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
12/23/21 5:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
12/23/21 6:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
12/23/21 7:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
12/23/21 8:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
12/23/21 9:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
12/23/21 10:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
12/23/21 11:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
12/23/21 12:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
12/23/21 13:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
12/23/21 14:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/23/21 15:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/23/21 16:00	0.6			1.5			14.5		1	0.7			1.5			14.5		1
12/23/21 17:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/23/21 18:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/23/21 19:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
12/23/21 20:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
12/23/21 21:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
12/23/21 22:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
12/23/21 23:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
12/24/21 0:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
12/24/21 1:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
12/24/21 2:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
12/24/21 3:00	0.6			1.6			14.5		1	0.6			1.5			14.5		1
12/24/21 4:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
12/24/21 5:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
12/24/21 6:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
12/24/21 7:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
12/24/21 8:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
12/24/21 9:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
12/24/21 10:00	0.5			1.5			14.5		1	0.7			1.5			14.6		1
12/24/21 11:00	0.5			1.5			14.5		1	0.7			1.5			14.6		1
12/24/21 12:00	0.5			1.5			14.5		1	0.7			1.5			14.6		1
12/24/21 13:00	0.5			1.5			14.5		1	0.7			1.5			14.6		1
12/24/21 14:00	0.5			1.5			14.5		1	0.7			1.5			14.6		1
12/24/21 15:00	0.5			1.5			14.5		1	0.7			1.5			14.6		1
12/24/21 16:00	0.5			1.5			14.5		1	0.7			1.5			14.6		1
12/24/21 17:00	0.5			1.5			14.5		1	0.7			1.5			14.6		1
12/24/21 18:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/24/21 19:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/24/21 20:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/24/21 21:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/24/21 22:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/24/21 23:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/25/21 0:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/25/21 1:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/25/21 2:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/25/21 3:00	0.6			1.6			14.5		1	0.7			1.5			14.6		1
12/25/21 4:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/25/21 5:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/25/21 6:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/25/21 7:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/25/21 8:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/25/21 9:00	0.5			1.5			14.5		1	0.7			1.5			14.6		1
12/25/21 10:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/25/21 11:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
12/25/21 12:00	0.6			1.6			14.5		1	0.6			1.5			14.5		1
12/25/21 13:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
12/25/21 14:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
12/25/21 15:00	0.6			1.4			14.4		1	0.7			1.4			14.5		1
12/25/21 16:00	0.6			1.7			14.5		1	0.6			1.6			14.5		1
12/25/21 17:00	0.6			1.6			14.5		1	0.6			1.5			14.5		1
12/25/21 18:00	0.6			1.6			14.5		1	0.6			1.5			14.5		1
12/25/21 19:00	0.6			1.6			14.5		1	0.6			1.5			14.5		1
12/25/21 20:00	0.6			1.6			14.5		1	0.6			1.5			14.5		1
12/25/21 21:00	0.5			1.6			14.5		1	0.6			1.5			14.5		1
12/25/21 22:00	0.5			1.6			14.5		1	0.7			1.5			14.6		1
12/25/21 23:00	0.5			1.6			14.5		1	0.7			1.5			14.6		1
12/26/21 0:00	0.5			1.6			14.5		1	0.7			1.5			14.6		1
12/26/21 1:00	0.5			1.6			14.5		1	0.7			1.5			14.6		1
12/26/21 2:00	0.5			1.5			14.5		1	0.7			1.5			14.6		1
12/26/21 3:00	0.6			1.6			14.5		1	0.6			1.5			14.5		1
12/26/21 4:00	0.5			1.5			14.5		1	0.7			1.5			14.6		1
12/26/21 5:00	0.5			1.5			14.5		1	0.7			1.5			14.6		1
12/26/21 6:00	0.6			1.5			14.5		1	0.6			1.5			14.5		1
12/26/21 7:00	0.5			1.6			14.5		1	0.7			1.5			14.6		1
12/26/21 8:00	0.5			1.6			14.6		1	0.7			1.5			14.6		1
12/26/21 9:00	0.5			1.6			14.6		1	0.7			1.5			14.6		1
12/26/21 10:00	0.5			1.6			14.5		1	0.7			1.5			14.6		1
12/26/21 11:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/26/21 12:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/26/21 13:00	0.6			1.5			14.4		1	0.8			1.4			14.5		1
12/26/21 14:00	0.6			1.6			14.5		1	0.7			1.3			14.5		1
12/26/21 15:00	0.6			1.6			14.4		1	0.7			1.5			14.5		1
12/26/21 16:00	0.8			1			14.4		1	1			0.8			14.4		1
12/26/21 17:00	1.5			1.4			14		1	1.5			1.3			14.1		1
12/26/21 18:00	0.9			1.8			14.3		1	1			1.6			14.4		1
12/26/21 19:00	0.6			1.7			14.5		1	0.6			1.5			14.5		1
12/26/21 20:00	0.6			1.5			14.5		1	0.7			1.4			14.5		1
12/26/21 21:00	0.7			1.5			14.3		1	0.8			1.4			14.4		1
12/26/21 22:00	0.6			1.9			14.4		1	0.8			1.6			14.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/26/21 23:00	0.6			1.7			14.5		1	0.7			1.5			14.6		1
12/27/21 0:00	0.6			1.6			14.5		1	0.6			1.5			14.5		1
12/27/21 1:00	0.6			1.6			14.5		1	0.6			1.5			14.5		1
12/27/21 2:00	0.6			1.6			14.5		1	0.6			1.5			14.5		1
12/27/21 3:00	0.6			1.6			14.5		1	0.6			1.5			14.5		1
12/27/21 4:00	0.6			1.6			14.5		1	0.6			1.5			14.5		1
12/27/21 5:00	0.9			1.5			14.3		1	1.1			1.4			14.2		1
12/27/21 6:00	1.3			1.5			14		1	1.6			1.5			14		1
12/27/21 7:00	1.3			1.5			14		1	1.5			1.5			14		1
12/27/21 8:00	1.3			1.5			13.9		1	1.4			1.5			14		1
12/27/21 9:00	1			1.5			14		1	1.2			1.5			14.1		1
12/27/21 10:00	0.7			1.5			14.3		1	0.8			1.4			14.4		1
12/27/21 11:00	0.7			1.6			14.3		1	0.8			1.5			14.4		1
12/27/21 12:00	0.5			1.6			14.5		1	0.7			1.6			14.6		1
12/27/21 13:00	0.5			1.4			14.5		1	0.7			1.4			14.6		1
12/27/21 14:00	0.7			1.5			14.3		1	0.8			1.5			14.4		1
12/27/21 15:00	0.9			1.5			14.1		1	1.2			1.5			14.2		1
12/27/21 16:00	1.1			1.5			13.9		1	1.2			1.5			14		1
12/27/21 17:00	1.2			1.5			13.9		1	1.2			1.5			13.9		1
12/27/21 18:00	1.3			1.5			13.8		1	1.3			1.5			13.8		1
12/27/21 19:00	1.2			1.5			13.8		1	1.2			1.5			13.8		1
12/27/21 20:00	1.2			1.5			13.7		1	1.2			1.5			13.8		1
12/27/21 21:00	1.5			1.5			14		1	1.5			1.5			14.1		1
12/27/21 22:00	1.2			1.5			14.1		1	1.4			1.5			14.2		1
12/27/21 23:00	0.7			1.7			14.4		1	0.8			1.5			14.4		1
12/28/21 0:00	0.6			1.7			14.4		1	0.7			1.5			14.5		1
12/28/21 1:00	0.6			1.6			14.5		1	0.6			1.5			14.5		1
12/28/21 2:00	0.6			1.5			14.5		1	0.7			1.5			14.5		1
12/28/21 3:00	0.7			1.5			14.4		1	0.8			1.5			14.4		1
12/28/21 4:00	0.6			1.7			14.5		1	0.7			1.5			14.5		1
12/28/21 5:00	0.7			1.4			14.3		1	0.9			1.4			14.4		1
12/28/21 6:00	0.8			1.5			14.2		1	0.9			1.5			14.3		1
12/28/21 7:00	0.6			1.9			14.5		1	0.8			1.4			14.5		1
12/28/21 8:00	0.7			1.6			14.4		1	0.8			1.3			14.5		1
12/28/21 9:00	0.7			1.5			14.3		1	0.9			1.4			14.4		1
12/28/21 10:00	0.6			1.7			14.5		1	0.7			1.3			14.6		1
12/28/21 11:00	0.6			1.6			14.5		1	0.7			1.3			14.6		1
12/28/21 12:00	0.6			1.5			14.5		1	0.7			1.4			14.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/28/21 13:00	0.5			1.5			14.5		1	0.7			1.5			14.6		1
12/28/21 14:00	0.5			1.5			14.5		1	0.7			1.5			14.6		1
12/28/21 15:00	0.6			1.3			14.4		1	0.7			1.3			14.5		1
12/28/21 16:00	0.6			1.6			14.4		1	0.8			1.3			14.5		1
12/28/21 17:00	0.6			1.5			14.4		1	0.8			1.5			14.4		1
12/28/21 18:00	0.7			1.5			14.3		1	0.9			1.5			14.4		1
12/28/21 19:00	0.8			1.4			14.2		1	0.9			1.4			14.3		1
12/28/21 20:00	0.7			1.6			14.3		1	0.9			1.5			14.4		1
12/28/21 21:00	0.7			1.6			14.4		1	0.8			1.3			14.5		1
12/28/21 22:00	0.6			1.5			14.5		1	0.7			1.5			14.5		1
12/28/21 23:00	0.6			1.5			14.5		1	0.7			1.5			14.5		1
12/29/21 0:00	0.6			1.5			14.5		1	0.7			1.5			14.5		1
12/29/21 1:00	0.6			1.5			14.5		1	0.7			1.5			14.5		1
12/29/21 2:00	0.6			1.4			14.5		1	0.6			1.4			14.5		1
12/29/21 3:00	0.6			1.5			14.5		1	0.7			1.5			14.5		1
12/29/21 4:00	0.5			1.5			14.5		1	0.6			1.5			14.5		1
12/29/21 5:00	0.5			1.5			14.4		1	0.7			1.5			14.5		1
12/29/21 6:00	0.6			1.4			14.4		1	0.7			1.4			14.5		1
12/29/21 7:00	0.6			1.7			14.5		1	0.7			1.5			14.5		1
12/29/21 8:00	0.6			1.6			14.5		1	0.6			1.4			14.5		1
12/29/21 9:00	0.6			1.6			14.5		1	0.6			1.5			14.5		1
12/29/21 10:00	0.6			1.6			14.5		1	0.7			1.5			14.6		1
12/29/21 11:00	0.5			1.5			14.5		1	0.7			1.5			14.6		1
12/29/21 12:00	0.6			1.5			14.5		1	0.7			1.5			14.5		1
12/29/21 13:00	0.6			1.5			14.4		1	0.7			1.4			14.5		1
12/29/21 14:00	0.7			1.4			14.3		1	0.8			1.4			14.3		1
12/29/21 15:00	0.7			1.5			14.3		1	0.8			1.3			14.4		1
12/29/21 16:00	0.7			1.6			14.3		1	0.8			1.4			14.4		1
12/29/21 17:00	0.7			1.4			14.3		1	0.8			1.5			14.4		1
12/29/21 18:00	0.7			1.4			14.3		1	0.8			1.5			14.4		1
12/29/21 19:00	0.7			1.4			14.3		1	0.8			1.5			14.4		1
12/29/21 20:00	0.7			1.4			14.3		1	0.8			1.5			14.4		1
12/29/21 21:00	0.7			1.7			14.3		1	0.8			1.5			14.4		1
12/29/21 22:00	0.6			1.7			14.5		1	0.7			1.4			14.5		1
12/29/21 23:00	0.6			1.6			14.5		1	0.7			1.5			14.6		1
12/30/21 0:00	0.5			1.6			14.5		1	0.7			1.5			14.6		1
12/30/21 1:00	0.6			1.6			14.5		1	0.7			1.5			14.6		1
12/30/21 2:00	0.6			1.5			14.5		1	0.7			1.4			14.6		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/30/21 3:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/30/21 4:00	0.6			1.6			14.5		1	0.7			1.5			14.6		1
12/30/21 5:00	1.2			1.4			14.1		1	1.5			1.3			14.1		1
12/30/21 6:00	1.6			1.5			14.1		1	1.6			1.5			14.1		1
12/30/21 7:00	1.6			1.5			14.1		1	1.5			1.5			14.1		1
12/30/21 8:00	1.6			1.5			14.1		1	1.6			1.5			14.1		1
12/30/21 9:00	1.6			1.5			14.1		1	1.5			1.5			14.1		1
12/30/21 10:00	0.7			1.7			14.4		1	0.8			1.3			14.5		1
12/30/21 11:00	0.6			1.5			14.5		1	0.7			1.2			14.6		1
12/30/21 12:00	0.6			1.4			14.5		1	0.7			1.2			14.6		1
12/30/21 13:00	0.6			1.4			14.5		1	0.7			1.2			14.6		1
12/30/21 14:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/30/21 15:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/30/21 16:00	0.9			1.4			14.2		1	1.1			1.4			14.2		1
12/30/21 17:00	1.5			1.5			14		1	1.6			1.5			14		1
12/30/21 18:00	1.7			1.5			14		1	1.6			1.5			14		1
12/30/21 19:00	1.5			1.5			14		1	1.6			1.5			14		1
12/30/21 20:00	1.7			1.5			14		1	1.7			1.5			14		1
12/30/21 21:00	1.6			1.5			14		1	1.6			1.5			14.1		1
12/30/21 22:00	1			1.5			14.2		1	1.2			1.5			14.3		1
12/30/21 23:00	0.6			1.6			14.5		1	0.7			1.4			14.5		1
12/31/21 0:00	0.6			1.6			14.5		1	0.7			1.4			14.6		1
12/31/21 1:00	0.6			1.6			14.5		1	0.7			1.4			14.6		1
12/31/21 2:00	0.6			1.5			14.5		1	0.7			1.4			14.6		1
12/31/21 3:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/31/21 4:00	0.6			1.6			14.5		1	0.7			1.5			14.6		1
12/31/21 5:00	0.6			1.6			14.5		1	0.7			1.5			14.6		1
12/31/21 6:00	0.6			1.6			14.5		1	0.7			1.5			14.6		1
12/31/21 7:00	0.6			1.6			14.5		1	0.7			1.5			14.5		1
12/31/21 8:00	0.6			1.5			14.5		1	0.7			1.5			14.5		1
12/31/21 9:00	0.6			1.6			14.5		1	0.7			1.5			14.5		1
12/31/21 10:00	0.6			1.5			14.5		1	0.7			1.5			14.6		1
12/31/21 11:00	0.6			1.4			14.5		1	0.7			1.5			14.6		1
12/31/21 12:00	0.6			1.3			14.5		1	0.7			1.5			14.6		1
12/31/21 13:00	0.5			1.3			14.5		1	0.7			1.4			14.6		1
12/31/21 14:00	0.5			1.4			14.5		1	0.7			1.5			14.6		1
12/31/21 15:00	0.5			1.3			14.5		1	0.7			1.5			14.6		1
12/31/21 16:00	0.6			1.2			14.5		1	0.7			1.3			14.5		1

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_O2Dry_Pct_1H			CT2_CO_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT2_O2Dry_Pct_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/31/21 17:00	0.8			1.4			14.2		1	0.9			1.5			14.3		1
12/31/21 18:00	0.7			1.3			14.3		1	0.9			1.4			14.3		1
12/31/21 19:00	0.7			1.3			14.4		1	0.8			1.5			14.4		1
12/31/21 20:00	0.7			1.3			14.3		1	0.9			1.4			14.3		1
12/31/21 21:00	0.6			1.4			14.3		1	0.8			1.5			14.4		1
12/31/21 22:00	0.8			1.4			14.2		1	1			1.5			14.3		1
12/31/21 23:00	0.7			1.7			14.4		1	0.9			1.5			14.5		1

AQ32 DAILY NOX CO

Date/Time	CT1_CO_Lb_1D			CT1_NOx_Lb_1D			CT2_CO_Lb_1D			CT2_NOx_Lb_1D			Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod						
10/01/21 0:00	13.86			46.15			17.28			49.28								
10/02/21 0:00	13.68			47.15			18.1			50.38								
10/03/21 0:00	15.9			46.32			18.75			49.15								
10/04/21 0:00	19.17			58.22			23.46			62.09								
10/05/21 0:00	11.81			44.6			15.25			47.23								
10/06/21 0:00	12.78			47.76			15.69			50.39								
10/07/21 0:00	11.13			46.19			13.69			49.14								
10/08/21 0:00	10.15			44.12			12.29			46.44								
10/09/21 0:00	8.62			40.56			10.54			43.2								
10/10/21 0:00	9.03			40.55			11.07			43.23								
10/11/21 0:00	15.37			55.81			20.05			59.65								
10/12/21 0:00	13.62			54.24			19.14			58.76								
10/13/21 0:00	15.21			56.16			20.44			59.81								
10/14/21 0:00	25.02			42.39			18.26			52.68								
10/15/21 0:00	0			0			41.5			67.51								
10/16/21 0:00	0			0			39.83			68.11								
10/17/21 0:00	0			0			39.39			68.86								
10/18/21 0:00	0			0			40.8			63.27								
10/19/21 0:00	0			0			37.83			60.82								
10/20/21 0:00	52.32			11.47			18.33			47.71								
10/21/21 0:00	13.88			51.89			18.72			55.59								
10/22/21 0:00	10.1			44.29			14.4			47.8								
10/23/21 0:00	12.32			48.93			16.23			50.99								
10/24/21 0:00	12.38			49.74			16.38			53.45								
10/25/21 0:00	11.26			46.53			14.72			49.51								
10/26/21 0:00	9.79			43.46			12.73			45.64								
10/27/21 0:00	10.16			44.99			12.52			47.99								
10/28/21 0:00	11.17			44.69			13.52			47.55								
10/29/21 0:00	12.11			44.78			15.18			47.53								
10/30/21 0:00	7.83			38.69			9.73			41.17								
10/31/21 0:00	7.14			38.03			9.25			40.65								
11/01/21 0:00	12.68			48.08			15.73			51.12								
11/02/21 0:00	10.57			45.06			12.92			48.46								
11/03/21 0:00	12.54			47.59			14.73			50.55								
11/04/21 0:00	8.76			40.64			9.82			41.62								

Date/Time	CT1_CO_Lb_1D			CT1_NOx_Lb_1D			CT2_CO_Lb_1D			CT2_NOx_Lb_1D			Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod						
11/05/21 0:00	10.75			44.43			12.57			46.82								
11/06/21 0:00	11.02			45.67			12.78			48								
11/07/21 0:00	8.86			42.67			9.73			37.87								
11/08/21 0:00	14.79			48.39			17.72			50.9								
11/09/21 0:00	9.72			43.6			11.04			45.76								
11/10/21 0:00	7.81			40.43			9.32			42.19								
11/11/21 0:00	15.98			45.33			17.99			47.63								
11/12/21 0:00	7.68			38.89			9.23			40.52								
11/13/21 0:00	12.11			46.61			14.27			48.26								
11/14/21 0:00	7.11			38.48			8.39			40.83								
11/15/21 0:00	9.25			40.33			10.88			42.02								
11/16/21 0:00	12.16			45.27			13.81			47.87								
11/17/21 0:00	14.14			44.88			16.17			46.73								
11/18/21 0:00	13.19			42.45			14.98			44.41								
11/19/21 0:00	67.36			29.79			12.25			38.18								
11/20/21 0:00	8.56			37.07			9.97			36.72								
11/21/21 0:00	13			41.77			15.32			42.17								
11/22/21 0:00	12.5			41.22			14.42			42.41								
11/23/21 0:00	8.16			35.18			9.21			36.27								
11/24/21 0:00	8.3			40.05			10.56			41.02								
11/25/21 0:00	9.36			39.03			12.26			41.4								
11/26/21 0:00	10.03			38.13			12.6			41.2								
11/27/21 0:00	10.1			40.33			12.78			42.27								
11/28/21 0:00	9.69			38.08			12.47			40.84								
11/29/21 0:00	12.19			43.32			15.35			45.29								
11/30/21 0:00	13.72			48.94			18.16			52.36								
12/01/21 0:00	12.41			42.63			15.23			45.01								
12/02/21 0:00	20.54			50.35			25.02			52.44								
12/03/21 0:00	19.15			50.9			21.23			53.4								
12/04/21 0:00	17.58			46.76			21.96			47.3								
12/05/21 0:00	14.12			46.11			17.44			48.37								
12/06/21 0:00	21.68			58.5			25.48			62.23								
12/07/21 0:00	20.79			57.09			24.52			59.94								
12/08/21 0:00	14.49			48.29			18.44			51.11								
12/09/21 0:00	11.99			44.41			15.56			45.79								
12/10/21 0:00	14.17			51.24			19.01			53.38								
12/11/21 0:00	12.39			46.98			16.09			48.54								
12/12/21 0:00	12.7			46.31			16.59			48.61								

Date/Time	CT1_CO_Lb_1D			CT1_NOx_Lb_1D			CT2_CO_Lb_1D			CT2_NOx_Lb_1D			Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod						
12/13/21 0:00	17.61			54.34			21.98			58.17								
12/14/21 0:00	11.94			45.85			16.05			47.99								
12/15/21 0:00	12.72			50.34			16.37			53.37								
12/16/21 0:00	24.49			57.92			28.09			61.71								
12/17/21 0:00	23.58			53.48			26.91			56.48								
12/18/21 0:00	22.34			54.04			27.38			54.88								
12/19/21 0:00	20.9			50.32			24.88			51.31								
12/20/21 0:00	19.72			57.31			25.46			64.17								
12/21/21 0:00	25.35			63.24			31.93			68.31								
12/22/21 0:00	23.21			53.07			27.28			57.13								
12/23/21 0:00	9.03			38.72			11.39			41.38								
12/24/21 0:00	8.23			38.07			10.95			41.1								
12/25/21 0:00	8.41			38.97			11.02			41.16								
12/26/21 0:00	11.02			43.54			14.12			43.54								
12/27/21 0:00	22.02			56.7			26.43			59.69								
12/28/21 0:00	11.17			46.04			15.1			45.74								
12/29/21 0:00	11.13			44.29			14.19			46.5								
12/30/21 0:00	23.93			51.65			26.92			53.48								
12/31/21 0:00	10.85			41.24			14.63			45.21								

Tons 12 Month Rolling Summary

CT1 and CT2 Combined



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:58 Location: Roseville, CA

* = Excess Emission

Date	Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2	
	CO, Ton		NOx, Ton		PM10, Ton		SO2, Ton		VOC, Ton	
	1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)	
	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum
Oct 2021	0.4854	5.2065	1.4017	10.1188	0.3030	2.0868	0.1514	1.0431	0.5047	3.4782
Nov 2021	0.3852	5.2713	1.2922	10.6823	0.2880	2.2353	0.1440	1.1173	0.4796	3.7254
Dec 2021	0.5686	5.7875	1.5683	12.2309	0.3450	2.5791	0.1722	1.2889	0.5749	4.2983
Sum/Avg	5.7875		12.2309		2.5791		1.2889		4.2983	
Limit Value										

AQ-33

AQ-33 The Project owner shall maintain records of Sox lb/hr, lb/day, and lb, quarter emissions. Sox emissions shall be based on fuel use records, natural gas sulfur content, and mass balance calculations.

Verification: The Project owner shall submit to the CPM all hourly, daily, and quarterly Sox emissions as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

AQ33 HOURLY SOX

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
10/01/21 0:00	0.19344			0.20874			0.4											
10/01/21 1:00	0.17502			0.18894			0.36											
10/01/21 2:00	0.17112			0.18444			0.36											
10/01/21 3:00	0.17532			0.18906			0.36											
10/01/21 4:00	0.22512			0.24288			0.47											
10/01/21 5:00	0.24144			0.26064			0.5											
10/01/21 6:00	0.19884			0.21396			0.41											
10/01/21 7:00	0.1905			0.20568			0.4											
10/01/21 8:00	0.16938			0.18222			0.35											
10/01/21 9:00	0.16584			0.17772			0.34											
10/01/21 10:00	0.17466			0.18684			0.36											
10/01/21 11:00	0.18588			0.19878			0.38											
10/01/21 12:00	0.22362			0.23862			0.46											
10/01/21 13:00	0.29724			0.31356			0.61											
10/01/21 14:00	0.26742			0.2844			0.55											
10/01/21 15:00	0.21666			0.23082			0.45											
10/01/21 16:00	0.24996			0.26604			0.52											
10/01/21 17:00	0.26202			0.2808			0.54											
10/01/21 18:00	0.24894			0.26718			0.52											
10/01/21 19:00	0.23838			0.25614			0.49											
10/01/21 20:00	0.26538			0.28644			0.55											
10/01/21 21:00	0.25782			0.27756			0.54											
10/01/21 22:00	0.19794			0.21264			0.41											
10/01/21 23:00	0.17502			0.18834			0.36											
10/02/21 0:00	0.21576			0.23262			0.45											
10/02/21 1:00	0.19086			0.20574			0.4											
10/02/21 2:00	0.19488			0.21006			0.4											
10/02/21 3:00	0.1893			0.2034			0.39											
10/02/21 4:00	0.20376			0.21942			0.42											
10/02/21 5:00	0.18852			0.20304			0.39											
10/02/21 6:00	0.26286			0.28458			0.55											
10/02/21 7:00	0.21276			0.22998			0.44											
10/02/21 8:00	0.16572			0.1779			0.34											
10/02/21 9:00	0.16536			0.17724			0.34											
10/02/21 10:00	0.16488			0.17628			0.34											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
10/02/21 11:00	0.16998			0.18174			0.35											
10/02/21 12:00	0.17394			0.18564			0.36											
10/02/21 13:00	0.23526			0.25086			0.49											
10/02/21 14:00	0.2412			0.25746			0.5											
10/02/21 15:00	0.21882			0.23346			0.45											
10/02/21 16:00	0.24306			0.2604			0.5											
10/02/21 17:00	0.26862			0.2892			0.56											
10/02/21 18:00	0.27132			0.29268			0.56											
10/02/21 19:00	0.27108			0.29244			0.56											
10/02/21 20:00	0.2712			0.29238			0.56											
10/02/21 21:00	0.261			0.2808			0.54											
10/02/21 22:00	0.2529			0.27252			0.53											
10/02/21 23:00	0.23856			0.2571			0.5											
10/03/21 0:00	0.1998			0.21498			0.41											
10/03/21 1:00	0.17166			0.18456			0.36											
10/03/21 2:00	0.17136			0.18432			0.36											
10/03/21 3:00	0.17238			0.18486			0.36											
10/03/21 4:00	0.17184			0.18468			0.36											
10/03/21 5:00	0.17214			0.18474			0.36											
10/03/21 6:00	0.17508			0.18876			0.36											
10/03/21 7:00	0.16638			0.17946			0.35											
10/03/21 8:00	0.16632			0.17868			0.35											
10/03/21 9:00	0.16506			0.17682			0.34											
10/03/21 10:00	0.16434			0.1758			0.34											
10/03/21 11:00	0.16776			0.17916			0.35											
10/03/21 12:00	0.17148			0.18276			0.35											
10/03/21 13:00	0.1872			0.19968			0.39											
10/03/21 14:00	0.2172			0.23172			0.45											
10/03/21 15:00	0.23868			0.25488			0.49											
10/03/21 16:00	0.28008			0.3015			0.58											
10/03/21 17:00	0.29466			0.31176			0.61											
10/03/21 18:00	0.29172			0.3105			0.6											
10/03/21 19:00	0.2895			0.30846			0.6											
10/03/21 20:00	0.29358			0.31242			0.61											
10/03/21 21:00	0.29514			0.31374			0.61											
10/03/21 22:00	0.23808			0.25512			0.49											
10/03/21 23:00	0.18624			0.19992			0.39											
10/04/21 0:00	0.17562			0.18888			0.36											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
10/04/21 1:00	0.1935			0.20826			0.4											
10/04/21 2:00	0.1812			0.19542			0.38											
10/04/21 3:00	0.26406			0.28512			0.55											
10/04/21 4:00	0.25854			0.279			0.54											
10/04/21 5:00	0.26754			0.28878			0.56											
10/04/21 6:00	0.26964			0.2913			0.56											
10/04/21 7:00	0.2604			0.28068			0.54											
10/04/21 8:00	0.27042			0.29154			0.56											
10/04/21 9:00	0.24672			0.26532			0.51											
10/04/21 10:00	0.2616			0.28128			0.54											
10/04/21 11:00	0.26496			0.28422			0.55											
10/04/21 12:00	0.27168			0.29166			0.56											
10/04/21 13:00	0.27138			0.2916			0.56											
10/04/21 14:00	0.27228			0.29136			0.56											
10/04/21 15:00	0.27564			0.29448			0.57											
10/04/21 16:00	0.34758			0.36396			0.71											
10/04/21 17:00	0.32568			0.3426			0.67											
10/04/21 18:00	0.31338			0.33138			0.64											
10/04/21 19:00	0.30234			0.32106			0.62											
10/04/21 20:00	0.29106			0.3108			0.6											
10/04/21 21:00	0.2931			0.31398			0.61											
10/04/21 22:00	0.2364			0.2541			0.49											
10/04/21 23:00	0.18288			0.19614			0.38											
10/05/21 0:00	0.17814			0.19086			0.37											
10/05/21 1:00	0.18696			0.2007			0.39											
10/05/21 2:00	0.17142			0.1842			0.36											
10/05/21 3:00	0.17622			0.18924			0.37											
10/05/21 4:00	0.21894			0.23562			0.45											
10/05/21 5:00	0.20466			0.22008			0.42											
10/05/21 6:00	0.2163			0.23268			0.45											
10/05/21 7:00	0.2415			0.26022			0.5											
10/05/21 8:00	0.17118			0.18336			0.35											
10/05/21 9:00	0.1794			0.1923			0.37											
10/05/21 10:00	0.2667			0.28698			0.55											
10/05/21 11:00	0.17634			0.18762			0.36											
10/05/21 12:00	0.1719			0.1827			0.35											
10/05/21 13:00	0.18144			0.1935			0.37											
10/05/21 14:00	0.21078			0.22536			0.44											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
10/05/21 15:00	0.21504			0.23016			0.45											
10/05/21 16:00	0.22974			0.24618			0.48											
10/05/21 17:00	0.22248			0.23832			0.46											
10/05/21 18:00	0.23958			0.25752			0.5											
10/05/21 19:00	0.18966			0.20322			0.39											
10/05/21 20:00	0.19902			0.21384			0.41											
10/05/21 21:00	0.22818			0.24588			0.47											
10/05/21 22:00	0.25044			0.27			0.52											
10/05/21 23:00	0.24948			0.26904			0.52											
10/06/21 0:00	0.17364			0.18654			0.36											
10/06/21 1:00	0.17328			0.18618			0.36											
10/06/21 2:00	0.17268			0.18558			0.36											
10/06/21 3:00	0.17268			0.1857			0.36											
10/06/21 4:00	0.1731			0.18588			0.36											
10/06/21 5:00	0.20142			0.21684			0.42											
10/06/21 6:00	0.22284			0.24012			0.46											
10/06/21 7:00	0.17556			0.18912			0.36											
10/06/21 8:00	0.19944			0.21462			0.41											
10/06/21 9:00	0.26202			0.28206			0.54											
10/06/21 10:00	0.22656			0.2436			0.47											
10/06/21 11:00	0.27174			0.29982			0.57											
10/06/21 12:00	0.273			0.29574			0.57											
10/06/21 13:00	0.23976			0.25818			0.5											
10/06/21 14:00	0.27402			0.29304			0.57											
10/06/21 15:00	0.22788			0.24384			0.47											
10/06/21 16:00	0.24684			0.26526			0.51											
10/06/21 17:00	0.18306			0.19572			0.38											
10/06/21 18:00	0.19752			0.21204			0.41											
10/06/21 19:00	0.19254			0.20688			0.4											
10/06/21 20:00	0.24918			0.26898			0.52											
10/06/21 21:00	0.2736			0.29526			0.57											
10/06/21 22:00	0.22362			0.24066			0.46											
10/06/21 23:00	0.17274			0.18594			0.36											
10/07/21 0:00	0.1725			0.18594			0.36											
10/07/21 1:00	0.17256			0.18594			0.36											
10/07/21 2:00	0.1725			0.186			0.36											
10/07/21 3:00	0.21594			0.23328			0.45											
10/07/21 4:00	0.23868			0.25782			0.5											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
10/07/21 5:00	0.264			0.28518			0.55											
10/07/21 6:00	0.2787			0.30072			0.58											
10/07/21 7:00	0.27198			0.29316			0.57											
10/07/21 8:00	0.24492			0.2643			0.51											
10/07/21 9:00	0.27312			0.2943			0.57											
10/07/21 10:00	0.20802			0.22302			0.43											
10/07/21 11:00	0.1893			0.20256			0.39											
10/07/21 12:00	0.17208			0.18408			0.36											
10/07/21 13:00	0.17142			0.183			0.35											
10/07/21 14:00	0.16848			0.17988			0.35											
10/07/21 15:00	0.17214			0.18384			0.36											
10/07/21 16:00	0.2073			0.22248			0.43											
10/07/21 17:00	0.27216			0.2937			0.57											
10/07/21 18:00	0.20934			0.22476			0.43											
10/07/21 19:00	0.1737			0.1863			0.36											
10/07/21 20:00	0.17964			0.19314			0.37											
10/07/21 21:00	0.1734			0.18624			0.36											
10/07/21 22:00	0.17634			0.18954			0.37											
10/07/21 23:00	0.21966			0.23712			0.46											
10/08/21 0:00	0.17322			0.18624			0.36											
10/08/21 1:00	0.17292			0.18606			0.36											
10/08/21 2:00	0.17244			0.18564			0.36											
10/08/21 3:00	0.17484			0.18816			0.36											
10/08/21 4:00	0.18282			0.19716			0.38											
10/08/21 5:00	0.16788			0.18114			0.35											
10/08/21 6:00	0.18132			0.19566			0.38											
10/08/21 7:00	0.27852			0.30126			0.58											
10/08/21 8:00	0.21354			0.23022			0.44											
10/08/21 9:00	0.27438			0.29616			0.57											
10/08/21 10:00	0.1791			0.1923			0.37											
10/08/21 11:00	0.23916			0.25758			0.5											
10/08/21 12:00	0.23238			0.2502			0.48											
10/08/21 13:00	0.24006			0.25866			0.5											
10/08/21 14:00	0.2739			0.29496			0.57											
10/08/21 15:00	0.1734			0.18552			0.36											
10/08/21 16:00	0.20352			0.21864			0.42											
10/08/21 17:00	0.17394			0.18636			0.36											
10/08/21 18:00	0.17118			0.1839			0.36											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
10/08/21 19:00	0.16956			0.18252			0.35											
10/08/21 20:00	0.17088			0.18414			0.36											
10/08/21 21:00	0.17232			0.1857			0.36											
10/08/21 22:00	0.1755			0.18918			0.36											
10/08/21 23:00	0.17028			0.1836			0.35											
10/09/21 0:00	0.16848			0.18228			0.35											
10/09/21 1:00	0.16512			0.17874			0.34											
10/09/21 2:00	0.16584			0.1794			0.35											
10/09/21 3:00	0.16536			0.17952			0.34											
10/09/21 4:00	0.17364			0.18792			0.36											
10/09/21 5:00	0.20628			0.22302			0.43											
10/09/21 6:00	0.20484			0.22182			0.43											
10/09/21 7:00	0.23994			0.25968			0.5											
10/09/21 8:00	0.19578			0.21126			0.41											
10/09/21 9:00	0.16836			0.18186			0.35											
10/09/21 10:00	0.16602			0.1791			0.35											
10/09/21 11:00	0.16596			0.17904			0.35											
10/09/21 12:00	0.16596			0.17844			0.34											
10/09/21 13:00	0.16584			0.17808			0.34											
10/09/21 14:00	0.16578			0.17784			0.34											
10/09/21 15:00	0.1713			0.18366			0.35											
10/09/21 16:00	0.21264			0.22764			0.44											
10/09/21 17:00	0.25308			0.27078			0.52											
10/09/21 18:00	0.18564			0.1989			0.38											
10/09/21 19:00	0.17106			0.18384			0.35											
10/09/21 20:00	0.168			0.18066			0.35											
10/09/21 21:00	0.17184			0.18516			0.36											
10/09/21 22:00	0.17124			0.18462			0.36											
10/09/21 23:00	0.17292			0.1866			0.36											
10/10/21 0:00	0.17316			0.18654			0.36											
10/10/21 1:00	0.17238			0.186			0.36											
10/10/21 2:00	0.17622			0.18996			0.37											
10/10/21 3:00	0.17448			0.18858			0.36											
10/10/21 4:00	0.1746			0.18852			0.36											
10/10/21 5:00	0.22008			0.23754			0.46											
10/10/21 6:00	0.23418			0.2532			0.49											
10/10/21 7:00	0.21552			0.23298			0.45											
10/10/21 8:00	0.17088			0.18408			0.35											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
10/10/21 9:00	0.16608			0.17886			0.34											
10/10/21 10:00	0.16842			0.18066			0.35											
10/10/21 11:00	0.16656			0.17838			0.34											
10/10/21 12:00	0.1665			0.17826			0.34											
10/10/21 13:00	0.16704			0.17874			0.35											
10/10/21 14:00	0.16878			0.18054			0.35											
10/10/21 15:00	0.18204			0.19464			0.38											
10/10/21 16:00	0.21828			0.23358			0.45											
10/10/21 17:00	0.18084			0.1932			0.37											
10/10/21 18:00	0.16782			0.18018			0.35											
10/10/21 19:00	0.18252			0.19578			0.38											
10/10/21 20:00	0.21402			0.22992			0.44											
10/10/21 21:00	0.1716			0.18438			0.36											
10/10/21 22:00	0.16824			0.18084			0.35											
10/10/21 23:00	0.16632			0.17922			0.35											
10/11/21 0:00	0.17472			0.18888			0.36											
10/11/21 1:00	0.1659			0.1794			0.35											
10/11/21 2:00	0.17034			0.18426			0.35											
10/11/21 3:00	0.1737			0.1875			0.36											
10/11/21 4:00	0.24366			0.2637			0.51											
10/11/21 5:00	0.24174			0.26148			0.5											
10/11/21 6:00	0.26082			0.28212			0.54											
10/11/21 7:00	0.27438			0.29676			0.57											
10/11/21 8:00	0.33636			0.3891			0.73											
10/11/21 9:00	0.32136			0.36204			0.68											
10/11/21 10:00	0.3519			0.37314			0.73											
10/11/21 11:00	0.29766			0.31974			0.62											
10/11/21 12:00	0.32106			0.34224			0.66											
10/11/21 13:00	0.324			0.34494			0.67											
10/11/21 14:00	0.31572			0.3369			0.65											
10/11/21 15:00	0.25212			0.27144			0.52											
10/11/21 16:00	0.26838			0.2895			0.56											
10/11/21 17:00	0.26514			0.2862			0.55											
10/11/21 18:00	0.20628			0.22224			0.43											
10/11/21 19:00	0.183			0.19734			0.38											
10/11/21 20:00	0.23634			0.25554			0.49											
10/11/21 21:00	0.20466			0.2214			0.43											
10/11/21 22:00	0.1857			0.20082			0.39											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
10/11/21 23:00	0.18294			0.19776			0.38											
10/12/21 0:00	0.17448			0.18804			0.36											
10/12/21 1:00	0.17154			0.18558			0.36											
10/12/21 2:00	0.16944			0.18354			0.35											
10/12/21 3:00	0.16968			0.1839			0.35											
10/12/21 4:00	0.16992			0.18432			0.35											
10/12/21 5:00	0.22974			0.24924			0.48											
10/12/21 6:00	0.2811			0.30444			0.59											
10/12/21 7:00	0.27696			0.29994			0.58											
10/12/21 8:00	0.27912			0.30222			0.58											
10/12/21 9:00	0.27936			0.30216			0.58											
10/12/21 10:00	0.27984			0.30246			0.58											
10/12/21 11:00	0.27966			0.30048			0.58											
10/12/21 12:00	0.27306			0.29292			0.57											
10/12/21 13:00	0.20826			0.22398			0.43											
10/12/21 14:00	0.27654			0.29562			0.57											
10/12/21 15:00	0.27576			0.29478			0.57											
10/12/21 16:00	0.25956			0.27972			0.54											
10/12/21 17:00	0.27132			0.27132			0.56											
10/12/21 18:00	0.27426			0.29664			0.57											
10/12/21 19:00	0.24762			0.2673			0.51											
10/12/21 20:00	0.2556			0.27546			0.53											
10/12/21 21:00	0.26802			0.28956			0.56											
10/12/21 22:00	0.27474			0.29724			0.57											
10/12/21 23:00	0.234			0.25284			0.49											
10/13/21 0:00	0.2778			0.30012			0.58											
10/13/21 1:00	0.1887			0.20364			0.39											
10/13/21 2:00	0.17442			0.18834			0.36											
10/13/21 3:00	0.21204			0.22932			0.44											
10/13/21 4:00	0.27774			0.30006			0.58											
10/13/21 5:00	0.26292			0.28416			0.55											
10/13/21 6:00	0.2571			0.27768			0.53											
10/13/21 7:00	0.27792			0.30024			0.58											
10/13/21 8:00	0.2784			0.30048			0.58											
10/13/21 9:00	0.27876			0.30054			0.58											
10/13/21 10:00	0.27744			0.29844			0.58											
10/13/21 11:00	0.27846			0.29802			0.58											
10/13/21 12:00	0.27792			0.29628			0.57											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
10/13/21 13:00	0.27846			0.30006			0.58											
10/13/21 14:00	0.27306			0.29424			0.57											
10/13/21 15:00	0.2454			0.26388			0.51											
10/13/21 16:00	0.2067			0.22212			0.43											
10/13/21 17:00	0.27474			0.29622			0.57											
10/13/21 18:00	0.25176			0.2712			0.52											
10/13/21 19:00	0.23604			0.25422			0.49											
10/13/21 20:00	0.2583			0.27918			0.54											
10/13/21 21:00	0.25206			0.27228			0.52											
10/13/21 22:00	0.2619			0.28272			0.54											
10/13/21 23:00	0.16896			0.1827			0.35											
10/14/21 0:00	0.17286			0.1869			0.36											
10/14/21 1:00	0.17082			0.18486			0.36											
10/14/21 2:00	0.1734			0.18756			0.36											
10/14/21 3:00	0.17376			0.1878			0.36											
10/14/21 4:00	0.17232			0.1866			0.36											
10/14/21 5:00	0.25746			0.27894			0.54											
10/14/21 6:00	0.27834			0.3015			0.58											
10/14/21 7:00	0.20706			0.22374			0.43											
10/14/21 8:00	0.17202			0.18576			0.36											
10/14/21 9:00	0.17202			0.18564			0.36											
10/14/21 10:00	0.1674			0.18054			0.35											
10/14/21 11:00	0.16824			0.18078			0.35											
10/14/21 12:00	0.1686			0.18108			0.35											
10/14/21 13:00	0.1731			0.1857			0.36											
10/14/21 14:00	0.17418			0.18672			0.36											
10/14/21 15:00	0.18498			0.1986			0.38											
10/14/21 16:00	0.22224			0.23802			0.46											
10/14/21 17:00	0.27456			0.29412			0.57											
10/14/21 18:00	0.25938			0.27972			0.54											
10/14/21 19:00	0.27966			0.30156			0.58											
10/14/21 20:00	0.27864			0.30336			0.58											
10/14/21 21:00	0.16518			0.37476			0.41											
10/14/21 22:00	0	X		0.32226			0.32											
10/14/21 23:00	0	X		0.30492			0.3											
10/15/21 0:00	0	X		0.30204			0.3											
10/15/21 1:00	0	X		0.30396			0.3											
10/15/21 2:00	0	X		0.3048			0.3											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
10/15/21 3:00	0	X		0.30492			0.3											
10/15/21 4:00	0	X		0.30468			0.3											
10/15/21 5:00	0	X		0.30486			0.3											
10/15/21 6:00	0	X		0.30414			0.3											
10/15/21 7:00	0	X		0.3039			0.3											
10/15/21 8:00	0	X		0.30198			0.3											
10/15/21 9:00	0	X		0.30186			0.3											
10/15/21 10:00	0	X		0.3027			0.3											
10/15/21 11:00	0	X		0.30198			0.3											
10/15/21 12:00	0	X		0.3015			0.3											
10/15/21 13:00	0	X		0.30168			0.3											
10/15/21 14:00	0	X		0.3012			0.3											
10/15/21 15:00	0	X		0.30006			0.3											
10/15/21 16:00	0	X		0.31374			0.31											
10/15/21 17:00	0	X		0.30888			0.31											
10/15/21 18:00	0	X		0.30024			0.3											
10/15/21 19:00	0	X		0.3			0.3											
10/15/21 20:00	0	X		0.30102			0.3											
10/15/21 21:00	0	X		0.30186			0.3											
10/15/21 22:00	0	X		0.3012			0.3											
10/15/21 23:00	0	X		0.3009			0.3											
10/16/21 0:00	0	X		0.3015			0.3											
10/16/21 1:00	0	X		0.30066			0.3											
10/16/21 2:00	0	X		0.3009			0.3											
10/16/21 3:00	0	X		0.30156			0.3											
10/16/21 4:00	0	X		0.30408			0.3											
10/16/21 5:00	0	X		0.30342			0.3											
10/16/21 6:00	0	X		0.30366			0.3											
10/16/21 7:00	0	X		0.30396			0.3											
10/16/21 8:00	0	X		0.30312			0.3											
10/16/21 9:00	0	X		0.3048			0.3											
10/16/21 10:00	0	X		0.30822			0.31											
10/16/21 11:00	0	X		0.31098			0.31											
10/16/21 12:00	0	X		0.31146			0.31											
10/16/21 13:00	0	X		0.31122			0.31											
10/16/21 14:00	0	X		0.31188			0.31											
10/16/21 15:00	0	X		0.31242			0.31											
10/16/21 16:00	0	X		0.31158			0.31											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
10/16/21 17:00	0	X		0.30978			0.31											
10/16/21 18:00	0	X		0.3099			0.31											
10/16/21 19:00	0	X		0.31068			0.31											
10/16/21 20:00	0	X		0.30822			0.31											
10/16/21 21:00	0	X		0.30606			0.31											
10/16/21 22:00	0	X		0.3048			0.3											
10/16/21 23:00	0	X		0.30012			0.3											
10/17/21 0:00	0	X		0.29802			0.3											
10/17/21 1:00	0	X		0.29832			0.3											
10/17/21 2:00	0	X		0.2988			0.3											
10/17/21 3:00	0	X		0.29892			0.3											
10/17/21 4:00	0	X		0.29964			0.3											
10/17/21 5:00	0	X		0.30096			0.3											
10/17/21 6:00	0	X		0.30168			0.3											
10/17/21 7:00	0	X		0.33984			0.34											
10/17/21 8:00	0	X		0.4107			0.41											
10/17/21 9:00	0	X		0.36156			0.36											
10/17/21 10:00	0	X		0.30558			0.31											
10/17/21 11:00	0	X		0.30672			0.31											
10/17/21 12:00	0	X		0.30258			0.3											
10/17/21 13:00	0	X		0.30072			0.3											
10/17/21 14:00	0	X		0.3009			0.3											
10/17/21 15:00	0	X		0.30162			0.3											
10/17/21 16:00	0	X		0.3096			0.31											
10/17/21 17:00	0	X		0.30174			0.3											
10/17/21 18:00	0	X		0.30222			0.3											
10/17/21 19:00	0	X		0.3027			0.3											
10/17/21 20:00	0	X		0.30234			0.3											
10/17/21 21:00	0	X		0.30318			0.3											
10/17/21 22:00	0	X		0.30462			0.3											
10/17/21 23:00	0	X		0.30456			0.3											
10/18/21 0:00	0	X		0.30414			0.3											
10/18/21 1:00	0	X		0.3042			0.3											
10/18/21 2:00	0	X		0.30438			0.3											
10/18/21 3:00	0	X		0.30468			0.3											
10/18/21 4:00	0	X		0.30444			0.3											
10/18/21 5:00	0	X		0.30432			0.3											
10/18/21 6:00	0	X		0.30474			0.3											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
10/18/21 7:00	0	X		0.26028			0.26											
10/18/21 8:00	0	X		0.26232			0.26											
10/18/21 9:00	0	X		0.30372			0.3											
10/18/21 10:00	0	X		0.30336			0.3											
10/18/21 11:00	0	X		0.30324			0.3											
10/18/21 12:00	0	X		0.303			0.3											
10/18/21 13:00	0	X		0.30384			0.3											
10/18/21 14:00	0	X		0.312			0.31											
10/18/21 15:00	0	X		0.3012			0.3											
10/18/21 16:00	0	X		0.22926			0.23											
10/18/21 17:00	0	X		0.30486			0.3											
10/18/21 18:00	0	X		0.30366			0.3											
10/18/21 19:00	0	X		0.3042			0.3											
10/18/21 20:00	0	X		0.30444			0.3											
10/18/21 21:00	0	X		0.25332			0.25											
10/18/21 22:00	0	X		0.18708			0.19											
10/18/21 23:00	0	X		0.18774			0.19											
10/19/21 0:00	0	X		0.1863			0.19											
10/19/21 1:00	0	X		0.1857			0.19											
10/19/21 2:00	0	X		0.1869			0.19											
10/19/21 3:00	0	X		0.25164			0.25											
10/19/21 4:00	0	X		0.30474			0.3											
10/19/21 5:00	0	X		0.3042			0.3											
10/19/21 6:00	0	X		0.30426			0.3											
10/19/21 7:00	0	X		0.30456			0.3											
10/19/21 8:00	0	X		0.30486			0.3											
10/19/21 9:00	0	X		0.30678			0.31											
10/19/21 10:00	0	X		0.30732			0.31											
10/19/21 11:00	0	X		0.3006			0.3											
10/19/21 12:00	0	X		0.29946			0.3											
10/19/21 13:00	0	X		0.25878			0.26											
10/19/21 14:00	0	X		0.3099			0.31											
10/19/21 15:00	0	X		0.31062			0.31											
10/19/21 16:00	0	X		0.31878			0.32											
10/19/21 17:00	0	X		0.31218			0.31											
10/19/21 18:00	0	X		0.30048			0.3											
10/19/21 19:00	0	X		0.29916			0.3											
10/19/21 20:00	0	X		0.30066			0.3											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
10/19/21 21:00	0	X		0.28458			0.28											
10/19/21 22:00	0	X		0.18414			0.18											
10/19/21 23:00	0	X		0.18462			0.18											
10/20/21 0:00	0	X		0.18456			0.18											
10/20/21 1:00	0	X		0.1848			0.18											
10/20/21 2:00	0	X		0.1848			0.18											
10/20/21 3:00	0	X		0.18498			0.18											
10/20/21 4:00	0	X		0.24996			0.25											
10/20/21 5:00	0	X		0.3033			0.3											
10/20/21 6:00	0	X		0.2541			0.25											
10/20/21 7:00	0	X		0.18606			0.19											
10/20/21 8:00	0	X		0.18582			0.19											
10/20/21 9:00	0	X		0.22374			0.22											
10/20/21 10:00	0	X		0.18696			0.19											
10/20/21 11:00	0	X		0.2508			0.25											
10/20/21 12:00	0	X		0.24042			0.24											
10/20/21 13:00	0	X		0.18462			0.18											
10/20/21 14:00	0	X		0.18552			0.19											
10/20/21 15:00	0	X		0.22524			0.23											
10/20/21 16:00	0	X		0.24618			0.25											
10/20/21 17:00	0	X		0.28512			0.29											
10/20/21 18:00	0	X		0.19128			0.19											
10/20/21 19:00	0	X		0.1857			0.19											
10/20/21 20:00	0	X		0.19068			0.19											
10/20/21 21:00	0	X		0.19764			0.2											
10/20/21 22:00	0.0585			0.28404			0.29											
10/20/21 23:00	0.1845			0.20298			0.39											
10/21/21 0:00	0.17652			0.18924			0.37											
10/21/21 1:00	0.17442			0.18696			0.36											
10/21/21 2:00	0.17466			0.18714			0.36											
10/21/21 3:00	0.2079			0.22368			0.43											
10/21/21 4:00	0.21894			0.23592			0.45											
10/21/21 5:00	0.24996			0.26904			0.52											
10/21/21 6:00	0.25302			0.27216			0.53											
10/21/21 7:00	0.24684			0.26616			0.51											
10/21/21 8:00	0.26838			0.28968			0.56											
10/21/21 9:00	0.28296			0.30516			0.59											
10/21/21 10:00	0.28134			0.3033			0.58											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
10/21/21 11:00	0.24786			0.26604			0.51											
10/21/21 12:00	0.17772			0.18996			0.37											
10/21/21 13:00	0.25656			0.2757			0.53											
10/21/21 14:00	0.23802			0.25536			0.49											
10/21/21 15:00	0.19938			0.21336			0.41											
10/21/21 16:00	0.2625			0.28098			0.54											
10/21/21 17:00	0.2796			0.29958			0.58											
10/21/21 18:00	0.27786			0.29898			0.58											
10/21/21 19:00	0.28002			0.3012			0.58											
10/21/21 20:00	0.27666			0.29784			0.57											
10/21/21 21:00	0.25152			0.27066			0.52											
10/21/21 22:00	0.18072			0.1941			0.37											
10/21/21 23:00	0.1662			0.17874			0.34											
10/22/21 0:00	0.16602			0.17886			0.34											
10/22/21 1:00	0.16614			0.17874			0.34											
10/22/21 2:00	0.16614			0.17862			0.34											
10/22/21 3:00	0.17238			0.18504			0.36											
10/22/21 4:00	0.1734			0.18684			0.36											
10/22/21 5:00	0.1719			0.18528			0.36											
10/22/21 6:00	0.17148			0.18498			0.36											
10/22/21 7:00	0.21546			0.23238			0.45											
10/22/21 8:00	0.27294			0.29502			0.57											
10/22/21 9:00	0.27018			0.29124			0.56											
10/22/21 10:00	0.2808			0.30258			0.58											
10/22/21 11:00	0.27684			0.29838			0.58											
10/22/21 12:00	0.20286			0.21786			0.42											
10/22/21 13:00	0.19464			0.20904			0.4											
10/22/21 14:00	0.19434			0.20874			0.4											
10/22/21 15:00	0.19434			0.2088			0.4											
10/22/21 16:00	0.21552			0.23214			0.45											
10/22/21 17:00	0.24474			0.26346			0.51											
10/22/21 18:00	0.16824			0.18054			0.35											
10/22/21 19:00	0.17796			0.19098			0.37											
10/22/21 20:00	0.17436			0.18732			0.36											
10/22/21 21:00	0.17076			0.18408			0.35											
10/22/21 22:00	0.17076			0.18372			0.35											
10/22/21 23:00	0.18912			0.20394			0.39											
10/23/21 0:00	0.19206			0.20682			0.4											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
10/23/21 1:00	0.16662			0.17952			0.35											
10/23/21 2:00	0.17238			0.18546			0.36											
10/23/21 3:00	0.17316			0.18654			0.36											
10/23/21 4:00	0.17472			0.18828			0.36											
10/23/21 5:00	0.20766			0.22422			0.43											
10/23/21 6:00	0.22836			0.24648			0.47											
10/23/21 7:00	0.21312			0.22974			0.44											
10/23/21 8:00	0.26496			0.28632			0.55											
10/23/21 9:00	0.23322			0.25104			0.48											
10/23/21 10:00	0.18948			0.20382			0.39											
10/23/21 11:00	0.189			0.20304			0.39											
10/23/21 12:00	0.27546			0.29682			0.57											
10/23/21 13:00	0.21882			0.23622			0.46											
10/23/21 14:00	0.2802			0.30282			0.58											
10/23/21 15:00	0.2724			0.29424			0.57											
10/23/21 16:00	0.2802			0.3021			0.58											
10/23/21 17:00	0.27864			0.30024			0.58											
10/23/21 18:00	0.17814			0.1917			0.37											
10/23/21 19:00	0.18504			0.1992			0.38											
10/23/21 20:00	0.17454			0.18786			0.36											
10/23/21 21:00	0.17484			0.1884			0.36											
10/23/21 22:00	0.18474			0.19902			0.38											
10/23/21 23:00	0.27078			0.29286			0.56											
10/24/21 0:00	0.2352			0.25422			0.49											
10/24/21 1:00	0.16896			0.1824			0.35											
10/24/21 2:00	0.16782			0.18072			0.35											
10/24/21 3:00	0.16794			0.18138			0.35											
10/24/21 4:00	0.16572			0.17886			0.34											
10/24/21 5:00	0.1713			0.18438			0.36											
10/24/21 6:00	0.1707			0.18426			0.35											
10/24/21 7:00	0.23664			0.25554			0.49											
10/24/21 8:00	0.27882			0.30114			0.58											
10/24/21 9:00	0.2796			0.30192			0.58											
10/24/21 10:00	0.273			0.29466			0.57											
10/24/21 11:00	0.27996			0.30174			0.58											
10/24/21 12:00	0.27294			0.29418			0.57											
10/24/21 13:00	0.27882			0.30048			0.58											
10/24/21 14:00	0.21774			0.2346			0.45											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/24/21 15:00	0.25446			0.27444			0.53											
10/24/21 16:00	0.23964			0.25836			0.5											
10/24/21 17:00	0.2685			0.28974			0.56											
10/24/21 18:00	0.21342			0.23028			0.44											
10/24/21 19:00	0.23922			0.25806			0.5											
10/24/21 20:00	0.18654			0.20118			0.39											
10/24/21 21:00	0.19422			0.20964			0.4											
10/24/21 22:00	0.17742			0.19134			0.37											
10/24/21 23:00	0.17592			0.19002			0.37											
10/25/21 0:00	0.19632			0.21192			0.41											
10/25/21 1:00	0.17826			0.192			0.37											
10/25/21 2:00	0.17604			0.19002			0.37											
10/25/21 3:00	0.17802			0.19206			0.37											
10/25/21 4:00	0.25986			0.2814			0.54											
10/25/21 5:00	0.2727			0.2949			0.57											
10/25/21 6:00	0.25986			0.2805			0.54											
10/25/21 7:00	0.25488			0.27492			0.53											
10/25/21 8:00	0.2706			0.29184			0.56											
10/25/21 9:00	0.21096			0.22698			0.44											
10/25/21 10:00	0.16896			0.18174			0.35											
10/25/21 11:00	0.16668			0.17898			0.35											
10/25/21 12:00	0.16716			0.1791			0.35											
10/25/21 13:00	0.16932			0.18156			0.35											
10/25/21 14:00	0.16884			0.18108			0.35											
10/25/21 15:00	0.16698			0.17922			0.35											
10/25/21 16:00	0.23382			0.2523			0.49											
10/25/21 17:00	0.22302			0.24018			0.46											
10/25/21 18:00	0.21798			0.2346			0.45											
10/25/21 19:00	0.24798			0.26814			0.52											
10/25/21 20:00	0.27066			0.29226			0.56											
10/25/21 21:00	0.1818			0.19572			0.38											
10/25/21 22:00	0.16836			0.1815			0.35											
10/25/21 23:00	0.17244			0.18564			0.36											
10/26/21 0:00	0.16782			0.18096			0.35											
10/26/21 1:00	0.16974			0.183			0.35											
10/26/21 2:00	0.17004			0.18324			0.35											
10/26/21 3:00	0.17322			0.18666			0.36											
10/26/21 4:00	0.1689			0.18192			0.35											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
10/26/21 5:00	0.2349			0.25374			0.49											
10/26/21 6:00	0.18126			0.1953			0.38											
10/26/21 7:00	0.2004			0.21624			0.42											
10/26/21 8:00	0.17472			0.18822			0.36											
10/26/21 9:00	0.17412			0.1872			0.36											
10/26/21 10:00	0.17412			0.18678			0.36											
10/26/21 11:00	0.18144			0.19476			0.38											
10/26/21 12:00	0.17406			0.18636			0.36											
10/26/21 13:00	0.17118			0.18354			0.35											
10/26/21 14:00	0.1851			0.19854			0.38											
10/26/21 15:00	0.17232			0.18486			0.36											
10/26/21 16:00	0.19224			0.20664			0.4											
10/26/21 17:00	0.17706			0.19026			0.37											
10/26/21 18:00	0.22392			0.24144			0.47											
10/26/21 19:00	0.22746			0.24522			0.47											
10/26/21 20:00	0.24294			0.26244			0.51											
10/26/21 21:00	0.23928			0.25842			0.5											
10/26/21 22:00	0.24738			0.267			0.51											
10/26/21 23:00	0.17538			0.1884			0.36											
10/27/21 0:00	0.17484			0.18792			0.36											
10/27/21 1:00	0.16992			0.18324			0.35											
10/27/21 2:00	0.168			0.18114			0.35											
10/27/21 3:00	0.171			0.18474			0.36											
10/27/21 4:00	0.17262			0.18606			0.36											
10/27/21 5:00	0.20424			0.22086			0.43											
10/27/21 6:00	0.25752			0.27798			0.54											
10/27/21 7:00	0.18678			0.20172			0.39											
10/27/21 8:00	0.1665			0.1794			0.35											
10/27/21 9:00	0.16662			0.17934			0.35											
10/27/21 10:00	0.16644			0.17934			0.35											
10/27/21 11:00	0.1665			0.17922			0.35											
10/27/21 12:00	0.16638			0.17904			0.35											
10/27/21 13:00	0.16704			0.1794			0.35											
10/27/21 14:00	0.16662			0.17916			0.35											
10/27/21 15:00	0.18312			0.19668			0.38											
10/27/21 16:00	0.2577			0.27756			0.54											
10/27/21 17:00	0.27954			0.30252			0.58											
10/27/21 18:00	0.25782			0.27816			0.54											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
10/27/21 19:00	0.26898			0.29028			0.56											
10/27/21 20:00	0.24714			0.26664			0.51											
10/27/21 21:00	0.25242			0.2724			0.52											
10/27/21 22:00	0.18486			0.19854			0.38											
10/27/21 23:00	0.17538			0.18816			0.36											
10/28/21 0:00	0.17514			0.18804			0.36											
10/28/21 1:00	0.17484			0.18822			0.36											
10/28/21 2:00	0.1749			0.18834			0.36											
10/28/21 3:00	0.17502			0.18828			0.36											
10/28/21 4:00	0.19122			0.20604			0.4											
10/28/21 5:00	0.22902			0.24762			0.48											
10/28/21 6:00	0.2337			0.25254			0.49											
10/28/21 7:00	0.17304			0.18666			0.36											
10/28/21 8:00	0.16776			0.18054			0.35											
10/28/21 9:00	0.16662			0.17916			0.35											
10/28/21 10:00	0.17058			0.18288			0.35											
10/28/21 11:00	0.17322			0.18564			0.36											
10/28/21 12:00	0.174			0.18612			0.36											
10/28/21 13:00	0.16644			0.17808			0.34											
10/28/21 14:00	0.16764			0.17934			0.35											
10/28/21 15:00	0.16986			0.18162			0.35											
10/28/21 16:00	0.25068			0.26892			0.52											
10/28/21 17:00	0.27966			0.30084			0.58											
10/28/21 18:00	0.26538			0.28674			0.55											
10/28/21 19:00	0.27504			0.2973			0.57											
10/28/21 20:00	0.26388			0.28464			0.55											
10/28/21 21:00	0.23406			0.25218			0.49											
10/28/21 22:00	0.17448			0.1872			0.36											
10/28/21 23:00	0.17184			0.18456			0.36											
10/29/21 0:00	0.17016			0.18324			0.35											
10/29/21 1:00	0.16968			0.18294			0.35											
10/29/21 2:00	0.1674			0.1806			0.35											
10/29/21 3:00	0.17496			0.18828			0.36											
10/29/21 4:00	0.17484			0.18834			0.36											
10/29/21 5:00	0.21078			0.22794			0.44											
10/29/21 6:00	0.23016			0.24888			0.48											
10/29/21 7:00	0.16998			0.18378			0.35											
10/29/21 8:00	0.16626			0.17928			0.35											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
10/29/21 9:00	0.16632			0.17988			0.35											
10/29/21 10:00	0.16758			0.17946			0.35											
10/29/21 11:00	0.16662			0.17922			0.35											
10/29/21 12:00	0.16644			0.1782			0.34											
10/29/21 13:00	0.16908			0.18108			0.35											
10/29/21 14:00	0.16656			0.1782			0.34											
10/29/21 15:00	0.20814			0.22506			0.43											
10/29/21 16:00	0.2667			0.28998			0.56											
10/29/21 17:00	0.27204			0.29352			0.57											
10/29/21 18:00	0.23334			0.25218			0.49											
10/29/21 19:00	0.27288			0.29454			0.57											
10/29/21 20:00	0.25956			0.28002			0.54											
10/29/21 21:00	0.23166			0.24978			0.48											
10/29/21 22:00	0.22554			0.24354			0.47											
10/29/21 23:00	0.20082			0.21624			0.42											
10/30/21 0:00	0.1893			0.20406			0.39											
10/30/21 1:00	0.17184			0.18474			0.36											
10/30/21 2:00	0.16794			0.18066			0.35											
10/30/21 3:00	0.17268			0.1857			0.36											
10/30/21 4:00	0.17226			0.18528			0.36											
10/30/21 5:00	0.19338			0.2085			0.4											
10/30/21 6:00	0.1704			0.18348			0.35											
10/30/21 7:00	0.16758			0.1806			0.35											
10/30/21 8:00	0.16644			0.17904			0.35											
10/30/21 9:00	0.16596			0.17868			0.34											
10/30/21 10:00	0.16626			0.1785			0.34											
10/30/21 11:00	0.16638			0.17838			0.34											
10/30/21 12:00	0.16632			0.17808			0.34											
10/30/21 13:00	0.16638			0.17784			0.34											
10/30/21 14:00	0.16626			0.17796			0.34											
10/30/21 15:00	0.20424			0.22008			0.42											
10/30/21 16:00	0.1839			0.19764			0.38											
10/30/21 17:00	0.17556			0.18858			0.36											
10/30/21 18:00	0.16704			0.17928			0.35											
10/30/21 19:00	0.17136			0.18396			0.36											
10/30/21 20:00	0.1692			0.18174			0.35											
10/30/21 21:00	0.16836			0.18084			0.35											
10/30/21 22:00	0.16788			0.18084			0.35											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
10/30/21 23:00	0.17238			0.18546			0.36											
10/31/21 0:00	0.16884			0.1818			0.35											
10/31/21 1:00	0.16896			0.18198			0.35											
10/31/21 2:00	0.16878			0.18186			0.35											
10/31/21 3:00	0.1689			0.18192			0.35											
10/31/21 4:00	0.16872			0.18198			0.35											
10/31/21 5:00	0.17412			0.18774			0.36											
10/31/21 6:00	0.18294			0.19752			0.38											
10/31/21 7:00	0.16926			0.18276			0.35											
10/31/21 8:00	0.16848			0.18162			0.35											
10/31/21 9:00	0.1701			0.18306			0.35											
10/31/21 10:00	0.16626			0.1788			0.35											
10/31/21 11:00	0.16596			0.17862			0.34											
10/31/21 12:00	0.16614			0.17844			0.34											
10/31/21 13:00	0.16644			0.17856			0.35											
10/31/21 14:00	0.16626			0.17838			0.34											
10/31/21 15:00	0.1812			0.19476			0.38											
10/31/21 16:00	0.16674			0.17928			0.35											
10/31/21 17:00	0.16614			0.17862			0.34											
10/31/21 18:00	0.16602			0.17862			0.34											
10/31/21 19:00	0.16548			0.17886			0.34											
10/31/21 20:00	0.16542			0.17886			0.34											
10/31/21 21:00	0.16566			0.17886			0.34											
10/31/21 22:00	0.16638			0.17952			0.35											
10/31/21 23:00	0.1686			0.18228			0.35											
11/01/21 0:00	0.16716			0.18066			0.35											
11/01/21 1:00	0.1701			0.18318			0.35											
11/01/21 2:00	0.16644			0.17916			0.35											
11/01/21 3:00	0.17268			0.18594			0.36											
11/01/21 4:00	0.198			0.21378			0.41											
11/01/21 5:00	0.1713			0.18474			0.36											
11/01/21 6:00	0.25998			0.28104			0.54											
11/01/21 7:00	0.2049			0.2211			0.43											
11/01/21 8:00	0.17262			0.18546			0.36											
11/01/21 9:00	0.21306			0.22968			0.44											
11/01/21 10:00	0.18342			0.19746			0.38											
11/01/21 11:00	0.21564			0.23304			0.45											
11/01/21 12:00	0.23082			0.24912			0.48											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
11/01/21 13:00	0.27822			0.30078			0.58											
11/01/21 14:00	0.23922			0.25848			0.5											
11/01/21 15:00	0.19062			0.2052			0.4											
11/01/21 16:00	0.2106			0.22716			0.44											
11/01/21 17:00	0.26652			0.28758			0.55											
11/01/21 18:00	0.2595			0.28032			0.54											
11/01/21 19:00	0.27024			0.29166			0.56											
11/01/21 20:00	0.27168			0.29394			0.57											
11/01/21 21:00	0.26238			0.28326			0.55											
11/01/21 22:00	0.21648			0.23304			0.45											
11/01/21 23:00	0.17652			0.18972			0.37											
11/02/21 0:00	0.17598			0.18894			0.36											
11/02/21 1:00	0.1737			0.18678			0.36											
11/02/21 2:00	0.16776			0.18054			0.35											
11/02/21 3:00	0.17232			0.18552			0.36											
11/02/21 4:00	0.17244			0.18546			0.36											
11/02/21 5:00	0.18192			0.1959			0.38											
11/02/21 6:00	0.23676			0.25572			0.49											
11/02/21 7:00	0.18462			0.19884			0.38											
11/02/21 8:00	0.16578			0.1785			0.34											
11/02/21 9:00	0.16794			0.18066			0.35											
11/02/21 10:00	0.16866			0.18108			0.35											
11/02/21 11:00	0.16908			0.18132			0.35											
11/02/21 12:00	0.16932			0.18156			0.35											
11/02/21 13:00	0.16566			0.17784			0.34											
11/02/21 14:00	0.16584			0.17784			0.34											
11/02/21 15:00	0.16878			0.18108			0.35											
11/02/21 16:00	0.2262			0.24426			0.47											
11/02/21 17:00	0.26856			0.2901			0.56											
11/02/21 18:00	0.25638			0.27702			0.53											
11/02/21 19:00	0.279			0.30132			0.58											
11/02/21 20:00	0.27486			0.29682			0.57											
11/02/21 21:00	0.24822			0.26772			0.52											
11/02/21 22:00	0.25992			0.28068			0.54											
11/02/21 23:00	0.22056			0.23802			0.46											
11/03/21 0:00	0.21462			0.23166			0.45											
11/03/21 1:00	0.2088			0.22518			0.43											
11/03/21 2:00	0.2085			0.22542			0.43											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
11/03/21 3:00	0.21288			0.22956			0.44											
11/03/21 4:00	0.22746			0.246			0.47											
11/03/21 5:00	0.252			0.27306			0.53											
11/03/21 6:00	0.252			0.2724			0.52											
11/03/21 7:00	0.19344			0.20808			0.4											
11/03/21 8:00	0.16944			0.18264			0.35											
11/03/21 9:00	0.16536			0.17844			0.34											
11/03/21 10:00	0.16686			0.1791			0.35											
11/03/21 11:00	0.1668			0.17898			0.35											
11/03/21 12:00	0.16848			0.18078			0.35											
11/03/21 13:00	0.16986			0.1821			0.35											
11/03/21 14:00	0.16926			0.18114			0.35											
11/03/21 15:00	0.20172			0.21606			0.42											
11/03/21 16:00	0.22452			0.24048			0.47											
11/03/21 17:00	0.27474			0.2949			0.57											
11/03/21 18:00	0.26088			0.28122			0.54											
11/03/21 19:00	0.27168			0.29292			0.56											
11/03/21 20:00	0.27066			0.29214			0.56											
11/03/21 21:00	0.25032			0.2703			0.52											
11/03/21 22:00	0.20976			0.2259			0.44											
11/03/21 23:00	0.17358			0.18624			0.36											
11/04/21 0:00	0.1713			0.18396			0.36											
11/04/21 1:00	0.16614			0.17856			0.34											
11/04/21 2:00	0.17364			0.1869			0.36											
11/04/21 3:00	0.22896			0.2475			0.48											
11/04/21 4:00	0.19884			0.21462			0.41											
11/04/21 5:00	0.252			0.2721			0.52											
11/04/21 6:00	0.26274			0.28332			0.55											
11/04/21 7:00	0.1899			0.20412			0.39											
11/04/21 8:00	0.1716			0.18402			0.36											
11/04/21 9:00	0.21504			0.23154			0.45											
11/04/21 10:00	0.16572			0.1779			0.34											
11/04/21 11:00	0.1665			0.1785			0.35											
11/04/21 12:00	0.16596			0.17778			0.34											
11/04/21 13:00	0.16776			0.17946			0.35											
11/04/21 14:00	0.16584			0.17748			0.34											
11/04/21 15:00	0.2043			0.2196			0.42											
11/04/21 16:00	0.1821			0.19524			0.38											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
11/04/21 17:00	0.1692			0.1818			0.35											
11/04/21 18:00	0.17124			0.1842			0.36											
11/04/21 19:00	0.17094			0.1842			0.36											
11/04/21 20:00	0.16944			0.1827			0.35											
11/04/21 21:00	0.16518			0.1785			0.34											
11/04/21 22:00	0.16548			0.17886			0.34											
11/04/21 23:00	0.16482			0.17826			0.34											
11/05/21 0:00	0.16488			0.17808			0.34											
11/05/21 1:00	0.16452			0.17808			0.34											
11/05/21 2:00	0.16524			0.17904			0.34											
11/05/21 3:00	0.17052			0.18426			0.35											
11/05/21 4:00	0.18666			0.2016			0.39											
11/05/21 5:00	0.23616			0.25542			0.49											
11/05/21 6:00	0.25002			0.27036			0.52											
11/05/21 7:00	0.21384			0.23076			0.44											
11/05/21 8:00	0.16962			0.18282			0.35											
11/05/21 9:00	0.1647			0.17778			0.34											
11/05/21 10:00	0.16494			0.17772			0.34											
11/05/21 11:00	0.16542			0.17778			0.34											
11/05/21 12:00	0.16566			0.17814			0.34											
11/05/21 13:00	0.16584			0.1782			0.34											
11/05/21 14:00	0.19542			0.2103			0.41											
11/05/21 15:00	0.2475			0.26628			0.51											
11/05/21 16:00	0.22518			0.2415			0.47											
11/05/21 17:00	0.22812			0.246			0.47											
11/05/21 18:00	0.19458			0.2091			0.4											
11/05/21 19:00	0.2187			0.23562			0.45											
11/05/21 20:00	0.22464			0.24216			0.47											
11/05/21 21:00	0.24684			0.26646			0.51											
11/05/21 22:00	0.19968			0.21528			0.41											
11/05/21 23:00	0.22662			0.24456			0.47											
11/06/21 0:00	0.17766			0.19098			0.37											
11/06/21 1:00	0.21144			0.22818			0.44											
11/06/21 2:00	0.18072			0.19458			0.38											
11/06/21 3:00	0.17454			0.18744			0.36											
11/06/21 4:00	0.18966			0.20442			0.39											
11/06/21 5:00	0.23028			0.249			0.48											
11/06/21 6:00	0.26046			0.28152			0.54											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
11/06/21 7:00	0.21612			0.23304			0.45											
11/06/21 8:00	0.20184			0.2172			0.42											
11/06/21 9:00	0.1704			0.1833			0.35											
11/06/21 10:00	0.16806			0.1809			0.35											
11/06/21 11:00	0.16812			0.18084			0.35											
11/06/21 12:00	0.16554			0.1788			0.34											
11/06/21 13:00	0.16548			0.17892			0.34											
11/06/21 14:00	0.1653			0.17868			0.34											
11/06/21 15:00	0.19182			0.20742			0.4											
11/06/21 16:00	0.23142			0.24954			0.48											
11/06/21 17:00	0.2631			0.28386			0.55											
11/06/21 18:00	0.20724			0.22296			0.43											
11/06/21 19:00	0.27516			0.29718			0.57											
11/06/21 20:00	0.2544			0.27432			0.53											
11/06/21 21:00	0.22974			0.24768			0.48											
11/06/21 22:00	0.17418			0.18762			0.36											
11/06/21 23:00	0.17364			0.1869			0.36											
11/07/21 0:00	0.16668			0.17976			0.35											
11/07/21 1:00	0.16608			0.17976			0.35											
11/07/21 2:00	0.16698			0.18042			0.35											
11/07/21 3:00	0.16752			0.18036			0.35											
11/07/21 4:00	0.16764			0.18024			0.35											
11/07/21 5:00	0.16824			0.18204			0.35											
11/07/21 6:00	0.2304			0.24912			0.48											
11/07/21 7:00	0.2475			0.26742			0.51											
11/07/21 8:00	0.16668			0.18036			0.35											
11/07/21 9:00	0.16668			0.18024			0.35											
11/07/21 10:00	0.1659			0.17922			0.35											
11/07/21 11:00	0.16524			0.17754			0.34											
11/07/21 12:00	0.16392			0.17712			0.34											
11/07/21 13:00	0.1641			0.17706			0.34											
11/07/21 14:00	0.1674			0.18036			0.35											
11/07/21 15:00	0.21762			0.23478			0.45											
11/07/21 16:00	0.22728			0.24504			0.47											
11/07/21 17:00	0.20418			0.22002			0.42											
11/07/21 18:00	0.19266			0.20772			0.4											
11/07/21 19:00	0.22662			0.24474			0.47											
11/07/21 20:00	0.18036			0.19494			0.38											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
11/07/21 21:00	0.1713			0.18498			0.36											
11/07/21 22:00	0.17148			0.18522			0.36											
11/07/21 23:00	0.16524			0.17814			0.34											
11/08/21 0:00	0.1665			0.17982			0.35											
11/08/21 1:00	0.17238			0.18642			0.36											
11/08/21 2:00	0.19314			0.2091			0.4											
11/08/21 3:00	0.26838			0.28998			0.56											
11/08/21 4:00	0.27012			0.29214			0.56											
11/08/21 5:00	0.27714			0.2997			0.58											
11/08/21 6:00	0.27462			0.29706			0.57											
11/08/21 7:00	0.21198			0.22884			0.44											
11/08/21 8:00	0.16572			0.17934			0.35											
11/08/21 9:00	0.16578			0.1791			0.34											
11/08/21 10:00	0.16458			0.17778			0.34											
11/08/21 11:00	0.16494			0.17772			0.34											
11/08/21 12:00	0.16488			0.17742			0.34											
11/08/21 13:00	0.165			0.17712			0.34											
11/08/21 14:00	0.16482			0.1767			0.34											
11/08/21 15:00	0.22746			0.24456			0.47											
11/08/21 16:00	0.27558			0.29832			0.57											
11/08/21 17:00	0.28956			0.31038			0.6											
11/08/21 18:00	0.2892			0.31038			0.6											
11/08/21 19:00	0.28026			0.30162			0.58											
11/08/21 20:00	0.26496			0.28692			0.55											
11/08/21 21:00	0.2481			0.26778			0.52											
11/08/21 22:00	0.21768			0.23496			0.45											
11/08/21 23:00	0.17322			0.18684			0.36											
11/09/21 0:00	0.17292			0.18642			0.36											
11/09/21 1:00	0.17256			0.18582			0.36											
11/09/21 2:00	0.17016			0.18306			0.35											
11/09/21 3:00	0.16614			0.17916			0.35											
11/09/21 4:00	0.1722			0.18528			0.36											
11/09/21 5:00	0.18624			0.20082			0.39											
11/09/21 6:00	0.18282			0.19734			0.38											
11/09/21 7:00	0.21156			0.22824			0.44											
11/09/21 8:00	0.16896			0.18168			0.35											
11/09/21 9:00	0.16644			0.17904			0.35											
11/09/21 10:00	0.17148			0.18522			0.36											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
11/09/21 11:00	0.16818			0.18108			0.35											
11/09/21 12:00	0.16776			0.18006			0.35											
11/09/21 13:00	0.16806			0.18012			0.35											
11/09/21 14:00	0.17442			0.18732			0.36											
11/09/21 15:00	0.19572			0.21114			0.41											
11/09/21 16:00	0.20076			0.21606			0.42											
11/09/21 17:00	0.2322			0.25032			0.48											
11/09/21 18:00	0.27732			0.29946			0.58											
11/09/21 19:00	0.2715			0.29316			0.56											
11/09/21 20:00	0.2673			0.28848			0.56											
11/09/21 21:00	0.19902			0.21444			0.41											
11/09/21 22:00	0.17442			0.18756			0.36											
11/09/21 23:00	0.1722			0.18492			0.36											
11/10/21 0:00	0.16794			0.18102			0.35											
11/10/21 1:00	0.1665			0.17946			0.35											
11/10/21 2:00	0.16656			0.1794			0.35											
11/10/21 3:00	0.16608			0.17928			0.35											
11/10/21 4:00	0.16608			0.17922			0.35											
11/10/21 5:00	0.21402			0.23112			0.45											
11/10/21 6:00	0.22914			0.24744			0.48											
11/10/21 7:00	0.22914			0.24702			0.48											
11/10/21 8:00	0.1659			0.17928			0.35											
11/10/21 9:00	0.16962			0.18252			0.35											
11/10/21 10:00	0.17166			0.18456			0.36											
11/10/21 11:00	0.16704			0.17946			0.35											
11/10/21 12:00	0.16656			0.1794			0.35											
11/10/21 13:00	0.1665			0.17934			0.35											
11/10/21 14:00	0.16626			0.17928			0.35											
11/10/21 15:00	0.16704			0.17994			0.35											
11/10/21 16:00	0.17118			0.18426			0.36											
11/10/21 17:00	0.1743			0.1869			0.36											
11/10/21 18:00	0.17394			0.18678			0.36											
11/10/21 19:00	0.17412			0.18792			0.36											
11/10/21 20:00	0.17514			0.189			0.36											
11/10/21 21:00	0.18798			0.20256			0.39											
11/10/21 22:00	0.17526			0.18852			0.36											
11/10/21 23:00	0.17406			0.18708			0.36											
11/11/21 0:00	0.1707			0.18402			0.35											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
11/11/21 1:00	0.17406			0.18732			0.36											
11/11/21 2:00	0.16566			0.1794			0.35											
11/11/21 3:00	0.1665			0.17988			0.35											
11/11/21 4:00	0.17292			0.18654			0.36											
11/11/21 5:00	0.17478			0.18852			0.36											
11/11/21 6:00	0.17388			0.18822			0.36											
11/11/21 7:00	0.1734			0.18762			0.36											
11/11/21 8:00	0.1734			0.18648			0.36											
11/11/21 9:00	0.174			0.18714			0.36											
11/11/21 10:00	0.17364			0.18636			0.36											
11/11/21 11:00	0.16698			0.1797			0.35											
11/11/21 12:00	0.1674			0.18018			0.35											
11/11/21 13:00	0.16818			0.1809			0.35											
11/11/21 14:00	0.16776			0.18036			0.35											
11/11/21 15:00	0.19074			0.20514			0.4											
11/11/21 16:00	0.2286			0.2442			0.47											
11/11/21 17:00	0.29064			0.31008			0.6											
11/11/21 18:00	0.29142			0.30906			0.6											
11/11/21 19:00	0.2922			0.30762			0.6											
11/11/21 20:00	0.2928			0.30654			0.6											
11/11/21 21:00	0.29322			0.30774			0.6											
11/11/21 22:00	0.24456			0.26256			0.51											
11/11/21 23:00	0.17988			0.19344			0.37											
11/12/21 0:00	0.16812			0.1812			0.35											
11/12/21 1:00	0.16596			0.1791			0.35											
11/12/21 2:00	0.16578			0.17916			0.34											
11/12/21 3:00	0.16566			0.17934			0.35											
11/12/21 4:00	0.16662			0.18048			0.35											
11/12/21 5:00	0.174			0.1878			0.36											
11/12/21 6:00	0.1743			0.1884			0.36											
11/12/21 7:00	0.1686			0.18246			0.35											
11/12/21 8:00	0.1686			0.1821			0.35											
11/12/21 9:00	0.1662			0.17922			0.35											
11/12/21 10:00	0.16644			0.17916			0.35											
11/12/21 11:00	0.16662			0.17934			0.35											
11/12/21 12:00	0.16638			0.17916			0.35											
11/12/21 13:00	0.16632			0.17904			0.35											
11/12/21 14:00	0.16854			0.18132			0.35											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
11/12/21 15:00	0.18426			0.1983			0.38											
11/12/21 16:00	0.17148			0.18438			0.36											
11/12/21 17:00	0.17274			0.186			0.36											
11/12/21 18:00	0.16662			0.17988			0.35											
11/12/21 19:00	0.17388			0.18774			0.36											
11/12/21 20:00	0.1746			0.18756			0.36											
11/12/21 21:00	0.195			0.21012			0.41											
11/12/21 22:00	0.17064			0.18378			0.35											
11/12/21 23:00	0.16644			0.17958			0.35											
11/13/21 0:00	0.16794			0.18108			0.35											
11/13/21 1:00	0.16746			0.18078			0.35											
11/13/21 2:00	0.17418			0.18762			0.36											
11/13/21 3:00	0.17448			0.18744			0.36											
11/13/21 4:00	0.18444			0.19848			0.38											
11/13/21 5:00	0.21618			0.23328			0.45											
11/13/21 6:00	0.27942			0.3015			0.58											
11/13/21 7:00	0.2793			0.30126			0.58											
11/13/21 8:00	0.279			0.30126			0.58											
11/13/21 9:00	0.27918			0.30114			0.58											
11/13/21 10:00	0.22482			0.24216			0.47											
11/13/21 11:00	0.18102			0.19446			0.38											
11/13/21 12:00	0.17016			0.18282			0.35											
11/13/21 13:00	0.16818			0.1809			0.35											
11/13/21 14:00	0.1674			0.18018			0.35											
11/13/21 15:00	0.1824			0.19614			0.38											
11/13/21 16:00	0.2664			0.28782			0.55											
11/13/21 17:00	0.1929			0.20766			0.4											
11/13/21 18:00	0.19494			0.21018			0.41											
11/13/21 19:00	0.24456			0.26412			0.51											
11/13/21 20:00	0.237			0.25536			0.49											
11/13/21 21:00	0.18696			0.20118			0.39											
11/13/21 22:00	0.17508			0.18828			0.36											
11/13/21 23:00	0.168			0.1812			0.35											
11/14/21 0:00	0.1662			0.17916			0.35											
11/14/21 1:00	0.16614			0.17916			0.35											
11/14/21 2:00	0.16596			0.17922			0.35											
11/14/21 3:00	0.1659			0.17898			0.34											
11/14/21 4:00	0.16638			0.1797			0.35											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
11/14/21 5:00	0.1659			0.1791			0.35											
11/14/21 6:00	0.1668			0.1803			0.35											
11/14/21 7:00	0.16848			0.18198			0.35											
11/14/21 8:00	0.16758			0.18078			0.35											
11/14/21 9:00	0.16704			0.18078			0.35											
11/14/21 10:00	0.16704			0.18072			0.35											
11/14/21 11:00	0.16704			0.1806			0.35											
11/14/21 12:00	0.16704			0.1806			0.35											
11/14/21 13:00	0.16674			0.17952			0.35											
11/14/21 14:00	0.16602			0.17898			0.35											
11/14/21 15:00	0.18072			0.19518			0.38											
11/14/21 16:00	0.16794			0.18096			0.35											
11/14/21 17:00	0.16782			0.18096			0.35											
11/14/21 18:00	0.16722			0.18018			0.35											
11/14/21 19:00	0.1698			0.183			0.35											
11/14/21 20:00	0.17778			0.19146			0.37											
11/14/21 21:00	0.17346			0.1869			0.36											
11/14/21 22:00	0.16896			0.18204			0.35											
11/14/21 23:00	0.16614			0.17934			0.35											
11/15/21 0:00	0.16626			0.17976			0.35											
11/15/21 1:00	0.1659			0.1791			0.35											
11/15/21 2:00	0.16614			0.17916			0.35											
11/15/21 3:00	0.16644			0.18006			0.35											
11/15/21 4:00	0.16824			0.18156			0.35											
11/15/21 5:00	0.17328			0.18648			0.36											
11/15/21 6:00	0.19086			0.20526			0.4											
11/15/21 7:00	0.19416			0.20946			0.4											
11/15/21 8:00	0.16962			0.18288			0.35											
11/15/21 9:00	0.17436			0.1878			0.36											
11/15/21 10:00	0.17424			0.18732			0.36											
11/15/21 11:00	0.17124			0.18438			0.36											
11/15/21 12:00	0.16554			0.17874			0.34											
11/15/21 13:00	0.16986			0.18306			0.35											
11/15/21 14:00	0.21252			0.22884			0.44											
11/15/21 15:00	0.20286			0.21828			0.42											
11/15/21 16:00	0.18414			0.19788			0.38											
11/15/21 17:00	0.1734			0.18624			0.36											
11/15/21 18:00	0.17514			0.18846			0.36											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
11/15/21 19:00	0.22038			0.23778			0.46											
11/15/21 20:00	0.17436			0.18744			0.36											
11/15/21 21:00	0.18858			0.20298			0.39											
11/15/21 22:00	0.17232			0.18582			0.36											
11/15/21 23:00	0.16578			0.17898			0.34											
11/16/21 0:00	0.17328			0.18654			0.36											
11/16/21 1:00	0.17412			0.18756			0.36											
11/16/21 2:00	0.16908			0.18252			0.35											
11/16/21 3:00	0.16662			0.17982			0.35											
11/16/21 4:00	0.17274			0.18606			0.36											
11/16/21 5:00	0.2346			0.25338			0.49											
11/16/21 6:00	0.28002			0.30264			0.58											
11/16/21 7:00	0.2802			0.30258			0.58											
11/16/21 8:00	0.23154			0.24936			0.48											
11/16/21 9:00	0.2106			0.22692			0.44											
11/16/21 10:00	0.17076			0.18396			0.35											
11/16/21 11:00	0.16998			0.18324			0.35											
11/16/21 12:00	0.16782			0.1809			0.35											
11/16/21 13:00	0.168			0.18096			0.35											
11/16/21 14:00	0.1677			0.18048			0.35											
11/16/21 15:00	0.1842			0.19884			0.38											
11/16/21 16:00	0.17424			0.1878			0.36											
11/16/21 17:00	0.21612			0.23316			0.45											
11/16/21 18:00	0.23208			0.24996			0.48											
11/16/21 19:00	0.20178			0.21768			0.42											
11/16/21 20:00	0.26064			0.2814			0.54											
11/16/21 21:00	0.26472			0.28548			0.55											
11/16/21 22:00	0.2391			0.25776			0.5											
11/16/21 23:00	0.2136			0.23064			0.44											
11/17/21 0:00	0.2835			0.30318			0.59											
11/17/21 1:00	0.24624			0.26022			0.51											
11/17/21 2:00	0.17388			0.18732			0.36											
11/17/21 3:00	0.17478			0.18804			0.36											
11/17/21 4:00	0.2118			0.22842			0.44											
11/17/21 5:00	0.21342			0.23022			0.44											
11/17/21 6:00	0.26958			0.29118			0.56											
11/17/21 7:00	0.2262			0.24396			0.47											
11/17/21 8:00	0.17274			0.18582			0.36											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
11/17/21 9:00	0.17388			0.18768			0.36											
11/17/21 10:00	0.1731			0.18678			0.36											
11/17/21 11:00	0.16722			0.18012			0.35											
11/17/21 12:00	0.16638			0.17916			0.35											
11/17/21 13:00	0.16596			0.1788			0.34											
11/17/21 14:00	0.16608			0.1788			0.34											
11/17/21 15:00	0.20118			0.21678			0.42											
11/17/21 16:00	0.22818			0.24648			0.47											
11/17/21 17:00	0.26316			0.28416			0.55											
11/17/21 18:00	0.27504			0.29694			0.57											
11/17/21 19:00	0.27564			0.2979			0.57											
11/17/21 20:00	0.27132			0.2934			0.56											
11/17/21 21:00	0.24858			0.2682			0.52											
11/17/21 22:00	0.18066			0.19506			0.38											
11/17/21 23:00	0.17472			0.18864			0.36											
11/18/21 0:00	0.17424			0.18822			0.36											
11/18/21 1:00	0.17442			0.18822			0.36											
11/18/21 2:00	0.17442			0.18816			0.36											
11/18/21 3:00	0.1743			0.18816			0.36											
11/18/21 4:00	0.17406			0.18816			0.36											
11/18/21 5:00	0.19938			0.216			0.42											
11/18/21 6:00	0.26544			0.28734			0.55											
11/18/21 7:00	0.24372			0.26286			0.51											
11/18/21 8:00	0.21978			0.23712			0.46											
11/18/21 9:00	0.17508			0.18864			0.36											
11/18/21 10:00	0.16758			0.18054			0.35											
11/18/21 11:00	0.16818			0.18084			0.35											
11/18/21 12:00	0.168			0.18078			0.35											
11/18/21 13:00	0.17712			0.19044			0.37											
11/18/21 14:00	0.18744			0.20142			0.39											
11/18/21 15:00	0.24804			0.26766			0.52											
11/18/21 16:00	0.2628			0.28356			0.55											
11/18/21 17:00	0.26538			0.28626			0.55											
11/18/21 18:00	0.28104			0.303			0.58											
11/18/21 19:00	0.273			0.29454			0.57											
11/18/21 20:00	0.23184			0.24972			0.48											
11/18/21 21:00	0.20958			0.22626			0.44											
11/18/21 22:00	0.19404			0.20922			0.4											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
11/18/21 23:00	0.18672			0.20124			0.39											
11/19/21 0:00	0.14184			0.1992			0.24											
11/19/21 1:00	0	X		0.18618			0.19											
11/19/21 2:00	0	X		0.18702			0.19											
11/19/21 3:00	0	X		0.22458			0.22											
11/19/21 4:00	0	X		0.1866			0.19											
11/19/21 5:00	0	X		0.18642			0.19											
11/19/21 6:00	0	X		0.19374			0.19											
11/19/21 7:00	0.0168			0.25266			0.25											
11/19/21 8:00	0.1743			0.21276			0.39											
11/19/21 9:00	0.16782			0.18084			0.35											
11/19/21 10:00	0.1686			0.18162			0.35											
11/19/21 11:00	0.17016			0.18276			0.35											
11/19/21 12:00	0.17784			0.19044			0.37											
11/19/21 13:00	0.25302			0.2721			0.53											
11/19/21 14:00	0.24096			0.25854			0.5											
11/19/21 15:00	0.20472			0.21978			0.42											
11/19/21 16:00	0.17652			0.18978			0.37											
11/19/21 17:00	0.1902			0.20472			0.39											
11/19/21 18:00	0.1815			0.19518			0.38											
11/19/21 19:00	0.17514			0.18822			0.36											
11/19/21 20:00	0.20268			0.21792			0.42											
11/19/21 21:00	0.1938			0.2085			0.4											
11/19/21 22:00	0.19602			0.2109			0.41											
11/19/21 23:00	0.1686			0.18168			0.35											
11/20/21 0:00	0.16614			0.17934			0.35											
11/20/21 1:00	0.16716			0.1803			0.35											
11/20/21 2:00	0.16722			0.18036			0.35											
11/20/21 3:00	0.1677			0.18132			0.35											
11/20/21 4:00	0.17484			0.18822			0.36											
11/20/21 5:00	0.16944			0.18288			0.35											
11/20/21 6:00	0.17724			0.1914			0.37											
11/20/21 7:00	0.21318			0.23004			0.44											
11/20/21 8:00	0.16578			0.17892			0.34											
11/20/21 9:00	0.16536			0.17874			0.34											
11/20/21 10:00	0.1656			0.17892			0.34											
11/20/21 11:00	0.16536			0.1785			0.34											
11/20/21 12:00	0.16536			0.17844			0.34											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/20/21 13:00	0.16518			0.17802			0.34											
11/20/21 14:00	0.16536			0.17784			0.34											
11/20/21 15:00	0.19842			0.2136			0.41											
11/20/21 16:00	0.19902			0.21396			0.41											
11/20/21 17:00	0.17922			0.19194			0.37											
11/20/21 18:00	0.17304			0.18576			0.36											
11/20/21 19:00	0.19104			0.2055			0.4											
11/20/21 20:00	0.20454			0.22068			0.43											
11/20/21 21:00	0.25854			0.27924			0.54											
11/20/21 22:00	0.22116			0.23886			0.46											
11/20/21 23:00	0.17376			0.18738			0.36											
11/21/21 0:00	0.2061			0.22308			0.43											
11/21/21 1:00	0.1749			0.18852			0.36											
11/21/21 2:00	0.16794			0.1815			0.35											
11/21/21 3:00	0.17442			0.18816			0.36											
11/21/21 4:00	0.17454			0.18864			0.36											
11/21/21 5:00	0.25194			0.2724			0.52											
11/21/21 6:00	0.25794			0.27906			0.54											
11/21/21 7:00	0.25854			0.27942			0.54											
11/21/21 8:00	0.27228			0.29388			0.57											
11/21/21 9:00	0.22152			0.23892			0.46											
11/21/21 10:00	0.22146			0.23862			0.46											
11/21/21 11:00	0.19104			0.20526			0.4											
11/21/21 12:00	0.16692			0.17946			0.35											
11/21/21 13:00	0.16656			0.17916			0.35											
11/21/21 14:00	0.1665			0.1791			0.35											
11/21/21 15:00	0.21456			0.2304			0.44											
11/21/21 16:00	0.20286			0.21816			0.42											
11/21/21 17:00	0.17316			0.18618			0.36											
11/21/21 18:00	0.17322			0.18678			0.36											
11/21/21 19:00	0.21486			0.23202			0.45											
11/21/21 20:00	0.27714			0.2997			0.58											
11/21/21 21:00	0.22998			0.24822			0.48											
11/21/21 22:00	0.22362			0.24138			0.47											
11/21/21 23:00	0.17412			0.18756			0.36											
11/22/21 0:00	0.17502			0.1884			0.36											
11/22/21 1:00	0.17508			0.18846			0.36											
11/22/21 2:00	0.17472			0.18852			0.36											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
11/22/21 3:00	0.17496			0.18858			0.36											
11/22/21 4:00	0.17472			0.18846			0.36											
11/22/21 5:00	0.17616			0.1902			0.37											
11/22/21 6:00	0.2085			0.22602			0.43											
11/22/21 7:00	0.20892			0.22584			0.43											
11/22/21 8:00	0.17478			0.18888			0.36											
11/22/21 9:00	0.168			0.18132			0.35											
11/22/21 10:00	0.16668			0.17964			0.35											
11/22/21 11:00	0.16668			0.17946			0.35											
11/22/21 12:00	0.17154			0.1839			0.36											
11/22/21 13:00	0.17424			0.1869			0.36											
11/22/21 14:00	0.23406			0.25218			0.49											
11/22/21 15:00	0.28098			0.303			0.58											
11/22/21 16:00	0.22998			0.2475			0.48											
11/22/21 17:00	0.18792			0.2022			0.39											
11/22/21 18:00	0.25788			0.27876			0.54											
11/22/21 19:00	0.25572			0.27582			0.53											
11/22/21 20:00	0.25974			0.28062			0.54											
11/22/21 21:00	0.25758			0.2784			0.54											
11/22/21 22:00	0.26034			0.28098			0.54											
11/22/21 23:00	0.21408			0.23094			0.45											
11/23/21 0:00	0.17382			0.18762			0.36											
11/23/21 1:00	0.1752			0.18846			0.36											
11/23/21 2:00	0.17568			0.18882			0.36											
11/23/21 3:00	0.1737			0.18744			0.36											
11/23/21 4:00	0.16866			0.18228			0.35											
11/23/21 5:00	0.16812			0.18186			0.35											
11/23/21 6:00	0.17436			0.18834			0.36											
11/23/21 7:00	0.20178			0.21822			0.42											
11/23/21 8:00	0.16884			0.18258			0.35											
11/23/21 9:00	0.16626			0.17952			0.35											
11/23/21 10:00	0.16596			0.17898			0.34											
11/23/21 11:00	0.1659			0.17898			0.34											
11/23/21 12:00	0.16596			0.17904			0.35											
11/23/21 13:00	0.1659			0.17886			0.34											
11/23/21 14:00	0.16614			0.17916			0.35											
11/23/21 15:00	0.19074			0.2055			0.4											
11/23/21 16:00	0.18702			0.20112			0.39											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
11/23/21 17:00	0.17436			0.1872			0.36											
11/23/21 18:00	0.17418			0.18714			0.36											
11/23/21 19:00	0.1743			0.18738			0.36											
11/23/21 20:00	0.16998			0.1833			0.35											
11/23/21 21:00	0.17172			0.18534			0.36											
11/23/21 22:00	0.17424			0.1881			0.36											
11/23/21 23:00	0.16968			0.18324			0.35											
11/24/21 0:00	0.17466			0.18852			0.36											
11/24/21 1:00	0.17448			0.18834			0.36											
11/24/21 2:00	0.16758			0.18156			0.35											
11/24/21 3:00	0.16752			0.18162			0.35											
11/24/21 4:00	0.16926			0.18318			0.35											
11/24/21 5:00	0.17088			0.18498			0.36											
11/24/21 6:00	0.18696			0.20262			0.39											
11/24/21 7:00	0.20844			0.22506			0.43											
11/24/21 8:00	0.17328			0.18738			0.36											
11/24/21 9:00	0.17946			0.19374			0.37											
11/24/21 10:00	0.1734			0.1869			0.36											
11/24/21 11:00	0.17316			0.18642			0.36											
11/24/21 12:00	0.1731			0.18612			0.36											
11/24/21 13:00	0.17292			0.186			0.36											
11/24/21 14:00	0.17334			0.18636			0.36											
11/24/21 15:00	0.19614			0.21102			0.41											
11/24/21 16:00	0.19548			0.21012			0.41											
11/24/21 17:00	0.1746			0.18714			0.36											
11/24/21 18:00	0.17436			0.18654			0.36											
11/24/21 19:00	0.17556			0.18882			0.36											
11/24/21 20:00	0.17808			0.19266			0.37											
11/24/21 21:00	0.18516			0.2004			0.39											
11/24/21 22:00	0.17424			0.18858			0.36											
11/24/21 23:00	0.17442			0.18912			0.36											
11/25/21 0:00	0.1743			0.18936			0.36											
11/25/21 1:00	0.17436			0.1893			0.36											
11/25/21 2:00	0.1743			0.18978			0.36											
11/25/21 3:00	0.17442			0.18966			0.36											
11/25/21 4:00	0.1743			0.19008			0.36											
11/25/21 5:00	0.17412			0.18984			0.36											
11/25/21 6:00	0.17682			0.19248			0.37											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
11/25/21 7:00	0.20136			0.216			0.42											
11/25/21 8:00	0.17994			0.19416			0.37											
11/25/21 9:00	0.17328			0.18684			0.36											
11/25/21 10:00	0.17382			0.18684			0.36											
11/25/21 11:00	0.1767			0.1899			0.37											
11/25/21 12:00	0.17316			0.18594			0.36											
11/25/21 13:00	0.17322			0.18624			0.36											
11/25/21 14:00	0.1731			0.18588			0.36											
11/25/21 15:00	0.17952			0.19284			0.37											
11/25/21 16:00	0.17946			0.19284			0.37											
11/25/21 17:00	0.17286			0.18576			0.36											
11/25/21 18:00	0.17418			0.18786			0.36											
11/25/21 19:00	0.17268			0.1857			0.36											
11/25/21 20:00	0.17256			0.1857			0.36											
11/25/21 21:00	0.17268			0.1863			0.36											
11/25/21 22:00	0.17196			0.18588			0.36											
11/25/21 23:00	0.1734			0.18636			0.36											
11/26/21 0:00	0.17226			0.18606			0.36											
11/26/21 1:00	0.17196			0.18624			0.36											
11/26/21 2:00	0.17244			0.18636			0.36											
11/26/21 3:00	0.1725			0.18648			0.36											
11/26/21 4:00	0.17274			0.18648			0.36											
11/26/21 5:00	0.17226			0.186			0.36											
11/26/21 6:00	0.17202			0.18618			0.36											
11/26/21 7:00	0.17256			0.1866			0.36											
11/26/21 8:00	0.17244			0.18606			0.36											
11/26/21 9:00	0.17244			0.18612			0.36											
11/26/21 10:00	0.17274			0.18618			0.36											
11/26/21 11:00	0.1722			0.18552			0.36											
11/26/21 12:00	0.17214			0.1851			0.36											
11/26/21 13:00	0.17202			0.18468			0.36											
11/26/21 14:00	0.17196			0.18438			0.36											
11/26/21 15:00	0.2037			0.21888			0.42											
11/26/21 16:00	0.17508			0.18786			0.36											
11/26/21 17:00	0.17172			0.18504			0.36											
11/26/21 18:00	0.17166			0.18474			0.36											
11/26/21 19:00	0.17172			0.18486			0.36											
11/26/21 20:00	0.17256			0.1857			0.36											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
11/26/21 21:00	0.17304			0.1863			0.36											
11/26/21 22:00	0.17286			0.18594			0.36											
11/26/21 23:00	0.17292			0.18684			0.36											
11/27/21 0:00	0.17178			0.18576			0.36											
11/27/21 1:00	0.17268			0.1866			0.36											
11/27/21 2:00	0.17184			0.18582			0.36											
11/27/21 3:00	0.17256			0.18624			0.36											
11/27/21 4:00	0.1722			0.18582			0.36											
11/27/21 5:00	0.18426			0.19866			0.38											
11/27/21 6:00	0.17766			0.19194			0.37											
11/27/21 7:00	0.21054			0.22782			0.44											
11/27/21 8:00	0.17202			0.1857			0.36											
11/27/21 9:00	0.18966			0.20472			0.39											
11/27/21 10:00	0.22176			0.23892			0.46											
11/27/21 11:00	0.17268			0.18552			0.36											
11/27/21 12:00	0.17268			0.18546			0.36											
11/27/21 13:00	0.17262			0.18516			0.36											
11/27/21 14:00	0.17274			0.18498			0.36											
11/27/21 15:00	0.1986			0.21348			0.41											
11/27/21 16:00	0.20784			0.22338			0.43											
11/27/21 17:00	0.17568			0.18828			0.36											
11/27/21 18:00	0.17238			0.18558			0.36											
11/27/21 19:00	0.17274			0.1857			0.36											
11/27/21 20:00	0.1734			0.18624			0.36											
11/27/21 21:00	0.18324			0.19752			0.38											
11/27/21 22:00	0.17256			0.18606			0.36											
11/27/21 23:00	0.17316			0.1863			0.36											
11/28/21 0:00	0.17274			0.18624			0.36											
11/28/21 1:00	0.17262			0.1863			0.36											
11/28/21 2:00	0.17274			0.1866			0.36											
11/28/21 3:00	0.17298			0.18672			0.36											
11/28/21 4:00	0.17298			0.18678			0.36											
11/28/21 5:00	0.17292			0.18672			0.36											
11/28/21 6:00	0.17286			0.1869			0.36											
11/28/21 7:00	0.18276			0.19764			0.38											
11/28/21 8:00	0.17304			0.1869			0.36											
11/28/21 9:00	0.17322			0.18654			0.36											
11/28/21 10:00	0.1731			0.18624			0.36											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
11/28/21 11:00	0.17286			0.18576			0.36											
11/28/21 12:00	0.17286			0.18564			0.36											
11/28/21 13:00	0.1728			0.18528			0.36											
11/28/21 14:00	0.17268			0.1851			0.36											
11/28/21 15:00	0.1737			0.18588			0.36											
11/28/21 16:00	0.1812			0.19422			0.38											
11/28/21 17:00	0.1728			0.18546			0.36											
11/28/21 18:00	0.17274			0.18564			0.36											
11/28/21 19:00	0.17304			0.18594			0.36											
11/28/21 20:00	0.17268			0.18606			0.36											
11/28/21 21:00	0.17274			0.18624			0.36											
11/28/21 22:00	0.17286			0.1863			0.36											
11/28/21 23:00	0.1728			0.18636			0.36											
11/29/21 0:00	0.17298			0.18636			0.36											
11/29/21 1:00	0.17298			0.1863			0.36											
11/29/21 2:00	0.17304			0.18642			0.36											
11/29/21 3:00	0.17304			0.18648			0.36											
11/29/21 4:00	0.1728			0.18684			0.36											
11/29/21 5:00	0.17682			0.19068			0.37											
11/29/21 6:00	0.21276			0.23028			0.44											
11/29/21 7:00	0.21468			0.23184			0.45											
11/29/21 8:00	0.17316			0.18684			0.36											
11/29/21 9:00	0.17322			0.18654			0.36											
11/29/21 10:00	0.1731			0.18636			0.36											
11/29/21 11:00	0.17298			0.18606			0.36											
11/29/21 12:00	0.17286			0.18564			0.36											
11/29/21 13:00	0.17274			0.18534			0.36											
11/29/21 14:00	0.17274			0.1851			0.36											
11/29/21 15:00	0.19278			0.20694			0.4											
11/29/21 16:00	0.2295			0.24702			0.48											
11/29/21 17:00	0.23832			0.25662			0.49											
11/29/21 18:00	0.19638			0.21144			0.41											
11/29/21 19:00	0.2343			0.25314			0.49											
11/29/21 20:00	0.27036			0.29172			0.56											
11/29/21 21:00	0.20586			0.22176			0.43											
11/29/21 22:00	0.18066			0.19476			0.38											
11/29/21 23:00	0.17268			0.1863			0.36											
11/30/21 0:00	0.23334			0.25194			0.49											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
11/30/21 1:00	0.18738			0.20172			0.39											
11/30/21 2:00	0.17274			0.18618			0.36											
11/30/21 3:00	0.17268			0.18612			0.36											
11/30/21 4:00	0.1734			0.18684			0.36											
11/30/21 5:00	0.18984			0.2049			0.39											
11/30/21 6:00	0.26004			0.28128			0.54											
11/30/21 7:00	0.25974			0.28068			0.54											
11/30/21 8:00	0.17784			0.19182			0.37											
11/30/21 9:00	0.1731			0.18618			0.36											
11/30/21 10:00	0.17256			0.18582			0.36											
11/30/21 11:00	0.17286			0.18552			0.36											
11/30/21 12:00	0.17286			0.18546			0.36											
11/30/21 13:00	0.17262			0.18522			0.36											
11/30/21 14:00	0.17256			0.18504			0.36											
11/30/21 15:00	0.2058			0.22074			0.43											
11/30/21 16:00	0.24228			0.26082			0.5											
11/30/21 17:00	0.29106			0.31506			0.61											
11/30/21 18:00	0.38052			0.40104			0.78											
11/30/21 19:00	0.37824			0.39942			0.78											
11/30/21 20:00	0.29772			0.32532			0.62											
11/30/21 21:00	0.35874			0.38058			0.74											
11/30/21 22:00	0.2937			0.30684			0.6											
11/30/21 23:00	0.24186			0.25932			0.5											
12/01/21 0:00	0.17268			0.18624			0.36											
12/01/21 1:00	0.17262			0.1863			0.36											
12/01/21 2:00	0.17292			0.18648			0.36											
12/01/21 3:00	0.17316			0.1866			0.36											
12/01/21 4:00	0.17286			0.18648			0.36											
12/01/21 5:00	0.17268			0.18666			0.36											
12/01/21 6:00	0.17268			0.18666			0.36											
12/01/21 7:00	0.17286			0.18666			0.36											
12/01/21 8:00	0.17304			0.18654			0.36											
12/01/21 9:00	0.17274			0.18618			0.36											
12/01/21 10:00	0.17298			0.18576			0.36											
12/01/21 11:00	0.1728			0.1854			0.36											
12/01/21 12:00	0.17286			0.18528			0.36											
12/01/21 13:00	0.17274			0.18498			0.36											
12/01/21 14:00	0.17268			0.18492			0.36											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
12/01/21 15:00	0.18762			0.20112			0.39											
12/01/21 16:00	0.2175			0.23424			0.45											
12/01/21 17:00	0.24114			0.25962			0.5											
12/01/21 18:00	0.25896			0.27948			0.54											
12/01/21 19:00	0.26862			0.29022			0.56											
12/01/21 20:00	0.25716			0.2775			0.53											
12/01/21 21:00	0.26706			0.28836			0.56											
12/01/21 22:00	0.18732			0.20142			0.39											
12/01/21 23:00	0.17292			0.186			0.36											
12/02/21 0:00	0.17556			0.18924			0.36											
12/02/21 1:00	0.18534			0.19986			0.39											
12/02/21 2:00	0.17982			0.19386			0.37											
12/02/21 3:00	0.24378			0.26334			0.51											
12/02/21 4:00	0.26352			0.285			0.55											
12/02/21 5:00	0.27408			0.29202			0.57											
12/02/21 6:00	0.30432			0.31962			0.62											
12/02/21 7:00	0.29394			0.31716			0.61											
12/02/21 8:00	0.24138			0.2601			0.5											
12/02/21 9:00	0.17298			0.18636			0.36											
12/02/21 10:00	0.17298			0.18594			0.36											
12/02/21 11:00	0.17292			0.18564			0.36											
12/02/21 12:00	0.17268			0.18528			0.36											
12/02/21 13:00	0.17268			0.18504			0.36											
12/02/21 14:00	0.17268			0.18474			0.36											
12/02/21 15:00	0.19638			0.21066			0.41											
12/02/21 16:00	0.22956			0.24648			0.48											
12/02/21 17:00	0.33702			0.35454			0.69											
12/02/21 18:00	0.29952			0.3183			0.62											
12/02/21 19:00	0.29622			0.3174			0.61											
12/02/21 20:00	0.3087			0.3306			0.64											
12/02/21 21:00	0.3075			0.33			0.64											
12/02/21 22:00	0.24354			0.26232			0.51											
12/02/21 23:00	0.17256			0.18594			0.36											
12/03/21 0:00	0.1725			0.18594			0.36											
12/03/21 1:00	0.17268			0.186			0.36											
12/03/21 2:00	0.17262			0.18606			0.36											
12/03/21 3:00	0.17256			0.186			0.36											
12/03/21 4:00	0.1725			0.18618			0.36											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
12/03/21 5:00	0.17838			0.19254			0.37											
12/03/21 6:00	0.18018			0.1947			0.37											
12/03/21 7:00	0.20376			0.2202			0.42											
12/03/21 8:00	0.17604			0.18978			0.37											
12/03/21 9:00	0.22296			0.24072			0.46											
12/03/21 10:00	0.27462			0.29622			0.57											
12/03/21 11:00	0.22722			0.2448			0.47											
12/03/21 12:00	0.20508			0.22068			0.43											
12/03/21 13:00	0.17328			0.18606			0.36											
12/03/21 14:00	0.17316			0.18588			0.36											
12/03/21 15:00	0.22038			0.2376			0.46											
12/03/21 16:00	0.25542			0.27738			0.53											
12/03/21 17:00	0.30282			0.32436			0.63											
12/03/21 18:00	0.30162			0.324			0.63											
12/03/21 19:00	0.30108			0.32382			0.62											
12/03/21 20:00	0.30108			0.32394			0.63											
12/03/21 21:00	0.30102			0.32394			0.62											
12/03/21 22:00	0.30084			0.32448			0.63											
12/03/21 23:00	0.2451			0.26466			0.51											
12/04/21 0:00	0.17268			0.18606			0.36											
12/04/21 1:00	0.17286			0.18642			0.36											
12/04/21 2:00	0.17364			0.1872			0.36											
12/04/21 3:00	0.1854			0.1998			0.39											
12/04/21 4:00	0.21			0.22656			0.44											
12/04/21 5:00	0.20118			0.21714			0.42											
12/04/21 6:00	0.19446			0.21036			0.4											
12/04/21 7:00	0.21792			0.23514			0.45											
12/04/21 8:00	0.1956			0.21114			0.41											
12/04/21 9:00	0.2418			0.26112			0.5											
12/04/21 10:00	0.1995			0.2148			0.41											
12/04/21 11:00	0.24906			0.26862			0.52											
12/04/21 12:00	0.1734			0.18654			0.36											
12/04/21 13:00	0.18894			0.20358			0.39											
12/04/21 14:00	0.18042			0.19422			0.37											
12/04/21 15:00	0.20466			0.22062			0.43											
12/04/21 16:00	0.2478			0.26754			0.52											
12/04/21 17:00	0.28164			0.30366			0.59											
12/04/21 18:00	0.29778			0.32004			0.62											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
12/04/21 19:00	0.29784			0.32034			0.62											
12/04/21 20:00	0.29826			0.32058			0.62											
12/04/21 21:00	0.2982			0.32028			0.62											
12/04/21 22:00	0.18504			0.19908			0.38											
12/04/21 23:00	0.17328			0.18648			0.36											
12/05/21 0:00	0.17334			0.18672			0.36											
12/05/21 1:00	0.17334			0.18678			0.36											
12/05/21 2:00	0.1731			0.18678			0.36											
12/05/21 3:00	0.17292			0.18696			0.36											
12/05/21 4:00	0.17382			0.18798			0.36											
12/05/21 5:00	0.17352			0.1875			0.36											
12/05/21 6:00	0.20592			0.22302			0.43											
12/05/21 7:00	0.19764			0.21366			0.41											
12/05/21 8:00	0.23958			0.25896			0.5											
12/05/21 9:00	0.27792			0.3			0.58											
12/05/21 10:00	0.2775			0.29922			0.58											
12/05/21 11:00	0.26574			0.2862			0.55											
12/05/21 12:00	0.17478			0.18798			0.36											
12/05/21 13:00	0.21816			0.23544			0.45											
12/05/21 14:00	0.19176			0.20622			0.4											
12/05/21 15:00	0.18324			0.19752			0.38											
12/05/21 16:00	0.20604			0.22254			0.43											
12/05/21 17:00	0.21672			0.2343			0.45											
12/05/21 18:00	0.26376			0.28518			0.55											
12/05/21 19:00	0.2784			0.3009			0.58											
12/05/21 20:00	0.27894			0.30114			0.58											
12/05/21 21:00	0.26718			0.2886			0.56											
12/05/21 22:00	0.27006			0.29166			0.56											
12/05/21 23:00	0.228			0.2463			0.47											
12/06/21 0:00	0.19968			0.21552			0.42											
12/06/21 1:00	0.17424			0.18816			0.36											
12/06/21 2:00	0.17376			0.18738			0.36											
12/06/21 3:00	0.1746			0.18816			0.36											
12/06/21 4:00	0.17454			0.1878			0.36											
12/06/21 5:00	0.22188			0.23964			0.46											
12/06/21 6:00	0.27522			0.29724			0.57											
12/06/21 7:00	0.27894			0.30126			0.58											
12/06/21 8:00	0.27636			0.29838			0.57											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
12/06/21 9:00	0.27876			0.30096			0.58											
12/06/21 10:00	0.27864			0.30102			0.58											
12/06/21 11:00	0.2787			0.30066			0.58											
12/06/21 12:00	0.27858			0.30042			0.58											
12/06/21 13:00	0.27852			0.30066			0.58											
12/06/21 14:00	0.27816			0.30054			0.58											
12/06/21 15:00	0.27828			0.3006			0.58											
12/06/21 16:00	0.29046			0.31254			0.6											
12/06/21 17:00	0.30234			0.32478			0.63											
12/06/21 18:00	0.31062			0.33264			0.64											
12/06/21 19:00	0.30252			0.3243			0.63											
12/06/21 20:00	0.30696			0.3291			0.64											
12/06/21 21:00	0.3036			0.32604			0.63											
12/06/21 22:00	0.28998			0.31224			0.6											
12/06/21 23:00	0.2763			0.29844			0.57											
12/07/21 0:00	0.25032			0.27036			0.52											
12/07/21 1:00	0.19908			0.2145			0.41											
12/07/21 2:00	0.17364			0.18678			0.36											
12/07/21 3:00	0.17346			0.18684			0.36											
12/07/21 4:00	0.2091			0.22572			0.43											
12/07/21 5:00	0.17382			0.18714			0.36											
12/07/21 6:00	0.21216			0.22908			0.44											
12/07/21 7:00	0.27786			0.30018			0.58											
12/07/21 8:00	0.27738			0.29934			0.58											
12/07/21 9:00	0.27732			0.29922			0.58											
12/07/21 10:00	0.23976			0.25824			0.5											
12/07/21 11:00	0.2109			0.22746			0.44											
12/07/21 12:00	0.255			0.2751			0.53											
12/07/21 13:00	0.27822			0.29988			0.58											
12/07/21 14:00	0.27714			0.29886			0.58											
12/07/21 15:00	0.27006			0.2913			0.56											
12/07/21 16:00	0.2859			0.31068			0.6											
12/07/21 17:00	0.30108			0.32418			0.63											
12/07/21 18:00	0.31452			0.33684			0.65											
12/07/21 19:00	0.33018			0.35298			0.68											
12/07/21 20:00	0.30492			0.32772			0.63											
12/07/21 21:00	0.30588			0.32802			0.63											
12/07/21 22:00	0.30594			0.32832			0.63											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
12/07/21 23:00	0.28758			0.30936			0.6											
12/08/21 0:00	0.23814			0.25716			0.5											
12/08/21 1:00	0.21924			0.23664			0.46											
12/08/21 2:00	0.1731			0.18636			0.36											
12/08/21 3:00	0.17472			0.18786			0.36											
12/08/21 4:00	0.17622			0.18972			0.37											
12/08/21 5:00	0.17586			0.189			0.36											
12/08/21 6:00	0.25584			0.27648			0.53											
12/08/21 7:00	0.25956			0.28026			0.54											
12/08/21 8:00	0.18864			0.20322			0.39											
12/08/21 9:00	0.17316			0.18648			0.36											
12/08/21 10:00	0.17328			0.18678			0.36											
12/08/21 11:00	0.26028			0.2817			0.54											
12/08/21 12:00	0.25734			0.2772			0.53											
12/08/21 13:00	0.17556			0.18876			0.36											
12/08/21 14:00	0.17328			0.1863			0.36											
12/08/21 15:00	0.17952			0.19332			0.37											
12/08/21 16:00	0.21858			0.23622			0.45											
12/08/21 17:00	0.27594			0.29796			0.57											
12/08/21 18:00	0.26604			0.28728			0.55											
12/08/21 19:00	0.2772			0.29922			0.58											
12/08/21 20:00	0.26646			0.28764			0.55											
12/08/21 21:00	0.2265			0.24432			0.47											
12/08/21 22:00	0.17238			0.18546			0.36											
12/08/21 23:00	0.17244			0.18576			0.36											
12/09/21 0:00	0.17358			0.18696			0.36											
12/09/21 1:00	0.1737			0.18672			0.36											
12/09/21 2:00	0.17298			0.18654			0.36											
12/09/21 3:00	0.17346			0.18702			0.36											
12/09/21 4:00	0.17382			0.18708			0.36											
12/09/21 5:00	0.17358			0.18726			0.36											
12/09/21 6:00	0.22446			0.24294			0.47											
12/09/21 7:00	0.19902			0.21468			0.41											
12/09/21 8:00	0.18192			0.19614			0.38											
12/09/21 9:00	0.23004			0.24846			0.48											
12/09/21 10:00	0.20136			0.21708			0.42											
12/09/21 11:00	0.17292			0.18588			0.36											
12/09/21 12:00	0.17754			0.19104			0.37											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
12/09/21 13:00	0.17232			0.18516			0.36											
12/09/21 14:00	0.17214			0.18504			0.36											
12/09/21 15:00	0.1782			0.19194			0.37											
12/09/21 16:00	0.23442			0.25344			0.49											
12/09/21 17:00	0.23292			0.25152			0.48											
12/09/21 18:00	0.19788			0.21348			0.41											
12/09/21 19:00	0.22146			0.23928			0.46											
12/09/21 20:00	0.252			0.27252			0.52											
12/09/21 21:00	0.23508			0.2541			0.49											
12/09/21 22:00	0.19938			0.21252			0.41											
12/09/21 23:00	0.17286			0.18666			0.36											
12/10/21 0:00	0.17568			0.18972			0.37											
12/10/21 1:00	0.17376			0.18792			0.36											
12/10/21 2:00	0.17358			0.18768			0.36											
12/10/21 3:00	0.17364			0.18804			0.36											
12/10/21 4:00	0.17322			0.18732			0.36											
12/10/21 5:00	0.19158			0.2073			0.4											
12/10/21 6:00	0.23232			0.25194			0.48											
12/10/21 7:00	0.2736			0.29562			0.57											
12/10/21 8:00	0.20154			0.21738			0.42											
12/10/21 9:00	0.17322			0.18732			0.36											
12/10/21 10:00	0.1914			0.207			0.4											
12/10/21 11:00	0.26592			0.2871			0.55											
12/10/21 12:00	0.21072			0.22722			0.44											
12/10/21 13:00	0.17538			0.18918			0.36											
12/10/21 14:00	0.17286			0.18624			0.36											
12/10/21 15:00	0.2172			0.23454			0.45											
12/10/21 16:00	0.26988			0.29172			0.56											
12/10/21 17:00	0.27774			0.29934			0.58											
12/10/21 18:00	0.27768			0.29988			0.58											
12/10/21 19:00	0.27822			0.29994			0.58											
12/10/21 20:00	0.27882			0.30108			0.58											
12/10/21 21:00	0.27864			0.30036			0.58											
12/10/21 22:00	0.27846			0.30054			0.58											
12/10/21 23:00	0.27888			0.29976			0.58											
12/11/21 0:00	0.2118			0.22896			0.44											
12/11/21 1:00	0.17424			0.18876			0.36											
12/11/21 2:00	0.17424			0.18882			0.36											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/11/21 3:00	0.17388			0.17384			0.36											
12/11/21 4:00	0.17406			0.1884			0.36											
12/11/21 5:00	0.1746			0.18894			0.36											
12/11/21 6:00	0.19152			0.20724			0.4											
12/11/21 7:00	0.19902			0.21504			0.41											
12/11/21 8:00	0.1734			0.18732			0.36											
12/11/21 9:00	0.17364			0.18732			0.36											
12/11/21 10:00	0.17358			0.18684			0.36											
12/11/21 11:00	0.1737			0.18666			0.36											
12/11/21 12:00	0.17352			0.18654			0.36											
12/11/21 13:00	0.17346			0.1863			0.36											
12/11/21 14:00	0.17322			0.18612			0.36											
12/11/21 15:00	0.1737			0.18672			0.36											
12/11/21 16:00	0.23376			0.25212			0.49											
12/11/21 17:00	0.25782			0.27828			0.54											
12/11/21 18:00	0.25176			0.27126			0.52											
12/11/21 19:00	0.27672			0.29838			0.58											
12/11/21 20:00	0.27636			0.29772			0.57											
12/11/21 21:00	0.27978			0.3012			0.58											
12/11/21 22:00	0.2799			0.30132			0.58											
12/11/21 23:00	0.22212			0.2391			0.46											
12/12/21 0:00	0.23124			0.24924			0.48											
12/12/21 1:00	0.17406			0.18726			0.36											
12/12/21 2:00	0.17568			0.18924			0.36											
12/12/21 3:00	0.25596			0.27624			0.53											
12/12/21 4:00	0.20328			0.2193			0.42											
12/12/21 5:00	0.17448			0.18798			0.36											
12/12/21 6:00	0.2037			0.21978			0.42											
12/12/21 7:00	0.19392			0.20928			0.4											
12/12/21 8:00	0.19338			0.20868			0.4											
12/12/21 9:00	0.17844			0.19218			0.37											
12/12/21 10:00	0.17352			0.18666			0.36											
12/12/21 11:00	0.17328			0.18648			0.36											
12/12/21 12:00	0.17286			0.1863			0.36											
12/12/21 13:00	0.17298			0.18612			0.36											
12/12/21 14:00	0.17562			0.18948			0.37											
12/12/21 15:00	0.19032			0.2055			0.4											
12/12/21 16:00	0.23244			0.25134			0.48											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
12/12/21 17:00	0.2541			0.27426			0.53											
12/12/21 18:00	0.25416			0.27438			0.53											
12/12/21 19:00	0.27342			0.2949			0.57											
12/12/21 20:00	0.26226			0.2826			0.54											
12/12/21 21:00	0.24402			0.26346			0.51											
12/12/21 22:00	0.22032			0.23778			0.46											
12/12/21 23:00	0.17274			0.1863			0.36											
12/13/21 0:00	0.1731			0.18678			0.36											
12/13/21 1:00	0.17364			0.18726			0.36											
12/13/21 2:00	0.17358			0.18714			0.36											
12/13/21 3:00	0.17274			0.18636			0.36											
12/13/21 4:00	0.17256			0.18606			0.36											
12/13/21 5:00	0.17256			0.186			0.36											
12/13/21 6:00	0.22776			0.24612			0.47											
12/13/21 7:00	0.2706			0.2922			0.56											
12/13/21 8:00	0.26508			0.28608			0.55											
12/13/21 9:00	0.27018			0.29154			0.56											
12/13/21 10:00	0.23268			0.2508			0.48											
12/13/21 11:00	0.1911			0.20628			0.4											
12/13/21 12:00	0.27378			0.2952			0.57											
12/13/21 13:00	0.2811			0.30324			0.58											
12/13/21 14:00	0.27774			0.2994			0.58											
12/13/21 15:00	0.2778			0.29982			0.58											
12/13/21 16:00	0.28632			0.3156			0.6											
12/13/21 17:00	0.31362			0.33552			0.65											
12/13/21 18:00	0.30648			0.32856			0.64											
12/13/21 19:00	0.30648			0.32868			0.64											
12/13/21 20:00	0.30642			0.32862			0.64											
12/13/21 21:00	0.30648			0.3288			0.64											
12/13/21 22:00	0.2463			0.2655			0.51											
12/13/21 23:00	0.17304			0.1866			0.36											
12/14/21 0:00	0.17364			0.18708			0.36											
12/14/21 1:00	0.17328			0.18702			0.36											
12/14/21 2:00	0.17304			0.18684			0.36											
12/14/21 3:00	0.17268			0.18648			0.36											
12/14/21 4:00	0.17208			0.18612			0.36											
12/14/21 5:00	0.20214			0.21834			0.42											
12/14/21 6:00	0.24384			0.26364			0.51											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
12/14/21 7:00	0.18402			0.19866			0.38											
12/14/21 8:00	0.17454			0.1884			0.36											
12/14/21 9:00	0.17304			0.18654			0.36											
12/14/21 10:00	0.17316			0.18636			0.36											
12/14/21 11:00	0.17298			0.1863			0.36											
12/14/21 12:00	0.17268			0.18588			0.36											
12/14/21 13:00	0.17286			0.18582			0.36											
12/14/21 14:00	0.17244			0.18576			0.36											
12/14/21 15:00	0.1728			0.18624			0.36											
12/14/21 16:00	0.19302			0.20832			0.4											
12/14/21 17:00	0.264			0.28554			0.55											
12/14/21 18:00	0.25758			0.27846			0.54											
12/14/21 19:00	0.2664			0.28836			0.55											
12/14/21 20:00	0.27768			0.30048			0.58											
12/14/21 21:00	0.2772			0.29952			0.58											
12/14/21 22:00	0.25374			0.27408			0.53											
12/14/21 23:00	0.17328			0.1872			0.36											
12/15/21 0:00	0.17946			0.19374			0.37											
12/15/21 1:00	0.17334			0.18702			0.36											
12/15/21 2:00	0.17352			0.18726			0.36											
12/15/21 3:00	0.17352			0.1872			0.36											
12/15/21 4:00	0.22746			0.24666			0.47											
12/15/21 5:00	0.27846			0.30114			0.58											
12/15/21 6:00	0.27804			0.30048			0.58											
12/15/21 7:00	0.25494			0.2751			0.53											
12/15/21 8:00	0.18312			0.19722			0.38											
12/15/21 9:00	0.1746			0.18786			0.36											
12/15/21 10:00	0.17436			0.18774			0.36											
12/15/21 11:00	0.1827			0.19644			0.38											
12/15/21 12:00	0.23964			0.25884			0.5											
12/15/21 13:00	0.22578			0.24294			0.47											
12/15/21 14:00	0.17328			0.1863			0.36											
12/15/21 15:00	0.19782			0.21312			0.41											
12/15/21 16:00	0.24222			0.26184			0.5											
12/15/21 17:00	0.27768			0.30018			0.58											
12/15/21 18:00	0.27474			0.29694			0.57											
12/15/21 19:00	0.27576			0.2982			0.57											
12/15/21 20:00	0.27942			0.3018			0.58											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
12/15/21 21:00	0.26814			0.2898			0.56											
12/15/21 22:00	0.25926			0.28038			0.54											
12/15/21 23:00	0.25242			0.27282			0.53											
12/16/21 0:00	0.25518			0.27588			0.53											
12/16/21 1:00	0.22284			0.24048			0.46											
12/16/21 2:00	0.17316			0.18678			0.36											
12/16/21 3:00	0.17322			0.18702			0.36											
12/16/21 4:00	0.24606			0.26694			0.51											
12/16/21 5:00	0.3012			0.32388			0.63											
12/16/21 6:00	0.30474			0.32808			0.63											
12/16/21 7:00	0.3054			0.3294			0.63											
12/16/21 8:00	0.29934			0.32292			0.62											
12/16/21 9:00	0.28716			0.31056			0.6											
12/16/21 10:00	0.30078			0.32352			0.62											
12/16/21 11:00	0.24276			0.26118			0.5											
12/16/21 12:00	0.17364			0.18624			0.36											
12/16/21 13:00	0.17706			0.19014			0.37											
12/16/21 14:00	0.2094			0.22542			0.43											
12/16/21 15:00	0.25494			0.27648			0.53											
12/16/21 16:00	0.30168			0.32472			0.63											
12/16/21 17:00	0.29772			0.32034			0.62											
12/16/21 18:00	0.29862			0.3198			0.62											
12/16/21 19:00	0.3042			0.32622			0.63											
12/16/21 20:00	0.30198			0.32046			0.62											
12/16/21 21:00	0.36192			0.38448			0.75											
12/16/21 22:00	0.31464			0.33354			0.65											
12/16/21 23:00	0.21978			0.23382			0.45											
12/17/21 0:00	0.17352			0.1872			0.36											
12/17/21 1:00	0.17538			0.18936			0.36											
12/17/21 2:00	0.17604			0.19002			0.37											
12/17/21 3:00	0.17562			0.1899			0.37											
12/17/21 4:00	0.25098			0.26994			0.52											
12/17/21 5:00	0.30102			0.32274			0.62											
12/17/21 6:00	0.3102			0.3315			0.64											
12/17/21 7:00	0.30828			0.33186			0.64											
12/17/21 8:00	0.2499			0.26718			0.52											
12/17/21 9:00	0.17538			0.18936			0.36											
12/17/21 10:00	0.1758			0.18954			0.37											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/17/21 11:00	0.17454			0.18804			0.36											
12/17/21 12:00	0.17442			0.18792			0.36											
12/17/21 13:00	0.17442			0.1878			0.36											
12/17/21 14:00	0.17388			0.1872			0.36											
12/17/21 15:00	0.24222			0.26214			0.5											
12/17/21 16:00	0.30528			0.32886			0.63											
12/17/21 17:00	0.30114			0.32094			0.62											
12/17/21 18:00	0.30156			0.31644			0.62											
12/17/21 19:00	0.30204			0.31596			0.62											
12/17/21 20:00	0.3021			0.3171			0.62											
12/17/21 21:00	0.30156			0.3162			0.62											
12/17/21 22:00	0.3021			0.31668			0.62											
12/17/21 23:00	0.25314			0.26952			0.52											
12/18/21 0:00	0.24162			0.26118			0.5											
12/18/21 1:00	0.25518			0.2757			0.53											
12/18/21 2:00	0.24486			0.26448			0.51											
12/18/21 3:00	0.20298			0.21996			0.42											
12/18/21 4:00	0.2334			0.25272			0.49											
12/18/21 5:00	0.24966			0.2694			0.52											
12/18/21 6:00	0.3024			0.31908			0.62											
12/18/21 7:00	0.24006			0.25686			0.5											
12/18/21 8:00	0.18828			0.20352			0.39											
12/18/21 9:00	0.18426			0.19938			0.38											
12/18/21 10:00	0.27708			0.2991			0.58											
12/18/21 11:00	0.21702			0.23388			0.45											
12/18/21 12:00	0.17412			0.18774			0.36											
12/18/21 13:00	0.17466			0.18804			0.36											
12/18/21 14:00	0.17424			0.18768			0.36											
12/18/21 15:00	0.18984			0.20472			0.39											
12/18/21 16:00	0.25296			0.2733			0.53											
12/18/21 17:00	0.3009			0.31992			0.62											
12/18/21 18:00	0.30132			0.31962			0.62											
12/18/21 19:00	0.3012			0.31986			0.62											
12/18/21 20:00	0.3012			0.31992			0.62											
12/18/21 21:00	0.30252			0.32124			0.62											
12/18/21 22:00	0.30234			0.32088			0.62											
12/18/21 23:00	0.2211			0.23604			0.46											
12/19/21 0:00	0.25434			0.2748			0.53											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
12/19/21 1:00	0.25368			0.27372			0.53											
12/19/21 2:00	0.24336			0.26268			0.51											
12/19/21 3:00	0.1743			0.18798			0.36											
12/19/21 4:00	0.17322			0.18702			0.36											
12/19/21 5:00	0.24216			0.26154			0.5											
12/19/21 6:00	0.2565			0.2733			0.53											
12/19/21 7:00	0.19284			0.20784			0.4											
12/19/21 8:00	0.17382			0.18738			0.36											
12/19/21 9:00	0.24258			0.26202			0.5											
12/19/21 10:00	0.26814			0.28926			0.56											
12/19/21 11:00	0.19116			0.20616			0.4											
12/19/21 12:00	0.1737			0.1869			0.36											
12/19/21 13:00	0.17634			0.18948			0.37											
12/19/21 14:00	0.20064			0.21642			0.42											
12/19/21 15:00	0.25026			0.27528			0.53											
12/19/21 16:00	0.29964			0.32166			0.62											
12/19/21 17:00	0.30186			0.32184			0.62											
12/19/21 18:00	0.30048			0.3183			0.62											
12/19/21 19:00	0.30162			0.31722			0.62											
12/19/21 20:00	0.30084			0.3225			0.62											
12/19/21 21:00	0.30102			0.32064			0.62											
12/19/21 22:00	0.27504			0.29562			0.57											
12/19/21 23:00	0.23622			0.25536			0.49											
12/20/21 0:00	0.192			0.20772			0.4											
12/20/21 1:00	0.22788			0.24654			0.47											
12/20/21 2:00	0.23232			0.25146			0.48											
12/20/21 3:00	0.2157			0.2334			0.45											
12/20/21 4:00	0.1917			0.20754			0.4											
12/20/21 5:00	0.27684			0.30192			0.58											
12/20/21 6:00	0.30774			0.32898			0.64											
12/20/21 7:00	0.29232			0.31512			0.61											
12/20/21 8:00	0.23154			0.25014			0.48											
12/20/21 9:00	0.18756			0.20322			0.39											
12/20/21 10:00	0.17526			0.18972			0.36											
12/20/21 11:00	0.20214			0.21834			0.42											
12/20/21 12:00	0.26988			0.29142			0.56											
12/20/21 13:00	0.27912			0.30132			0.58											
12/20/21 14:00	0.31062			0.34254			0.65											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
12/20/21 15:00	0.3555			0.37776			0.73											
12/20/21 16:00	0.3201			0.34512			0.67											
12/20/21 17:00	0.35892			0.38178			0.74											
12/20/21 18:00	0.33624			0.35934			0.7											
12/20/21 19:00	0.34458			0.3681			0.71											
12/20/21 20:00	0.3657			0.38868			0.75											
12/20/21 21:00	0.34332			0.36696			0.71											
12/20/21 22:00	0.32706			0.3558			0.68											
12/20/21 23:00	0.3033			0.33156			0.63											
12/21/21 0:00	0.2781			0.30078			0.58											
12/21/21 1:00	0.27654			0.29892			0.58											
12/21/21 2:00	0.27666			0.2988			0.58											
12/21/21 3:00	0.26268			0.28398			0.55											
12/21/21 4:00	0.24816			0.26802			0.52											
12/21/21 5:00	0.249			0.2691			0.52											
12/21/21 6:00	0.26808			0.2895			0.56											
12/21/21 7:00	0.28344			0.30552			0.59											
12/21/21 8:00	0.38166			0.40428			0.79											
12/21/21 9:00	0.38058			0.40296			0.78											
12/21/21 10:00	0.29838			0.3174			0.62											
12/21/21 11:00	0.2442			0.26178			0.51											
12/21/21 12:00	0.2298			0.24816			0.48											
12/21/21 13:00	0.27108			0.29214			0.56											
12/21/21 14:00	0.28728			0.31032			0.6											
12/21/21 15:00	0.30192			0.30192			0.63											
12/21/21 16:00	0.30456			0.327			0.63											
12/21/21 17:00	0.30048			0.3219			0.62											
12/21/21 18:00	0.3003			0.32208			0.62											
12/21/21 19:00	0.30024			0.32208			0.62											
12/21/21 20:00	0.30132			0.32184			0.62											
12/21/21 21:00	0.3012			0.32256			0.62											
12/21/21 22:00	0.30108			0.32376			0.62											
12/21/21 23:00	0.24888			0.26676			0.52											
12/22/21 0:00	0.17448			0.1881			0.36											
12/22/21 1:00	0.1743			0.18816			0.36											
12/22/21 2:00	0.17412			0.18804			0.36											
12/22/21 3:00	0.17412			0.1878			0.36											
12/22/21 4:00	0.17478			0.18852			0.36											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
12/22/21 5:00	0.27834			0.3042			0.58											
12/22/21 6:00	0.30024			0.3225			0.62											
12/22/21 7:00	0.30048			0.32214			0.62											
12/22/21 8:00	0.30078			0.32352			0.62											
12/22/21 9:00	0.30144			0.32388			0.63											
12/22/21 10:00	0.25608			0.27528			0.53											
12/22/21 11:00	0.17442			0.18756			0.36											
12/22/21 12:00	0.17514			0.18822			0.36											
12/22/21 13:00	0.24792			0.26856			0.52											
12/22/21 14:00	0.30906			0.33138			0.64											
12/22/21 15:00	0.30714			0.32916			0.64											
12/22/21 16:00	0.3063			0.32808			0.63											
12/22/21 17:00	0.30678			0.3285			0.64											
12/22/21 18:00	0.30648			0.32844			0.63											
12/22/21 19:00	0.30078			0.32268			0.62											
12/22/21 20:00	0.17814			0.19128			0.37											
12/22/21 21:00	0.17832			0.1917			0.37											
12/22/21 22:00	0.19578			0.21096			0.41											
12/22/21 23:00	0.17958			0.19314			0.37											
12/23/21 0:00	0.23034			0.24876			0.48											
12/23/21 1:00	0.18828			0.2028			0.39											
12/23/21 2:00	0.17652			0.1899			0.37											
12/23/21 3:00	0.17412			0.18738			0.36											
12/23/21 4:00	0.17352			0.1869			0.36											
12/23/21 5:00	0.17388			0.18726			0.36											
12/23/21 6:00	0.17454			0.1878			0.36											
12/23/21 7:00	0.17412			0.1875			0.36											
12/23/21 8:00	0.17412			0.18744			0.36											
12/23/21 9:00	0.17412			0.18738			0.36											
12/23/21 10:00	0.17484			0.18768			0.36											
12/23/21 11:00	0.17448			0.18732			0.36											
12/23/21 12:00	0.17406			0.1869			0.36											
12/23/21 13:00	0.17442			0.18708			0.36											
12/23/21 14:00	0.17442			0.18696			0.36											
12/23/21 15:00	0.17424			0.18702			0.36											
12/23/21 16:00	0.17406			0.1869			0.36											
12/23/21 17:00	0.17418			0.1872			0.36											
12/23/21 18:00	0.17478			0.18756			0.36											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/23/21 19:00	0.1734			0.18642			0.36											
12/23/21 20:00	0.1737			0.18648			0.36											
12/23/21 21:00	0.17316			0.18624			0.36											
12/23/21 22:00	0.17286			0.18606			0.36											
12/23/21 23:00	0.17376			0.18678			0.36											
12/24/21 0:00	0.17406			0.1872			0.36											
12/24/21 1:00	0.17406			0.18756			0.36											
12/24/21 2:00	0.17382			0.18744			0.36											
12/24/21 3:00	0.17418			0.18726			0.36											
12/24/21 4:00	0.17418			0.18714			0.36											
12/24/21 5:00	0.17424			0.18732			0.36											
12/24/21 6:00	0.1743			0.18732			0.36											
12/24/21 7:00	0.1743			0.18744			0.36											
12/24/21 8:00	0.177			0.19032			0.37											
12/24/21 9:00	0.17436			0.1872			0.36											
12/24/21 10:00	0.17454			0.18756			0.36											
12/24/21 11:00	0.17412			0.18714			0.36											
12/24/21 12:00	0.17412			0.18708			0.36											
12/24/21 13:00	0.174			0.1869			0.36											
12/24/21 14:00	0.17412			0.1866			0.36											
12/24/21 15:00	0.17406			0.18672			0.36											
12/24/21 16:00	0.17442			0.18744			0.36											
12/24/21 17:00	0.17418			0.1872			0.36											
12/24/21 18:00	0.17364			0.18708			0.36											
12/24/21 19:00	0.17358			0.18696			0.36											
12/24/21 20:00	0.1734			0.18678			0.36											
12/24/21 21:00	0.17364			0.1869			0.36											
12/24/21 22:00	0.17334			0.18666			0.36											
12/24/21 23:00	0.17352			0.18672			0.36											
12/25/21 0:00	0.17376			0.18696			0.36											
12/25/21 1:00	0.17376			0.18702			0.36											
12/25/21 2:00	0.17358			0.1869			0.36											
12/25/21 3:00	0.1734			0.18684			0.36											
12/25/21 4:00	0.17358			0.18678			0.36											
12/25/21 5:00	0.1737			0.18702			0.36											
12/25/21 6:00	0.17346			0.18678			0.36											
12/25/21 7:00	0.174			0.18726			0.36											
12/25/21 8:00	0.17358			0.18714			0.36											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
12/25/21 9:00	0.1734			0.1872			0.36											
12/25/21 10:00	0.17412			0.18786			0.36											
12/25/21 11:00	0.17436			0.18816			0.36											
12/25/21 12:00	0.1746			0.18828			0.36											
12/25/21 13:00	0.17514			0.18876			0.36											
12/25/21 14:00	0.17526			0.1887			0.36											
12/25/21 15:00	0.18174			0.19602			0.38											
12/25/21 16:00	0.17436			0.18816			0.36											
12/25/21 17:00	0.17466			0.18798			0.36											
12/25/21 18:00	0.17424			0.18756			0.36											
12/25/21 19:00	0.17418			0.18714			0.36											
12/25/21 20:00	0.17454			0.18798			0.36											
12/25/21 21:00	0.17424			0.18762			0.36											
12/25/21 22:00	0.17376			0.1872			0.36											
12/25/21 23:00	0.17328			0.18702			0.36											
12/26/21 0:00	0.17316			0.18696			0.36											
12/26/21 1:00	0.17322			0.18702			0.36											
12/26/21 2:00	0.17328			0.1872			0.36											
12/26/21 3:00	0.17454			0.18852			0.36											
12/26/21 4:00	0.1746			0.18846			0.36											
12/26/21 5:00	0.17514			0.18924			0.36											
12/26/21 6:00	0.17538			0.18942			0.36											
12/26/21 7:00	0.17742			0.19194			0.37											
12/26/21 8:00	0.17376			0.18744			0.36											
12/26/21 9:00	0.17454			0.18828			0.36											
12/26/21 10:00	0.17478			0.1884			0.36											
12/26/21 11:00	0.17832			0.19224			0.37											
12/26/21 12:00	0.17586			0.1893			0.37											
12/26/21 13:00	0.18804			0.20286			0.39											
12/26/21 14:00	0.18036			0.19434			0.37											
12/26/21 15:00	0.18078			0.19482			0.38											
12/26/21 16:00	0.2454			0.26532			0.51											
12/26/21 17:00	0.3039			0.32724			0.63											
12/26/21 18:00	0.21786			0.23508			0.45											
12/26/21 19:00	0.1761			0.18978			0.37											
12/26/21 20:00	0.18			0.19404			0.37											
12/26/21 21:00	0.261			0.28218			0.54											
12/26/21 22:00	0.19512			0.21018			0.41											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
12/26/21 23:00	0.17502			0.18846			0.36											
12/27/21 0:00	0.1761			0.1899			0.37											
12/27/21 1:00	0.17502			0.18894			0.36											
12/27/21 2:00	0.17508			0.18918			0.36											
12/27/21 3:00	0.17484			0.18864			0.36											
12/27/21 4:00	0.17376			0.18774			0.36											
12/27/21 5:00	0.24738			0.27018			0.52											
12/27/21 6:00	0.30414			0.32712			0.63											
12/27/21 7:00	0.30402			0.32706			0.63											
12/27/21 8:00	0.30678			0.32982			0.64											
12/27/21 9:00	0.2763			0.29754			0.57											
12/27/21 10:00	0.21612			0.23286			0.45											
12/27/21 11:00	0.26568			0.28566			0.55											
12/27/21 12:00	0.17376			0.1866			0.36											
12/27/21 13:00	0.18372			0.19776			0.38											
12/27/21 14:00	0.25158			0.2712			0.52											
12/27/21 15:00	0.28386			0.30492			0.59											
12/27/21 16:00	0.30618			0.32808			0.63											
12/27/21 17:00	0.3096			0.33252			0.64											
12/27/21 18:00	0.31278			0.3363			0.65											
12/27/21 19:00	0.3156			0.3387			0.65											
12/27/21 20:00	0.3168			0.33906			0.66											
12/27/21 21:00	0.30294			0.32586			0.63											
12/27/21 22:00	0.26886			0.29046			0.56											
12/27/21 23:00	0.20934			0.22578			0.44											
12/28/21 0:00	0.18096			0.19548			0.38											
12/28/21 1:00	0.17526			0.18918			0.36											
12/28/21 2:00	0.17556			0.18936			0.36											
12/28/21 3:00	0.18018			0.19434			0.37											
12/28/21 4:00	0.1755			0.1893			0.36											
12/28/21 5:00	0.2403			0.25986			0.5											
12/28/21 6:00	0.23544			0.25458			0.49											
12/28/21 7:00	0.17994			0.19446			0.37											
12/28/21 8:00	0.20484			0.22152			0.43											
12/28/21 9:00	0.20088			0.21702			0.42											
12/28/21 10:00	0.17412			0.18768			0.36											
12/28/21 11:00	0.17394			0.18744			0.36											
12/28/21 12:00	0.1743			0.18774			0.36											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
12/28/21 13:00	0.17376			0.1869			0.36											
12/28/21 14:00	0.17364			0.18696			0.36											
12/28/21 15:00	0.2034			0.21936			0.42											
12/28/21 16:00	0.22788			0.24594			0.47											
12/28/21 17:00	0.28026			0.30228			0.58											
12/28/21 18:00	0.26256			0.28338			0.55											
12/28/21 19:00	0.2385			0.25764			0.5											
12/28/21 20:00	0.23346			0.25224			0.49											
12/28/21 21:00	0.18618			0.2007			0.39											
12/28/21 22:00	0.17748			0.19134			0.37											
12/28/21 23:00	0.17652			0.19008			0.37											
12/29/21 0:00	0.17694			0.19056			0.37											
12/29/21 1:00	0.17646			0.19008			0.37											
12/29/21 2:00	0.174			0.18816			0.36											
12/29/21 3:00	0.17364			0.18792			0.36											
12/29/21 4:00	0.17388			0.18792			0.36											
12/29/21 5:00	0.17526			0.18924			0.36											
12/29/21 6:00	0.1806			0.19518			0.38											
12/29/21 7:00	0.17418			0.18804			0.36											
12/29/21 8:00	0.17406			0.18798			0.36											
12/29/21 9:00	0.17358			0.18732			0.36											
12/29/21 10:00	0.1734			0.18714			0.36											
12/29/21 11:00	0.1737			0.18762			0.36											
12/29/21 12:00	0.17412			0.18822			0.36											
12/29/21 13:00	0.18234			0.19686			0.38											
12/29/21 14:00	0.22332			0.24096			0.46											
12/29/21 15:00	0.22818			0.24636			0.47											
12/29/21 16:00	0.22548			0.2433			0.47											
12/29/21 17:00	0.27522			0.29712			0.57											
12/29/21 18:00	0.27666			0.29856			0.58											
12/29/21 19:00	0.28014			0.30246			0.58											
12/29/21 20:00	0.28038			0.30264			0.58											
12/29/21 21:00	0.20952			0.22614			0.44											
12/29/21 22:00	0.1764			0.19026			0.37											
12/29/21 23:00	0.17436			0.1881			0.36											
12/30/21 0:00	0.174			0.1878			0.36											
12/30/21 1:00	0.17412			0.1875			0.36											
12/30/21 2:00	0.17394			0.18774			0.36											

Date/Time	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H			Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod									
12/30/21 3:00	0.17364			0.1875			0.36											
12/30/21 4:00	0.1743			0.18798			0.36											
12/30/21 5:00	0.27516			0.29862			0.57											
12/30/21 6:00	0.30012			0.32292			0.62											
12/30/21 7:00	0.29964			0.32262			0.62											
12/30/21 8:00	0.29994			0.32154			0.62											
12/30/21 9:00	0.30036			0.32172			0.62											
12/30/21 10:00	0.18666			0.20028			0.39											
12/30/21 11:00	0.1746			0.18762			0.36											
12/30/21 12:00	0.17478			0.1878			0.36											
12/30/21 13:00	0.17478			0.18762			0.36											
12/30/21 14:00	0.17514			0.18828			0.36											
12/30/21 15:00	0.17544			0.18846			0.36											
12/30/21 16:00	0.2481			0.26874			0.52											
12/30/21 17:00	0.30312			0.3249			0.63											
12/30/21 18:00	0.303			0.3255			0.63											
12/30/21 19:00	0.30408			0.32574			0.63											
12/30/21 20:00	0.30432			0.3261			0.63											
12/30/21 21:00	0.3033			0.32622			0.63											
12/30/21 22:00	0.22938			0.24726			0.48											
12/30/21 23:00	0.17568			0.1893			0.36											
12/31/21 0:00	0.1746			0.1884			0.36											
12/31/21 1:00	0.17376			0.18804			0.36											
12/31/21 2:00	0.174			0.18786			0.36											
12/31/21 3:00	0.1743			0.1881			0.36											
12/31/21 4:00	0.1743			0.18816			0.36											
12/31/21 5:00	0.17382			0.18786			0.36											
12/31/21 6:00	0.17418			0.1881			0.36											
12/31/21 7:00	0.1746			0.1884			0.36											
12/31/21 8:00	0.17538			0.18912			0.36											
12/31/21 9:00	0.17592			0.18966			0.37											
12/31/21 10:00	0.17472			0.18846			0.36											
12/31/21 11:00	0.17328			0.18684			0.36											
12/31/21 12:00	0.17328			0.18672			0.36											
12/31/21 13:00	0.17322			0.18666			0.36											
12/31/21 14:00	0.17298			0.18642			0.36											
12/31/21 15:00	0.17298			0.18648			0.36											
12/31/21 16:00	0.20346			0.21948			0.42											

	CT1_SO2_LbPerHr_1H			CT2_SO2_LbPerHr_1H			ALL_SO2_Lb_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/31/21 17:00	0.2247			0.24258			0.47											
12/31/21 18:00	0.24402			0.26364			0.51											
12/31/21 19:00	0.2721			0.29382			0.57											
12/31/21 20:00	0.2493			0.26952			0.52											
12/31/21 21:00	0.27204			0.29388			0.57											
12/31/21 22:00	0.23502			0.25386			0.49											
12/31/21 23:00	0.1836			0.19848			0.38											

AQ33 DAILY SOX

Date/Time	CT1_SO2_Lb_1D			CT2_SO2_Lb_1D														
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/01/21 0:00	5.4			5.7														
10/02/21 0:00	5.5			5.9														
10/03/21 0:00	5.4			5.6														
10/04/21 0:00	6.6			6.9														
10/05/21 0:00	5			5.3														
10/06/21 0:00	5.3			5.6														
10/07/21 0:00	5.3			5.5														
10/08/21 0:00	5.1			5.4														
10/09/21 0:00	4.9			5														
10/10/21 0:00	4.8			4.9														
10/11/21 0:00	6.1			6.6														
10/12/21 0:00	6.3			6.5														
10/13/21 0:00	6.5			6.7														
10/14/21 0:00	4.8			5.8														
10/15/21 0:00	0			7.2														
10/16/21 0:00	0			7.2														
10/17/21 0:00	0			7.4														
10/18/21 0:00	0			6.9														
10/19/21 0:00	0			6.7														
10/20/21 0:00	0.2			5.4														
10/21/21 0:00	6			6.3														
10/22/21 0:00	5.2			5.3														
10/23/21 0:00	5.5			5.6														
10/24/21 0:00	5.6			6														
10/25/21 0:00	5.4			5.6														
10/26/21 0:00	4.8			5.2														
10/27/21 0:00	5.4			5.5														
10/28/21 0:00	5.3			5.5														
10/29/21 0:00	5.2			5.3														
10/30/21 0:00	4.8			4.8														
10/31/21 0:00	4.8			4.8														
11/01/21 0:00	5.5			5.6														
11/02/21 0:00	5.3			5.5														
11/03/21 0:00	5.5			5.5														
11/04/21 0:00	5			5														

Date/Time	CT1_SO2_Lb_1D			CT2_SO2_Lb_1D														
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/05/21 0:00	4.9			5.2														
11/06/21 0:00	5.2			5.2														
11/07/21 0:00	4.8			4.9														
11/08/21 0:00	5.7			5.8														
11/09/21 0:00	5.1			5.2														
11/10/21 0:00	4.8			4.8														
11/11/21 0:00	5.3			5.4														
11/12/21 0:00	4.8			4.8														
11/13/21 0:00	5.3			5.5														
11/14/21 0:00	4.8			4.8														
11/15/21 0:00	4.8			4.8														
11/16/21 0:00	5.2			5.5														
11/17/21 0:00	5.4			5.6														
11/18/21 0:00	5.3			5.5														
11/19/21 0:00	3.3			5.1														
11/20/21 0:00	4.9			4.9														
11/21/21 0:00	5.3			5.3														
11/22/21 0:00	5.4			5.5														
11/23/21 0:00	4.8			4.8														
11/24/21 0:00	4.8			4.8														
11/25/21 0:00	4.8			4.8														
11/26/21 0:00	4.8			4.8														
11/27/21 0:00	4.8			4.8														
11/28/21 0:00	4.8			4.8														
11/29/21 0:00	4.9			5.1														
11/30/21 0:00	5.9			6.2														
12/01/21 0:00	5.2			5.3														
12/02/21 0:00	5.7			6.1														
12/03/21 0:00	5.6			5.7														
12/04/21 0:00	5.3			5.6														
12/05/21 0:00	5.6			5.7														
12/06/21 0:00	6.6			6.6														
12/07/21 0:00	6.4			6.6														
12/08/21 0:00	5.6			5.7														
12/09/21 0:00	4.9			5.2														
12/10/21 0:00	5.8			5.9														
12/11/21 0:00	5.4			5.5														
12/12/21 0:00	5.3			5.5														

Date/Time	CT1_SO2_Lb_1D			CT2_SO2_Lb_1D														
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/13/21 0:00	6.1			6.3														
12/14/21 0:00	5.4			5.5														
12/15/21 0:00	5.8			6														
12/16/21 0:00	6.4			6.6														
12/17/21 0:00	6			6.2														
12/18/21 0:00	5.8			6.3														
12/19/21 0:00	6			6.4														
12/20/21 0:00	6.6			7.2														
12/21/21 0:00	6.9			7.3														
12/22/21 0:00	6			6.1														
12/23/21 0:00	4.8			4.8														
12/24/21 0:00	4.8			4.8														
12/25/21 0:00	4.8			4.8														
12/26/21 0:00	5			5.1														
12/27/21 0:00	6.2			6.3														
12/28/21 0:00	5			5.4														
12/29/21 0:00	5.2			5.2														
12/30/21 0:00	5.8			5.9														
12/31/21 0:00	5			5.3														

Tons 12 Month Rolling Summary

CT1 and CT2 Combined



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:58 Location: Roseville, CA

* = Excess Emission

Date	Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2	
	CO, Ton		NOx, Ton		PM10, Ton		SO2, Ton		VOC, Ton	
	1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)	
	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum
Oct 2021	0.4854	5.2065	1.4017	10.1188	0.3030	2.0868	0.1514	1.0431	0.5047	3.4782
Nov 2021	0.3852	5.2713	1.2922	10.6823	0.2880	2.2353	0.1440	1.1173	0.4796	3.7254
Dec 2021	0.5686	5.7875	1.5683	12.2309	0.3450	2.5791	0.1722	1.2889	0.5749	4.2983
Sum/Avg	5.7875		12.2309		2.5791		1.2889		4.2983	
Limit Value										

AQ-34

AQ-34 the Project owner shall maintain the following records: occurrence, duration, and type of any startup, shutdown, or malfunction: performance testing, evaluations, calibrations, check, adjustments, any period during which a continuous monitoring system or monitoring device was inoperative, maintenance of any continuous emission monitor; emission measurements, total daily and rolling twelve month averages hours of operation, hourly quantity of fuel used and gross three hour average operating load.

Verification; The Project owner shall submit to the CPM all data identified in this condition as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/01/2021 00:00	3,073.8	0.0	3,073.8	104,900.0	322.4	0.39	0.2	0.6
10/01/2021 01:00	2,780.9	0.0	2,780.9	104,900.0	291.7	0.35	0.2	0.6
10/01/2021 02:00	2,719.2	0.0	2,719.2	104,900.0	285.2	0.34	0.2	0.6
10/01/2021 03:00	2,785.2	0.0	2,785.2	104,900.0	292.2	0.35	0.2	0.6
10/01/2021 04:00	3,576.4	0.0	3,576.4	104,900.0	375.2	0.45	0.2	0.7
10/01/2021 05:00	3,836.0	0.0	3,836.0	104,900.0	402.4	0.48	0.2	0.8
10/01/2021 06:00	3,158.9	0.0	3,158.9	104,900.0	331.4	0.40	0.2	0.7
10/01/2021 07:00	3,027.0	0.0	3,027.0	104,900.0	317.5	0.38	0.2	0.6
10/01/2021 08:00	2,691.6	0.0	2,691.6	104,900.0	282.3	0.34	0.2	0.6
10/01/2021 09:00	2,634.7	0.0	2,634.7	104,900.0	276.4	0.33	0.2	0.6
10/01/2021 10:00	2,775.2	0.0	2,775.2	104,900.0	291.1	0.35	0.2	0.6
10/01/2021 11:00	2,953.2	0.0	2,953.2	104,900.0	309.8	0.37	0.2	0.6
10/01/2021 12:00	3,553.0	0.0	3,553.0	104,900.0	372.7	0.45	0.2	0.7
10/01/2021 13:00	4,405.9	363.7	4,722.3	104,900.0	495.4	0.60	0.3	1.0
10/01/2021 14:00	4,234.8	43.0	4,249.0	104,900.0	445.7	0.54	0.3	0.9
10/01/2021 15:00	3,442.2	0.0	3,442.2	104,900.0	361.1	0.43	0.2	0.7
10/01/2021 16:00	3,971.4	0.0	3,971.4	104,900.0	416.6	0.50	0.2	0.8
10/01/2021 17:00	4,163.0	0.0	4,163.0	104,900.0	436.7	0.52	0.3	0.9
10/01/2021 18:00	3,955.2	0.0	3,955.2	104,900.0	414.9	0.50	0.2	0.8
10/01/2021 19:00	3,787.1	0.0	3,787.1	104,900.0	397.3	0.48	0.2	0.8
10/01/2021 20:00	4,216.7	0.0	4,216.7	104,900.0	442.3	0.53	0.3	0.9
10/01/2021 21:00	4,096.2	0.0	4,096.2	104,900.0	429.7	0.52	0.3	0.9
10/01/2021 22:00	3,145.3	0.0	3,145.3	104,900.0	329.9	0.39	0.2	0.7
10/01/2021 23:00	2,780.8	0.0	2,780.8	104,900.0	291.7	0.35	0.2	0.6
Average/Sum#:	3,406.8	16.9	3,420.6	104,900.0	358.8	0.43	0.2	0.7
Minimum:	2,634.7	0.0	2,634.7	104,900.0	276.4	0.33	0.2	0.6
Maximum:	4,405.9	363.7	4,722.3	104,900.0	495.4	0.60	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/02/2021 00:00	3,427.6	0.0	3,427.6	104,900.0	359.6	0.43	0.2	0.7
10/02/2021 01:00	3,032.5	0.0	3,032.5	104,900.0	318.1	0.38	0.2	0.6
10/02/2021 02:00	3,096.7	0.0	3,096.7	104,900.0	324.8	0.39	0.2	0.6
10/02/2021 03:00	3,007.9	0.0	3,007.9	104,900.0	315.5	0.38	0.2	0.6
10/02/2021 04:00	3,237.6	0.0	3,237.6	104,900.0	339.6	0.41	0.2	0.7
10/02/2021 05:00	2,995.0	0.0	2,995.0	104,900.0	314.2	0.38	0.2	0.6
10/02/2021 06:00	4,176.8	0.0	4,176.8	104,900.0	438.1	0.53	0.3	0.9
10/02/2021 07:00	3,380.2	0.0	3,380.2	104,900.0	354.6	0.43	0.2	0.7
10/02/2021 08:00	2,633.0	0.0	2,633.0	104,900.0	276.2	0.33	0.2	0.6
10/02/2021 09:00	2,627.5	0.0	2,627.5	104,900.0	275.6	0.33	0.2	0.6
10/02/2021 10:00	2,619.4	0.0	2,619.4	104,900.0	274.8	0.33	0.2	0.6
10/02/2021 11:00	2,701.0	0.0	2,701.0	104,900.0	283.3	0.34	0.2	0.6
10/02/2021 12:00	2,763.5	0.0	2,763.5	104,900.0	289.9	0.35	0.2	0.6
10/02/2021 13:00	3,737.7	0.0	3,737.7	104,900.0	392.1	0.47	0.2	0.8
10/02/2021 14:00	3,832.6	0.0	3,832.6	104,900.0	402.0	0.48	0.2	0.8
10/02/2021 15:00	3,476.3	0.0	3,476.3	104,900.0	364.7	0.44	0.2	0.7
10/02/2021 16:00	3,861.7	0.0	3,861.7	104,900.0	405.1	0.49	0.2	0.8
10/02/2021 17:00	4,267.9	0.0	4,267.9	104,900.0	447.7	0.54	0.3	0.9
10/02/2021 18:00	4,310.4	0.0	4,310.4	104,900.0	452.2	0.54	0.3	0.9
10/02/2021 19:00	4,306.9	0.0	4,306.9	104,900.0	451.8	0.54	0.3	0.9
10/02/2021 20:00	4,308.9	0.0	4,308.9	104,900.0	452.0	0.54	0.3	0.9
10/02/2021 21:00	4,146.6	0.0	4,146.6	104,900.0	435.0	0.52	0.3	0.9
10/02/2021 22:00	4,017.7	0.0	4,017.7	104,900.0	421.5	0.51	0.3	0.8
10/02/2021 23:00	3,790.5	0.0	3,790.5	104,900.0	397.6	0.48	0.2	0.8
Average/Sum#:	3,489.8	0.0	3,489.8	104,900.0	366.1	0.44	0.2	0.7
Minimum:	2,619.4	0.0	2,619.4	104,900.0	274.8	0.33	0.2	0.6
Maximum:	4,310.4	0.0	4,310.4	104,900.0	452.2	0.54	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/03/2021 00:00	3,174.3	0.0	3,174.3	104,900.0	333.0	0.40	0.2	0.7
10/03/2021 01:00	2,727.1	0.0	2,727.1	104,900.0	286.1	0.34	0.2	0.6
10/03/2021 02:00	2,722.8	0.0	2,722.8	104,900.0	285.6	0.34	0.2	0.6
10/03/2021 03:00	2,738.6	0.0	2,738.6	104,900.0	287.3	0.35	0.2	0.6
10/03/2021 04:00	2,729.9	0.0	2,729.9	104,900.0	286.4	0.34	0.2	0.6
10/03/2021 05:00	2,734.7	0.0	2,734.7	104,900.0	286.9	0.34	0.2	0.6
10/03/2021 06:00	2,781.3	0.0	2,781.3	104,900.0	291.8	0.35	0.2	0.6
10/03/2021 07:00	2,643.5	0.0	2,643.5	104,900.0	277.3	0.33	0.2	0.6
10/03/2021 08:00	2,642.5	0.0	2,642.5	104,900.0	277.2	0.33	0.2	0.6
10/03/2021 09:00	2,622.4	0.0	2,622.4	104,900.0	275.1	0.33	0.2	0.6
10/03/2021 10:00	2,611.3	0.0	2,611.3	104,900.0	273.9	0.33	0.2	0.6
10/03/2021 11:00	2,665.3	0.0	2,665.3	104,900.0	279.6	0.33	0.2	0.6
10/03/2021 12:00	2,724.5	0.0	2,724.5	104,900.0	285.8	0.34	0.2	0.6
10/03/2021 13:00	2,974.5	0.0	2,974.5	104,900.0	312.0	0.37	0.2	0.6
10/03/2021 14:00	3,451.2	0.0	3,451.2	104,900.0	362.0	0.43	0.2	0.7
10/03/2021 15:00	3,792.0	0.0	3,792.0	104,900.0	397.8	0.48	0.2	0.8
10/03/2021 16:00	4,261.4	400.8	4,449.8	104,900.0	466.8	0.59	0.3	1.0
10/03/2021 17:00	4,363.7	317.7	4,681.4	104,900.0	491.1	0.59	0.3	1.0
10/03/2021 18:00	4,367.8	267.4	4,635.2	104,900.0	486.2	0.58	0.3	1.0
10/03/2021 19:00	4,400.3	199.7	4,600.0	104,900.0	482.5	0.58	0.3	1.0
10/03/2021 20:00	4,421.8	242.7	4,664.5	104,900.0	489.3	0.59	0.3	1.0
10/03/2021 21:00	4,426.9	261.9	4,688.8	104,900.0	491.9	0.59	0.3	1.0
10/03/2021 22:00	3,752.7	63.3	3,782.5	104,900.0	396.8	0.48	0.2	0.8
10/03/2021 23:00	2,958.8	0.0	2,958.8	104,900.0	310.4	0.37	0.2	0.6
Average/Sum#:	3,278.7	73.1	3,341.5	104,900.0	350.5	0.42	0.2	0.7
Minimum:	2,611.3	0.0	2,611.3	104,900.0	273.9	0.33	0.2	0.6
Maximum:	4,426.9	400.8	4,688.8	104,900.0	491.9	0.59	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/04/2021 00:00	2,789.9	0.0	2,789.9	104,900.0	292.7	0.35	0.2	0.6
10/04/2021 01:00	3,074.2	0.0	3,074.2	104,900.0	322.5	0.39	0.2	0.6
10/04/2021 02:00	2,879.1	0.0	2,879.1	104,900.0	302.0	0.36	0.2	0.6
10/04/2021 03:00	4,195.0	0.0	4,195.0	104,900.0	440.1	0.53	0.3	0.9
10/04/2021 04:00	4,107.9	0.0	4,107.9	104,900.0	430.9	0.52	0.3	0.9
10/04/2021 05:00	4,250.3	0.0	4,250.3	104,900.0	445.9	0.54	0.3	0.9
10/04/2021 06:00	4,283.7	0.0	4,283.7	104,900.0	449.4	0.54	0.3	0.9
10/04/2021 07:00	4,137.3	0.0	4,137.3	104,900.0	434.0	0.52	0.3	0.9
10/04/2021 08:00	4,296.3	0.0	4,296.3	104,900.0	450.7	0.54	0.3	0.9
10/04/2021 09:00	3,920.3	0.0	3,920.3	104,900.0	411.2	0.49	0.2	0.8
10/04/2021 10:00	4,156.6	0.0	4,156.6	104,900.0	436.0	0.52	0.3	0.9
10/04/2021 11:00	4,209.5	0.0	4,209.5	104,900.0	441.6	0.53	0.3	0.9
10/04/2021 12:00	4,316.7	0.0	4,316.7	104,900.0	452.8	0.54	0.3	0.9
10/04/2021 13:00	4,312.2	0.0	4,312.2	104,900.0	452.3	0.54	0.3	0.9
10/04/2021 14:00	4,326.3	0.0	4,326.3	104,900.0	453.8	0.54	0.3	0.9
10/04/2021 15:00	4,323.6	205.3	4,379.0	104,900.0	459.4	0.57	0.3	1.0
10/04/2021 16:00	4,355.3	1,167.3	5,522.6	104,900.0	579.3	0.70	0.3	1.2
10/04/2021 17:00	4,367.9	807.0	5,174.9	104,900.0	542.8	0.65	0.3	1.1
10/04/2021 18:00	4,372.0	606.6	4,978.6	104,900.0	522.3	0.63	0.3	1.0
10/04/2021 19:00	4,368.4	435.1	4,803.5	104,900.0	503.9	0.60	0.3	1.0
10/04/2021 20:00	4,379.2	245.1	4,624.3	104,900.0	485.1	0.58	0.3	1.0
10/04/2021 21:00	4,392.6	264.2	4,656.8	104,900.0	488.5	0.59	0.3	1.0
10/04/2021 22:00	3,721.1	74.4	3,756.1	104,900.0	394.0	0.48	0.2	0.8
10/04/2021 23:00	2,906.1	0.0	2,906.1	104,900.0	304.8	0.36	0.2	0.6
Average/Sum#:	4,018.4	158.5	4,169.1	104,900.0	437.3	0.53	0.3	0.9
Minimum:	2,789.9	0.0	2,789.9	104,900.0	292.7	0.35	0.2	0.6
Maximum:	4,392.6	1,167.3	5,522.6	104,900.0	579.3	0.70	0.3	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/05/2021 00:00	2,830.7	0.0	2,830.7	104,900.0	296.9	0.36	0.2	0.6
10/05/2021 01:00	2,970.1	0.0	2,970.1	104,900.0	311.6	0.37	0.2	0.6
10/05/2021 02:00	2,723.4	0.0	2,723.4	104,900.0	285.7	0.34	0.2	0.6
10/05/2021 03:00	2,799.9	0.0	2,799.9	104,900.0	293.7	0.35	0.2	0.6
10/05/2021 04:00	3,478.4	0.0	3,478.4	104,900.0	364.9	0.44	0.2	0.7
10/05/2021 05:00	3,251.7	0.0	3,251.7	104,900.0	341.1	0.41	0.2	0.7
10/05/2021 06:00	3,436.6	0.0	3,436.6	104,900.0	360.5	0.43	0.2	0.7
10/05/2021 07:00	3,837.1	0.0	3,837.1	104,900.0	402.5	0.48	0.2	0.8
10/05/2021 08:00	2,719.5	0.0	2,719.5	104,900.0	285.3	0.34	0.2	0.6
10/05/2021 09:00	2,850.7	0.0	2,850.7	104,900.0	299.0	0.36	0.2	0.6
10/05/2021 10:00	4,237.2	0.0	4,237.2	104,900.0	444.5	0.53	0.3	0.9
10/05/2021 11:00	2,802.0	0.0	2,802.0	104,900.0	293.9	0.35	0.2	0.6
10/05/2021 12:00	2,730.9	0.0	2,730.9	104,900.0	286.5	0.34	0.2	0.6
10/05/2021 13:00	2,882.9	0.0	2,882.9	104,900.0	302.4	0.36	0.2	0.6
10/05/2021 14:00	3,349.3	0.0	3,349.3	104,900.0	351.3	0.42	0.2	0.7
10/05/2021 15:00	3,416.5	0.0	3,416.5	104,900.0	358.4	0.43	0.2	0.7
10/05/2021 16:00	3,650.6	0.0	3,650.6	104,900.0	382.9	0.46	0.2	0.8
10/05/2021 17:00	3,535.2	0.0	3,535.2	104,900.0	370.8	0.45	0.2	0.7
10/05/2021 18:00	3,806.5	0.0	3,806.5	104,900.0	399.3	0.48	0.2	0.8
10/05/2021 19:00	3,013.4	0.0	3,013.4	104,900.0	316.1	0.38	0.2	0.6
10/05/2021 20:00	3,162.1	0.0	3,162.1	104,900.0	331.7	0.40	0.2	0.7
10/05/2021 21:00	3,625.3	0.0	3,625.3	104,900.0	380.3	0.46	0.2	0.8
10/05/2021 22:00	3,979.5	0.0	3,979.5	104,900.0	417.4	0.50	0.3	0.8
10/05/2021 23:00	3,963.7	0.0	3,963.7	104,900.0	415.8	0.50	0.2	0.8
Average/Sum#:	3,293.9	0.0	3,293.9	104,900.0	345.5	0.41	0.2	0.7
Minimum:	2,719.5	0.0	2,719.5	104,900.0	285.3	0.34	0.2	0.6
Maximum:	4,237.2	0.0	4,237.2	104,900.0	444.5	0.53	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/06/2021 00:00	2,758.5	0.0	2,758.5	104,900.0	289.4	0.35	0.2	0.6
10/06/2021 01:00	2,753.1	0.0	2,753.1	104,900.0	288.8	0.35	0.2	0.6
10/06/2021 02:00	2,743.9	0.0	2,743.9	104,900.0	287.8	0.35	0.2	0.6
10/06/2021 03:00	2,743.5	0.0	2,743.5	104,900.0	287.8	0.35	0.2	0.6
10/06/2021 04:00	2,750.2	0.0	2,750.2	104,900.0	288.5	0.35	0.2	0.6
10/06/2021 05:00	3,200.5	0.0	3,200.5	104,900.0	335.7	0.40	0.2	0.7
10/06/2021 06:00	3,540.2	0.0	3,540.2	104,900.0	371.4	0.45	0.2	0.7
10/06/2021 07:00	2,789.0	0.0	2,789.0	104,900.0	292.6	0.35	0.2	0.6
10/06/2021 08:00	3,169.1	0.0	3,169.1	104,900.0	332.4	0.40	0.2	0.7
10/06/2021 09:00	4,163.0	0.0	4,163.0	104,900.0	436.7	0.52	0.3	0.9
10/06/2021 10:00	3,599.5	0.0	3,599.5	104,900.0	377.6	0.45	0.2	0.8
10/06/2021 11:00	4,317.0	0.0	4,317.0	104,900.0	452.9	0.54	0.3	0.9
10/06/2021 12:00	4,337.8	0.0	4,337.8	104,900.0	455.0	0.55	0.3	0.9
10/06/2021 13:00	3,808.9	0.0	3,808.9	104,900.0	399.6	0.48	0.2	0.8
10/06/2021 14:00	4,353.7	0.0	4,353.7	104,900.0	456.7	0.55	0.3	0.9
10/06/2021 15:00	3,620.9	0.0	3,620.9	104,900.0	379.8	0.46	0.2	0.8
10/06/2021 16:00	3,921.7	0.0	3,921.7	104,900.0	411.4	0.49	0.2	0.8
10/06/2021 17:00	2,908.8	0.0	2,908.8	104,900.0	305.1	0.36	0.2	0.6
10/06/2021 18:00	3,138.7	0.0	3,138.7	104,900.0	329.2	0.40	0.2	0.7
10/06/2021 19:00	3,059.3	0.0	3,059.3	104,900.0	320.9	0.38	0.2	0.6
10/06/2021 20:00	3,958.7	0.0	3,958.7	104,900.0	415.3	0.50	0.2	0.8
10/06/2021 21:00	4,347.2	0.0	4,347.2	104,900.0	456.0	0.55	0.3	0.9
10/06/2021 22:00	3,552.5	0.0	3,552.5	104,900.0	372.7	0.45	0.2	0.7
10/06/2021 23:00	2,744.4	0.0	2,744.4	104,900.0	287.9	0.34	0.2	0.6
Average/Sum#:	3,428.3	0.0	3,428.3	104,900.0	359.6	0.43	0.2	0.7
Minimum:	2,743.5	0.0	2,743.5	104,900.0	287.8	0.34	0.2	0.6
Maximum:	4,353.7	0.0	4,353.7	104,900.0	456.7	0.55	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/07/2021 00:00	2,740.7	0.0	2,740.7	104,900.0	287.5	0.34	0.2	0.6
10/07/2021 01:00	2,741.6	0.0	2,741.6	104,900.0	287.6	0.35	0.2	0.6
10/07/2021 02:00	2,740.9	0.0	2,740.9	104,900.0	287.5	0.35	0.2	0.6
10/07/2021 03:00	3,430.9	0.0	3,430.9	104,900.0	359.9	0.43	0.2	0.7
10/07/2021 04:00	3,792.2	0.0	3,792.2	104,900.0	397.8	0.48	0.2	0.8
10/07/2021 05:00	4,194.4	0.0	4,194.4	104,900.0	440.0	0.53	0.3	0.9
10/07/2021 06:00	4,428.1	0.0	4,428.1	104,900.0	464.5	0.56	0.3	0.9
10/07/2021 07:00	4,321.1	0.0	4,321.1	104,900.0	453.3	0.55	0.3	0.9
10/07/2021 08:00	3,891.0	0.0	3,891.0	104,900.0	408.2	0.49	0.2	0.8
10/07/2021 09:00	4,339.8	0.0	4,339.8	104,900.0	455.2	0.55	0.3	0.9
10/07/2021 10:00	3,304.9	0.0	3,304.9	104,900.0	346.7	0.42	0.2	0.7
10/07/2021 11:00	3,007.3	0.0	3,007.3	104,900.0	315.5	0.38	0.2	0.6
10/07/2021 12:00	2,733.9	0.0	2,733.9	104,900.0	286.8	0.34	0.2	0.6
10/07/2021 13:00	2,723.1	0.0	2,723.1	104,900.0	285.7	0.34	0.2	0.6
10/07/2021 14:00	2,676.4	0.0	2,676.4	104,900.0	280.8	0.34	0.2	0.6
10/07/2021 15:00	2,735.1	0.0	2,735.1	104,900.0	286.9	0.34	0.2	0.6
10/07/2021 16:00	3,293.3	0.0	3,293.3	104,900.0	345.5	0.41	0.2	0.7
10/07/2021 17:00	4,324.3	0.0	4,324.3	104,900.0	453.6	0.55	0.3	0.9
10/07/2021 18:00	3,326.1	0.0	3,326.1	104,900.0	348.9	0.42	0.2	0.7
10/07/2021 19:00	2,760.2	0.0	2,760.2	104,900.0	289.5	0.35	0.2	0.6
10/07/2021 20:00	2,854.3	0.0	2,854.3	104,900.0	299.4	0.36	0.2	0.6
10/07/2021 21:00	2,754.8	0.0	2,754.8	104,900.0	289.0	0.35	0.2	0.6
10/07/2021 22:00	2,801.5	0.0	2,801.5	104,900.0	293.9	0.36	0.2	0.6
10/07/2021 23:00	3,490.4	0.0	3,490.4	104,900.0	366.1	0.44	0.2	0.7
Average/Sum#:	3,308.6	0.0	3,308.6	104,900.0	347.1	0.42	0.2	0.7
Minimum:	2,676.4	0.0	2,676.4	104,900.0	280.8	0.34	0.2	0.6
Maximum:	4,428.1	0.0	4,428.1	104,900.0	464.5	0.56	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/08/2021 00:00	2,751.9	0.0	2,751.9	104,900.0	288.7	0.35	0.2	0.6
10/08/2021 01:00	2,747.8	0.0	2,747.8	104,900.0	288.2	0.35	0.2	0.6
10/08/2021 02:00	2,739.5	0.0	2,739.5	104,900.0	287.4	0.35	0.2	0.6
10/08/2021 03:00	2,777.6	0.0	2,777.6	104,900.0	291.4	0.35	0.2	0.6
10/08/2021 04:00	2,904.7	0.0	2,904.7	104,900.0	304.7	0.37	0.2	0.6
10/08/2021 05:00	2,667.2	0.0	2,667.2	104,900.0	279.8	0.34	0.2	0.6
10/08/2021 06:00	2,881.0	0.0	2,881.0	104,900.0	302.2	0.36	0.2	0.6
10/08/2021 07:00	4,425.5	0.0	4,425.5	104,900.0	464.2	0.56	0.3	0.9
10/08/2021 08:00	3,393.0	0.0	3,393.0	104,900.0	355.9	0.43	0.2	0.7
10/08/2021 09:00	4,359.7	0.0	4,359.7	104,900.0	457.3	0.55	0.3	0.9
10/08/2021 10:00	2,846.0	0.0	2,846.0	104,900.0	298.5	0.36	0.2	0.6
10/08/2021 11:00	3,800.0	0.0	3,800.0	104,900.0	398.6	0.48	0.2	0.8
10/08/2021 12:00	3,691.9	0.0	3,691.9	104,900.0	387.3	0.46	0.2	0.8
10/08/2021 13:00	3,814.1	0.0	3,814.1	104,900.0	400.1	0.48	0.2	0.8
10/08/2021 14:00	4,351.6	0.0	4,351.6	104,900.0	456.5	0.55	0.3	0.9
10/08/2021 15:00	2,754.6	0.0	2,754.6	104,900.0	289.0	0.35	0.2	0.6
10/08/2021 16:00	3,233.2	0.0	3,233.2	104,900.0	339.2	0.41	0.2	0.7
10/08/2021 17:00	2,763.4	0.0	2,763.4	104,900.0	289.9	0.35	0.2	0.6
10/08/2021 18:00	2,719.7	0.0	2,719.7	104,900.0	285.3	0.34	0.2	0.6
10/08/2021 19:00	2,693.6	0.0	2,693.6	104,900.0	282.6	0.34	0.2	0.6
10/08/2021 20:00	2,714.9	0.0	2,714.9	104,900.0	284.8	0.34	0.2	0.6
10/08/2021 21:00	2,738.3	0.0	2,738.3	104,900.0	287.2	0.35	0.2	0.6
10/08/2021 22:00	2,788.0	0.0	2,788.0	104,900.0	292.5	0.35	0.2	0.6
10/08/2021 23:00	2,705.0	0.0	2,705.0	104,900.0	283.8	0.34	0.2	0.6
Average/Sum#:	3,135.9	0.0	3,135.9	104,900.0	329.0	0.40	0.2	0.7
Minimum:	2,667.2	0.0	2,667.2	104,900.0	279.8	0.34	0.2	0.6
Maximum:	4,425.5	0.0	4,425.5	104,900.0	464.2	0.56	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/09/2021 00:00	2,676.4	0.0	2,676.4	104,900.0	280.8	0.34	0.2	0.6
10/09/2021 01:00	2,623.6	0.0	2,623.6	104,900.0	275.2	0.33	0.2	0.6
10/09/2021 02:00	2,635.3	0.0	2,635.3	104,900.0	276.4	0.33	0.2	0.6
10/09/2021 03:00	2,627.0	0.0	2,627.0	104,900.0	275.6	0.33	0.2	0.6
10/09/2021 04:00	2,758.9	0.0	2,758.9	104,900.0	289.4	0.35	0.2	0.6
10/09/2021 05:00	3,277.2	0.0	3,277.2	104,900.0	343.8	0.41	0.2	0.7
10/09/2021 06:00	3,254.1	0.0	3,254.1	104,900.0	341.4	0.41	0.2	0.7
10/09/2021 07:00	3,812.6	0.0	3,812.6	104,900.0	399.9	0.48	0.2	0.8
10/09/2021 08:00	3,110.5	0.0	3,110.5	104,900.0	326.3	0.39	0.2	0.7
10/09/2021 09:00	2,675.1	0.0	2,675.1	104,900.0	280.6	0.34	0.2	0.6
10/09/2021 10:00	2,637.3	0.0	2,637.3	104,900.0	276.7	0.33	0.2	0.6
10/09/2021 11:00	2,636.6	0.0	2,636.6	104,900.0	276.6	0.33	0.2	0.6
10/09/2021 12:00	2,637.1	0.0	2,637.1	104,900.0	276.6	0.33	0.2	0.6
10/09/2021 13:00	2,634.8	0.0	2,634.8	104,900.0	276.4	0.33	0.2	0.6
10/09/2021 14:00	2,634.2	0.0	2,634.2	104,900.0	276.3	0.33	0.2	0.6
10/09/2021 15:00	2,722.1	0.0	2,722.1	104,900.0	285.5	0.34	0.2	0.6
10/09/2021 16:00	3,378.2	0.0	3,378.2	104,900.0	354.4	0.43	0.2	0.7
10/09/2021 17:00	4,021.2	0.0	4,021.2	104,900.0	421.8	0.51	0.3	0.8
10/09/2021 18:00	2,949.5	0.0	2,949.5	104,900.0	309.4	0.37	0.2	0.6
10/09/2021 19:00	2,717.5	0.0	2,717.5	104,900.0	285.1	0.34	0.2	0.6
10/09/2021 20:00	2,668.9	0.0	2,668.9	104,900.0	280.0	0.34	0.2	0.6
10/09/2021 21:00	2,730.4	0.0	2,730.4	104,900.0	286.4	0.35	0.2	0.6
10/09/2021 22:00	2,720.5	0.0	2,720.5	104,900.0	285.4	0.34	0.2	0.6
10/09/2021 23:00	2,747.8	0.0	2,747.8	104,900.0	288.2	0.35	0.2	0.6
Average/Sum#:	2,887.0	0.0	2,887.0	104,900.0	302.8	0.36	0.2	0.6
Minimum:	2,623.6	0.0	2,623.6	104,900.0	275.2	0.33	0.2	0.6
Maximum:	4,021.2	0.0	4,021.2	104,900.0	421.8	0.51	0.3	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/10/2021 00:00	2,751.2	0.0	2,751.2	104,900.0	288.6	0.35	0.2	0.6
10/10/2021 01:00	2,738.8	0.0	2,738.8	104,900.0	287.3	0.35	0.2	0.6
10/10/2021 02:00	2,799.4	0.0	2,799.4	104,900.0	293.7	0.35	0.2	0.6
10/10/2021 03:00	2,772.3	0.0	2,772.3	104,900.0	290.8	0.35	0.2	0.6
10/10/2021 04:00	2,774.3	0.0	2,774.3	104,900.0	291.0	0.35	0.2	0.6
10/10/2021 05:00	3,496.4	0.0	3,496.4	104,900.0	366.8	0.44	0.2	0.7
10/10/2021 06:00	3,721.1	0.0	3,721.1	104,900.0	390.3	0.47	0.2	0.8
10/10/2021 07:00	3,424.2	0.0	3,424.2	104,900.0	359.2	0.43	0.2	0.7
10/10/2021 08:00	2,715.1	0.0	2,715.1	104,900.0	284.8	0.34	0.2	0.6
10/10/2021 09:00	2,638.4	0.0	2,638.4	104,900.0	276.8	0.33	0.2	0.6
10/10/2021 10:00	2,676.0	0.0	2,676.0	104,900.0	280.7	0.34	0.2	0.6
10/10/2021 11:00	2,646.6	0.0	2,646.6	104,900.0	277.6	0.33	0.2	0.6
10/10/2021 12:00	2,645.7	0.0	2,645.7	104,900.0	277.5	0.33	0.2	0.6
10/10/2021 13:00	2,654.3	0.0	2,654.3	104,900.0	278.4	0.33	0.2	0.6
10/10/2021 14:00	2,682.0	0.0	2,682.0	104,900.0	281.3	0.34	0.2	0.6
10/10/2021 15:00	2,892.6	0.0	2,892.6	104,900.0	303.4	0.36	0.2	0.6
10/10/2021 16:00	3,468.2	0.0	3,468.2	104,900.0	363.8	0.43	0.2	0.7
10/10/2021 17:00	2,873.0	0.0	2,873.0	104,900.0	301.4	0.36	0.2	0.6
10/10/2021 18:00	2,666.8	0.0	2,666.8	104,900.0	279.7	0.33	0.2	0.6
10/10/2021 19:00	2,900.3	0.0	2,900.3	104,900.0	304.2	0.37	0.2	0.6
10/10/2021 20:00	3,400.7	0.0	3,400.7	104,900.0	356.7	0.43	0.2	0.7
10/10/2021 21:00	2,726.1	0.0	2,726.1	104,900.0	286.0	0.34	0.2	0.6
10/10/2021 22:00	2,673.0	0.0	2,673.0	104,900.0	280.4	0.34	0.2	0.6
10/10/2021 23:00	2,642.1	0.0	2,642.1	104,900.0	277.2	0.33	0.2	0.6
Average/Sum#:	2,890.8	0.0	2,890.8	104,900.0	303.2	0.36	0.2	0.6
Minimum:	2,638.4	0.0	2,638.4	104,900.0	276.8	0.33	0.2	0.6
Maximum:	3,721.1	0.0	3,721.1	104,900.0	390.3	0.47	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/11/2021 00:00	2,776.3	0.0	2,776.3	104,900.0	291.2	0.35	0.2	0.6
10/11/2021 01:00	2,635.4	0.0	2,635.4	104,900.0	276.5	0.33	0.2	0.6
10/11/2021 02:00	2,706.6	0.0	2,706.6	104,900.0	283.9	0.34	0.2	0.6
10/11/2021 03:00	2,760.0	0.0	2,760.0	104,900.0	289.5	0.35	0.2	0.6
10/11/2021 04:00	3,871.5	0.0	3,871.5	104,900.0	406.1	0.49	0.2	0.8
10/11/2021 05:00	3,840.5	0.0	3,840.5	104,900.0	402.9	0.48	0.2	0.8
10/11/2021 06:00	4,143.9	0.0	4,143.9	104,900.0	434.7	0.52	0.3	0.9
10/11/2021 07:00	4,359.1	0.0	4,359.1	104,900.0	457.3	0.55	0.3	0.9
10/11/2021 08:00	4,595.7	971.5	5,343.8	104,900.0	560.6	0.70	0.4	1.2
10/11/2021 09:00	4,584.5	613.7	5,106.1	104,900.0	535.6	0.65	0.3	1.1
10/11/2021 10:00	4,576.8	1,014.6	5,591.4	104,900.0	586.5	0.70	0.4	1.2
10/11/2021 11:00	4,561.2	210.0	4,729.2	104,900.0	496.1	0.60	0.3	1.0
10/11/2021 12:00	4,564.8	536.5	5,101.3	104,900.0	535.1	0.64	0.3	1.1
10/11/2021 13:00	4,559.6	588.4	5,148.0	104,900.0	540.0	0.65	0.3	1.1
10/11/2021 14:00	4,559.1	457.0	5,016.1	104,900.0	526.2	0.63	0.3	1.1
10/11/2021 15:00	3,991.1	59.2	4,005.9	104,900.0	420.2	0.51	0.3	0.9
10/11/2021 16:00	4,263.9	0.0	4,263.9	104,900.0	447.3	0.54	0.3	0.9
10/11/2021 17:00	4,212.4	0.0	4,212.4	104,900.0	441.9	0.53	0.3	0.9
10/11/2021 18:00	3,277.1	0.0	3,277.1	104,900.0	343.8	0.41	0.2	0.7
10/11/2021 19:00	2,907.1	0.0	2,907.1	104,900.0	305.0	0.37	0.2	0.6
10/11/2021 20:00	3,755.2	0.0	3,755.2	104,900.0	393.9	0.47	0.2	0.8
10/11/2021 21:00	3,251.5	0.0	3,251.5	104,900.0	341.1	0.41	0.2	0.7
10/11/2021 22:00	2,950.9	0.0	2,950.9	104,900.0	309.5	0.37	0.2	0.6
10/11/2021 23:00	2,906.6	0.0	2,906.6	104,900.0	304.9	0.37	0.2	0.6
Average/Sum#:	3,775.5	185.5	3,944.2	104,900.0	413.7	0.50	0.3	0.8
Minimum:	2,635.4	0.0	2,635.4	104,900.0	276.5	0.33	0.2	0.6
Maximum:	4,595.7	1,014.6	5,591.4	104,900.0	586.5	0.70	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/12/2021 00:00	2,772.5	0.0	2,772.5	104,900.0	290.8	0.35	0.2	0.6
10/12/2021 01:00	2,725.8	0.0	2,725.8	104,900.0	285.9	0.34	0.2	0.6
10/12/2021 02:00	2,691.8	0.0	2,691.8	104,900.0	282.4	0.34	0.2	0.6
10/12/2021 03:00	2,695.7	0.0	2,695.7	104,900.0	282.8	0.34	0.2	0.6
10/12/2021 04:00	2,699.6	0.0	2,699.6	104,900.0	283.2	0.34	0.2	0.6
10/12/2021 05:00	3,649.8	0.0	3,649.8	104,900.0	382.9	0.46	0.2	0.8
10/12/2021 06:00	4,466.4	0.0	4,466.4	104,900.0	468.5	0.56	0.3	0.9
10/12/2021 07:00	4,400.7	0.0	4,400.7	104,900.0	461.6	0.56	0.3	0.9
10/12/2021 08:00	4,434.4	0.0	4,434.4	104,900.0	465.2	0.56	0.3	0.9
10/12/2021 09:00	4,438.8	0.0	4,438.8	104,900.0	465.6	0.56	0.3	0.9
10/12/2021 10:00	4,445.8	0.0	4,445.8	104,900.0	466.4	0.56	0.3	0.9
10/12/2021 11:00	4,443.5	0.0	4,443.5	104,900.0	466.1	0.56	0.3	0.9
10/12/2021 12:00	4,338.6	0.0	4,338.6	104,900.0	455.1	0.55	0.3	0.9
10/12/2021 13:00	3,308.6	0.0	3,308.6	104,900.0	347.1	0.42	0.2	0.7
10/12/2021 14:00	4,393.8	0.0	4,393.8	104,900.0	460.9	0.55	0.3	0.9
10/12/2021 15:00	4,381.1	0.0	4,381.1	104,900.0	459.6	0.55	0.3	0.9
10/12/2021 16:00	4,124.0	0.0	4,124.0	104,900.0	432.6	0.52	0.3	0.9
10/12/2021 17:00	4,310.3	0.0	4,310.3	104,900.0	452.2	0.54	0.3	0.9
10/12/2021 18:00	4,357.6	0.0	4,357.6	104,900.0	457.1	0.55	0.3	0.9
10/12/2021 19:00	3,934.1	0.0	3,934.1	104,900.0	412.7	0.50	0.2	0.8
10/12/2021 20:00	4,060.9	0.0	4,060.9	104,900.0	426.0	0.51	0.3	0.9
10/12/2021 21:00	4,258.4	0.0	4,258.4	104,900.0	446.7	0.54	0.3	0.9
10/12/2021 22:00	4,364.9	0.0	4,364.9	104,900.0	457.9	0.55	0.3	0.9
10/12/2021 23:00	3,717.6	0.0	3,717.6	104,900.0	390.0	0.47	0.2	0.8
Average/Sum#:	3,892.3	0.0	3,892.3	104,900.0	408.3	0.49	0.3	0.8
Minimum:	2,691.8	0.0	2,691.8	104,900.0	282.4	0.34	0.2	0.6
Maximum:	4,466.4	0.0	4,466.4	104,900.0	468.5	0.56	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/13/2021 00:00	4,413.4	0.0	4,413.4	104,900.0	463.0	0.56	0.3	0.9
10/13/2021 01:00	2,997.9	0.0	2,997.9	104,900.0	314.5	0.38	0.2	0.6
10/13/2021 02:00	2,771.4	0.0	2,771.4	104,900.0	290.7	0.35	0.2	0.6
10/13/2021 03:00	3,368.5	0.0	3,368.5	104,900.0	353.4	0.42	0.2	0.7
10/13/2021 04:00	4,413.2	0.0	4,413.2	104,900.0	462.9	0.56	0.3	0.9
10/13/2021 05:00	4,177.0	0.0	4,177.0	104,900.0	438.2	0.53	0.3	0.9
10/13/2021 06:00	4,084.7	0.0	4,084.7	104,900.0	428.5	0.51	0.3	0.9
10/13/2021 07:00	4,415.5	0.0	4,415.5	104,900.0	463.2	0.56	0.3	0.9
10/13/2021 08:00	4,423.3	0.0	4,423.3	104,900.0	464.0	0.56	0.3	0.9
10/13/2021 09:00	4,428.8	0.0	4,428.8	104,900.0	464.6	0.56	0.3	0.9
10/13/2021 10:00	4,407.8	0.0	4,407.8	104,900.0	462.4	0.56	0.3	0.9
10/13/2021 11:00	4,424.5	0.0	4,424.5	104,900.0	464.1	0.56	0.3	0.9
10/13/2021 12:00	4,415.5	0.0	4,415.5	104,900.0	463.2	0.56	0.3	0.9
10/13/2021 13:00	4,423.8	0.0	4,423.8	104,900.0	464.1	0.56	0.3	0.9
10/13/2021 14:00	4,338.6	0.0	4,338.6	104,900.0	455.1	0.55	0.3	0.9
10/13/2021 15:00	3,899.4	0.0	3,899.4	104,900.0	409.0	0.49	0.2	0.8
10/13/2021 16:00	3,284.1	0.0	3,284.1	104,900.0	344.5	0.41	0.2	0.7
10/13/2021 17:00	4,365.4	0.0	4,365.4	104,900.0	457.9	0.55	0.3	0.9
10/13/2021 18:00	3,999.8	0.0	3,999.8	104,900.0	419.6	0.50	0.3	0.8
10/13/2021 19:00	3,750.7	0.0	3,750.7	104,900.0	393.4	0.47	0.2	0.8
10/13/2021 20:00	4,104.0	0.0	4,104.0	104,900.0	430.5	0.52	0.3	0.9
10/13/2021 21:00	4,005.0	0.0	4,005.0	104,900.0	420.1	0.50	0.3	0.8
10/13/2021 22:00	4,160.8	0.0	4,160.8	104,900.0	436.5	0.52	0.3	0.9
10/13/2021 23:00	2,684.8	0.0	2,684.8	104,900.0	281.6	0.34	0.2	0.6
Average/Sum#:	3,989.9	0.0	3,989.9	104,900.0	418.5	0.50	0.3	0.8
Minimum:	2,684.8	0.0	2,684.8	104,900.0	281.6	0.34	0.2	0.6
Maximum:	4,428.8	0.0	4,428.8	104,900.0	464.6	0.56	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/14/2021 00:00	2,746.4	0.0	2,746.4	104,900.0	288.1	0.35	0.2	0.6
10/14/2021 01:00	2,714.0	0.0	2,714.0	104,900.0	284.7	0.34	0.2	0.6
10/14/2021 02:00	2,755.0	0.0	2,755.0	104,900.0	289.0	0.35	0.2	0.6
10/14/2021 03:00	2,761.1	0.0	2,761.1	104,900.0	289.6	0.35	0.2	0.6
10/14/2021 04:00	2,737.9	0.0	2,737.9	104,900.0	287.2	0.35	0.2	0.6
10/14/2021 05:00	4,090.1	0.0	4,090.1	104,900.0	429.1	0.52	0.3	0.9
10/14/2021 06:00	4,421.9	0.0	4,421.9	104,900.0	463.9	0.56	0.3	0.9
10/14/2021 07:00	3,290.0	0.0	3,290.0	104,900.0	345.1	0.41	0.2	0.7
10/14/2021 08:00	2,733.1	0.0	2,733.1	104,900.0	286.7	0.35	0.2	0.6
10/14/2021 09:00	2,733.1	0.0	2,733.1	104,900.0	286.7	0.34	0.2	0.6
10/14/2021 10:00	2,659.9	0.0	2,659.9	104,900.0	279.0	0.33	0.2	0.6
10/14/2021 11:00	2,673.1	0.0	2,673.1	104,900.0	280.4	0.34	0.2	0.6
10/14/2021 12:00	2,678.6	0.0	2,678.6	104,900.0	281.0	0.34	0.2	0.6
10/14/2021 13:00	2,750.2	0.0	2,750.2	104,900.0	288.5	0.35	0.2	0.6
10/14/2021 14:00	2,767.0	0.0	2,767.0	104,900.0	290.3	0.35	0.2	0.6
10/14/2021 15:00	2,938.8	0.0	2,938.8	104,900.0	308.3	0.37	0.2	0.6
10/14/2021 16:00	3,531.1	0.0	3,531.1	104,900.0	370.4	0.44	0.2	0.7
10/14/2021 17:00	4,361.8	0.0	4,361.8	104,900.0	457.6	0.55	0.3	0.9
10/14/2021 18:00	4,120.9	0.0	4,120.9	104,900.0	432.3	0.52	0.3	0.9
10/14/2021 19:00	4,443.7	0.0	4,443.7	104,900.0	466.1	0.56	0.3	0.9
10/14/2021 20:00	4,427.0	0.0	4,427.0	104,900.0	464.4	0.56	0.3	0.9
10/14/2021 21:00	2,624.4	0.0	2,624.4	104,900.0	275.3	0.00	0.0	0.0
10/14/2021 22:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/14/2021 23:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
Average/Sum#:	3,225.4	0.0	3,225.4	104,900.0	338.4	0.41	0.2	0.7
Minimum:	2,624.4	0.0	2,624.4	104,900.0	275.3	0.33	0.2	0.6
Maximum:	4,443.7	0.0	4,443.7	104,900.0	466.1	0.56	0.3	0.9
%SI	8.33	8.33	8.33	0.00	8.33	12.50	12.50	12.50

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/15/2021 00:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/15/2021 01:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/15/2021 02:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/15/2021 03:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/15/2021 04:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/15/2021 05:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/15/2021 06:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/15/2021 07:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/15/2021 08:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/15/2021 09:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/15/2021 10:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/15/2021 11:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/15/2021 12:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/15/2021 13:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/15/2021 14:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/15/2021 15:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/15/2021 16:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/15/2021 17:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/15/2021 18:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/15/2021 19:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/15/2021 20:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/15/2021 21:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/15/2021 22:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/15/2021 23:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/16/2021 00:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/16/2021 01:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/16/2021 02:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/16/2021 03:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/16/2021 04:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/16/2021 05:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/16/2021 06:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/16/2021 07:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/16/2021 08:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/16/2021 09:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/16/2021 10:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/16/2021 11:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/16/2021 12:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/16/2021 13:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/16/2021 14:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/16/2021 15:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/16/2021 16:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/16/2021 17:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/16/2021 18:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/16/2021 19:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/16/2021 20:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/16/2021 21:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/16/2021 22:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/16/2021 23:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/17/2021 00:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/17/2021 01:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/17/2021 02:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/17/2021 03:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/17/2021 04:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/17/2021 05:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/17/2021 06:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/17/2021 07:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/17/2021 08:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/17/2021 09:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/17/2021 10:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/17/2021 11:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/17/2021 12:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/17/2021 13:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/17/2021 14:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/17/2021 15:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/17/2021 16:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/17/2021 17:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/17/2021 18:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/17/2021 19:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/17/2021 20:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/17/2021 21:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/17/2021 22:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/17/2021 23:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/18/2021 00:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/18/2021 01:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/18/2021 02:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/18/2021 03:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/18/2021 04:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/18/2021 05:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/18/2021 06:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/18/2021 07:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/18/2021 08:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/18/2021 09:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/18/2021 10:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/18/2021 11:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/18/2021 12:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/18/2021 13:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/18/2021 14:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/18/2021 15:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/18/2021 16:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/18/2021 17:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/18/2021 18:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/18/2021 19:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/18/2021 20:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/18/2021 21:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/18/2021 22:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/18/2021 23:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	> 4.73 Unit CT1 PM10_Norm, LbPerHr	> 1 Unit CT1 SO2_Norm, LbPerHr	> 1.8 Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/19/2021 00:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/19/2021 01:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/19/2021 02:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/19/2021 03:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/19/2021 04:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/19/2021 05:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/19/2021 06:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/19/2021 07:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/19/2021 08:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/19/2021 09:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/19/2021 10:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/19/2021 11:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/19/2021 12:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/19/2021 13:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/19/2021 14:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/19/2021 15:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/19/2021 16:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/19/2021 17:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/19/2021 18:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/19/2021 19:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/19/2021 20:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/19/2021 21:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/19/2021 22:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/19/2021 23:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/20/2021 00:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/20/2021 01:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/20/2021 02:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/20/2021 03:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/20/2021 04:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/20/2021 05:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/20/2021 06:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/20/2021 07:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/20/2021 08:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/20/2021 09:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/20/2021 10:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/20/2021 11:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/20/2021 12:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/20/2021 13:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/20/2021 14:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/20/2021 15:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/20/2021 16:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/20/2021 17:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/20/2021 18:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/20/2021 19:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/20/2021 20:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/20/2021 21:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
10/20/2021 22:00	929.0	0.0	929.0	104,900.0	97.5	0.00	0.0	0.0
10/20/2021 23:00	2,931.1	0.0	2,931.1	104,900.0	307.5	0.35	0.2	0.6
Average/Sum#:	1,930.1	0.0	1,930.1	104,900.0	202.5	0.35	0.2	0.6
Minimum:	929.0	0.0	929.0	104,900.0	97.5	0.35	0.2	0.6
Maximum:	2,931.1	0.0	2,931.1	104,900.0	307.5	0.35	0.2	0.6
%SI	91.67	91.67	91.67	0.00	91.67	95.83	95.83	95.83

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/21/2021 00:00	2,804.1	0.0	2,804.1	104,900.0	294.2	0.35	0.2	0.6
10/21/2021 01:00	2,771.2	0.0	2,771.2	104,900.0	290.7	0.35	0.2	0.6
10/21/2021 02:00	2,775.4	0.0	2,775.4	104,900.0	291.1	0.35	0.2	0.6
10/21/2021 03:00	3,303.0	0.0	3,303.0	104,900.0	346.5	0.42	0.2	0.7
10/21/2021 04:00	3,478.4	0.0	3,478.4	104,900.0	364.9	0.44	0.2	0.7
10/21/2021 05:00	3,971.7	0.0	3,971.7	104,900.0	416.6	0.50	0.2	0.8
10/21/2021 06:00	4,020.0	0.0	4,020.0	104,900.0	421.7	0.50	0.3	0.8
10/21/2021 07:00	3,922.0	0.0	3,922.0	104,900.0	411.4	0.49	0.2	0.8
10/21/2021 08:00	4,264.5	0.0	4,264.5	104,900.0	447.3	0.54	0.3	0.9
10/21/2021 09:00	4,495.5	0.0	4,495.5	104,900.0	471.6	0.57	0.3	0.9
10/21/2021 10:00	4,470.3	0.0	4,470.3	104,900.0	468.9	0.56	0.3	0.9
10/21/2021 11:00	3,938.5	0.0	3,938.5	104,900.0	413.1	0.50	0.2	0.8
10/21/2021 12:00	2,824.0	0.0	2,824.0	104,900.0	296.2	0.35	0.2	0.6
10/21/2021 13:00	4,076.4	0.0	4,076.4	104,900.0	427.6	0.51	0.3	0.9
10/21/2021 14:00	3,781.7	0.0	3,781.7	104,900.0	396.7	0.48	0.2	0.8
10/21/2021 15:00	3,168.2	0.0	3,168.2	104,900.0	332.3	0.40	0.2	0.7
10/21/2021 16:00	4,170.9	0.0	4,170.9	104,900.0	437.5	0.52	0.3	0.9
10/21/2021 17:00	4,442.1	0.0	4,442.1	104,900.0	466.0	0.56	0.3	0.9
10/21/2021 18:00	4,414.8	0.0	4,414.8	104,900.0	463.1	0.56	0.3	0.9
10/21/2021 19:00	4,449.2	0.0	4,449.2	104,900.0	466.7	0.56	0.3	0.9
10/21/2021 20:00	4,395.7	0.0	4,395.7	104,900.0	461.1	0.55	0.3	0.9
10/21/2021 21:00	3,996.4	0.0	3,996.4	104,900.0	419.2	0.50	0.3	0.8
10/21/2021 22:00	2,871.7	0.0	2,871.7	104,900.0	301.2	0.36	0.2	0.6
10/21/2021 23:00	2,640.6	0.0	2,640.6	104,900.0	277.0	0.33	0.2	0.6
Average/Sum#:	3,726.9	0.0	3,726.9	104,900.0	390.9	0.47	0.2	0.8
Minimum:	2,640.6	0.0	2,640.6	104,900.0	277.0	0.33	0.2	0.6
Maximum:	4,495.5	0.0	4,495.5	104,900.0	471.6	0.57	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/22/2021 00:00	2,637.9	0.0	2,637.9	104,900.0	276.7	0.33	0.2	0.6
10/22/2021 01:00	2,639.3	0.0	2,639.3	104,900.0	276.9	0.33	0.2	0.6
10/22/2021 02:00	2,640.0	0.0	2,640.0	104,900.0	276.9	0.33	0.2	0.6
10/22/2021 03:00	2,738.8	0.0	2,738.8	104,900.0	287.3	0.35	0.2	0.6
10/22/2021 04:00	2,755.3	0.0	2,755.3	104,900.0	289.0	0.35	0.2	0.6
10/22/2021 05:00	2,731.2	0.0	2,731.2	104,900.0	286.5	0.35	0.2	0.6
10/22/2021 06:00	2,724.7	0.0	2,724.7	104,900.0	285.8	0.34	0.2	0.6
10/22/2021 07:00	3,422.9	0.0	3,422.9	104,900.0	359.1	0.43	0.2	0.7
10/22/2021 08:00	4,336.9	0.0	4,336.9	104,900.0	454.9	0.54	0.3	0.9
10/22/2021 09:00	4,292.8	0.0	4,292.8	104,900.0	450.3	0.54	0.3	0.9
10/22/2021 10:00	4,461.5	0.0	4,461.5	104,900.0	468.0	0.56	0.3	0.9
10/22/2021 11:00	4,398.4	0.0	4,398.4	104,900.0	461.4	0.55	0.3	0.9
10/22/2021 12:00	3,222.9	0.0	3,222.9	104,900.0	338.1	0.41	0.2	0.7
10/22/2021 13:00	3,092.3	0.0	3,092.3	104,900.0	324.4	0.39	0.2	0.7
10/22/2021 14:00	3,087.9	0.0	3,087.9	104,900.0	323.9	0.39	0.2	0.7
10/22/2021 15:00	3,087.3	0.0	3,087.3	104,900.0	323.9	0.39	0.2	0.7
10/22/2021 16:00	3,424.1	0.0	3,424.1	104,900.0	359.2	0.43	0.2	0.7
10/22/2021 17:00	3,888.3	0.0	3,888.3	104,900.0	407.9	0.49	0.2	0.8
10/22/2021 18:00	2,672.9	0.0	2,672.9	104,900.0	280.4	0.34	0.2	0.6
10/22/2021 19:00	2,827.9	0.0	2,827.9	104,900.0	296.6	0.36	0.2	0.6
10/22/2021 20:00	2,770.1	0.0	2,770.1	104,900.0	290.6	0.35	0.2	0.6
10/22/2021 21:00	2,713.4	0.0	2,713.4	104,900.0	284.6	0.34	0.2	0.6
10/22/2021 22:00	2,713.1	0.0	2,713.1	104,900.0	284.6	0.34	0.2	0.6
10/22/2021 23:00	3,005.2	0.0	3,005.2	104,900.0	315.2	0.38	0.2	0.6
Average/Sum#:	3,178.5	0.0	3,178.5	104,900.0	333.4	0.40	0.2	0.7
Minimum:	2,637.9	0.0	2,637.9	104,900.0	276.7	0.33	0.2	0.6
Maximum:	4,461.5	0.0	4,461.5	104,900.0	468.0	0.56	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/23/2021 00:00	3,051.5	0.0	3,051.5	104,900.0	320.1	0.38	0.2	0.6
10/23/2021 01:00	2,647.6	0.0	2,647.6	104,900.0	277.7	0.33	0.2	0.6
10/23/2021 02:00	2,738.9	0.0	2,738.9	104,900.0	287.3	0.34	0.2	0.6
10/23/2021 03:00	2,751.3	0.0	2,751.3	104,900.0	288.6	0.35	0.2	0.6
10/23/2021 04:00	2,776.1	0.0	2,776.1	104,900.0	291.2	0.35	0.2	0.6
10/23/2021 05:00	3,299.7	0.0	3,299.7	104,900.0	346.1	0.42	0.2	0.7
10/23/2021 06:00	3,628.6	0.0	3,628.6	104,900.0	380.6	0.46	0.2	0.8
10/23/2021 07:00	3,385.8	0.0	3,385.8	104,900.0	355.2	0.43	0.2	0.7
10/23/2021 08:00	4,209.3	0.0	4,209.3	104,900.0	441.6	0.53	0.3	0.9
10/23/2021 09:00	3,705.1	0.0	3,705.1	104,900.0	388.7	0.47	0.2	0.8
10/23/2021 10:00	3,010.7	0.0	3,010.7	104,900.0	315.8	0.38	0.2	0.6
10/23/2021 11:00	3,003.3	0.0	3,003.3	104,900.0	315.0	0.38	0.2	0.6
10/23/2021 12:00	4,376.4	0.0	4,376.4	104,900.0	459.1	0.55	0.3	0.9
10/23/2021 13:00	3,476.9	0.0	3,476.9	104,900.0	364.7	0.44	0.2	0.7
10/23/2021 14:00	4,451.5	0.0	4,451.5	104,900.0	467.0	0.56	0.3	0.9
10/23/2021 15:00	4,327.8	0.0	4,327.8	104,900.0	454.0	0.55	0.3	0.9
10/23/2021 16:00	4,451.8	0.0	4,451.8	104,900.0	467.0	0.56	0.3	0.9
10/23/2021 17:00	4,427.3	0.0	4,427.3	104,900.0	464.4	0.56	0.3	0.9
10/23/2021 18:00	2,830.7	0.0	2,830.7	104,900.0	296.9	0.36	0.2	0.6
10/23/2021 19:00	2,939.7	0.0	2,939.7	104,900.0	308.4	0.37	0.2	0.6
10/23/2021 20:00	2,773.4	0.0	2,773.4	104,900.0	290.9	0.35	0.2	0.6
10/23/2021 21:00	2,777.9	0.0	2,777.9	104,900.0	291.4	0.35	0.2	0.6
10/23/2021 22:00	2,935.6	0.0	2,935.6	104,900.0	307.9	0.37	0.2	0.6
10/23/2021 23:00	4,302.0	0.0	4,302.0	104,900.0	451.3	0.54	0.3	0.9
Average/Sum#:	3,428.3	0.0	3,428.3	104,900.0	359.6	0.43	0.2	0.7
Minimum:	2,647.6	0.0	2,647.6	104,900.0	277.7	0.33	0.2	0.6
Maximum:	4,451.8	0.0	4,451.8	104,900.0	467.0	0.56	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/24/2021 00:00	3,737.1	0.0	3,737.1	104,900.0	392.0	0.47	0.2	0.8
10/24/2021 01:00	2,684.9	0.0	2,684.9	104,900.0	281.6	0.34	0.2	0.6
10/24/2021 02:00	2,666.1	0.0	2,666.1	104,900.0	279.7	0.33	0.2	0.6
10/24/2021 03:00	2,667.9	0.0	2,667.9	104,900.0	279.9	0.33	0.2	0.6
10/24/2021 04:00	2,632.7	0.0	2,632.7	104,900.0	276.2	0.33	0.2	0.6
10/24/2021 05:00	2,721.7	0.0	2,721.7	104,900.0	285.5	0.34	0.2	0.6
10/24/2021 06:00	2,712.4	0.0	2,712.4	104,900.0	284.5	0.34	0.2	0.6
10/24/2021 07:00	3,759.8	0.0	3,759.8	104,900.0	394.4	0.47	0.2	0.8
10/24/2021 08:00	4,430.0	0.0	4,430.0	104,900.0	464.7	0.56	0.3	0.9
10/24/2021 09:00	4,442.4	0.0	4,442.4	104,900.0	466.0	0.56	0.3	0.9
10/24/2021 10:00	4,337.1	0.0	4,337.1	104,900.0	455.0	0.55	0.3	0.9
10/24/2021 11:00	4,447.9	0.0	4,447.9	104,900.0	466.6	0.56	0.3	0.9
10/24/2021 12:00	4,336.9	0.0	4,336.9	104,900.0	454.9	0.55	0.3	0.9
10/24/2021 13:00	4,429.8	0.0	4,429.8	104,900.0	464.7	0.56	0.3	0.9
10/24/2021 14:00	3,459.5	0.0	3,459.5	104,900.0	362.9	0.44	0.2	0.7
10/24/2021 15:00	4,042.9	0.0	4,042.9	104,900.0	424.1	0.51	0.3	0.8
10/24/2021 16:00	3,807.4	0.0	3,807.4	104,900.0	399.4	0.48	0.2	0.8
10/24/2021 17:00	4,265.8	0.0	4,265.8	104,900.0	447.5	0.54	0.3	0.9
10/24/2021 18:00	3,390.5	0.0	3,390.5	104,900.0	355.7	0.43	0.2	0.7
10/24/2021 19:00	3,800.8	0.0	3,800.8	104,900.0	398.7	0.48	0.2	0.8
10/24/2021 20:00	2,964.0	0.0	2,964.0	104,900.0	310.9	0.37	0.2	0.6
10/24/2021 21:00	3,085.5	0.0	3,085.5	104,900.0	323.7	0.39	0.2	0.6
10/24/2021 22:00	2,819.1	0.0	2,819.1	104,900.0	295.7	0.35	0.2	0.6
10/24/2021 23:00	2,794.8	0.0	2,794.8	104,900.0	293.2	0.35	0.2	0.6
Average/Sum#:	3,518.2	0.0	3,518.2	104,900.0	369.1	0.44	0.2	0.7
Minimum:	2,632.7	0.0	2,632.7	104,900.0	276.2	0.33	0.2	0.6
Maximum:	4,447.9	0.0	4,447.9	104,900.0	466.6	0.56	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/25/2021 00:00	3,119.5	0.0	3,119.5	104,900.0	327.2	0.39	0.2	0.7
10/25/2021 01:00	2,832.1	0.0	2,832.1	104,900.0	297.1	0.35	0.2	0.6
10/25/2021 02:00	2,797.2	0.0	2,797.2	104,900.0	293.4	0.35	0.2	0.6
10/25/2021 03:00	2,828.1	0.0	2,828.1	104,900.0	296.7	0.36	0.2	0.6
10/25/2021 04:00	4,128.6	0.0	4,128.6	104,900.0	433.1	0.52	0.3	0.9
10/25/2021 05:00	4,332.3	0.0	4,332.3	104,900.0	454.5	0.54	0.3	0.9
10/25/2021 06:00	4,129.0	0.0	4,129.0	104,900.0	433.1	0.52	0.3	0.9
10/25/2021 07:00	4,049.1	0.0	4,049.1	104,900.0	424.8	0.51	0.3	0.9
10/25/2021 08:00	4,299.1	0.0	4,299.1	104,900.0	451.0	0.54	0.3	0.9
10/25/2021 09:00	3,351.7	0.0	3,351.7	104,900.0	351.6	0.42	0.2	0.7
10/25/2021 10:00	2,684.7	0.0	2,684.7	104,900.0	281.6	0.34	0.2	0.6
10/25/2021 11:00	2,648.5	0.0	2,648.5	104,900.0	277.8	0.33	0.2	0.6
10/25/2021 12:00	2,656.2	0.0	2,656.2	104,900.0	278.6	0.33	0.2	0.6
10/25/2021 13:00	2,690.2	0.0	2,690.2	104,900.0	282.2	0.34	0.2	0.6
10/25/2021 14:00	2,682.2	0.0	2,682.2	104,900.0	281.4	0.34	0.2	0.6
10/25/2021 15:00	2,653.3	0.0	2,653.3	104,900.0	278.3	0.33	0.2	0.6
10/25/2021 16:00	3,715.3	0.0	3,715.3	104,900.0	389.7	0.47	0.2	0.8
10/25/2021 17:00	3,542.9	0.0	3,542.9	104,900.0	371.7	0.45	0.2	0.7
10/25/2021 18:00	3,463.2	0.0	3,463.2	104,900.0	363.3	0.44	0.2	0.7
10/25/2021 19:00	3,940.3	0.0	3,940.3	104,900.0	413.3	0.50	0.2	0.8
10/25/2021 20:00	4,300.7	0.0	4,300.7	104,900.0	451.1	0.54	0.3	0.9
10/25/2021 21:00	2,888.7	0.0	2,888.7	104,900.0	303.0	0.36	0.2	0.6
10/25/2021 22:00	2,675.2	0.0	2,675.2	104,900.0	280.6	0.34	0.2	0.6
10/25/2021 23:00	2,740.0	0.0	2,740.0	104,900.0	287.4	0.35	0.2	0.6
Average/Sum#:	3,297.8	0.0	3,297.8	104,900.0	345.9	0.42	0.2	0.7
Minimum:	2,648.5	0.0	2,648.5	104,900.0	277.8	0.33	0.2	0.6
Maximum:	4,332.3	0.0	4,332.3	104,900.0	454.5	0.54	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/26/2021 00:00	2,666.2	0.0	2,666.2	104,900.0	279.7	0.34	0.2	0.6
10/26/2021 01:00	2,696.4	0.0	2,696.4	104,900.0	282.9	0.34	0.2	0.6
10/26/2021 02:00	2,701.3	0.0	2,701.3	104,900.0	283.4	0.34	0.2	0.6
10/26/2021 03:00	2,751.9	0.0	2,751.9	104,900.0	288.7	0.35	0.2	0.6
10/26/2021 04:00	2,683.7	0.0	2,683.7	104,900.0	281.5	0.34	0.2	0.6
10/26/2021 05:00	3,732.2	0.0	3,732.2	104,900.0	391.5	0.47	0.2	0.8
10/26/2021 06:00	2,879.9	0.0	2,879.9	104,900.0	302.1	0.36	0.2	0.6
10/26/2021 07:00	3,184.3	0.0	3,184.3	104,900.0	334.0	0.40	0.2	0.7
10/26/2021 08:00	2,775.7	0.0	2,775.7	104,900.0	291.2	0.35	0.2	0.6
10/26/2021 09:00	2,766.7	0.0	2,766.7	104,900.0	290.2	0.35	0.2	0.6
10/26/2021 10:00	2,766.2	0.0	2,766.2	104,900.0	290.2	0.35	0.2	0.6
10/26/2021 11:00	2,883.2	0.0	2,883.2	104,900.0	302.4	0.36	0.2	0.6
10/26/2021 12:00	2,765.5	0.0	2,765.5	104,900.0	290.1	0.35	0.2	0.6
10/26/2021 13:00	2,719.8	0.0	2,719.8	104,900.0	285.3	0.34	0.2	0.6
10/26/2021 14:00	2,940.8	0.0	2,940.8	104,900.0	308.5	0.37	0.2	0.6
10/26/2021 15:00	2,738.3	0.0	2,738.3	104,900.0	287.2	0.34	0.2	0.6
10/26/2021 16:00	3,054.4	0.0	3,054.4	104,900.0	320.4	0.38	0.2	0.6
10/26/2021 17:00	2,812.7	0.0	2,812.7	104,900.0	295.1	0.35	0.2	0.6
10/26/2021 18:00	3,558.1	0.0	3,558.1	104,900.0	373.2	0.45	0.2	0.7
10/26/2021 19:00	3,614.2	0.0	3,614.2	104,900.0	379.1	0.46	0.2	0.8
10/26/2021 20:00	3,859.8	0.0	3,859.8	104,900.0	404.9	0.49	0.2	0.8
10/26/2021 21:00	3,801.7	0.0	3,801.7	104,900.0	398.8	0.48	0.2	0.8
10/26/2021 22:00	3,930.5	0.0	3,930.5	104,900.0	412.3	0.50	0.2	0.8
10/26/2021 23:00	2,786.3	0.0	2,786.3	104,900.0	292.3	0.35	0.2	0.6
Average/Sum#:	3,044.6	0.0	3,044.6	104,900.0	319.4	0.38	0.2	0.7
Minimum:	2,666.2	0.0	2,666.2	104,900.0	279.7	0.34	0.2	0.6
Maximum:	3,930.5	0.0	3,930.5	104,900.0	412.3	0.50	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/27/2021 00:00	2,778.3	0.0	2,778.3	104,900.0	291.4	0.35	0.2	0.6
10/27/2021 01:00	2,699.7	0.0	2,699.7	104,900.0	283.2	0.34	0.2	0.6
10/27/2021 02:00	2,668.8	0.0	2,668.8	104,900.0	280.0	0.34	0.2	0.6
10/27/2021 03:00	2,716.4	0.0	2,716.4	104,900.0	285.0	0.34	0.2	0.6
10/27/2021 04:00	2,742.4	0.0	2,742.4	104,900.0	287.7	0.35	0.2	0.6
10/27/2021 05:00	3,244.6	0.0	3,244.6	104,900.0	340.4	0.41	0.2	0.7
10/27/2021 06:00	4,091.4	0.0	4,091.4	104,900.0	429.2	0.51	0.3	0.9
10/27/2021 07:00	2,967.6	0.0	2,967.6	104,900.0	311.3	0.37	0.2	0.6
10/27/2021 08:00	2,645.4	0.0	2,645.4	104,900.0	277.5	0.33	0.2	0.6
10/27/2021 09:00	2,647.4	0.0	2,647.4	104,900.0	277.7	0.33	0.2	0.6
10/27/2021 10:00	2,644.5	0.0	2,644.5	104,900.0	277.4	0.33	0.2	0.6
10/27/2021 11:00	2,644.9	0.0	2,644.9	104,900.0	277.5	0.33	0.2	0.6
10/27/2021 12:00	2,643.6	0.0	2,643.6	104,900.0	277.3	0.33	0.2	0.6
10/27/2021 13:00	2,653.6	0.0	2,653.6	104,900.0	278.4	0.33	0.2	0.6
10/27/2021 14:00	2,647.5	0.0	2,647.5	104,900.0	277.7	0.33	0.2	0.6
10/27/2021 15:00	2,909.1	0.0	2,909.1	104,900.0	305.2	0.37	0.2	0.6
10/27/2021 16:00	4,094.1	0.0	4,094.1	104,900.0	429.5	0.52	0.3	0.9
10/27/2021 17:00	4,441.7	0.0	4,441.7	104,900.0	465.9	0.56	0.3	0.9
10/27/2021 18:00	4,096.0	0.0	4,096.0	104,900.0	429.7	0.52	0.3	0.9
10/27/2021 19:00	4,273.3	0.0	4,273.3	104,900.0	448.3	0.54	0.3	0.9
10/27/2021 20:00	3,926.4	0.0	3,926.4	104,900.0	411.9	0.50	0.2	0.8
10/27/2021 21:00	4,010.2	0.0	4,010.2	104,900.0	420.7	0.51	0.3	0.8
10/27/2021 22:00	2,937.4	0.0	2,937.4	104,900.0	308.1	0.37	0.2	0.6
10/27/2021 23:00	2,786.6	0.0	2,786.6	104,900.0	292.3	0.35	0.2	0.6
Average/Sum#:	3,163.0	0.0	3,163.0	104,900.0	331.8	0.40	0.2	0.7
Minimum:	2,643.6	0.0	2,643.6	104,900.0	277.3	0.33	0.2	0.6
Maximum:	4,441.7	0.0	4,441.7	104,900.0	465.9	0.56	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/28/2021 00:00	2,783.0	0.0	2,783.0	104,900.0	291.9	0.35	0.2	0.6
10/28/2021 01:00	2,777.6	0.0	2,777.6	104,900.0	291.4	0.35	0.2	0.6
10/28/2021 02:00	2,779.2	0.0	2,779.2	104,900.0	291.5	0.35	0.2	0.6
10/28/2021 03:00	2,780.8	0.0	2,780.8	104,900.0	291.7	0.35	0.2	0.6
10/28/2021 04:00	3,038.4	0.0	3,038.4	104,900.0	318.7	0.38	0.2	0.6
10/28/2021 05:00	3,638.6	0.0	3,638.6	104,900.0	381.7	0.46	0.2	0.8
10/28/2021 06:00	3,713.4	0.0	3,713.4	104,900.0	389.5	0.47	0.2	0.8
10/28/2021 07:00	2,749.6	0.0	2,749.6	104,900.0	288.4	0.35	0.2	0.6
10/28/2021 08:00	2,665.4	0.0	2,665.4	104,900.0	279.6	0.33	0.2	0.6
10/28/2021 09:00	2,647.1	0.0	2,647.1	104,900.0	277.7	0.33	0.2	0.6
10/28/2021 10:00	2,710.3	0.0	2,710.3	104,900.0	284.3	0.34	0.2	0.6
10/28/2021 11:00	2,752.0	0.0	2,752.0	104,900.0	288.7	0.35	0.2	0.6
10/28/2021 12:00	2,765.0	0.0	2,765.0	104,900.0	290.0	0.35	0.2	0.6
10/28/2021 13:00	2,644.1	0.0	2,644.1	104,900.0	277.4	0.33	0.2	0.6
10/28/2021 14:00	2,663.6	0.0	2,663.6	104,900.0	279.4	0.33	0.2	0.6
10/28/2021 15:00	2,698.7	0.0	2,698.7	104,900.0	283.1	0.34	0.2	0.6
10/28/2021 16:00	3,982.7	0.0	3,982.7	104,900.0	417.8	0.50	0.3	0.8
10/28/2021 17:00	4,443.0	0.0	4,443.0	104,900.0	466.1	0.56	0.3	0.9
10/28/2021 18:00	4,216.3	0.0	4,216.3	104,900.0	442.3	0.53	0.3	0.9
10/28/2021 19:00	4,369.8	0.0	4,369.8	104,900.0	458.4	0.55	0.3	0.9
10/28/2021 20:00	4,192.1	0.0	4,192.1	104,900.0	439.8	0.53	0.3	0.9
10/28/2021 21:00	3,718.7	0.0	3,718.7	104,900.0	390.1	0.47	0.2	0.8
10/28/2021 22:00	2,772.1	0.0	2,772.1	104,900.0	290.8	0.35	0.2	0.6
10/28/2021 23:00	2,730.0	0.0	2,730.0	104,900.0	286.4	0.34	0.2	0.6
Average/Sum#:	3,176.3	0.0	3,176.3	104,900.0	333.2	0.40	0.2	0.7
Minimum:	2,644.1	0.0	2,644.1	104,900.0	277.4	0.33	0.2	0.6
Maximum:	4,443.0	0.0	4,443.0	104,900.0	466.1	0.56	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/29/2021 00:00	2,703.3	0.0	2,703.3	104,900.0	283.6	0.34	0.2	0.6
10/29/2021 01:00	2,696.0	0.0	2,696.0	104,900.0	282.8	0.34	0.2	0.6
10/29/2021 02:00	2,660.1	0.0	2,660.1	104,900.0	279.0	0.34	0.2	0.6
10/29/2021 03:00	2,779.8	0.0	2,779.8	104,900.0	291.6	0.35	0.2	0.6
10/29/2021 04:00	2,778.1	0.0	2,778.1	104,900.0	291.4	0.35	0.2	0.6
10/29/2021 05:00	3,349.2	0.0	3,349.2	104,900.0	351.3	0.42	0.2	0.7
10/29/2021 06:00	3,656.6	0.0	3,656.6	104,900.0	383.6	0.46	0.2	0.8
10/29/2021 07:00	2,701.0	0.0	2,701.0	104,900.0	283.3	0.34	0.2	0.6
10/29/2021 08:00	2,641.3	0.0	2,641.3	104,900.0	277.1	0.33	0.2	0.6
10/29/2021 09:00	2,642.4	0.0	2,642.4	104,900.0	277.2	0.33	0.2	0.6
10/29/2021 10:00	2,663.0	0.0	2,663.0	104,900.0	279.3	0.34	0.2	0.6
10/29/2021 11:00	2,647.4	0.0	2,647.4	104,900.0	277.7	0.33	0.2	0.6
10/29/2021 12:00	2,644.3	0.0	2,644.3	104,900.0	277.4	0.33	0.2	0.6
10/29/2021 13:00	2,686.1	0.0	2,686.1	104,900.0	281.8	0.34	0.2	0.6
10/29/2021 14:00	2,646.5	0.0	2,646.5	104,900.0	277.6	0.33	0.2	0.6
10/29/2021 15:00	3,306.9	0.0	3,306.9	104,900.0	346.9	0.42	0.2	0.7
10/29/2021 16:00	4,236.9	0.0	4,236.9	104,900.0	444.5	0.54	0.3	0.9
10/29/2021 17:00	4,321.9	0.0	4,321.9	104,900.0	453.4	0.55	0.3	0.9
10/29/2021 18:00	3,707.6	0.0	3,707.6	104,900.0	388.9	0.47	0.2	0.8
10/29/2021 19:00	4,335.4	0.0	4,335.4	104,900.0	454.8	0.55	0.3	0.9
10/29/2021 20:00	4,124.2	0.0	4,124.2	104,900.0	432.6	0.52	0.3	0.9
10/29/2021 21:00	3,680.9	0.0	3,680.9	104,900.0	386.1	0.46	0.2	0.8
10/29/2021 22:00	3,583.4	0.0	3,583.4	104,900.0	375.9	0.45	0.2	0.8
10/29/2021 23:00	3,190.6	0.0	3,190.6	104,900.0	334.7	0.40	0.2	0.7
Average/Sum#:	3,182.6	0.0	3,182.6	104,900.0	333.9	0.40	0.2	0.7
Minimum:	2,641.3	0.0	2,641.3	104,900.0	277.1	0.33	0.2	0.6
Maximum:	4,335.4	0.0	4,335.4	104,900.0	454.8	0.55	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/30/2021 00:00	3,007.6	0.0	3,007.6	104,900.0	315.5	0.38	0.2	0.6
10/30/2021 01:00	2,730.6	0.0	2,730.6	104,900.0	286.4	0.35	0.2	0.6
10/30/2021 02:00	2,667.9	0.0	2,667.9	104,900.0	279.9	0.34	0.2	0.6
10/30/2021 03:00	2,743.7	0.0	2,743.7	104,900.0	287.8	0.35	0.2	0.6
10/30/2021 04:00	2,737.3	0.0	2,737.3	104,900.0	287.1	0.35	0.2	0.6
10/30/2021 05:00	3,072.3	0.0	3,072.3	104,900.0	322.3	0.39	0.2	0.6
10/30/2021 06:00	2,707.2	0.0	2,707.2	104,900.0	284.0	0.34	0.2	0.6
10/30/2021 07:00	2,662.8	0.0	2,662.8	104,900.0	279.3	0.33	0.2	0.6
10/30/2021 08:00	2,644.6	0.0	2,644.6	104,900.0	277.4	0.33	0.2	0.6
10/30/2021 09:00	2,636.4	0.0	2,636.4	104,900.0	276.6	0.33	0.2	0.6
10/30/2021 10:00	2,641.5	0.0	2,641.5	104,900.0	277.1	0.33	0.2	0.6
10/30/2021 11:00	2,643.6	0.0	2,643.6	104,900.0	277.3	0.33	0.2	0.6
10/30/2021 12:00	2,642.6	0.0	2,642.6	104,900.0	277.2	0.33	0.2	0.6
10/30/2021 13:00	2,643.2	0.0	2,643.2	104,900.0	277.3	0.33	0.2	0.6
10/30/2021 14:00	2,641.1	0.0	2,641.1	104,900.0	277.1	0.33	0.2	0.6
10/30/2021 15:00	3,245.4	0.0	3,245.4	104,900.0	340.4	0.41	0.2	0.7
10/30/2021 16:00	2,921.7	0.0	2,921.7	104,900.0	306.5	0.37	0.2	0.6
10/30/2021 17:00	2,789.0	0.0	2,789.0	104,900.0	292.6	0.35	0.2	0.6
10/30/2021 18:00	2,653.6	0.0	2,653.6	104,900.0	278.4	0.33	0.2	0.6
10/30/2021 19:00	2,722.9	0.0	2,722.9	104,900.0	285.6	0.34	0.2	0.6
10/30/2021 20:00	2,688.5	0.0	2,688.5	104,900.0	282.0	0.34	0.2	0.6
10/30/2021 21:00	2,674.7	0.0	2,674.7	104,900.0	280.6	0.34	0.2	0.6
10/30/2021 22:00	2,667.3	0.0	2,667.3	104,900.0	279.8	0.34	0.2	0.6
10/30/2021 23:00	2,738.4	0.0	2,738.4	104,900.0	287.3	0.34	0.2	0.6
Average/Sum#:	2,746.8	0.0	2,746.8	104,900.0	288.1	0.35	0.2	0.6
Minimum:	2,636.4	0.0	2,636.4	104,900.0	276.6	0.33	0.2	0.6
Maximum:	3,245.4	0.0	3,245.4	104,900.0	340.4	0.41	0.2	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/31/2021 00:00	2,682.6	0.0	2,682.6	104,900.0	281.4	0.34	0.2	0.6
10/31/2021 01:00	2,684.1	0.0	2,684.1	104,900.0	281.6	0.34	0.2	0.6
10/31/2021 02:00	2,681.4	0.0	2,681.4	104,900.0	281.3	0.34	0.2	0.6
10/31/2021 03:00	2,683.2	0.0	2,683.2	104,900.0	281.5	0.34	0.2	0.6
10/31/2021 04:00	2,680.6	0.0	2,680.6	104,900.0	281.2	0.34	0.2	0.6
10/31/2021 05:00	2,766.0	0.0	2,766.0	104,900.0	290.2	0.35	0.2	0.6
10/31/2021 06:00	2,906.8	0.0	2,906.8	104,900.0	304.9	0.37	0.2	0.6
10/31/2021 07:00	2,688.9	0.0	2,688.9	104,900.0	282.1	0.34	0.2	0.6
10/31/2021 08:00	2,676.7	0.0	2,676.7	104,900.0	280.8	0.34	0.2	0.6
10/31/2021 09:00	2,702.9	0.0	2,702.9	104,900.0	283.5	0.34	0.2	0.6
10/31/2021 10:00	2,641.1	0.0	2,641.1	104,900.0	277.1	0.33	0.2	0.6
10/31/2021 11:00	2,637.2	0.0	2,637.2	104,900.0	276.6	0.33	0.2	0.6
10/31/2021 12:00	2,640.1	0.0	2,640.1	104,900.0	276.9	0.33	0.2	0.6
10/31/2021 13:00	2,644.6	0.0	2,644.6	104,900.0	277.4	0.33	0.2	0.6
10/31/2021 14:00	2,642.0	0.0	2,642.0	104,900.0	277.1	0.33	0.2	0.6
10/31/2021 15:00	2,879.1	0.0	2,879.1	104,900.0	302.0	0.36	0.2	0.6
10/31/2021 16:00	2,648.9	0.0	2,648.9	104,900.0	277.9	0.33	0.2	0.6
10/31/2021 17:00	2,639.2	0.0	2,639.2	104,900.0	276.9	0.33	0.2	0.6
10/31/2021 18:00	2,637.8	0.0	2,637.8	104,900.0	276.7	0.33	0.2	0.6
10/31/2021 19:00	2,628.7	0.0	2,628.7	104,900.0	275.8	0.33	0.2	0.6
10/31/2021 20:00	2,628.4	0.0	2,628.4	104,900.0	275.7	0.33	0.2	0.6
10/31/2021 21:00	2,631.7	0.0	2,631.7	104,900.0	276.1	0.33	0.2	0.6
10/31/2021 22:00	2,643.3	0.0	2,643.3	104,900.0	277.3	0.33	0.2	0.6
10/31/2021 23:00	2,678.8	0.0	2,678.8	104,900.0	281.0	0.34	0.2	0.6
Average/Sum#:	2,682.3	0.0	2,682.3	104,900.0	281.4	0.34	0.2	0.6
Minimum:	2,628.4	0.0	2,628.4	104,900.0	275.7	0.33	0.2	0.6
Maximum:	2,906.8	0.0	2,906.8	104,900.0	304.9	0.37	0.2	0.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/01/2021 00:00	2,661.1	0.0	2,661.1	104,700.0	278.6	0.34	0.2	0.6
11/01/2021 01:00	2,707.4	0.0	2,707.4	104,700.0	283.5	0.34	0.2	0.6
11/01/2021 02:00	2,649.6	0.0	2,649.6	104,700.0	277.4	0.33	0.2	0.6
11/01/2021 03:00	2,748.5	0.0	2,748.5	104,700.0	287.8	0.35	0.2	0.6
11/01/2021 04:00	3,151.8	0.0	3,151.8	104,700.0	330.0	0.40	0.2	0.7
11/01/2021 05:00	2,727.3	0.0	2,727.3	104,700.0	285.5	0.34	0.2	0.6
11/01/2021 06:00	4,138.6	0.0	4,138.6	104,700.0	433.3	0.52	0.3	0.9
11/01/2021 07:00	3,262.0	0.0	3,262.0	104,700.0	341.5	0.41	0.2	0.7
11/01/2021 08:00	2,748.1	0.0	2,748.1	104,700.0	287.7	0.34	0.2	0.6
11/01/2021 09:00	3,391.8	0.0	3,391.8	104,700.0	355.1	0.43	0.2	0.7
11/01/2021 10:00	2,920.2	0.0	2,920.2	104,700.0	305.7	0.37	0.2	0.6
11/01/2021 11:00	3,432.3	0.0	3,432.3	104,700.0	359.4	0.43	0.2	0.7
11/01/2021 12:00	3,674.4	0.0	3,674.4	104,700.0	384.7	0.46	0.2	0.8
11/01/2021 13:00	4,429.0	0.0	4,429.0	104,700.0	463.7	0.56	0.3	0.9
11/01/2021 14:00	3,807.9	0.0	3,807.9	104,700.0	398.7	0.48	0.2	0.8
11/01/2021 15:00	3,034.5	0.0	3,034.5	104,700.0	317.7	0.38	0.2	0.6
11/01/2021 16:00	3,352.4	0.0	3,352.4	104,700.0	351.0	0.42	0.2	0.7
11/01/2021 17:00	4,242.8	0.0	4,242.8	104,700.0	444.2	0.53	0.3	0.9
11/01/2021 18:00	4,130.9	0.0	4,130.9	104,700.0	432.5	0.52	0.3	0.9
11/01/2021 19:00	4,301.4	0.0	4,301.4	104,700.0	450.4	0.54	0.3	0.9
11/01/2021 20:00	4,324.4	0.0	4,324.4	104,700.0	452.8	0.54	0.3	0.9
11/01/2021 21:00	4,177.1	0.0	4,177.1	104,700.0	437.3	0.53	0.3	0.9
11/01/2021 22:00	3,445.8	0.0	3,445.8	104,700.0	360.8	0.43	0.2	0.7
11/01/2021 23:00	2,809.6	0.0	2,809.6	104,700.0	294.2	0.35	0.2	0.6
Average/Sum#:	3,427.9	0.0	3,427.9	104,700.0	358.9	0.43	0.2	0.7
Minimum:	2,649.6	0.0	2,649.6	104,700.0	277.4	0.33	0.2	0.6
Maximum:	4,429.0	0.0	4,429.0	104,700.0	463.7	0.56	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/02/2021 00:00	2,800.9	0.0	2,800.9	104,700.0	293.3	0.35	0.2	0.6
11/02/2021 01:00	2,764.8	0.0	2,764.8	104,700.0	289.5	0.35	0.2	0.6
11/02/2021 02:00	2,670.6	0.0	2,670.6	104,700.0	279.6	0.33	0.2	0.6
11/02/2021 03:00	2,743.5	0.0	2,743.5	104,700.0	287.2	0.35	0.2	0.6
11/02/2021 04:00	2,744.7	0.0	2,744.7	104,700.0	287.4	0.35	0.2	0.6
11/02/2021 05:00	2,896.0	0.0	2,896.0	104,700.0	303.2	0.37	0.2	0.6
11/02/2021 06:00	3,768.6	0.0	3,768.6	104,700.0	394.6	0.47	0.2	0.8
11/02/2021 07:00	2,938.4	0.0	2,938.4	104,700.0	307.7	0.37	0.2	0.6
11/02/2021 08:00	2,639.1	0.0	2,639.1	104,700.0	276.3	0.33	0.2	0.6
11/02/2021 09:00	2,673.4	0.0	2,673.4	104,700.0	279.9	0.34	0.2	0.6
11/02/2021 10:00	2,684.5	0.0	2,684.5	104,700.0	281.1	0.34	0.2	0.6
11/02/2021 11:00	2,691.5	0.0	2,691.5	104,700.0	281.8	0.34	0.2	0.6
11/02/2021 12:00	2,695.4	0.0	2,695.4	104,700.0	282.2	0.34	0.2	0.6
11/02/2021 13:00	2,637.5	0.0	2,637.5	104,700.0	276.1	0.33	0.2	0.6
11/02/2021 14:00	2,640.0	0.0	2,640.0	104,700.0	276.4	0.33	0.2	0.6
11/02/2021 15:00	2,687.0	0.0	2,687.0	104,700.0	281.3	0.34	0.2	0.6
11/02/2021 16:00	3,600.9	0.0	3,600.9	104,700.0	377.0	0.45	0.2	0.8
11/02/2021 17:00	4,274.6	0.0	4,274.6	104,700.0	447.6	0.54	0.3	0.9
11/02/2021 18:00	4,081.3	0.0	4,081.3	104,700.0	427.3	0.51	0.3	0.9
11/02/2021 19:00	4,441.6	0.0	4,441.6	104,700.0	465.0	0.56	0.3	0.9
11/02/2021 20:00	4,375.4	0.0	4,375.4	104,700.0	458.1	0.55	0.3	0.9
11/02/2021 21:00	3,950.9	0.0	3,950.9	104,700.0	413.7	0.50	0.2	0.8
11/02/2021 22:00	4,137.9	0.0	4,137.9	104,700.0	433.2	0.52	0.3	0.9
11/02/2021 23:00	3,511.3	0.0	3,511.3	104,700.0	367.6	0.44	0.2	0.7
Average/Sum#:	3,210.4	0.0	3,210.4	104,700.0	336.1	0.40	0.2	0.7
Minimum:	2,637.5	0.0	2,637.5	104,700.0	276.1	0.33	0.2	0.6
Maximum:	4,441.6	0.0	4,441.6	104,700.0	465.0	0.56	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/03/2021 00:00	3,416.3	0.0	3,416.3	104,700.0	357.7	0.43	0.2	0.7
11/03/2021 01:00	3,323.4	0.0	3,323.4	104,700.0	348.0	0.42	0.2	0.7
11/03/2021 02:00	3,318.7	0.0	3,318.7	104,700.0	347.5	0.42	0.2	0.7
11/03/2021 03:00	3,388.7	0.0	3,388.7	104,700.0	354.8	0.42	0.2	0.7
11/03/2021 04:00	3,620.8	0.0	3,620.8	104,700.0	379.1	0.45	0.2	0.8
11/03/2021 05:00	4,011.8	0.0	4,011.8	104,700.0	420.0	0.50	0.3	0.8
11/03/2021 06:00	4,011.9	0.0	4,011.9	104,700.0	420.0	0.51	0.3	0.8
11/03/2021 07:00	3,078.9	0.0	3,078.9	104,700.0	322.4	0.39	0.2	0.6
11/03/2021 08:00	2,697.5	0.0	2,697.5	104,700.0	282.4	0.34	0.2	0.6
11/03/2021 09:00	2,632.7	0.0	2,632.7	104,700.0	275.6	0.33	0.2	0.6
11/03/2021 10:00	2,656.1	0.0	2,656.1	104,700.0	278.1	0.33	0.2	0.6
11/03/2021 11:00	2,655.6	0.0	2,655.6	104,700.0	278.0	0.33	0.2	0.6
11/03/2021 12:00	2,682.3	0.0	2,682.3	104,700.0	280.8	0.34	0.2	0.6
11/03/2021 13:00	2,703.7	0.0	2,703.7	104,700.0	283.1	0.34	0.2	0.6
11/03/2021 14:00	2,694.6	0.0	2,694.6	104,700.0	282.1	0.34	0.2	0.6
11/03/2021 15:00	3,210.8	0.0	3,210.8	104,700.0	336.2	0.40	0.2	0.7
11/03/2021 16:00	3,573.7	0.0	3,573.7	104,700.0	374.2	0.45	0.2	0.7
11/03/2021 17:00	4,373.4	0.0	4,373.4	104,700.0	457.9	0.55	0.3	0.9
11/03/2021 18:00	4,152.4	0.0	4,152.4	104,700.0	434.8	0.52	0.3	0.9
11/03/2021 19:00	4,324.9	0.0	4,324.9	104,700.0	452.8	0.54	0.3	0.9
11/03/2021 20:00	4,308.7	0.0	4,308.7	104,700.0	451.1	0.54	0.3	0.9
11/03/2021 21:00	3,984.6	0.0	3,984.6	104,700.0	417.2	0.50	0.3	0.8
11/03/2021 22:00	3,339.0	0.0	3,339.0	104,700.0	349.6	0.42	0.2	0.7
11/03/2021 23:00	2,762.8	0.0	2,762.8	104,700.0	289.3	0.35	0.2	0.6
Average/Sum#:	3,371.8	0.0	3,371.8	104,700.0	353.0	0.42	0.2	0.7
Minimum:	2,632.7	0.0	2,632.7	104,700.0	275.6	0.33	0.2	0.6
Maximum:	4,373.4	0.0	4,373.4	104,700.0	457.9	0.55	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/04/2021 00:00	2,726.5	0.0	2,726.5	104,700.0	285.5	0.34	0.2	0.6
11/04/2021 01:00	2,644.6	0.0	2,644.6	104,700.0	276.9	0.33	0.2	0.6
11/04/2021 02:00	2,763.8	0.0	2,763.8	104,700.0	289.4	0.35	0.2	0.6
11/04/2021 03:00	3,644.7	0.0	3,644.7	104,700.0	381.6	0.46	0.2	0.8
11/04/2021 04:00	3,165.0	0.0	3,165.0	104,700.0	331.4	0.40	0.2	0.7
11/04/2021 05:00	4,011.7	0.0	4,011.7	104,700.0	420.0	0.50	0.3	0.8
11/04/2021 06:00	4,182.4	0.0	4,182.4	104,700.0	437.9	0.53	0.3	0.9
11/04/2021 07:00	3,023.1	0.0	3,023.1	104,700.0	316.5	0.38	0.2	0.6
11/04/2021 08:00	2,731.4	0.0	2,731.4	104,700.0	286.0	0.34	0.2	0.6
11/04/2021 09:00	3,423.2	0.0	3,423.2	104,700.0	358.4	0.43	0.2	0.7
11/04/2021 10:00	2,638.3	0.0	2,638.3	104,700.0	276.2	0.33	0.2	0.6
11/04/2021 11:00	2,650.1	0.0	2,650.1	104,700.0	277.5	0.33	0.2	0.6
11/04/2021 12:00	2,641.4	0.0	2,641.4	104,700.0	276.6	0.33	0.2	0.6
11/04/2021 13:00	2,670.3	0.0	2,670.3	104,700.0	279.6	0.33	0.2	0.6
11/04/2021 14:00	2,640.0	0.0	2,640.0	104,700.0	276.4	0.33	0.2	0.6
11/04/2021 15:00	3,252.5	0.0	3,252.5	104,700.0	340.5	0.41	0.2	0.7
11/04/2021 16:00	2,898.5	0.0	2,898.5	104,700.0	303.5	0.36	0.2	0.6
11/04/2021 17:00	2,693.5	0.0	2,693.5	104,700.0	282.0	0.34	0.2	0.6
11/04/2021 18:00	2,725.9	0.0	2,725.9	104,700.0	285.4	0.34	0.2	0.6
11/04/2021 19:00	2,720.8	0.0	2,720.8	104,700.0	284.9	0.34	0.2	0.6
11/04/2021 20:00	2,696.8	0.0	2,696.8	104,700.0	282.4	0.34	0.2	0.6
11/04/2021 21:00	2,629.7	0.0	2,629.7	104,700.0	275.3	0.33	0.2	0.6
11/04/2021 22:00	2,634.2	0.0	2,634.2	104,700.0	275.8	0.33	0.2	0.6
11/04/2021 23:00	2,623.7	0.0	2,623.7	104,700.0	274.7	0.33	0.2	0.6
Average/Sum#:	2,934.7	0.0	2,934.7	104,700.0	307.3	0.37	0.2	0.6
Minimum:	2,623.7	0.0	2,623.7	104,700.0	274.7	0.33	0.2	0.6
Maximum:	4,182.4	0.0	4,182.4	104,700.0	437.9	0.53	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/05/2021 00:00	2,624.4	0.0	2,624.4	104,700.0	274.8	0.33	0.2	0.6
11/05/2021 01:00	2,618.6	0.0	2,618.6	104,700.0	274.2	0.33	0.2	0.6
11/05/2021 02:00	2,630.8	0.0	2,630.8	104,700.0	275.4	0.33	0.2	0.6
11/05/2021 03:00	2,714.5	0.0	2,714.5	104,700.0	284.2	0.34	0.2	0.6
11/05/2021 04:00	2,971.6	0.0	2,971.6	104,700.0	311.1	0.37	0.2	0.6
11/05/2021 05:00	3,759.3	0.0	3,759.3	104,700.0	393.6	0.47	0.2	0.8
11/05/2021 06:00	3,980.4	0.0	3,980.4	104,700.0	416.7	0.50	0.3	0.8
11/05/2021 07:00	3,403.7	0.0	3,403.7	104,700.0	356.4	0.43	0.2	0.7
11/05/2021 08:00	2,700.3	0.0	2,700.3	104,700.0	282.7	0.34	0.2	0.6
11/05/2021 09:00	2,621.7	0.0	2,621.7	104,700.0	274.5	0.33	0.2	0.6
11/05/2021 10:00	2,625.6	0.0	2,625.6	104,700.0	274.9	0.33	0.2	0.6
11/05/2021 11:00	2,632.8	0.0	2,632.8	104,700.0	275.7	0.33	0.2	0.6
11/05/2021 12:00	2,636.9	0.0	2,636.9	104,700.0	276.1	0.33	0.2	0.6
11/05/2021 13:00	2,640.4	0.0	2,640.4	104,700.0	276.4	0.33	0.2	0.6
11/05/2021 14:00	3,110.6	0.0	3,110.6	104,700.0	325.7	0.39	0.2	0.7
11/05/2021 15:00	3,939.5	0.0	3,939.5	104,700.0	412.5	0.50	0.2	0.8
11/05/2021 16:00	3,584.1	0.0	3,584.1	104,700.0	375.3	0.45	0.2	0.8
11/05/2021 17:00	3,631.1	0.0	3,631.1	104,700.0	380.2	0.46	0.2	0.8
11/05/2021 18:00	3,097.8	0.0	3,097.8	104,700.0	324.3	0.39	0.2	0.6
11/05/2021 19:00	3,481.5	0.0	3,481.5	104,700.0	364.5	0.44	0.2	0.7
11/05/2021 20:00	3,576.1	0.0	3,576.1	104,700.0	374.4	0.45	0.2	0.7
11/05/2021 21:00	3,929.4	0.0	3,929.4	104,700.0	411.4	0.49	0.2	0.8
11/05/2021 22:00	3,178.3	0.0	3,178.3	104,700.0	332.8	0.40	0.2	0.7
11/05/2021 23:00	3,607.0	0.0	3,607.0	104,700.0	377.7	0.45	0.2	0.8
Average/Sum#:	3,154.0	0.0	3,154.0	104,700.0	330.2	0.40	0.2	0.7
Minimum:	2,618.6	0.0	2,618.6	104,700.0	274.2	0.33	0.2	0.6
Maximum:	3,980.4	0.0	3,980.4	104,700.0	416.7	0.50	0.3	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/06/2021 00:00	2,828.0	0.0	2,828.0	104,700.0	296.1	0.36	0.2	0.6
11/06/2021 01:00	3,365.8	0.0	3,365.8	104,700.0	352.4	0.42	0.2	0.7
11/06/2021 02:00	2,877.2	0.0	2,877.2	104,700.0	301.2	0.36	0.2	0.6
11/06/2021 03:00	2,778.0	0.0	2,778.0	104,700.0	290.9	0.35	0.2	0.6
11/06/2021 04:00	3,019.3	0.0	3,019.3	104,700.0	316.1	0.38	0.2	0.6
11/06/2021 05:00	3,666.0	0.0	3,666.0	104,700.0	383.8	0.46	0.2	0.8
11/06/2021 06:00	4,145.8	0.0	4,145.8	104,700.0	434.1	0.52	0.3	0.9
11/06/2021 07:00	3,440.2	0.0	3,440.2	104,700.0	360.2	0.43	0.2	0.7
11/06/2021 08:00	3,212.8	0.0	3,212.8	104,700.0	336.4	0.40	0.2	0.7
11/06/2021 09:00	2,712.1	0.0	2,712.1	104,700.0	284.0	0.34	0.2	0.6
11/06/2021 10:00	2,675.4	0.0	2,675.4	104,700.0	280.1	0.34	0.2	0.6
11/06/2021 11:00	2,676.2	0.0	2,676.2	104,700.0	280.2	0.34	0.2	0.6
11/06/2021 12:00	2,635.2	0.0	2,635.2	104,700.0	275.9	0.33	0.2	0.6
11/06/2021 13:00	2,633.8	0.0	2,633.8	104,700.0	275.8	0.33	0.2	0.6
11/06/2021 14:00	2,631.5	0.0	2,631.5	104,700.0	275.5	0.33	0.2	0.6
11/06/2021 15:00	3,053.4	0.0	3,053.4	104,700.0	319.7	0.38	0.2	0.6
11/06/2021 16:00	3,684.3	0.0	3,684.3	104,700.0	385.7	0.46	0.2	0.8
11/06/2021 17:00	4,187.8	0.0	4,187.8	104,700.0	438.5	0.53	0.3	0.9
11/06/2021 18:00	3,299.1	0.0	3,299.1	104,700.0	345.4	0.42	0.2	0.7
11/06/2021 19:00	4,380.3	0.0	4,380.3	104,700.0	458.6	0.55	0.3	0.9
11/06/2021 20:00	4,049.4	0.0	4,049.4	104,700.0	424.0	0.51	0.3	0.8
11/06/2021 21:00	3,657.1	0.0	3,657.1	104,700.0	382.9	0.46	0.2	0.8
11/06/2021 22:00	2,772.6	0.0	2,772.6	104,700.0	290.3	0.35	0.2	0.6
11/06/2021 23:00	2,764.4	0.0	2,764.4	104,700.0	289.4	0.35	0.2	0.6
Average/Sum#:	3,214.4	0.0	3,214.4	104,700.0	336.6	0.40	0.2	0.7
Minimum:	2,631.5	0.0	2,631.5	104,700.0	275.5	0.33	0.2	0.6
Maximum:	4,380.3	0.0	4,380.3	104,700.0	458.6	0.55	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/07/2021 00:00	2,653.6	0.0	2,653.6	104,700.0	277.8	0.33	0.2	0.6
11/07/2021 01:00	2,644.0	0.0	2,644.0	104,700.0	276.8	0.33	0.2	0.6
11/07/2021 02:00	2,658.0	0.0	2,658.0	104,700.0	278.3	0.33	0.2	0.6
11/07/2021 03:00	2,666.6	0.0	2,666.6	104,700.0	279.2	0.34	0.2	0.6
11/07/2021 04:00	2,668.8	0.0	2,668.8	104,700.0	279.4	0.34	0.2	0.6
11/07/2021 05:00	2,678.2	0.0	2,678.2	104,700.0	280.4	0.34	0.2	0.6
11/07/2021 06:00	3,667.8	0.0	3,667.8	104,700.0	384.0	0.46	0.2	0.8
11/07/2021 07:00	3,939.6	0.0	3,939.6	104,700.0	412.5	0.50	0.2	0.8
11/07/2021 08:00	2,653.4	0.0	2,653.4	104,700.0	277.8	0.33	0.2	0.6
11/07/2021 09:00	2,652.9	0.0	2,652.9	104,700.0	277.8	0.33	0.2	0.6
11/07/2021 10:00	2,640.5	0.0	2,640.5	104,700.0	276.5	0.33	0.2	0.6
11/07/2021 11:00	2,630.2	0.0	2,630.2	104,700.0	275.4	0.33	0.2	0.6
11/07/2021 12:00	2,609.4	0.0	2,609.4	104,700.0	273.2	0.33	0.2	0.5
11/07/2021 13:00	2,612.5	0.0	2,612.5	104,700.0	273.5	0.33	0.2	0.5
11/07/2021 14:00	2,664.3	0.0	2,664.3	104,700.0	279.0	0.34	0.2	0.6
11/07/2021 15:00	3,464.5	0.0	3,464.5	104,700.0	362.7	0.44	0.2	0.7
11/07/2021 16:00	3,617.5	0.0	3,617.5	104,700.0	378.8	0.45	0.2	0.8
11/07/2021 17:00	3,249.8	0.0	3,249.8	104,700.0	340.3	0.41	0.2	0.7
11/07/2021 18:00	3,066.6	0.0	3,066.6	104,700.0	321.1	0.38	0.2	0.6
11/07/2021 19:00	3,607.7	0.0	3,607.7	104,700.0	377.7	0.45	0.2	0.8
11/07/2021 20:00	2,871.0	0.0	2,871.0	104,700.0	300.6	0.36	0.2	0.6
11/07/2021 21:00	2,727.3	0.0	2,727.3	104,700.0	285.5	0.34	0.2	0.6
11/07/2021 22:00	2,730.1	0.0	2,730.1	104,700.0	285.8	0.34	0.2	0.6
11/07/2021 23:00	2,630.8	0.0	2,630.8	104,700.0	275.4	0.33	0.2	0.6
Average/Sum#:	2,916.9	0.0	2,916.9	104,700.0	305.4	0.37	0.2	0.6
Minimum:	2,609.4	0.0	2,609.4	104,700.0	273.2	0.33	0.2	0.5
Maximum:	3,939.6	0.0	3,939.6	104,700.0	412.5	0.50	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/08/2021 00:00	2,650.3	0.0	2,650.3	104,700.0	277.5	0.33	0.2	0.6
11/08/2021 01:00	2,743.7	0.0	2,743.7	104,700.0	287.3	0.34	0.2	0.6
11/08/2021 02:00	3,074.5	0.0	3,074.5	104,700.0	321.9	0.38	0.2	0.6
11/08/2021 03:00	4,271.8	0.0	4,271.8	104,700.0	447.3	0.53	0.3	0.9
11/08/2021 04:00	4,300.1	0.0	4,300.1	104,700.0	450.2	0.54	0.3	0.9
11/08/2021 05:00	4,411.4	0.0	4,411.4	104,700.0	461.9	0.55	0.3	0.9
11/08/2021 06:00	4,371.1	0.0	4,371.1	104,700.0	457.7	0.55	0.3	0.9
11/08/2021 07:00	3,374.8	0.0	3,374.8	104,700.0	353.3	0.42	0.2	0.7
11/08/2021 08:00	2,638.3	0.0	2,638.3	104,700.0	276.2	0.33	0.2	0.6
11/08/2021 09:00	2,638.8	0.0	2,638.8	104,700.0	276.3	0.33	0.2	0.6
11/08/2021 10:00	2,619.9	0.0	2,619.9	104,700.0	274.3	0.33	0.2	0.6
11/08/2021 11:00	2,625.5	0.0	2,625.5	104,700.0	274.9	0.33	0.2	0.6
11/08/2021 12:00	2,624.2	0.0	2,624.2	104,700.0	274.8	0.33	0.2	0.6
11/08/2021 13:00	2,626.9	0.0	2,626.9	104,700.0	275.0	0.33	0.2	0.6
11/08/2021 14:00	2,624.1	0.0	2,624.1	104,700.0	274.7	0.33	0.2	0.6
11/08/2021 15:00	3,620.4	0.0	3,620.4	104,700.0	379.1	0.45	0.2	0.8
11/08/2021 16:00	4,358.2	74.7	4,386.6	104,700.0	459.3	0.56	0.3	0.9
11/08/2021 17:00	4,420.0	189.7	4,609.7	104,700.0	482.6	0.58	0.3	1.0
11/08/2021 18:00	4,424.8	178.8	4,603.6	104,700.0	482.0	0.58	0.3	1.0
11/08/2021 19:00	4,381.3	109.5	4,461.2	104,700.0	467.1	0.57	0.3	0.9
11/08/2021 20:00	4,217.6	0.0	4,217.6	104,700.0	441.6	0.53	0.3	0.9
11/08/2021 21:00	3,949.1	0.0	3,949.1	104,700.0	413.5	0.50	0.2	0.8
11/08/2021 22:00	3,464.7	0.0	3,464.7	104,700.0	362.8	0.43	0.2	0.7
11/08/2021 23:00	2,757.8	0.0	2,757.8	104,700.0	288.7	0.34	0.2	0.6
Average/Sum#:	3,466.2	23.0	3,486.1	104,700.0	365.0	0.44	0.2	0.7
Minimum:	2,619.9	0.0	2,619.9	104,700.0	274.3	0.33	0.2	0.6
Maximum:	4,424.8	189.7	4,609.7	104,700.0	482.6	0.58	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/09/2021 00:00	2,752.9	0.0	2,752.9	104,700.0	288.2	0.35	0.2	0.6
11/09/2021 01:00	2,746.9	0.0	2,746.9	104,700.0	287.6	0.35	0.2	0.6
11/09/2021 02:00	2,708.6	0.0	2,708.6	104,700.0	283.6	0.34	0.2	0.6
11/09/2021 03:00	2,644.6	0.0	2,644.6	104,700.0	276.9	0.33	0.2	0.6
11/09/2021 04:00	2,741.2	0.0	2,741.2	104,700.0	287.0	0.34	0.2	0.6
11/09/2021 05:00	2,964.4	0.0	2,964.4	104,700.0	310.4	0.37	0.2	0.6
11/09/2021 06:00	2,910.0	0.0	2,910.0	104,700.0	304.7	0.36	0.2	0.6
11/09/2021 07:00	3,367.3	0.0	3,367.3	104,700.0	352.6	0.42	0.2	0.7
11/09/2021 08:00	2,689.4	0.0	2,689.4	104,700.0	281.6	0.34	0.2	0.6
11/09/2021 09:00	2,649.8	0.0	2,649.8	104,700.0	277.4	0.33	0.2	0.6
11/09/2021 10:00	2,730.1	0.0	2,730.1	104,700.0	285.8	0.35	0.2	0.6
11/09/2021 11:00	2,676.7	0.0	2,676.7	104,700.0	280.3	0.34	0.2	0.6
11/09/2021 12:00	2,670.4	0.0	2,670.4	104,700.0	279.6	0.34	0.2	0.6
11/09/2021 13:00	2,675.7	0.0	2,675.7	104,700.0	280.1	0.34	0.2	0.6
11/09/2021 14:00	2,776.2	0.0	2,776.2	104,700.0	290.7	0.35	0.2	0.6
11/09/2021 15:00	3,115.8	0.0	3,115.8	104,700.0	326.2	0.39	0.2	0.7
11/09/2021 16:00	3,195.6	0.0	3,195.6	104,700.0	334.6	0.40	0.2	0.7
11/09/2021 17:00	3,696.2	0.0	3,696.2	104,700.0	387.0	0.46	0.2	0.8
11/09/2021 18:00	4,414.3	0.0	4,414.3	104,700.0	462.2	0.56	0.3	0.9
11/09/2021 19:00	4,321.7	0.0	4,321.7	104,700.0	452.5	0.54	0.3	0.9
11/09/2021 20:00	4,254.8	0.0	4,254.8	104,700.0	445.5	0.54	0.3	0.9
11/09/2021 21:00	3,168.2	0.0	3,168.2	104,700.0	331.7	0.40	0.2	0.7
11/09/2021 22:00	2,776.1	0.0	2,776.1	104,700.0	290.7	0.35	0.2	0.6
11/09/2021 23:00	2,741.3	0.0	2,741.3	104,700.0	287.0	0.34	0.2	0.6
Average/Sum#:	3,057.8	0.0	3,057.8	104,700.0	320.2	0.38	0.2	0.7
Minimum:	2,644.6	0.0	2,644.6	104,700.0	276.9	0.33	0.2	0.6
Maximum:	4,414.3	0.0	4,414.3	104,700.0	462.2	0.56	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/10/2021 00:00	2,673.1	0.0	2,673.1	104,700.0	279.9	0.33	0.2	0.6
11/10/2021 01:00	2,650.2	0.0	2,650.2	104,700.0	277.5	0.33	0.2	0.6
11/10/2021 02:00	2,651.0	0.0	2,651.0	104,700.0	277.6	0.33	0.2	0.6
11/10/2021 03:00	2,644.0	0.0	2,644.0	104,700.0	276.8	0.33	0.2	0.6
11/10/2021 04:00	2,643.3	0.0	2,643.3	104,700.0	276.8	0.33	0.2	0.6
11/10/2021 05:00	3,407.0	0.0	3,407.0	104,700.0	356.7	0.43	0.2	0.7
11/10/2021 06:00	3,647.5	0.0	3,647.5	104,700.0	381.9	0.46	0.2	0.8
11/10/2021 07:00	3,647.6	0.0	3,647.6	104,700.0	381.9	0.46	0.2	0.8
11/10/2021 08:00	2,640.9	0.0	2,640.9	104,700.0	276.5	0.33	0.2	0.6
11/10/2021 09:00	2,700.1	0.0	2,700.1	104,700.0	282.7	0.34	0.2	0.6
11/10/2021 10:00	2,732.3	0.0	2,732.3	104,700.0	286.1	0.34	0.2	0.6
11/10/2021 11:00	2,658.6	0.0	2,658.6	104,700.0	278.4	0.33	0.2	0.6
11/10/2021 12:00	2,651.5	0.0	2,651.5	104,700.0	277.6	0.33	0.2	0.6
11/10/2021 13:00	2,650.0	0.0	2,650.0	104,700.0	277.5	0.33	0.2	0.6
11/10/2021 14:00	2,646.3	0.0	2,646.3	104,700.0	277.1	0.33	0.2	0.6
11/10/2021 15:00	2,659.0	0.0	2,659.0	104,700.0	278.4	0.33	0.2	0.6
11/10/2021 16:00	2,724.6	0.0	2,724.6	104,700.0	285.3	0.34	0.2	0.6
11/10/2021 17:00	2,774.4	0.0	2,774.4	104,700.0	290.5	0.35	0.2	0.6
11/10/2021 18:00	2,769.0	0.0	2,769.0	104,700.0	289.9	0.35	0.2	0.6
11/10/2021 19:00	2,771.5	0.0	2,771.5	104,700.0	290.2	0.35	0.2	0.6
11/10/2021 20:00	2,787.7	0.0	2,787.7	104,700.0	291.9	0.35	0.2	0.6
11/10/2021 21:00	2,992.7	0.0	2,992.7	104,700.0	313.3	0.38	0.2	0.6
11/10/2021 22:00	2,790.3	0.0	2,790.3	104,700.0	292.1	0.35	0.2	0.6
11/10/2021 23:00	2,770.6	0.0	2,770.6	104,700.0	290.1	0.35	0.2	0.6
Average/Sum#:	2,820.1	0.0	2,820.1	104,700.0	295.3	0.35	0.2	0.6
Minimum:	2,640.9	0.0	2,640.9	104,700.0	276.5	0.33	0.2	0.6
Maximum:	3,647.6	0.0	3,647.6	104,700.0	381.9	0.46	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/11/2021 00:00	2,717.5	0.0	2,717.5	104,700.0	284.5	0.34	0.2	0.6
11/11/2021 01:00	2,770.7	0.0	2,770.7	104,700.0	290.1	0.35	0.2	0.6
11/11/2021 02:00	2,637.5	0.0	2,637.5	104,700.0	276.1	0.33	0.2	0.6
11/11/2021 03:00	2,650.0	0.0	2,650.0	104,700.0	277.5	0.33	0.2	0.6
11/11/2021 04:00	2,752.3	0.0	2,752.3	104,700.0	288.2	0.35	0.2	0.6
11/11/2021 05:00	2,781.9	0.0	2,781.9	104,700.0	291.3	0.35	0.2	0.6
11/11/2021 06:00	2,768.3	0.0	2,768.3	104,700.0	289.8	0.35	0.2	0.6
11/11/2021 07:00	2,760.3	0.0	2,760.3	104,700.0	289.0	0.35	0.2	0.6
11/11/2021 08:00	2,760.6	0.0	2,760.6	104,700.0	289.0	0.35	0.2	0.6
11/11/2021 09:00	2,769.6	0.0	2,769.6	104,700.0	290.0	0.35	0.2	0.6
11/11/2021 10:00	2,763.9	0.0	2,763.9	104,700.0	289.4	0.35	0.2	0.6
11/11/2021 11:00	2,657.8	0.0	2,657.8	104,700.0	278.3	0.33	0.2	0.6
11/11/2021 12:00	2,665.0	0.0	2,665.0	104,700.0	279.0	0.33	0.2	0.6
11/11/2021 13:00	2,676.7	0.0	2,676.7	104,700.0	280.3	0.33	0.2	0.6
11/11/2021 14:00	2,670.9	0.0	2,670.9	104,700.0	279.6	0.33	0.2	0.6
11/11/2021 15:00	3,036.3	0.0	3,036.3	104,700.0	317.9	0.38	0.2	0.6
11/11/2021 16:00	3,613.3	72.1	3,638.5	104,700.0	381.0	0.46	0.2	0.8
11/11/2021 17:00	4,485.8	140.8	4,626.6	104,700.0	484.4	0.58	0.3	1.0
11/11/2021 18:00	4,501.1	137.9	4,639.0	104,700.0	485.7	0.58	0.3	1.0
11/11/2021 19:00	4,514.4	137.4	4,651.8	104,700.0	487.0	0.58	0.3	1.0
11/11/2021 20:00	4,522.1	138.4	4,660.5	104,700.0	488.0	0.59	0.3	1.0
11/11/2021 21:00	4,530.4	137.5	4,667.9	104,700.0	488.7	0.59	0.3	1.0
11/11/2021 22:00	3,856.9	70.3	3,893.5	104,700.0	407.6	0.49	0.2	0.8
11/11/2021 23:00	2,863.8	0.0	2,863.8	104,700.0	299.8	0.36	0.2	0.6
Average/Sum#:	3,197.0	34.8	3,228.4	104,700.0	338.0	0.41	0.2	0.7
Minimum:	2,637.5	0.0	2,637.5	104,700.0	276.1	0.33	0.2	0.6
Maximum:	4,530.4	140.8	4,667.9	104,700.0	488.7	0.59	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/12/2021 00:00	2,676.0	0.0	2,676.0	104,700.0	280.2	0.33	0.2	0.6
11/12/2021 01:00	2,641.4	0.0	2,641.4	104,700.0	276.6	0.33	0.2	0.6
11/12/2021 02:00	2,639.2	0.0	2,639.2	104,700.0	276.3	0.33	0.2	0.6
11/12/2021 03:00	2,637.1	0.0	2,637.1	104,700.0	276.1	0.33	0.2	0.6
11/12/2021 04:00	2,652.3	0.0	2,652.3	104,700.0	277.7	0.33	0.2	0.6
11/12/2021 05:00	2,769.7	0.0	2,769.7	104,700.0	290.0	0.35	0.2	0.6
11/12/2021 06:00	2,774.8	0.0	2,774.8	104,700.0	290.5	0.35	0.2	0.6
11/12/2021 07:00	2,684.0	0.0	2,684.0	104,700.0	281.0	0.34	0.2	0.6
11/12/2021 08:00	2,684.1	0.0	2,684.1	104,700.0	281.0	0.34	0.2	0.6
11/12/2021 09:00	2,645.5	0.0	2,645.5	104,700.0	277.0	0.33	0.2	0.6
11/12/2021 10:00	2,649.2	0.0	2,649.2	104,700.0	277.4	0.33	0.2	0.6
11/12/2021 11:00	2,652.2	0.0	2,652.2	104,700.0	277.7	0.33	0.2	0.6
11/12/2021 12:00	2,648.3	0.0	2,648.3	104,700.0	277.3	0.33	0.2	0.6
11/12/2021 13:00	2,647.8	0.0	2,647.8	104,700.0	277.2	0.33	0.2	0.6
11/12/2021 14:00	2,682.9	0.0	2,682.9	104,700.0	280.9	0.34	0.2	0.6
11/12/2021 15:00	2,932.9	0.0	2,932.9	104,700.0	307.1	0.37	0.2	0.6
11/12/2021 16:00	2,729.8	0.0	2,729.8	104,700.0	285.8	0.34	0.2	0.6
11/12/2021 17:00	2,749.9	0.0	2,749.9	104,700.0	287.9	0.35	0.2	0.6
11/12/2021 18:00	2,652.4	0.0	2,652.4	104,700.0	277.7	0.33	0.2	0.6
11/12/2021 19:00	2,768.2	0.0	2,768.2	104,700.0	289.8	0.35	0.2	0.6
11/12/2021 20:00	2,779.5	0.0	2,779.5	104,700.0	291.0	0.35	0.2	0.6
11/12/2021 21:00	3,104.4	0.0	3,104.4	104,700.0	325.0	0.39	0.2	0.7
11/12/2021 22:00	2,716.6	0.0	2,716.6	104,700.0	284.4	0.34	0.2	0.6
11/12/2021 23:00	2,649.8	0.0	2,649.8	104,700.0	277.4	0.33	0.2	0.6
Average/Sum#:	2,715.3	0.0	2,715.3	104,700.0	284.3	0.34	0.2	0.6
Minimum:	2,637.1	0.0	2,637.1	104,700.0	276.1	0.33	0.2	0.6
Maximum:	3,104.4	0.0	3,104.4	104,700.0	325.0	0.39	0.2	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/13/2021 00:00	2,673.8	0.0	2,673.8	104,700.0	279.9	0.34	0.2	0.6
11/13/2021 01:00	2,665.6	0.0	2,665.6	104,700.0	279.1	0.33	0.2	0.6
11/13/2021 02:00	2,772.3	0.0	2,772.3	104,700.0	290.3	0.35	0.2	0.6
11/13/2021 03:00	2,777.6	0.0	2,777.6	104,700.0	290.8	0.35	0.2	0.6
11/13/2021 04:00	2,936.1	0.0	2,936.1	104,700.0	307.4	0.37	0.2	0.6
11/13/2021 05:00	3,441.3	0.0	3,441.3	104,700.0	360.3	0.43	0.2	0.7
11/13/2021 06:00	4,447.7	0.0	4,447.7	104,700.0	465.7	0.56	0.3	0.9
11/13/2021 07:00	4,446.5	0.0	4,446.5	104,700.0	465.5	0.56	0.3	0.9
11/13/2021 08:00	4,441.3	0.0	4,441.3	104,700.0	465.0	0.56	0.3	0.9
11/13/2021 09:00	4,443.8	0.0	4,443.8	104,700.0	465.3	0.56	0.3	0.9
11/13/2021 10:00	3,579.2	0.0	3,579.2	104,700.0	374.7	0.45	0.2	0.7
11/13/2021 11:00	2,881.9	0.0	2,881.9	104,700.0	301.7	0.36	0.2	0.6
11/13/2021 12:00	2,708.5	0.0	2,708.5	104,700.0	283.6	0.34	0.2	0.6
11/13/2021 13:00	2,677.5	0.0	2,677.5	104,700.0	280.3	0.34	0.2	0.6
11/13/2021 14:00	2,665.1	0.0	2,665.1	104,700.0	279.0	0.33	0.2	0.6
11/13/2021 15:00	2,903.6	0.0	2,903.6	104,700.0	304.0	0.36	0.2	0.6
11/13/2021 16:00	4,241.0	0.0	4,241.0	104,700.0	444.0	0.53	0.3	0.9
11/13/2021 17:00	3,070.5	0.0	3,070.5	104,700.0	321.5	0.39	0.2	0.6
11/13/2021 18:00	3,103.6	0.0	3,103.6	104,700.0	324.9	0.39	0.2	0.7
11/13/2021 19:00	3,892.7	0.0	3,892.7	104,700.0	407.6	0.49	0.2	0.8
11/13/2021 20:00	3,772.6	0.0	3,772.6	104,700.0	395.0	0.47	0.2	0.8
11/13/2021 21:00	2,975.9	0.0	2,975.9	104,700.0	311.6	0.37	0.2	0.6
11/13/2021 22:00	2,786.8	0.0	2,786.8	104,700.0	291.8	0.35	0.2	0.6
11/13/2021 23:00	2,674.6	0.0	2,674.6	104,700.0	280.0	0.33	0.2	0.6
Average/Sum#:	3,290.8	0.0	3,290.8	104,700.0	344.5	0.41	0.2	0.7
Minimum:	2,665.1	0.0	2,665.1	104,700.0	279.0	0.33	0.2	0.6
Maximum:	4,447.7	0.0	4,447.7	104,700.0	465.7	0.56	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/14/2021 00:00	2,645.8	0.0	2,645.8	104,700.0	277.0	0.33	0.2	0.6
11/14/2021 01:00	2,644.4	0.0	2,644.4	104,700.0	276.9	0.33	0.2	0.6
11/14/2021 02:00	2,641.5	0.0	2,641.5	104,700.0	276.6	0.33	0.2	0.6
11/14/2021 03:00	2,641.1	0.0	2,641.1	104,700.0	276.5	0.33	0.2	0.6
11/14/2021 04:00	2,648.9	0.0	2,648.9	104,700.0	277.3	0.33	0.2	0.6
11/14/2021 05:00	2,640.8	0.0	2,640.8	104,700.0	276.5	0.33	0.2	0.6
11/14/2021 06:00	2,655.3	0.0	2,655.3	104,700.0	278.0	0.33	0.2	0.6
11/14/2021 07:00	2,681.6	0.0	2,681.6	104,700.0	280.8	0.34	0.2	0.6
11/14/2021 08:00	2,667.8	0.0	2,667.8	104,700.0	279.3	0.33	0.2	0.6
11/14/2021 09:00	2,658.9	0.0	2,658.9	104,700.0	278.4	0.33	0.2	0.6
11/14/2021 10:00	2,658.8	0.0	2,658.8	104,700.0	278.4	0.33	0.2	0.6
11/14/2021 11:00	2,659.5	0.0	2,659.5	104,700.0	278.4	0.33	0.2	0.6
11/14/2021 12:00	2,658.8	0.0	2,658.8	104,700.0	278.4	0.33	0.2	0.6
11/14/2021 13:00	2,654.5	0.0	2,654.5	104,700.0	277.9	0.33	0.2	0.6
11/14/2021 14:00	2,642.8	0.0	2,642.8	104,700.0	276.7	0.33	0.2	0.6
11/14/2021 15:00	2,876.8	0.0	2,876.8	104,700.0	301.2	0.36	0.2	0.6
11/14/2021 16:00	2,673.6	0.0	2,673.6	104,700.0	279.9	0.34	0.2	0.6
11/14/2021 17:00	2,671.5	0.0	2,671.5	104,700.0	279.7	0.33	0.2	0.6
11/14/2021 18:00	2,661.6	0.0	2,661.6	104,700.0	278.7	0.33	0.2	0.6
11/14/2021 19:00	2,702.6	0.0	2,702.6	104,700.0	283.0	0.34	0.2	0.6
11/14/2021 20:00	2,829.7	0.0	2,829.7	104,700.0	296.3	0.36	0.2	0.6
11/14/2021 21:00	2,760.9	0.0	2,760.9	104,700.0	289.1	0.35	0.2	0.6
11/14/2021 22:00	2,689.3	0.0	2,689.3	104,700.0	281.6	0.34	0.2	0.6
11/14/2021 23:00	2,644.3	0.0	2,644.3	104,700.0	276.9	0.33	0.2	0.6
Average/Sum#:	2,679.6	0.0	2,679.6	104,700.0	280.6	0.34	0.2	0.6
Minimum:	2,640.8	0.0	2,640.8	104,700.0	276.5	0.33	0.2	0.6
Maximum:	2,876.8	0.0	2,876.8	104,700.0	301.2	0.36	0.2	0.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/15/2021 00:00	2,646.7	0.0	2,646.7	104,700.0	277.1	0.33	0.2	0.6
11/15/2021 01:00	2,640.8	0.0	2,640.8	104,700.0	276.5	0.33	0.2	0.6
11/15/2021 02:00	2,644.3	0.0	2,644.3	104,700.0	276.9	0.33	0.2	0.6
11/15/2021 03:00	2,649.8	0.0	2,649.8	104,700.0	277.4	0.33	0.2	0.6
11/15/2021 04:00	2,677.7	0.0	2,677.7	104,700.0	280.4	0.34	0.2	0.6
11/15/2021 05:00	2,758.4	0.0	2,758.4	104,700.0	288.8	0.35	0.2	0.6
11/15/2021 06:00	3,038.2	0.0	3,038.2	104,700.0	318.1	0.38	0.2	0.6
11/15/2021 07:00	3,091.0	0.0	3,091.0	104,700.0	323.6	0.39	0.2	0.6
11/15/2021 08:00	2,700.0	0.0	2,700.0	104,700.0	282.7	0.34	0.2	0.6
11/15/2021 09:00	2,775.9	0.0	2,775.9	104,700.0	290.6	0.35	0.2	0.6
11/15/2021 10:00	2,773.2	0.0	2,773.2	104,700.0	290.4	0.35	0.2	0.6
11/15/2021 11:00	2,725.6	0.0	2,725.6	104,700.0	285.4	0.34	0.2	0.6
11/15/2021 12:00	2,634.9	0.0	2,634.9	104,700.0	275.9	0.33	0.2	0.6
11/15/2021 13:00	2,703.8	0.0	2,703.8	104,700.0	283.1	0.34	0.2	0.6
11/15/2021 14:00	3,383.4	0.0	3,383.4	104,700.0	354.2	0.43	0.2	0.7
11/15/2021 15:00	3,228.9	0.0	3,228.9	104,700.0	338.1	0.41	0.2	0.7
11/15/2021 16:00	2,931.2	0.0	2,931.2	104,700.0	306.9	0.37	0.2	0.6
11/15/2021 17:00	2,760.4	0.0	2,760.4	104,700.0	289.0	0.35	0.2	0.6
11/15/2021 18:00	2,788.4	0.0	2,788.4	104,700.0	291.9	0.35	0.2	0.6
11/15/2021 19:00	3,507.9	0.0	3,507.9	104,700.0	367.3	0.44	0.2	0.7
11/15/2021 20:00	2,775.8	0.0	2,775.8	104,700.0	290.6	0.35	0.2	0.6
11/15/2021 21:00	3,002.1	0.0	3,002.1	104,700.0	314.3	0.38	0.2	0.6
11/15/2021 22:00	2,742.9	0.0	2,742.9	104,700.0	287.2	0.35	0.2	0.6
11/15/2021 23:00	2,639.4	0.0	2,639.4	104,700.0	276.3	0.33	0.2	0.6
Average/Sum#:	2,842.5	0.0	2,842.5	104,700.0	297.6	0.36	0.2	0.6
Minimum:	2,634.9	0.0	2,634.9	104,700.0	275.9	0.33	0.2	0.6
Maximum:	3,507.9	0.0	3,507.9	104,700.0	367.3	0.44	0.2	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/16/2021 00:00	2,758.4	0.0	2,758.4	104,700.0	288.8	0.35	0.2	0.6
11/16/2021 01:00	2,771.7	0.0	2,771.7	104,700.0	290.2	0.35	0.2	0.6
11/16/2021 02:00	2,691.4	0.0	2,691.4	104,700.0	281.8	0.34	0.2	0.6
11/16/2021 03:00	2,652.8	0.0	2,652.8	104,700.0	277.7	0.33	0.2	0.6
11/16/2021 04:00	2,749.4	0.0	2,749.4	104,700.0	287.9	0.35	0.2	0.6
11/16/2021 05:00	3,734.2	0.0	3,734.2	104,700.0	391.0	0.47	0.2	0.8
11/16/2021 06:00	4,457.3	0.0	4,457.3	104,700.0	466.7	0.56	0.3	0.9
11/16/2021 07:00	4,460.1	0.0	4,460.1	104,700.0	467.0	0.56	0.3	0.9
11/16/2021 08:00	3,685.6	0.0	3,685.6	104,700.0	385.9	0.46	0.2	0.8
11/16/2021 09:00	3,352.6	0.0	3,352.6	104,700.0	351.0	0.42	0.2	0.7
11/16/2021 10:00	2,718.1	0.0	2,718.1	104,700.0	284.6	0.34	0.2	0.6
11/16/2021 11:00	2,706.3	0.0	2,706.3	104,700.0	283.3	0.34	0.2	0.6
11/16/2021 12:00	2,671.6	0.0	2,671.6	104,700.0	279.7	0.34	0.2	0.6
11/16/2021 13:00	2,674.4	0.0	2,674.4	104,700.0	280.0	0.34	0.2	0.6
11/16/2021 14:00	2,669.7	0.0	2,669.7	104,700.0	279.5	0.33	0.2	0.6
11/16/2021 15:00	2,931.9	0.0	2,931.9	104,700.0	307.0	0.37	0.2	0.6
11/16/2021 16:00	2,773.9	0.0	2,773.9	104,700.0	290.4	0.35	0.2	0.6
11/16/2021 17:00	3,440.1	0.0	3,440.1	104,700.0	360.2	0.43	0.2	0.7
11/16/2021 18:00	3,694.0	0.0	3,694.0	104,700.0	386.8	0.46	0.2	0.8
11/16/2021 19:00	3,212.0	0.0	3,212.0	104,700.0	336.3	0.40	0.2	0.7
11/16/2021 20:00	4,149.0	0.0	4,149.0	104,700.0	434.4	0.52	0.3	0.9
11/16/2021 21:00	4,213.9	0.0	4,213.9	104,700.0	441.2	0.53	0.3	0.9
11/16/2021 22:00	3,805.8	0.0	3,805.8	104,700.0	398.5	0.48	0.2	0.8
11/16/2021 23:00	3,400.5	0.0	3,400.5	104,700.0	356.0	0.43	0.2	0.7
Average/Sum#:	3,265.6	0.0	3,265.6	104,700.0	341.9	0.41	0.2	0.7
Minimum:	2,652.8	0.0	2,652.8	104,700.0	277.7	0.33	0.2	0.6
Maximum:	4,460.1	0.0	4,460.1	104,700.0	467.0	0.56	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/17/2021 00:00	4,456.0	87.7	4,513.0	104,700.0	472.5	0.57	0.3	1.0
11/17/2021 01:00	3,882.7	70.3	3,919.3	104,700.0	410.4	0.50	0.2	0.8
11/17/2021 02:00	2,768.2	0.0	2,768.2	104,700.0	289.8	0.35	0.2	0.6
11/17/2021 03:00	2,782.5	0.0	2,782.5	104,700.0	291.3	0.35	0.2	0.6
11/17/2021 04:00	3,371.8	0.0	3,371.8	104,700.0	353.0	0.42	0.2	0.7
11/17/2021 05:00	3,396.9	0.0	3,396.9	104,700.0	355.7	0.43	0.2	0.7
11/17/2021 06:00	4,291.7	0.0	4,291.7	104,700.0	449.3	0.54	0.3	0.9
11/17/2021 07:00	3,601.2	0.0	3,601.2	104,700.0	377.0	0.45	0.2	0.8
11/17/2021 08:00	2,750.2	0.0	2,750.2	104,700.0	287.9	0.35	0.2	0.6
11/17/2021 09:00	2,768.0	0.0	2,768.0	104,700.0	289.8	0.35	0.2	0.6
11/17/2021 10:00	2,755.8	0.0	2,755.8	104,700.0	288.5	0.35	0.2	0.6
11/17/2021 11:00	2,662.0	0.0	2,662.0	104,700.0	278.7	0.33	0.2	0.6
11/17/2021 12:00	2,648.1	0.0	2,648.1	104,700.0	277.3	0.33	0.2	0.6
11/17/2021 13:00	2,641.4	0.0	2,641.4	104,700.0	276.6	0.33	0.2	0.6
11/17/2021 14:00	2,643.6	0.0	2,643.6	104,700.0	276.8	0.33	0.2	0.6
11/17/2021 15:00	3,202.9	0.0	3,202.9	104,700.0	335.3	0.40	0.2	0.7
11/17/2021 16:00	3,632.7	0.0	3,632.7	104,700.0	380.3	0.46	0.2	0.8
11/17/2021 17:00	4,189.5	0.0	4,189.5	104,700.0	438.6	0.53	0.3	0.9
11/17/2021 18:00	4,378.4	0.0	4,378.4	104,700.0	458.4	0.55	0.3	0.9
11/17/2021 19:00	4,388.2	0.0	4,388.2	104,700.0	459.4	0.55	0.3	0.9
11/17/2021 20:00	4,319.2	0.0	4,319.2	104,700.0	452.2	0.54	0.3	0.9
11/17/2021 21:00	3,957.3	0.0	3,957.3	104,700.0	414.3	0.50	0.2	0.8
11/17/2021 22:00	2,875.5	0.0	2,875.5	104,700.0	301.1	0.36	0.2	0.6
11/17/2021 23:00	2,780.9	0.0	2,780.9	104,700.0	291.2	0.35	0.2	0.6
Average/Sum#:	3,381.0	6.6	3,384.9	104,700.0	354.4	0.43	0.2	0.7
Minimum:	2,641.4	0.0	2,641.4	104,700.0	276.6	0.33	0.2	0.6
Maximum:	4,456.0	87.7	4,513.0	104,700.0	472.5	0.57	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/18/2021 00:00	2,773.2	0.0	2,773.2	104,700.0	290.4	0.35	0.2	0.6
11/18/2021 01:00	2,776.5	0.0	2,776.5	104,700.0	290.7	0.35	0.2	0.6
11/18/2021 02:00	2,776.4	0.0	2,776.4	104,700.0	290.7	0.35	0.2	0.6
11/18/2021 03:00	2,774.2	0.0	2,774.2	104,700.0	290.5	0.35	0.2	0.6
11/18/2021 04:00	2,771.1	0.0	2,771.1	104,700.0	290.1	0.35	0.2	0.6
11/18/2021 05:00	3,174.1	0.0	3,174.1	104,700.0	332.3	0.40	0.2	0.7
11/18/2021 06:00	4,225.5	0.0	4,225.5	104,700.0	442.4	0.53	0.3	0.9
11/18/2021 07:00	3,879.4	0.0	3,879.4	104,700.0	406.2	0.49	0.2	0.8
11/18/2021 08:00	3,498.7	0.0	3,498.7	104,700.0	366.3	0.44	0.2	0.7
11/18/2021 09:00	2,786.9	0.0	2,786.9	104,700.0	291.8	0.35	0.2	0.6
11/18/2021 10:00	2,667.5	0.0	2,667.5	104,700.0	279.3	0.34	0.2	0.6
11/18/2021 11:00	2,677.4	0.0	2,677.4	104,700.0	280.3	0.34	0.2	0.6
11/18/2021 12:00	2,674.5	0.0	2,674.5	104,700.0	280.0	0.34	0.2	0.6
11/18/2021 13:00	2,819.9	0.0	2,819.9	104,700.0	295.2	0.35	0.2	0.6
11/18/2021 14:00	2,984.0	0.0	2,984.0	104,700.0	312.4	0.37	0.2	0.6
11/18/2021 15:00	3,948.3	0.0	3,948.3	104,700.0	413.4	0.50	0.2	0.8
11/18/2021 16:00	4,183.0	0.0	4,183.0	104,700.0	438.0	0.53	0.3	0.9
11/18/2021 17:00	4,224.7	0.0	4,224.7	104,700.0	442.3	0.53	0.3	0.9
11/18/2021 18:00	4,474.0	0.0	4,474.0	104,700.0	468.4	0.56	0.3	0.9
11/18/2021 19:00	4,345.3	0.0	4,345.3	104,700.0	455.0	0.55	0.3	0.9
11/18/2021 20:00	3,690.4	0.0	3,690.4	104,700.0	386.4	0.46	0.2	0.8
11/18/2021 21:00	3,336.1	0.0	3,336.1	104,700.0	349.3	0.42	0.2	0.7
11/18/2021 22:00	3,088.7	0.0	3,088.7	104,700.0	323.4	0.39	0.2	0.6
11/18/2021 23:00	2,972.6	0.0	2,972.6	104,700.0	311.2	0.37	0.2	0.6
Average/Sum#:	3,313.4	0.0	3,313.4	104,700.0	346.9	0.42	0.2	0.7
Minimum:	2,667.5	0.0	2,667.5	104,700.0	279.3	0.34	0.2	0.6
Maximum:	4,474.0	0.0	4,474.0	104,700.0	468.4	0.56	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/19/2021 00:00	2,257.8	0.0	2,257.8	104,700.0	236.4	0.33	0.2	0.6
11/19/2021 01:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
11/19/2021 02:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
11/19/2021 03:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
11/19/2021 04:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
11/19/2021 05:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
11/19/2021 06:00	0.0	0.0	0.0	104,700.0	0.0	0.00	0.0	0.0
11/19/2021 07:00	267.9	0.0	267.9	104,700.0	28.0	0.00	0.0	0.0
11/19/2021 08:00	2,774.8	0.0	2,774.8	104,700.0	290.5	0.34	0.2	0.6
11/19/2021 09:00	2,671.1	0.0	2,671.1	104,700.0	279.7	0.33	0.2	0.6
11/19/2021 10:00	2,684.0	0.0	2,684.0	104,700.0	281.0	0.34	0.2	0.6
11/19/2021 11:00	2,708.4	0.0	2,708.4	104,700.0	283.6	0.34	0.2	0.6
11/19/2021 12:00	2,831.1	0.0	2,831.1	104,700.0	296.4	0.36	0.2	0.6
11/19/2021 13:00	4,027.3	0.0	4,027.3	104,700.0	421.7	0.51	0.3	0.8
11/19/2021 14:00	3,835.9	0.0	3,835.9	104,700.0	401.6	0.48	0.2	0.8
11/19/2021 15:00	3,258.4	0.0	3,258.4	104,700.0	341.2	0.41	0.2	0.7
11/19/2021 16:00	2,809.6	0.0	2,809.6	104,700.0	294.2	0.36	0.2	0.6
11/19/2021 17:00	3,027.7	0.0	3,027.7	104,700.0	317.0	0.38	0.2	0.6
11/19/2021 18:00	2,888.9	0.0	2,888.9	104,700.0	302.5	0.36	0.2	0.6
11/19/2021 19:00	2,787.8	0.0	2,787.8	104,700.0	291.9	0.35	0.2	0.6
11/19/2021 20:00	3,226.4	0.0	3,226.4	104,700.0	337.8	0.41	0.2	0.7
11/19/2021 21:00	3,084.9	0.0	3,084.9	104,700.0	323.0	0.39	0.2	0.6
11/19/2021 22:00	3,120.6	0.0	3,120.6	104,700.0	326.7	0.39	0.2	0.7
11/19/2021 23:00	2,683.7	0.0	2,683.7	104,700.0	281.0	0.34	0.2	0.6
Average/Sum#:	2,830.4	0.0	2,830.4	104,700.0	296.3	0.38	0.2	0.6
Minimum:	267.9	0.0	267.9	104,700.0	28.0	0.33	0.2	0.6
Maximum:	4,027.3	0.0	4,027.3	104,700.0	421.7	0.51	0.3	0.8
%SI	25.00	25.00	25.00	0.00	25.00	29.17	29.17	29.17

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/20/2021 00:00	2,645.0	0.0	2,645.0	104,700.0	276.9	0.33	0.2	0.6
11/20/2021 01:00	2,661.0	0.0	2,661.0	104,700.0	278.6	0.33	0.2	0.6
11/20/2021 02:00	2,661.8	0.0	2,661.8	104,700.0	278.7	0.33	0.2	0.6
11/20/2021 03:00	2,669.1	0.0	2,669.1	104,700.0	279.5	0.33	0.2	0.6
11/20/2021 04:00	2,783.6	0.0	2,783.6	104,700.0	291.4	0.35	0.2	0.6
11/20/2021 05:00	2,696.9	0.0	2,696.9	104,700.0	282.4	0.34	0.2	0.6
11/20/2021 06:00	2,821.6	0.0	2,821.6	104,700.0	295.4	0.35	0.2	0.6
11/20/2021 07:00	3,393.6	0.0	3,393.6	104,700.0	355.3	0.43	0.2	0.7
11/20/2021 08:00	2,638.5	0.0	2,638.5	104,700.0	276.3	0.33	0.2	0.6
11/20/2021 09:00	2,632.6	0.0	2,632.6	104,700.0	275.6	0.33	0.2	0.6
11/20/2021 10:00	2,636.3	0.0	2,636.3	104,700.0	276.0	0.33	0.2	0.6
11/20/2021 11:00	2,632.5	0.0	2,632.5	104,700.0	275.6	0.33	0.2	0.6
11/20/2021 12:00	2,632.1	0.0	2,632.1	104,700.0	275.6	0.33	0.2	0.6
11/20/2021 13:00	2,629.5	0.0	2,629.5	104,700.0	275.3	0.33	0.2	0.6
11/20/2021 14:00	2,632.1	0.0	2,632.1	104,700.0	275.6	0.33	0.2	0.6
11/20/2021 15:00	3,159.0	0.0	3,159.0	104,700.0	330.7	0.40	0.2	0.7
11/20/2021 16:00	3,168.1	0.0	3,168.1	104,700.0	331.7	0.40	0.2	0.7
11/20/2021 17:00	2,853.3	0.0	2,853.3	104,700.0	298.7	0.36	0.2	0.6
11/20/2021 18:00	2,755.0	0.0	2,755.0	104,700.0	288.4	0.35	0.2	0.6
11/20/2021 19:00	3,041.5	0.0	3,041.5	104,700.0	318.4	0.38	0.2	0.6
11/20/2021 20:00	3,255.8	0.0	3,255.8	104,700.0	340.9	0.41	0.2	0.7
11/20/2021 21:00	4,115.9	0.0	4,115.9	104,700.0	430.9	0.52	0.3	0.9
11/20/2021 22:00	3,520.6	0.0	3,520.6	104,700.0	368.6	0.44	0.2	0.7
11/20/2021 23:00	2,766.4	0.0	2,766.4	104,700.0	289.6	0.35	0.2	0.6
Average/Sum#:	2,891.7	0.0	2,891.7	104,700.0	302.8	0.36	0.2	0.6
Minimum:	2,629.5	0.0	2,629.5	104,700.0	275.3	0.33	0.2	0.6
Maximum:	4,115.9	0.0	4,115.9	104,700.0	430.9	0.52	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/21/2021 00:00	3,281.2	0.0	3,281.2	104,700.0	343.5	0.41	0.2	0.7
11/21/2021 01:00	2,784.2	0.0	2,784.2	104,700.0	291.5	0.35	0.2	0.6
11/21/2021 02:00	2,673.8	0.0	2,673.8	104,700.0	279.9	0.34	0.2	0.6
11/21/2021 03:00	2,776.8	0.0	2,776.8	104,700.0	290.7	0.35	0.2	0.6
11/21/2021 04:00	2,778.0	0.0	2,778.0	104,700.0	290.9	0.35	0.2	0.6
11/21/2021 05:00	4,010.2	0.0	4,010.2	104,700.0	419.9	0.50	0.3	0.8
11/21/2021 06:00	4,105.8	0.0	4,105.8	104,700.0	429.9	0.52	0.3	0.9
11/21/2021 07:00	4,115.8	0.0	4,115.8	104,700.0	430.9	0.52	0.3	0.9
11/21/2021 08:00	4,334.0	0.0	4,334.0	104,700.0	453.8	0.55	0.3	0.9
11/21/2021 09:00	3,526.2	0.0	3,526.2	104,700.0	369.2	0.44	0.2	0.7
11/21/2021 10:00	3,524.9	0.0	3,524.9	104,700.0	369.1	0.44	0.2	0.7
11/21/2021 11:00	3,040.9	0.0	3,040.9	104,700.0	318.4	0.38	0.2	0.6
11/21/2021 12:00	2,656.7	0.0	2,656.7	104,700.0	278.2	0.33	0.2	0.6
11/21/2021 13:00	2,651.5	0.0	2,651.5	104,700.0	277.6	0.33	0.2	0.6
11/21/2021 14:00	2,650.0	0.0	2,650.0	104,700.0	277.5	0.33	0.2	0.6
11/21/2021 15:00	3,415.9	0.0	3,415.9	104,700.0	357.6	0.43	0.2	0.7
11/21/2021 16:00	3,229.3	0.0	3,229.3	104,700.0	338.1	0.41	0.2	0.7
11/21/2021 17:00	2,756.5	0.0	2,756.5	104,700.0	288.6	0.35	0.2	0.6
11/21/2021 18:00	2,757.5	0.0	2,757.5	104,700.0	288.7	0.35	0.2	0.6
11/21/2021 19:00	3,420.5	0.0	3,420.5	104,700.0	358.1	0.43	0.2	0.7
11/21/2021 20:00	4,411.5	0.0	4,411.5	104,700.0	461.9	0.56	0.3	0.9
11/21/2021 21:00	3,660.9	0.0	3,660.9	104,700.0	383.3	0.46	0.2	0.8
11/21/2021 22:00	3,560.1	0.0	3,560.1	104,700.0	372.7	0.45	0.2	0.7
11/21/2021 23:00	2,772.2	0.0	2,772.2	104,700.0	290.2	0.35	0.2	0.6
Average/Sum#:	3,287.3	0.0	3,287.3	104,700.0	344.2	0.41	0.2	0.7
Minimum:	2,650.0	0.0	2,650.0	104,700.0	277.5	0.33	0.2	0.6
Maximum:	4,411.5	0.0	4,411.5	104,700.0	461.9	0.56	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/22/2021 00:00	2,786.3	0.0	2,786.3	104,700.0	291.7	0.35	0.2	0.6
11/22/2021 01:00	2,786.7	0.0	2,786.7	104,700.0	291.8	0.35	0.2	0.6
11/22/2021 02:00	2,781.5	0.0	2,781.5	104,700.0	291.2	0.35	0.2	0.6
11/22/2021 03:00	2,785.4	0.0	2,785.4	104,700.0	291.6	0.35	0.2	0.6
11/22/2021 04:00	2,780.9	0.0	2,780.9	104,700.0	291.2	0.35	0.2	0.6
11/22/2021 05:00	2,804.3	0.0	2,804.3	104,700.0	293.6	0.35	0.2	0.6
11/22/2021 06:00	3,318.8	0.0	3,318.8	104,700.0	347.5	0.42	0.2	0.7
11/22/2021 07:00	3,325.8	0.0	3,325.8	104,700.0	348.2	0.42	0.2	0.7
11/22/2021 08:00	2,782.1	0.0	2,782.1	104,700.0	291.3	0.35	0.2	0.6
11/22/2021 09:00	2,674.7	0.0	2,674.7	104,700.0	280.0	0.33	0.2	0.6
11/22/2021 10:00	2,653.5	0.0	2,653.5	104,700.0	277.8	0.33	0.2	0.6
11/22/2021 11:00	2,653.7	0.0	2,653.7	104,700.0	277.8	0.33	0.2	0.6
11/22/2021 12:00	2,730.3	0.0	2,730.3	104,700.0	285.9	0.34	0.2	0.6
11/22/2021 13:00	2,774.1	0.0	2,774.1	104,700.0	290.4	0.35	0.2	0.6
11/22/2021 14:00	3,726.2	0.0	3,726.2	104,700.0	390.1	0.47	0.2	0.8
11/22/2021 15:00	4,473.0	0.0	4,473.0	104,700.0	468.3	0.56	0.3	0.9
11/22/2021 16:00	3,660.9	0.0	3,660.9	104,700.0	383.3	0.46	0.2	0.8
11/22/2021 17:00	2,991.5	0.0	2,991.5	104,700.0	313.2	0.38	0.2	0.6
11/22/2021 18:00	4,104.8	0.0	4,104.8	104,700.0	429.8	0.52	0.3	0.9
11/22/2021 19:00	4,070.3	0.0	4,070.3	104,700.0	426.2	0.51	0.3	0.9
11/22/2021 20:00	4,134.2	0.0	4,134.2	104,700.0	432.9	0.52	0.3	0.9
11/22/2021 21:00	4,099.9	0.0	4,099.9	104,700.0	429.3	0.52	0.3	0.9
11/22/2021 22:00	4,144.6	0.0	4,144.6	104,700.0	433.9	0.52	0.3	0.9
11/22/2021 23:00	3,407.5	0.0	3,407.5	104,700.0	356.8	0.43	0.2	0.7
Average/Sum#:	3,268.8	0.0	3,268.8	104,700.0	342.2	0.41	0.2	0.7
Minimum:	2,653.5	0.0	2,653.5	104,700.0	277.8	0.33	0.2	0.6
Maximum:	4,473.0	0.0	4,473.0	104,700.0	468.3	0.56	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/23/2021 00:00	2,767.4	0.0	2,767.4	104,700.0	289.7	0.35	0.2	0.6
11/23/2021 01:00	2,789.0	0.0	2,789.0	104,700.0	292.0	0.35	0.2	0.6
11/23/2021 02:00	2,796.1	0.0	2,796.1	104,700.0	292.8	0.35	0.2	0.6
11/23/2021 03:00	2,764.8	0.0	2,764.8	104,700.0	289.5	0.35	0.2	0.6
11/23/2021 04:00	2,684.5	0.0	2,684.5	104,700.0	281.1	0.34	0.2	0.6
11/23/2021 05:00	2,676.0	0.0	2,676.0	104,700.0	280.2	0.33	0.2	0.6
11/23/2021 06:00	2,775.7	0.0	2,775.7	104,700.0	290.6	0.35	0.2	0.6
11/23/2021 07:00	3,212.0	0.0	3,212.0	104,700.0	336.3	0.40	0.2	0.7
11/23/2021 08:00	2,688.1	0.0	2,688.1	104,700.0	281.4	0.34	0.2	0.6
11/23/2021 09:00	2,647.0	0.0	2,647.0	104,700.0	277.1	0.33	0.2	0.6
11/23/2021 10:00	2,642.3	0.0	2,642.3	104,700.0	276.6	0.33	0.2	0.6
11/23/2021 11:00	2,640.9	0.0	2,640.9	104,700.0	276.5	0.33	0.2	0.6
11/23/2021 12:00	2,641.9	0.0	2,641.9	104,700.0	276.6	0.33	0.2	0.6
11/23/2021 13:00	2,641.2	0.0	2,641.2	104,700.0	276.5	0.33	0.2	0.6
11/23/2021 14:00	2,644.7	0.0	2,644.7	104,700.0	276.9	0.33	0.2	0.6
11/23/2021 15:00	3,036.2	0.0	3,036.2	104,700.0	317.9	0.38	0.2	0.6
11/23/2021 16:00	2,977.5	0.0	2,977.5	104,700.0	311.7	0.38	0.2	0.6
11/23/2021 17:00	2,775.9	0.0	2,775.9	104,700.0	290.6	0.35	0.2	0.6
11/23/2021 18:00	2,773.1	0.0	2,773.1	104,700.0	290.3	0.35	0.2	0.6
11/23/2021 19:00	2,774.3	0.0	2,774.3	104,700.0	290.5	0.35	0.2	0.6
11/23/2021 20:00	2,706.0	0.0	2,706.0	104,700.0	283.3	0.34	0.2	0.6
11/23/2021 21:00	2,733.8	0.0	2,733.8	104,700.0	286.2	0.34	0.2	0.6
11/23/2021 22:00	2,773.6	0.0	2,773.6	104,700.0	290.4	0.35	0.2	0.6
11/23/2021 23:00	2,700.9	0.0	2,700.9	104,700.0	282.8	0.34	0.2	0.6
Average/Sum#:	2,761.0	0.0	2,761.0	104,700.0	289.1	0.35	0.2	0.6
Minimum:	2,640.9	0.0	2,640.9	104,700.0	276.5	0.33	0.2	0.6
Maximum:	3,212.0	0.0	3,212.0	104,700.0	336.3	0.40	0.2	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/24/2021 00:00	2,780.8	0.0	2,780.8	104,700.0	291.1	0.35	0.2	0.6
11/24/2021 01:00	2,777.1	0.0	2,777.1	104,700.0	290.8	0.35	0.2	0.6
11/24/2021 02:00	2,667.4	0.0	2,667.4	104,700.0	279.3	0.33	0.2	0.6
11/24/2021 03:00	2,667.0	0.0	2,667.0	104,700.0	279.2	0.33	0.2	0.6
11/24/2021 04:00	2,694.5	0.0	2,694.5	104,700.0	282.1	0.34	0.2	0.6
11/24/2021 05:00	2,719.9	0.0	2,719.9	104,700.0	284.8	0.34	0.2	0.6
11/24/2021 06:00	2,976.1	0.0	2,976.1	104,700.0	311.6	0.37	0.2	0.6
11/24/2021 07:00	3,318.5	0.0	3,318.5	104,700.0	347.4	0.42	0.2	0.7
11/24/2021 08:00	2,758.3	0.0	2,758.3	104,700.0	288.8	0.35	0.2	0.6
11/24/2021 09:00	2,856.4	0.0	2,856.4	104,700.0	299.1	0.36	0.2	0.6
11/24/2021 10:00	2,760.4	0.0	2,760.4	104,700.0	289.0	0.35	0.2	0.6
11/24/2021 11:00	2,756.8	0.0	2,756.8	104,700.0	288.6	0.35	0.2	0.6
11/24/2021 12:00	2,755.2	0.0	2,755.2	104,700.0	288.5	0.35	0.2	0.6
11/24/2021 13:00	2,752.9	0.0	2,752.9	104,700.0	288.2	0.35	0.2	0.6
11/24/2021 14:00	2,759.4	0.0	2,759.4	104,700.0	288.9	0.35	0.2	0.6
11/24/2021 15:00	3,121.9	0.0	3,121.9	104,700.0	326.9	0.39	0.2	0.7
11/24/2021 16:00	3,111.6	0.0	3,111.6	104,700.0	325.8	0.39	0.2	0.7
11/24/2021 17:00	2,779.5	0.0	2,779.5	104,700.0	291.0	0.35	0.2	0.6
11/24/2021 18:00	2,775.6	0.0	2,775.6	104,700.0	290.6	0.35	0.2	0.6
11/24/2021 19:00	2,794.5	0.0	2,794.5	104,700.0	292.6	0.35	0.2	0.6
11/24/2021 20:00	2,834.7	0.0	2,834.7	104,700.0	296.8	0.36	0.2	0.6
11/24/2021 21:00	2,947.2	0.0	2,947.2	104,700.0	308.6	0.37	0.2	0.6
11/24/2021 22:00	2,773.6	0.0	2,773.6	104,700.0	290.4	0.35	0.2	0.6
11/24/2021 23:00	2,776.3	0.0	2,776.3	104,700.0	290.7	0.35	0.2	0.6
Average/Sum#:	2,829.8	0.0	2,829.8	104,700.0	296.3	0.36	0.2	0.6
Minimum:	2,667.0	0.0	2,667.0	104,700.0	279.2	0.33	0.2	0.6
Maximum:	3,318.5	0.0	3,318.5	104,700.0	347.4	0.42	0.2	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/25/2021 00:00	2,774.4	0.0	2,774.4	104,700.0	290.5	0.35	0.2	0.6
11/25/2021 01:00	2,775.1	0.0	2,775.1	104,700.0	290.6	0.35	0.2	0.6
11/25/2021 02:00	2,774.9	0.0	2,774.9	104,700.0	290.5	0.35	0.2	0.6
11/25/2021 03:00	2,776.2	0.0	2,776.2	104,700.0	290.7	0.35	0.2	0.6
11/25/2021 04:00	2,775.0	0.0	2,775.0	104,700.0	290.5	0.35	0.2	0.6
11/25/2021 05:00	2,771.9	0.0	2,771.9	104,700.0	290.2	0.35	0.2	0.6
11/25/2021 06:00	2,815.0	0.0	2,815.0	104,700.0	294.7	0.36	0.2	0.6
11/25/2021 07:00	3,205.8	0.0	3,205.8	104,700.0	335.6	0.40	0.2	0.7
11/25/2021 08:00	2,864.5	0.0	2,864.5	104,700.0	299.9	0.36	0.2	0.6
11/25/2021 09:00	2,758.4	0.0	2,758.4	104,700.0	288.8	0.35	0.2	0.6
11/25/2021 10:00	2,766.7	0.0	2,766.7	104,700.0	289.7	0.35	0.2	0.6
11/25/2021 11:00	2,812.5	0.0	2,812.5	104,700.0	294.5	0.36	0.2	0.6
11/25/2021 12:00	2,756.5	0.0	2,756.5	104,700.0	288.6	0.35	0.2	0.6
11/25/2021 13:00	2,757.1	0.0	2,757.1	104,700.0	288.7	0.35	0.2	0.6
11/25/2021 14:00	2,755.1	0.0	2,755.1	104,700.0	288.5	0.35	0.2	0.6
11/25/2021 15:00	2,858.0	0.0	2,858.0	104,700.0	299.2	0.36	0.2	0.6
11/25/2021 16:00	2,856.5	0.0	2,856.5	104,700.0	299.1	0.36	0.2	0.6
11/25/2021 17:00	2,751.4	0.0	2,751.4	104,700.0	288.1	0.35	0.2	0.6
11/25/2021 18:00	2,772.7	0.0	2,772.7	104,700.0	290.3	0.35	0.2	0.6
11/25/2021 19:00	2,748.5	0.0	2,748.5	104,700.0	287.8	0.35	0.2	0.6
11/25/2021 20:00	2,746.7	0.0	2,746.7	104,700.0	287.6	0.35	0.2	0.6
11/25/2021 21:00	2,748.7	0.0	2,748.7	104,700.0	287.8	0.34	0.2	0.6
11/25/2021 22:00	2,737.7	0.0	2,737.7	104,700.0	286.6	0.34	0.2	0.6
11/25/2021 23:00	2,760.4	0.0	2,760.4	104,700.0	289.0	0.35	0.2	0.6
Average/Sum#:	2,796.7	0.0	2,796.7	104,700.0	292.8	0.35	0.2	0.6
Minimum:	2,737.7	0.0	2,737.7	104,700.0	286.6	0.34	0.2	0.6
Maximum:	3,205.8	0.0	3,205.8	104,700.0	335.6	0.40	0.2	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/26/2021 00:00	2,741.8	0.0	2,741.8	104,700.0	287.1	0.34	0.2	0.6
11/26/2021 01:00	2,737.3	0.0	2,737.3	104,700.0	286.6	0.34	0.2	0.6
11/26/2021 02:00	2,745.4	0.0	2,745.4	104,700.0	287.4	0.34	0.2	0.6
11/26/2021 03:00	2,746.1	0.0	2,746.1	104,700.0	287.5	0.34	0.2	0.6
11/26/2021 04:00	2,749.8	0.0	2,749.8	104,700.0	287.9	0.34	0.2	0.6
11/26/2021 05:00	2,741.8	0.0	2,741.8	104,700.0	287.1	0.34	0.2	0.6
11/26/2021 06:00	2,738.1	0.0	2,738.1	104,700.0	286.7	0.34	0.2	0.6
11/26/2021 07:00	2,747.1	0.0	2,747.1	104,700.0	287.6	0.34	0.2	0.6
11/26/2021 08:00	2,744.7	0.0	2,744.7	104,700.0	287.4	0.34	0.2	0.6
11/26/2021 09:00	2,745.0	0.0	2,745.0	104,700.0	287.4	0.34	0.2	0.6
11/26/2021 10:00	2,749.4	0.0	2,749.4	104,700.0	287.9	0.35	0.2	0.6
11/26/2021 11:00	2,741.2	0.0	2,741.2	104,700.0	287.0	0.34	0.2	0.6
11/26/2021 12:00	2,740.2	0.0	2,740.2	104,700.0	286.9	0.34	0.2	0.6
11/26/2021 13:00	2,737.9	0.0	2,737.9	104,700.0	286.7	0.34	0.2	0.6
11/26/2021 14:00	2,737.0	0.0	2,737.0	104,700.0	286.6	0.34	0.2	0.6
11/26/2021 15:00	3,242.2	0.0	3,242.2	104,700.0	339.5	0.41	0.2	0.7
11/26/2021 16:00	2,786.8	0.0	2,786.8	104,700.0	291.8	0.35	0.2	0.6
11/26/2021 17:00	2,733.2	0.0	2,733.2	104,700.0	286.2	0.34	0.2	0.6
11/26/2021 18:00	2,732.6	0.0	2,732.6	104,700.0	286.1	0.34	0.2	0.6
11/26/2021 19:00	2,733.6	0.0	2,733.6	104,700.0	286.2	0.34	0.2	0.6
11/26/2021 20:00	2,747.1	0.0	2,747.1	104,700.0	287.6	0.35	0.2	0.6
11/26/2021 21:00	2,754.4	0.0	2,754.4	104,700.0	288.4	0.35	0.2	0.6
11/26/2021 22:00	2,751.6	0.0	2,751.6	104,700.0	288.1	0.35	0.2	0.6
11/26/2021 23:00	2,753.1	0.0	2,753.1	104,700.0	288.2	0.35	0.2	0.6
Average/Sum#:	2,765.7	0.0	2,765.7	104,700.0	289.6	0.35	0.2	0.6
Minimum:	2,732.6	0.0	2,732.6	104,700.0	286.1	0.34	0.2	0.6
Maximum:	3,242.2	0.0	3,242.2	104,700.0	339.5	0.41	0.2	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/27/2021 00:00	2,734.2	0.0	2,734.2	104,700.0	286.3	0.34	0.2	0.6
11/27/2021 01:00	2,748.6	0.0	2,748.6	104,700.0	287.8	0.35	0.2	0.6
11/27/2021 02:00	2,735.6	0.0	2,735.6	104,700.0	286.4	0.34	0.2	0.6
11/27/2021 03:00	2,747.1	0.0	2,747.1	104,700.0	287.6	0.35	0.2	0.6
11/27/2021 04:00	2,740.9	0.0	2,740.9	104,700.0	287.0	0.34	0.2	0.6
11/27/2021 05:00	2,933.6	0.0	2,933.6	104,700.0	307.1	0.37	0.2	0.6
11/27/2021 06:00	2,828.4	0.0	2,828.4	104,700.0	296.1	0.36	0.2	0.6
11/27/2021 07:00	3,351.7	0.0	3,351.7	104,700.0	350.9	0.42	0.2	0.7
11/27/2021 08:00	2,738.4	0.0	2,738.4	104,700.0	286.7	0.34	0.2	0.6
11/27/2021 09:00	3,019.5	0.0	3,019.5	104,700.0	316.1	0.38	0.2	0.6
11/27/2021 10:00	3,529.7	0.0	3,529.7	104,700.0	369.6	0.44	0.2	0.7
11/27/2021 11:00	2,749.1	0.0	2,749.1	104,700.0	287.8	0.35	0.2	0.6
11/27/2021 12:00	2,748.9	0.0	2,748.9	104,700.0	287.8	0.35	0.2	0.6
11/27/2021 13:00	2,747.9	0.0	2,747.9	104,700.0	287.7	0.35	0.2	0.6
11/27/2021 14:00	2,749.4	0.0	2,749.4	104,700.0	287.9	0.35	0.2	0.6
11/27/2021 15:00	3,161.0	0.0	3,161.0	104,700.0	331.0	0.40	0.2	0.7
11/27/2021 16:00	3,308.7	0.0	3,308.7	104,700.0	346.4	0.42	0.2	0.7
11/27/2021 17:00	2,796.5	0.0	2,796.5	104,700.0	292.8	0.35	0.2	0.6
11/27/2021 18:00	2,744.3	0.0	2,744.3	104,700.0	287.3	0.34	0.2	0.6
11/27/2021 19:00	2,749.7	0.0	2,749.7	104,700.0	287.9	0.35	0.2	0.6
11/27/2021 20:00	2,760.2	0.0	2,760.2	104,700.0	289.0	0.35	0.2	0.6
11/27/2021 21:00	2,917.3	0.0	2,917.3	104,700.0	305.4	0.37	0.2	0.6
11/27/2021 22:00	2,747.1	0.0	2,747.1	104,700.0	287.6	0.35	0.2	0.6
11/27/2021 23:00	2,756.1	0.0	2,756.1	104,700.0	288.6	0.35	0.2	0.6
Average/Sum#:	2,876.8	0.0	2,876.8	104,700.0	301.2	0.36	0.2	0.6
Minimum:	2,734.2	0.0	2,734.2	104,700.0	286.3	0.34	0.2	0.6
Maximum:	3,529.7	0.0	3,529.7	104,700.0	369.6	0.44	0.2	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/28/2021 00:00	2,749.3	0.0	2,749.3	104,700.0	287.9	0.35	0.2	0.6
11/28/2021 01:00	2,748.0	0.0	2,748.0	104,700.0	287.7	0.35	0.2	0.6
11/28/2021 02:00	2,749.3	0.0	2,749.3	104,700.0	287.9	0.35	0.2	0.6
11/28/2021 03:00	2,753.3	0.0	2,753.3	104,700.0	288.3	0.35	0.2	0.6
11/28/2021 04:00	2,754.0	0.0	2,754.0	104,700.0	288.3	0.35	0.2	0.6
11/28/2021 05:00	2,752.3	0.0	2,752.3	104,700.0	288.2	0.35	0.2	0.6
11/28/2021 06:00	2,751.5	0.0	2,751.5	104,700.0	288.1	0.35	0.2	0.6
11/28/2021 07:00	2,909.4	0.0	2,909.4	104,700.0	304.6	0.37	0.2	0.6
11/28/2021 08:00	2,754.4	0.0	2,754.4	104,700.0	288.4	0.35	0.2	0.6
11/28/2021 09:00	2,757.6	0.0	2,757.6	104,700.0	288.7	0.35	0.2	0.6
11/28/2021 10:00	2,755.4	0.0	2,755.4	104,700.0	288.5	0.35	0.2	0.6
11/28/2021 11:00	2,752.1	0.0	2,752.1	104,700.0	288.1	0.35	0.2	0.6
11/28/2021 12:00	2,751.7	0.0	2,751.7	104,700.0	288.1	0.35	0.2	0.6
11/28/2021 13:00	2,751.1	0.0	2,751.1	104,700.0	288.0	0.35	0.2	0.6
11/28/2021 14:00	2,748.9	0.0	2,748.9	104,700.0	287.8	0.35	0.2	0.6
11/28/2021 15:00	2,764.6	0.0	2,764.6	104,700.0	289.5	0.35	0.2	0.6
11/28/2021 16:00	2,884.0	0.0	2,884.0	104,700.0	302.0	0.36	0.2	0.6
11/28/2021 17:00	2,750.9	0.0	2,750.9	104,700.0	288.0	0.35	0.2	0.6
11/28/2021 18:00	2,750.0	0.0	2,750.0	104,700.0	287.9	0.35	0.2	0.6
11/28/2021 19:00	2,754.9	0.0	2,754.9	104,700.0	288.4	0.35	0.2	0.6
11/28/2021 20:00	2,748.4	0.0	2,748.4	104,700.0	287.8	0.35	0.2	0.6
11/28/2021 21:00	2,749.8	0.0	2,749.8	104,700.0	287.9	0.35	0.2	0.6
11/28/2021 22:00	2,752.0	0.0	2,752.0	104,700.0	288.1	0.35	0.2	0.6
11/28/2021 23:00	2,751.0	0.0	2,751.0	104,700.0	288.0	0.35	0.2	0.6
Average/Sum#:	2,764.3	0.0	2,764.3	104,700.0	289.4	0.35	0.2	0.6
Minimum:	2,748.0	0.0	2,748.0	104,700.0	287.7	0.35	0.2	0.6
Maximum:	2,909.4	0.0	2,909.4	104,700.0	304.6	0.37	0.2	0.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/29/2021 00:00	2,753.4	0.0	2,753.4	104,700.0	288.3	0.35	0.2	0.6
11/29/2021 01:00	2,753.2	0.0	2,753.2	104,700.0	288.3	0.35	0.2	0.6
11/29/2021 02:00	2,754.9	0.0	2,754.9	104,700.0	288.4	0.35	0.2	0.6
11/29/2021 03:00	2,754.9	0.0	2,754.9	104,700.0	288.4	0.35	0.2	0.6
11/29/2021 04:00	2,750.9	0.0	2,750.9	104,700.0	288.0	0.35	0.2	0.6
11/29/2021 05:00	2,814.7	0.0	2,814.7	104,700.0	294.7	0.36	0.2	0.6
11/29/2021 06:00	3,387.0	0.0	3,387.0	104,700.0	354.6	0.43	0.2	0.7
11/29/2021 07:00	3,417.3	0.0	3,417.3	104,700.0	357.8	0.43	0.2	0.7
11/29/2021 08:00	2,756.9	0.0	2,756.9	104,700.0	288.6	0.35	0.2	0.6
11/29/2021 09:00	2,757.1	0.0	2,757.1	104,700.0	288.7	0.35	0.2	0.6
11/29/2021 10:00	2,755.9	0.0	2,755.9	104,700.0	288.5	0.35	0.2	0.6
11/29/2021 11:00	2,753.5	0.0	2,753.5	104,700.0	288.3	0.35	0.2	0.6
11/29/2021 12:00	2,752.0	0.0	2,752.0	104,700.0	288.1	0.35	0.2	0.6
11/29/2021 13:00	2,750.2	0.0	2,750.2	104,700.0	287.9	0.35	0.2	0.6
11/29/2021 14:00	2,749.9	0.0	2,749.9	104,700.0	287.9	0.35	0.2	0.6
11/29/2021 15:00	3,068.5	0.0	3,068.5	104,700.0	321.3	0.39	0.2	0.6
11/29/2021 16:00	3,653.1	0.0	3,653.1	104,700.0	382.5	0.46	0.2	0.8
11/29/2021 17:00	3,793.9	0.0	3,793.9	104,700.0	397.2	0.48	0.2	0.8
11/29/2021 18:00	3,126.2	0.0	3,126.2	104,700.0	327.3	0.40	0.2	0.7
11/29/2021 19:00	3,729.5	0.0	3,729.5	104,700.0	390.5	0.47	0.2	0.8
11/29/2021 20:00	4,304.0	0.0	4,304.0	104,700.0	450.6	0.54	0.3	0.9
11/29/2021 21:00	3,277.3	0.0	3,277.3	104,700.0	343.1	0.41	0.2	0.7
11/29/2021 22:00	2,876.0	0.0	2,876.0	104,700.0	301.1	0.36	0.2	0.6
11/29/2021 23:00	2,749.1	0.0	2,749.1	104,700.0	287.8	0.35	0.2	0.6
Average/Sum#:	3,051.6	0.0	3,051.6	104,700.0	319.5	0.39	0.2	0.7
Minimum:	2,749.1	0.0	2,749.1	104,700.0	287.8	0.35	0.2	0.6
Maximum:	4,304.0	0.0	4,304.0	104,700.0	450.6	0.54	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/30/2021 00:00	3,714.5	0.0	3,714.5	104,700.0	388.9	0.47	0.2	0.8
11/30/2021 01:00	2,982.7	0.0	2,982.7	104,700.0	312.3	0.37	0.2	0.6
11/30/2021 02:00	2,749.7	0.0	2,749.7	104,700.0	287.9	0.35	0.2	0.6
11/30/2021 03:00	2,749.2	0.0	2,749.2	104,700.0	287.8	0.35	0.2	0.6
11/30/2021 04:00	2,760.6	0.0	2,760.6	104,700.0	289.0	0.35	0.2	0.6
11/30/2021 05:00	3,021.6	0.0	3,021.6	104,700.0	316.4	0.38	0.2	0.6
11/30/2021 06:00	4,139.3	0.0	4,139.3	104,700.0	433.4	0.52	0.3	0.9
11/30/2021 07:00	4,135.0	0.0	4,135.0	104,700.0	432.9	0.52	0.3	0.9
11/30/2021 08:00	2,831.4	0.0	2,831.4	104,700.0	296.4	0.36	0.2	0.6
11/30/2021 09:00	2,755.4	0.0	2,755.4	104,700.0	288.5	0.35	0.2	0.6
11/30/2021 10:00	2,747.2	0.0	2,747.2	104,700.0	287.6	0.35	0.2	0.6
11/30/2021 11:00	2,751.5	0.0	2,751.5	104,700.0	288.1	0.35	0.2	0.6
11/30/2021 12:00	2,751.3	0.0	2,751.3	104,700.0	288.1	0.35	0.2	0.6
11/30/2021 13:00	2,748.1	0.0	2,748.1	104,700.0	287.7	0.35	0.2	0.6
11/30/2021 14:00	2,746.8	0.0	2,746.8	104,700.0	287.6	0.35	0.2	0.6
11/30/2021 15:00	3,275.9	0.0	3,275.9	104,700.0	343.0	0.41	0.2	0.7
11/30/2021 16:00	3,856.9	0.0	3,856.9	104,700.0	403.8	0.49	0.2	0.8
11/30/2021 17:00	4,463.6	394.3	4,633.1	104,700.0	485.1	0.61	0.3	1.0
11/30/2021 18:00	4,480.7	1,576.7	6,057.4	104,700.0	634.2	0.76	0.4	1.3
11/30/2021 19:00	4,489.0	1,531.7	6,020.7	104,700.0	630.4	0.76	0.4	1.3
11/30/2021 20:00	4,516.7	359.3	4,739.5	104,700.0	496.2	0.61	0.3	1.0
11/30/2021 21:00	4,532.8	1,177.4	5,710.2	104,700.0	597.9	0.72	0.4	1.2
11/30/2021 22:00	4,533.5	228.4	4,675.1	104,700.0	489.5	0.60	0.3	1.0
11/30/2021 23:00	3,837.3	41.8	3,849.8	104,700.0	403.1	0.49	0.2	0.8
Average/Sum#:	3,482.1	221.2	3,683.5	104,700.0	385.7	0.47	0.2	0.8
Minimum:	2,746.8	0.0	2,746.8	104,700.0	287.6	0.35	0.2	0.6
Maximum:	4,533.5	1,576.7	6,057.4	104,700.0	634.2	0.76	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/01/2021 00:00	2,748.9	0.0	2,748.9	104,700.0	287.8	0.35	0.2	0.6
12/01/2021 01:00	2,748.1	0.0	2,748.1	104,700.0	287.7	0.35	0.2	0.6
12/01/2021 02:00	2,753.1	0.0	2,753.1	104,700.0	288.2	0.35	0.2	0.6
12/01/2021 03:00	2,756.1	0.0	2,756.1	104,700.0	288.6	0.35	0.2	0.6
12/01/2021 04:00	2,752.1	0.0	2,752.1	104,700.0	288.1	0.35	0.2	0.6
12/01/2021 05:00	2,748.4	0.0	2,748.4	104,700.0	287.8	0.35	0.2	0.6
12/01/2021 06:00	2,748.9	0.0	2,748.9	104,700.0	287.8	0.35	0.2	0.6
12/01/2021 07:00	2,752.0	0.0	2,752.0	104,700.0	288.1	0.35	0.2	0.6
12/01/2021 08:00	2,754.1	0.0	2,754.1	104,700.0	288.4	0.35	0.2	0.6
12/01/2021 09:00	2,750.2	0.0	2,750.2	104,700.0	287.9	0.35	0.2	0.6
12/01/2021 10:00	2,753.2	0.0	2,753.2	104,700.0	288.3	0.35	0.2	0.6
12/01/2021 11:00	2,750.8	0.0	2,750.8	104,700.0	288.0	0.35	0.2	0.6
12/01/2021 12:00	2,752.1	0.0	2,752.1	104,700.0	288.1	0.35	0.2	0.6
12/01/2021 13:00	2,749.5	0.0	2,749.5	104,700.0	287.9	0.35	0.2	0.6
12/01/2021 14:00	2,749.1	0.0	2,749.1	104,700.0	287.8	0.35	0.2	0.6
12/01/2021 15:00	2,987.1	0.0	2,987.1	104,700.0	312.7	0.38	0.2	0.6
12/01/2021 16:00	3,462.7	0.0	3,462.7	104,700.0	362.5	0.43	0.2	0.7
12/01/2021 17:00	3,838.3	0.0	3,838.3	104,700.0	401.9	0.48	0.2	0.8
12/01/2021 18:00	4,121.8	0.0	4,121.8	104,700.0	431.6	0.52	0.3	0.9
12/01/2021 19:00	4,276.5	0.0	4,276.5	104,700.0	447.7	0.54	0.3	0.9
12/01/2021 20:00	4,093.8	0.0	4,093.8	104,700.0	428.6	0.51	0.3	0.9
12/01/2021 21:00	4,251.5	0.0	4,251.5	104,700.0	445.1	0.53	0.3	0.9
12/01/2021 22:00	2,981.8	0.0	2,981.8	104,700.0	312.2	0.38	0.2	0.6
12/01/2021 23:00	2,752.7	0.0	2,752.7	104,700.0	288.2	0.35	0.2	0.6
Average/Sum#:	3,084.7	0.0	3,084.7	104,700.0	323.0	0.39	0.2	0.7
Minimum:	2,748.1	0.0	2,748.1	104,700.0	287.7	0.35	0.2	0.6
Maximum:	4,276.5	0.0	4,276.5	104,700.0	447.7	0.54	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/02/2021 00:00	2,794.4	0.0	2,794.4	104,700.0	292.6	0.35	0.2	0.6
12/02/2021 01:00	2,950.5	0.0	2,950.5	104,700.0	308.9	0.37	0.2	0.6
12/02/2021 02:00	2,862.1	0.0	2,862.1	104,700.0	299.7	0.36	0.2	0.6
12/02/2021 03:00	3,880.3	0.0	3,880.3	104,700.0	406.3	0.49	0.2	0.8
12/02/2021 04:00	4,195.0	0.0	4,195.0	104,700.0	439.2	0.53	0.3	0.9
12/02/2021 05:00	4,343.2	52.2	4,362.5	104,700.0	456.8	0.55	0.3	0.9
12/02/2021 06:00	4,586.7	257.9	4,844.6	104,700.0	507.2	0.61	0.3	1.0
12/02/2021 07:00	4,596.3	192.5	4,679.1	104,700.0	489.9	0.60	0.3	1.0
12/02/2021 08:00	3,842.3	0.0	3,842.3	104,700.0	402.3	0.48	0.2	0.8
12/02/2021 09:00	2,754.0	0.0	2,754.0	104,700.0	288.3	0.35	0.2	0.6
12/02/2021 10:00	2,753.5	0.0	2,753.5	104,700.0	288.3	0.35	0.2	0.6
12/02/2021 11:00	2,752.8	0.0	2,752.8	104,700.0	288.2	0.35	0.2	0.6
12/02/2021 12:00	2,749.2	0.0	2,749.2	104,700.0	287.8	0.35	0.2	0.6
12/02/2021 13:00	2,748.9	0.0	2,748.9	104,700.0	287.8	0.35	0.2	0.6
12/02/2021 14:00	2,748.8	0.0	2,748.8	104,700.0	287.8	0.35	0.2	0.6
12/02/2021 15:00	3,126.0	0.0	3,126.0	104,700.0	327.3	0.40	0.2	0.7
12/02/2021 16:00	3,634.5	66.6	3,654.5	104,700.0	382.6	0.46	0.2	0.8
12/02/2021 17:00	4,453.3	911.2	5,364.5	104,700.0	561.7	0.67	0.3	1.1
12/02/2021 18:00	4,469.5	363.6	4,767.7	104,700.0	499.2	0.61	0.3	1.0
12/02/2021 19:00	4,470.8	262.7	4,715.1	104,700.0	493.7	0.59	0.3	1.0
12/02/2021 20:00	4,491.6	422.7	4,914.3	104,700.0	514.5	0.62	0.3	1.0
12/02/2021 21:00	4,502.8	391.7	4,894.5	104,700.0	512.5	0.61	0.3	1.0
12/02/2021 22:00	3,812.0	134.5	3,876.6	104,700.0	405.9	0.49	0.2	0.8
12/02/2021 23:00	2,747.2	0.0	2,747.2	104,700.0	287.6	0.35	0.2	0.6
Average/Sum#:	3,594.4	127.3	3,707.4	104,700.0	388.2	0.47	0.2	0.8
Minimum:	2,747.2	0.0	2,747.2	104,700.0	287.6	0.35	0.2	0.6
Maximum:	4,596.3	911.2	5,364.5	104,700.0	561.7	0.67	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/03/2021 00:00	2,746.4	0.0	2,746.4	104,700.0	287.5	0.35	0.2	0.6
12/03/2021 01:00	2,748.7	0.0	2,748.7	104,700.0	287.8	0.35	0.2	0.6
12/03/2021 02:00	2,748.0	0.0	2,748.0	104,700.0	287.7	0.35	0.2	0.6
12/03/2021 03:00	2,746.9	0.0	2,746.9	104,700.0	287.6	0.35	0.2	0.6
12/03/2021 04:00	2,746.0	0.0	2,746.0	104,700.0	287.5	0.35	0.2	0.6
12/03/2021 05:00	2,840.0	0.0	2,840.0	104,700.0	297.3	0.36	0.2	0.6
12/03/2021 06:00	2,868.3	0.0	2,868.3	104,700.0	300.3	0.36	0.2	0.6
12/03/2021 07:00	3,243.1	0.0	3,243.1	104,700.0	339.6	0.41	0.2	0.7
12/03/2021 08:00	2,802.4	0.0	2,802.4	104,700.0	293.4	0.35	0.2	0.6
12/03/2021 09:00	3,549.5	0.0	3,549.5	104,700.0	371.6	0.45	0.2	0.7
12/03/2021 10:00	4,371.7	0.0	4,371.7	104,700.0	457.7	0.55	0.3	0.9
12/03/2021 11:00	3,617.4	0.0	3,617.4	104,700.0	378.7	0.46	0.2	0.8
12/03/2021 12:00	3,265.0	0.0	3,265.0	104,700.0	341.8	0.41	0.2	0.7
12/03/2021 13:00	2,758.8	0.0	2,758.8	104,700.0	288.8	0.35	0.2	0.6
12/03/2021 14:00	2,756.5	0.0	2,756.5	104,700.0	288.6	0.35	0.2	0.6
12/03/2021 15:00	3,507.7	0.0	3,507.7	104,700.0	367.3	0.44	0.2	0.7
12/03/2021 16:00	4,017.5	126.5	4,065.6	104,700.0	425.7	0.52	0.3	0.9
12/03/2021 17:00	4,501.8	318.2	4,820.0	104,700.0	504.7	0.61	0.3	1.0
12/03/2021 18:00	4,516.9	284.3	4,801.2	104,700.0	502.7	0.60	0.3	1.0
12/03/2021 19:00	4,529.5	262.9	4,792.4	104,700.0	501.8	0.60	0.3	1.0
12/03/2021 20:00	4,536.4	256.6	4,793.0	104,700.0	501.8	0.60	0.3	1.0
12/03/2021 21:00	4,531.8	259.9	4,791.7	104,700.0	501.7	0.60	0.3	1.0
12/03/2021 22:00	4,526.0	263.3	4,789.3	104,700.0	501.4	0.60	0.3	1.0
12/03/2021 23:00	3,835.4	127.1	3,901.5	104,700.0	408.5	0.50	0.2	0.8
Average/Sum#:	3,513.0	79.1	3,586.3	104,700.0	375.5	0.45	0.2	0.8
Minimum:	2,746.0	0.0	2,746.0	104,700.0	287.5	0.35	0.2	0.6
Maximum:	4,536.4	318.2	4,820.0	104,700.0	504.7	0.61	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/04/2021 00:00	2,748.9	0.0	2,748.9	104,700.0	287.8	0.35	0.2	0.6
12/04/2021 01:00	2,751.2	0.0	2,751.2	104,700.0	288.1	0.35	0.2	0.6
12/04/2021 02:00	2,764.5	0.0	2,764.5	104,700.0	289.4	0.35	0.2	0.6
12/04/2021 03:00	2,951.3	0.0	2,951.3	104,700.0	309.0	0.37	0.2	0.6
12/04/2021 04:00	3,342.5	0.0	3,342.5	104,700.0	350.0	0.42	0.2	0.7
12/04/2021 05:00	3,202.4	0.0	3,202.4	104,700.0	335.3	0.40	0.2	0.7
12/04/2021 06:00	3,095.8	0.0	3,095.8	104,700.0	324.1	0.39	0.2	0.6
12/04/2021 07:00	3,469.4	0.0	3,469.4	104,700.0	363.2	0.44	0.2	0.7
12/04/2021 08:00	3,113.5	0.0	3,113.5	104,700.0	326.0	0.39	0.2	0.7
12/04/2021 09:00	3,849.2	0.0	3,849.2	104,700.0	403.0	0.48	0.2	0.8
12/04/2021 10:00	3,175.4	0.0	3,175.4	104,700.0	332.5	0.40	0.2	0.7
12/04/2021 11:00	3,965.1	0.0	3,965.1	104,700.0	415.1	0.50	0.2	0.8
12/04/2021 12:00	2,760.5	0.0	2,760.5	104,700.0	289.0	0.35	0.2	0.6
12/04/2021 13:00	3,007.7	0.0	3,007.7	104,700.0	314.9	0.38	0.2	0.6
12/04/2021 14:00	2,871.8	0.0	2,871.8	104,700.0	300.7	0.36	0.2	0.6
12/04/2021 15:00	3,257.5	0.0	3,257.5	104,700.0	341.1	0.41	0.2	0.7
12/04/2021 16:00	3,944.2	0.0	3,944.2	104,700.0	413.0	0.50	0.2	0.8
12/04/2021 17:00	4,439.3	87.9	4,483.3	104,700.0	469.4	0.57	0.3	0.9
12/04/2021 18:00	4,584.8	155.6	4,740.4	104,700.0	496.3	0.60	0.3	1.0
12/04/2021 19:00	4,592.7	148.3	4,741.0	104,700.0	496.4	0.60	0.3	1.0
12/04/2021 20:00	4,589.0	158.9	4,747.9	104,700.0	497.1	0.60	0.3	1.0
12/04/2021 21:00	4,583.2	163.3	4,746.5	104,700.0	497.0	0.60	0.3	1.0
12/04/2021 22:00	2,945.6	0.6	2,945.6	104,700.0	308.4	0.37	0.2	0.6
12/04/2021 23:00	2,758.8	0.0	2,758.8	104,700.0	288.8	0.35	0.2	0.6
Average/Sum#:	3,448.5	29.8	3,476.4	104,700.0	364.0	0.44	0.2	0.7
Minimum:	2,748.9	0.0	2,748.9	104,700.0	287.8	0.35	0.2	0.6
Maximum:	4,592.7	163.3	4,747.9	104,700.0	497.1	0.60	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/05/2021 00:00	2,759.4	0.0	2,759.4	104,700.0	288.9	0.35	0.2	0.6
12/05/2021 01:00	2,758.9	0.0	2,758.9	104,700.0	288.9	0.35	0.2	0.6
12/05/2021 02:00	2,755.1	0.0	2,755.1	104,700.0	288.5	0.35	0.2	0.6
12/05/2021 03:00	2,752.6	0.0	2,752.6	104,700.0	288.2	0.35	0.2	0.6
12/05/2021 04:00	2,766.8	0.0	2,766.8	104,700.0	289.7	0.35	0.2	0.6
12/05/2021 05:00	2,761.9	0.0	2,761.9	104,700.0	289.2	0.35	0.2	0.6
12/05/2021 06:00	3,278.1	0.0	3,278.1	104,700.0	343.2	0.41	0.2	0.7
12/05/2021 07:00	3,146.3	0.0	3,146.3	104,700.0	329.4	0.40	0.2	0.7
12/05/2021 08:00	3,813.7	0.0	3,813.7	104,700.0	399.3	0.48	0.2	0.8
12/05/2021 09:00	4,424.4	0.0	4,424.4	104,700.0	463.2	0.56	0.3	0.9
12/05/2021 10:00	4,417.3	0.0	4,417.3	104,700.0	462.5	0.56	0.3	0.9
12/05/2021 11:00	4,229.9	0.0	4,229.9	104,700.0	442.9	0.53	0.3	0.9
12/05/2021 12:00	2,782.2	0.0	2,782.2	104,700.0	291.3	0.35	0.2	0.6
12/05/2021 13:00	3,472.5	0.0	3,472.5	104,700.0	363.6	0.44	0.2	0.7
12/05/2021 14:00	3,052.2	0.0	3,052.2	104,700.0	319.6	0.39	0.2	0.6
12/05/2021 15:00	2,916.9	0.0	2,916.9	104,700.0	305.4	0.37	0.2	0.6
12/05/2021 16:00	3,280.3	0.0	3,280.3	104,700.0	343.4	0.41	0.2	0.7
12/05/2021 17:00	3,450.3	0.0	3,450.3	104,700.0	361.2	0.43	0.2	0.7
12/05/2021 18:00	4,198.4	0.0	4,198.4	104,700.0	439.6	0.53	0.3	0.9
12/05/2021 19:00	4,432.0	0.0	4,432.0	104,700.0	464.0	0.56	0.3	0.9
12/05/2021 20:00	4,440.0	0.0	4,440.0	104,700.0	464.9	0.56	0.3	0.9
12/05/2021 21:00	4,252.7	0.0	4,252.7	104,700.0	445.3	0.54	0.3	0.9
12/05/2021 22:00	4,298.6	0.0	4,298.6	104,700.0	450.1	0.54	0.3	0.9
12/05/2021 23:00	3,629.1	0.0	3,629.1	104,700.0	380.0	0.46	0.2	0.8
Average/Sum#:	3,502.9	0.0	3,502.9	104,700.0	366.8	0.44	0.2	0.7
Minimum:	2,752.6	0.0	2,752.6	104,700.0	288.2	0.35	0.2	0.6
Maximum:	4,440.0	0.0	4,440.0	104,700.0	464.9	0.56	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/06/2021 00:00	3,178.3	0.0	3,178.3	104,700.0	332.8	0.40	0.2	0.7
12/06/2021 01:00	2,773.6	0.0	2,773.6	104,700.0	290.4	0.35	0.2	0.6
12/06/2021 02:00	2,766.3	0.0	2,766.3	104,700.0	289.6	0.35	0.2	0.6
12/06/2021 03:00	2,779.4	0.0	2,779.4	104,700.0	291.0	0.35	0.2	0.6
12/06/2021 04:00	2,778.8	0.0	2,778.8	104,700.0	290.9	0.35	0.2	0.6
12/06/2021 05:00	3,531.8	0.0	3,531.8	104,700.0	369.8	0.44	0.2	0.7
12/06/2021 06:00	4,381.1	0.0	4,381.1	104,700.0	458.7	0.55	0.3	0.9
12/06/2021 07:00	4,440.7	0.0	4,440.7	104,700.0	464.9	0.56	0.3	0.9
12/06/2021 08:00	4,398.9	0.0	4,398.9	104,700.0	460.6	0.55	0.3	0.9
12/06/2021 09:00	4,437.9	0.0	4,437.9	104,700.0	464.6	0.56	0.3	0.9
12/06/2021 10:00	4,435.1	0.0	4,435.1	104,700.0	464.4	0.56	0.3	0.9
12/06/2021 11:00	4,436.1	0.0	4,436.1	104,700.0	464.5	0.56	0.3	0.9
12/06/2021 12:00	4,435.0	0.0	4,435.0	104,700.0	464.3	0.56	0.3	0.9
12/06/2021 13:00	4,433.4	0.0	4,433.4	104,700.0	464.2	0.56	0.3	0.9
12/06/2021 14:00	4,428.3	0.0	4,428.3	104,700.0	463.6	0.56	0.3	0.9
12/06/2021 15:00	4,430.1	0.0	4,430.1	104,700.0	463.8	0.56	0.3	0.9
12/06/2021 16:00	4,490.6	251.2	4,623.7	104,700.0	484.1	0.60	0.3	1.0
12/06/2021 17:00	4,574.2	238.5	4,812.7	104,700.0	503.9	0.61	0.3	1.0
12/06/2021 18:00	4,574.4	370.5	4,944.9	104,700.0	517.7	0.62	0.3	1.0
12/06/2021 19:00	4,570.2	245.8	4,816.0	104,700.0	504.2	0.60	0.3	1.0
12/06/2021 20:00	4,565.9	320.3	4,886.2	104,700.0	511.6	0.61	0.3	1.0
12/06/2021 21:00	4,567.8	264.6	4,832.4	104,700.0	506.0	0.61	0.3	1.0
12/06/2021 22:00	4,489.6	173.2	4,616.0	104,700.0	483.3	0.58	0.3	1.0
12/06/2021 23:00	4,398.5	0.0	4,398.5	104,700.0	460.5	0.55	0.3	0.9
Average/Sum#:	4,095.7	77.7	4,166.5	104,700.0	436.2	0.53	0.3	0.9
Minimum:	2,766.3	0.0	2,766.3	104,700.0	289.6	0.35	0.2	0.6
Maximum:	4,574.4	370.5	4,944.9	104,700.0	517.7	0.62	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/07/2021 00:00	3,985.1	0.0	3,985.1	104,700.0	417.2	0.50	0.3	0.8
12/07/2021 01:00	3,168.8	0.0	3,168.8	104,700.0	331.8	0.40	0.2	0.7
12/07/2021 02:00	2,769.3	0.0	2,769.3	104,500.0	289.4	0.35	0.2	0.6
12/07/2021 03:00	2,766.6	0.0	2,766.6	104,500.0	289.1	0.35	0.2	0.6
12/07/2021 04:00	3,334.9	0.0	3,334.9	104,500.0	348.5	0.42	0.2	0.7
12/07/2021 05:00	2,772.7	0.0	2,772.7	104,500.0	289.7	0.35	0.2	0.6
12/07/2021 06:00	3,383.7	0.0	3,383.7	104,500.0	353.6	0.42	0.2	0.7
12/07/2021 07:00	4,431.7	0.0	4,431.7	104,500.0	463.1	0.56	0.3	0.9
12/07/2021 08:00	4,423.7	0.0	4,423.7	104,500.0	462.3	0.55	0.3	0.9
12/07/2021 09:00	4,423.0	0.0	4,423.0	104,500.0	462.2	0.55	0.3	0.9
12/07/2021 10:00	3,824.0	0.0	3,824.0	104,500.0	399.6	0.48	0.2	0.8
12/07/2021 11:00	3,363.9	0.0	3,363.9	104,500.0	351.5	0.42	0.2	0.7
12/07/2021 12:00	4,066.8	0.0	4,066.8	104,500.0	425.0	0.51	0.3	0.8
12/07/2021 13:00	4,437.4	0.0	4,437.4	104,500.0	463.7	0.56	0.3	0.9
12/07/2021 14:00	4,420.4	0.0	4,420.4	104,500.0	461.9	0.55	0.3	0.9
12/07/2021 15:00	4,306.9	0.0	4,306.9	104,500.0	450.1	0.54	0.3	0.9
12/07/2021 16:00	4,487.8	172.3	4,560.2	104,500.0	476.5	0.58	0.3	1.0
12/07/2021 17:00	4,533.4	268.6	4,802.0	104,500.0	501.8	0.60	0.3	1.0
12/07/2021 18:00	4,546.8	469.1	5,015.9	104,500.0	524.2	0.63	0.3	1.0
12/07/2021 19:00	4,539.1	727.1	5,266.2	104,500.0	550.3	0.66	0.3	1.1
12/07/2021 20:00	4,542.9	320.1	4,863.0	104,500.0	508.2	0.61	0.3	1.0
12/07/2021 21:00	4,553.1	324.9	4,878.0	104,500.0	509.8	0.61	0.3	1.0
12/07/2021 22:00	4,552.0	327.3	4,879.3	104,500.0	509.9	0.61	0.3	1.0
12/07/2021 23:00	4,431.1	201.9	4,586.6	104,500.0	479.3	0.58	0.3	1.0
Average/Sum#:	4,002.7	117.1	4,113.8	104,516.7	429.9	0.52	0.3	0.9
Minimum:	2,766.6	0.0	2,766.6	104,500.0	289.1	0.35	0.2	0.6
Maximum:	4,553.1	727.1	5,266.2	104,700.0	550.3	0.66	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/08/2021 00:00	3,798.4	0.0	3,798.4	104,500.0	396.9	0.48	0.2	0.8
12/08/2021 01:00	3,496.4	0.0	3,496.4	104,500.0	365.4	0.44	0.2	0.7
12/08/2021 02:00	2,760.8	0.0	2,760.8	104,500.0	288.5	0.35	0.2	0.6
12/08/2021 03:00	2,786.5	0.0	2,786.5	104,500.0	291.2	0.35	0.2	0.6
12/08/2021 04:00	2,810.8	0.0	2,810.8	104,500.0	293.7	0.35	0.2	0.6
12/08/2021 05:00	2,804.8	0.0	2,804.8	104,500.0	293.1	0.35	0.2	0.6
12/08/2021 06:00	4,080.5	0.0	4,080.5	104,500.0	426.4	0.51	0.3	0.9
12/08/2021 07:00	4,139.8	0.0	4,139.8	104,500.0	432.6	0.52	0.3	0.9
12/08/2021 08:00	3,008.8	0.0	3,008.8	104,500.0	314.4	0.38	0.2	0.6
12/08/2021 09:00	2,761.7	0.0	2,761.7	104,500.0	288.6	0.35	0.2	0.6
12/08/2021 10:00	2,763.4	0.0	2,763.4	104,500.0	288.8	0.35	0.2	0.6
12/08/2021 11:00	4,107.8	104.0	4,151.5	104,500.0	433.8	0.53	0.3	0.9
12/08/2021 12:00	4,086.3	65.8	4,104.1	104,500.0	428.9	0.52	0.3	0.9
12/08/2021 13:00	2,800.0	0.0	2,800.0	104,500.0	292.6	0.35	0.2	0.6
12/08/2021 14:00	2,763.3	0.0	2,763.3	104,500.0	288.8	0.35	0.2	0.6
12/08/2021 15:00	2,862.7	0.0	2,862.7	104,500.0	299.2	0.36	0.2	0.6
12/08/2021 16:00	3,485.8	0.0	3,485.8	104,500.0	364.3	0.44	0.2	0.7
12/08/2021 17:00	4,401.4	0.0	4,401.4	104,500.0	459.9	0.55	0.3	0.9
12/08/2021 18:00	4,243.4	0.0	4,243.4	104,500.0	443.4	0.53	0.3	0.9
12/08/2021 19:00	4,420.9	0.0	4,420.9	104,500.0	462.0	0.55	0.3	0.9
12/08/2021 20:00	4,249.3	0.0	4,249.3	104,500.0	444.1	0.53	0.3	0.9
12/08/2021 21:00	3,612.9	0.0	3,612.9	104,500.0	377.5	0.45	0.2	0.8
12/08/2021 22:00	2,749.2	0.0	2,749.2	104,500.0	287.3	0.34	0.2	0.6
12/08/2021 23:00	2,750.0	0.0	2,750.0	104,500.0	287.4	0.34	0.2	0.6
Average/Sum#:	3,406.0	7.1	3,408.6	104,500.0	356.2	0.43	0.2	0.7
Minimum:	2,749.2	0.0	2,749.2	104,500.0	287.3	0.34	0.2	0.6
Maximum:	4,420.9	104.0	4,420.9	104,500.0	462.0	0.55	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/09/2021 00:00	2,768.5	0.0	2,768.5	104,500.0	289.3	0.35	0.2	0.6
12/09/2021 01:00	2,770.1	0.0	2,770.1	104,500.0	289.5	0.35	0.2	0.6
12/09/2021 02:00	2,758.7	0.0	2,758.7	104,500.0	288.3	0.35	0.2	0.6
12/09/2021 03:00	2,766.1	0.0	2,766.1	104,500.0	289.1	0.35	0.2	0.6
12/09/2021 04:00	2,772.3	0.0	2,772.3	104,500.0	289.7	0.35	0.2	0.6
12/09/2021 05:00	2,768.4	0.0	2,768.4	104,500.0	289.3	0.35	0.2	0.6
12/09/2021 06:00	3,579.9	0.0	3,579.9	104,500.0	374.1	0.45	0.2	0.7
12/09/2021 07:00	3,173.8	0.0	3,173.8	104,500.0	331.7	0.40	0.2	0.7
12/09/2021 08:00	2,901.5	0.0	2,901.5	104,500.0	303.2	0.36	0.2	0.6
12/09/2021 09:00	3,668.8	0.0	3,668.8	104,500.0	383.4	0.46	0.2	0.8
12/09/2021 10:00	3,211.1	0.0	3,211.1	104,500.0	335.6	0.40	0.2	0.7
12/09/2021 11:00	2,757.9	0.0	2,757.9	104,500.0	288.2	0.34	0.2	0.6
12/09/2021 12:00	2,831.9	0.0	2,831.9	104,500.0	295.9	0.35	0.2	0.6
12/09/2021 13:00	2,748.8	0.0	2,748.8	104,500.0	287.2	0.34	0.2	0.6
12/09/2021 14:00	2,745.8	0.0	2,745.8	104,500.0	286.9	0.34	0.2	0.6
12/09/2021 15:00	2,842.1	0.0	2,842.1	104,500.0	297.0	0.35	0.2	0.6
12/09/2021 16:00	3,738.3	0.0	3,738.3	104,500.0	390.7	0.47	0.2	0.8
12/09/2021 17:00	3,715.1	0.0	3,715.1	104,500.0	388.2	0.47	0.2	0.8
12/09/2021 18:00	3,156.3	0.0	3,156.3	104,500.0	329.8	0.39	0.2	0.7
12/09/2021 19:00	3,531.8	0.0	3,531.8	104,500.0	369.1	0.44	0.2	0.7
12/09/2021 20:00	4,019.5	0.0	4,019.5	104,500.0	420.0	0.50	0.3	0.8
12/09/2021 21:00	3,749.7	0.0	3,749.7	104,500.0	391.8	0.47	0.2	0.8
12/09/2021 22:00	3,179.5	0.0	3,179.5	104,500.0	332.3	0.40	0.2	0.7
12/09/2021 23:00	2,757.2	0.0	2,757.2	104,500.0	288.1	0.35	0.2	0.6
Average/Sum#:	3,121.4	0.0	3,121.4	104,500.0	326.2	0.39	0.2	0.7
Minimum:	2,745.8	0.0	2,745.8	104,500.0	286.9	0.34	0.2	0.6
Maximum:	4,019.5	0.0	4,019.5	104,500.0	420.0	0.50	0.3	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/10/2021 00:00	2,801.7	0.0	2,801.7	104,500.0	292.8	0.35	0.2	0.6
12/10/2021 01:00	2,771.2	0.0	2,771.2	104,500.0	289.6	0.35	0.2	0.6
12/10/2021 02:00	2,768.2	0.0	2,768.2	104,500.0	289.3	0.35	0.2	0.6
12/10/2021 03:00	2,769.5	0.0	2,769.5	104,500.0	289.4	0.35	0.2	0.6
12/10/2021 04:00	2,762.7	0.0	2,762.7	104,500.0	288.7	0.35	0.2	0.6
12/10/2021 05:00	3,055.9	0.0	3,055.9	104,500.0	319.3	0.38	0.2	0.6
12/10/2021 06:00	3,705.3	0.0	3,705.3	104,500.0	387.2	0.47	0.2	0.8
12/10/2021 07:00	4,363.5	0.0	4,363.5	104,500.0	456.0	0.55	0.3	0.9
12/10/2021 08:00	3,213.9	0.0	3,213.9	104,500.0	335.9	0.40	0.2	0.7
12/10/2021 09:00	2,763.0	0.0	2,763.0	104,500.0	288.7	0.35	0.2	0.6
12/10/2021 10:00	3,052.6	0.0	3,052.6	104,500.0	319.0	0.39	0.2	0.6
12/10/2021 11:00	4,241.3	0.0	4,241.3	104,500.0	443.2	0.53	0.3	0.9
12/10/2021 12:00	3,360.4	0.0	3,360.4	104,500.0	351.2	0.42	0.2	0.7
12/10/2021 13:00	2,796.8	0.0	2,796.8	104,500.0	292.3	0.35	0.2	0.6
12/10/2021 14:00	2,757.2	0.0	2,757.2	104,500.0	288.1	0.35	0.2	0.6
12/10/2021 15:00	3,464.3	0.0	3,464.3	104,500.0	362.0	0.44	0.2	0.7
12/10/2021 16:00	4,303.9	0.0	4,303.9	104,500.0	449.8	0.54	0.3	0.9
12/10/2021 17:00	4,429.9	0.0	4,429.9	104,500.0	462.9	0.56	0.3	0.9
12/10/2021 18:00	4,428.3	0.0	4,428.3	104,500.0	462.8	0.56	0.3	0.9
12/10/2021 19:00	4,437.0	0.0	4,437.0	104,500.0	463.7	0.56	0.3	0.9
12/10/2021 20:00	4,446.5	0.0	4,446.5	104,500.0	464.7	0.56	0.3	0.9
12/10/2021 21:00	4,444.3	0.0	4,444.3	104,500.0	464.4	0.56	0.3	0.9
12/10/2021 22:00	4,440.9	0.0	4,440.9	104,500.0	464.1	0.56	0.3	0.9
12/10/2021 23:00	4,447.9	0.0	4,447.9	104,500.0	464.8	0.56	0.3	0.9
Average/Sum#:	3,584.4	0.0	3,584.4	104,500.0	374.6	0.45	0.2	0.7
Minimum:	2,757.2	0.0	2,757.2	104,500.0	288.1	0.35	0.2	0.6
Maximum:	4,447.9	0.0	4,447.9	104,500.0	464.8	0.56	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/11/2021 00:00	3,378.4	0.0	3,378.4	104,500.0	353.0	0.42	0.2	0.7
12/11/2021 01:00	2,779.0	0.0	2,779.0	104,500.0	290.4	0.35	0.2	0.6
12/11/2021 02:00	2,779.2	0.0	2,779.2	104,500.0	290.4	0.35	0.2	0.6
12/11/2021 03:00	2,773.0	0.0	2,773.0	104,500.0	289.8	0.35	0.2	0.6
12/11/2021 04:00	2,775.9	0.0	2,775.9	104,500.0	290.1	0.35	0.2	0.6
12/11/2021 05:00	2,785.0	0.0	2,785.0	104,500.0	291.0	0.35	0.2	0.6
12/11/2021 06:00	3,054.5	0.0	3,054.5	104,500.0	319.2	0.38	0.2	0.6
12/11/2021 07:00	3,174.6	0.0	3,174.6	104,500.0	331.7	0.40	0.2	0.7
12/11/2021 08:00	2,765.7	0.0	2,765.7	104,500.0	289.0	0.35	0.2	0.6
12/11/2021 09:00	2,769.7	0.0	2,769.7	104,500.0	289.4	0.35	0.2	0.6
12/11/2021 10:00	2,768.2	0.0	2,768.2	104,500.0	289.3	0.35	0.2	0.6
12/11/2021 11:00	2,770.4	0.0	2,770.4	104,500.0	289.5	0.35	0.2	0.6
12/11/2021 12:00	2,767.7	0.0	2,767.7	104,500.0	289.2	0.35	0.2	0.6
12/11/2021 13:00	2,766.5	0.0	2,766.5	104,500.0	289.1	0.35	0.2	0.6
12/11/2021 14:00	2,762.4	0.0	2,762.4	104,500.0	288.7	0.35	0.2	0.6
12/11/2021 15:00	2,770.7	0.0	2,770.7	104,500.0	289.5	0.35	0.2	0.6
12/11/2021 16:00	3,728.2	0.0	3,728.2	104,500.0	389.6	0.47	0.2	0.8
12/11/2021 17:00	4,112.0	0.0	4,112.0	104,500.0	429.7	0.52	0.3	0.9
12/11/2021 18:00	4,015.7	0.0	4,015.7	104,500.0	419.6	0.50	0.3	0.8
12/11/2021 19:00	4,413.7	0.0	4,413.7	104,500.0	461.2	0.55	0.3	0.9
12/11/2021 20:00	4,407.7	0.0	4,407.7	104,500.0	460.6	0.55	0.3	0.9
12/11/2021 21:00	4,462.1	0.0	4,462.1	104,500.0	466.3	0.56	0.3	0.9
12/11/2021 22:00	4,464.0	0.0	4,464.0	104,500.0	466.5	0.56	0.3	0.9
12/11/2021 23:00	3,542.9	0.0	3,542.9	104,500.0	370.2	0.45	0.2	0.7
Average/Sum#:	3,282.8	0.0	3,282.8	104,500.0	343.0	0.41	0.2	0.7
Minimum:	2,762.4	0.0	2,762.4	104,500.0	288.7	0.35	0.2	0.6
Maximum:	4,464.0	0.0	4,464.0	104,500.0	466.5	0.56	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/12/2021 00:00	3,687.8	0.0	3,687.8	104,500.0	385.4	0.46	0.2	0.8
12/12/2021 01:00	2,776.5	0.0	2,776.5	104,500.0	290.1	0.35	0.2	0.6
12/12/2021 02:00	2,802.2	0.0	2,802.2	104,500.0	292.8	0.35	0.2	0.6
12/12/2021 03:00	4,082.1	0.0	4,082.1	104,500.0	426.6	0.51	0.3	0.9
12/12/2021 04:00	3,242.5	0.0	3,242.5	104,500.0	338.8	0.41	0.2	0.7
12/12/2021 05:00	2,782.7	0.0	2,782.7	104,500.0	290.8	0.35	0.2	0.6
12/12/2021 06:00	3,248.9	0.0	3,248.9	104,500.0	339.5	0.41	0.2	0.7
12/12/2021 07:00	3,093.3	0.0	3,093.3	104,500.0	323.2	0.39	0.2	0.6
12/12/2021 08:00	3,084.3	0.0	3,084.3	104,500.0	322.3	0.39	0.2	0.6
12/12/2021 09:00	2,846.0	0.0	2,846.0	104,500.0	297.4	0.36	0.2	0.6
12/12/2021 10:00	2,767.2	0.0	2,767.2	104,500.0	289.2	0.35	0.2	0.6
12/12/2021 11:00	2,763.9	0.0	2,763.9	104,500.0	288.8	0.35	0.2	0.6
12/12/2021 12:00	2,757.0	0.0	2,757.0	104,500.0	288.1	0.35	0.2	0.6
12/12/2021 13:00	2,758.7	0.0	2,758.7	104,500.0	288.3	0.35	0.2	0.6
12/12/2021 14:00	2,800.7	0.0	2,800.7	104,500.0	292.7	0.35	0.2	0.6
12/12/2021 15:00	3,035.8	0.0	3,035.8	104,500.0	317.2	0.38	0.2	0.6
12/12/2021 16:00	3,707.4	0.0	3,707.4	104,500.0	387.4	0.47	0.2	0.8
12/12/2021 17:00	4,052.7	0.0	4,052.7	104,500.0	423.5	0.51	0.3	0.8
12/12/2021 18:00	4,053.2	0.0	4,053.2	104,500.0	423.6	0.51	0.3	0.8
12/12/2021 19:00	4,360.7	0.0	4,360.7	104,500.0	455.7	0.55	0.3	0.9
12/12/2021 20:00	4,183.1	0.0	4,183.1	104,500.0	437.1	0.53	0.3	0.9
12/12/2021 21:00	3,892.2	0.0	3,892.2	104,500.0	406.7	0.49	0.2	0.8
12/12/2021 22:00	3,514.3	0.0	3,514.3	104,500.0	367.2	0.44	0.2	0.7
12/12/2021 23:00	2,754.9	0.0	2,754.9	104,500.0	287.9	0.35	0.2	0.6
Average/Sum#:	3,293.7	0.0	3,293.7	104,500.0	344.2	0.42	0.2	0.7
Minimum:	2,754.9	0.0	2,754.9	104,500.0	287.9	0.35	0.2	0.6
Maximum:	4,360.7	0.0	4,360.7	104,500.0	455.7	0.55	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/13/2021 00:00	2,761.0	0.0	2,761.0	104,500.0	288.5	0.35	0.2	0.6
12/13/2021 01:00	2,768.9	0.0	2,768.9	104,500.0	289.4	0.35	0.2	0.6
12/13/2021 02:00	2,768.2	0.0	2,768.2	104,500.0	289.3	0.35	0.2	0.6
12/13/2021 03:00	2,755.5	0.0	2,755.5	104,500.0	287.9	0.35	0.2	0.6
12/13/2021 04:00	2,751.9	0.0	2,751.9	104,500.0	287.6	0.35	0.2	0.6
12/13/2021 05:00	2,752.4	0.0	2,752.4	104,500.0	287.6	0.35	0.2	0.6
12/13/2021 06:00	3,632.5	0.0	3,632.5	104,500.0	379.6	0.46	0.2	0.8
12/13/2021 07:00	4,315.4	0.0	4,315.4	104,500.0	451.0	0.54	0.3	0.9
12/13/2021 08:00	4,227.7	0.0	4,227.7	104,500.0	441.8	0.53	0.3	0.9
12/13/2021 09:00	4,308.8	0.0	4,308.8	104,500.0	450.3	0.54	0.3	0.9
12/13/2021 10:00	3,710.8	0.0	3,710.8	104,500.0	387.8	0.47	0.2	0.8
12/13/2021 11:00	3,047.8	0.0	3,047.8	104,500.0	318.5	0.38	0.2	0.6
12/13/2021 12:00	4,366.4	0.0	4,366.4	104,500.0	456.3	0.55	0.3	0.9
12/13/2021 13:00	4,483.1	0.0	4,483.1	104,500.0	468.5	0.56	0.3	0.9
12/13/2021 14:00	4,429.9	0.0	4,429.9	104,500.0	462.9	0.56	0.3	0.9
12/13/2021 15:00	4,430.4	0.0	4,430.4	104,500.0	463.0	0.56	0.3	0.9
12/13/2021 16:00	4,470.9	272.2	4,566.2	104,500.0	477.2	0.60	0.3	1.0
12/13/2021 17:00	4,499.6	502.5	5,002.1	104,500.0	522.7	0.63	0.3	1.0
12/13/2021 18:00	4,501.8	386.1	4,887.9	104,500.0	510.8	0.61	0.3	1.0
12/13/2021 19:00	4,499.5	388.7	4,888.2	104,500.0	510.8	0.61	0.3	1.0
12/13/2021 20:00	4,496.8	390.2	4,887.0	104,500.0	510.7	0.61	0.3	1.0
12/13/2021 21:00	4,526.4	362.0	4,888.4	104,500.0	510.8	0.61	0.3	1.0
12/13/2021 22:00	3,857.2	137.5	3,928.7	104,500.0	410.5	0.50	0.3	0.8
12/13/2021 23:00	2,759.4	0.0	2,759.4	104,500.0	288.4	0.35	0.2	0.6
Average/Sum#:	3,796.8	101.6	3,888.3	104,500.0	406.3	0.49	0.3	0.8
Minimum:	2,751.9	0.0	2,751.9	104,500.0	287.6	0.35	0.2	0.6
Maximum:	4,526.4	502.5	5,002.1	104,500.0	522.7	0.63	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/14/2021 00:00	2,769.1	0.0	2,769.1	104,500.0	289.4	0.35	0.2	0.6
12/14/2021 01:00	2,763.4	0.0	2,763.4	104,500.0	288.8	0.35	0.2	0.6
12/14/2021 02:00	2,759.9	0.0	2,759.9	104,500.0	288.4	0.35	0.2	0.6
12/14/2021 03:00	2,754.0	0.0	2,754.0	104,500.0	287.8	0.35	0.2	0.6
12/14/2021 04:00	2,744.8	0.0	2,744.8	104,500.0	286.8	0.34	0.2	0.6
12/14/2021 05:00	3,224.3	0.0	3,224.3	104,500.0	336.9	0.41	0.2	0.7
12/14/2021 06:00	3,888.8	0.0	3,888.8	104,500.0	406.4	0.49	0.2	0.8
12/14/2021 07:00	2,935.4	0.0	2,935.4	104,500.0	306.7	0.37	0.2	0.6
12/14/2021 08:00	2,784.2	0.0	2,784.2	104,500.0	290.9	0.35	0.2	0.6
12/14/2021 09:00	2,760.1	0.0	2,760.1	104,500.0	288.4	0.35	0.2	0.6
12/14/2021 10:00	2,761.5	0.0	2,761.5	104,500.0	288.6	0.35	0.2	0.6
12/14/2021 11:00	2,759.0	0.0	2,759.0	104,500.0	288.3	0.35	0.2	0.6
12/14/2021 12:00	2,753.7	0.0	2,753.7	104,500.0	287.8	0.35	0.2	0.6
12/14/2021 13:00	2,756.8	0.0	2,756.8	104,500.0	288.1	0.35	0.2	0.6
12/14/2021 14:00	2,749.8	0.0	2,749.8	104,500.0	287.4	0.34	0.2	0.6
12/14/2021 15:00	2,756.3	0.0	2,756.3	104,500.0	288.0	0.35	0.2	0.6
12/14/2021 16:00	3,078.8	0.0	3,078.8	104,500.0	321.7	0.39	0.2	0.6
12/14/2021 17:00	4,210.2	0.0	4,210.2	104,500.0	440.0	0.53	0.3	0.9
12/14/2021 18:00	4,108.5	0.0	4,108.5	104,500.0	429.3	0.51	0.3	0.9
12/14/2021 19:00	4,249.1	0.0	4,249.1	104,500.0	444.0	0.53	0.3	0.9
12/14/2021 20:00	4,429.0	0.0	4,429.0	104,500.0	462.8	0.55	0.3	0.9
12/14/2021 21:00	4,421.3	0.0	4,421.3	104,500.0	462.0	0.56	0.3	0.9
12/14/2021 22:00	4,047.0	0.0	4,047.0	104,500.0	422.9	0.51	0.3	0.8
12/14/2021 23:00	2,763.9	0.0	2,763.9	104,500.0	288.8	0.35	0.2	0.6
Average/Sum#:	3,217.9	0.0	3,217.9	104,500.0	336.3	0.41	0.2	0.7
Minimum:	2,744.8	0.0	2,744.8	104,500.0	286.8	0.34	0.2	0.6
Maximum:	4,429.0	0.0	4,429.0	104,500.0	462.8	0.56	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/15/2021 00:00	2,862.6	0.0	2,862.6	104,500.0	299.1	0.36	0.2	0.6
12/15/2021 01:00	2,765.0	0.0	2,765.0	104,500.0	288.9	0.35	0.2	0.6
12/15/2021 02:00	2,767.7	0.0	2,767.7	104,500.0	289.2	0.35	0.2	0.6
12/15/2021 03:00	2,767.0	0.0	2,767.0	104,500.0	289.2	0.35	0.2	0.6
12/15/2021 04:00	3,628.2	0.0	3,628.2	104,500.0	379.1	0.46	0.2	0.8
12/15/2021 05:00	4,440.7	0.0	4,440.7	104,500.0	464.1	0.56	0.3	0.9
12/15/2021 06:00	4,434.6	0.0	4,434.6	104,500.0	463.4	0.56	0.3	0.9
12/15/2021 07:00	4,066.1	0.0	4,066.1	104,500.0	424.9	0.51	0.3	0.8
12/15/2021 08:00	2,920.1	0.0	2,920.1	104,500.0	305.2	0.37	0.2	0.6
12/15/2021 09:00	2,784.6	0.0	2,784.6	104,500.0	291.0	0.35	0.2	0.6
12/15/2021 10:00	2,781.2	0.0	2,781.2	104,500.0	290.6	0.35	0.2	0.6
12/15/2021 11:00	2,914.1	0.0	2,914.1	104,500.0	304.5	0.37	0.2	0.6
12/15/2021 12:00	3,822.0	0.0	3,822.0	104,500.0	399.4	0.48	0.2	0.8
12/15/2021 13:00	3,601.1	0.0	3,601.1	104,500.0	376.3	0.45	0.2	0.8
12/15/2021 14:00	2,763.4	0.0	2,763.4	104,500.0	288.8	0.35	0.2	0.6
12/15/2021 15:00	3,155.4	0.0	3,155.4	104,500.0	329.7	0.40	0.2	0.7
12/15/2021 16:00	3,863.4	0.0	3,863.4	104,500.0	403.7	0.48	0.2	0.8
12/15/2021 17:00	4,428.3	0.0	4,428.3	104,500.0	462.8	0.56	0.3	0.9
12/15/2021 18:00	4,382.1	0.0	4,382.1	104,500.0	457.9	0.55	0.3	0.9
12/15/2021 19:00	4,398.3	0.0	4,398.3	104,500.0	459.6	0.55	0.3	0.9
12/15/2021 20:00	4,456.0	0.0	4,456.0	104,500.0	465.7	0.56	0.3	0.9
12/15/2021 21:00	4,276.9	0.0	4,276.9	104,500.0	446.9	0.54	0.3	0.9
12/15/2021 22:00	4,134.7	0.0	4,134.7	104,500.0	432.1	0.52	0.3	0.9
12/15/2021 23:00	4,025.9	0.0	4,025.9	104,500.0	420.7	0.50	0.3	0.8
Average/Sum#:	3,601.6	0.0	3,601.6	104,500.0	376.4	0.45	0.2	0.8
Minimum:	2,763.4	0.0	2,763.4	104,500.0	288.8	0.35	0.2	0.6
Maximum:	4,456.0	0.0	4,456.0	104,500.0	465.7	0.56	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/16/2021 00:00	4,069.5	0.0	4,069.5	104,500.0	425.3	0.51	0.3	0.9
12/16/2021 01:00	3,554.2	0.0	3,554.2	104,500.0	371.4	0.45	0.2	0.7
12/16/2021 02:00	2,761.9	0.0	2,761.9	104,500.0	288.6	0.35	0.2	0.6
12/16/2021 03:00	2,763.1	0.0	2,763.1	104,500.0	288.7	0.35	0.2	0.6
12/16/2021 04:00	3,887.7	97.0	3,924.6	104,500.0	410.1	0.50	0.2	0.8
12/16/2021 05:00	4,593.7	209.7	4,803.4	104,500.0	502.0	0.60	0.3	1.0
12/16/2021 06:00	4,596.0	264.1	4,860.1	104,500.0	507.9	0.61	0.3	1.0
12/16/2021 07:00	4,597.9	272.6	4,870.5	104,500.0	509.0	0.61	0.3	1.0
12/16/2021 08:00	4,601.1	172.9	4,774.0	104,500.0	498.9	0.60	0.3	1.0
12/16/2021 09:00	4,507.6	114.5	4,579.7	104,500.0	478.6	0.58	0.3	1.0
12/16/2021 10:00	4,599.3	197.5	4,796.8	104,500.0	501.3	0.60	0.3	1.0
12/16/2021 11:00	3,854.6	58.7	3,872.2	104,500.0	404.6	0.49	0.2	0.8
12/16/2021 12:00	2,769.1	0.0	2,769.1	104,500.0	289.4	0.35	0.2	0.6
12/16/2021 13:00	2,823.6	0.0	2,823.6	104,500.0	295.1	0.36	0.2	0.6
12/16/2021 14:00	3,339.4	0.0	3,339.4	104,500.0	349.0	0.42	0.2	0.7
12/16/2021 15:00	3,962.3	216.3	4,066.1	104,500.0	424.9	0.53	0.3	0.9
12/16/2021 16:00	4,590.4	221.2	4,811.6	104,500.0	502.8	0.60	0.3	1.0
12/16/2021 17:00	4,610.1	138.4	4,748.5	104,500.0	496.2	0.60	0.3	1.0
12/16/2021 18:00	4,627.4	135.6	4,763.0	104,500.0	497.7	0.60	0.3	1.0
12/16/2021 19:00	4,636.0	215.7	4,851.7	104,500.0	507.0	0.61	0.3	1.0
12/16/2021 20:00	4,646.6	169.2	4,815.8	104,500.0	503.3	0.60	0.3	1.0
12/16/2021 21:00	4,656.6	1,115.3	5,771.9	104,500.0	603.2	0.72	0.4	1.2
12/16/2021 22:00	4,662.0	356.5	5,018.5	104,500.0	524.4	0.63	0.3	1.0
12/16/2021 23:00	3,494.9	37.1	3,504.9	104,500.0	366.3	0.44	0.2	0.7
Average/Sum#:	4,050.2	166.3	4,204.8	104,500.0	439.4	0.53	0.3	0.9
Minimum:	2,761.9	0.0	2,761.9	104,500.0	288.6	0.35	0.2	0.6
Maximum:	4,662.0	1,115.3	5,771.9	104,500.0	603.2	0.72	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/17/2021 00:00	2,767.6	0.0	2,767.6	104,500.0	289.2	0.35	0.2	0.6
12/17/2021 01:00	2,797.3	0.0	2,797.3	104,500.0	292.3	0.35	0.2	0.6
12/17/2021 02:00	2,807.7	0.0	2,807.7	104,500.0	293.4	0.35	0.2	0.6
12/17/2021 03:00	2,801.4	0.0	2,801.4	104,500.0	292.7	0.35	0.2	0.6
12/17/2021 04:00	3,960.0	89.5	4,003.0	104,500.0	418.3	0.51	0.3	0.8
12/17/2021 05:00	4,659.2	141.5	4,800.7	104,500.0	501.7	0.60	0.3	1.0
12/17/2021 06:00	4,667.9	279.6	4,947.5	104,500.0	517.0	0.62	0.3	1.0
12/17/2021 07:00	4,689.9	261.0	4,917.0	104,500.0	513.8	0.62	0.3	1.0
12/17/2021 08:00	3,949.2	70.1	3,985.7	104,500.0	416.5	0.51	0.3	0.8
12/17/2021 09:00	2,797.3	0.0	2,797.3	104,500.0	292.3	0.35	0.2	0.6
12/17/2021 10:00	2,803.5	0.0	2,803.5	104,500.0	293.0	0.35	0.2	0.6
12/17/2021 11:00	2,784.1	0.0	2,784.1	104,500.0	290.9	0.35	0.2	0.6
12/17/2021 12:00	2,781.7	0.0	2,781.7	104,500.0	290.7	0.35	0.2	0.6
12/17/2021 13:00	2,782.0	0.0	2,782.0	104,500.0	290.7	0.35	0.2	0.6
12/17/2021 14:00	2,772.9	0.0	2,772.9	104,500.0	289.8	0.35	0.2	0.6
12/17/2021 15:00	3,836.8	79.5	3,863.0	104,500.0	403.7	0.49	0.2	0.8
12/17/2021 16:00	4,619.3	249.4	4,868.7	104,500.0	508.8	0.61	0.3	1.0
12/17/2021 17:00	4,657.1	145.7	4,802.8	104,500.0	501.9	0.60	0.3	1.0
12/17/2021 18:00	4,672.9	136.5	4,809.4	104,500.0	502.6	0.60	0.3	1.0
12/17/2021 19:00	4,680.7	136.8	4,817.5	104,500.0	503.4	0.60	0.3	1.0
12/17/2021 20:00	4,676.8	141.1	4,817.9	104,500.0	503.5	0.60	0.3	1.0
12/17/2021 21:00	4,672.1	137.4	4,809.5	104,500.0	502.6	0.60	0.3	1.0
12/17/2021 22:00	4,679.3	138.8	4,818.1	104,500.0	503.5	0.60	0.3	1.0
12/17/2021 23:00	4,000.2	71.4	4,037.3	104,500.0	421.9	0.51	0.3	0.9
Average/Sum#:	3,763.2	86.6	3,841.4	104,500.0	401.4	0.48	0.3	0.8
Minimum:	2,767.6	0.0	2,767.6	104,500.0	289.2	0.35	0.2	0.6
Maximum:	4,689.9	279.6	4,947.5	104,500.0	517.0	0.62	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/18/2021 00:00	3,853.6	0.0	3,853.6	104,500.0	402.7	0.48	0.2	0.8
12/18/2021 01:00	4,070.1	0.0	4,070.1	104,500.0	425.3	0.51	0.3	0.9
12/18/2021 02:00	3,905.1	0.0	3,905.1	104,500.0	408.1	0.49	0.2	0.8
12/18/2021 03:00	3,237.4	0.0	3,237.4	104,500.0	338.3	0.41	0.2	0.7
12/18/2021 04:00	3,722.2	0.0	3,722.2	104,500.0	389.0	0.47	0.2	0.8
12/18/2021 05:00	3,964.7	52.4	3,982.0	104,500.0	416.1	0.50	0.3	0.8
12/18/2021 06:00	4,681.7	141.2	4,822.9	104,500.0	504.0	0.60	0.3	1.0
12/18/2021 07:00	3,819.3	36.4	3,829.1	104,500.0	400.1	0.48	0.2	0.8
12/18/2021 08:00	3,002.5	0.0	3,002.5	104,500.0	313.8	0.38	0.2	0.6
12/18/2021 09:00	2,938.5	0.0	2,938.5	104,500.0	307.1	0.37	0.2	0.6
12/18/2021 10:00	4,419.0	0.0	4,419.0	104,500.0	461.8	0.55	0.3	0.9
12/18/2021 11:00	3,461.4	0.0	3,461.4	104,500.0	361.7	0.44	0.2	0.7
12/18/2021 12:00	2,777.5	0.0	2,777.5	104,500.0	290.2	0.35	0.2	0.6
12/18/2021 13:00	2,785.9	0.0	2,785.9	104,500.0	291.1	0.35	0.2	0.6
12/18/2021 14:00	2,779.1	0.0	2,779.1	104,500.0	290.4	0.35	0.2	0.6
12/18/2021 15:00	3,027.7	0.0	3,027.7	104,500.0	316.4	0.38	0.2	0.6
12/18/2021 16:00	4,002.5	75.9	4,034.4	104,500.0	421.6	0.51	0.3	0.9
12/18/2021 17:00	4,659.3	139.3	4,798.6	104,500.0	501.5	0.60	0.3	1.0
12/18/2021 18:00	4,666.4	139.6	4,806.0	104,500.0	502.2	0.60	0.3	1.0
12/18/2021 19:00	4,664.5	139.0	4,803.5	104,500.0	502.0	0.60	0.3	1.0
12/18/2021 20:00	4,662.9	141.0	4,803.9	104,500.0	502.0	0.60	0.3	1.0
12/18/2021 21:00	4,664.3	160.3	4,824.6	104,500.0	504.2	0.60	0.3	1.0
12/18/2021 22:00	4,664.7	157.3	4,822.0	104,500.0	503.9	0.60	0.3	1.0
12/18/2021 23:00	3,516.7	36.2	3,526.5	104,500.0	368.5	0.45	0.2	0.7
Average/Sum#:	3,831.1	50.8	3,876.4	104,500.0	405.1	0.49	0.2	0.8
Minimum:	2,777.5	0.0	2,777.5	104,500.0	290.2	0.35	0.2	0.6
Maximum:	4,681.7	160.3	4,824.6	104,500.0	504.2	0.60	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/19/2021 00:00	4,056.4	0.0	4,056.4	104,500.0	423.9	0.51	0.3	0.8
12/19/2021 01:00	4,046.1	0.0	4,046.1	104,500.0	422.8	0.51	0.3	0.8
12/19/2021 02:00	3,881.8	0.0	3,881.8	104,500.0	405.6	0.49	0.2	0.8
12/19/2021 03:00	2,779.5	0.0	2,779.5	104,500.0	290.5	0.35	0.2	0.6
12/19/2021 04:00	2,762.8	0.0	2,762.8	104,500.0	288.7	0.35	0.2	0.6
12/19/2021 05:00	3,846.0	48.0	3,861.8	104,500.0	403.6	0.49	0.2	0.8
12/19/2021 06:00	4,055.7	68.3	4,091.2	104,500.0	427.5	0.52	0.3	0.9
12/19/2021 07:00	3,075.6	0.0	3,075.6	104,500.0	321.4	0.39	0.2	0.6
12/19/2021 08:00	2,772.7	0.0	2,772.7	104,500.0	289.7	0.35	0.2	0.6
12/19/2021 09:00	3,869.2	0.0	3,869.2	104,500.0	404.3	0.49	0.2	0.8
12/19/2021 10:00	4,276.1	0.0	4,276.1	104,500.0	446.9	0.54	0.3	0.9
12/19/2021 11:00	3,049.0	0.0	3,049.0	104,500.0	318.6	0.39	0.2	0.6
12/19/2021 12:00	2,770.4	0.0	2,770.4	104,500.0	289.5	0.35	0.2	0.6
12/19/2021 13:00	2,812.5	0.0	2,812.5	104,500.0	293.9	0.35	0.2	0.6
12/19/2021 14:00	3,200.1	0.0	3,200.1	104,500.0	334.4	0.40	0.2	0.7
12/19/2021 15:00	3,967.1	79.6	3,991.0	104,500.0	417.1	0.51	0.3	0.8
12/19/2021 16:00	4,640.2	138.6	4,778.8	104,500.0	499.4	0.60	0.3	1.0
12/19/2021 17:00	4,653.2	160.9	4,814.1	104,500.0	503.1	0.60	0.3	1.0
12/19/2021 18:00	4,653.9	138.5	4,792.4	104,500.0	500.8	0.60	0.3	1.0
12/19/2021 19:00	4,669.9	140.9	4,810.8	104,500.0	502.7	0.60	0.3	1.0
12/19/2021 20:00	4,642.6	155.8	4,798.4	104,500.0	501.4	0.60	0.3	1.0
12/19/2021 21:00	4,658.6	141.9	4,800.5	104,500.0	501.7	0.60	0.3	1.0
12/19/2021 22:00	4,343.0	83.4	4,386.4	104,500.0	458.4	0.55	0.3	0.9
12/19/2021 23:00	3,767.1	0.0	3,767.1	104,500.0	393.7	0.47	0.2	0.8
Average/Sum#:	3,802.1	48.2	3,843.5	104,500.0	401.7	0.48	0.3	0.8
Minimum:	2,762.8	0.0	2,762.8	104,500.0	288.7	0.35	0.2	0.6
Maximum:	4,669.9	160.9	4,814.1	104,500.0	503.1	0.60	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/20/2021 00:00	3,062.3	0.0	3,062.3	104,500.0	320.0	0.38	0.2	0.6
12/20/2021 01:00	3,634.4	0.0	3,634.4	104,500.0	379.8	0.46	0.2	0.8
12/20/2021 02:00	3,705.7	0.0	3,705.7	104,500.0	387.2	0.47	0.2	0.8
12/20/2021 03:00	3,440.3	0.0	3,440.3	104,500.0	359.5	0.43	0.2	0.7
12/20/2021 04:00	3,057.1	0.0	3,057.1	104,500.0	319.5	0.38	0.2	0.6
12/20/2021 05:00	4,314.4	194.5	4,415.5	104,500.0	461.4	0.57	0.3	0.9
12/20/2021 06:00	4,684.7	223.8	4,908.5	104,500.0	512.9	0.62	0.3	1.0
12/20/2021 07:00	4,554.2	140.5	4,662.4	104,500.0	487.2	0.59	0.3	1.0
12/20/2021 08:00	3,692.9	0.0	3,692.9	104,500.0	385.9	0.46	0.2	0.8
12/20/2021 09:00	2,991.2	0.0	2,991.2	104,500.0	312.6	0.38	0.2	0.6
12/20/2021 10:00	2,795.1	0.0	2,795.1	104,500.0	292.1	0.35	0.2	0.6
12/20/2021 11:00	3,224.1	0.0	3,224.1	104,500.0	336.9	0.40	0.2	0.7
12/20/2021 12:00	4,304.0	0.0	4,304.0	104,500.0	449.8	0.54	0.3	0.9
12/20/2021 13:00	4,451.2	0.0	4,451.2	104,500.0	465.2	0.56	0.3	0.9
12/20/2021 14:00	4,617.4	634.3	4,953.6	104,500.0	517.7	0.66	0.3	1.1
12/20/2021 15:00	4,645.6	1,024.7	5,670.3	104,500.0	592.5	0.71	0.4	1.2
12/20/2021 16:00	4,649.6	523.4	5,105.0	104,500.0	533.5	0.65	0.3	1.1
12/20/2021 17:00	4,661.8	1,062.9	5,724.7	104,500.0	598.2	0.72	0.4	1.2
12/20/2021 18:00	4,667.0	695.7	5,362.7	104,500.0	560.4	0.67	0.3	1.1
12/20/2021 19:00	4,657.3	838.1	5,495.4	104,500.0	574.3	0.69	0.3	1.1
12/20/2021 20:00	4,669.1	1,163.9	5,833.0	104,500.0	609.5	0.73	0.4	1.2
12/20/2021 21:00	4,665.7	810.3	5,476.0	104,500.0	572.2	0.69	0.3	1.1
12/20/2021 22:00	4,674.7	636.9	5,216.1	104,500.0	545.1	0.67	0.3	1.1
12/20/2021 23:00	4,610.7	314.2	4,836.9	104,500.0	505.5	0.62	0.3	1.0
Average/Sum#:	4,101.3	344.3	4,417.4	104,500.0	461.6	0.56	0.3	0.9
Minimum:	2,795.1	0.0	2,795.1	104,500.0	292.1	0.35	0.2	0.6
Maximum:	4,684.7	1,163.9	5,833.0	104,500.0	609.5	0.73	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/21/2021 00:00	4,435.6	0.0	4,435.6	104,500.0	463.5	0.56	0.3	0.9
12/21/2021 01:00	4,410.8	0.0	4,410.8	104,500.0	460.9	0.55	0.3	0.9
12/21/2021 02:00	4,412.1	0.0	4,412.1	104,500.0	461.1	0.55	0.3	0.9
12/21/2021 03:00	4,189.4	0.0	4,189.4	104,500.0	437.8	0.53	0.3	0.9
12/21/2021 04:00	3,957.9	0.0	3,957.9	104,500.0	413.6	0.50	0.2	0.8
12/21/2021 05:00	3,971.2	0.0	3,971.2	104,500.0	415.0	0.50	0.2	0.8
12/21/2021 06:00	4,275.3	0.0	4,275.3	104,500.0	446.8	0.54	0.3	0.9
12/21/2021 07:00	4,501.9	68.6	4,520.4	104,500.0	472.4	0.57	0.3	1.0
12/21/2021 08:00	4,664.0	1,423.0	6,087.0	104,500.0	636.1	0.76	0.4	1.3
12/21/2021 09:00	4,691.1	1,379.1	6,070.2	104,500.0	634.3	0.76	0.4	1.3
12/21/2021 10:00	4,677.7	105.7	4,759.1	104,500.0	497.3	0.60	0.3	1.0
12/21/2021 11:00	3,894.4	1.8	3,894.4	104,500.0	407.0	0.49	0.2	0.8
12/21/2021 12:00	3,665.2	0.0	3,665.2	104,500.0	383.0	0.46	0.2	0.8
12/21/2021 13:00	4,323.8	0.0	4,323.8	104,500.0	451.8	0.54	0.3	0.9
12/21/2021 14:00	4,538.3	103.3	4,581.7	104,500.0	478.8	0.58	0.3	1.0
12/21/2021 15:00	4,634.6	193.9	4,814.9	104,500.0	503.2	0.61	0.3	1.0
12/21/2021 16:00	4,655.2	201.8	4,857.0	104,500.0	507.6	0.61	0.3	1.0
12/21/2021 17:00	4,654.5	137.6	4,792.1	104,500.0	500.8	0.60	0.3	1.0
12/21/2021 18:00	4,649.4	139.6	4,789.0	104,500.0	500.5	0.60	0.3	1.0
12/21/2021 19:00	4,654.6	133.6	4,788.2	104,500.0	500.4	0.60	0.3	1.0
12/21/2021 20:00	4,670.4	135.5	4,805.9	104,500.0	502.2	0.60	0.3	1.0
12/21/2021 21:00	4,666.3	137.5	4,803.8	104,500.0	502.0	0.60	0.3	1.0
12/21/2021 22:00	4,662.7	139.2	4,801.9	104,500.0	501.8	0.60	0.3	1.0
12/21/2021 23:00	3,932.1	72.1	3,969.6	104,500.0	414.8	0.50	0.3	0.8
Average/Sum#:	4,407.9	182.2	4,582.4	104,500.0	478.9	0.58	0.3	1.0
Minimum:	3,665.2	0.0	3,665.2	104,500.0	383.0	0.46	0.2	0.8
Maximum:	4,691.1	1,423.0	6,087.0	104,500.0	636.1	0.76	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/22/2021 00:00	2,782.9	0.0	2,782.9	104,500.0	290.8	0.35	0.2	0.6
12/22/2021 01:00	2,779.6	0.0	2,779.6	104,500.0	290.5	0.35	0.2	0.6
12/22/2021 02:00	2,776.7	0.0	2,776.7	104,500.0	290.2	0.35	0.2	0.6
12/22/2021 03:00	2,777.0	0.0	2,777.0	104,500.0	290.2	0.35	0.2	0.6
12/22/2021 04:00	2,787.3	0.0	2,787.3	104,500.0	291.3	0.35	0.2	0.6
12/22/2021 05:00	4,382.3	98.3	4,439.3	104,500.0	463.9	0.56	0.3	0.9
12/22/2021 06:00	4,650.1	138.4	4,788.5	104,500.0	500.4	0.60	0.3	1.0
12/22/2021 07:00	4,656.5	135.5	4,792.0	104,500.0	500.8	0.60	0.3	1.0
12/22/2021 08:00	4,646.7	150.5	4,797.2	104,500.0	501.3	0.60	0.3	1.0
12/22/2021 09:00	4,640.6	167.2	4,807.8	104,500.0	502.4	0.60	0.3	1.0
12/22/2021 10:00	4,041.9	81.4	4,084.2	104,500.0	426.8	0.52	0.3	0.9
12/22/2021 11:00	2,781.5	0.0	2,781.5	104,500.0	290.7	0.35	0.2	0.6
12/22/2021 12:00	2,793.4	0.0	2,793.4	104,500.0	291.9	0.35	0.2	0.6
12/22/2021 13:00	3,899.5	144.7	3,954.5	104,500.0	413.2	0.51	0.3	0.8
12/22/2021 14:00	4,570.7	358.9	4,929.6	104,500.0	515.1	0.62	0.3	1.0
12/22/2021 15:00	4,568.7	330.0	4,898.7	104,500.0	511.9	0.61	0.3	1.0
12/22/2021 16:00	4,562.9	322.4	4,885.3	104,500.0	510.5	0.61	0.3	1.0
12/22/2021 17:00	4,573.1	319.8	4,892.9	104,500.0	511.3	0.61	0.3	1.0
12/22/2021 18:00	4,570.3	317.7	4,888.0	104,500.0	510.8	0.61	0.3	1.0
12/22/2021 19:00	4,543.9	272.8	4,797.6	104,500.0	501.3	0.60	0.3	1.0
12/22/2021 20:00	2,841.0	0.0	2,841.0	104,500.0	296.9	0.36	0.2	0.6
12/22/2021 21:00	2,844.3	0.0	2,844.3	104,500.0	297.2	0.36	0.2	0.6
12/22/2021 22:00	3,122.4	0.0	3,122.4	104,500.0	326.3	0.39	0.2	0.7
12/22/2021 23:00	2,864.2	0.0	2,864.2	104,500.0	299.3	0.36	0.2	0.6
Average/Sum#:	3,727.4	118.2	3,837.7	104,500.0	401.0	0.48	0.3	0.8
Minimum:	2,776.7	0.0	2,776.7	104,500.0	290.2	0.35	0.2	0.6
Maximum:	4,656.5	358.9	4,929.6	104,500.0	515.1	0.62	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/23/2021 00:00	3,674.1	0.0	3,674.1	104,500.0	383.9	0.46	0.2	0.8
12/23/2021 01:00	3,002.4	0.0	3,002.4	104,500.0	313.8	0.38	0.2	0.6
12/23/2021 02:00	2,815.5	0.0	2,815.5	104,500.0	294.2	0.35	0.2	0.6
12/23/2021 03:00	2,777.1	0.0	2,777.1	104,500.0	290.2	0.35	0.2	0.6
12/23/2021 04:00	2,767.2	0.0	2,767.2	104,500.0	289.2	0.35	0.2	0.6
12/23/2021 05:00	2,773.3	0.0	2,773.3	104,500.0	289.8	0.35	0.2	0.6
12/23/2021 06:00	2,783.4	0.0	2,783.4	104,500.0	290.9	0.35	0.2	0.6
12/23/2021 07:00	2,776.9	0.0	2,776.9	104,500.0	290.2	0.35	0.2	0.6
12/23/2021 08:00	2,776.9	0.0	2,776.9	104,500.0	290.2	0.35	0.2	0.6
12/23/2021 09:00	2,777.3	0.0	2,777.3	104,500.0	290.2	0.35	0.2	0.6
12/23/2021 10:00	2,788.1	0.0	2,788.1	104,500.0	291.4	0.35	0.2	0.6
12/23/2021 11:00	2,782.9	0.0	2,782.9	104,500.0	290.8	0.35	0.2	0.6
12/23/2021 12:00	2,776.1	0.0	2,776.1	104,500.0	290.1	0.35	0.2	0.6
12/23/2021 13:00	2,781.9	0.0	2,781.9	104,500.0	290.7	0.35	0.2	0.6
12/23/2021 14:00	2,782.1	0.0	2,782.1	104,500.0	290.7	0.35	0.2	0.6
12/23/2021 15:00	2,778.8	0.0	2,778.8	104,500.0	290.4	0.35	0.2	0.6
12/23/2021 16:00	2,776.5	0.0	2,776.5	104,500.0	290.1	0.35	0.2	0.6
12/23/2021 17:00	2,778.1	0.0	2,778.1	104,500.0	290.3	0.35	0.2	0.6
12/23/2021 18:00	2,787.7	0.0	2,787.7	104,500.0	291.3	0.35	0.2	0.6
12/23/2021 19:00	2,766.0	0.0	2,766.0	104,500.0	289.0	0.35	0.2	0.6
12/23/2021 20:00	2,770.4	0.0	2,770.4	104,500.0	289.5	0.35	0.2	0.6
12/23/2021 21:00	2,762.1	0.0	2,762.1	104,500.0	288.6	0.35	0.2	0.6
12/23/2021 22:00	2,757.2	0.0	2,757.2	104,500.0	288.1	0.35	0.2	0.6
12/23/2021 23:00	2,771.6	0.0	2,771.6	104,500.0	289.6	0.35	0.2	0.6
Average/Sum#:	2,824.3	0.0	2,824.3	104,500.0	295.1	0.36	0.2	0.6
Minimum:	2,757.2	0.0	2,757.2	104,500.0	288.1	0.35	0.2	0.6
Maximum:	3,674.1	0.0	3,674.1	104,500.0	383.9	0.46	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/24/2021 00:00	2,776.3	0.0	2,776.3	104,500.0	290.1	0.35	0.2	0.6
12/24/2021 01:00	2,775.6	0.0	2,775.6	104,500.0	290.1	0.35	0.2	0.6
12/24/2021 02:00	2,772.3	0.0	2,772.3	104,500.0	289.7	0.35	0.2	0.6
12/24/2021 03:00	2,777.7	0.0	2,777.7	104,500.0	290.3	0.35	0.2	0.6
12/24/2021 04:00	2,778.2	0.0	2,778.2	104,500.0	290.3	0.35	0.2	0.6
12/24/2021 05:00	2,779.2	0.0	2,779.2	104,500.0	290.4	0.35	0.2	0.6
12/24/2021 06:00	2,780.0	0.0	2,780.0	104,500.0	290.5	0.35	0.2	0.6
12/24/2021 07:00	2,780.2	0.0	2,780.2	104,500.0	290.5	0.35	0.2	0.6
12/24/2021 08:00	2,822.8	0.0	2,822.8	104,500.0	295.0	0.35	0.2	0.6
12/24/2021 09:00	2,780.5	0.0	2,780.5	104,500.0	290.6	0.35	0.2	0.6
12/24/2021 10:00	2,783.9	0.0	2,783.9	104,500.0	290.9	0.35	0.2	0.6
12/24/2021 11:00	2,777.1	0.0	2,777.1	104,500.0	290.2	0.35	0.2	0.6
12/24/2021 12:00	2,777.5	0.0	2,777.5	104,500.0	290.2	0.35	0.2	0.6
12/24/2021 13:00	2,775.3	0.0	2,775.3	104,500.0	290.0	0.35	0.2	0.6
12/24/2021 14:00	2,776.7	0.0	2,776.7	104,500.0	290.2	0.35	0.2	0.6
12/24/2021 15:00	2,776.2	0.0	2,776.2	104,500.0	290.1	0.35	0.2	0.6
12/24/2021 16:00	2,782.0	0.0	2,782.0	104,500.0	290.7	0.35	0.2	0.6
12/24/2021 17:00	2,778.2	0.0	2,778.2	104,500.0	290.3	0.35	0.2	0.6
12/24/2021 18:00	2,769.6	0.0	2,769.6	104,500.0	289.4	0.35	0.2	0.6
12/24/2021 19:00	2,768.3	0.0	2,768.3	104,500.0	289.3	0.35	0.2	0.6
12/24/2021 20:00	2,765.6	0.0	2,765.6	104,500.0	289.0	0.35	0.2	0.6
12/24/2021 21:00	2,769.2	0.0	2,769.2	104,500.0	289.4	0.35	0.2	0.6
12/24/2021 22:00	2,764.2	0.0	2,764.2	104,500.0	288.9	0.35	0.2	0.6
12/24/2021 23:00	2,767.5	0.0	2,767.5	104,500.0	289.2	0.35	0.2	0.6
Average/Sum#:	2,777.3	0.0	2,777.3	104,500.0	290.2	0.35	0.2	0.6
Minimum:	2,764.2	0.0	2,764.2	104,500.0	288.9	0.35	0.2	0.6
Maximum:	2,822.8	0.0	2,822.8	104,500.0	295.0	0.35	0.2	0.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/25/2021 00:00	2,771.2	0.0	2,771.2	104,500.0	289.6	0.35	0.2	0.6
12/25/2021 01:00	2,771.2	0.0	2,771.2	104,500.0	289.6	0.35	0.2	0.6
12/25/2021 02:00	2,768.5	0.0	2,768.5	104,500.0	289.3	0.35	0.2	0.6
12/25/2021 03:00	2,765.1	0.0	2,765.1	104,500.0	289.0	0.35	0.2	0.6
12/25/2021 04:00	2,768.7	0.0	2,768.7	104,500.0	289.3	0.35	0.2	0.6
12/25/2021 05:00	2,770.3	0.0	2,770.3	104,500.0	289.5	0.35	0.2	0.6
12/25/2021 06:00	2,766.1	0.0	2,766.1	104,500.0	289.1	0.35	0.2	0.6
12/25/2021 07:00	2,774.8	0.0	2,774.8	104,500.0	290.0	0.35	0.2	0.6
12/25/2021 08:00	2,768.4	0.0	2,768.4	104,500.0	289.3	0.35	0.2	0.6
12/25/2021 09:00	2,766.0	0.0	2,766.0	104,500.0	289.0	0.35	0.2	0.6
12/25/2021 10:00	2,777.3	0.0	2,777.3	104,500.0	290.2	0.35	0.2	0.6
12/25/2021 11:00	2,780.4	0.0	2,780.4	104,500.0	290.6	0.35	0.2	0.6
12/25/2021 12:00	2,784.3	0.0	2,784.3	104,500.0	291.0	0.35	0.2	0.6
12/25/2021 13:00	2,793.2	0.0	2,793.2	104,500.0	291.9	0.35	0.2	0.6
12/25/2021 14:00	2,795.0	0.0	2,795.0	104,500.0	292.1	0.35	0.2	0.6
12/25/2021 15:00	2,898.3	0.0	2,898.3	104,500.0	302.9	0.36	0.2	0.6
12/25/2021 16:00	2,780.7	0.0	2,780.7	104,500.0	290.6	0.35	0.2	0.6
12/25/2021 17:00	2,785.2	0.0	2,785.2	104,500.0	291.1	0.35	0.2	0.6
12/25/2021 18:00	2,778.5	0.0	2,778.5	104,500.0	290.4	0.35	0.2	0.6
12/25/2021 19:00	2,778.1	0.0	2,778.1	104,500.0	290.3	0.35	0.2	0.6
12/25/2021 20:00	2,783.8	0.0	2,783.8	104,500.0	290.9	0.35	0.2	0.6
12/25/2021 21:00	2,778.8	0.0	2,778.8	104,500.0	290.4	0.35	0.2	0.6
12/25/2021 22:00	2,771.6	0.0	2,771.6	104,500.0	289.6	0.35	0.2	0.6
12/25/2021 23:00	2,763.5	0.0	2,763.5	104,500.0	288.8	0.35	0.2	0.6
Average/Sum#:	2,780.8	0.0	2,780.8	104,500.0	290.6	0.35	0.2	0.6
Minimum:	2,763.5	0.0	2,763.5	104,500.0	288.8	0.35	0.2	0.6
Maximum:	2,898.3	0.0	2,898.3	104,500.0	302.9	0.36	0.2	0.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/26/2021 00:00	2,762.2	0.0	2,762.2	104,500.0	288.6	0.35	0.2	0.6
12/26/2021 01:00	2,762.9	0.0	2,762.9	104,500.0	288.7	0.35	0.2	0.6
12/26/2021 02:00	2,763.9	0.0	2,763.9	104,500.0	288.8	0.35	0.2	0.6
12/26/2021 03:00	2,784.1	0.0	2,784.1	104,500.0	290.9	0.35	0.2	0.6
12/26/2021 04:00	2,784.6	0.0	2,784.6	104,500.0	291.0	0.35	0.2	0.6
12/26/2021 05:00	2,793.3	0.0	2,793.3	104,500.0	291.9	0.35	0.2	0.6
12/26/2021 06:00	2,797.0	0.0	2,797.0	104,500.0	292.3	0.35	0.2	0.6
12/26/2021 07:00	2,829.8	0.0	2,829.8	104,500.0	295.7	0.36	0.2	0.6
12/26/2021 08:00	2,771.5	0.0	2,771.5	104,500.0	289.6	0.35	0.2	0.6
12/26/2021 09:00	2,783.8	0.0	2,783.8	104,500.0	290.9	0.35	0.2	0.6
12/26/2021 10:00	2,787.9	0.0	2,787.9	104,500.0	291.3	0.35	0.2	0.6
12/26/2021 11:00	2,843.7	0.0	2,843.7	104,500.0	297.2	0.36	0.2	0.6
12/26/2021 12:00	2,805.2	0.0	2,805.2	104,500.0	293.1	0.35	0.2	0.6
12/26/2021 13:00	2,998.7	0.0	2,998.7	104,500.0	313.4	0.38	0.2	0.6
12/26/2021 14:00	2,876.6	0.0	2,876.6	104,500.0	300.6	0.36	0.2	0.6
12/26/2021 15:00	2,883.2	0.0	2,883.2	104,500.0	301.3	0.36	0.2	0.6
12/26/2021 16:00	3,910.5	29.3	3,914.0	104,500.0	409.0	0.49	0.2	0.8
12/26/2021 17:00	4,619.2	227.4	4,846.6	104,500.0	506.5	0.61	0.3	1.0
12/26/2021 18:00	3,460.0	53.2	3,474.4	104,500.0	363.1	0.44	0.2	0.7
12/26/2021 19:00	2,808.5	0.0	2,808.5	104,500.0	293.5	0.35	0.2	0.6
12/26/2021 20:00	2,870.4	0.0	2,870.4	104,500.0	300.0	0.36	0.2	0.6
12/26/2021 21:00	4,162.9	0.0	4,162.9	104,500.0	435.0	0.52	0.3	0.9
12/26/2021 22:00	3,111.9	0.0	3,111.9	104,500.0	325.2	0.39	0.2	0.7
12/26/2021 23:00	2,791.2	0.0	2,791.2	104,500.0	291.7	0.35	0.2	0.6
Average/Sum#:	3,031.8	12.9	3,042.0	104,500.0	317.9	0.38	0.2	0.6
Minimum:	2,762.2	0.0	2,762.2	104,500.0	288.6	0.35	0.2	0.6
Maximum:	4,619.2	227.4	4,846.6	104,500.0	506.5	0.61	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/27/2021 00:00	2,808.3	0.0	2,808.3	104,500.0	293.5	0.35	0.2	0.6
12/27/2021 01:00	2,791.4	0.0	2,791.4	104,500.0	291.7	0.35	0.2	0.6
12/27/2021 02:00	2,792.8	0.0	2,792.8	104,500.0	291.8	0.35	0.2	0.6
12/27/2021 03:00	2,788.4	0.0	2,788.4	104,500.0	291.4	0.35	0.2	0.6
12/27/2021 04:00	2,771.3	0.0	2,771.3	104,500.0	289.6	0.35	0.2	0.6
12/27/2021 05:00	3,921.4	75.0	3,945.4	104,500.0	412.3	0.50	0.3	0.8
12/27/2021 06:00	4,602.1	248.9	4,851.0	104,500.0	506.9	0.61	0.3	1.0
12/27/2021 07:00	4,601.7	247.5	4,849.2	104,500.0	506.7	0.61	0.3	1.0
12/27/2021 08:00	4,597.9	294.6	4,892.5	104,500.0	511.3	0.61	0.3	1.0
12/27/2021 09:00	4,314.5	177.3	4,406.7	104,500.0	460.5	0.56	0.3	0.9
12/27/2021 10:00	3,447.0	0.0	3,447.0	104,500.0	360.2	0.43	0.2	0.7
12/27/2021 11:00	4,237.5	0.0	4,237.5	104,500.0	442.8	0.53	0.3	0.9
12/27/2021 12:00	2,771.1	0.0	2,771.1	104,500.0	289.6	0.35	0.2	0.6
12/27/2021 13:00	2,930.6	0.0	2,930.6	104,500.0	306.2	0.37	0.2	0.6
12/27/2021 14:00	4,012.9	0.0	4,012.9	104,500.0	419.3	0.50	0.3	0.8
12/27/2021 15:00	4,425.9	191.7	4,527.5	104,500.0	473.1	0.58	0.3	1.0
12/27/2021 16:00	4,587.5	296.0	4,883.5	104,500.0	510.3	0.61	0.3	1.0
12/27/2021 17:00	4,581.5	356.7	4,938.2	104,500.0	516.0	0.62	0.3	1.0
12/27/2021 18:00	4,588.5	400.0	4,988.5	104,500.0	521.3	0.63	0.3	1.0
12/27/2021 19:00	4,601.7	431.4	5,033.1	104,500.0	526.0	0.63	0.3	1.1
12/27/2021 20:00	4,617.7	434.7	5,052.4	104,500.0	528.0	0.63	0.3	1.1
12/27/2021 21:00	4,617.0	214.5	4,831.5	104,500.0	504.9	0.61	0.3	1.0
12/27/2021 22:00	4,232.6	107.1	4,288.3	104,500.0	448.1	0.54	0.3	0.9
12/27/2021 23:00	3,339.1	0.0	3,339.1	104,500.0	348.9	0.42	0.2	0.7
Average/Sum#:	3,874.2	144.8	4,007.4	104,500.0	418.8	0.50	0.3	0.8
Minimum:	2,771.1	0.0	2,771.1	104,500.0	289.6	0.35	0.2	0.6
Maximum:	4,617.7	434.7	5,052.4	104,500.0	528.0	0.63	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/28/2021 00:00	2,886.1	0.0	2,886.1	104,500.0	301.6	0.36	0.2	0.6
12/28/2021 01:00	2,795.4	0.0	2,795.4	104,500.0	292.1	0.35	0.2	0.6
12/28/2021 02:00	2,799.8	0.0	2,799.8	104,500.0	292.6	0.35	0.2	0.6
12/28/2021 03:00	2,874.0	0.0	2,874.0	104,500.0	300.3	0.36	0.2	0.6
12/28/2021 04:00	2,799.2	0.0	2,799.2	104,500.0	292.5	0.35	0.2	0.6
12/28/2021 05:00	3,832.2	0.0	3,832.2	104,500.0	400.5	0.48	0.2	0.8
12/28/2021 06:00	3,755.5	0.0	3,755.5	104,500.0	392.4	0.47	0.2	0.8
12/28/2021 07:00	2,870.1	0.0	2,870.1	104,500.0	299.9	0.36	0.2	0.6
12/28/2021 08:00	3,267.4	0.0	3,267.4	104,500.0	341.4	0.41	0.2	0.7
12/28/2021 09:00	3,204.3	0.0	3,204.3	104,500.0	334.8	0.40	0.2	0.7
12/28/2021 10:00	2,776.7	0.0	2,776.7	104,500.0	290.2	0.35	0.2	0.6
12/28/2021 11:00	2,773.9	0.0	2,773.9	104,500.0	289.9	0.35	0.2	0.6
12/28/2021 12:00	2,779.7	0.0	2,779.7	104,500.0	290.5	0.35	0.2	0.6
12/28/2021 13:00	2,771.1	0.0	2,771.1	104,500.0	289.6	0.35	0.2	0.6
12/28/2021 14:00	2,769.2	0.0	2,769.2	104,500.0	289.4	0.35	0.2	0.6
12/28/2021 15:00	3,244.1	0.0	3,244.1	104,500.0	339.0	0.41	0.2	0.7
12/28/2021 16:00	3,634.3	0.0	3,634.3	104,500.0	379.8	0.46	0.2	0.8
12/28/2021 17:00	4,469.9	0.0	4,469.9	104,500.0	467.1	0.56	0.3	0.9
12/28/2021 18:00	4,187.7	0.0	4,187.7	104,500.0	437.6	0.53	0.3	0.9
12/28/2021 19:00	3,803.4	0.0	3,803.4	104,500.0	397.5	0.48	0.2	0.8
12/28/2021 20:00	3,723.7	0.0	3,723.7	104,500.0	389.1	0.47	0.2	0.8
12/28/2021 21:00	2,969.4	0.0	2,969.4	104,500.0	310.3	0.37	0.2	0.6
12/28/2021 22:00	2,830.2	0.0	2,830.2	104,500.0	295.8	0.36	0.2	0.6
12/28/2021 23:00	2,814.9	0.0	2,814.9	104,500.0	294.2	0.35	0.2	0.6
Average/Sum#:	3,193.0	0.0	3,193.0	104,500.0	333.7	0.40	0.2	0.7
Minimum:	2,769.2	0.0	2,769.2	104,500.0	289.4	0.35	0.2	0.6
Maximum:	4,469.9	0.0	4,469.9	104,500.0	467.1	0.56	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1	Unit CT1	Unit CT1
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/29/2021 00:00	2,822.2	0.0	2,822.2	104,500.0	294.9	0.35	0.2	0.6
12/29/2021 01:00	2,814.7	0.0	2,814.7	104,500.0	294.1	0.35	0.2	0.6
12/29/2021 02:00	2,775.1	0.0	2,775.1	104,500.0	290.0	0.35	0.2	0.6
12/29/2021 03:00	2,769.0	0.0	2,769.0	104,500.0	289.4	0.35	0.2	0.6
12/29/2021 04:00	2,772.8	0.0	2,772.8	104,500.0	289.8	0.35	0.2	0.6
12/29/2021 05:00	2,795.0	0.0	2,795.0	104,500.0	292.1	0.35	0.2	0.6
12/29/2021 06:00	2,880.1	0.0	2,880.1	104,500.0	301.0	0.36	0.2	0.6
12/29/2021 07:00	2,778.3	0.0	2,778.3	104,500.0	290.3	0.35	0.2	0.6
12/29/2021 08:00	2,775.6	0.0	2,775.6	104,500.0	290.1	0.35	0.2	0.6
12/29/2021 09:00	2,768.6	0.0	2,768.6	104,500.0	289.3	0.35	0.2	0.6
12/29/2021 10:00	2,765.1	0.0	2,765.1	104,500.0	289.0	0.35	0.2	0.6
12/29/2021 11:00	2,769.9	0.0	2,769.9	104,500.0	289.5	0.35	0.2	0.6
12/29/2021 12:00	2,776.9	0.0	2,776.9	104,500.0	290.2	0.35	0.2	0.6
12/29/2021 13:00	2,907.8	0.0	2,907.8	104,500.0	303.9	0.37	0.2	0.6
12/29/2021 14:00	3,561.5	0.0	3,561.5	104,500.0	372.2	0.45	0.2	0.7
12/29/2021 15:00	3,639.4	0.0	3,639.4	104,500.0	380.3	0.46	0.2	0.8
12/29/2021 16:00	3,596.5	0.0	3,596.5	104,500.0	375.8	0.45	0.2	0.8
12/29/2021 17:00	4,389.7	0.0	4,389.7	104,500.0	458.7	0.55	0.3	0.9
12/29/2021 18:00	4,412.3	0.0	4,412.3	104,500.0	461.1	0.55	0.3	0.9
12/29/2021 19:00	4,468.0	0.0	4,468.0	104,500.0	466.9	0.56	0.3	0.9
12/29/2021 20:00	4,471.9	0.0	4,471.9	104,500.0	467.3	0.56	0.3	0.9
12/29/2021 21:00	3,341.8	0.0	3,341.8	104,500.0	349.2	0.42	0.2	0.7
12/29/2021 22:00	2,813.5	0.0	2,813.5	104,500.0	294.0	0.35	0.2	0.6
12/29/2021 23:00	2,780.6	0.0	2,780.6	104,500.0	290.6	0.35	0.2	0.6
Average/Sum#:	3,193.6	0.0	3,193.6	104,500.0	333.7	0.40	0.2	0.7
Minimum:	2,765.1	0.0	2,765.1	104,500.0	289.0	0.35	0.2	0.6
Maximum:	4,471.9	0.0	4,471.9	104,500.0	467.3	0.56	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/30/2021 00:00	2,774.9	0.0	2,774.9	104,500.0	290.0	0.35	0.2	0.6
12/30/2021 01:00	2,777.0	0.0	2,777.0	104,500.0	290.2	0.35	0.2	0.6
12/30/2021 02:00	2,774.6	0.0	2,774.6	104,500.0	289.9	0.35	0.2	0.6
12/30/2021 03:00	2,769.2	0.0	2,769.2	104,500.0	289.4	0.35	0.2	0.6
12/30/2021 04:00	2,779.8	0.0	2,779.8	104,500.0	290.5	0.35	0.2	0.6
12/30/2021 05:00	4,311.6	133.3	4,388.9	104,500.0	458.6	0.56	0.3	0.9
12/30/2021 06:00	4,643.2	143.3	4,786.5	104,500.0	500.2	0.60	0.3	1.0
12/30/2021 07:00	4,641.0	137.5	4,778.5	104,500.0	499.4	0.60	0.3	1.0
12/30/2021 08:00	4,649.0	135.2	4,784.2	104,500.0	499.9	0.60	0.3	1.0
12/30/2021 09:00	4,643.1	147.1	4,790.2	104,500.0	500.6	0.60	0.3	1.0
12/30/2021 10:00	2,977.0	1.6	2,977.0	104,500.0	311.1	0.38	0.2	0.6
12/30/2021 11:00	2,784.6	0.0	2,784.6	104,500.0	291.0	0.35	0.2	0.6
12/30/2021 12:00	2,788.0	0.0	2,788.0	104,500.0	291.3	0.35	0.2	0.6
12/30/2021 13:00	2,787.9	0.0	2,787.9	104,500.0	291.3	0.35	0.2	0.6
12/30/2021 14:00	2,793.0	0.0	2,793.0	104,500.0	291.9	0.35	0.2	0.6
12/30/2021 15:00	2,798.0	0.0	2,798.0	104,500.0	292.4	0.35	0.2	0.6
12/30/2021 16:00	3,897.7	138.4	3,957.2	104,500.0	413.5	0.51	0.3	0.8
12/30/2021 17:00	4,574.8	259.4	4,834.2	104,500.0	505.2	0.61	0.3	1.0
12/30/2021 18:00	4,572.3	260.4	4,832.7	104,500.0	505.0	0.61	0.3	1.0
12/30/2021 19:00	4,601.4	248.5	4,849.9	104,500.0	506.8	0.61	0.3	1.0
12/30/2021 20:00	4,625.1	228.1	4,853.2	104,500.0	507.2	0.61	0.3	1.0
12/30/2021 21:00	4,623.7	213.2	4,836.9	104,500.0	505.5	0.61	0.3	1.0
12/30/2021 22:00	3,645.1	50.4	3,658.7	104,500.0	382.3	0.46	0.2	0.8
12/30/2021 23:00	2,801.5	0.0	2,801.5	104,500.0	292.8	0.35	0.2	0.6
Average/Sum#:	3,626.4	87.4	3,706.5	104,500.0	387.3	0.47	0.2	0.8
Minimum:	2,769.2	0.0	2,769.2	104,500.0	289.4	0.35	0.2	0.6
Maximum:	4,649.0	260.4	4,853.2	104,500.0	507.2	0.61	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/31/2021 00:00	2,784.3	0.0	2,784.3	104,500.0	291.0	0.35	0.2	0.6
12/31/2021 01:00	2,771.5	0.0	2,771.5	104,500.0	289.6	0.35	0.2	0.6
12/31/2021 02:00	2,774.7	0.0	2,774.7	104,500.0	290.0	0.35	0.2	0.6
12/31/2021 03:00	2,780.2	0.0	2,780.2	104,500.0	290.5	0.35	0.2	0.6
12/31/2021 04:00	2,780.0	0.0	2,780.0	104,500.0	290.5	0.35	0.2	0.6
12/31/2021 05:00	2,772.7	0.0	2,772.7	104,500.0	289.7	0.35	0.2	0.6
12/31/2021 06:00	2,778.1	0.0	2,778.1	104,500.0	290.3	0.35	0.2	0.6
12/31/2021 07:00	2,785.0	0.0	2,785.0	104,500.0	291.0	0.35	0.2	0.6
12/31/2021 08:00	2,797.1	0.0	2,797.1	104,500.0	292.3	0.35	0.2	0.6
12/31/2021 09:00	2,805.8	0.0	2,805.8	104,500.0	293.2	0.35	0.2	0.6
12/31/2021 10:00	2,787.0	0.0	2,787.0	104,500.0	291.2	0.35	0.2	0.6
12/31/2021 11:00	2,763.6	0.0	2,763.6	104,500.0	288.8	0.35	0.2	0.6
12/31/2021 12:00	2,763.9	0.0	2,763.9	104,500.0	288.8	0.35	0.2	0.6
12/31/2021 13:00	2,762.7	0.0	2,762.7	104,500.0	288.7	0.35	0.2	0.6
12/31/2021 14:00	2,758.8	0.0	2,758.8	104,500.0	288.3	0.35	0.2	0.6
12/31/2021 15:00	2,758.9	0.0	2,758.9	104,500.0	288.3	0.35	0.2	0.6
12/31/2021 16:00	3,244.5	0.0	3,244.5	104,500.0	339.1	0.41	0.2	0.7
12/31/2021 17:00	3,583.4	0.0	3,583.4	104,500.0	374.5	0.45	0.2	0.7
12/31/2021 18:00	3,892.3	0.0	3,892.3	104,500.0	406.7	0.49	0.2	0.8
12/31/2021 19:00	4,339.6	0.0	4,339.6	104,500.0	453.5	0.54	0.3	0.9
12/31/2021 20:00	3,975.6	0.0	3,975.6	104,500.0	415.5	0.50	0.2	0.8
12/31/2021 21:00	4,338.3	0.0	4,338.3	104,500.0	453.4	0.54	0.3	0.9
12/31/2021 22:00	3,748.8	0.0	3,748.8	104,500.0	391.7	0.47	0.2	0.8
12/31/2021 23:00	2,928.1	0.0	2,928.1	104,500.0	306.0	0.37	0.2	0.6
Average/Sum#:	3,103.1	0.0	3,103.1	104,500.0	324.3	0.39	0.2	0.7
Minimum:	2,758.8	0.0	2,758.8	104,500.0	288.3	0.35	0.2	0.6
Maximum:	4,339.6	0.0	4,339.6	104,500.0	453.5	0.54	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/01/2021 00:00	3,316.3	0.0	3,316.3	104,900.0	347.9	0.4	0.2	0.7
10/01/2021 01:00	3,001.5	0.0	3,001.5	104,900.0	314.9	0.4	0.2	0.6
10/01/2021 02:00	2,930.7	0.0	2,930.7	104,900.0	307.4	0.4	0.2	0.6
10/01/2021 03:00	3,003.8	0.0	3,003.8	104,900.0	315.1	0.4	0.2	0.6
10/01/2021 04:00	3,859.2	0.0	3,859.2	104,900.0	404.8	0.5	0.2	0.8
10/01/2021 05:00	4,141.5	0.0	4,141.5	104,900.0	434.4	0.5	0.3	0.9
10/01/2021 06:00	3,399.9	0.0	3,399.9	104,900.0	356.6	0.4	0.2	0.7
10/01/2021 07:00	3,267.4	0.0	3,267.4	104,900.0	342.8	0.4	0.2	0.7
10/01/2021 08:00	2,895.0	0.0	2,895.0	104,900.0	303.7	0.4	0.2	0.6
10/01/2021 09:00	2,823.6	0.0	2,823.6	104,900.0	296.2	0.4	0.2	0.6
10/01/2021 10:00	2,968.3	0.0	2,968.3	104,900.0	311.4	0.4	0.2	0.6
10/01/2021 11:00	3,158.1	0.0	3,158.1	104,900.0	331.3	0.4	0.2	0.7
10/01/2021 12:00	3,791.5	0.0	3,791.5	104,900.0	397.7	0.5	0.2	0.8
10/01/2021 13:00	4,675.9	351.5	4,981.7	104,900.0	522.6	0.6	0.3	1.1
10/01/2021 14:00	4,516.6	9.4	4,518.7	104,900.0	474.0	0.6	0.3	1.0
10/01/2021 15:00	3,667.0	0.0	3,667.0	104,900.0	384.7	0.5	0.2	0.8
10/01/2021 16:00	4,227.3	0.0	4,227.3	104,900.0	443.4	0.5	0.3	0.9
10/01/2021 17:00	4,461.2	0.0	4,461.2	104,900.0	468.0	0.6	0.3	0.9
10/01/2021 18:00	4,244.9	0.0	4,244.9	104,900.0	445.3	0.5	0.3	0.9
10/01/2021 19:00	4,069.4	0.0	4,069.4	104,900.0	426.9	0.5	0.3	0.9
10/01/2021 20:00	4,551.3	0.0	4,551.3	104,900.0	477.4	0.6	0.3	1.0
10/01/2021 21:00	4,410.0	0.0	4,410.0	104,900.0	462.6	0.6	0.3	0.9
10/01/2021 22:00	3,378.4	0.0	3,378.4	104,900.0	354.4	0.4	0.2	0.7
10/01/2021 23:00	2,992.0	0.0	2,992.0	104,900.0	313.9	0.4	0.2	0.6
Average/Sum#:	3,656.3	15.0	3,669.1	104,900.0	384.9	0.5	0.2	0.8
Minimum:	2,823.6	0.0	2,823.6	104,900.0	296.2	0.4	0.2	0.6
Maximum:	4,675.9	351.5	4,981.7	104,900.0	522.6	0.6	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/02/2021 00:00	3,695.5	0.0	3,695.5	104,900.0	387.7	0.5	0.2	0.8
10/02/2021 01:00	3,269.3	0.0	3,269.3	104,900.0	342.9	0.4	0.2	0.7
10/02/2021 02:00	3,337.8	0.0	3,337.8	104,900.0	350.1	0.4	0.2	0.7
10/02/2021 03:00	3,232.0	0.0	3,232.0	104,900.0	339.0	0.4	0.2	0.7
10/02/2021 04:00	3,486.4	0.0	3,486.4	104,900.0	365.7	0.4	0.2	0.7
10/02/2021 05:00	3,226.4	0.0	3,226.4	104,900.0	338.4	0.4	0.2	0.7
10/02/2021 06:00	4,521.3	0.0	4,521.3	104,900.0	474.3	0.6	0.3	0.9
10/02/2021 07:00	3,653.7	0.0	3,653.7	104,900.0	383.3	0.5	0.2	0.8
10/02/2021 08:00	2,826.8	0.0	2,826.8	104,900.0	296.5	0.4	0.2	0.6
10/02/2021 09:00	2,815.7	0.0	2,815.7	104,900.0	295.4	0.4	0.2	0.6
10/02/2021 10:00	2,800.9	0.0	2,800.9	104,900.0	293.8	0.4	0.2	0.6
10/02/2021 11:00	2,887.1	0.0	2,887.1	104,900.0	302.9	0.4	0.2	0.6
10/02/2021 12:00	2,949.7	0.0	2,949.7	104,900.0	309.4	0.4	0.2	0.6
10/02/2021 13:00	3,986.0	0.0	3,986.0	104,900.0	418.1	0.5	0.3	0.8
10/02/2021 14:00	4,090.1	0.0	4,090.1	104,900.0	429.1	0.5	0.3	0.9
10/02/2021 15:00	3,708.9	0.0	3,708.9	104,900.0	389.1	0.5	0.2	0.8
10/02/2021 16:00	4,136.9	0.0	4,136.9	104,900.0	434.0	0.5	0.3	0.9
10/02/2021 17:00	4,594.4	0.0	4,594.4	104,900.0	482.0	0.6	0.3	1.0
10/02/2021 18:00	4,649.9	0.0	4,649.9	104,900.0	487.8	0.6	0.3	1.0
10/02/2021 19:00	4,646.6	0.0	4,646.6	104,900.0	487.4	0.6	0.3	1.0
10/02/2021 20:00	4,645.4	0.0	4,645.4	104,900.0	487.3	0.6	0.3	1.0
10/02/2021 21:00	4,461.5	0.0	4,461.5	104,900.0	468.0	0.6	0.3	0.9
10/02/2021 22:00	4,329.9	0.0	4,329.9	104,900.0	454.2	0.5	0.3	0.9
10/02/2021 23:00	4,085.1	0.0	4,085.1	104,900.0	428.5	0.5	0.3	0.9
Average/Sum#:	3,751.6	0.0	3,751.6	104,900.0	393.5	0.5	0.2	0.8
Minimum:	2,800.9	0.0	2,800.9	104,900.0	293.8	0.4	0.2	0.6
Maximum:	4,649.9	0.0	4,649.9	104,900.0	487.8	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/03/2021 00:00	3,416.0	0.0	3,416.0	104,900.0	358.3	0.4	0.2	0.7
10/03/2021 01:00	2,931.9	0.0	2,931.9	104,900.0	307.6	0.4	0.2	0.6
10/03/2021 02:00	2,928.9	0.0	2,928.9	104,900.0	307.2	0.4	0.2	0.6
10/03/2021 03:00	2,936.7	0.0	2,936.7	104,900.0	308.1	0.4	0.2	0.6
10/03/2021 04:00	2,934.1	0.0	2,934.1	104,900.0	307.8	0.4	0.2	0.6
10/03/2021 05:00	2,934.7	0.0	2,934.7	104,900.0	307.9	0.4	0.2	0.6
10/03/2021 06:00	2,998.7	0.0	2,998.7	104,900.0	314.6	0.4	0.2	0.6
10/03/2021 07:00	2,851.1	0.0	2,851.1	104,900.0	299.1	0.4	0.2	0.6
10/03/2021 08:00	2,839.2	0.0	2,839.2	104,900.0	297.8	0.4	0.2	0.6
10/03/2021 09:00	2,809.3	0.0	2,809.3	104,900.0	294.7	0.4	0.2	0.6
10/03/2021 10:00	2,793.2	0.0	2,793.2	104,900.0	293.0	0.4	0.2	0.6
10/03/2021 11:00	2,846.9	0.0	2,846.9	104,900.0	298.6	0.4	0.2	0.6
10/03/2021 12:00	2,903.8	0.0	2,903.8	104,900.0	304.6	0.4	0.2	0.6
10/03/2021 13:00	3,172.6	0.0	3,172.6	104,900.0	332.8	0.4	0.2	0.7
10/03/2021 14:00	3,681.3	0.0	3,681.3	104,900.0	386.2	0.5	0.2	0.8
10/03/2021 15:00	4,049.1	0.0	4,049.1	104,900.0	424.8	0.5	0.3	0.9
10/03/2021 16:00	4,544.2	464.1	4,790.2	104,900.0	502.5	0.6	0.3	1.1
10/03/2021 17:00	4,638.9	314.4	4,953.3	104,900.0	519.6	0.6	0.3	1.0
10/03/2021 18:00	4,667.5	265.6	4,933.1	104,900.0	517.5	0.6	0.3	1.0
10/03/2021 19:00	4,702.6	198.4	4,901.0	104,900.0	514.1	0.6	0.3	1.0
10/03/2021 20:00	4,723.2	241.0	4,964.2	104,900.0	520.7	0.6	0.3	1.0
10/03/2021 21:00	4,729.4	255.4	4,984.8	104,900.0	522.9	0.6	0.3	1.0
10/03/2021 22:00	4,030.4	49.6	4,053.7	104,900.0	425.2	0.5	0.3	0.9
10/03/2021 23:00	3,176.2	0.0	3,176.2	104,900.0	333.2	0.4	0.2	0.7
Average/Sum#:	3,510.0	74.5	3,574.3	104,900.0	375.0	0.5	0.2	0.8
Minimum:	2,793.2	0.0	2,793.2	104,900.0	293.0	0.4	0.2	0.6
Maximum:	4,729.4	464.1	4,984.8	104,900.0	522.9	0.6	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/04/2021 00:00	3,001.4	0.0	3,001.4	104,900.0	314.8	0.4	0.2	0.6
10/04/2021 01:00	3,308.8	0.0	3,308.8	104,900.0	347.1	0.4	0.2	0.7
10/04/2021 02:00	3,105.3	0.0	3,105.3	104,900.0	325.7	0.4	0.2	0.7
10/04/2021 03:00	4,529.9	0.0	4,529.9	104,900.0	475.2	0.6	0.3	1.0
10/04/2021 04:00	4,432.9	0.0	4,432.9	104,900.0	465.0	0.6	0.3	0.9
10/04/2021 05:00	4,588.6	0.0	4,588.6	104,900.0	481.3	0.6	0.3	1.0
10/04/2021 06:00	4,628.2	0.0	4,628.2	104,900.0	485.5	0.6	0.3	1.0
10/04/2021 07:00	4,459.6	0.0	4,459.6	104,900.0	467.8	0.6	0.3	0.9
10/04/2021 08:00	4,632.4	0.0	4,632.4	104,900.0	485.9	0.6	0.3	1.0
10/04/2021 09:00	4,215.6	0.0	4,215.6	104,900.0	442.2	0.5	0.3	0.9
10/04/2021 10:00	4,469.2	0.0	4,469.2	104,900.0	468.8	0.6	0.3	0.9
10/04/2021 11:00	4,515.6	0.0	4,515.6	104,900.0	473.7	0.6	0.3	0.9
10/04/2021 12:00	4,633.9	0.0	4,633.9	104,900.0	486.1	0.6	0.3	1.0
10/04/2021 13:00	4,633.0	0.0	4,633.0	104,900.0	486.0	0.6	0.3	1.0
10/04/2021 14:00	4,629.5	0.0	4,629.5	104,900.0	485.6	0.6	0.3	1.0
10/04/2021 15:00	4,621.0	205.6	4,678.6	104,900.0	490.8	0.6	0.3	1.0
10/04/2021 16:00	4,625.2	1,157.2	5,782.4	104,900.0	606.6	0.7	0.4	1.2
10/04/2021 17:00	4,643.6	799.5	5,443.1	104,900.0	571.0	0.7	0.3	1.1
10/04/2021 18:00	4,663.9	600.9	5,264.8	104,900.0	552.3	0.7	0.3	1.1
10/04/2021 19:00	4,670.2	431.3	5,101.5	104,900.0	535.1	0.6	0.3	1.1
10/04/2021 20:00	4,694.5	243.5	4,938.0	104,900.0	518.0	0.6	0.3	1.0
10/04/2021 21:00	4,725.8	262.5	4,988.3	104,900.0	523.3	0.6	0.3	1.0
10/04/2021 22:00	4,003.9	70.4	4,037.0	104,900.0	423.5	0.5	0.3	0.9
10/04/2021 23:00	3,116.5	0.0	3,116.5	104,900.0	326.9	0.4	0.2	0.7
Average/Sum#:	4,314.5	157.1	4,463.9	104,900.0	468.3	0.6	0.3	0.9
Minimum:	3,001.4	0.0	3,001.4	104,900.0	314.8	0.4	0.2	0.6
Maximum:	4,725.8	1,157.2	5,782.4	104,900.0	606.6	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/05/2021 00:00	3,032.3	0.0	3,032.3	104,900.0	318.1	0.4	0.2	0.6
10/05/2021 01:00	3,188.6	0.0	3,188.6	104,900.0	334.5	0.4	0.2	0.7
10/05/2021 02:00	2,926.3	0.0	2,926.3	104,900.0	307.0	0.4	0.2	0.6
10/05/2021 03:00	3,006.6	0.0	3,006.6	104,900.0	315.4	0.4	0.2	0.6
10/05/2021 04:00	3,743.3	0.0	3,743.3	104,900.0	392.7	0.5	0.2	0.8
10/05/2021 05:00	3,497.0	0.0	3,497.0	104,900.0	366.8	0.4	0.2	0.7
10/05/2021 06:00	3,697.2	0.0	3,697.2	104,900.0	387.8	0.5	0.2	0.8
10/05/2021 07:00	4,134.6	0.0	4,134.6	104,900.0	433.7	0.5	0.3	0.9
10/05/2021 08:00	2,913.1	0.0	2,913.1	104,900.0	305.6	0.4	0.2	0.6
10/05/2021 09:00	3,055.0	0.0	3,055.0	104,900.0	320.5	0.4	0.2	0.6
10/05/2021 10:00	4,560.0	0.0	4,560.0	104,900.0	478.3	0.6	0.3	1.0
10/05/2021 11:00	2,980.6	0.0	2,980.6	104,900.0	312.7	0.4	0.2	0.6
10/05/2021 12:00	2,902.7	0.0	2,902.7	104,900.0	304.5	0.4	0.2	0.6
10/05/2021 13:00	3,074.5	0.0	3,074.5	104,900.0	322.5	0.4	0.2	0.6
10/05/2021 14:00	3,580.8	0.0	3,580.8	104,900.0	375.6	0.5	0.2	0.8
10/05/2021 15:00	3,656.5	0.0	3,656.5	104,900.0	383.6	0.5	0.2	0.8
10/05/2021 16:00	3,911.7	0.0	3,911.7	104,900.0	410.3	0.5	0.2	0.8
10/05/2021 17:00	3,786.2	0.0	3,786.2	104,900.0	397.2	0.5	0.2	0.8
10/05/2021 18:00	4,091.9	0.0	4,091.9	104,900.0	429.2	0.5	0.3	0.9
10/05/2021 19:00	3,228.5	0.0	3,228.5	104,900.0	338.7	0.4	0.2	0.7
10/05/2021 20:00	3,397.6	0.0	3,397.6	104,900.0	356.4	0.4	0.2	0.7
10/05/2021 21:00	3,907.0	0.0	3,907.0	104,900.0	409.8	0.5	0.2	0.8
10/05/2021 22:00	4,289.6	0.0	4,289.6	104,900.0	450.0	0.5	0.3	0.9
10/05/2021 23:00	4,274.2	0.0	4,274.2	104,900.0	448.4	0.5	0.3	0.9
Average/Sum#:	3,534.8	0.0	3,534.8	104,900.0	370.8	0.5	0.2	0.7
Minimum:	2,902.7	0.0	2,902.7	104,900.0	304.5	0.4	0.2	0.6
Maximum:	4,560.0	0.0	4,560.0	104,900.0	478.3	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/06/2021 00:00	2,963.8	0.0	2,963.8	104,900.0	310.9	0.4	0.2	0.6
10/06/2021 01:00	2,957.6	0.0	2,957.6	104,900.0	310.3	0.4	0.2	0.6
10/06/2021 02:00	2,948.5	0.0	2,948.5	104,900.0	309.3	0.4	0.2	0.6
10/06/2021 03:00	2,950.8	0.0	2,950.8	104,900.0	309.5	0.4	0.2	0.6
10/06/2021 04:00	2,953.2	0.0	2,953.2	104,900.0	309.8	0.4	0.2	0.6
10/06/2021 05:00	3,445.4	0.0	3,445.4	104,900.0	361.4	0.4	0.2	0.7
10/06/2021 06:00	3,815.4	0.0	3,815.4	104,900.0	400.2	0.5	0.2	0.8
10/06/2021 07:00	3,004.6	0.0	3,004.6	104,900.0	315.2	0.4	0.2	0.6
10/06/2021 08:00	3,409.7	0.0	3,409.7	104,900.0	357.7	0.4	0.2	0.7
10/06/2021 09:00	4,481.8	0.0	4,481.8	104,900.0	470.1	0.6	0.3	0.9
10/06/2021 10:00	3,870.5	0.0	3,870.5	104,900.0	406.0	0.5	0.2	0.8
10/06/2021 11:00	4,641.2	159.3	4,763.9	104,900.0	499.7	0.6	0.3	1.0
10/06/2021 12:00	4,692.2	6.7	4,698.9	104,900.0	492.9	0.6	0.3	1.0
10/06/2021 13:00	4,100.2	8.7	4,101.8	104,900.0	430.3	0.5	0.3	0.9
10/06/2021 14:00	4,656.0	0.0	4,656.0	104,900.0	488.4	0.6	0.3	1.0
10/06/2021 15:00	3,874.2	0.0	3,874.2	104,900.0	406.4	0.5	0.2	0.8
10/06/2021 16:00	4,214.6	0.0	4,214.6	104,900.0	442.1	0.5	0.3	0.9
10/06/2021 17:00	3,110.1	0.0	3,110.1	104,900.0	326.2	0.4	0.2	0.7
10/06/2021 18:00	3,368.5	0.0	3,368.5	104,900.0	353.4	0.4	0.2	0.7
10/06/2021 19:00	3,286.5	0.0	3,286.5	104,900.0	344.8	0.4	0.2	0.7
10/06/2021 20:00	4,273.3	0.0	4,273.3	104,900.0	448.3	0.5	0.3	0.9
10/06/2021 21:00	4,691.1	0.0	4,691.1	104,900.0	492.1	0.6	0.3	1.0
10/06/2021 22:00	3,824.1	0.0	3,824.1	104,900.0	401.1	0.5	0.2	0.8
10/06/2021 23:00	2,953.9	0.0	2,953.9	104,900.0	309.9	0.4	0.2	0.6
Average/Sum#:	3,687.0	7.3	3,692.4	104,900.0	387.3	0.5	0.2	0.8
Minimum:	2,948.5	0.0	2,948.5	104,900.0	309.3	0.4	0.2	0.6
Maximum:	4,692.2	159.3	4,763.9	104,900.0	499.7	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/07/2021 00:00	2,954.6	0.0	2,954.6	104,900.0	309.9	0.4	0.2	0.6
10/07/2021 01:00	2,954.2	0.0	2,954.2	104,900.0	309.9	0.4	0.2	0.6
10/07/2021 02:00	2,955.5	0.0	2,955.5	104,900.0	310.0	0.4	0.2	0.6
10/07/2021 03:00	3,706.8	0.0	3,706.8	104,900.0	388.8	0.5	0.2	0.8
10/07/2021 04:00	4,096.1	0.0	4,096.1	104,900.0	429.7	0.5	0.3	0.9
10/07/2021 05:00	4,530.8	0.0	4,530.8	104,900.0	475.3	0.6	0.3	1.0
10/07/2021 06:00	4,778.3	0.0	4,778.3	104,900.0	501.2	0.6	0.3	1.0
10/07/2021 07:00	4,657.8	0.0	4,657.8	104,900.0	488.6	0.6	0.3	1.0
10/07/2021 08:00	4,198.8	0.0	4,198.8	104,900.0	440.5	0.5	0.3	0.9
10/07/2021 09:00	4,676.3	0.0	4,676.3	104,900.0	490.5	0.6	0.3	1.0
10/07/2021 10:00	3,543.0	0.0	3,543.0	104,900.0	371.7	0.4	0.2	0.7
10/07/2021 11:00	3,218.6	0.0	3,218.6	104,900.0	337.6	0.4	0.2	0.7
10/07/2021 12:00	2,924.4	0.0	2,924.4	104,900.0	306.8	0.4	0.2	0.6
10/07/2021 13:00	2,907.1	0.0	2,907.1	104,900.0	305.0	0.4	0.2	0.6
10/07/2021 14:00	2,858.1	0.0	2,858.1	104,900.0	299.8	0.4	0.2	0.6
10/07/2021 15:00	2,920.9	0.0	2,920.9	104,900.0	306.4	0.4	0.2	0.6
10/07/2021 16:00	3,535.1	0.0	3,535.1	104,900.0	370.8	0.4	0.2	0.7
10/07/2021 17:00	4,666.0	0.0	4,666.0	104,900.0	489.5	0.6	0.3	1.0
10/07/2021 18:00	3,571.4	0.0	3,571.4	104,900.0	374.6	0.4	0.2	0.7
10/07/2021 19:00	2,959.6	0.0	2,959.6	104,900.0	310.5	0.4	0.2	0.6
10/07/2021 20:00	3,068.4	0.0	3,068.4	104,900.0	321.9	0.4	0.2	0.6
10/07/2021 21:00	2,959.2	0.0	2,959.2	104,900.0	310.4	0.4	0.2	0.6
10/07/2021 22:00	3,011.6	0.0	3,011.6	104,900.0	315.9	0.4	0.2	0.6
10/07/2021 23:00	3,767.5	0.0	3,767.5	104,900.0	395.2	0.5	0.2	0.8
Average/Sum#:	3,559.2	0.0	3,559.2	104,900.0	373.4	0.5	0.2	0.7
Minimum:	2,858.1	0.0	2,858.1	104,900.0	299.8	0.4	0.2	0.6
Maximum:	4,778.3	0.0	4,778.3	104,900.0	501.2	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/08/2021 00:00	2,959.3	0.0	2,959.3	104,900.0	310.4	0.4	0.2	0.6
10/08/2021 01:00	2,956.4	0.0	2,956.4	104,900.0	310.1	0.4	0.2	0.6
10/08/2021 02:00	2,949.9	0.0	2,949.9	104,900.0	309.4	0.4	0.2	0.6
10/08/2021 03:00	2,989.2	0.0	2,989.2	104,900.0	313.6	0.4	0.2	0.6
10/08/2021 04:00	3,132.4	0.0	3,132.4	104,900.0	328.6	0.4	0.2	0.7
10/08/2021 05:00	2,878.1	0.0	2,878.1	104,900.0	301.9	0.4	0.2	0.6
10/08/2021 06:00	3,108.7	0.0	3,108.7	104,900.0	326.1	0.4	0.2	0.7
10/08/2021 07:00	4,786.3	0.0	4,786.3	104,900.0	502.1	0.6	0.3	1.0
10/08/2021 08:00	3,658.2	0.0	3,658.2	104,900.0	383.7	0.5	0.2	0.8
10/08/2021 09:00	4,705.8	0.0	4,705.8	104,900.0	493.6	0.6	0.3	1.0
10/08/2021 10:00	3,055.7	0.0	3,055.7	104,900.0	320.5	0.4	0.2	0.6
10/08/2021 11:00	4,092.5	0.0	4,092.5	104,900.0	429.3	0.5	0.3	0.9
10/08/2021 12:00	3,975.4	0.0	3,975.4	104,900.0	417.0	0.5	0.3	0.8
10/08/2021 13:00	4,109.5	0.0	4,109.5	104,900.0	431.1	0.5	0.3	0.9
10/08/2021 14:00	4,685.9	0.0	4,685.9	104,900.0	491.6	0.6	0.3	1.0
10/08/2021 15:00	2,947.6	0.0	2,947.6	104,900.0	309.2	0.4	0.2	0.6
10/08/2021 16:00	3,474.2	0.0	3,474.2	104,900.0	364.4	0.4	0.2	0.7
10/08/2021 17:00	2,961.3	0.0	2,961.3	104,900.0	310.6	0.4	0.2	0.6
10/08/2021 18:00	2,922.1	0.0	2,922.1	104,900.0	306.5	0.4	0.2	0.6
10/08/2021 19:00	2,900.2	0.0	2,900.2	104,900.0	304.2	0.4	0.2	0.6
10/08/2021 20:00	2,925.8	0.0	2,925.8	104,900.0	306.9	0.4	0.2	0.6
10/08/2021 21:00	2,950.3	0.0	2,950.3	104,900.0	309.5	0.4	0.2	0.6
10/08/2021 22:00	3,006.1	0.0	3,006.1	104,900.0	315.3	0.4	0.2	0.6
10/08/2021 23:00	2,916.7	0.0	2,916.7	104,900.0	306.0	0.4	0.2	0.6
Average/Sum#:	3,377.0	0.0	3,377.0	104,900.0	354.2	0.4	0.2	0.7
Minimum:	2,878.1	0.0	2,878.1	104,900.0	301.9	0.4	0.2	0.6
Maximum:	4,786.3	0.0	4,786.3	104,900.0	502.1	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/09/2021 00:00	2,896.2	0.0	2,896.2	104,900.0	303.8	0.4	0.2	0.6
10/09/2021 01:00	2,839.7	0.0	2,839.7	104,900.0	297.9	0.4	0.2	0.6
10/09/2021 02:00	2,850.1	0.0	2,850.1	104,900.0	299.0	0.4	0.2	0.6
10/09/2021 03:00	2,852.2	0.0	2,852.2	104,900.0	299.2	0.4	0.2	0.6
10/09/2021 04:00	2,985.3	0.0	2,985.3	104,900.0	313.2	0.4	0.2	0.6
10/09/2021 05:00	3,543.8	0.0	3,543.8	104,900.0	371.7	0.4	0.2	0.7
10/09/2021 06:00	3,523.9	0.0	3,523.9	104,900.0	369.7	0.4	0.2	0.7
10/09/2021 07:00	4,125.5	0.0	4,125.5	104,900.0	432.8	0.5	0.3	0.9
10/09/2021 08:00	3,356.6	0.0	3,356.6	104,900.0	352.1	0.4	0.2	0.7
10/09/2021 09:00	2,889.6	0.0	2,889.6	104,900.0	303.1	0.4	0.2	0.6
10/09/2021 10:00	2,845.6	0.0	2,845.6	104,900.0	298.5	0.4	0.2	0.6
10/09/2021 11:00	2,844.3	0.0	2,844.3	104,900.0	298.4	0.4	0.2	0.6
10/09/2021 12:00	2,835.4	0.0	2,835.4	104,900.0	297.4	0.4	0.2	0.6
10/09/2021 13:00	2,829.8	0.0	2,829.8	104,900.0	296.8	0.4	0.2	0.6
10/09/2021 14:00	2,825.8	0.0	2,825.8	104,900.0	296.4	0.4	0.2	0.6
10/09/2021 15:00	2,918.3	0.0	2,918.3	104,900.0	306.1	0.4	0.2	0.6
10/09/2021 16:00	3,616.5	0.0	3,616.5	104,900.0	379.4	0.5	0.2	0.8
10/09/2021 17:00	4,301.9	0.0	4,301.9	104,900.0	451.3	0.5	0.3	0.9
10/09/2021 18:00	3,160.6	0.0	3,160.6	104,900.0	331.5	0.4	0.2	0.7
10/09/2021 19:00	2,920.7	0.0	2,920.7	104,900.0	306.4	0.4	0.2	0.6
10/09/2021 20:00	2,869.9	0.0	2,869.9	104,900.0	301.1	0.4	0.2	0.6
10/09/2021 21:00	2,941.4	0.0	2,941.4	104,900.0	308.6	0.4	0.2	0.6
10/09/2021 22:00	2,933.3	0.0	2,933.3	104,900.0	307.7	0.4	0.2	0.6
10/09/2021 23:00	2,965.2	0.0	2,965.2	104,900.0	311.0	0.4	0.2	0.6
Average/Sum#:	3,111.3	0.0	3,111.3	104,900.0	326.4	0.4	0.2	0.7
Minimum:	2,825.8	0.0	2,825.8	104,900.0	296.4	0.4	0.2	0.6
Maximum:	4,301.9	0.0	4,301.9	104,900.0	451.3	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/10/2021 00:00	2,963.6	0.0	2,963.6	104,900.0	310.9	0.4	0.2	0.6
10/10/2021 01:00	2,955.5	0.0	2,955.5	104,900.0	310.0	0.4	0.2	0.6
10/10/2021 02:00	3,018.2	0.0	3,018.2	104,900.0	316.6	0.4	0.2	0.6
10/10/2021 03:00	2,995.8	0.0	2,995.8	104,900.0	314.3	0.4	0.2	0.6
10/10/2021 04:00	2,995.4	0.0	2,995.4	104,900.0	314.2	0.4	0.2	0.6
10/10/2021 05:00	3,773.7	0.0	3,773.7	104,900.0	395.9	0.5	0.2	0.8
10/10/2021 06:00	4,023.1	0.0	4,023.1	104,900.0	422.0	0.5	0.3	0.8
10/10/2021 07:00	3,701.4	0.0	3,701.4	104,900.0	388.3	0.5	0.2	0.8
10/10/2021 08:00	2,924.8	0.0	2,924.8	104,900.0	306.8	0.4	0.2	0.6
10/10/2021 09:00	2,842.2	0.0	2,842.2	104,900.0	298.1	0.4	0.2	0.6
10/10/2021 10:00	2,870.8	0.0	2,870.8	104,900.0	301.1	0.4	0.2	0.6
10/10/2021 11:00	2,834.4	0.0	2,834.4	104,900.0	297.3	0.4	0.2	0.6
10/10/2021 12:00	2,832.0	0.0	2,832.0	104,900.0	297.1	0.4	0.2	0.6
10/10/2021 13:00	2,839.4	0.0	2,839.4	104,900.0	297.9	0.4	0.2	0.6
10/10/2021 14:00	2,868.2	0.0	2,868.2	104,900.0	300.9	0.4	0.2	0.6
10/10/2021 15:00	3,092.6	0.0	3,092.6	104,900.0	324.4	0.4	0.2	0.6
10/10/2021 16:00	3,711.0	0.0	3,711.0	104,900.0	389.3	0.5	0.2	0.8
10/10/2021 17:00	3,069.5	0.0	3,069.5	104,900.0	322.0	0.4	0.2	0.6
10/10/2021 18:00	2,862.8	0.0	2,862.8	104,900.0	300.3	0.4	0.2	0.6
10/10/2021 19:00	3,110.4	0.0	3,110.4	104,900.0	326.3	0.4	0.2	0.7
10/10/2021 20:00	3,652.7	0.0	3,652.7	104,900.0	383.2	0.5	0.2	0.8
10/10/2021 21:00	2,929.1	0.0	2,929.1	104,900.0	307.3	0.4	0.2	0.6
10/10/2021 22:00	2,873.5	0.0	2,873.5	104,900.0	301.4	0.4	0.2	0.6
10/10/2021 23:00	2,847.6	0.0	2,847.6	104,900.0	298.7	0.4	0.2	0.6
Average/Sum#:	3,107.8	0.0	3,107.8	104,900.0	326.0	0.4	0.2	0.6
Minimum:	2,832.0	0.0	2,832.0	104,900.0	297.1	0.4	0.2	0.6
Maximum:	4,023.1	0.0	4,023.1	104,900.0	422.0	0.5	0.3	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/11/2021 00:00	3,000.5	0.0	3,000.5	104,900.0	314.8	0.4	0.2	0.6
10/11/2021 01:00	2,850.8	0.0	2,850.8	104,900.0	299.0	0.4	0.2	0.6
10/11/2021 02:00	2,928.0	0.0	2,928.0	104,900.0	307.1	0.4	0.2	0.6
10/11/2021 03:00	2,979.4	0.0	2,979.4	104,900.0	312.5	0.4	0.2	0.6
10/11/2021 04:00	4,189.3	0.0	4,189.3	104,900.0	439.5	0.5	0.3	0.9
10/11/2021 05:00	4,154.9	0.0	4,154.9	104,900.0	435.8	0.5	0.3	0.9
10/11/2021 06:00	4,482.4	0.0	4,482.4	104,900.0	470.2	0.6	0.3	0.9
10/11/2021 07:00	4,714.6	2.7	4,714.7	104,900.0	494.6	0.6	0.3	1.0
10/11/2021 08:00	4,955.4	1,227.0	6,182.4	104,900.0	648.5	0.8	0.4	1.3
10/11/2021 09:00	4,938.1	813.9	5,752.0	104,900.0	603.4	0.7	0.4	1.2
10/11/2021 10:00	4,922.7	1,006.1	5,928.8	104,900.0	621.9	0.7	0.4	1.2
10/11/2021 11:00	4,897.2	210.7	5,080.5	104,900.0	532.9	0.6	0.3	1.1
10/11/2021 12:00	4,905.4	532.3	5,437.7	104,900.0	570.4	0.7	0.3	1.1
10/11/2021 13:00	4,897.3	583.1	5,480.4	104,900.0	574.9	0.7	0.3	1.1
10/11/2021 14:00	4,899.4	453.1	5,352.5	104,900.0	561.5	0.7	0.3	1.1
10/11/2021 15:00	4,297.5	59.8	4,312.5	104,900.0	452.4	0.5	0.3	0.9
10/11/2021 16:00	4,600.0	0.0	4,600.0	104,900.0	482.5	0.6	0.3	1.0
10/11/2021 17:00	4,546.9	0.0	4,546.9	104,900.0	477.0	0.6	0.3	1.0
10/11/2021 18:00	3,531.3	0.0	3,531.3	104,900.0	370.4	0.4	0.2	0.7
10/11/2021 19:00	3,135.5	0.0	3,135.5	104,900.0	328.9	0.4	0.2	0.7
10/11/2021 20:00	4,059.6	0.0	4,059.6	104,900.0	425.9	0.5	0.3	0.9
10/11/2021 21:00	3,517.5	0.0	3,517.5	104,900.0	369.0	0.4	0.2	0.7
10/11/2021 22:00	3,190.3	0.0	3,190.3	104,900.0	334.7	0.4	0.2	0.7
10/11/2021 23:00	3,142.0	0.0	3,142.0	104,900.0	329.6	0.4	0.2	0.7
Average/Sum#:	4,072.3	203.7	4,272.9	104,900.0	448.2	0.5	0.3	0.9
Minimum:	2,850.8	0.0	2,850.8	104,900.0	299.0	0.4	0.2	0.6
Maximum:	4,955.4	1,227.0	6,182.4	104,900.0	648.5	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/12/2021 00:00	2,987.9	0.0	2,987.9	104,900.0	313.4	0.4	0.2	0.6
10/12/2021 01:00	2,948.9	0.0	2,948.9	104,900.0	309.3	0.4	0.2	0.6
10/12/2021 02:00	2,915.9	0.0	2,915.9	104,900.0	305.9	0.4	0.2	0.6
10/12/2021 03:00	2,922.1	0.0	2,922.1	104,900.0	306.5	0.4	0.2	0.6
10/12/2021 04:00	2,928.7	0.0	2,928.7	104,900.0	307.2	0.4	0.2	0.6
10/12/2021 05:00	3,960.4	0.0	3,960.4	104,900.0	415.4	0.5	0.2	0.8
10/12/2021 06:00	4,837.2	0.0	4,837.2	104,900.0	507.4	0.6	0.3	1.0
10/12/2021 07:00	4,765.6	0.0	4,765.6	104,900.0	499.9	0.6	0.3	1.0
10/12/2021 08:00	4,802.0	0.0	4,802.0	104,900.0	503.7	0.6	0.3	1.0
10/12/2021 09:00	4,800.5	0.0	4,800.5	104,900.0	503.6	0.6	0.3	1.0
10/12/2021 10:00	4,805.4	0.0	4,805.4	104,900.0	504.1	0.6	0.3	1.0
10/12/2021 11:00	4,774.4	0.0	4,774.4	104,900.0	500.8	0.6	0.3	1.0
10/12/2021 12:00	4,654.3	0.0	4,654.3	104,900.0	488.2	0.6	0.3	1.0
10/12/2021 13:00	3,558.6	0.0	3,558.6	104,900.0	373.3	0.4	0.2	0.7
10/12/2021 14:00	4,696.5	0.0	4,696.5	104,900.0	492.7	0.6	0.3	1.0
10/12/2021 15:00	4,683.9	0.0	4,683.9	104,900.0	491.3	0.6	0.3	1.0
10/12/2021 16:00	4,444.7	0.0	4,444.7	104,900.0	466.2	0.6	0.3	0.9
10/12/2021 17:00	4,662.0	0.0	4,662.0	104,900.0	489.0	0.6	0.3	1.0
10/12/2021 18:00	4,713.4	0.0	4,713.4	104,900.0	494.4	0.6	0.3	1.0
10/12/2021 19:00	4,246.5	0.0	4,246.5	104,900.0	445.5	0.5	0.3	0.9
10/12/2021 20:00	4,376.8	0.0	4,376.8	104,900.0	459.1	0.6	0.3	0.9
10/12/2021 21:00	4,600.3	0.0	4,600.3	104,900.0	482.6	0.6	0.3	1.0
10/12/2021 22:00	4,722.4	0.0	4,722.4	104,900.0	495.4	0.6	0.3	1.0
10/12/2021 23:00	4,017.1	0.0	4,017.1	104,900.0	421.4	0.5	0.3	0.8
Average/Sum#:	4,201.1	0.0	4,201.1	104,900.0	440.7	0.5	0.3	0.9
Minimum:	2,915.9	0.0	2,915.9	104,900.0	305.9	0.4	0.2	0.6
Maximum:	4,837.2	0.0	4,837.2	104,900.0	507.4	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/13/2021 00:00	4,768.2	0.0	4,768.2	104,900.0	500.2	0.6	0.3	1.0
10/13/2021 01:00	3,235.1	0.0	3,235.1	104,900.0	339.4	0.4	0.2	0.7
10/13/2021 02:00	2,992.1	0.0	2,992.1	104,900.0	313.9	0.4	0.2	0.6
10/13/2021 03:00	3,643.1	0.0	3,643.1	104,900.0	382.2	0.5	0.2	0.8
10/13/2021 04:00	4,767.5	0.0	4,767.5	104,900.0	500.1	0.6	0.3	1.0
10/13/2021 05:00	4,514.9	0.0	4,514.9	104,900.0	473.6	0.6	0.3	0.9
10/13/2021 06:00	4,411.4	0.0	4,411.4	104,900.0	462.8	0.6	0.3	0.9
10/13/2021 07:00	4,770.0	0.0	4,770.0	104,900.0	500.4	0.6	0.3	1.0
10/13/2021 08:00	4,774.0	0.0	4,774.0	104,900.0	500.8	0.6	0.3	1.0
10/13/2021 09:00	4,775.0	0.0	4,775.0	104,900.0	500.9	0.6	0.3	1.0
10/13/2021 10:00	4,741.5	0.0	4,741.5	104,900.0	497.4	0.6	0.3	1.0
10/13/2021 11:00	4,735.4	0.0	4,735.4	104,900.0	496.7	0.6	0.3	1.0
10/13/2021 12:00	4,707.6	0.0	4,707.6	104,900.0	493.8	0.6	0.3	1.0
10/13/2021 13:00	4,767.7	0.0	4,767.7	104,900.0	500.1	0.6	0.3	1.0
10/13/2021 14:00	4,675.3	0.0	4,675.3	104,900.0	490.4	0.6	0.3	1.0
10/13/2021 15:00	4,192.1	0.0	4,192.1	104,900.0	439.8	0.5	0.3	0.9
10/13/2021 16:00	3,529.1	0.0	3,529.1	104,900.0	370.2	0.4	0.2	0.7
10/13/2021 17:00	4,706.8	0.0	4,706.8	104,900.0	493.7	0.6	0.3	1.0
10/13/2021 18:00	4,309.0	0.0	4,309.0	104,900.0	452.0	0.5	0.3	0.9
10/13/2021 19:00	4,038.9	0.0	4,038.9	104,900.0	423.7	0.5	0.3	0.8
10/13/2021 20:00	4,435.5	0.0	4,435.5	104,900.0	465.3	0.6	0.3	0.9
10/13/2021 21:00	4,325.6	0.0	4,325.6	104,900.0	453.8	0.5	0.3	0.9
10/13/2021 22:00	4,491.9	0.0	4,491.9	104,900.0	471.2	0.6	0.3	0.9
10/13/2021 23:00	2,903.2	0.0	2,903.2	104,900.0	304.5	0.4	0.2	0.6
Average/Sum#:	4,300.5	0.0	4,300.5	104,900.0	451.1	0.5	0.3	0.9
Minimum:	2,903.2	0.0	2,903.2	104,900.0	304.5	0.4	0.2	0.6
Maximum:	4,775.0	0.0	4,775.0	104,900.0	500.9	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/14/2021 00:00	2,969.2	0.0	2,969.2	104,900.0	311.5	0.4	0.2	0.6
10/14/2021 01:00	2,937.0	0.0	2,937.0	104,900.0	308.1	0.4	0.2	0.6
10/14/2021 02:00	2,980.1	0.0	2,980.1	104,900.0	312.6	0.4	0.2	0.6
10/14/2021 03:00	2,983.4	0.0	2,983.4	104,900.0	313.0	0.4	0.2	0.6
10/14/2021 04:00	2,965.0	0.0	2,965.0	104,900.0	311.0	0.4	0.2	0.6
10/14/2021 05:00	4,431.5	0.0	4,431.5	104,900.0	464.9	0.6	0.3	0.9
10/14/2021 06:00	4,790.0	0.0	4,790.0	104,900.0	502.5	0.6	0.3	1.0
10/14/2021 07:00	3,555.2	0.0	3,555.2	104,900.0	372.9	0.4	0.2	0.7
10/14/2021 08:00	2,951.5	0.0	2,951.5	104,900.0	309.6	0.4	0.2	0.6
10/14/2021 09:00	2,949.3	0.0	2,949.3	104,900.0	309.4	0.4	0.2	0.6
10/14/2021 10:00	2,868.7	0.0	2,868.7	104,900.0	300.9	0.4	0.2	0.6
10/14/2021 11:00	2,872.7	0.0	2,872.7	104,900.0	301.3	0.4	0.2	0.6
10/14/2021 12:00	2,876.7	0.0	2,876.7	104,900.0	301.8	0.4	0.2	0.6
10/14/2021 13:00	2,950.7	0.0	2,950.7	104,900.0	309.5	0.4	0.2	0.6
10/14/2021 14:00	2,966.8	0.0	2,966.8	104,900.0	311.2	0.4	0.2	0.6
10/14/2021 15:00	3,155.5	0.0	3,155.5	104,900.0	331.0	0.4	0.2	0.7
10/14/2021 16:00	3,781.6	0.0	3,781.6	104,900.0	396.7	0.5	0.2	0.8
10/14/2021 17:00	4,672.6	0.0	4,672.6	104,900.0	490.2	0.6	0.3	1.0
10/14/2021 18:00	4,444.0	0.0	4,444.0	104,900.0	466.2	0.6	0.3	0.9
10/14/2021 19:00	4,790.9	0.0	4,790.9	104,900.0	502.6	0.6	0.3	1.0
10/14/2021 20:00	4,820.0	0.1	4,820.0	104,900.0	505.6	0.6	0.3	1.0
10/14/2021 21:00	4,813.2	1,140.9	5,954.1	104,900.0	624.6	0.7	0.4	1.2
10/14/2021 22:00	4,819.2	301.3	5,120.5	104,900.0	537.1	0.6	0.3	1.1
10/14/2021 23:00	4,800.7	43.7	4,844.4	104,900.0	508.2	0.6	0.3	1.0
Average/Sum#:	3,672.7	61.9	3,734.6	104,900.0	391.8	0.5	0.2	0.8
Minimum:	2,868.7	0.0	2,868.7	104,900.0	300.9	0.4	0.2	0.6
Maximum:	4,820.0	1,140.9	5,954.1	104,900.0	624.6	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/15/2021 00:00	4,787.7	11.4	4,799.1	104,900.0	503.4	0.6	0.3	1.0
10/15/2021 01:00	4,817.1	12.4	4,829.5	104,900.0	506.6	0.6	0.3	1.0
10/15/2021 02:00	4,830.3	12.0	4,842.3	104,900.0	508.0	0.6	0.3	1.0
10/15/2021 03:00	4,833.0	11.2	4,844.2	104,900.0	508.2	0.6	0.3	1.0
10/15/2021 04:00	4,828.6	12.5	4,841.1	104,900.0	507.8	0.6	0.3	1.0
10/15/2021 05:00	4,832.0	12.1	4,844.1	104,900.0	508.1	0.6	0.3	1.0
10/15/2021 06:00	4,820.9	11.1	4,832.0	104,900.0	506.9	0.6	0.3	1.0
10/15/2021 07:00	4,815.6	13.0	4,828.6	104,900.0	506.5	0.6	0.3	1.0
10/15/2021 08:00	4,785.1	13.1	4,798.2	104,900.0	503.3	0.6	0.3	1.0
10/15/2021 09:00	4,782.4	13.6	4,796.0	104,900.0	503.1	0.6	0.3	1.0
10/15/2021 10:00	4,796.3	13.2	4,809.5	104,900.0	504.5	0.6	0.3	1.0
10/15/2021 11:00	4,784.5	13.2	4,797.7	104,900.0	503.3	0.6	0.3	1.0
10/15/2021 12:00	4,777.0	13.7	4,790.7	104,900.0	502.5	0.6	0.3	1.0
10/15/2021 13:00	4,780.0	13.2	4,793.2	104,900.0	502.8	0.6	0.3	1.0
10/15/2021 14:00	4,772.1	13.4	4,785.5	104,900.0	502.0	0.6	0.3	1.0
10/15/2021 15:00	4,753.2	14.3	4,767.5	104,900.0	500.1	0.6	0.3	1.0
10/15/2021 16:00	4,779.7	204.8	4,984.5	104,900.0	522.9	0.6	0.3	1.0
10/15/2021 17:00	4,769.4	137.8	4,907.2	104,900.0	514.8	0.6	0.3	1.0
10/15/2021 18:00	4,757.6	12.6	4,770.2	104,900.0	500.4	0.6	0.3	1.0
10/15/2021 19:00	4,753.5	12.5	4,766.0	104,900.0	500.0	0.6	0.3	1.0
10/15/2021 20:00	4,771.2	11.4	4,782.6	104,900.0	501.7	0.6	0.3	1.0
10/15/2021 21:00	4,784.7	11.6	4,796.3	104,900.0	503.1	0.6	0.3	1.0
10/15/2021 22:00	4,773.9	11.8	4,785.7	104,900.0	502.0	0.6	0.3	1.0
10/15/2021 23:00	4,770.2	10.8	4,781.0	104,900.0	501.5	0.6	0.3	1.0
Average/Sum#:	4,789.8	25.7	4,815.5	104,900.0	505.1	0.6	0.3	1.0
Minimum:	4,753.2	10.8	4,766.0	104,900.0	500.0	0.6	0.3	1.0
Maximum:	4,833.0	204.8	4,984.5	104,900.0	522.9	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/16/2021 00:00	4,776.3	13.5	4,789.8	104,900.0	502.5	0.6	0.3	1.0
10/16/2021 01:00	4,764.8	12.5	4,777.3	104,900.0	501.1	0.6	0.3	1.0
10/16/2021 02:00	4,768.0	12.8	4,780.8	104,900.0	501.5	0.6	0.3	1.0
10/16/2021 03:00	4,779.0	12.4	4,791.2	104,900.0	502.6	0.6	0.3	1.0
10/16/2021 04:00	4,809.4	21.5	4,830.9	104,900.0	506.8	0.6	0.3	1.0
10/16/2021 05:00	4,809.8	11.4	4,821.2	104,900.0	505.7	0.6	0.3	1.0
10/16/2021 06:00	4,811.3	13.0	4,824.3	104,900.0	506.1	0.6	0.3	1.0
10/16/2021 07:00	4,814.7	14.3	4,829.0	104,900.0	506.6	0.6	0.3	1.0
10/16/2021 08:00	4,802.8	13.2	4,816.0	104,900.0	505.2	0.6	0.3	1.0
10/16/2021 09:00	4,758.1	84.9	4,843.0	104,900.0	508.0	0.6	0.3	1.0
10/16/2021 10:00	4,664.5	232.2	4,896.7	104,900.0	513.7	0.6	0.3	1.0
10/16/2021 11:00	4,590.7	349.9	4,940.6	104,900.0	518.3	0.6	0.3	1.0
10/16/2021 12:00	4,532.9	415.5	4,948.4	104,900.0	519.1	0.6	0.3	1.0
10/16/2021 13:00	4,488.2	456.4	4,944.6	104,900.0	518.7	0.6	0.3	1.0
10/16/2021 14:00	4,464.3	490.9	4,955.2	104,900.0	519.8	0.6	0.3	1.0
10/16/2021 15:00	4,450.4	513.7	4,964.1	104,900.0	520.7	0.6	0.3	1.0
10/16/2021 16:00	4,467.8	482.2	4,950.0	104,900.0	519.3	0.6	0.3	1.0
10/16/2021 17:00	4,504.9	416.5	4,921.4	104,900.0	516.3	0.6	0.3	1.0
10/16/2021 18:00	4,550.9	373.1	4,924.0	104,900.0	516.5	0.6	0.3	1.0
10/16/2021 19:00	4,598.9	337.6	4,936.5	104,900.0	517.8	0.6	0.3	1.0
10/16/2021 20:00	4,652.1	245.3	4,897.4	104,900.0	513.7	0.6	0.3	1.0
10/16/2021 21:00	4,672.4	190.8	4,863.2	104,900.0	510.1	0.6	0.3	1.0
10/16/2021 22:00	4,689.2	153.3	4,842.5	104,900.0	508.0	0.6	0.3	1.0
10/16/2021 23:00	4,715.9	52.3	4,768.2	104,900.0	500.2	0.6	0.3	1.0
Average/Sum#:	4,664.1	205.0	4,869.0	104,900.0	510.8	0.6	0.3	1.0
Minimum:	4,450.4	11.4	4,768.2	104,900.0	500.2	0.6	0.3	1.0
Maximum:	4,814.7	513.7	4,964.1	104,900.0	520.7	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/17/2021 00:00	4,721.4	14.0	4,735.4	104,900.0	496.7	0.6	0.3	1.0
10/17/2021 01:00	4,727.3	12.8	4,740.1	104,900.0	497.2	0.6	0.3	1.0
10/17/2021 02:00	4,735.5	12.1	4,747.6	104,900.0	498.0	0.6	0.3	1.0
10/17/2021 03:00	4,737.9	11.4	4,749.3	104,900.0	498.2	0.6	0.3	1.0
10/17/2021 04:00	4,749.0	12.0	4,761.0	104,900.0	499.4	0.6	0.3	1.0
10/17/2021 05:00	4,767.1	14.3	4,781.4	104,900.0	501.6	0.6	0.3	1.0
10/17/2021 06:00	4,779.3	13.6	4,792.9	104,900.0	502.8	0.6	0.3	1.0
10/17/2021 07:00	4,796.6	602.7	5,399.3	104,900.0	566.4	0.7	0.3	1.1
10/17/2021 08:00	4,884.2	1,641.3	6,525.5	104,900.0	684.5	0.8	0.4	1.4
10/17/2021 09:00	4,857.1	887.6	5,744.7	104,900.0	602.6	0.7	0.4	1.2
10/17/2021 10:00	4,802.1	52.8	4,854.9	104,900.0	509.3	0.6	0.3	1.0
10/17/2021 11:00	4,784.3	88.5	4,872.8	104,900.0	511.2	0.6	0.3	1.0
10/17/2021 12:00	4,778.1	29.4	4,807.5	104,900.0	504.3	0.6	0.3	1.0
10/17/2021 13:00	4,765.2	12.6	4,777.8	104,900.0	501.2	0.6	0.3	1.0
10/17/2021 14:00	4,767.9	13.0	4,780.9	104,900.0	501.5	0.6	0.3	1.0
10/17/2021 15:00	4,778.6	14.0	4,792.6	104,900.0	502.7	0.6	0.3	1.0
10/17/2021 16:00	4,801.2	117.9	4,919.1	104,900.0	516.0	0.6	0.3	1.0
10/17/2021 17:00	4,781.3	12.7	4,794.0	104,900.0	502.9	0.6	0.3	1.0
10/17/2021 18:00	4,789.9	12.2	4,802.1	104,900.0	503.7	0.6	0.3	1.0
10/17/2021 19:00	4,797.1	11.8	4,808.9	104,900.0	504.5	0.6	0.3	1.0
10/17/2021 20:00	4,792.3	11.2	4,803.5	104,900.0	503.9	0.6	0.3	1.0
10/17/2021 21:00	4,805.1	12.0	4,817.1	104,900.0	505.3	0.6	0.3	1.0
10/17/2021 22:00	4,826.4	13.4	4,839.8	104,900.0	507.7	0.6	0.3	1.0
10/17/2021 23:00	4,826.9	12.0	4,838.9	104,900.0	507.6	0.6	0.3	1.0
Average/Sum#:	4,785.5	151.5	4,937.0	104,900.0	517.9	0.6	0.3	1.0
Minimum:	4,721.4	11.2	4,735.4	104,900.0	496.7	0.6	0.3	1.0
Maximum:	4,884.2	1,641.3	6,525.5	104,900.0	684.5	0.8	0.4	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/18/2021 00:00	4,820.0	11.8	4,831.8	104,900.0	506.9	0.6	0.3	1.0
10/18/2021 01:00	4,820.1	13.1	4,833.2	104,900.0	507.0	0.6	0.3	1.0
10/18/2021 02:00	4,822.9	13.1	4,836.0	104,900.0	507.3	0.6	0.3	1.0
10/18/2021 03:00	4,827.3	13.6	4,840.9	104,900.0	507.8	0.6	0.3	1.0
10/18/2021 04:00	4,825.3	11.9	4,837.2	104,900.0	507.4	0.6	0.3	1.0
10/18/2021 05:00	4,823.7	11.7	4,835.4	104,900.0	507.2	0.6	0.3	1.0
10/18/2021 06:00	4,829.5	11.8	4,841.3	104,900.0	507.9	0.6	0.3	1.0
10/18/2021 07:00	4,131.9	8.4	4,135.8	104,900.0	433.8	0.5	0.3	0.9
10/18/2021 08:00	4,166.4	4.6	4,168.0	104,900.0	437.2	0.5	0.3	0.9
10/18/2021 09:00	4,813.9	11.6	4,825.5	104,900.0	506.2	0.6	0.3	1.0
10/18/2021 10:00	4,807.1	12.8	4,819.9	104,900.0	505.6	0.6	0.3	1.0
10/18/2021 11:00	4,807.0	10.8	4,817.8	104,900.0	505.4	0.6	0.3	1.0
10/18/2021 12:00	4,800.3	13.5	4,813.8	104,900.0	505.0	0.6	0.3	1.0
10/18/2021 13:00	4,775.8	51.2	4,827.0	104,900.0	506.4	0.6	0.3	1.0
10/18/2021 14:00	4,782.4	174.3	4,956.7	104,900.0	520.0	0.6	0.3	1.0
10/18/2021 15:00	4,761.0	24.8	4,785.1	104,900.0	502.0	0.6	0.3	1.0
10/18/2021 16:00	3,640.4	12.8	3,642.1	104,900.0	382.1	0.5	0.2	0.8
10/18/2021 17:00	4,786.1	57.4	4,843.5	104,900.0	508.1	0.6	0.3	1.0
10/18/2021 18:00	4,815.2	9.6	4,824.8	104,900.0	506.1	0.6	0.3	1.0
10/18/2021 19:00	4,819.7	13.4	4,833.1	104,900.0	507.0	0.6	0.3	1.0
10/18/2021 20:00	4,824.0	13.0	4,837.0	104,900.0	507.4	0.6	0.3	1.0
10/18/2021 21:00	4,022.7	4.8	4,025.0	104,900.0	422.2	0.5	0.3	0.8
10/18/2021 22:00	2,972.3	0.0	2,972.3	104,900.0	311.8	0.4	0.2	0.6
10/18/2021 23:00	2,982.7	0.0	2,982.7	104,900.0	312.9	0.4	0.2	0.6
Average/Sum#:	4,519.9	21.3	4,540.2	104,900.0	476.3	0.6	0.3	0.9
Minimum:	2,972.3	0.0	2,972.3	104,900.0	311.8	0.4	0.2	0.6
Maximum:	4,829.5	174.3	4,956.7	104,900.0	520.0	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/19/2021 00:00	2,959.5	0.0	2,959.5	104,900.0	310.5	0.4	0.2	0.6
10/19/2021 01:00	2,950.3	0.0	2,950.3	104,900.0	309.5	0.4	0.2	0.6
10/19/2021 02:00	2,969.8	0.0	2,969.8	104,900.0	311.5	0.4	0.2	0.6
10/19/2021 03:00	3,996.0	4.5	3,997.7	104,900.0	419.4	0.5	0.3	0.8
10/19/2021 04:00	4,828.3	13.5	4,841.8	104,900.0	507.9	0.6	0.3	1.0
10/19/2021 05:00	4,819.7	13.5	4,833.2	104,900.0	507.0	0.6	0.3	1.0
10/19/2021 06:00	4,822.0	12.1	4,834.1	104,900.0	507.1	0.6	0.3	1.0
10/19/2021 07:00	4,825.7	12.9	4,838.6	104,900.0	507.6	0.6	0.3	1.0
10/19/2021 08:00	4,830.2	13.0	4,843.2	104,900.0	508.1	0.6	0.3	1.0
10/19/2021 09:00	4,824.9	49.0	4,873.9	104,900.0	511.3	0.6	0.3	1.0
10/19/2021 10:00	4,794.8	88.3	4,883.1	104,900.0	512.2	0.6	0.3	1.0
10/19/2021 11:00	4,764.0	11.9	4,775.9	104,900.0	501.0	0.6	0.3	1.0
10/19/2021 12:00	4,733.9	25.2	4,758.3	104,900.0	499.1	0.6	0.3	1.0
10/19/2021 13:00	4,081.7	74.4	4,111.5	104,900.0	431.3	0.5	0.3	0.9
10/19/2021 14:00	4,726.4	197.4	4,923.8	104,900.0	516.5	0.6	0.3	1.0
10/19/2021 15:00	4,711.6	223.5	4,935.1	104,900.0	517.7	0.6	0.3	1.0
10/19/2021 16:00	4,712.2	353.1	5,065.3	104,900.0	531.3	0.6	0.3	1.1
10/19/2021 17:00	4,736.0	223.7	4,959.7	104,900.0	520.3	0.6	0.3	1.0
10/19/2021 18:00	4,751.5	23.0	4,774.5	104,900.0	500.8	0.6	0.3	1.0
10/19/2021 19:00	4,749.5	3.8	4,753.3	104,900.0	498.6	0.6	0.3	1.0
10/19/2021 20:00	4,766.3	10.4	4,776.7	104,900.0	501.1	0.6	0.3	1.0
10/19/2021 21:00	4,515.6	8.8	4,521.9	104,900.0	474.3	0.6	0.3	0.9
10/19/2021 22:00	2,925.4	0.0	2,925.4	104,900.0	306.9	0.4	0.2	0.6
10/19/2021 23:00	2,933.3	0.0	2,933.3	104,900.0	307.7	0.4	0.2	0.6
Average/Sum#:	4,322.0	56.8	4,376.7	104,900.0	459.1	0.6	0.3	0.9
Minimum:	2,925.4	0.0	2,925.4	104,900.0	306.9	0.4	0.2	0.6
Maximum:	4,830.2	353.1	5,065.3	104,900.0	531.3	0.6	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/20/2021 00:00	2,932.4	0.0	2,932.4	104,900.0	307.6	0.4	0.2	0.6
10/20/2021 01:00	2,935.8	0.0	2,935.8	104,900.0	308.0	0.4	0.2	0.6
10/20/2021 02:00	2,936.1	0.0	2,936.1	104,900.0	308.0	0.4	0.2	0.6
10/20/2021 03:00	2,938.8	0.0	2,938.8	104,900.0	308.3	0.4	0.2	0.6
10/20/2021 04:00	3,969.2	4.5	3,971.0	104,900.0	416.6	0.5	0.3	0.8
10/20/2021 05:00	4,806.9	12.1	4,819.0	104,900.0	505.5	0.6	0.3	1.0
10/20/2021 06:00	4,034.0	6.3	4,037.0	104,900.0	423.5	0.5	0.3	0.8
10/20/2021 07:00	2,956.2	0.0	2,956.2	104,900.0	310.1	0.4	0.2	0.6
10/20/2021 08:00	2,952.5	0.0	2,952.5	104,900.0	309.7	0.4	0.2	0.6
10/20/2021 09:00	3,554.5	0.0	3,554.5	104,900.0	372.9	0.4	0.2	0.7
10/20/2021 10:00	2,970.1	0.0	2,970.1	104,900.0	311.6	0.4	0.2	0.6
10/20/2021 11:00	3,984.4	0.0	3,984.4	104,900.0	418.0	0.5	0.3	0.8
10/20/2021 12:00	3,819.6	0.0	3,819.6	104,900.0	400.7	0.5	0.2	0.8
10/20/2021 13:00	2,932.8	0.0	2,932.8	104,900.0	307.7	0.4	0.2	0.6
10/20/2021 14:00	2,947.2	0.0	2,947.2	104,900.0	309.2	0.4	0.2	0.6
10/20/2021 15:00	3,578.6	0.0	3,578.6	104,900.0	375.4	0.4	0.2	0.8
10/20/2021 16:00	3,910.9	0.0	3,910.9	104,900.0	410.3	0.5	0.2	0.8
10/20/2021 17:00	4,530.1	0.0	4,530.1	104,900.0	475.2	0.6	0.3	0.9
10/20/2021 18:00	3,039.5	0.0	3,039.5	104,900.0	318.8	0.4	0.2	0.6
10/20/2021 19:00	2,950.6	0.0	2,950.6	104,900.0	309.5	0.4	0.2	0.6
10/20/2021 20:00	3,029.6	0.0	3,029.6	104,900.0	317.8	0.4	0.2	0.6
10/20/2021 21:00	3,140.2	0.0	3,140.2	104,900.0	329.4	0.4	0.2	0.7
10/20/2021 22:00	4,512.9	0.0	4,512.9	104,900.0	473.4	0.6	0.3	0.9
10/20/2021 23:00	3,224.8	0.0	3,224.8	104,900.0	338.3	0.4	0.2	0.7
Average/Sum#:	3,441.2	1.0	3,441.9	104,900.0	361.1	0.4	0.2	0.7
Minimum:	2,932.4	0.0	2,932.4	104,900.0	307.6	0.4	0.2	0.6
Maximum:	4,806.9	12.1	4,819.0	104,900.0	505.5	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/21/2021 00:00	3,007.1	0.0	3,007.1	104,900.0	315.4	0.4	0.2	0.6
10/21/2021 01:00	2,970.5	0.0	2,970.5	104,900.0	311.6	0.4	0.2	0.6
10/21/2021 02:00	2,973.7	0.0	2,973.7	104,900.0	311.9	0.4	0.2	0.6
10/21/2021 03:00	3,554.0	0.0	3,554.0	104,900.0	372.8	0.4	0.2	0.7
10/21/2021 04:00	3,748.8	0.0	3,748.8	104,900.0	393.2	0.5	0.2	0.8
10/21/2021 05:00	4,274.4	0.0	4,274.4	104,900.0	448.4	0.5	0.3	0.9
10/21/2021 06:00	4,324.2	0.0	4,324.2	104,900.0	453.6	0.5	0.3	0.9
10/21/2021 07:00	4,228.4	0.0	4,228.4	104,900.0	443.6	0.5	0.3	0.9
10/21/2021 08:00	4,602.8	0.0	4,602.8	104,900.0	482.8	0.6	0.3	1.0
10/21/2021 09:00	4,848.9	0.0	4,848.9	104,900.0	508.6	0.6	0.3	1.0
10/21/2021 10:00	4,818.6	0.0	4,818.6	104,900.0	505.5	0.6	0.3	1.0
10/21/2021 11:00	4,227.1	0.0	4,227.1	104,900.0	443.4	0.5	0.3	0.9
10/21/2021 12:00	3,018.4	0.0	3,018.4	104,900.0	316.6	0.4	0.2	0.6
10/21/2021 13:00	4,380.4	0.0	4,380.4	104,900.0	459.5	0.5	0.3	0.9
10/21/2021 14:00	4,056.9	0.0	4,056.9	104,900.0	425.6	0.5	0.3	0.9
10/21/2021 15:00	3,390.0	0.0	3,390.0	104,900.0	355.6	0.4	0.2	0.7
10/21/2021 16:00	4,464.6	0.0	4,464.6	104,900.0	468.3	0.6	0.3	0.9
10/21/2021 17:00	4,759.5	0.0	4,759.5	104,900.0	499.3	0.6	0.3	1.0
10/21/2021 18:00	4,750.4	0.0	4,750.4	104,900.0	498.3	0.6	0.3	1.0
10/21/2021 19:00	4,785.2	0.0	4,785.2	104,900.0	502.0	0.6	0.3	1.0
10/21/2021 20:00	4,732.1	0.0	4,732.1	104,900.0	496.4	0.6	0.3	1.0
10/21/2021 21:00	4,300.6	0.0	4,300.6	104,900.0	451.1	0.5	0.3	0.9
10/21/2021 22:00	3,084.2	0.0	3,084.2	104,900.0	323.5	0.4	0.2	0.6
10/21/2021 23:00	2,840.1	0.0	2,840.1	104,900.0	297.9	0.4	0.2	0.6
Average/Sum#:	4,005.9	0.0	4,005.9	104,900.0	420.2	0.5	0.3	0.8
Minimum:	2,840.1	0.0	2,840.1	104,900.0	297.9	0.4	0.2	0.6
Maximum:	4,848.9	0.0	4,848.9	104,900.0	508.6	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/22/2021 00:00	2,841.6	0.0	2,841.6	104,900.0	298.1	0.4	0.2	0.6
10/22/2021 01:00	2,839.8	0.0	2,839.8	104,900.0	297.9	0.4	0.2	0.6
10/22/2021 02:00	2,838.1	0.0	2,838.1	104,900.0	297.7	0.4	0.2	0.6
10/22/2021 03:00	2,940.2	0.0	2,940.2	104,900.0	308.4	0.4	0.2	0.6
10/22/2021 04:00	2,968.3	0.0	2,968.3	104,900.0	311.4	0.4	0.2	0.6
10/22/2021 05:00	2,943.9	0.0	2,943.9	104,900.0	308.8	0.4	0.2	0.6
10/22/2021 06:00	2,938.9	0.0	2,938.9	104,900.0	308.3	0.4	0.2	0.6
10/22/2021 07:00	3,692.5	0.0	3,692.5	104,900.0	387.3	0.5	0.2	0.8
10/22/2021 08:00	4,687.6	0.0	4,687.6	104,900.0	491.7	0.6	0.3	1.0
10/22/2021 09:00	4,627.7	0.0	4,627.7	104,900.0	485.4	0.6	0.3	1.0
10/22/2021 10:00	4,807.4	0.0	4,807.4	104,900.0	504.3	0.6	0.3	1.0
10/22/2021 11:00	4,740.4	0.0	4,740.4	104,900.0	497.3	0.6	0.3	1.0
10/22/2021 12:00	3,461.5	0.0	3,461.5	104,900.0	363.1	0.4	0.2	0.7
10/22/2021 13:00	3,321.1	0.0	3,321.1	104,900.0	348.4	0.4	0.2	0.7
10/22/2021 14:00	3,316.3	0.0	3,316.3	104,900.0	347.9	0.4	0.2	0.7
10/22/2021 15:00	3,317.9	0.0	3,317.9	104,900.0	348.0	0.4	0.2	0.7
10/22/2021 16:00	3,688.1	0.0	3,688.1	104,900.0	386.9	0.5	0.2	0.8
10/22/2021 17:00	4,185.9	0.0	4,185.9	104,900.0	439.1	0.5	0.3	0.9
10/22/2021 18:00	2,868.0	0.0	2,868.0	104,900.0	300.9	0.4	0.2	0.6
10/22/2021 19:00	3,034.0	0.0	3,034.0	104,900.0	318.3	0.4	0.2	0.6
10/22/2021 20:00	2,976.1	0.0	2,976.1	104,900.0	312.2	0.4	0.2	0.6
10/22/2021 21:00	2,925.1	0.0	2,925.1	104,900.0	306.8	0.4	0.2	0.6
10/22/2021 22:00	2,919.1	0.0	2,919.1	104,900.0	306.2	0.4	0.2	0.6
10/22/2021 23:00	3,240.2	0.0	3,240.2	104,900.0	339.9	0.4	0.2	0.7
Average/Sum#:	3,421.7	0.0	3,421.7	104,900.0	358.9	0.4	0.2	0.7
Minimum:	2,838.1	0.0	2,838.1	104,900.0	297.7	0.4	0.2	0.6
Maximum:	4,807.4	0.0	4,807.4	104,900.0	504.3	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/23/2021 00:00	3,285.6	0.0	3,285.6	104,900.0	344.7	0.4	0.2	0.7
10/23/2021 01:00	2,852.6	0.0	2,852.6	104,900.0	299.2	0.4	0.2	0.6
10/23/2021 02:00	2,946.7	0.0	2,946.7	104,900.0	309.1	0.4	0.2	0.6
10/23/2021 03:00	2,963.3	0.0	2,963.3	104,900.0	310.9	0.4	0.2	0.6
10/23/2021 04:00	2,991.7	0.0	2,991.7	104,900.0	313.8	0.4	0.2	0.6
10/23/2021 05:00	3,562.8	0.0	3,562.8	104,900.0	373.7	0.4	0.2	0.7
10/23/2021 06:00	3,916.0	0.0	3,916.0	104,900.0	410.8	0.5	0.2	0.8
10/23/2021 07:00	3,650.4	0.0	3,650.4	104,900.0	382.9	0.5	0.2	0.8
10/23/2021 08:00	4,548.7	0.0	4,548.7	104,900.0	477.2	0.6	0.3	1.0
10/23/2021 09:00	3,989.0	0.0	3,989.0	104,900.0	418.4	0.5	0.3	0.8
10/23/2021 10:00	3,238.2	0.0	3,238.2	104,900.0	339.7	0.4	0.2	0.7
10/23/2021 11:00	3,225.7	0.0	3,225.7	104,900.0	338.4	0.4	0.2	0.7
10/23/2021 12:00	4,716.2	0.0	4,716.2	104,900.0	494.7	0.6	0.3	1.0
10/23/2021 13:00	3,752.9	0.0	3,752.9	104,900.0	393.7	0.5	0.2	0.8
10/23/2021 14:00	4,811.1	0.0	4,811.1	104,900.0	504.7	0.6	0.3	1.0
10/23/2021 15:00	4,675.3	0.0	4,675.3	104,900.0	490.4	0.6	0.3	1.0
10/23/2021 16:00	4,799.5	0.0	4,799.5	104,900.0	503.5	0.6	0.3	1.0
10/23/2021 17:00	4,770.6	0.0	4,770.6	104,900.0	500.4	0.6	0.3	1.0
10/23/2021 18:00	3,046.2	0.0	3,046.2	104,900.0	319.5	0.4	0.2	0.6
10/23/2021 19:00	3,164.5	0.0	3,164.5	104,900.0	332.0	0.4	0.2	0.7
10/23/2021 20:00	2,984.7	0.0	2,984.7	104,900.0	313.1	0.4	0.2	0.6
10/23/2021 21:00	2,993.7	0.0	2,993.7	104,900.0	314.0	0.4	0.2	0.6
10/23/2021 22:00	3,162.3	0.0	3,162.3	104,900.0	331.7	0.4	0.2	0.7
10/23/2021 23:00	4,652.8	0.0	4,652.8	104,900.0	488.1	0.6	0.3	1.0
Average/Sum#:	3,695.9	0.0	3,695.9	104,900.0	387.7	0.5	0.2	0.8
Minimum:	2,852.6	0.0	2,852.6	104,900.0	299.2	0.4	0.2	0.6
Maximum:	4,811.1	0.0	4,811.1	104,900.0	504.7	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/24/2021 00:00	4,038.7	0.0	4,038.7	104,900.0	423.7	0.5	0.3	0.8
10/24/2021 01:00	2,897.7	0.0	2,897.7	104,900.0	304.0	0.4	0.2	0.6
10/24/2021 02:00	2,871.2	0.0	2,871.2	104,900.0	301.2	0.4	0.2	0.6
10/24/2021 03:00	2,881.8	0.0	2,881.8	104,900.0	302.3	0.4	0.2	0.6
10/24/2021 04:00	2,842.0	0.0	2,842.0	104,900.0	298.1	0.4	0.2	0.6
10/24/2021 05:00	2,929.6	0.0	2,929.6	104,900.0	307.3	0.4	0.2	0.6
10/24/2021 06:00	2,927.8	0.0	2,927.8	104,900.0	307.1	0.4	0.2	0.6
10/24/2021 07:00	4,060.2	0.0	4,060.2	104,900.0	425.9	0.5	0.3	0.9
10/24/2021 08:00	4,784.3	0.0	4,784.3	104,900.0	501.9	0.6	0.3	1.0
10/24/2021 09:00	4,796.5	0.0	4,796.5	104,900.0	503.2	0.6	0.3	1.0
10/24/2021 10:00	4,681.6	0.0	4,681.6	104,900.0	491.1	0.6	0.3	1.0
10/24/2021 11:00	4,793.7	0.0	4,793.7	104,900.0	502.9	0.6	0.3	1.0
10/24/2021 12:00	4,674.2	0.0	4,674.2	104,900.0	490.3	0.6	0.3	1.0
10/24/2021 13:00	4,774.0	0.0	4,774.0	104,900.0	500.8	0.6	0.3	1.0
10/24/2021 14:00	3,727.7	0.0	3,727.7	104,900.0	391.0	0.5	0.2	0.8
10/24/2021 15:00	4,360.7	0.0	4,360.7	104,900.0	457.4	0.5	0.3	0.9
10/24/2021 16:00	4,104.6	0.0	4,104.6	104,900.0	430.6	0.5	0.3	0.9
10/24/2021 17:00	4,603.1	0.0	4,603.1	104,900.0	482.9	0.6	0.3	1.0
10/24/2021 18:00	3,659.0	0.0	3,659.0	104,900.0	383.8	0.5	0.2	0.8
10/24/2021 19:00	4,099.8	0.0	4,099.8	104,900.0	430.1	0.5	0.3	0.9
10/24/2021 20:00	3,196.3	0.0	3,196.3	104,900.0	335.3	0.4	0.2	0.7
10/24/2021 21:00	3,330.6	0.0	3,330.6	104,900.0	349.4	0.4	0.2	0.7
10/24/2021 22:00	3,039.6	0.0	3,039.6	104,900.0	318.9	0.4	0.2	0.6
10/24/2021 23:00	3,018.9	0.0	3,018.9	104,900.0	316.7	0.4	0.2	0.6
Average/Sum#:	3,795.6	0.0	3,795.6	104,900.0	398.2	0.5	0.3	0.8
Minimum:	2,842.0	0.0	2,842.0	104,900.0	298.1	0.4	0.2	0.6
Maximum:	4,796.5	0.0	4,796.5	104,900.0	503.2	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/25/2021 00:00	3,366.8	0.0	3,366.8	104,900.0	353.2	0.4	0.2	0.7
10/25/2021 01:00	3,050.1	0.0	3,050.1	104,900.0	320.0	0.4	0.2	0.6
10/25/2021 02:00	3,019.3	0.0	3,019.3	104,900.0	316.7	0.4	0.2	0.6
10/25/2021 03:00	3,051.3	0.0	3,051.3	104,900.0	320.1	0.4	0.2	0.6
10/25/2021 04:00	4,470.8	0.0	4,470.8	104,900.0	469.0	0.6	0.3	0.9
10/25/2021 05:00	4,685.2	0.0	4,685.2	104,900.0	491.5	0.6	0.3	1.0
10/25/2021 06:00	4,456.3	0.0	4,456.3	104,900.0	467.5	0.6	0.3	0.9
10/25/2021 07:00	4,368.1	0.0	4,368.1	104,900.0	458.2	0.5	0.3	0.9
10/25/2021 08:00	4,636.5	0.0	4,636.5	104,900.0	486.4	0.6	0.3	1.0
10/25/2021 09:00	3,606.1	0.0	3,606.1	104,900.0	378.3	0.5	0.2	0.8
10/25/2021 10:00	2,887.5	0.0	2,887.5	104,900.0	302.9	0.4	0.2	0.6
10/25/2021 11:00	2,844.1	0.0	2,844.1	104,900.0	298.3	0.4	0.2	0.6
10/25/2021 12:00	2,845.8	0.0	2,845.8	104,900.0	298.5	0.4	0.2	0.6
10/25/2021 13:00	2,885.0	0.0	2,885.0	104,900.0	302.6	0.4	0.2	0.6
10/25/2021 14:00	2,876.7	0.0	2,876.7	104,900.0	301.8	0.4	0.2	0.6
10/25/2021 15:00	2,847.3	0.0	2,847.3	104,900.0	298.7	0.4	0.2	0.6
10/25/2021 16:00	4,008.2	0.0	4,008.2	104,900.0	420.5	0.5	0.3	0.8
10/25/2021 17:00	3,815.8	0.0	3,815.8	104,900.0	400.3	0.5	0.2	0.8
10/25/2021 18:00	3,727.0	0.0	3,727.0	104,900.0	391.0	0.5	0.2	0.8
10/25/2021 19:00	4,259.9	0.0	4,259.9	104,900.0	446.9	0.5	0.3	0.9
10/25/2021 20:00	4,643.3	0.0	4,643.3	104,900.0	487.1	0.6	0.3	1.0
10/25/2021 21:00	3,109.5	0.0	3,109.5	104,900.0	326.2	0.4	0.2	0.7
10/25/2021 22:00	2,883.4	0.0	2,883.4	104,900.0	302.5	0.4	0.2	0.6
10/25/2021 23:00	2,949.4	0.0	2,949.4	104,900.0	309.4	0.4	0.2	0.6
Average/Sum#:	3,553.9	0.0	3,553.9	104,900.0	372.8	0.5	0.2	0.7
Minimum:	2,844.1	0.0	2,844.1	104,900.0	298.3	0.4	0.2	0.6
Maximum:	4,685.2	0.0	4,685.2	104,900.0	491.5	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/26/2021 00:00	2,874.9	0.0	2,874.9	104,900.0	301.6	0.4	0.2	0.6
10/26/2021 01:00	2,907.3	0.0	2,907.3	104,900.0	305.0	0.4	0.2	0.6
10/26/2021 02:00	2,911.4	0.0	2,911.4	104,900.0	305.4	0.4	0.2	0.6
10/26/2021 03:00	2,965.9	0.0	2,965.9	104,900.0	311.1	0.4	0.2	0.6
10/26/2021 04:00	2,890.8	0.0	2,890.8	104,900.0	303.2	0.4	0.2	0.6
10/26/2021 05:00	4,031.9	0.0	4,031.9	104,900.0	422.9	0.5	0.3	0.8
10/26/2021 06:00	3,103.2	0.0	3,103.2	104,900.0	325.5	0.4	0.2	0.7
10/26/2021 07:00	3,435.8	0.0	3,435.8	104,900.0	360.4	0.4	0.2	0.7
10/26/2021 08:00	2,990.4	0.0	2,990.4	104,900.0	313.7	0.4	0.2	0.6
10/26/2021 09:00	2,974.6	0.0	2,974.6	104,900.0	312.0	0.4	0.2	0.6
10/26/2021 10:00	2,967.3	0.0	2,967.3	104,900.0	311.3	0.4	0.2	0.6
10/26/2021 11:00	3,094.3	0.0	3,094.3	104,900.0	324.6	0.4	0.2	0.6
10/26/2021 12:00	2,960.6	0.0	2,960.6	104,900.0	310.6	0.4	0.2	0.6
10/26/2021 13:00	2,916.0	0.0	2,916.0	104,900.0	305.9	0.4	0.2	0.6
10/26/2021 14:00	3,154.2	0.0	3,154.2	104,900.0	330.9	0.4	0.2	0.7
10/26/2021 15:00	2,936.8	0.0	2,936.8	104,900.0	308.1	0.4	0.2	0.6
10/26/2021 16:00	3,283.5	0.0	3,283.5	104,900.0	344.4	0.4	0.2	0.7
10/26/2021 17:00	3,023.1	0.0	3,023.1	104,900.0	317.1	0.4	0.2	0.6
10/26/2021 18:00	3,835.6	0.0	3,835.6	104,900.0	402.4	0.5	0.2	0.8
10/26/2021 19:00	3,896.3	0.0	3,896.3	104,900.0	408.7	0.5	0.2	0.8
10/26/2021 20:00	4,169.8	0.0	4,169.8	104,900.0	437.4	0.5	0.3	0.9
10/26/2021 21:00	4,106.0	0.0	4,106.0	104,900.0	430.7	0.5	0.3	0.9
10/26/2021 22:00	4,242.2	0.0	4,242.2	104,900.0	445.0	0.5	0.3	0.9
10/26/2021 23:00	2,993.5	0.0	2,993.5	104,900.0	314.0	0.4	0.2	0.6
Average/Sum#:	3,277.7	0.0	3,277.7	104,900.0	343.8	0.4	0.2	0.7
Minimum:	2,874.9	0.0	2,874.9	104,900.0	301.6	0.4	0.2	0.6
Maximum:	4,242.2	0.0	4,242.2	104,900.0	445.0	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/27/2021 00:00	2,985.7	0.0	2,985.7	104,900.0	313.2	0.4	0.2	0.6
10/27/2021 01:00	2,911.7	0.0	2,911.7	104,900.0	305.4	0.4	0.2	0.6
10/27/2021 02:00	2,878.4	0.0	2,878.4	104,900.0	301.9	0.4	0.2	0.6
10/27/2021 03:00	2,935.0	0.0	2,935.0	104,900.0	307.9	0.4	0.2	0.6
10/27/2021 04:00	2,956.3	0.0	2,956.3	104,900.0	310.1	0.4	0.2	0.6
10/27/2021 05:00	3,509.3	0.0	3,509.3	104,900.0	368.1	0.4	0.2	0.7
10/27/2021 06:00	4,416.9	0.0	4,416.9	104,900.0	463.3	0.6	0.3	0.9
10/27/2021 07:00	3,204.6	0.0	3,204.6	104,900.0	336.2	0.4	0.2	0.7
10/27/2021 08:00	2,850.2	0.0	2,850.2	104,900.0	299.0	0.4	0.2	0.6
10/27/2021 09:00	2,849.7	0.0	2,849.7	104,900.0	298.9	0.4	0.2	0.6
10/27/2021 10:00	2,849.5	0.0	2,849.5	104,900.0	298.9	0.4	0.2	0.6
10/27/2021 11:00	2,847.1	0.0	2,847.1	104,900.0	298.7	0.4	0.2	0.6
10/27/2021 12:00	2,844.3	0.0	2,844.3	104,900.0	298.4	0.4	0.2	0.6
10/27/2021 13:00	2,849.9	0.0	2,849.9	104,900.0	299.0	0.4	0.2	0.6
10/27/2021 14:00	2,846.4	0.0	2,846.4	104,900.0	298.6	0.4	0.2	0.6
10/27/2021 15:00	3,125.3	0.0	3,125.3	104,900.0	327.8	0.4	0.2	0.7
10/27/2021 16:00	4,410.3	0.0	4,410.3	104,900.0	462.6	0.6	0.3	0.9
10/27/2021 17:00	4,806.6	0.0	4,806.6	104,900.0	504.2	0.6	0.3	1.0
10/27/2021 18:00	4,419.3	0.0	4,419.3	104,900.0	463.6	0.6	0.3	0.9
10/27/2021 19:00	4,612.4	0.0	4,612.4	104,900.0	483.8	0.6	0.3	1.0
10/27/2021 20:00	4,236.3	0.0	4,236.3	104,900.0	444.4	0.5	0.3	0.9
10/27/2021 21:00	4,328.0	0.0	4,328.0	104,900.0	454.0	0.5	0.3	0.9
10/27/2021 22:00	3,154.0	0.0	3,154.0	104,900.0	330.9	0.4	0.2	0.7
10/27/2021 23:00	2,989.7	0.0	2,989.7	104,900.0	313.6	0.4	0.2	0.6
Average/Sum#:	3,409.0	0.0	3,409.0	104,900.0	357.6	0.5	0.2	0.7
Minimum:	2,844.3	0.0	2,844.3	104,900.0	298.4	0.4	0.2	0.6
Maximum:	4,806.6	0.0	4,806.6	104,900.0	504.2	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/28/2021 00:00	2,987.7	0.0	2,987.7	104,900.0	313.4	0.4	0.2	0.6
10/28/2021 01:00	2,990.7	0.0	2,990.7	104,900.0	313.7	0.4	0.2	0.6
10/28/2021 02:00	2,992.4	0.0	2,992.4	104,900.0	313.9	0.4	0.2	0.6
10/28/2021 03:00	2,991.7	0.0	2,991.7	104,900.0	313.8	0.4	0.2	0.6
10/28/2021 04:00	3,274.0	0.0	3,274.0	104,900.0	343.4	0.4	0.2	0.7
10/28/2021 05:00	3,933.8	0.0	3,933.8	104,900.0	412.7	0.5	0.2	0.8
10/28/2021 06:00	4,012.0	0.0	4,012.0	104,900.0	420.9	0.5	0.3	0.8
10/28/2021 07:00	2,965.7	0.0	2,965.7	104,900.0	311.1	0.4	0.2	0.6
10/28/2021 08:00	2,868.6	0.0	2,868.6	104,900.0	300.9	0.4	0.2	0.6
10/28/2021 09:00	2,846.8	0.0	2,846.8	104,900.0	298.6	0.4	0.2	0.6
10/28/2021 10:00	2,906.0	0.0	2,906.0	104,900.0	304.8	0.4	0.2	0.6
10/28/2021 11:00	2,949.4	0.0	2,949.4	104,900.0	309.4	0.4	0.2	0.6
10/28/2021 12:00	2,956.8	0.0	2,956.8	104,900.0	310.2	0.4	0.2	0.6
10/28/2021 13:00	2,829.5	0.0	2,829.5	104,900.0	296.8	0.4	0.2	0.6
10/28/2021 14:00	2,849.4	0.0	2,849.4	104,900.0	298.9	0.4	0.2	0.6
10/28/2021 15:00	2,885.9	0.0	2,885.9	104,900.0	302.7	0.4	0.2	0.6
10/28/2021 16:00	4,273.0	0.0	4,273.0	104,900.0	448.2	0.5	0.3	0.9
10/28/2021 17:00	4,779.5	0.0	4,779.5	104,900.0	501.4	0.6	0.3	1.0
10/28/2021 18:00	4,555.3	0.0	4,555.3	104,900.0	477.9	0.6	0.3	1.0
10/28/2021 19:00	4,723.5	0.0	4,723.5	104,900.0	495.5	0.6	0.3	1.0
10/28/2021 20:00	4,522.0	0.0	4,522.0	104,900.0	474.4	0.6	0.3	0.9
10/28/2021 21:00	4,006.4	0.0	4,006.4	104,900.0	420.3	0.5	0.3	0.8
10/28/2021 22:00	2,973.9	0.0	2,973.9	104,900.0	312.0	0.4	0.2	0.6
10/28/2021 23:00	2,932.2	0.0	2,932.2	104,900.0	307.6	0.4	0.2	0.6
Average/Sum#:	3,416.9	0.0	3,416.9	104,900.0	358.4	0.5	0.2	0.7
Minimum:	2,829.5	0.0	2,829.5	104,900.0	296.8	0.4	0.2	0.6
Maximum:	4,779.5	0.0	4,779.5	104,900.0	501.4	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/29/2021 00:00	2,911.8	0.0	2,911.8	104,900.0	305.4	0.4	0.2	0.6
10/29/2021 01:00	2,906.5	0.0	2,906.5	104,900.0	304.9	0.4	0.2	0.6
10/29/2021 02:00	2,869.7	0.0	2,869.7	104,900.0	301.0	0.4	0.2	0.6
10/29/2021 03:00	2,991.7	0.0	2,991.7	104,900.0	313.8	0.4	0.2	0.6
10/29/2021 04:00	2,992.1	0.0	2,992.1	104,900.0	313.9	0.4	0.2	0.6
10/29/2021 05:00	3,621.2	0.0	3,621.2	104,900.0	379.9	0.5	0.2	0.8
10/29/2021 06:00	3,953.8	0.0	3,953.8	104,900.0	414.8	0.5	0.2	0.8
10/29/2021 07:00	2,919.8	0.0	2,919.8	104,900.0	306.3	0.4	0.2	0.6
10/29/2021 08:00	2,848.2	0.0	2,848.2	104,900.0	298.8	0.4	0.2	0.6
10/29/2021 09:00	2,858.2	0.0	2,858.2	104,900.0	299.8	0.4	0.2	0.6
10/29/2021 10:00	2,851.2	0.0	2,851.2	104,900.0	299.1	0.4	0.2	0.6
10/29/2021 11:00	2,847.5	0.0	2,847.5	104,900.0	298.7	0.4	0.2	0.6
10/29/2021 12:00	2,831.6	0.0	2,831.6	104,900.0	297.0	0.4	0.2	0.6
10/29/2021 13:00	2,876.9	0.0	2,876.9	104,900.0	301.8	0.4	0.2	0.6
10/29/2021 14:00	2,830.8	0.0	2,830.8	104,900.0	297.0	0.4	0.2	0.6
10/29/2021 15:00	3,571.1	33.2	3,576.1	104,900.0	375.1	0.5	0.2	0.8
10/29/2021 16:00	4,607.1	0.0	4,607.1	104,900.0	483.3	0.6	0.3	1.0
10/29/2021 17:00	4,663.5	0.0	4,663.5	104,900.0	489.2	0.6	0.3	1.0
10/29/2021 18:00	4,006.2	0.0	4,006.2	104,900.0	420.3	0.5	0.3	0.8
10/29/2021 19:00	4,679.3	0.0	4,679.3	104,900.0	490.9	0.6	0.3	1.0
10/29/2021 20:00	4,448.7	0.0	4,448.7	104,900.0	466.7	0.6	0.3	0.9
10/29/2021 21:00	3,968.9	0.0	3,968.9	104,900.0	416.3	0.5	0.2	0.8
10/29/2021 22:00	3,869.3	0.0	3,869.3	104,900.0	405.9	0.5	0.2	0.8
10/29/2021 23:00	3,435.6	0.0	3,435.6	104,900.0	360.4	0.4	0.2	0.7
Average/Sum#:	3,431.7	1.4	3,431.9	104,900.0	360.0	0.5	0.2	0.7
Minimum:	2,830.8	0.0	2,830.8	104,900.0	297.0	0.4	0.2	0.6
Maximum:	4,679.3	33.2	4,679.3	104,900.0	490.9	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/30/2021 00:00	3,241.8	0.0	3,241.8	104,900.0	340.1	0.4	0.2	0.7
10/30/2021 01:00	2,935.0	0.0	2,935.0	104,900.0	307.9	0.4	0.2	0.6
10/30/2021 02:00	2,870.8	0.0	2,870.8	104,900.0	301.1	0.4	0.2	0.6
10/30/2021 03:00	2,950.8	0.0	2,950.8	104,900.0	309.5	0.4	0.2	0.6
10/30/2021 04:00	2,944.2	0.0	2,944.2	104,900.0	308.8	0.4	0.2	0.6
10/30/2021 05:00	3,312.9	0.0	3,312.9	104,900.0	347.5	0.4	0.2	0.7
10/30/2021 06:00	2,914.9	0.0	2,914.9	104,900.0	305.8	0.4	0.2	0.6
10/30/2021 07:00	2,869.3	0.0	2,869.3	104,900.0	301.0	0.4	0.2	0.6
10/30/2021 08:00	2,844.9	0.0	2,844.9	104,900.0	298.4	0.4	0.2	0.6
10/30/2021 09:00	2,838.6	0.0	2,838.6	104,900.0	297.8	0.4	0.2	0.6
10/30/2021 10:00	2,836.2	0.0	2,836.2	104,900.0	297.5	0.4	0.2	0.6
10/30/2021 11:00	2,834.1	0.0	2,834.1	104,900.0	297.3	0.4	0.2	0.6
10/30/2021 12:00	2,829.4	0.0	2,829.4	104,900.0	296.8	0.4	0.2	0.6
10/30/2021 13:00	2,825.8	0.0	2,825.8	104,900.0	296.4	0.4	0.2	0.6
10/30/2021 14:00	2,827.8	0.0	2,827.8	104,900.0	296.6	0.4	0.2	0.6
10/30/2021 15:00	3,496.4	0.0	3,496.4	104,900.0	366.8	0.4	0.2	0.7
10/30/2021 16:00	3,139.7	0.0	3,139.7	104,900.0	329.4	0.4	0.2	0.7
10/30/2021 17:00	2,996.4	0.0	2,996.4	104,900.0	314.3	0.4	0.2	0.6
10/30/2021 18:00	2,848.0	0.0	2,848.0	104,900.0	298.8	0.4	0.2	0.6
10/30/2021 19:00	2,923.0	0.0	2,923.0	104,900.0	306.6	0.4	0.2	0.6
10/30/2021 20:00	2,887.9	0.0	2,887.9	104,900.0	302.9	0.4	0.2	0.6
10/30/2021 21:00	2,873.1	0.0	2,873.1	104,900.0	301.4	0.4	0.2	0.6
10/30/2021 22:00	2,873.1	0.0	2,873.1	104,900.0	301.4	0.4	0.2	0.6
10/30/2021 23:00	2,946.4	0.0	2,946.4	104,900.0	309.1	0.4	0.2	0.6
Average/Sum#:	2,952.5	0.0	2,952.5	104,900.0	309.7	0.4	0.2	0.6
Minimum:	2,825.8	0.0	2,825.8	104,900.0	296.4	0.4	0.2	0.6
Maximum:	3,496.4	0.0	3,496.4	104,900.0	366.8	0.4	0.2	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/31/2021 00:00	2,888.4	0.0	2,888.4	104,900.0	303.0	0.4	0.2	0.6
10/31/2021 01:00	2,891.4	0.0	2,891.4	104,900.0	303.3	0.4	0.2	0.6
10/31/2021 02:00	2,889.7	0.0	2,889.7	104,900.0	303.1	0.4	0.2	0.6
10/31/2021 03:00	2,890.6	0.0	2,890.6	104,900.0	303.2	0.4	0.2	0.6
10/31/2021 04:00	2,891.2	0.0	2,891.2	104,900.0	303.3	0.4	0.2	0.6
10/31/2021 05:00	2,982.8	0.0	2,982.8	104,900.0	312.9	0.4	0.2	0.6
10/31/2021 06:00	3,138.4	0.0	3,138.4	104,900.0	329.2	0.4	0.2	0.7
10/31/2021 07:00	2,904.0	0.0	2,904.0	104,900.0	304.6	0.4	0.2	0.6
10/31/2021 08:00	2,885.9	0.0	2,885.9	104,900.0	302.7	0.4	0.2	0.6
10/31/2021 09:00	2,908.1	0.0	2,908.1	104,900.0	305.1	0.4	0.2	0.6
10/31/2021 10:00	2,841.0	0.0	2,841.0	104,900.0	298.0	0.4	0.2	0.6
10/31/2021 11:00	2,838.1	0.0	2,838.1	104,900.0	297.7	0.4	0.2	0.6
10/31/2021 12:00	2,834.9	0.0	2,834.9	104,900.0	297.4	0.4	0.2	0.6
10/31/2021 13:00	2,837.0	0.0	2,837.0	104,900.0	297.6	0.4	0.2	0.6
10/31/2021 14:00	2,833.9	0.0	2,833.9	104,900.0	297.3	0.4	0.2	0.6
10/31/2021 15:00	3,094.6	0.0	3,094.6	104,900.0	324.6	0.4	0.2	0.6
10/31/2021 16:00	2,848.2	0.0	2,848.2	104,900.0	298.8	0.4	0.2	0.6
10/31/2021 17:00	2,837.6	0.0	2,837.6	104,900.0	297.7	0.4	0.2	0.6
10/31/2021 18:00	2,837.6	0.0	2,837.6	104,900.0	297.7	0.4	0.2	0.6
10/31/2021 19:00	2,841.3	0.0	2,841.3	104,900.0	298.1	0.4	0.2	0.6
10/31/2021 20:00	2,841.3	0.0	2,841.3	104,900.0	298.1	0.4	0.2	0.6
10/31/2021 21:00	2,841.9	0.0	2,841.9	104,900.0	298.1	0.4	0.2	0.6
10/31/2021 22:00	2,852.6	0.0	2,852.6	104,900.0	299.2	0.4	0.2	0.6
10/31/2021 23:00	2,896.3	0.0	2,896.3	104,900.0	303.8	0.4	0.2	0.6
Average/Sum#:	2,889.5	0.0	2,889.5	104,900.0	303.1	0.4	0.2	0.6
Minimum:	2,833.9	0.0	2,833.9	104,900.0	297.3	0.4	0.2	0.6
Maximum:	3,138.4	0.0	3,138.4	104,900.0	329.2	0.4	0.2	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/01/2021 00:00	2,876.1	0.0	2,876.1	104,700.0	301.1	0.4	0.2	0.6
11/01/2021 01:00	2,916.2	0.0	2,916.2	104,700.0	305.3	0.4	0.2	0.6
11/01/2021 02:00	2,851.7	0.0	2,851.7	104,700.0	298.6	0.4	0.2	0.6
11/01/2021 03:00	2,960.1	0.0	2,960.1	104,700.0	309.9	0.4	0.2	0.6
11/01/2021 04:00	3,403.2	0.0	3,403.2	104,700.0	356.3	0.4	0.2	0.7
11/01/2021 05:00	2,940.5	0.0	2,940.5	104,700.0	307.9	0.4	0.2	0.6
11/01/2021 06:00	4,473.5	0.0	4,473.5	104,700.0	468.4	0.6	0.3	0.9
11/01/2021 07:00	3,519.6	0.0	3,519.6	104,700.0	368.5	0.4	0.2	0.7
11/01/2021 08:00	2,952.5	0.0	2,952.5	104,700.0	309.1	0.4	0.2	0.6
11/01/2021 09:00	3,655.7	0.0	3,655.7	104,700.0	382.8	0.5	0.2	0.8
11/01/2021 10:00	3,142.9	0.0	3,142.9	104,700.0	329.1	0.4	0.2	0.7
11/01/2021 11:00	3,709.2	0.0	3,709.2	104,700.0	388.4	0.5	0.2	0.8
11/01/2021 12:00	3,965.8	0.0	3,965.8	104,700.0	415.2	0.5	0.2	0.8
11/01/2021 13:00	4,787.6	0.0	4,787.6	104,700.0	501.3	0.6	0.3	1.0
11/01/2021 14:00	4,114.3	0.0	4,114.3	104,700.0	430.8	0.5	0.3	0.9
11/01/2021 15:00	3,266.9	0.0	3,266.9	104,700.0	342.0	0.4	0.2	0.7
11/01/2021 16:00	3,616.5	0.0	3,616.5	104,700.0	378.6	0.5	0.2	0.8
11/01/2021 17:00	4,577.7	0.0	4,577.7	104,700.0	479.3	0.6	0.3	1.0
11/01/2021 18:00	4,462.2	0.0	4,462.2	104,700.0	467.2	0.6	0.3	0.9
11/01/2021 19:00	4,642.7	0.0	4,642.7	104,700.0	486.1	0.6	0.3	1.0
11/01/2021 20:00	4,679.1	0.0	4,679.1	104,700.0	489.9	0.6	0.3	1.0
11/01/2021 21:00	4,508.8	0.0	4,508.8	104,700.0	472.1	0.6	0.3	0.9
11/01/2021 22:00	3,710.1	0.0	3,710.1	104,700.0	388.4	0.5	0.2	0.8
11/01/2021 23:00	3,019.6	0.0	3,019.6	104,700.0	316.2	0.4	0.2	0.6
Average/Sum#:	3,698.0	0.0	3,698.0	104,700.0	387.2	0.5	0.2	0.8
Minimum:	2,851.7	0.0	2,851.7	104,700.0	298.6	0.4	0.2	0.6
Maximum:	4,787.6	0.0	4,787.6	104,700.0	501.3	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/02/2021 00:00	3,007.4	0.0	3,007.4	104,700.0	314.9	0.4	0.2	0.6
11/02/2021 01:00	2,972.9	0.0	2,972.9	104,700.0	311.3	0.4	0.2	0.6
11/02/2021 02:00	2,873.9	0.0	2,873.9	104,700.0	300.9	0.4	0.2	0.6
11/02/2021 03:00	2,953.4	0.0	2,953.4	104,700.0	309.2	0.4	0.2	0.6
11/02/2021 04:00	2,951.9	0.0	2,951.9	104,700.0	309.1	0.4	0.2	0.6
11/02/2021 05:00	3,118.2	0.0	3,118.2	104,700.0	326.5	0.4	0.2	0.7
11/02/2021 06:00	4,070.9	0.0	4,070.9	104,700.0	426.2	0.5	0.3	0.9
11/02/2021 07:00	3,164.9	0.0	3,164.9	104,700.0	331.4	0.4	0.2	0.7
11/02/2021 08:00	2,841.7	0.0	2,841.7	104,700.0	297.5	0.4	0.2	0.6
11/02/2021 09:00	2,876.1	0.0	2,876.1	104,700.0	301.1	0.4	0.2	0.6
11/02/2021 10:00	2,882.9	0.0	2,882.9	104,700.0	301.8	0.4	0.2	0.6
11/02/2021 11:00	2,886.5	0.0	2,886.5	104,700.0	302.2	0.4	0.2	0.6
11/02/2021 12:00	2,890.2	0.0	2,890.2	104,700.0	302.6	0.4	0.2	0.6
11/02/2021 13:00	2,831.1	0.0	2,831.1	104,700.0	296.4	0.4	0.2	0.6
11/02/2021 14:00	2,830.7	0.0	2,830.7	104,700.0	296.4	0.4	0.2	0.6
11/02/2021 15:00	2,882.2	0.0	2,882.2	104,700.0	301.8	0.4	0.2	0.6
11/02/2021 16:00	3,888.2	0.0	3,888.2	104,700.0	407.1	0.5	0.2	0.8
11/02/2021 17:00	4,617.7	0.0	4,617.7	104,700.0	483.5	0.6	0.3	1.0
11/02/2021 18:00	4,410.1	0.0	4,410.1	104,700.0	461.7	0.6	0.3	0.9
11/02/2021 19:00	4,796.6	0.0	4,796.6	104,700.0	502.2	0.6	0.3	1.0
11/02/2021 20:00	4,725.2	0.0	4,725.2	104,700.0	494.7	0.6	0.3	1.0
11/02/2021 21:00	4,261.6	0.0	4,261.6	104,700.0	446.2	0.5	0.3	0.9
11/02/2021 22:00	4,467.6	0.0	4,467.6	104,700.0	467.8	0.6	0.3	0.9
11/02/2021 23:00	3,789.3	0.0	3,789.3	104,700.0	396.7	0.5	0.2	0.8
Average/Sum#:	3,458.0	0.0	3,458.0	104,700.0	362.1	0.5	0.2	0.7
Minimum:	2,830.7	0.0	2,830.7	104,700.0	296.4	0.4	0.2	0.6
Maximum:	4,796.6	0.0	4,796.6	104,700.0	502.2	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/03/2021 00:00	3,688.1	0.0	3,688.1	104,700.0	386.1	0.5	0.2	0.8
11/03/2021 01:00	3,584.3	0.0	3,584.3	104,700.0	375.3	0.5	0.2	0.8
11/03/2021 02:00	3,588.4	0.0	3,588.4	104,700.0	375.7	0.5	0.2	0.8
11/03/2021 03:00	3,654.1	0.0	3,654.1	104,700.0	382.6	0.5	0.2	0.8
11/03/2021 04:00	3,916.2	0.0	3,916.2	104,700.0	410.0	0.5	0.2	0.8
11/03/2021 05:00	4,346.6	0.0	4,346.6	104,700.0	455.1	0.5	0.3	0.9
11/03/2021 06:00	4,335.8	0.0	4,335.8	104,700.0	454.0	0.5	0.3	0.9
11/03/2021 07:00	3,312.1	0.0	3,312.1	104,700.0	346.8	0.4	0.2	0.7
11/03/2021 08:00	2,907.0	0.0	2,907.0	104,700.0	304.4	0.4	0.2	0.6
11/03/2021 09:00	2,840.5	0.0	2,840.5	104,700.0	297.4	0.4	0.2	0.6
11/03/2021 10:00	2,850.8	0.0	2,850.8	104,700.0	298.5	0.4	0.2	0.6
11/03/2021 11:00	2,849.1	0.0	2,849.1	104,700.0	298.3	0.4	0.2	0.6
11/03/2021 12:00	2,877.6	0.0	2,877.6	104,700.0	301.3	0.4	0.2	0.6
11/03/2021 13:00	2,898.8	0.0	2,898.8	104,700.0	303.5	0.4	0.2	0.6
11/03/2021 14:00	2,883.3	0.0	2,883.3	104,700.0	301.9	0.4	0.2	0.6
11/03/2021 15:00	3,439.5	0.0	3,439.5	104,700.0	360.1	0.4	0.2	0.7
11/03/2021 16:00	3,827.7	0.0	3,827.7	104,700.0	400.8	0.5	0.2	0.8
11/03/2021 17:00	4,694.8	0.0	4,694.8	104,700.0	491.5	0.6	0.3	1.0
11/03/2021 18:00	4,476.4	0.0	4,476.4	104,700.0	468.7	0.6	0.3	0.9
11/03/2021 19:00	4,662.8	0.0	4,662.8	104,700.0	488.2	0.6	0.3	1.0
11/03/2021 20:00	4,650.4	0.0	4,650.4	104,700.0	486.9	0.6	0.3	1.0
11/03/2021 21:00	4,302.9	0.0	4,302.9	104,700.0	450.5	0.5	0.3	0.9
11/03/2021 22:00	3,595.8	0.0	3,595.8	104,700.0	376.5	0.5	0.2	0.8
11/03/2021 23:00	2,965.1	0.0	2,965.1	104,700.0	310.4	0.4	0.2	0.6
Average/Sum#:	3,631.2	0.0	3,631.2	104,700.0	380.2	0.5	0.2	0.8
Minimum:	2,840.5	0.0	2,840.5	104,700.0	297.4	0.4	0.2	0.6
Maximum:	4,694.8	0.0	4,694.8	104,700.0	491.5	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/04/2021 00:00	2,928.4	0.0	2,928.4	104,700.0	306.6	0.4	0.2	0.6
11/04/2021 01:00	2,842.5	0.0	2,842.5	104,700.0	297.6	0.4	0.2	0.6
11/04/2021 02:00	2,975.6	0.0	2,975.6	104,700.0	311.5	0.4	0.2	0.6
11/04/2021 03:00	3,940.0	0.0	3,940.0	104,700.0	412.5	0.5	0.2	0.8
11/04/2021 04:00	3,416.5	0.0	3,416.5	104,700.0	357.7	0.4	0.2	0.7
11/04/2021 05:00	4,331.5	0.0	4,331.5	104,700.0	453.5	0.5	0.3	0.9
11/04/2021 06:00	4,510.1	0.0	4,510.1	104,700.0	472.2	0.6	0.3	0.9
11/04/2021 07:00	3,248.9	0.0	3,248.9	104,700.0	340.2	0.4	0.2	0.7
11/04/2021 08:00	2,928.9	0.0	2,928.9	104,700.0	306.7	0.4	0.2	0.6
11/04/2021 09:00	3,686.2	0.0	3,686.2	104,700.0	385.9	0.5	0.2	0.8
11/04/2021 10:00	2,831.9	0.0	2,831.9	104,700.0	296.5	0.4	0.2	0.6
11/04/2021 11:00	2,841.4	0.0	2,841.4	104,700.0	297.5	0.4	0.2	0.6
11/04/2021 12:00	2,830.2	0.0	2,830.2	104,700.0	296.3	0.4	0.2	0.6
11/04/2021 13:00	2,857.1	0.0	2,857.1	104,700.0	299.1	0.4	0.2	0.6
11/04/2021 14:00	2,824.8	0.0	2,824.8	104,700.0	295.8	0.4	0.2	0.6
11/04/2021 15:00	3,495.8	0.0	3,495.8	104,700.0	366.0	0.4	0.2	0.7
11/04/2021 16:00	3,108.4	0.0	3,108.4	104,700.0	325.4	0.4	0.2	0.7
11/04/2021 17:00	2,894.2	0.0	2,894.2	104,700.0	303.0	0.4	0.2	0.6
11/04/2021 18:00	2,932.3	0.0	2,932.3	104,700.0	307.0	0.4	0.2	0.6
11/04/2021 19:00	2,932.2	0.0	2,932.2	104,700.0	307.0	0.4	0.2	0.6
11/04/2021 20:00	2,908.1	0.0	2,908.1	104,700.0	304.5	0.4	0.2	0.6
11/04/2021 21:00	2,841.5	0.0	2,841.5	104,700.0	297.5	0.4	0.2	0.6
11/04/2021 22:00	2,847.6	0.0	2,847.6	104,700.0	298.1	0.4	0.2	0.6
11/04/2021 23:00	2,838.1	0.0	2,838.1	104,700.0	297.1	0.4	0.2	0.6
Average/Sum#:	3,158.0	0.0	3,158.0	104,700.0	330.6	0.4	0.2	0.7
Minimum:	2,824.8	0.0	2,824.8	104,700.0	295.8	0.4	0.2	0.6
Maximum:	4,510.1	0.0	4,510.1	104,700.0	472.2	0.6	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/05/2021 00:00	2,835.0	0.0	2,835.0	104,700.0	296.8	0.4	0.2	0.6
11/05/2021 01:00	2,834.4	0.0	2,834.4	104,700.0	296.8	0.4	0.2	0.6
11/05/2021 02:00	2,849.6	0.0	2,849.6	104,700.0	298.4	0.4	0.2	0.6
11/05/2021 03:00	2,932.8	0.0	2,932.8	104,700.0	307.1	0.4	0.2	0.6
11/05/2021 04:00	3,208.7	0.0	3,208.7	104,700.0	336.0	0.4	0.2	0.7
11/05/2021 05:00	4,065.9	0.0	4,065.9	104,700.0	425.7	0.5	0.3	0.9
11/05/2021 06:00	4,303.6	0.0	4,303.6	104,700.0	450.6	0.5	0.3	0.9
11/05/2021 07:00	3,673.4	0.0	3,673.4	104,700.0	384.6	0.5	0.2	0.8
11/05/2021 08:00	2,910.3	0.0	2,910.3	104,700.0	304.7	0.4	0.2	0.6
11/05/2021 09:00	2,830.2	0.0	2,830.2	104,700.0	296.3	0.4	0.2	0.6
11/05/2021 10:00	2,829.5	0.0	2,829.5	104,700.0	296.2	0.4	0.2	0.6
11/05/2021 11:00	2,830.0	0.0	2,830.0	104,700.0	296.3	0.4	0.2	0.6
11/05/2021 12:00	2,836.0	0.0	2,836.0	104,700.0	296.9	0.4	0.2	0.6
11/05/2021 13:00	2,836.8	0.0	2,836.8	104,700.0	297.0	0.4	0.2	0.6
11/05/2021 14:00	3,348.1	0.0	3,348.1	104,700.0	350.5	0.4	0.2	0.7
11/05/2021 15:00	4,238.9	0.0	4,238.9	104,700.0	443.8	0.5	0.3	0.9
11/05/2021 16:00	3,844.0	0.0	3,844.0	104,700.0	402.5	0.5	0.2	0.8
11/05/2021 17:00	3,915.6	0.0	3,915.6	104,700.0	410.0	0.5	0.2	0.8
11/05/2021 18:00	3,328.4	0.0	3,328.4	104,700.0	348.5	0.4	0.2	0.7
11/05/2021 19:00	3,750.8	0.0	3,750.8	104,700.0	392.7	0.5	0.2	0.8
11/05/2021 20:00	3,855.2	0.0	3,855.2	104,700.0	403.6	0.5	0.2	0.8
11/05/2021 21:00	4,241.3	0.0	4,241.3	104,700.0	444.1	0.5	0.3	0.9
11/05/2021 22:00	3,427.1	0.0	3,427.1	104,700.0	358.8	0.4	0.2	0.7
11/05/2021 23:00	3,893.1	0.0	3,893.1	104,700.0	407.6	0.5	0.2	0.8
Average/Sum#:	3,400.8	0.0	3,400.8	104,700.0	356.1	0.4	0.2	0.7
Minimum:	2,829.5	0.0	2,829.5	104,700.0	296.2	0.4	0.2	0.6
Maximum:	4,303.6	0.0	4,303.6	104,700.0	450.6	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/06/2021 00:00	3,039.7	0.0	3,039.7	104,700.0	318.3	0.4	0.2	0.6
11/06/2021 01:00	3,632.2	0.0	3,632.2	104,700.0	380.3	0.5	0.2	0.8
11/06/2021 02:00	3,097.1	0.0	3,097.1	104,700.0	324.3	0.4	0.2	0.6
11/06/2021 03:00	2,984.1	0.0	2,984.1	104,700.0	312.4	0.4	0.2	0.6
11/06/2021 04:00	3,254.5	0.0	3,254.5	104,700.0	340.7	0.4	0.2	0.7
11/06/2021 05:00	3,964.1	0.0	3,964.1	104,700.0	415.0	0.5	0.2	0.8
11/06/2021 06:00	4,481.2	0.0	4,481.2	104,700.0	469.2	0.6	0.3	0.9
11/06/2021 07:00	3,710.0	0.0	3,710.0	104,700.0	388.4	0.5	0.2	0.8
11/06/2021 08:00	3,457.1	0.0	3,457.1	104,700.0	362.0	0.4	0.2	0.7
11/06/2021 09:00	2,917.9	0.0	2,917.9	104,700.0	305.5	0.4	0.2	0.6
11/06/2021 10:00	2,879.6	0.0	2,879.6	104,700.0	301.5	0.4	0.2	0.6
11/06/2021 11:00	2,878.5	0.0	2,878.5	104,700.0	301.4	0.4	0.2	0.6
11/06/2021 12:00	2,846.0	0.0	2,846.0	104,700.0	298.0	0.4	0.2	0.6
11/06/2021 13:00	2,847.8	0.0	2,847.8	104,700.0	298.2	0.4	0.2	0.6
11/06/2021 14:00	2,844.7	0.0	2,844.7	104,700.0	297.8	0.4	0.2	0.6
11/06/2021 15:00	3,302.1	0.0	3,302.1	104,700.0	345.7	0.4	0.2	0.7
11/06/2021 16:00	3,972.6	0.0	3,972.6	104,700.0	415.9	0.5	0.2	0.8
11/06/2021 17:00	4,518.8	0.0	4,518.8	104,700.0	473.1	0.6	0.3	0.9
11/06/2021 18:00	3,549.3	0.0	3,549.3	104,700.0	371.6	0.4	0.2	0.7
11/06/2021 19:00	4,730.5	0.0	4,730.5	104,700.0	495.3	0.6	0.3	1.0
11/06/2021 20:00	4,367.0	0.0	4,367.0	104,700.0	457.2	0.5	0.3	0.9
11/06/2021 21:00	3,943.1	0.0	3,943.1	104,700.0	412.8	0.5	0.2	0.8
11/06/2021 22:00	2,986.8	0.0	2,986.8	104,700.0	312.7	0.4	0.2	0.6
11/06/2021 23:00	2,975.0	0.0	2,975.0	104,700.0	311.5	0.4	0.2	0.6
Average/Sum#:	3,465.8	0.0	3,465.8	104,700.0	362.9	0.5	0.2	0.7
Minimum:	2,844.7	0.0	2,844.7	104,700.0	297.8	0.4	0.2	0.6
Maximum:	4,730.5	0.0	4,730.5	104,700.0	495.3	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/07/2021 00:00	2,861.5	0.0	2,861.5	104,700.0	299.6	0.4	0.2	0.6
11/07/2021 01:00	2,861.2	0.0	2,861.2	104,700.0	299.6	0.4	0.2	0.6
11/07/2021 02:00	2,872.4	0.0	2,872.4	104,700.0	300.7	0.4	0.2	0.6
11/07/2021 03:00	2,871.0	0.0	2,871.0	104,700.0	300.6	0.4	0.2	0.6
11/07/2021 04:00	2,868.9	0.0	2,868.9	104,700.0	300.4	0.4	0.2	0.6
11/07/2021 05:00	2,897.8	0.0	2,897.8	104,700.0	303.4	0.4	0.2	0.6
11/07/2021 06:00	3,965.2	0.0	3,965.2	104,700.0	415.2	0.5	0.2	0.8
11/07/2021 07:00	4,257.4	0.0	4,257.4	104,700.0	445.7	0.5	0.3	0.9
11/07/2021 08:00	2,870.6	0.0	2,870.6	104,700.0	300.6	0.4	0.2	0.6
11/07/2021 09:00	2,868.9	0.0	2,868.9	104,700.0	300.4	0.4	0.2	0.6
11/07/2021 10:00	2,852.5	0.0	2,852.5	104,700.0	298.7	0.4	0.2	0.6
11/07/2021 11:00	2,826.6	0.0	2,826.6	104,700.0	295.9	0.4	0.2	0.6
11/07/2021 12:00	2,819.6	0.0	2,819.6	104,700.0	295.2	0.4	0.2	0.6
11/07/2021 13:00	2,818.8	0.0	2,818.8	104,700.0	295.1	0.4	0.2	0.6
11/07/2021 14:00	2,870.6	0.0	2,870.6	104,700.0	300.6	0.4	0.2	0.6
11/07/2021 15:00	3,737.1	0.0	3,737.1	104,700.0	391.3	0.5	0.2	0.8
11/07/2021 16:00	3,901.0	0.0	3,901.0	104,700.0	408.4	0.5	0.2	0.8
11/07/2021 17:00	3,502.4	0.0	3,502.4	104,700.0	366.7	0.4	0.2	0.7
11/07/2021 18:00	3,306.8	0.0	3,306.8	104,700.0	346.2	0.4	0.2	0.7
11/07/2021 19:00	3,895.9	0.0	3,895.9	104,700.0	407.9	0.5	0.2	0.8
11/07/2021 20:00	3,102.7	0.0	3,102.7	104,700.0	324.9	0.4	0.2	0.7
11/07/2021 21:00	2,944.9	0.0	2,944.9	104,700.0	308.3	0.4	0.2	0.6
11/07/2021 22:00	2,948.1	0.0	2,948.1	104,700.0	308.7	0.4	0.2	0.6
11/07/2021 23:00	2,835.9	0.0	2,835.9	104,700.0	296.9	0.4	0.2	0.6
Average/Sum#:	3,148.2	0.0	3,148.2	104,700.0	329.6	0.4	0.2	0.7
Minimum:	2,818.8	0.0	2,818.8	104,700.0	295.1	0.4	0.2	0.6
Maximum:	4,257.4	0.0	4,257.4	104,700.0	445.7	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/08/2021 00:00	2,862.1	0.0	2,862.1	104,700.0	299.7	0.4	0.2	0.6
11/08/2021 01:00	2,967.9	0.0	2,967.9	104,700.0	310.7	0.4	0.2	0.6
11/08/2021 02:00	3,328.6	0.0	3,328.6	104,700.0	348.5	0.4	0.2	0.7
11/08/2021 03:00	4,616.4	0.0	4,616.4	104,700.0	483.3	0.6	0.3	1.0
11/08/2021 04:00	4,650.2	0.0	4,650.2	104,700.0	486.9	0.6	0.3	1.0
11/08/2021 05:00	4,771.1	0.0	4,771.1	104,700.0	499.5	0.6	0.3	1.0
11/08/2021 06:00	4,728.8	0.0	4,728.8	104,700.0	495.1	0.6	0.3	1.0
11/08/2021 07:00	3,643.0	0.0	3,643.0	104,700.0	381.4	0.5	0.2	0.8
11/08/2021 08:00	2,855.3	0.0	2,855.3	104,700.0	298.9	0.4	0.2	0.6
11/08/2021 09:00	2,851.4	0.0	2,851.4	104,700.0	298.5	0.4	0.2	0.6
11/08/2021 10:00	2,829.8	0.0	2,829.8	104,700.0	296.3	0.4	0.2	0.6
11/08/2021 11:00	2,829.2	0.0	2,829.2	104,700.0	296.2	0.4	0.2	0.6
11/08/2021 12:00	2,824.4	0.0	2,824.4	104,700.0	295.7	0.4	0.2	0.6
11/08/2021 13:00	2,819.7	0.0	2,819.7	104,700.0	295.2	0.4	0.2	0.6
11/08/2021 14:00	2,812.5	0.0	2,812.5	104,700.0	294.5	0.4	0.2	0.6
11/08/2021 15:00	3,892.8	0.0	3,892.8	104,700.0	407.6	0.5	0.2	0.8
11/08/2021 16:00	4,700.1	107.5	4,748.5	104,700.0	497.2	0.6	0.3	1.0
11/08/2021 17:00	4,752.4	188.6	4,941.0	104,700.0	517.3	0.6	0.3	1.0
11/08/2021 18:00	4,763.7	177.2	4,940.9	104,700.0	517.3	0.6	0.3	1.0
11/08/2021 19:00	4,725.2	104.8	4,801.7	104,700.0	502.7	0.6	0.3	1.0
11/08/2021 20:00	4,567.5	0.0	4,567.5	104,700.0	478.2	0.6	0.3	1.0
11/08/2021 21:00	4,262.7	0.0	4,262.7	104,700.0	446.3	0.5	0.3	0.9
11/08/2021 22:00	3,740.6	0.0	3,740.6	104,700.0	391.6	0.5	0.2	0.8
11/08/2021 23:00	2,974.1	0.0	2,974.1	104,700.0	311.4	0.4	0.2	0.6
Average/Sum#:	3,740.4	24.1	3,760.8	104,700.0	393.8	0.5	0.2	0.8
Minimum:	2,812.5	0.0	2,812.5	104,700.0	294.5	0.4	0.2	0.6
Maximum:	4,771.1	188.6	4,941.0	104,700.0	517.3	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/09/2021 00:00	2,967.7	0.0	2,967.7	104,700.0	310.7	0.4	0.2	0.6
11/09/2021 01:00	2,957.7	0.0	2,957.7	104,700.0	309.7	0.4	0.2	0.6
11/09/2021 02:00	2,914.0	0.0	2,914.0	104,700.0	305.1	0.4	0.2	0.6
11/09/2021 03:00	2,851.6	0.0	2,851.6	104,700.0	298.6	0.4	0.2	0.6
11/09/2021 04:00	2,949.5	0.0	2,949.5	104,700.0	308.8	0.4	0.2	0.6
11/09/2021 05:00	3,196.4	0.0	3,196.4	104,700.0	334.7	0.4	0.2	0.7
11/09/2021 06:00	3,141.0	0.0	3,141.0	104,700.0	328.9	0.4	0.2	0.7
11/09/2021 07:00	3,632.9	0.0	3,632.9	104,700.0	380.4	0.5	0.2	0.8
11/09/2021 08:00	2,892.0	0.0	2,892.0	104,700.0	302.8	0.4	0.2	0.6
11/09/2021 09:00	2,849.8	0.0	2,849.8	104,700.0	298.4	0.4	0.2	0.6
11/09/2021 10:00	2,948.0	0.0	2,948.0	104,700.0	308.7	0.4	0.2	0.6
11/09/2021 11:00	2,882.7	0.0	2,882.7	104,700.0	301.8	0.4	0.2	0.6
11/09/2021 12:00	2,866.5	0.0	2,866.5	104,700.0	300.1	0.4	0.2	0.6
11/09/2021 13:00	2,867.2	0.0	2,867.2	104,700.0	300.2	0.4	0.2	0.6
11/09/2021 14:00	2,982.0	0.0	2,982.0	104,700.0	312.2	0.4	0.2	0.6
11/09/2021 15:00	3,360.7	0.0	3,360.7	104,700.0	351.9	0.4	0.2	0.7
11/09/2021 16:00	3,439.2	0.0	3,439.2	104,700.0	360.1	0.4	0.2	0.7
11/09/2021 17:00	3,984.3	0.0	3,984.3	104,700.0	417.2	0.5	0.3	0.8
11/09/2021 18:00	4,766.9	0.0	4,766.9	104,700.0	499.1	0.6	0.3	1.0
11/09/2021 19:00	4,666.6	0.0	4,666.6	104,700.0	488.6	0.6	0.3	1.0
11/09/2021 20:00	4,591.7	0.0	4,591.7	104,700.0	480.8	0.6	0.3	1.0
11/09/2021 21:00	3,413.9	0.0	3,413.9	104,700.0	357.4	0.4	0.2	0.7
11/09/2021 22:00	2,986.0	0.0	2,986.0	104,700.0	312.6	0.4	0.2	0.6
11/09/2021 23:00	2,944.1	0.0	2,944.1	104,700.0	308.2	0.4	0.2	0.6
Average/Sum#:	3,293.9	0.0	3,293.9	104,700.0	344.9	0.4	0.2	0.7
Minimum:	2,849.8	0.0	2,849.8	104,700.0	298.4	0.4	0.2	0.6
Maximum:	4,766.9	0.0	4,766.9	104,700.0	499.1	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/10/2021 00:00	2,881.1	0.0	2,881.1	104,700.0	301.7	0.4	0.2	0.6
11/10/2021 01:00	2,856.9	0.0	2,856.9	104,700.0	299.1	0.4	0.2	0.6
11/10/2021 02:00	2,856.2	0.0	2,856.2	104,700.0	299.0	0.4	0.2	0.6
11/10/2021 03:00	2,853.5	0.0	2,853.5	104,700.0	298.8	0.4	0.2	0.6
11/10/2021 04:00	2,853.1	0.0	2,853.1	104,700.0	298.7	0.4	0.2	0.6
11/10/2021 05:00	3,678.8	0.0	3,678.8	104,700.0	385.2	0.5	0.2	0.8
11/10/2021 06:00	3,938.8	0.0	3,938.8	104,700.0	412.4	0.5	0.2	0.8
11/10/2021 07:00	3,932.1	0.0	3,932.1	104,700.0	411.7	0.5	0.2	0.8
11/10/2021 08:00	2,853.4	0.0	2,853.4	104,700.0	298.8	0.4	0.2	0.6
11/10/2021 09:00	2,905.3	0.0	2,905.3	104,700.0	304.2	0.4	0.2	0.6
11/10/2021 10:00	2,938.2	0.0	2,938.2	104,700.0	307.6	0.4	0.2	0.6
11/10/2021 11:00	2,856.9	0.0	2,856.9	104,700.0	299.1	0.4	0.2	0.6
11/10/2021 12:00	2,855.5	0.0	2,855.5	104,700.0	299.0	0.4	0.2	0.6
11/10/2021 13:00	2,855.0	0.0	2,855.0	104,700.0	298.9	0.4	0.2	0.6
11/10/2021 14:00	2,853.9	0.0	2,853.9	104,700.0	298.8	0.4	0.2	0.6
11/10/2021 15:00	2,863.9	0.0	2,863.9	104,700.0	299.9	0.4	0.2	0.6
11/10/2021 16:00	2,932.9	0.0	2,932.9	104,700.0	307.1	0.4	0.2	0.6
11/10/2021 17:00	2,975.4	0.0	2,975.4	104,700.0	311.5	0.4	0.2	0.6
11/10/2021 18:00	2,973.7	0.0	2,973.7	104,700.0	311.3	0.4	0.2	0.6
11/10/2021 19:00	2,991.1	0.0	2,991.1	104,700.0	313.2	0.4	0.2	0.6
11/10/2021 20:00	3,008.5	0.0	3,008.5	104,700.0	315.0	0.4	0.2	0.6
11/10/2021 21:00	3,224.8	0.0	3,224.8	104,700.0	337.6	0.4	0.2	0.7
11/10/2021 22:00	3,000.7	0.0	3,000.7	104,700.0	314.2	0.4	0.2	0.6
11/10/2021 23:00	2,978.2	0.0	2,978.2	104,700.0	311.8	0.4	0.2	0.6
Average/Sum#:	3,038.2	0.0	3,038.2	104,700.0	318.1	0.4	0.2	0.6
Minimum:	2,853.1	0.0	2,853.1	104,700.0	298.7	0.4	0.2	0.6
Maximum:	3,938.8	0.0	3,938.8	104,700.0	412.4	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/11/2021 00:00	2,929.1	0.0	2,929.1	104,700.0	306.7	0.4	0.2	0.6
11/11/2021 01:00	2,982.2	0.0	2,982.2	104,700.0	312.2	0.4	0.2	0.6
11/11/2021 02:00	2,855.9	0.0	2,855.9	104,700.0	299.0	0.4	0.2	0.6
11/11/2021 03:00	2,863.5	0.0	2,863.5	104,700.0	299.8	0.4	0.2	0.6
11/11/2021 04:00	2,969.9	0.0	2,969.9	104,700.0	310.9	0.4	0.2	0.6
11/11/2021 05:00	3,000.5	0.0	3,000.5	104,700.0	314.2	0.4	0.2	0.6
11/11/2021 06:00	2,996.3	0.0	2,996.3	104,700.0	313.7	0.4	0.2	0.6
11/11/2021 07:00	2,986.8	0.0	2,986.8	104,700.0	312.7	0.4	0.2	0.6
11/11/2021 08:00	2,968.8	0.0	2,968.8	104,700.0	310.8	0.4	0.2	0.6
11/11/2021 09:00	2,978.6	0.0	2,978.6	104,700.0	311.9	0.4	0.2	0.6
11/11/2021 10:00	2,967.0	0.0	2,967.0	104,700.0	310.6	0.4	0.2	0.6
11/11/2021 11:00	2,861.0	0.0	2,861.0	104,700.0	299.5	0.4	0.2	0.6
11/11/2021 12:00	2,868.4	0.0	2,868.4	104,700.0	300.3	0.4	0.2	0.6
11/11/2021 13:00	2,879.2	0.0	2,879.2	104,700.0	301.5	0.4	0.2	0.6
11/11/2021 14:00	2,871.3	0.0	2,871.3	104,700.0	300.6	0.4	0.2	0.6
11/11/2021 15:00	3,265.3	0.0	3,265.3	104,700.0	341.9	0.4	0.2	0.7
11/11/2021 16:00	3,860.1	72.4	3,886.9	104,700.0	407.0	0.5	0.2	0.8
11/11/2021 17:00	4,801.4	134.8	4,936.2	104,700.0	516.8	0.6	0.3	1.0
11/11/2021 18:00	4,824.8	94.7	4,919.5	104,700.0	515.1	0.6	0.3	1.0
11/11/2021 19:00	4,849.5	47.8	4,897.3	104,700.0	512.7	0.6	0.3	1.0
11/11/2021 20:00	4,871.5	8.0	4,879.5	104,700.0	510.9	0.6	0.3	1.0
11/11/2021 21:00	4,887.1	11.7	4,898.8	104,700.0	512.9	0.6	0.3	1.0
11/11/2021 22:00	4,157.9	41.6	4,179.5	104,700.0	437.6	0.5	0.3	0.9
11/11/2021 23:00	3,079.2	0.0	3,079.2	104,700.0	322.4	0.4	0.2	0.6
Average/Sum#:	3,440.6	17.1	3,455.0	104,700.0	361.7	0.5	0.2	0.7
Minimum:	2,855.9	0.0	2,855.9	104,700.0	299.0	0.4	0.2	0.6
Maximum:	4,887.1	134.8	4,936.2	104,700.0	516.8	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/12/2021 00:00	2,884.3	0.0	2,884.3	104,700.0	302.0	0.4	0.2	0.6
11/12/2021 01:00	2,851.2	0.0	2,851.2	104,700.0	298.5	0.4	0.2	0.6
11/12/2021 02:00	2,852.2	0.0	2,852.2	104,700.0	298.6	0.4	0.2	0.6
11/12/2021 03:00	2,854.4	0.0	2,854.4	104,700.0	298.9	0.4	0.2	0.6
11/12/2021 04:00	2,873.1	0.0	2,873.1	104,700.0	300.8	0.4	0.2	0.6
11/12/2021 05:00	2,989.3	0.0	2,989.3	104,700.0	313.0	0.4	0.2	0.6
11/12/2021 06:00	2,998.6	0.0	2,998.6	104,700.0	314.0	0.4	0.2	0.6
11/12/2021 07:00	2,904.9	0.0	2,904.9	104,700.0	304.1	0.4	0.2	0.6
11/12/2021 08:00	2,898.6	0.0	2,898.6	104,700.0	303.5	0.4	0.2	0.6
11/12/2021 09:00	2,852.9	0.0	2,852.9	104,700.0	298.7	0.4	0.2	0.6
11/12/2021 10:00	2,851.9	0.0	2,851.9	104,700.0	298.6	0.4	0.2	0.6
11/12/2021 11:00	2,854.4	0.0	2,854.4	104,700.0	298.9	0.4	0.2	0.6
11/12/2021 12:00	2,851.9	0.0	2,851.9	104,700.0	298.6	0.4	0.2	0.6
11/12/2021 13:00	2,850.2	0.0	2,850.2	104,700.0	298.4	0.4	0.2	0.6
11/12/2021 14:00	2,886.7	0.0	2,886.7	104,700.0	302.2	0.4	0.2	0.6
11/12/2021 15:00	3,157.0	0.0	3,157.0	104,700.0	330.5	0.4	0.2	0.7
11/12/2021 16:00	2,935.3	0.0	2,935.3	104,700.0	307.3	0.4	0.2	0.6
11/12/2021 17:00	2,960.4	0.0	2,960.4	104,700.0	310.0	0.4	0.2	0.6
11/12/2021 18:00	2,863.6	0.0	2,863.6	104,700.0	299.8	0.4	0.2	0.6
11/12/2021 19:00	2,988.1	0.0	2,988.1	104,700.0	312.9	0.4	0.2	0.6
11/12/2021 20:00	2,985.5	0.0	2,985.5	104,700.0	312.6	0.4	0.2	0.6
11/12/2021 21:00	3,344.7	0.0	3,344.7	104,700.0	350.2	0.4	0.2	0.7
11/12/2021 22:00	2,925.3	0.0	2,925.3	104,700.0	306.3	0.4	0.2	0.6
11/12/2021 23:00	2,858.2	0.0	2,858.2	104,700.0	299.3	0.4	0.2	0.6
Average/Sum#:	2,928.0	0.0	2,928.0	104,700.0	306.6	0.4	0.2	0.6
Minimum:	2,850.2	0.0	2,850.2	104,700.0	298.4	0.4	0.2	0.6
Maximum:	3,344.7	0.0	3,344.7	104,700.0	350.2	0.4	0.2	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/13/2021 00:00	2,882.9	0.0	2,882.9	104,700.0	301.8	0.4	0.2	0.6
11/13/2021 01:00	2,877.7	0.0	2,877.7	104,700.0	301.3	0.4	0.2	0.6
11/13/2021 02:00	2,987.0	0.0	2,987.0	104,700.0	312.7	0.4	0.2	0.6
11/13/2021 03:00	2,984.1	0.0	2,984.1	104,700.0	312.4	0.4	0.2	0.6
11/13/2021 04:00	3,159.6	0.0	3,159.6	104,700.0	330.8	0.4	0.2	0.7
11/13/2021 05:00	3,713.8	0.0	3,713.8	104,700.0	388.8	0.5	0.2	0.8
11/13/2021 06:00	4,799.5	0.0	4,799.5	104,700.0	502.5	0.6	0.3	1.0
11/13/2021 07:00	4,795.9	0.0	4,795.9	104,700.0	502.1	0.6	0.3	1.0
11/13/2021 08:00	4,795.3	0.0	4,795.3	104,700.0	502.1	0.6	0.3	1.0
11/13/2021 09:00	4,793.6	0.0	4,793.6	104,700.0	501.9	0.6	0.3	1.0
11/13/2021 10:00	3,855.1	0.0	3,855.1	104,700.0	403.6	0.5	0.2	0.8
11/13/2021 11:00	3,095.6	0.0	3,095.6	104,700.0	324.1	0.4	0.2	0.6
11/13/2021 12:00	2,910.0	0.0	2,910.0	104,700.0	304.7	0.4	0.2	0.6
11/13/2021 13:00	2,880.1	0.0	2,880.1	104,700.0	301.5	0.4	0.2	0.6
11/13/2021 14:00	2,868.6	0.0	2,868.6	104,700.0	300.3	0.4	0.2	0.6
11/13/2021 15:00	3,122.2	0.0	3,122.2	104,700.0	326.9	0.4	0.2	0.7
11/13/2021 16:00	4,581.2	0.0	4,581.2	104,700.0	479.7	0.6	0.3	1.0
11/13/2021 17:00	3,305.2	0.0	3,305.2	104,700.0	346.1	0.4	0.2	0.7
11/13/2021 18:00	3,345.5	0.0	3,345.5	104,700.0	350.3	0.4	0.2	0.7
11/13/2021 19:00	4,204.5	0.0	4,204.5	104,700.0	440.2	0.5	0.3	0.9
11/13/2021 20:00	4,065.1	0.0	4,065.1	104,700.0	425.6	0.5	0.3	0.9
11/13/2021 21:00	3,202.9	0.0	3,202.9	104,700.0	335.3	0.4	0.2	0.7
11/13/2021 22:00	2,997.4	0.0	2,997.4	104,700.0	313.8	0.4	0.2	0.6
11/13/2021 23:00	2,884.1	0.0	2,884.1	104,700.0	302.0	0.4	0.2	0.6
Average/Sum#:	3,546.1	0.0	3,546.1	104,700.0	371.3	0.5	0.2	0.7
Minimum:	2,868.6	0.0	2,868.6	104,700.0	300.3	0.4	0.2	0.6
Maximum:	4,799.5	0.0	4,799.5	104,700.0	502.5	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/14/2021 00:00	2,852.4	0.0	2,852.4	104,700.0	298.6	0.4	0.2	0.6
11/14/2021 01:00	2,851.8	0.0	2,851.8	104,700.0	298.6	0.4	0.2	0.6
11/14/2021 02:00	2,852.5	0.0	2,852.5	104,700.0	298.7	0.4	0.2	0.6
11/14/2021 03:00	2,849.4	0.0	2,849.4	104,700.0	298.3	0.4	0.2	0.6
11/14/2021 04:00	2,860.5	0.0	2,860.5	104,700.0	299.5	0.4	0.2	0.6
11/14/2021 05:00	2,851.4	0.0	2,851.4	104,700.0	298.5	0.4	0.2	0.6
11/14/2021 06:00	2,870.2	0.0	2,870.2	104,700.0	300.5	0.4	0.2	0.6
11/14/2021 07:00	2,897.1	0.0	2,897.1	104,700.0	303.3	0.4	0.2	0.6
11/14/2021 08:00	2,877.5	0.0	2,877.5	104,700.0	301.3	0.4	0.2	0.6
11/14/2021 09:00	2,878.1	0.0	2,878.1	104,700.0	301.3	0.4	0.2	0.6
11/14/2021 10:00	2,876.8	0.0	2,876.8	104,700.0	301.2	0.4	0.2	0.6
11/14/2021 11:00	2,875.0	0.0	2,875.0	104,700.0	301.0	0.4	0.2	0.6
11/14/2021 12:00	2,874.6	0.0	2,874.6	104,700.0	301.0	0.4	0.2	0.6
11/14/2021 13:00	2,857.3	0.0	2,857.3	104,700.0	299.2	0.4	0.2	0.6
11/14/2021 14:00	2,848.9	0.0	2,848.9	104,700.0	298.3	0.4	0.2	0.6
11/14/2021 15:00	3,107.4	0.0	3,107.4	104,700.0	325.3	0.4	0.2	0.7
11/14/2021 16:00	2,880.5	0.0	2,880.5	104,700.0	301.6	0.4	0.2	0.6
11/14/2021 17:00	2,880.9	0.0	2,880.9	104,700.0	301.6	0.4	0.2	0.6
11/14/2021 18:00	2,868.6	0.0	2,868.6	104,700.0	300.3	0.4	0.2	0.6
11/14/2021 19:00	2,913.0	0.0	2,913.0	104,700.0	305.0	0.4	0.2	0.6
11/14/2021 20:00	3,047.4	0.0	3,047.4	104,700.0	319.1	0.4	0.2	0.6
11/14/2021 21:00	2,975.5	0.0	2,975.5	104,700.0	311.5	0.4	0.2	0.6
11/14/2021 22:00	2,897.4	0.0	2,897.4	104,700.0	303.4	0.4	0.2	0.6
11/14/2021 23:00	2,854.9	0.0	2,854.9	104,700.0	298.9	0.4	0.2	0.6
Average/Sum#:	2,891.6	0.0	2,891.6	104,700.0	302.8	0.4	0.2	0.6
Minimum:	2,848.9	0.0	2,848.9	104,700.0	298.3	0.4	0.2	0.6
Maximum:	3,107.4	0.0	3,107.4	104,700.0	325.3	0.4	0.2	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/15/2021 00:00	2,861.2	0.0	2,861.2	104,700.0	299.6	0.4	0.2	0.6
11/15/2021 01:00	2,851.4	0.0	2,851.4	104,700.0	298.5	0.4	0.2	0.6
11/15/2021 02:00	2,852.2	0.0	2,852.2	104,700.0	298.6	0.4	0.2	0.6
11/15/2021 03:00	2,866.6	0.0	2,866.6	104,700.0	300.1	0.4	0.2	0.6
11/15/2021 04:00	2,890.4	0.0	2,890.4	104,700.0	302.6	0.4	0.2	0.6
11/15/2021 05:00	2,968.8	0.0	2,968.8	104,700.0	310.8	0.4	0.2	0.6
11/15/2021 06:00	3,267.9	0.0	3,267.9	104,700.0	342.1	0.4	0.2	0.7
11/15/2021 07:00	3,334.7	0.0	3,334.7	104,700.0	349.1	0.4	0.2	0.7
11/15/2021 08:00	2,911.1	0.0	2,911.1	104,700.0	304.8	0.4	0.2	0.6
11/15/2021 09:00	2,989.4	0.0	2,989.4	104,700.0	313.0	0.4	0.2	0.6
11/15/2021 10:00	2,982.2	0.0	2,982.2	104,700.0	312.2	0.4	0.2	0.6
11/15/2021 11:00	2,935.0	0.0	2,935.0	104,700.0	307.3	0.4	0.2	0.6
11/15/2021 12:00	2,845.3	0.0	2,845.3	104,700.0	297.9	0.4	0.2	0.6
11/15/2021 13:00	2,914.1	0.0	2,914.1	104,700.0	305.1	0.4	0.2	0.6
11/15/2021 14:00	3,642.9	0.0	3,642.9	104,700.0	381.4	0.5	0.2	0.8
11/15/2021 15:00	3,474.7	0.0	3,474.7	104,700.0	363.8	0.4	0.2	0.7
11/15/2021 16:00	3,149.7	0.0	3,149.7	104,700.0	329.8	0.4	0.2	0.7
11/15/2021 17:00	2,965.1	0.0	2,965.1	104,700.0	310.4	0.4	0.2	0.6
11/15/2021 18:00	3,000.3	0.0	3,000.3	104,700.0	314.1	0.4	0.2	0.6
11/15/2021 19:00	3,785.1	0.0	3,785.1	104,700.0	396.3	0.5	0.2	0.8
11/15/2021 20:00	2,983.9	0.0	2,983.9	104,700.0	312.4	0.4	0.2	0.6
11/15/2021 21:00	3,231.5	0.0	3,231.5	104,700.0	338.3	0.4	0.2	0.7
11/15/2021 22:00	2,958.1	0.0	2,958.1	104,700.0	309.7	0.4	0.2	0.6
11/15/2021 23:00	2,849.5	0.0	2,849.5	104,700.0	298.3	0.4	0.2	0.6
Average/Sum#:	3,063.0	0.0	3,063.0	104,700.0	320.7	0.4	0.2	0.6
Minimum:	2,845.3	0.0	2,845.3	104,700.0	297.9	0.4	0.2	0.6
Maximum:	3,785.1	0.0	3,785.1	104,700.0	396.3	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/16/2021 00:00	2,969.8	0.0	2,969.8	104,700.0	310.9	0.4	0.2	0.6
11/16/2021 01:00	2,985.3	0.0	2,985.3	104,700.0	312.6	0.4	0.2	0.6
11/16/2021 02:00	2,905.0	0.0	2,905.0	104,700.0	304.2	0.4	0.2	0.6
11/16/2021 03:00	2,862.0	0.0	2,862.0	104,700.0	299.7	0.4	0.2	0.6
11/16/2021 04:00	2,961.7	0.0	2,961.7	104,700.0	310.1	0.4	0.2	0.6
11/16/2021 05:00	4,033.3	0.0	4,033.3	104,700.0	422.3	0.5	0.3	0.8
11/16/2021 06:00	4,817.7	0.0	4,817.7	104,700.0	504.4	0.6	0.3	1.0
11/16/2021 07:00	4,816.9	0.0	4,816.9	104,700.0	504.3	0.6	0.3	1.0
11/16/2021 08:00	3,969.3	0.0	3,969.3	104,700.0	415.6	0.5	0.2	0.8
11/16/2021 09:00	3,612.2	0.0	3,612.2	104,700.0	378.2	0.5	0.2	0.8
11/16/2021 10:00	2,928.4	0.0	2,928.4	104,700.0	306.6	0.4	0.2	0.6
11/16/2021 11:00	2,916.5	0.0	2,916.5	104,700.0	305.4	0.4	0.2	0.6
11/16/2021 12:00	2,880.0	0.0	2,880.0	104,700.0	301.5	0.4	0.2	0.6
11/16/2021 13:00	2,880.8	0.0	2,880.8	104,700.0	301.6	0.4	0.2	0.6
11/16/2021 14:00	2,873.2	0.0	2,873.2	104,700.0	300.8	0.4	0.2	0.6
11/16/2021 15:00	3,164.9	0.0	3,164.9	104,700.0	331.4	0.4	0.2	0.7
11/16/2021 16:00	2,989.7	0.0	2,989.7	104,700.0	313.0	0.4	0.2	0.6
11/16/2021 17:00	3,711.7	0.0	3,711.7	104,700.0	388.6	0.5	0.2	0.8
11/16/2021 18:00	3,979.3	0.0	3,979.3	104,700.0	416.6	0.5	0.2	0.8
11/16/2021 19:00	3,464.8	0.0	3,464.8	104,700.0	362.8	0.4	0.2	0.7
11/16/2021 20:00	4,479.9	0.0	4,479.9	104,700.0	469.0	0.6	0.3	0.9
11/16/2021 21:00	4,544.8	0.0	4,544.8	104,700.0	475.8	0.6	0.3	1.0
11/16/2021 22:00	4,102.8	0.0	4,102.8	104,700.0	429.6	0.5	0.3	0.9
11/16/2021 23:00	3,671.5	0.0	3,671.5	104,700.0	384.4	0.5	0.2	0.8
Average/Sum#:	3,521.7	0.0	3,521.7	104,700.0	368.7	0.5	0.2	0.7
Minimum:	2,862.0	0.0	2,862.0	104,700.0	299.7	0.4	0.2	0.6
Maximum:	4,817.7	0.0	4,817.7	104,700.0	504.4	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/17/2021 00:00	4,805.6	28.7	4,826.3	104,700.0	505.3	0.6	0.3	1.0
11/17/2021 01:00	4,140.8	2.5	4,142.1	104,700.0	433.7	0.5	0.3	0.9
11/17/2021 02:00	2,981.6	0.0	2,981.6	104,700.0	312.2	0.4	0.2	0.6
11/17/2021 03:00	2,993.5	0.0	2,993.5	104,700.0	313.4	0.4	0.2	0.6
11/17/2021 04:00	3,636.4	0.0	3,636.4	104,700.0	380.7	0.5	0.2	0.8
11/17/2021 05:00	3,665.0	0.0	3,665.0	104,700.0	383.7	0.5	0.2	0.8
11/17/2021 06:00	4,634.7	0.0	4,634.7	104,700.0	485.3	0.6	0.3	1.0
11/17/2021 07:00	3,883.4	0.0	3,883.4	104,700.0	406.6	0.5	0.2	0.8
11/17/2021 08:00	2,957.9	0.0	2,957.9	104,700.0	309.7	0.4	0.2	0.6
11/17/2021 09:00	2,988.0	0.0	2,988.0	104,700.0	312.8	0.4	0.2	0.6
11/17/2021 10:00	2,973.4	0.0	2,973.4	104,700.0	311.3	0.4	0.2	0.6
11/17/2021 11:00	2,867.1	0.0	2,867.1	104,700.0	300.2	0.4	0.2	0.6
11/17/2021 12:00	2,851.8	0.0	2,851.8	104,700.0	298.6	0.4	0.2	0.6
11/17/2021 13:00	2,846.2	0.0	2,846.2	104,700.0	298.0	0.4	0.2	0.6
11/17/2021 14:00	2,846.2	0.0	2,846.2	104,700.0	298.0	0.4	0.2	0.6
11/17/2021 15:00	3,451.2	0.0	3,451.2	104,700.0	361.3	0.4	0.2	0.7
11/17/2021 16:00	3,923.5	0.0	3,923.5	104,700.0	410.8	0.5	0.2	0.8
11/17/2021 17:00	4,523.1	0.0	4,523.1	104,700.0	473.6	0.6	0.3	0.9
11/17/2021 18:00	4,727.1	0.0	4,727.1	104,700.0	494.9	0.6	0.3	1.0
11/17/2021 19:00	4,741.9	0.0	4,741.9	104,700.0	496.5	0.6	0.3	1.0
11/17/2021 20:00	4,670.4	0.0	4,670.4	104,700.0	489.0	0.6	0.3	1.0
11/17/2021 21:00	4,268.9	0.0	4,268.9	104,700.0	447.0	0.5	0.3	0.9
11/17/2021 22:00	3,104.7	0.0	3,104.7	104,700.0	325.1	0.4	0.2	0.7
11/17/2021 23:00	3,002.4	0.0	3,002.4	104,700.0	314.4	0.4	0.2	0.6
Average/Sum#:	3,645.2	1.3	3,646.1	104,700.0	381.8	0.5	0.2	0.8
Minimum:	2,846.2	0.0	2,846.2	104,700.0	298.0	0.4	0.2	0.6
Maximum:	4,805.6	28.7	4,826.3	104,700.0	505.3	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/18/2021 00:00	2,996.3	0.0	2,996.3	104,700.0	313.7	0.4	0.2	0.6
11/18/2021 01:00	2,996.4	0.0	2,996.4	104,700.0	313.7	0.4	0.2	0.6
11/18/2021 02:00	2,995.7	0.0	2,995.7	104,700.0	313.6	0.4	0.2	0.6
11/18/2021 03:00	2,995.6	0.0	2,995.6	104,700.0	313.6	0.4	0.2	0.6
11/18/2021 04:00	2,995.0	0.0	2,995.0	104,700.0	313.6	0.4	0.2	0.6
11/18/2021 05:00	3,438.1	0.0	3,438.1	104,700.0	360.0	0.4	0.2	0.7
11/18/2021 06:00	4,574.3	0.0	4,574.3	104,700.0	478.9	0.6	0.3	1.0
11/18/2021 07:00	4,184.5	0.0	4,184.5	104,700.0	438.1	0.5	0.3	0.9
11/18/2021 08:00	3,774.7	0.0	3,774.7	104,700.0	395.2	0.5	0.2	0.8
11/18/2021 09:00	3,003.2	0.0	3,003.2	104,700.0	314.4	0.4	0.2	0.6
11/18/2021 10:00	2,874.0	0.0	2,874.0	104,700.0	300.9	0.4	0.2	0.6
11/18/2021 11:00	2,879.1	0.0	2,879.1	104,700.0	301.4	0.4	0.2	0.6
11/18/2021 12:00	2,877.4	0.0	2,877.4	104,700.0	301.3	0.4	0.2	0.6
11/18/2021 13:00	3,031.3	0.0	3,031.3	104,700.0	317.4	0.4	0.2	0.6
11/18/2021 14:00	3,206.2	0.0	3,206.2	104,700.0	335.7	0.4	0.2	0.7
11/18/2021 15:00	4,260.5	0.0	4,260.5	104,700.0	446.1	0.5	0.3	0.9
11/18/2021 16:00	4,514.3	0.0	4,514.3	104,700.0	472.6	0.6	0.3	0.9
11/18/2021 17:00	4,557.1	0.0	4,557.1	104,700.0	477.1	0.6	0.3	1.0
11/18/2021 18:00	4,823.6	0.0	4,823.6	104,700.0	505.0	0.6	0.3	1.0
11/18/2021 19:00	4,688.2	0.0	4,688.2	104,700.0	490.9	0.6	0.3	1.0
11/18/2021 20:00	3,975.4	0.0	3,975.4	104,700.0	416.2	0.5	0.2	0.8
11/18/2021 21:00	3,602.0	0.0	3,602.0	104,700.0	377.1	0.5	0.2	0.8
11/18/2021 22:00	3,330.2	0.0	3,330.2	104,700.0	348.7	0.4	0.2	0.7
11/18/2021 23:00	3,203.4	0.0	3,203.4	104,700.0	335.4	0.4	0.2	0.7
Average/Sum#:	3,574.0	0.0	3,574.0	104,700.0	374.2	0.5	0.2	0.7
Minimum:	2,874.0	0.0	2,874.0	104,700.0	300.9	0.4	0.2	0.6
Maximum:	4,823.6	0.0	4,823.6	104,700.0	505.0	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/19/2021 00:00	3,171.3	0.0	3,171.3	104,700.0	332.0	0.4	0.2	0.7
11/19/2021 01:00	2,963.8	0.0	2,963.8	104,700.0	310.3	0.4	0.2	0.6
11/19/2021 02:00	2,976.6	0.0	2,976.6	104,700.0	311.7	0.4	0.2	0.6
11/19/2021 03:00	3,575.3	0.0	3,575.3	104,700.0	374.3	0.4	0.2	0.7
11/19/2021 04:00	2,970.1	0.0	2,970.1	104,700.0	311.0	0.4	0.2	0.6
11/19/2021 05:00	2,968.0	0.0	2,968.0	104,700.0	310.7	0.4	0.2	0.6
11/19/2021 06:00	3,084.1	0.0	3,084.1	104,700.0	322.9	0.4	0.2	0.6
11/19/2021 07:00	4,021.6	0.0	4,021.6	104,700.0	421.1	0.5	0.3	0.8
11/19/2021 08:00	3,386.4	0.0	3,386.4	104,700.0	354.6	0.4	0.2	0.7
11/19/2021 09:00	2,879.0	0.0	2,879.0	104,700.0	301.4	0.4	0.2	0.6
11/19/2021 10:00	2,891.1	0.0	2,891.1	104,700.0	302.7	0.4	0.2	0.6
11/19/2021 11:00	2,909.7	0.0	2,909.7	104,700.0	304.6	0.4	0.2	0.6
11/19/2021 12:00	3,031.4	0.0	3,031.4	104,700.0	317.4	0.4	0.2	0.6
11/19/2021 13:00	4,331.7	0.0	4,331.7	104,700.0	453.5	0.5	0.3	0.9
11/19/2021 14:00	4,115.3	0.0	4,115.3	104,700.0	430.9	0.5	0.3	0.9
11/19/2021 15:00	3,498.2	0.0	3,498.2	104,700.0	366.3	0.4	0.2	0.7
11/19/2021 16:00	3,020.8	0.0	3,020.8	104,700.0	316.3	0.4	0.2	0.6
11/19/2021 17:00	3,258.6	0.0	3,258.6	104,700.0	341.2	0.4	0.2	0.7
11/19/2021 18:00	3,107.3	0.0	3,107.3	104,700.0	325.3	0.4	0.2	0.7
11/19/2021 19:00	2,995.8	0.0	2,995.8	104,700.0	313.7	0.4	0.2	0.6
11/19/2021 20:00	3,468.8	0.0	3,468.8	104,700.0	363.2	0.4	0.2	0.7
11/19/2021 21:00	3,319.0	0.0	3,319.0	104,700.0	347.5	0.4	0.2	0.7
11/19/2021 22:00	3,357.0	0.0	3,357.0	104,700.0	351.5	0.4	0.2	0.7
11/19/2021 23:00	2,892.4	0.0	2,892.4	104,700.0	302.8	0.4	0.2	0.6
Average/Sum#:	3,258.1	0.0	3,258.1	104,700.0	341.1	0.4	0.2	0.7
Minimum:	2,879.0	0.0	2,879.0	104,700.0	301.4	0.4	0.2	0.6
Maximum:	4,331.7	0.0	4,331.7	104,700.0	453.5	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/20/2021 00:00	2,855.2	0.0	2,855.2	104,700.0	298.9	0.4	0.2	0.6
11/20/2021 01:00	2,870.3	0.0	2,870.3	104,700.0	300.5	0.4	0.2	0.6
11/20/2021 02:00	2,870.9	0.0	2,870.9	104,700.0	300.6	0.4	0.2	0.6
11/20/2021 03:00	2,886.1	0.0	2,886.1	104,700.0	302.2	0.4	0.2	0.6
11/20/2021 04:00	2,996.2	0.0	2,996.2	104,700.0	313.7	0.4	0.2	0.6
11/20/2021 05:00	2,910.8	0.0	2,910.8	104,700.0	304.8	0.4	0.2	0.6
11/20/2021 06:00	3,046.9	0.0	3,046.9	104,700.0	319.0	0.4	0.2	0.6
11/20/2021 07:00	3,661.9	0.0	3,661.9	104,700.0	383.4	0.5	0.2	0.8
11/20/2021 08:00	2,847.9	0.0	2,847.9	104,700.0	298.2	0.4	0.2	0.6
11/20/2021 09:00	2,845.7	0.0	2,845.7	104,700.0	297.9	0.4	0.2	0.6
11/20/2021 10:00	2,848.6	0.0	2,848.6	104,700.0	298.2	0.4	0.2	0.6
11/20/2021 11:00	2,841.8	0.0	2,841.8	104,700.0	297.5	0.4	0.2	0.6
11/20/2021 12:00	2,840.1	0.0	2,840.1	104,700.0	297.4	0.4	0.2	0.6
11/20/2021 13:00	2,834.1	0.0	2,834.1	104,700.0	296.7	0.4	0.2	0.6
11/20/2021 14:00	2,831.0	0.0	2,831.0	104,700.0	296.4	0.4	0.2	0.6
11/20/2021 15:00	3,400.0	0.0	3,400.0	104,700.0	356.0	0.4	0.2	0.7
11/20/2021 16:00	3,405.6	0.0	3,405.6	104,700.0	356.6	0.4	0.2	0.7
11/20/2021 17:00	3,055.2	0.0	3,055.2	104,700.0	319.9	0.4	0.2	0.6
11/20/2021 18:00	2,956.9	0.0	2,956.9	104,700.0	309.6	0.4	0.2	0.6
11/20/2021 19:00	3,271.4	0.0	3,271.4	104,700.0	342.5	0.4	0.2	0.7
11/20/2021 20:00	3,513.2	0.0	3,513.2	104,700.0	367.8	0.4	0.2	0.7
11/20/2021 21:00	4,445.0	0.0	4,445.0	104,700.0	465.4	0.6	0.3	0.9
11/20/2021 22:00	3,802.0	0.0	3,802.0	104,700.0	398.1	0.5	0.2	0.8
11/20/2021 23:00	2,982.8	0.0	2,982.8	104,700.0	312.3	0.4	0.2	0.6
Average/Sum#:	3,117.5	0.0	3,117.5	104,700.0	326.4	0.4	0.2	0.6
Minimum:	2,831.0	0.0	2,831.0	104,700.0	296.4	0.4	0.2	0.6
Maximum:	4,445.0	0.0	4,445.0	104,700.0	465.4	0.6	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/21/2021 00:00	3,550.7	0.0	3,550.7	104,700.0	371.8	0.4	0.2	0.7
11/21/2021 01:00	3,000.8	0.0	3,000.8	104,700.0	314.2	0.4	0.2	0.6
11/21/2021 02:00	2,889.6	0.0	2,889.6	104,700.0	302.5	0.4	0.2	0.6
11/21/2021 03:00	2,995.2	0.0	2,995.2	104,700.0	313.6	0.4	0.2	0.6
11/21/2021 04:00	3,002.6	0.0	3,002.6	104,700.0	314.4	0.4	0.2	0.6
11/21/2021 05:00	4,336.6	0.0	4,336.6	104,700.0	454.0	0.5	0.3	0.9
11/21/2021 06:00	4,442.3	0.0	4,442.3	104,700.0	465.1	0.6	0.3	0.9
11/21/2021 07:00	4,447.5	0.0	4,447.5	104,700.0	465.7	0.6	0.3	0.9
11/21/2021 08:00	4,678.3	0.0	4,678.3	104,700.0	489.8	0.6	0.3	1.0
11/21/2021 09:00	3,803.7	0.0	3,803.7	104,700.0	398.2	0.5	0.2	0.8
11/21/2021 10:00	3,798.7	0.0	3,798.7	104,700.0	397.7	0.5	0.2	0.8
11/21/2021 11:00	3,267.2	0.0	3,267.2	104,700.0	342.1	0.4	0.2	0.7
11/21/2021 12:00	2,856.4	0.0	2,856.4	104,700.0	299.1	0.4	0.2	0.6
11/21/2021 13:00	2,852.4	0.0	2,852.4	104,700.0	298.6	0.4	0.2	0.6
11/21/2021 14:00	2,851.2	0.0	2,851.2	104,700.0	298.5	0.4	0.2	0.6
11/21/2021 15:00	3,668.0	0.0	3,668.0	104,700.0	384.0	0.5	0.2	0.8
11/21/2021 16:00	3,472.9	0.0	3,472.9	104,700.0	363.6	0.4	0.2	0.7
11/21/2021 17:00	2,963.8	0.0	2,963.8	104,700.0	310.3	0.4	0.2	0.6
11/21/2021 18:00	2,973.5	0.0	2,973.5	104,700.0	311.3	0.4	0.2	0.6
11/21/2021 19:00	3,693.3	0.0	3,693.3	104,700.0	386.7	0.5	0.2	0.8
11/21/2021 20:00	4,770.5	0.0	4,770.5	104,700.0	499.5	0.6	0.3	1.0
11/21/2021 21:00	3,951.4	0.0	3,951.4	104,700.0	413.7	0.5	0.2	0.8
11/21/2021 22:00	3,842.4	0.0	3,842.4	104,700.0	402.3	0.5	0.2	0.8
11/21/2021 23:00	2,985.6	0.0	2,985.6	104,700.0	312.6	0.4	0.2	0.6
Average/Sum#:	3,545.6	0.0	3,545.6	104,700.0	371.2	0.5	0.2	0.7
Minimum:	2,851.2	0.0	2,851.2	104,700.0	298.5	0.4	0.2	0.6
Maximum:	4,770.5	0.0	4,770.5	104,700.0	499.5	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/22/2021 00:00	2,998.6	0.0	2,998.6	104,700.0	314.0	0.4	0.2	0.6
11/22/2021 01:00	2,999.7	0.0	2,999.7	104,700.0	314.1	0.4	0.2	0.6
11/22/2021 02:00	3,001.3	0.0	3,001.3	104,700.0	314.2	0.4	0.2	0.6
11/22/2021 03:00	3,001.5	0.0	3,001.5	104,700.0	314.3	0.4	0.2	0.6
11/22/2021 04:00	2,999.7	0.0	2,999.7	104,700.0	314.1	0.4	0.2	0.6
11/22/2021 05:00	3,028.0	0.0	3,028.0	104,700.0	317.0	0.4	0.2	0.6
11/22/2021 06:00	3,597.5	0.0	3,597.5	104,700.0	376.7	0.5	0.2	0.8
11/22/2021 07:00	3,594.7	0.0	3,594.7	104,700.0	376.4	0.5	0.2	0.8
11/22/2021 08:00	3,006.8	0.0	3,006.8	104,700.0	314.8	0.4	0.2	0.6
11/22/2021 09:00	2,886.6	0.0	2,886.6	104,700.0	302.2	0.4	0.2	0.6
11/22/2021 10:00	2,859.7	0.0	2,859.7	104,700.0	299.4	0.4	0.2	0.6
11/22/2021 11:00	2,856.4	0.0	2,856.4	104,700.0	299.1	0.4	0.2	0.6
11/22/2021 12:00	2,927.0	0.0	2,927.0	104,700.0	306.5	0.4	0.2	0.6
11/22/2021 13:00	2,974.7	0.0	2,974.7	104,700.0	311.5	0.4	0.2	0.6
11/22/2021 14:00	4,014.6	0.0	4,014.6	104,700.0	420.3	0.5	0.3	0.8
11/22/2021 15:00	4,823.4	0.0	4,823.4	104,700.0	505.0	0.6	0.3	1.0
11/22/2021 16:00	3,940.1	0.0	3,940.1	104,700.0	412.5	0.5	0.2	0.8
11/22/2021 17:00	3,218.7	0.0	3,218.7	104,700.0	337.0	0.4	0.2	0.7
11/22/2021 18:00	4,437.8	0.0	4,437.8	104,700.0	464.6	0.6	0.3	0.9
11/22/2021 19:00	4,391.1	0.0	4,391.1	104,700.0	459.7	0.6	0.3	0.9
11/22/2021 20:00	4,467.1	0.0	4,467.1	104,700.0	467.7	0.6	0.3	0.9
11/22/2021 21:00	4,431.6	0.0	4,431.6	104,700.0	464.0	0.6	0.3	0.9
11/22/2021 22:00	4,473.2	0.0	4,473.2	104,700.0	468.3	0.6	0.3	0.9
11/22/2021 23:00	3,676.3	0.0	3,676.3	104,700.0	384.9	0.5	0.2	0.8
Average/Sum#:	3,525.3	0.0	3,525.3	104,700.0	369.1	0.5	0.2	0.7
Minimum:	2,856.4	0.0	2,856.4	104,700.0	299.1	0.4	0.2	0.6
Maximum:	4,823.4	0.0	4,823.4	104,700.0	505.0	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/23/2021 00:00	2,986.6	0.0	2,986.6	104,700.0	312.7	0.4	0.2	0.6
11/23/2021 01:00	3,000.1	0.0	3,000.1	104,700.0	314.1	0.4	0.2	0.6
11/23/2021 02:00	3,005.6	0.0	3,005.6	104,700.0	314.7	0.4	0.2	0.6
11/23/2021 03:00	2,983.3	0.0	2,983.3	104,700.0	312.4	0.4	0.2	0.6
11/23/2021 04:00	2,901.2	0.0	2,901.2	104,700.0	303.8	0.4	0.2	0.6
11/23/2021 05:00	2,894.7	0.0	2,894.7	104,700.0	303.1	0.4	0.2	0.6
11/23/2021 06:00	2,998.4	0.0	2,998.4	104,700.0	313.9	0.4	0.2	0.6
11/23/2021 07:00	3,473.4	0.0	3,473.4	104,700.0	363.7	0.4	0.2	0.7
11/23/2021 08:00	2,906.6	0.0	2,906.6	104,700.0	304.3	0.4	0.2	0.6
11/23/2021 09:00	2,857.3	0.0	2,857.3	104,700.0	299.2	0.4	0.2	0.6
11/23/2021 10:00	2,849.4	0.0	2,849.4	104,700.0	298.3	0.4	0.2	0.6
11/23/2021 11:00	2,849.2	0.0	2,849.2	104,700.0	298.3	0.4	0.2	0.6
11/23/2021 12:00	2,850.5	0.0	2,850.5	104,700.0	298.4	0.4	0.2	0.6
11/23/2021 13:00	2,847.3	0.0	2,847.3	104,700.0	298.1	0.4	0.2	0.6
11/23/2021 14:00	2,851.9	0.0	2,851.9	104,700.0	298.6	0.4	0.2	0.6
11/23/2021 15:00	3,271.0	0.0	3,271.0	104,700.0	342.5	0.4	0.2	0.7
11/23/2021 16:00	3,201.3	0.0	3,201.3	104,700.0	335.2	0.4	0.2	0.7
11/23/2021 17:00	2,979.6	0.0	2,979.6	104,700.0	312.0	0.4	0.2	0.6
11/23/2021 18:00	2,978.8	0.0	2,978.8	104,700.0	311.9	0.4	0.2	0.6
11/23/2021 19:00	2,982.6	0.0	2,982.6	104,700.0	312.3	0.4	0.2	0.6
11/23/2021 20:00	2,917.8	0.0	2,917.8	104,700.0	305.5	0.4	0.2	0.6
11/23/2021 21:00	2,950.3	0.0	2,950.3	104,700.0	308.9	0.4	0.2	0.6
11/23/2021 22:00	2,994.7	0.0	2,994.7	104,700.0	313.5	0.4	0.2	0.6
11/23/2021 23:00	2,917.0	0.0	2,917.0	104,700.0	305.4	0.4	0.2	0.6
Average/Sum#:	2,977.0	0.0	2,977.0	104,700.0	311.7	0.4	0.2	0.6
Minimum:	2,847.3	0.0	2,847.3	104,700.0	298.1	0.4	0.2	0.6
Maximum:	3,473.4	0.0	3,473.4	104,700.0	363.7	0.4	0.2	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/24/2021 00:00	3,000.9	0.0	3,000.9	104,700.0	314.2	0.4	0.2	0.6
11/24/2021 01:00	2,997.9	0.0	2,997.9	104,700.0	313.9	0.4	0.2	0.6
11/24/2021 02:00	2,889.7	0.0	2,889.7	104,700.0	302.6	0.4	0.2	0.6
11/24/2021 03:00	2,891.4	0.0	2,891.4	104,700.0	302.7	0.4	0.2	0.6
11/24/2021 04:00	2,916.3	0.0	2,916.3	104,700.0	305.3	0.4	0.2	0.6
11/24/2021 05:00	2,944.6	0.0	2,944.6	104,700.0	308.3	0.4	0.2	0.6
11/24/2021 06:00	3,225.0	0.0	3,225.0	104,700.0	337.7	0.4	0.2	0.7
11/24/2021 07:00	3,582.5	0.0	3,582.5	104,700.0	375.1	0.5	0.2	0.8
11/24/2021 08:00	2,983.1	0.0	2,983.1	104,700.0	312.3	0.4	0.2	0.6
11/24/2021 09:00	3,084.1	0.0	3,084.1	104,700.0	322.9	0.4	0.2	0.6
11/24/2021 10:00	2,975.1	0.0	2,975.1	104,700.0	311.5	0.4	0.2	0.6
11/24/2021 11:00	2,967.5	0.0	2,967.5	104,700.0	310.7	0.4	0.2	0.6
11/24/2021 12:00	2,962.7	0.0	2,962.7	104,700.0	310.2	0.4	0.2	0.6
11/24/2021 13:00	2,960.8	0.0	2,960.8	104,700.0	310.0	0.4	0.2	0.6
11/24/2021 14:00	2,966.3	0.0	2,966.3	104,700.0	310.6	0.4	0.2	0.6
11/24/2021 15:00	3,358.7	0.0	3,358.7	104,700.0	351.7	0.4	0.2	0.7
11/24/2021 16:00	3,345.2	0.0	3,345.2	104,700.0	350.2	0.4	0.2	0.7
11/24/2021 17:00	2,979.2	0.0	2,979.2	104,700.0	311.9	0.4	0.2	0.6
11/24/2021 18:00	2,969.1	0.0	2,969.1	104,700.0	310.9	0.4	0.2	0.6
11/24/2021 19:00	3,005.5	0.0	3,005.5	104,700.0	314.7	0.4	0.2	0.6
11/24/2021 20:00	3,066.4	0.0	3,066.4	104,700.0	321.1	0.4	0.2	0.6
11/24/2021 21:00	3,189.6	0.0	3,189.6	104,700.0	334.0	0.4	0.2	0.7
11/24/2021 22:00	3,001.7	0.0	3,001.7	104,700.0	314.3	0.4	0.2	0.6
11/24/2021 23:00	3,010.6	0.0	3,010.6	104,700.0	315.2	0.4	0.2	0.6
Average/Sum#:	3,053.1	0.0	3,053.1	104,700.0	319.7	0.4	0.2	0.6
Minimum:	2,889.7	0.0	2,889.7	104,700.0	302.6	0.4	0.2	0.6
Maximum:	3,582.5	0.0	3,582.5	104,700.0	375.1	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/25/2021 00:00	3,014.6	0.0	3,014.6	104,700.0	315.6	0.4	0.2	0.6
11/25/2021 01:00	3,013.1	0.0	3,013.1	104,700.0	315.5	0.4	0.2	0.6
11/25/2021 02:00	3,020.9	0.0	3,020.9	104,700.0	316.3	0.4	0.2	0.6
11/25/2021 03:00	3,018.7	0.0	3,018.7	104,700.0	316.1	0.4	0.2	0.6
11/25/2021 04:00	3,025.5	0.0	3,025.5	104,700.0	316.8	0.4	0.2	0.6
11/25/2021 05:00	3,021.8	0.0	3,021.8	104,700.0	316.4	0.4	0.2	0.6
11/25/2021 06:00	3,064.3	0.0	3,064.3	104,700.0	320.8	0.4	0.2	0.6
11/25/2021 07:00	3,438.4	0.0	3,438.4	104,700.0	360.0	0.4	0.2	0.7
11/25/2021 08:00	3,091.1	0.0	3,091.1	104,700.0	323.6	0.4	0.2	0.6
11/25/2021 09:00	2,974.2	0.0	2,974.2	104,700.0	311.4	0.4	0.2	0.6
11/25/2021 10:00	2,973.9	0.0	2,973.9	104,700.0	311.4	0.4	0.2	0.6
11/25/2021 11:00	3,022.5	0.0	3,022.5	104,700.0	316.5	0.4	0.2	0.6
11/25/2021 12:00	2,959.9	0.0	2,959.9	104,700.0	309.9	0.4	0.2	0.6
11/25/2021 13:00	2,965.0	0.0	2,965.0	104,700.0	310.4	0.4	0.2	0.6
11/25/2021 14:00	2,958.6	0.0	2,958.6	104,700.0	309.8	0.4	0.2	0.6
11/25/2021 15:00	3,070.0	0.0	3,070.0	104,700.0	321.4	0.4	0.2	0.6
11/25/2021 16:00	3,069.4	0.0	3,069.4	104,700.0	321.4	0.4	0.2	0.6
11/25/2021 17:00	2,957.1	0.0	2,957.1	104,700.0	309.6	0.4	0.2	0.6
11/25/2021 18:00	2,990.0	0.0	2,990.0	104,700.0	313.1	0.4	0.2	0.6
11/25/2021 19:00	2,956.3	0.0	2,956.3	104,700.0	309.5	0.4	0.2	0.6
11/25/2021 20:00	2,956.5	0.0	2,956.5	104,700.0	309.5	0.4	0.2	0.6
11/25/2021 21:00	2,966.0	0.0	2,966.0	104,700.0	310.5	0.4	0.2	0.6
11/25/2021 22:00	2,958.9	0.0	2,958.9	104,700.0	309.8	0.4	0.2	0.6
11/25/2021 23:00	2,966.7	0.0	2,966.7	104,700.0	310.6	0.4	0.2	0.6
Average/Sum#:	3,018.9	0.0	3,018.9	104,700.0	316.1	0.4	0.2	0.6
Minimum:	2,956.3	0.0	2,956.3	104,700.0	309.5	0.4	0.2	0.6
Maximum:	3,438.4	0.0	3,438.4	104,700.0	360.0	0.4	0.2	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/26/2021 00:00	2,962.1	0.0	2,962.1	104,700.0	310.1	0.4	0.2	0.6
11/26/2021 01:00	2,964.5	0.0	2,964.5	104,700.0	310.4	0.4	0.2	0.6
11/26/2021 02:00	2,966.2	0.0	2,966.2	104,700.0	310.6	0.4	0.2	0.6
11/26/2021 03:00	2,968.1	0.0	2,968.1	104,700.0	310.8	0.4	0.2	0.6
11/26/2021 04:00	2,968.3	0.0	2,968.3	104,700.0	310.8	0.4	0.2	0.6
11/26/2021 05:00	2,961.2	0.0	2,961.2	104,700.0	310.0	0.4	0.2	0.6
11/26/2021 06:00	2,963.7	0.0	2,963.7	104,700.0	310.3	0.4	0.2	0.6
11/26/2021 07:00	2,970.4	0.0	2,970.4	104,700.0	311.0	0.4	0.2	0.6
11/26/2021 08:00	2,962.2	0.0	2,962.2	104,700.0	310.1	0.4	0.2	0.6
11/26/2021 09:00	2,963.1	0.0	2,963.1	104,700.0	310.2	0.4	0.2	0.6
11/26/2021 10:00	2,963.6	0.0	2,963.6	104,700.0	310.3	0.4	0.2	0.6
11/26/2021 11:00	2,952.9	0.0	2,952.9	104,700.0	309.2	0.4	0.2	0.6
11/26/2021 12:00	2,946.3	0.0	2,946.3	104,700.0	308.5	0.4	0.2	0.6
11/26/2021 13:00	2,940.2	0.0	2,940.2	104,700.0	307.8	0.4	0.2	0.6
11/26/2021 14:00	2,934.8	0.0	2,934.8	104,700.0	307.3	0.4	0.2	0.6
11/26/2021 15:00	3,484.0	0.0	3,484.0	104,700.0	364.8	0.4	0.2	0.7
11/26/2021 16:00	2,990.3	0.0	2,990.3	104,700.0	313.1	0.4	0.2	0.6
11/26/2021 17:00	2,946.0	0.0	2,946.0	104,700.0	308.4	0.4	0.2	0.6
11/26/2021 18:00	2,941.0	0.0	2,941.0	104,700.0	307.9	0.4	0.2	0.6
11/26/2021 19:00	2,942.7	0.0	2,942.7	104,700.0	308.1	0.4	0.2	0.6
11/26/2021 20:00	2,956.4	0.0	2,956.4	104,700.0	309.5	0.4	0.2	0.6
11/26/2021 21:00	2,965.7	0.0	2,965.7	104,700.0	310.5	0.4	0.2	0.6
11/26/2021 22:00	2,960.3	0.0	2,960.3	104,700.0	309.9	0.4	0.2	0.6
11/26/2021 23:00	2,974.4	0.0	2,974.4	104,700.0	311.4	0.4	0.2	0.6
Average/Sum#:	2,981.2	0.0	2,981.2	104,700.0	312.1	0.4	0.2	0.6
Minimum:	2,934.8	0.0	2,934.8	104,700.0	307.3	0.4	0.2	0.6
Maximum:	3,484.0	0.0	3,484.0	104,700.0	364.8	0.4	0.2	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/27/2021 00:00	2,957.1	0.0	2,957.1	104,700.0	309.6	0.4	0.2	0.6
11/27/2021 01:00	2,970.7	0.0	2,970.7	104,700.0	311.0	0.4	0.2	0.6
11/27/2021 02:00	2,958.1	0.0	2,958.1	104,700.0	309.7	0.4	0.2	0.6
11/27/2021 03:00	2,964.7	0.0	2,964.7	104,700.0	310.4	0.4	0.2	0.6
11/27/2021 04:00	2,958.0	0.0	2,958.0	104,700.0	309.7	0.4	0.2	0.6
11/27/2021 05:00	3,162.1	0.0	3,162.1	104,700.0	331.1	0.4	0.2	0.7
11/27/2021 06:00	3,055.8	0.0	3,055.8	104,700.0	319.9	0.4	0.2	0.6
11/27/2021 07:00	3,626.1	0.0	3,626.1	104,700.0	379.7	0.5	0.2	0.8
11/27/2021 08:00	2,956.5	0.0	2,956.5	104,700.0	309.5	0.4	0.2	0.6
11/27/2021 09:00	3,258.9	0.0	3,258.9	104,700.0	341.2	0.4	0.2	0.7
11/27/2021 10:00	3,803.2	0.0	3,803.2	104,700.0	398.2	0.5	0.2	0.8
11/27/2021 11:00	2,953.6	0.0	2,953.6	104,700.0	309.2	0.4	0.2	0.6
11/27/2021 12:00	2,951.8	0.0	2,951.8	104,700.0	309.1	0.4	0.2	0.6
11/27/2021 13:00	2,947.4	0.0	2,947.4	104,700.0	308.6	0.4	0.2	0.6
11/27/2021 14:00	2,944.9	0.0	2,944.9	104,700.0	308.3	0.4	0.2	0.6
11/27/2021 15:00	3,398.0	0.0	3,398.0	104,700.0	355.8	0.4	0.2	0.7
11/27/2021 16:00	3,556.1	0.0	3,556.1	104,700.0	372.3	0.4	0.2	0.7
11/27/2021 17:00	2,997.5	0.0	2,997.5	104,700.0	313.8	0.4	0.2	0.6
11/27/2021 18:00	2,953.9	0.0	2,953.9	104,700.0	309.3	0.4	0.2	0.6
11/27/2021 19:00	2,956.0	0.0	2,956.0	104,700.0	309.5	0.4	0.2	0.6
11/27/2021 20:00	2,964.4	0.0	2,964.4	104,700.0	310.4	0.4	0.2	0.6
11/27/2021 21:00	3,144.2	0.0	3,144.2	104,700.0	329.2	0.4	0.2	0.7
11/27/2021 22:00	2,961.4	0.0	2,961.4	104,700.0	310.1	0.4	0.2	0.6
11/27/2021 23:00	2,965.2	0.0	2,965.2	104,700.0	310.5	0.4	0.2	0.6
Average/Sum#:	3,098.6	0.0	3,098.6	104,700.0	324.4	0.4	0.2	0.6
Minimum:	2,944.9	0.0	2,944.9	104,700.0	308.3	0.4	0.2	0.6
Maximum:	3,803.2	0.0	3,803.2	104,700.0	398.2	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/28/2021 00:00	2,964.5	0.0	2,964.5	104,700.0	310.4	0.4	0.2	0.6
11/28/2021 01:00	2,965.6	0.0	2,965.6	104,700.0	310.5	0.4	0.2	0.6
11/28/2021 02:00	2,970.3	0.0	2,970.3	104,700.0	311.0	0.4	0.2	0.6
11/28/2021 03:00	2,972.1	0.0	2,972.1	104,700.0	311.2	0.4	0.2	0.6
11/28/2021 04:00	2,973.0	0.0	2,973.0	104,700.0	311.3	0.4	0.2	0.6
11/28/2021 05:00	2,972.7	0.0	2,972.7	104,700.0	311.2	0.4	0.2	0.6
11/28/2021 06:00	2,975.2	0.0	2,975.2	104,700.0	311.5	0.4	0.2	0.6
11/28/2021 07:00	3,145.9	0.0	3,145.9	104,700.0	329.4	0.4	0.2	0.7
11/28/2021 08:00	2,974.9	0.0	2,974.9	104,700.0	311.5	0.4	0.2	0.6
11/28/2021 09:00	2,969.6	0.0	2,969.6	104,700.0	310.9	0.4	0.2	0.6
11/28/2021 10:00	2,964.6	0.0	2,964.6	104,700.0	310.4	0.4	0.2	0.6
11/28/2021 11:00	2,957.4	0.0	2,957.4	104,700.0	309.6	0.4	0.2	0.6
11/28/2021 12:00	2,955.3	0.0	2,955.3	104,700.0	309.4	0.4	0.2	0.6
11/28/2021 13:00	2,949.4	0.0	2,949.4	104,700.0	308.8	0.4	0.2	0.6
11/28/2021 14:00	2,946.5	0.0	2,946.5	104,700.0	308.5	0.4	0.2	0.6
11/28/2021 15:00	2,958.5	0.0	2,958.5	104,700.0	309.8	0.4	0.2	0.6
11/28/2021 16:00	3,091.5	0.0	3,091.5	104,700.0	323.7	0.4	0.2	0.6
11/28/2021 17:00	2,952.7	0.0	2,952.7	104,700.0	309.1	0.4	0.2	0.6
11/28/2021 18:00	2,954.9	0.0	2,954.9	104,700.0	309.4	0.4	0.2	0.6
11/28/2021 19:00	2,959.6	0.0	2,959.6	104,700.0	309.9	0.4	0.2	0.6
11/28/2021 20:00	2,961.7	0.0	2,961.7	104,700.0	310.1	0.4	0.2	0.6
11/28/2021 21:00	2,964.9	0.0	2,964.9	104,700.0	310.4	0.4	0.2	0.6
11/28/2021 22:00	2,965.4	0.0	2,965.4	104,700.0	310.5	0.4	0.2	0.6
11/28/2021 23:00	2,966.3	0.0	2,966.3	104,700.0	310.6	0.4	0.2	0.6
Average/Sum#:	2,976.4	0.0	2,976.4	104,700.0	311.6	0.4	0.2	0.6
Minimum:	2,946.5	0.0	2,946.5	104,700.0	308.5	0.4	0.2	0.6
Maximum:	3,145.9	0.0	3,145.9	104,700.0	329.4	0.4	0.2	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/29/2021 00:00	2,966.6	0.0	2,966.6	104,700.0	310.6	0.4	0.2	0.6
11/29/2021 01:00	2,965.9	0.0	2,965.9	104,700.0	310.5	0.4	0.2	0.6
11/29/2021 02:00	2,967.5	0.0	2,967.5	104,700.0	310.7	0.4	0.2	0.6
11/29/2021 03:00	2,968.6	0.0	2,968.6	104,700.0	310.8	0.4	0.2	0.6
11/29/2021 04:00	2,974.0	0.0	2,974.0	104,700.0	311.4	0.4	0.2	0.6
11/29/2021 05:00	3,035.6	0.0	3,035.6	104,700.0	317.8	0.4	0.2	0.6
11/29/2021 06:00	3,665.3	0.0	3,665.3	104,700.0	383.8	0.5	0.2	0.8
11/29/2021 07:00	3,690.8	0.0	3,690.8	104,700.0	386.4	0.5	0.2	0.8
11/29/2021 08:00	2,974.4	0.0	2,974.4	104,700.0	311.4	0.4	0.2	0.6
11/29/2021 09:00	2,969.1	0.0	2,969.1	104,700.0	310.9	0.4	0.2	0.6
11/29/2021 10:00	2,966.5	0.0	2,966.5	104,700.0	310.6	0.4	0.2	0.6
11/29/2021 11:00	2,961.4	0.0	2,961.4	104,700.0	310.1	0.4	0.2	0.6
11/29/2021 12:00	2,955.2	0.0	2,955.2	104,700.0	309.4	0.4	0.2	0.6
11/29/2021 13:00	2,950.0	0.0	2,950.0	104,700.0	308.9	0.4	0.2	0.6
11/29/2021 14:00	2,946.6	0.0	2,946.6	104,700.0	308.5	0.4	0.2	0.6
11/29/2021 15:00	3,293.7	0.0	3,293.7	104,700.0	344.9	0.4	0.2	0.7
11/29/2021 16:00	3,932.5	0.0	3,932.5	104,700.0	411.7	0.5	0.2	0.8
11/29/2021 17:00	4,085.4	0.0	4,085.4	104,700.0	427.7	0.5	0.3	0.9
11/29/2021 18:00	3,366.0	0.0	3,366.0	104,700.0	352.4	0.4	0.2	0.7
11/29/2021 19:00	4,029.9	0.0	4,029.9	104,700.0	421.9	0.5	0.3	0.8
11/29/2021 20:00	4,643.5	0.0	4,643.5	104,700.0	486.2	0.6	0.3	1.0
11/29/2021 21:00	3,530.4	0.0	3,530.4	104,700.0	369.6	0.4	0.2	0.7
11/29/2021 22:00	3,100.4	0.0	3,100.4	104,700.0	324.6	0.4	0.2	0.6
11/29/2021 23:00	2,965.7	0.0	2,965.7	104,700.0	310.5	0.4	0.2	0.6
Average/Sum#:	3,287.7	0.0	3,287.7	104,700.0	344.2	0.4	0.2	0.7
Minimum:	2,946.6	0.0	2,946.6	104,700.0	308.5	0.4	0.2	0.6
Maximum:	4,643.5	0.0	4,643.5	104,700.0	486.2	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/30/2021 00:00	4,010.9	0.0	4,010.9	104,700.0	419.9	0.5	0.3	0.8
11/30/2021 01:00	3,210.8	0.0	3,210.8	104,700.0	336.2	0.4	0.2	0.7
11/30/2021 02:00	2,963.3	0.0	2,963.3	104,700.0	310.3	0.4	0.2	0.6
11/30/2021 03:00	2,962.8	0.0	2,962.8	104,700.0	310.2	0.4	0.2	0.6
11/30/2021 04:00	2,974.1	0.0	2,974.1	104,700.0	311.4	0.4	0.2	0.6
11/30/2021 05:00	3,262.0	0.0	3,262.0	104,700.0	341.5	0.4	0.2	0.7
11/30/2021 06:00	4,477.2	0.0	4,477.2	104,700.0	468.8	0.6	0.3	0.9
11/30/2021 07:00	4,467.6	0.0	4,467.6	104,700.0	467.8	0.6	0.3	0.9
11/30/2021 08:00	3,053.4	0.0	3,053.4	104,700.0	319.7	0.4	0.2	0.6
11/30/2021 09:00	2,963.8	0.0	2,963.8	104,700.0	310.3	0.4	0.2	0.6
11/30/2021 10:00	2,958.4	0.0	2,958.4	104,700.0	309.7	0.4	0.2	0.6
11/30/2021 11:00	2,953.1	0.0	2,953.1	104,700.0	309.2	0.4	0.2	0.6
11/30/2021 12:00	2,952.5	0.0	2,952.5	104,700.0	309.1	0.4	0.2	0.6
11/30/2021 13:00	2,948.3	0.0	2,948.3	104,700.0	308.7	0.4	0.2	0.6
11/30/2021 14:00	2,946.0	0.0	2,946.0	104,700.0	308.4	0.4	0.2	0.6
11/30/2021 15:00	3,514.3	0.0	3,514.3	104,700.0	367.9	0.4	0.2	0.7
11/30/2021 16:00	4,151.8	0.0	4,151.8	104,700.0	434.7	0.5	0.3	0.9
11/30/2021 17:00	4,802.5	442.9	5,015.1	104,700.0	525.1	0.7	0.3	1.1
11/30/2021 18:00	4,818.9	1,564.7	6,383.6	104,700.0	668.4	0.8	0.4	1.3
11/30/2021 19:00	4,837.4	1,520.7	6,358.1	104,700.0	665.7	0.8	0.4	1.3
11/30/2021 20:00	4,879.3	383.5	5,178.4	104,700.0	542.2	0.7	0.3	1.1
11/30/2021 21:00	4,890.7	1,167.9	6,058.6	104,700.0	634.3	0.8	0.4	1.3
11/30/2021 22:00	4,862.7	57.3	4,884.5	104,700.0	511.4	0.6	0.3	1.0
11/30/2021 23:00	4,120.9	21.9	4,127.9	104,700.0	432.2	0.5	0.3	0.9
Average/Sum#:	3,749.3	215.0	3,949.0	104,700.0	413.5	0.5	0.3	0.8
Minimum:	2,946.0	0.0	2,946.0	104,700.0	308.4	0.4	0.2	0.6
Maximum:	4,890.7	1,564.7	6,383.6	104,700.0	668.4	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/01/2021 00:00	2,965.0	0.0	2,965.0	104,700.0	310.4	0.4	0.2	0.6
12/01/2021 01:00	2,965.7	0.0	2,965.7	104,700.0	310.5	0.4	0.2	0.6
12/01/2021 02:00	2,968.5	0.0	2,968.5	104,700.0	310.8	0.4	0.2	0.6
12/01/2021 03:00	2,970.2	0.0	2,970.2	104,700.0	311.0	0.4	0.2	0.6
12/01/2021 04:00	2,968.1	0.0	2,968.1	104,700.0	310.8	0.4	0.2	0.6
12/01/2021 05:00	2,971.2	0.0	2,971.2	104,700.0	311.1	0.4	0.2	0.6
12/01/2021 06:00	2,971.8	0.0	2,971.8	104,700.0	311.1	0.4	0.2	0.6
12/01/2021 07:00	2,971.7	0.0	2,971.7	104,700.0	311.1	0.4	0.2	0.6
12/01/2021 08:00	2,969.0	0.0	2,969.0	104,700.0	310.9	0.4	0.2	0.6
12/01/2021 09:00	2,963.5	0.0	2,963.5	104,700.0	310.3	0.4	0.2	0.6
12/01/2021 10:00	2,957.3	0.0	2,957.3	104,700.0	309.6	0.4	0.2	0.6
12/01/2021 11:00	2,951.0	0.0	2,951.0	104,700.0	309.0	0.4	0.2	0.6
12/01/2021 12:00	2,949.6	0.0	2,949.6	104,700.0	308.8	0.4	0.2	0.6
12/01/2021 13:00	2,944.3	0.0	2,944.3	104,700.0	308.3	0.4	0.2	0.6
12/01/2021 14:00	2,943.2	0.0	2,943.2	104,700.0	308.2	0.4	0.2	0.6
12/01/2021 15:00	3,201.8	0.0	3,201.8	104,700.0	335.2	0.4	0.2	0.7
12/01/2021 16:00	3,728.8	0.0	3,728.8	104,700.0	390.4	0.5	0.2	0.8
12/01/2021 17:00	4,133.0	0.0	4,133.0	104,700.0	432.7	0.5	0.3	0.9
12/01/2021 18:00	4,448.5	0.0	4,448.5	104,700.0	465.8	0.6	0.3	0.9
12/01/2021 19:00	4,619.4	0.0	4,619.4	104,700.0	483.7	0.6	0.3	1.0
12/01/2021 20:00	4,417.5	0.0	4,417.5	104,700.0	462.5	0.6	0.3	0.9
12/01/2021 21:00	4,590.7	0.0	4,590.7	104,700.0	480.6	0.6	0.3	1.0
12/01/2021 22:00	3,206.5	0.0	3,206.5	104,700.0	335.7	0.4	0.2	0.7
12/01/2021 23:00	2,961.3	0.0	2,961.3	104,700.0	310.0	0.4	0.2	0.6
Average/Sum#:	3,322.4	0.0	3,322.4	104,700.0	347.9	0.4	0.2	0.7
Minimum:	2,943.2	0.0	2,943.2	104,700.0	308.2	0.4	0.2	0.6
Maximum:	4,619.4	0.0	4,619.4	104,700.0	483.7	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/02/2021 00:00	3,012.8	0.0	3,012.8	104,700.0	315.4	0.4	0.2	0.6
12/02/2021 01:00	3,181.3	0.0	3,181.3	104,700.0	333.1	0.4	0.2	0.7
12/02/2021 02:00	3,086.1	0.0	3,086.1	104,700.0	323.1	0.4	0.2	0.6
12/02/2021 03:00	4,192.0	0.0	4,192.0	104,700.0	438.9	0.5	0.3	0.9
12/02/2021 04:00	4,537.2	0.0	4,537.2	104,700.0	475.0	0.6	0.3	1.0
12/02/2021 05:00	4,648.0	1.1	4,648.5	104,700.0	486.7	0.6	0.3	1.0
12/02/2021 06:00	4,895.2	192.3	5,087.5	104,700.0	532.7	0.6	0.3	1.1
12/02/2021 07:00	4,962.5	192.2	5,049.0	104,700.0	528.6	0.6	0.3	1.1
12/02/2021 08:00	4,140.8	0.0	4,140.8	104,700.0	433.5	0.5	0.3	0.9
12/02/2021 09:00	2,967.0	0.0	2,967.0	104,700.0	310.6	0.4	0.2	0.6
12/02/2021 10:00	2,959.9	0.0	2,959.9	104,700.0	309.9	0.4	0.2	0.6
12/02/2021 11:00	2,954.7	0.0	2,954.7	104,700.0	309.4	0.4	0.2	0.6
12/02/2021 12:00	2,949.8	0.0	2,949.8	104,700.0	308.8	0.4	0.2	0.6
12/02/2021 13:00	2,945.5	0.0	2,945.5	104,700.0	308.4	0.4	0.2	0.6
12/02/2021 14:00	2,941.2	0.0	2,941.2	104,700.0	307.9	0.4	0.2	0.6
12/02/2021 15:00	3,353.5	0.0	3,353.5	104,700.0	351.1	0.4	0.2	0.7
12/02/2021 16:00	3,888.7	93.7	3,923.4	104,700.0	410.8	0.5	0.3	0.8
12/02/2021 17:00	4,740.2	903.3	5,643.5	104,700.0	590.9	0.7	0.4	1.2
12/02/2021 18:00	4,775.3	350.7	5,066.4	104,700.0	530.5	0.6	0.3	1.1
12/02/2021 19:00	4,815.2	255.1	5,052.4	104,700.0	529.0	0.6	0.3	1.1
12/02/2021 20:00	4,843.2	419.5	5,262.7	104,700.0	551.0	0.7	0.3	1.1
12/02/2021 21:00	4,863.4	389.4	5,252.8	104,700.0	550.0	0.7	0.3	1.1
12/02/2021 22:00	4,111.9	134.0	4,176.2	104,700.0	437.2	0.5	0.3	0.9
12/02/2021 23:00	2,959.5	0.0	2,959.5	104,700.0	309.9	0.4	0.2	0.6
Average/Sum#:	3,863.5	122.1	3,972.7	104,700.0	415.9	0.5	0.3	0.8
Minimum:	2,941.2	0.0	2,941.2	104,700.0	307.9	0.4	0.2	0.6
Maximum:	4,962.5	903.3	5,643.5	104,700.0	590.9	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/03/2021 00:00	2,959.7	0.0	2,959.7	104,700.0	309.9	0.4	0.2	0.6
12/03/2021 01:00	2,960.5	0.0	2,960.5	104,700.0	310.0	0.4	0.2	0.6
12/03/2021 02:00	2,961.5	0.0	2,961.5	104,700.0	310.1	0.4	0.2	0.6
12/03/2021 03:00	2,961.2	0.0	2,961.2	104,700.0	310.0	0.4	0.2	0.6
12/03/2021 04:00	2,963.6	0.0	2,963.6	104,700.0	310.3	0.4	0.2	0.6
12/03/2021 05:00	3,065.2	0.0	3,065.2	104,700.0	320.9	0.4	0.2	0.6
12/03/2021 06:00	3,099.6	0.0	3,099.6	104,700.0	324.5	0.4	0.2	0.6
12/03/2021 07:00	3,505.4	0.0	3,505.4	104,700.0	367.0	0.4	0.2	0.7
12/03/2021 08:00	3,020.6	0.0	3,020.6	104,700.0	316.3	0.4	0.2	0.6
12/03/2021 09:00	3,831.6	0.0	3,831.6	104,700.0	401.2	0.5	0.2	0.8
12/03/2021 10:00	4,715.5	0.0	4,715.5	104,700.0	493.7	0.6	0.3	1.0
12/03/2021 11:00	3,896.5	0.0	3,896.5	104,700.0	408.0	0.5	0.2	0.8
12/03/2021 12:00	3,512.6	0.0	3,512.6	104,700.0	367.8	0.4	0.2	0.7
12/03/2021 13:00	2,961.8	0.0	2,961.8	104,700.0	310.1	0.4	0.2	0.6
12/03/2021 14:00	2,959.4	0.0	2,959.4	104,700.0	309.8	0.4	0.2	0.6
12/03/2021 15:00	3,782.7	0.0	3,782.7	104,700.0	396.0	0.5	0.2	0.8
12/03/2021 16:00	4,332.9	174.8	4,415.1	104,700.0	462.3	0.6	0.3	0.9
12/03/2021 17:00	4,848.2	315.5	5,163.7	104,700.0	540.6	0.7	0.3	1.1
12/03/2021 18:00	4,875.2	282.3	5,157.5	104,700.0	540.0	0.7	0.3	1.1
12/03/2021 19:00	4,893.6	261.0	5,154.6	104,700.0	539.7	0.6	0.3	1.1
12/03/2021 20:00	4,902.3	254.5	5,156.8	104,700.0	539.9	0.6	0.3	1.1
12/03/2021 21:00	4,898.7	257.5	5,156.2	104,700.0	539.9	0.6	0.3	1.1
12/03/2021 22:00	4,904.5	261.0	5,165.5	104,700.0	540.8	0.7	0.3	1.1
12/03/2021 23:00	4,147.8	125.3	4,213.0	104,700.0	441.1	0.5	0.3	0.9
Average/Sum#:	3,790.0	80.5	3,864.2	104,700.0	404.6	0.5	0.2	0.8
Minimum:	2,959.4	0.0	2,959.4	104,700.0	309.8	0.4	0.2	0.6
Maximum:	4,904.5	315.5	5,165.5	104,700.0	540.8	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/04/2021 00:00	2,961.8	0.0	2,961.8	104,700.0	310.1	0.4	0.2	0.6
12/04/2021 01:00	2,967.5	0.0	2,967.5	104,700.0	310.7	0.4	0.2	0.6
12/04/2021 02:00	2,979.5	0.0	2,979.5	104,700.0	312.0	0.4	0.2	0.6
12/04/2021 03:00	3,180.5	0.0	3,180.5	104,700.0	333.0	0.4	0.2	0.7
12/04/2021 04:00	3,606.9	0.0	3,606.9	104,700.0	377.6	0.5	0.2	0.8
12/04/2021 05:00	3,456.3	0.0	3,456.3	104,700.0	361.9	0.4	0.2	0.7
12/04/2021 06:00	3,348.3	0.0	3,348.3	104,700.0	350.6	0.4	0.2	0.7
12/04/2021 07:00	3,743.5	0.0	3,743.5	104,700.0	391.9	0.5	0.2	0.8
12/04/2021 08:00	3,361.1	0.0	3,361.1	104,700.0	351.9	0.4	0.2	0.7
12/04/2021 09:00	4,156.8	0.0	4,156.8	104,700.0	435.2	0.5	0.3	0.9
12/04/2021 10:00	3,419.7	0.0	3,419.7	104,700.0	358.0	0.4	0.2	0.7
12/04/2021 11:00	4,275.8	0.0	4,275.8	104,700.0	447.7	0.5	0.3	0.9
12/04/2021 12:00	2,969.0	0.0	2,969.0	104,700.0	310.9	0.4	0.2	0.6
12/04/2021 13:00	3,240.8	0.0	3,240.8	104,700.0	339.3	0.4	0.2	0.7
12/04/2021 14:00	3,091.6	0.0	3,091.6	104,700.0	323.7	0.4	0.2	0.6
12/04/2021 15:00	3,512.3	0.0	3,512.3	104,700.0	367.7	0.4	0.2	0.7
12/04/2021 16:00	4,258.4	0.0	4,258.4	104,700.0	445.9	0.5	0.3	0.9
12/04/2021 17:00	4,788.9	86.7	4,834.0	104,700.0	506.1	0.6	0.3	1.0
12/04/2021 18:00	4,939.1	155.4	5,094.5	104,700.0	533.4	0.6	0.3	1.1
12/04/2021 19:00	4,949.9	149.4	5,099.3	104,700.0	533.9	0.6	0.3	1.1
12/04/2021 20:00	4,945.0	157.8	5,102.8	104,700.0	534.3	0.6	0.3	1.1
12/04/2021 21:00	4,939.2	159.4	5,098.6	104,700.0	533.8	0.6	0.3	1.1
12/04/2021 22:00	3,169.5	0.5	3,169.5	104,700.0	331.8	0.4	0.2	0.7
12/04/2021 23:00	2,968.6	0.0	2,968.6	104,700.0	310.8	0.4	0.2	0.6
Average/Sum#:	3,717.9	29.6	3,745.7	104,700.0	392.2	0.5	0.2	0.8
Minimum:	2,961.8	0.0	2,961.8	104,700.0	310.1	0.4	0.2	0.6
Maximum:	4,949.9	159.4	5,102.8	104,700.0	534.3	0.6	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/05/2021 00:00	2,971.9	0.0	2,971.9	104,700.0	311.2	0.4	0.2	0.6
12/05/2021 01:00	2,972.8	0.0	2,972.8	104,700.0	311.3	0.4	0.2	0.6
12/05/2021 02:00	2,973.6	0.0	2,973.6	104,700.0	311.3	0.4	0.2	0.6
12/05/2021 03:00	2,976.2	0.0	2,976.2	104,700.0	311.6	0.4	0.2	0.6
12/05/2021 04:00	2,992.4	0.0	2,992.4	104,700.0	313.3	0.4	0.2	0.6
12/05/2021 05:00	2,985.0	0.0	2,985.0	104,700.0	312.5	0.4	0.2	0.6
12/05/2021 06:00	3,549.8	0.0	3,549.8	104,700.0	371.7	0.4	0.2	0.7
12/05/2021 07:00	3,400.7	0.0	3,400.7	104,700.0	356.1	0.4	0.2	0.7
12/05/2021 08:00	4,122.6	0.0	4,122.6	104,700.0	431.6	0.5	0.3	0.9
12/05/2021 09:00	4,775.7	0.0	4,775.7	104,700.0	500.0	0.6	0.3	1.0
12/05/2021 10:00	4,763.6	0.0	4,763.6	104,700.0	498.7	0.6	0.3	1.0
12/05/2021 11:00	4,555.6	0.0	4,555.6	104,700.0	477.0	0.6	0.3	1.0
12/05/2021 12:00	2,992.1	0.0	2,992.1	104,700.0	313.3	0.4	0.2	0.6
12/05/2021 13:00	3,748.0	0.0	3,748.0	104,700.0	392.4	0.5	0.2	0.8
12/05/2021 14:00	3,282.9	0.0	3,282.9	104,700.0	343.7	0.4	0.2	0.7
12/05/2021 15:00	3,143.8	0.0	3,143.8	104,700.0	329.2	0.4	0.2	0.7
12/05/2021 16:00	3,542.1	0.0	3,542.1	104,700.0	370.9	0.4	0.2	0.7
12/05/2021 17:00	3,729.9	0.0	3,729.9	104,700.0	390.5	0.5	0.2	0.8
12/05/2021 18:00	4,539.8	0.0	4,539.8	104,700.0	475.3	0.6	0.3	1.0
12/05/2021 19:00	4,789.4	0.0	4,789.4	104,700.0	501.5	0.6	0.3	1.0
12/05/2021 20:00	4,793.7	0.0	4,793.7	104,700.0	501.9	0.6	0.3	1.0
12/05/2021 21:00	4,593.8	0.0	4,593.8	104,700.0	481.0	0.6	0.3	1.0
12/05/2021 22:00	4,642.9	0.0	4,642.9	104,700.0	486.1	0.6	0.3	1.0
12/05/2021 23:00	3,920.3	0.0	3,920.3	104,700.0	410.5	0.5	0.2	0.8
Average/Sum#:	3,781.6	0.0	3,781.6	104,700.0	395.9	0.5	0.2	0.8
Minimum:	2,971.9	0.0	2,971.9	104,700.0	311.2	0.4	0.2	0.6
Maximum:	4,793.7	0.0	4,793.7	104,700.0	501.9	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/06/2021 00:00	3,431.1	0.0	3,431.1	104,700.0	359.2	0.4	0.2	0.7
12/06/2021 01:00	2,994.8	0.0	2,994.8	104,700.0	313.6	0.4	0.2	0.6
12/06/2021 02:00	2,983.1	0.0	2,983.1	104,700.0	312.3	0.4	0.2	0.6
12/06/2021 03:00	2,995.5	0.0	2,995.5	104,700.0	313.6	0.4	0.2	0.6
12/06/2021 04:00	2,989.1	0.0	2,989.1	104,700.0	313.0	0.4	0.2	0.6
12/06/2021 05:00	3,814.3	0.0	3,814.3	104,700.0	399.4	0.5	0.2	0.8
12/06/2021 06:00	4,731.6	0.0	4,731.6	104,700.0	495.4	0.6	0.3	1.0
12/06/2021 07:00	4,795.3	0.0	4,795.3	104,700.0	502.1	0.6	0.3	1.0
12/06/2021 08:00	4,750.0	0.0	4,750.0	104,700.0	497.3	0.6	0.3	1.0
12/06/2021 09:00	4,791.3	0.0	4,791.3	104,700.0	501.6	0.6	0.3	1.0
12/06/2021 10:00	4,791.5	0.0	4,791.5	104,700.0	501.7	0.6	0.3	1.0
12/06/2021 11:00	4,785.9	0.0	4,785.9	104,700.0	501.1	0.6	0.3	1.0
12/06/2021 12:00	4,782.3	0.0	4,782.3	104,700.0	500.7	0.6	0.3	1.0
12/06/2021 13:00	4,785.8	0.0	4,785.8	104,700.0	501.1	0.6	0.3	1.0
12/06/2021 14:00	4,784.6	0.0	4,784.6	104,700.0	500.9	0.6	0.3	1.0
12/06/2021 15:00	4,785.5	0.0	4,785.5	104,700.0	501.0	0.6	0.3	1.0
12/06/2021 16:00	4,843.0	248.4	4,974.7	104,700.0	520.9	0.6	0.3	1.1
12/06/2021 17:00	4,933.9	236.1	5,170.0	104,700.0	541.3	0.6	0.3	1.1
12/06/2021 18:00	4,928.0	367.4	5,295.4	104,700.0	554.4	0.7	0.3	1.1
12/06/2021 19:00	4,918.9	243.6	5,162.5	104,700.0	540.5	0.6	0.3	1.1
12/06/2021 20:00	4,921.2	318.0	5,239.2	104,700.0	548.5	0.7	0.3	1.1
12/06/2021 21:00	4,927.3	263.1	5,190.4	104,700.0	543.4	0.7	0.3	1.1
12/06/2021 22:00	4,844.9	172.3	4,970.7	104,700.0	520.4	0.6	0.3	1.1
12/06/2021 23:00	4,750.4	0.0	4,750.4	104,700.0	497.4	0.6	0.3	1.0
Average/Sum#:	4,419.1	77.0	4,489.4	104,700.0	470.0	0.6	0.3	0.9
Minimum:	2,983.1	0.0	2,983.1	104,700.0	312.3	0.4	0.2	0.6
Maximum:	4,933.9	367.4	5,295.4	104,700.0	554.4	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/07/2021 00:00	4,303.4	0.0	4,303.4	104,700.0	450.6	0.5	0.3	0.9
12/07/2021 01:00	3,414.1	0.0	3,414.1	104,700.0	357.5	0.4	0.2	0.7
12/07/2021 02:00	2,978.6	0.0	2,978.6	104,500.0	311.3	0.4	0.2	0.6
12/07/2021 03:00	2,979.6	0.0	2,979.6	104,500.0	311.4	0.4	0.2	0.6
12/07/2021 04:00	3,599.8	0.0	3,599.8	104,500.0	376.2	0.5	0.2	0.8
12/07/2021 05:00	2,984.8	0.0	2,984.8	104,500.0	311.9	0.4	0.2	0.6
12/07/2021 06:00	3,653.8	0.0	3,653.8	104,500.0	381.8	0.5	0.2	0.8
12/07/2021 07:00	4,787.3	0.0	4,787.3	104,500.0	500.3	0.6	0.3	1.0
12/07/2021 08:00	4,774.2	0.0	4,774.2	104,500.0	498.9	0.6	0.3	1.0
12/07/2021 09:00	4,771.9	0.0	4,771.9	104,500.0	498.7	0.6	0.3	1.0
12/07/2021 10:00	4,118.5	0.0	4,118.5	104,500.0	430.4	0.5	0.3	0.9
12/07/2021 11:00	3,627.5	0.0	3,627.5	104,500.0	379.1	0.5	0.2	0.8
12/07/2021 12:00	4,387.6	0.0	4,387.6	104,500.0	458.5	0.6	0.3	0.9
12/07/2021 13:00	4,783.1	0.0	4,783.1	104,500.0	499.8	0.6	0.3	1.0
12/07/2021 14:00	4,766.5	0.0	4,766.5	104,500.0	498.1	0.6	0.3	1.0
12/07/2021 15:00	4,645.9	0.0	4,645.9	104,500.0	485.5	0.6	0.3	1.0
12/07/2021 16:00	4,848.2	221.6	4,954.6	104,500.0	517.8	0.6	0.3	1.1
12/07/2021 17:00	4,904.0	265.9	5,169.9	104,500.0	540.3	0.6	0.3	1.1
12/07/2021 18:00	4,907.0	465.5	5,372.5	104,500.0	561.4	0.7	0.3	1.1
12/07/2021 19:00	4,909.3	720.3	5,629.6	104,500.0	588.3	0.7	0.4	1.2
12/07/2021 20:00	4,910.0	316.9	5,226.9	104,500.0	546.2	0.7	0.3	1.1
12/07/2021 21:00	4,909.3	322.0	5,231.3	104,500.0	546.7	0.7	0.3	1.1
12/07/2021 22:00	4,911.4	324.8	5,236.2	104,500.0	547.2	0.7	0.3	1.1
12/07/2021 23:00	4,780.3	199.5	4,933.9	104,500.0	515.6	0.6	0.3	1.0
Average/Sum#:	4,319.0	118.2	4,430.5	104,516.7	463.1	0.6	0.3	0.9
Minimum:	2,978.6	0.0	2,978.6	104,500.0	311.3	0.4	0.2	0.6
Maximum:	4,911.4	720.3	5,629.6	104,700.0	588.3	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/08/2021 00:00	4,101.0	0.0	4,101.0	104,500.0	428.6	0.5	0.3	0.9
12/08/2021 01:00	3,774.5	0.0	3,774.5	104,500.0	394.4	0.5	0.2	0.8
12/08/2021 02:00	2,972.2	0.0	2,972.2	104,500.0	310.6	0.4	0.2	0.6
12/08/2021 03:00	2,996.6	0.0	2,996.6	104,500.0	313.1	0.4	0.2	0.6
12/08/2021 04:00	3,025.5	0.0	3,025.5	104,500.0	316.2	0.4	0.2	0.6
12/08/2021 05:00	3,014.3	0.0	3,014.3	104,500.0	315.0	0.4	0.2	0.6
12/08/2021 06:00	4,409.8	0.0	4,409.8	104,500.0	460.8	0.6	0.3	0.9
12/08/2021 07:00	4,469.6	0.0	4,469.6	104,500.0	467.1	0.6	0.3	0.9
12/08/2021 08:00	3,241.1	0.0	3,241.1	104,500.0	338.7	0.4	0.2	0.7
12/08/2021 09:00	2,974.5	0.0	2,974.5	104,500.0	310.8	0.4	0.2	0.6
12/08/2021 10:00	2,979.4	0.0	2,979.4	104,500.0	311.3	0.4	0.2	0.6
12/08/2021 11:00	4,425.5	139.6	4,492.5	104,500.0	469.5	0.6	0.3	1.0
12/08/2021 12:00	4,403.3	65.1	4,420.9	104,500.0	462.0	0.6	0.3	0.9
12/08/2021 13:00	3,010.5	0.0	3,010.5	104,500.0	314.6	0.4	0.2	0.6
12/08/2021 14:00	2,971.3	0.0	2,971.3	104,500.0	310.5	0.4	0.2	0.6
12/08/2021 15:00	3,083.5	0.0	3,083.5	104,500.0	322.2	0.4	0.2	0.6
12/08/2021 16:00	3,767.1	0.0	3,767.1	104,500.0	393.7	0.5	0.2	0.8
12/08/2021 17:00	4,752.2	0.0	4,752.2	104,500.0	496.6	0.6	0.3	1.0
12/08/2021 18:00	4,581.5	0.0	4,581.5	104,500.0	478.8	0.6	0.3	1.0
12/08/2021 19:00	4,772.7	0.0	4,772.7	104,500.0	498.7	0.6	0.3	1.0
12/08/2021 20:00	4,587.1	0.0	4,587.1	104,500.0	479.4	0.6	0.3	1.0
12/08/2021 21:00	3,896.5	0.0	3,896.5	104,500.0	407.2	0.5	0.2	0.8
12/08/2021 22:00	2,957.8	0.0	2,957.8	104,500.0	309.1	0.4	0.2	0.6
12/08/2021 23:00	2,962.9	0.0	2,962.9	104,500.0	309.6	0.4	0.2	0.6
Average/Sum#:	3,672.1	8.5	3,675.6	104,500.0	384.1	0.5	0.2	0.8
Minimum:	2,957.8	0.0	2,957.8	104,500.0	309.1	0.4	0.2	0.6
Maximum:	4,772.7	139.6	4,772.7	104,500.0	498.7	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/09/2021 00:00	2,981.6	0.0	2,981.6	104,500.0	311.6	0.4	0.2	0.6
12/09/2021 01:00	2,978.0	0.0	2,978.0	104,500.0	311.2	0.4	0.2	0.6
12/09/2021 02:00	2,974.9	0.0	2,974.9	104,500.0	310.9	0.4	0.2	0.6
12/09/2021 03:00	2,982.6	0.0	2,982.6	104,500.0	311.7	0.4	0.2	0.6
12/09/2021 04:00	2,984.1	0.0	2,984.1	104,500.0	311.8	0.4	0.2	0.6
12/09/2021 05:00	2,986.5	0.0	2,986.5	104,500.0	312.1	0.4	0.2	0.6
12/09/2021 06:00	3,874.3	0.0	3,874.3	104,500.0	404.9	0.5	0.2	0.8
12/09/2021 07:00	3,423.8	0.0	3,423.8	104,500.0	357.8	0.4	0.2	0.7
12/09/2021 08:00	3,128.6	0.0	3,128.6	104,500.0	326.9	0.4	0.2	0.7
12/09/2021 09:00	3,962.9	0.0	3,962.9	104,500.0	414.1	0.5	0.2	0.8
12/09/2021 10:00	3,462.5	0.0	3,462.5	104,500.0	361.8	0.4	0.2	0.7
12/09/2021 11:00	2,964.5	0.0	2,964.5	104,500.0	309.8	0.4	0.2	0.6
12/09/2021 12:00	3,046.6	0.0	3,046.6	104,500.0	318.4	0.4	0.2	0.6
12/09/2021 13:00	2,953.3	0.0	2,953.3	104,500.0	308.6	0.4	0.2	0.6
12/09/2021 14:00	2,951.2	0.0	2,951.2	104,500.0	308.4	0.4	0.2	0.6
12/09/2021 15:00	3,061.6	0.0	3,061.6	104,500.0	319.9	0.4	0.2	0.6
12/09/2021 16:00	4,042.3	0.0	4,042.3	104,500.0	422.4	0.5	0.3	0.8
12/09/2021 17:00	4,011.1	0.0	4,011.1	104,500.0	419.2	0.5	0.3	0.8
12/09/2021 18:00	3,404.9	0.0	3,404.9	104,500.0	355.8	0.4	0.2	0.7
12/09/2021 19:00	3,816.6	0.0	3,816.6	104,500.0	398.8	0.5	0.2	0.8
12/09/2021 20:00	4,346.6	0.0	4,346.6	104,500.0	454.2	0.5	0.3	0.9
12/09/2021 21:00	4,052.6	0.0	4,052.6	104,500.0	423.5	0.5	0.3	0.8
12/09/2021 22:00	3,389.5	0.0	3,389.5	104,500.0	354.2	0.4	0.2	0.7
12/09/2021 23:00	2,977.3	0.0	2,977.3	104,500.0	311.1	0.4	0.2	0.6
Average/Sum#:	3,364.9	0.0	3,364.9	104,500.0	351.6	0.4	0.2	0.7
Minimum:	2,951.2	0.0	2,951.2	104,500.0	308.4	0.4	0.2	0.6
Maximum:	4,346.6	0.0	4,346.6	104,500.0	454.2	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/10/2021 00:00	3,025.9	0.0	3,025.9	104,500.0	316.2	0.4	0.2	0.6
12/10/2021 01:00	2,997.5	0.0	2,997.5	104,500.0	313.2	0.4	0.2	0.6
12/10/2021 02:00	2,993.2	0.0	2,993.2	104,500.0	312.8	0.4	0.2	0.6
12/10/2021 03:00	2,999.2	0.0	2,999.2	104,500.0	313.4	0.4	0.2	0.6
12/10/2021 04:00	2,988.0	0.0	2,988.0	104,500.0	312.2	0.4	0.2	0.6
12/10/2021 05:00	3,305.8	0.0	3,305.8	104,500.0	345.5	0.4	0.2	0.7
12/10/2021 06:00	4,018.3	0.0	4,018.3	104,500.0	419.9	0.5	0.3	0.8
12/10/2021 07:00	4,714.6	0.0	4,714.6	104,500.0	492.7	0.6	0.3	1.0
12/10/2021 08:00	3,467.4	0.0	3,467.4	104,500.0	362.3	0.4	0.2	0.7
12/10/2021 09:00	2,987.7	0.0	2,987.7	104,500.0	312.2	0.4	0.2	0.6
12/10/2021 10:00	3,301.9	0.0	3,301.9	104,500.0	345.0	0.4	0.2	0.7
12/10/2021 11:00	4,578.8	0.0	4,578.8	104,500.0	478.5	0.6	0.3	1.0
12/10/2021 12:00	3,623.7	0.0	3,623.7	104,500.0	378.7	0.5	0.2	0.8
12/10/2021 13:00	3,017.7	0.0	3,017.7	104,500.0	315.3	0.4	0.2	0.6
12/10/2021 14:00	2,970.5	0.0	2,970.5	104,500.0	310.4	0.4	0.2	0.6
12/10/2021 15:00	3,740.6	0.0	3,740.6	104,500.0	390.9	0.5	0.2	0.8
12/10/2021 16:00	4,652.4	0.0	4,652.4	104,500.0	486.2	0.6	0.3	1.0
12/10/2021 17:00	4,773.8	0.0	4,773.8	104,500.0	498.9	0.6	0.3	1.0
12/10/2021 18:00	4,782.4	0.0	4,782.4	104,500.0	499.8	0.6	0.3	1.0
12/10/2021 19:00	4,783.3	0.0	4,783.3	104,500.0	499.9	0.6	0.3	1.0
12/10/2021 20:00	4,801.7	0.0	4,801.7	104,500.0	501.8	0.6	0.3	1.0
12/10/2021 21:00	4,790.3	0.0	4,790.3	104,500.0	500.6	0.6	0.3	1.0
12/10/2021 22:00	4,793.1	0.0	4,793.1	104,500.0	500.9	0.6	0.3	1.0
12/10/2021 23:00	4,780.9	0.0	4,780.9	104,500.0	499.6	0.6	0.3	1.0
Average/Sum#:	3,870.4	0.0	3,870.4	104,500.0	404.5	0.5	0.2	0.8
Minimum:	2,970.5	0.0	2,970.5	104,500.0	310.4	0.4	0.2	0.6
Maximum:	4,801.7	0.0	4,801.7	104,500.0	501.8	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/11/2021 00:00	3,651.8	0.0	3,651.8	104,500.0	381.6	0.5	0.2	0.8
12/11/2021 01:00	3,010.9	0.0	3,010.9	104,500.0	314.6	0.4	0.2	0.6
12/11/2021 02:00	3,011.1	0.0	3,011.1	104,500.0	314.7	0.4	0.2	0.6
12/11/2021 03:00	3,003.8	0.0	3,003.8	104,500.0	313.9	0.4	0.2	0.6
12/11/2021 04:00	3,004.6	0.0	3,004.6	104,500.0	314.0	0.4	0.2	0.6
12/11/2021 05:00	3,013.0	0.0	3,013.0	104,500.0	314.9	0.4	0.2	0.6
12/11/2021 06:00	3,305.3	0.0	3,305.3	104,500.0	345.4	0.4	0.2	0.7
12/11/2021 07:00	3,429.8	0.0	3,429.8	104,500.0	358.4	0.4	0.2	0.7
12/11/2021 08:00	2,987.9	0.0	2,987.9	104,500.0	312.2	0.4	0.2	0.6
12/11/2021 09:00	2,987.5	0.0	2,987.5	104,500.0	312.2	0.4	0.2	0.6
12/11/2021 10:00	2,979.9	0.0	2,979.9	104,500.0	311.4	0.4	0.2	0.6
12/11/2021 11:00	2,977.0	0.0	2,977.0	104,500.0	311.1	0.4	0.2	0.6
12/11/2021 12:00	2,975.4	0.0	2,975.4	104,500.0	310.9	0.4	0.2	0.6
12/11/2021 13:00	2,971.6	0.0	2,971.6	104,500.0	310.5	0.4	0.2	0.6
12/11/2021 14:00	2,968.8	0.0	2,968.8	104,500.0	310.2	0.4	0.2	0.6
12/11/2021 15:00	2,978.4	0.0	2,978.4	104,500.0	311.2	0.4	0.2	0.6
12/11/2021 16:00	4,021.1	0.0	4,021.1	104,500.0	420.2	0.5	0.3	0.8
12/11/2021 17:00	4,438.3	0.0	4,438.3	104,500.0	463.8	0.6	0.3	0.9
12/11/2021 18:00	4,326.0	0.0	4,326.0	104,500.0	452.1	0.5	0.3	0.9
12/11/2021 19:00	4,759.1	0.0	4,759.1	104,500.0	497.3	0.6	0.3	1.0
12/11/2021 20:00	4,748.6	0.0	4,748.6	104,500.0	496.2	0.6	0.3	1.0
12/11/2021 21:00	4,804.1	0.0	4,804.1	104,500.0	502.0	0.6	0.3	1.0
12/11/2021 22:00	4,805.5	0.0	4,805.5	104,500.0	502.2	0.6	0.3	1.0
12/11/2021 23:00	3,813.2	0.0	3,813.2	104,500.0	398.5	0.5	0.2	0.8
Average/Sum#:	3,540.5	0.0	3,540.5	104,500.0	370.0	0.5	0.2	0.7
Minimum:	2,968.8	0.0	2,968.8	104,500.0	310.2	0.4	0.2	0.6
Maximum:	4,805.5	0.0	4,805.5	104,500.0	502.2	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/12/2021 00:00	3,975.3	0.0	3,975.3	104,500.0	415.4	0.5	0.2	0.8
12/12/2021 01:00	2,986.9	0.0	2,986.9	104,500.0	312.1	0.4	0.2	0.6
12/12/2021 02:00	3,018.0	0.0	3,018.0	104,500.0	315.4	0.4	0.2	0.6
12/12/2021 03:00	4,405.3	0.0	4,405.3	104,500.0	460.4	0.6	0.3	0.9
12/12/2021 04:00	3,497.4	0.0	3,497.4	104,500.0	365.5	0.4	0.2	0.7
12/12/2021 05:00	2,998.2	0.0	2,998.2	104,500.0	313.3	0.4	0.2	0.6
12/12/2021 06:00	3,505.4	0.0	3,505.4	104,500.0	366.3	0.4	0.2	0.7
12/12/2021 07:00	3,337.4	0.0	3,337.4	104,500.0	348.8	0.4	0.2	0.7
12/12/2021 08:00	3,328.7	0.0	3,328.7	104,500.0	347.8	0.4	0.2	0.7
12/12/2021 09:00	3,065.1	0.0	3,065.1	104,500.0	320.3	0.4	0.2	0.6
12/12/2021 10:00	2,977.5	0.0	2,977.5	104,500.0	311.1	0.4	0.2	0.6
12/12/2021 11:00	2,973.8	0.0	2,973.8	104,500.0	310.8	0.4	0.2	0.6
12/12/2021 12:00	2,971.2	0.0	2,971.2	104,500.0	310.5	0.4	0.2	0.6
12/12/2021 13:00	2,968.1	0.0	2,968.1	104,500.0	310.2	0.4	0.2	0.6
12/12/2021 14:00	3,022.1	0.0	3,022.1	104,500.0	315.8	0.4	0.2	0.6
12/12/2021 15:00	3,277.5	0.0	3,277.5	104,500.0	342.5	0.4	0.2	0.7
12/12/2021 16:00	4,008.4	0.0	4,008.4	104,500.0	418.9	0.5	0.3	0.8
12/12/2021 17:00	4,374.4	0.0	4,374.4	104,500.0	457.1	0.6	0.3	0.9
12/12/2021 18:00	4,375.8	0.0	4,375.8	104,500.0	457.3	0.6	0.3	0.9
12/12/2021 19:00	4,703.7	0.0	4,703.7	104,500.0	491.5	0.6	0.3	1.0
12/12/2021 20:00	4,507.2	0.0	4,507.2	104,500.0	471.0	0.6	0.3	0.9
12/12/2021 21:00	4,202.1	0.0	4,202.1	104,500.0	439.1	0.5	0.3	0.9
12/12/2021 22:00	3,792.1	0.0	3,792.1	104,500.0	396.3	0.5	0.2	0.8
12/12/2021 23:00	2,971.1	0.0	2,971.1	104,500.0	310.5	0.4	0.2	0.6
Average/Sum#:	3,551.8	0.0	3,551.8	104,500.0	371.2	0.5	0.2	0.7
Minimum:	2,968.1	0.0	2,968.1	104,500.0	310.2	0.4	0.2	0.6
Maximum:	4,703.7	0.0	4,703.7	104,500.0	491.5	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/13/2021 00:00	2,979.2	0.0	2,979.2	104,500.0	311.3	0.4	0.2	0.6
12/13/2021 01:00	2,986.8	0.0	2,986.8	104,500.0	312.1	0.4	0.2	0.6
12/13/2021 02:00	2,984.9	0.0	2,984.9	104,500.0	311.9	0.4	0.2	0.6
12/13/2021 03:00	2,972.0	0.0	2,972.0	104,500.0	310.6	0.4	0.2	0.6
12/13/2021 04:00	2,967.2	0.0	2,967.2	104,500.0	310.1	0.4	0.2	0.6
12/13/2021 05:00	2,966.5	0.0	2,966.5	104,500.0	310.0	0.4	0.2	0.6
12/13/2021 06:00	3,925.8	0.0	3,925.8	104,500.0	410.2	0.5	0.2	0.8
12/13/2021 07:00	4,660.0	0.0	4,660.0	104,500.0	487.0	0.6	0.3	1.0
12/13/2021 08:00	4,562.6	0.0	4,562.6	104,500.0	476.8	0.6	0.3	1.0
12/13/2021 09:00	4,649.6	0.0	4,649.6	104,500.0	485.9	0.6	0.3	1.0
12/13/2021 10:00	4,000.0	0.0	4,000.0	104,500.0	418.0	0.5	0.3	0.8
12/13/2021 11:00	3,290.2	0.0	3,290.2	104,500.0	343.8	0.4	0.2	0.7
12/13/2021 12:00	4,707.8	0.0	4,707.8	104,500.0	492.0	0.6	0.3	1.0
12/13/2021 13:00	4,836.2	0.0	4,836.2	104,500.0	505.4	0.6	0.3	1.0
12/13/2021 14:00	4,775.1	0.0	4,775.1	104,500.0	499.0	0.6	0.3	1.0
12/13/2021 15:00	4,781.9	0.0	4,781.9	104,500.0	499.7	0.6	0.3	1.0
12/13/2021 16:00	4,820.9	442.9	5,033.5	104,500.0	526.0	0.7	0.3	1.1
12/13/2021 17:00	4,853.7	497.6	5,351.3	104,500.0	559.2	0.7	0.3	1.1
12/13/2021 18:00	4,856.6	383.2	5,239.8	104,500.0	547.6	0.7	0.3	1.1
12/13/2021 19:00	4,856.1	385.6	5,241.7	104,500.0	547.8	0.7	0.3	1.1
12/13/2021 20:00	4,853.7	387.1	5,240.8	104,500.0	547.7	0.7	0.3	1.1
12/13/2021 21:00	4,885.1	358.6	5,243.7	104,500.0	548.0	0.7	0.3	1.1
12/13/2021 22:00	4,163.9	136.5	4,234.9	104,500.0	442.5	0.5	0.3	0.9
12/13/2021 23:00	2,976.1	0.0	2,976.1	104,500.0	311.0	0.4	0.2	0.6
Average/Sum#:	4,096.3	108.0	4,192.0	104,500.0	438.1	0.5	0.3	0.9
Minimum:	2,966.5	0.0	2,966.5	104,500.0	310.0	0.4	0.2	0.6
Maximum:	4,885.1	497.6	5,351.3	104,500.0	559.2	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/14/2021 00:00	2,983.7	0.0	2,983.7	104,500.0	311.8	0.4	0.2	0.6
12/14/2021 01:00	2,982.8	0.0	2,982.8	104,500.0	311.7	0.4	0.2	0.6
12/14/2021 02:00	2,979.7	0.0	2,979.7	104,500.0	311.4	0.4	0.2	0.6
12/14/2021 03:00	2,974.4	0.0	2,974.4	104,500.0	310.8	0.4	0.2	0.6
12/14/2021 04:00	2,968.3	0.0	2,968.3	104,500.0	310.2	0.4	0.2	0.6
12/14/2021 05:00	3,482.5	0.0	3,482.5	104,500.0	363.9	0.4	0.2	0.7
12/14/2021 06:00	4,204.6	0.0	4,204.6	104,500.0	439.4	0.5	0.3	0.9
12/14/2021 07:00	3,168.5	0.0	3,168.5	104,500.0	331.1	0.4	0.2	0.7
12/14/2021 08:00	3,004.5	0.0	3,004.5	104,500.0	314.0	0.4	0.2	0.6
12/14/2021 09:00	2,974.8	0.0	2,974.8	104,500.0	310.9	0.4	0.2	0.6
12/14/2021 10:00	2,972.6	0.0	2,972.6	104,500.0	310.6	0.4	0.2	0.6
12/14/2021 11:00	2,971.2	0.0	2,971.2	104,500.0	310.5	0.4	0.2	0.6
12/14/2021 12:00	2,964.7	0.0	2,964.7	104,500.0	309.8	0.4	0.2	0.6
12/14/2021 13:00	2,963.4	0.0	2,963.4	104,500.0	309.7	0.4	0.2	0.6
12/14/2021 14:00	2,962.6	0.0	2,962.6	104,500.0	309.6	0.4	0.2	0.6
12/14/2021 15:00	2,970.1	0.0	2,970.1	104,500.0	310.4	0.4	0.2	0.6
12/14/2021 16:00	3,322.3	0.0	3,322.3	104,500.0	347.2	0.4	0.2	0.7
12/14/2021 17:00	4,554.2	0.0	4,554.2	104,500.0	475.9	0.6	0.3	1.0
12/14/2021 18:00	4,441.5	0.0	4,441.5	104,500.0	464.1	0.6	0.3	0.9
12/14/2021 19:00	4,599.1	0.0	4,599.1	104,500.0	480.6	0.6	0.3	1.0
12/14/2021 20:00	4,792.6	0.0	4,792.6	104,500.0	500.8	0.6	0.3	1.0
12/14/2021 21:00	4,777.5	0.0	4,777.5	104,500.0	499.2	0.6	0.3	1.0
12/14/2021 22:00	4,371.1	0.0	4,371.1	104,500.0	456.8	0.5	0.3	0.9
12/14/2021 23:00	2,985.7	0.0	2,985.7	104,500.0	312.0	0.4	0.2	0.6
Average/Sum#:	3,473.9	0.0	3,473.9	104,500.0	363.0	0.5	0.2	0.7
Minimum:	2,962.6	0.0	2,962.6	104,500.0	309.6	0.4	0.2	0.6
Maximum:	4,792.6	0.0	4,792.6	104,500.0	500.8	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/15/2021 00:00	3,090.0	0.0	3,090.0	104,500.0	322.9	0.4	0.2	0.6
12/15/2021 01:00	2,983.0	0.0	2,983.0	104,500.0	311.7	0.4	0.2	0.6
12/15/2021 02:00	2,986.7	0.0	2,986.7	104,500.0	312.1	0.4	0.2	0.6
12/15/2021 03:00	2,985.9	0.0	2,985.9	104,500.0	312.0	0.4	0.2	0.6
12/15/2021 04:00	3,933.6	0.0	3,933.6	104,500.0	411.1	0.5	0.2	0.8
12/15/2021 05:00	4,802.7	0.0	4,802.7	104,500.0	501.9	0.6	0.3	1.0
12/15/2021 06:00	4,792.5	0.0	4,792.5	104,500.0	500.8	0.6	0.3	1.0
12/15/2021 07:00	4,387.1	0.0	4,387.1	104,500.0	458.5	0.6	0.3	0.9
12/15/2021 08:00	3,145.4	0.0	3,145.4	104,500.0	328.7	0.4	0.2	0.7
12/15/2021 09:00	2,996.5	0.0	2,996.5	104,500.0	313.1	0.4	0.2	0.6
12/15/2021 10:00	2,993.8	0.0	2,993.8	104,500.0	312.9	0.4	0.2	0.6
12/15/2021 11:00	3,132.8	0.0	3,132.8	104,500.0	327.4	0.4	0.2	0.7
12/15/2021 12:00	4,128.4	0.0	4,128.4	104,500.0	431.4	0.5	0.3	0.9
12/15/2021 13:00	3,874.7	0.0	3,874.7	104,500.0	404.9	0.5	0.2	0.8
12/15/2021 14:00	2,971.1	0.0	2,971.1	104,500.0	310.5	0.4	0.2	0.6
12/15/2021 15:00	3,398.8	0.0	3,398.8	104,500.0	355.2	0.4	0.2	0.7
12/15/2021 16:00	4,176.4	0.0	4,176.4	104,500.0	436.4	0.5	0.3	0.9
12/15/2021 17:00	4,787.9	0.0	4,787.9	104,500.0	500.3	0.6	0.3	1.0
12/15/2021 18:00	4,736.3	0.0	4,736.3	104,500.0	494.9	0.6	0.3	1.0
12/15/2021 19:00	4,755.6	0.0	4,755.6	104,500.0	497.0	0.6	0.3	1.0
12/15/2021 20:00	4,813.7	0.0	4,813.7	104,500.0	503.0	0.6	0.3	1.0
12/15/2021 21:00	4,621.7	0.0	4,621.7	104,500.0	483.0	0.6	0.3	1.0
12/15/2021 22:00	4,471.7	0.0	4,471.7	104,500.0	467.3	0.6	0.3	0.9
12/15/2021 23:00	4,351.3	0.0	4,351.3	104,500.0	454.7	0.5	0.3	0.9
Average/Sum#:	3,888.2	0.0	3,888.2	104,500.0	406.3	0.5	0.3	0.8
Minimum:	2,971.1	0.0	2,971.1	104,500.0	310.5	0.4	0.2	0.6
Maximum:	4,813.7	0.0	4,813.7	104,500.0	503.0	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/16/2021 00:00	4,399.9	0.0	4,399.9	104,500.0	459.8	0.6	0.3	0.9
12/16/2021 01:00	3,835.8	0.0	3,835.8	104,500.0	400.8	0.5	0.2	0.8
12/16/2021 02:00	2,979.1	0.0	2,979.1	104,500.0	311.3	0.4	0.2	0.6
12/16/2021 03:00	2,983.0	0.0	2,983.0	104,500.0	311.7	0.4	0.2	0.6
12/16/2021 04:00	4,194.9	139.0	4,257.5	104,500.0	444.9	0.5	0.3	0.9
12/16/2021 05:00	4,956.9	208.4	5,165.3	104,500.0	539.8	0.6	0.3	1.1
12/16/2021 06:00	4,970.7	261.9	5,232.6	104,500.0	546.8	0.7	0.3	1.1
12/16/2021 07:00	4,983.1	270.7	5,253.8	104,500.0	549.0	0.7	0.3	1.1
12/16/2021 08:00	4,979.0	171.5	5,150.5	104,500.0	538.2	0.6	0.3	1.1
12/16/2021 09:00	4,864.8	130.5	4,953.5	104,500.0	517.6	0.6	0.3	1.0
12/16/2021 10:00	4,963.4	196.0	5,159.4	104,500.0	539.2	0.6	0.3	1.1
12/16/2021 11:00	4,146.7	58.4	4,165.4	104,500.0	435.3	0.5	0.3	0.9
12/16/2021 12:00	2,970.8	0.0	2,970.8	104,500.0	310.4	0.4	0.2	0.6
12/16/2021 13:00	3,032.2	0.0	3,032.2	104,500.0	316.9	0.4	0.2	0.6
12/16/2021 14:00	3,595.5	0.0	3,595.5	104,500.0	375.7	0.5	0.2	0.8
12/16/2021 15:00	4,280.7	242.6	4,409.3	104,500.0	460.8	0.6	0.3	0.9
12/16/2021 16:00	4,959.6	219.3	5,178.9	104,500.0	541.2	0.6	0.3	1.1
12/16/2021 17:00	4,978.0	131.4	5,109.4	104,500.0	533.9	0.6	0.3	1.1
12/16/2021 18:00	4,994.1	105.9	5,100.0	104,500.0	533.0	0.6	0.3	1.1
12/16/2021 19:00	5,008.1	194.3	5,202.4	104,500.0	543.7	0.7	0.3	1.1
12/16/2021 20:00	5,016.0	95.1	5,111.1	104,500.0	534.1	0.6	0.3	1.1
12/16/2021 21:00	5,025.1	1,107.4	6,132.5	104,500.0	640.8	0.8	0.4	1.3
12/16/2021 22:00	5,025.0	294.4	5,319.4	104,500.0	555.9	0.7	0.3	1.1
12/16/2021 23:00	3,726.1	10.4	3,728.9	104,500.0	389.7	0.5	0.2	0.8
Average/Sum#:	4,369.5	159.9	4,517.8	104,500.0	472.1	0.6	0.3	1.0
Minimum:	2,970.8	0.0	2,970.8	104,500.0	310.4	0.4	0.2	0.6
Maximum:	5,025.1	1,107.4	6,132.5	104,500.0	640.8	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/17/2021 00:00	2,985.6	0.0	2,985.6	104,500.0	312.0	0.4	0.2	0.6
12/17/2021 01:00	3,020.4	0.0	3,020.4	104,500.0	315.6	0.4	0.2	0.6
12/17/2021 02:00	3,030.2	0.0	3,030.2	104,500.0	316.7	0.4	0.2	0.6
12/17/2021 03:00	3,028.6	0.0	3,028.6	104,500.0	316.5	0.4	0.2	0.6
12/17/2021 04:00	4,264.8	85.2	4,305.7	104,500.0	449.9	0.5	0.3	0.9
12/17/2021 05:00	5,020.0	127.3	5,147.3	104,500.0	537.9	0.6	0.3	1.1
12/17/2021 06:00	5,049.8	237.7	5,287.5	104,500.0	552.5	0.7	0.3	1.1
12/17/2021 07:00	5,066.5	243.6	5,293.0	104,500.0	553.1	0.7	0.3	1.1
12/17/2021 08:00	4,238.6	44.2	4,261.6	104,500.0	445.3	0.5	0.3	0.9
12/17/2021 09:00	3,020.2	0.0	3,020.2	104,500.0	315.6	0.4	0.2	0.6
12/17/2021 10:00	3,023.1	0.0	3,023.1	104,500.0	315.9	0.4	0.2	0.6
12/17/2021 11:00	2,999.3	0.0	2,999.3	104,500.0	313.4	0.4	0.2	0.6
12/17/2021 12:00	2,996.7	0.0	2,996.7	104,500.0	313.2	0.4	0.2	0.6
12/17/2021 13:00	2,995.4	0.0	2,995.4	104,500.0	313.0	0.4	0.2	0.6
12/17/2021 14:00	2,985.3	0.0	2,985.3	104,500.0	312.0	0.4	0.2	0.6
12/17/2021 15:00	4,134.1	115.9	4,180.5	104,500.0	436.9	0.5	0.3	0.9
12/17/2021 16:00	4,996.9	247.8	5,244.7	104,500.0	548.1	0.7	0.3	1.1
12/17/2021 17:00	5,029.7	88.5	5,118.2	104,500.0	534.9	0.6	0.3	1.1
12/17/2021 18:00	5,036.4	10.4	5,046.8	104,500.0	527.4	0.6	0.3	1.1
12/17/2021 19:00	5,030.4	9.2	5,039.6	104,500.0	526.6	0.6	0.3	1.1
12/17/2021 20:00	5,032.4	25.0	5,057.4	104,500.0	528.5	0.6	0.3	1.1
12/17/2021 21:00	5,033.6	9.4	5,043.0	104,500.0	527.0	0.6	0.3	1.1
12/17/2021 22:00	5,039.9	10.9	5,050.8	104,500.0	527.8	0.6	0.3	1.1
12/17/2021 23:00	4,293.9	9.7	4,298.9	104,500.0	449.2	0.5	0.3	0.9
Average/Sum#:	4,056.3	52.7	4,102.5	104,500.0	428.7	0.5	0.3	0.9
Minimum:	2,985.3	0.0	2,985.3	104,500.0	312.0	0.4	0.2	0.6
Maximum:	5,066.5	247.8	5,293.0	104,500.0	553.1	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/18/2021 00:00	4,165.7	0.0	4,165.7	104,500.0	435.3	0.5	0.3	0.9
12/18/2021 01:00	4,397.2	0.0	4,397.2	104,500.0	459.5	0.6	0.3	0.9
12/18/2021 02:00	4,218.0	0.0	4,218.0	104,500.0	440.8	0.5	0.3	0.9
12/18/2021 03:00	3,507.9	0.0	3,507.9	104,500.0	366.6	0.4	0.2	0.7
12/18/2021 04:00	4,031.0	0.0	4,031.0	104,500.0	421.2	0.5	0.3	0.8
12/18/2021 05:00	4,271.1	64.6	4,296.9	104,500.0	449.0	0.5	0.3	0.9
12/18/2021 06:00	5,048.8	40.4	5,089.2	104,500.0	531.8	0.6	0.3	1.1
12/18/2021 07:00	4,095.2	5.7	4,096.7	104,500.0	428.1	0.5	0.3	0.9
12/18/2021 08:00	3,245.7	0.0	3,245.7	104,500.0	339.2	0.4	0.2	0.7
12/18/2021 09:00	3,179.5	0.0	3,179.5	104,500.0	332.3	0.4	0.2	0.7
12/18/2021 10:00	4,770.2	0.0	4,770.2	104,500.0	498.5	0.6	0.3	1.0
12/18/2021 11:00	3,729.8	0.0	3,729.8	104,500.0	389.8	0.5	0.2	0.8
12/18/2021 12:00	2,994.5	0.0	2,994.5	104,500.0	312.9	0.4	0.2	0.6
12/18/2021 13:00	2,999.4	0.0	2,999.4	104,500.0	313.4	0.4	0.2	0.6
12/18/2021 14:00	2,993.5	0.0	2,993.5	104,500.0	312.8	0.4	0.2	0.6
12/18/2021 15:00	3,265.1	0.0	3,265.1	104,500.0	341.2	0.4	0.2	0.7
12/18/2021 16:00	4,318.2	85.7	4,359.3	104,500.0	455.5	0.6	0.3	0.9
12/18/2021 17:00	5,032.0	70.2	5,102.2	104,500.0	533.2	0.6	0.3	1.1
12/18/2021 18:00	5,027.7	69.7	5,097.4	104,500.0	532.7	0.6	0.3	1.1
12/18/2021 19:00	5,027.8	73.4	5,101.2	104,500.0	533.1	0.6	0.3	1.1
12/18/2021 20:00	5,027.9	74.7	5,102.6	104,500.0	533.2	0.6	0.3	1.1
12/18/2021 21:00	5,030.4	93.0	5,123.4	104,500.0	535.4	0.6	0.3	1.1
12/18/2021 22:00	5,025.2	92.8	5,118.0	104,500.0	534.8	0.6	0.3	1.1
12/18/2021 23:00	3,759.8	18.8	3,764.9	104,500.0	393.4	0.5	0.2	0.8
Average/Sum#:	4,131.7	28.7	4,156.2	104,500.0	434.3	0.5	0.3	0.9
Minimum:	2,993.5	0.0	2,993.5	104,500.0	312.8	0.4	0.2	0.6
Maximum:	5,048.8	93.0	5,123.4	104,500.0	535.4	0.6	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/19/2021 00:00	4,382.6	0.0	4,382.6	104,500.0	458.0	0.5	0.3	0.9
12/19/2021 01:00	4,365.4	0.0	4,365.4	104,500.0	456.2	0.5	0.3	0.9
12/19/2021 02:00	4,189.3	0.0	4,189.3	104,500.0	437.8	0.5	0.3	0.9
12/19/2021 03:00	2,997.8	0.0	2,997.8	104,500.0	313.3	0.4	0.2	0.6
12/19/2021 04:00	2,983.1	0.0	2,983.1	104,500.0	311.7	0.4	0.2	0.6
12/19/2021 05:00	4,144.8	65.4	4,171.0	104,500.0	435.9	0.5	0.3	0.9
12/19/2021 06:00	4,338.5	38.6	4,358.6	104,500.0	455.5	0.5	0.3	0.9
12/19/2021 07:00	3,315.3	0.0	3,315.3	104,500.0	346.4	0.4	0.2	0.7
12/19/2021 08:00	2,988.8	0.0	2,988.8	104,500.0	312.3	0.4	0.2	0.6
12/19/2021 09:00	4,178.9	0.0	4,178.9	104,500.0	436.7	0.5	0.3	0.9
12/19/2021 10:00	4,613.6	0.0	4,613.6	104,500.0	482.1	0.6	0.3	1.0
12/19/2021 11:00	3,288.2	0.0	3,288.2	104,500.0	343.6	0.4	0.2	0.7
12/19/2021 12:00	2,980.8	0.0	2,980.8	104,500.0	311.5	0.4	0.2	0.6
12/19/2021 13:00	3,021.8	0.0	3,021.8	104,500.0	315.8	0.4	0.2	0.6
12/19/2021 14:00	3,452.1	0.0	3,452.1	104,500.0	360.7	0.4	0.2	0.7
12/19/2021 15:00	4,291.5	197.3	4,390.2	104,500.0	458.8	0.6	0.3	0.9
12/19/2021 16:00	4,998.0	131.8	5,129.8	104,500.0	536.1	0.6	0.3	1.1
12/19/2021 17:00	5,015.9	117.2	5,133.1	104,500.0	536.4	0.6	0.3	1.1
12/19/2021 18:00	5,030.2	46.1	5,076.3	104,500.0	530.5	0.6	0.3	1.1
12/19/2021 19:00	5,030.2	29.5	5,059.7	104,500.0	528.7	0.6	0.3	1.1
12/19/2021 20:00	5,027.3	116.7	5,144.0	104,500.0	537.5	0.6	0.3	1.1
12/19/2021 21:00	5,028.8	84.8	5,113.6	104,500.0	534.4	0.6	0.3	1.1
12/19/2021 22:00	4,676.2	75.1	4,715.3	104,500.0	492.7	0.6	0.3	1.0
12/19/2021 23:00	4,072.9	0.0	4,072.9	104,500.0	425.6	0.5	0.3	0.9
Average/Sum#:	4,100.5	37.6	4,130.1	104,500.0	431.6	0.5	0.3	0.9
Minimum:	2,980.8	0.0	2,980.8	104,500.0	311.5	0.4	0.2	0.6
Maximum:	5,030.2	197.3	5,144.0	104,500.0	537.5	0.6	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/20/2021 00:00	3,312.7	0.0	3,312.7	104,500.0	346.2	0.4	0.2	0.7
12/20/2021 01:00	3,932.4	0.0	3,932.4	104,500.0	410.9	0.5	0.2	0.8
12/20/2021 02:00	4,010.7	0.0	4,010.7	104,500.0	419.1	0.5	0.3	0.8
12/20/2021 03:00	3,722.1	0.0	3,722.1	104,500.0	389.0	0.5	0.2	0.8
12/20/2021 04:00	3,310.1	0.0	3,310.1	104,500.0	345.9	0.4	0.2	0.7
12/20/2021 05:00	4,693.1	213.8	4,815.0	104,500.0	503.2	0.6	0.3	1.0
12/20/2021 06:00	5,071.5	175.4	5,246.9	104,500.0	548.3	0.7	0.3	1.1
12/20/2021 07:00	4,920.9	135.9	5,025.5	104,500.0	525.2	0.6	0.3	1.1
12/20/2021 08:00	3,989.7	0.0	3,989.7	104,500.0	416.9	0.5	0.3	0.8
12/20/2021 09:00	3,240.7	0.0	3,240.7	104,500.0	338.7	0.4	0.2	0.7
12/20/2021 10:00	3,025.8	0.0	3,025.8	104,500.0	316.2	0.4	0.2	0.6
12/20/2021 11:00	3,482.1	0.0	3,482.1	104,500.0	363.9	0.4	0.2	0.7
12/20/2021 12:00	4,648.1	0.0	4,648.1	104,500.0	485.7	0.6	0.3	1.0
12/20/2021 13:00	4,805.3	0.0	4,805.3	104,500.0	502.2	0.6	0.3	1.0
12/20/2021 14:00	4,983.4	773.0	5,462.7	104,500.0	570.9	0.7	0.4	1.2
12/20/2021 15:00	5,009.5	1,015.2	6,024.7	104,500.0	629.6	0.8	0.4	1.3
12/20/2021 16:00	5,014.6	526.6	5,504.3	104,500.0	575.2	0.7	0.3	1.2
12/20/2021 17:00	5,036.0	1,053.2	6,089.2	104,500.0	636.3	0.8	0.4	1.3
12/20/2021 18:00	5,041.9	689.3	5,731.2	104,500.0	598.9	0.7	0.4	1.2
12/20/2021 19:00	5,041.3	829.9	5,871.2	104,500.0	613.5	0.7	0.4	1.2
12/20/2021 20:00	5,044.5	1,154.5	6,199.0	104,500.0	647.8	0.8	0.4	1.3
12/20/2021 21:00	5,049.5	802.7	5,852.2	104,500.0	611.6	0.7	0.4	1.2
12/20/2021 22:00	5,054.7	666.1	5,674.2	104,500.0	593.0	0.7	0.4	1.2
12/20/2021 23:00	4,956.6	430.9	5,288.4	104,500.0	552.6	0.7	0.3	1.1
Average/Sum#:	4,433.2	352.8	4,761.0	104,500.0	497.5	0.6	0.3	1.0
Minimum:	3,025.8	0.0	3,025.8	104,500.0	316.2	0.4	0.2	0.6
Maximum:	5,071.5	1,154.5	6,199.0	104,500.0	647.8	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/21/2021 00:00	4,797.5	0.0	4,797.5	104,500.0	501.3	0.6	0.3	1.0
12/21/2021 01:00	4,767.6	0.0	4,767.6	104,500.0	498.2	0.6	0.3	1.0
12/21/2021 02:00	4,765.1	0.0	4,765.1	104,500.0	498.0	0.6	0.3	1.0
12/21/2021 03:00	4,528.8	0.0	4,528.8	104,500.0	473.3	0.6	0.3	0.9
12/21/2021 04:00	4,274.9	0.0	4,274.9	104,500.0	446.7	0.5	0.3	0.9
12/21/2021 05:00	4,291.8	0.0	4,291.8	104,500.0	448.5	0.5	0.3	0.9
12/21/2021 06:00	4,617.0	0.0	4,617.0	104,500.0	482.5	0.6	0.3	1.0
12/21/2021 07:00	4,859.3	50.0	4,872.8	104,500.0	509.2	0.6	0.3	1.0
12/21/2021 08:00	5,036.3	1,411.9	6,448.2	104,500.0	673.8	0.8	0.4	1.3
12/21/2021 09:00	5,060.5	1,366.6	6,427.1	104,500.0	671.6	0.8	0.4	1.3
12/21/2021 10:00	5,024.9	43.5	5,061.9	104,500.0	529.0	0.6	0.3	1.1
12/21/2021 11:00	4,175.1	0.0	4,175.1	104,500.0	436.3	0.5	0.3	0.9
12/21/2021 12:00	3,957.9	0.0	3,957.9	104,500.0	413.6	0.5	0.2	0.8
12/21/2021 13:00	4,659.6	0.0	4,659.6	104,500.0	486.9	0.6	0.3	1.0
12/21/2021 14:00	4,893.8	116.0	4,949.5	104,500.0	517.2	0.6	0.3	1.0
12/21/2021 15:00	4,999.6	175.8	5,163.1	104,500.0	539.5	0.6	0.3	1.1
12/21/2021 16:00	5,020.5	194.7	5,215.2	104,500.0	545.0	0.7	0.3	1.1
12/21/2021 17:00	5,021.1	112.8	5,133.9	104,500.0	536.5	0.6	0.3	1.1
12/21/2021 18:00	5,017.9	119.0	5,136.9	104,500.0	536.8	0.6	0.3	1.1
12/21/2021 19:00	5,026.0	110.8	5,136.8	104,500.0	536.8	0.6	0.3	1.1
12/21/2021 20:00	5,041.7	91.2	5,132.9	104,500.0	536.4	0.6	0.3	1.1
12/21/2021 21:00	5,037.8	106.8	5,144.6	104,500.0	537.6	0.6	0.3	1.1
12/21/2021 22:00	5,031.6	132.0	5,163.6	104,500.0	539.6	0.6	0.3	1.1
12/21/2021 23:00	4,220.5	65.9	4,254.8	104,500.0	444.6	0.5	0.3	0.9
Average/Sum#:	4,755.3	170.7	4,919.9	104,500.0	514.1	0.6	0.3	1.0
Minimum:	3,957.9	0.0	3,957.9	104,500.0	413.6	0.5	0.2	0.8
Maximum:	5,060.5	1,411.9	6,448.2	104,500.0	673.8	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/22/2021 00:00	3,000.0	0.0	3,000.0	104,500.0	313.5	0.4	0.2	0.6
12/22/2021 01:00	3,001.2	0.0	3,001.2	104,500.0	313.6	0.4	0.2	0.6
12/22/2021 02:00	2,998.7	0.0	2,998.7	104,500.0	313.4	0.4	0.2	0.6
12/22/2021 03:00	2,994.8	0.0	2,994.8	104,500.0	313.0	0.4	0.2	0.6
12/22/2021 04:00	3,007.0	0.0	3,007.0	104,500.0	314.2	0.4	0.2	0.6
12/22/2021 05:00	4,736.7	164.1	4,851.6	104,500.0	507.0	0.6	0.3	1.0
12/22/2021 06:00	5,015.2	128.8	5,144.0	104,500.0	537.5	0.6	0.3	1.1
12/22/2021 07:00	5,023.9	113.8	5,137.7	104,500.0	536.9	0.6	0.3	1.1
12/22/2021 08:00	5,010.4	149.4	5,159.8	104,500.0	539.2	0.6	0.3	1.1
12/22/2021 09:00	4,999.7	166.0	5,165.7	104,500.0	539.8	0.6	0.3	1.1
12/22/2021 10:00	4,350.1	77.1	4,390.2	104,500.0	458.8	0.6	0.3	0.9
12/22/2021 11:00	2,991.2	0.0	2,991.2	104,500.0	312.6	0.4	0.2	0.6
12/22/2021 12:00	3,001.7	0.0	3,001.7	104,500.0	313.7	0.4	0.2	0.6
12/22/2021 13:00	4,195.8	194.4	4,283.3	104,500.0	447.6	0.6	0.3	0.9
12/22/2021 14:00	4,928.7	356.1	5,284.8	104,500.0	552.3	0.7	0.3	1.1
12/22/2021 15:00	4,922.2	327.2	5,249.4	104,500.0	548.6	0.7	0.3	1.1
12/22/2021 16:00	4,913.0	319.9	5,232.9	104,500.0	546.8	0.7	0.3	1.1
12/22/2021 17:00	4,921.7	317.4	5,239.1	104,500.0	547.5	0.7	0.3	1.1
12/22/2021 18:00	4,923.2	315.0	5,238.2	104,500.0	547.4	0.7	0.3	1.1
12/22/2021 19:00	4,894.8	270.9	5,146.7	104,500.0	537.8	0.6	0.3	1.1
12/22/2021 20:00	3,050.7	0.0	3,050.7	104,500.0	318.8	0.4	0.2	0.6
12/22/2021 21:00	3,057.1	0.0	3,057.1	104,500.0	319.5	0.4	0.2	0.6
12/22/2021 22:00	3,364.8	0.0	3,364.8	104,500.0	351.6	0.4	0.2	0.7
12/22/2021 23:00	3,080.7	0.0	3,080.7	104,500.0	321.9	0.4	0.2	0.6
Average/Sum#:	4,016.0	120.8	4,128.0	104,500.0	431.4	0.5	0.3	0.9
Minimum:	2,991.2	0.0	2,991.2	104,500.0	312.6	0.4	0.2	0.6
Maximum:	5,023.9	356.1	5,284.8	104,500.0	552.3	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/23/2021 00:00	3,967.5	0.0	3,967.5	104,500.0	414.6	0.5	0.2	0.8
12/23/2021 01:00	3,234.7	0.0	3,234.7	104,500.0	338.0	0.4	0.2	0.7
12/23/2021 02:00	3,028.9	0.0	3,028.9	104,500.0	316.5	0.4	0.2	0.6
12/23/2021 03:00	2,988.2	0.0	2,988.2	104,500.0	312.3	0.4	0.2	0.6
12/23/2021 04:00	2,981.2	0.0	2,981.2	104,500.0	311.5	0.4	0.2	0.6
12/23/2021 05:00	2,986.3	0.0	2,986.3	104,500.0	312.1	0.4	0.2	0.6
12/23/2021 06:00	2,995.0	0.0	2,995.0	104,500.0	313.0	0.4	0.2	0.6
12/23/2021 07:00	2,990.1	0.0	2,990.1	104,500.0	312.5	0.4	0.2	0.6
12/23/2021 08:00	2,989.5	0.0	2,989.5	104,500.0	312.4	0.4	0.2	0.6
12/23/2021 09:00	2,988.3	0.0	2,988.3	104,500.0	312.3	0.4	0.2	0.6
12/23/2021 10:00	2,993.4	0.0	2,993.4	104,500.0	312.8	0.4	0.2	0.6
12/23/2021 11:00	2,987.3	0.0	2,987.3	104,500.0	312.2	0.4	0.2	0.6
12/23/2021 12:00	2,981.0	0.0	2,981.0	104,500.0	311.5	0.4	0.2	0.6
12/23/2021 13:00	2,983.5	0.0	2,983.5	104,500.0	311.8	0.4	0.2	0.6
12/23/2021 14:00	2,982.0	0.0	2,982.0	104,500.0	311.6	0.4	0.2	0.6
12/23/2021 15:00	2,982.5	0.0	2,982.5	104,500.0	311.7	0.4	0.2	0.6
12/23/2021 16:00	2,980.4	0.0	2,980.4	104,500.0	311.5	0.4	0.2	0.6
12/23/2021 17:00	2,985.5	0.0	2,985.5	104,500.0	312.0	0.4	0.2	0.6
12/23/2021 18:00	2,991.1	0.0	2,991.1	104,500.0	312.6	0.4	0.2	0.6
12/23/2021 19:00	2,973.4	0.0	2,973.4	104,500.0	310.7	0.4	0.2	0.6
12/23/2021 20:00	2,974.5	0.0	2,974.5	104,500.0	310.8	0.4	0.2	0.6
12/23/2021 21:00	2,970.4	0.0	2,970.4	104,500.0	310.4	0.4	0.2	0.6
12/23/2021 22:00	2,967.9	0.0	2,967.9	104,500.0	310.1	0.4	0.2	0.6
12/23/2021 23:00	2,978.9	0.0	2,978.9	104,500.0	311.3	0.4	0.2	0.6
Average/Sum#:	3,036.7	0.0	3,036.7	104,500.0	317.3	0.4	0.2	0.6
Minimum:	2,967.9	0.0	2,967.9	104,500.0	310.1	0.4	0.2	0.6
Maximum:	3,967.5	0.0	3,967.5	104,500.0	414.6	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/24/2021 00:00	2,986.1	0.0	2,986.1	104,500.0	312.0	0.4	0.2	0.6
12/24/2021 01:00	2,991.6	0.0	2,991.6	104,500.0	312.6	0.4	0.2	0.6
12/24/2021 02:00	2,989.1	0.0	2,989.1	104,500.0	312.4	0.4	0.2	0.6
12/24/2021 03:00	2,986.8	0.0	2,986.8	104,500.0	312.1	0.4	0.2	0.6
12/24/2021 04:00	2,984.7	0.0	2,984.7	104,500.0	311.9	0.4	0.2	0.6
12/24/2021 05:00	2,988.0	0.0	2,988.0	104,500.0	312.2	0.4	0.2	0.6
12/24/2021 06:00	2,987.9	0.0	2,987.9	104,500.0	312.2	0.4	0.2	0.6
12/24/2021 07:00	2,989.7	0.0	2,989.7	104,500.0	312.4	0.4	0.2	0.6
12/24/2021 08:00	3,035.3	0.0	3,035.3	104,500.0	317.2	0.4	0.2	0.6
12/24/2021 09:00	2,985.7	0.0	2,985.7	104,500.0	312.0	0.4	0.2	0.6
12/24/2021 10:00	2,991.0	0.0	2,991.0	104,500.0	312.6	0.4	0.2	0.6
12/24/2021 11:00	2,984.9	0.0	2,984.9	104,500.0	311.9	0.4	0.2	0.6
12/24/2021 12:00	2,983.6	0.0	2,983.6	104,500.0	311.8	0.4	0.2	0.6
12/24/2021 13:00	2,981.1	0.0	2,981.1	104,500.0	311.5	0.4	0.2	0.6
12/24/2021 14:00	2,976.1	0.0	2,976.1	104,500.0	311.0	0.4	0.2	0.6
12/24/2021 15:00	2,978.0	0.0	2,978.0	104,500.0	311.2	0.4	0.2	0.6
12/24/2021 16:00	2,989.6	0.0	2,989.6	104,500.0	312.4	0.4	0.2	0.6
12/24/2021 17:00	2,985.8	0.0	2,985.8	104,500.0	312.0	0.4	0.2	0.6
12/24/2021 18:00	2,983.9	0.0	2,983.9	104,500.0	311.8	0.4	0.2	0.6
12/24/2021 19:00	2,981.7	0.0	2,981.7	104,500.0	311.6	0.4	0.2	0.6
12/24/2021 20:00	2,979.2	0.0	2,979.2	104,500.0	311.3	0.4	0.2	0.6
12/24/2021 21:00	2,981.1	0.0	2,981.1	104,500.0	311.5	0.4	0.2	0.6
12/24/2021 22:00	2,976.7	0.0	2,976.7	104,500.0	311.1	0.4	0.2	0.6
12/24/2021 23:00	2,977.9	0.0	2,977.9	104,500.0	311.2	0.4	0.2	0.6
Average/Sum#:	2,986.5	0.0	2,986.5	104,500.0	312.1	0.4	0.2	0.6
Minimum:	2,976.1	0.0	2,976.1	104,500.0	311.0	0.4	0.2	0.6
Maximum:	3,035.3	0.0	3,035.3	104,500.0	317.2	0.4	0.2	0.6
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/25/2021 00:00	2,981.9	0.0	2,981.9	104,500.0	311.6	0.4	0.2	0.6
12/25/2021 01:00	2,982.4	0.0	2,982.4	104,500.0	311.7	0.4	0.2	0.6
12/25/2021 02:00	2,980.7	0.0	2,980.7	104,500.0	311.5	0.4	0.2	0.6
12/25/2021 03:00	2,979.7	0.0	2,979.7	104,500.0	311.4	0.4	0.2	0.6
12/25/2021 04:00	2,979.3	0.0	2,979.3	104,500.0	311.3	0.4	0.2	0.6
12/25/2021 05:00	2,983.0	0.0	2,983.0	104,500.0	311.7	0.4	0.2	0.6
12/25/2021 06:00	2,978.9	0.0	2,978.9	104,500.0	311.3	0.4	0.2	0.6
12/25/2021 07:00	2,986.8	0.0	2,986.8	104,500.0	312.1	0.4	0.2	0.6
12/25/2021 08:00	2,984.9	0.0	2,984.9	104,500.0	311.9	0.4	0.2	0.6
12/25/2021 09:00	2,986.0	0.0	2,986.0	104,500.0	312.0	0.4	0.2	0.6
12/25/2021 10:00	2,996.0	0.0	2,996.0	104,500.0	313.1	0.4	0.2	0.6
12/25/2021 11:00	3,001.0	0.0	3,001.0	104,500.0	313.6	0.4	0.2	0.6
12/25/2021 12:00	3,002.5	0.0	3,002.5	104,500.0	313.8	0.4	0.2	0.6
12/25/2021 13:00	3,010.5	0.0	3,010.5	104,500.0	314.6	0.4	0.2	0.6
12/25/2021 14:00	3,009.2	0.0	3,009.2	104,500.0	314.5	0.4	0.2	0.6
12/25/2021 15:00	3,126.0	0.0	3,126.0	104,500.0	326.7	0.4	0.2	0.7
12/25/2021 16:00	3,001.3	0.0	3,001.3	104,500.0	313.6	0.4	0.2	0.6
12/25/2021 17:00	2,998.5	0.0	2,998.5	104,500.0	313.3	0.4	0.2	0.6
12/25/2021 18:00	2,991.5	0.0	2,991.5	104,500.0	312.6	0.4	0.2	0.6
12/25/2021 19:00	2,984.6	0.0	2,984.6	104,500.0	311.9	0.4	0.2	0.6
12/25/2021 20:00	2,997.7	0.0	2,997.7	104,500.0	313.3	0.4	0.2	0.6
12/25/2021 21:00	2,992.0	0.0	2,992.0	104,500.0	312.7	0.4	0.2	0.6
12/25/2021 22:00	2,985.3	0.0	2,985.3	104,500.0	312.0	0.4	0.2	0.6
12/25/2021 23:00	2,983.1	0.0	2,983.1	104,500.0	311.7	0.4	0.2	0.6
Average/Sum#:	2,996.0	0.0	2,996.0	104,500.0	313.1	0.4	0.2	0.6
Minimum:	2,978.9	0.0	2,978.9	104,500.0	311.3	0.4	0.2	0.6
Maximum:	3,126.0	0.0	3,126.0	104,500.0	326.7	0.4	0.2	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/26/2021 00:00	2,981.5	0.0	2,981.5	104,500.0	311.6	0.4	0.2	0.6
12/26/2021 01:00	2,983.2	0.0	2,983.2	104,500.0	311.7	0.4	0.2	0.6
12/26/2021 02:00	2,985.6	0.0	2,985.6	104,500.0	312.0	0.4	0.2	0.6
12/26/2021 03:00	3,006.9	0.0	3,006.9	104,500.0	314.2	0.4	0.2	0.6
12/26/2021 04:00	3,006.0	0.0	3,006.0	104,500.0	314.1	0.4	0.2	0.6
12/26/2021 05:00	3,018.5	0.0	3,018.5	104,500.0	315.4	0.4	0.2	0.6
12/26/2021 06:00	3,021.1	0.0	3,021.1	104,500.0	315.7	0.4	0.2	0.6
12/26/2021 07:00	3,060.9	0.0	3,060.9	104,500.0	319.9	0.4	0.2	0.6
12/26/2021 08:00	2,989.6	0.0	2,989.6	104,500.0	312.4	0.4	0.2	0.6
12/26/2021 09:00	3,003.2	0.0	3,003.2	104,500.0	313.8	0.4	0.2	0.6
12/26/2021 10:00	3,004.8	0.0	3,004.8	104,500.0	314.0	0.4	0.2	0.6
12/26/2021 11:00	3,065.7	0.0	3,065.7	104,500.0	320.4	0.4	0.2	0.6
12/26/2021 12:00	3,018.9	0.0	3,018.9	104,500.0	315.5	0.4	0.2	0.6
12/26/2021 13:00	3,235.2	0.0	3,235.2	104,500.0	338.1	0.4	0.2	0.7
12/26/2021 14:00	3,099.2	0.0	3,099.2	104,500.0	323.9	0.4	0.2	0.6
12/26/2021 15:00	3,106.8	0.0	3,106.8	104,500.0	324.7	0.4	0.2	0.6
12/26/2021 16:00	4,216.9	73.2	4,231.5	104,500.0	442.2	0.5	0.3	0.9
12/26/2021 17:00	4,990.1	229.0	5,219.1	104,500.0	545.4	0.7	0.3	1.1
12/26/2021 18:00	3,735.0	51.4	3,748.9	104,500.0	391.8	0.5	0.2	0.8
12/26/2021 19:00	3,027.1	0.0	3,027.1	104,500.0	316.3	0.4	0.2	0.6
12/26/2021 20:00	3,094.5	0.0	3,094.5	104,500.0	323.4	0.4	0.2	0.6
12/26/2021 21:00	4,500.3	0.0	4,500.3	104,500.0	470.3	0.6	0.3	0.9
12/26/2021 22:00	3,351.8	0.0	3,351.8	104,500.0	350.3	0.4	0.2	0.7
12/26/2021 23:00	3,005.7	0.0	3,005.7	104,500.0	314.1	0.4	0.2	0.6
Average/Sum#:	3,271.2	14.7	3,281.9	104,500.0	343.0	0.4	0.2	0.7
Minimum:	2,981.5	0.0	2,981.5	104,500.0	311.6	0.4	0.2	0.6
Maximum:	4,990.1	229.0	5,219.1	104,500.0	545.4	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/27/2021 00:00	3,028.5	0.0	3,028.5	104,500.0	316.5	0.4	0.2	0.6
12/27/2021 01:00	3,013.7	0.0	3,013.7	104,500.0	314.9	0.4	0.2	0.6
12/27/2021 02:00	3,017.2	0.0	3,017.2	104,500.0	315.3	0.4	0.2	0.6
12/27/2021 03:00	3,009.0	0.0	3,009.0	104,500.0	314.4	0.4	0.2	0.6
12/27/2021 04:00	2,994.3	0.0	2,994.3	104,500.0	312.9	0.4	0.2	0.6
12/27/2021 05:00	4,235.4	162.8	4,308.7	104,500.0	450.3	0.6	0.3	0.9
12/27/2021 06:00	4,970.2	247.2	5,217.4	104,500.0	545.2	0.7	0.3	1.1
12/27/2021 07:00	4,971.1	245.6	5,216.7	104,500.0	545.1	0.7	0.3	1.1
12/27/2021 08:00	4,967.2	292.7	5,259.9	104,500.0	549.7	0.7	0.3	1.1
12/27/2021 09:00	4,654.3	175.2	4,745.4	104,500.0	495.9	0.6	0.3	1.0
12/27/2021 10:00	3,713.6	0.0	3,713.6	104,500.0	388.1	0.5	0.2	0.8
12/27/2021 11:00	4,555.9	0.0	4,555.9	104,500.0	476.1	0.6	0.3	1.0
12/27/2021 12:00	2,976.4	0.0	2,976.4	104,500.0	311.0	0.4	0.2	0.6
12/27/2021 13:00	3,154.4	0.0	3,154.4	104,500.0	329.6	0.4	0.2	0.7
12/27/2021 14:00	4,325.6	0.0	4,325.6	104,500.0	452.0	0.5	0.3	0.9
12/27/2021 15:00	4,769.7	180.0	4,863.3	104,500.0	508.2	0.6	0.3	1.0
12/27/2021 16:00	4,939.2	293.5	5,232.7	104,500.0	546.8	0.7	0.3	1.1
12/27/2021 17:00	4,949.5	353.6	5,303.1	104,500.0	554.2	0.7	0.3	1.1
12/27/2021 18:00	4,966.3	397.2	5,363.5	104,500.0	560.5	0.7	0.3	1.1
12/27/2021 19:00	4,974.9	427.4	5,402.3	104,500.0	564.5	0.7	0.3	1.1
12/27/2021 20:00	4,975.5	431.9	5,407.4	104,500.0	565.1	0.7	0.3	1.1
12/27/2021 21:00	4,984.2	212.9	5,197.1	104,500.0	543.1	0.7	0.3	1.1
12/27/2021 22:00	4,578.3	104.8	4,632.8	104,500.0	484.1	0.6	0.3	1.0
12/27/2021 23:00	3,601.2	0.0	3,601.2	104,500.0	376.3	0.5	0.2	0.8
Average/Sum#:	4,180.2	146.9	4,314.2	104,500.0	450.8	0.6	0.3	0.9
Minimum:	2,976.4	0.0	2,976.4	104,500.0	311.0	0.4	0.2	0.6
Maximum:	4,984.2	431.9	5,407.4	104,500.0	565.1	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/28/2021 00:00	3,117.3	0.0	3,117.3	104,500.0	325.8	0.4	0.2	0.7
12/28/2021 01:00	3,017.4	0.0	3,017.4	104,500.0	315.3	0.4	0.2	0.6
12/28/2021 02:00	3,019.8	0.0	3,019.8	104,500.0	315.6	0.4	0.2	0.6
12/28/2021 03:00	3,099.5	0.0	3,099.5	104,500.0	323.9	0.4	0.2	0.6
12/28/2021 04:00	3,018.9	0.0	3,018.9	104,500.0	315.5	0.4	0.2	0.6
12/28/2021 05:00	4,144.6	0.0	4,144.6	104,500.0	433.1	0.5	0.3	0.9
12/28/2021 06:00	4,060.2	0.0	4,060.2	104,500.0	424.3	0.5	0.3	0.8
12/28/2021 07:00	3,101.1	0.0	3,101.1	104,500.0	324.1	0.4	0.2	0.6
12/28/2021 08:00	3,533.2	0.0	3,533.2	104,500.0	369.2	0.4	0.2	0.7
12/28/2021 09:00	3,460.8	0.0	3,460.8	104,500.0	361.7	0.4	0.2	0.7
12/28/2021 10:00	2,993.1	0.0	2,993.1	104,500.0	312.8	0.4	0.2	0.6
12/28/2021 11:00	2,989.3	0.0	2,989.3	104,500.0	312.4	0.4	0.2	0.6
12/28/2021 12:00	2,994.3	0.0	2,994.3	104,500.0	312.9	0.4	0.2	0.6
12/28/2021 13:00	2,981.2	0.0	2,981.2	104,500.0	311.5	0.4	0.2	0.6
12/28/2021 14:00	2,981.5	0.0	2,981.5	104,500.0	311.6	0.4	0.2	0.6
12/28/2021 15:00	3,498.5	0.0	3,498.5	104,500.0	365.6	0.4	0.2	0.7
12/28/2021 16:00	3,922.4	0.0	3,922.4	104,500.0	409.9	0.5	0.2	0.8
12/28/2021 17:00	4,820.6	0.0	4,820.6	104,500.0	503.8	0.6	0.3	1.0
12/28/2021 18:00	4,519.7	0.0	4,519.7	104,500.0	472.3	0.6	0.3	0.9
12/28/2021 19:00	4,109.0	0.0	4,109.0	104,500.0	429.4	0.5	0.3	0.9
12/28/2021 20:00	4,022.6	0.0	4,022.6	104,500.0	420.4	0.5	0.3	0.8
12/28/2021 21:00	3,200.6	0.0	3,200.6	104,500.0	334.5	0.4	0.2	0.7
12/28/2021 22:00	3,051.5	0.0	3,051.5	104,500.0	318.9	0.4	0.2	0.6
12/28/2021 23:00	3,031.7	0.0	3,031.7	104,500.0	316.8	0.4	0.2	0.6
Average/Sum#:	3,445.4	0.0	3,445.4	104,500.0	360.1	0.4	0.2	0.7
Minimum:	2,981.2	0.0	2,981.2	104,500.0	311.5	0.4	0.2	0.6
Maximum:	4,820.6	0.0	4,820.6	104,500.0	503.8	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/29/2021 00:00	3,039.0	0.0	3,039.0	104,500.0	317.6	0.4	0.2	0.6
12/29/2021 01:00	3,031.5	0.0	3,031.5	104,500.0	316.8	0.4	0.2	0.6
12/29/2021 02:00	3,001.4	0.0	3,001.4	104,500.0	313.6	0.4	0.2	0.6
12/29/2021 03:00	2,997.1	0.0	2,997.1	104,500.0	313.2	0.4	0.2	0.6
12/29/2021 04:00	2,997.1	0.0	2,997.1	104,500.0	313.2	0.4	0.2	0.6
12/29/2021 05:00	3,018.4	0.0	3,018.4	104,500.0	315.4	0.4	0.2	0.6
12/29/2021 06:00	3,113.3	0.0	3,113.3	104,500.0	325.3	0.4	0.2	0.7
12/29/2021 07:00	2,999.4	0.0	2,999.4	104,500.0	313.4	0.4	0.2	0.6
12/29/2021 08:00	2,997.8	0.0	2,997.8	104,500.0	313.3	0.4	0.2	0.6
12/29/2021 09:00	2,987.2	0.0	2,987.2	104,500.0	312.2	0.4	0.2	0.6
12/29/2021 10:00	2,984.7	0.0	2,984.7	104,500.0	311.9	0.4	0.2	0.6
12/29/2021 11:00	2,992.1	0.0	2,992.1	104,500.0	312.7	0.4	0.2	0.6
12/29/2021 12:00	3,002.2	0.0	3,002.2	104,500.0	313.7	0.4	0.2	0.6
12/29/2021 13:00	3,139.9	0.0	3,139.9	104,500.0	328.1	0.4	0.2	0.7
12/29/2021 14:00	3,842.6	0.0	3,842.6	104,500.0	401.6	0.5	0.2	0.8
12/29/2021 15:00	3,929.0	0.0	3,929.0	104,500.0	410.6	0.5	0.2	0.8
12/29/2021 16:00	3,880.8	0.0	3,880.8	104,500.0	405.5	0.5	0.2	0.8
12/29/2021 17:00	4,738.8	0.0	4,738.8	104,500.0	495.2	0.6	0.3	1.0
12/29/2021 18:00	4,761.8	0.0	4,761.8	104,500.0	497.6	0.6	0.3	1.0
12/29/2021 19:00	4,824.1	0.0	4,824.1	104,500.0	504.1	0.6	0.3	1.0
12/29/2021 20:00	4,827.2	0.0	4,827.2	104,500.0	504.4	0.6	0.3	1.0
12/29/2021 21:00	3,606.7	0.0	3,606.7	104,500.0	376.9	0.5	0.2	0.8
12/29/2021 22:00	3,034.4	0.0	3,034.4	104,500.0	317.1	0.4	0.2	0.6
12/29/2021 23:00	3,000.0	0.0	3,000.0	104,500.0	313.5	0.4	0.2	0.6
Average/Sum#:	3,447.8	0.0	3,447.8	104,500.0	360.3	0.5	0.2	0.7
Minimum:	2,984.7	0.0	2,984.7	104,500.0	311.9	0.4	0.2	0.6
Maximum:	4,827.2	0.0	4,827.2	104,500.0	504.4	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/30/2021 00:00	2,994.8	0.0	2,994.8	104,500.0	313.0	0.4	0.2	0.6
12/30/2021 01:00	2,990.2	0.0	2,990.2	104,500.0	312.5	0.4	0.2	0.6
12/30/2021 02:00	2,994.1	0.0	2,994.1	104,500.0	312.9	0.4	0.2	0.6
12/30/2021 03:00	2,990.4	0.0	2,990.4	104,500.0	312.5	0.4	0.2	0.6
12/30/2021 04:00	2,997.9	0.0	2,997.9	104,500.0	313.3	0.4	0.2	0.6
12/30/2021 05:00	4,654.5	167.1	4,763.1	104,500.0	497.7	0.6	0.3	1.0
12/30/2021 06:00	5,010.4	139.4	5,149.8	104,500.0	538.2	0.6	0.3	1.1
12/30/2021 07:00	5,012.6	132.6	5,145.2	104,500.0	537.7	0.6	0.3	1.1
12/30/2021 08:00	5,005.4	122.5	5,127.9	104,500.0	535.9	0.6	0.3	1.1
12/30/2021 09:00	4,989.6	141.2	5,130.8	104,500.0	536.2	0.6	0.3	1.1
12/30/2021 10:00	3,194.5	0.0	3,194.5	104,500.0	333.8	0.4	0.2	0.7
12/30/2021 11:00	2,992.8	0.0	2,992.8	104,500.0	312.7	0.4	0.2	0.6
12/30/2021 12:00	2,994.9	0.0	2,994.9	104,500.0	313.0	0.4	0.2	0.6
12/30/2021 13:00	2,992.5	0.0	2,992.5	104,500.0	312.7	0.4	0.2	0.6
12/30/2021 14:00	3,002.8	0.0	3,002.8	104,500.0	313.8	0.4	0.2	0.6
12/30/2021 15:00	3,006.0	0.0	3,006.0	104,500.0	314.1	0.4	0.2	0.6
12/30/2021 16:00	4,198.4	182.1	4,285.8	104,500.0	447.9	0.5	0.3	0.9
12/30/2021 17:00	4,924.3	257.7	5,182.0	104,500.0	541.5	0.7	0.3	1.1
12/30/2021 18:00	4,933.7	258.1	5,191.8	104,500.0	542.5	0.7	0.3	1.1
12/30/2021 19:00	4,948.3	246.7	5,195.0	104,500.0	542.9	0.7	0.3	1.1
12/30/2021 20:00	4,974.4	226.5	5,200.9	104,500.0	543.5	0.7	0.3	1.1
12/30/2021 21:00	4,991.1	211.7	5,202.8	104,500.0	543.7	0.7	0.3	1.1
12/30/2021 22:00	3,931.0	47.7	3,943.9	104,500.0	412.1	0.5	0.2	0.8
12/30/2021 23:00	3,019.0	0.0	3,019.0	104,500.0	315.5	0.4	0.2	0.6
Average/Sum#:	3,906.0	88.9	3,987.0	104,500.0	416.7	0.5	0.2	0.8
Minimum:	2,990.2	0.0	2,990.2	104,500.0	312.5	0.4	0.2	0.6
Maximum:	5,012.6	258.1	5,202.8	104,500.0	543.7	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:06 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
						PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/31/2021 00:00	3,004.8	0.0	3,004.8	104,500.0	314.0	0.4	0.2	0.6
12/31/2021 01:00	2,999.2	0.0	2,999.2	104,500.0	313.4	0.4	0.2	0.6
12/31/2021 02:00	2,995.7	0.0	2,995.7	104,500.0	313.1	0.4	0.2	0.6
12/31/2021 03:00	2,999.8	0.0	2,999.8	104,500.0	313.5	0.4	0.2	0.6
12/31/2021 04:00	3,001.1	0.0	3,001.1	104,500.0	313.6	0.4	0.2	0.6
12/31/2021 05:00	2,996.0	0.0	2,996.0	104,500.0	313.1	0.4	0.2	0.6
12/31/2021 06:00	3,000.3	0.0	3,000.3	104,500.0	313.5	0.4	0.2	0.6
12/31/2021 07:00	3,004.5	0.0	3,004.5	104,500.0	314.0	0.4	0.2	0.6
12/31/2021 08:00	3,016.7	0.0	3,016.7	104,500.0	315.2	0.4	0.2	0.6
12/31/2021 09:00	3,024.8	0.0	3,024.8	104,500.0	316.1	0.4	0.2	0.6
12/31/2021 10:00	3,005.8	0.0	3,005.8	104,500.0	314.1	0.4	0.2	0.6
12/31/2021 11:00	2,979.7	0.0	2,979.7	104,500.0	311.4	0.4	0.2	0.6
12/31/2021 12:00	2,977.6	0.0	2,977.6	104,500.0	311.2	0.4	0.2	0.6
12/31/2021 13:00	2,977.3	0.0	2,977.3	104,500.0	311.1	0.4	0.2	0.6
12/31/2021 14:00	2,973.3	0.0	2,973.3	104,500.0	310.7	0.4	0.2	0.6
12/31/2021 15:00	2,973.7	0.0	2,973.7	104,500.0	310.8	0.4	0.2	0.6
12/31/2021 16:00	3,500.0	0.0	3,500.0	104,500.0	365.8	0.4	0.2	0.7
12/31/2021 17:00	3,868.9	0.0	3,868.9	104,500.0	404.3	0.5	0.2	0.8
12/31/2021 18:00	4,205.1	0.0	4,205.1	104,500.0	439.4	0.5	0.3	0.9
12/31/2021 19:00	4,686.6	0.0	4,686.6	104,500.0	489.7	0.6	0.3	1.0
12/31/2021 20:00	4,298.7	0.0	4,298.7	104,500.0	449.2	0.5	0.3	0.9
12/31/2021 21:00	4,686.8	0.0	4,686.8	104,500.0	489.8	0.6	0.3	1.0
12/31/2021 22:00	4,048.5	0.0	4,048.5	104,500.0	423.1	0.5	0.3	0.8
12/31/2021 23:00	3,165.4	0.0	3,165.4	104,500.0	330.8	0.4	0.2	0.7
Average/Sum#:	3,349.6	0.0	3,349.6	104,500.0	350.0	0.4	0.2	0.7
Minimum:	2,973.3	0.0	2,973.3	104,500.0	310.7	0.4	0.2	0.6
Maximum:	4,686.8	0.0	4,686.8	104,500.0	489.8	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/01/21 0:00	1			37			38											
10/01/21 1:00	1			36			38											
10/01/21 2:00	1			36			38											
10/01/21 3:00	1			35			36											
10/01/21 4:00	1			39			40											
10/01/21 5:00	1			46			47											
10/01/21 6:00	1			48			49											
10/01/21 7:00	1			44			46											
10/01/21 8:00	1			38			39											
10/01/21 9:00	1			35			36											
10/01/21 10:00	1			33			34											
10/01/21 11:00	1			35			36											
10/01/21 12:00	1			40			41											
10/01/21 13:00	1			51			52											
10/01/21 14:00	1			59			60											
10/01/21 15:00	1			58			59											
10/01/21 16:00	1			55			55											
10/01/21 17:00	1			54			54											
10/01/21 18:00	1			57			58											
10/01/21 19:00	1			56			57											
10/01/21 20:00	1			56			58											
10/01/21 21:00	1			57			59											
10/01/21 22:00	1			53			55											
10/01/21 23:00	1			45			46											
10/02/21 0:00	1			41			42											
10/02/21 1:00	1			40			41											
10/02/21 2:00	1			42			43											
10/02/21 3:00	1			40			41											
10/02/21 4:00	1			41			42											
10/02/21 5:00	1			40			41											
10/02/21 6:00	1			47			48											
10/02/21 7:00	1			48			49											
10/02/21 8:00	1			46			47											
10/02/21 9:00	1			37			38											
10/02/21 10:00	1			32			33											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/02/21 11:00	1			33			34											
10/02/21 12:00	1			34			35											
10/02/21 13:00	1			40			41											
10/02/21 14:00	1			47			48											
10/02/21 15:00	1			51			52											
10/02/21 16:00	1			52			53											
10/02/21 17:00	1			54			55											
10/02/21 18:00	1			59			60											
10/02/21 19:00	1			62			63											
10/02/21 20:00	1			62			63											
10/02/21 21:00	1			61			62											
10/02/21 22:00	1			59			60											
10/02/21 23:00	1			56			57											
10/03/21 0:00	1			51			52											
10/03/21 1:00	1			43			44											
10/03/21 2:00	1			37			38											
10/03/21 3:00	1			34			35											
10/03/21 4:00	1			34			35											
10/03/21 5:00	1			34			35											
10/03/21 6:00	1			34			35											
10/03/21 7:00	1			34			35											
10/03/21 8:00	1			33			34											
10/03/21 9:00	1			32			33											
10/03/21 10:00	1			32			33											
10/03/21 11:00	1			32			33											
10/03/21 12:00	1			33			34											
10/03/21 13:00	1			35			36											
10/03/21 14:00	1			40			41											
10/03/21 15:00	1			46			47											
10/03/21 16:00	1			55			56											
10/03/21 17:00	1			62			63											
10/03/21 18:00	1			66			67											
10/03/21 19:00	1			66			67											
10/03/21 20:00	1			66			67											
10/03/21 21:00	1			67			68											
10/03/21 22:00	1			62			63											
10/03/21 23:00	1			53			54											
10/04/21 0:00	1			42			43											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/04/21 1:00	1			38			39											
10/04/21 2:00	1			37			38											
10/04/21 3:00	1			46			47											
10/04/21 4:00	1			52			53											
10/04/21 5:00	1			60			61											
10/04/21 6:00	1			61			62											
10/04/21 7:00	1			61			62											
10/04/21 8:00	1			61			62											
10/04/21 9:00	1			59			60											
10/04/21 10:00	1			59			60											
10/04/21 11:00	1			58			59											
10/04/21 12:00	1			60			61											
10/04/21 13:00	1			61			62											
10/04/21 14:00	1			62			63											
10/04/21 15:00	1			63			64											
10/04/21 16:00	1			67			68											
10/04/21 17:00	1			70			71											
10/04/21 18:00	1			72			73											
10/04/21 19:00	1			70			71											
10/04/21 20:00	1			68			69											
10/04/21 21:00	1			67			68											
10/04/21 22:00	1			62			63											
10/04/21 23:00	1			53			54											
10/05/21 0:00	1			42			43											
10/05/21 1:00	1			37			38											
10/05/21 2:00	1			36			37											
10/05/21 3:00	1			36			37											
10/05/21 4:00	1			39			40											
10/05/21 5:00	1			42			43											
10/05/21 6:00	1			45			47											
10/05/21 7:00	1			47			49											
10/05/21 8:00	1			44			46											
10/05/21 9:00	1			41			42											
10/05/21 10:00	1			43			44											
10/05/21 11:00	1			44			45											
10/05/21 12:00	1			43			44											
10/05/21 13:00	1			35			36											
10/05/21 14:00	1			39			40											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/05/21 15:00	1			43			44											
10/05/21 16:00	1			47			48											
10/05/21 17:00	1			48			49											
10/05/21 18:00	1			50			52											
10/05/21 19:00	1			47			48											
10/05/21 20:00	1			45			46											
10/05/21 21:00	1			44			45											
10/05/21 22:00	1			49			51											
10/05/21 23:00	1			54			56											
10/06/21 0:00	1			49			50											
10/06/21 1:00	1			41			43											
10/06/21 2:00	1			34			35											
10/06/21 3:00	1			34			35											
10/06/21 4:00	1			34			35											
10/06/21 5:00	1			37			38											
10/06/21 6:00	1			41			42											
10/06/21 7:00	1			42			43											
10/06/21 8:00	1			41			43											
10/06/21 9:00	1			45			46											
10/06/21 10:00	1			50			51											
10/06/21 11:00	1			57			58											
10/06/21 12:00	1			59			60											
10/06/21 13:00	1			60			61											
10/06/21 14:00	1			59			61											
10/06/21 15:00	1			55			56											
10/06/21 16:00	1			55			57											
10/06/21 17:00	1			47			48											
10/06/21 18:00	1			44			45											
10/06/21 19:00	1			39			40											
10/06/21 20:00	1			46			47											
10/06/21 21:00	1			53			54											
10/06/21 22:00	1			55			57											
10/06/21 23:00	1			48			50											
10/07/21 0:00	1			39			40											
10/07/21 1:00	1			34			35											
10/07/21 2:00	1			34			35											
10/07/21 3:00	1			38			39											
10/07/21 4:00	1			44			45											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/07/21 5:00	1			52			54											
10/07/21 6:00	1			58			60											
10/07/21 7:00	1			61			63											
10/07/21 8:00	1			59			61											
10/07/21 9:00	1			59			61											
10/07/21 10:00	1			53			55											
10/07/21 11:00	1			48			49											
10/07/21 12:00	1			39			40											
10/07/21 13:00	1			36			37											
10/07/21 14:00	1			34			35											
10/07/21 15:00	1			34			35											
10/07/21 16:00	1			37			38											
10/07/21 17:00	1			46			48											
10/07/21 18:00	1			50			51											
10/07/21 19:00	1			46			48											
10/07/21 20:00	1			38			39											
10/07/21 21:00	1			35			36											
10/07/21 22:00	1			35			36											
10/07/21 23:00	1			39			40											
10/08/21 0:00	1			39			40											
10/08/21 1:00	1			38			39											
10/08/21 2:00	1			34			35											
10/08/21 3:00	1			34			35											
10/08/21 4:00	1			35			36											
10/08/21 5:00	1			35			36											
10/08/21 6:00	1			36			37											
10/08/21 7:00	1			44			45											
10/08/21 8:00	1			48			50											
10/08/21 9:00	1			57			58											
10/08/21 10:00	1			48			49											
10/08/21 11:00	1			50			51											
10/08/21 12:00	1			46			47											
10/08/21 13:00	1			52			53											
10/08/21 14:00	1			55			56											
10/08/21 15:00	1			50			51											
10/08/21 16:00	1			46			47											
10/08/21 17:00	1			37			38											
10/08/21 18:00	1			37			38											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/08/21 19:00	1			34			35											
10/08/21 20:00	1			33			35											
10/08/21 21:00	1			33			35											
10/08/21 22:00	1			34			35											
10/08/21 23:00	1			34			35											
10/09/21 0:00	1			34			35											
10/09/21 1:00	1			33			34											
10/09/21 2:00	1			32			33											
10/09/21 3:00	1			32			33											
10/09/21 4:00	1			33			34											
10/09/21 5:00	1			36			37											
10/09/21 6:00	1			40			41											
10/09/21 7:00	1			46			47											
10/09/21 8:00	1			45			47											
10/09/21 9:00	1			42			43											
10/09/21 10:00	1			35			36											
10/09/21 11:00	1			32			33											
10/09/21 12:00	1			32			33											
10/09/21 13:00	1			32			33											
10/09/21 14:00	1			32			33											
10/09/21 15:00	1			33			34											
10/09/21 16:00	1			37			38											
10/09/21 17:00	1			45			46											
10/09/21 18:00	1			46			47											
10/09/21 19:00	1			42			43											
10/09/21 20:00	1			35			36											
10/09/21 21:00	1			33			34											
10/09/21 22:00	1			33			35											
10/09/21 23:00	1			34			35											
10/10/21 0:00	1			34			35											
10/10/21 1:00	1			34			35											
10/10/21 2:00	1			34			35											
10/10/21 3:00	1			34			35											
10/10/21 4:00	1			34			35											
10/10/21 5:00	1			38			39											
10/10/21 6:00	1			44			45											
10/10/21 7:00	1			48			49											
10/10/21 8:00	1			43			44											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/10/21 9:00	1			37			38											
10/10/21 10:00	1			32			33											
10/10/21 11:00	1			32			33											
10/10/21 12:00	1			32			33											
10/10/21 13:00	1			32			33											
10/10/21 14:00	1			32			33											
10/10/21 15:00	1			34			34											
10/10/21 16:00	1			38			39											
10/10/21 17:00	1			39			40											
10/10/21 18:00	1			38			39											
10/10/21 19:00	1			35			36											
10/10/21 20:00	1			38			39											
10/10/21 21:00	1			38			39											
10/10/21 22:00	1			37			38											
10/10/21 23:00	1			32			33											
10/11/21 0:00	1			33			34											
10/11/21 1:00	1			33			34											
10/11/21 2:00	1			33			34											
10/11/21 3:00	1			33			34											
10/11/21 4:00	1			40			41											
10/11/21 5:00	1			47			48											
10/11/21 6:00	1			55			56											
10/11/21 7:00	1			58			59											
10/11/21 8:00	1			65			67											
10/11/21 9:00	1			70			73											
10/11/21 10:00	1			74			77											
10/11/21 11:00	1			72			74											
10/11/21 12:00	1			72			73											
10/11/21 13:00	1			70			71											
10/11/21 14:00	1			71			72											
10/11/21 15:00	1			66			67											
10/11/21 16:00	1			62			63											
10/11/21 17:00	1			58			60											
10/11/21 18:00	1			54			55											
10/11/21 19:00	1			46			48											
10/11/21 20:00	1			44			45											
10/11/21 21:00	1			43			45											
10/11/21 22:00	1			43			45											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/11/21 23:00	1			38			40											
10/12/21 0:00	1			36			37											
10/12/21 1:00	1			34			36											
10/12/21 2:00	1			33			34											
10/12/21 3:00	1			33			34											
10/12/21 4:00	1			33			34											
10/12/21 5:00	1			38			40											
10/12/21 6:00	1			48			50											
10/12/21 7:00	1			58			60											
10/12/21 8:00	1			63			65											
10/12/21 9:00	1			63			65											
10/12/21 10:00	1			63			65											
10/12/21 11:00	1			63			65											
10/12/21 12:00	1			63			64											
10/12/21 13:00	1			56			57											
10/12/21 14:00	1			56			57											
10/12/21 15:00	1			56			57											
10/12/21 16:00	1			61			62											
10/12/21 17:00	1			60			62											
10/12/21 18:00	1			60			62											
10/12/21 19:00	1			59			61											
10/12/21 20:00	1			58			60											
10/12/21 21:00	1			57			59											
10/12/21 22:00	1			60			61											
10/12/21 23:00	1			58			59											
10/13/21 0:00	1			59			60											
10/13/21 1:00	1			51			52											
10/13/21 2:00	1			45			46											
10/13/21 3:00	1			39			40											
10/13/21 4:00	1			47			48											
10/13/21 5:00	1			56			57											
10/13/21 6:00	1			60			61											
10/13/21 7:00	1			60			62											
10/13/21 8:00	1			61			63											
10/13/21 9:00	1			63			65											
10/13/21 10:00	1			63			65											
10/13/21 11:00	1			63			64											
10/13/21 12:00	1			63			64											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/13/21 13:00	1			63			64											
10/13/21 14:00	1			63			64											
10/13/21 15:00	1			60			61											
10/13/21 16:00	1			53			55											
10/13/21 17:00	1			53			55											
10/13/21 18:00	1			54			55											
10/13/21 19:00	1			56			58											
10/13/21 20:00	1			55			56											
10/13/21 21:00	1			55			56											
10/13/21 22:00	1			57			59											
10/13/21 23:00	1			49			50											
10/14/21 0:00	1			42			43											
10/14/21 1:00	1			33			34											
10/14/21 2:00	1			34			35											
10/14/21 3:00	1			34			35											
10/14/21 4:00	1			34			35											
10/14/21 5:00	1			42			43											
10/14/21 6:00	1			51			53											
10/14/21 7:00	1			54			56											
10/14/21 8:00	1			46			48											
10/14/21 9:00	1			36			38											
10/14/21 10:00	1			33			34											
10/14/21 11:00	1			32			34											
10/14/21 12:00	1			32			33											
10/14/21 13:00	1			33			34											
10/14/21 14:00	1			34			35											
10/14/21 15:00	1			35			36											
10/14/21 16:00	1			40			41											
10/14/21 17:00	1			49			50											
10/14/21 18:00	1			56			57											
10/14/21 19:00	1			61			63											
10/14/21 20:00	1			61			63											
10/14/21 21:00	1			50			68											
10/14/21 22:00	1			29			69											
10/14/21 23:00	1			8			68											
10/15/21 0:00	1			0			65											
10/15/21 1:00	1			0			64											
10/15/21 2:00	1			0			64											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/15/21 3:00	1			0			64											
10/15/21 4:00	1			0			64											
10/15/21 5:00	1			0			64											
10/15/21 6:00	1			0			63											
10/15/21 7:00	1			0			63											
10/15/21 8:00	1			0			63											
10/15/21 9:00	1			0			63											
10/15/21 10:00	1			0			63											
10/15/21 11:00	1			0			63											
10/15/21 12:00	1			0			63											
10/15/21 13:00	1			0			63											
10/15/21 14:00	1			0			63											
10/15/21 15:00	1			0			63											
10/15/21 16:00	1			0			63											
10/15/21 17:00	1			0			64											
10/15/21 18:00	1			0			64											
10/15/21 19:00	1			0			63											
10/15/21 20:00	1			0			63											
10/15/21 21:00	1			0			63											
10/15/21 22:00	1			0			63											
10/15/21 23:00	1			0			63											
10/16/21 0:00	1			0			63											
10/16/21 1:00	1			0			63											
10/16/21 2:00	1			0			63											
10/16/21 3:00	1			0			63											
10/16/21 4:00	1			0			63											
10/16/21 5:00	1			0			63											
10/16/21 6:00	1			0			63											
10/16/21 7:00	1			0			63											
10/16/21 8:00	1			0			63											
10/16/21 9:00	1			0			63											
10/16/21 10:00	1			0			63											
10/16/21 11:00	1			0			63											
10/16/21 12:00	1			0			63											
10/16/21 13:00	1			0			63											
10/16/21 14:00	1			0			63											
10/16/21 15:00	1			0			63											
10/16/21 16:00	1			0			63											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/16/21 17:00	1			0			63											
10/16/21 18:00	1			0			63											
10/16/21 19:00	1			0			63											
10/16/21 20:00	1			0			63											
10/16/21 21:00	1			0			63											
10/16/21 22:00	1			0			63											
10/16/21 23:00	1			0			63											
10/17/21 0:00	1			0			63											
10/17/21 1:00	1			0			63											
10/17/21 2:00	1			0			63											
10/17/21 3:00	1			0			63											
10/17/21 4:00	1			0			63											
10/17/21 5:00	1			0			63											
10/17/21 6:00	1			0			63											
10/17/21 7:00	1			0			65											
10/17/21 8:00	1			0			70											
10/17/21 9:00	1			0			73											
10/17/21 10:00	1			0			72											
10/17/21 11:00	1			0			66											
10/17/21 12:00	1			0			63											
10/17/21 13:00	1			0			63											
10/17/21 14:00	1			0			63											
10/17/21 15:00	1			0			63											
10/17/21 16:00	1			0			63											
10/17/21 17:00	1			0			63											
10/17/21 18:00	1			0			63											
10/17/21 19:00	1			0			63											
10/17/21 20:00	1			0			63											
10/17/21 21:00	1			0			63											
10/17/21 22:00	1			0			63											
10/17/21 23:00	1			0			63											
10/18/21 0:00	1			0			63											
10/18/21 1:00	1			0			63											
10/18/21 2:00	1			0			63											
10/18/21 3:00	1			0			63											
10/18/21 4:00	1			0			63											
10/18/21 5:00	1			0			63											
10/18/21 6:00	1			0			63											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/18/21 7:00	1			0			59											
10/18/21 8:00	1			0			55											
10/18/21 9:00	1			0			55											
10/18/21 10:00	1			0			59											
10/18/21 11:00	1			0			63											
10/18/21 12:00	1			0			63											
10/18/21 13:00	1			0			63											
10/18/21 14:00	1			0			63											
10/18/21 15:00	1			0			63											
10/18/21 16:00	1			0			56											
10/18/21 17:00	1			0			56											
10/18/21 18:00	1			0			56											
10/18/21 19:00	1			0			63											
10/18/21 20:00	1			0			63											
10/18/21 21:00	1			0			59											
10/18/21 22:00	1			0			48											
10/18/21 23:00	1			0			38											
10/19/21 0:00	1			0			32											
10/19/21 1:00	1			0			32											
10/19/21 2:00	1			0			32											
10/19/21 3:00	1			0			38											
10/19/21 4:00	1			0			48											
10/19/21 5:00	1			0			58											
10/19/21 6:00	1			0			63											
10/19/21 7:00	1			0			63											
10/19/21 8:00	1			0			63											
10/19/21 9:00	1			0			63											
10/19/21 10:00	1			0			63											
10/19/21 11:00	1			0			63											
10/19/21 12:00	1			0			63											
10/19/21 13:00	1			0			59											
10/19/21 14:00	1			0			59											
10/19/21 15:00	1			0			59											
10/19/21 16:00	1			0			63											
10/19/21 17:00	1			0			63											
10/19/21 18:00	1			0			63											
10/19/21 19:00	1			0			63											
10/19/21 20:00	1			0			63											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/19/21 21:00	1			0			61											
10/19/21 22:00	1			0			51											
10/19/21 23:00	1			0			40											
10/20/21 0:00	1			0			31											
10/20/21 1:00	1			0			31											
10/20/21 2:00	1			0			31											
10/20/21 3:00	1			0			31											
10/20/21 4:00	1			0			37											
10/20/21 5:00	1			0			48											
10/20/21 6:00	1			0			54											
10/20/21 7:00	1			0			48											
10/20/21 8:00	1			0			38											
10/20/21 9:00	1			0			35											
10/20/21 10:00	1			0			35											
10/20/21 11:00	1			0			41											
10/20/21 12:00	1			0			42											
10/20/21 13:00	1			0			42											
10/20/21 14:00	1			0			37											
10/20/21 15:00	1			0			35											
10/20/21 16:00	1			0			40											
10/20/21 17:00	1			0			49											
10/20/21 18:00	1			0			46											
10/20/21 19:00	1			0			40											
10/20/21 20:00	1			0			32											
10/20/21 21:00	1			0			33											
10/20/21 22:00	1			1			41											
10/20/21 23:00	1			11			42											
10/21/21 0:00	1			23			42											
10/21/21 1:00	1			33			35											
10/21/21 2:00	1			34			35											
10/21/21 3:00	1			37			38											
10/21/21 4:00	1			41			43											
10/21/21 5:00	1			48			50											
10/21/21 6:00	1			52			54											
10/21/21 7:00	1			55			56											
10/21/21 8:00	1			56			58											
10/21/21 9:00	1			59			60											
10/21/21 10:00	1			62			63											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/21/21 11:00	1			60			61											
10/21/21 12:00	1			51			52											
10/21/21 13:00	1			48			50											
10/21/21 14:00	1			48			49											
10/21/21 15:00	1			50			51											
10/21/21 16:00	1			50			51											
10/21/21 17:00	1			54			55											
10/21/21 18:00	1			61			62											
10/21/21 19:00	1			63			64											
10/21/21 20:00	1			63			64											
10/21/21 21:00	1			61			62											
10/21/21 22:00	1			52			53											
10/21/21 23:00	1			41			42											
10/22/21 0:00	1			33			34											
10/22/21 1:00	1			32			33											
10/22/21 2:00	1			32			33											
10/22/21 3:00	1			33			34											
10/22/21 4:00	1			33			34											
10/22/21 5:00	1			34			35											
10/22/21 6:00	1			34			35											
10/22/21 7:00	1			38			39											
10/22/21 8:00	1			47			48											
10/22/21 9:00	1			56			57											
10/22/21 10:00	1			62			63											
10/22/21 11:00	1			62			64											
10/22/21 12:00	1			56			57											
10/22/21 13:00	1			48			49											
10/22/21 14:00	1			41			42											
10/22/21 15:00	1			40			41											
10/22/21 16:00	1			42			43											
10/22/21 17:00	1			47			48											
10/22/21 18:00	1			44			45											
10/22/21 19:00	1			40			41											
10/22/21 20:00	1			34			35											
10/22/21 21:00	1			34			35											
10/22/21 22:00	1			33			34											
10/22/21 23:00	1			35			36											
10/23/21 0:00	1			37			38											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/23/21 1:00	1			36			37											
10/23/21 2:00	1			35			36											
10/23/21 3:00	1			33			34											
10/23/21 4:00	1			34			35											
10/23/21 5:00	1			37			38											
10/23/21 6:00	1			42			43											
10/23/21 7:00	1			46			47											
10/23/21 8:00	1			51			52											
10/23/21 9:00	1			51			53											
10/23/21 10:00	1			49			50											
10/23/21 11:00	1			42			43											
10/23/21 12:00	1			46			47											
10/23/21 13:00	1			49			50											
10/23/21 14:00	1			57			59											
10/23/21 15:00	1			57			59											
10/23/21 16:00	1			62			64											
10/23/21 17:00	1			62			64											
10/23/21 18:00	1			54			55											
10/23/21 19:00	1			45			46											
10/23/21 20:00	1			35			36											
10/23/21 21:00	1			35			36											
10/23/21 22:00	1			35			36											
10/23/21 23:00	1			44			45											
10/24/21 0:00	1			50			51											
10/24/21 1:00	1			49			50											
10/24/21 2:00	1			39			40											
10/24/21 3:00	1			32			33											
10/24/21 4:00	1			32			33											
10/24/21 5:00	1			32			33											
10/24/21 6:00	1			33			34											
10/24/21 7:00	1			39			40											
10/24/21 8:00	1			49			50											
10/24/21 9:00	1			59			60											
10/24/21 10:00	1			63			64											
10/24/21 11:00	1			63			64											
10/24/21 12:00	1			62			64											
10/24/21 13:00	1			63			64											
10/24/21 14:00	1			57			58											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/24/21 15:00	1			55			56											
10/24/21 16:00	1			51			52											
10/24/21 17:00	1			56			57											
10/24/21 18:00	1			52			54											
10/24/21 19:00	1			52			53											
10/24/21 20:00	1			45			46											
10/24/21 21:00	1			42			43											
10/24/21 22:00	1			37			38											
10/24/21 23:00	1			36			37											
10/25/21 0:00	1			36			37											
10/25/21 1:00	1			36			37											
10/25/21 2:00	1			36			37											
10/25/21 3:00	1			35			36											
10/25/21 4:00	1			42			43											
10/25/21 5:00	1			50			52											
10/25/21 6:00	1			58			59											
10/25/21 7:00	1			58			59											
10/25/21 8:00	1			58			59											
10/25/21 9:00	1			54			55											
10/25/21 10:00	1			46			47											
10/25/21 11:00	1			36			38											
10/25/21 12:00	1			32			33											
10/25/21 13:00	1			32			33											
10/25/21 14:00	1			32			34											
10/25/21 15:00	1			32			34											
10/25/21 16:00	1			38			40											
10/25/21 17:00	1			43			45											
10/25/21 18:00	1			48			49											
10/25/21 19:00	1			49			51											
10/25/21 20:00	1			53			55											
10/25/21 21:00	1			50			52											
10/25/21 22:00	1			43			44											
10/25/21 23:00	1			34			35											
10/26/21 0:00	1			32			33											
10/26/21 1:00	1			32			33											
10/26/21 2:00	1			32			33											
10/26/21 3:00	1			32			34											
10/26/21 4:00	1			32			34											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/26/21 5:00	1			39			40											
10/26/21 6:00	1			40			41											
10/26/21 7:00	1			43			44											
10/26/21 8:00	1			37			38											
10/26/21 9:00	1			36			37											
10/26/21 10:00	1			34			35											
10/26/21 11:00	1			35			36											
10/26/21 12:00	1			35			36											
10/26/21 13:00	1			34			35											
10/26/21 14:00	1			35			36											
10/26/21 15:00	1			34			35											
10/26/21 16:00	1			36			37											
10/26/21 17:00	1			36			37											
10/26/21 18:00	1			41			42											
10/26/21 19:00	1			44			45											
10/26/21 20:00	1			50			51											
10/26/21 21:00	1			51			53											
10/26/21 22:00	1			53			55											
10/26/21 23:00	1			47			48											
10/27/21 0:00	1			41			42											
10/27/21 1:00	1			34			35											
10/27/21 2:00	1			33			34											
10/27/21 3:00	1			33			34											
10/27/21 4:00	1			33			34											
10/27/21 5:00	1			36			38											
10/27/21 6:00	1			44			46											
10/27/21 7:00	1			46			47											
10/27/21 8:00	1			42			43											
10/27/21 9:00	1			34			35											
10/27/21 10:00	1			32			33											
10/27/21 11:00	1			32			33											
10/27/21 12:00	1			32			33											
10/27/21 13:00	1			32			33											
10/27/21 14:00	1			32			33											
10/27/21 15:00	1			33			34											
10/27/21 16:00	1			42			43											
10/27/21 17:00	1			52			53											
10/27/21 18:00	1			59			61											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/27/21 19:00	1			60			62											
10/27/21 20:00	1			58			59											
10/27/21 21:00	1			57			58											
10/27/21 22:00	1			49			50											
10/27/21 23:00	1			42			43											
10/28/21 0:00	1			35			36											
10/28/21 1:00	1			34			35											
10/28/21 2:00	1			34			35											
10/28/21 3:00	1			34			35											
10/28/21 4:00	1			36			37											
10/28/21 5:00	1			41			42											
10/28/21 6:00	1			46			47											
10/28/21 7:00	1			45			46											
10/28/21 8:00	1			39			40											
10/28/21 9:00	1			33			34											
10/28/21 10:00	1			32			33											
10/28/21 11:00	1			33			34											
10/28/21 12:00	1			34			35											
10/28/21 13:00	1			33			34											
10/28/21 14:00	1			33			34											
10/28/21 15:00	1			32			33											
10/28/21 16:00	1			40			41											
10/28/21 17:00	1			50			52											
10/28/21 18:00	1			59			61											
10/28/21 19:00	1			62			63											
10/28/21 20:00	1			60			62											
10/28/21 21:00	1			57			59											
10/28/21 22:00	1			48			49											
10/28/21 23:00	1			39			40											
10/29/21 0:00	1			33			34											
10/29/21 1:00	1			33			34											
10/29/21 2:00	1			33			34											
10/29/21 3:00	1			33			34											
10/29/21 4:00	1			33			34											
10/29/21 5:00	1			37			38											
10/29/21 6:00	1			43			44											
10/29/21 7:00	1			42			43											
10/29/21 8:00	1			38			39											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/29/21 9:00	1			32			33											
10/29/21 10:00	1			32			33											
10/29/21 11:00	1			32			33											
10/29/21 12:00	1			32			33											
10/29/21 13:00	1			32			33											
10/29/21 14:00	1			32			33											
10/29/21 15:00	1			36			37											
10/29/21 16:00	1			45			47											
10/29/21 17:00	1			55			57											
10/29/21 18:00	1			57			59											
10/29/21 19:00	1			58			60											
10/29/21 20:00	1			57			59											
10/29/21 21:00	1			57			58											
10/29/21 22:00	1			53			54											
10/29/21 23:00	1			47			48											
10/30/21 0:00	1			43			44											
10/30/21 1:00	1			38			39											
10/30/21 2:00	1			35			36											
10/30/21 3:00	1			34			34											
10/30/21 4:00	1			34			34											
10/30/21 5:00	1			36			37											
10/30/21 6:00	1			35			37											
10/30/21 7:00	1			35			36											
10/30/21 8:00	1			32			33											
10/30/21 9:00	1			32			33											
10/30/21 10:00	1			32			33											
10/30/21 11:00	1			32			33											
10/30/21 12:00	1			32			33											
10/30/21 13:00	1			32			33											
10/30/21 14:00	1			32			33											
10/30/21 15:00	1			35			37											
10/30/21 16:00	1			37			38											
10/30/21 17:00	1			38			39											
10/30/21 18:00	1			35			36											
10/30/21 19:00	1			33			34											
10/30/21 20:00	1			32			33											
10/30/21 21:00	1			32			33											
10/30/21 22:00	1			32			33											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/30/21 23:00	1			32			33											
10/31/21 0:00	1			32			33											
10/31/21 1:00	1			32			33											
10/31/21 2:00	1			32			33											
10/31/21 3:00	1			32			33											
10/31/21 4:00	1			32			33											
10/31/21 5:00	1			33			34											
10/31/21 6:00	1			34			35											
10/31/21 7:00	1			35			36											
10/31/21 8:00	1			34			35											
10/31/21 9:00	1			33			34											
10/31/21 10:00	1			32			34											
10/31/21 11:00	1			32			33											
10/31/21 12:00	1			32			33											
10/31/21 13:00	1			32			33											
10/31/21 14:00	1			32			33											
10/31/21 15:00	1			33			34											
10/31/21 16:00	1			33			34											
10/31/21 17:00	1			33			34											
10/31/21 18:00	1			32			33											
10/31/21 19:00	1			32			33											
10/31/21 20:00	1			32			33											
10/31/21 21:00	1			32			33											
10/31/21 22:00	1			32			33											
10/31/21 23:00	1			32			33											
11/01/21 0:00	1			32			33											
11/01/21 1:00	1			33			34											
11/01/21 2:00	1			32			33											
11/01/21 3:00	1			33			34											
11/01/21 4:00	1			36			37											
11/01/21 5:00	1			36			37											
11/01/21 6:00	1			44			46											
11/01/21 7:00	1			45			46											
11/01/21 8:00	1			45			46											
11/01/21 9:00	1			41			42											
11/01/21 10:00	1			39			40											
11/01/21 11:00	1			43			44											
11/01/21 12:00	1			44			46											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/01/21 13:00	1			53			55											
11/01/21 14:00	1			55			57											
11/01/21 15:00	1			52			53											
11/01/21 16:00	1			46			47											
11/01/21 17:00	1			48			50											
11/01/21 18:00	1			54			56											
11/01/21 19:00	1			60			62											
11/01/21 20:00	1			60			62											
11/01/21 21:00	1			60			62											
11/01/21 22:00	1			55			57											
11/01/21 23:00	1			46			47											
11/02/21 0:00	1			38			39											
11/02/21 1:00	1			34			35											
11/02/21 2:00	1			33			34											
11/02/21 3:00	1			33			34											
11/02/21 4:00	1			33			34											
11/02/21 5:00	1			34			36											
11/02/21 6:00	1			40			42											
11/02/21 7:00	1			41			43											
11/02/21 8:00	1			40			41											
11/02/21 9:00	1			34			35											
11/02/21 10:00	1			32			34											
11/02/21 11:00	1			33			34											
11/02/21 12:00	1			33			34											
11/02/21 13:00	1			33			34											
11/02/21 14:00	1			32			33											
11/02/21 15:00	1			32			33											
11/02/21 16:00	1			38			39											
11/02/21 17:00	1			48			49											
11/02/21 18:00	1			56			57											
11/02/21 19:00	1			60			62											
11/02/21 20:00	1			61			63											
11/02/21 21:00	1			60			62											
11/02/21 22:00	1			58			60											
11/02/21 23:00	1			54			55											
11/03/21 0:00	1			51			52											
11/03/21 1:00	1			46			47											
11/03/21 2:00	1			45			46											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/03/21 3:00	1			44			46											
11/03/21 4:00	1			46			48											
11/03/21 5:00	1			50			52											
11/03/21 6:00	1			54			56											
11/03/21 7:00	1			51			52											
11/03/21 8:00	1			43			44											
11/03/21 9:00	1			35			36											
11/03/21 10:00	1			32			33											
11/03/21 11:00	1			32			33											
11/03/21 12:00	1			32			33											
11/03/21 13:00	1			32			33											
11/03/21 14:00	1			33			33											
11/03/21 15:00	1			36			37											
11/03/21 16:00	1			41			42											
11/03/21 17:00	1			51			52											
11/03/21 18:00	1			56			57											
11/03/21 19:00	1			61			62											
11/03/21 20:00	1			61			62											
11/03/21 21:00	1			60			61											
11/03/21 22:00	1			54			55											
11/03/21 23:00	1			45			46											
11/04/21 0:00	1			38			38											
11/04/21 1:00	1			33			34											
11/04/21 2:00	1			33			34											
11/04/21 3:00	1			39			40											
11/04/21 4:00	1			42			43											
11/04/21 5:00	1			49			50											
11/04/21 6:00	1			52			53											
11/04/21 7:00	1			51			52											
11/04/21 8:00	1			44			45											
11/04/21 9:00	1			40			41											
11/04/21 10:00	1			37			38											
11/04/21 11:00	1			37			38											
11/04/21 12:00	1			32			33											
11/04/21 13:00	1			32			33											
11/04/21 14:00	1			32			33											
11/04/21 15:00	1			36			37											
11/04/21 16:00	1			37			38											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/04/21 17:00	1			38			39											
11/04/21 18:00	1			35			36											
11/04/21 19:00	1			33			35											
11/04/21 20:00	1			33			35											
11/04/21 21:00	1			33			34											
11/04/21 22:00	1			32			33											
11/04/21 23:00	1			32			33											
11/05/21 0:00	1			32			33											
11/05/21 1:00	1			32			33											
11/05/21 2:00	1			32			33											
11/05/21 3:00	1			32			33											
11/05/21 4:00	1			34			35											
11/05/21 5:00	1			41			42											
11/05/21 6:00	1			49			50											
11/05/21 7:00	1			51			52											
11/05/21 8:00	1			45			46											
11/05/21 9:00	1			37			38											
11/05/21 10:00	1			32			34											
11/05/21 11:00	1			32			33											
11/05/21 12:00	1			32			33											
11/05/21 13:00	1			32			33											
11/05/21 14:00	1			35			36											
11/05/21 15:00	1			42			43											
11/05/21 16:00	1			48			49											
11/05/21 17:00	1			51			52											
11/05/21 18:00	1			46			47											
11/05/21 19:00	1			46			47											
11/05/21 20:00	1			45			46											
11/05/21 21:00	1			50			51											
11/05/21 22:00	1			48			50											
11/05/21 23:00	1			48			50											
11/06/21 0:00	1			42			43											
11/06/21 1:00	1			43			44											
11/06/21 2:00	1			39			40											
11/06/21 3:00	1			38			39											
11/06/21 4:00	1			36			37											
11/06/21 5:00	1			41			42											
11/06/21 6:00	1			49			50											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/06/21 7:00	1			51			53											
11/06/21 8:00	1			49			50											
11/06/21 9:00	1			40			41											
11/06/21 10:00	1			36			37											
11/06/21 11:00	1			32			33											
11/06/21 12:00	1			32			33											
11/06/21 13:00	1			32			33											
11/06/21 14:00	1			32			33											
11/06/21 15:00	1			34			35											
11/06/21 16:00	1			40			42											
11/06/21 17:00	1			49			51											
11/06/21 18:00	1			51			53											
11/06/21 19:00	1			55			57											
11/06/21 20:00	1			54			56											
11/06/21 21:00	1			56			58											
11/06/21 22:00	1			47			48											
11/06/21 23:00	1			39			40											
11/07/21 0:00	1			33			34											
11/07/21 1:00	1			33			34											
11/07/21 2:00	1			32			33											
11/07/21 3:00	1			32			33											
11/07/21 4:00	1			32			33											
11/07/21 5:00	1			32			33											
11/07/21 6:00	1			38			39											
11/07/21 7:00	1			45			47											
11/07/21 8:00	1			45			47											
11/07/21 9:00	1			39			41											
11/07/21 10:00	1			32			33											
11/07/21 11:00	1			32			33											
11/07/21 12:00	1			32			33											
11/07/21 13:00	1			32			33											
11/07/21 14:00	1			32			33											
11/07/21 15:00	1			37			38											
11/07/21 16:00	1			43			44											
11/07/21 17:00	1			47			48											
11/07/21 18:00	1			44			46											
11/07/21 19:00	1			44			46											
11/07/21 20:00	1			42			43											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/07/21 21:00	1			40			41											
11/07/21 22:00	1			35			36											
11/07/21 23:00	1			33			34											
11/08/21 0:00	1			33			34											
11/08/21 1:00	1			33			34											
11/08/21 2:00	1			35			36											
11/08/21 3:00	1			45			46											
11/08/21 4:00	1			54			55											
11/08/21 5:00	1			62			63											
11/08/21 6:00	1			62			64											
11/08/21 7:00	1			57			59											
11/08/21 8:00	1			47			48											
11/08/21 9:00	1			37			38											
11/08/21 10:00	1			32			33											
11/08/21 11:00	1			32			33											
11/08/21 12:00	1			32			33											
11/08/21 13:00	1			32			33											
11/08/21 14:00	1			32			33											
11/08/21 15:00	1			38			39											
11/08/21 16:00	1			48			50											
11/08/21 17:00	1			60			61											
11/08/21 18:00	1			65			67											
11/08/21 19:00	1			66			67											
11/08/21 20:00	1			64			65											
11/08/21 21:00	1			61			62											
11/08/21 22:00	1			55			56											
11/08/21 23:00	1			46			47											
11/09/21 0:00	1			39			40											
11/09/21 1:00	1			34			35											
11/09/21 2:00	1			34			35											
11/09/21 3:00	1			33			34											
11/09/21 4:00	1			33			34											
11/09/21 5:00	1			35			36											
11/09/21 6:00	1			36			37											
11/09/21 7:00	1			40			41											
11/09/21 8:00	1			38			39											
11/09/21 9:00	1			37			38											
11/09/21 10:00	1			33			34											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/09/21 11:00	1			32			33											
11/09/21 12:00	1			32			33											
11/09/21 13:00	1			32			33											
11/09/21 14:00	1			33			34											
11/09/21 15:00	1			35			36											
11/09/21 16:00	1			39			40											
11/09/21 17:00	1			44			45											
11/09/21 18:00	1			52			53											
11/09/21 19:00	1			58			60											
11/09/21 20:00	1			61			63											
11/09/21 21:00	1			54			56											
11/09/21 22:00	1			45			47											
11/09/21 23:00	1			36			37											
11/10/21 0:00	1			33			34											
11/10/21 1:00	1			32			33											
11/10/21 2:00	1			32			33											
11/10/21 3:00	1			32			33											
11/10/21 4:00	1			32			33											
11/10/21 5:00	1			36			37											
11/10/21 6:00	1			42			43											
11/10/21 7:00	1			48			49											
11/10/21 8:00	1			44			45											
11/10/21 9:00	1			38			39											
11/10/21 10:00	1			33			34											
11/10/21 11:00	1			33			34											
11/10/21 12:00	1			32			33											
11/10/21 13:00	1			32			33											
11/10/21 14:00	1			32			33											
11/10/21 15:00	1			32			33											
11/10/21 16:00	1			32			33											
11/10/21 17:00	1			33			34											
11/10/21 18:00	1			34			35											
11/10/21 19:00	1			34			35											
11/10/21 20:00	1			34			35											
11/10/21 21:00	1			35			36											
11/10/21 22:00	1			35			36											
11/10/21 23:00	1			35			36											
11/11/21 0:00	1			34			35											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/11/21 1:00	1			34			35											
11/11/21 2:00	1			33			34											
11/11/21 3:00	1			33			34											
11/11/21 4:00	1			33			34											
11/11/21 5:00	1			33			34											
11/11/21 6:00	1			34			35											
11/11/21 7:00	1			34			35											
11/11/21 8:00	1			34			35											
11/11/21 9:00	1			34			35											
11/11/21 10:00	1			34			35											
11/11/21 11:00	1			33			34											
11/11/21 12:00	1			33			34											
11/11/21 13:00	1			32			33											
11/11/21 14:00	1			32			33											
11/11/21 15:00	1			34			35											
11/11/21 16:00	1			40			41											
11/11/21 17:00	1			52			53											
11/11/21 18:00	1			61			62											
11/11/21 19:00	1			66			67											
11/11/21 20:00	1			67			68											
11/11/21 21:00	1			67			68											
11/11/21 22:00	1			63			64											
11/11/21 23:00	1			52			54											
11/12/21 0:00	1			41			42											
11/12/21 1:00	1			33			34											
11/12/21 2:00	1			32			33											
11/12/21 3:00	1			32			33											
11/12/21 4:00	1			32			33											
11/12/21 5:00	1			33			34											
11/12/21 6:00	1			33			34											
11/12/21 7:00	1			33			34											
11/12/21 8:00	1			33			34											
11/12/21 9:00	1			32			33											
11/12/21 10:00	1			32			33											
11/12/21 11:00	1			32			33											
11/12/21 12:00	1			32			33											
11/12/21 13:00	1			32			33											
11/12/21 14:00	1			32			33											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/12/21 15:00	1			34			35											
11/12/21 16:00	1			34			35											
11/12/21 17:00	1			35			36											
11/12/21 18:00	1			33			34											
11/12/21 19:00	1			33			34											
11/12/21 20:00	1			33			34											
11/12/21 21:00	1			36			37											
11/12/21 22:00	1			36			37											
11/12/21 23:00	1			35			36											
11/13/21 0:00	1			32			33											
11/13/21 1:00	1			32			33											
11/13/21 2:00	1			33			34											
11/13/21 3:00	1			33			34											
11/13/21 4:00	1			35			36											
11/13/21 5:00	1			39			40											
11/13/21 6:00	1			49			50											
11/13/21 7:00	1			57			59											
11/13/21 8:00	1			63			65											
11/13/21 9:00	1			63			65											
11/13/21 10:00	1			58			60											
11/13/21 11:00	1			49			51											
11/13/21 12:00	1			39			40											
11/13/21 13:00	1			33			34											
11/13/21 14:00	1			32			33											
11/13/21 15:00	1			33			34											
11/13/21 16:00	1			43			44											
11/13/21 17:00	1			45			46											
11/13/21 18:00	1			47			48											
11/13/21 19:00	1			45			46											
11/13/21 20:00	1			49			50											
11/13/21 21:00	1			48			49											
11/13/21 22:00	1			41			42											
11/13/21 23:00	1			35			36											
11/14/21 0:00	1			33			34											
11/14/21 1:00	1			32			33											
11/14/21 2:00	1			32			33											
11/14/21 3:00	1			32			33											
11/14/21 4:00	1			32			33											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/14/21 5:00	1			32			33											
11/14/21 6:00	1			32			33											
11/14/21 7:00	1			32			33											
11/14/21 8:00	1			32			33											
11/14/21 9:00	1			32			33											
11/14/21 10:00	1			31			33											
11/14/21 11:00	1			31			33											
11/14/21 12:00	1			31			33											
11/14/21 13:00	1			32			33											
11/14/21 14:00	1			32			33											
11/14/21 15:00	1			33			34											
11/14/21 16:00	1			33			34											
11/14/21 17:00	1			33			34											
11/14/21 18:00	1			32			33											
11/14/21 19:00	1			32			33											
11/14/21 20:00	1			33			34											
11/14/21 21:00	1			34			35											
11/14/21 22:00	1			34			35											
11/14/21 23:00	1			33			34											
11/15/21 0:00	1			32			33											
11/15/21 1:00	1			32			33											
11/15/21 2:00	1			32			33											
11/15/21 3:00	1			32			33											
11/15/21 4:00	1			32			33											
11/15/21 5:00	1			33			34											
11/15/21 6:00	1			35			36											
11/15/21 7:00	1			38			39											
11/15/21 8:00	1			37			38											
11/15/21 9:00	1			36			37											
11/15/21 10:00	1			34			35											
11/15/21 11:00	1			34			35											
11/15/21 12:00	1			33			34											
11/15/21 13:00	1			33			34											
11/15/21 14:00	1			37			38											
11/15/21 15:00	1			40			41											
11/15/21 16:00	1			41			43											
11/15/21 17:00	1			38			39											
11/15/21 18:00	1			35			36											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/15/21 19:00	1			38			39											
11/15/21 20:00	1			38			39											
11/15/21 21:00	1			40			41											
11/15/21 22:00	1			35			36											
11/15/21 23:00	1			35			36											
11/16/21 0:00	1			33			34											
11/16/21 1:00	1			33			34											
11/16/21 2:00	1			34			35											
11/16/21 3:00	1			33			34											
11/16/21 4:00	1			33			34											
11/16/21 5:00	1			39			40											
11/16/21 6:00	1			49			51											
11/16/21 7:00	1			59			61											
11/16/21 8:00	1			59			60											
11/16/21 9:00	1			52			54											
11/16/21 10:00	1			42			43											
11/16/21 11:00	1			36			38											
11/16/21 12:00	1			32			34											
11/16/21 13:00	1			32			33											
11/16/21 14:00	1			32			33											
11/16/21 15:00	1			34			35											
11/16/21 16:00	1			34			35											
11/16/21 17:00	1			39			40											
11/16/21 18:00	1			43			45											
11/16/21 19:00	1			46			47											
11/16/21 20:00	1			50			51											
11/16/21 21:00	1			53			54											
11/16/21 22:00	1			56			57											
11/16/21 23:00	1			52			53											
11/17/21 0:00	1			54			55											
11/17/21 1:00	1			54			56											
11/17/21 2:00	1			51			52											
11/17/21 3:00	1			41			42											
11/17/21 4:00	1			38			39											
11/17/21 5:00	1			41			42											
11/17/21 6:00	1			50			51											
11/17/21 7:00	1			51			53											
11/17/21 8:00	1			47			49											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/17/21 9:00	1			39			40											
11/17/21 10:00	1			34			35											
11/17/21 11:00	1			33			34											
11/17/21 12:00	1			33			34											
11/17/21 13:00	1			32			33											
11/17/21 14:00	1			32			33											
11/17/21 15:00	1			35			36											
11/17/21 16:00	1			41			42											
11/17/21 17:00	1			50			51											
11/17/21 18:00	1			57			58											
11/17/21 19:00	1			61			62											
11/17/21 20:00	1			62			63											
11/17/21 21:00	1			59			60											
11/17/21 22:00	1			51			52											
11/17/21 23:00	1			42			43											
11/18/21 0:00	1			35			36											
11/18/21 1:00	1			34			35											
11/18/21 2:00	1			34			35											
11/18/21 3:00	1			34			35											
11/18/21 4:00	1			34			35											
11/18/21 5:00	1			36			37											
11/18/21 6:00	1			45			46											
11/18/21 7:00	1			51			52											
11/18/21 8:00	1			53			54											
11/18/21 9:00	1			45			46											
11/18/21 10:00	1			38			39											
11/18/21 11:00	1			33			34											
11/18/21 12:00	1			32			33											
11/18/21 13:00	1			33			34											
11/18/21 14:00	1			34			35											
11/18/21 15:00	1			42			43											
11/18/21 16:00	1			50			51											
11/18/21 17:00	1			57			59											
11/18/21 18:00	1			60			62											
11/18/21 19:00	1			61			63											
11/18/21 20:00	1			58			60											
11/18/21 21:00	1			52			54											
11/18/21 22:00	1			45			46											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/18/21 23:00	1			41			42											
11/19/21 0:00	1			32			39											
11/19/21 1:00	1			19			36											
11/19/21 2:00	1			6			33											
11/19/21 3:00	1			0			34											
11/19/21 4:00	1			0			34											
11/19/21 5:00	1			0			34											
11/19/21 6:00	1			0			32											
11/19/21 7:00	1			0			37											
11/19/21 8:00	1			9			39											
11/19/21 9:00	1			20			39											
11/19/21 10:00	1			31			34											
11/19/21 11:00	1			33			34											
11/19/21 12:00	1			34			35											
11/19/21 13:00	1			41			42											
11/19/21 14:00	1			48			49											
11/19/21 15:00	1			51			52											
11/19/21 16:00	1			44			45											
11/19/21 17:00	1			39			40											
11/19/21 18:00	1			37			38											
11/19/21 19:00	1			36			37											
11/19/21 20:00	1			37			38											
11/19/21 21:00	1			39			40											
11/19/21 22:00	1			41			42											
11/19/21 23:00	1			38			39											
11/20/21 0:00	1			35			36											
11/20/21 1:00	1			32			33											
11/20/21 2:00	1			32			33											
11/20/21 3:00	1			32			33											
11/20/21 4:00	1			33			34											
11/20/21 5:00	1			33			34											
11/20/21 6:00	1			34			35											
11/20/21 7:00	1			37			39											
11/20/21 8:00	1			37			38											
11/20/21 9:00	1			36			37											
11/20/21 10:00	1			32			33											
11/20/21 11:00	1			32			33											
11/20/21 12:00	1			32			33											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/20/21 13:00	1			32			33											
11/20/21 14:00	1			32			33											
11/20/21 15:00	1			35			36											
11/20/21 16:00	1			38			39											
11/20/21 17:00	1			39			40											
11/20/21 18:00	1			37			38											
11/20/21 19:00	1			36			37											
11/20/21 20:00	1			39			40											
11/20/21 21:00	1			47			48											
11/20/21 22:00	1			49			51											
11/20/21 23:00	1			46			48											
11/21/21 0:00	1			41			43											
11/21/21 1:00	1			37			39											
11/21/21 2:00	1			37			38											
11/21/21 3:00	1			34			35											
11/21/21 4:00	1			33			35											
11/21/21 5:00	1			41			42											
11/21/21 6:00	1			49			50											
11/21/21 7:00	1			57			58											
11/21/21 8:00	1			59			60											
11/21/21 9:00	1			56			57											
11/21/21 10:00	1			52			54											
11/21/21 11:00	1			45			46											
11/21/21 12:00	1			40			41											
11/21/21 13:00	1			34			35											
11/21/21 14:00	1			32			33											
11/21/21 15:00	1			36			37											
11/21/21 16:00	1			40			41											
11/21/21 17:00	1			40			42											
11/21/21 18:00	1			37			38											
11/21/21 19:00	1			38			39											
11/21/21 20:00	1			48			49											
11/21/21 21:00	1			53			54											
11/21/21 22:00	1			54			55											
11/21/21 23:00	1			44			45											
11/22/21 0:00	1			39			40											
11/22/21 1:00	1			34			35											
11/22/21 2:00	1			34			35											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/22/21 3:00	1			34			35											
11/22/21 4:00	1			34			35											
11/22/21 5:00	1			34			35											
11/22/21 6:00	1			38			39											
11/22/21 7:00	1			41			42											
11/22/21 8:00	1			41			42											
11/22/21 9:00	1			37			38											
11/22/21 10:00	1			33			34											
11/22/21 11:00	1			32			33											
11/22/21 12:00	1			32			33											
11/22/21 13:00	1			33			34											
11/22/21 14:00	1			39			40											
11/22/21 15:00	1			49			51											
11/22/21 16:00	1			55			56											
11/22/21 17:00	1			50			52											
11/22/21 18:00	1			49			50											
11/22/21 19:00	1			51			52											
11/22/21 20:00	1			58			59											
11/22/21 21:00	1			57			59											
11/22/21 22:00	1			58			60											
11/22/21 23:00	1			53			55											
11/23/21 0:00	1			46			47											
11/23/21 1:00	1			38			39											
11/23/21 2:00	1			34			35											
11/23/21 3:00	1			34			35											
11/23/21 4:00	1			33			34											
11/23/21 5:00	1			33			34											
11/23/21 6:00	1			33			34											
11/23/21 7:00	1			36			37											
11/23/21 8:00	1			36			37											
11/23/21 9:00	1			36			37											
11/23/21 10:00	1			32			33											
11/23/21 11:00	1			32			33											
11/23/21 12:00	1			32			33											
11/23/21 13:00	1			32			33											
11/23/21 14:00	1			32			33											
11/23/21 15:00	1			34			35											
11/23/21 16:00	1			36			37											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/23/21 17:00	1			37			38											
11/23/21 18:00	1			35			36											
11/23/21 19:00	1			34			35											
11/23/21 20:00	1			34			35											
11/23/21 21:00	1			33			34											
11/23/21 22:00	1			33			34											
11/23/21 23:00	1			33			34											
11/24/21 0:00	1			34			35											
11/24/21 1:00	1			34			35											
11/24/21 2:00	1			33			34											
11/24/21 3:00	1			33			34											
11/24/21 4:00	1			32			33											
11/24/21 5:00	1			32			33											
11/24/21 6:00	1			34			35											
11/24/21 7:00	1			38			39											
11/24/21 8:00	1			38			40											
11/24/21 9:00	1			38			39											
11/24/21 10:00	1			35			36											
11/24/21 11:00	1			35			36											
11/24/21 12:00	1			34			35											
11/24/21 13:00	1			34			35											
11/24/21 14:00	1			34			35											
11/24/21 15:00	1			36			37											
11/24/21 16:00	1			38			40											
11/24/21 17:00	1			38			40											
11/24/21 18:00	1			36			37											
11/24/21 19:00	1			34			35											
11/24/21 20:00	1			34			36											
11/24/21 21:00	1			35			37											
11/24/21 22:00	1			35			37											
11/24/21 23:00	1			35			36											
11/25/21 0:00	1			34			35											
11/25/21 1:00	1			34			35											
11/25/21 2:00	1			34			35											
11/25/21 3:00	1			34			35											
11/25/21 4:00	1			34			36											
11/25/21 5:00	1			34			36											
11/25/21 6:00	1			34			36											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/25/21 7:00	1			37			38											
11/25/21 8:00	1			38			39											
11/25/21 9:00	1			37			38											
11/25/21 10:00	1			35			36											
11/25/21 11:00	1			34			35											
11/25/21 12:00	1			34			35											
11/25/21 13:00	1			34			35											
11/25/21 14:00	1			34			35											
11/25/21 15:00	1			35			36											
11/25/21 16:00	1			35			36											
11/25/21 17:00	1			35			36											
11/25/21 18:00	1			35			36											
11/25/21 19:00	1			34			35											
11/25/21 20:00	1			34			35											
11/25/21 21:00	1			34			35											
11/25/21 22:00	1			34			35											
11/25/21 23:00	1			34			35											
11/26/21 0:00	1			34			35											
11/26/21 1:00	1			34			35											
11/26/21 2:00	1			34			35											
11/26/21 3:00	1			34			35											
11/26/21 4:00	1			34			35											
11/26/21 5:00	1			34			35											
11/26/21 6:00	1			34			35											
11/26/21 7:00	1			34			35											
11/26/21 8:00	1			34			35											
11/26/21 9:00	1			34			35											
11/26/21 10:00	1			34			35											
11/26/21 11:00	1			34			35											
11/26/21 12:00	1			34			35											
11/26/21 13:00	1			34			35											
11/26/21 14:00	1			34			35											
11/26/21 15:00	1			37			38											
11/26/21 16:00	1			37			38											
11/26/21 17:00	1			37			38											
11/26/21 18:00	1			34			35											
11/26/21 19:00	1			34			35											
11/26/21 20:00	1			34			35											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/26/21 21:00	1			34			35											
11/26/21 22:00	1			34			35											
11/26/21 23:00	1			34			35											
11/27/21 0:00	1			34			35											
11/27/21 1:00	1			34			35											
11/27/21 2:00	1			34			35											
11/27/21 3:00	1			34			35											
11/27/21 4:00	1			34			35											
11/27/21 5:00	1			35			36											
11/27/21 6:00	1			35			36											
11/27/21 7:00	1			39			40											
11/27/21 8:00	1			38			39											
11/27/21 9:00	1			39			40											
11/27/21 10:00	1			40			41											
11/27/21 11:00	1			40			41											
11/27/21 12:00	1			39			40											
11/27/21 13:00	1			34			35											
11/27/21 14:00	1			34			35											
11/27/21 15:00	1			36			38											
11/27/21 16:00	1			40			41											
11/27/21 17:00	1			40			41											
11/27/21 18:00	1			38			39											
11/27/21 19:00	1			34			35											
11/27/21 20:00	1			34			35											
11/27/21 21:00	1			35			36											
11/27/21 22:00	1			35			36											
11/27/21 23:00	1			35			36											
11/28/21 0:00	1			34			35											
11/28/21 1:00	1			34			35											
11/28/21 2:00	1			34			35											
11/28/21 3:00	1			34			35											
11/28/21 4:00	1			34			35											
11/28/21 5:00	1			34			35											
11/28/21 6:00	1			34			35											
11/28/21 7:00	1			35			36											
11/28/21 8:00	1			35			36											
11/28/21 9:00	1			35			36											
11/28/21 10:00	1			34			35											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/28/21 11:00	1			34			35											
11/28/21 12:00	1			34			35											
11/28/21 13:00	1			34			35											
11/28/21 14:00	1			34			35											
11/28/21 15:00	1			34			35											
11/28/21 16:00	1			35			36											
11/28/21 17:00	1			35			36											
11/28/21 18:00	1			35			36											
11/28/21 19:00	1			34			35											
11/28/21 20:00	1			34			35											
11/28/21 21:00	1			34			35											
11/28/21 22:00	1			34			35											
11/28/21 23:00	1			34			35											
11/29/21 0:00	1			34			35											
11/29/21 1:00	1			34			35											
11/29/21 2:00	1			34			35											
11/29/21 3:00	1			34			35											
11/29/21 4:00	1			34			35											
11/29/21 5:00	1			34			35											
11/29/21 6:00	1			38			39											
11/29/21 7:00	1			42			43											
11/29/21 8:00	1			42			43											
11/29/21 9:00	1			38			39											
11/29/21 10:00	1			34			35											
11/29/21 11:00	1			34			35											
11/29/21 12:00	1			34			35											
11/29/21 13:00	1			34			35											
11/29/21 14:00	1			34			35											
11/29/21 15:00	1			36			37											
11/29/21 16:00	1			41			42											
11/29/21 17:00	1			48			49											
11/29/21 18:00	1			48			49											
11/29/21 19:00	1			48			50											
11/29/21 20:00	1			51			53											
11/29/21 21:00	1			52			54											
11/29/21 22:00	1			47			49											
11/29/21 23:00	1			38			39											
11/30/21 0:00	1			40			42											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/30/21 1:00	1			41			42											
11/30/21 2:00	1			41			42											
11/30/21 3:00	1			35			36											
11/30/21 4:00	1			34			35											
11/30/21 5:00	1			36			37											
11/30/21 6:00	1			44			45											
11/30/21 7:00	1			52			53											
11/30/21 8:00	1			51			52											
11/30/21 9:00	1			43			44											
11/30/21 10:00	1			35			36											
11/30/21 11:00	1			34			35											
11/30/21 12:00	1			34			35											
11/30/21 13:00	1			34			35											
11/30/21 14:00	1			34			35											
11/30/21 15:00	1			37			38											
11/30/21 16:00	1			43			45											
11/30/21 17:00	1			55			56											
11/30/21 18:00	1			67			69											
11/30/21 19:00	1			76			78											
11/30/21 20:00	1			77			79											
11/30/21 21:00	1			76			78											
11/30/21 22:00	1			71			73											
11/30/21 23:00	1			66			68											
12/01/21 0:00	1			52			53											
12/01/21 1:00	1			41			42											
12/01/21 2:00	1			34			35											
12/01/21 3:00	1			34			35											
12/01/21 4:00	1			34			35											
12/01/21 5:00	1			34			35											
12/01/21 6:00	1			34			35											
12/01/21 7:00	1			34			35											
12/01/21 8:00	1			34			35											
12/01/21 9:00	1			34			35											
12/01/21 10:00	1			34			35											
12/01/21 11:00	1			34			35											
12/01/21 12:00	1			34			35											
12/01/21 13:00	1			34			35											
12/01/21 14:00	1			34			35											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/01/21 15:00	1			36			37											
12/01/21 16:00	1			40			41											
12/01/21 17:00	1			47			48											
12/01/21 18:00	1			53			54											
12/01/21 19:00	1			58			59											
12/01/21 20:00	1			59			61											
12/01/21 21:00	1			60			62											
12/01/21 22:00	1			53			54											
12/01/21 23:00	1			45			46											
12/02/21 0:00	1			36			37											
12/02/21 1:00	1			36			37											
12/02/21 2:00	1			36			37											
12/02/21 3:00	1			43			44											
12/02/21 4:00	1			50			51											
12/02/21 5:00	1			58			60											
12/02/21 6:00	1			63			65											
12/02/21 7:00	1			66			68											
12/02/21 8:00	1			63			65											
12/02/21 9:00	1			52			53											
12/02/21 10:00	1			40			42											
12/02/21 11:00	1			34			35											
12/02/21 12:00	1			34			35											
12/02/21 13:00	1			34			35											
12/02/21 14:00	1			34			35											
12/02/21 15:00	1			36			37											
12/02/21 16:00	1			42			43											
12/02/21 17:00	1			55			56											
12/02/21 18:00	1			64			65											
12/02/21 19:00	1			70			71											
12/02/21 20:00	1			69			70											
12/02/21 21:00	1			69			70											
12/02/21 22:00	1			64			66											
12/02/21 23:00	1			53			54											
12/03/21 0:00	1			42			43											
12/03/21 1:00	1			35			36											
12/03/21 2:00	1			35			36											
12/03/21 3:00	1			34			35											
12/03/21 4:00	1			34			35											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/03/21 5:00	1			35			36											
12/03/21 6:00	1			35			36											
12/03/21 7:00	1			38			39											
12/03/21 8:00	1			38			39											
12/03/21 9:00	1			42			43											
12/03/21 10:00	1			48			50											
12/03/21 11:00	1			53			54											
12/03/21 12:00	1			51			53											
12/03/21 13:00	1			42			43											
12/03/21 14:00	1			37			38											
12/03/21 15:00	1			38			39											
12/03/21 16:00	1			46			47											
12/03/21 17:00	1			58			59											
12/03/21 18:00	1			65			66											
12/03/21 19:00	1			68			70											
12/03/21 20:00	1			68			70											
12/03/21 21:00	1			68			70											
12/03/21 22:00	1			68			70											
12/03/21 23:00	1			64			65											
12/04/21 0:00	1			52			54											
12/04/21 1:00	1			41			42											
12/04/21 2:00	1			34			35											
12/04/21 3:00	1			35			36											
12/04/21 4:00	1			38			39											
12/04/21 5:00	1			41			42											
12/04/21 6:00	1			42			43											
12/04/21 7:00	1			43			44											
12/04/21 8:00	1			43			44											
12/04/21 9:00	1			47			48											
12/04/21 10:00	1			45			47											
12/04/21 11:00	1			50			52											
12/04/21 12:00	1			44			45											
12/04/21 13:00	1			43			44											
12/04/21 14:00	1			36			37											
12/04/21 15:00	1			39			40											
12/04/21 16:00	1			45			46											
12/04/21 17:00	1			54			55											
12/04/21 18:00	1			63			64											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/04/21 19:00	1			67			69											
12/04/21 20:00	1			68			70											
12/04/21 21:00	1			68			70											
12/04/21 22:00	1			58			60											
12/04/21 23:00	1			47			48											
12/05/21 0:00	1			36			37											
12/05/21 1:00	1			35			36											
12/05/21 2:00	1			35			36											
12/05/21 3:00	1			34			35											
12/05/21 4:00	1			34			35											
12/05/21 5:00	1			34			35											
12/05/21 6:00	1			37			38											
12/05/21 7:00	1			39			41											
12/05/21 8:00	1			46			47											
12/05/21 9:00	1			52			54											
12/05/21 10:00	1			60			61											
12/05/21 11:00	1			62			64											
12/05/21 12:00	1			53			54											
12/05/21 13:00	1			47			49											
12/05/21 14:00	1			40			42											
12/05/21 15:00	1			41			42											
12/05/21 16:00	1			40			41											
12/05/21 17:00	1			42			43											
12/05/21 18:00	1			50			51											
12/05/21 19:00	1			57			58											
12/05/21 20:00	1			62			64											
12/05/21 21:00	1			62			64											
12/05/21 22:00	1			61			63											
12/05/21 23:00	1			57			59											
12/06/21 0:00	1			51			52											
12/06/21 1:00	1			42			43											
12/06/21 2:00	1			36			38											
12/06/21 3:00	1			34			35											
12/06/21 4:00	1			34			35											
12/06/21 5:00	1			38			40											
12/06/21 6:00	1			48			49											
12/06/21 7:00	1			57			59											
12/06/21 8:00	1			63			64											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/06/21 9:00	1			63			65											
12/06/21 10:00	1			63			65											
12/06/21 11:00	1			63			65											
12/06/21 12:00	1			63			65											
12/06/21 13:00	1			63			65											
12/06/21 14:00	1			63			65											
12/06/21 15:00	1			63			65											
12/06/21 16:00	1			64			66											
12/06/21 17:00	1			66			68											
12/06/21 18:00	1			69			70											
12/06/21 19:00	1			69			70											
12/06/21 20:00	1			69			71											
12/06/21 21:00	1			68			70											
12/06/21 22:00	1			68			70											
12/06/21 23:00	1			66			68											
12/07/21 0:00	1			62			63											
12/07/21 1:00	1			54			55											
12/07/21 2:00	1			44			45											
12/07/21 3:00	1			37			38											
12/07/21 4:00	1			37			39											
12/07/21 5:00	1			37			39											
12/07/21 6:00	1			41			42											
12/07/21 7:00	1			47			49											
12/07/21 8:00	1			57			59											
12/07/21 9:00	1			63			65											
12/07/21 10:00	1			60			61											
12/07/21 11:00	1			54			55											
12/07/21 12:00	1			52			53											
12/07/21 13:00	1			55			56											
12/07/21 14:00	1			61			63											
12/07/21 15:00	1			62			64											
12/07/21 16:00	1			63			65											
12/07/21 17:00	1			65			67											
12/07/21 18:00	1			68			70											
12/07/21 19:00	1			70			72											
12/07/21 20:00	1			71			73											
12/07/21 21:00	1			70			72											
12/07/21 22:00	1			69			71											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/07/21 23:00	1			68			70											
12/08/21 0:00	1			63			64											
12/08/21 1:00	1			56			57											
12/08/21 2:00	1			45			46											
12/08/21 3:00	1			39			40											
12/08/21 4:00	1			34			35											
12/08/21 5:00	1			34			35											
12/08/21 6:00	1			42			43											
12/08/21 7:00	1			50			51											
12/08/21 8:00	1			51			53											
12/08/21 9:00	1			44			45											
12/08/21 10:00	1			36			37											
12/08/21 11:00	1			42			43											
12/08/21 12:00	1			50			52											
12/08/21 13:00	1			51			52											
12/08/21 14:00	1			42			44											
12/08/21 15:00	1			35			36											
12/08/21 16:00	1			39			40											
12/08/21 17:00	1			49			50											
12/08/21 18:00	1			57			58											
12/08/21 19:00	1			62			64											
12/08/21 20:00	1			61			63											
12/08/21 21:00	1			58			59											
12/08/21 22:00	1			48			49											
12/08/21 23:00	1			39			40											
12/09/21 0:00	1			34			35											
12/09/21 1:00	1			34			35											
12/09/21 2:00	1			34			35											
12/09/21 3:00	1			34			35											
12/09/21 4:00	1			34			35											
12/09/21 5:00	1			34			35											
12/09/21 6:00	1			39			40											
12/09/21 7:00	1			41			43											
12/09/21 8:00	1			42			44											
12/09/21 9:00	1			43			44											
12/09/21 10:00	1			43			44											
12/09/21 11:00	1			42			43											
12/09/21 12:00	1			37			38											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/09/21 13:00	1			35			36											
12/09/21 14:00	1			35			36											
12/09/21 15:00	1			35			36											
12/09/21 16:00	1			40			42											
12/09/21 17:00	1			46			48											
12/09/21 18:00	1			48			50											
12/09/21 19:00	1			47			48											
12/09/21 20:00	1			49			50											
12/09/21 21:00	1			52			53											
12/09/21 22:00	1			50			51											
12/09/21 23:00	1			43			43											
12/10/21 0:00	1			37			38											
12/10/21 1:00	1			34			35											
12/10/21 2:00	1			34			35											
12/10/21 3:00	1			34			35											
12/10/21 4:00	1			34			35											
12/10/21 5:00	1			36			37											
12/10/21 6:00	1			41			43											
12/10/21 7:00	1			51			52											
12/10/21 8:00	1			52			53											
12/10/21 9:00	1			46			47											
12/10/21 10:00	1			38			40											
12/10/21 11:00	1			44			46											
12/10/21 12:00	1			48			50											
12/10/21 13:00	1			47			48											
12/10/21 14:00	1			38			39											
12/10/21 15:00	1			38			40											
12/10/21 16:00	1			47			49											
12/10/21 17:00	1			57			59											
12/10/21 18:00	1			62			64											
12/10/21 19:00	1			63			65											
12/10/21 20:00	1			63			65											
12/10/21 21:00	1			63			65											
12/10/21 22:00	1			63			65											
12/10/21 23:00	1			63			65											
12/11/21 0:00	1			57			59											
12/11/21 1:00	1			47			49											
12/11/21 2:00	1			38			39											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/11/21 3:00	1			34			35											
12/11/21 4:00	1			34			35											
12/11/21 5:00	1			34			35											
12/11/21 6:00	1			36			37											
12/11/21 7:00	1			38			39											
12/11/21 8:00	1			38			39											
12/11/21 9:00	1			36			37											
12/11/21 10:00	1			34			35											
12/11/21 11:00	1			34			35											
12/11/21 12:00	1			34			35											
12/11/21 13:00	1			34			35											
12/11/21 14:00	1			34			35											
12/11/21 15:00	1			34			35											
12/11/21 16:00	1			40			41											
12/11/21 17:00	1			48			49											
12/11/21 18:00	1			55			56											
12/11/21 19:00	1			59			60											
12/11/21 20:00	1			61			62											
12/11/21 21:00	1			63			64											
12/11/21 22:00	1			63			65											
12/11/21 23:00	1			58			60											
12/12/21 0:00	1			54			55											
12/12/21 1:00	1			44			45											
12/12/21 2:00	1			40			41											
12/12/21 3:00	1			42			43											
12/12/21 4:00	1			45			46											
12/12/21 5:00	1			45			46											
12/12/21 6:00	1			40			41											
12/12/21 7:00	1			39			40											
12/12/21 8:00	1			41			42											
12/12/21 9:00	1			38			40											
12/12/21 10:00	1			36			38											
12/12/21 11:00	1			34			36											
12/12/21 12:00	1			34			35											
12/12/21 13:00	1			34			35											
12/12/21 14:00	1			34			35											
12/12/21 15:00	1			36			37											
12/12/21 16:00	1			42			43											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/12/21 17:00	1			49			50											
12/12/21 18:00	1			55			56											
12/12/21 19:00	1			59			60											
12/12/21 20:00	1			59			61											
12/12/21 21:00	1			58			60											
12/12/21 22:00	1			54			55											
12/12/21 23:00	1			45			47											
12/13/21 0:00	1			39			40											
12/13/21 1:00	1			34			35											
12/13/21 2:00	1			34			35											
12/13/21 3:00	1			34			35											
12/13/21 4:00	1			34			35											
12/13/21 5:00	1			34			35											
12/13/21 6:00	1			39			40											
12/13/21 7:00	1			48			49											
12/13/21 8:00	1			57			58											
12/13/21 9:00	1			61			62											
12/13/21 10:00	1			57			59											
12/13/21 11:00	1			50			52											
12/13/21 12:00	1			50			51											
12/13/21 13:00	1			54			56											
12/13/21 14:00	1			62			64											
12/13/21 15:00	1			63			65											
12/13/21 16:00	1			64			66											
12/13/21 17:00	1			67			69											
12/13/21 18:00	1			68			70											
12/13/21 19:00	1			69			71											
12/13/21 20:00	1			68			70											
12/13/21 21:00	1			68			70											
12/13/21 22:00	1			64			65											
12/13/21 23:00	1			52			54											
12/14/21 0:00	1			41			42											
12/14/21 1:00	1			34			35											
12/14/21 2:00	1			34			35											
12/14/21 3:00	1			34			35											
12/14/21 4:00	1			34			35											
12/14/21 5:00	1			37			38											
12/14/21 6:00	1			43			44											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/14/21 7:00	1			44			45											
12/14/21 8:00	1			42			43											
12/14/21 9:00	1			35			36											
12/14/21 10:00	1			34			35											
12/14/21 11:00	1			34			35											
12/14/21 12:00	1			34			35											
12/14/21 13:00	1			34			35											
12/14/21 14:00	1			34			35											
12/14/21 15:00	1			34			35											
12/14/21 16:00	1			36			37											
12/14/21 17:00	1			45			46											
12/14/21 18:00	1			53			54											
12/14/21 19:00	1			59			61											
12/14/21 20:00	1			60			62											
12/14/21 21:00	1			62			64											
12/14/21 22:00	1			61			62											
12/14/21 23:00	1			51			52											
12/15/21 0:00	1			42			43											
12/15/21 1:00	1			35			36											
12/15/21 2:00	1			35			36											
12/15/21 3:00	1			34			35											
12/15/21 4:00	1			39			40											
12/15/21 5:00	1			49			50											
12/15/21 6:00	1			58			60											
12/15/21 7:00	1			61			63											
12/15/21 8:00	1			52			54											
12/15/21 9:00	1			43			44											
12/15/21 10:00	1			35			36											
12/15/21 11:00	1			35			36											
12/15/21 12:00	1			41			42											
12/15/21 13:00	1			46			47											
12/15/21 14:00	1			45			46											
12/15/21 15:00	1			41			42											
12/15/21 16:00	1			43			44											
12/15/21 17:00	1			52			53											
12/15/21 18:00	1			59			60											
12/15/21 19:00	1			62			64											
12/15/21 20:00	1			62			64											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/15/21 21:00	1			62			64											
12/15/21 22:00	1			60			62											
12/15/21 23:00	1			58			59											
12/16/21 0:00	1			57			58											
12/16/21 1:00	1			54			55											
12/16/21 2:00	1			46			47											
12/16/21 3:00	1			39			40											
12/16/21 4:00	1			41			42											
12/16/21 5:00	1			52			54											
12/16/21 6:00	1			64			66											
12/16/21 7:00	1			69			71											
12/16/21 8:00	1			69			71											
12/16/21 9:00	1			68			70											
12/16/21 10:00	1			67			69											
12/16/21 11:00	1			63			64											
12/16/21 12:00	1			52			53											
12/16/21 13:00	1			41			42											
12/16/21 14:00	1			38			39											
12/16/21 15:00	1			45			46											
12/16/21 16:00	1			57			58											
12/16/21 17:00	1			65			66											
12/16/21 18:00	1			68			70											
12/16/21 19:00	1			68			70											
12/16/21 20:00	1			69			70											
12/16/21 21:00	1			72			74											
12/16/21 22:00	1			73			74											
12/16/21 23:00	1			66			67											
12/17/21 0:00	1			51			52											
12/17/21 1:00	1			39			39											
12/17/21 2:00	1			34			35											
12/17/21 3:00	1			34			35											
12/17/21 4:00	1			41			42											
12/17/21 5:00	1			53			54											
12/17/21 6:00	1			65			66											
12/17/21 7:00	1			70			71											
12/17/21 8:00	1			65			67											
12/17/21 9:00	1			53			55											
12/17/21 10:00	1			41			42											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/17/21 11:00	1			34			35											
12/17/21 12:00	1			34			35											
12/17/21 13:00	1			34			35											
12/17/21 14:00	1			34			35											
12/17/21 15:00	1			40			42											
12/17/21 16:00	1			52			53											
12/17/21 17:00	1			63			65											
12/17/21 18:00	1			69			70											
12/17/21 19:00	1			69			70											
12/17/21 20:00	1			69			70											
12/17/21 21:00	1			69			70											
12/17/21 22:00	1			69			70											
12/17/21 23:00	1			65			66											
12/18/21 0:00	1			60			61											
12/18/21 1:00	1			56			57											
12/18/21 2:00	1			55			57											
12/18/21 3:00	1			51			53											
12/18/21 4:00	1			49			51											
12/18/21 5:00	1			50			51											
12/18/21 6:00	1			59			60											
12/18/21 7:00	1			59			61											
12/18/21 8:00	1			54			55											
12/18/21 9:00	1			43			44											
12/18/21 10:00	1			46			47											
12/18/21 11:00	1			48			50											
12/18/21 12:00	1			47			49											
12/18/21 13:00	1			38			39											
12/18/21 14:00	1			34			35											
12/18/21 15:00	1			36			37											
12/18/21 16:00	1			43			44											
12/18/21 17:00	1			55			56											
12/18/21 18:00	1			65			66											
12/18/21 19:00	1			69			70											
12/18/21 20:00	1			69			70											
12/18/21 21:00	1			69			70											
12/18/21 22:00	1			69			70											
12/18/21 23:00	1			62			63											
12/19/21 0:00	1			58			59											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/19/21 1:00	1			54			56											
12/19/21 2:00	1			56			58											
12/19/21 3:00	1			49			50											
12/19/21 4:00	1			41			42											
12/19/21 5:00	1			41			42											
12/19/21 6:00	1			49			50											
12/19/21 7:00	1			51			52											
12/19/21 8:00	1			44			45											
12/19/21 9:00	1			42			44											
12/19/21 10:00	1			49			51											
12/19/21 11:00	1			51			52											
12/19/21 12:00	1			44			46											
12/19/21 13:00	1			36			37											
12/19/21 14:00	1			37			38											
12/19/21 15:00	1			44			46											
12/19/21 16:00	1			55			57											
12/19/21 17:00	1			64			66											
12/19/21 18:00	1			69			70											
12/19/21 19:00	1			69			70											
12/19/21 20:00	1			69			70											
12/19/21 21:00	1			69			70											
12/19/21 22:00	1			67			68											
12/19/21 23:00	1			61			63											
12/20/21 0:00	1			51			53											
12/20/21 1:00	1			47			48											
12/20/21 2:00	1			46			48											
12/20/21 3:00	1			49			50											
12/20/21 4:00	1			45			47											
12/20/21 5:00	1			49			51											
12/20/21 6:00	1			57			59											
12/20/21 7:00	1			67			69											
12/20/21 8:00	1			62			64											
12/20/21 9:00	1			52			53											
12/20/21 10:00	1			41			42											
12/20/21 11:00	1			38			39											
12/20/21 12:00	1			45			47											
12/20/21 13:00	1			55			57											
12/20/21 14:00	1			65			67											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/20/21 15:00	1			71			73											
12/20/21 16:00	1			74			76											
12/20/21 17:00	1			75			77											
12/20/21 18:00	1			74			76											
12/20/21 19:00	1			75			77											
12/20/21 20:00	1			76			78											
12/20/21 21:00	1			76			78											
12/20/21 22:00	1			76			78											
12/20/21 23:00	1			73			75											
12/21/21 0:00	1			69			71											
12/21/21 1:00	1			65			67											
12/21/21 2:00	1			63			64											
12/21/21 3:00	1			62			63											
12/21/21 4:00	1			59			61											
12/21/21 5:00	1			56			58											
12/21/21 6:00	1			57			59											
12/21/21 7:00	1			60			62											
12/21/21 8:00	1			69			70											
12/21/21 9:00	1			76			78											
12/21/21 10:00	1			77			79											
12/21/21 11:00	1			69			70											
12/21/21 12:00	1			58			59											
12/21/21 13:00	1			55			57											
12/21/21 14:00	1			59			61											
12/21/21 15:00	1			65			67											
12/21/21 16:00	1			68			70											
12/21/21 17:00	1			69			70											
12/21/21 18:00	1			69			70											
12/21/21 19:00	1			69			70											
12/21/21 20:00	1			69			70											
12/21/21 21:00	1			69			70											
12/21/21 22:00	1			69			70											
12/21/21 23:00	1			64			65											
12/22/21 0:00	1			52			54											
12/22/21 1:00	1			41			42											
12/22/21 2:00	1			34			35											
12/22/21 3:00	1			34			35											
12/22/21 4:00	1			34			35											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/22/21 5:00	1			44			45											
12/22/21 6:00	1			55			57											
12/22/21 7:00	1			67			68											
12/22/21 8:00	1			69			70											
12/22/21 9:00	1			69			70											
12/22/21 10:00	1			65			66											
12/22/21 11:00	1			53			55											
12/22/21 12:00	1			42			43											
12/22/21 13:00	1			41			42											
12/22/21 14:00	1			52			54											
12/22/21 15:00	1			64			65											
12/22/21 16:00	1			68			70											
12/22/21 17:00	1			68			70											
12/22/21 18:00	1			69			70											
12/22/21 19:00	1			69			70											
12/22/21 20:00	1			57			59											
12/22/21 21:00	1			46			47											
12/22/21 22:00	1			37			38											
12/22/21 23:00	1			37			38											
12/23/21 0:00	1			42			43											
12/23/21 1:00	1			41			43											
12/23/21 2:00	1			41			42											
12/23/21 3:00	1			36			37											
12/23/21 4:00	1			34			35											
12/23/21 5:00	1			34			35											
12/23/21 6:00	1			34			35											
12/23/21 7:00	1			34			35											
12/23/21 8:00	1			34			35											
12/23/21 9:00	1			34			35											
12/23/21 10:00	1			34			35											
12/23/21 11:00	1			34			35											
12/23/21 12:00	1			34			35											
12/23/21 13:00	1			34			35											
12/23/21 14:00	1			34			35											
12/23/21 15:00	1			34			35											
12/23/21 16:00	1			34			35											
12/23/21 17:00	1			34			35											
12/23/21 18:00	1			34			35											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/23/21 19:00	1			34			35											
12/23/21 20:00	1			34			35											
12/23/21 21:00	1			34			35											
12/23/21 22:00	1			34			35											
12/23/21 23:00	1			34			35											
12/24/21 0:00	1			34			35											
12/24/21 1:00	1			34			35											
12/24/21 2:00	1			34			35											
12/24/21 3:00	1			34			35											
12/24/21 4:00	1			34			35											
12/24/21 5:00	1			34			35											
12/24/21 6:00	1			34			35											
12/24/21 7:00	1			34			35											
12/24/21 8:00	1			34			35											
12/24/21 9:00	1			34			35											
12/24/21 10:00	1			34			35											
12/24/21 11:00	1			34			35											
12/24/21 12:00	1			34			35											
12/24/21 13:00	1			34			35											
12/24/21 14:00	1			34			35											
12/24/21 15:00	1			34			35											
12/24/21 16:00	1			34			35											
12/24/21 17:00	1			34			35											
12/24/21 18:00	1			34			35											
12/24/21 19:00	1			34			35											
12/24/21 20:00	1			34			35											
12/24/21 21:00	1			34			35											
12/24/21 22:00	1			34			35											
12/24/21 23:00	1			34			35											
12/25/21 0:00	1			34			35											
12/25/21 1:00	1			34			35											
12/25/21 2:00	1			34			35											
12/25/21 3:00	1			34			35											
12/25/21 4:00	1			34			35											
12/25/21 5:00	1			34			35											
12/25/21 6:00	1			34			35											
12/25/21 7:00	1			34			35											
12/25/21 8:00	1			34			35											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/25/21 9:00	1			34			35											
12/25/21 10:00	1			34			35											
12/25/21 11:00	1			34			35											
12/25/21 12:00	1			34			35											
12/25/21 13:00	1			34			35											
12/25/21 14:00	1			34			35											
12/25/21 15:00	1			35			36											
12/25/21 16:00	1			35			36											
12/25/21 17:00	1			35			36											
12/25/21 18:00	1			34			35											
12/25/21 19:00	1			34			35											
12/25/21 20:00	1			34			35											
12/25/21 21:00	1			34			35											
12/25/21 22:00	1			34			35											
12/25/21 23:00	1			34			35											
12/26/21 0:00	1			34			35											
12/26/21 1:00	1			34			35											
12/26/21 2:00	1			34			35											
12/26/21 3:00	1			34			35											
12/26/21 4:00	1			34			35											
12/26/21 5:00	1			34			35											
12/26/21 6:00	1			34			35											
12/26/21 7:00	1			34			35											
12/26/21 8:00	1			34			35											
12/26/21 9:00	1			34			35											
12/26/21 10:00	1			34			35											
12/26/21 11:00	1			34			35											
12/26/21 12:00	1			34			35											
12/26/21 13:00	1			36			37											
12/26/21 14:00	1			36			37											
12/26/21 15:00	1			37			38											
12/26/21 16:00	1			42			43											
12/26/21 17:00	1			53			54											
12/26/21 18:00	1			56			58											
12/26/21 19:00	1			50			51											
12/26/21 20:00	1			39			40											
12/26/21 21:00	1			42			44											
12/26/21 22:00	1			44			46											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/26/21 23:00	1			44			45											
12/27/21 0:00	1			36			37											
12/27/21 1:00	1			34			35											
12/27/21 2:00	1			34			35											
12/27/21 3:00	1			34			35											
12/27/21 4:00	1			34			35											
12/27/21 5:00	1			41			42											
12/27/21 6:00	1			52			54											
12/27/21 7:00	1			64			66											
12/27/21 8:00	1			68			70											
12/27/21 9:00	1			67			69											
12/27/21 10:00	1			59			61											
12/27/21 11:00	1			56			57											
12/27/21 12:00	1			46			47											
12/27/21 13:00	1			43			44											
12/27/21 14:00	1			42			43											
12/27/21 15:00	1			52			54											
12/27/21 16:00	1			63			64											
12/27/21 17:00	1			67			69											
12/27/21 18:00	1			69			71											
12/27/21 19:00	1			70			72											
12/27/21 20:00	1			70			72											
12/27/21 21:00	1			70			71											
12/27/21 22:00	1			67			68											
12/27/21 23:00	1			58			59											
12/28/21 0:00	1			47			48											
12/28/21 1:00	1			38			39											
12/28/21 2:00	1			35			36											
12/28/21 3:00	1			34			35											
12/28/21 4:00	1			34			35											
12/28/21 5:00	1			40			42											
12/28/21 6:00	1			46			47											
12/28/21 7:00	1			47			48											
12/28/21 8:00	1			44			45											
12/28/21 9:00	1			40			41											
12/28/21 10:00	1			40			41											
12/28/21 11:00	1			37			38											
12/28/21 12:00	1			34			35											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/28/21 13:00	1			34			35											
12/28/21 14:00	1			34			35											
12/28/21 15:00	1			37			38											
12/28/21 16:00	1			42			43											
12/28/21 17:00	1			51			53											
12/28/21 18:00	1			57			59											
12/28/21 19:00	1			58			60											
12/28/21 20:00	1			54			56											
12/28/21 21:00	1			47			48											
12/28/21 22:00	1			41			42											
12/28/21 23:00	1			36			37											
12/29/21 0:00	1			35			36											
12/29/21 1:00	1			35			36											
12/29/21 2:00	1			34			35											
12/29/21 3:00	1			34			35											
12/29/21 4:00	1			34			35											
12/29/21 5:00	1			34			35											
12/29/21 6:00	1			35			36											
12/29/21 7:00	1			35			36											
12/29/21 8:00	1			35			36											
12/29/21 9:00	1			34			35											
12/29/21 10:00	1			34			35											
12/29/21 11:00	1			34			35											
12/29/21 12:00	1			34			35											
12/29/21 13:00	1			35			36											
12/29/21 14:00	1			39			40											
12/29/21 15:00	1			44			45											
12/29/21 16:00	1			48			49											
12/29/21 17:00	1			53			54											
12/29/21 18:00	1			57			59											
12/29/21 19:00	1			62			64											
12/29/21 20:00	1			63			65											
12/29/21 21:00	1			57			58											
12/29/21 22:00	1			47			49											
12/29/21 23:00	1			38			39											
12/30/21 0:00	1			34			35											
12/30/21 1:00	1			34			35											
12/30/21 2:00	1			34			35											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/30/21 3:00	1			34			35											
12/30/21 4:00	1			34			35											
12/30/21 5:00	1			43			45											
12/30/21 6:00	1			55			56											
12/30/21 7:00	1			66			68											
12/30/21 8:00	1			68			70											
12/30/21 9:00	1			68			70											
12/30/21 10:00	1			58			60											
12/30/21 11:00	1			47			48											
12/30/21 12:00	1			35			36											
12/30/21 13:00	1			34			35											
12/30/21 14:00	1			34			35											
12/30/21 15:00	1			34			35											
12/30/21 16:00	1			41			42											
12/30/21 17:00	1			52			54											
12/30/21 18:00	1			64			65											
12/30/21 19:00	1			68			70											
12/30/21 20:00	1			68			70											
12/30/21 21:00	1			68			70											
12/30/21 22:00	1			62			64											
12/30/21 23:00	1			51			52											
12/31/21 0:00	1			39			40											
12/31/21 1:00	1			34			35											
12/31/21 2:00	1			34			35											
12/31/21 3:00	1			34			35											
12/31/21 4:00	1			34			35											
12/31/21 5:00	1			34			35											
12/31/21 6:00	1			34			35											
12/31/21 7:00	1			34			35											
12/31/21 8:00	1			34			35											
12/31/21 9:00	1			34			35											
12/31/21 10:00	1			34			35											
12/31/21 11:00	1			34			35											
12/31/21 12:00	1			34			35											
12/31/21 13:00	1			34			35											
12/31/21 14:00	1			34			35											
12/31/21 15:00	1			34			35											
12/31/21 16:00	1			37			38											

	ALL_UnitOn_TF_1H			CT1_Load_Total_3Hr_MWe_1H			CT2_Load_Total_3Hr_MWe_1H											
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/31/21 17:00	1			42			43											
12/31/21 18:00	1			48			50											
12/31/21 19:00	1			55			56											
12/31/21 20:00	1			57			59											
12/31/21 21:00	1			60			61											
12/31/21 22:00	1			56			58											
12/31/21 23:00	1			50			51											

Tons 12 Month Rolling Summary

CT1 and CT2 Combined



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:58 Location: Roseville, CA

* = Excess Emission

Date	Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2	
	CO, Ton		NOx, Ton		PM10, Ton		SO2, Ton		VOC, Ton	
	1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)	
	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum
Oct 2021	0.4854	5.2065	1.4017	10.1188	0.3030	2.0868	0.1514	1.0431	0.5047	3.4782
Nov 2021	0.3852	5.2713	1.2922	10.6823	0.2880	2.2353	0.1440	1.1173	0.4796	3.7254
Dec 2021	0.5686	5.7875	1.5683	12.2309	0.3450	2.5791	0.1722	1.2889	0.5749	4.2983
Sum/Avg	5.7875		12.2309		2.5791		1.2889		4.2983	
Limit Value										

Monthly Summary Report

Units CT1 and CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:03 **Location:** Roseville, CA

Date	Unit CT1 OperatingTime, Hr		Unit CT1 DBOn, Hr		Unit CT2 OperatingTime, Hr		Unit CT2 DBOn, Hr	
	1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)	
	Sum	Running Sum	Sum	Running Sum	Sum	Running Sum	Sum	Running Sum
Oct 21	598.41	598.41	20.55	20.55	744.00	744.00	136.82	136.82
Nov 21	712.38	1,310.79	15.12	35.67	720.00	1,464.00	15.25	152.07
Dec 21	744.00	2,054.79	137.68	173.35	744.00	2,208.00	139.92	291.99
Sum/Avg	2,054.79		173.35		2,208.00		291.99	

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/01/21 04:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/01/21 04:24	200.0	189.0	188.7	R-A /Span * 100		0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/01/21 04:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/01/21 04:20	30.0	27.7	28.0	R-A /Span * 100		1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/01/21 04:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/01/21 04:24	200.0	189.0	187.3	R-A /Span * 100		0.9
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/01/21 04:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/01/21 04:19	30.0	23.7	23.5	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/01/21 05:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	10/01/21 05:25	200.0	177.4	175.7	R-A /Span * 100		0.9
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/01/21 05:15	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	10/01/21 05:20	10.0	8.9	8.9	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/01/21 05:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/01/21 05:25	200.0	189.0	187.1	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/01/21 05:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/01/21 05:20	10.0	9.0	8.5	>1x Alert R-A /Span * 100		5.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/01/21 05:15	21.0	18.3	18.3	R-A		0.0
	Zero	10/01/21 05:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/01/21 05:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/01/21 05:25	200.0	177.1	178.2	R-A /Span * 100		0.6
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/01/21 05:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/01/21 05:20	10.0	9.0	9.3	R-A /Span * 100		3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/01/21 05:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/01/21 05:25	200.0	189.0	187.4	R-A /Span * 100		0.8

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/01/21 05:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/01/21 05:20	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/01/21 05:15	21.0	18.1	18.1	R-A		0.0
	Zero	10/01/21 05:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/02/21 04:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/02/21 04:24	200.0	189.0	188.6	R-A /Span * 100		0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/02/21 04:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/02/21 04:20	30.0	27.7	28.1	R-A /Span * 100		1.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/02/21 04:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/02/21 04:24	200.0	189.0	189.0	R-A /Span * 100		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/02/21 04:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/02/21 04:19	30.0	23.7	23.7	R-A /Span * 100		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/02/21 05:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	10/02/21 05:24	200.0	177.1	178.9	R-A /Span * 100		0.9
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/02/21 05:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	10/02/21 05:19	10.0	9.0	9.4	R-A /Span * 100		4.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/02/21 05:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/02/21 05:24	200.0	189.0	187.4	R-A /Span * 100		0.8
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/02/21 05:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/02/21 05:19	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/02/21 05:14	21.0	18.1	18.1	R-A		0.0
	Zero	10/02/21 05:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/02/21 05:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	10/02/21 05:25	200.0	177.4	175.4	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/02/21 05:14	10.0	0.0		R-A /Span * 100	1.0
	High	10/02/21 05:19	10.0	8.9		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/02/21 05:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/02/21 05:25	200.0	189.0		R-A /Span * 100	1.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/02/21 05:14	10.0	0.0		R-A /Span * 100	0.0
	High	10/02/21 05:19	10.0	8.5	>1x Alert	R-A /Span * 100	5.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/02/21 05:14	21.0	18.3		R-A	0.0
	Zero	10/02/21 05:19	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/03/21 04:15	200.0	0.0		R-A /Span * 100	0.0
	High	10/03/21 04:25	200.0	189.0		R-A /Span * 100	0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/03/21 04:15	30.0	0.0		R-A /Span * 100	0.0
	High	10/03/21 04:20	30.0	27.7		R-A /Span * 100	1.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/03/21 04:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/03/21 04:25	200.0	189.0		R-A /Span * 100	0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/03/21 04:14	30.0	0.0		R-A /Span * 100	0.0
	High	10/03/21 04:19	30.0	23.7		R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/03/21 05:14	200.0	0.0		R-A /Span * 100	0.1
	High	10/03/21 05:25	200.0	177.4		R-A /Span * 100	0.9
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/03/21 05:14	10.0	0.0		R-A /Span * 100	1.0
	High	10/03/21 05:19	10.0	8.9		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/03/21 05:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/03/21 05:25	200.0	189.0		R-A /Span * 100	1.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/03/21 05:14	10.0	0.0		R-A /Span * 100	0.0
	High	10/03/21 05:19	10.0	8.5	>1x Alert	R-A /Span * 100	5.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/03/21 05:14	21.0	18.3	R-A		0.0
	Zero	10/03/21 05:19	21.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/03/21 05:14	200.0	0.1	R-A /Span * 100		0.1
	High	10/03/21 05:25	200.0	179.0	R-A /Span * 100		1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/03/21 05:14	10.0	0.1	R-A /Span * 100		1.0
	High	10/03/21 05:20	10.0	9.4	R-A /Span * 100		4.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/03/21 05:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/03/21 05:25	200.0	187.4	R-A /Span * 100		0.8
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/03/21 05:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/03/21 05:20	10.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/03/21 05:14	21.0	18.1	R-A		0.0
	Zero	10/03/21 05:20	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/04/21 04:15	200.0	0.0	R-A /Span * 100		0.0
	High	10/04/21 04:24	200.0	188.8	R-A /Span * 100		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/04/21 04:15	30.0	0.0	R-A /Span * 100		0.0
	High	10/04/21 04:19	30.0	28.1	R-A /Span * 100		1.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/04/21 04:15	200.0	0.0	R-A /Span * 100		0.0
	High	10/04/21 04:25	200.0	189.0	R-A /Span * 100		0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/04/21 04:15	30.0	0.0	R-A /Span * 100		0.0
	High	10/04/21 04:20	30.0	23.7	R-A /Span * 100		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/04/21 05:15	200.0	0.0	R-A /Span * 100		0.0
	High	10/04/21 05:25	200.0	175.8	R-A /Span * 100		0.8
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/04/21 05:15	10.0	0.1	R-A /Span * 100		1.0
	High	10/04/21 05:20	10.0	8.9	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/04/21 05:15	200.0	0.0		R-A /Span * 100	0.0
	High	10/04/21 05:25	200.0	189.0		R-A /Span * 100	1.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/04/21 05:15	10.0	0.0		R-A /Span * 100	0.0
	High	10/04/21 05:20	10.0	8.5	>1x Alert	R-A /Span * 100	5.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/04/21 05:15	21.0	18.3		R-A	0.0
	Zero	10/04/21 05:20	21.0	0.0		R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/04/21 05:14	200.0	0.1		R-A /Span * 100	0.1
	High	10/04/21 05:24	200.0	177.1		R-A /Span * 100	1.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/04/21 05:14	10.0	0.1		R-A /Span * 100	1.0
	High	10/04/21 05:19	10.0	9.4		R-A /Span * 100	4.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/04/21 05:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/04/21 05:24	200.0	189.0		R-A /Span * 100	0.8
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/04/21 05:14	10.0	0.0		R-A /Span * 100	0.0
	High	10/04/21 05:19	10.0	9.0		R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/04/21 05:14	21.0	18.1		R-A	0.0
	Zero	10/04/21 05:19	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/05/21 02:15	200.0	0.0		R-A /Span * 100	0.0
	High	10/05/21 02:25	200.0	189.0		R-A /Span * 100	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/05/21 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	10/05/21 02:20	30.0	27.7		R-A /Span * 100	1.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/05/21 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/05/21 02:24	200.0	189.0		R-A /Span * 100	0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/05/21 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	10/05/21 02:20	30.0	23.7		R-A /Span * 100	0.3

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/05/21 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	10/05/21 03:24	200.0	177.4	175.8	R-A /Span * 100		0.8
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/05/21 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	10/05/21 03:19	10.0	8.9	8.9	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/05/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/05/21 03:24	200.0	189.0	188.3	R-A /Span * 100		0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/05/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/05/21 03:19	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/05/21 03:14	21.0	18.3	18.3	R-A		0.0
	Zero	10/05/21 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/05/21 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	10/05/21 03:25	200.0	177.1	179.6	R-A /Span * 100		1.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/05/21 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	10/05/21 03:19	10.0	9.0	9.5	R-A /Span * 100		5.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/05/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/05/21 03:25	200.0	189.0	187.5	R-A /Span * 100		0.8
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/05/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/05/21 03:19	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/05/21 03:14	21.0	18.1	18.1	R-A		0.0
	Zero	10/05/21 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/06/21 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/06/21 02:24	200.0	189.0	188.3	R-A /Span * 100		0.4
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/06/21 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/06/21 02:19	30.0	23.7	23.5	R-A /Span * 100		0.7

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/06/21 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/06/21 02:25	200.0	189.0	187.4	R-A /Span * 100		0.8
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/06/21 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/06/21 02:20	30.0	27.7	27.3	R-A /Span * 100		1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/06/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/06/21 03:24	200.0	177.4	177.4	R-A /Span * 100		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/06/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/06/21 03:19	10.0	8.9	8.8	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/06/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/06/21 03:24	200.0	189.0	188.4	R-A /Span * 100		0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/06/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/06/21 03:19	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/06/21 03:14	21.0	18.3	18.3	R-A		0.0
	Zero	10/06/21 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/06/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/06/21 03:25	200.0	177.1	177.5	R-A /Span * 100		0.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/06/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/06/21 03:19	10.0	9.0	9.1	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/06/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/06/21 03:25	200.0	189.0	188.2	R-A /Span * 100		0.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/06/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/06/21 03:19	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/06/21 03:14	21.0	18.1	18.1	R-A		0.0
	Zero	10/06/21 03:19	21.0	0.0	0.0	R-A		0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/07/21 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/07/21 02:25	200.0	189.0	188.4	R-A /Span * 100		0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/07/21 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/07/21 02:19	30.0	27.7	27.4	R-A /Span * 100		1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/07/21 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/07/21 02:25	200.0	189.0	188.9	R-A /Span * 100		0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/07/21 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/07/21 02:20	30.0	23.7	23.6	R-A /Span * 100		0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/07/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/07/21 03:24	200.0	177.1	177.8	R-A /Span * 100		0.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/07/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/07/21 03:19	10.0	9.0	9.1	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/07/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/07/21 03:24	200.0	189.0	188.8	R-A /Span * 100		0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/07/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/07/21 03:19	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/07/21 03:14	21.0	18.1	18.1	R-A		0.0
	Zero	10/07/21 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/07/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/07/21 03:25	200.0	177.4	177.4	R-A /Span * 100		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/07/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/07/21 03:19	10.0	8.9	8.8	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/07/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/07/21 03:25	200.0	189.0	188.6	R-A /Span * 100		0.2

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/07/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/07/21 03:19	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/07/21 03:14	21.0	18.3	18.3	R-A		0.0
	Zero	10/07/21 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/08/21 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/08/21 02:25	200.0	189.0	190.9	R-A /Span * 100		1.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/08/21 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/08/21 02:20	30.0	27.7	27.7	R-A /Span * 100		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/08/21 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/08/21 02:25	200.0	189.0	188.4	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/08/21 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/08/21 02:20	30.0	23.7	23.5	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/08/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/08/21 03:25	200.0	177.4	177.6	R-A /Span * 100		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/08/21 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	10/08/21 03:19	10.0	8.9	8.9	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/08/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/08/21 03:25	200.0	189.0	188.5	R-A /Span * 100		0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/08/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/08/21 03:19	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/08/21 03:14	21.0	18.3	18.3	R-A		0.0
	Zero	10/08/21 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/08/21 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/08/21 03:25	200.0	177.1	177.4	R-A /Span * 100		0.2

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/08/21 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	10/08/21 03:20	10.0	9.0	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/08/21 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	10/08/21 03:25	200.0	189.0	R-A /Span * 100		0.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/08/21 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	10/08/21 03:20	10.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/08/21 03:15	21.0	18.2	R-A		0.1
	Zero	10/08/21 03:20	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/09/21 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	10/09/21 02:25	200.0	189.0	R-A /Span * 100		0.6
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/09/21 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	10/09/21 02:20	30.0	27.7	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/09/21 02:15	200.0	0.0	R-A /Span * 100		0.1
	High	10/09/21 02:24	200.0	189.0	R-A /Span * 100		1.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/09/21 02:15	30.0	0.0	R-A /Span * 100		0.3
	High	10/09/21 02:19	30.0	23.7	R-A /Span * 100		2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/09/21 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	10/09/21 03:24	200.0	177.4	R-A /Span * 100		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/09/21 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	10/09/21 03:19	10.0	8.9	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/09/21 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	10/09/21 03:24	200.0	189.0	R-A /Span * 100		0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/09/21 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	10/09/21 03:19	10.0	9.0	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/09/21 03:15	21.0	18.3	R-A		0.0
	Zero	10/09/21 03:19	21.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/09/21 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/09/21 03:24	200.0	177.1	R-A /Span * 100		0.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/09/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/09/21 03:19	10.0	9.1	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/09/21 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/09/21 03:24	200.0	189.0	R-A /Span * 100		0.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/09/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/09/21 03:19	10.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/09/21 03:14	21.0	18.2	R-A		0.1
	Zero	10/09/21 03:19	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/10/21 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/10/21 02:24	200.0	189.0	R-A /Span * 100		1.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/10/21 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	10/10/21 02:19	30.0	27.7	R-A /Span * 100		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/10/21 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/10/21 02:25	200.0	189.0	R-A /Span * 100		1.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/10/21 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	10/10/21 02:20	30.0	23.7	R-A /Span * 100		1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/10/21 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	10/10/21 03:25	200.0	177.4	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/10/21 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	10/10/21 03:20	10.0	8.9	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:08 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/10/21 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	10/10/21 03:25	200.0	189.0		R-A /Span * 100	0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/10/21 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	10/10/21 03:20	10.0	9.0		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/10/21 03:15	21.0	18.3		R-A	0.0
	Zero	10/10/21 03:20	21.0	0.0		R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/10/21 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/10/21 03:25	200.0	177.1		R-A /Span * 100	0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/10/21 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	10/10/21 03:19	10.0	9.0		R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/10/21 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/10/21 03:25	200.0	189.0		R-A /Span * 100	0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/10/21 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	10/10/21 03:19	10.0	9.0		R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/10/21 03:14	21.0	18.2		R-A	0.1
	Zero	10/10/21 03:19	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/11/21 02:15	200.0	0.0		R-A /Span * 100	0.0
	High	10/11/21 02:24	200.0	189.0		R-A /Span * 100	1.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/11/21 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	10/11/21 02:20	30.0	27.7		R-A /Span * 100	0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/11/21 02:15	200.0	0.1		R-A /Span * 100	0.1
	High	10/11/21 02:25	200.0	189.0		R-A /Span * 100	1.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/11/21 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	10/11/21 02:20	30.0	23.7		R-A /Span * 100	1.3

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/11/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/11/21 03:24	200.0	177.1	177.5	R-A /Span * 100		0.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/11/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/11/21 03:19	10.0	9.0	9.2	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/11/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/11/21 03:24	200.0	189.0	189.4	R-A /Span * 100		0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/11/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/11/21 03:19	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/11/21 03:14	21.0	18.2	18.3	R-A		0.1
	Zero	10/11/21 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/11/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/11/21 03:25	200.0	177.4	177.6	R-A /Span * 100		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/11/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/11/21 03:19	10.0	8.9	8.9	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/11/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/11/21 03:25	200.0	189.0	188.8	R-A /Span * 100		0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/11/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/11/21 03:19	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/11/21 03:14	21.0	18.3	18.3	R-A		0.0
	Zero	10/11/21 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/12/21 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/12/21 02:24	200.0	189.0	187.0	R-A /Span * 100		1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/12/21 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/12/21 02:19	30.0	23.7	23.2	R-A /Span * 100		1.7

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/12/21 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/12/21 02:24	200.0	189.0	192.2	R-A /Span * 100		1.6
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/12/21 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/12/21 02:20	30.0	27.7	27.9	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/12/21 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/12/21 03:25	200.0	177.4	177.4	R-A /Span * 100		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/12/21 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/12/21 03:19	10.0	8.9	8.8	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/12/21 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/12/21 03:25	200.0	189.0	187.5	R-A /Span * 100		0.8
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/12/21 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/12/21 03:19	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/12/21 03:15	21.0	18.3	18.3	R-A		0.0
	Zero	10/12/21 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/12/21 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/12/21 03:25	200.0	177.1	176.8	R-A /Span * 100		0.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/12/21 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/12/21 03:19	10.0	9.0	9.2	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/12/21 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/12/21 03:25	200.0	189.0	189.2	R-A /Span * 100		0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/12/21 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/12/21 03:19	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/12/21 03:15	21.0	18.2	18.3	R-A		0.1
	Zero	10/12/21 03:19	21.0	0.0	0.0	R-A		0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/13/21 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/13/21 02:24	200.0	189.0	192.5	R-A /Span * 100		1.8
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/13/21 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/13/21 02:19	30.0	27.7	27.9	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/13/21 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/13/21 02:25	200.0	189.0	187.8	R-A /Span * 100		0.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/13/21 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/13/21 02:19	30.0	23.7	23.4	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/13/21 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/13/21 03:25	200.0	177.4	177.5	R-A /Span * 100		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/13/21 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/13/21 03:19	10.0	8.9	8.8	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/13/21 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/13/21 03:25	200.0	189.0	186.9	R-A /Span * 100		1.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/13/21 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/13/21 03:19	10.0	9.0	8.9	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/13/21 03:15	21.0	18.3	18.3	R-A		0.0
	Zero	10/13/21 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/13/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/13/21 03:25	200.0	177.1	177.1	R-A /Span * 100		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/13/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/13/21 03:19	10.0	9.0	9.1	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/13/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/13/21 03:25	200.0	189.0	189.0	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/13/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/13/21 03:19	10.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/13/21 03:14	21.0	18.2	R-A		0.1
	Zero	10/13/21 03:19	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/14/21 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/14/21 02:24	200.0	189.0	R-A /Span * 100		1.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/14/21 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	10/14/21 02:19	30.0	27.7	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/14/21 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/14/21 02:25	200.0	189.0	R-A /Span * 100		1.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/14/21 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	10/14/21 02:19	30.0	23.7	R-A /Span * 100		1.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/14/21 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	10/14/21 03:25	200.0	177.4	R-A /Span * 100		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/14/21 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	10/14/21 03:20	10.0	8.9	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/14/21 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	10/14/21 03:25	200.0	189.0	R-A /Span * 100		0.9
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/14/21 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	10/14/21 03:20	10.0	9.0	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/14/21 03:15	21.0	18.3	R-A		0.0
	Zero	10/14/21 03:20	21.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/14/21 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/14/21 03:25	200.0	177.1	R-A /Span * 100		0.1

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:08 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/14/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/14/21 03:20	10.0	9.0	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/14/21 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/14/21 03:25	200.0	189.0	R-A /Span * 100		0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/14/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/14/21 03:20	10.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/14/21 03:14	21.0	18.2	R-A		0.1
	Zero	10/14/21 03:20	21.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/15/21 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	10/15/21 02:25	200.0	189.0	R-A /Span * 100		0.9
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/15/21 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	10/15/21 02:20	30.0	23.7	R-A /Span * 100		1.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/15/21 03:14	200.0	0.0	R-A /Span * 100		0.1
	High	10/15/21 03:24	200.0	177.1	R-A /Span * 100		0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/15/21 03:14	10.0	0.0	R-A /Span * 100		1.0
	High	10/15/21 03:19	10.0	9.0	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/15/21 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/15/21 03:24	200.0	189.0	R-A /Span * 100		0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/15/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/15/21 03:19	10.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/15/21 03:14	21.0	18.2	R-A		0.1
	Zero	10/15/21 03:19	21.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/16/21 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/16/21 02:25	200.0	189.0	R-A /Span * 100		0.1

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:08 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/16/21 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	10/16/21 02:20	30.0	23.7		R-A /Span * 100	0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/16/21 03:14	200.0	0.1		R-A /Span * 100	0.1
	High	10/16/21 03:24	200.0	177.1		R-A /Span * 100	0.6
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/16/21 03:14	10.0	0.1		R-A /Span * 100	1.0
	High	10/16/21 03:19	10.0	9.0		R-A /Span * 100	3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/16/21 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/16/21 03:24	200.0	189.0		R-A /Span * 100	0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/16/21 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	10/16/21 03:19	10.0	9.0		R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/16/21 03:14	21.0	18.2		R-A	0.1
	Zero	10/16/21 03:19	21.0	0.0		R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/17/21 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/17/21 02:24	200.0	189.0		R-A /Span * 100	0.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/17/21 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	10/17/21 02:20	30.0	23.7		R-A /Span * 100	0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/17/21 03:15	200.0	0.1		R-A /Span * 100	0.1
	High	10/17/21 03:25	200.0	177.3		R-A /Span * 100	0.6
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/17/21 03:15	10.0	0.1		R-A /Span * 100	1.0
	High	10/17/21 03:20	10.0	9.0		R-A /Span * 100	3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/17/21 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	10/17/21 03:25	200.0	189.0		R-A /Span * 100	0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/17/21 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	10/17/21 03:20	10.0	9.0		R-A /Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/17/21 03:15	21.0	18.2	18.3	R-A		0.1
	Zero	10/17/21 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/18/21 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/18/21 02:24	200.0	189.0	187.8	R-A /Span * 100		0.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/18/21 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/18/21 02:20	30.0	23.7	23.4	R-A /Span * 100		1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/18/21 03:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	10/18/21 03:25	200.0	177.3	178.6	R-A /Span * 100		0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/18/21 03:15	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	10/18/21 03:20	10.0	9.0	9.3	R-A /Span * 100		3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/18/21 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/18/21 03:25	200.0	189.0	188.6	R-A /Span * 100		0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/18/21 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/18/21 03:20	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/18/21 03:15	21.0	18.2	18.3	R-A		0.1
	Zero	10/18/21 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/19/21 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/19/21 02:25	200.0	189.0	187.1	R-A /Span * 100		1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/19/21 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/19/21 02:20	30.0	23.7	23.3	R-A /Span * 100		1.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/19/21 03:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	10/19/21 03:25	200.0	177.3	178.3	R-A /Span * 100		0.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/19/21 03:15	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	10/19/21 03:20	10.0	9.0	9.3	R-A /Span * 100		3.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/19/21 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	10/19/21 03:25	200.0	189.0		R-A /Span * 100	0.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/19/21 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	10/19/21 03:20	10.0	9.0		R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/19/21 03:15	21.0	18.2		R-A	0.1
	Zero	10/19/21 03:20	21.0	0.0		R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/20/21 02:15	200.0	0.0		R-A /Span * 100	0.0
	High	10/20/21 02:24	200.0	189.0		R-A /Span * 100	0.9
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/20/21 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	10/20/21 02:19	30.0	23.7		R-A /Span * 100	1.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/20/21 03:14	200.0	0.0		R-A /Span * 100	0.1
	High	10/20/21 03:25	200.0	177.3		R-A /Span * 100	0.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/20/21 03:14	10.0	0.0		R-A /Span * 100	1.0
	High	10/20/21 03:19	10.0	9.0		R-A /Span * 100	3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/20/21 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/20/21 03:25	200.0	189.0		R-A /Span * 100	0.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/20/21 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	10/20/21 03:19	10.0	9.0		R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/20/21 03:14	21.0	18.2		R-A	0.1
	Zero	10/20/21 03:19	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/21/21 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/21/21 02:25	200.0	189.0		R-A /Span * 100	0.8
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/21/21 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	10/21/21 02:19	30.0	27.7		R-A /Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/21/21 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/21/21 02:24	200.0	189.0	186.5	R-A /Span * 100		1.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/21/21 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/21/21 02:19	30.0	23.7	23.3	R-A /Span * 100		1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/21/21 02:23	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	10/21/21 02:34	200.0	177.4	177.4	R-A /Span * 100		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/21/21 02:23	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	10/21/21 02:28	10.0	8.9	8.9	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/21/21 02:23	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/21/21 02:34	200.0	189.0	189.2	R-A /Span * 100		0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/21/21 02:23	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/21/21 02:28	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/21/21 02:23	21.0	18.3	18.3	R-A		0.0
	Zero	10/21/21 02:28	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/21/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/21/21 03:25	200.0	177.3	177.6	R-A /Span * 100		0.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/21/21 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	10/21/21 03:20	10.0	9.0	9.3	R-A /Span * 100		3.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/21/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/21/21 03:25	200.0	189.0	187.8	R-A /Span * 100		0.6
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/21/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/21/21 03:20	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/21/21 03:14	21.0	18.2	18.3	R-A		0.1
	Zero	10/21/21 03:20	21.0	0.0	0.0	R-A		0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/22/21 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/22/21 02:24	200.0	189.0	186.6	R-A /Span * 100		1.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/22/21 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/22/21 02:19	30.0	23.7	23.3	R-A /Span * 100		1.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/22/21 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/22/21 02:25	200.0	189.0	189.0	R-A /Span * 100		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/22/21 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/22/21 02:19	30.0	27.7	27.3	R-A /Span * 100		1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/22/21 02:38	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/22/21 02:48	200.0	177.4	178.1	R-A /Span * 100		0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/22/21 02:38	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	10/22/21 02:43	10.0	8.3	8.3	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/22/21 02:38	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/22/21 02:48	200.0	189.0	189.6	R-A /Span * 100		0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/22/21 02:38	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/22/21 02:43	10.0	8.8	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/22/21 02:38	21.0	18.3	18.3	R-A		0.0
	Zero	10/22/21 02:43	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/22/21 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/22/21 03:25	200.0	177.3	178.9	R-A /Span * 100		0.8
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/22/21 03:15	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	10/22/21 03:19	10.0	9.1	9.1	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/22/21 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/22/21 03:25	200.0	189.0	187.7	R-A /Span * 100		0.7

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/22/21 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/22/21 03:19	10.0	9.0	8.8	R-A /Span * 100		2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/22/21 03:15	21.0	18.2	18.3	R-A		0.1
	Zero	10/22/21 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/23/21 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/23/21 02:25	200.0	189.0	189.7	R-A /Span * 100		0.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/23/21 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/23/21 02:19	30.0	27.7	27.2	R-A /Span * 100		1.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/23/21 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/23/21 02:25	200.0	189.0	185.6	R-A /Span * 100		1.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/23/21 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/23/21 02:20	30.0	23.7	23.1	R-A /Span * 100		2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/23/21 02:51	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/23/21 03:02	200.0	177.4	178.1	R-A /Span * 100		0.4
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/23/21 02:51	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	10/23/21 02:56	10.0	8.3	8.3	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/23/21 02:51	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/23/21 03:02	200.0	189.0	189.7	R-A /Span * 100		0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/23/21 02:51	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/23/21 02:56	10.0	8.8	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/23/21 02:51	21.0	18.3	18.3	R-A		0.0
	Zero	10/23/21 02:56	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/23/21 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/23/21 03:25	200.0	177.3	177.2	R-A /Span * 100		0.1

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/23/21 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	10/23/21 03:20	10.0	9.1	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/23/21 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	10/23/21 03:25	200.0	189.0	R-A /Span * 100		0.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/23/21 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	10/23/21 03:20	10.0	9.0	R-A /Span * 100		2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/23/21 03:15	21.0	18.2	R-A		0.1
	Zero	10/23/21 03:20	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/24/21 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	10/24/21 02:25	200.0	189.0	R-A /Span * 100		0.5
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/24/21 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	10/24/21 02:20	30.0	27.7	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/24/21 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/24/21 02:25	200.0	189.0	R-A /Span * 100		1.5
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/24/21 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	10/24/21 02:20	30.0	27.7	R-A /Span * 100		1.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/24/21 03:05	200.0	0.0	R-A /Span * 100		0.1
	High	10/24/21 03:16	200.0	177.4	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/24/21 03:05	10.0	0.0	R-A /Span * 100		1.0
	High	10/24/21 03:11	10.0	8.3	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/24/21 03:05	200.0	0.0	R-A /Span * 100		0.0
	High	10/24/21 03:16	200.0	189.0	R-A /Span * 100		0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/24/21 03:05	10.0	0.0	R-A /Span * 100		0.0
	High	10/24/21 03:11	10.0	8.8	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/24/21 03:05	21.0	18.3	R-A		0.0
	Zero	10/24/21 03:11	21.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/24/21 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/24/21 03:24	200.0	177.3	R-A /Span * 100		0.8
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/24/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/24/21 03:19	10.0	9.1	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/24/21 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/24/21 03:24	200.0	189.0	R-A /Span * 100		0.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/24/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/24/21 03:19	10.0	9.0	R-A /Span * 100		2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/24/21 03:14	21.0	18.2	R-A		0.1
	Zero	10/24/21 03:19	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/25/21 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/25/21 02:25	200.0	189.0	R-A /Span * 100		0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/25/21 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	10/25/21 02:19	30.0	27.7	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/25/21 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	10/25/21 02:25	200.0	189.0	R-A /Span * 100		1.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/25/21 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	10/25/21 02:20	30.0	27.7	R-A /Span * 100		1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/25/21 03:14	200.0	0.0	R-A /Span * 100		0.1
	High	10/25/21 03:24	200.0	177.4	R-A /Span * 100		0.9
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/25/21 03:14	10.0	0.0	R-A /Span * 100		1.0
	High	10/25/21 03:19	10.0	8.3	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/25/21 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/25/21 03:24	200.0	189.0		R-A /Span * 100	0.5
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/25/21 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	10/25/21 03:19	10.0	8.8		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/25/21 03:14	21.0	18.3		R-A	0.0
	Zero	10/25/21 03:19	21.0	0.0		R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/25/21 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/25/21 03:25	200.0	177.3		R-A /Span * 100	0.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/25/21 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	10/25/21 03:19	10.0	9.1		R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/25/21 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/25/21 03:25	200.0	189.0		R-A /Span * 100	0.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/25/21 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	10/25/21 03:19	10.0	9.0		R-A /Span * 100	2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/25/21 03:14	21.0	18.2		R-A	0.1
	Zero	10/25/21 03:19	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/26/21 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/26/21 02:25	200.0	189.0		R-A /Span * 100	0.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/26/21 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	10/26/21 02:19	30.0	27.7		R-A /Span * 100	0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/26/21 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	10/26/21 02:25	200.0	189.0		R-A /Span * 100	1.9
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/26/21 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	10/26/21 02:19	30.0	27.7		R-A /Span * 100	2.3

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/26/21 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/26/21 03:25	200.0	177.4	177.5	R-A /Span * 100		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/26/21 03:15	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	10/26/21 03:20	10.0	8.3	8.3	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/26/21 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/26/21 03:25	200.0	189.0	189.4	R-A /Span * 100		0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/26/21 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/26/21 03:20	10.0	8.8	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/26/21 03:15	21.0	18.3	18.3	R-A		0.0
	Zero	10/26/21 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/26/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/26/21 03:25	200.0	177.3	176.4	R-A /Span * 100		0.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/26/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/26/21 03:19	10.0	9.1	9.0	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/26/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/26/21 03:25	200.0	189.0	188.5	R-A /Span * 100		0.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/26/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/26/21 03:19	10.0	9.0	8.8	R-A /Span * 100		2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/26/21 03:14	21.0	18.2	18.3	R-A		0.1
	Zero	10/26/21 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/27/21 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/27/21 02:25	200.0	189.0	190.0	R-A /Span * 100		0.5
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/27/21 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/27/21 02:19	30.0	27.7	27.5	R-A /Span * 100		0.7

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/27/21 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/27/21 02:25	200.0	189.0	185.0	R-A /Span * 100		2.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/27/21 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/27/21 02:19	30.0	27.7	27.0	R-A /Span * 100		2.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/27/21 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	10/27/21 03:24	200.0	177.4	176.9	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/27/21 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	10/27/21 03:19	10.0	8.3	8.3	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/27/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/27/21 03:24	200.0	189.0	189.2	R-A /Span * 100		0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/27/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/27/21 03:19	10.0	8.8	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/27/21 03:14	21.0	18.3	18.3	R-A		0.0
	Zero	10/27/21 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/27/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/27/21 03:24	200.0	177.3	175.4	R-A /Span * 100		1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/27/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/27/21 03:19	10.0	9.1	8.9	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/27/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/27/21 03:24	200.0	189.0	188.1	R-A /Span * 100		0.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/27/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/27/21 03:19	10.0	9.0	8.8	R-A /Span * 100		2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/27/21 03:14	21.0	18.2	18.3	R-A		0.1
	Zero	10/27/21 03:19	21.0	0.0	0.0	R-A		0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/28/21 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/28/21 02:24	200.0	189.0	189.7	R-A /Span * 100		0.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/28/21 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/28/21 02:19	30.0	27.7	27.4	R-A /Span * 100		1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/28/21 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/28/21 02:25	200.0	189.0	185.2	R-A /Span * 100		1.9
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/28/21 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/28/21 02:20	30.0	27.7	27.0	R-A /Span * 100		2.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/28/21 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	10/28/21 03:25	200.0	177.4	177.5	R-A /Span * 100		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/28/21 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	10/28/21 03:19	10.0	8.3	8.3	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/28/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/28/21 03:25	200.0	189.0	189.7	R-A /Span * 100		0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/28/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/28/21 03:19	10.0	8.8	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/28/21 03:14	21.0	18.3	18.3	R-A		0.0
	Zero	10/28/21 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/28/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/28/21 03:25	200.0	177.3	176.3	R-A /Span * 100		0.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/28/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/28/21 03:19	10.0	9.1	8.9	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/28/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/28/21 03:25	200.0	189.0	188.3	R-A /Span * 100		0.4

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/28/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/28/21 03:19	10.0	9.0	8.8	R-A /Span * 100		2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/28/21 03:14	21.0	18.2	18.3	R-A		0.1
	Zero	10/28/21 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/29/21 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/29/21 02:25	200.0	189.0	186.8	R-A /Span * 100		1.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/29/21 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/29/21 02:20	30.0	27.7	27.3	R-A /Span * 100		1.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/29/21 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/29/21 02:25	200.0	189.0	185.4	R-A /Span * 100		1.8
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/29/21 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/29/21 02:19	30.0	27.7	27.0	R-A /Span * 100		2.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/29/21 03:14	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	10/29/21 03:24	200.0	177.2	177.8	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/29/21 03:14	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	10/29/21 03:19	10.0	8.3	8.3	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/29/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/29/21 03:24	200.0	189.0	189.9	R-A /Span * 100		0.5
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/29/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/29/21 03:19	10.0	8.8	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/29/21 03:14	21.0	18.1	18.0	R-A		0.1
	Zero	10/29/21 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/29/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/29/21 03:25	200.0	177.3	176.5	R-A /Span * 100		0.4

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/29/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/29/21 03:20	10.0	9.1	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/29/21 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/29/21 03:25	200.0	189.0	R-A /Span * 100		0.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/29/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/29/21 03:20	10.0	9.0	R-A /Span * 100		2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	10/29/21 03:14	21.0	18.2	R-A		0.1
	Zero	10/29/21 03:20	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/30/21 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/30/21 02:24	200.0	189.0	R-A /Span * 100		0.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/30/21 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	10/30/21 02:20	30.0	27.7	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/30/21 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	10/30/21 02:25	200.0	189.0	R-A /Span * 100		0.9
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/30/21 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	10/30/21 02:20	30.0	27.7	R-A /Span * 100		1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/30/21 03:14	200.0	0.0	R-A /Span * 100		0.1
	High	10/30/21 03:24	200.0	177.2	R-A /Span * 100		0.5
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/30/21 03:14	10.0	0.0	R-A /Span * 100		1.0
	High	10/30/21 03:19	10.0	8.3	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	10/30/21 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	10/30/21 03:24	200.0	189.0	R-A /Span * 100		0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	10/30/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	10/30/21 03:19	10.0	8.8	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/30/21 03:14	21.0	18.1	18.0	R-A		0.1
	Zero	10/30/21 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/30/21 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/30/21 03:25	200.0	177.3	177.5	R-A /Span * 100		0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/30/21 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/30/21 03:20	10.0	9.1	8.9	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/30/21 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/30/21 03:25	200.0	189.0	188.3	R-A /Span * 100		0.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/30/21 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/30/21 03:20	10.0	9.0	8.8	R-A /Span * 100		2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/30/21 03:15	21.0	18.2	18.3	R-A		0.1
	Zero	10/30/21 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/31/21 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/31/21 02:25	200.0	189.0	190.4	R-A /Span * 100		0.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/31/21 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/31/21 02:20	30.0	27.7	27.4	R-A /Span * 100		1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/31/21 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/31/21 02:25	200.0	189.0	186.5	R-A /Span * 100		1.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/31/21 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/31/21 02:20	30.0	27.7	27.2	R-A /Span * 100		1.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/31/21 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/31/21 03:25	200.0	177.2	177.8	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/31/21 03:15	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	10/31/21 03:20	10.0	8.3	8.3	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/31/21 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/31/21 03:25	200.0	189.0	189.7	R-A /Span * 100		0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/31/21 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/31/21 03:20	10.0	8.8	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/31/21 03:15	21.0	18.1	18.0	R-A		0.1
	Zero	10/31/21 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/31/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/31/21 03:24	200.0	177.3	177.6	R-A /Span * 100		0.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/31/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/31/21 03:20	10.0	9.1	8.9	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	10/31/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/31/21 03:24	200.0	189.0	188.4	R-A /Span * 100		0.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	10/31/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	10/31/21 03:20	10.0	9.0	8.8	R-A /Span * 100		2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	10/31/21 03:14	21.0	18.2	18.3	R-A		0.1
	Zero	10/31/21 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/01/21 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/01/21 02:25	200.0	189.0	190.1	R-A /Span * 100		0.6
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/01/21 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/01/21 02:20	30.0	27.7	27.3	R-A /Span * 100		1.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/01/21 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/01/21 02:24	200.0	189.0	186.4	R-A /Span * 100		1.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/01/21 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/01/21 02:20	30.0	27.7	27.1	R-A /Span * 100		2.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:08 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/01/21 03:15	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	11/01/21 03:25	200.0	177.2	177.8	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/01/21 03:15	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	11/01/21 03:19	10.0	8.3	8.3	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/01/21 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/01/21 03:25	200.0	189.0	189.1	R-A /Span * 100		0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/01/21 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/01/21 03:19	10.0	8.8	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/01/21 03:15	21.0	18.1	18.0	R-A		0.1
	Zero	11/01/21 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/01/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/01/21 03:25	200.0	177.3	178.1	R-A /Span * 100		0.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/01/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/01/21 03:20	10.0	9.1	9.0	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/01/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/01/21 03:25	200.0	189.0	188.3	R-A /Span * 100		0.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/01/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/01/21 03:20	10.0	9.0	8.8	R-A /Span * 100		2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/01/21 03:14	21.0	18.2	18.3	R-A		0.1
	Zero	11/01/21 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/02/21 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/02/21 02:25	200.0	189.0	189.3	R-A /Span * 100		0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/02/21 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/02/21 02:20	30.0	27.7	27.3	R-A /Span * 100		1.3

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/02/21 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/02/21 02:25	200.0	189.0	185.7	R-A /Span * 100		1.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/02/21 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/02/21 02:20	30.0	27.7	27.1	R-A /Span * 100		2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/02/21 03:14	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	11/02/21 03:25	200.0	177.2	176.9	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/02/21 03:14	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	11/02/21 03:20	10.0	8.3	8.3	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/02/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/02/21 03:25	200.0	189.0	188.8	R-A /Span * 100		0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/02/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/02/21 03:20	10.0	8.8	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/02/21 03:14	21.0	18.1	18.0	R-A		0.1
	Zero	11/02/21 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/02/21 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/02/21 03:25	200.0	177.3	176.9	R-A /Span * 100		0.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/02/21 03:15	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	11/02/21 03:20	10.0	9.0	8.9	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/02/21 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/02/21 03:25	200.0	189.0	187.9	R-A /Span * 100		0.6
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/02/21 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/02/21 03:20	10.0	8.8	8.7	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/02/21 03:15	21.0	18.2	18.3	R-A		0.1
	Zero	11/02/21 03:20	21.0	0.0	0.0	R-A		0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:08 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/03/21 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/03/21 02:25	200.0	189.0	190.4	R-A /Span * 100		0.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/03/21 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/03/21 02:19	30.0	27.7	27.5	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/03/21 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/03/21 02:25	200.0	189.0	186.1	R-A /Span * 100		1.5
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/03/21 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/03/21 02:19	30.0	27.7	27.1	R-A /Span * 100		2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/03/21 03:15	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	11/03/21 03:25	200.0	177.2	177.1	R-A /Span * 100		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/03/21 03:15	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	11/03/21 03:20	10.0	8.3	8.3	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/03/21 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/03/21 03:25	200.0	189.0	189.0	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/03/21 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/03/21 03:20	10.0	8.8	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/03/21 03:15	21.0	18.1	18.0	R-A		0.1
	Zero	11/03/21 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/03/21 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/03/21 03:25	200.0	177.3	176.7	R-A /Span * 100		0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/03/21 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/03/21 03:20	10.0	9.0	8.9	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/03/21 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/03/21 03:25	200.0	189.0	188.0	R-A /Span * 100		0.5

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/03/21 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	11/03/21 03:20	10.0	8.8		R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/03/21 03:15	21.0	18.2		R-A	0.1
	Zero	11/03/21 03:20	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/04/21 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/04/21 02:25	200.0	189.0		R-A /Span * 100	0.5
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/04/21 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	11/04/21 02:19	30.0	27.7		R-A /Span * 100	1.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/04/21 02:15	200.0	0.0		R-A /Span * 100	0.0
	High	11/04/21 02:25	200.0	189.0		R-A /Span * 100	2.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/04/21 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	11/04/21 02:20	30.0	27.7	>1x Alert	R-A /Span * 100	2.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/04/21 03:14	200.0	0.0		R-A /Span * 100	0.1
	High	11/04/21 03:25	200.0	177.2		R-A /Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/04/21 03:14	10.0	0.0		R-A /Span * 100	1.0
	High	11/04/21 03:19	10.0	8.3		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/04/21 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/04/21 03:25	200.0	189.0		R-A /Span * 100	0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/04/21 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/04/21 03:19	10.0	8.8		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/04/21 03:14	21.0	18.1		R-A	0.1
	Zero	11/04/21 03:19	21.0	0.0		R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/04/21 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/04/21 03:25	200.0	177.3		R-A /Span * 100	0.3

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:08 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/04/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	11/04/21 03:20	10.0	9.0	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/04/21 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	11/04/21 03:25	200.0	189.0	R-A /Span * 100		0.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/04/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	11/04/21 03:20	10.0	8.8	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/04/21 03:14	21.0	18.2	R-A		0.1
	Zero	11/04/21 03:20	21.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/04/21 08:14	200.0	0.0	R-A /Span * 100		0.1
	High	11/04/21 08:24	200.0	177.3	R-A /Span * 100		1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/04/21 08:14	10.0	0.0	R-A /Span * 100		1.0
	High	11/04/21 08:19	10.0	9.0	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/04/21 08:14	200.0	0.0	R-A /Span * 100		0.0
	High	11/04/21 08:24	200.0	189.0	R-A /Span * 100		0.5
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/04/21 08:14	10.0	0.0	R-A /Span * 100		0.0
	High	11/04/21 08:19	10.0	8.8	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/04/21 08:14	21.0	18.2	R-A		0.1
	Zero	11/04/21 08:19	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/05/21 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	11/05/21 02:25	200.0	189.0	R-A /Span * 100		0.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/05/21 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	11/05/21 02:20	30.0	27.7	R-A /Span * 100		1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/05/21 02:15	200.0	0.0	R-A /Span * 100		0.1
	High	11/05/21 02:25	200.0	189.0	R-A /Span * 100		2.2

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/05/21 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	11/05/21 02:19	30.0	27.7	26.8 >1x Alert	R-A /Span * 100	3.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/05/21 03:14	200.0	0.0		R-A /Span * 100	0.1
	High	11/05/21 03:25	200.0	177.2	177.5	R-A /Span * 100	0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/05/21 03:14	10.0	0.0		R-A /Span * 100	1.0
	High	11/05/21 03:20	10.0	8.3	8.3	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/05/21 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/05/21 03:25	200.0	189.0	189.6	R-A /Span * 100	0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/05/21 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/05/21 03:20	10.0	8.8	8.9	R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/05/21 03:14	21.0	18.1	18.0	R-A	0.1
	Zero	11/05/21 03:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/05/21 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/05/21 03:25	200.0	177.3	176.8	R-A /Span * 100	0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/05/21 03:14	10.0	0.0		R-A /Span * 100	1.0
	High	11/05/21 03:19	10.0	9.0	8.8	R-A /Span * 100	2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/05/21 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/05/21 03:25	200.0	189.0	188.3	R-A /Span * 100	0.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/05/21 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/05/21 03:19	10.0	8.8	8.7	R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/05/21 03:14	21.0	18.2	18.3	R-A	0.1
	Zero	11/05/21 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/06/21 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/06/21 02:25	200.0	189.0	190.8	R-A /Span * 100	0.9

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:08 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/06/21 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/06/21 02:20	30.0	27.7	27.6	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/06/21 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/06/21 02:25	200.0	189.0	185.4	R-A /Span * 100		1.8
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/06/21 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/06/21 02:20	30.0	27.7	27.0	R-A /Span * 100		2.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/06/21 03:14	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	11/06/21 03:24	200.0	177.2	177.6	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/06/21 03:14	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	11/06/21 03:19	10.0	8.3	8.3	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/06/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/06/21 03:24	200.0	189.0	189.4	R-A /Span * 100		0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/06/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/06/21 03:19	10.0	8.8	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/06/21 03:14	21.0	18.1	18.0	R-A		0.1
	Zero	11/06/21 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/06/21 03:14	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	11/06/21 03:25	200.0	177.3	176.4	R-A /Span * 100		0.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/06/21 03:14	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	11/06/21 03:20	10.0	9.0	8.8	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/06/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/06/21 03:25	200.0	189.0	188.5	R-A /Span * 100		0.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/06/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/06/21 03:20	10.0	8.8	8.7	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:08 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/06/21 03:14	21.0	18.2	18.3	R-A	0.1
	Zero	11/06/21 03:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/07/21 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/07/21 02:24	200.0	189.0	190.7	R-A /Span * 100	0.9
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/07/21 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/07/21 02:20	30.0	27.7	27.3	R-A /Span * 100	1.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Warning	
	Zero	11/07/21 02:15	200.0	0.0	18.6	>2x R-A /Span * 100	9.3
	High	11/07/21 02:24	200.0	189.0	183.8	>1x R-A /Span * 100	2.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Fail	
	Zero	11/07/21 02:15	30.0	0.0	19.1	>4x R-A /Span * 100	63.7
	High	11/07/21 02:20	30.0	27.7	26.8	>1x R-A /Span * 100	3.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/07/21 03:14	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	11/07/21 03:24	200.0	177.2	177.4	R-A /Span * 100	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/07/21 03:14	10.0	0.0	-0.1	R-A /Span * 100	1.0
	High	11/07/21 03:19	10.0	8.3	8.3	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/07/21 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/07/21 03:24	200.0	189.0	189.6	R-A /Span * 100	0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/07/21 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/07/21 03:19	10.0	8.8	8.8	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/07/21 03:14	21.0	18.1	18.0	R-A	0.1
	Zero	11/07/21 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/07/21 03:14	200.0	0.0	0.4	R-A /Span * 100	0.2
	High	11/07/21 03:25	200.0	177.3	175.6	R-A /Span * 100	0.9
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/07/21 03:14	10.0	0.0	0.5	R-A /Span * 100	5.0
	High	11/07/21 03:20	10.0	9.0	8.8	R-A /Span * 100	2.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/07/21 03:14	200.0	0.0	1.6	R-A /Span * 100	0.8
	High	11/07/21 03:25	200.0	189.0	188.8	R-A /Span * 100	0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/07/21 03:14	10.0	0.0	1.6	R-A	1.6
	High	11/07/21 03:20	10.0	8.8	8.7	R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Fail	
	High	11/07/21 03:14	21.0	18.1	14.8	>2x R-A	3.3
	Zero	11/07/21 03:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/07/21 05:12	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/07/21 05:23	200.0	177.3	175.4	R-A /Span * 100	1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/07/21 05:12	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	11/07/21 05:17	10.0	9.0	8.8	R-A /Span * 100	2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/07/21 05:12	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/07/21 05:23	200.0	189.0	188.6	R-A /Span * 100	0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/07/21 05:12	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/07/21 05:17	10.0	8.8	8.7	R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/07/21 05:12	21.0	18.1	18.2	R-A	0.1
	Zero	11/07/21 05:17	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/07/21 06:06	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	11/07/21 06:16	200.0	189.0	190.4	R-A /Span * 100	0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/07/21 06:06	30.0	0.0	0.1	R-A /Span * 100	0.3
	High	11/07/21 06:11	30.0	27.7	28.4	R-A /Span * 100	2.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/08/21 02:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/08/21 02:25	200.0	189.0	192.1	R-A /Span * 100	1.6
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/08/21 02:15	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/08/21 02:20	30.0	27.7	27.7	R-A /Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:08 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/08/21 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	11/08/21 02:25	200.0	189.0	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/08/21 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	11/08/21 02:20	30.0	27.7	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/08/21 03:14	200.0	-0.1	R-A /Span * 100		0.1
	High	11/08/21 03:25	200.0	177.2	R-A /Span * 100		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/08/21 03:14	10.0	-0.1	R-A /Span * 100		1.0
	High	11/08/21 03:19	10.0	8.3	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/08/21 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	11/08/21 03:25	200.0	189.0	R-A /Span * 100		0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/08/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	11/08/21 03:19	10.0	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/08/21 03:14	21.0	18.1	R-A		0.1
	Zero	11/08/21 03:19	21.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/08/21 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	11/08/21 03:25	200.0	177.3	R-A /Span * 100		0.9
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/08/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	11/08/21 03:19	10.0	9.0	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/08/21 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	11/08/21 03:25	200.0	189.0	R-A /Span * 100		0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/08/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	11/08/21 03:19	10.0	8.8	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/08/21 03:14	21.0	18.1	R-A		0.1
	Zero	11/08/21 03:19	21.0	0.0	R-A		0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/09/21 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/09/21 02:25	200.0	189.0	190.7	R-A /Span * 100		0.9
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/09/21 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/09/21 02:20	30.0	27.7	27.4	R-A /Span * 100		1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/09/21 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/09/21 02:25	200.0	180.0	178.8	R-A /Span * 100		0.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/09/21 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/09/21 02:20	30.0	27.7	27.6	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/09/21 03:14	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	11/09/21 03:25	200.0	177.2	177.6	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/09/21 03:14	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	11/09/21 03:19	10.0	8.3	8.3	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/09/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/09/21 03:25	200.0	189.0	189.2	R-A /Span * 100		0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/09/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/09/21 03:19	10.0	8.8	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/09/21 03:14	21.0	18.1	18.0	R-A		0.1
	Zero	11/09/21 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/09/21 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/09/21 03:25	200.0	185.1	182.1	R-A /Span * 100		1.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/09/21 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/09/21 03:20	10.0	9.0	8.8	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/09/21 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/09/21 03:25	200.0	180.0	179.6	R-A /Span * 100		0.2

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/09/21 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	11/09/21 03:20	10.0	8.8	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/09/21 03:15	21.0	18.1	R-A		0.1
	Zero	11/09/21 03:20	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/10/21 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	11/10/21 02:25	200.0	189.0	R-A /Span * 100		0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/10/21 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	11/10/21 02:20	30.0	27.7	R-A /Span * 100		1.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/10/21 02:15	200.0	0.0	R-A /Span * 100		0.1
	High	11/10/21 02:25	200.0	180.0	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/10/21 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	11/10/21 02:20	30.0	27.7	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/10/21 03:14	200.0	0.0	R-A /Span * 100		0.1
	High	11/10/21 03:25	200.0	177.2	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/10/21 03:14	10.0	0.0	R-A /Span * 100		1.0
	High	11/10/21 03:19	10.0	8.3	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/10/21 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	11/10/21 03:25	200.0	189.0	R-A /Span * 100		0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/10/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	11/10/21 03:19	10.0	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/10/21 03:14	21.0	18.1	R-A		0.1
	Zero	11/10/21 03:19	21.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/10/21 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	11/10/21 03:25	200.0	185.1	R-A /Span * 100		1.9

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/10/21 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/10/21 03:19	10.0	9.0	8.8	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/10/21 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/10/21 03:25	200.0	180.0	179.4	R-A /Span * 100		0.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/10/21 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/10/21 03:19	10.0	8.8	8.7	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/10/21 03:15	21.0	18.1	18.2	R-A		0.1
	Zero	11/10/21 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/11/21 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/11/21 02:25	200.0	189.0	190.6	R-A /Span * 100		0.8
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/11/21 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/11/21 02:19	30.0	27.7	27.5	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/11/21 02:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	11/11/21 02:25	200.0	180.0	180.4	R-A /Span * 100		0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/11/21 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/11/21 02:20	30.0	27.7	27.7	R-A /Span * 100		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/11/21 03:14	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	11/11/21 03:25	200.0	177.2	176.8	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/11/21 03:14	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	11/11/21 03:19	10.0	8.3	8.3	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/11/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/11/21 03:25	200.0	189.0	189.5	R-A /Span * 100		0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/11/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/11/21 03:19	10.0	8.8	8.8	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:08 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/11/21 03:14	21.0	18.1	18.0	R-A	0.1
	Zero	11/11/21 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/11/21 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/11/21 03:25	200.0	185.1	182.4	R-A /Span * 100	1.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/11/21 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/11/21 03:19	10.0	9.0	8.9	R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/11/21 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/11/21 03:25	200.0	180.0	179.6	R-A /Span * 100	0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/11/21 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/11/21 03:19	10.0	8.8	8.7	R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/11/21 03:14	21.0	18.1	18.2	R-A	0.1
	Zero	11/11/21 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/12/21 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/12/21 02:24	200.0	189.0	189.3	R-A /Span * 100	0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/12/21 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/12/21 02:20	30.0	27.7	27.3	R-A /Span * 100	1.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/12/21 02:15	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	11/12/21 02:25	200.0	180.0	180.2	R-A /Span * 100	0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/12/21 02:15	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/12/21 02:20	30.0	27.7	27.7	R-A /Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/12/21 03:14	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	11/12/21 03:25	200.0	177.2	177.1	R-A /Span * 100	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/12/21 03:14	10.0	0.0	-0.1	R-A /Span * 100	1.0
	High	11/12/21 03:19	10.0	8.3	8.3	R-A /Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:08 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/12/21 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/12/21 03:25	200.0	189.0		R-A /Span * 100	0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/12/21 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/12/21 03:19	10.0	8.8		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/12/21 03:14	21.0	18.1		R-A	0.1
	Zero	11/12/21 03:19	21.0	0.0		R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/12/21 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/12/21 03:25	200.0	185.1		R-A /Span * 100	1.6
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/12/21 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/12/21 03:19	10.0	9.0		R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/12/21 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/12/21 03:25	200.0	180.0		R-A /Span * 100	0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/12/21 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/12/21 03:19	10.0	8.8		R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/12/21 03:14	21.0	18.1		R-A	0.1
	Zero	11/12/21 03:19	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/13/21 02:15	200.0	0.0		R-A /Span * 100	0.0
	High	11/13/21 02:25	200.0	189.0		R-A /Span * 100	0.8
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/13/21 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	11/13/21 02:20	30.0	27.7		R-A /Span * 100	1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/13/21 02:15	200.0	0.0		R-A /Span * 100	0.0
	High	11/13/21 02:24	200.0	180.0		R-A /Span * 100	0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/13/21 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	11/13/21 02:19	30.0	27.7		R-A /Span * 100	0.3

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:08 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/13/21 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	11/13/21 03:24	200.0	185.1	R-A /Span * 100		1.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/13/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	11/13/21 03:20	10.0	9.0	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/13/21 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	11/13/21 03:24	200.0	180.0	R-A /Span * 100		0.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/13/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	11/13/21 03:20	10.0	8.8	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/13/21 03:14	21.0	18.1	R-A		0.1
	Zero	11/13/21 03:20	21.0	0.0	R-A		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/13/21 03:14	200.0	0.0	R-A /Span * 100		0.1
	High	11/13/21 03:24	200.0	177.2	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/13/21 03:14	10.0	0.0	R-A /Span * 100		1.0
	High	11/13/21 03:20	10.0	8.3	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/13/21 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	11/13/21 03:24	200.0	189.0	R-A /Span * 100		0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/13/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	11/13/21 03:20	10.0	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/13/21 03:14	21.0	18.1	R-A		0.1
	Zero	11/13/21 03:20	21.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/14/21 02:14	200.0	0.0	R-A /Span * 100		0.1
	High	11/14/21 02:24	200.0	180.0	R-A /Span * 100		0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/14/21 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	11/14/21 02:19	30.0	27.7	R-A /Span * 100		0.3

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:08 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/14/21 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/14/21 02:25	200.0	189.0	190.7	R-A /Span * 100		0.9
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/14/21 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/14/21 02:19	30.0	27.7	27.4	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/14/21 03:14	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	11/14/21 03:25	200.0	177.2	176.8	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/14/21 03:14	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	11/14/21 03:20	10.0	8.3	8.3	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/14/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/14/21 03:25	200.0	189.0	189.4	R-A /Span * 100		0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/14/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/14/21 03:20	10.0	8.8	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/14/21 03:14	21.0	18.1	18.0	R-A		0.1
	Zero	11/14/21 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/14/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/14/21 03:25	200.0	185.1	181.9	R-A /Span * 100		1.6
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/14/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/14/21 03:20	10.0	9.0	8.9	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/14/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/14/21 03:25	200.0	180.0	179.3	R-A /Span * 100		0.4
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/14/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/14/21 03:20	10.0	8.8	8.7	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/14/21 03:14	21.0	18.1	18.2	R-A		0.1
	Zero	11/14/21 03:20	21.0	0.0	0.0	R-A		0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/15/21 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/15/21 02:25	200.0	189.0	190.6	R-A /Span * 100		0.8
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/15/21 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/15/21 02:20	30.0	27.7	27.5	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/15/21 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/15/21 02:24	200.0	180.0	179.9	R-A /Span * 100		0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/15/21 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/15/21 02:19	30.0	27.7	27.6	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/15/21 03:14	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	11/15/21 03:25	200.0	177.2	177.1	R-A /Span * 100		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/15/21 03:14	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	11/15/21 03:19	10.0	8.3	8.3	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/15/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/15/21 03:25	200.0	189.0	189.5	R-A /Span * 100		0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/15/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/15/21 03:19	10.0	8.8	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/15/21 03:14	21.0	18.1	18.0	R-A		0.1
	Zero	11/15/21 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/15/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/15/21 03:24	200.0	185.1	182.8	R-A /Span * 100		1.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/15/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/15/21 03:19	10.0	9.0	8.9	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/15/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/15/21 03:24	200.0	180.0	179.6	R-A /Span * 100		0.2

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/15/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	11/15/21 03:19	10.0	8.8	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/15/21 03:14	21.0	18.1	R-A		0.1
	Zero	11/15/21 03:19	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/16/21 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	11/16/21 02:24	200.0	189.0	R-A /Span * 100		0.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/16/21 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	11/16/21 02:20	30.0	27.7	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/16/21 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	11/16/21 02:25	200.0	180.0	R-A /Span * 100		0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/16/21 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	11/16/21 02:20	30.0	27.7	R-A /Span * 100		2.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/16/21 03:14	200.0	0.0	R-A /Span * 100		0.1
	High	11/16/21 03:25	200.0	177.2	R-A /Span * 100		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/16/21 03:14	10.0	0.0	R-A /Span * 100		1.0
	High	11/16/21 03:20	10.0	8.3	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/16/21 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	11/16/21 03:25	200.0	189.0	R-A /Span * 100		0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/16/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	11/16/21 03:20	10.0	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/16/21 03:14	21.0	18.1	R-A		0.1
	Zero	11/16/21 03:20	21.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/16/21 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	11/16/21 03:24	200.0	185.1	R-A /Span * 100		1.3

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/16/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	11/16/21 03:19	10.0	9.0	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/16/21 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	11/16/21 03:24	200.0	180.0	R-A /Span * 100		0.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/16/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	11/16/21 03:19	10.0	8.8	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/16/21 03:14	21.0	18.1	R-A		0.1
	Zero	11/16/21 03:19	21.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/17/21 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	11/17/21 02:24	200.0	180.0	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/17/21 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	11/17/21 02:19	30.0	27.7	R-A /Span * 100		1.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/17/21 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	11/17/21 02:25	200.0	189.0	R-A /Span * 100		1.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/17/21 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	11/17/21 02:19	30.0	27.7	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/17/21 03:14	200.0	0.0	R-A /Span * 100		0.1
	High	11/17/21 03:25	200.0	177.2	R-A /Span * 100		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/17/21 03:14	10.0	0.0	R-A /Span * 100		1.0
	High	11/17/21 03:19	10.0	8.3	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/17/21 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	11/17/21 03:25	200.0	189.0	R-A /Span * 100		0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/17/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	11/17/21 03:19	10.0	8.8	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:08 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/17/21 03:14	21.0	18.1	18.0	R-A	0.1
	Zero	11/17/21 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/17/21 03:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/17/21 03:25	200.0	185.1	182.2	R-A /Span * 100	1.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/17/21 03:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/17/21 03:20	10.0	9.0	8.9	R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/17/21 03:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/17/21 03:25	200.0	180.0	179.8	R-A /Span * 100	0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/17/21 03:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/17/21 03:20	10.0	8.8	8.7	R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/17/21 03:15	21.0	18.1	18.2	R-A	0.1
	Zero	11/17/21 03:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/18/21 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/18/21 02:24	200.0	189.0	192.4	R-A /Span * 100	1.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/18/21 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/18/21 02:19	30.0	27.7	27.7	R-A /Span * 100	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/18/21 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/18/21 02:24	200.0	180.0	179.8	R-A /Span * 100	0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/18/21 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/18/21 02:19	30.0	27.7	27.0	R-A /Span * 100	2.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/18/21 03:14	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	11/18/21 03:25	200.0	177.2	177.2	R-A /Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/18/21 03:14	10.0	0.0	-0.1	R-A /Span * 100	1.0
	High	11/18/21 03:20	10.0	8.3	8.3	R-A /Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:08 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/18/21 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/18/21 03:25	200.0	189.0		R-A /Span * 100	0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/18/21 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/18/21 03:20	10.0	8.8		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/18/21 03:14	21.0	18.1		R-A	0.1
	Zero	11/18/21 03:20	21.0	0.0		R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/18/21 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/18/21 03:24	200.0	185.1		R-A /Span * 100	1.6
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/18/21 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/18/21 03:19	10.0	9.0		R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/18/21 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/18/21 03:24	200.0	180.0		R-A /Span * 100	0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/18/21 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/18/21 03:19	10.0	8.8		R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/18/21 03:14	21.0	18.1		R-A	0.1
	Zero	11/18/21 03:19	21.0	0.0		R-A	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/19/21 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/19/21 02:24	200.0	180.0		R-A /Span * 100	0.5
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/19/21 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	11/19/21 02:19	30.0	27.7		R-A /Span * 100	2.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/19/21 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/19/21 03:24	200.0	185.1		R-A /Span * 100	1.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/19/21 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/19/21 03:19	10.0	9.0		R-A /Span * 100	2.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:08 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/19/21 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	11/19/21 03:24	200.0	180.0	R-A /Span * 100		0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/19/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	11/19/21 03:19	10.0	8.8	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/19/21 03:14	21.0	18.1	R-A		0.1
	Zero	11/19/21 03:19	21.0	0.0	R-A		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/19/21 11:29	200.0	0.0	R-A /Span * 100		0.1
	High	11/19/21 11:40	200.0	177.2	R-A /Span * 100		0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/19/21 11:29	10.0	0.0	R-A /Span * 100		1.0
	High	11/19/21 11:35	10.0	8.3	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/19/21 11:29	200.0	0.0	R-A /Span * 100		0.0
	High	11/19/21 11:40	200.0	189.0	R-A /Span * 100		0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/19/21 11:29	10.0	0.0	R-A /Span * 100		0.0
	High	11/19/21 11:35	10.0	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/19/21 11:29	21.0	18.1	R-A		0.1
	Zero	11/19/21 11:35	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/20/21 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	11/20/21 02:25	200.0	189.0	R-A /Span * 100		1.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/20/21 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	11/20/21 02:19	30.0	27.7	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/20/21 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	11/20/21 02:25	200.0	180.0	R-A /Span * 100		0.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/20/21 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	11/20/21 02:19	30.0	27.7	R-A /Span * 100		3.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:08 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/20/21 03:14	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	11/20/21 03:24	200.0	177.2	177.4	R-A /Span * 100	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/20/21 03:14	10.0	0.0	-0.1	R-A /Span * 100	1.0
	High	11/20/21 03:20	10.0	8.3	8.3	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/20/21 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/20/21 03:24	200.0	189.0	189.5	R-A /Span * 100	0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/20/21 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/20/21 03:20	10.0	8.8	8.8	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/20/21 03:14	21.0	18.1	18.0	R-A	0.1
	Zero	11/20/21 03:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/20/21 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/20/21 03:25	200.0	185.1	182.1	R-A /Span * 100	1.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/20/21 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/20/21 03:20	10.0	9.0	8.8	R-A /Span * 100	2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/20/21 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/20/21 03:25	200.0	180.0	179.9	R-A /Span * 100	0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/20/21 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/20/21 03:20	10.0	8.8	8.7	R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/20/21 03:14	21.0	18.1	18.2	R-A	0.1
	Zero	11/20/21 03:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/21/21 02:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/21/21 02:25	200.0	189.0	192.2	R-A /Span * 100	1.6
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/21/21 02:15	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/21/21 02:19	30.0	27.7	27.7	R-A /Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:08 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/21/21 02:15	200.0	0.0		R-A /Span * 100	0.1
	High	11/21/21 02:25	200.0	180.0		R-A /Span * 100	0.5
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/21/21 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	11/21/21 02:19	30.0	27.7	>1x Alert	R-A /Span * 100	2.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/21/21 03:15	200.0	-0.1		R-A /Span * 100	0.1
	High	11/21/21 03:25	200.0	177.2		R-A /Span * 100	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/21/21 03:15	10.0	-0.1		R-A /Span * 100	1.0
	High	11/21/21 03:19	10.0	8.3		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/21/21 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	11/21/21 03:25	200.0	189.0		R-A /Span * 100	0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/21/21 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	11/21/21 03:19	10.0	8.8		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/21/21 03:15	21.0	18.1		R-A	0.1
	Zero	11/21/21 03:19	21.0	0.0		R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/21/21 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/21/21 03:24	200.0	185.1		R-A /Span * 100	2.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/21/21 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/21/21 03:19	10.0	9.0		R-A /Span * 100	2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/21/21 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/21/21 03:24	200.0	180.0		R-A /Span * 100	0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/21/21 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/21/21 03:19	10.0	8.8		R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/21/21 03:14	21.0	18.1		R-A	0.1
	Zero	11/21/21 03:19	21.0	0.0		R-A	0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:08 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/22/21 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/22/21 02:24	200.0	189.0	192.0	R-A /Span * 100		1.5
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/22/21 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/22/21 02:19	30.0	27.7	27.7	R-A /Span * 100		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/22/21 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/22/21 02:25	200.0	180.0	179.4	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/22/21 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/22/21 02:19	30.0	27.7	27.0	R-A /Span * 100		2.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/22/21 03:15	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	11/22/21 03:25	200.0	177.2	177.2	R-A /Span * 100		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/22/21 03:15	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	11/22/21 03:20	10.0	8.3	8.3	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/22/21 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/22/21 03:25	200.0	189.0	189.4	R-A /Span * 100		0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/22/21 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/22/21 03:20	10.0	8.8	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/22/21 03:15	21.0	18.1	18.0	R-A		0.1
	Zero	11/22/21 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/22/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/22/21 03:24	200.0	185.1	181.5	R-A /Span * 100		1.8
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/22/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/22/21 03:19	10.0	9.0	8.8	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/22/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/22/21 03:24	200.0	180.0	180.1	R-A /Span * 100		0.1

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/22/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/22/21 03:19	10.0	8.8	8.7	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/22/21 03:14	21.0	18.1	18.2	R-A		0.1
	Zero	11/22/21 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/23/21 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/23/21 02:25	200.0	189.0	192.5	R-A /Span * 100		1.8
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/23/21 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/23/21 02:20	30.0	27.7	27.7	R-A /Span * 100		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/23/21 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/23/21 02:24	200.0	180.0	179.6	R-A /Span * 100		0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/23/21 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/23/21 02:20	30.0	27.7	27.0	R-A /Span * 100		2.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/23/21 03:15	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	11/23/21 03:25	200.0	177.2	177.6	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/23/21 03:15	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	11/23/21 03:20	10.0	8.3	8.3	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/23/21 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/23/21 03:25	200.0	189.0	189.1	R-A /Span * 100		0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/23/21 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/23/21 03:20	10.0	8.8	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/23/21 03:15	21.0	18.1	18.0	R-A		0.1
	Zero	11/23/21 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/23/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/23/21 03:25	200.0	185.1	181.1	R-A /Span * 100		2.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:08 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/23/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	11/23/21 03:20	10.0	9.0	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/23/21 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	11/23/21 03:25	200.0	180.0	R-A /Span * 100		0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/23/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	11/23/21 03:20	10.0	8.8	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/23/21 03:14	21.0	18.1	R-A		0.1
	Zero	11/23/21 03:20	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/24/21 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	11/24/21 02:25	200.0	189.0	194.4 >1x Alert R-A /Span * 100		2.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/24/21 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	11/24/21 02:20	30.0	27.7	R-A /Span * 100		1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/24/21 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	11/24/21 02:25	200.0	180.0	R-A /Span * 100		0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/24/21 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	11/24/21 02:19	30.0	27.7	R-A /Span * 100		2.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/24/21 03:15	200.0	0.0	R-A /Span * 100		0.1
	High	11/24/21 03:25	200.0	177.2	R-A /Span * 100		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/24/21 03:15	10.0	0.0	R-A /Span * 100		1.0
	High	11/24/21 03:20	10.0	8.3	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/24/21 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	11/24/21 03:25	200.0	189.0	R-A /Span * 100		0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/24/21 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	11/24/21 03:20	10.0	8.8	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:08 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/24/21 03:15	21.0	18.1	18.0	R-A	0.1
	Zero	11/24/21 03:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/24/21 03:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/24/21 03:25	200.0	185.1	181.7	R-A /Span * 100	1.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/24/21 03:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/24/21 03:20	10.0	9.0	8.9	R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/24/21 03:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/24/21 03:25	200.0	180.0	180.5	R-A /Span * 100	0.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/24/21 03:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/24/21 03:20	10.0	8.8	8.7	R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/24/21 03:15	21.0	18.1	18.2	R-A	0.1
	Zero	11/24/21 03:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/25/21 02:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/25/21 02:25	200.0	189.0	187.6	R-A /Span * 100	0.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/25/21 02:15	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/25/21 02:19	30.0	27.7	27.8	R-A /Span * 100	0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/25/21 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/25/21 02:25	200.0	180.0	180.8	R-A /Span * 100	0.4
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/25/21 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/25/21 02:19	30.0	27.7	27.1	R-A /Span * 100	2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/25/21 03:14	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	11/25/21 03:25	200.0	177.2	176.7	R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/25/21 03:14	10.0	0.0	-0.1	R-A /Span * 100	1.0
	High	11/25/21 03:20	10.0	8.3	8.3	R-A /Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:08 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/25/21 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	11/25/21 03:25	200.0	189.0	R-A /Span * 100		0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/25/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	11/25/21 03:20	10.0	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/25/21 03:14	21.0	18.1	R-A		0.0
	Zero	11/25/21 03:20	21.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/25/21 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	11/25/21 03:25	200.0	185.1	R-A /Span * 100		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/25/21 03:14	10.0	0.0	R-A /Span * 100		1.0
	High	11/25/21 03:20	10.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/25/21 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	11/25/21 03:25	200.0	180.0	R-A /Span * 100		0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/25/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	11/25/21 03:20	10.0	8.8	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/25/21 03:14	21.0	18.1	R-A		0.1
	Zero	11/25/21 03:20	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/26/21 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	11/26/21 02:25	200.0	189.0	R-A /Span * 100		1.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/26/21 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	11/26/21 02:20	30.0	27.7	R-A /Span * 100		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/26/21 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	11/26/21 02:25	200.0	180.0	R-A /Span * 100		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/26/21 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	11/26/21 02:20	30.0	27.7	R-A /Span * 100		2.3

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/26/21 03:14	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	11/26/21 03:24	200.0	177.2	176.9	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/26/21 03:14	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	11/26/21 03:19	10.0	8.3	8.3	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/26/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/26/21 03:24	200.0	189.0	188.8	R-A /Span * 100		0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/26/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/26/21 03:19	10.0	8.8	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/26/21 03:14	21.0	18.1	18.0	R-A		0.1
	Zero	11/26/21 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/26/21 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/26/21 03:25	200.0	185.1	185.4	R-A /Span * 100		0.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/26/21 03:15	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	11/26/21 03:19	10.0	9.0	8.9	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/26/21 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/26/21 03:25	200.0	180.0	179.6	R-A /Span * 100		0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/26/21 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/26/21 03:19	10.0	8.8	8.7	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/26/21 03:15	21.0	18.1	18.2	R-A		0.1
	Zero	11/26/21 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/27/21 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/27/21 02:25	200.0	189.0	187.3	R-A /Span * 100		0.9
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/27/21 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/27/21 02:20	30.0	27.7	27.7	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/27/21 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/27/21 02:25	200.0	180.0	180.4	R-A /Span * 100		0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/27/21 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/27/21 02:20	30.0	27.7	27.2	R-A /Span * 100		1.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/27/21 03:14	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	11/27/21 03:24	200.0	177.2	176.9	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/27/21 03:14	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	11/27/21 03:20	10.0	8.3	8.3	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/27/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/27/21 03:24	200.0	189.0	188.8	R-A /Span * 100		0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/27/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/27/21 03:20	10.0	8.8	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/27/21 03:14	21.0	18.1	18.0	R-A		0.1
	Zero	11/27/21 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/27/21 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	11/27/21 03:25	200.0	185.1	186.0	R-A /Span * 100		0.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/27/21 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	11/27/21 03:19	10.0	9.0	8.9	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/27/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/27/21 03:25	200.0	180.0	179.6	R-A /Span * 100		0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/27/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/27/21 03:19	10.0	8.8	8.7	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/27/21 03:14	21.0	18.1	18.2	R-A		0.1
	Zero	11/27/21 03:19	21.0	0.0	0.0	R-A		0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/28/21 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/28/21 02:24	200.0	189.0	187.7	R-A /Span * 100		0.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/28/21 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/28/21 02:19	30.0	27.7	27.8	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/28/21 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/28/21 02:24	200.0	180.0	180.1	R-A /Span * 100		0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/28/21 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/28/21 02:19	30.0	27.7	27.0	R-A /Span * 100		2.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/28/21 03:14	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	11/28/21 03:24	200.0	177.2	176.8	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/28/21 03:14	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	11/28/21 03:20	10.0	8.3	8.3	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/28/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/28/21 03:24	200.0	189.0	188.8	R-A /Span * 100		0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/28/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/28/21 03:20	10.0	8.8	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	11/28/21 03:14	21.0	18.1	18.0	R-A		0.1
	Zero	11/28/21 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/28/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/28/21 03:24	200.0	185.1	185.8	R-A /Span * 100		0.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	11/28/21 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	11/28/21 03:19	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	11/28/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	11/28/21 03:24	200.0	180.0	179.8	R-A /Span * 100		0.1

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/28/21 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/28/21 03:19	10.0	8.8		R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/28/21 03:14	21.0	18.1		R-A	0.1
	Zero	11/28/21 03:19	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/29/21 02:15	200.0	0.0		R-A /Span * 100	0.0
	High	11/29/21 02:25	200.0	189.0		R-A /Span * 100	1.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/29/21 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	11/29/21 02:20	30.0	27.7		R-A /Span * 100	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/29/21 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/29/21 02:25	200.0	180.0		R-A /Span * 100	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/29/21 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	11/29/21 02:19	30.0	27.7		R-A /Span * 100	2.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/29/21 03:14	200.0	0.0		R-A /Span * 100	0.1
	High	11/29/21 03:25	200.0	177.2		R-A /Span * 100	0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/29/21 03:14	10.0	0.0		R-A /Span * 100	1.0
	High	11/29/21 03:20	10.0	8.3		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/29/21 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	11/29/21 03:25	200.0	189.0		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/29/21 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	11/29/21 03:20	10.0	8.8		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/29/21 03:14	21.0	18.1		R-A	0.1
	Zero	11/29/21 03:20	21.0	0.0		R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/29/21 03:14	200.0	0.0		R-A /Span * 100	0.1
	High	11/29/21 03:25	200.0	185.1		R-A /Span * 100	0.7

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/29/21 03:14	10.0	0.0	0.2	R-A /Span * 100	2.0
	High	11/29/21 03:20	10.0	9.0	9.0	R-A /Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/29/21 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/29/21 03:25	200.0	180.0	179.8	R-A /Span * 100	0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/29/21 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/29/21 03:20	10.0	8.8	8.7	R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/29/21 03:14	21.0	18.1	18.2	R-A	0.1
	Zero	11/29/21 03:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/30/21 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/30/21 02:25	200.0	189.0	187.7	R-A /Span * 100	0.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/30/21 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/30/21 02:20	30.0	27.7	27.7	R-A /Span * 100	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/30/21 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/30/21 02:24	200.0	180.0	180.3	R-A /Span * 100	0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/30/21 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/30/21 02:19	30.0	27.7	27.1	R-A /Span * 100	2.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/30/21 03:14	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	11/30/21 03:24	200.0	185.1	186.4	R-A /Span * 100	0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/30/21 03:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	11/30/21 03:19	10.0	9.0	9.0	R-A /Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/30/21 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/30/21 03:24	200.0	180.0	179.7	R-A /Span * 100	0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/30/21 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/30/21 03:19	10.0	8.8	8.7	R-A /Span * 100	1.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:08 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/30/21 03:14	21.0	18.1	18.2	R-A	0.1
	Zero	11/30/21 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/30/21 03:15	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	11/30/21 03:25	200.0	177.2	177.1	R-A /Span * 100	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/30/21 03:15	10.0	0.0	-0.1	R-A /Span * 100	1.0
	High	11/30/21 03:20	10.0	8.3	8.3	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	11/30/21 03:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/30/21 03:25	200.0	189.0	189.1	R-A /Span * 100	0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	11/30/21 03:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	11/30/21 03:20	10.0	8.8	8.8	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	11/30/21 03:15	21.0	18.1	18.0	R-A	0.1
	Zero	11/30/21 03:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/01/21 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/01/21 02:25	200.0	189.0	187.8	R-A /Span * 100	0.6
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/01/21 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/01/21 02:20	30.0	27.7	26.8	>1x Alert R-A /Span * 100	3.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/01/21 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/01/21 02:25	200.0	180.0	179.9	R-A /Span * 100	0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/01/21 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/01/21 02:20	30.0	27.7	27.0	R-A /Span * 100	2.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/01/21 03:14	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	12/01/21 03:24	200.0	177.2	177.1	R-A /Span * 100	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/01/21 03:14	10.0	0.0	-0.1	R-A /Span * 100	1.0
	High	12/01/21 03:20	10.0	8.3	8.3	R-A /Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:08 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/01/21 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/01/21 03:24	200.0	189.0	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/01/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	12/01/21 03:20	10.0	8.8	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/01/21 03:14	21.0	18.1	R-A		0.1
	Zero	12/01/21 03:20	21.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/01/21 03:15	200.0	0.1	R-A /Span * 100		0.1
	High	12/01/21 03:25	200.0	185.1	R-A /Span * 100		0.6
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/01/21 03:15	10.0	0.1	R-A /Span * 100		1.0
	High	12/01/21 03:20	10.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/01/21 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	12/01/21 03:25	200.0	180.0	R-A /Span * 100		0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/01/21 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	12/01/21 03:20	10.0	8.8	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/01/21 03:15	21.0	18.1	R-A		0.1
	Zero	12/01/21 03:20	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/02/21 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	12/02/21 02:25	200.0	189.0	R-A /Span * 100		0.8
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/02/21 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	12/02/21 02:20	30.0	27.7	R-A /Span * 100		3.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/02/21 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	12/02/21 02:25	200.0	180.0	R-A /Span * 100		0.5
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/02/21 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	12/02/21 02:19	30.0	27.7	R-A /Span * 100		2.3

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/02/21 03:15	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	12/02/21 03:25	200.0	177.2	177.2	R-A /Span * 100		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/02/21 03:15	10.0	0.0	-0.1	R-A /Span * 100		1.0
	High	12/02/21 03:19	10.0	8.3	8.3	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/02/21 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/02/21 03:25	200.0	189.0	190.7	R-A /Span * 100		0.9
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/02/21 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/02/21 03:19	10.0	8.8	8.9	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/02/21 03:15	21.0	18.1	18.0	R-A		0.1
	Zero	12/02/21 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/02/21 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/02/21 03:25	200.0	185.1	185.6	R-A /Span * 100		0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/02/21 03:15	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	12/02/21 03:20	10.0	9.0	8.9	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/02/21 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/02/21 03:25	200.0	180.0	180.1	R-A /Span * 100		0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/02/21 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/02/21 03:20	10.0	8.8	8.7	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/02/21 03:15	21.0	18.1	18.2	R-A		0.1
	Zero	12/02/21 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/03/21 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/03/21 02:24	200.0	189.0	187.3	R-A /Span * 100		0.9
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/03/21 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/03/21 02:19	30.0	27.7	27.5	R-A /Span * 100		0.7

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/03/21 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/03/21 02:25	200.0	180.0	178.7	R-A /Span * 100	0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/03/21 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	12/03/21 02:20	30.0	27.7	26.8	>1x Alert R-A /Span * 100	3.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/03/21 03:15	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	12/03/21 03:25	200.0	177.2	177.2	R-A /Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/03/21 03:15	10.0	0.0	-0.1	R-A /Span * 100	1.0
	High	12/03/21 03:19	10.0	8.3	8.3	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/03/21 03:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/03/21 03:25	200.0	189.0	190.5	R-A /Span * 100	0.8
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/03/21 03:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/03/21 03:19	10.0	8.8	8.9	R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/03/21 03:15	21.0	18.1	18.0	R-A	0.1
	Zero	12/03/21 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/03/21 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/03/21 03:25	200.0	185.1	186.0	R-A /Span * 100	0.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/03/21 03:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	12/03/21 03:19	10.0	9.0	9.0	R-A /Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/03/21 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/03/21 03:25	200.0	180.0	180.1	R-A /Span * 100	0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/03/21 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/03/21 03:19	10.0	8.8	8.7	R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/03/21 03:14	21.0	18.1	18.2	R-A	0.1
	Zero	12/03/21 03:19	21.0	0.0	0.0	R-A	0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/04/21 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/04/21 02:25	200.0	189.0		R-A /Span * 100	0.9
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/04/21 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	12/04/21 02:20	30.0	27.7		R-A /Span * 100	0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/04/21 02:15	200.0	0.0		R-A /Span * 100	0.0
	High	12/04/21 02:25	200.0	180.0		R-A /Span * 100	0.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/04/21 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	12/04/21 02:20	30.0	27.7	>1x Alert	R-A /Span * 100	3.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/04/21 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/04/21 03:24	200.0	185.1		R-A /Span * 100	0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/04/21 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	12/04/21 03:19	10.0	9.0		R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/04/21 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/04/21 03:24	200.0	180.0		R-A /Span * 100	0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/04/21 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	12/04/21 03:19	10.0	8.8		R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/04/21 03:14	21.0	18.1		R-A	0.1
	Zero	12/04/21 03:19	21.0	0.0		R-A	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/04/21 03:14	200.0	0.0		R-A /Span * 100	0.1
	High	12/04/21 03:25	200.0	177.2		R-A /Span * 100	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/04/21 03:14	10.0	0.0		R-A /Span * 100	1.0
	High	12/04/21 03:20	10.0	8.3		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/04/21 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/04/21 03:25	200.0	189.0		R-A /Span * 100	0.7

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/04/21 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	12/04/21 03:20	10.0	8.8		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/04/21 03:14	21.0	18.1		R-A	0.1
	Zero	12/04/21 03:20	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/05/21 02:15	200.0	0.0		R-A /Span * 100	0.0
	High	12/05/21 02:24	200.0	189.0		R-A /Span * 100	1.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/05/21 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	12/05/21 02:20	30.0	27.7		R-A /Span * 100	1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/05/21 02:15	200.0	0.0		R-A /Span * 100	0.0
	High	12/05/21 02:24	200.0	180.0		R-A /Span * 100	1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/05/21 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	12/05/21 02:19	30.0	27.7	>1x Alert	R-A /Span * 100	3.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/05/21 03:14	200.0	0.0		R-A /Span * 100	0.1
	High	12/05/21 03:24	200.0	185.1		R-A /Span * 100	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/05/21 03:14	10.0	0.0		R-A /Span * 100	1.0
	High	12/05/21 03:19	10.0	9.0		R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/05/21 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/05/21 03:24	200.0	180.0		R-A /Span * 100	0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/05/21 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	12/05/21 03:19	10.0	8.8		R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/05/21 03:14	21.0	18.1		R-A	0.1
	Zero	12/05/21 03:19	21.0	0.0		R-A	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/05/21 03:14	200.0	0.0		R-A /Span * 100	0.1
	High	12/05/21 03:25	200.0	177.2		R-A /Span * 100	0.2

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:08 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/05/21 03:14	10.0	0.0	-0.1	R-A /Span * 100	1.0
	High	12/05/21 03:20	10.0	8.3	8.3	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/05/21 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/05/21 03:25	200.0	189.0	190.3	R-A /Span * 100	0.7
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/05/21 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/05/21 03:20	10.0	8.8	8.9	R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/05/21 03:14	21.0	18.1	18.0	R-A	0.1
	Zero	12/05/21 03:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/06/21 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/06/21 02:24	200.0	189.0	187.7	R-A /Span * 100	0.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/06/21 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/06/21 02:19	30.0	27.7	27.5	R-A /Span * 100	0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/06/21 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/06/21 02:25	200.0	180.0	179.0	R-A /Span * 100	0.5
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/06/21 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/06/21 02:20	30.0	27.7	26.9	>1x Alert R-A /Span * 100	2.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/06/21 03:15	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	12/06/21 03:25	200.0	177.2	177.1	R-A /Span * 100	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/06/21 03:15	10.0	0.0	-0.1	R-A /Span * 100	1.0
	High	12/06/21 03:20	10.0	8.3	8.3	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/06/21 03:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/06/21 03:25	200.0	189.0	190.3	R-A /Span * 100	0.7
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/06/21 03:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/06/21 03:20	10.0	8.8	8.9	R-A /Span * 100	1.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:08 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/06/21 03:15	21.0	18.1	18.0	R-A	0.1
	Zero	12/06/21 03:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/06/21 03:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/06/21 03:24	200.0	185.1	185.0	R-A /Span * 100	0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/06/21 03:15	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	12/06/21 03:20	10.0	9.0	8.9	R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/06/21 03:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/06/21 03:24	200.0	180.0	180.0	R-A /Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/06/21 03:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/06/21 03:20	10.0	8.8	8.7	R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/06/21 03:15	21.0	18.1	18.2	R-A	0.1
	Zero	12/06/21 03:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/07/21 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/07/21 02:25	200.0	189.0	187.3	R-A /Span * 100	0.9
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/07/21 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/07/21 02:19	30.0	27.3	26.9	R-A /Span * 100	1.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/07/21 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/07/21 02:25	200.0	180.0	178.8	R-A /Span * 100	0.6
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/07/21 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/07/21 02:20	30.0	27.7	26.9	R-A /Span * 100	2.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/07/21 03:14	200.0	0.0	-0.1	R-A /Span * 100	0.1
	High	12/07/21 03:25	200.0	177.2	177.6	R-A /Span * 100	0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/07/21 03:14	10.0	0.0	-0.1	R-A /Span * 100	1.0
	High	12/07/21 03:20	10.0	8.3	8.3	R-A /Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/07/21 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/07/21 03:25	200.0	189.0	R-A /Span * 100		0.8
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/07/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	12/07/21 03:20	10.0	8.8	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/07/21 03:14	21.0	18.1	R-A		0.1
	Zero	12/07/21 03:20	21.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/07/21 03:14	200.0	0.1	R-A /Span * 100		0.1
	High	12/07/21 03:25	200.0	185.1	R-A /Span * 100		0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/07/21 03:14	10.0	0.1	R-A /Span * 100		1.0
	High	12/07/21 03:20	10.0	9.0	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/07/21 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/07/21 03:25	200.0	180.0	R-A /Span * 100		0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/07/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	12/07/21 03:20	10.0	8.8	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/07/21 03:14	21.0	18.1	R-A		0.1
	Zero	12/07/21 03:20	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/08/21 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	12/08/21 02:25	200.0	189.0	R-A /Span * 100		0.9
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/08/21 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	12/08/21 02:20	30.0	27.3	R-A /Span * 100		1.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/08/21 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/08/21 02:24	200.0	180.0	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/08/21 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	12/08/21 02:19	30.0	27.7	R-A /Span * 100		2.7

>1x Alert

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:08 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/08/21 03:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	12/08/21 03:25	200.0	177.2	177.6	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/08/21 03:15	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	12/08/21 03:20	10.0	8.3	8.3	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/08/21 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/08/21 03:25	200.0	189.0	190.4	R-A /Span * 100		0.7
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/08/21 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/08/21 03:20	10.0	8.8	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/08/21 03:15	21.0	18.1	18.1	R-A		0.0
	Zero	12/08/21 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/08/21 03:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	12/08/21 03:25	200.0	185.1	186.0	R-A /Span * 100		0.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/08/21 03:15	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	12/08/21 03:20	10.0	9.0	8.9	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/08/21 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/08/21 03:25	200.0	180.0	179.7	R-A /Span * 100		0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/08/21 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/08/21 03:20	10.0	8.8	8.7	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/08/21 03:15	21.0	18.1	18.2	R-A		0.1
	Zero	12/08/21 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/09/21 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/09/21 02:24	200.0	180.0	180.0	R-A /Span * 100		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/09/21 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/09/21 02:19	30.0	27.7	27.0	R-A /Span * 100		2.3

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:08 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/09/21 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/09/21 02:25	200.0	180.0	R-A /Span * 100		1.8
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/09/21 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	12/09/21 02:19	30.0	27.3	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/09/21 03:15	200.0	0.1	R-A /Span * 100		0.1
	High	12/09/21 03:25	200.0	184.6	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/09/21 03:15	10.0	0.1	R-A /Span * 100		1.0
	High	12/09/21 03:20	10.0	8.3	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/09/21 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	12/09/21 03:25	200.0	180.0	R-A /Span * 100		0.8
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/09/21 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	12/09/21 03:20	10.0	8.8	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/09/21 03:15	21.0	18.1	R-A		0.0
	Zero	12/09/21 03:20	21.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/09/21 03:14	200.0	0.1	R-A /Span * 100		0.1
	High	12/09/21 03:25	200.0	185.1	R-A /Span * 100		1.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/09/21 03:14	10.0	0.2	R-A /Span * 100		2.0
	High	12/09/21 03:20	10.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/09/21 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/09/21 03:25	200.0	180.0	R-A /Span * 100		0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/09/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	12/09/21 03:20	10.0	8.8	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/09/21 03:14	21.0	18.1	R-A		0.0
	Zero	12/09/21 03:20	21.0	0.0	R-A		0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/10/21 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/10/21 02:25	200.0	180.0	179.2	R-A /Span * 100		0.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/10/21 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/10/21 02:20	30.0	27.3	27.1	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/10/21 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/10/21 02:25	200.0	180.0	180.5	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/10/21 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/10/21 02:20	30.0	27.7	27.1	R-A /Span * 100		2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/10/21 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	12/10/21 03:25	200.0	184.6	183.2	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/10/21 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	12/10/21 03:19	10.0	8.3	8.3	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/10/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/10/21 03:25	200.0	180.0	181.5	R-A /Span * 100		0.8
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/10/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/10/21 03:19	10.0	8.8	8.9	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/10/21 03:14	21.0	18.1	18.1	R-A		0.0
	Zero	12/10/21 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/10/21 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	12/10/21 03:24	200.0	185.1	186.0	R-A /Span * 100		0.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/10/21 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	12/10/21 03:19	10.0	9.0	9.1	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/10/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/10/21 03:24	200.0	180.0	180.3	R-A /Span * 100		0.2

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/10/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	12/10/21 03:19	10.0	8.8	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/10/21 03:14	21.0	18.1	R-A		0.1
	Zero	12/10/21 03:19	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/11/21 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/11/21 02:25	200.0	180.0	R-A /Span * 100		0.5
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/11/21 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	12/11/21 02:20	30.0	27.3	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/11/21 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	12/11/21 02:25	200.0	180.0	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/11/21 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	12/11/21 02:20	30.0	27.7	R-A /Span * 100		2.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/11/21 03:14	200.0	0.0	R-A /Span * 100		0.1
	High	12/11/21 03:24	200.0	184.4	R-A /Span * 100		0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/11/21 03:14	10.0	0.0	R-A /Span * 100		2.0
	High	12/11/21 03:19	10.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/11/21 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/11/21 03:24	200.0	180.0	R-A /Span * 100		0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/11/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	12/11/21 03:19	10.0	8.8	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/11/21 03:14	21.0	18.1	R-A		0.1
	Zero	12/11/21 03:19	21.0	0.0	R-A		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/11/21 03:14	200.0	0.0	R-A /Span * 100		0.1
	High	12/11/21 03:24	200.0	184.6	R-A /Span * 100		1.3

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/11/21 03:14	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	12/11/21 03:20	10.0	8.3	8.3	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/11/21 03:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/11/21 03:24	200.0	180.0	180.6	R-A /Span * 100	0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/11/21 03:14	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/11/21 03:20	10.0	8.8	8.8	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/11/21 03:14	21.0	18.1	18.1	R-A	0.0
	Zero	12/11/21 03:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/12/21 02:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/12/21 02:25	200.0	180.0	178.5	R-A /Span * 100	0.8
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/12/21 02:15	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/12/21 02:20	30.0	27.3	27.1	R-A /Span * 100	0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/12/21 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/12/21 02:25	200.0	180.0	180.6	R-A /Span * 100	0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/12/21 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/12/21 02:20	30.0	27.2	27.0	R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/12/21 03:15	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	12/12/21 03:25	200.0	184.6	183.2	R-A /Span * 100	0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/12/21 03:15	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	12/12/21 03:20	10.0	8.3	8.3	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/12/21 03:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/12/21 03:25	200.0	180.0	180.6	R-A /Span * 100	0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/12/21 03:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/12/21 03:20	10.0	8.8	8.8	R-A /Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:08 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/12/21 03:15	21.0	18.1	R-A		0.0
	Zero	12/12/21 03:20	21.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/12/21 03:14	200.0	0.1	R-A /Span * 100		0.1
	High	12/12/21 03:25	200.0	186.5	R-A /Span * 100		1.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/12/21 03:14	10.0	0.2	R-A /Span * 100		2.0
	High	12/12/21 03:20	10.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/12/21 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/12/21 03:25	200.0	180.3	R-A /Span * 100		0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/12/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	12/12/21 03:20	10.0	8.7	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/12/21 03:14	21.0	18.1	R-A		0.0
	Zero	12/12/21 03:20	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/13/21 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	12/13/21 02:25	200.0	178.5	R-A /Span * 100		0.8
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/13/21 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	12/13/21 02:20	30.0	27.1	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/13/21 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	12/13/21 02:25	200.0	180.2	R-A /Span * 100		0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/13/21 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	12/13/21 02:20	30.0	27.0	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/13/21 03:15	200.0	0.1	R-A /Span * 100		0.1
	High	12/13/21 03:25	200.0	184.3	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/13/21 03:15	10.0	0.1	R-A /Span * 100		1.0
	High	12/13/21 03:20	10.0	8.3	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:08 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/13/21 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	12/13/21 03:25	200.0	180.0		R-A /Span * 100	0.7
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/13/21 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	12/13/21 03:20	10.0	8.8		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/13/21 03:15	21.0	18.1		R-A	0.0
	Zero	12/13/21 03:20	21.0	0.0		R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/13/21 03:15	200.0	0.0		R-A /Span * 100	0.1
	High	12/13/21 03:24	200.0	184.4		R-A /Span * 100	1.8
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/13/21 03:15	10.0	0.0		R-A /Span * 100	2.0
	High	12/13/21 03:20	10.0	9.0		R-A /Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/13/21 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	12/13/21 03:24	200.0	180.0		R-A /Span * 100	0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/13/21 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	12/13/21 03:20	10.0	8.8		R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/13/21 03:15	21.0	18.1		R-A	0.0
	Zero	12/13/21 03:20	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/14/21 02:15	200.0	0.0		R-A /Span * 100	0.0
	High	12/14/21 02:25	200.0	180.0		R-A /Span * 100	0.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/14/21 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	12/14/21 02:20	30.0	27.3		R-A /Span * 100	1.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/14/21 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/14/21 02:25	200.0	180.0		R-A /Span * 100	0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/14/21 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	12/14/21 02:19	30.0	27.2		R-A /Span * 100	0.7

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/14/21 03:15	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	12/14/21 03:25	200.0	184.6	184.3	R-A /Span * 100	0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/14/21 03:15	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	12/14/21 03:20	10.0	8.3	8.3	R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/14/21 03:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/14/21 03:25	200.0	180.0	181.3	R-A /Span * 100	0.7
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/14/21 03:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/14/21 03:20	10.0	8.8	8.8	R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/14/21 03:15	21.0	18.1	18.1	R-A	0.0
	Zero	12/14/21 03:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/14/21 03:15	200.0	0.0	0.1	R-A /Span * 100	0.1
	High	12/14/21 03:25	200.0	184.4	187.8	R-A /Span * 100	1.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/14/21 03:15	10.0	0.0	0.2	R-A /Span * 100	2.0
	High	12/14/21 03:20	10.0	9.0	9.1	R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/14/21 03:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/14/21 03:25	200.0	180.0	180.5	R-A /Span * 100	0.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/14/21 03:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/14/21 03:20	10.0	8.8	8.7	R-A /Span * 100	1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/14/21 03:15	21.0	18.1	18.1	R-A	0.0
	Zero	12/14/21 03:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/15/21 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/15/21 02:24	200.0	180.0	178.8	R-A /Span * 100	0.6
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/15/21 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/15/21 02:19	30.0	27.3	27.2	R-A /Span * 100	0.3

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:08

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/15/21 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/15/21 02:25	200.0	180.0	180.7	R-A /Span * 100		0.4
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/15/21 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/15/21 02:20	30.0	27.2	27.1	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/15/21 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	12/15/21 03:25	200.0	184.6	182.8	R-A /Span * 100		0.9
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/15/21 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	12/15/21 03:20	10.0	8.3	8.3	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/15/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/15/21 03:25	200.0	180.0	180.8	R-A /Span * 100		0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/15/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/15/21 03:20	10.0	8.8	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/15/21 03:14	21.0	18.1	18.1	R-A		0.0
	Zero	12/15/21 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/15/21 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	12/15/21 03:24	200.0	184.4	185.7	R-A /Span * 100		0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/15/21 03:14	10.0	0.0	0.2	R-A /Span * 100		2.0
	High	12/15/21 03:19	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/15/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/15/21 03:24	200.0	180.0	180.4	R-A /Span * 100		0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/15/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/15/21 03:19	10.0	8.8	8.7	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/15/21 03:14	21.0	18.1	18.1	R-A		0.0
	Zero	12/15/21 03:19	21.0	0.0	0.0	R-A		0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:09 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/16/21 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/16/21 02:25	200.0	180.0	179.5	R-A /Span * 100		0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/16/21 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/16/21 02:20	30.0	27.3	27.3	R-A /Span * 100		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/16/21 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/16/21 02:25	200.0	180.0	179.1	R-A /Span * 100		0.5
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/16/21 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/16/21 02:20	30.0	27.2	27.0	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/16/21 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/16/21 03:25	200.0	184.6	185.6	R-A /Span * 100		0.5
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/16/21 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/16/21 03:20	10.0	8.3	8.3	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/16/21 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/16/21 03:25	200.0	180.0	179.5	R-A /Span * 100		0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/16/21 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/16/21 03:20	10.0	8.8	8.7	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/16/21 03:15	21.0	18.1	18.1	R-A		0.0
	Zero	12/16/21 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/16/21 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/16/21 03:25	200.0	184.4	185.0	R-A /Span * 100		0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/16/21 03:15	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	12/16/21 03:20	10.0	9.0	8.9	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/16/21 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/16/21 03:25	200.0	180.0	179.7	R-A /Span * 100		0.2

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:09

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/16/21 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	12/16/21 03:20	10.0	8.8		R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/16/21 03:15	21.0	18.1		R-A	0.1
	Zero	12/16/21 03:20	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/17/21 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/17/21 02:25	200.0	180.0		R-A /Span * 100	0.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/17/21 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	12/17/21 02:20	30.0	27.3		R-A /Span * 100	0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/17/21 02:15	200.0	0.0		R-A /Span * 100	0.0
	High	12/17/21 02:25	200.0	180.0		R-A /Span * 100	0.9
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/17/21 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	12/17/21 02:20	30.0	27.2		R-A /Span * 100	1.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/17/21 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	12/17/21 03:25	200.0	184.6		R-A /Span * 100	0.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/17/21 03:15	10.0	0.0		R-A /Span * 100	1.0
	High	12/17/21 03:20	10.0	8.3		R-A /Span * 100	0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/17/21 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	12/17/21 03:25	200.0	180.0		R-A /Span * 100	0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/17/21 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	12/17/21 03:20	10.0	8.8		R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/17/21 03:15	21.0	18.1		R-A	0.0
	Zero	12/17/21 03:20	21.0	0.0		R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/17/21 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/17/21 03:25	200.0	184.4		R-A /Span * 100	0.1

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:09 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/17/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	12/17/21 03:20	10.0	9.0	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/17/21 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/17/21 03:25	200.0	180.0	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/17/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	12/17/21 03:20	10.0	8.8	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/17/21 03:14	21.0	18.1	R-A		0.1
	Zero	12/17/21 03:20	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/18/21 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	12/18/21 02:25	200.0	180.0	R-A /Span * 100		0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/18/21 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	12/18/21 02:20	30.0	27.3	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/18/21 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/18/21 02:24	200.0	180.0	R-A /Span * 100		0.5
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/18/21 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	12/18/21 02:19	30.0	27.2	R-A /Span * 100		1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/18/21 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	12/18/21 03:24	200.0	184.6	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/18/21 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	12/18/21 03:19	10.0	8.3	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/18/21 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	12/18/21 03:24	200.0	180.0	R-A /Span * 100		0.5
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/18/21 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	12/18/21 03:19	10.0	8.8	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:09 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/18/21 03:15	21.0	18.1	18.2	R-A	0.1
	Zero	12/18/21 03:19	21.0	0.0	0.0	R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/18/21 03:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/18/21 03:25	200.0	184.4	183.5	R-A /Span * 100	0.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/18/21 03:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/18/21 03:20	10.0	9.0	9.0	R-A /Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/18/21 03:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/18/21 03:25	200.0	180.0	180.1	R-A /Span * 100	0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/18/21 03:15	10.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/18/21 03:20	10.0	8.8	8.8	R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/18/21 03:15	21.0	18.1	18.2	R-A	0.1
	Zero	12/18/21 03:20	21.0	0.0	0.0	R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/19/21 02:14	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/19/21 02:25	200.0	180.0	179.5	R-A /Span * 100	0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/19/21 02:14	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/19/21 02:20	30.0	27.3	27.2	R-A /Span * 100	0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/19/21 02:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/19/21 02:25	200.0	180.0	179.1	R-A /Span * 100	0.5
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/19/21 02:15	30.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/19/21 02:20	30.0	27.2	26.8	R-A /Span * 100	1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/19/21 03:15	200.0	0.0	0.0	R-A /Span * 100	0.0
	High	12/19/21 03:25	200.0	184.6	184.9	R-A /Span * 100	0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/19/21 03:15	10.0	0.0	0.1	R-A /Span * 100	1.0
	High	12/19/21 03:20	10.0	8.3	8.3	R-A /Span * 100	0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:09

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/19/21 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	12/19/21 03:25	200.0	180.0	R-A /Span * 100		0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/19/21 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	12/19/21 03:20	10.0	8.8	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/19/21 03:15	21.0	18.1	R-A		0.0
	Zero	12/19/21 03:20	21.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/19/21 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	12/19/21 03:25	200.0	184.4	R-A /Span * 100		0.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/19/21 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	12/19/21 03:19	10.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/19/21 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	12/19/21 03:25	200.0	180.0	R-A /Span * 100		0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/19/21 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	12/19/21 03:19	10.0	8.8	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/19/21 03:15	21.0	18.1	R-A		0.1
	Zero	12/19/21 03:19	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/20/21 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/20/21 02:24	200.0	180.0	R-A /Span * 100		0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/20/21 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	12/20/21 02:19	30.0	27.3	R-A /Span * 100		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/20/21 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	12/20/21 02:25	200.0	180.0	R-A /Span * 100		0.4
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/20/21 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	12/20/21 02:20	30.0	27.2	R-A /Span * 100		1.3

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:09

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/20/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/20/21 03:25	200.0	184.6	185.0	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/20/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/20/21 03:20	10.0	8.3	8.3	R-A /Span * 100		0.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/20/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/20/21 03:25	200.0	180.0	179.3	R-A /Span * 100		0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/20/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/20/21 03:20	10.0	8.8	8.7	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/20/21 03:14	21.0	18.1	18.1	R-A		0.0
	Zero	12/20/21 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/20/21 03:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	12/20/21 03:25	200.0	184.4	184.7	R-A /Span * 100		0.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/20/21 03:15	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	12/20/21 03:20	10.0	9.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/20/21 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/20/21 03:25	200.0	180.0	180.3	R-A /Span * 100		0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/20/21 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/20/21 03:20	10.0	8.8	8.8	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/20/21 03:15	21.0	18.1	18.1	R-A		0.0
	Zero	12/20/21 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/21/21 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/21/21 02:25	200.0	180.0	179.8	R-A /Span * 100		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/21/21 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/21/21 02:19	30.0	27.3	27.2	R-A /Span * 100		0.3

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:09

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/21/21 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/21/21 02:24	200.0	180.0	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/21/21 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	12/21/21 02:20	30.0	27.2	R-A /Span * 100		1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/21/21 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	12/21/21 03:24	200.0	184.6	R-A /Span * 100		0.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/21/21 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	12/21/21 03:20	10.0	8.3	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/21/21 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	12/21/21 03:24	200.0	180.0	R-A /Span * 100		0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/21/21 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	12/21/21 03:20	10.0	8.8	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/21/21 03:15	21.0	18.1	R-A		0.0
	Zero	12/21/21 03:20	21.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/21/21 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/21/21 03:25	200.0	184.4	R-A /Span * 100		0.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/21/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	12/21/21 03:19	10.0	9.0	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/21/21 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/21/21 03:25	200.0	180.0	R-A /Span * 100		0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/21/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	12/21/21 03:19	10.0	8.8	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/21/21 03:14	21.0	18.1	R-A		0.1
	Zero	12/21/21 03:19	21.0	0.0	R-A		0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:09 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/22/21 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/22/21 02:25	200.0	180.0		R-A /Span * 100	0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/22/21 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	12/22/21 02:19	30.0	27.3		R-A /Span * 100	0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/22/21 02:15	200.0	0.0		R-A /Span * 100	0.0
	High	12/22/21 02:25	200.0	180.0		R-A /Span * 100	0.9
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/22/21 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	12/22/21 02:20	30.0	27.2		R-A /Span * 100	2.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/22/21 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/22/21 03:24	200.0	184.6		R-A /Span * 100	0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/22/21 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	12/22/21 03:19	10.0	8.3		R-A /Span * 100	1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/22/21 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/22/21 03:24	200.0	180.0		R-A /Span * 100	0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/22/21 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	12/22/21 03:19	10.0	8.8		R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/22/21 03:14	21.0	18.1		R-A	0.0
	Zero	12/22/21 03:19	21.0	0.0		R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/22/21 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/22/21 03:25	200.0	184.4		R-A /Span * 100	0.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/22/21 03:14	10.0	0.0		R-A /Span * 100	1.0
	High	12/22/21 03:20	10.0	9.0		R-A /Span * 100	0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/22/21 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/22/21 03:25	200.0	180.0		R-A /Span * 100	0.2

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:09

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/22/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/22/21 03:20	10.0	8.8	8.8	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/22/21 03:14	21.0	18.1	18.2	R-A		0.1
	Zero	12/22/21 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/23/21 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/23/21 02:24	200.0	180.0	180.1	R-A /Span * 100		0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/23/21 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/23/21 02:20	30.0	27.2	27.0	R-A /Span * 100		0.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/23/21 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/23/21 02:25	200.0	180.0	179.3	R-A /Span * 100		0.4
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/23/21 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/23/21 02:20	30.0	27.3	27.2	R-A /Span * 100		0.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/23/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/23/21 03:25	200.0	184.6	186.9	R-A /Span * 100		1.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/23/21 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	12/23/21 03:20	10.0	8.3	8.4	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/23/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/23/21 03:25	200.0	180.0	179.9	R-A /Span * 100		0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/23/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/23/21 03:20	10.0	8.8	8.7	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/23/21 03:14	21.0	18.1	18.1	R-A		0.0
	Zero	12/23/21 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/23/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/23/21 03:25	200.0	184.4	187.4	R-A /Span * 100		1.5

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:09 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/23/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	12/23/21 03:20	10.0	9.0	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/23/21 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/23/21 03:25	200.0	180.0	R-A /Span * 100		0.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/23/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	12/23/21 03:20	10.0	8.8	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/23/21 03:14	21.0	18.1	R-A		0.0
	Zero	12/23/21 03:20	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/24/21 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/24/21 02:25	200.0	180.0	R-A /Span * 100		0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/24/21 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	12/24/21 02:20	30.0	27.3	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/24/21 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	12/24/21 02:25	200.0	180.0	R-A /Span * 100		0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/24/21 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	12/24/21 02:20	30.0	27.2	R-A /Span * 100		0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/24/21 03:14	200.0	0.0	R-A /Span * 100		0.1
	High	12/24/21 03:24	200.0	184.4	R-A /Span * 100		1.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/24/21 03:14	10.0	0.0	R-A /Span * 100		1.0
	High	12/24/21 03:19	10.0	9.0	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/24/21 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/24/21 03:24	200.0	180.0	R-A /Span * 100		0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/24/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	12/24/21 03:19	10.0	8.8	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:09

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/24/21 03:14	21.0	18.1	R-A		0.0
	Zero	12/24/21 03:19	21.0	0.0	R-A		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/24/21 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/24/21 03:25	200.0	184.6	R-A /Span * 100		1.1
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/24/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	12/24/21 03:20	10.0	8.3	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/24/21 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/24/21 03:25	200.0	180.0	R-A /Span * 100		0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/24/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	12/24/21 03:20	10.0	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/24/21 03:14	21.0	18.1	R-A		0.0
	Zero	12/24/21 03:20	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/25/21 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	12/25/21 02:24	200.0	180.0	R-A /Span * 100		0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/25/21 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	12/25/21 02:20	30.0	27.3	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/25/21 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/25/21 02:24	200.0	180.0	R-A /Span * 100		0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/25/21 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	12/25/21 02:19	30.0	27.2	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/25/21 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	12/25/21 03:25	200.0	184.6	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/25/21 03:15	10.0	0.1	R-A /Span * 100		1.0
	High	12/25/21 03:20	10.0	8.3	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:09 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/25/21 03:15	200.0	0.0		R-A /Span * 100	0.0
	High	12/25/21 03:25	200.0	180.0		R-A /Span * 100	0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/25/21 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	12/25/21 03:20	10.0	8.8		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/25/21 03:15	21.0	18.1		R-A	0.0
	Zero	12/25/21 03:20	21.0	0.0		R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/25/21 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/25/21 03:24	200.0	184.4		R-A /Span * 100	1.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/25/21 03:14	10.0	0.0		R-A /Span * 100	1.0
	High	12/25/21 03:19	10.0	9.0		R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/25/21 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/25/21 03:24	200.0	180.0		R-A /Span * 100	0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/25/21 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	12/25/21 03:19	10.0	8.8		R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/25/21 03:14	21.0	18.1		R-A	0.0
	Zero	12/25/21 03:19	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/26/21 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/26/21 02:25	200.0	180.0		R-A /Span * 100	0.1
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/26/21 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	12/26/21 02:19	30.0	27.3		R-A /Span * 100	0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/26/21 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/26/21 02:25	200.0	180.0		R-A /Span * 100	0.2
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/26/21 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	12/26/21 02:19	30.0	27.2		R-A /Span * 100	0.7

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:09

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/26/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/26/21 03:24	200.0	184.6	185.8	R-A /Span * 100		0.6
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/26/21 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	12/26/21 03:20	10.0	8.3	8.4	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/26/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/26/21 03:24	200.0	180.0	179.9	R-A /Span * 100		0.1
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/26/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/26/21 03:20	10.0	8.8	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/26/21 03:14	21.0	18.1	18.1	R-A		0.0
	Zero	12/26/21 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/26/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/26/21 03:24	200.0	184.4	186.8	R-A /Span * 100		1.2
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/26/21 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	12/26/21 03:20	10.0	9.0	9.1	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/26/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/26/21 03:24	200.0	180.0	180.1	R-A /Span * 100		0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/26/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/26/21 03:20	10.0	8.8	8.7	R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/26/21 03:14	21.0	18.1	18.2	R-A		0.1
	Zero	12/26/21 03:20	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/27/21 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/27/21 02:25	200.0	180.0	180.0	R-A /Span * 100		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/27/21 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/27/21 02:20	30.0	27.3	27.3	R-A /Span * 100		0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:09

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/27/21 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/27/21 02:25	200.0	180.0	R-A /Span * 100		0.1
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/27/21 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	12/27/21 02:19	30.0	27.2	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/27/21 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	12/27/21 03:25	200.0	184.6	R-A /Span * 100		0.9
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/27/21 03:15	10.0	0.1	R-A /Span * 100		1.0
	High	12/27/21 03:19	10.0	8.3	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/27/21 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	12/27/21 03:25	200.0	180.0	R-A /Span * 100		0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/27/21 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	12/27/21 03:19	10.0	8.8	R-A /Span * 100		0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/27/21 03:15	21.0	18.1	R-A		0.0
	Zero	12/27/21 03:19	21.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/27/21 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	12/27/21 03:25	200.0	184.4	R-A /Span * 100		0.9
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/27/21 03:15	10.0	0.0	R-A /Span * 100		1.0
	High	12/27/21 03:20	10.0	9.0	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/27/21 03:15	200.0	0.0	R-A /Span * 100		0.0
	High	12/27/21 03:25	200.0	180.0	R-A /Span * 100		0.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/27/21 03:15	10.0	0.0	R-A /Span * 100		0.0
	High	12/27/21 03:20	10.0	8.8	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/27/21 03:15	21.0	18.1	R-A		0.0
	Zero	12/27/21 03:20	21.0	0.0	R-A		0.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:09

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/28/21 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/28/21 02:25	200.0	180.0	180.5	R-A /Span * 100		0.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/28/21 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/28/21 02:20	30.0	27.3	27.4	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/28/21 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/28/21 02:25	200.0	180.0	180.5	R-A /Span * 100		0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/28/21 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/28/21 02:19	30.0	27.2	27.0	R-A /Span * 100		0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/28/21 03:15	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	12/28/21 03:24	200.0	184.4	186.5	R-A /Span * 100		1.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/28/21 03:15	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	12/28/21 03:19	10.0	9.0	9.1	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/28/21 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/28/21 03:24	200.0	180.0	180.2	R-A /Span * 100		0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/28/21 03:15	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/28/21 03:19	10.0	8.8	8.8	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/28/21 03:15	21.0	18.1	18.1	R-A		0.0
	Zero	12/28/21 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/28/21 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/28/21 03:25	200.0	184.6	185.8	R-A /Span * 100		0.6
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/28/21 03:15	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	12/28/21 03:20	10.0	8.3	8.4	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/28/21 03:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/28/21 03:25	200.0	180.0	179.6	R-A /Span * 100		0.2

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:09

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/28/21 03:15	10.0	0.0		R-A /Span * 100	0.0
	High	12/28/21 03:20	10.0	8.8		R-A /Span * 100	0.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/28/21 03:15	21.0	18.1		R-A	0.0
	Zero	12/28/21 03:20	21.0	0.0		R-A	0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/29/21 02:15	200.0	0.0		R-A /Span * 100	0.0
	High	12/29/21 02:25	200.0	180.4		R-A /Span * 100	0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/29/21 02:15	30.0	0.0		R-A /Span * 100	0.0
	High	12/29/21 02:19	30.0	27.4		R-A /Span * 100	0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/29/21 02:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/29/21 02:25	200.0	180.6		R-A /Span * 100	0.3
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/29/21 02:14	30.0	0.0		R-A /Span * 100	0.0
	High	12/29/21 02:19	30.0	27.1		R-A /Span * 100	0.3
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/29/21 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/29/21 03:24	200.0	184.4		R-A /Span * 100	1.4
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/29/21 03:14	10.0	0.1		R-A /Span * 100	1.0
	High	12/29/21 03:19	10.0	9.1		R-A /Span * 100	1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/29/21 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/29/21 03:24	200.0	180.1		R-A /Span * 100	0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/29/21 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	12/29/21 03:19	10.0	8.8		R-A /Span * 100	0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/29/21 03:14	21.0	18.1		R-A	0.0
	Zero	12/29/21 03:19	21.0	0.0		R-A	0.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/29/21 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/29/21 03:25	200.0	184.6		R-A /Span * 100	1.1

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:09

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/29/21 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	12/29/21 03:19	10.0	8.3	8.4	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/29/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/29/21 03:25	200.0	180.0	179.2	R-A /Span * 100		0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/29/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/29/21 03:19	10.0	8.8	8.7	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	12/29/21 03:14	21.0	18.1	18.1	R-A		0.0
	Zero	12/29/21 03:19	21.0	0.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/30/21 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/30/21 02:25	200.0	180.0	179.7	R-A /Span * 100		0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/30/21 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/30/21 02:20	30.0	27.3	27.3	R-A /Span * 100		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/30/21 02:15	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/30/21 02:25	200.0	180.0	178.5	R-A /Span * 100		0.8
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/30/21 02:15	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/30/21 02:19	30.0	27.2	26.8	R-A /Span * 100		1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/30/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/30/21 03:25	200.0	184.6	185.8	R-A /Span * 100		0.6
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/30/21 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	12/30/21 03:20	10.0	8.3	8.4	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	12/30/21 03:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/30/21 03:25	200.0	180.0	179.3	R-A /Span * 100		0.4
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	12/30/21 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	12/30/21 03:20	10.0	8.8	8.7	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:09 Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/30/21 03:14	21.0	18.1	R-A		0.0
	Zero	12/30/21 03:20	21.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/30/21 03:14	200.0	0.1	R-A /Span * 100		0.1
	High	12/30/21 03:25	200.0	185.6	R-A /Span * 100		0.6
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/30/21 03:14	10.0	0.1	R-A /Span * 100		1.0
	High	12/30/21 03:19	10.0	9.8	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/30/21 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/30/21 03:25	200.0	180.2	R-A /Span * 100		0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/30/21 03:14	10.0	0.0	R-A /Span * 100		0.0
	High	12/30/21 03:19	10.0	9.0	R-A /Span * 100		2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/30/21 03:14	21.0	18.2	R-A		0.1
	Zero	12/30/21 03:19	21.0	0.0	R-A		0.0
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/31/21 02:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/31/21 02:24	200.0	179.7	R-A /Span * 100		0.2
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/31/21 02:14	30.0	0.0	R-A /Span * 100		0.0
	High	12/31/21 02:19	30.0	27.3	R-A /Span * 100		0.0
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/31/21 02:15	200.0	0.0	R-A /Span * 100		0.0
	High	12/31/21 02:25	200.0	178.7	R-A /Span * 100		0.7
Part 60	CT2_NOXInlet_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/31/21 02:15	30.0	0.0	R-A /Span * 100		0.0
	High	12/31/21 02:20	30.0	26.8	R-A /Span * 100		1.3
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/31/21 03:14	200.0	0.0	R-A /Span * 100		0.0
	High	12/31/21 03:24	200.0	184.6	R-A /Span * 100		0.8
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/31/21 03:14	10.0	0.1	R-A /Span * 100		1.0
	High	12/31/21 03:19	10.0	8.4	R-A /Span * 100		1.0

Daily Calibration Results

CT1 and CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/04/2022 09:09

Location: Roseville, CA



All Monitoring Sites, All Instruments, Daily Calibrations

	Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/31/21 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/31/21 03:24	200.0	180.0		R-A /Span * 100	0.2
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/31/21 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	12/31/21 03:19	10.0	8.8		R-A /Span * 100	1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/31/21 03:14	21.0	18.1		R-A	0.0
	Zero	12/31/21 03:19	21.0	0.0		R-A	0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/31/21 03:14	200.0	0.0		R-A /Span * 100	0.1
	High	12/31/21 03:24	200.0	184.4		R-A /Span * 100	1.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/31/21 03:14	10.0	0.0		R-A /Span * 100	1.0
	High	12/31/21 03:19	10.0	9.6		R-A /Span * 100	2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	Zero	12/31/21 03:14	200.0	0.0		R-A /Span * 100	0.0
	High	12/31/21 03:24	200.0	180.0		R-A /Span * 100	0.1
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low		Calibration Result: Online	Pass	
	Zero	12/31/21 03:14	10.0	0.0		R-A /Span * 100	0.0
	High	12/31/21 03:19	10.0	8.8		R-A /Span * 100	2.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High		Calibration Result: Online	Pass	
	High	12/31/21 03:14	21.0	18.1		R-A	0.1
	Zero	12/31/21 03:19	21.0	0.0		R-A	0.0

CEMs Log

Date/Time	Operator	Description
12/30/21 0:09	Operator (RC)	PREVIOUS LOG ENTRY FOR CYLINDER EB0120754 EXP DATE CORRECTION TO 10-21-23
12/30/21 0:07	Operator (RC)	REPLACE LOW NOX/CO BOTTLE ON UNIT 2 NOX@ 8.813/ CO @ 9.636, CYLINDER # EB0120754, EXP DATE 10-21-21
12/11/21 10:58	Operator (EO)	CHANGED CT-2 INLET NOX BOTTLE. CYLINDER # EB0025106, VALUE 27.17 PPM, EXP. DATE 7/28/24
12/10/21 11:38	Operator (DWN)	CHANGED UNIT 2 HIGH NOX/CO. CC249427. CO 184.4 / NOX 180.0. 10/26/24 EXPIRATION
12/10/21 11:37	Operator (DWN)	CHANGED CT2 O2 BOTTLE. EB0105962. 18.13%. 10/22/26 EXPIRATION
12/08/21 10:11	Operator (DWN)	CHANGED UNIT 1 HIGH NOX/CO. CYLINDER# EB0022293. CO 184.6PPM / NOX 180.0PPM. EXPIRATION 10/26/24
12/07/21 5:50	Operator (LHR)	CHANGED OUT UNIT 1 O2 BOTTLE. NEW VALUE = 18.13. CYLINDER # EB0112239.
12/07/21 2:34	Operator (CC)	UPDATED ALL 3 FUEL FACTOR GCV FOR DECEMBER TO 104500
12/06/21 4:23	Operator (LHR)	EDITED FROM LAST ENTRY - CHANGED OUT LOW INLET NOX (20-30) ON UNIT 1. CYLINDER# CC216315. NEW VALUE = 27.27 PPM, EXPIRATION DATE 7-28-24
12/06/21 4:21	Operator (LHR)	CHANGED OUT LOW INLET NOX (20-30) ON UNIT 1. CYLINDER# CC216315. NEW VALUE = 27.27 PPM
12/02/21 8:06	Operator (RG)	MANUALLY CALIBRATED SCR AFTER VACUUM PUMP REPLACED.
11/15/21 15:03	Operator (ME)	CHANGED OUT LOW INLET NOX (20-30) ON UNIT 2. CYLINDER# EB0024524. NEW VALUE = 27.17 PPM
11/08/21 13:20	Operator (ME)	CHANGED OUT HIGH NOX/CO BOTTLE ON UNIT 2. NEW VALUES ARE NOX = 180.0 PPM, CO = 185.1 PPM. CYLINDER # EB0025179. EXP 10/26/2024.
11/07/21 6:51	Operator (BRB)	Manually caled Stack and INLET, checked Spans at analyzer
11/06/21 8:38	Operator (ME)	CHANGED OUT UNIT 2 O2 BOTTLE. NEW VALUE = 18.14. CYLINDER # EB0106099.
11/05/21 8:34	Operator (BRB)	Replaced CT2 SCR PS2 switch and 2 way SOL valve for CT2 SCR 30 Range bottle.
11/03/21 7:00	Operator (ME)	UPDATED ALL 3 FUEL FACTOR GCV FOR NOVEMBER TO 104700.
11/01/21 15:18	Operator (LH)	REPLACED UNIT 2 LOW NOX/CO BOTTLE 8.792 NOX 8.950 CO CYLINDER #EB0097681
10/28/21 15:23	Operator (LH)	UNIT 1 O2 BOTTLE CHANGED 18.05% O2 BOTTLE # CC19835
10/28/21 15:21	Operator (LH)	UNIT 1 HIGH NOX/CO BOTTLE CHANGED 189 PPM NOX 177.2 PPM CO #EB0051575
10/25/21 10:20	Operator (brb)	LE-1/22/21 COMPLETED ALL LINEARITYS AND CGAS FOR UNIT 1 AND 2.
10/23/21 15:49	Operator (LH)	UNIT 2 LOW NOX 30 PPM: CYLINDER EB0032799 NOX @ 26.67, C @ 25.90, EXP DATE 6-10-23

Date/Time	Operator	Description
10/21/21 9:28	Operator (CC)	Exchanged Nox Low on CEMS 2. Bottle EB0030645. Nox 8.991, CO 9.088
10/21/21 9:26	Operator (CC)	Exchanged Nox Low on CEMS 1. Bottle EV0031989. Nox 8.792, CO 8.341
10/16/21 20:38	Administrator (DE)	CHANGED UNIT 2 HIGH NOX / CO. CYLINDER # EB0030590. NOX 189.0 PPM / CO 177.3 PPM
10/14/21 11:33	Administrator (TJ)	CHANGED CT2 NH3 CORRECTION FACTOR FROM 0.128 TO 0.222
10/14/21 11:32	Administrator (TJ)	CHANGED CT1 NH3 CORRECTION FACTOR FROM 0.274 TO 0.319
10/07/21 14:31	Operator (ME)	CHANGED OUT UNIT 2 O2 BOTTLE. 18.24%. CYLINDER # EB0010396.
10/04/21 7:43	Operator (RG)	CHANGED DAILY AUTO CALIBRATION TIME FOR SCR FROM 410 TO 210, CHANGED STACK FROM 510 TO 310.
10/03/21 11:36	Operator (DE)	FUEL FACTOR GCV UPDATED FOR ALL THREE CONSTANTS TO 104,900 FOR OCTOBER.

Cylinder Gas Audit

01/04/2022

Page 1

Facility: ROSEVILLE ENERGY
Unit/Stack: CT1
Parameter/Scal CO / Low

Test Date: 10/22/2021
Test **Pass**

Instrument CT1_CODualRg_P_Instr
Performance 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference	Measured Value	Ref Value As Pct Span
10/22/2021	09:30	L	10	2.400	2.200	24.0 %
10/22/2021	09:36	M	10	5.700	5.500	57.0 %
10/22/2021	09:43	L	10	2.400	2.200	24.0 %
10/22/2021	09:48	M	10	5.700	5.500	57.0 %
10/22/2021	09:55	L	10	2.400	2.200	24.0 %
10/22/2021	10:00	M	10	5.700	5.500	57.0 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Specification	Results
L	2.400	2.200	Std	8.3
M	5.700	5.500	Std	3.5

Cylinder Gas Audit

01/04/2022

Page 2

Facility:	ROSEVILLE ENERGY	Instrument	CT1_CODualRg_P_Instr
Unit/Stack:	CT1	Performance	15 Pct
Parameter/Scal	CO / High	Test	Pass
		Test Date:	10/22/2021
		Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference	Measured Value	Ref Value As Pct Span
10/22/2021	05:31	L	200	50.300	49.000	25.2 %
10/22/2021	05:36	M	200	112.800	113.600	56.4 %
10/22/2021	05:48	L	200	50.300	49.700	25.2 %
10/22/2021	05:53	M	200	112.800	113.800	56.4 %
10/22/2021	06:05	L	200	50.300	49.700	25.2 %
10/22/2021	06:10	M	200	112.800	113.600	56.4 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Specification	Results
L	50.300	49.467	Std	1.7
M	112.800	113.667	Std	0.8

Cylinder Gas Audit

01/04/2022

Page 3

Facility: ROSEVILLE ENERGY
Unit/Stack: CT2
Parameter/Scal CO / Low

Test Date: 10/22/2021
Test **Pass**

Instrument CT2_CODualRg_P_Instr
Performance 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference	Measured Value	Ref Value As Pct Span
10/22/2021	11:27	L	10	2.400	2.300	24.0 %
10/22/2021	11:32	M	10	5.700	5.600	57.0 %
10/22/2021	11:39	L	10	2.400	2.300	24.0 %
10/22/2021	11:44	M	10	5.700	5.600	57.0 %
10/22/2021	11:52	L	10	2.400	2.300	24.0 %
10/22/2021	11:57	M	10	5.700	5.600	57.0 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Specification	Results
L	2.400	2.300	Std	4.2
M	5.700	5.600	Std	1.8

Cylinder Gas Audit

01/04/2022

Page 4

Facility:	ROSEVILLE ENERGY	Instrument	CT2_CODualRg_P_Instr
Unit/Stack:	CT2	Performance	15 Pct
Parameter/Scal	CO / High	Test	Pass
		Test Date:	10/22/2021
		Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference	Measured Value	Ref Value As Pct Span
10/22/2021	06:30	L	200	49.400	49.900	24.7 %
10/22/2021	06:35	M	200	112.700	114.600	56.4 %
10/22/2021	06:47	L	200	49.400	49.900	24.7 %
10/22/2021	06:52	M	200	112.700	115.400	56.4 %
10/22/2021	07:04	L	200	49.400	49.700	24.7 %
10/22/2021	07:09	M	200	112.700	114.900	56.4 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Specification	Results
L	49.400	49.833	Std	0.9
M	112.700	114.967	Std	2.0

Linearity Report

01/04/2022

Page 1

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY	ReasonForTes	QA
EDR Site ID:	CT001	Component ID:	A15	Grace Period:	0
		Component Type:	NOXA		
Instrument	CT1_NOXDualRg_P_Instr	Test End	10/22/2021	Scale:	High
Performance	5 %	Test No.:	112	Highest	3.7
		Status	Passed		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
10/22/2021	0531	L	200.0	47.6	48.5		23.8 %
10/22/2021	0536	M	200.0	105.0	108.6		52.5 %
10/22/2021	0541	H	200.0	189.0	190.5		94.5 %
10/22/2021	0548	L	200.0	47.6	49.0		23.8 %
10/22/2021	0553	M	200.0	105.0	109.1		52.5 %
10/22/2021	0558	H	200.0	189.0	190.3		94.5 %
10/22/2021	0605	L	200.0	47.6	49.1		23.8 %
10/22/2021	0610	M	200.0	105.0	109.0		52.5 %
10/22/2021	0615	H	200.0	189.0	190.3		94.5 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	47.600	48.867	No	2.7
M	105.000	108.900	No	3.7
H	189.000	190.367	No	0.7

Linearity Report

01/04/2022

Page 2

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY	ReasonForTes	QA
EDR Site ID:	CT001	Component ID:	A16	Grace Period:	0
		Component Type:	O2D		
Instrument	CT1_O2D_P_Instrument	Test End	10/22/2021	Scale:	High
Performance	5 %	Test No.:	113	Highest	3.6
		Status	Passed		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
10/22/2021	0732	L	21.0	5.5	5.3		26.2 %
10/22/2021	0737	M	21.0	11.1	11.0		52.9 %
10/22/2021	0742	H	21.0	18.3	18.3		87.1 %
10/22/2021	0749	L	21.0	5.5	5.3		26.2 %
10/22/2021	0754	M	21.0	11.1	11.0		52.9 %
10/22/2021	0759	H	21.0	18.3	18.3		87.1 %
10/22/2021	0806	L	21.0	5.5	5.3		26.2 %
10/22/2021	0811	M	21.0	11.1	11.0		52.9 %
10/22/2021	0816	H	21.0	18.3	18.3		87.1 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.500	5.300	No	3.6
M	11.100	11.000	No	0.9
H	18.300	18.300	No	0.0

Linearity Report

01/04/2022

Page 3

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY	ReasonForTes	QA
EDR Site ID:	CT002	Component ID:	A21	Grace Period:	0
		Component Type:	NOXA		
Instrument	CT2_NOXDualRg_P_Instr	Test End	10/22/2021	Scale:	High
Performance	5 %	Test No.:	115	Highest	2.5
		Status	Passed		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
10/22/2021	0630	L	200.0	48.2	48.8		24.1 %
10/22/2021	0635	M	200.0	106.0	108.6		53.0 %
10/22/2021	0640	H	200.0	189.0	187.7		94.5 %
10/22/2021	0647	L	200.0	48.2	49.2		24.1 %
10/22/2021	0652	M	200.0	106.0	108.7		53.0 %
10/22/2021	0657	H	200.0	189.0	187.9		94.5 %
10/22/2021	0704	L	200.0	48.2	49.2		24.1 %
10/22/2021	0709	M	200.0	106.0	108.8		53.0 %
10/22/2021	0714	H	200.0	189.0	187.9		94.5 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	48.200	49.067	No	1.8
M	106.000	108.700	No	2.5
H	189.000	187.833	No	0.6

Linearity Report

01/04/2022

Page 4

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY	ReasonForTes	QA
EDR Site ID:	CT002	Component ID:	A22	Grace Period:	0
		Component Type:	O2D		
Instrument	CT2_O2D_P_Instrument	Test End	10/22/2021	Scale:	High
Performance	5 %	Test No.:	116	Highest	0.5
		Status	Passed		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
10/22/2021	0832	L	21.0	5.0	5.0		23.8 %
10/22/2021	0837	M	21.0	11.2	11.2		53.3 %
10/22/2021	0842	H	21.0	18.2	18.3		86.7 %
10/22/2021	0849	L	21.0	5.0	5.0		23.8 %
10/22/2021	0854	M	21.0	11.2	11.2		53.3 %
10/22/2021	0859	H	21.0	18.2	18.3		86.7 %
10/22/2021	0906	L	21.0	5.0	5.0		23.8 %
10/22/2021	0911	M	21.0	11.2	11.2		53.3 %
10/22/2021	0916	H	21.0	18.2	18.3		86.7 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.000	5.000	No	0.0
M	11.200	11.200	No	0.0
H	18.200	18.300	No	0.5

Roseville Energy Park Revision History

RegPerfect® by Teledyne Monitor Labs, Inc.

Teledyne Monitor Labs, Inc.

35 Inverness Drive East

Englewood, CO 80112-5189

Telephone: (800) 846-6062

<http://www.teledyne-ml.com/>

<http://www.regperfect.com/>

©1998-2005 Teledyne Monitor Labs, Inc. All rights reserved.

RegPerfect® is a registered trademark of Teledyne Monitor Labs, Inc.

NOTE: This server's C drive is only 20 GB in size!! Do not place large files on this drive.

12/27/21 Taylor Sullivan

Disabled the custom alarms on CT1/2_OpHoursQtr_Hr_1H.

12/22/21 Taylor Sullivan

EDR check

12/10/21 Taylor Sullivan

EDR check

11/23/21 Taylor Sullivan

EDR check

11/15/21 Taylor Sullivan

Updated the expiration dates on the NOx low-range daily cal bottles that expired while in use and were recertified (EB0052247 and EB0101792).

11/11/21 Taylor Sullivan

EDR check

11/10/21 Greg Terry

RS Logix is not installed on this server but using the PLC read/write tool verified the sample valid delay after cals is 9 minutes on both units. (address N50:65)

10/19-21/21 Taylor Sullivan

Q3 EDR

CO Ppmvdc EDS/CMS Summary Report

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:07 **Location:** Roseville, CA
Description: Electric Utility

CMS Data from: CT1_CO_Ppmvdc_1H
EDS Data from: CT1_CO_Ppmvdc_3H
Emission Limitation: 4
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 04/09/2006 14:00
Process Unit(s) Description:
Operating time for EDS: 2,058.00 Hour(s)
Operating time for CMS: 2,058.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

NOx Ppmvdc EDS/CMS Summary Report

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:08 **Location:** Roseville, CA
Description: Electric Utility

CMS Data from: CT1_NOx_Ppmvdc_1H
EDS Data from: CT1_NOx_Ppmvdc_1H
Emission Limitation: 2.0
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-02
Date of Latest CMS Certification or Audit: 04/09/2006 14:00
Process Unit(s) Description:
Operating time for EDS: 2,058.00 Hour(s)
Operating time for CMS: 2,058.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	1
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	1
4. Time of Excess Emission as a percentage of operating time	0.05
5. Time in compliance as percentage of operating time	99.95

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

CO Ppmvdc EDS/CMS Summary Report

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:14 **Location:** Roseville, CA
Description: Electric Utility

CMS Data from: CT2_CO_Ppmvdc_1H
EDS Data from: CT2_CO_Ppmvdc_3H
Emission Limitation: 4
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 04/10/2006 07:00
Process Unit(s) Description:
Operating time for EDS: 2,208.00 Hour(s)
Operating time for CMS: 2,208.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	3
2. Total CMS Downtime	3
3. Total Downtime as a percentage of operating time	0.14
4. Total Availability as a percentage of operating time	99.86

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

NOx Ppmvdc EDS/CMS Summary Report

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:14 **Location:** Roseville, CA
Description: Electric Utility

CMS Data from: CT2_NOx_Ppmvdc_1H
EDS Data from: CT2_NOx_Ppmvdc_1H
Emission Limitation: 2.0
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-02
Date of Latest CMS Certification or Audit: 04/10/2006 07:00
Process Unit(s) Description:
Operating time for EDS: 2,208.00 Hour(s)
Operating time for CMS: 2,208.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	3
2. Total CMS Downtime	3
3. Total Downtime as a percentage of operating time	0.14
4. Total Availability as a percentage of operating time	99.86

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

CO Invalid Data

CT1

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:15 Location: Roseville, CA



Tag Name: CT1_CO_Ppm_1H
Total Operating Time: 2,058.00 Hour(s)
Non-Operating Time: 150.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	2,058.00 Hour(s)
Total Monitor Downtime (Online only):	0.00 Hour(s)
Percent Monitor Availability:	100.00 %
Percent Monitor Downtime:	0.00 %

NOx Invalid Data



CT1

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:16 Location: Roseville, CA

Tag Name: CT1_NOx_Ppm_1H
Total Operating Time: 2,058.00 Hour(s)
Non-Operating Time: 150.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	2,058.00 Hour(s)
Total Monitor Downtime (Online only):	0.00 Hour(s)
Percent Monitor Availability:	100.00 %
Percent Monitor Downtime:	0.00 %

NOx SCR Invalid Data



CT1

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:16 Location: Roseville, CA

Tag Name: CT1_NOx_SCR_Ppm_1H
Total Operating Time: 2,058.00 Hour(s)
Non-Operating Time: 150.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	11/30/2021 09:00	11/30/2021 09:59	1		
2	11/30/2021 10:00	11/30/2021 10:59	1		

Total Operating Time:	2,058.00 Hour(s)
Total Monitor Downtime (Online only):	2.00 Hour(s)
Percent Monitor Availability:	99.90 %
Percent Monitor Downtime:	0.10 %

O2 Invalid Data

CT1

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:17 Location: Roseville, CA



Tag Name: CT1_O2Dry_Pct_1H
Total Operating Time: 2,058.00 Hour(s)
Non-Operating Time: 150.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	2,058.00 Hour(s)
Total Monitor Downtime (Online only):	0.00 Hour(s)
Percent Monitor Availability:	100.00 %
Percent Monitor Downtime:	0.00 %

CO Invalid Data

CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:17 Location: Roseville, CA



Tag Name: CT2_CO_Ppm_1H
Total Operating Time: 2,208.00 Hour(s)
Non-Operating Time: 0.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	11/04/2021 07:00	11/04/2021 07:59	1		

Total Operating Time:	2,208.00 Hour(s)
Total Monitor Downtime (Online only):	1.00 Hour(s)
Percent Monitor Availability:	99.95 %
Percent Monitor Downtime:	0.05 %

NOx Invalid Data

CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:18 Location: Roseville, CA



Tag Name: CT2_NOx_Ppm_1H
Total Operating Time: 2,208.00 Hour(s)
Non-Operating Time: 0.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	11/04/2021 07:00	11/04/2021 07:59	1		

Total Operating Time:	2,208.00 Hour(s)
Total Monitor Downtime (Online only):	1.00 Hour(s)
Percent Monitor Availability:	99.95 %
Percent Monitor Downtime:	0.05 %

NOx SCR Invalid Data

CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:18 Location: Roseville, CA



Tag Name: CT2_NOx_SCR_Ppm_1H

Total Operating Time: 2,208.00 Hour(s)

Non-Operating Time: 0.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	11/04/2021 07:00	11/04/2021 07:59	1		
2	11/06/2021 02:00	11/06/2021 02:59	1	3 - Quality assurance calibration	
3	11/06/2021 03:00	11/06/2021 03:59	1		
4	11/06/2021 04:00	11/06/2021 04:59	1		
5	11/06/2021 05:00	11/06/2021 05:59	1		
6	11/06/2021 06:00	11/06/2021 06:59	1		
7	11/06/2021 07:00	11/06/2021 07:59	1		
8	11/06/2021 08:00	11/06/2021 08:59	1		
9	11/06/2021 09:00	11/06/2021 09:59	1		
10	11/06/2021 10:00	11/06/2021 10:59	1		
11	11/06/2021 11:00	11/06/2021 11:59	1		
12	11/06/2021 12:00	11/06/2021 12:59	1		
13	11/06/2021 13:00	11/06/2021 13:59	1		
14	11/06/2021 14:00	11/06/2021 14:59	1		
15	11/06/2021 15:00	11/06/2021 15:59	1		
16	11/06/2021 16:00	11/06/2021 16:59	1		
17	11/06/2021 17:00	11/06/2021 17:59	1		
18	11/06/2021 18:00	11/06/2021 18:59	1		
19	11/06/2021 19:00	11/06/2021 19:59	1		
20	11/06/2021 20:00	11/06/2021 20:59	1		
21	11/06/2021 21:00	11/06/2021 21:59	1		
22	11/06/2021 22:00	11/06/2021 22:59	1		
23	11/06/2021 23:00	11/06/2021 23:59	1		
24	11/07/2021 00:00	11/07/2021 00:59	1		
25	11/07/2021 01:00	11/07/2021 01:59	1		
26	11/07/2021 02:00	11/07/2021 02:59	1	3 - Quality assurance calibration	

NOx SCR Invalid Data

CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59
Generated: 01/04/2022 10:18

Facility Name: ROSEVILLE ENERGY
Location: Roseville, CA



Tag Name: CT2_NOx_SCR_Ppm_1H

Total Operating Time: 2,208.00 Hour(s)

Non-Operating Time: 0.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
27	11/07/2021 03:00	11/07/2021 03:59	1		
28	11/07/2021 04:00	11/07/2021 04:59	1		
29	11/07/2021 05:00	11/07/2021 05:59	1		

Total Operating Time:	2,208.00 Hour(s)
Total Monitor Downtime (Online only):	29.00 Hour(s)
Percent Monitor Availability:	98.69 %
Percent Monitor Downtime:	1.31 %

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Quality assurance calibration	2	6.90

02 Invalid Data

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:19 Location: Roseville, CA

Tag Name: CT2_O2Dry_Pct_1H
Total Operating Time: 2,208.00 Hour(s)
Non-Operating Time: 0.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	11/04/2021 07:00	11/04/2021 07:59	1		
2	11/07/2021 03:00	11/07/2021 03:59	1	3 - Quality assurance calibration	
3	11/07/2021 04:00	11/07/2021 04:59	1		

Total Operating Time:	2,208.00 Hour(s)
Total Monitor Downtime (Online only):	3.00 Hour(s)
Percent Monitor Availability:	99.86 %
Percent Monitor Downtime:	0.14 %

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Quality assurance calibration	1	33.33

AQ-36

AQ-36: The project owner shall notify the _PCAPCD of any breakdown condition as soon as reasonably possible, but no later than two PCAPCD business hours after its detection.

Verification: The Project owner shall include the identification of all breakdowns, PCAPCD notification, resulting excess emission (if any) and corrective actions taken (if any) as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6



Year Non-Compliance Event Number

Year

Non-Compliance Event Number

110 Maple Street, Auburn, CA 95603 • (530) 745-2330 • Fax (530) 745-2373 • www.placerair.org

Erik C. White, Air Pollution Control Officer

NON-COMPLIANCE EVENT NOTIFICATION FORM – PART I

submit within 2 business hours after detection of the Non-Compliance Event

1. Company Name	ROSEVILLE ENERGY PARK	5120 PHILLIP ROAD
2. Title V Source Status	Major Yes ☒ No ☐	Synthetic Minor Yes ☐ No ☒
3. For Title V Sources, is the Non-Compliance Event the Result of an Emergency under District Rule 507, Section 402.2(I)	Yes ☐ No ☒	
4. Emission Exceedances	NOx ☐ SOx ☐ PM ☐ VOC ☐ CO ☐ Opacity ☐ None ☒	check all that apply
5. CEMS / COMS / CMS Breakdown	Yes ☐ No ☒	
6. Detection of Non-Compliance Event	Date 11-7-21	Time 02:15 ☒ AM ☐ PM
7. Start of Non-Compliance Event	Date 11-7-21	Time 02:15 ☒ AM ☐ PM ☐ Not known
8. Violation	Permit No. REPR-20-02	Condition No. Rule Section
9. Unit / Equipment Involved	CT2	
10. Description / Cause of Non-Compliance Event	CEMS failed calibration due to low cal gas flow ☐ additional information attached	
11. Immediate Corrective Actions	Instrument Tech called in to troubleshoot failure ☐ additional information attached	
12. Was the Non-Compliance Event an Emission Violation or Monitoring Equipment Failure or Malfunction	Yes ☐ No ☒	
If yes, do you Request that the Violation, Failure or Malfunction be Shielded from Enforcement Action as an Upset / Breakdown Pursuant to District Rule 404		
Yes ☐ No ☐ Not Able to Determine at this Time ☐ If "Yes", complete and submit the Upset / Breakdown Checklist Form with Part I		
13. Submitted By	Tony Johnson	Telephone (916) 746 - 1656
Signature		Date 11-10-21 Time 08:00 ☐ AM ☐ PM

NON-COMPLIANCE EVENT NOTIFICATION FORM – PART II

submit within 7 calendar days after end of the Non-Compliance Event

14. End of Non-Compliance Event	Date 11-7-21	Time 5:33	☒ AM ☐ PM
15. Duration of Non-Compliance Event	Hours n/a	Minutes	
16. Excess Emissions Estimates	NOx	SOx	PM
	VOC	CO	Opacity %, for minutes Other N/A
17. Variance in Effect	Yes ☐ Variance # No ☒		
18. Corrective and Preventative Actions Taken	(a) Minimize Emissions (b) Correct Event Found cal gas isolated at regulator. Opened valve ran successful cal (c) Prevent Future Events Review procedure with staff ☐ additional information attached		
19. If Not Able to Determine in Item 12 of Part I, Was the Non-Compliance Event an Emission Violation or Monitoring Equipment Failure or Malfunction	Yes ☐ No ☒ If "Yes", complete and submit the Upset / Breakdown Checklist Form if not previously submitted with Part I		
20. Submitted By	Tony Johnson	Telephone	(916) 746 - 1656
I certify under penalty of law that I am the responsible official for this facility, or his/her duly designated representative, and based on information and belief formed after reasonable inquiry, the statements and information in this document are true, accurate, and complete.			
Signature		Date 11-10-21	Time 08:00 ☒ AM ☐ PM



| | | - | 2 0 2 1 0 0 9

Year

Non-Compliance
Event Number

110 Maple Street, Auburn, CA 95603 • (530) 745-2330 • Fax (530) 745-2373 • www.placerair.org

Erik C. White, Air Pollution Control Officer

NON-COMPLIANCE EVENT NOTIFICATION FORM – PART I

submit within 2 business hours after detection of the Non-Compliance Event

1. Company Name	ROSEVILLE ENERGY PARK		5120 PHILLIP ROAD	
2. Title V Source Status	Major Yes ☒ No ☐		Synthetic Minor Yes ☐ No ☐	
3. For Title V Sources, is the Non-Compliance Event the Result of an Emergency under District Rule 507, Section 402.2(l)	Yes ☐ No ☒			
4. Emission Exceedances	NOx ☒	SOx ☐	PM ☐	VOC ☐ CO ☐ Opacity ☐ None ☐ check all that apply
5. CEMS / COMS / CMS Breakdown	Yes ☐ No ☒			
6. Detection of Non-Compliance Event	Date	11-19-21	Time	09:00 ☒ AM ☐ PM
7. Start of Non-Compliance Event	Date	11-19-21	Time	08:40 ☒ AM ☐ PM ☐ Not known
8. Violation	Permit No. REPR-20-01	Condition No. 49	Rule	Section
9. Unit / Equipment Involved	CT1			
10. Description / Cause of Non-Compliance Event	NOx exceedance coming out of startup period ☐ additional information attached			
11. Immediate Corrective Actions	manually increased ammonia flow ☐ additional information attached			
12. Was the Non-Compliance Event an Emission Violation or Monitoring Equipment Failure or Malfunction	Yes ☐ No ☐			
If yes, do you Request that the Violation, Failure or Malfunction be Shielded from Enforcement Action as an Upset / Breakdown Pursuant to District Rule 404				
Yes ☐		No ☐	Not Able to Determine at this Time ☐	
If "Yes", complete and submit the Upset / Breakdown Checklist Form with Part I				
13. Submitted By	Tony Johnson		Telephone	(916) 746 - 1656
Signature			Date	11-19-21 Time 07:00 ☐ AM ☐ PM

NON-COMPLIANCE EVENT NOTIFICATION FORM – PART II

submit within 7 calendar days after end of the Non-Compliance Event

14. End of Non-Compliance Event	Date	11-19-21	Time	09:00 ☐ AM ☐ PM
15. Duration of Non-Compliance Event	Hours	Minutes 20		
16. Excess Emissions Estimates	NOx 2.1 ppmvdc	SOx	PM	
VOC	CO	Opacity	%, for	minutes Other
17. Variance in Effect	Yes ☐ Variance #		No ☐	
18. Corrective and Preventative Actions Taken	(a) Minimize Emissions (b) Correct Event (c) Prevent Future Events ☐ additional information attached			
19. If Not Able to Determine in Item 12 of Part I, Was the Non-Compliance Event an Emission Violation or Monitoring Equipment Failure or Malfunction	If yes, do you Request that the Violation, Failure or Malfunction be Shielded from Enforcement Action as an Upset / Breakdown Under District Rule 404			
Yes ☐		No ☐	If "Yes", complete and submit the Upset / Breakdown Checklist Form if not previously submitted with Part I	
20. Submitted By	Tony Johnson		Telephone	(916) 746 - 1656
I certify under penalty of law that I am the responsible official for this facility, or his/her duly designated representative, and based on information and belief formed after reasonable inquiry, the statements and information in this document are true, accurate, and complete.				
Signature			Date	11-19-21 Time 10:00 ☐ AM ☐ PM

NOx Ppmvdc 1-Hour Block Excess Emissions

CT1

From: 11/19/2021 00:00 To: 11/19/2021 09:26 Facility Name: ROSEVILLE ENERGY
Generated: 11/19/2021 09:28 Location: Roseville, CA



Tag Name: CT1_NOx_Ppmvdc_1H

Total Operating Time: 3.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 7.00 Hour(s) Report Time: 10.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Tag Value	Limit	Reason Code	Action Code
1	11/19/21 08:00	11/19/21 08:59	1	2.1	2.0		

Total Operating Time:	3.00 Hour(s)
Total Duration (Online only):	1.00 Hour(s)
Time in exceedance as a percentage of operating time:	33.33 %
Time in compliance as a percentage of operating time:	66.67 %

Date/Time	CT1_NOx_Ppmvdc_1M			CT1_SUSDTF_1M			CT1_Load_CT_MWe_1M			CT1_NH3Inj_LbPerHr_1M			_None			Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod			
11/19/21 8:35	2.55			1			25			28								
11/19/21 8:36	2.29			1			23.9			25.7								
11/19/21 8:37	1.79			1			23.3			22.9								
11/19/21 8:38	1.7			1			22.5			21.9								
11/19/21 8:39	1.72			1			21.8			21.8								
11/19/21 8:40	1.72			0			21.2			21.7								
11/19/21 8:41	1.84			0			20.4			25								
11/19/21 8:42	2.03			0			19.8			30.4								
11/19/21 8:43	2.21			0			19.4			33.7								
11/19/21 8:44	2.53			0			19.2			36.4								
11/19/21 8:45	2.66			0			19.2			39.5								
11/19/21 8:46	2.76			0			19.2			39.9								
11/19/21 8:47	2.66			0			19.2			44.2								
11/19/21 8:48	2.57			0			19.2			53								
11/19/21 8:49	2.38			0			19.2			37.8								
11/19/21 8:50	2.19			0			19.2			40.2								
11/19/21 8:51	2			0			19.2			40								
11/19/21 8:52	1.9			0			19.2			39.8								
11/19/21 8:53	1.9			0			19.2			39.7								
11/19/21 8:54	1.81			0			19.3			39.5								
11/19/21 8:55	1.81			0			19.2			39.6								
11/19/21 8:56	1.71			0			19.2			39.4								
11/19/21 8:57	1.71			0			19.2			39.3								
11/19/21 8:58	1.62			0			20.4			40.2								
11/19/21 8:59	1.59			0			21.3			40								
11/19/21 9:00	1.48			0			21.3			33.7								
11/19/21 9:01	1.29			0			21.4			32								
11/19/21 9:02	1.2			0			21.2			30.5								
11/19/21 9:03	1.2			0			21			29.2								
11/19/21 9:04	1.11			0			20.9			28.6								
11/19/21 9:05	1.11			0			20.8			27.7								

START UP OVER

NH3 TO MANUAL

END OF HOUR 2.05 ppm

Excess Emissions NOx ppmvdc CT1 11-19-21

Date/Time	CT1_NOx_Ppmvdc_1M			CT1_SUSD_TF_1M			CT1_Load_CT_MWe_1M			CT1_NH3Inj_LbPerHr_1M			_None			Value	SI	Mod
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod			
11/19/21 8:00	10.25			1			0			0								
11/19/21 8:01	12.92			1			0			0								
11/19/21 8:02	19.24			1			0			0								
11/19/21 8:03	15.26			1			1.9			0								
11/19/21 8:04	26			1			4.6			0								
11/19/21 8:05	27.48			1			7.5			0								
11/19/21 8:06	28.17			1			10.5			0								
11/19/21 8:07	28.98			1			13.4			0								
11/19/21 8:08	29.03			1			15.9			0								
11/19/21 8:09	29.07			1			19.3			0								
11/19/21 8:10	14.12			1			22.5			0								
11/19/21 8:11	9.48			1			25.3			0								
11/19/21 8:12	7.25			1			26.6			0								
11/19/21 8:13	7			1			26.8			0								
11/19/21 8:14	6.91			1			26.8			0								
11/19/21 8:15	6.41			1			26.6			0								
11/19/21 8:16	6.16			1			26.4			0								
11/19/21 8:17	5.73			1			26.4			0								
11/19/21 8:18	5.64			1			26.4			0								
11/19/21 8:19	5.64			1			26.4			0								
11/19/21 8:20	5.47			1			26.4			0								
11/19/21 8:21	5.47			1			26.4			0								
11/19/21 8:22	5.47			1			26.4			0								
11/19/21 8:23	5.47			1			26.5			0								
11/19/21 8:24	5.47			1			26.7			0								
11/19/21 8:25	5.55			1			26.8			0								
11/19/21 8:26	5.64			1			26.8			1.5								
11/19/21 8:27	5.73			1			26.8			45.3								
11/19/21 8:28	5.29			1			26.7			31.3								
11/19/21 8:29	3.56			1			26.4			24.7								
11/19/21 8:30	2.99			1			26.2			21.4								
11/19/21 8:31	2.91			1			26.1			20.9								
11/19/21 8:32	2.82			1			26			23.6								
11/19/21 8:33	2.73			1			26			25.5								
11/19/21 8:34	2.64			1			26.3			27.5								

AQ-37

AQ-37 Any Violation of any emission standard listed in this permit which is indicated by the CEMS shall be reported to the PCAPCD no later than 96 hours after such occurrence as per California Health and Safety Code 42706

Verification: The Project owner shall include all violations of emissions standards and corresponding PCAPCD notifications in the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

All Notices of Non Compliance are included in AQ-41.

AQ-40

AQ-40 The Project owner shall comply with the applicable requirements for quality assurance testing and maintenance of the continuous emission monitor equipment in accordance with the procedures and guidance specified in 40 CFR Part 60, Appendix F.

Verification: The Project owner shall include all CEMS quality assurance test failures that required corrective action as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

Cylinder Gas Audit

01/04/2022

Page 1

Facility: ROSEVILLE ENERGY
Unit/Stack: CT1
Parameter/Scal CO / Low

Test Date: 10/22/2021
Test **Pass**

Instrument CT1_CODualRg_P_Instr
Performance 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference	Measured Value	Ref Value As Pct Span
10/22/2021	09:30	L	10	2.400	2.200	24.0 %
10/22/2021	09:36	M	10	5.700	5.500	57.0 %
10/22/2021	09:43	L	10	2.400	2.200	24.0 %
10/22/2021	09:48	M	10	5.700	5.500	57.0 %
10/22/2021	09:55	L	10	2.400	2.200	24.0 %
10/22/2021	10:00	M	10	5.700	5.500	57.0 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Specification	Results
L	2.400	2.200	Std	8.3
M	5.700	5.500	Std	3.5

Cylinder Gas Audit

01/04/2022

Page 2

Facility:	ROSEVILLE ENERGY	Instrument	CT1_CODualRg_P_Instr
Unit/Stack:	CT1	Performance	15 Pct
Parameter/Scal	CO / High	Test	Pass
		Test Date:	10/22/2021
		Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference	Measured Value	Ref Value As Pct Span
10/22/2021	05:31	L	200	50.300	49.000	25.2 %
10/22/2021	05:36	M	200	112.800	113.600	56.4 %
10/22/2021	05:48	L	200	50.300	49.700	25.2 %
10/22/2021	05:53	M	200	112.800	113.800	56.4 %
10/22/2021	06:05	L	200	50.300	49.700	25.2 %
10/22/2021	06:10	M	200	112.800	113.600	56.4 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Specification	Results
L	50.300	49.467	Std	1.7
M	112.800	113.667	Std	0.8

Cylinder Gas Audit

01/04/2022

Page 3

Facility: ROSEVILLE ENERGY
Unit/Stack: CT2
Parameter/Scale: CO / Low

Test Date: 10/22/2021
Test **Pass**

Instrument: CT2_CODualRg_P_Instr
Performance: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference	Measured Value	Ref Value As Pct Span
10/22/2021	11:27	L	10	2.400	2.300	24.0 %
10/22/2021	11:32	M	10	5.700	5.600	57.0 %
10/22/2021	11:39	L	10	2.400	2.300	24.0 %
10/22/2021	11:44	M	10	5.700	5.600	57.0 %
10/22/2021	11:52	L	10	2.400	2.300	24.0 %
10/22/2021	11:57	M	10	5.700	5.600	57.0 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Specification	Results
L	2.400	2.300	Std	4.2
M	5.700	5.600	Std	1.8

Cylinder Gas Audit

01/04/2022

Page 4

Facility:	ROSEVILLE ENERGY	Instrument	CT2_CODualRg_P_Instr
Unit/Stack:	CT2	Performance	15 Pct
Parameter/Scal	CO / High	Test	Pass
		Test Date:	10/22/2021
		Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference	Measured Value	Ref Value As Pct Span
10/22/2021	06:30	L	200	49.400	49.900	24.7 %
10/22/2021	06:35	M	200	112.700	114.600	56.4 %
10/22/2021	06:47	L	200	49.400	49.900	24.7 %
10/22/2021	06:52	M	200	112.700	115.400	56.4 %
10/22/2021	07:04	L	200	49.400	49.700	24.7 %
10/22/2021	07:09	M	200	112.700	114.900	56.4 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Specification	Results
L	49.400	49.833	Std	0.9
M	112.700	114.967	Std	2.0

Linearity Report

01/04/2022

Page 1

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY	ReasonForTes	QA
EDR Site ID:	CT001	Component ID:	A15	Grace Period:	0
		Component Type:	NOXA		
Instrument	CT1_NOXDualRg_P_Instr	Test End	10/22/2021	Scale:	High
Performance	5 %	Test No.:	112	Highest	3.7
		Status	Passed		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
10/22/2021	0531	L	200.0	47.6	48.5		23.8 %
10/22/2021	0536	M	200.0	105.0	108.6		52.5 %
10/22/2021	0541	H	200.0	189.0	190.5		94.5 %
10/22/2021	0548	L	200.0	47.6	49.0		23.8 %
10/22/2021	0553	M	200.0	105.0	109.1		52.5 %
10/22/2021	0558	H	200.0	189.0	190.3		94.5 %
10/22/2021	0605	L	200.0	47.6	49.1		23.8 %
10/22/2021	0610	M	200.0	105.0	109.0		52.5 %
10/22/2021	0615	H	200.0	189.0	190.3		94.5 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	47.600	48.867	No	2.7
M	105.000	108.900	No	3.7
H	189.000	190.367	No	0.7

Linearity Report

01/04/2022

Page 2

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY	ReasonForTes	QA
EDR Site ID:	CT001	Component ID:	A16	Grace Period:	0
		Component Type:	O2D		
Instrument	CT1_O2D_P_Instrument	Test End	10/22/2021	Scale:	High
Performance	5 %	Test No.:	113	Highest	3.6
		Status	Passed		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
10/22/2021	0732	L	21.0	5.5	5.3		26.2 %
10/22/2021	0737	M	21.0	11.1	11.0		52.9 %
10/22/2021	0742	H	21.0	18.3	18.3		87.1 %
10/22/2021	0749	L	21.0	5.5	5.3		26.2 %
10/22/2021	0754	M	21.0	11.1	11.0		52.9 %
10/22/2021	0759	H	21.0	18.3	18.3		87.1 %
10/22/2021	0806	L	21.0	5.5	5.3		26.2 %
10/22/2021	0811	M	21.0	11.1	11.0		52.9 %
10/22/2021	0816	H	21.0	18.3	18.3		87.1 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.500	5.300	No	3.6
M	11.100	11.000	No	0.9
H	18.300	18.300	No	0.0

Linearity Report

01/04/2022

Page 3

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY	ReasonForTes	QA
EDR Site ID:	CT002	Component ID:	A21	Grace Period:	0
		Component Type:	NOXA		
Instrument	CT2_NOXDualRg_P_Instr	Test End	10/22/2021	Scale:	High
Performance	5 %	Test No.:	115	Highest	2.5
		Status	Passed		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
10/22/2021	0630	L	200.0	48.2	48.8		24.1 %
10/22/2021	0635	M	200.0	106.0	108.6		53.0 %
10/22/2021	0640	H	200.0	189.0	187.7		94.5 %
10/22/2021	0647	L	200.0	48.2	49.2		24.1 %
10/22/2021	0652	M	200.0	106.0	108.7		53.0 %
10/22/2021	0657	H	200.0	189.0	187.9		94.5 %
10/22/2021	0704	L	200.0	48.2	49.2		24.1 %
10/22/2021	0709	M	200.0	106.0	108.8		53.0 %
10/22/2021	0714	H	200.0	189.0	187.9		94.5 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	48.200	49.067	No	1.8
M	106.000	108.700	No	2.5
H	189.000	187.833	No	0.6

Linearity Report

01/04/2022

Page 4

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY	ReasonForTes	QA
EDR Site ID:	CT002	Component ID:	A22	Grace Period:	0
		Component Type:	O2D		
Instrument	CT2_O2D_P_Instrument	Test End	10/22/2021	Scale:	High
Performance	5 %	Test No.:	116	Highest	0.5
		Status	Passed		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
10/22/2021	0832	L	21.0	5.0	5.0		23.8 %
10/22/2021	0837	M	21.0	11.2	11.2		53.3 %
10/22/2021	0842	H	21.0	18.2	18.3		86.7 %
10/22/2021	0849	L	21.0	5.0	5.0		23.8 %
10/22/2021	0854	M	21.0	11.2	11.2		53.3 %
10/22/2021	0859	H	21.0	18.2	18.3		86.7 %
10/22/2021	0906	L	21.0	5.0	5.0		23.8 %
10/22/2021	0911	M	21.0	11.2	11.2		53.3 %
10/22/2021	0916	H	21.0	18.2	18.3		86.7 %

Summary

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.000	5.000	No	0.0
M	11.200	11.200	No	0.0
H	18.200	18.300	No	0.5

Roseville Energy Park Revision History

RegPerfect® by Teledyne Monitor Labs, Inc.

Teledyne Monitor Labs, Inc.

35 Inverness Drive East

Englewood, CO 80112-5189

Telephone: (800) 846-6062

<http://www.teledyne-ml.com/>

<http://www.regperfect.com/>

©1998-2005 Teledyne Monitor Labs, Inc. All rights reserved.

RegPerfect® is a registered trademark of Teledyne Monitor Labs, Inc.

NOTE: This server's C drive is only 20 GB in size!! Do not place large files on this drive.

12/27/21 Taylor Sullivan

Disabled the custom alarms on CT1/2_OpHoursQtr_Hr_1H.

12/22/21 Taylor Sullivan

EDR check

12/10/21 Taylor Sullivan

EDR check

11/23/21 Taylor Sullivan

EDR check

11/15/21 Taylor Sullivan

Updated the expiration dates on the NOx low-range daily cal bottles that expired while in use and were recertified (EB0052247 and EB0101792).

11/11/21 Taylor Sullivan

EDR check

11/10/21 Greg Terry

RS Logix is not installed on this server but using the PLC read/write tool verified the sample valid delay after cals is 9 minutes on both units. (address N50:65)

10/19-21/21 Taylor Sullivan

Q3 EDR

AQ-41

AQ-41 The Project owner shall submit a written report to the APCO and the CPM for each calendar quarter, within 30 days of the end of the quarter, including: time intervals, data and magnitude of excess emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; averaging period used for data reporting shall correspond to the averaging period for each respective emission standard; applicable time and date of each period during which the CEMS was inoperative (except for zero and span checks) and the nature of the system repairs and adjustments; and a negative declaration when no excess emission occurred.

Verification: The Project owner shall include the excess emission report as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6

Excess Emission Report



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:25 **Location:** Roseville, CA

Tag Name: ALL_CO_Lb_1D
Total Operating Time: 92.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 0.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	92.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:26 **Location:** Roseville, CA

Tag Name: ALL_NOX_Lb_1D
Total Operating Time: 92.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 0.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	92.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:27 **Location:** Roseville, CA

Tag Name: ALL_PM10_Lb_1D
Total Operating Time: 92.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 0.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	92.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:27 **Location:** Roseville, CA

Tag Name: ALL_SO2_Lb_1D
Total Operating Time: 92.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 0.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	92.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 10:27 **Location:** Roseville, CA

Tag Name: ALL_VOC_Lb_1D
Total Operating Time: 92.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 0.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	92.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO LbPerHr 3-Hour Rolling Excess Emissions

CT1

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:42 Location: Roseville, CA



Tag Name: CT1_CO_3Hr_LbPerHr_1H
Total Operating Time: 2,058.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 150.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,058.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO Ppmvdc 3-Hour Block Excess Emissions



CT1

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:44 Location: Roseville, CA

Tag Name: CT1_CO_Ppmvdc_3H
Total Operating Time: 2,058.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 150.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,058.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO LbPerHr SUSd 1-Hour Block Excess Emissions



CT1

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:44 Location: Roseville, CA

Tag Name: CT1_CO_SUSD_LbPerHr_1H
Total Operating Time: 2,058.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 150.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,058.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NH3 Slip Ppmvdc 1-Hour Block Excess Emissions



CT1

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:45 Location: Roseville, CA

Tag Name: CT1_NH3Slip_Ppmvdc_1H
Total Operating Time: 2,058.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 150.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,058.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx LbPerHr 1-Hour Block Excess Emissions



CT1

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:45 Location: Roseville, CA

Tag Name: CT1_NOx_Norm_LbPerHr_1H
Total Operating Time: 2,058.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 150.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,058.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx Ppmvdc 1-Hour Block Excess Emissions

CT1

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:46 Location: Roseville, CA



Tag Name: CT1_NOx_Ppmvdc_1H

Total Operating Time: 2,058.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 150.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Tag Value	Limit	Reason Code	Action Code
1	11/19/21 08:00	11/19/21 08:59	1	2.1	2.0	1 - Startup/shutdown	3 - RETURN TO NORMAL OPERATIONS

Total Operating Time:	2,058.00 Hour(s)
Total Duration (Online only):	1.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.05 %
Time in compliance as a percentage of operating time:	99.95 %

Report Code	Type	Text	Duration	Duration Percent
1	Reason	Startup/shutdown	1	100.00
3	Action	RETURN TO NORMAL OPERATIONS	1	100.00

NOx LbPerHr SUSd 1-Hour Block Excess Emissions



CT1

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:46 Location: Roseville, CA

Tag Name: CT1_NOx_SUSd_LbPerHr_1H
Total Operating Time: 2,058.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 150.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,058.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

PM10 LbPerHr 1-Hour Block Excess Emissions



CT1

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:47 Location: Roseville, CA

Tag Name: CT1_PM10_Norm_LbPerHr_1H
Total Operating Time: 2,058.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 150.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,058.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

S02 LbPerHr 1-Hour Block Excess Emissions



CT1

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:47 Location: Roseville, CA

Tag Name: CT1_S02_Norm_LbPerHr_1H
Total Operating Time: 2,058.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 150.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,058.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

VOC LbPerHr 1-Hour Block Excess Emissions



CT1

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:48 Location: Roseville, CA

Tag Name: CT1_VOC_Norm_LbPerHr_1H
Total Operating Time: 2,058.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 150.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,058.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO LbPerHr 3-Hour Rolling Excess Emissions

CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:53 Location: Roseville, CA



Tag Name: CT2_CO_3Hr_LbPerHr_1H
Total Operating Time: 2,208.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 0.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,208.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO Ppmvdc 3-Hour Block Excess Emissions



CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:54 Location: Roseville, CA

Tag Name: CT2_CO_Ppmvdc_3H
Total Operating Time: 2,208.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 0.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,208.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO LbPerHr SUSd 1-Hour Block Excess Emissions



CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:55 Location: Roseville, CA

Tag Name: CT2_CO_SUSD_LbPerHr_1H
Total Operating Time: 2,208.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 0.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,208.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NH3 Slip Ppmvdc 1-Hour Block Excess Emissions



CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:55 Location: Roseville, CA

Tag Name: CT2_NH3Slip_Ppmvdc_1H
Total Operating Time: 2,208.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 0.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,208.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx LbPerHr 1-Hour Block Excess Emissions

CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:56 Location: Roseville, CA



Tag Name: CT2_NOx_Norm_LbPerHr_1H
Total Operating Time: 2,208.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 0.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,208.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx Ppmvdc 1-Hour Block Excess Emissions

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:56 Location: Roseville, CA

Tag Name: CT2_NOx_Ppmvdc_1H
Total Operating Time: 2,208.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 0.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,208.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx LbPerHr SUSd 1-Hour Block Excess Emissions



CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:56 Location: Roseville, CA

Tag Name: CT2_NOx_SUSd_LbPerHr_1H
Total Operating Time: 2,208.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 0.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,208.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

PM10 LbPerHr 1-Hour Block Excess Emissions

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:57 Location: Roseville, CA

Tag Name: CT2_PM10_Norm_LbPerHr_1H
Total Operating Time: 2,208.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 0.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,208.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

S02 LbPerHr 1-Hour Block Excess Emissions

CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:57 Location: Roseville, CA



Tag Name: CT2_S02_Norm_LbPerHr_1H
Total Operating Time: 2,208.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 0.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,208.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

VOC LbPerHr 1-Hour Block Excess Emissions

CT2

From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 10:58 Location: Roseville, CA



Tag Name: CT2_VOC_Norm_LbPerHr_1H
Total Operating Time: 2,208.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 0.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,208.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

AQ-42

AQ-42 The Project owner shall provide the PCAPCD and CPM with a written emission statement showing actual emissions of volatile organic compounds and oxides of nitrogen. Pursuant to PCAPCD Rule 503 the Project owner shall submit this emission statement on a form or in a format specified by the Air Pollution Control Officer. The statement shall contain the following information:

- a) Information contained in the California Air Resources Board's Emission Inventory Turn Around Document as described in Instructions for the Emission Data System Review and Update Report;
- b) Actual emissions of volatile organic compounds and oxides of nitrogen, in tons per year, for the calendar year prior to the preparation of the emission statement;
- c) Information regarding seasonal or diurnal peaks in the emission of affected pollutants; and
- d) Certification by a responsible official of the Project owner that the information contained in the emission statement is accurate to the best knowledge of the individual certifying the emission statement.

Verification: The Project owner shall submit to the CPM the emission statement described herein prior to the beginning of March each year.

12 Month Running Summary Report

AQ42 12 Month Running Summary Report



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:25 Location: Roseville, CA

Date	Units CT1 & CT2		Units CT1 & CT2	
	NOx, Ton		VOC, Ton	
	1 Day(s)		1 Day(s)	
	Sum	Running Sum	Sum	Running Sum
Oct 21	1.4017	1.4017	0.5047	0.5047
Nov 21	1.2922	2.6939	0.4796	0.9843
Dec 21	1.5683	4.2622	0.5749	1.5592
Sum/Avg	4.2622		1.5592	

Roseville Energy Park Quarterly Emissions Summary

for PCAPCD



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 11:05 Location: Roseville, CA

* = Excess Emission

Date	Unit CT1 CO, Ton		Unit CT1 NOX, Ton		Unit CT1 OperatingTime, Hrs		Unit CT2 CO, Ton		Unit CT2 NOX, Ton		Unit CT2 OperatingTime, Hrs	
	1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)	
	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum
Oct 2021	0.1831	1.9281	0.5889	4.4438	598.41	3,930.65	0.3026	3.2444	0.8128	5.6761	744.00	4,576.56
Nov 2021	0.1914	2.1195	0.6306	5.0744	712.38	4,643.03	0.1939	3.1179	0.6608	5.6082	720.00	4,696.49
Dec 2021	0.2551	2.3490	0.7645	5.8304	744.00	5,384.31	0.3138	3.4049	0.8041	6.4010	744.00	5,437.64
Sum/Avg	2.3490		5.8304		5,384.31		3.4049		6.4010		5,437.64	
Limit Value												

AQ-47

AQ-47 No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

In regards to AQ-47 of Roseville Energy Park's 4Q21 QAQR, there were no violations of PCAPCD's Rule 205 for nuisance.

AQ-48

AQ-48 Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited and is in violation of PCAPCD Rule 202, Visible Emissions.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

In regards to AQ-48 of Roseville Energy Park's 4Q21 QAQR, there were no violations of PCAPCD's Rule 202 for opacity.

AQ-51

AQ-51 The ammonia slip shall not exceed 10 ppmv @ 15% O₂ averaged over one hour. The SCR catalyst shall be replaced, repaired or otherwise reconditioned within 24 months of the ammonia slip reaching 7 ppm @ 15% O₂ averaged over 24 hours. The SCR ammonia injection grid replacement, repair or reconditioning scheduled event may be cancelled if the Project owner can demonstrate to the CPM that, subsequent to the initial exceedance, the ammonia slip consistently remains below 7 ppm @ 15% O₂ averaged over 24 hours and that the initial exceedance does not accurately indicate expected future operating conditions.

Compliance with ammonia slip limits shall be demonstrated by using the following calculation procedure:

$$\text{Ammonia slip ppmv @ 15\% O}_2 = ((a - (b \times c / 1,000,000)) \times 1,000,000 / b) \times d,$$

Where

a = ammonia injection rate (lb/hr)/17(lb/lb mol)

b = dry exhaust gas flow rate (lb/hr)/ (29(lb/lb mol)

c = change in measured NOX conc. Ppmv @ 15% O₂ across catalyst, and

d = correction factor

The correction factor shall be derived annually during compliance testing by comparing the measured and calculated ammonia slip.

Verification: The Project owner shall include the ammonia slip concentrations averaged on an hourly and 24 hour basis calculated via the protocol provided as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6. The Project owner shall notify the CPM within 10 days of an exceedance of the 7 ppm ammonia slip limit herein. The Project owner shall notify the CPM no less than 30 days prior to the scheduled date of the SCR catalyst replacement, repair or reconditioning event. If the Project owner finds that the exceedance of the 7 ppm slip limit does not accurately reflect the expected future operations provided for in this condition, the Project owner shall submit all relevant information to the CPM no less than 30 days prior to the scheduled date of the SCR catalyst replacement, repair or reconditioning event in order to cancel the event.

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/01/2021 00:00	1	1.4	9.7	14.5	16.9	689,847.5	0.00	1.00
10/01/2021 01:00	3	1.7	11.9	14.5	23.8	624,158.0	0.00	1.00
10/01/2021 02:00	3	1.7	12.1	14.6	23.9	619,936.2	0.00	1.00
10/01/2021 03:00	2	1.6	11.7	14.5	22.6	625,227.8	0.00	1.00
10/01/2021 04:00	1	1.3	9.1	14.5	20.1	802,825.0	0.00	1.00
10/01/2021 05:00	1	1.7	8.6	14.3	12.9	834,933.9	0.00	1.00
10/01/2021 06:00	3	1.7	11.4	14.4	26.7	698,195.8	0.00	1.00
10/01/2021 07:00	3	1.4	12.1	14.5	27.4	679,362.9	0.00	1.00
10/01/2021 08:00	2	1.6	12.6	14.6	24.1	613,632.5	0.00	1.00
10/01/2021 09:00	3	1.5	13.3	14.7	26.4	610,498.2	0.00	1.00
10/01/2021 10:00	1	1.5	10.1	14.7	16.5	642,966.8	0.00	1.00
10/01/2021 11:00	1	1.6	9.3	14.5	13.9	662,887.0	0.00	1.00
10/01/2021 12:00	1	1.4	8.3	14.5	12.8	797,475.7	0.00	1.00
10/01/2021 13:00	1	1.8	9.1	13.9	17.3	969,161.2	0.00	1.00
10/01/2021 14:00	1	1.7	7.6	14.3	15.5	924,776.4	0.00	1.00
10/01/2021 15:00	2	1.3	8.7	14.5	20.1	772,654.9	0.00	1.00
10/01/2021 16:00	0	1.5	7.7	14.4	12.6	877,695.7	0.00	1.00
10/01/2021 17:00	1	1.6	6.9	14.4	13.6	920,042.5	0.00	1.00
10/01/2021 18:00	1	1.7	6.6	14.4	13.8	874,114.1	0.00	1.00
10/01/2021 19:00	1	1.7	6.9	14.3	12.9	824,352.0	0.00	1.00
10/01/2021 20:00	1	1.7	6.8	14.4	15.7	931,840.6	0.00	1.00
10/01/2021 21:00	1	1.7	7.1	14.3	15.5	891,578.3	0.00	1.00
10/01/2021 22:00	2	1.8	9.6	14.4	19.4	695,035.5	0.00	1.00
10/01/2021 23:00	2	1.6	10.7	14.6	19.6	634,065.2	0.00	1.00
Average/Sum#:	2	1.6	9.5	14.4	18.5	759,052.7	0.00 #	24.00 #
Minimum:	0	1.3	6.6	13.9	12.6	610,498.2	0.00	1.00
Maximum:	3	1.8	13.3	14.7	27.4	969,161.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/02/2021 00:00	1	1.6	8.2	14.4	12.3	757,607.7	0.00	1.00
10/02/2021 01:00	2	1.6	10.0	14.4	18.9	670,175.2	0.00	1.00
10/02/2021 02:00	2	1.6	10.1	14.4	18.4	684,290.8	0.00	1.00
10/02/2021 03:00	2	1.6	10.3	14.4	18.1	664,697.5	0.00	1.00
10/02/2021 04:00	1	1.2	9.9	14.3	19.7	704,631.1	0.00	1.00
10/02/2021 05:00	2	1.5	11.7	14.4	24.5	661,958.7	0.00	1.00
10/02/2021 06:00	1	1.6	7.3	14.3	13.3	909,007.3	0.00	1.00
10/02/2021 07:00	2	1.8	10.0	14.4	22.2	747,073.7	0.00	1.00
10/02/2021 08:00	3	1.6	13.7	14.7	28.4	610,056.5	0.00	1.00
10/02/2021 09:00	3	1.5	13.5	14.8	26.1	618,710.4	0.00	1.00
10/02/2021 10:00	2	1.6	12.7	14.8	24.4	616,914.5	0.00	1.00
10/02/2021 11:00	1	1.6	10.5	14.7	17.1	625,738.6	0.00	1.00
10/02/2021 12:00	1	1.5	9.4	14.7	14.9	640,316.3	0.00	1.00
10/02/2021 13:00	0	1.5	7.7	14.5	9.7	838,986.4	0.00	1.00
10/02/2021 14:00	0	1.5	7.4	14.4	9.2	846,936.3	0.00	1.00
10/02/2021 15:00	1	1.5	8.3	14.5	14.0	780,357.9	0.00	1.00
10/02/2021 16:00	0	1.5	7.2	14.4	9.6	853,467.4	0.00	1.00
10/02/2021 17:00	0	1.7	6.8	14.5	11.7	957,955.2	0.00	1.00
10/02/2021 18:00	1	1.6	6.8	14.5	14.5	967,583.9	0.00	1.00
10/02/2021 19:00	1	1.6	6.8	14.5	15.0	966,728.0	0.00	1.00
10/02/2021 20:00	1	1.7	6.9	14.4	15.6	952,276.6	0.00	1.00
10/02/2021 21:00	1	1.7	6.9	14.4	15.0	916,460.9	0.00	1.00
10/02/2021 22:00	1	1.7	7.1	14.3	15.4	874,564.2	0.00	1.00
10/02/2021 23:00	1	1.7	7.4	14.3	15.4	824,974.4	0.00	1.00
Average/Sum#:	1	1.6	9.0	14.5	16.8	778,811.2	0.00 #	24.00 #
Minimum:	0	1.2	6.8	14.3	9.2	610,056.5	0.00	1.00
Maximum:	3	1.8	13.7	14.8	28.4	967,583.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/03/2021 00:00	2	1.7	9.6	14.4	18.0	701,566.6	0.00	1.00
10/03/2021 01:00	2	1.6	11.4	14.6	20.4	621,892.6	0.00	1.00
10/03/2021 02:00	2	1.6	11.0	14.6	20.0	620,805.7	0.00	1.00
10/03/2021 03:00	2	1.6	11.8	14.6	22.7	624,501.0	0.00	1.00
10/03/2021 04:00	2	1.6	12.9	14.6	24.6	622,544.7	0.00	1.00
10/03/2021 05:00	3	1.6	12.6	14.6	25.0	623,631.5	0.00	1.00
10/03/2021 06:00	3	1.6	12.4	14.5	24.3	624,371.9	0.00	1.00
10/03/2021 07:00	4	1.6	14.1	14.7	30.6	612,486.1	0.00	1.00
10/03/2021 08:00	3	1.5	13.9	14.7	27.4	612,265.2	0.00	1.00
10/03/2021 09:00	3	1.6	13.5	14.7	27.7	607,626.9	0.00	1.00
10/03/2021 10:00	3	1.6	13.5	14.8	26.9	614,894.0	0.00	1.00
10/03/2021 11:00	2	1.5	11.5	14.8	19.6	627,690.3	0.00	1.00
10/03/2021 12:00	1	1.6	9.8	14.7	16.0	631,260.5	0.00	1.00
10/03/2021 13:00	1	1.4	8.8	14.6	14.4	678,191.1	0.00	1.00
10/03/2021 14:00	1	1.5	8.3	14.5	12.6	774,580.7	0.00	1.00
10/03/2021 15:00	0	1.5	7.5	14.5	10.0	851,182.8	0.00	1.00
10/03/2021 16:00	1	1.8	8.6	13.9	16.4	913,210.4	0.00	1.00
10/03/2021 17:00	1	1.8	8.7	14.0	19.2	974,672.9	0.00	1.00
10/03/2021 18:00	1	1.8	8.6	14.0	19.6	964,948.0	0.00	1.00
10/03/2021 19:00	1	1.7	8.6	14.1	20.3	971,687.2	0.00	1.00
10/03/2021 20:00	1	1.8	8.9	14.0	21.4	971,100.5	0.00	1.00
10/03/2021 21:00	1	1.8	9.1	14.0	22.0	976,260.7	0.00	1.00
10/03/2021 22:00	2	1.8	9.0	14.2	19.4	811,026.3	0.00	1.00
10/03/2021 23:00	2	1.6	10.1	14.5	18.4	664,170.8	0.00	1.00
Average/Sum#:	2	1.6	10.6	14.4	20.7	737,357.0	0.00 #	24.00 #
Minimum:	0	1.4	7.5	13.9	10.0	607,626.9	0.00	1.00
Maximum:	4	1.8	14.1	14.8	30.6	976,260.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/04/2021 00:00	2	1.6	10.9	14.5	19.7	626,297.7	0.00	1.00
10/04/2021 01:00	1	1.5	9.5	14.4	16.0	679,445.2	0.00	1.00
10/04/2021 02:00	2	1.6	10.9	14.5	21.1	646,197.1	0.00	1.00
10/04/2021 03:00	0	1.6	7.0	14.4	11.3	927,205.6	0.00	1.00
10/04/2021 04:00	1	1.7	7.6	14.3	16.6	894,068.1	0.00	1.00
10/04/2021 05:00	1	1.7	7.5	14.3	18.3	925,191.4	0.00	1.00
10/04/2021 06:00	1	1.7	7.5	14.3	18.6	932,453.5	0.00	1.00
10/04/2021 07:00	1	1.7	7.4	14.3	17.5	900,500.3	0.00	1.00
10/04/2021 08:00	1	1.7	7.0	14.4	17.2	949,537.8	0.00	1.00
10/04/2021 09:00	1	1.7	7.2	14.3	16.1	853,192.9	0.00	1.00
10/04/2021 10:00	1	1.7	7.0	14.4	16.0	918,567.7	0.00	1.00
10/04/2021 11:00	1	1.7	6.9	14.4	16.0	930,365.9	0.00	1.00
10/04/2021 12:00	1	1.6	6.9	14.5	15.8	968,867.8	0.00	1.00
10/04/2021 13:00	1	1.6	6.8	14.5	15.2	967,797.9	0.00	1.00
10/04/2021 14:00	1	1.6	6.9	14.5	15.2	971,007.5	0.00	1.00
10/04/2021 15:00	1	1.8	7.6	14.2	18.2	938,975.5	0.00	1.00
10/04/2021 16:00	2	2.0	11.9	12.8	29.8	979,392.0	0.00	1.00
10/04/2021 17:00	2	1.9	10.4	13.3	24.8	978,057.3	0.00	1.00
10/04/2021 18:00	2	1.9	9.5	13.5	23.1	966,554.5	0.00	1.00
10/04/2021 19:00	1	1.8	9.0	13.8	21.7	971,905.6	0.00	1.00
10/04/2021 20:00	1	1.8	8.5	14.0	20.0	962,764.9	0.00	1.00
10/04/2021 21:00	1	1.8	8.7	14.0	20.7	969,512.8	0.00	1.00
10/04/2021 22:00	2	1.8	8.9	14.3	18.9	817,504.9	0.00	1.00
10/04/2021 23:00	2	1.6	9.9	14.4	17.6	642,154.7	0.00	1.00
Average/Sum#:	1	1.7	8.4	14.2	18.6	888,229.9	0.00 #	24.00 #
Minimum:	0	1.5	6.8	12.8	11.3	626,297.7	0.00	1.00
Maximum:	2	2.0	11.9	14.5	29.8	979,392.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/05/2021 00:00	2	1.6	10.2	14.5	17.7	635,284.5	0.00	1.00
10/05/2021 01:00	1	1.6	9.7	14.4	16.5	656,481.0	0.00	1.00
10/05/2021 02:00	2	1.5	11.5	14.6	20.2	621,023.1	0.00	1.00
10/05/2021 03:00	2	1.5	10.7	14.5	20.0	628,437.4	0.00	1.00
10/05/2021 04:00	1	1.6	8.6	14.4	13.5	768,773.8	0.00	1.00
10/05/2021 05:00	2	1.5	9.2	14.4	17.0	718,631.8	0.00	1.00
10/05/2021 06:00	1	1.8	7.9	14.3	13.3	747,996.2	0.00	1.00
10/05/2021 07:00	1	1.8	8.2	14.3	17.3	835,141.4	0.00	1.00
10/05/2021 08:00	3	1.6	11.5	14.6	23.1	620,153.6	0.00	1.00
10/05/2021 09:00	2	1.5	10.0	14.6	19.0	649,933.2	0.00	1.00
10/05/2021 10:00	0	1.5	6.8	14.4	10.2	936,475.6	0.00	1.00
10/05/2021 11:00	2	1.7	10.2	14.6	19.6	638,847.3	0.00	1.00
10/05/2021 12:00	2	1.6	10.0	14.7	18.7	632,806.6	0.00	1.00
10/05/2021 13:00	2	1.5	9.4	14.6	17.3	657,323.7	0.00	1.00
10/05/2021 14:00	1	1.5	8.3	14.5	13.5	751,685.6	0.00	1.00
10/05/2021 15:00	1	1.5	8.5	14.5	14.9	766,877.7	0.00	1.00
10/05/2021 16:00	1	1.5	8.0	14.5	13.3	819,300.9	0.00	1.00
10/05/2021 17:00	1	1.7	7.2	14.3	10.3	769,367.5	0.00	1.00
10/05/2021 18:00	1	1.7	7.0	14.4	12.5	841,247.9	0.00	1.00
10/05/2021 19:00	2	1.7	9.0	14.4	16.5	665,961.6	0.00	1.00
10/05/2021 20:00	2	1.6	8.7	14.4	17.1	698,827.8	0.00	1.00
10/05/2021 21:00	0	1.4	6.9	14.3	8.0	789,078.9	0.00	1.00
10/05/2021 22:00	1	1.7	6.9	14.3	14.4	866,057.2	0.00	1.00
10/05/2021 23:00	1	1.7	6.8	14.3	15.3	862,737.4	0.00	1.00
Average/Sum#:	1	1.6	8.8	14.5	15.8	732,435.5	0.00 #	24.00 #
Minimum:	0	1.4	6.8	14.3	8.0	620,153.6	0.00	1.00
Maximum:	3	1.8	11.5	14.7	23.1	936,475.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOX, Ppm	Unit CT1 NOX, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/06/2021 00:00	3	1.8	11.0	14.5	22.8	619,236.6	0.00	1.00
10/06/2021 01:00	2	1.6	10.7	14.5	21.2	617,952.8	0.00	1.00
10/06/2021 02:00	3	1.6	11.6	14.5	23.0	615,813.0	0.00	1.00
10/06/2021 03:00	3	1.6	11.4	14.5	23.6	615,813.0	0.00	1.00
10/06/2021 04:00	3	1.6	11.3	14.5	22.9	617,310.8	0.00	1.00
10/06/2021 05:00	2	1.5	9.6	14.5	18.9	718,305.9	0.00	1.00
10/06/2021 06:00	2	1.9	9.9	14.5	22.5	794,694.1	0.00	1.00
10/06/2021 07:00	3	1.6	12.3	14.6	26.5	636,021.5	0.00	1.00
10/06/2021 08:00	2	1.4	11.0	14.6	22.2	722,534.4	0.00	1.00
10/06/2021 09:00	0	1.6	6.8	14.4	10.8	920,042.5	0.00	1.00
10/06/2021 10:00	1	1.7	7.0	14.4	13.9	795,530.2	0.00	1.00
10/06/2021 11:00	1	1.6	7.2	14.4	17.1	954,172.8	0.00	1.00
10/06/2021 12:00	1	1.7	6.8	14.4	16.1	958,597.1	0.00	1.00
10/06/2021 13:00	1	1.6	7.1	14.3	14.1	829,124.2	0.00	1.00
10/06/2021 14:00	1	1.7	7.4	14.4	17.8	962,178.6	0.00	1.00
10/06/2021 15:00	1	1.6	8.0	14.4	15.4	800,165.2	0.00	1.00
10/06/2021 16:00	1	1.7	7.4	14.4	14.7	866,740.3	0.00	1.00
10/06/2021 17:00	2	1.7	10.6	14.5	21.7	652,830.3	0.00	1.00
10/06/2021 18:00	1	1.7	9.0	14.3	16.0	683,052.3	0.00	1.00
10/06/2021 19:00	2	1.6	10.0	14.5	19.6	686,637.9	0.00	1.00
10/06/2021 20:00	0	1.5	6.9	14.3	10.9	861,699.9	0.00	1.00
10/06/2021 21:00	1	1.7	7.2	14.4	17.5	960,703.9	0.00	1.00
10/06/2021 22:00	2	1.8	9.4	14.4	21.7	785,206.9	0.00	1.00
10/06/2021 23:00	3	1.6	11.9	14.6	24.1	625,805.2	0.00	1.00
Average/Sum#:	2	1.6	9.2	14.5	19.0	762,507.1	0.00 #	24.00 #
Minimum:	0	1.4	6.8	14.3	10.8	615,813.0	0.00	1.00
Maximum:	3	1.9	12.3	14.6	26.5	962,178.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/07/2021 00:00	3	1.6	12.0	14.6	24.4	624,935.7	0.00	1.00
10/07/2021 01:00	3	1.6	12.0	14.6	24.4	625,153.1	0.00	1.00
10/07/2021 02:00	2	1.6	12.3	14.6	24.5	624,935.7	0.00	1.00
10/07/2021 03:00	1	1.4	9.1	14.4	18.0	758,239.7	0.00	1.00
10/07/2021 04:00	1	1.7	8.0	14.3	15.3	825,389.4	0.00	1.00
10/07/2021 05:00	1	1.7	7.3	14.3	17.3	912,949.6	0.00	1.00
10/07/2021 06:00	1	1.7	7.4	14.4	19.1	978,611.7	0.00	1.00
10/07/2021 07:00	1	1.7	7.4	14.4	18.9	955,015.5	0.00	1.00
10/07/2021 08:00	1	1.7	7.6	14.3	17.1	846,968.2	0.00	1.00
10/07/2021 09:00	1	1.7	7.4	14.4	18.3	959,018.4	0.00	1.00
10/07/2021 10:00	2	1.8	10.2	14.5	23.3	741,842.9	0.00	1.00
10/07/2021 11:00	1	1.5	9.6	14.5	15.4	675,083.4	0.00	1.00
10/07/2021 12:00	2	1.6	11.1	14.6	22.3	623,414.1	0.00	1.00
10/07/2021 13:00	2	1.6	11.2	14.7	21.8	631,039.6	0.00	1.00
10/07/2021 14:00	2	1.6	12.1	14.7	23.9	620,216.7	0.00	1.00
10/07/2021 15:00	2	1.5	11.7	14.7	23.3	633,690.1	0.00	1.00
10/07/2021 16:00	2	1.5	10.2	14.6	18.8	751,009.7	0.00	1.00
10/07/2021 17:00	0	1.7	7.4	14.4	13.5	955,647.5	0.00	1.00
10/07/2021 18:00	2	1.8	9.9	14.4	21.4	735,064.9	0.00	1.00
10/07/2021 19:00	2	1.6	11.4	14.6	22.2	629,283.1	0.00	1.00
10/07/2021 20:00	2	1.6	10.8	14.5	21.6	640,633.8	0.00	1.00
10/07/2021 21:00	2	1.6	11.5	14.6	23.1	628,196.3	0.00	1.00
10/07/2021 22:00	2	1.6	11.1	14.5	22.4	628,865.4	0.00	1.00
10/07/2021 23:00	1	1.7	8.0	14.3	12.5	759,615.6	0.00	1.00
Average/Sum#:	2	1.6	9.9	14.5	20.1	740,200.8	0.00 #	24.00 #
Minimum:	0	1.4	7.3	14.3	12.5	620,216.7	0.00	1.00
Maximum:	3	1.8	12.3	14.7	24.5	978,611.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/08/2021 00:00	3	1.7	12.0	14.5	26.6	617,738.8	0.00	1.00
10/08/2021 01:00	3	1.6	12.0	14.5	25.2	616,668.9	0.00	1.00
10/08/2021 02:00	3	1.6	12.6	14.5	25.4	614,957.1	0.00	1.00
10/08/2021 03:00	3	1.7	12.0	14.5	25.1	623,516.0	0.00	1.00
10/08/2021 04:00	2	1.6	11.6	14.5	22.6	651,974.4	0.00	1.00
10/08/2021 05:00	4	1.8	14.0	14.7	31.5	618,008.0	0.00	1.00
10/08/2021 06:00	3	1.6	11.4	14.5	24.3	646,625.1	0.00	1.00
10/08/2021 07:00	1	1.6	7.5	14.4	14.3	977,979.7	0.00	1.00
10/08/2021 08:00	2	1.7	8.7	14.3	18.1	738,451.7	0.00	1.00
10/08/2021 09:00	1	1.7	7.5	14.4	17.0	963,442.7	0.00	1.00
10/08/2021 10:00	3	1.8	11.4	14.5	24.8	638,708.1	0.00	1.00
10/08/2021 11:00	1	1.4	7.3	14.3	11.6	827,049.3	0.00	1.00
10/08/2021 12:00	1	1.7	7.2	14.3	14.6	803,603.1	0.00	1.00
10/08/2021 13:00	1	1.7	7.1	14.3	15.2	830,161.7	0.00	1.00
10/08/2021 14:00	1	1.7	7.4	14.4	17.9	961,757.3	0.00	1.00
10/08/2021 15:00	3	1.8	12.1	14.6	25.2	628,196.3	0.00	1.00
10/08/2021 16:00	2	1.4	10.6	14.6	20.7	737,315.5	0.00	1.00
10/08/2021 17:00	3	1.8	12.3	14.6	25.1	630,152.6	0.00	1.00
10/08/2021 18:00	3	1.6	12.7	14.6	27.0	620,153.6	0.00	1.00
10/08/2021 19:00	3	1.6	13.2	14.7	28.8	624,192.5	0.00	1.00
10/08/2021 20:00	3	1.6	12.6	14.6	25.8	619,066.8	0.00	1.00
10/08/2021 21:00	2	1.6	11.9	14.6	23.6	624,283.6	0.00	1.00
10/08/2021 22:00	3	1.6	11.8	14.5	24.5	625,869.7	0.00	1.00
10/08/2021 23:00	3	1.7	13.2	14.7	28.9	626,843.0	0.00	1.00
Average/Sum#:	2	1.7	10.8	14.5	22.7	702,779.8	0.00 #	24.00 #
Minimum:	1	1.4	7.1	14.3	11.6	614,957.1	0.00	1.00
Maximum:	4	1.8	14.0	14.7	31.5	977,979.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/09/2021 00:00	4	1.7	13.9	14.7	31.4	620,216.7	0.00	1.00
10/09/2021 01:00	4	1.5	15.4	14.8	36.7	617,812.4	0.00	1.00
10/09/2021 02:00	4	1.5	15.9	14.8	35.9	620,506.4	0.00	1.00
10/09/2021 03:00	5	1.6	16.0	14.8	38.9	618,710.4	0.00	1.00
10/09/2021 04:00	3	1.6	13.3	14.6	27.8	629,065.7	0.00	1.00
10/09/2021 05:00	2	1.5	10.2	14.4	19.8	724,320.2	0.00	1.00
10/09/2021 06:00	3	1.7	10.5	14.4	24.0	719,263.8	0.00	1.00
10/09/2021 07:00	2	1.7	7.9	14.3	18.3	829,746.7	0.00	1.00
10/09/2021 08:00	2	1.8	10.4	14.4	22.8	687,451.0	0.00	1.00
10/09/2021 09:00	4	1.7	14.3	14.7	34.4	619,775.0	0.00	1.00
10/09/2021 10:00	4	1.5	14.6	14.8	32.6	621,179.9	0.00	1.00
10/09/2021 11:00	3	1.6	14.2	14.8	30.6	620,955.4	0.00	1.00
10/09/2021 12:00	3	1.6	13.9	14.7	29.7	610,940.0	0.00	1.00
10/09/2021 13:00	3	1.6	13.8	14.7	29.2	610,498.2	0.00	1.00
10/09/2021 14:00	3	1.6	13.6	14.8	28.3	620,281.9	0.00	1.00
10/09/2021 15:00	2	1.5	12.3	14.7	24.0	630,597.8	0.00	1.00
10/09/2021 16:00	1	1.5	9.9	14.6	17.9	770,355.6	0.00	1.00
10/09/2021 17:00	1	1.7	7.8	14.5	13.9	902,536.3	0.00	1.00
10/09/2021 18:00	2	1.7	10.7	14.6	22.2	672,539.5	0.00	1.00
10/09/2021 19:00	3	1.6	11.9	14.7	25.2	629,714.3	0.00	1.00
10/09/2021 20:00	3	1.6	13.5	14.7	28.8	618,449.7	0.00	1.00
10/09/2021 21:00	3	1.6	12.3	14.6	25.0	622,544.7	0.00	1.00
10/09/2021 22:00	3	1.6	12.8	14.6	27.4	620,371.0	0.00	1.00
10/09/2021 23:00	3	1.6	12.3	14.6	24.7	626,457.3	0.00	1.00
Average/Sum#:	3	1.6	12.6	14.6	27.1	661,012.1	0.00 #	24.00 #
Minimum:	1	1.5	7.8	14.3	13.9	610,498.2	0.00	1.00
Maximum:	5	1.8	16.0	14.8	38.9	902,536.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/10/2021 00:00	3	1.6	12.2	14.6	25.3	627,326.8	0.00	1.00
10/10/2021 01:00	3	1.7	12.6	14.6	26.7	624,501.0	0.00	1.00
10/10/2021 02:00	2	1.7	11.9	14.6	22.6	638,412.6	0.00	1.00
10/10/2021 03:00	3	1.6	12.2	14.5	25.8	622,232.2	0.00	1.00
10/10/2021 04:00	3	1.6	12.6	14.5	27.3	622,660.1	0.00	1.00
10/10/2021 05:00	2	1.5	9.1	14.4	18.3	772,776.7	0.00	1.00
10/10/2021 06:00	2	1.8	8.8	14.4	19.6	822,286.7	0.00	1.00
10/10/2021 07:00	2	1.8	8.9	14.3	19.7	745,298.8	0.00	1.00
10/10/2021 08:00	4	1.7	12.8	14.7	29.5	629,051.7	0.00	1.00
10/10/2021 09:00	4	1.5	14.3	14.8	32.0	621,404.4	0.00	1.00
10/10/2021 10:00	3	1.5	12.9	14.7	26.1	619,995.8	0.00	1.00
10/10/2021 11:00	3	1.6	13.3	14.7	28.6	613,148.7	0.00	1.00
10/10/2021 12:00	3	1.6	13.2	14.7	27.2	612,927.8	0.00	1.00
10/10/2021 13:00	3	1.6	12.7	14.8	25.4	624,996.3	0.00	1.00
10/10/2021 14:00	3	1.5	12.4	14.8	25.4	631,506.7	0.00	1.00
10/10/2021 15:00	1	1.5	10.3	14.6	17.5	659,497.4	0.00	1.00
10/10/2021 16:00	1	1.5	9.6	14.5	17.7	778,432.2	0.00	1.00
10/10/2021 17:00	2	1.7	10.3	14.6	18.1	655,150.0	0.00	1.00
10/10/2021 18:00	3	1.6	12.0	14.7	24.8	617,787.1	0.00	1.00
10/10/2021 19:00	1	1.6	9.7	14.6	17.0	661,236.3	0.00	1.00
10/10/2021 20:00	1	1.7	9.4	14.5	17.5	763,240.1	0.00	1.00
10/10/2021 21:00	2	1.6	11.3	14.6	22.2	621,675.2	0.00	1.00
10/10/2021 22:00	3	1.6	12.4	14.7	25.7	619,333.2	0.00	1.00
10/10/2021 23:00	3	1.6	13.6	14.7	29.7	612,265.2	0.00	1.00
Average/Sum#:	3	1.6	11.6	14.6	23.7	659,047.6	0.00 #	24.00 #
Minimum:	1	1.5	8.8	14.3	17.0	612,265.2	0.00	1.00
Maximum:	4	1.8	14.3	14.8	32.0	822,286.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/11/2021 00:00	3	1.5	12.5	14.6	24.8	632,978.4	0.00	1.00
10/11/2021 01:00	4	1.7	15.1	14.8	36.0	620,730.9	0.00	1.00
10/11/2021 02:00	2	1.6	13.2	14.7	27.5	627,063.8	0.00	1.00
10/11/2021 03:00	3	1.6	12.8	14.6	28.7	629,283.1	0.00	1.00
10/11/2021 04:00	1	1.6	7.7	14.3	12.6	842,611.0	0.00	1.00
10/11/2021 05:00	1	1.7	7.9	14.3	17.3	835,971.3	0.00	1.00
10/11/2021 06:00	1	1.7	7.8	14.3	19.1	901,952.7	0.00	1.00
10/11/2021 07:00	1	1.7	7.8	14.4	20.2	963,442.7	0.00	1.00
10/11/2021 08:00	3	2.0	12.0	13.1	34.7	984,229.9	0.00	1.00
10/11/2021 09:00	2	1.9	10.4	13.5	28.8	991,167.2	0.00	1.00
10/11/2021 10:00	2	2.0	11.9	13.0	32.8	1,016,667.6	0.00	1.00
10/11/2021 11:00	2	1.7	8.9	14.1	24.1	999,075.6	0.00	1.00
10/11/2021 12:00	2	1.9	10.0	13.6	27.3	1,003,806.8	0.00	1.00
10/11/2021 13:00	2	1.8	10.2	13.6	27.6	1,012,998.9	0.00	1.00
10/11/2021 14:00	2	1.8	9.8	13.7	25.9	1,000,821.0	0.00	1.00
10/11/2021 15:00	1	1.7	8.4	14.3	18.5	871,866.9	0.00	1.00
10/11/2021 16:00	1	1.7	7.5	14.4	18.1	942,374.7	0.00	1.00
10/11/2021 17:00	1	1.7	7.5	14.3	18.4	916,891.9	0.00	1.00
10/11/2021 18:00	3	1.8	10.9	14.4	25.2	724,320.2	0.00	1.00
10/11/2021 19:00	3	1.6	12.1	14.5	25.2	652,616.3	0.00	1.00
10/11/2021 20:00	2	1.8	9.3	14.4	19.1	829,871.2	0.00	1.00
10/11/2021 21:00	2	1.8	10.4	14.4	22.7	718,631.8	0.00	1.00
10/11/2021 22:00	3	1.8	12.3	14.6	26.6	672,756.9	0.00	1.00
10/11/2021 23:00	3	1.7	12.3	14.5	27.2	652,402.3	0.00	1.00
Average/Sum#:	2	1.7	10.4	14.2	24.5	835,188.9	0.00 #	24.00 #
Minimum:	1	1.5	7.5	13.0	12.6	620,730.9	0.00	1.00
Maximum:	4	2.0	15.1	14.8	36.0	1,016,667.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/12/2021 00:00	3	1.6	13.4	14.6	30.2	632,108.9	0.00	1.00
10/12/2021 01:00	4	1.7	14.8	14.7	35.0	631,481.3	0.00	1.00
10/12/2021 02:00	5	1.8	17.0	14.7	36.2	623,750.7	0.00	1.00
10/12/2021 03:00	3	1.5	15.8	14.7	36.8	624,634.2	0.00	1.00
10/12/2021 04:00	4	1.7	16.0	14.8	37.8	635,772.1	0.00	1.00
10/12/2021 05:00	2	1.6	9.8	14.4	20.3	806,696.3	0.00	1.00
10/12/2021 06:00	1	1.7	8.1	14.4	22.1	987,039.0	0.00	1.00
10/12/2021 07:00	2	1.7	8.1	14.4	23.4	972,502.0	0.00	1.00
10/12/2021 08:00	2	1.6	8.2	14.4	23.6	980,086.5	0.00	1.00
10/12/2021 09:00	1	1.6	8.2	14.5	22.9	996,256.2	0.00	1.00
10/12/2021 10:00	1	1.6	8.3	14.5	22.9	997,968.0	0.00	1.00
10/12/2021 11:00	1	1.6	8.6	14.5	23.8	997,326.1	0.00	1.00
10/12/2021 12:00	1	1.6	8.5	14.5	23.0	973,789.1	0.00	1.00
10/12/2021 13:00	2	1.6	8.8	14.4	18.5	731,272.6	0.00	1.00
10/12/2021 14:00	1	1.7	8.6	14.5	22.8	986,199.5	0.00	1.00
10/12/2021 15:00	1	1.6	8.6	14.5	22.9	983,417.9	0.00	1.00
10/12/2021 16:00	1	1.6	7.7	14.5	18.8	925,645.3	0.00	1.00
10/12/2021 17:00	1	1.6	7.8	14.5	20.7	967,583.9	0.00	1.00
10/12/2021 18:00	1	1.6	7.9	14.5	21.5	978,068.6	0.00	1.00
10/12/2021 19:00	1	1.6	7.7	14.4	18.9	869,479.1	0.00	1.00
10/12/2021 20:00	2	1.7	8.0	14.4	20.3	897,499.7	0.00	1.00
10/12/2021 21:00	1	1.6	7.7	14.5	20.4	955,815.4	0.00	1.00
10/12/2021 22:00	2	1.7	7.9	14.4	22.7	964,706.8	0.00	1.00
10/12/2021 23:00	2	1.6	8.8	14.4	21.2	821,654.6	0.00	1.00
Average/Sum#:	2	1.6	9.8	14.5	24.4	872,531.4	0.00 #	24.00 #
Minimum:	1	1.5	7.7	14.4	18.5	623,750.7	0.00	1.00
Maximum:	5	1.8	17.0	14.8	37.8	997,968.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/13/2021 00:00	1	1.7	8.1	14.5	22.6	990,693.0	0.00	1.00
10/13/2021 01:00	3	1.7	11.6	14.5	26.6	672,943.7	0.00	1.00
10/13/2021 02:00	3	1.6	13.6	14.6	28.1	631,891.5	0.00	1.00
10/13/2021 03:00	2	1.5	10.5	14.5	22.1	756,179.0	0.00	1.00
10/13/2021 04:00	1	1.7	8.2	14.5	20.5	990,479.0	0.00	1.00
10/13/2021 05:00	1	1.7	8.1	14.4	20.9	923,202.7	0.00	1.00
10/13/2021 06:00	1	1.7	8.0	14.4	20.4	902,766.7	0.00	1.00
10/13/2021 07:00	1	1.6	7.9	14.5	21.9	991,120.9	0.00	1.00
10/13/2021 08:00	1	1.6	8.0	14.5	21.6	992,832.7	0.00	1.00
10/13/2021 09:00	1	1.6	8.1	14.5	21.4	994,116.5	0.00	1.00
10/13/2021 10:00	1	1.6	8.5	14.5	22.9	989,409.1	0.00	1.00
10/13/2021 11:00	1	1.6	8.7	14.5	23.1	993,046.7	0.00	1.00
10/13/2021 12:00	1	1.6	8.8	14.5	23.6	991,120.9	0.00	1.00
10/13/2021 13:00	1	1.6	7.7	14.4	18.2	977,769.0	0.00	1.00
10/13/2021 14:00	1	1.7	7.5	14.4	18.4	958,807.7	0.00	1.00
10/13/2021 15:00	1	1.7	7.6	14.3	16.2	848,628.1	0.00	1.00
10/13/2021 16:00	2	1.6	11.1	14.6	22.4	748,836.0	0.00	1.00
10/13/2021 17:00	1	1.7	7.4	14.4	16.5	964,706.8	0.00	1.00
10/13/2021 18:00	1	1.7	7.5	14.3	17.4	870,621.9	0.00	1.00
10/13/2021 19:00	2	1.8	8.5	14.3	19.6	816,259.9	0.00	1.00
10/13/2021 20:00	1	1.7	7.7	14.3	17.9	893,238.2	0.00	1.00
10/13/2021 21:00	2	1.7	8.1	14.3	20.5	871,659.4	0.00	1.00
10/13/2021 22:00	1	1.7	8.1	14.4	19.9	919,621.1	0.00	1.00
10/13/2021 23:00	5	1.8	15.4	14.7	38.6	621,983.7	0.00	1.00
Average/Sum#:	2	1.7	8.9	14.5	21.7	887,997.3	0.00 #	24.00 #
Minimum:	1	1.5	7.4	14.3	16.2	621,983.7	0.00	1.00
Maximum:	5	1.8	15.4	14.7	38.6	994,116.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOX, Ppm	Unit CT1 NOX, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/14/2021 00:00	4	1.6	13.6	14.6	29.1	626,239.9	0.00	1.00
10/14/2021 01:00	4	1.7	14.8	14.7	33.4	628,830.8	0.00	1.00
10/14/2021 02:00	4	1.8	14.7	14.6	29.6	628,196.3	0.00	1.00
10/14/2021 03:00	4	1.6	14.0	14.6	32.9	629,500.5	0.00	1.00
10/14/2021 04:00	4	1.8	14.7	14.6	33.1	624,283.6	0.00	1.00
10/14/2021 05:00	1	1.6	8.4	14.4	18.3	904,030.8	0.00	1.00
10/14/2021 06:00	2	1.7	7.9	14.4	22.5	977,347.6	0.00	1.00
10/14/2021 07:00	3	1.8	10.6	14.4	25.4	727,059.0	0.00	1.00
10/14/2021 08:00	5	1.8	14.1	14.6	33.4	623,196.8	0.00	1.00
10/14/2021 09:00	3	1.6	13.2	14.6	27.5	623,196.8	0.00	1.00
10/14/2021 10:00	4	1.6	14.4	14.7	32.9	616,241.0	0.00	1.00
10/14/2021 11:00	3	1.5	13.5	14.7	27.4	619,333.2	0.00	1.00
10/14/2021 12:00	3	1.6	12.5	14.7	25.6	620,658.5	0.00	1.00
10/14/2021 13:00	2	1.6	10.8	14.7	19.7	637,224.1	0.00	1.00
10/14/2021 14:00	2	1.6	10.7	14.7	20.5	641,199.8	0.00	1.00
10/14/2021 15:00	2	1.6	10.0	14.6	17.6	670,148.5	0.00	1.00
10/14/2021 16:00	2	1.6	9.2	14.6	18.9	805,134.6	0.00	1.00
10/14/2021 17:00	1	1.6	7.9	14.5	18.3	979,138.4	0.00	1.00
10/14/2021 18:00	1	1.7	7.4	14.3	16.4	896,973.0	0.00	1.00
10/14/2021 19:00	1	1.7	7.3	14.4	18.5	981,982.6	0.00	1.00
10/14/2021 20:00	2	1.7	7.7	14.4	20.5	978,401.1	0.00	1.00
10/14/2021 21:00	0	7.4	19.5	15.1	0.7	650,004.4	0.23	0.23
10/14/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/14/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	3	1.9	11.7	14.6	23.7	731,287.3	0.23 #	21.23 #
Minimum:	1	1.5	7.3	14.3	0.7	616,241.0	0.00	0.00
Maximum:	5	7.4	19.5	15.1	33.4	981,982.6	0.23	1.00
%SI	12.50	8.33	8.33	8.33	8.33	8.33	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/15/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/15/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/16/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/16/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/17/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/17/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/18/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/18/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/19/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2021 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/19/2021 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/20/2021 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2021 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2021 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2021 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2021 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2021 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2021 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2021 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2021 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2021 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2021 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2021 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2021 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2021 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2021 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2021 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
10/20/2021 22:00	0	8.3	13.7	19.2	0.0	785,405.2	0.18	0.18
10/20/2021 23:00	4	9.2	14.5	14.5	9.5	657,965.6	0.88	1.00
Average/Sum#:	4	8.8	14.1	16.9	4.8	721,685.4	1.06 #	1.18 #
Minimum:	4	8.3	13.7	14.5	0.0	657,965.6	0.00	0.00
Maximum:	4	9.2	14.5	19.2	9.5	785,405.2	0.88	1.00
%SI	95.83	91.67	91.67	91.67	91.67	91.67	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/21/2021 00:00	3	1.6	10.9	14.5	22.5	629,507.3	0.00	1.00
10/21/2021 01:00	3	1.6	11.6	14.5	24.0	622,018.2	0.00	1.00
10/21/2021 02:00	3	1.6	12.0	14.5	25.1	622,874.1	0.00	1.00
10/21/2021 03:00	2	1.5	9.3	14.4	17.1	730,008.5	0.00	1.00
10/21/2021 04:00	2	1.7	8.1	14.4	17.1	768,773.8	0.00	1.00
10/21/2021 05:00	2	1.7	8.0	14.4	19.7	877,695.7	0.00	1.00
10/21/2021 06:00	2	1.7	7.8	14.3	19.5	874,979.2	0.00	1.00
10/21/2021 07:00	2	1.7	7.3	14.3	18.6	853,607.9	0.00	1.00
10/21/2021 08:00	2	1.7	7.6	14.4	21.2	942,374.7	0.00	1.00
10/21/2021 09:00	2	1.7	7.8	14.4	22.4	993,570.1	0.00	1.00
10/21/2021 10:00	2	1.6	7.7	14.4	21.6	987,881.7	0.00	1.00
10/21/2021 11:00	2	1.7	7.2	14.3	17.4	857,135.2	0.00	1.00
10/21/2021 12:00	1	1.5	9.1	14.5	16.4	633,786.7	0.00	1.00
10/21/2021 13:00	1	1.6	7.0	14.5	13.7	914,946.7	0.00	1.00
10/21/2021 14:00	1	1.6	7.3	14.4	14.4	835,770.2	0.00	1.00
10/21/2021 15:00	2	1.5	9.0	14.6	16.9	722,317.0	0.00	1.00
10/21/2021 16:00	1	1.6	7.0	14.4	13.1	921,728.0	0.00	1.00
10/21/2021 17:00	1	1.7	7.4	14.4	17.7	981,771.9	0.00	1.00
10/21/2021 18:00	1	1.7	7.1	14.4	17.7	975,662.2	0.00	1.00
10/21/2021 19:00	2	1.7	7.4	14.4	19.9	983,246.7	0.00	1.00
10/21/2021 20:00	1	1.7	7.0	14.4	18.6	971,448.6	0.00	1.00
10/21/2021 21:00	2	1.7	6.7	14.3	17.2	869,792.0	0.00	1.00
10/21/2021 22:00	3	1.8	9.7	14.4	21.0	634,570.2	0.00	1.00
10/21/2021 23:00	4	1.6	12.6	14.6	28.1	602,112.0	0.00	1.00
Average/Sum#:	2	1.6	8.4	14.4	19.2	825,315.8	0.00 #	24.00 #
Minimum:	1	1.5	6.7	14.3	13.1	602,112.0	0.00	1.00
Maximum:	4	1.8	12.6	14.6	28.1	993,570.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/22/2021 00:00	4	1.6	12.6	14.6	27.2	601,459.9	0.00	1.00
10/22/2021 01:00	4	1.6	12.6	14.6	27.2	601,894.6	0.00	1.00
10/22/2021 02:00	4	1.5	12.9	14.6	27.6	601,894.6	0.00	1.00
10/22/2021 03:00	3	1.6	10.7	14.5	20.4	614,743.2	0.00	1.00
10/22/2021 04:00	3	1.6	10.3	14.5	20.5	618,380.7	0.00	1.00
10/22/2021 05:00	3	1.6	10.9	14.6	21.5	622,762.0	0.00	1.00
10/22/2021 06:00	6	1.8	11.4	14.7	26.0	631,260.5	0.00	1.00
10/22/2021 07:00	0	1.3	7.7	14.3	10.7	745,091.4	0.00	1.00
10/22/2021 08:00	2	1.7	7.1	14.4	18.2	958,386.4	0.00	1.00
10/22/2021 09:00	2	1.7	7.0	14.3	20.6	934,320.9	0.00	1.00
10/22/2021 10:00	2	1.7	7.2	14.4	20.0	985,985.6	0.00	1.00
10/22/2021 11:00	2	1.7	7.2	14.4	19.5	972,080.6	0.00	1.00
10/22/2021 12:00	2	1.7	8.3	14.3	17.4	701,518.8	0.00	1.00
10/22/2021 13:00	2	1.7	8.7	14.3	17.2	673,092.8	0.00	1.00
10/22/2021 14:00	2	1.7	8.8	14.3	17.1	672,055.4	0.00	1.00
10/22/2021 15:00	2	1.7	8.8	14.3	17.1	672,055.4	0.00	1.00
10/22/2021 16:00	2	1.6	8.3	14.3	16.9	745,298.8	0.00	1.00
10/22/2021 17:00	2	1.8	8.2	14.4	19.3	859,366.5	0.00	1.00
10/22/2021 18:00	4	1.6	13.2	14.7	30.7	619,333.2	0.00	1.00
10/22/2021 19:00	3	1.6	11.0	14.5	21.9	634,642.6	0.00	1.00
10/22/2021 20:00	3	1.6	11.2	14.5	23.7	621,804.3	0.00	1.00
10/22/2021 21:00	4	1.7	12.1	14.6	27.3	618,632.0	0.00	1.00
10/22/2021 22:00	4	1.7	12.3	14.6	26.5	618,632.0	0.00	1.00
10/22/2021 23:00	2	1.5	10.3	14.4	20.4	664,065.5	0.00	1.00
Average/Sum#:	3	1.6	10.0	14.5	21.5	707,864.9	0.00 #	24.00 #
Minimum:	0	1.3	7.0	14.3	10.7	601,459.9	0.00	1.00
Maximum:	6	1.8	13.2	14.7	30.7	985,985.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/23/2021 00:00	3	1.9	10.0	14.4	21.3	674,388.8	0.00	1.00
10/23/2021 01:00	5	1.7	14.2	14.7	33.8	613,369.6	0.00	1.00
10/23/2021 02:00	3	1.4	12.7	14.5	25.3	614,743.2	0.00	1.00
10/23/2021 03:00	3	1.7	11.8	14.5	25.2	617,524.8	0.00	1.00
10/23/2021 04:00	3	1.7	11.7	14.5	25.3	623,088.1	0.00	1.00
10/23/2021 05:00	2	1.6	9.6	14.4	20.2	729,165.8	0.00	1.00
10/23/2021 06:00	2	1.7	8.2	14.3	19.2	789,701.4	0.00	1.00
10/23/2021 07:00	3	1.9	9.3	14.4	22.4	748,337.8	0.00	1.00
10/23/2021 08:00	2	1.6	7.1	14.4	18.4	930,365.9	0.00	1.00
10/23/2021 09:00	2	1.8	7.5	14.3	18.8	806,508.0	0.00	1.00
10/23/2021 10:00	3	1.7	10.0	14.4	23.0	665,329.6	0.00	1.00
10/23/2021 11:00	2	1.7	10.1	14.4	19.7	663,644.1	0.00	1.00
10/23/2021 12:00	1	1.6	7.5	14.4	17.7	967,235.0	0.00	1.00
10/23/2021 13:00	2	1.8	8.1	14.3	19.5	756,710.7	0.00	1.00
10/23/2021 14:00	2	1.7	7.4	14.4	21.1	983,878.7	0.00	1.00
10/23/2021 15:00	2	1.7	7.2	14.4	20.8	956,490.3	0.00	1.00
10/23/2021 16:00	2	1.7	7.3	14.4	21.4	983,878.7	0.00	1.00
10/23/2021 17:00	2	1.7	7.3	14.4	21.4	978,401.1	0.00	1.00
10/23/2021 18:00	4	1.9	11.3	14.5	25.4	635,284.5	0.00	1.00
10/23/2021 19:00	3	1.7	9.8	14.4	21.5	649,739.2	0.00	1.00
10/23/2021 20:00	3	1.6	10.8	14.5	23.7	622,446.2	0.00	1.00
10/23/2021 21:00	3	1.6	10.4	14.5	22.8	623,516.0	0.00	1.00
10/23/2021 22:00	3	1.6	9.8	14.4	22.3	648,685.8	0.00	1.00
10/23/2021 23:00	1	1.6	7.4	14.4	18.3	950,801.9	0.00	1.00
Average/Sum#:	3	1.7	9.4	14.4	22.0	759,718.1	0.00 #	24.00 #
Minimum:	1	1.4	7.1	14.3	17.7	613,369.6	0.00	1.00
Maximum:	5	1.9	14.2	14.7	33.8	983,878.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOX, Ppm	Unit CT1 NOX, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/24/2021 00:00	2	1.8	7.5	14.2	18.5	801,215.5	0.00	1.00
10/24/2021 01:00	5	1.8	12.5	14.6	29.7	612,111.0	0.00	1.00
10/24/2021 02:00	4	1.5	14.0	14.6	31.2	607,981.0	0.00	1.00
10/24/2021 03:00	5	1.7	13.3	14.6	29.9	608,415.7	0.00	1.00
10/24/2021 04:00	5	1.6	13.8	14.6	31.6	600,373.0	0.00	1.00
10/24/2021 05:00	3	1.6	12.0	14.5	25.1	610,891.7	0.00	1.00
10/24/2021 06:00	4	1.7	12.1	14.5	27.4	608,751.9	0.00	1.00
10/24/2021 07:00	2	1.5	8.7	14.4	18.4	830,924.6	0.00	1.00
10/24/2021 08:00	2	1.7	7.9	14.4	21.4	979,033.1	0.00	1.00
10/24/2021 09:00	2	1.7	7.9	14.4	22.3	981,771.9	0.00	1.00
10/24/2021 10:00	2	1.7	7.5	14.3	21.4	944,072.9	0.00	1.00
10/24/2021 11:00	2	1.7	7.9	14.3	23.3	968,141.5	0.00	1.00
10/24/2021 12:00	2	1.7	7.5	14.3	21.7	943,865.4	0.00	1.00
10/24/2021 13:00	2	1.7	7.8	14.3	22.7	964,199.3	0.00	1.00
10/24/2021 14:00	2	1.7	8.6	14.4	20.3	764,560.2	0.00	1.00
10/24/2021 15:00	2	1.7	7.4	14.3	19.6	879,958.9	0.00	1.00
10/24/2021 16:00	2	1.7	7.6	14.3	19.1	828,709.2	0.00	1.00
10/24/2021 17:00	2	1.7	7.4	14.3	20.3	928,511.2	0.00	1.00
10/24/2021 18:00	3	1.8	8.2	14.3	20.6	738,036.7	0.00	1.00
10/24/2021 19:00	2	1.7	7.9	14.3	19.0	827,256.8	0.00	1.00
10/24/2021 20:00	3	1.7	9.2	14.3	20.9	645,081.9	0.00	1.00
10/24/2021 21:00	3	1.7	8.5	14.3	19.1	671,640.4	0.00	1.00
10/24/2021 22:00	3	1.7	10.1	14.4	22.8	622,982.8	0.00	1.00
10/24/2021 23:00	3	1.6	10.2	14.4	21.7	617,715.7	0.00	1.00
Average/Sum#:	3	1.7	9.4	14.4	22.8	774,425.1	0.00 #	24.00 #
Minimum:	2	1.5	7.4	14.2	18.4	600,373.0	0.00	1.00
Maximum:	5	1.8	14.0	14.6	31.6	981,771.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/25/2021 00:00	3	1.6	8.5	14.3	18.9	678,902.5	0.00	1.00
10/25/2021 01:00	3	1.8	10.0	14.4	22.8	625,932.3	0.00	1.00
10/25/2021 02:00	3	1.6	10.7	14.5	22.9	627,795.5	0.00	1.00
10/25/2021 03:00	3	1.6	10.4	14.5	23.8	634,856.6	0.00	1.00
10/25/2021 04:00	1	1.6	6.9	14.3	16.8	898,632.9	0.00	1.00
10/25/2021 05:00	2	1.7	7.3	14.4	20.1	957,543.7	0.00	1.00
10/25/2021 06:00	2	1.7	7.1	14.3	19.9	898,632.9	0.00	1.00
10/25/2021 07:00	2	1.7	6.8	14.3	19.1	881,411.3	0.00	1.00
10/25/2021 08:00	2	1.7	6.8	14.3	20.1	935,773.3	0.00	1.00
10/25/2021 09:00	3	1.8	9.4	14.4	22.6	740,753.3	0.00	1.00
10/25/2021 10:00	4	1.6	13.3	14.6	29.8	612,111.0	0.00	1.00
10/25/2021 11:00	4	1.6	13.9	14.6	29.1	603,850.9	0.00	1.00
10/25/2021 12:00	4	1.6	14.0	14.6	28.9	605,589.9	0.00	1.00
10/25/2021 13:00	3	1.6	12.9	14.6	25.0	613,415.2	0.00	1.00
10/25/2021 14:00	3	1.6	12.9	14.7	26.8	621,542.0	0.00	1.00
10/25/2021 15:00	3	1.6	13.7	14.7	27.6	614,694.8	0.00	1.00
10/25/2021 16:00	1	1.4	8.6	14.5	14.7	833,851.1	0.00	1.00
10/25/2021 17:00	2	1.7	8.1	14.3	16.8	771,234.9	0.00	1.00
10/25/2021 18:00	3	1.9	8.5	14.3	20.1	753,805.9	0.00	1.00
10/25/2021 19:00	2	1.6	7.3	14.3	17.7	857,550.1	0.00	1.00
10/25/2021 20:00	2	1.7	7.5	14.3	20.6	935,980.8	0.00	1.00
10/25/2021 21:00	4	1.9	11.2	14.4	26.7	638,362.4	0.00	1.00
10/25/2021 22:00	5	1.7	14.0	14.7	32.9	619,775.0	0.00	1.00
10/25/2021 23:00	4	1.7	12.9	14.6	28.5	624,718.4	0.00	1.00
Average/Sum#:	3	1.7	10.1	14.5	23.0	732,779.9	0.00 #	24.00 #
Minimum:	1	1.4	6.8	14.3	14.7	603,850.9	0.00	1.00
Maximum:	5	1.9	14.0	14.7	32.9	957,543.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOX, Ppm	Unit CT1 NOX, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/26/2021 00:00	5	1.6	14.2	14.7	34.2	617,787.1	0.00	1.00
10/26/2021 01:00	4	1.6	13.5	14.7	30.4	624,855.1	0.00	1.00
10/26/2021 02:00	5	1.7	14.6	14.7	31.0	625,959.5	0.00	1.00
10/26/2021 03:00	4	1.9	12.6	14.6	26.1	627,544.2	0.00	1.00
10/26/2021 04:00	5	1.6	14.3	14.7	34.3	621,762.8	0.00	1.00
10/26/2021 05:00	1	1.6	8.2	14.4	16.2	824,814.8	0.00	1.00
10/26/2021 06:00	4	1.9	11.5	14.4	27.1	636,466.3	0.00	1.00
10/26/2021 07:00	3	1.5	10.1	14.4	22.0	703,673.5	0.00	1.00
10/26/2021 08:00	4	1.8	12.2	14.5	28.5	623,088.1	0.00	1.00
10/26/2021 09:00	3	1.6	12.1	14.6	25.7	630,804.7	0.00	1.00
10/26/2021 10:00	3	1.6	11.9	14.6	23.8	630,804.7	0.00	1.00
10/26/2021 11:00	3	1.7	11.6	14.5	22.9	647,053.0	0.00	1.00
10/26/2021 12:00	3	1.6	11.8	14.6	23.9	630,587.3	0.00	1.00
10/26/2021 13:00	4	1.6	12.7	14.7	27.6	630,156.1	0.00	1.00
10/26/2021 14:00	2	1.6	10.3	14.5	17.1	660,105.3	0.00	1.00
10/26/2021 15:00	3	1.7	12.4	14.6	25.0	624,283.6	0.00	1.00
10/26/2021 16:00	2	1.6	10.0	14.5	17.1	685,568.1	0.00	1.00
10/26/2021 17:00	4	1.8	12.4	14.6	28.8	641,455.8	0.00	1.00
10/26/2021 18:00	1	1.5	8.2	14.3	14.3	774,347.2	0.00	1.00
10/26/2021 19:00	2	1.7	7.6	14.3	15.7	786,589.1	0.00	1.00
10/26/2021 20:00	2	1.7	7.1	14.3	17.5	840,121.1	0.00	1.00
10/26/2021 21:00	2	1.8	8.1	14.3	20.8	827,464.3	0.00	1.00
10/26/2021 22:00	2	1.7	7.2	14.3	18.2	855,475.3	0.00	1.00
10/26/2021 23:00	4	1.7	12.1	14.5	28.8	625,441.8	0.00	1.00
Average/Sum#:	3	1.7	11.1	14.5	24.0	683,175.4	0.00 #	24.00 #
Minimum:	1	1.5	7.1	14.3	14.3	617,787.1	0.00	1.00
Maximum:	5	1.9	14.6	14.7	34.3	855,475.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/27/2021 00:00	4	1.6	11.8	14.6	26.2	633,413.1	0.00	1.00
10/27/2021 01:00	5	1.7	13.2	14.7	31.6	625,517.7	0.00	1.00
10/27/2021 02:00	4	1.5	14.4	14.7	32.7	618,449.7	0.00	1.00
10/27/2021 03:00	4	1.6	13.2	14.6	29.4	619,501.5	0.00	1.00
10/27/2021 04:00	4	1.7	12.5	14.6	27.2	625,370.5	0.00	1.00
10/27/2021 05:00	3	1.6	11.0	14.6	24.6	739,923.9	0.00	1.00
10/27/2021 06:00	2	1.8	7.8	14.3	19.6	890,540.8	0.00	1.00
10/27/2021 07:00	4	2.0	12.1	14.5	30.3	666,096.6	0.00	1.00
10/27/2021 08:00	5	1.6	15.2	14.8	35.2	622,975.8	0.00	1.00
10/27/2021 09:00	4	1.6	14.5	14.8	32.2	623,424.8	0.00	1.00
10/27/2021 10:00	4	1.6	14.1	14.8	30.7	622,751.4	0.00	1.00
10/27/2021 11:00	4	1.6	13.7	14.7	28.6	612,927.8	0.00	1.00
10/27/2021 12:00	4	1.6	13.6	14.7	28.5	612,486.1	0.00	1.00
10/27/2021 13:00	3	1.6	13.0	14.7	25.9	614,915.7	0.00	1.00
10/27/2021 14:00	3	1.6	12.7	14.7	25.3	613,369.6	0.00	1.00
10/27/2021 15:00	2	1.4	11.0	14.6	20.9	663,410.0	0.00	1.00
10/27/2021 16:00	0	1.6	7.2	14.4	11.6	904,873.5	0.00	1.00
10/27/2021 17:00	1	1.7	6.9	14.4	16.6	981,561.3	0.00	1.00
10/27/2021 18:00	2	1.7	6.7	14.3	17.7	891,578.3	0.00	1.00
10/27/2021 19:00	2	1.7	6.7	14.3	18.7	930,171.1	0.00	1.00
10/27/2021 20:00	2	1.7	6.8	14.3	16.9	854,645.3	0.00	1.00
10/27/2021 21:00	2	1.7	6.6	14.3	18.0	872,904.3	0.00	1.00
10/27/2021 22:00	4	1.8	10.6	14.4	24.9	649,107.2	0.00	1.00
10/27/2021 23:00	4	1.6	11.3	14.5	25.4	625,441.8	0.00	1.00
Average/Sum#:	3	1.7	11.1	14.6	24.9	713,139.9	0.00 #	24.00 #
Minimum:	0	1.4	6.6	14.3	11.6	612,486.1	0.00	1.00
Maximum:	5	2.0	15.2	14.8	35.2	981,561.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOX, Ppm	Unit CT1 NOX, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/28/2021 00:00	4	1.6	11.3	14.5	25.4	624,585.9	0.00	1.00
10/28/2021 01:00	4	1.6	11.3	14.5	25.8	623,516.0	0.00	1.00
10/28/2021 02:00	3	1.6	11.9	14.5	25.9	623,730.0	0.00	1.00
10/28/2021 03:00	4	1.6	11.7	14.5	26.7	624,158.0	0.00	1.00
10/28/2021 04:00	3	1.5	10.6	14.4	24.0	671,439.3	0.00	1.00
10/28/2021 05:00	2	1.8	8.8	14.4	19.9	804,168.1	0.00	1.00
10/28/2021 06:00	2	1.8	8.3	14.3	21.0	808,167.9	0.00	1.00
10/28/2021 07:00	4	1.8	12.4	14.5	29.7	617,096.9	0.00	1.00
10/28/2021 08:00	4	1.6	13.4	14.7	30.8	617,566.2	0.00	1.00
10/28/2021 09:00	4	1.6	13.3	14.7	27.7	613,369.6	0.00	1.00
10/28/2021 10:00	3	1.5	11.7	14.6	22.3	617,979.9	0.00	1.00
10/28/2021 11:00	2	1.7	10.5	14.6	20.2	627,544.2	0.00	1.00
10/28/2021 12:00	2	1.6	10.1	14.6	18.0	630,370.0	0.00	1.00
10/28/2021 13:00	3	1.6	12.2	14.7	24.7	612,707.0	0.00	1.00
10/28/2021 14:00	2	1.6	11.6	14.7	21.5	617,124.5	0.00	1.00
10/28/2021 15:00	2	1.5	10.9	14.7	18.5	625,296.8	0.00	1.00
10/28/2021 16:00	1	1.5	7.5	14.4	12.2	880,223.9	0.00	1.00
10/28/2021 17:00	1	1.7	7.0	14.4	15.1	981,982.6	0.00	1.00
10/28/2021 18:00	1	1.7	6.6	14.3	16.9	917,721.8	0.00	1.00
10/28/2021 19:00	2	1.7	6.8	14.4	19.5	965,760.2	0.00	1.00
10/28/2021 20:00	2	1.7	6.8	14.3	18.1	912,534.6	0.00	1.00
10/28/2021 21:00	2	1.8	7.7	14.3	19.4	809,412.8	0.00	1.00
10/28/2021 22:00	3	1.6	10.7	14.5	24.2	622,232.2	0.00	1.00
10/28/2021 23:00	4	1.7	11.5	14.6	25.6	622,544.7	0.00	1.00
Average/Sum#:	3	1.6	10.2	14.5	22.2	711,301.4	0.00 #	24.00 #
Minimum:	1	1.5	6.6	14.3	12.2	612,707.0	0.00	1.00
Maximum:	4	1.8	13.4	14.7	30.8	981,982.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/29/2021 00:00	4	1.7	12.3	14.6	27.4	616,458.3	0.00	1.00
10/29/2021 01:00	4	1.7	12.3	14.6	27.2	614,719.4	0.00	1.00
10/29/2021 02:00	4	1.5	13.9	14.6	31.9	606,459.4	0.00	1.00
10/29/2021 03:00	3	1.7	11.0	14.5	22.3	623,944.0	0.00	1.00
10/29/2021 04:00	4	1.6	11.2	14.5	25.2	623,516.0	0.00	1.00
10/29/2021 05:00	3	1.5	9.4	14.4	21.0	740,121.2	0.00	1.00
10/29/2021 06:00	3	1.9	9.2	14.3	22.9	795,926.1	0.00	1.00
10/29/2021 07:00	5	1.9	13.3	14.6	31.7	615,806.2	0.00	1.00
10/29/2021 08:00	5	1.6	14.0	14.7	32.1	612,044.3	0.00	1.00
10/29/2021 09:00	4	1.6	13.2	14.7	27.6	612,265.2	0.00	1.00
10/29/2021 10:00	3	1.6	12.3	14.6	24.5	607,111.5	0.00	1.00
10/29/2021 11:00	3	1.6	12.3	14.6	24.5	603,633.6	0.00	1.00
10/29/2021 12:00	3	1.6	11.8	14.7	22.1	612,707.0	0.00	1.00
10/29/2021 13:00	2	1.5	10.9	14.7	18.7	622,425.5	0.00	1.00
10/29/2021 14:00	2	1.7	11.3	14.7	20.4	613,148.7	0.00	1.00
10/29/2021 15:00	1	1.4	8.7	14.5	14.1	742,270.8	0.00	1.00
10/29/2021 16:00	0	1.6	7.0	14.4	10.8	936,475.6	0.00	1.00
10/29/2021 17:00	1	1.7	7.1	14.4	16.3	955,226.2	0.00	1.00
10/29/2021 18:00	2	1.7	6.5	14.3	14.6	806,922.9	0.00	1.00
10/29/2021 19:00	1	1.7	6.8	14.4	17.8	958,175.7	0.00	1.00
10/29/2021 20:00	2	1.7	6.7	14.4	17.6	911,404.6	0.00	1.00
10/29/2021 21:00	2	1.7	6.9	14.3	17.5	801,113.3	0.00	1.00
10/29/2021 22:00	1	1.6	6.7	14.3	14.1	779,949.4	0.00	1.00
10/29/2021 23:00	3	1.7	8.6	14.4	19.5	705,148.2	0.00	1.00
Average/Sum#:	3	1.6	10.1	14.5	21.7	713,207.2	0.00 #	24.00 #
Minimum:	0	1.4	6.5	14.3	10.8	603,633.6	0.00	1.00
Maximum:	5	1.9	14.0	14.7	32.1	958,175.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/30/2021 00:00	2	1.7	8.6	14.4	16.8	664,697.5	0.00	1.00
10/30/2021 01:00	3	1.7	10.5	14.5	22.4	612,817.4	0.00	1.00
10/30/2021 02:00	3	1.5	12.7	14.6	26.8	608,415.7	0.00	1.00
10/30/2021 03:00	3	1.7	10.6	14.5	21.2	615,813.0	0.00	1.00
10/30/2021 04:00	3	1.7	11.0	14.5	23.4	614,315.2	0.00	1.00
10/30/2021 05:00	2	1.5	9.3	14.4	19.4	679,023.8	0.00	1.00
10/30/2021 06:00	4	1.9	11.8	14.6	27.7	617,327.8	0.00	1.00
10/30/2021 07:00	4	1.6	12.9	14.6	29.2	607,111.5	0.00	1.00
10/30/2021 08:00	4	1.6	13.3	14.7	29.2	612,707.0	0.00	1.00
10/30/2021 09:00	4	1.6	13.4	14.7	29.4	610,940.0	0.00	1.00
10/30/2021 10:00	4	1.6	13.1	14.7	27.5	612,044.3	0.00	1.00
10/30/2021 11:00	3	1.6	12.8	14.7	25.5	612,486.1	0.00	1.00
10/30/2021 12:00	3	1.6	12.5	14.7	24.6	612,265.2	0.00	1.00
10/30/2021 13:00	3	1.6	12.3	14.7	23.6	612,486.1	0.00	1.00
10/30/2021 14:00	3	1.6	12.5	14.7	24.3	612,044.3	0.00	1.00
10/30/2021 15:00	2	1.4	10.3	14.6	19.4	739,923.9	0.00	1.00
10/30/2021 16:00	3	1.6	10.6	14.5	20.9	655,825.9	0.00	1.00
10/30/2021 17:00	2	1.7	10.5	14.5	19.9	626,083.7	0.00	1.00
10/30/2021 18:00	4	1.6	13.1	14.7	29.1	614,915.7	0.00	1.00
10/30/2021 19:00	3	1.7	11.9	14.6	25.0	620,805.7	0.00	1.00
10/30/2021 20:00	4	1.5	12.8	14.6	27.5	612,980.4	0.00	1.00
10/30/2021 21:00	4	1.7	13.0	14.6	28.8	609,937.3	0.00	1.00
10/30/2021 22:00	4	1.6	13.3	14.6	29.3	608,198.3	0.00	1.00
10/30/2021 23:00	3	1.7	11.5	14.6	24.1	624,501.0	0.00	1.00
Average/Sum#:	3	1.6	11.8	14.6	24.8	625,736.1	0.00 #	24.00 #
Minimum:	2	1.4	8.6	14.4	16.8	607,111.5	0.00	1.00
Maximum:	4	1.9	13.4	14.7	29.4	739,923.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/31/2021 00:00	4	1.6	13.0	14.6	29.1	611,676.2	0.00	1.00
10/31/2021 01:00	4	1.6	12.8	14.6	28.7	612,111.0	0.00	1.00
10/31/2021 02:00	4	1.6	13.4	14.6	28.8	611,458.9	0.00	1.00
10/31/2021 03:00	4	1.6	13.0	14.6	29.3	611,893.6	0.00	1.00
10/31/2021 04:00	4	1.6	12.9	14.6	28.9	611,241.5	0.00	1.00
10/31/2021 05:00	3	1.6	11.9	14.5	25.4	620,948.4	0.00	1.00
10/31/2021 06:00	3	1.8	10.8	14.4	23.7	642,365.4	0.00	1.00
10/31/2021 07:00	4	1.9	13.5	14.7	30.3	623,088.1	0.00	1.00
10/31/2021 08:00	4	1.6	13.6	14.7	30.7	620,216.7	0.00	1.00
10/31/2021 09:00	4	1.7	12.7	14.6	26.9	616,241.0	0.00	1.00
10/31/2021 10:00	4	1.6	14.2	14.7	31.6	612,044.3	0.00	1.00
10/31/2021 11:00	4	1.6	14.0	14.7	30.5	610,940.0	0.00	1.00
10/31/2021 12:00	4	1.6	13.8	14.7	29.1	611,602.6	0.00	1.00
10/31/2021 13:00	3	1.6	13.4	14.7	26.8	612,707.0	0.00	1.00
10/31/2021 14:00	3	1.6	13.3	14.7	26.7	612,044.3	0.00	1.00
10/31/2021 15:00	3	1.4	11.7	14.6	22.7	656,454.2	0.00	1.00
10/31/2021 16:00	3	1.6	13.0	14.7	26.4	613,811.3	0.00	1.00
10/31/2021 17:00	4	1.6	13.3	14.7	28.1	611,602.6	0.00	1.00
10/31/2021 18:00	4	1.6	13.5	14.7	29.7	611,160.9	0.00	1.00
10/31/2021 19:00	5	1.6	14.0	14.7	32.1	609,173.0	0.00	1.00
10/31/2021 20:00	5	1.6	14.0	14.7	32.6	608,952.1	0.00	1.00
10/31/2021 21:00	5	1.6	14.2	14.7	33.1	609,835.6	0.00	1.00
10/31/2021 22:00	4	1.6	13.9	14.7	31.6	612,486.1	0.00	1.00
10/31/2021 23:00	4	1.7	13.0	14.6	29.3	610,806.7	0.00	1.00
Average/Sum#:	4	1.6	13.2	14.6	28.8	616,035.9	0.00 #	24.00 #
Minimum:	3	1.4	10.8	14.4	22.7	608,952.1	0.00	1.00
Maximum:	5	1.9	14.2	14.7	33.1	656,454.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/01/2021 00:00	4	1.7	13.4	14.6	31.0	605,589.9	0.00	1.00
11/01/2021 01:00	4	1.6	12.2	14.6	26.3	616,241.0	0.00	1.00
11/01/2021 02:00	4	1.6	14.2	14.7	32.1	612,707.0	0.00	1.00
11/01/2021 03:00	3	1.6	11.5	14.5	25.0	615,813.0	0.00	1.00
11/01/2021 04:00	3	1.6	10.3	14.5	21.5	706,109.4	0.00	1.00
11/01/2021 05:00	4	1.8	11.5	14.5	24.9	610,891.7	0.00	1.00
11/01/2021 06:00	1	1.6	7.0	14.4	15.4	912,879.4	0.00	1.00
11/01/2021 07:00	3	1.8	9.4	14.5	21.2	730,716.3	0.00	1.00
11/01/2021 08:00	3	1.6	11.1	14.6	22.8	625,370.5	0.00	1.00
11/01/2021 09:00	1	1.5	8.0	14.4	14.8	748,127.1	0.00	1.00
11/01/2021 10:00	2	1.7	9.6	14.5	18.9	654,114.1	0.00	1.00
11/01/2021 11:00	1	1.6	7.3	14.3	13.8	745,713.8	0.00	1.00
11/01/2021 12:00	2	1.6	8.1	14.4	18.3	810,488.6	0.00	1.00
11/01/2021 13:00	1	1.6	7.4	14.4	18.1	976,926.3	0.00	1.00
11/01/2021 14:00	2	1.7	7.7	14.3	18.7	827,256.8	0.00	1.00
11/01/2021 15:00	3	1.7	9.1	14.4	19.4	669,332.5	0.00	1.00
11/01/2021 16:00	2	1.6	8.8	14.4	18.5	739,489.2	0.00	1.00
11/01/2021 17:00	1	1.7	6.5	14.4	16.2	935,843.6	0.00	1.00
11/01/2021 18:00	2	1.7	6.5	14.4	17.4	911,193.9	0.00	1.00
11/01/2021 19:00	2	1.7	6.9	14.4	18.7	948,905.8	0.00	1.00
11/01/2021 20:00	2	1.7	6.9	14.4	19.5	953,962.1	0.00	1.00
11/01/2021 21:00	2	1.7	7.1	14.3	19.3	907,347.4	0.00	1.00
11/01/2021 22:00	3	1.8	8.8	14.4	21.3	760,135.9	0.00	1.00
11/01/2021 23:00	3	1.6	10.1	14.5	21.7	629,507.3	0.00	1.00
Average/Sum#:	2	1.7	9.1	14.5	20.6	760,610.9	0.00 #	24.00 #
Minimum:	1	1.5	6.5	14.3	13.8	605,589.9	0.00	1.00
Maximum:	4	1.8	14.2	14.7	32.1	976,926.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/02/2021 00:00	3	1.6	10.1	14.5	22.0	627,581.5	0.00	1.00
11/02/2021 01:00	4	1.7	10.9	14.5	24.8	619,450.6	0.00	1.00
11/02/2021 02:00	4	1.5	13.5	14.6	30.1	607,763.6	0.00	1.00
11/02/2021 03:00	3	1.6	11.3	14.5	24.0	614,529.2	0.00	1.00
11/02/2021 04:00	3	1.7	11.0	14.5	23.7	614,957.1	0.00	1.00
11/02/2021 05:00	3	1.5	9.8	14.5	22.4	648,764.8	0.00	1.00
11/02/2021 06:00	1	1.7	7.5	14.3	16.1	818,749.8	0.00	1.00
11/02/2021 07:00	4	1.9	10.6	14.5	25.1	658,393.6	0.00	1.00
11/02/2021 08:00	5	1.6	13.7	14.7	32.3	610,277.4	0.00	1.00
11/02/2021 09:00	4	1.6	12.7	14.7	27.4	618,228.8	0.00	1.00
11/02/2021 10:00	3	1.6	12.0	14.6	25.2	611,024.1	0.00	1.00
11/02/2021 11:00	3	1.6	11.9	14.7	22.9	622,425.5	0.00	1.00
11/02/2021 12:00	3	1.6	11.5	14.6	22.4	613,415.2	0.00	1.00
11/02/2021 13:00	3	1.6	12.3	14.7	25.5	609,835.6	0.00	1.00
11/02/2021 14:00	3	1.6	12.6	14.7	25.6	610,498.2	0.00	1.00
11/02/2021 15:00	2	1.6	11.6	14.7	21.4	621,321.1	0.00	1.00
11/02/2021 16:00	1	1.5	8.5	14.5	14.7	806,676.6	0.00	1.00
11/02/2021 17:00	1	1.7	7.0	14.4	15.3	943,006.7	0.00	1.00
11/02/2021 18:00	2	1.7	6.6	14.3	17.1	886,598.5	0.00	1.00
11/02/2021 19:00	1	1.7	7.1	14.4	18.9	979,665.1	0.00	1.00
11/02/2021 20:00	2	1.7	6.9	14.4	19.7	965,128.2	0.00	1.00
11/02/2021 21:00	2	1.7	7.5	14.4	20.3	871,586.0	0.00	1.00
11/02/2021 22:00	2	1.7	7.1	14.3	18.2	898,840.4	0.00	1.00
11/02/2021 23:00	2	1.7	7.4	14.2	16.8	751,343.9	0.00	1.00
Average/Sum#:	3	1.6	10.0	14.5	22.2	717,919.2	0.00 #	24.00 #
Minimum:	1	1.5	6.6	14.2	14.7	607,763.6	0.00	1.00
Maximum:	5	1.9	13.7	14.7	32.3	979,665.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/03/2021 00:00	2	1.7	6.9	14.2	16.8	731,109.1	0.00	1.00
11/03/2021 01:00	3	1.7	7.7	14.2	19.5	711,283.1	0.00	1.00
11/03/2021 02:00	3	1.7	8.1	14.2	19.7	710,261.2	0.00	1.00
11/03/2021 03:00	3	1.7	7.7	14.2	19.4	725,181.7	0.00	1.00
11/03/2021 04:00	2	1.7	7.9	14.2	19.5	774,848.9	0.00	1.00
11/03/2021 05:00	2	1.7	6.9	14.3	20.2	871,451.9	0.00	1.00
11/03/2021 06:00	2	1.7	7.5	14.3	21.4	871,451.9	0.00	1.00
11/03/2021 07:00	4	2.0	11.5	14.5	28.4	689,847.5	0.00	1.00
11/03/2021 08:00	4	1.7	13.2	14.6	30.3	613,849.9	0.00	1.00
11/03/2021 09:00	4	1.6	13.8	14.7	31.3	608,731.2	0.00	1.00
11/03/2021 10:00	4	1.6	13.2	14.7	27.4	614,253.1	0.00	1.00
11/03/2021 11:00	3	1.6	12.7	14.7	25.7	614,032.2	0.00	1.00
11/03/2021 12:00	3	1.6	11.9	14.7	23.3	620,216.7	0.00	1.00
11/03/2021 13:00	2	1.5	11.0	14.7	20.2	625,296.8	0.00	1.00
11/03/2021 14:00	2	1.6	11.1	14.7	20.9	623,088.1	0.00	1.00
11/03/2021 15:00	2	1.4	9.3	14.6	17.5	730,794.4	0.00	1.00
11/03/2021 16:00	1	1.6	7.9	14.4	12.8	788,367.1	0.00	1.00
11/03/2021 17:00	1	1.7	7.2	14.4	16.0	964,706.8	0.00	1.00
11/03/2021 18:00	1	1.7	6.6	14.3	16.7	902,160.2	0.00	1.00
11/03/2021 19:00	2	1.7	6.7	14.4	18.2	953,962.1	0.00	1.00
11/03/2021 20:00	2	1.7	6.7	14.4	19.0	950,380.5	0.00	1.00
11/03/2021 21:00	2	1.7	6.7	14.3	18.6	865,642.2	0.00	1.00
11/03/2021 22:00	3	1.8	8.2	14.3	19.5	725,379.9	0.00	1.00
11/03/2021 23:00	3	1.7	10.8	14.5	23.7	619,022.6	0.00	1.00
Average/Sum#:	3	1.7	9.2	14.4	21.1	746,055.0	0.00 #	24.00 #
Minimum:	1	1.4	6.6	14.2	12.8	608,731.2	0.00	1.00
Maximum:	4	2.0	13.8	14.7	31.3	964,706.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/04/2021 00:00	4	1.7	11.2	14.5	24.7	610,891.7	0.00	1.00
11/04/2021 01:00	4	1.6	13.5	14.7	31.4	611,602.6	0.00	1.00
11/04/2021 02:00	3	1.7	10.7	14.5	19.2	619,236.6	0.00	1.00
11/04/2021 03:00	1	1.3	7.7	14.3	19.3	791,776.3	0.00	1.00
11/04/2021 04:00	3	1.7	9.1	14.4	20.4	698,195.8	0.00	1.00
11/04/2021 05:00	2	1.7	6.8	14.3	16.5	871,451.9	0.00	1.00
11/04/2021 06:00	2	1.7	7.1	14.3	19.0	908,592.3	0.00	1.00
11/04/2021 07:00	4	1.9	10.6	14.5	25.5	677,223.2	0.00	1.00
11/04/2021 08:00	3	1.6	11.5	14.6	23.9	621,675.2	0.00	1.00
11/04/2021 09:00	2	1.6	9.5	14.5	18.6	766,877.7	0.00	1.00
11/04/2021 10:00	5	1.5	14.0	14.7	35.4	610,056.5	0.00	1.00
11/04/2021 11:00	3	1.5	13.3	14.7	25.6	612,927.8	0.00	1.00
11/04/2021 12:00	4	1.6	13.7	14.7	28.2	610,940.0	0.00	1.00
11/04/2021 13:00	3	1.5	13.0	14.7	25.0	617,566.2	0.00	1.00
11/04/2021 14:00	4	1.6	13.4	14.7	27.9	610,498.2	0.00	1.00
11/04/2021 15:00	2	1.3	10.4	14.6	19.3	740,141.3	0.00	1.00
11/04/2021 16:00	2	1.7	10.5	14.5	18.2	649,406.7	0.00	1.00
11/04/2021 17:00	3	1.6	11.8	14.6	24.8	612,980.4	0.00	1.00
11/04/2021 18:00	3	1.6	11.7	14.6	25.1	620,371.0	0.00	1.00
11/04/2021 19:00	4	1.7	11.8	14.6	26.1	619,284.1	0.00	1.00
11/04/2021 20:00	4	1.7	12.5	14.6	28.4	613,849.9	0.00	1.00
11/04/2021 21:00	5	1.6	14.7	14.7	35.8	608,068.6	0.00	1.00
11/04/2021 22:00	5	1.6	14.7	14.7	35.2	609,173.0	0.00	1.00
11/04/2021 23:00	5	1.6	14.7	14.8	35.2	616,690.0	0.00	1.00
Average/Sum#:	3	1.6	11.6	14.6	25.4	663,728.2	0.00 #	24.00 #
Minimum:	1	1.3	6.8	14.3	16.5	608,068.6	0.00	1.00
Maximum:	5	1.9	14.7	14.8	35.8	908,592.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/05/2021 00:00	5	1.6	14.6	14.7	33.9	606,964.2	0.00	1.00
11/05/2021 01:00	5	1.6	15.2	14.8	37.3	615,567.5	0.00	1.00
11/05/2021 02:00	5	1.5	16.0	14.8	37.8	618,261.4	0.00	1.00
11/05/2021 03:00	3	1.6	13.3	14.6	29.6	617,762.6	0.00	1.00
11/05/2021 04:00	3	1.6	11.4	14.4	24.2	655,427.6	0.00	1.00
11/05/2021 05:00	2	1.7	9.2	14.4	21.3	829,239.1	0.00	1.00
11/05/2021 06:00	2	1.7	7.5	14.3	20.2	864,604.8	0.00	1.00
11/05/2021 07:00	3	2.0	10.5	14.4	26.5	750,865.9	0.00	1.00
11/05/2021 08:00	5	1.7	13.7	14.6	33.2	614,502.0	0.00	1.00
11/05/2021 09:00	6	1.6	15.7	14.8	38.9	616,241.0	0.00	1.00
11/05/2021 10:00	4	1.6	14.9	14.8	33.5	617,139.0	0.00	1.00
11/05/2021 11:00	4	1.6	14.0	14.7	29.7	608,952.1	0.00	1.00
11/05/2021 12:00	4	1.6	13.7	14.7	28.7	609,835.6	0.00	1.00
11/05/2021 13:00	4	1.6	13.5	14.7	28.1	610,498.2	0.00	1.00
11/05/2021 14:00	2	1.4	9.7	14.5	17.4	696,908.6	0.00	1.00
11/05/2021 15:00	1	1.6	7.5	14.4	12.1	869,057.8	0.00	1.00
11/05/2021 16:00	2	1.6	8.5	14.4	17.8	790,684.6	0.00	1.00
11/05/2021 17:00	2	1.7	7.4	14.3	16.8	788,871.4	0.00	1.00
11/05/2021 18:00	3	1.8	9.4	14.4	21.7	683,237.4	0.00	1.00
11/05/2021 19:00	1	1.6	7.8	14.3	14.7	756,295.7	0.00	1.00
11/05/2021 20:00	2	1.7	8.3	14.4	19.9	788,788.4	0.00	1.00
11/05/2021 21:00	2	1.7	7.8	14.4	20.6	866,740.3	0.00	1.00
11/05/2021 22:00	3	1.7	9.4	14.4	23.1	701,145.3	0.00	1.00
11/05/2021 23:00	2	1.7	7.7	14.3	17.6	783,684.2	0.00	1.00
Average/Sum#:	3	1.6	11.1	14.5	25.2	706,719.8	0.00 #	24.00 #
Minimum:	1	1.4	7.4	14.3	12.1	606,964.2	0.00	1.00
Maximum:	6	2.0	16.0	14.8	38.9	869,057.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/06/2021 00:00	4	1.7	11.6	14.5	27.7	633,572.8	0.00	1.00
11/06/2021 01:00	2	1.6	7.8	14.2	16.2	720,276.3	0.00	1.00
11/06/2021 02:00	4	1.9	11.4	14.4	25.9	634,570.2	0.00	1.00
11/06/2021 03:00	4	1.6	12.0	14.5	27.5	622,446.2	0.00	1.00
11/06/2021 04:00	3	1.5	10.1	14.4	21.0	665,961.6	0.00	1.00
11/06/2021 05:00	2	1.7	7.7	14.3	18.4	796,341.0	0.00	1.00
11/06/2021 06:00	2	1.7	7.1	14.3	20.3	900,707.8	0.00	1.00
11/06/2021 07:00	3	1.9	9.5	14.4	24.0	758,871.8	0.00	1.00
11/06/2021 08:00	3	1.8	10.0	14.4	21.3	708,729.8	0.00	1.00
11/06/2021 09:00	5	1.7	13.6	14.7	32.7	627,284.7	0.00	1.00
11/06/2021 10:00	4	1.6	13.9	14.7	30.6	618,670.6	0.00	1.00
11/06/2021 11:00	4	1.6	13.7	14.7	29.9	618,891.5	0.00	1.00
11/06/2021 12:00	5	1.6	14.3	14.8	33.2	619,383.9	0.00	1.00
11/06/2021 13:00	5	1.6	14.5	14.8	34.7	619,159.4	0.00	1.00
11/06/2021 14:00	5	1.6	14.7	14.8	35.6	618,485.9	0.00	1.00
11/06/2021 15:00	3	1.4	12.2	14.7	27.4	706,137.1	0.00	1.00
11/06/2021 16:00	1	1.7	8.7	14.5	16.9	825,292.2	0.00	1.00
11/06/2021 17:00	1	1.7	7.6	14.4	17.8	923,834.8	0.00	1.00
11/06/2021 18:00	3	1.7	9.2	14.4	21.2	727,691.0	0.00	1.00
11/06/2021 19:00	1	1.6	7.1	14.4	15.8	966,181.6	0.00	1.00
11/06/2021 20:00	2	1.7	7.1	14.3	18.3	879,751.4	0.00	1.00
11/06/2021 21:00	3	1.9	8.6	14.3	21.3	794,473.6	0.00	1.00
11/06/2021 22:00	4	1.6	12.5	14.5	29.4	621,162.3	0.00	1.00
11/06/2021 23:00	4	1.6	12.6	14.5	29.2	619,236.6	0.00	1.00
Average/Sum#:	3	1.7	10.7	14.5	24.8	717,796.4	0.00 #	24.00 #
Minimum:	1	1.4	7.1	14.2	15.8	618,485.9	0.00	1.00
Maximum:	5	1.9	14.7	14.8	35.6	966,181.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/07/2021 00:00	6	1.7	15.5	14.8	38.6	623,649.3	0.00	1.00
11/07/2021 01:00	6	1.6	15.9	14.8	39.7	621,404.4	0.00	1.00
11/07/2021 02:00	5	1.5	16.3	14.8	39.0	624,771.8	0.00	1.00
11/07/2021 03:00	6	1.6	15.9	14.8	39.1	626,792.3	0.00	1.00
11/07/2021 04:00	6	1.6	15.9	14.8	39.4	627,241.3	0.00	1.00
11/07/2021 05:00	5	1.5	15.9	14.8	38.3	629,486.2	0.00	1.00
11/07/2021 06:00	2	1.7	9.7	14.4	18.0	809,013.8	0.00	1.00
11/07/2021 07:00	3	2.0	9.4	14.4	23.9	869,057.8	0.00	1.00
11/07/2021 08:00	6	2.0	17.4	14.8	43.5	623,649.3	0.00	1.00
11/07/2021 09:00	6	1.6	16.5	14.8	40.6	623,649.3	0.00	1.00
11/07/2021 10:00	5	1.6	15.5	14.8	37.0	620,730.9	0.00	1.00
11/07/2021 11:00	5	1.6	15.3	14.8	35.0	618,261.4	0.00	1.00
11/07/2021 12:00	5	1.6	15.6	14.8	35.9	613,322.5	0.00	1.00
11/07/2021 13:00	5	1.5	15.7	14.8	34.6	613,996.0	0.00	1.00
11/07/2021 14:00	3	1.6	13.8	14.7	27.7	616,241.0	0.00	1.00
11/07/2021 15:00	2	1.4	10.3	14.5	20.6	776,078.5	0.00	1.00
11/07/2021 16:00	2	1.7	9.0	14.4	18.7	798,058.4	0.00	1.00
11/07/2021 17:00	3	1.9	9.3	14.3	20.2	706,083.5	0.00	1.00
11/07/2021 18:00	3	1.7	11.0	14.4	24.6	676,495.6	0.00	1.00
11/07/2021 19:00	2	1.8	8.0	14.3	17.8	783,684.2	0.00	1.00
11/07/2021 20:00	5	2.0	12.7	14.5	30.5	643,201.5	0.00	1.00
11/07/2021 21:00	5	1.6	13.7	14.6	32.5	620,588.4	0.00	1.00
11/07/2021 22:00	5	1.6	13.5	14.5	31.6	611,533.6	0.00	1.00
11/07/2021 23:00	6	1.8	17.2	14.8	43.3	618,261.4	0.00	1.00
Average/Sum#:	4	1.7	13.7	14.6	32.1	666,468.9	0.00 #	24.00 #
Minimum:	2	1.4	8.0	14.3	17.8	611,533.6	0.00	1.00
Maximum:	6	2.0	17.4	14.8	43.5	869,057.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOX, Ppm	Unit CT1 NOX, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/08/2021 00:00	6	1.6	17.1	14.8	42.0	622,975.8	0.00	1.00
11/08/2021 01:00	4	1.7	13.2	14.5	28.8	614,743.2	0.00	1.00
11/08/2021 02:00	2	1.5	10.8	14.4	25.2	678,181.1	0.00	1.00
11/08/2021 03:00	2	1.7	7.7	14.3	19.0	928,096.3	0.00	1.00
11/08/2021 04:00	2	1.7	7.7	14.4	22.2	948,484.4	0.00	1.00
11/08/2021 05:00	2	1.7	7.7	14.4	23.1	973,134.0	0.00	1.00
11/08/2021 06:00	2	1.7	7.5	14.3	22.9	949,675.1	0.00	1.00
11/08/2021 07:00	5	2.1	11.9	14.5	32.5	755,965.1	0.00	1.00
11/08/2021 08:00	6	1.6	17.5	14.8	44.7	620,057.4	0.00	1.00
11/08/2021 09:00	6	1.4	15.7	14.8	40.0	620,281.9	0.00	1.00
11/08/2021 10:00	6	1.4	15.5	14.8	39.0	615,792.0	0.00	1.00
11/08/2021 11:00	4	1.4	14.6	14.7	31.8	607,185.1	0.00	1.00
11/08/2021 12:00	4	1.5	14.2	14.7	31.0	606,964.2	0.00	1.00
11/08/2021 13:00	4	1.5	14.1	14.7	30.2	607,406.0	0.00	1.00
11/08/2021 14:00	4	1.5	13.9	14.7	30.1	606,743.4	0.00	1.00
11/08/2021 15:00	1	1.4	9.4	14.5	15.9	811,170.0	0.00	1.00
11/08/2021 16:00	1	1.7	7.9	14.3	17.9	952,994.9	0.00	1.00
11/08/2021 17:00	2	1.7	8.6	14.1	22.8	971,888.5	0.00	1.00
11/08/2021 18:00	2	1.7	8.5	14.1	23.2	970,680.2	0.00	1.00
11/08/2021 19:00	2	1.7	8.0	14.2	22.3	954,713.6	0.00	1.00
11/08/2021 20:00	2	1.7	6.9	14.4	19.7	930,365.9	0.00	1.00
11/08/2021 21:00	2	1.7	7.5	14.3	20.8	857,965.1	0.00	1.00
11/08/2021 22:00	3	1.8	8.6	14.4	20.8	764,349.5	0.00	1.00
11/08/2021 23:00	4	1.6	11.7	14.5	27.3	617,738.8	0.00	1.00
Average/Sum#:	3	1.6	11.1	14.5	27.2	774,481.3	0.00 #	24.00 #
Minimum:	1	1.4	6.9	14.1	15.9	606,743.4	0.00	1.00
Maximum:	6	2.1	17.5	14.8	44.7	973,134.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/09/2021 00:00	4	1.6	11.5	14.5	26.1	616,668.9	0.00	1.00
11/09/2021 01:00	4	1.6	11.6	14.5	26.5	615,385.1	0.00	1.00
11/09/2021 02:00	4	1.6	12.6	14.5	27.3	606,826.2	0.00	1.00
11/09/2021 03:00	4	1.6	14.2	14.7	33.9	611,602.6	0.00	1.00
11/09/2021 04:00	3	1.7	11.5	14.5	23.6	614,101.2	0.00	1.00
11/09/2021 05:00	3	1.5	10.3	14.4	22.7	653,952.8	0.00	1.00
11/09/2021 06:00	3	1.8	10.5	14.4	24.3	641,944.0	0.00	1.00
11/09/2021 07:00	3	1.9	11.0	14.5	26.3	754,467.2	0.00	1.00
11/09/2021 08:00	4	1.7	13.1	14.7	29.5	621,983.7	0.00	1.00
11/09/2021 09:00	5	1.6	14.2	14.7	32.7	612,707.0	0.00	1.00
11/09/2021 10:00	4	1.7	11.8	14.6	25.6	621,240.5	0.00	1.00
11/09/2021 11:00	5	1.7	13.6	14.7	32.2	619,112.3	0.00	1.00
11/09/2021 12:00	4	1.6	13.7	14.7	31.2	617,566.2	0.00	1.00
11/09/2021 13:00	4	1.6	13.5	14.7	30.2	618,670.6	0.00	1.00
11/09/2021 14:00	3	1.6	11.8	14.6	24.2	631,891.5	0.00	1.00
11/09/2021 15:00	3	1.6	10.5	14.5	22.3	697,978.5	0.00	1.00
11/09/2021 16:00	2	1.6	9.0	14.4	19.5	704,937.5	0.00	1.00
11/09/2021 17:00	2	1.7	7.1	14.3	16.1	802,980.7	0.00	1.00
11/09/2021 18:00	2	1.7	7.0	14.4	19.0	973,766.1	0.00	1.00
11/09/2021 19:00	2	1.7	6.9	14.4	19.5	953,330.1	0.00	1.00
11/09/2021 20:00	2	1.7	7.0	14.4	19.9	938,582.4	0.00	1.00
11/09/2021 21:00	3	1.8	9.7	14.4	23.8	698,827.8	0.00	1.00
11/09/2021 22:00	4	1.6	11.2	14.5	26.0	622,018.2	0.00	1.00
11/09/2021 23:00	4	1.7	12.1	14.6	28.6	623,848.9	0.00	1.00
Average/Sum#:	3	1.7	11.1	14.5	25.5	686,432.9	0.00 #	24.00 #
Minimum:	2	1.5	6.9	14.3	16.1	606,826.2	0.00	1.00
Maximum:	5	1.9	14.2	14.7	33.9	973,766.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/10/2021 00:00	5	1.7	13.6	14.7	32.4	618,228.8	0.00	1.00
11/10/2021 01:00	5	1.6	14.5	14.8	34.7	622,975.8	0.00	1.00
11/10/2021 02:00	5	1.6	15.3	14.8	35.2	623,200.3	0.00	1.00
11/10/2021 03:00	5	1.6	15.3	14.8	37.9	621,404.4	0.00	1.00
11/10/2021 04:00	5	1.6	15.0	14.8	36.1	621,404.4	0.00	1.00
11/10/2021 05:00	2	1.4	10.0	14.5	19.5	763,240.1	0.00	1.00
11/10/2021 06:00	2	1.7	8.1	14.3	16.8	792,398.7	0.00	1.00
11/10/2021 07:00	3	2.0	9.4	14.5	23.9	817,161.2	0.00	1.00
11/10/2021 08:00	5	1.6	15.0	14.8	36.2	620,730.9	0.00	1.00
11/10/2021 09:00	4	1.6	13.4	14.7	28.0	624,413.3	0.00	1.00
11/10/2021 10:00	3	1.7	12.4	14.6	26.1	621,892.6	0.00	1.00
11/10/2021 11:00	4	1.6	14.3	14.8	32.6	624,996.3	0.00	1.00
11/10/2021 12:00	4	1.6	14.5	14.8	32.9	623,200.3	0.00	1.00
11/10/2021 13:00	4	1.6	14.4	14.8	32.2	622,975.8	0.00	1.00
11/10/2021 14:00	4	1.6	14.0	14.7	30.4	612,044.3	0.00	1.00
11/10/2021 15:00	4	1.5	13.4	14.7	28.0	614,915.7	0.00	1.00
11/10/2021 16:00	2	1.6	11.4	14.6	20.7	620,153.6	0.00	1.00
11/10/2021 17:00	3	1.7	10.4	14.6	20.9	631,456.8	0.00	1.00
11/10/2021 18:00	3	1.6	11.2	14.5	24.6	620,306.5	0.00	1.00
11/10/2021 19:00	3	1.6	11.3	14.5	24.9	620,948.4	0.00	1.00
11/10/2021 20:00	3	1.6	11.2	14.5	25.0	624,585.9	0.00	1.00
11/10/2021 21:00	3	1.9	11.0	14.5	24.6	670,376.0	0.00	1.00
11/10/2021 22:00	3	1.7	11.2	14.5	24.8	625,013.8	0.00	1.00
11/10/2021 23:00	4	1.7	11.5	14.5	26.8	620,734.4	0.00	1.00
Average/Sum#:	4	1.6	12.6	14.6	28.1	644,948.3	0.00 #	24.00 #
Minimum:	2	1.4	8.1	14.3	16.8	612,044.3	0.00	1.00
Maximum:	5	2.0	15.3	14.8	37.9	817,161.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/11/2021 00:00	4	1.8	13.5	14.7	31.1	628,389.1	0.00	1.00
11/11/2021 01:00	4	1.6	12.0	14.5	26.9	620,734.4	0.00	1.00
11/11/2021 02:00	6	1.8	16.4	14.8	39.7	619,832.9	0.00	1.00
11/11/2021 03:00	5	1.8	15.8	14.8	37.7	622,975.8	0.00	1.00
11/11/2021 04:00	4	1.6	12.9	14.6	28.8	626,457.3	0.00	1.00
11/11/2021 05:00	4	1.6	13.0	14.5	30.8	623,302.1	0.00	1.00
11/11/2021 06:00	4	1.6	12.8	14.6	29.9	629,935.2	0.00	1.00
11/11/2021 07:00	5	1.7	13.4	14.6	31.7	628,196.3	0.00	1.00
11/11/2021 08:00	4	1.6	12.3	14.5	27.5	618,380.7	0.00	1.00
11/11/2021 09:00	4	1.6	12.7	14.5	28.8	620,520.4	0.00	1.00
11/11/2021 10:00	4	1.6	12.7	14.5	27.4	619,236.6	0.00	1.00
11/11/2021 11:00	5	1.6	15.0	14.8	36.0	624,771.8	0.00	1.00
11/11/2021 12:00	4	1.5	14.5	14.8	31.9	626,343.3	0.00	1.00
11/11/2021 13:00	3	1.6	12.7	14.7	26.3	619,112.3	0.00	1.00
11/11/2021 14:00	3	1.6	12.9	14.7	26.2	617,566.2	0.00	1.00
11/11/2021 15:00	2	1.4	10.2	14.6	19.4	691,015.9	0.00	1.00
11/11/2021 16:00	1	1.7	8.8	14.4	16.6	802,693.4	0.00	1.00
11/11/2021 17:00	2	1.7	8.5	14.2	21.3	990,073.4	0.00	1.00
11/11/2021 18:00	2	1.7	8.3	14.1	23.0	978,131.5	0.00	1.00
11/11/2021 19:00	2	1.7	8.2	14.1	24.0	980,749.5	0.00	1.00
11/11/2021 20:00	2	1.7	8.2	14.1	24.5	982,763.4	0.00	1.00
11/11/2021 21:00	2	1.7	8.2	14.1	24.4	984,173.1	0.00	1.00
11/11/2021 22:00	3	1.8	8.9	14.2	23.5	833,100.6	0.00	1.00
11/11/2021 23:00	3	1.6	10.7	14.5	24.7	641,489.7	0.00	1.00
Average/Sum#:	3	1.7	11.8	14.5	27.6	717,914.4	0.00 #	24.00 #
Minimum:	1	1.4	8.2	14.1	16.6	617,566.2	0.00	1.00
Maximum:	6	1.8	16.4	14.8	39.7	990,073.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/12/2021 00:00	5	1.7	13.7	14.7	33.3	618,891.5	0.00	1.00
11/12/2021 01:00	5	1.6	14.7	14.8	35.9	620,955.4	0.00	1.00
11/12/2021 02:00	5	1.5	16.1	14.8	38.6	620,281.9	0.00	1.00
11/12/2021 03:00	6	1.6	16.1	14.8	40.2	619,832.9	0.00	1.00
11/12/2021 04:00	6	1.5	15.9	14.8	39.5	623,424.8	0.00	1.00
11/12/2021 05:00	3	1.6	12.5	14.5	26.4	620,520.4	0.00	1.00
11/12/2021 06:00	4	1.6	12.0	14.5	27.5	621,590.3	0.00	1.00
11/12/2021 07:00	5	1.8	15.2	14.7	37.4	620,658.5	0.00	1.00
11/12/2021 08:00	5	1.7	14.8	14.7	34.9	620,658.5	0.00	1.00
11/12/2021 09:00	5	1.5	14.9	14.8	34.8	621,853.4	0.00	1.00
11/12/2021 10:00	4	1.6	14.7	14.8	33.0	622,751.4	0.00	1.00
11/12/2021 11:00	4	1.6	14.5	14.8	31.9	623,424.8	0.00	1.00
11/12/2021 12:00	4	1.6	14.5	14.8	32.9	622,526.9	0.00	1.00
11/12/2021 13:00	4	1.6	14.2	14.8	31.4	622,302.4	0.00	1.00
11/12/2021 14:00	3	1.5	13.4	14.7	27.9	620,437.6	0.00	1.00
11/12/2021 15:00	2	1.6	10.9	14.5	21.1	657,109.7	0.00	1.00
11/12/2021 16:00	3	1.8	12.0	14.6	24.4	621,240.5	0.00	1.00
11/12/2021 17:00	4	1.7	11.4	14.5	25.4	616,027.0	0.00	1.00
11/12/2021 18:00	5	1.7	14.1	14.8	34.4	623,424.8	0.00	1.00
11/12/2021 19:00	3	1.6	10.9	14.5	22.4	620,092.5	0.00	1.00
11/12/2021 20:00	3	1.6	11.0	14.5	24.5	622,660.1	0.00	1.00
11/12/2021 21:00	3	1.7	9.7	14.4	20.1	684,712.2	0.00	1.00
11/12/2021 22:00	5	1.8	12.7	14.6	30.7	618,197.3	0.00	1.00
11/12/2021 23:00	5	1.7	14.6	14.8	35.7	622,751.4	0.00	1.00
Average/Sum#:	4	1.6	13.5	14.7	31.0	625,263.6	0.00 #	24.00 #
Minimum:	2	1.5	9.7	14.4	20.1	616,027.0	0.00	1.00
Maximum:	6	1.8	16.1	14.8	40.2	684,712.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/13/2021 00:00	5	1.7	14.1	14.7	32.7	618,228.8	0.00	1.00
11/13/2021 01:00	5	1.6	14.4	14.7	34.4	616,461.8	0.00	1.00
11/13/2021 02:00	3	1.7	11.9	14.5	22.7	621,162.3	0.00	1.00
11/13/2021 03:00	4	1.6	11.6	14.5	26.5	622,232.2	0.00	1.00
11/13/2021 04:00	3	1.7	11.0	14.4	24.8	647,632.4	0.00	1.00
11/13/2021 05:00	2	1.5	8.9	14.4	19.3	759,082.5	0.00	1.00
11/13/2021 06:00	2	1.7	7.2	14.4	19.8	981,139.9	0.00	1.00
11/13/2021 07:00	2	1.7	7.2	14.3	21.1	965,859.2	0.00	1.00
11/13/2021 08:00	2	1.7	7.2	14.3	21.7	964,821.7	0.00	1.00
11/13/2021 09:00	2	1.7	7.1	14.4	21.5	980,297.2	0.00	1.00
11/13/2021 10:00	3	1.8	9.0	14.4	23.7	789,420.5	0.00	1.00
11/13/2021 11:00	3	1.7	12.0	14.6	25.9	655,802.1	0.00	1.00
11/13/2021 12:00	4	1.5	13.5	14.7	28.4	626,401.2	0.00	1.00
11/13/2021 13:00	4	1.7	13.8	14.7	31.3	619,112.3	0.00	1.00
11/13/2021 14:00	4	1.6	13.5	14.7	30.3	616,241.0	0.00	1.00
11/13/2021 15:00	2	1.5	10.7	14.5	19.3	650,476.6	0.00	1.00
11/13/2021 16:00	1	1.6	7.0	14.4	13.0	935,422.2	0.00	1.00
11/13/2021 17:00	3	1.8	9.2	14.3	21.3	667,075.7	0.00	1.00
11/13/2021 18:00	3	1.7	9.2	14.4	20.7	684,501.5	0.00	1.00
11/13/2021 19:00	2	1.6	6.9	14.3	16.6	845,723.3	0.00	1.00
11/13/2021 20:00	2	1.7	7.5	14.3	20.3	819,579.7	0.00	1.00
11/13/2021 21:00	4	1.9	10.4	14.4	24.5	656,481.0	0.00	1.00
11/13/2021 22:00	4	1.6	11.3	14.5	26.0	624,371.9	0.00	1.00
11/13/2021 23:00	5	1.7	13.8	14.7	33.9	618,449.7	0.00	1.00
Average/Sum#:	3	1.7	10.4	14.5	24.2	732,749.0	0.00 #	24.00 #
Minimum:	1	1.5	6.9	14.3	13.0	616,241.0	0.00	1.00
Maximum:	5	1.9	14.4	14.7	34.4	981,139.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/14/2021 00:00	5	1.6	14.9	14.8	37.2	621,853.4	0.00	1.00
11/14/2021 01:00	5	1.6	14.9	14.8	36.8	621,628.9	0.00	1.00
11/14/2021 02:00	5	1.5	15.6	14.8	36.9	620,955.4	0.00	1.00
11/14/2021 03:00	5	1.6	15.4	14.8	37.9	620,730.9	0.00	1.00
11/14/2021 04:00	5	1.6	15.1	14.8	36.8	622,526.9	0.00	1.00
11/14/2021 05:00	5	1.6	15.0	14.8	36.7	620,730.9	0.00	1.00
11/14/2021 06:00	5	1.6	14.8	14.8	35.9	624,098.3	0.00	1.00
11/14/2021 07:00	4	1.7	14.1	14.7	32.2	620,216.7	0.00	1.00
11/14/2021 08:00	5	1.6	14.8	14.7	35.8	616,903.6	0.00	1.00
11/14/2021 09:00	5	1.6	14.7	14.8	34.9	624,996.3	0.00	1.00
11/14/2021 10:00	5	1.6	14.7	14.8	34.3	624,996.3	0.00	1.00
11/14/2021 11:00	5	1.6	14.6	14.8	33.8	624,996.3	0.00	1.00
11/14/2021 12:00	4	1.6	14.5	14.8	32.8	624,996.3	0.00	1.00
11/14/2021 13:00	5	1.6	14.4	14.7	32.9	613,811.3	0.00	1.00
11/14/2021 14:00	5	1.6	14.4	14.8	33.4	621,179.9	0.00	1.00
11/14/2021 15:00	3	1.4	12.1	14.6	25.0	654,715.3	0.00	1.00
11/14/2021 16:00	4	1.7	13.2	14.7	29.9	618,228.8	0.00	1.00
11/14/2021 17:00	5	1.7	13.7	14.7	32.3	617,787.1	0.00	1.00
11/14/2021 18:00	5	1.6	14.1	14.7	32.9	615,578.3	0.00	1.00
11/14/2021 19:00	4	1.7	13.1	14.7	28.7	625,076.0	0.00	1.00
11/14/2021 20:00	3	1.7	11.3	14.5	24.2	634,000.7	0.00	1.00
11/14/2021 21:00	4	1.7	12.2	14.5	27.8	618,594.7	0.00	1.00
11/14/2021 22:00	5	1.8	13.8	14.7	32.1	621,983.7	0.00	1.00
11/14/2021 23:00	6	1.6	15.3	14.8	38.3	621,628.9	0.00	1.00
Average/Sum#:	5	1.6	14.2	14.7	33.3	623,009.0	0.00 #	24.00 #
Minimum:	3	1.4	11.3	14.5	24.2	613,811.3	0.00	1.00
Maximum:	6	1.8	15.6	14.8	38.3	654,715.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/15/2021 00:00	5	1.6	15.0	14.8	36.3	622,077.9	0.00	1.00
11/15/2021 01:00	5	1.6	15.1	14.8	36.7	620,730.9	0.00	1.00
11/15/2021 02:00	5	1.6	15.5	14.8	35.5	621,628.9	0.00	1.00
11/15/2021 03:00	5	1.6	15.2	14.7	36.6	612,707.0	0.00	1.00
11/15/2021 04:00	4	1.6	14.0	14.7	32.0	619,333.2	0.00	1.00
11/15/2021 05:00	3	1.7	11.8	14.5	24.4	617,952.8	0.00	1.00
11/15/2021 06:00	3	1.7	10.0	14.4	21.3	670,175.2	0.00	1.00
11/15/2021 07:00	3	1.8	10.5	14.5	23.8	692,415.2	0.00	1.00
11/15/2021 08:00	4	1.7	13.2	14.7	29.9	624,413.3	0.00	1.00
11/15/2021 09:00	3	1.6	11.3	14.5	23.4	621,804.3	0.00	1.00
11/15/2021 10:00	4	1.6	11.5	14.5	25.3	621,376.3	0.00	1.00
11/15/2021 11:00	4	1.7	12.4	14.6	27.8	620,371.0	0.00	1.00
11/15/2021 12:00	5	1.6	14.8	14.8	36.7	619,383.9	0.00	1.00
11/15/2021 13:00	4	1.6	12.9	14.7	27.9	625,296.8	0.00	1.00
11/15/2021 14:00	2	1.5	9.1	14.4	18.1	746,230.9	0.00	1.00
11/15/2021 15:00	2	1.6	9.2	14.4	18.8	712,311.4	0.00	1.00
11/15/2021 16:00	2	1.7	9.5	14.4	18.5	646,579.0	0.00	1.00
11/15/2021 17:00	4	1.7	11.5	14.5	26.0	618,380.7	0.00	1.00
11/15/2021 18:00	3	1.6	11.0	14.5	24.6	624,585.9	0.00	1.00
11/15/2021 19:00	2	1.7	7.7	14.3	16.2	762,105.4	0.00	1.00
11/15/2021 20:00	3	1.6	10.7	14.5	23.9	621,804.3	0.00	1.00
11/15/2021 21:00	3	1.7	9.7	14.4	21.1	662,169.4	0.00	1.00
11/15/2021 22:00	4	1.7	11.9	14.5	27.5	614,529.2	0.00	1.00
11/15/2021 23:00	5	1.7	14.5	14.7	35.6	610,277.4	0.00	1.00
Average/Sum#:	4	1.6	12.0	14.6	27.0	642,860.0	0.00 #	24.00 #
Minimum:	2	1.5	7.7	14.3	16.2	610,277.4	0.00	1.00
Maximum:	5	1.8	15.5	14.8	36.7	762,105.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/16/2021 00:00	3	1.6	11.2	14.5	21.5	617,952.8	0.00	1.00
11/16/2021 01:00	3	1.6	11.1	14.5	23.6	620,948.4	0.00	1.00
11/16/2021 02:00	5	1.8	13.7	14.7	30.7	622,425.5	0.00	1.00
11/16/2021 03:00	5	1.6	14.5	14.8	33.7	623,424.8	0.00	1.00
11/16/2021 04:00	3	1.6	11.9	14.6	23.7	625,805.2	0.00	1.00
11/16/2021 05:00	1	1.5	8.1	14.4	16.3	823,761.4	0.00	1.00
11/16/2021 06:00	1	1.7	7.3	14.4	18.5	983,246.7	0.00	1.00
11/16/2021 07:00	2	1.7	7.3	14.4	20.1	983,878.7	0.00	1.00
11/16/2021 08:00	3	1.8	9.0	14.4	23.0	813,016.7	0.00	1.00
11/16/2021 09:00	3	1.3	9.3	14.4	22.3	739,489.2	0.00	1.00
11/16/2021 10:00	5	1.7	12.9	14.6	32.1	618,632.0	0.00	1.00
11/16/2021 11:00	4	1.6	13.4	14.6	31.4	615,806.2	0.00	1.00
11/16/2021 12:00	4	1.5	13.9	14.7	32.1	617,787.1	0.00	1.00
11/16/2021 13:00	4	1.6	13.3	14.7	29.3	618,449.7	0.00	1.00
11/16/2021 14:00	4	1.6	13.1	14.7	29.1	617,345.3	0.00	1.00
11/16/2021 15:00	3	1.5	10.9	14.5	21.4	656,895.8	0.00	1.00
11/16/2021 16:00	3	1.7	10.2	14.5	21.0	621,376.3	0.00	1.00
11/16/2021 17:00	2	1.5	8.0	14.4	15.6	758,871.8	0.00	1.00
11/16/2021 18:00	2	1.8	7.2	14.3	16.2	802,565.7	0.00	1.00
11/16/2021 19:00	3	1.6	8.9	14.3	21.9	697,784.0	0.00	1.00
11/16/2021 20:00	2	1.7	7.1	14.3	18.9	901,330.2	0.00	1.00
11/16/2021 21:00	2	1.7	7.4	14.3	20.4	915,439.5	0.00	1.00
11/16/2021 22:00	2	1.8	8.4	14.3	22.0	826,841.8	0.00	1.00
11/16/2021 23:00	2	1.6	7.9	14.2	17.7	727,634.4	0.00	1.00
Average/Sum#:	3	1.6	10.3	14.5	23.4	727,112.9	0.00 #	24.00 #
Minimum:	1	1.3	7.1	14.2	15.6	615,806.2	0.00	1.00
Maximum:	5	1.8	14.5	14.8	33.7	983,878.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/17/2021 00:00	2	1.7	8.0	14.2	24.4	965,750.8	0.00	1.00
11/17/2021 01:00	3	1.9	9.3	14.2	25.2	838,823.5	0.00	1.00
11/17/2021 02:00	4	1.6	12.5	14.5	28.6	620,092.5	0.00	1.00
11/17/2021 03:00	4	1.7	12.1	14.5	28.0	623,302.1	0.00	1.00
11/17/2021 04:00	3	1.5	9.4	14.4	20.9	743,702.8	0.00	1.00
11/17/2021 05:00	3	1.8	9.5	14.4	22.2	749,391.2	0.00	1.00
11/17/2021 06:00	2	1.7	7.4	14.3	20.0	932,246.0	0.00	1.00
11/17/2021 07:00	3	1.9	9.3	14.4	24.2	794,266.1	0.00	1.00
11/17/2021 08:00	4	1.6	12.2	14.5	29.9	616,027.0	0.00	1.00
11/17/2021 09:00	4	1.6	11.6	14.5	25.6	620,092.5	0.00	1.00
11/17/2021 10:00	4	1.6	12.0	14.5	28.0	617,310.8	0.00	1.00
11/17/2021 11:00	5	1.6	14.3	14.7	35.6	615,578.3	0.00	1.00
11/17/2021 12:00	5	1.4	14.7	14.8	36.7	622,526.9	0.00	1.00
11/17/2021 13:00	5	1.4	14.9	14.8	37.4	620,955.4	0.00	1.00
11/17/2021 14:00	5	1.4	14.8	14.8	36.8	621,404.4	0.00	1.00
11/17/2021 15:00	3	1.2	10.8	14.6	22.3	728,838.1	0.00	1.00
11/17/2021 16:00	2	1.6	8.7	14.4	19.5	801,218.6	0.00	1.00
11/17/2021 17:00	2	1.5	7.1	14.3	20.2	910,044.7	0.00	1.00
11/17/2021 18:00	2	1.4	7.3	14.4	22.3	965,760.2	0.00	1.00
11/17/2021 19:00	2	1.4	7.3	14.4	23.1	967,867.0	0.00	1.00
11/17/2021 20:00	2	1.5	7.3	14.3	23.4	938,263.2	0.00	1.00
11/17/2021 21:00	2	1.5	7.7	14.3	22.1	859,625.0	0.00	1.00
11/17/2021 22:00	4	1.7	11.7	14.4	29.1	634,359.5	0.00	1.00
11/17/2021 23:00	5	1.4	12.7	14.5	31.2	623,088.1	0.00	1.00
Average/Sum#:	3	1.6	10.5	14.5	26.5	751,272.3	0.00 #	24.00 #
Minimum:	2	1.2	7.1	14.2	19.5	615,578.3	0.00	1.00
Maximum:	5	1.9	14.9	14.8	37.4	967,867.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/18/2021 00:00	5	1.4	12.8	14.5	31.2	621,376.3	0.00	1.00
11/18/2021 01:00	5	1.4	12.8	14.5	31.3	622,018.2	0.00	1.00
11/18/2021 02:00	4	1.5	13.3	14.5	29.6	622,018.2	0.00	1.00
11/18/2021 03:00	4	1.7	12.9	14.5	30.0	621,590.3	0.00	1.00
11/18/2021 04:00	4	1.6	12.7	14.5	29.1	620,734.4	0.00	1.00
11/18/2021 05:00	3	1.5	10.6	14.4	23.6	700,091.9	0.00	1.00
11/18/2021 06:00	2	1.7	7.2	14.3	18.9	917,929.3	0.00	1.00
11/18/2021 07:00	3	1.8	8.3	14.3	22.9	842,818.5	0.00	1.00
11/18/2021 08:00	3	1.6	8.7	14.3	23.3	760,030.5	0.00	1.00
11/18/2021 09:00	5	1.6	13.0	14.5	32.6	624,371.9	0.00	1.00
11/18/2021 10:00	6	1.4	14.9	14.7	38.0	616,903.6	0.00	1.00
11/18/2021 11:00	5	1.2	14.1	14.7	33.4	619,112.3	0.00	1.00
11/18/2021 12:00	5	1.3	13.7	14.7	32.7	618,449.7	0.00	1.00
11/18/2021 13:00	3	1.4	11.4	14.5	22.5	631,647.0	0.00	1.00
11/18/2021 14:00	2	1.5	9.8	14.4	18.4	658,166.4	0.00	1.00
11/18/2021 15:00	2	1.4	7.7	14.4	18.2	870,953.9	0.00	1.00
11/18/2021 16:00	2	1.4	7.1	14.3	20.8	908,799.8	0.00	1.00
11/18/2021 17:00	2	1.3	7.0	14.3	21.9	917,721.8	0.00	1.00
11/18/2021 18:00	1	1.5	7.4	14.4	19.8	986,828.3	0.00	1.00
11/18/2021 19:00	2	1.7	7.2	14.4	19.4	958,597.1	0.00	1.00
11/18/2021 20:00	3	1.8	8.4	14.3	21.8	801,735.7	0.00	1.00
11/18/2021 21:00	3	1.4	7.8	14.2	20.3	713,940.2	0.00	1.00
11/18/2021 22:00	3	1.7	9.9	14.4	24.2	681,341.3	0.00	1.00
11/18/2021 23:00	3	1.5	10.1	14.4	23.3	655,638.3	0.00	1.00
Average/Sum#:	3	1.5	10.4	14.4	25.3	733,034.0	0.00 #	24.00 #
Minimum:	1	1.2	7.0	14.2	18.2	616,903.6	0.00	1.00
Maximum:	6	1.8	14.9	14.7	38.0	986,828.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/19/2021 00:00	5	3.8	20.0	15.3	21.1	578,092.7	0.13	0.30
11/19/2021 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2021 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2021 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2021 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2021 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2021 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
11/19/2021 07:00	0	0.7	3.5	20.4	0.0	766,877.7	0.08	0.08
11/19/2021 08:00	6	6.1	16.0	14.9	18.4	663,029.6	0.67	1.00
11/19/2021 09:00	5	1.4	14.9	14.7	36.9	617,787.1	0.00	1.00
11/19/2021 10:00	5	1.3	14.1	14.7	33.1	620,658.5	0.00	1.00
11/19/2021 11:00	4	1.4	13.1	14.6	26.5	616,458.3	0.00	1.00
11/19/2021 12:00	3	1.3	11.0	14.5	23.5	634,214.7	0.00	1.00
11/19/2021 13:00	1	1.2	7.3	14.4	15.7	888,440.4	0.00	1.00
11/19/2021 14:00	2	1.3	8.1	14.4	19.6	846,093.6	0.00	1.00
11/19/2021 15:00	3	1.4	9.2	14.4	21.2	718,842.5	0.00	1.00
11/19/2021 16:00	4	1.5	11.3	14.5	27.0	629,507.3	0.00	1.00
11/19/2021 17:00	3	1.4	10.0	14.4	22.4	667,857.7	0.00	1.00
11/19/2021 18:00	4	1.4	11.2	14.4	27.5	637,309.0	0.00	1.00
11/19/2021 19:00	4	1.3	12.1	14.5	29.0	624,585.9	0.00	1.00
11/19/2021 20:00	3	1.4	9.4	14.3	21.0	700,896.3	0.00	1.00
11/19/2021 21:00	3	1.4	10.0	14.4	23.6	680,498.6	0.00	1.00
11/19/2021 22:00	3	1.5	10.6	14.4	25.6	688,293.8	0.00	1.00
11/19/2021 23:00	6	1.5	15.0	14.7	38.1	620,658.5	0.00	1.00
Average/Sum#:	4	1.7	11.5	14.9	23.9	677,783.5	0.88 #	16.38 #
Minimum:	1	0.7	3.5	14.3	0.0	578,092.7	0.00	0.00
Maximum:	6	6.1	20.0	20.4	38.1	888,440.4	0.67	1.00
%SI	29.17	25.00	25.00	25.00	25.00	25.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOX, Ppm	Unit CT1 NOX, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/20/2021 00:00	6	1.4	16.0	14.8	40.8	621,628.9	0.00	1.00
11/20/2021 01:00	6	1.4	15.6	14.8	40.0	625,445.3	0.00	1.00
11/20/2021 02:00	6	1.3	16.5	14.8	41.9	625,669.8	0.00	1.00
11/20/2021 03:00	6	1.4	16.1	14.8	41.4	627,465.8	0.00	1.00
11/20/2021 04:00	5	1.3	13.3	14.5	32.1	623,516.0	0.00	1.00
11/20/2021 05:00	6	1.5	16.1	14.7	40.5	623,750.7	0.00	1.00
11/20/2021 06:00	4	1.6	13.4	14.5	28.5	632,074.9	0.00	1.00
11/20/2021 07:00	3	1.9	11.4	14.5	24.9	760,244.5	0.00	1.00
11/20/2021 08:00	6	1.7	17.0	14.9	43.4	630,619.9	0.00	1.00
11/20/2021 09:00	6	1.6	17.5	14.9	45.2	629,022.3	0.00	1.00
11/20/2021 10:00	6	1.5	16.7	14.8	42.8	619,608.4	0.00	1.00
11/20/2021 11:00	6	1.4	16.2	14.8	41.1	618,710.4	0.00	1.00
11/20/2021 12:00	5	1.4	15.6	14.8	38.2	618,710.4	0.00	1.00
11/20/2021 13:00	5	1.3	15.3	14.8	36.4	618,036.9	0.00	1.00
11/20/2021 14:00	5	1.4	14.8	14.8	33.9	618,710.4	0.00	1.00
11/20/2021 15:00	2	1.2	10.9	14.6	21.4	718,839.1	0.00	1.00
11/20/2021 16:00	2	1.4	10.3	14.6	20.0	721,012.8	0.00	1.00
11/20/2021 17:00	3	1.5	11.8	14.5	25.1	639,136.0	0.00	1.00
11/20/2021 18:00	4	1.4	12.6	14.6	28.7	626,892.1	0.00	1.00
11/20/2021 19:00	3	1.3	10.8	14.4	23.0	670,807.3	0.00	1.00
11/20/2021 20:00	3	1.5	9.4	14.3	21.2	707,328.4	0.00	1.00
11/20/2021 21:00	2	1.5	7.3	14.3	18.0	894,068.1	0.00	1.00
11/20/2021 22:00	3	1.7	10.0	14.4	25.6	776,569.0	0.00	1.00
11/20/2021 23:00	5	1.6	14.3	14.6	35.3	629,500.5	0.00	1.00
Average/Sum#:	5	1.5	13.7	14.6	32.9	661,557.0	0.00 #	24.00 #
Minimum:	2	1.2	7.3	14.3	18.0	618,036.9	0.00	1.00
Maximum:	6	1.9	17.5	14.9	45.2	894,068.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/21/2021 00:00	3	1.7	10.6	14.4	24.4	723,688.1	0.00	1.00
11/21/2021 01:00	5	1.6	13.6	14.5	34.0	623,730.0	0.00	1.00
11/21/2021 02:00	6	1.6	17.6	14.8	46.2	628,363.7	0.00	1.00
11/21/2021 03:00	5	1.6	14.3	14.5	31.9	622,018.2	0.00	1.00
11/21/2021 04:00	5	1.4	14.2	14.5	35.7	622,446.2	0.00	1.00
11/21/2021 05:00	1	1.4	7.9	14.3	18.0	871,244.4	0.00	1.00
11/21/2021 06:00	2	1.5	7.8	14.3	21.9	891,993.2	0.00	1.00
11/21/2021 07:00	2	1.5	7.8	14.3	22.9	894,068.1	0.00	1.00
11/21/2021 08:00	2	1.4	7.6	14.4	24.0	956,068.9	0.00	1.00
11/21/2021 09:00	3	1.7	10.0	14.4	25.9	777,833.1	0.00	1.00
11/21/2021 10:00	2	1.4	8.2	14.3	18.5	765,840.2	0.00	1.00
11/21/2021 11:00	3	1.6	10.8	14.5	25.1	681,288.6	0.00	1.00
11/21/2021 12:00	5	1.4	15.0	14.8	36.7	624,547.3	0.00	1.00
11/21/2021 13:00	5	1.3	15.3	14.8	36.1	623,200.3	0.00	1.00
11/21/2021 14:00	4	1.4	14.8	14.8	33.6	622,975.8	0.00	1.00
11/21/2021 15:00	2	1.2	11.0	14.6	22.4	777,311.4	0.00	1.00
11/21/2021 16:00	2	1.5	9.4	14.4	18.3	712,311.4	0.00	1.00
11/21/2021 17:00	4	1.6	12.0	14.6	27.6	627,326.8	0.00	1.00
11/21/2021 18:00	4	1.4	12.8	14.6	30.7	627,544.2	0.00	1.00
11/21/2021 19:00	2	1.3	9.8	14.5	21.8	766,235.7	0.00	1.00
11/21/2021 20:00	2	1.5	7.5	14.4	20.8	973,134.0	0.00	1.00
11/21/2021 21:00	3	1.7	9.1	14.4	25.0	807,539.0	0.00	1.00
11/21/2021 22:00	3	1.6	8.7	14.3	22.4	773,309.8	0.00	1.00
11/21/2021 23:00	5	1.6	13.3	14.5	33.6	620,948.4	0.00	1.00
Average/Sum#:	3	1.5	11.2	14.5	27.4	733,957.0	0.00 #	24.00 #
Minimum:	1	1.2	7.5	14.3	18.0	620,948.4	0.00	1.00
Maximum:	6	1.7	17.6	14.8	46.2	973,134.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/22/2021 00:00	5	1.4	13.1	14.5	32.4	624,158.0	0.00	1.00
11/22/2021 01:00	5	1.4	13.5	14.5	33.5	624,371.9	0.00	1.00
11/22/2021 02:00	5	1.4	14.2	14.5	33.6	623,088.1	0.00	1.00
11/22/2021 03:00	5	1.5	14.2	14.5	35.2	623,944.0	0.00	1.00
11/22/2021 04:00	5	1.4	14.1	14.5	34.6	623,088.1	0.00	1.00
11/22/2021 05:00	5	1.4	13.7	14.5	33.8	628,223.4	0.00	1.00
11/22/2021 06:00	3	1.3	11.2	14.4	25.9	732,115.3	0.00	1.00
11/22/2021 07:00	4	1.9	12.1	14.5	29.4	745,052.5	0.00	1.00
11/22/2021 08:00	5	1.8	14.7	14.6	34.1	633,195.8	0.00	1.00
11/22/2021 09:00	6	1.6	15.9	14.8	40.6	628,588.2	0.00	1.00
11/22/2021 10:00	5	1.4	15.8	14.8	39.2	623,649.3	0.00	1.00
11/22/2021 11:00	5	1.4	14.7	14.8	33.8	623,649.3	0.00	1.00
11/22/2021 12:00	3	1.3	12.8	14.6	25.9	621,457.8	0.00	1.00
11/22/2021 13:00	3	1.4	11.5	14.6	23.5	631,239.4	0.00	1.00
11/22/2021 14:00	1	1.3	8.9	14.5	17.0	834,707.0	0.00	1.00
11/22/2021 15:00	1	1.5	7.6	14.4	17.6	986,617.6	0.00	1.00
11/22/2021 16:00	2	1.5	8.2	14.3	18.5	795,303.6	0.00	1.00
11/22/2021 17:00	4	1.6	10.7	14.4	25.6	659,851.9	0.00	1.00
11/22/2021 18:00	2	1.4	6.8	14.3	17.8	891,785.8	0.00	1.00
11/22/2021 19:00	2	1.5	7.1	14.3	20.8	884,316.2	0.00	1.00
11/22/2021 20:00	2	1.5	7.5	14.3	22.0	898,217.9	0.00	1.00
11/22/2021 21:00	2	1.5	7.4	14.3	22.1	890,748.3	0.00	1.00
11/22/2021 22:00	2	1.5	7.6	14.3	22.9	900,292.8	0.00	1.00
11/22/2021 23:00	4	1.7	10.6	14.4	28.0	751,708.6	0.00	1.00
Average/Sum#:	4	1.5	11.4	14.5	27.8	728,307.1	0.00 #	24.00 #
Minimum:	1	1.3	6.8	14.3	17.0	621,457.8	0.00	1.00
Maximum:	6	1.9	15.9	14.8	40.6	986,617.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/23/2021 00:00	5	1.5	13.8	14.5	34.4	619,878.5	0.00	1.00
11/23/2021 01:00	4	1.4	12.7	14.5	29.1	624,799.9	0.00	1.00
11/23/2021 02:00	4	1.4	13.0	14.5	28.9	626,511.7	0.00	1.00
11/23/2021 03:00	5	1.5	13.5	14.5	32.3	619,450.6	0.00	1.00
11/23/2021 04:00	5	1.5	15.3	14.7	36.7	620,879.3	0.00	1.00
11/23/2021 05:00	6	1.5	15.7	14.8	39.1	629,037.2	0.00	1.00
11/23/2021 06:00	4	1.4	14.1	14.6	33.2	631,674.2	0.00	1.00
11/23/2021 07:00	4	1.8	12.4	14.5	28.9	719,589.7	0.00	1.00
11/23/2021 08:00	6	1.7	16.5	14.8	41.4	631,731.2	0.00	1.00
11/23/2021 09:00	6	1.5	16.6	14.8	42.1	622,077.9	0.00	1.00
11/23/2021 10:00	6	1.3	15.8	14.8	39.4	620,955.4	0.00	1.00
11/23/2021 11:00	5	1.4	15.1	14.8	35.8	620,730.9	0.00	1.00
11/23/2021 12:00	5	1.4	14.6	14.8	33.7	620,955.4	0.00	1.00
11/23/2021 13:00	4	1.4	14.1	14.7	31.5	610,719.1	0.00	1.00
11/23/2021 14:00	4	1.4	14.0	14.7	31.2	611,602.6	0.00	1.00
11/23/2021 15:00	3	1.2	11.4	14.5	23.4	680,218.8	0.00	1.00
11/23/2021 16:00	3	1.5	10.7	14.5	21.8	666,952.5	0.00	1.00
11/23/2021 17:00	4	1.5	12.0	14.5	26.3	621,804.3	0.00	1.00
11/23/2021 18:00	4	1.4	12.4	14.5	27.7	621,162.3	0.00	1.00
11/23/2021 19:00	4	1.4	13.0	14.5	30.4	621,590.3	0.00	1.00
11/23/2021 20:00	5	1.5	15.1	14.7	37.0	625,738.6	0.00	1.00
11/23/2021 21:00	5	1.5	14.6	14.6	34.8	622,109.9	0.00	1.00
11/23/2021 22:00	5	1.4	13.8	14.5	32.6	621,376.3	0.00	1.00
11/23/2021 23:00	6	1.6	16.3	14.7	41.4	624,634.2	0.00	1.00
Average/Sum#:	5	1.5	14.0	14.6	33.0	630,674.2	0.00 #	24.00 #
Minimum:	3	1.2	10.7	14.5	21.8	610,719.1	0.00	1.00
Maximum:	6	1.8	16.6	14.8	42.1	719,589.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/24/2021 00:00	4	1.5	13.9	14.5	30.2	622,874.1	0.00	1.00
11/24/2021 01:00	5	1.6	14.3	14.5	33.4	622,232.2	0.00	1.00
11/24/2021 02:00	6	1.9	18.4	14.8	46.4	627,016.8	0.00	1.00
11/24/2021 03:00	6	1.6	17.9	14.8	43.2	626,792.3	0.00	1.00
11/24/2021 04:00	5	1.6	17.1	14.8	40.7	633,302.7	0.00	1.00
11/24/2021 05:00	5	1.7	16.8	14.7	39.1	629,051.7	0.00	1.00
11/24/2021 06:00	4	1.7	13.7	14.5	30.7	666,738.5	0.00	1.00
11/24/2021 07:00	4	1.9	12.4	14.5	30.1	743,340.7	0.00	1.00
11/24/2021 08:00	5	1.6	14.6	14.6	34.6	627,761.5	0.00	1.00
11/24/2021 09:00	4	1.6	13.2	14.5	30.3	639,991.9	0.00	1.00
11/24/2021 10:00	4	1.7	14.1	14.6	31.1	628,196.3	0.00	1.00
11/24/2021 11:00	4	1.6	13.8	14.6	29.3	627,326.8	0.00	1.00
11/24/2021 12:00	3	1.6	13.0	14.6	26.3	627,109.4	0.00	1.00
11/24/2021 13:00	3	1.6	13.0	14.6	26.9	626,457.3	0.00	1.00
11/24/2021 14:00	3	1.6	13.2	14.6	25.7	627,978.9	0.00	1.00
11/24/2021 15:00	2	1.5	10.9	14.5	20.8	699,476.3	0.00	1.00
11/24/2021 16:00	2	1.6	10.6	14.5	19.3	697,122.6	0.00	1.00
11/24/2021 17:00	4	1.7	12.5	14.6	27.2	632,543.6	0.00	1.00
11/24/2021 18:00	3	1.6	12.5	14.6	26.2	631,674.2	0.00	1.00
11/24/2021 19:00	4	1.6	12.6	14.5	27.7	626,083.7	0.00	1.00
11/24/2021 20:00	4	1.6	12.6	14.5	28.0	635,070.6	0.00	1.00
11/24/2021 21:00	3	1.7	11.6	14.4	24.8	650,160.6	0.00	1.00
11/24/2021 22:00	4	1.6	13.1	14.5	29.5	621,376.3	0.00	1.00
11/24/2021 23:00	4	1.6	13.2	14.6	30.4	631,891.5	0.00	1.00
Average/Sum#:	4	1.6	13.7	14.6	30.5	641,732.1	0.00 #	24.00 #
Minimum:	2	1.5	10.6	14.4	19.3	621,376.3	0.00	1.00
Maximum:	6	1.9	18.4	14.8	46.4	743,340.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/25/2021 00:00	5	1.6	13.5	14.6	32.4	631,456.8	0.00	1.00
11/25/2021 01:00	5	1.6	13.9	14.6	32.9	631,674.2	0.00	1.00
11/25/2021 02:00	4	1.6	14.4	14.6	32.8	631,456.8	0.00	1.00
11/25/2021 03:00	5	1.6	13.8	14.6	32.5	631,891.5	0.00	1.00
11/25/2021 04:00	5	1.6	13.7	14.6	32.7	631,456.8	0.00	1.00
11/25/2021 05:00	5	1.6	13.9	14.6	33.4	630,804.7	0.00	1.00
11/25/2021 06:00	4	1.6	13.7	14.6	32.7	640,586.3	0.00	1.00
11/25/2021 07:00	3	1.8	11.6	14.4	26.8	707,044.3	0.00	1.00
11/25/2021 08:00	4	1.8	13.3	14.5	31.1	641,703.7	0.00	1.00
11/25/2021 09:00	5	1.6	14.5	14.6	33.7	627,761.5	0.00	1.00
11/25/2021 10:00	4	1.6	13.4	14.6	28.7	629,717.8	0.00	1.00
11/25/2021 11:00	3	1.6	12.3	14.6	25.2	640,151.6	0.00	1.00
11/25/2021 12:00	3	1.6	12.6	14.6	26.3	627,326.8	0.00	1.00
11/25/2021 13:00	3	1.6	12.5	14.6	25.5	627,544.2	0.00	1.00
11/25/2021 14:00	3	1.6	12.4	14.6	25.5	627,109.4	0.00	1.00
11/25/2021 15:00	3	1.5	11.6	14.5	23.7	640,205.9	0.00	1.00
11/25/2021 16:00	3	1.6	11.4	14.5	22.7	639,991.9	0.00	1.00
11/25/2021 17:00	4	1.7	12.6	14.6	28.1	626,239.9	0.00	1.00
11/25/2021 18:00	4	1.6	12.7	14.6	27.9	631,022.1	0.00	1.00
11/25/2021 19:00	4	1.6	13.1	14.6	29.5	625,587.8	0.00	1.00
11/25/2021 20:00	4	1.6	13.3	14.6	30.4	625,153.1	0.00	1.00
11/25/2021 21:00	4	1.6	13.5	14.6	31.2	625,587.8	0.00	1.00
11/25/2021 22:00	4	1.6	13.4	14.6	31.4	622,979.4	0.00	1.00
11/25/2021 23:00	4	1.6	13.6	14.5	31.1	618,380.7	0.00	1.00
Average/Sum#:	4	1.6	13.1	14.6	29.5	633,868.1	0.00 #	24.00 #
Minimum:	3	1.5	11.4	14.4	22.7	618,380.7	0.00	1.00
Maximum:	5	1.8	14.5	14.6	33.7	707,044.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/26/2021 00:00	4	1.6	13.4	14.6	31.3	624,066.3	0.00	1.00
11/26/2021 01:00	5	1.6	13.5	14.6	32.4	622,979.4	0.00	1.00
11/26/2021 02:00	4	1.6	14.3	14.6	33.0	624,718.4	0.00	1.00
11/26/2021 03:00	5	1.7	13.8	14.6	32.5	624,935.7	0.00	1.00
11/26/2021 04:00	5	1.6	13.7	14.6	32.3	625,805.2	0.00	1.00
11/26/2021 05:00	5	1.6	13.6	14.6	32.3	624,066.3	0.00	1.00
11/26/2021 06:00	5	1.6	13.8	14.6	33.4	623,196.8	0.00	1.00
11/26/2021 07:00	5	1.6	14.1	14.6	33.7	625,153.1	0.00	1.00
11/26/2021 08:00	5	1.6	14.1	14.6	33.4	624,718.4	0.00	1.00
11/26/2021 09:00	4	1.6	13.4	14.6	29.9	624,718.4	0.00	1.00
11/26/2021 10:00	4	1.6	13.5	14.6	29.6	625,805.2	0.00	1.00
11/26/2021 11:00	4	1.6	13.5	14.6	28.8	623,848.9	0.00	1.00
11/26/2021 12:00	4	1.6	13.2	14.6	27.7	623,631.5	0.00	1.00
11/26/2021 13:00	3	1.6	12.8	14.6	26.2	623,196.8	0.00	1.00
11/26/2021 14:00	3	1.6	12.5	14.6	25.2	622,979.4	0.00	1.00
11/26/2021 15:00	2	1.4	10.4	14.5	21.2	726,436.8	0.00	1.00
11/26/2021 16:00	3	1.6	12.0	14.6	24.9	634,282.6	0.00	1.00
11/26/2021 17:00	4	1.6	12.9	14.6	28.0	622,109.9	0.00	1.00
11/26/2021 18:00	4	1.6	12.8	14.6	28.3	621,892.6	0.00	1.00
11/26/2021 19:00	4	1.6	12.9	14.6	27.3	622,109.9	0.00	1.00
11/26/2021 20:00	4	1.6	13.0	14.6	29.0	625,153.1	0.00	1.00
11/26/2021 21:00	4	1.6	12.6	14.5	27.8	617,096.9	0.00	1.00
11/26/2021 22:00	4	1.6	12.9	14.5	29.0	616,454.9	0.00	1.00
11/26/2021 23:00	4	1.6	12.7	14.5	28.3	616,668.9	0.00	1.00
Average/Sum#:	4	1.6	13.1	14.6	29.4	627,751.1	0.00 #	24.00 #
Minimum:	2	1.4	10.4	14.5	21.2	616,454.9	0.00	1.00
Maximum:	5	1.7	14.3	14.6	33.7	726,436.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/27/2021 00:00	4	1.6	13.2	14.5	30.2	612,603.4	0.00	1.00
11/27/2021 01:00	4	1.6	13.5	14.5	31.0	615,813.0	0.00	1.00
11/27/2021 02:00	4	1.6	14.2	14.5	31.9	612,817.4	0.00	1.00
11/27/2021 03:00	5	1.7	14.2	14.5	33.2	615,385.1	0.00	1.00
11/27/2021 04:00	5	1.6	13.8	14.6	32.3	623,848.9	0.00	1.00
11/27/2021 05:00	4	1.6	12.4	14.4	27.1	647,000.4	0.00	1.00
11/27/2021 06:00	4	1.8	13.0	14.5	31.2	633,572.8	0.00	1.00
11/27/2021 07:00	3	1.9	10.2	14.4	21.7	739,278.5	0.00	1.00
11/27/2021 08:00	5	1.8	13.7	14.6	32.7	623,196.8	0.00	1.00
11/27/2021 09:00	3	1.5	11.7	14.5	25.8	676,367.3	0.00	1.00
11/27/2021 10:00	1	1.8	8.5	14.3	14.8	766,877.7	0.00	1.00
11/27/2021 11:00	4	1.6	12.4	14.6	27.0	625,587.8	0.00	1.00
11/27/2021 12:00	3	1.6	12.4	14.6	25.9	625,587.8	0.00	1.00
11/27/2021 13:00	3	1.6	12.2	14.6	25.1	625,370.5	0.00	1.00
11/27/2021 14:00	3	1.6	11.8	14.6	23.8	625,805.2	0.00	1.00
11/27/2021 15:00	2	1.4	10.1	14.5	19.7	708,249.2	0.00	1.00
11/27/2021 16:00	2	1.6	9.1	14.4	16.7	729,797.9	0.00	1.00
11/27/2021 17:00	4	1.8	12.0	14.5	25.8	626,511.7	0.00	1.00
11/27/2021 18:00	4	1.6	12.5	14.6	27.7	624,501.0	0.00	1.00
11/27/2021 19:00	4	1.6	12.4	14.5	27.7	616,027.0	0.00	1.00
11/27/2021 20:00	4	1.6	12.4	14.5	26.4	618,380.7	0.00	1.00
11/27/2021 21:00	3	1.6	10.6	14.4	21.7	643,418.8	0.00	1.00
11/27/2021 22:00	4	1.7	12.3	14.5	28.1	615,385.1	0.00	1.00
11/27/2021 23:00	4	1.6	12.7	14.5	28.8	617,524.8	0.00	1.00
Average/Sum#:	4	1.6	12.1	14.5	26.5	644,537.9	0.00 #	24.00 #
Minimum:	1	1.4	8.5	14.3	14.8	612,603.4	0.00	1.00
Maximum:	5	1.9	14.2	14.6	33.2	766,877.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/28/2021 00:00	4	1.6	12.9	14.5	29.5	616,027.0	0.00	1.00
11/28/2021 01:00	5	1.6	13.3	14.5	31.0	615,599.1	0.00	1.00
11/28/2021 02:00	4	1.6	14.0	14.5	31.6	616,027.0	0.00	1.00
11/28/2021 03:00	5	1.7	13.8	14.5	32.5	616,882.9	0.00	1.00
11/28/2021 04:00	5	1.6	13.6	14.5	31.7	616,882.9	0.00	1.00
11/28/2021 05:00	5	1.6	13.5	14.5	31.7	616,668.9	0.00	1.00
11/28/2021 06:00	4	1.6	13.4	14.6	31.5	626,239.9	0.00	1.00
11/28/2021 07:00	4	1.7	12.0	14.5	27.0	651,760.4	0.00	1.00
11/28/2021 08:00	5	1.7	13.5	14.5	32.6	617,096.9	0.00	1.00
11/28/2021 09:00	4	1.6	13.5	14.5	30.6	617,738.8	0.00	1.00
11/28/2021 10:00	4	1.6	12.9	14.6	27.2	627,109.4	0.00	1.00
11/28/2021 11:00	3	1.6	12.3	14.6	25.3	626,239.9	0.00	1.00
11/28/2021 12:00	3	1.6	12.0	14.6	24.1	626,239.9	0.00	1.00
11/28/2021 13:00	3	1.6	11.7	14.6	23.2	626,022.6	0.00	1.00
11/28/2021 14:00	3	1.6	11.5	14.6	22.6	625,587.8	0.00	1.00
11/28/2021 15:00	3	1.6	11.3	14.6	22.2	629,283.1	0.00	1.00
11/28/2021 16:00	3	1.5	9.9	14.5	20.5	646,197.1	0.00	1.00
11/28/2021 17:00	3	1.5	11.2	14.6	22.3	626,022.6	0.00	1.00
11/28/2021 18:00	3	1.6	11.5	14.6	25.0	625,805.2	0.00	1.00
11/28/2021 19:00	4	1.6	11.8	14.6	25.9	626,892.1	0.00	1.00
11/28/2021 20:00	4	1.6	12.1	14.5	28.0	615,813.0	0.00	1.00
11/28/2021 21:00	4	1.6	12.5	14.5	29.0	616,027.0	0.00	1.00
11/28/2021 22:00	4	1.6	12.7	14.5	29.3	616,454.9	0.00	1.00
11/28/2021 23:00	4	1.6	12.7	14.5	29.4	616,241.0	0.00	1.00
Average/Sum#:	4	1.6	12.5	14.5	27.7	623,369.1	0.00 #	24.00 #
Minimum:	3	1.5	9.9	14.5	20.5	615,599.1	0.00	1.00
Maximum:	5	1.7	14.0	14.6	32.6	651,760.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/29/2021 00:00	4	1.6	12.9	14.5	29.6	616,882.9	0.00	1.00
11/29/2021 01:00	4	1.6	12.9	14.5	29.7	616,882.9	0.00	1.00
11/29/2021 02:00	4	1.6	13.7	14.5	30.6	617,096.9	0.00	1.00
11/29/2021 03:00	5	1.7	13.5	14.5	31.4	617,096.9	0.00	1.00
11/29/2021 04:00	5	1.6	13.5	14.5	31.4	616,241.0	0.00	1.00
11/29/2021 05:00	4	1.6	13.3	14.5	31.3	630,577.1	0.00	1.00
11/29/2021 06:00	2	1.6	9.5	14.3	19.7	735,754.4	0.00	1.00
11/29/2021 07:00	3	2.0	10.3	14.4	24.9	753,815.5	0.00	1.00
11/29/2021 08:00	5	1.9	13.8	14.5	33.2	617,524.8	0.00	1.00
11/29/2021 09:00	4	1.6	13.4	14.5	30.2	617,738.8	0.00	1.00
11/29/2021 10:00	4	1.6	12.8	14.5	27.0	617,310.8	0.00	1.00
11/29/2021 11:00	3	1.6	12.4	14.6	26.1	626,674.7	0.00	1.00
11/29/2021 12:00	3	1.6	11.8	14.6	23.9	626,239.9	0.00	1.00
11/29/2021 13:00	3	1.6	11.5	14.6	22.5	625,805.2	0.00	1.00
11/29/2021 14:00	3	1.6	11.1	14.6	21.5	625,805.2	0.00	1.00
11/29/2021 15:00	2	1.5	9.5	14.5	17.7	687,493.8	0.00	1.00
11/29/2021 16:00	1	1.6	7.6	14.4	11.8	805,853.6	0.00	1.00
11/29/2021 17:00	1	1.8	6.9	14.2	13.0	811,843.8	0.00	1.00
11/29/2021 18:00	2	1.7	9.2	14.3	18.1	679,110.0	0.00	1.00
11/29/2021 19:00	2	1.8	7.3	14.3	17.2	810,242.8	0.00	1.00
11/29/2021 20:00	2	1.7	7.1	14.4	20.1	949,327.1	0.00	1.00
11/29/2021 21:00	3	1.9	9.6	14.4	23.3	722,845.4	0.00	1.00
11/29/2021 22:00	4	1.7	11.2	14.4	25.9	634,359.5	0.00	1.00
11/29/2021 23:00	4	1.6	12.6	14.5	28.2	615,813.0	0.00	1.00
Average/Sum#:	3	1.7	11.1	14.5	24.5	678,264.0	0.00 #	24.00 #
Minimum:	1	1.5	6.9	14.2	11.8	615,813.0	0.00	1.00
Maximum:	5	2.0	13.8	14.6	33.2	949,327.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/30/2021 00:00	2	1.6	8.5	14.4	17.3	819,337.1	0.00	1.00
11/30/2021 01:00	4	1.9	11.4	14.4	26.5	657,955.7	0.00	1.00
11/30/2021 02:00	4	1.6	13.4	14.5	29.8	616,027.0	0.00	1.00
11/30/2021 03:00	4	1.7	13.1	14.5	29.8	615,813.0	0.00	1.00
11/30/2021 04:00	4	1.6	13.0	14.5	28.9	618,380.7	0.00	1.00
11/30/2021 05:00	4	1.5	11.7	14.5	26.8	677,009.2	0.00	1.00
11/30/2021 06:00	1	1.7	7.6	14.3	17.5	899,255.3	0.00	1.00
11/30/2021 07:00	2	1.8	8.2	14.3	22.4	898,217.9	0.00	1.00
11/30/2021 08:00	4	1.9	12.4	14.4	29.8	624,457.5	0.00	1.00
11/30/2021 09:00	0	1.5	0.0	14.5	32.9	617,310.8	0.00	1.00
11/30/2021 10:00	0	1.2	0.0	14.5	33.1	615,385.1	0.00	1.00
11/30/2021 11:00	2	1.4	12.5	14.5	24.1	616,454.9	0.00	1.00
11/30/2021 12:00	3	1.5	11.7	14.5	24.1	616,454.9	0.00	1.00
11/30/2021 13:00	3	1.5	11.2	14.6	23.4	625,370.5	0.00	1.00
11/30/2021 14:00	3	1.5	10.7	14.6	22.3	625,153.1	0.00	1.00
11/30/2021 15:00	2	1.4	9.1	14.5	18.6	733,925.9	0.00	1.00
11/30/2021 16:00	1	1.5	7.4	14.4	15.9	850,728.6	0.00	1.00
11/30/2021 17:00	2	1.7	8.6	13.9	23.6	949,011.1	0.00	1.00
11/30/2021 18:00	4	2.0	13.5	12.3	40.5	1,009,870.9	0.00	1.00
11/30/2021 19:00	4	2.1	13.2	12.3	41.5	1,003,819.9	0.00	1.00
11/30/2021 20:00	3	1.7	8.8	13.9	28.6	970,726.3	0.00	1.00
11/30/2021 21:00	4	1.9	12.1	12.7	37.5	998,510.8	0.00	1.00
11/30/2021 22:00	3	1.6	8.5	14.0	28.0	971,497.4	0.00	1.00
11/30/2021 23:00	3	1.7	8.7	14.3	24.2	836,386.3	0.00	1.00
Average/Sum#:	3	1.6	10.7	14.1	27.0	769,460.8	0.00 #	24.00 #
Minimum:	1	1.2	7.4	12.3	15.9	615,385.1	0.00	1.00
Maximum:	4	2.1	13.5	14.6	41.5	1,009,870.9	0.00	1.00
%SI	8.33	0.00	8.33	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/01/2021 00:00	5	1.7	12.5	14.5	31.0	615,813.0	0.00	1.00
12/01/2021 01:00	5	1.5	12.3	14.5	30.3	615,599.1	0.00	1.00
12/01/2021 02:00	5	1.5	13.3	14.5	32.4	616,668.9	0.00	1.00
12/01/2021 03:00	5	1.6	12.9	14.5	31.8	617,524.8	0.00	1.00
12/01/2021 04:00	5	1.6	12.8	14.5	31.1	616,454.9	0.00	1.00
12/01/2021 05:00	5	1.6	12.7	14.5	31.1	615,813.0	0.00	1.00
12/01/2021 06:00	5	1.7	12.7	14.5	31.2	615,813.0	0.00	1.00
12/01/2021 07:00	5	1.7	12.8	14.5	31.6	616,454.9	0.00	1.00
12/01/2021 08:00	5	1.7	12.9	14.5	31.8	617,096.9	0.00	1.00
12/01/2021 09:00	4	1.6	12.4	14.5	28.3	616,027.0	0.00	1.00
12/01/2021 10:00	3	1.6	11.6	14.5	25.1	616,882.9	0.00	1.00
12/01/2021 11:00	3	1.6	10.9	14.6	22.7	626,022.6	0.00	1.00
12/01/2021 12:00	3	1.6	10.6	14.6	22.2	626,239.9	0.00	1.00
12/01/2021 13:00	3	1.6	10.4	14.6	21.1	625,805.2	0.00	1.00
12/01/2021 14:00	3	1.6	10.3	14.6	20.9	625,587.8	0.00	1.00
12/01/2021 15:00	2	1.5	9.1	14.5	18.4	669,092.2	0.00	1.00
12/01/2021 16:00	1	1.6	7.5	14.4	13.0	763,717.4	0.00	1.00
12/01/2021 17:00	1	1.7	6.8	14.3	15.3	833,896.5	0.00	1.00
12/01/2021 18:00	2	1.7	6.7	14.4	18.2	909,297.8	0.00	1.00
12/01/2021 19:00	2	1.7	6.7	14.4	19.7	943,217.4	0.00	1.00
12/01/2021 20:00	2	1.7	6.7	14.3	19.5	889,295.9	0.00	1.00
12/01/2021 21:00	2	1.7	6.8	14.4	20.0	937,739.7	0.00	1.00
12/01/2021 22:00	4	1.7	9.8	14.4	24.0	657,745.1	0.00	1.00
12/01/2021 23:00	4	1.4	11.4	14.5	28.4	616,668.9	0.00	1.00
Average/Sum#:	4	1.6	10.5	14.5	25.0	687,686.5	0.00 #	24.00 #
Minimum:	1	1.4	6.7	14.3	13.0	615,599.1	0.00	1.00
Maximum:	5	1.7	13.3	14.6	32.4	943,217.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/02/2021 00:00	4	1.4	11.3	14.5	27.9	626,083.7	0.00	1.00
12/02/2021 01:00	4	1.3	10.8	14.4	26.2	650,792.6	0.00	1.00
12/02/2021 02:00	4	1.7	11.3	14.4	28.9	631,410.0	0.00	1.00
12/02/2021 03:00	2	1.5	7.2	14.2	17.6	830,443.5	0.00	1.00
12/02/2021 04:00	2	1.7	7.0	14.3	20.8	911,289.7	0.00	1.00
12/02/2021 05:00	2	1.7	7.5	14.2	24.0	933,661.3	0.00	1.00
12/02/2021 06:00	3	1.8	8.4	14.0	27.9	1,006,626.2	0.00	1.00
12/02/2021 07:00	3	1.8	8.7	13.8	26.0	944,902.8	0.00	1.00
12/02/2021 08:00	3	1.8	9.9	14.3	26.5	834,726.4	0.00	1.00
12/02/2021 09:00	5	1.7	13.5	14.5	32.9	616,882.9	0.00	1.00
12/02/2021 10:00	5	1.4	13.0	14.5	31.2	616,882.9	0.00	1.00
12/02/2021 11:00	4	1.4	12.1	14.5	27.2	616,668.9	0.00	1.00
12/02/2021 12:00	3	1.4	11.5	14.6	25.5	625,587.8	0.00	1.00
12/02/2021 13:00	3	1.4	11.0	14.6	23.1	625,587.8	0.00	1.00
12/02/2021 14:00	3	1.6	10.8	14.6	21.0	625,587.8	0.00	1.00
12/02/2021 15:00	2	1.5	9.3	14.5	17.8	700,332.2	0.00	1.00
12/02/2021 16:00	1	1.7	8.1	14.3	15.1	793,851.2	0.00	1.00
12/02/2021 17:00	2	2.0	10.8	13.2	27.7	998,968.4	0.00	1.00
12/02/2021 18:00	2	1.8	8.6	13.9	24.3	976,595.2	0.00	1.00
12/02/2021 19:00	2	1.8	8.5	14.0	24.7	979,833.1	0.00	1.00
12/02/2021 20:00	2	1.8	9.0	13.8	26.8	992,350.5	0.00	1.00
12/02/2021 21:00	2	1.8	9.1	13.8	27.5	988,493.0	0.00	1.00
12/02/2021 22:00	3	1.8	9.4	14.1	25.6	817,425.5	0.00	1.00
12/02/2021 23:00	4	1.7	12.2	14.5	28.9	615,385.1	0.00	1.00
Average/Sum#:	3	1.6	10.0	14.2	25.2	790,015.4	0.00 #	24.00 #
Minimum:	1	1.3	7.0	13.2	15.1	615,385.1	0.00	1.00
Maximum:	5	2.0	13.5	14.6	32.9	1,006,626.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/03/2021 00:00	4	1.6	12.4	14.5	29.3	615,171.1	0.00	1.00
12/03/2021 01:00	4	1.6	12.6	14.5	29.7	615,813.0	0.00	1.00
12/03/2021 02:00	4	1.6	13.3	14.5	30.6	615,599.1	0.00	1.00
12/03/2021 03:00	5	1.7	13.2	14.5	30.8	615,385.1	0.00	1.00
12/03/2021 04:00	4	1.6	13.0	14.5	30.4	615,171.1	0.00	1.00
12/03/2021 05:00	4	1.6	12.4	14.4	29.5	626,353.6	0.00	1.00
12/03/2021 06:00	4	1.8	12.3	14.5	29.1	642,559.6	0.00	1.00
12/03/2021 07:00	3	2.0	10.5	14.4	23.6	715,471.6	0.00	1.00
12/03/2021 08:00	4	1.7	12.5	14.5	28.7	627,795.5	0.00	1.00
12/03/2021 09:00	2	1.5	9.2	14.4	20.0	782,889.4	0.00	1.00
12/03/2021 10:00	2	1.7	7.3	14.3	18.9	949,675.1	0.00	1.00
12/03/2021 11:00	2	1.8	9.0	14.4	20.2	797,847.7	0.00	1.00
12/03/2021 12:00	3	1.9	9.4	14.3	21.4	709,195.8	0.00	1.00
12/03/2021 13:00	4	1.6	12.3	14.5	27.9	617,952.8	0.00	1.00
12/03/2021 14:00	4	1.6	12.3	14.5	26.5	617,524.8	0.00	1.00
12/03/2021 15:00	2	1.5	9.4	14.4	19.2	773,830.1	0.00	1.00
12/03/2021 16:00	2	1.8	8.2	14.2	20.7	870,095.5	0.00	1.00
12/03/2021 17:00	2	1.8	9.0	13.9	25.9	987,355.0	0.00	1.00
12/03/2021 18:00	2	1.8	8.9	14.0	26.1	997,695.1	0.00	1.00
12/03/2021 19:00	2	1.8	8.7	14.0	25.4	995,908.9	0.00	1.00
12/03/2021 20:00	2	1.8	8.6	14.0	25.6	995,908.9	0.00	1.00
12/03/2021 21:00	2	1.8	8.6	14.0	25.4	995,710.5	0.00	1.00
12/03/2021 22:00	2	1.8	8.7	14.0	25.4	995,115.1	0.00	1.00
12/03/2021 23:00	3	1.7	9.3	14.2	25.2	834,940.1	0.00	1.00
Average/Sum#:	3	1.7	10.5	14.3	25.6	775,456.9	0.00 #	24.00 #
Minimum:	2	1.5	7.3	13.9	18.9	615,171.1	0.00	1.00
Maximum:	5	2.0	13.3	14.5	30.8	997,695.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/04/2021 00:00	4	1.5	12.1	14.5	29.4	615,813.0	0.00	1.00
12/04/2021 01:00	4	1.3	12.1	14.5	29.6	616,454.9	0.00	1.00
12/04/2021 02:00	4	1.3	12.7	14.5	30.3	619,236.6	0.00	1.00
12/04/2021 03:00	4	1.5	10.7	14.4	22.3	651,003.3	0.00	1.00
12/04/2021 04:00	3	1.4	9.5	14.4	20.8	737,382.4	0.00	1.00
12/04/2021 05:00	3	1.8	10.0	14.4	22.8	706,412.3	0.00	1.00
12/04/2021 06:00	3	1.9	10.0	14.3	24.0	672,470.4	0.00	1.00
12/04/2021 07:00	3	1.8	9.3	14.3	23.2	753,598.4	0.00	1.00
12/04/2021 08:00	4	1.9	10.8	14.4	26.0	686,819.0	0.00	1.00
12/04/2021 09:00	2	1.6	8.4	14.4	22.4	849,043.1	0.00	1.00
12/04/2021 10:00	4	1.9	10.7	14.4	26.9	700,513.2	0.00	1.00
12/04/2021 11:00	2	1.6	8.0	14.3	19.6	861,284.9	0.00	1.00
12/04/2021 12:00	5	1.7	12.8	14.5	31.1	618,380.7	0.00	1.00
12/04/2021 13:00	4	1.3	11.4	14.4	28.2	663,433.4	0.00	1.00
12/04/2021 14:00	4	1.7	11.6	14.4	26.6	633,516.8	0.00	1.00
12/04/2021 15:00	3	1.4	10.2	14.4	23.7	718,631.8	0.00	1.00
12/04/2021 16:00	2	1.5	8.0	14.4	20.1	870,111.2	0.00	1.00
12/04/2021 17:00	2	1.5	7.9	14.2	24.7	959,414.6	0.00	1.00
12/04/2021 18:00	2	1.7	8.5	14.1	25.7	999,478.4	0.00	1.00
12/04/2021 19:00	2	1.7	8.5	14.1	26.0	999,679.8	0.00	1.00
12/04/2021 20:00	2	1.7	8.5	14.1	26.4	1,001,089.5	0.00	1.00
12/04/2021 21:00	2	1.7	8.5	14.1	26.8	1,000,888.1	0.00	1.00
12/04/2021 22:00	4	1.7	11.5	14.4	28.7	649,739.2	0.00	1.00
12/04/2021 23:00	5	1.6	12.9	14.5	30.8	617,952.8	0.00	1.00
Average/Sum#:	3	1.6	10.2	14.4	25.7	758,431.2	0.00 #	24.00 #
Minimum:	2	1.3	7.9	14.1	19.6	615,813.0	0.00	1.00
Maximum:	5	1.9	12.9	14.5	31.1	1,001,089.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/05/2021 00:00	5	1.6	12.9	14.5	30.9	618,166.7	0.00	1.00
12/05/2021 01:00	5	1.6	12.9	14.5	30.9	618,166.7	0.00	1.00
12/05/2021 02:00	4	1.6	13.6	14.5	31.4	617,310.8	0.00	1.00
12/05/2021 03:00	5	1.7	13.3	14.6	31.9	626,457.3	0.00	1.00
12/05/2021 04:00	5	1.6	13.4	14.5	32.4	619,878.5	0.00	1.00
12/05/2021 05:00	5	1.6	13.3	14.5	32.1	618,808.6	0.00	1.00
12/05/2021 06:00	3	1.5	10.2	14.4	22.4	723,056.1	0.00	1.00
12/05/2021 07:00	4	2.1	10.8	14.4	25.9	693,982.1	0.00	1.00
12/05/2021 08:00	2	1.5	8.3	14.3	21.9	828,501.8	0.00	1.00
12/05/2021 09:00	2	1.5	7.2	14.4	22.9	975,872.9	0.00	1.00
12/05/2021 10:00	2	1.5	7.3	14.4	23.4	974,398.1	0.00	1.00
12/05/2021 11:00	2	1.5	7.3	14.3	22.4	918,966.8	0.00	1.00
12/05/2021 12:00	5	1.9	12.6	14.5	30.6	623,302.1	0.00	1.00
12/05/2021 13:00	3	1.4	9.4	14.4	21.5	766,034.9	0.00	1.00
12/05/2021 14:00	4	1.8	10.8	14.4	25.9	673,335.4	0.00	1.00
12/05/2021 15:00	4	1.4	11.5	14.4	27.6	643,418.8	0.00	1.00
12/05/2021 16:00	3	1.5	10.0	14.5	22.3	734,781.8	0.00	1.00
12/05/2021 17:00	2	1.6	8.2	14.2	19.6	738,262.8	0.00	1.00
12/05/2021 18:00	2	1.5	7.0	14.3	21.5	912,119.6	0.00	1.00
12/05/2021 19:00	2	1.5	7.4	14.4	24.1	977,558.3	0.00	1.00
12/05/2021 20:00	2	1.5	7.5	14.3	24.6	964,614.2	0.00	1.00
12/05/2021 21:00	2	1.5	7.3	14.3	23.7	923,946.5	0.00	1.00
12/05/2021 22:00	2	1.5	7.3	14.3	23.8	933,905.9	0.00	1.00
12/05/2021 23:00	3	1.6	7.8	14.2	21.8	776,688.5	0.00	1.00
Average/Sum#:	3	1.6	9.9	14.4	25.6	770,897.3	0.00 #	24.00 #
Minimum:	2	1.4	7.0	14.2	19.6	617,310.8	0.00	1.00
Maximum:	5	2.1	13.6	14.6	32.4	977,558.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/06/2021 00:00	4	1.8	10.9	14.4	27.8	701,145.3	0.00	1.00
12/06/2021 01:00	5	1.7	13.2	14.5	32.5	621,376.3	0.00	1.00
12/06/2021 02:00	5	1.6	13.8	14.5	33.8	619,664.5	0.00	1.00
12/06/2021 03:00	5	1.5	13.5	14.5	33.6	622,660.1	0.00	1.00
12/06/2021 04:00	5	1.5	13.2	14.5	32.2	622,446.2	0.00	1.00
12/06/2021 05:00	3	1.4	9.9	14.4	22.9	779,097.1	0.00	1.00
12/06/2021 06:00	2	1.7	7.4	14.4	19.5	966,392.3	0.00	1.00
12/06/2021 07:00	2	1.7	7.4	14.3	22.1	964,614.2	0.00	1.00
12/06/2021 08:00	2	1.7	7.4	14.3	21.9	955,692.2	0.00	1.00
12/06/2021 09:00	2	1.7	7.4	14.4	22.0	978,822.4	0.00	1.00
12/06/2021 10:00	2	1.7	7.3	14.4	22.9	978,401.1	0.00	1.00
12/06/2021 11:00	2	1.7	7.3	14.4	22.9	978,611.7	0.00	1.00
12/06/2021 12:00	2	1.7	7.3	14.4	22.5	978,190.4	0.00	1.00
12/06/2021 13:00	2	1.7	7.3	14.4	21.8	977,979.7	0.00	1.00
12/06/2021 14:00	2	1.7	7.2	14.4	22.5	976,715.6	0.00	1.00
12/06/2021 15:00	2	1.7	7.2	14.4	22.3	977,137.0	0.00	1.00
12/06/2021 16:00	2	1.8	8.5	14.0	26.0	960,780.2	0.00	1.00
12/06/2021 17:00	2	1.8	8.8	14.0	27.0	1,000,076.7	0.00	1.00
12/06/2021 18:00	3	1.8	9.3	13.8	28.8	998,522.5	0.00	1.00
12/06/2021 19:00	2	1.8	8.9	14.0	28.0	1,000,672.1	0.00	1.00
12/06/2021 20:00	2	1.8	9.2	13.9	28.2	1,000,853.6	0.00	1.00
12/06/2021 21:00	2	1.8	9.0	14.0	27.6	1,004,244.5	0.00	1.00
12/06/2021 22:00	2	1.7	8.4	14.1	25.8	973,298.2	0.00	1.00
12/06/2021 23:00	2	1.7	7.2	14.4	22.0	970,184.5	0.00	1.00
Average/Sum#:	3	1.7	9.0	14.3	25.7	900,315.8	0.00 #	24.00 #
Minimum:	2	1.4	7.2	13.8	19.5	619,664.5	0.00	1.00
Maximum:	5	1.8	13.8	14.5	33.8	1,004,244.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/07/2021 00:00	2	1.7	7.3	14.2	21.4	852,722.2	0.00	1.00
12/07/2021 01:00	4	1.6	10.1	14.3	26.2	688,447.0	0.00	1.00
12/07/2021 02:00	5	1.5	13.1	14.5	32.1	619,236.6	0.00	1.00
12/07/2021 03:00	5	1.4	12.7	14.5	31.4	618,594.7	0.00	1.00
12/07/2021 04:00	2	1.4	8.9	14.3	19.3	723,097.6	0.00	1.00
12/07/2021 05:00	4	1.9	12.5	14.5	29.6	619,878.5	0.00	1.00
12/07/2021 06:00	3	1.5	9.5	14.4	21.2	744,966.9	0.00	1.00
12/07/2021 07:00	2	1.7	7.3	14.4	20.0	975,662.2	0.00	1.00
12/07/2021 08:00	2	1.7	7.3	14.4	21.4	973,976.8	0.00	1.00
12/07/2021 09:00	2	1.7	7.3	14.4	21.6	973,766.1	0.00	1.00
12/07/2021 10:00	3	1.8	8.5	14.3	22.5	829,124.2	0.00	1.00
12/07/2021 11:00	3	1.8	8.4	14.3	20.0	729,322.2	0.00	1.00
12/07/2021 12:00	2	1.6	6.9	14.3	18.1	881,826.3	0.00	1.00
12/07/2021 13:00	2	1.7	7.2	14.4	21.0	976,926.3	0.00	1.00
12/07/2021 14:00	2	1.7	7.2	14.4	20.6	973,134.0	0.00	1.00
12/07/2021 15:00	2	1.7	7.1	14.4	20.6	948,273.7	0.00	1.00
12/07/2021 16:00	2	1.7	8.1	14.2	24.6	973,926.4	0.00	1.00
12/07/2021 17:00	2	1.8	8.8	14.0	26.3	995,908.9	0.00	1.00
12/07/2021 18:00	2	1.8	9.5	13.8	28.0	1,011,059.5	0.00	1.00
12/07/2021 19:00	3	1.9	10.1	13.4	29.9	1,004,792.3	0.00	1.00
12/07/2021 20:00	2	1.8	8.8	13.9	26.6	994,202.1	0.00	1.00
12/07/2021 21:00	2	1.8	8.9	13.9	26.9	997,332.2	0.00	1.00
12/07/2021 22:00	2	1.8	9.0	13.9	27.0	997,527.8	0.00	1.00
12/07/2021 23:00	2	1.7	8.4	14.1	25.3	965,242.8	0.00	1.00
Average/Sum#:	3	1.7	8.9	14.2	24.2	877,872.8	0.00 #	24.00 #
Minimum:	2	1.4	6.9	13.4	18.1	618,594.7	0.00	1.00
Maximum:	5	1.9	13.1	14.5	32.1	1,011,059.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/08/2021 00:00	2	1.8	8.0	14.3	21.2	823,522.0	0.00	1.00
12/08/2021 01:00	3	1.8	8.4	14.3	21.1	758,163.1	0.00	1.00
12/08/2021 02:00	5	1.7	13.2	14.5	31.0	617,310.8	0.00	1.00
12/08/2021 03:00	4	1.6	12.6	14.5	29.6	623,088.1	0.00	1.00
12/08/2021 04:00	4	1.7	11.7	14.5	27.0	628,437.4	0.00	1.00
12/08/2021 05:00	4	1.6	11.8	14.5	27.5	627,153.6	0.00	1.00
12/08/2021 06:00	2	1.6	8.0	14.4	18.5	898,342.4	0.00	1.00
12/08/2021 07:00	2	1.8	7.7	14.3	20.7	897,595.4	0.00	1.00
12/08/2021 08:00	4	1.9	11.2	14.4	26.9	662,380.0	0.00	1.00
12/08/2021 09:00	5	1.6	12.9	14.5	30.6	617,524.8	0.00	1.00
12/08/2021 10:00	4	1.6	12.8	14.5	29.8	617,952.8	0.00	1.00
12/08/2021 11:00	2	1.6	8.9	14.2	20.2	886,651.2	0.00	1.00
12/08/2021 12:00	2	1.7	7.9	14.2	19.7	876,636.0	0.00	1.00
12/08/2021 13:00	4	1.8	11.5	14.5	26.5	626,083.7	0.00	1.00
12/08/2021 14:00	4	1.6	11.8	14.5	26.2	617,952.8	0.00	1.00
12/08/2021 15:00	3	1.6	10.9	14.5	24.2	640,205.9	0.00	1.00
12/08/2021 16:00	2	1.6	9.0	14.4	20.6	767,509.7	0.00	1.00
12/08/2021 17:00	2	1.7	7.4	14.4	19.8	968,920.4	0.00	1.00
12/08/2021 18:00	2	1.7	7.1	14.3	19.9	920,004.2	0.00	1.00
12/08/2021 19:00	2	1.7	7.5	14.4	21.2	973,344.7	0.00	1.00
12/08/2021 20:00	2	1.7	7.1	14.3	20.4	921,456.6	0.00	1.00
12/08/2021 21:00	3	1.9	8.5	14.3	21.3	783,269.2	0.00	1.00
12/08/2021 22:00	4	1.6	11.7	14.5	26.9	614,743.2	0.00	1.00
12/08/2021 23:00	4	1.6	11.6	14.5	26.2	614,957.1	0.00	1.00
Average/Sum#:	3	1.7	10.0	14.4	24.0	749,300.2	0.00 #	24.00 #
Minimum:	2	1.6	7.1	14.2	18.5	614,743.2	0.00	1.00
Maximum:	5	1.9	13.2	14.5	31.0	973,344.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/09/2021 00:00	4	1.6	11.3	14.5	25.4	619,022.6	0.00	1.00
12/09/2021 01:00	4	1.6	11.5	14.5	26.1	619,450.6	0.00	1.00
12/09/2021 02:00	4	1.6	11.9	14.5	26.5	616,882.9	0.00	1.00
12/09/2021 03:00	4	1.6	11.7	14.5	27.0	618,594.7	0.00	1.00
12/09/2021 04:00	4	1.6	11.8	14.5	27.3	619,878.5	0.00	1.00
12/09/2021 05:00	4	1.6	11.9	14.5	27.4	619,022.6	0.00	1.00
12/09/2021 06:00	2	1.5	8.5	14.4	18.2	788,156.4	0.00	1.00
12/09/2021 07:00	3	1.9	9.4	14.3	21.7	688,239.5	0.00	1.00
12/09/2021 08:00	4	1.8	10.7	14.4	24.5	638,783.8	0.00	1.00
12/09/2021 09:00	2	1.6	7.8	14.3	18.3	795,511.1	0.00	1.00
12/09/2021 10:00	3	1.8	9.6	14.4	21.9	707,044.3	0.00	1.00
12/09/2021 11:00	4	1.9	12.0	14.5	28.1	616,668.9	0.00	1.00
12/09/2021 12:00	4	1.6	11.5	14.4	25.7	623,404.1	0.00	1.00
12/09/2021 13:00	4	1.6	12.1	14.5	26.7	614,529.2	0.00	1.00
12/09/2021 14:00	4	1.6	12.3	14.6	27.8	623,631.5	0.00	1.00
12/09/2021 15:00	3	1.5	11.5	14.5	25.5	635,498.5	0.00	1.00
12/09/2021 16:00	2	1.6	8.7	14.4	18.9	823,129.4	0.00	1.00
12/09/2021 17:00	2	1.7	7.8	14.3	19.5	805,470.5	0.00	1.00
12/09/2021 18:00	3	1.8	9.5	14.3	21.8	684,297.2	0.00	1.00
12/09/2021 19:00	3	1.8	8.2	14.3	21.5	765,840.2	0.00	1.00
12/09/2021 20:00	2	1.7	7.4	14.3	20.5	871,451.9	0.00	1.00
12/09/2021 21:00	3	1.8	8.1	14.3	22.2	812,940.1	0.00	1.00
12/09/2021 22:00	3	1.9	10.2	14.4	24.9	700,091.9	0.00	1.00
12/09/2021 23:00	5	1.9	13.2	14.6	31.7	626,239.9	0.00	1.00
Average/Sum#:	3	1.7	10.4	14.4	24.1	688,907.5	0.00 #	24.00 #
Minimum:	2	1.5	7.4	14.3	18.2	614,529.2	0.00	1.00
Maximum:	5	1.9	13.2	14.6	31.7	871,451.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOX, Ppm	Unit CT1 NOX, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/10/2021 00:00	5	1.7	13.2	14.5	31.8	626,511.7	0.00	1.00
12/10/2021 01:00	5	1.7	14.0	14.5	34.2	619,664.5	0.00	1.00
12/10/2021 02:00	5	1.6	14.1	14.6	33.0	628,848.4	0.00	1.00
12/10/2021 03:00	5	1.7	14.1	14.5	34.6	619,236.6	0.00	1.00
12/10/2021 04:00	5	1.6	13.6	14.6	33.1	627,544.2	0.00	1.00
12/10/2021 05:00	4	1.6	12.1	14.4	28.5	672,703.4	0.00	1.00
12/10/2021 06:00	3	1.8	9.8	14.4	24.5	815,755.6	0.00	1.00
12/10/2021 07:00	2	1.7	8.6	14.3	26.0	946,147.8	0.00	1.00
12/10/2021 08:00	4	2.0	12.0	14.5	30.8	718,733.8	0.00	1.00
12/10/2021 09:00	5	1.8	14.0	14.6	34.3	627,544.2	0.00	1.00
12/10/2021 10:00	4	1.6	12.1	14.5	28.8	682,572.5	0.00	1.00
12/10/2021 11:00	2	1.7	7.8	14.3	21.4	919,589.2	0.00	1.00
12/10/2021 12:00	4	1.8	10.1	14.3	26.7	728,699.8	0.00	1.00
12/10/2021 13:00	4	1.8	13.1	14.6	29.8	635,369.4	0.00	1.00
12/10/2021 14:00	5	1.6	13.7	14.6	32.6	626,239.9	0.00	1.00
12/10/2021 15:00	3	1.5	10.6	14.5	23.3	774,580.7	0.00	1.00
12/10/2021 16:00	2	1.7	8.2	14.4	22.6	947,641.7	0.00	1.00
12/10/2021 17:00	2	1.7	8.5	14.4	25.5	975,240.8	0.00	1.00
12/10/2021 18:00	2	1.7	8.5	14.4	27.0	975,030.2	0.00	1.00
12/10/2021 19:00	2	1.7	8.4	14.3	26.8	962,124.4	0.00	1.00
12/10/2021 20:00	3	1.7	8.4	14.3	27.0	964,199.3	0.00	1.00
12/10/2021 21:00	2	1.7	8.4	14.3	26.8	963,576.8	0.00	1.00
12/10/2021 22:00	2	1.7	8.4	14.3	26.7	962,954.3	0.00	1.00
12/10/2021 23:00	2	1.7	8.4	14.3	27.0	964,406.7	0.00	1.00
Average/Sum#:	3	1.7	10.8	14.4	28.5	791,038.2	0.00 #	24.00 #
Minimum:	2	1.5	7.8	14.3	21.4	619,236.6	0.00	1.00
Maximum:	5	2.0	14.1	14.6	34.6	975,240.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/11/2021 00:00	4	1.8	10.9	14.3	30.2	732,434.6	0.00	1.00
12/11/2021 01:00	5	1.8	13.7	14.5	33.1	621,376.3	0.00	1.00
12/11/2021 02:00	5	1.7	14.3	14.5	34.5	621,376.3	0.00	1.00
12/11/2021 03:00	5	1.7	13.7	14.6	33.8	629,935.2	0.00	1.00
12/11/2021 04:00	5	1.7	13.7	14.6	33.7	630,587.3	0.00	1.00
12/11/2021 05:00	5	1.7	14.1	14.5	34.5	622,660.1	0.00	1.00
12/11/2021 06:00	4	1.7	11.7	14.3	26.8	662,303.4	0.00	1.00
12/11/2021 07:00	4	1.9	11.7	14.5	29.2	709,747.0	0.00	1.00
12/11/2021 08:00	5	1.8	14.0	14.6	34.5	628,196.3	0.00	1.00
12/11/2021 09:00	5	1.7	13.9	14.6	34.0	629,065.7	0.00	1.00
12/11/2021 10:00	5	1.6	13.9	14.6	32.9	628,848.4	0.00	1.00
12/11/2021 11:00	4	1.6	13.8	14.6	31.8	629,283.1	0.00	1.00
12/11/2021 12:00	4	1.6	13.3	14.6	29.9	628,631.0	0.00	1.00
12/11/2021 13:00	3	1.6	12.4	14.6	26.4	628,413.6	0.00	1.00
12/11/2021 14:00	3	1.6	12.2	14.6	26.3	627,544.2	0.00	1.00
12/11/2021 15:00	4	1.6	12.2	14.6	26.4	629,283.1	0.00	1.00
12/11/2021 16:00	2	1.5	9.4	14.5	20.1	833,637.1	0.00	1.00
12/11/2021 17:00	2	1.7	8.2	14.3	21.2	891,578.3	0.00	1.00
12/11/2021 18:00	3	1.8	8.7	14.3	24.1	870,621.9	0.00	1.00
12/11/2021 19:00	2	1.6	7.8	14.4	22.1	971,659.3	0.00	1.00
12/11/2021 20:00	2	1.7	8.0	14.4	23.4	970,395.2	0.00	1.00
12/11/2021 21:00	2	1.7	8.2	14.4	24.3	982,404.0	0.00	1.00
12/11/2021 22:00	2	1.7	8.1	14.4	23.8	982,825.3	0.00	1.00
12/11/2021 23:00	3	1.7	9.7	14.3	24.9	768,122.6	0.00	1.00
Average/Sum#:	4	1.7	11.6	14.5	28.4	730,455.4	0.00 #	24.00 #
Minimum:	2	1.5	7.8	14.3	20.1	621,376.3	0.00	1.00
Maximum:	5	1.9	14.3	14.6	34.5	982,825.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/12/2021 00:00	3	1.8	9.0	14.4	22.2	811,963.3	0.00	1.00
12/12/2021 01:00	4	1.6	12.5	14.5	29.1	620,734.4	0.00	1.00
12/12/2021 02:00	3	1.6	12.5	14.5	27.6	626,511.7	0.00	1.00
12/12/2021 03:00	2	1.7	7.6	14.3	18.2	885,146.1	0.00	1.00
12/12/2021 04:00	3	1.8	10.0	14.2	24.5	692,479.1	0.00	1.00
12/12/2021 05:00	4	1.7	12.2	14.5	29.0	622,232.2	0.00	1.00
12/12/2021 06:00	3	1.7	10.0	14.4	22.3	715,260.9	0.00	1.00
12/12/2021 07:00	4	1.8	10.8	14.4	25.8	680,919.9	0.00	1.00
12/12/2021 08:00	3	1.7	10.9	14.4	24.6	679,023.8	0.00	1.00
12/12/2021 09:00	4	1.7	11.6	14.5	26.7	636,354.4	0.00	1.00
12/12/2021 10:00	4	1.6	12.4	14.5	28.5	618,808.6	0.00	1.00
12/12/2021 11:00	4	1.6	12.4	14.5	27.6	617,952.8	0.00	1.00
12/12/2021 12:00	4	1.6	12.4	14.5	27.9	616,454.9	0.00	1.00
12/12/2021 13:00	4	1.6	12.6	14.5	28.1	616,882.9	0.00	1.00
12/12/2021 14:00	4	1.6	12.1	14.5	26.7	626,297.7	0.00	1.00
12/12/2021 15:00	3	1.6	10.9	14.4	24.7	668,279.1	0.00	1.00
12/12/2021 16:00	2	1.7	9.2	14.4	22.0	816,176.9	0.00	1.00
12/12/2021 17:00	2	1.7	7.5	14.3	21.1	878,714.0	0.00	1.00
12/12/2021 18:00	2	1.7	7.5	14.3	21.9	878,921.5	0.00	1.00
12/12/2021 19:00	2	1.7	8.0	14.3	24.2	945,525.3	0.00	1.00
12/12/2021 20:00	2	1.7	7.6	14.3	23.0	906,932.4	0.00	1.00
12/12/2021 21:00	3	1.7	8.2	14.2	23.6	831,261.0	0.00	1.00
12/12/2021 22:00	3	1.6	9.5	14.3	25.6	761,897.9	0.00	1.00
12/12/2021 23:00	4	1.7	12.6	14.5	29.9	616,027.0	0.00	1.00
Average/Sum#:	3	1.7	10.4	14.4	25.2	723,781.6	0.00 #	24.00 #
Minimum:	2	1.6	7.5	14.2	18.2	616,027.0	0.00	1.00
Maximum:	4	1.8	12.6	14.5	29.9	945,525.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/13/2021 00:00	4	1.6	12.4	14.5	28.7	617,310.8	0.00	1.00
12/13/2021 01:00	4	1.6	12.3	14.5	28.9	619,236.6	0.00	1.00
12/13/2021 02:00	4	1.6	12.4	14.5	27.5	619,022.6	0.00	1.00
12/13/2021 03:00	4	1.7	12.4	14.5	29.0	616,027.0	0.00	1.00
12/13/2021 04:00	4	1.6	12.4	14.5	28.9	615,385.1	0.00	1.00
12/13/2021 05:00	4	1.6	12.4	14.5	28.5	615,385.1	0.00	1.00
12/13/2021 06:00	2	1.5	9.6	14.4	22.3	799,743.8	0.00	1.00
12/13/2021 07:00	2	1.7	7.9	14.3	21.9	935,773.3	0.00	1.00
12/13/2021 08:00	2	1.7	8.1	14.3	23.6	916,684.4	0.00	1.00
12/13/2021 09:00	2	1.7	7.7	14.3	23.2	934,320.9	0.00	1.00
12/13/2021 10:00	3	1.8	9.6	14.4	25.6	817,019.7	0.00	1.00
12/13/2021 11:00	3	1.7	10.4	14.3	23.8	660,851.0	0.00	1.00
12/13/2021 12:00	2	1.6	8.3	14.4	24.2	961,335.9	0.00	1.00
12/13/2021 13:00	2	1.7	8.4	14.3	25.7	972,083.8	0.00	1.00
12/13/2021 14:00	2	1.7	7.9	14.4	23.7	975,240.8	0.00	1.00
12/13/2021 15:00	2	1.7	7.9	14.4	24.0	975,451.5	0.00	1.00
12/13/2021 16:00	3	1.7	9.1	14.0	28.1	947,086.0	0.00	1.00
12/13/2021 17:00	3	1.9	9.9	13.6	30.6	980,545.4	0.00	1.00
12/13/2021 18:00	3	1.8	9.9	13.8	29.7	985,214.0	0.00	1.00
12/13/2021 19:00	3	1.8	9.9	13.8	29.5	985,214.0	0.00	1.00
12/13/2021 20:00	3	1.8	9.9	13.8	29.6	985,021.2	0.00	1.00
12/13/2021 21:00	3	1.8	9.9	13.8	30.3	985,214.0	0.00	1.00
12/13/2021 22:00	3	1.9	10.4	14.1	28.9	826,689.3	0.00	1.00
12/13/2021 23:00	5	1.8	13.0	14.5	31.0	617,096.9	0.00	1.00
Average/Sum#:	3	1.7	10.1	14.2	27.0	831,789.7	0.00 #	24.00 #
Minimum:	2	1.5	7.7	13.6	21.9	615,385.1	0.00	1.00
Maximum:	5	1.9	13.0	14.5	31.0	985,214.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/14/2021 00:00	5	1.7	12.9	14.5	30.8	619,236.6	0.00	1.00
12/14/2021 01:00	4	1.6	12.6	14.5	29.6	617,952.8	0.00	1.00
12/14/2021 02:00	4	1.6	13.5	14.5	31.2	617,096.9	0.00	1.00
12/14/2021 03:00	5	1.7	13.1	14.5	31.1	615,813.0	0.00	1.00
12/14/2021 04:00	5	1.7	13.4	14.5	32.0	613,673.3	0.00	1.00
12/14/2021 05:00	3	1.6	11.1	14.4	25.9	709,783.2	0.00	1.00
12/14/2021 06:00	3	1.8	8.9	14.2	23.6	830,647.9	0.00	1.00
12/14/2021 07:00	4	2.0	12.1	14.4	29.0	646,157.6	0.00	1.00
12/14/2021 08:00	5	2.0	13.0	14.5	30.8	622,446.2	0.00	1.00
12/14/2021 09:00	5	1.7	13.3	14.5	32.0	617,096.9	0.00	1.00
12/14/2021 10:00	5	1.7	13.3	14.5	32.0	617,524.8	0.00	1.00
12/14/2021 11:00	5	1.6	13.3	14.5	31.2	616,882.9	0.00	1.00
12/14/2021 12:00	5	1.6	13.4	14.5	31.5	615,813.0	0.00	1.00
12/14/2021 13:00	4	1.6	13.4	14.5	30.9	616,454.9	0.00	1.00
12/14/2021 14:00	5	1.6	13.3	14.5	31.0	614,957.1	0.00	1.00
12/14/2021 15:00	4	1.6	13.2	14.5	30.3	616,241.0	0.00	1.00
12/14/2021 16:00	3	1.5	11.4	14.5	25.9	688,349.7	0.00	1.00
12/14/2021 17:00	2	1.7	7.3	14.3	18.2	912,949.6	0.00	1.00
12/14/2021 18:00	2	1.7	7.5	14.3	21.5	890,748.3	0.00	1.00
12/14/2021 19:00	2	1.7	7.6	14.3	23.3	921,249.1	0.00	1.00
12/14/2021 20:00	2	1.7	7.7	14.3	24.5	960,257.0	0.00	1.00
12/14/2021 21:00	2	1.7	7.7	14.3	24.9	958,597.1	0.00	1.00
12/14/2021 22:00	2	1.7	7.7	14.2	22.9	864,372.5	0.00	1.00
12/14/2021 23:00	5	1.9	13.1	14.5	33.0	617,952.8	0.00	1.00
Average/Sum#:	4	1.7	11.4	14.4	28.2	709,260.6	0.00 #	24.00 #
Minimum:	2	1.5	7.3	14.2	18.2	613,673.3	0.00	1.00
Maximum:	5	2.0	13.5	14.5	33.0	960,257.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/15/2021 00:00	4	1.6	12.6	14.5	30.6	639,991.9	0.00	1.00
12/15/2021 01:00	5	1.8	13.3	14.6	31.8	627,978.9	0.00	1.00
12/15/2021 02:00	5	1.6	14.0	14.6	33.7	628,631.0	0.00	1.00
12/15/2021 03:00	5	1.7	13.8	14.6	33.8	628,631.0	0.00	1.00
12/15/2021 04:00	3	1.5	10.2	14.4	23.3	798,690.4	0.00	1.00
12/15/2021 05:00	2	1.7	7.7	14.3	22.0	962,954.3	0.00	1.00
12/15/2021 06:00	2	1.7	7.7	14.3	23.9	961,501.9	0.00	1.00
12/15/2021 07:00	2	1.7	8.1	14.3	23.4	881,618.8	0.00	1.00
12/15/2021 08:00	4	1.9	12.3	14.5	30.5	653,044.3	0.00	1.00
12/15/2021 09:00	5	1.7	13.8	14.5	34.1	622,660.1	0.00	1.00
12/15/2021 10:00	5	1.5	13.6	14.5	33.8	621,804.3	0.00	1.00
12/15/2021 11:00	3	1.3	11.7	14.4	29.6	641,522.7	0.00	1.00
12/15/2021 12:00	2	1.5	8.9	14.4	19.0	841,458.6	0.00	1.00
12/15/2021 13:00	3	1.9	10.2	14.4	24.5	792,791.4	0.00	1.00
12/15/2021 14:00	5	1.6	13.2	14.5	31.1	617,952.8	0.00	1.00
12/15/2021 15:00	3	1.5	11.2	14.5	25.2	705,467.5	0.00	1.00
12/15/2021 16:00	2	1.7	8.5	14.4	19.8	850,517.9	0.00	1.00
12/15/2021 17:00	2	1.7	8.0	14.4	23.0	975,030.2	0.00	1.00
12/15/2021 18:00	2	1.7	7.9	14.4	23.4	964,706.8	0.00	1.00
12/15/2021 19:00	2	1.7	7.8	14.4	24.0	968,288.4	0.00	1.00
12/15/2021 20:00	2	1.7	8.0	14.4	24.4	981,139.9	0.00	1.00
12/15/2021 21:00	2	1.7	7.8	14.3	23.6	927,266.3	0.00	1.00
12/15/2021 22:00	2	1.7	7.3	14.3	22.7	896,558.0	0.00	1.00
12/15/2021 23:00	2	1.7	7.4	14.3	22.3	872,904.3	0.00	1.00
Average/Sum#:	3	1.7	10.2	14.4	26.4	794,296.3	0.00 #	24.00 #
Minimum:	2	1.3	7.3	14.3	19.0	617,952.8	0.00	1.00
Maximum:	5	1.9	14.0	14.6	34.1	981,139.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/16/2021 00:00	3	1.7	7.3	14.3	23.1	882,448.8	0.00	1.00
12/16/2021 01:00	3	1.9	8.8	14.2	23.8	759,110.8	0.00	1.00
12/16/2021 02:00	5	1.8	13.9	14.5	33.9	617,524.8	0.00	1.00
12/16/2021 03:00	5	1.7	13.7	14.5	33.4	617,738.8	0.00	1.00
12/16/2021 04:00	2	1.6	9.9	14.3	24.0	850,910.5	0.00	1.00
12/16/2021 05:00	2	1.8	9.1	14.0	27.9	996,305.9	0.00	1.00
12/16/2021 06:00	3	1.8	9.2	13.9	29.4	993,615.2	0.00	1.00
12/16/2021 07:00	3	1.8	9.3	13.9	29.8	995,767.2	0.00	1.00
12/16/2021 08:00	3	1.7	8.9	14.1	29.1	1,004,714.4	0.00	1.00
12/16/2021 09:00	2	1.7	8.3	14.2	26.7	978,218.7	0.00	1.00
12/16/2021 10:00	3	1.7	8.8	14.0	28.1	994,916.6	0.00	1.00
12/16/2021 11:00	3	1.8	9.3	14.3	25.1	839,498.6	0.00	1.00
12/16/2021 12:00	4	1.7	12.7	14.5	29.8	619,236.6	0.00	1.00
12/16/2021 13:00	4	1.6	12.6	14.5	28.4	631,433.0	0.00	1.00
12/16/2021 14:00	3	1.7	9.9	14.4	23.6	735,275.6	0.00	1.00
12/16/2021 15:00	3	1.3	9.7	14.1	25.8	855,688.9	0.00	1.00
12/16/2021 16:00	3	1.6	8.9	14.0	28.8	997,893.6	0.00	1.00
12/16/2021 17:00	3	1.6	8.7	14.1	29.5	999,277.0	0.00	1.00
12/16/2021 18:00	3	1.6	8.7	14.1	29.7	1,002,297.8	0.00	1.00
12/16/2021 19:00	3	1.8	8.9	14.0	28.7	1,006,229.2	0.00	1.00
12/16/2021 20:00	3	1.7	8.8	14.1	29.3	1,013,575.4	0.00	1.00
12/16/2021 21:00	4	2.0	12.3	12.9	39.2	1,032,546.0	0.00	1.00
12/16/2021 22:00	3	1.8	9.6	13.8	31.3	1,011,445.3	0.00	1.00
12/16/2021 23:00	4	1.9	10.4	14.3	30.6	760,030.5	0.00	1.00
Average/Sum#:	3	1.7	9.9	14.1	28.7	883,154.1	0.00 #	24.00 #
Minimum:	2	1.3	7.3	12.9	23.1	617,524.8	0.00	1.00
Maximum:	5	2.0	13.9	14.5	39.2	1,032,546.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/17/2021 00:00	4	1.6	13.3	14.6	31.6	628,631.0	0.00	1.00
12/17/2021 01:00	5	1.7	13.6	14.5	33.3	625,441.8	0.00	1.00
12/17/2021 02:00	5	1.6	13.9	14.5	34.1	627,795.5	0.00	1.00
12/17/2021 03:00	5	1.7	13.8	14.5	34.2	626,297.7	0.00	1.00
12/17/2021 04:00	3	1.6	10.4	14.3	27.4	867,924.6	0.00	1.00
12/17/2021 05:00	3	1.6	9.6	14.1	31.8	1,010,353.3	0.00	1.00
12/17/2021 06:00	3	1.7	10.0	14.0	34.9	1,026,076.0	0.00	1.00
12/17/2021 07:00	3	1.7	10.1	13.9	34.3	1,005,157.5	0.00	1.00
12/17/2021 08:00	4	1.7	10.6	14.2	32.5	851,291.4	0.00	1.00
12/17/2021 09:00	5	1.8	13.6	14.5	33.5	625,441.8	0.00	1.00
12/17/2021 10:00	5	1.8	13.4	14.6	33.1	636,891.0	0.00	1.00
12/17/2021 11:00	5	1.7	13.6	14.6	33.4	632,326.3	0.00	1.00
12/17/2021 12:00	5	1.7	13.6	14.6	33.5	631,891.5	0.00	1.00
12/17/2021 13:00	5	1.7	13.6	14.6	33.4	631,891.5	0.00	1.00
12/17/2021 14:00	5	1.6	13.8	14.6	33.7	629,935.2	0.00	1.00
12/17/2021 15:00	2	1.6	10.2	14.3	24.2	837,631.2	0.00	1.00
12/17/2021 16:00	2	1.8	9.7	14.0	28.6	1,009,801.6	0.00	1.00
12/17/2021 17:00	3	1.8	9.5	14.1	31.2	1,010,756.0	0.00	1.00
12/17/2021 18:00	3	1.7	9.6	14.1	32.1	1,012,165.7	0.00	1.00
12/17/2021 19:00	3	1.7	9.5	14.1	32.3	1,013,776.8	0.00	1.00
12/17/2021 20:00	3	1.7	9.5	14.1	32.4	1,013,978.2	0.00	1.00
12/17/2021 21:00	3	1.7	9.5	14.1	32.3	1,012,165.7	0.00	1.00
12/17/2021 22:00	3	1.7	9.5	14.1	32.7	1,013,978.2	0.00	1.00
12/17/2021 23:00	3	1.8	10.0	14.2	29.8	862,328.6	0.00	1.00
Average/Sum#:	4	1.7	11.4	14.3	32.1	826,830.3	0.00 #	24.00 #
Minimum:	2	1.6	9.5	13.9	24.2	625,441.8	0.00	1.00
Maximum:	5	1.8	13.9	14.6	34.9	1,026,076.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/18/2021 00:00	3	1.7	8.3	14.3	23.6	835,556.4	0.00	1.00
12/18/2021 01:00	3	1.7	7.7	14.3	24.6	882,448.8	0.00	1.00
12/18/2021 02:00	3	1.8	9.2	14.3	26.1	846,760.7	0.00	1.00
12/18/2021 03:00	4	1.6	10.7	14.2	28.5	691,457.1	0.00	1.00
12/18/2021 04:00	3	1.7	9.1	14.3	24.8	807,130.4	0.00	1.00
12/18/2021 05:00	3	1.8	9.8	14.2	28.9	850,473.9	0.00	1.00
12/18/2021 06:00	3	1.7	9.7	14.1	33.1	1,014,985.1	0.00	1.00
12/18/2021 07:00	3	1.9	10.3	14.3	29.8	830,161.7	0.00	1.00
12/18/2021 08:00	4	1.9	12.0	14.5	30.1	671,445.9	0.00	1.00
12/18/2021 09:00	5	1.8	13.1	14.5	33.0	657,109.7	0.00	1.00
12/18/2021 10:00	2	1.6	8.1	14.3	24.5	958,182.1	0.00	1.00
12/18/2021 11:00	4	1.8	10.9	14.4	29.4	762,032.0	0.00	1.00
12/18/2021 12:00	5	1.8	13.7	14.6	33.9	630,804.7	0.00	1.00
12/18/2021 13:00	5	1.7	13.7	14.6	33.9	632,761.0	0.00	1.00
12/18/2021 14:00	5	1.7	13.5	14.6	33.4	631,239.4	0.00	1.00
12/18/2021 15:00	4	1.6	12.0	14.5	30.0	677,009.2	0.00	1.00
12/18/2021 16:00	3	1.7	9.7	14.2	26.4	861,715.4	0.00	1.00
12/18/2021 17:00	3	1.6	9.5	14.1	31.8	1,009,950.5	0.00	1.00
12/18/2021 18:00	3	1.6	9.4	14.1	32.6	1,011,360.2	0.00	1.00
12/18/2021 19:00	3	1.6	9.4	14.1	32.7	1,010,957.4	0.00	1.00
12/18/2021 20:00	3	1.6	9.3	14.1	32.6	1,010,957.4	0.00	1.00
12/18/2021 21:00	3	1.6	9.4	14.1	32.9	1,015,387.9	0.00	1.00
12/18/2021 22:00	3	1.6	9.4	14.1	33.0	1,014,783.7	0.00	1.00
12/18/2021 23:00	4	1.8	10.9	14.3	30.1	764,595.3	0.00	1.00
Average/Sum#:	4	1.7	10.4	14.3	30.0	836,636.1	0.00 #	24.00 #
Minimum:	2	1.6	7.7	14.1	23.6	630,804.7	0.00	1.00
Maximum:	5	1.9	13.7	14.6	33.9	1,015,387.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOX, Ppm	Unit CT1 NOX, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/19/2021 00:00	3	1.4	7.8	14.3	24.2	879,543.9	0.00	1.00
12/19/2021 01:00	3	1.5	7.5	14.3	24.6	877,261.6	0.00	1.00
12/19/2021 02:00	3	1.8	8.6	14.2	25.3	829,012.7	0.00	1.00
12/19/2021 03:00	5	1.9	13.4	14.5	33.1	621,590.3	0.00	1.00
12/19/2021 04:00	5	1.7	13.7	14.6	33.7	627,544.2	0.00	1.00
12/19/2021 05:00	3	1.5	10.2	14.3	28.3	837,423.8	0.00	1.00
12/19/2021 06:00	3	1.6	9.8	14.2	30.1	873,774.5	0.00	1.00
12/19/2021 07:00	4	1.8	11.4	14.4	29.1	677,127.7	0.00	1.00
12/19/2021 08:00	5	1.8	13.2	14.6	32.6	629,717.8	0.00	1.00
12/19/2021 09:00	3	1.4	9.0	14.4	24.2	851,782.0	0.00	1.00
12/19/2021 10:00	2	1.5	7.5	14.3	24.2	927,266.3	0.00	1.00
12/19/2021 11:00	4	1.9	11.4	14.4	28.9	671,228.6	0.00	1.00
12/19/2021 12:00	5	1.7	13.6	14.6	33.5	629,283.1	0.00	1.00
12/19/2021 13:00	5	1.5	13.3	14.5	32.4	628,865.4	0.00	1.00
12/19/2021 14:00	3	1.4	10.6	14.4	24.7	704,516.2	0.00	1.00
12/19/2021 15:00	3	1.6	9.5	14.3	25.4	865,434.7	0.00	1.00
12/19/2021 16:00	3	1.5	8.9	14.1	29.0	1,005,721.4	0.00	1.00
12/19/2021 17:00	3	1.5	8.9	14.1	31.4	1,013,172.7	0.00	1.00
12/19/2021 18:00	3	1.5	8.9	14.1	31.6	1,008,540.8	0.00	1.00
12/19/2021 19:00	3	1.6	8.9	14.1	31.4	1,012,367.1	0.00	1.00
12/19/2021 20:00	3	1.6	8.9	14.1	31.1	1,009,749.1	0.00	1.00
12/19/2021 21:00	3	1.6	8.9	14.1	31.3	1,010,353.3	0.00	1.00
12/19/2021 22:00	3	1.6	8.2	14.2	27.2	936,931.5	0.00	1.00
12/19/2021 23:00	3	1.6	7.9	14.2	23.7	804,690.1	0.00	1.00
Average/Sum#:	3	1.6	10.0	14.3	28.8	830,537.5	0.00 #	24.00 #
Minimum:	2	1.4	7.5	14.1	23.7	621,590.3	0.00	1.00
Maximum:	5	1.9	13.7	14.6	33.7	1,013,172.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/20/2021 00:00	4	1.8	11.3	14.4	28.9	674,178.2	0.00	1.00
12/20/2021 01:00	3	1.5	8.2	14.2	22.3	776,279.7	0.00	1.00
12/20/2021 02:00	3	1.4	8.4	14.2	24.3	791,404.7	0.00	1.00
12/20/2021 03:00	4	1.7	10.7	14.2	28.9	734,788.2	0.00	1.00
12/20/2021 04:00	4	1.7	11.5	14.3	28.9	662,925.9	0.00	1.00
12/20/2021 05:00	3	1.5	9.3	14.1	30.9	929,194.7	0.00	1.00
12/20/2021 06:00	3	1.7	9.7	14.0	32.5	1,017,938.8	0.00	1.00
12/20/2021 07:00	3	1.7	9.1	14.1	31.2	981,152.3	0.00	1.00
12/20/2021 08:00	4	1.8	9.9	14.4	29.2	813,016.7	0.00	1.00
12/20/2021 09:00	4	1.8	12.0	14.4	29.8	658,587.8	0.00	1.00
12/20/2021 10:00	5	2.0	13.6	14.5	33.4	625,013.8	0.00	1.00
12/20/2021 11:00	4	1.5	10.4	14.4	26.7	709,783.2	0.00	1.00
12/20/2021 12:00	2	1.3	7.7	14.4	24.1	947,641.7	0.00	1.00
12/20/2021 13:00	2	1.2	7.6	14.4	25.8	980,086.5	0.00	1.00
12/20/2021 14:00	3	1.6	10.5	13.5	34.0	958,041.9	0.00	1.00
12/20/2021 15:00	3	1.9	12.2	13.0	37.7	1,027,068.3	0.00	1.00
12/20/2021 16:00	3	1.7	10.0	13.7	34.0	1,014,705.4	0.00	1.00
12/20/2021 17:00	4	1.9	12.1	12.9	39.5	1,023,987.1	0.00	1.00
12/20/2021 18:00	3	1.8	10.5	13.4	34.8	1,023,233.9	0.00	1.00
12/20/2021 19:00	3	1.8	11.0	13.3	37.5	1,034,816.3	0.00	1.00
12/20/2021 20:00	4	1.9	12.7	12.8	41.8	1,030,449.6	0.00	1.00
12/20/2021 21:00	3	1.8	11.1	13.3	37.2	1,031,032.4	0.00	1.00
12/20/2021 22:00	3	1.8	10.7	13.5	35.7	1,008,747.6	0.00	1.00
12/20/2021 23:00	3	1.6	9.3	13.9	31.6	988,920.0	0.00	1.00
Average/Sum#:	3	1.7	10.4	13.9	31.7	893,458.1	0.00 #	24.00 #
Minimum:	2	1.2	7.6	12.8	22.3	625,013.8	0.00	1.00
Maximum:	5	2.0	13.6	14.5	41.8	1,034,816.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOX, Ppm	Unit CT1 NOX, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/21/2021 00:00	3	1.6	7.6	14.3	26.2	961,709.4	0.00	1.00
12/21/2021 01:00	3	1.6	7.7	14.3	26.8	956,314.7	0.00	1.00
12/21/2021 02:00	3	1.6	8.2	14.3	27.0	956,729.7	0.00	1.00
12/21/2021 03:00	3	1.6	7.8	14.2	26.0	894,826.9	0.00	1.00
12/21/2021 04:00	3	1.6	7.6	14.2	23.9	845,364.1	0.00	1.00
12/21/2021 05:00	3	1.7	8.1	14.3	24.0	861,077.5	0.00	1.00
12/21/2021 06:00	2	1.7	7.6	14.3	24.4	927,058.8	0.00	1.00
12/21/2021 07:00	3	1.7	8.1	14.2	27.0	965,546.4	0.00	1.00
12/21/2021 08:00	4	2.1	13.9	12.5	46.3	1,037,012.9	0.00	1.00
12/21/2021 09:00	4	2.2	13.9	12.5	44.4	1,034,078.4	0.00	1.00
12/21/2021 10:00	3	1.7	8.9	14.2	29.6	1,016,439.9	0.00	1.00
12/21/2021 11:00	3	1.8	8.6	14.3	25.0	844,478.4	0.00	1.00
12/21/2021 12:00	3	1.7	9.4	14.4	23.8	806,907.0	0.00	1.00
12/21/2021 13:00	2	1.7	7.5	14.3	22.8	937,433.2	0.00	1.00
12/21/2021 14:00	2	1.7	8.3	14.2	26.2	978,627.5	0.00	1.00
12/21/2021 15:00	3	1.7	8.9	14.1	29.6	1,013,374.0	0.00	1.00
12/21/2021 16:00	3	1.8	9.0	14.0	28.9	1,007,420.0	0.00	1.00
12/21/2021 17:00	3	1.7	8.7	14.1	29.3	1,008,540.8	0.00	1.00
12/21/2021 18:00	3	1.7	8.8	14.1	29.9	1,007,936.6	0.00	1.00
12/21/2021 19:00	3	1.7	8.7	14.1	29.9	1,007,735.2	0.00	1.00
12/21/2021 20:00	3	1.7	8.8	14.1	29.7	1,011,360.2	0.00	1.00
12/21/2021 21:00	3	1.7	8.7	14.1	30.0	1,010,957.4	0.00	1.00
12/21/2021 22:00	3	1.7	8.8	14.1	30.1	1,010,554.6	0.00	1.00
12/21/2021 23:00	3	1.9	9.8	14.2	28.4	847,816.8	0.00	1.00
Average/Sum#:	3	1.7	8.9	14.1	28.7	956,220.9	0.00 #	24.00 #
Minimum:	2	1.6	7.5	12.5	22.8	806,907.0	0.00	1.00
Maximum:	4	2.2	13.9	14.4	46.3	1,037,012.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOX, Ppm	Unit CT1 NOX, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/22/2021 00:00	5	1.9	13.2	14.6	32.2	632,108.9	0.00	1.00
12/22/2021 01:00	5	1.7	13.3	14.6	32.4	631,456.8	0.00	1.00
12/22/2021 02:00	5	1.7	13.9	14.5	33.8	620,948.4	0.00	1.00
12/22/2021 03:00	5	1.7	13.6	14.5	33.7	620,948.4	0.00	1.00
12/22/2021 04:00	5	1.7	13.5	14.5	33.1	623,302.1	0.00	1.00
12/22/2021 05:00	2	1.5	8.8	14.2	25.2	948,173.1	0.00	1.00
12/22/2021 06:00	3	1.6	9.3	14.1	31.5	1,007,735.2	0.00	1.00
12/22/2021 07:00	3	1.6	9.4	14.1	32.4	1,008,540.8	0.00	1.00
12/22/2021 08:00	3	1.6	9.4	14.1	32.3	1,009,547.7	0.00	1.00
12/22/2021 09:00	3	1.6	9.4	14.1	32.3	1,011,763.0	0.00	1.00
12/22/2021 10:00	3	1.7	9.7	14.2	29.1	872,343.8	0.00	1.00
12/22/2021 11:00	5	1.8	12.9	14.5	31.3	622,018.2	0.00	1.00
12/22/2021 12:00	5	1.6	12.9	14.5	30.8	624,585.9	0.00	1.00
12/22/2021 13:00	2	1.6	9.9	14.2	24.2	844,546.5	0.00	1.00
12/22/2021 14:00	3	1.8	10.1	13.9	30.0	1,007,700.7	0.00	1.00
12/22/2021 15:00	3	1.8	9.9	13.9	30.5	1,001,440.5	0.00	1.00
12/22/2021 16:00	3	1.8	9.8	13.9	30.0	998,701.6	0.00	1.00
12/22/2021 17:00	3	1.8	9.8	13.9	29.7	1,000,266.7	0.00	1.00
12/22/2021 18:00	3	1.8	9.8	13.9	29.9	999,288.5	0.00	1.00
12/22/2021 19:00	3	1.8	9.7	13.9	29.4	980,703.5	0.00	1.00
12/22/2021 20:00	4	1.8	11.6	14.4	27.4	625,510.9	0.00	1.00
12/22/2021 21:00	4	1.6	11.3	14.5	26.0	635,926.4	0.00	1.00
12/22/2021 22:00	3	1.7	10.1	14.4	22.8	687,451.0	0.00	1.00
12/22/2021 23:00	3	1.7	10.7	14.4	24.3	630,567.3	0.00	1.00
Average/Sum#:	4	1.7	10.9	14.2	29.8	818,565.7	0.00 #	24.00 #
Minimum:	2	1.5	8.8	13.9	22.8	620,948.4	0.00	1.00
Maximum:	5	1.9	13.9	14.6	33.8	1,011,763.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/23/2021 00:00	2	1.7	7.7	14.3	18.6	796,548.5	0.00	1.00
12/23/2021 01:00	3	1.7	9.5	14.3	22.4	651,099.0	0.00	1.00
12/23/2021 02:00	4	1.6	11.7	14.5	26.1	629,507.3	0.00	1.00
12/23/2021 03:00	4	1.7	11.2	14.5	25.1	620,948.4	0.00	1.00
12/23/2021 04:00	4	1.6	11.2	14.5	25.5	618,808.6	0.00	1.00
12/23/2021 05:00	4	1.6	11.1	14.5	25.0	620,092.5	0.00	1.00
12/23/2021 06:00	4	1.6	11.2	14.5	25.3	622,446.2	0.00	1.00
12/23/2021 07:00	4	1.6	11.3	14.5	25.8	620,948.4	0.00	1.00
12/23/2021 08:00	4	1.6	11.1	14.5	25.2	620,948.4	0.00	1.00
12/23/2021 09:00	4	1.6	11.2	14.5	25.5	620,948.4	0.00	1.00
12/23/2021 10:00	3	1.6	11.1	14.5	24.7	623,516.0	0.00	1.00
12/23/2021 11:00	3	1.6	11.1	14.5	24.7	622,232.2	0.00	1.00
12/23/2021 12:00	3	1.6	10.8	14.5	23.4	620,734.4	0.00	1.00
12/23/2021 13:00	3	1.6	10.8	14.5	23.5	622,018.2	0.00	1.00
12/23/2021 14:00	3	1.6	10.7	14.5	22.9	622,018.2	0.00	1.00
12/23/2021 15:00	3	1.6	10.6	14.5	22.6	621,376.3	0.00	1.00
12/23/2021 16:00	3	1.6	10.7	14.5	23.4	620,734.4	0.00	1.00
12/23/2021 17:00	3	1.6	10.7	14.5	23.8	621,162.3	0.00	1.00
12/23/2021 18:00	3	1.6	10.8	14.5	24.1	623,302.1	0.00	1.00
12/23/2021 19:00	4	1.6	10.9	14.5	24.9	618,380.7	0.00	1.00
12/23/2021 20:00	4	1.6	11.3	14.5	25.7	619,450.6	0.00	1.00
12/23/2021 21:00	4	1.6	11.3	14.5	25.9	617,524.8	0.00	1.00
12/23/2021 22:00	4	1.6	11.3	14.5	25.7	616,454.9	0.00	1.00
12/23/2021 23:00	4	1.6	11.3	14.5	25.9	619,664.5	0.00	1.00
Average/Sum#:	4	1.6	10.9	14.5	24.4	629,619.4	0.00 #	24.00 #
Minimum:	2	1.6	7.7	14.3	18.6	616,454.9	0.00	1.00
Maximum:	4	1.7	11.7	14.5	26.1	796,548.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOX, Ppm	Unit CT1 NOX, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/24/2021 00:00	4	1.6	11.4	14.5	26.0	620,734.4	0.00	1.00
12/24/2021 01:00	4	1.6	11.2	14.5	25.3	620,734.4	0.00	1.00
12/24/2021 02:00	4	1.6	11.7	14.5	26.0	619,878.5	0.00	1.00
12/24/2021 03:00	4	1.7	11.4	14.5	26.2	621,162.3	0.00	1.00
12/24/2021 04:00	4	1.6	11.3	14.5	26.0	621,162.3	0.00	1.00
12/24/2021 05:00	4	1.6	11.4	14.5	26.1	621,376.3	0.00	1.00
12/24/2021 06:00	4	1.6	11.3	14.5	26.2	621,590.3	0.00	1.00
12/24/2021 07:00	4	1.6	11.2	14.5	25.6	621,590.3	0.00	1.00
12/24/2021 08:00	4	1.7	11.1	14.5	25.4	631,219.1	0.00	1.00
12/24/2021 09:00	4	1.6	11.6	14.5	26.7	621,804.3	0.00	1.00
12/24/2021 10:00	4	1.6	11.9	14.5	27.4	622,446.2	0.00	1.00
12/24/2021 11:00	4	1.6	12.5	14.5	28.5	620,948.4	0.00	1.00
12/24/2021 12:00	4	1.6	12.5	14.5	28.4	620,948.4	0.00	1.00
12/24/2021 13:00	4	1.6	12.4	14.5	27.8	620,520.4	0.00	1.00
12/24/2021 14:00	4	1.6	12.2	14.5	26.9	620,948.4	0.00	1.00
12/24/2021 15:00	4	1.6	12.2	14.5	27.2	620,734.4	0.00	1.00
12/24/2021 16:00	4	1.6	12.0	14.5	26.6	622,018.2	0.00	1.00
12/24/2021 17:00	4	1.6	12.0	14.5	27.5	621,162.3	0.00	1.00
12/24/2021 18:00	4	1.6	12.1	14.5	27.9	619,236.6	0.00	1.00
12/24/2021 19:00	4	1.6	12.3	14.5	28.8	619,022.6	0.00	1.00
12/24/2021 20:00	4	1.6	12.5	14.5	29.5	618,380.7	0.00	1.00
12/24/2021 21:00	4	1.6	12.7	14.5	29.9	619,236.6	0.00	1.00
12/24/2021 22:00	4	1.6	12.7	14.5	29.8	618,166.7	0.00	1.00
12/24/2021 23:00	4	1.6	12.7	14.5	29.5	618,808.6	0.00	1.00
Average/Sum#:	4	1.6	11.9	14.5	27.3	620,992.9	0.00 #	24.00 #
Minimum:	4	1.6	11.1	14.5	25.3	618,166.7	0.00	1.00
Maximum:	4	1.7	12.7	14.5	29.9	631,219.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/25/2021 00:00	4	1.6	12.7	14.5	29.8	619,664.5	0.00	1.00
12/25/2021 01:00	4	1.6	12.6	14.5	29.5	619,664.5	0.00	1.00
12/25/2021 02:00	4	1.6	13.3	14.5	30.3	619,022.6	0.00	1.00
12/25/2021 03:00	5	1.7	13.0	14.5	30.6	618,380.7	0.00	1.00
12/25/2021 04:00	4	1.6	13.0	14.5	30.6	619,022.6	0.00	1.00
12/25/2021 05:00	4	1.6	12.8	14.5	30.3	619,450.6	0.00	1.00
12/25/2021 06:00	4	1.6	12.6	14.5	29.6	618,594.7	0.00	1.00
12/25/2021 07:00	4	1.6	12.8	14.5	29.7	620,520.4	0.00	1.00
12/25/2021 08:00	4	1.6	12.7	14.5	29.9	619,022.6	0.00	1.00
12/25/2021 09:00	4	1.6	12.7	14.5	30.0	618,380.7	0.00	1.00
12/25/2021 10:00	4	1.6	12.5	14.5	29.9	620,948.4	0.00	1.00
12/25/2021 11:00	4	1.6	12.3	14.5	28.8	621,804.3	0.00	1.00
12/25/2021 12:00	4	1.7	12.3	14.5	29.2	622,660.1	0.00	1.00
12/25/2021 13:00	4	1.6	12.1	14.5	28.7	624,585.9	0.00	1.00
12/25/2021 14:00	4	1.6	11.7	14.5	27.6	625,013.8	0.00	1.00
12/25/2021 15:00	4	1.6	10.8	14.4	25.1	638,151.8	0.00	1.00
12/25/2021 16:00	4	1.8	11.8	14.5	27.1	621,804.3	0.00	1.00
12/25/2021 17:00	4	1.7	12.0	14.5	28.4	622,874.1	0.00	1.00
12/25/2021 18:00	4	1.7	12.1	14.5	28.8	621,376.3	0.00	1.00
12/25/2021 19:00	4	1.7	12.4	14.5	29.4	621,162.3	0.00	1.00
12/25/2021 20:00	4	1.7	12.7	14.5	30.4	622,446.2	0.00	1.00
12/25/2021 21:00	5	1.7	13.2	14.5	31.8	621,376.3	0.00	1.00
12/25/2021 22:00	5	1.7	13.5	14.5	32.4	619,664.5	0.00	1.00
12/25/2021 23:00	5	1.7	13.2	14.5	31.7	617,952.8	0.00	1.00
Average/Sum#:	4	1.6	12.5	14.5	29.6	621,397.7	0.00 #	24.00 #
Minimum:	4	1.6	10.8	14.4	25.1	617,952.8	0.00	1.00
Maximum:	5	1.8	13.5	14.5	32.4	638,151.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/26/2021 00:00	5	1.7	13.3	14.5	32.0	617,524.8	0.00	1.00
12/26/2021 01:00	5	1.7	13.3	14.5	32.2	617,738.8	0.00	1.00
12/26/2021 02:00	5	1.6	14.0	14.5	32.9	617,952.8	0.00	1.00
12/26/2021 03:00	5	1.7	13.8	14.5	33.4	622,446.2	0.00	1.00
12/26/2021 04:00	5	1.6	13.7	14.5	33.2	622,660.1	0.00	1.00
12/26/2021 05:00	5	1.7	13.8	14.5	33.2	624,585.9	0.00	1.00
12/26/2021 06:00	5	1.6	13.6	14.5	32.8	625,441.8	0.00	1.00
12/26/2021 07:00	4	1.7	13.0	14.5	30.9	632,716.9	0.00	1.00
12/26/2021 08:00	5	1.7	13.7	14.6	33.6	629,500.5	0.00	1.00
12/26/2021 09:00	5	1.7	13.9	14.6	34.0	632,326.3	0.00	1.00
12/26/2021 10:00	5	1.7	13.8	14.5	33.6	623,302.1	0.00	1.00
12/26/2021 11:00	4	1.7	13.0	14.5	30.7	635,926.4	0.00	1.00
12/26/2021 12:00	5	1.7	13.1	14.5	31.7	627,153.6	0.00	1.00
12/26/2021 13:00	4	1.6	12.0	14.4	28.0	660,273.2	0.00	1.00
12/26/2021 14:00	4	1.8	12.4	14.5	29.3	643,201.5	0.00	1.00
12/26/2021 15:00	4	1.8	12.4	14.4	29.2	634,780.9	0.00	1.00
12/26/2021 16:00	4	1.2	9.7	14.4	37.8	861,684.0	0.00	1.00
12/26/2021 17:00	2	1.6	9.7	14.0	23.7	1,005,236.9	0.00	1.00
12/26/2021 18:00	4	2.0	11.3	14.3	29.2	753,390.9	0.00	1.00
12/26/2021 19:00	5	1.8	13.5	14.5	32.8	628,009.5	0.00	1.00
12/26/2021 20:00	5	1.7	12.9	14.5	31.6	641,917.7	0.00	1.00
12/26/2021 21:00	2	1.6	7.6	14.3	20.3	902,575.2	0.00	1.00
12/26/2021 22:00	4	2.1	11.8	14.4	29.3	685,133.6	0.00	1.00
12/26/2021 23:00	5	1.9	13.5	14.5	32.7	624,158.0	0.00	1.00
Average/Sum#:	4	1.7	12.6	14.5	31.2	673,734.9	0.00 #	24.00 #
Minimum:	2	1.2	7.6	14.0	20.3	617,524.8	0.00	1.00
Maximum:	5	2.1	14.0	14.6	37.8	1,005,236.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/27/2021 00:00	5	1.7	13.1	14.5	31.7	628,009.5	0.00	1.00
12/27/2021 01:00	5	1.7	12.7	14.5	30.6	624,158.0	0.00	1.00
12/27/2021 02:00	5	1.7	13.8	14.5	32.7	624,371.9	0.00	1.00
12/27/2021 03:00	5	1.7	13.2	14.5	31.5	623,516.0	0.00	1.00
12/27/2021 04:00	5	1.7	13.1	14.5	31.3	619,664.5	0.00	1.00
12/27/2021 05:00	3	1.6	9.9	14.3	25.3	855,475.3	0.00	1.00
12/27/2021 06:00	3	1.8	9.8	14.0	29.7	1,006,030.8	0.00	1.00
12/27/2021 07:00	3	1.8	9.7	14.0	30.9	1,005,633.8	0.00	1.00
12/27/2021 08:00	3	1.8	9.8	13.9	31.4	1,000,266.7	0.00	1.00
12/27/2021 09:00	3	1.8	9.3	14.0	27.8	913,941.9	0.00	1.00
12/27/2021 10:00	3	1.7	9.4	14.3	24.1	747,373.7	0.00	1.00
12/27/2021 11:00	2	1.8	8.3	14.3	23.9	918,759.3	0.00	1.00
12/27/2021 12:00	4	1.8	12.6	14.5	30.1	619,664.5	0.00	1.00
12/27/2021 13:00	4	1.5	12.0	14.5	28.1	655,184.0	0.00	1.00
12/27/2021 14:00	2	1.7	8.2	14.3	18.7	869,999.5	0.00	1.00
12/27/2021 15:00	2	1.8	9.4	14.1	27.1	952,756.9	0.00	1.00
12/27/2021 16:00	2	1.8	10.4	13.9	30.6	998,310.4	0.00	1.00
12/27/2021 17:00	3	1.8	10.4	13.9	31.1	1,009,461.4	0.00	1.00
12/27/2021 18:00	3	1.8	10.5	13.8	32.4	1,005,466.1	0.00	1.00
12/27/2021 19:00	3	1.8	10.6	13.8	33.1	1,014,531.3	0.00	1.00
12/27/2021 20:00	3	1.8	10.7	13.7	33.2	1,004,244.5	0.00	1.00
12/27/2021 21:00	3	1.8	9.9	14.0	32.1	1,002,061.4	0.00	1.00
12/27/2021 22:00	3	1.7	9.2	14.1	28.4	902,410.4	0.00	1.00
12/27/2021 23:00	4	1.9	10.5	14.4	26.5	735,064.9	0.00	1.00
Average/Sum#:	3	1.8	10.7	14.2	29.3	847,348.2	0.00 #	24.00 #
Minimum:	2	1.5	8.2	13.7	18.7	619,664.5	0.00	1.00
Maximum:	5	1.9	13.8	14.5	33.2	1,014,531.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/28/2021 00:00	4	1.9	12.6	14.4	30.0	635,412.9	0.00	1.00
12/28/2021 01:00	5	1.8	13.6	14.5	32.9	625,013.8	0.00	1.00
12/28/2021 02:00	5	1.7	13.9	14.5	33.0	626,083.7	0.00	1.00
12/28/2021 03:00	4	1.7	13.0	14.4	31.2	632,674.1	0.00	1.00
12/28/2021 04:00	5	1.8	13.5	14.5	32.4	625,869.7	0.00	1.00
12/28/2021 05:00	2	1.6	8.2	14.3	19.9	830,991.6	0.00	1.00
12/28/2021 06:00	3	1.7	8.0	14.2	22.1	802,033.0	0.00	1.00
12/28/2021 07:00	5	2.1	12.4	14.5	30.4	641,703.7	0.00	1.00
12/28/2021 08:00	4	1.8	11.1	14.4	28.5	719,263.8	0.00	1.00
12/28/2021 09:00	4	1.7	10.4	14.3	26.0	694,671.6	0.00	1.00
12/28/2021 10:00	5	1.9	13.6	14.5	33.5	620,948.4	0.00	1.00
12/28/2021 11:00	5	1.7	13.7	14.5	33.8	620,306.5	0.00	1.00
12/28/2021 12:00	5	1.6	13.7	14.5	33.0	621,590.3	0.00	1.00
12/28/2021 13:00	5	1.6	13.5	14.5	32.4	619,664.5	0.00	1.00
12/28/2021 14:00	5	1.6	13.7	14.5	33.0	619,236.6	0.00	1.00
12/28/2021 15:00	3	1.5	11.3	14.4	26.8	714,207.5	0.00	1.00
12/28/2021 16:00	3	1.8	9.6	14.4	22.2	800,165.2	0.00	1.00
12/28/2021 17:00	2	1.7	8.1	14.4	23.3	984,089.4	0.00	1.00
12/28/2021 18:00	2	1.7	7.7	14.3	23.0	907,969.9	0.00	1.00
12/28/2021 19:00	3	1.6	7.8	14.2	23.6	812,457.0	0.00	1.00
12/28/2021 20:00	3	1.8	8.4	14.3	23.0	807,337.9	0.00	1.00
12/28/2021 21:00	4	1.8	11.7	14.4	29.3	653,742.1	0.00	1.00
12/28/2021 22:00	4	1.6	12.2	14.5	29.4	632,930.8	0.00	1.00
12/28/2021 23:00	4	1.6	12.5	14.5	30.2	629,507.3	0.00	1.00
Average/Sum#:	4	1.7	11.4	14.4	28.5	703,244.6	0.00 #	24.00 #
Minimum:	2	1.5	7.7	14.2	19.9	619,236.6	0.00	1.00
Maximum:	5	2.1	13.9	14.5	33.8	984,089.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/29/2021 00:00	5	1.6	12.8	14.5	31.2	631,005.1	0.00	1.00
12/29/2021 01:00	4	1.6	12.5	14.5	30.3	629,293.3	0.00	1.00
12/29/2021 02:00	5	1.6	13.4	14.5	32.0	620,520.4	0.00	1.00
12/29/2021 03:00	5	1.6	13.2	14.5	32.0	619,236.6	0.00	1.00
12/29/2021 04:00	5	1.6	13.2	14.5	32.0	620,092.5	0.00	1.00
12/29/2021 05:00	5	1.6	13.2	14.4	31.8	615,398.3	0.00	1.00
12/29/2021 06:00	4	1.5	12.0	14.4	28.9	634,148.8	0.00	1.00
12/29/2021 07:00	5	1.8	13.1	14.5	30.6	621,162.3	0.00	1.00
12/29/2021 08:00	5	1.7	13.4	14.5	32.6	620,734.4	0.00	1.00
12/29/2021 09:00	5	1.7	13.3	14.5	32.3	619,022.6	0.00	1.00
12/29/2021 10:00	5	1.7	13.3	14.5	32.0	618,380.7	0.00	1.00
12/29/2021 11:00	5	1.6	13.1	14.5	31.7	619,450.6	0.00	1.00
12/29/2021 12:00	5	1.7	13.1	14.5	31.8	620,948.4	0.00	1.00
12/29/2021 13:00	4	1.6	12.4	14.4	30.2	640,258.6	0.00	1.00
12/29/2021 14:00	3	1.6	9.0	14.3	22.2	772,272.4	0.00	1.00
12/29/2021 15:00	3	1.7	9.3	14.3	24.5	789,078.9	0.00	1.00
12/29/2021 16:00	3	1.8	9.8	14.3	25.6	779,741.9	0.00	1.00
12/29/2021 17:00	2	1.6	8.1	14.3	26.1	951,749.9	0.00	1.00
12/29/2021 18:00	3	1.6	8.2	14.3	26.7	956,729.7	0.00	1.00
12/29/2021 19:00	3	1.6	8.4	14.3	27.5	968,764.0	0.00	1.00
12/29/2021 20:00	3	1.6	8.4	14.3	27.9	969,594.0	0.00	1.00
12/29/2021 21:00	4	1.8	10.9	14.3	29.0	724,550.0	0.00	1.00
12/29/2021 22:00	5	1.8	13.3	14.5	32.3	629,079.3	0.00	1.00
12/29/2021 23:00	5	1.7	13.5	14.5	33.0	621,804.3	0.00	1.00
Average/Sum#:	4	1.7	11.7	14.4	29.8	703,875.7	0.00 #	24.00 #
Minimum:	2	1.5	8.1	14.3	22.2	615,398.3	0.00	1.00
Maximum:	5	1.8	13.5	14.5	33.0	969,594.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/30/2021 00:00	5	1.7	13.4	14.5	32.7	620,520.4	0.00	1.00
12/30/2021 01:00	5	1.7	13.5	14.5	33.0	620,948.4	0.00	1.00
12/30/2021 02:00	5	1.6	13.9	14.5	33.9	620,306.5	0.00	1.00
12/30/2021 03:00	5	1.7	13.6	14.5	33.5	619,236.6	0.00	1.00
12/30/2021 04:00	5	1.7	13.6	14.5	33.3	621,590.3	0.00	1.00
12/30/2021 05:00	2	1.6	9.3	14.1	24.8	923,555.9	0.00	1.00
12/30/2021 06:00	3	1.8	9.6	14.1	30.2	1,007,332.5	0.00	1.00
12/30/2021 07:00	3	1.7	9.4	14.1	31.1	1,005,721.4	0.00	1.00
12/30/2021 08:00	3	1.7	9.4	14.1	31.5	1,006,728.3	0.00	1.00
12/30/2021 09:00	3	1.7	9.4	14.1	31.2	1,008,138.0	0.00	1.00
12/30/2021 10:00	4	1.9	12.0	14.4	29.6	655,427.6	0.00	1.00
12/30/2021 11:00	5	1.6	13.2	14.5	32.4	622,660.1	0.00	1.00
12/30/2021 12:00	5	1.5	13.1	14.5	32.1	623,302.1	0.00	1.00
12/30/2021 13:00	5	1.5	12.9	14.5	31.5	623,302.1	0.00	1.00
12/30/2021 14:00	4	1.6	12.5	14.5	28.2	624,585.9	0.00	1.00
12/30/2021 15:00	4	1.6	12.2	14.5	28.3	625,655.8	0.00	1.00
12/30/2021 16:00	2	1.6	9.5	14.2	22.8	845,159.7	0.00	1.00
12/30/2021 17:00	2	1.8	9.3	14.0	27.4	1,002,656.8	0.00	1.00
12/30/2021 18:00	3	1.8	9.3	14.0	29.2	1,002,259.9	0.00	1.00
12/30/2021 19:00	3	1.8	9.3	14.0	29.9	1,005,832.3	0.00	1.00
12/30/2021 20:00	3	1.8	9.3	14.0	30.1	1,006,626.2	0.00	1.00
12/30/2021 21:00	3	1.8	9.3	14.0	30.3	1,003,252.2	0.00	1.00
12/30/2021 22:00	4	1.7	9.9	14.2	29.3	781,389.5	0.00	1.00
12/30/2021 23:00	4	1.7	12.8	14.5	30.6	626,511.7	0.00	1.00
Average/Sum#:	4	1.7	11.2	14.3	30.3	795,945.8	0.00 #	24.00 #
Minimum:	2	1.5	9.3	14.0	22.8	619,236.6	0.00	1.00
Maximum:	5	1.9	13.9	14.5	33.9	1,008,138.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:15 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/31/2021 00:00	5	1.7	13.1	14.5	32.2	622,660.1	0.00	1.00
12/31/2021 01:00	5	1.7	13.2	14.5	32.1	619,664.5	0.00	1.00
12/31/2021 02:00	5	1.6	13.7	14.5	33.6	620,520.4	0.00	1.00
12/31/2021 03:00	5	1.6	13.4	14.5	33.1	621,590.3	0.00	1.00
12/31/2021 04:00	5	1.7	13.4	14.5	32.7	621,590.3	0.00	1.00
12/31/2021 05:00	5	1.7	13.4	14.5	32.7	619,878.5	0.00	1.00
12/31/2021 06:00	5	1.7	13.5	14.5	33.0	621,162.3	0.00	1.00
12/31/2021 07:00	5	1.7	13.6	14.5	33.2	622,660.1	0.00	1.00
12/31/2021 08:00	5	1.7	13.1	14.5	31.9	625,441.8	0.00	1.00
12/31/2021 09:00	5	1.7	13.2	14.5	32.3	627,367.5	0.00	1.00
12/31/2021 10:00	5	1.6	13.1	14.5	32.0	623,088.1	0.00	1.00
12/31/2021 11:00	5	1.6	13.2	14.5	32.0	617,952.8	0.00	1.00
12/31/2021 12:00	5	1.4	13.2	14.5	32.0	617,952.8	0.00	1.00
12/31/2021 13:00	5	1.4	13.1	14.5	31.9	617,738.8	0.00	1.00
12/31/2021 14:00	5	1.4	13.3	14.5	32.5	616,882.9	0.00	1.00
12/31/2021 15:00	5	1.4	13.2	14.5	32.3	616,882.9	0.00	1.00
12/31/2021 16:00	3	1.3	11.0	14.5	26.3	725,581.0	0.00	1.00
12/31/2021 17:00	2	1.5	8.0	14.2	18.2	765,446.9	0.00	1.00
12/31/2021 18:00	2	1.5	7.6	14.3	21.9	843,855.9	0.00	1.00
12/31/2021 19:00	2	1.5	7.7	14.4	25.0	955,436.9	0.00	1.00
12/31/2021 20:00	3	1.5	7.6	14.3	24.1	862,114.9	0.00	1.00
12/31/2021 21:00	2	1.6	7.8	14.3	24.9	940,753.1	0.00	1.00
12/31/2021 22:00	3	1.6	8.2	14.2	24.2	800,602.3	0.00	1.00
12/31/2021 23:00	4	1.9	12.0	14.4	29.8	644,682.9	0.00	1.00
Average/Sum#:	4	1.6	11.8	14.4	29.7	686,312.8	0.00 #	24.00 #
Minimum:	2	1.3	7.6	14.2	18.2	616,882.9	0.00	1.00
Maximum:	5	1.9	13.7	14.5	33.6	955,436.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/01/2021 00:00	0	1.4	11.8	14.5	16.2	744,410.5	0.00	1.00
10/01/2021 01:00	1	1.7	13.7	14.6	21.6	684,494.8	0.00	1.00
10/01/2021 02:00	1	1.6	14.6	14.7	23.9	678,969.4	0.00	1.00
10/01/2021 03:00	0	1.6	14.0	14.6	21.1	684,929.6	0.00	1.00
10/01/2021 04:00	0	1.1	9.9	14.5	20.0	866,160.9	0.00	1.00
10/01/2021 05:00	0	1.7	9.6	14.4	12.1	915,196.8	0.00	1.00
10/01/2021 06:00	1	1.5	13.5	14.5	27.6	763,026.1	0.00	1.00
10/01/2021 07:00	1	1.2	14.4	14.5	23.7	733,497.9	0.00	1.00
10/01/2021 08:00	1	1.6	15.5	14.7	24.1	670,797.1	0.00	1.00
10/01/2021 09:00	1	1.6	16.5	14.8	26.1	664,956.6	0.00	1.00
10/01/2021 10:00	0	1.5	12.6	14.7	16.8	687,804.4	0.00	1.00
10/01/2021 11:00	0	1.6	11.3	14.6	15.8	720,143.3	0.00	1.00
10/01/2021 12:00	0	1.5	9.5	14.5	12.4	850,968.9	0.00	1.00
10/01/2021 13:00	0	1.8	9.2	14.0	16.2	1,037,190.1	0.00	1.00
10/01/2021 14:00	0	1.6	8.1	14.4	13.9	998,626.4	0.00	1.00
10/01/2021 15:00	0	1.3	10.1	14.6	18.2	836,218.3	0.00	1.00
10/01/2021 16:00	0	1.5	8.6	14.5	13.6	948,754.3	0.00	1.00
10/01/2021 17:00	0	1.6	7.8	14.5	13.0	1,001,391.6	0.00	1.00
10/01/2021 18:00	0	1.7	7.7	14.4	12.6	938,161.0	0.00	1.00
10/01/2021 19:00	0	1.7	7.9	14.3	12.9	885,768.6	0.00	1.00
10/01/2021 20:00	0	1.7	7.9	14.5	14.7	1,021,505.0	0.00	1.00
10/01/2021 21:00	0	1.7	8.2	14.4	14.5	974,608.8	0.00	1.00
10/01/2021 22:00	1	1.8	11.6	14.4	19.8	746,652.3	0.00	1.00
10/01/2021 23:00	0	1.6	13.7	14.7	20.9	693,326.3	0.00	1.00
Average/Sum#:	0	1.6	11.2	14.5	18.0	822,815.0	0.00 #	24.00 #
Minimum:	0	1.1	7.7	14.0	12.1	664,956.6	0.00	1.00
Maximum:	1	1.8	16.5	14.8	27.6	1,037,190.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/02/2021 00:00	0	1.6	9.7	14.4	14.7	816,809.0	0.00	1.00
10/02/2021 01:00	0	1.5	12.4	14.5	19.0	733,711.9	0.00	1.00
10/02/2021 02:00	0	1.5	12.1	14.4	18.6	737,593.0	0.00	1.00
10/02/2021 03:00	0	1.6	13.0	14.4	19.9	714,207.5	0.00	1.00
10/02/2021 04:00	0	1.2	11.7	14.4	18.0	770,459.2	0.00	1.00
10/02/2021 05:00	0	1.3	14.4	14.5	24.5	724,083.1	0.00	1.00
10/02/2021 06:00	0	1.6	8.2	14.4	11.7	999,258.4	0.00	1.00
10/02/2021 07:00	1	1.8	12.2	14.4	22.6	807,539.0	0.00	1.00
10/02/2021 08:00	1	1.5	17.8	14.8	28.7	665,630.0	0.00	1.00
10/02/2021 09:00	1	1.5	17.3	14.8	26.7	663,160.6	0.00	1.00
10/02/2021 10:00	1	1.6	16.6	14.8	26.2	659,568.7	0.00	1.00
10/02/2021 11:00	0	1.6	13.2	14.8	18.6	679,997.8	0.00	1.00
10/02/2021 12:00	0	1.6	11.7	14.8	15.7	694,590.0	0.00	1.00
10/02/2021 13:00	0	1.5	8.7	14.5	11.1	894,619.3	0.00	1.00
10/02/2021 14:00	0	1.6	8.2	14.4	11.8	904,030.8	0.00	1.00
10/02/2021 15:00	0	1.5	10.4	14.5	16.5	832,567.2	0.00	1.00
10/02/2021 16:00	0	1.6	8.6	14.5	13.3	928,640.9	0.00	1.00
10/02/2021 17:00	0	1.6	8.0	14.5	14.3	1,031,347.7	0.00	1.00
10/02/2021 18:00	0	1.6	7.9	14.5	14.4	1,043,758.1	0.00	1.00
10/02/2021 19:00	0	1.6	7.8	14.5	14.6	1,042,902.3	0.00	1.00
10/02/2021 20:00	0	1.6	7.9	14.5	14.9	1,042,688.3	0.00	1.00
10/02/2021 21:00	0	1.6	7.9	14.4	13.8	985,985.6	0.00	1.00
10/02/2021 22:00	0	1.7	8.2	14.4	14.5	956,911.6	0.00	1.00
10/02/2021 23:00	0	1.7	8.5	14.4	14.9	902,766.7	0.00	1.00
Average/Sum#:	0	1.6	10.9	14.5	17.5	843,034.4	0.00 #	24.00 #
Minimum:	0	1.2	7.8	14.4	11.1	659,568.7	0.00	1.00
Maximum:	1	1.8	17.8	14.8	28.7	1,043,758.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/03/2021 00:00	0	1.6	11.5	14.5	18.2	766,663.7	0.00	1.00
10/03/2021 01:00	0	1.6	14.3	14.7	21.7	679,411.2	0.00	1.00
10/03/2021 02:00	1	1.6	14.5	14.7	22.4	678,527.7	0.00	1.00
10/03/2021 03:00	1	1.6	15.2	14.6	24.0	669,713.7	0.00	1.00
10/03/2021 04:00	1	1.6	16.1	14.6	24.9	669,061.6	0.00	1.00
10/03/2021 05:00	1	1.6	15.7	14.6	24.7	669,279.0	0.00	1.00
10/03/2021 06:00	1	1.6	15.2	14.6	23.8	683,842.7	0.00	1.00
10/03/2021 07:00	1	1.6	18.0	14.7	30.9	660,636.8	0.00	1.00
10/03/2021 08:00	1	1.5	17.6	14.7	26.3	657,765.5	0.00	1.00
10/03/2021 09:00	1	1.6	17.4	14.8	29.0	661,589.1	0.00	1.00
10/03/2021 10:00	1	1.6	17.1	14.8	26.8	657,772.7	0.00	1.00
10/03/2021 11:00	0	1.6	14.8	14.8	20.5	670,344.5	0.00	1.00
10/03/2021 12:00	0	1.6	12.4	14.8	17.8	683,814.2	0.00	1.00
10/03/2021 13:00	0	1.4	11.0	14.7	15.1	735,071.7	0.00	1.00
10/03/2021 14:00	0	1.4	9.7	14.6	13.8	839,478.9	0.00	1.00
10/03/2021 15:00	0	1.5	8.8	14.5	12.5	908,955.4	0.00	1.00
10/03/2021 16:00	0	1.8	9.5	13.9	16.5	983,051.1	0.00	1.00
10/03/2021 17:00	0	1.8	9.0	14.0	17.3	1,031,236.1	0.00	1.00
10/03/2021 18:00	0	1.7	9.0	14.1	17.6	1,042,172.2	0.00	1.00
10/03/2021 19:00	0	1.7	9.0	14.1	18.1	1,035,325.1	0.00	1.00
10/03/2021 20:00	0	1.7	9.3	14.0	18.9	1,033,419.2	0.00	1.00
10/03/2021 21:00	0	1.8	9.3	14.0	18.9	1,037,785.5	0.00	1.00
10/03/2021 22:00	1	1.8	10.5	14.3	19.9	882,241.3	0.00	1.00
10/03/2021 23:00	0	1.4	12.6	14.5	18.9	712,956.6	0.00	1.00
Average/Sum#:	0	1.6	12.8	14.5	20.8	793,754.8	0.00 #	24.00 #
Minimum:	0	1.4	8.8	13.9	12.5	657,765.5	0.00	1.00
Maximum:	1	1.8	18.0	14.8	30.9	1,042,172.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/04/2021 00:00	0	1.6	13.3	14.6	19.9	684,277.5	0.00	1.00
10/04/2021 01:00	0	1.4	11.5	14.5	15.5	742,698.8	0.00	1.00
10/04/2021 02:00	1	1.6	13.8	14.6	22.4	707,970.7	0.00	1.00
10/04/2021 03:00	0	1.5	7.9	14.4	11.4	1,001,154.6	0.00	1.00
10/04/2021 04:00	0	1.7	8.5	14.3	14.3	964,821.7	0.00	1.00
10/04/2021 05:00	0	1.7	8.4	14.4	15.3	1,014,006.1	0.00	1.00
10/04/2021 06:00	0	1.7	8.4	14.4	15.7	1,022,854.7	0.00	1.00
10/04/2021 07:00	0	1.7	8.4	14.4	14.8	985,564.2	0.00	1.00
10/04/2021 08:00	0	1.6	8.1	14.4	15.1	1,023,697.4	0.00	1.00
10/04/2021 09:00	0	1.7	8.4	14.3	14.0	917,514.3	0.00	1.00
10/04/2021 10:00	0	1.7	7.9	14.5	13.8	1,003,103.4	0.00	1.00
10/04/2021 11:00	0	1.6	7.9	14.5	14.1	1,013,588.0	0.00	1.00
10/04/2021 12:00	0	1.6	7.8	14.5	14.4	1,040,120.6	0.00	1.00
10/04/2021 13:00	0	1.7	8.1	14.5	15.1	1,039,906.6	0.00	1.00
10/04/2021 14:00	0	1.6	8.1	14.5	15.2	1,039,050.8	0.00	1.00
10/04/2021 15:00	0	1.7	8.7	14.2	17.0	1,003,154.5	0.00	1.00
10/04/2021 16:00	1	2.0	12.0	12.9	24.1	1,038,366.0	0.00	1.00
10/04/2021 17:00	0	1.9	10.8	13.4	21.2	1,042,588.4	0.00	1.00
10/04/2021 18:00	0	1.9	10.2	13.6	20.1	1,036,072.7	0.00	1.00
10/04/2021 19:00	0	1.8	9.7	13.8	19.2	1,032,083.1	0.00	1.00
10/04/2021 20:00	0	1.8	9.2	14.0	18.3	1,028,060.6	0.00	1.00
10/04/2021 21:00	0	1.8	9.3	14.0	18.8	1,038,579.4	0.00	1.00
10/04/2021 22:00	1	1.8	10.7	14.3	20.3	878,714.0	0.00	1.00
10/04/2021 23:00	0	1.5	13.1	14.5	19.2	699,476.3	0.00	1.00
Average/Sum#:	0	1.7	9.6	14.2	17.1	958,226.0	0.00 #	24.00 #
Minimum:	0	1.4	7.8	12.9	11.4	684,277.5	0.00	1.00
Maximum:	1	2.0	13.8	14.6	24.1	1,042,588.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/05/2021 00:00	0	1.6	13.8	14.6	20.4	691,450.6	0.00	1.00
10/05/2021 01:00	0	1.6	12.6	14.5	19.1	715,738.2	0.00	1.00
10/05/2021 02:00	1	1.6	15.7	14.7	23.7	678,085.9	0.00	1.00
10/05/2021 03:00	0	1.5	14.8	14.6	21.9	685,581.7	0.00	1.00
10/05/2021 04:00	0	1.5	10.3	14.4	13.9	827,343.0	0.00	1.00
10/05/2021 05:00	0	1.5	11.7	14.5	18.2	784,851.4	0.00	1.00
10/05/2021 06:00	1	1.7	11.2	14.4	19.2	817,019.7	0.00	1.00
10/05/2021 07:00	0	1.7	9.0	14.4	13.7	913,722.1	0.00	1.00
10/05/2021 08:00	1	1.5	14.9	14.6	22.5	664,279.5	0.00	1.00
10/05/2021 09:00	0	1.5	13.1	14.6	19.3	696,667.5	0.00	1.00
10/05/2021 10:00	0	1.6	7.8	14.5	11.1	1,023,430.8	0.00	1.00
10/05/2021 11:00	1	1.7	13.2	14.6	20.9	679,712.7	0.00	1.00
10/05/2021 12:00	0	1.6	13.4	14.8	20.0	683,589.7	0.00	1.00
10/05/2021 13:00	0	1.4	12.2	14.7	17.1	712,321.6	0.00	1.00
10/05/2021 14:00	0	1.3	9.8	14.5	13.6	803,680.9	0.00	1.00
10/05/2021 15:00	0	1.5	10.3	14.6	15.6	833,827.3	0.00	1.00
10/05/2021 16:00	0	1.5	9.3	14.5	14.4	877,929.4	0.00	1.00
10/05/2021 17:00	0	1.7	8.4	14.4	13.0	836,823.6	0.00	1.00
10/05/2021 18:00	0	1.6	8.2	14.4	12.3	904,241.5	0.00	1.00
10/05/2021 19:00	0	1.6	11.1	14.4	17.1	713,575.4	0.00	1.00
10/05/2021 20:00	0	1.4	10.8	14.5	16.7	762,598.2	0.00	1.00
10/05/2021 21:00	0	1.4	7.3	14.3	7.7	850,288.0	0.00	1.00
10/05/2021 22:00	0	1.7	7.6	14.4	12.6	948,063.0	0.00	1.00
10/05/2021 23:00	0	1.7	7.7	14.4	12.9	944,692.1	0.00	1.00
Average/Sum#:	0	1.6	11.0	14.5	16.5	793,729.7	0.00 #	24.00 #
Minimum:	0	1.3	7.3	14.3	7.7	664,279.5	0.00	1.00
Maximum:	1	1.7	15.7	14.8	23.7	1,023,430.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/06/2021 00:00	1	1.8	14.2	14.6	23.3	675,800.1	0.00	1.00
10/06/2021 01:00	1	1.6	14.0	14.6	21.7	674,495.9	0.00	1.00
10/06/2021 02:00	0	1.6	14.7	14.6	22.3	672,322.2	0.00	1.00
10/06/2021 03:00	1	1.6	14.6	14.6	22.5	672,756.9	0.00	1.00
10/06/2021 04:00	1	1.6	14.3	14.6	21.6	673,409.0	0.00	1.00
10/06/2021 05:00	0	1.4	11.9	14.5	17.3	773,296.8	0.00	1.00
10/06/2021 06:00	1	1.8	11.7	14.5	21.9	856,318.2	0.00	1.00
10/06/2021 07:00	1	1.4	15.5	14.6	23.7	685,146.9	0.00	1.00
10/06/2021 08:00	0	1.3	13.8	14.6	21.2	777,528.7	0.00	1.00
10/06/2021 09:00	0	1.5	7.5	14.4	10.3	990,409.9	0.00	1.00
10/06/2021 10:00	0	1.7	8.2	14.4	12.8	855,363.5	0.00	1.00
10/06/2021 11:00	0	1.7	8.5	14.2	15.7	1,021,345.3	0.00	1.00
10/06/2021 12:00	0	1.7	8.0	14.3	15.3	1,022,711.0	0.00	1.00
10/06/2021 13:00	0	1.6	8.1	14.3	13.2	892,823.2	0.00	1.00
10/06/2021 14:00	0	1.6	7.7	14.5	14.8	1,045,042.0	0.00	1.00
10/06/2021 15:00	0	1.5	9.3	14.4	14.6	856,206.3	0.00	1.00
10/06/2021 16:00	0	1.6	8.2	14.4	14.0	931,419.3	0.00	1.00
10/06/2021 17:00	1	1.7	13.3	14.6	21.4	709,057.5	0.00	1.00
10/06/2021 18:00	0	1.6	11.0	14.4	16.0	744,545.5	0.00	1.00
10/06/2021 19:00	0	1.5	12.4	14.5	19.3	737,777.4	0.00	1.00
10/06/2021 20:00	0	1.5	7.8	14.4	10.2	944,481.5	0.00	1.00
10/06/2021 21:00	0	1.7	7.9	14.5	15.0	1,052,959.0	0.00	1.00
10/06/2021 22:00	1	1.8	11.3	14.5	21.4	858,243.9	0.00	1.00
10/06/2021 23:00	1	1.6	15.4	14.6	23.5	673,626.4	0.00	1.00
Average/Sum#:	0	1.6	11.2	14.5	18.0	824,878.6	0.00 #	24.00 #
Minimum:	0	1.3	7.5	14.2	10.2	672,322.2	0.00	1.00
Maximum:	1	1.8	15.5	14.6	23.7	1,052,959.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/07/2021 00:00	1	1.6	15.4	14.6	24.1	673,626.4	0.00	1.00
10/07/2021 01:00	1	1.6	15.3	14.6	24.0	673,626.4	0.00	1.00
10/07/2021 02:00	1	1.6	15.7	14.6	23.9	673,843.7	0.00	1.00
10/07/2021 03:00	0	1.2	10.9	14.4	16.2	819,126.5	0.00	1.00
10/07/2021 04:00	0	1.6	9.0	14.4	13.5	905,294.9	0.00	1.00
10/07/2021 05:00	0	1.7	7.9	14.4	13.6	1,001,365.2	0.00	1.00
10/07/2021 06:00	0	1.7	7.9	14.4	15.4	1,055,931.5	0.00	1.00
10/07/2021 07:00	0	1.7	8.1	14.4	15.1	1,029,385.8	0.00	1.00
10/07/2021 08:00	0	1.7	8.7	14.4	14.8	928,048.4	0.00	1.00
10/07/2021 09:00	0	1.6	7.8	14.5	14.9	1,049,535.4	0.00	1.00
10/07/2021 10:00	1	1.7	12.4	14.5	23.4	795,336.0	0.00	1.00
10/07/2021 11:00	0	1.5	12.0	14.5	15.6	722,371.4	0.00	1.00
10/07/2021 12:00	1	1.6	14.2	14.7	22.5	677,644.2	0.00	1.00
10/07/2021 13:00	0	1.6	14.3	14.7	21.8	673,668.4	0.00	1.00
10/07/2021 14:00	1	1.6	15.5	14.8	24.2	673,038.4	0.00	1.00
10/07/2021 15:00	1	1.5	15.1	14.7	23.2	676,760.7	0.00	1.00
10/07/2021 16:00	0	1.5	12.3	14.6	18.1	806,004.1	0.00	1.00
10/07/2021 17:00	0	1.7	7.8	14.5	13.1	1,047,395.7	0.00	1.00
10/07/2021 18:00	1	1.7	11.8	14.5	20.9	801,541.2	0.00	1.00
10/07/2021 19:00	1	1.6	14.4	14.6	22.5	674,930.6	0.00	1.00
10/07/2021 20:00	1	1.6	13.7	14.5	21.1	688,777.7	0.00	1.00
10/07/2021 21:00	1	1.6	14.6	14.6	23.1	674,713.2	0.00	1.00
10/07/2021 22:00	1	1.6	14.3	14.6	22.1	686,668.5	0.00	1.00
10/07/2021 23:00	0	1.7	9.2	14.3	11.6	819,994.7	0.00	1.00
Average/Sum#:	1	1.6	12.0	14.5	19.1	801,192.9	0.00 #	24.00 #
Minimum:	0	1.2	7.8	14.3	11.6	673,038.4	0.00	1.00
Maximum:	1	1.7	15.7	14.8	24.2	1,055,931.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/08/2021 00:00	1	1.6	15.1	14.6	25.8	674,713.2	0.00	1.00
10/08/2021 01:00	1	1.6	15.1	14.6	23.7	674,061.1	0.00	1.00
10/08/2021 02:00	1	1.5	16.1	14.6	25.1	672,539.5	0.00	1.00
10/08/2021 03:00	1	1.6	15.1	14.6	23.2	681,669.0	0.00	1.00
10/08/2021 04:00	0	1.5	14.4	14.5	21.2	703,113.8	0.00	1.00
10/08/2021 05:00	1	1.6	17.8	14.7	29.9	666,821.3	0.00	1.00
10/08/2021 06:00	1	1.5	14.3	14.6	22.7	708,840.1	0.00	1.00
10/08/2021 07:00	0	1.6	7.8	14.4	11.9	1,057,827.7	0.00	1.00
10/08/2021 08:00	0	1.6	10.5	14.4	16.8	808,381.7	0.00	1.00
10/08/2021 09:00	0	1.7	7.9	14.5	13.8	1,056,168.6	0.00	1.00
10/08/2021 10:00	1	1.8	14.3	14.5	25.2	685,782.1	0.00	1.00
10/08/2021 11:00	0	1.3	8.2	14.4	10.3	904,452.1	0.00	1.00
10/08/2021 12:00	0	1.7	8.0	14.3	12.3	865,227.2	0.00	1.00
10/08/2021 13:00	0	1.7	7.9	14.4	13.3	908,244.4	0.00	1.00
10/08/2021 14:00	0	1.6	7.9	14.5	15.1	1,051,889.1	0.00	1.00
10/08/2021 15:00	1	1.8	15.1	14.7	25.4	682,945.2	0.00	1.00
10/08/2021 16:00	0	1.4	12.9	14.6	19.3	792,092.5	0.00	1.00
10/08/2021 17:00	1	1.8	15.2	14.7	25.8	686,037.4	0.00	1.00
10/08/2021 18:00	1	1.6	15.8	14.7	26.9	676,981.6	0.00	1.00
10/08/2021 19:00	1	1.5	16.7	14.7	28.0	671,901.4	0.00	1.00
10/08/2021 20:00	1	1.6	16.1	14.7	26.5	677,865.1	0.00	1.00
10/08/2021 21:00	1	1.6	15.6	14.6	23.7	672,756.9	0.00	1.00
10/08/2021 22:00	1	1.6	15.4	14.6	24.7	685,364.3	0.00	1.00
10/08/2021 23:00	1	1.5	17.2	14.7	28.6	675,877.2	0.00	1.00
Average/Sum#:	1	1.6	13.4	14.6	21.6	764,231.4	0.00 #	24.00 #
Minimum:	0	1.3	7.8	14.3	10.3	666,821.3	0.00	1.00
Maximum:	1	1.8	17.8	14.7	29.9	1,057,827.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOX, Ppm	Unit CT2 NOX, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/09/2021 00:00	1	1.6	17.6	14.7	30.3	671,017.9	0.00	1.00
10/09/2021 01:00	1	1.6	19.7	14.8	33.8	668,773.0	0.00	1.00
10/09/2021 02:00	1	1.5	20.3	14.8	33.7	671,242.4	0.00	1.00
10/09/2021 03:00	1	1.6	19.6	14.8	32.8	671,691.4	0.00	1.00
10/09/2021 04:00	1	1.6	16.4	14.6	24.8	680,799.6	0.00	1.00
10/09/2021 05:00	0	1.4	11.4	14.4	16.0	783,100.1	0.00	1.00
10/09/2021 06:00	0	1.5	12.7	14.5	20.3	791,056.6	0.00	1.00
10/09/2021 07:00	0	1.7	9.1	14.4	13.1	911,826.0	0.00	1.00
10/09/2021 08:00	1	1.8	12.4	14.5	20.6	753,397.4	0.00	1.00
10/09/2021 09:00	1	1.6	17.9	14.7	32.2	669,471.8	0.00	1.00
10/09/2021 10:00	1	1.6	18.5	14.8	30.8	670,120.0	0.00	1.00
10/09/2021 11:00	1	1.6	17.4	14.8	28.0	669,895.5	0.00	1.00
10/09/2021 12:00	1	1.6	16.8	14.8	26.9	667,650.5	0.00	1.00
10/09/2021 13:00	1	1.6	16.7	14.8	26.7	666,303.5	0.00	1.00
10/09/2021 14:00	1	1.5	16.6	14.8	26.4	665,405.6	0.00	1.00
10/09/2021 15:00	0	1.5	15.0	14.8	21.7	687,181.6	0.00	1.00
10/09/2021 16:00	0	1.4	11.8	14.7	18.0	837,999.4	0.00	1.00
10/09/2021 17:00	0	1.6	9.5	14.5	15.1	965,658.2	0.00	1.00
10/09/2021 18:00	1	1.7	13.4	14.7	22.5	732,200.3	0.00	1.00
10/09/2021 19:00	1	1.5	14.9	14.7	25.1	676,760.7	0.00	1.00
10/09/2021 20:00	1	1.6	16.9	14.8	27.8	675,956.9	0.00	1.00
10/09/2021 21:00	1	1.6	15.3	14.7	24.3	681,619.9	0.00	1.00
10/09/2021 22:00	1	1.6	15.8	14.7	25.9	679,632.1	0.00	1.00
10/09/2021 23:00	0	1.6	15.2	14.7	22.4	686,920.9	0.00	1.00
Average/Sum#:	1	1.6	15.5	14.7	25.0	718,153.4	0.00 #	24.00 #
Minimum:	0	1.4	9.1	14.4	13.1	665,405.6	0.00	1.00
Maximum:	1	1.8	20.3	14.8	33.8	965,658.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/10/2021 00:00	1	1.6	15.6	14.6	25.1	675,800.1	0.00	1.00
10/10/2021 01:00	1	1.6	16.2	14.6	27.2	673,843.7	0.00	1.00
10/10/2021 02:00	1	1.7	15.2	14.6	22.0	688,190.1	0.00	1.00
10/10/2021 03:00	1	1.6	15.7	14.6	24.8	683,190.6	0.00	1.00
10/10/2021 04:00	1	1.6	15.4	14.6	24.6	682,973.2	0.00	1.00
10/10/2021 05:00	0	1.5	11.7	14.5	17.0	847,117.4	0.00	1.00
10/10/2021 06:00	0	1.6	11.0	14.4	18.7	889,072.4	0.00	1.00
10/10/2021 07:00	1	1.8	11.5	14.4	19.8	818,073.1	0.00	1.00
10/10/2021 08:00	1	1.6	16.3	14.7	29.2	677,644.2	0.00	1.00
10/10/2021 09:00	1	1.5	18.2	14.8	29.3	669,222.0	0.00	1.00
10/10/2021 10:00	1	1.5	16.2	14.8	24.9	675,956.9	0.00	1.00
10/10/2021 11:00	1	1.6	16.6	14.8	27.1	667,426.0	0.00	1.00
10/10/2021 12:00	1	1.5	16.3	14.8	25.8	666,977.0	0.00	1.00
10/10/2021 13:00	1	1.6	15.7	14.8	24.7	668,773.0	0.00	1.00
10/10/2021 14:00	1	1.5	15.5	14.8	23.8	675,507.9	0.00	1.00
10/10/2021 15:00	0	1.6	13.3	14.7	18.2	716,518.2	0.00	1.00
10/10/2021 16:00	0	1.5	11.8	14.6	18.3	846,217.3	0.00	1.00
10/10/2021 17:00	1	1.7	13.0	14.6	20.5	699,928.0	0.00	1.00
10/10/2021 18:00	1	1.5	15.4	14.8	25.1	674,160.9	0.00	1.00
10/10/2021 19:00	0	1.6	12.4	14.7	17.7	720,714.8	0.00	1.00
10/10/2021 20:00	0	1.7	11.6	14.5	19.0	819,942.8	0.00	1.00
10/10/2021 21:00	1	1.6	14.5	14.7	23.4	678,748.6	0.00	1.00
10/10/2021 22:00	1	1.5	15.9	14.7	25.0	665,717.0	0.00	1.00
10/10/2021 23:00	1	1.6	17.1	14.7	27.9	659,753.3	0.00	1.00
Average/Sum#:	1	1.6	14.7	14.7	23.3	714,227.9	0.00 #	24.00 #
Minimum:	0	1.5	11.0	14.4	17.0	659,753.3	0.00	1.00
Maximum:	1	1.8	18.2	14.8	29.3	889,072.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/11/2021 00:00	0	1.6	15.8	14.7	23.7	695,314.2	0.00	1.00
10/11/2021 01:00	1	1.6	18.6	14.8	32.5	671,242.4	0.00	1.00
10/11/2021 02:00	0	1.6	16.1	14.7	25.3	678,306.8	0.00	1.00
10/11/2021 03:00	0	1.6	15.9	14.7	26.4	690,234.1	0.00	1.00
10/11/2021 04:00	0	1.6	9.7	14.4	12.9	925,941.6	0.00	1.00
10/11/2021 05:00	0	1.7	10.2	14.4	17.1	918,146.4	0.00	1.00
10/11/2021 06:00	0	1.7	9.2	14.4	16.1	990,620.5	0.00	1.00
10/11/2021 07:00	0	1.7	9.0	14.4	17.6	1,042,026.6	0.00	1.00
10/11/2021 08:00	1	2.0	13.3	12.9	30.9	1,110,089.6	0.00	1.00
10/11/2021 09:00	1	1.9	12.0	13.4	27.6	1,101,747.6	0.00	1.00
10/11/2021 10:00	1	2.0	12.5	13.1	28.0	1,091,852.6	0.00	1.00
10/11/2021 11:00	0	1.7	9.7	14.1	21.6	1,073,185.7	0.00	1.00
10/11/2021 12:00	0	1.8	10.8	13.7	24.1	1,084,888.4	0.00	1.00
10/11/2021 13:00	0	1.8	10.9	13.7	24.2	1,093,447.3	0.00	1.00
10/11/2021 14:00	0	1.8	10.5	13.8	23.5	1,083,002.5	0.00	1.00
10/11/2021 15:00	0	1.6	10.1	14.3	18.7	938,678.2	0.00	1.00
10/11/2021 16:00	0	1.7	8.9	14.5	17.8	1,032,417.6	0.00	1.00
10/11/2021 17:00	0	1.7	9.1	14.4	17.5	1,004,946.8	0.00	1.00
10/11/2021 18:00	1	1.6	13.4	14.5	23.4	792,554.4	0.00	1.00
10/11/2021 19:00	1	1.7	15.0	14.6	24.7	714,926.5	0.00	1.00
10/11/2021 20:00	0	1.7	11.2	14.4	20.0	897,289.0	0.00	1.00
10/11/2021 21:00	1	1.6	13.1	14.4	22.0	777,411.7	0.00	1.00
10/11/2021 22:00	1	1.6	15.5	14.6	26.7	727,533.9	0.00	1.00
10/11/2021 23:00	1	1.6	15.2	14.6	25.1	716,448.1	0.00	1.00
Average/Sum#:	0	1.7	12.3	14.2	22.8	910,510.5	0.00 #	24.00 #
Minimum:	0	1.6	8.9	12.9	12.9	671,242.4	0.00	1.00
Maximum:	1	2.0	18.6	14.8	32.5	1,110,089.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOX, Ppm	Unit CT2 NOX, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/12/2021 00:00	1	1.6	16.0	14.6	26.7	681,234.3	0.00	1.00
10/12/2021 01:00	1	1.6	17.9	14.7	32.7	683,166.1	0.00	1.00
10/12/2021 02:00	1	2.0	20.3	14.8	29.9	686,732.7	0.00	1.00
10/12/2021 03:00	1	1.6	19.4	14.7	31.5	676,981.6	0.00	1.00
10/12/2021 04:00	1	1.6	19.3	14.8	33.4	689,651.1	0.00	1.00
10/12/2021 05:00	0	1.5	12.0	14.5	17.4	888,842.0	0.00	1.00
10/12/2021 06:00	0	1.7	9.4	14.5	18.1	1,085,696.8	0.00	1.00
10/12/2021 07:00	0	1.6	9.4	14.5	18.8	1,069,648.8	0.00	1.00
10/12/2021 08:00	0	1.6	9.3	14.5	19.4	1,077,779.8	0.00	1.00
10/12/2021 09:00	0	1.6	9.2	14.6	19.6	1,094,670.0	0.00	1.00
10/12/2021 10:00	0	1.6	9.5	14.6	20.8	1,095,756.9	0.00	1.00
10/12/2021 11:00	0	1.6	9.7	14.6	21.0	1,088,583.7	0.00	1.00
10/12/2021 12:00	0	1.6	9.6	14.6	19.8	1,061,195.2	0.00	1.00
10/12/2021 13:00	0	1.6	11.9	14.5	20.6	798,759.6	0.00	1.00
10/12/2021 14:00	0	1.6	9.7	14.6	19.1	1,070,976.8	0.00	1.00
10/12/2021 15:00	0	1.6	9.8	14.6	20.5	1,067,933.7	0.00	1.00
10/12/2021 16:00	0	1.6	9.4	14.6	17.9	1,013,374.0	0.00	1.00
10/12/2021 17:00	0	1.6	9.3	14.6	18.7	1,062,934.2	0.00	1.00
10/12/2021 18:00	0	1.6	9.3	14.6	19.2	1,074,672.1	0.00	1.00
10/12/2021 19:00	0	1.6	9.6	14.5	17.1	953,247.8	0.00	1.00
10/12/2021 20:00	0	1.7	10.1	14.5	20.0	982,348.0	0.00	1.00
10/12/2021 21:00	0	1.6	9.2	14.5	17.0	1,032,631.6	0.00	1.00
10/12/2021 22:00	0	1.6	9.4	14.5	19.1	1,060,020.1	0.00	1.00
10/12/2021 23:00	0	1.6	10.9	14.5	18.9	901,680.4	0.00	1.00
Average/Sum#:	0	1.6	11.7	14.6	21.6	954,104.9	0.00 #	24.00 #
Minimum:	0	1.5	9.2	14.5	17.0	676,981.6	0.00	1.00
Maximum:	1	2.0	20.3	14.8	33.4	1,095,756.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/13/2021 00:00	0	1.7	9.3	14.5	19.3	1,070,290.7	0.00	1.00
10/13/2021 01:00	1	1.7	15.2	14.5	26.7	726,222.9	0.00	1.00
10/13/2021 02:00	1	1.6	17.1	14.6	27.2	682,321.1	0.00	1.00
10/13/2021 03:00	0	1.5	13.3	14.5	20.2	817,803.1	0.00	1.00
10/13/2021 04:00	0	1.7	9.4	14.5	18.0	1,070,076.8	0.00	1.00
10/13/2021 05:00	0	1.6	9.8	14.5	19.3	1,013,374.0	0.00	1.00
10/13/2021 06:00	0	1.6	9.8	14.4	19.2	975,030.2	0.00	1.00
10/13/2021 07:00	0	1.6	9.1	14.5	18.6	1,070,718.7	0.00	1.00
10/13/2021 08:00	0	1.6	9.1	14.6	19.2	1,088,583.7	0.00	1.00
10/13/2021 09:00	0	1.6	9.2	14.6	19.8	1,088,801.1	0.00	1.00
10/13/2021 10:00	0	1.6	9.6	14.6	20.6	1,081,193.2	0.00	1.00
10/13/2021 11:00	0	1.6	9.7	14.6	20.9	1,079,671.6	0.00	1.00
10/13/2021 12:00	0	1.6	9.7	14.6	20.6	1,073,367.9	0.00	1.00
10/13/2021 13:00	0	1.6	8.7	14.5	17.2	1,070,076.8	0.00	1.00
10/13/2021 14:00	0	1.6	8.8	14.5	17.1	1,049,321.4	0.00	1.00
10/13/2021 15:00	0	1.7	9.4	14.4	17.1	926,573.6	0.00	1.00
10/13/2021 16:00	0	1.5	13.5	14.7	21.7	817,678.9	0.00	1.00
10/13/2021 17:00	0	1.7	8.8	14.5	17.1	1,056,382.5	0.00	1.00
10/13/2021 18:00	0	1.6	9.3	14.4	16.9	952,276.6	0.00	1.00
10/13/2021 19:00	0	1.7	10.8	14.4	19.7	892,654.0	0.00	1.00
10/13/2021 20:00	0	1.7	9.3	14.4	17.5	980,297.2	0.00	1.00
10/13/2021 21:00	0	1.6	10.2	14.4	19.3	956,068.9	0.00	1.00
10/13/2021 22:00	0	1.7	9.8	14.4	18.1	992,727.3	0.00	1.00
10/13/2021 23:00	1	1.5	18.6	14.7	34.0	672,564.1	0.00	1.00
Average/Sum#:	0	1.6	10.7	14.5	20.2	966,836.5	0.00 #	24.00 #
Minimum:	0	1.5	8.7	14.4	16.9	672,564.1	0.00	1.00
Maximum:	1	1.7	18.6	14.7	34.0	1,088,801.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/14/2021 00:00	1	1.7	16.7	14.6	26.7	677,104.3	0.00	1.00
10/14/2021 01:00	2	1.6	18.0	14.7	31.3	680,515.6	0.00	1.00
10/14/2021 02:00	1	1.8	17.9	14.6	26.2	679,495.3	0.00	1.00
10/14/2021 03:00	1	1.6	17.4	14.6	29.1	680,364.8	0.00	1.00
10/14/2021 04:00	1	1.6	18.1	14.7	30.4	686,920.9	0.00	1.00
10/14/2021 05:00	0	1.6	10.1	14.5	14.9	994,758.4	0.00	1.00
10/14/2021 06:00	0	1.7	9.4	14.4	18.2	1,058,670.4	0.00	1.00
10/14/2021 07:00	1	1.6	13.6	14.4	23.5	785,628.2	0.00	1.00
10/14/2021 08:00	2	1.7	17.3	14.7	32.3	683,828.7	0.00	1.00
10/14/2021 09:00	1	1.6	16.4	14.7	25.0	683,386.9	0.00	1.00
10/14/2021 10:00	1	1.6	17.7	14.8	30.2	675,507.9	0.00	1.00
10/14/2021 11:00	1	1.5	16.4	14.8	25.3	676,405.8	0.00	1.00
10/14/2021 12:00	1	1.6	15.6	14.8	25.4	677,528.3	0.00	1.00
10/14/2021 13:00	1	1.6	13.5	14.7	19.9	683,607.8	0.00	1.00
10/14/2021 14:00	1	1.6	13.2	14.8	19.9	698,630.9	0.00	1.00
10/14/2021 15:00	1	1.6	12.7	14.7	19.8	731,095.9	0.00	1.00
10/14/2021 16:00	0	1.5	11.5	14.7	17.9	876,210.7	0.00	1.00
10/14/2021 17:00	0	1.6	9.2	14.6	16.9	1,065,542.6	0.00	1.00
10/14/2021 18:00	0	1.7	8.9	14.4	17.1	982,193.3	0.00	1.00
10/14/2021 19:00	0	1.6	8.7	14.5	17.1	1,075,426.1	0.00	1.00
10/14/2021 20:00	0	1.6	8.9	14.5	18.4	1,081,845.3	0.00	1.00
10/14/2021 21:00	1	2.0	13.7	13.0	33.0	1,082,712.0	0.00	1.00
10/14/2021 22:00	1	1.8	10.9	14.1	22.6	1,081,643.9	0.00	1.00
10/14/2021 23:00	1	1.7	10.1	14.3	21.2	1,054,456.8	0.00	1.00
Average/Sum#:	1	1.6	13.6	14.5	23.4	835,561.7	0.00 #	24.00 #
Minimum:	0	1.5	8.7	13.0	14.9	675,507.9	0.00	1.00
Maximum:	2	2.0	18.1	14.8	33.0	1,082,712.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/15/2021 00:00	1	1.7	9.9	14.3	21.0	1,044,497.3	0.00	1.00
10/15/2021 01:00	1	1.7	10.0	14.3	21.6	1,051,137.0	0.00	1.00
10/15/2021 02:00	0	1.6	10.4	14.3	21.8	1,054,041.8	0.00	1.00
10/15/2021 03:00	1	1.7	10.1	14.3	21.6	1,054,456.8	0.00	1.00
10/15/2021 04:00	1	1.7	10.2	14.3	21.8	1,053,626.8	0.00	1.00
10/15/2021 05:00	1	1.7	10.0	14.3	21.4	1,054,249.3	0.00	1.00
10/15/2021 06:00	1	1.7	9.8	14.3	20.9	1,051,759.4	0.00	1.00
10/15/2021 07:00	1	1.7	9.9	14.3	21.3	1,050,929.5	0.00	1.00
10/15/2021 08:00	1	1.7	9.9	14.3	21.6	1,044,289.8	0.00	1.00
10/15/2021 09:00	1	1.7	9.3	14.3	19.1	1,043,874.9	0.00	1.00
10/15/2021 10:00	1	1.7	9.2	14.3	19.3	1,046,779.7	0.00	1.00
10/15/2021 11:00	1	1.7	9.2	14.3	19.1	1,044,289.8	0.00	1.00
10/15/2021 12:00	1	1.7	9.2	14.3	19.0	1,042,629.9	0.00	1.00
10/15/2021 13:00	1	1.7	9.2	14.3	18.9	1,043,252.4	0.00	1.00
10/15/2021 14:00	1	1.7	9.2	14.3	18.8	1,041,592.5	0.00	1.00
10/15/2021 15:00	1	1.7	9.1	14.3	18.7	1,037,650.2	0.00	1.00
10/15/2021 16:00	1	1.8	9.7	14.1	21.4	1,053,047.1	0.00	1.00
10/15/2021 17:00	0	1.7	9.7	14.1	19.0	1,036,734.8	0.00	1.00
10/15/2021 18:00	1	1.7	9.3	14.3	19.2	1,038,272.7	0.00	1.00
10/15/2021 19:00	1	1.7	9.3	14.2	19.0	1,021,958.5	0.00	1.00
10/15/2021 20:00	1	1.7	9.3	14.2	19.5	1,025,433.2	0.00	1.00
10/15/2021 21:00	1	1.7	9.3	14.2	19.3	1,028,294.6	0.00	1.00
10/15/2021 22:00	1	1.7	9.4	14.2	19.2	1,026,046.3	0.00	1.00
10/15/2021 23:00	1	1.7	9.5	14.2	19.3	1,025,024.4	0.00	1.00
Average/Sum#:	1	1.7	9.6	14.3	20.1	1,042,244.5	0.00 #	24.00 #
Minimum:	0	1.6	9.1	14.1	18.7	1,021,958.5	0.00	1.00
Maximum:	1	1.8	10.4	14.3	21.8	1,054,456.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/16/2021 00:00	1	1.7	9.8	14.3	20.8	1,042,629.9	0.00	1.00
10/16/2021 01:00	1	1.7	9.9	14.3	20.9	1,039,725.1	0.00	1.00
10/16/2021 02:00	0	1.7	10.1	14.3	20.6	1,040,555.0	0.00	1.00
10/16/2021 03:00	1	1.7	10.1	14.3	21.2	1,042,837.4	0.00	1.00
10/16/2021 04:00	1	1.7	10.0	14.2	21.0	1,035,857.1	0.00	1.00
10/16/2021 05:00	1	1.7	9.8	14.2	20.8	1,033,608.8	0.00	1.00
10/16/2021 06:00	1	1.7	9.8	14.2	20.8	1,034,426.4	0.00	1.00
10/16/2021 07:00	1	1.7	9.9	14.2	21.4	1,035,448.3	0.00	1.00
10/16/2021 08:00	1	1.7	10.0	14.3	21.7	1,048,232.1	0.00	1.00
10/16/2021 09:00	1	1.7	10.1	14.3	21.9	1,054,041.8	0.00	1.00
10/16/2021 10:00	1	1.7	10.4	14.2	21.9	1,049,960.2	0.00	1.00
10/16/2021 11:00	1	1.7	10.7	14.1	21.8	1,043,783.3	0.00	1.00
10/16/2021 12:00	1	1.8	10.8	14.0	21.2	1,030,243.8	0.00	1.00
10/16/2021 13:00	1	1.8	10.9	14.0	21.3	1,029,449.9	0.00	1.00
10/16/2021 14:00	1	1.8	11.0	13.9	21.5	1,016,895.4	0.00	1.00
10/16/2021 15:00	1	1.8	11.1	13.9	21.5	1,018,656.1	0.00	1.00
10/16/2021 16:00	1	1.8	11.1	14.0	21.5	1,030,640.7	0.00	1.00
10/16/2021 17:00	1	1.8	10.9	14.0	21.4	1,024,686.7	0.00	1.00
10/16/2021 18:00	1	1.7	11.0	14.1	22.0	1,040,158.4	0.00	1.00
10/16/2021 19:00	1	1.7	11.0	14.1	22.3	1,042,776.4	0.00	1.00
10/16/2021 20:00	1	1.7	10.7	14.1	21.9	1,034,519.6	0.00	1.00
10/16/2021 21:00	1	1.7	10.5	14.2	21.8	1,042,602.1	0.00	1.00
10/16/2021 22:00	1	1.7	10.5	14.2	22.0	1,038,309.8	0.00	1.00
10/16/2021 23:00	1	1.7	10.4	14.3	22.0	1,037,857.7	0.00	1.00
Average/Sum#:	1	1.7	10.4	14.2	21.5	1,036,995.9	0.00 #	24.00 #
Minimum:	0	1.7	9.8	13.9	20.6	1,016,895.4	0.00	1.00
Maximum:	1	1.8	11.1	14.3	22.3	1,054,041.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/17/2021 00:00	1	1.7	10.4	14.3	21.7	1,030,595.6	0.00	1.00
10/17/2021 01:00	1	1.7	10.2	14.3	21.5	1,031,633.0	0.00	1.00
10/17/2021 02:00	1	1.7	10.5	14.3	21.6	1,033,292.9	0.00	1.00
10/17/2021 03:00	1	1.7	10.3	14.3	22.1	1,033,707.9	0.00	1.00
10/17/2021 04:00	1	1.7	10.3	14.3	21.7	1,036,197.8	0.00	1.00
10/17/2021 05:00	1	1.7	10.3	14.3	21.9	1,040,762.5	0.00	1.00
10/17/2021 06:00	1	1.7	10.3	14.3	21.9	1,043,252.4	0.00	1.00
10/17/2021 07:00	1	1.8	12.0	13.7	27.8	1,077,280.5	0.00	1.00
10/17/2021 08:00	2	2.2	14.9	12.3	37.3	1,089,966.3	0.00	1.00
10/17/2021 09:00	1	2.0	12.7	13.2	26.0	1,071,708.0	0.00	1.00
10/17/2021 10:00	0	1.7	9.8	14.2	19.7	1,040,966.9	0.00	1.00
10/17/2021 11:00	1	1.7	9.8	14.2	20.3	1,044,850.4	0.00	1.00
10/17/2021 12:00	1	1.7	9.5	14.2	19.4	1,030,747.3	0.00	1.00
10/17/2021 13:00	1	1.7	9.4	14.2	19.3	1,024,411.2	0.00	1.00
10/17/2021 14:00	1	1.7	9.4	14.2	19.3	1,025,024.4	0.00	1.00
10/17/2021 15:00	1	1.7	9.6	14.2	19.9	1,027,477.1	0.00	1.00
10/17/2021 16:00	1	1.7	9.9	14.1	21.1	1,039,151.4	0.00	1.00
10/17/2021 17:00	1	1.7	9.4	14.2	19.4	1,027,885.9	0.00	1.00
10/17/2021 18:00	1	1.7	9.4	14.2	19.8	1,029,521.0	0.00	1.00
10/17/2021 19:00	1	1.7	9.5	14.2	20.0	1,031,156.1	0.00	1.00
10/17/2021 20:00	1	1.7	9.4	14.2	19.7	1,029,929.8	0.00	1.00
10/17/2021 21:00	1	1.7	9.5	14.2	19.9	1,032,791.3	0.00	1.00
10/17/2021 22:00	1	1.7	9.5	14.2	20.3	1,037,696.7	0.00	1.00
10/17/2021 23:00	1	1.7	9.5	14.2	20.4	1,037,492.3	0.00	1.00
Average/Sum#:	1	1.7	10.2	14.1	21.8	1,039,479.1	0.00 #	24.00 #
Minimum:	0	1.7	9.4	12.3	19.3	1,024,411.2	0.00	1.00
Maximum:	2	2.2	14.9	14.3	37.3	1,089,966.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/18/2021 00:00	1	1.7	9.7	14.2	20.9	1,036,061.5	0.00	1.00
10/18/2021 01:00	1	1.7	9.8	14.2	20.9	1,036,265.9	0.00	1.00
10/18/2021 02:00	1	1.7	10.1	14.2	20.9	1,036,879.1	0.00	1.00
10/18/2021 03:00	1	1.7	9.9	14.2	20.7	1,037,901.0	0.00	1.00
10/18/2021 04:00	1	1.7	9.7	14.2	20.4	1,037,083.5	0.00	1.00
10/18/2021 05:00	1	1.7	9.7	14.2	20.7	1,036,674.7	0.00	1.00
10/18/2021 06:00	1	1.7	9.8	14.2	20.9	1,038,105.4	0.00	1.00
10/18/2021 07:00	1	1.6	11.9	14.3	24.9	900,085.3	0.00	1.00
10/18/2021 08:00	0	1.6	11.1	14.4	17.1	921,095.9	0.00	1.00
10/18/2021 09:00	1	1.7	9.7	14.2	20.5	1,034,630.8	0.00	1.00
10/18/2021 10:00	1	1.7	9.6	14.3	20.8	1,049,062.1	0.00	1.00
10/18/2021 11:00	1	1.7	9.7	14.3	21.1	1,048,647.1	0.00	1.00
10/18/2021 12:00	1	1.7	9.8	14.3	21.3	1,047,817.1	0.00	1.00
10/18/2021 13:00	1	1.7	9.9	14.3	21.4	1,050,722.0	0.00	1.00
10/18/2021 14:00	1	1.7	10.3	14.2	22.3	1,062,836.8	0.00	1.00
10/18/2021 15:00	1	1.7	10.0	14.3	21.8	1,041,592.5	0.00	1.00
10/18/2021 16:00	1	1.6	12.6	14.5	20.7	817,589.2	0.00	1.00
10/18/2021 17:00	1	1.7	10.0	14.3	21.7	1,054,249.3	0.00	1.00
10/18/2021 18:00	1	1.7	9.8	14.3	21.5	1,050,099.5	0.00	1.00
10/18/2021 19:00	1	1.7	9.8	14.3	21.4	1,051,966.9	0.00	1.00
10/18/2021 20:00	1	1.7	9.8	14.2	21.3	1,037,083.5	0.00	1.00
10/18/2021 21:00	1	1.7	12.2	14.4	24.7	889,493.8	0.00	1.00
10/18/2021 22:00	1	1.6	16.4	14.6	25.8	677,756.4	0.00	1.00
10/18/2021 23:00	1	1.6	16.5	14.6	27.3	680,147.4	0.00	1.00
Average/Sum#:	1	1.7	10.7	14.3	21.7	986,410.3	0.00 #	24.00 #
Minimum:	0	1.6	9.6	14.2	17.1	677,756.4	0.00	1.00
Maximum:	1	1.7	16.5	14.6	27.3	1,062,836.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOX, Ppm	Unit CT2 NOX, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/19/2021 00:00	1	1.6	17.5	14.6	29.3	674,930.6	0.00	1.00
10/19/2021 01:00	1	1.6	18.0	14.6	29.8	672,756.9	0.00	1.00
10/19/2021 02:00	1	1.6	17.9	14.6	28.5	677,104.3	0.00	1.00
10/19/2021 03:00	0	1.5	12.9	14.4	20.5	883,594.7	0.00	1.00
10/19/2021 04:00	0	1.7	9.7	14.2	18.8	1,038,105.4	0.00	1.00
10/19/2021 05:00	1	1.7	9.7	14.2	20.1	1,036,265.9	0.00	1.00
10/19/2021 06:00	1	1.7	9.8	14.2	20.5	1,036,470.3	0.00	1.00
10/19/2021 07:00	1	1.7	9.8	14.2	20.5	1,037,492.3	0.00	1.00
10/19/2021 08:00	1	1.7	9.7	14.2	20.8	1,038,514.2	0.00	1.00
10/19/2021 09:00	1	1.7	9.9	14.2	21.6	1,045,054.8	0.00	1.00
10/19/2021 10:00	1	1.7	10.0	14.2	21.8	1,046,894.3	0.00	1.00
10/19/2021 11:00	1	1.7	9.8	14.3	21.2	1,039,517.6	0.00	1.00
10/19/2021 12:00	1	1.7	10.0	14.3	21.4	1,035,575.3	0.00	1.00
10/19/2021 13:00	1	1.7	11.2	14.4	20.2	908,665.7	0.00	1.00
10/19/2021 14:00	1	1.7	10.4	14.2	22.5	1,055,683.1	0.00	1.00
10/19/2021 15:00	1	1.7	10.5	14.2	22.6	1,058,135.8	0.00	1.00
10/19/2021 16:00	1	1.7	10.9	14.0	24.2	1,054,456.8	0.00	1.00
10/19/2021 17:00	1	1.7	10.7	14.1	22.0	1,047,811.0	0.00	1.00
10/19/2021 18:00	1	1.7	10.3	14.3	22.0	1,039,102.6	0.00	1.00
10/19/2021 19:00	1	1.7	10.3	14.3	22.1	1,034,537.9	0.00	1.00
10/19/2021 20:00	1	1.7	10.2	14.3	22.0	1,039,725.1	0.00	1.00
10/19/2021 21:00	1	1.7	10.2	14.3	20.5	984,118.2	0.00	1.00
10/19/2021 22:00	1	1.6	16.1	14.7	27.0	677,865.1	0.00	1.00
10/19/2021 23:00	1	1.6	16.0	14.7	25.6	679,632.1	0.00	1.00
Average/Sum#:	1	1.7	11.7	14.3	22.7	951,750.4	0.00 #	24.00 #
Minimum:	0	1.5	9.7	14.0	18.8	672,756.9	0.00	1.00
Maximum:	1	1.7	18.0	14.7	29.8	1,058,135.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOX, Ppm	Unit CT2 NOX, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/20/2021 00:00	1	1.6	16.2	14.7	26.0	679,411.2	0.00	1.00
10/20/2021 01:00	1	1.6	16.4	14.6	26.6	669,496.4	0.00	1.00
10/20/2021 02:00	1	1.6	16.9	14.6	26.7	669,496.4	0.00	1.00
10/20/2021 03:00	1	1.6	16.8	14.6	27.1	670,148.5	0.00	1.00
10/20/2021 04:00	0	1.6	12.4	14.4	18.6	877,695.7	0.00	1.00
10/20/2021 05:00	0	1.7	9.9	14.3	19.9	1,048,854.6	0.00	1.00
10/20/2021 06:00	1	1.7	11.6	14.4	22.7	892,232.7	0.00	1.00
10/20/2021 07:00	1	1.6	15.5	14.6	25.0	674,061.1	0.00	1.00
10/20/2021 08:00	1	1.6	15.5	14.6	25.0	673,191.6	0.00	1.00
10/20/2021 09:00	1	1.6	12.5	14.5	20.6	797,903.7	0.00	1.00
10/20/2021 10:00	1	1.6	14.9	14.6	23.3	677,321.6	0.00	1.00
10/20/2021 11:00	0	1.6	9.9	14.4	15.2	880,645.2	0.00	1.00
10/20/2021 12:00	1	1.7	11.5	14.5	20.2	857,388.0	0.00	1.00
10/20/2021 13:00	1	1.6	15.0	14.7	24.2	679,632.1	0.00	1.00
10/20/2021 14:00	1	1.6	14.4	14.7	22.7	682,945.2	0.00	1.00
10/20/2021 15:00	0	1.5	12.0	14.6	17.6	816,003.0	0.00	1.00
10/20/2021 16:00	1	1.6	11.1	14.5	18.6	877,929.4	0.00	1.00
10/20/2021 17:00	0	1.6	9.1	14.5	16.4	1,016,797.6	0.00	1.00
10/20/2021 18:00	1	1.7	13.9	14.6	23.3	692,972.2	0.00	1.00
10/20/2021 19:00	1	1.6	14.8	14.7	23.7	683,607.8	0.00	1.00
10/20/2021 20:00	1	1.6	14.5	14.6	22.9	690,798.5	0.00	1.00
10/20/2021 21:00	1	1.6	13.7	14.5	22.2	704,825.6	0.00	1.00
10/20/2021 22:00	0	1.5	9.4	14.5	14.4	1,012,946.1	0.00	1.00
10/20/2021 23:00	1	1.7	12.2	14.4	20.0	712,732.7	0.00	1.00
Average/Sum#:	1	1.6	13.3	14.5	21.8	776,626.5	0.00 #	24.00 #
Minimum:	0	1.5	9.1	14.3	14.4	669,496.4	0.00	1.00
Maximum:	1	1.7	16.9	14.7	27.1	1,048,854.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/21/2021 00:00	1	1.6	13.1	14.6	20.9	685,581.7	0.00	1.00
10/21/2021 01:00	1	1.6	14.1	14.6	22.4	677,321.6	0.00	1.00
10/21/2021 02:00	1	1.6	14.5	14.6	22.2	677,973.8	0.00	1.00
10/21/2021 03:00	0	1.4	11.6	14.5	16.8	797,689.7	0.00	1.00
10/21/2021 04:00	1	1.6	10.8	14.5	17.0	841,340.1	0.00	1.00
10/21/2021 05:00	0	1.6	9.9	14.4	17.3	944,692.1	0.00	1.00
10/21/2021 06:00	1	1.7	9.9	14.4	18.3	955,647.5	0.00	1.00
10/21/2021 07:00	0	1.5	9.1	14.4	15.5	934,579.5	0.00	1.00
10/21/2021 08:00	0	1.7	9.3	14.4	17.5	1,017,166.3	0.00	1.00
10/21/2021 09:00	0	1.7	9.0	14.4	18.1	1,071,521.9	0.00	1.00
10/21/2021 10:00	0	1.6	9.1	14.4	18.2	1,064,990.8	0.00	1.00
10/21/2021 11:00	1	1.8	9.5	14.4	17.4	934,158.1	0.00	1.00
10/21/2021 12:00	0	1.5	12.1	14.6	17.7	688,190.1	0.00	1.00
10/21/2021 13:00	0	1.6	9.2	14.5	15.4	983,203.9	0.00	1.00
10/21/2021 14:00	0	1.6	9.5	14.4	16.4	896,657.0	0.00	1.00
10/21/2021 15:00	1	1.5	11.7	14.6	18.0	772,964.0	0.00	1.00
10/21/2021 16:00	0	1.7	8.7	14.5	14.7	1,002,033.5	0.00	1.00
10/21/2021 17:00	0	1.7	8.8	14.4	17.0	1,051,928.6	0.00	1.00
10/21/2021 18:00	0	1.7	8.8	14.4	16.5	1,049,821.8	0.00	1.00
10/21/2021 19:00	0	1.7	8.9	14.4	17.7	1,057,617.0	0.00	1.00
10/21/2021 20:00	0	1.6	8.7	14.4	16.3	1,045,818.9	0.00	1.00
10/21/2021 21:00	1	1.8	8.8	14.4	15.8	950,380.5	0.00	1.00
10/21/2021 22:00	1	1.6	13.0	14.5	20.3	692,201.2	0.00	1.00
10/21/2021 23:00	1	1.6	16.5	14.7	27.0	657,986.3	0.00	1.00
Average/Sum#:	0	1.6	10.6	14.5	18.1	893,811.1	0.00 #	24.00 #
Minimum:	0	1.4	8.7	14.4	14.7	657,986.3	0.00	1.00
Maximum:	1	1.8	16.5	14.7	27.0	1,071,521.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/22/2021 00:00	1	1.6	16.3	14.7	25.4	658,428.1	0.00	1.00
10/22/2021 01:00	1	1.6	16.3	14.7	25.8	657,986.3	0.00	1.00
10/22/2021 02:00	1	1.6	16.7	14.7	25.3	657,544.6	0.00	1.00
10/22/2021 03:00	1	1.6	14.1	14.6	21.6	670,365.8	0.00	1.00
10/22/2021 04:00	1	1.6	13.4	14.6	19.4	676,886.9	0.00	1.00
10/22/2021 05:00	1	1.6	14.1	14.6	21.9	671,235.3	0.00	1.00
10/22/2021 06:00	1	1.5	14.8	14.6	21.0	670,148.5	0.00	1.00
10/22/2021 07:00	0	1.7	10.6	14.3	17.4	803,603.1	0.00	1.00
10/22/2021 08:00	0	1.5	8.8	14.4	15.5	1,035,916.9	0.00	1.00
10/22/2021 09:00	0	1.7	8.6	14.4	15.7	1,022,644.0	0.00	1.00
10/22/2021 10:00	0	1.7	8.8	14.4	16.9	1,062,462.6	0.00	1.00
10/22/2021 11:00	0	1.6	8.7	14.4	17.2	1,047,715.0	0.00	1.00
10/22/2021 12:00	1	1.7	11.2	14.4	17.3	764,981.5	0.00	1.00
10/22/2021 13:00	1	1.7	11.5	14.4	18.0	734,011.5	0.00	1.00
10/22/2021 14:00	1	1.7	11.6	14.4	17.8	732,958.1	0.00	1.00
10/22/2021 15:00	1	1.7	11.6	14.4	17.9	733,168.7	0.00	1.00
10/22/2021 16:00	0	1.6	10.8	14.4	16.6	815,123.5	0.00	1.00
10/22/2021 17:00	1	1.8	10.3	14.4	19.2	925,098.8	0.00	1.00
10/22/2021 18:00	1	1.6	16.9	14.7	28.4	664,612.6	0.00	1.00
10/22/2021 19:00	1	1.6	13.9	14.6	20.7	691,885.4	0.00	1.00
10/22/2021 20:00	1	1.6	14.2	14.6	22.4	678,625.9	0.00	1.00
10/22/2021 21:00	1	1.6	15.7	14.6	27.0	666,887.9	0.00	1.00
10/22/2021 22:00	1	1.6	15.7	14.7	25.1	676,318.9	0.00	1.00
10/22/2021 23:00	0	1.6	13.4	14.5	18.2	727,292.7	0.00	1.00
Average/Sum#:	1	1.6	12.8	14.5	20.5	768,579.3	0.00 #	24.00 #
Minimum:	0	1.5	8.6	14.3	15.5	657,544.6	0.00	1.00
Maximum:	1	1.8	16.9	14.7	28.4	1,062,462.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/23/2021 00:00	1	1.7	12.8	14.5	21.8	737,563.4	0.00	1.00
10/23/2021 01:00	2	1.6	17.5	14.8	30.0	671,691.4	0.00	1.00
10/23/2021 02:00	1	1.5	15.6	14.6	23.2	671,887.4	0.00	1.00
10/23/2021 03:00	1	1.6	14.7	14.6	20.8	675,800.1	0.00	1.00
10/23/2021 04:00	1	1.6	14.7	14.6	23.0	682,103.8	0.00	1.00
10/23/2021 05:00	0	1.5	11.8	14.5	16.9	799,615.5	0.00	1.00
10/23/2021 06:00	1	1.6	10.4	14.4	17.0	865,476.2	0.00	1.00
10/23/2021 07:00	1	1.7	11.6	14.4	21.3	806,696.3	0.00	1.00
10/23/2021 08:00	0	1.6	8.9	14.4	13.4	1,005,368.2	0.00	1.00
10/23/2021 09:00	1	1.8	9.3	14.3	16.2	868,132.1	0.00	1.00
10/23/2021 10:00	1	1.6	13.0	14.5	21.5	726,864.8	0.00	1.00
10/23/2021 11:00	1	1.6	13.6	14.5	21.4	724,083.1	0.00	1.00
10/23/2021 12:00	0	1.6	9.0	14.5	15.2	1,058,522.3	0.00	1.00
10/23/2021 13:00	1	1.6	10.7	14.4	18.8	829,449.8	0.00	1.00
10/23/2021 14:00	0	1.6	8.9	14.5	15.9	1,079,919.5	0.00	1.00
10/23/2021 15:00	0	1.7	8.7	14.4	16.4	1,033,178.0	0.00	1.00
10/23/2021 16:00	0	1.6	8.8	14.4	17.3	1,060,777.2	0.00	1.00
10/23/2021 17:00	0	1.6	8.8	14.4	17.2	1,054,246.1	0.00	1.00
10/23/2021 18:00	1	1.7	14.5	14.6	23.4	694,493.8	0.00	1.00
10/23/2021 19:00	1	1.6	12.9	14.5	20.9	710,388.9	0.00	1.00
10/23/2021 20:00	1	1.6	14.1	14.6	22.2	680,582.2	0.00	1.00
10/23/2021 21:00	1	1.6	13.8	14.6	21.5	682,538.5	0.00	1.00
10/23/2021 22:00	1	1.6	13.0	14.5	20.1	709,747.0	0.00	1.00
10/23/2021 23:00	0	1.6	8.9	14.4	14.0	1,028,332.4	0.00	1.00
Average/Sum#:	1	1.6	11.9	14.5	19.6	827,394.1	0.00 #	24.00 #
Minimum:	0	1.5	8.7	14.3	13.4	671,691.4	0.00	1.00
Maximum:	2	1.8	17.5	14.8	30.0	1,079,919.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/24/2021 00:00	1	1.7	9.6	14.3	19.7	879,129.0	0.00	1.00
10/24/2021 01:00	1	1.6	15.8	14.7	25.9	671,459.7	0.00	1.00
10/24/2021 02:00	1	1.6	17.3	14.7	26.2	665,275.2	0.00	1.00
10/24/2021 03:00	2	1.7	16.2	14.6	23.0	657,106.3	0.00	1.00
10/24/2021 04:00	1	1.6	17.0	14.7	27.4	658,428.1	0.00	1.00
10/24/2021 05:00	1	1.6	14.7	14.6	22.0	667,974.8	0.00	1.00
10/24/2021 06:00	1	1.6	14.7	14.6	24.4	667,540.0	0.00	1.00
10/24/2021 07:00	0	1.6	10.4	14.5	14.4	911,309.1	0.00	1.00
10/24/2021 08:00	0	1.7	9.3	14.4	17.4	1,057,406.3	0.00	1.00
10/24/2021 09:00	0	1.7	9.3	14.4	18.3	1,060,145.2	0.00	1.00
10/24/2021 10:00	0	1.7	9.1	14.4	17.6	1,034,652.8	0.00	1.00
10/24/2021 11:00	0	1.7	9.3	14.4	18.8	1,059,513.1	0.00	1.00
10/24/2021 12:00	0	1.7	9.0	14.4	17.4	1,032,967.3	0.00	1.00
10/24/2021 13:00	0	1.7	9.2	14.4	18.6	1,055,088.8	0.00	1.00
10/24/2021 14:00	1	1.6	10.8	14.4	17.4	823,761.4	0.00	1.00
10/24/2021 15:00	0	1.7	9.2	14.4	16.9	963,653.4	0.00	1.00
10/24/2021 16:00	1	1.6	9.6	14.4	16.4	907,191.0	0.00	1.00
10/24/2021 17:00	0	1.6	8.8	14.4	16.0	1,017,377.0	0.00	1.00
10/24/2021 18:00	1	1.7	10.2	14.4	17.7	808,592.4	0.00	1.00
10/24/2021 19:00	1	1.7	9.8	14.4	16.7	906,137.6	0.00	1.00
10/24/2021 20:00	1	1.6	11.9	14.4	18.5	706,412.3	0.00	1.00
10/24/2021 21:00	1	1.7	11.2	14.4	17.0	736,118.3	0.00	1.00
10/24/2021 22:00	1	1.7	12.5	14.5	20.7	682,358.5	0.00	1.00
10/24/2021 23:00	1	1.6	12.3	14.5	17.3	677,651.1	0.00	1.00
Average/Sum#:	1	1.7	11.6	14.5	19.4	846,135.4	0.00 #	24.00 #
Minimum:	0	1.6	8.8	14.3	14.4	657,106.3	0.00	1.00
Maximum:	2	1.7	17.3	14.7	27.4	1,060,145.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOX, Ppm	Unit CT2 NOX, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/25/2021 00:00	1	1.7	11.5	14.4	18.1	744,124.1	0.00	1.00
10/25/2021 01:00	1	1.6	12.4	14.5	19.0	684,712.2	0.00	1.00
10/25/2021 02:00	1	1.6	12.7	14.5	18.6	677,651.1	0.00	1.00
10/25/2021 03:00	1	1.6	12.9	14.5	19.8	684,926.2	0.00	1.00
10/25/2021 04:00	0	1.6	8.7	14.4	13.3	988,092.4	0.00	1.00
10/25/2021 05:00	0	1.6	8.9	14.4	16.0	1,035,495.5	0.00	1.00
10/25/2021 06:00	0	1.7	9.1	14.4	16.4	984,932.2	0.00	1.00
10/25/2021 07:00	0	1.7	8.3	14.4	14.0	965,338.9	0.00	1.00
10/25/2021 08:00	0	1.7	9.1	14.4	16.9	1,024,750.8	0.00	1.00
10/25/2021 09:00	1	1.7	11.5	14.4	19.9	797,005.0	0.00	1.00
10/25/2021 10:00	1	1.6	16.3	14.7	26.9	669,030.1	0.00	1.00
10/25/2021 11:00	1	1.6	17.0	14.7	27.2	658,869.8	0.00	1.00
10/25/2021 12:00	1	1.6	16.8	14.7	26.9	659,311.6	0.00	1.00
10/25/2021 13:00	1	1.6	15.7	14.7	23.8	668,367.4	0.00	1.00
10/25/2021 14:00	1	1.6	15.7	14.7	25.3	666,600.5	0.00	1.00
10/25/2021 15:00	1	1.6	16.5	14.7	26.4	659,753.3	0.00	1.00
10/25/2021 16:00	0	1.5	10.8	14.5	14.9	899,754.6	0.00	1.00
10/25/2021 17:00	0	1.6	10.5	14.4	15.9	843,354.7	0.00	1.00
10/25/2021 18:00	1	1.7	11.4	14.4	20.0	823,761.4	0.00	1.00
10/25/2021 19:00	0	1.6	9.4	14.4	14.2	941,531.9	0.00	1.00
10/25/2021 20:00	0	1.7	9.3	14.4	17.4	1,026,225.6	0.00	1.00
10/25/2021 21:00	1	1.7	14.6	14.5	26.0	697,978.5	0.00	1.00
10/25/2021 22:00	1	1.5	17.5	14.7	29.5	668,146.6	0.00	1.00
10/25/2021 23:00	1	1.6	15.7	14.7	25.5	683,386.9	0.00	1.00
Average/Sum#:	1	1.6	12.6	14.5	20.5	798,045.9	0.00 #	24.00 #
Minimum:	0	1.5	8.3	14.4	13.3	658,869.8	0.00	1.00
Maximum:	1	1.7	17.5	14.7	29.5	1,035,495.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/26/2021 00:00	1	1.5	17.5	14.8	28.8	677,079.3	0.00	1.00
10/26/2021 01:00	1	1.6	16.4	14.7	26.4	673,668.4	0.00	1.00
10/26/2021 02:00	2	1.8	17.3	14.7	26.3	674,551.9	0.00	1.00
10/26/2021 03:00	2	1.7	15.3	14.7	23.8	687,141.8	0.00	1.00
10/26/2021 04:00	1	1.5	17.5	14.8	28.0	680,671.3	0.00	1.00
10/26/2021 05:00	0	1.6	10.3	14.4	13.9	890,968.6	0.00	1.00
10/26/2021 06:00	1	1.7	14.6	14.5	25.9	696,480.7	0.00	1.00
10/26/2021 07:00	1	1.5	12.7	14.5	18.7	771,157.1	0.00	1.00
10/26/2021 08:00	1	1.7	15.0	14.6	26.3	681,886.4	0.00	1.00
10/26/2021 09:00	1	1.6	14.6	14.6	23.2	678,191.1	0.00	1.00
10/26/2021 10:00	1	1.6	14.6	14.6	22.4	676,669.5	0.00	1.00
10/26/2021 11:00	1	1.7	14.9	14.6	24.5	705,579.6	0.00	1.00
10/26/2021 12:00	1	1.6	14.5	14.7	22.6	686,037.4	0.00	1.00
10/26/2021 13:00	1	1.6	15.8	14.7	27.4	675,656.3	0.00	1.00
10/26/2021 14:00	0	1.6	13.3	14.5	18.6	708,035.2	0.00	1.00
10/26/2021 15:00	1	1.6	15.2	14.7	24.4	680,515.6	0.00	1.00
10/26/2021 16:00	1	1.7	13.1	14.5	20.3	736,921.5	0.00	1.00
10/26/2021 17:00	1	1.6	15.6	14.6	27.7	689,276.9	0.00	1.00
10/26/2021 18:00	0	1.5	10.7	14.4	16.1	847,779.0	0.00	1.00
10/26/2021 19:00	0	1.6	9.6	14.3	15.3	848,005.7	0.00	1.00
10/26/2021 20:00	0	1.6	9.2	14.3	15.3	907,554.9	0.00	1.00
10/26/2021 21:00	1	1.6	10.2	14.4	17.9	907,401.7	0.00	1.00
10/26/2021 22:00	0	1.7	9.0	14.4	14.7	937,529.0	0.00	1.00
10/26/2021 23:00	1	1.6	14.6	14.6	24.6	682,538.5	0.00	1.00
Average/Sum#:	1	1.6	13.8	14.6	22.2	741,720.7	0.00 #	24.00 #
Minimum:	0	1.5	9.0	14.3	13.9	673,668.4	0.00	1.00
Maximum:	2	1.8	17.5	14.8	28.8	937,529.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/27/2021 00:00	1	1.6	14.5	14.6	23.0	680,799.6	0.00	1.00
10/27/2021 01:00	1	1.6	16.6	14.7	28.2	674,551.9	0.00	1.00
10/27/2021 02:00	1	1.6	17.6	14.7	28.4	666,821.3	0.00	1.00
10/27/2021 03:00	1	1.6	16.3	14.6	25.1	669,279.0	0.00	1.00
10/27/2021 04:00	1	1.6	15.5	14.7	24.7	684,933.1	0.00	1.00
10/27/2021 05:00	1	1.5	13.6	14.6	20.6	800,135.1	0.00	1.00
10/27/2021 06:00	1	1.8	10.2	14.4	18.5	976,083.6	0.00	1.00
10/27/2021 07:00	2	1.5	15.0	14.6	29.7	730,794.4	0.00	1.00
10/27/2021 08:00	1	1.6	18.4	14.8	28.9	671,242.4	0.00	1.00
10/27/2021 09:00	1	1.6	18.0	14.8	30.0	671,017.9	0.00	1.00
10/27/2021 10:00	1	1.6	17.4	14.8	28.5	671,017.9	0.00	1.00
10/27/2021 11:00	1	1.6	16.6	14.8	26.7	670,569.0	0.00	1.00
10/27/2021 12:00	1	1.6	16.3	14.8	26.2	669,895.5	0.00	1.00
10/27/2021 13:00	1	1.6	15.4	14.8	23.9	671,242.4	0.00	1.00
10/27/2021 14:00	1	1.6	15.2	14.8	24.0	670,344.5	0.00	1.00
10/27/2021 15:00	1	1.5	13.3	14.7	19.2	724,027.9	0.00	1.00
10/27/2021 16:00	0	1.6	9.2	14.5	14.0	989,837.1	0.00	1.00
10/27/2021 17:00	0	1.7	8.6	14.5	15.5	1,078,849.6	0.00	1.00
10/27/2021 18:00	0	1.7	8.3	14.4	13.9	976,715.6	0.00	1.00
10/27/2021 19:00	0	1.7	8.5	14.4	15.8	1,019,273.1	0.00	1.00
10/27/2021 20:00	0	1.7	8.3	14.3	14.8	922,079.1	0.00	1.00
10/27/2021 21:00	0	1.6	8.2	14.4	13.5	956,490.3	0.00	1.00
10/27/2021 22:00	1	1.7	13.0	14.5	22.5	708,035.2	0.00	1.00
10/27/2021 23:00	1	1.6	13.6	14.6	21.6	681,669.0	0.00	1.00
Average/Sum#:	1	1.6	13.7	14.6	22.4	776,487.7	0.00 #	24.00 #
Minimum:	0	1.5	8.2	14.3	13.5	666,821.3	0.00	1.00
Maximum:	2	1.8	18.4	14.8	30.0	1,078,849.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/28/2021 00:00	1	1.6	13.5	14.6	21.2	681,234.3	0.00	1.00
10/28/2021 01:00	1	1.6	13.5	14.6	21.5	681,886.4	0.00	1.00
10/28/2021 02:00	1	1.6	14.2	14.6	21.9	682,321.1	0.00	1.00
10/28/2021 03:00	1	1.6	14.2	14.6	22.2	682,103.8	0.00	1.00
10/28/2021 04:00	1	1.5	12.8	14.5	19.6	734,781.8	0.00	1.00
10/28/2021 05:00	1	1.6	10.9	14.4	17.3	869,479.1	0.00	1.00
10/28/2021 06:00	1	1.7	10.3	14.3	17.9	873,319.3	0.00	1.00
10/28/2021 07:00	2	1.7	15.7	14.6	28.6	676,234.8	0.00	1.00
10/28/2021 08:00	1	1.5	17.5	14.7	28.0	664,612.6	0.00	1.00
10/28/2021 09:00	1	1.6	16.9	14.7	27.2	659,532.5	0.00	1.00
10/28/2021 10:00	1	1.6	14.4	14.7	20.6	673,226.7	0.00	1.00
10/28/2021 11:00	1	1.6	13.1	14.6	20.9	672,539.5	0.00	1.00
10/28/2021 12:00	1	1.6	12.5	14.6	17.7	674,278.5	0.00	1.00
10/28/2021 13:00	1	1.6	14.9	14.8	24.3	666,303.5	0.00	1.00
10/28/2021 14:00	1	1.6	14.2	14.8	21.8	671,017.9	0.00	1.00
10/28/2021 15:00	1	1.6	13.4	14.7	18.9	668,588.3	0.00	1.00
10/28/2021 16:00	0	1.5	9.2	14.5	14.0	959,025.0	0.00	1.00
10/28/2021 17:00	0	1.7	9.0	14.4	16.5	1,056,352.9	0.00	1.00
10/28/2021 18:00	0	1.6	8.5	14.4	14.6	1,006,842.9	0.00	1.00
10/28/2021 19:00	0	1.7	8.9	14.4	17.4	1,043,922.7	0.00	1.00
10/28/2021 20:00	0	1.7	8.5	14.4	14.7	999,469.1	0.00	1.00
10/28/2021 21:00	1	1.7	9.8	14.4	18.3	885,490.9	0.00	1.00
10/28/2021 22:00	1	1.6	13.0	14.6	19.4	678,191.1	0.00	1.00
10/28/2021 23:00	1	1.6	14.3	14.6	24.1	668,626.9	0.00	1.00
Average/Sum#:	1	1.6	12.6	14.6	20.4	772,057.6	0.00 #	24.00 #
Minimum:	0	1.5	8.5	14.3	14.0	659,532.5	0.00	1.00
Maximum:	2	1.7	17.5	14.8	28.6	1,056,352.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/29/2021 00:00	1	1.6	15.1	14.6	23.5	663,844.8	0.00	1.00
10/29/2021 01:00	1	1.6	15.3	14.6	24.3	662,757.9	0.00	1.00
10/29/2021 02:00	1	1.5	16.9	14.7	26.2	664,833.5	0.00	1.00
10/29/2021 03:00	1	1.6	13.6	14.6	18.8	682,103.8	0.00	1.00
10/29/2021 04:00	1	1.6	13.7	14.6	21.0	682,321.1	0.00	1.00
10/29/2021 05:00	1	1.5	11.7	14.5	17.5	812,881.8	0.00	1.00
10/29/2021 06:00	1	1.7	11.2	14.4	21.8	873,903.4	0.00	1.00
10/29/2021 07:00	1	1.6	15.9	14.6	25.9	665,801.1	0.00	1.00
10/29/2021 08:00	1	1.6	17.4	14.7	27.9	659,974.2	0.00	1.00
10/29/2021 09:00	1	1.6	15.5	14.7	23.9	662,183.0	0.00	1.00
10/29/2021 10:00	1	1.6	14.8	14.7	22.7	660,636.8	0.00	1.00
10/29/2021 11:00	1	1.6	14.5	14.7	22.1	659,753.3	0.00	1.00
10/29/2021 12:00	1	1.6	14.4	14.7	22.0	655,998.5	0.00	1.00
10/29/2021 13:00	1	1.6	13.3	14.7	18.2	666,600.5	0.00	1.00
10/29/2021 14:00	1	1.6	13.9	14.7	22.1	655,998.5	0.00	1.00
10/29/2021 15:00	0	1.5	10.8	14.5	14.2	802,611.1	0.00	1.00
10/29/2021 16:00	0	1.6	8.6	14.4	14.1	1,018,219.7	0.00	1.00
10/29/2021 17:00	0	1.6	8.3	14.5	14.4	1,046,753.8	0.00	1.00
10/29/2021 18:00	1	1.6	9.1	14.3	15.3	872,074.3	0.00	1.00
10/29/2021 19:00	0	1.7	8.5	14.4	15.3	1,034,231.4	0.00	1.00
10/29/2021 20:00	0	1.7	8.3	14.4	13.9	983,246.7	0.00	1.00
10/29/2021 21:00	1	1.8	9.1	14.3	16.5	863,774.8	0.00	1.00
10/29/2021 22:00	0	1.6	9.4	14.3	15.0	842,196.0	0.00	1.00
10/29/2021 23:00	1	1.6	11.4	14.5	18.1	771,157.1	0.00	1.00
Average/Sum#:	1	1.6	12.5	14.5	19.8	773,494.0	0.00 #	24.00 #
Minimum:	0	1.5	8.3	14.3	13.9	655,998.5	0.00	1.00
Maximum:	1	1.8	17.4	14.7	27.9	1,046,753.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOX, Ppm	Unit CT2 NOX, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/30/2021 00:00	1	1.7	12.0	14.4	18.6	716,525.0	0.00	1.00
10/30/2021 01:00	1	1.7	13.7	14.6	21.9	669,279.0	0.00	1.00
10/30/2021 02:00	1	1.4	16.4	14.7	24.6	665,054.3	0.00	1.00
10/30/2021 03:00	1	1.6	13.6	14.6	19.2	672,756.9	0.00	1.00
10/30/2021 04:00	1	1.6	14.0	14.6	21.2	671,235.3	0.00	1.00
10/30/2021 05:00	0	1.6	12.0	14.5	17.0	743,554.6	0.00	1.00
10/30/2021 06:00	2	1.6	15.1	14.6	26.8	664,714.2	0.00	1.00
10/30/2021 07:00	1	1.6	16.3	14.7	25.3	664,833.5	0.00	1.00
10/30/2021 08:00	1	1.6	16.5	14.7	26.0	659,090.7	0.00	1.00
10/30/2021 09:00	1	1.6	16.5	14.7	25.9	657,765.5	0.00	1.00
10/30/2021 10:00	1	1.6	15.8	14.7	24.2	657,102.8	0.00	1.00
10/30/2021 11:00	1	1.6	15.2	14.7	23.2	656,661.1	0.00	1.00
10/30/2021 12:00	1	1.6	15.0	14.7	23.1	655,556.7	0.00	1.00
10/30/2021 13:00	1	1.6	15.1	14.7	23.2	654,673.2	0.00	1.00
10/30/2021 14:00	1	1.6	15.3	14.7	23.9	655,115.0	0.00	1.00
10/30/2021 15:00	0	1.5	12.7	14.6	18.3	797,309.3	0.00	1.00
10/30/2021 16:00	1	1.7	14.1	14.5	21.9	704,825.6	0.00	1.00
10/30/2021 17:00	1	1.7	13.5	14.6	21.8	683,190.6	0.00	1.00
10/30/2021 18:00	1	1.5	16.4	14.7	26.7	659,974.2	0.00	1.00
10/30/2021 19:00	1	1.6	14.5	14.7	22.6	677,202.4	0.00	1.00
10/30/2021 20:00	1	1.5	15.5	14.7	23.7	669,030.1	0.00	1.00
10/30/2021 21:00	1	1.6	15.9	14.7	25.9	665,717.0	0.00	1.00
10/30/2021 22:00	1	1.6	16.0	14.7	25.4	665,717.0	0.00	1.00
10/30/2021 23:00	1	1.6	14.3	14.6	22.2	671,887.4	0.00	1.00
Average/Sum#:	1	1.6	14.8	14.6	23.0	677,448.8	0.00 #	24.00 #
Minimum:	0	1.4	12.0	14.4	17.0	654,673.2	0.00	1.00
Maximum:	2	1.7	16.5	14.7	26.8	797,309.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/31/2021 00:00	1	1.6	15.8	14.7	24.6	669,250.9	0.00	1.00
10/31/2021 01:00	1	1.6	15.8	14.7	25.0	669,913.6	0.00	1.00
10/31/2021 02:00	1	1.6	16.4	14.7	25.1	669,471.8	0.00	1.00
10/31/2021 03:00	1	1.6	16.3	14.7	25.8	669,692.7	0.00	1.00
10/31/2021 04:00	1	1.6	16.2	14.7	25.4	669,913.6	0.00	1.00
10/31/2021 05:00	1	1.6	14.8	14.6	21.9	680,147.4	0.00	1.00
10/31/2021 06:00	1	1.7	14.0	14.5	23.3	704,397.7	0.00	1.00
10/31/2021 07:00	1	1.6	17.1	14.7	28.7	672,784.9	0.00	1.00
10/31/2021 08:00	1	1.6	17.1	14.7	27.5	668,588.3	0.00	1.00
10/31/2021 09:00	1	1.6	15.8	14.7	25.4	673,889.3	0.00	1.00
10/31/2021 10:00	1	1.5	17.4	14.7	28.0	658,207.2	0.00	1.00
10/31/2021 11:00	1	1.6	17.1	14.7	27.1	657,544.6	0.00	1.00
10/31/2021 12:00	1	1.6	16.7	14.7	26.6	656,882.0	0.00	1.00
10/31/2021 13:00	1	1.6	16.1	14.7	25.4	657,323.7	0.00	1.00
10/31/2021 14:00	1	1.6	16.1	14.7	25.4	656,661.1	0.00	1.00
10/31/2021 15:00	1	1.5	14.3	14.6	21.4	705,579.6	0.00	1.00
10/31/2021 16:00	1	1.6	16.7	14.7	28.3	659,974.2	0.00	1.00
10/31/2021 17:00	1	1.6	17.0	14.8	27.5	668,324.0	0.00	1.00
10/31/2021 18:00	1	1.6	17.1	14.7	27.7	657,544.6	0.00	1.00
10/31/2021 19:00	1	1.6	17.2	14.7	27.7	658,428.1	0.00	1.00
10/31/2021 20:00	1	1.6	17.1	14.7	28.0	658,428.1	0.00	1.00
10/31/2021 21:00	1	1.6	17.3	14.7	28.1	658,428.1	0.00	1.00
10/31/2021 22:00	1	1.6	17.0	14.8	27.2	671,691.4	0.00	1.00
10/31/2021 23:00	1	1.6	15.5	14.7	24.5	671,017.9	0.00	1.00
Average/Sum#:	1	1.6	16.3	14.7	26.1	668,503.5	0.00 #	24.00 #
Minimum:	1	1.5	14.0	14.5	21.4	656,661.1	0.00	1.00
Maximum:	1	1.7	17.4	14.8	28.7	705,579.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/01/2021 00:00	1	1.6	16.2	14.7	25.6	665,054.3	0.00	1.00
11/01/2021 01:00	1	1.5	15.1	14.7	23.5	674,331.1	0.00	1.00
11/01/2021 02:00	1	1.6	17.6	14.7	28.3	659,532.5	0.00	1.00
11/01/2021 03:00	0	1.6	14.2	14.6	21.1	673,626.4	0.00	1.00
11/01/2021 04:00	1	1.5	13.1	14.5	18.8	762,384.2	0.00	1.00
11/01/2021 05:00	1	1.7	15.3	14.6	25.6	669,279.0	0.00	1.00
11/01/2021 06:00	0	1.5	8.7	14.4	12.1	986,828.3	0.00	1.00
11/01/2021 07:00	1	1.7	12.2	14.5	20.9	788,488.9	0.00	1.00
11/01/2021 08:00	1	1.6	14.2	14.6	22.4	671,887.4	0.00	1.00
11/01/2021 09:00	1	1.5	10.6	14.4	16.2	806,485.6	0.00	1.00
11/01/2021 10:00	1	1.7	13.4	14.5	21.7	704,183.7	0.00	1.00
11/01/2021 11:00	0	1.5	10.0	14.3	14.4	805,885.5	0.00	1.00
11/01/2021 12:00	1	1.6	10.3	14.4	17.0	874,746.2	0.00	1.00
11/01/2021 13:00	0	1.7	8.8	14.4	16.2	1,056,142.2	0.00	1.00
11/01/2021 14:00	1	1.6	9.8	14.4	17.7	907,612.3	0.00	1.00
11/01/2021 15:00	1	1.6	11.8	14.5	18.1	731,786.2	0.00	1.00
11/01/2021 16:00	1	1.6	11.4	14.5	18.2	810,100.1	0.00	1.00
11/01/2021 17:00	0	1.7	8.6	14.4	14.2	1,009,792.5	0.00	1.00
11/01/2021 18:00	0	1.7	8.3	14.4	14.3	984,300.1	0.00	1.00
11/01/2021 19:00	0	1.7	8.7	14.4	16.1	1,024,118.8	0.00	1.00
11/01/2021 20:00	0	1.7	8.7	14.4	16.2	1,032,124.6	0.00	1.00
11/01/2021 21:00	1	1.7	8.8	14.4	17.4	994,623.5	0.00	1.00
11/01/2021 22:00	1	1.7	11.3	14.5	19.0	831,069.4	0.00	1.00
11/01/2021 23:00	1	1.6	12.9	14.6	20.1	687,320.6	0.00	1.00
Average/Sum#:	1	1.6	11.7	14.5	19.0	825,487.6	0.00 #	24.00 #
Minimum:	0	1.5	8.3	14.3	12.1	659,532.5	0.00	1.00
Maximum:	1	1.7	17.6	14.7	28.3	1,056,142.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/02/2021 00:00	1	1.6	13.0	14.6	20.1	684,494.8	0.00	1.00
11/02/2021 01:00	1	1.7	13.9	14.6	23.6	676,669.5	0.00	1.00
11/02/2021 02:00	1	1.5	17.0	14.7	25.9	664,612.6	0.00	1.00
11/02/2021 03:00	1	1.6	14.4	14.6	21.7	672,104.8	0.00	1.00
11/02/2021 04:00	1	1.6	14.4	14.6	22.4	671,887.4	0.00	1.00
11/02/2021 05:00	1	1.6	13.1	14.6	20.1	709,709.6	0.00	1.00
11/02/2021 06:00	0	1.7	10.0	14.3	15.6	884,316.2	0.00	1.00
11/02/2021 07:00	1	1.7	13.9	14.5	24.7	709,105.1	0.00	1.00
11/02/2021 08:00	2	1.6	17.8	14.7	29.7	657,102.8	0.00	1.00
11/02/2021 09:00	1	1.6	16.3	14.7	26.3	665,054.3	0.00	1.00
11/02/2021 10:00	1	1.6	15.5	14.7	24.5	666,600.5	0.00	1.00
11/02/2021 11:00	1	1.6	15.0	14.7	22.5	667,483.9	0.00	1.00
11/02/2021 12:00	1	1.6	14.7	14.7	22.6	668,367.4	0.00	1.00
11/02/2021 13:00	1	1.6	15.7	14.7	26.0	654,673.2	0.00	1.00
11/02/2021 14:00	1	1.6	15.7	14.7	25.0	654,673.2	0.00	1.00
11/02/2021 15:00	1	1.6	14.5	14.7	21.5	666,600.5	0.00	1.00
11/02/2021 16:00	0	1.5	10.7	14.5	15.9	871,082.3	0.00	1.00
11/02/2021 17:00	0	1.6	8.5	14.4	13.6	1,018,641.1	0.00	1.00
11/02/2021 18:00	0	1.7	8.2	14.4	13.9	972,712.7	0.00	1.00
11/02/2021 19:00	0	1.7	8.7	14.4	17.2	1,058,038.3	0.00	1.00
11/02/2021 20:00	0	1.7	8.7	14.4	16.4	1,042,237.3	0.00	1.00
11/02/2021 21:00	1	1.7	9.8	14.4	19.0	940,057.2	0.00	1.00
11/02/2021 22:00	0	1.7	9.1	14.4	15.7	985,564.2	0.00	1.00
11/02/2021 23:00	1	1.7	10.2	14.2	19.3	810,821.9	0.00	1.00
Average/Sum#:	1	1.6	12.9	14.6	21.0	778,025.5	0.00 #	24.00 #
Minimum:	0	1.5	8.2	14.2	13.6	654,673.2	0.00	1.00
Maximum:	2	1.7	17.8	14.7	29.7	1,058,038.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/03/2021 00:00	1	1.7	10.9	14.2	19.4	789,156.4	0.00	1.00
11/03/2021 01:00	1	1.7	13.5	14.2	22.7	767,082.0	0.00	1.00
11/03/2021 02:00	1	1.7	14.0	14.2	22.3	767,899.6	0.00	1.00
11/03/2021 03:00	1	1.7	12.4	14.2	21.8	782,002.6	0.00	1.00
11/03/2021 04:00	1	1.7	10.3	14.3	19.0	850,703.0	0.00	1.00
11/03/2021 05:00	0	1.6	8.5	14.3	13.4	944,280.4	0.00	1.00
11/03/2021 06:00	1	1.7	9.8	14.3	19.0	941,998.0	0.00	1.00
11/03/2021 07:00	2	1.7	14.6	14.5	26.6	742,056.8	0.00	1.00
11/03/2021 08:00	1	1.5	16.9	14.7	27.3	672,343.2	0.00	1.00
11/03/2021 09:00	1	1.6	18.0	14.7	29.2	656,882.0	0.00	1.00
11/03/2021 10:00	1	1.6	16.6	14.7	26.3	659,311.6	0.00	1.00
11/03/2021 11:00	1	1.6	15.6	14.7	24.7	658,869.8	0.00	1.00
11/03/2021 12:00	1	1.6	15.1	14.7	23.9	665,496.1	0.00	1.00
11/03/2021 13:00	1	1.5	13.8	14.7	20.2	670,355.3	0.00	1.00
11/03/2021 14:00	1	1.6	13.9	14.7	22.0	666,821.3	0.00	1.00
11/03/2021 15:00	0	1.4	11.7	14.6	17.2	782,745.6	0.00	1.00
11/03/2021 16:00	0	1.6	10.2	14.5	16.3	857,602.0	0.00	1.00
11/03/2021 17:00	0	1.7	8.9	14.5	15.9	1,051,675.1	0.00	1.00
11/03/2021 18:00	0	1.7	8.5	14.4	14.6	987,460.3	0.00	1.00
11/03/2021 19:00	0	1.7	8.8	14.4	16.6	1,028,543.1	0.00	1.00
11/03/2021 20:00	0	1.7	8.8	14.4	16.5	1,025,804.2	0.00	1.00
11/03/2021 21:00	0	1.7	8.5	14.3	15.0	934,735.9	0.00	1.00
11/03/2021 22:00	1	1.7	11.1	14.4	19.3	793,212.7	0.00	1.00
11/03/2021 23:00	1	1.6	14.0	14.6	23.0	674,713.2	0.00	1.00
Average/Sum#:	1	1.6	12.3	14.5	20.5	807,156.3	0.00 #	24.00 #
Minimum:	0	1.4	8.5	14.2	13.4	656,882.0	0.00	1.00
Maximum:	2	1.7	18.0	14.7	29.2	1,051,675.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/04/2021 00:00	1	1.6	14.9	14.6	25.5	666,453.2	0.00	1.00
11/04/2021 01:00	1	1.5	17.3	14.7	28.2	657,323.7	0.00	1.00
11/04/2021 02:00	1	1.8	13.6	14.6	17.6	677,104.3	0.00	1.00
11/04/2021 03:00	0	1.3	9.9	14.4	16.2	869,057.8	0.00	1.00
11/04/2021 04:00	1	1.6	12.0	14.5	19.3	765,379.8	0.00	1.00
11/04/2021 05:00	0	1.7	8.8	14.4	14.8	955,436.9	0.00	1.00
11/04/2021 06:00	0	1.7	9.0	14.4	17.0	994,834.1	0.00	1.00
11/04/2021 07:00	0	0.0	0.0	0.0	18.5	222,908.2	0.00	1.00
11/04/2021 08:00	3	1.9	14.8	14.7	25.0	677,423.3	0.00	1.00
11/04/2021 09:00	1	1.3	12.4	14.5	18.7	825,720.1	0.00	1.00
11/04/2021 10:00	2	1.5	17.7	14.8	30.8	665,630.0	0.00	1.00
11/04/2021 11:00	1	1.6	16.8	14.8	27.0	667,875.0	0.00	1.00
11/04/2021 12:00	1	1.6	16.7	14.8	27.0	665,181.1	0.00	1.00
11/04/2021 13:00	1	1.5	15.9	14.8	24.2	671,466.9	0.00	1.00
11/04/2021 14:00	1	1.6	16.5	14.8	27.4	664,058.6	0.00	1.00
11/04/2021 15:00	0	1.4	12.9	14.6	18.5	795,570.4	0.00	1.00
11/04/2021 16:00	1	1.7	13.3	14.5	21.8	696,266.7	0.00	1.00
11/04/2021 17:00	1	1.6	15.3	14.7	25.7	669,250.9	0.00	1.00
11/04/2021 18:00	1	1.6	14.4	14.7	22.4	678,085.9	0.00	1.00
11/04/2021 19:00	1	1.6	14.8	14.6	24.7	667,322.7	0.00	1.00
11/04/2021 20:00	1	1.5	15.8	14.7	26.2	672,564.1	0.00	1.00
11/04/2021 21:00	1	1.6	18.4	14.8	30.9	667,875.0	0.00	1.00
11/04/2021 22:00	2	1.6	18.3	14.8	31.0	669,222.0	0.00	1.00
11/04/2021 23:00	2	1.6	18.7	14.8	31.8	666,977.0	0.00	1.00
Average/Sum#:	1	1.6	14.7	14.7	23.8	722,003.5	0.00 #	24.00 #
Minimum:	0	1.3	8.8	14.4	14.8	657,323.7	0.00	1.00
Maximum:	3	1.9	18.7	14.8	31.8	994,834.1	0.00	1.00
%SI	4.17	4.17	4.17	4.17	0.00	4.17	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/05/2021 00:00	2	1.6	18.9	14.8	32.1	666,303.5	0.00	1.00
11/05/2021 01:00	2	1.6	18.8	14.8	32.1	666,303.5	0.00	1.00
11/05/2021 02:00	1	1.5	19.0	14.8	31.4	669,895.5	0.00	1.00
11/05/2021 03:00	1	1.6	16.7	14.7	26.2	678,306.8	0.00	1.00
11/05/2021 04:00	1	1.7	14.5	14.5	22.1	718,947.8	0.00	1.00
11/05/2021 05:00	1	1.5	11.3	14.5	18.4	910,881.2	0.00	1.00
11/05/2021 06:00	0	1.7	9.3	14.4	16.8	949,327.1	0.00	1.00
11/05/2021 07:00	1	1.7	13.4	14.5	24.8	822,938.5	0.00	1.00
11/05/2021 08:00	2	1.6	17.0	14.7	30.2	673,005.8	0.00	1.00
11/05/2021 09:00	2	1.5	19.5	14.8	33.5	665,181.1	0.00	1.00
11/05/2021 10:00	1	1.5	18.3	14.8	30.7	664,956.6	0.00	1.00
11/05/2021 11:00	1	1.6	17.5	14.8	28.8	665,181.1	0.00	1.00
11/05/2021 12:00	1	1.6	17.0	14.7	27.5	655,777.6	0.00	1.00
11/05/2021 13:00	1	1.6	16.8	14.7	27.5	655,998.5	0.00	1.00
11/05/2021 14:00	0	1.4	12.1	14.6	16.4	761,878.2	0.00	1.00
11/05/2021 15:00	0	1.6	9.6	14.5	15.3	949,610.2	0.00	1.00
11/05/2021 16:00	1	1.6	10.9	14.5	18.3	861,239.6	0.00	1.00
11/05/2021 17:00	1	1.7	9.9	14.4	17.7	863,790.8	0.00	1.00
11/05/2021 18:00	1	1.6	12.0	14.5	20.3	745,694.4	0.00	1.00
11/05/2021 19:00	1	1.5	10.4	14.4	16.3	827,343.0	0.00	1.00
11/05/2021 20:00	1	1.6	10.7	14.5	17.4	863,593.3	0.00	1.00
11/05/2021 21:00	1	1.7	9.8	14.4	18.4	935,632.9	0.00	1.00
11/05/2021 22:00	1	1.5	12.2	14.5	20.6	767,733.5	0.00	1.00
11/05/2021 23:00	1	1.7	10.1	14.4	17.3	858,734.4	0.00	1.00
Average/Sum#:	1	1.6	14.0	14.6	23.3	770,760.6	0.00 #	24.00 #
Minimum:	0	1.4	9.3	14.4	15.3	655,777.6	0.00	1.00
Maximum:	2	1.7	19.5	14.8	33.5	949,610.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/06/2021 00:00	1	1.5	14.6	14.6	24.2	691,885.4	0.00	1.00
11/06/2021 01:00	1	1.7	12.3	14.3	20.4	789,078.9	0.00	1.00
11/06/2021 02:00	0	1.7	0.0	14.5	23.6	693,913.0	0.00	1.00
11/06/2021 03:00	0	1.6	0.0	14.6	24.2	679,060.6	0.00	1.00
11/06/2021 04:00	0	1.6	0.0	14.5	21.8	729,004.5	0.00	1.00
11/06/2021 05:00	0	1.6	0.0	14.4	17.5	874,324.8	0.00	1.00
11/06/2021 06:00	0	1.7	0.0	14.4	15.1	988,513.7	0.00	1.00
11/06/2021 07:00	0	1.7	0.0	14.5	23.4	831,069.4	0.00	1.00
11/06/2021 08:00	0	1.7	0.0	14.5	21.5	774,580.7	0.00	1.00
11/06/2021 09:00	0	1.4	0.0	14.7	30.3	674,772.8	0.00	1.00
11/06/2021 10:00	0	1.6	0.0	14.7	29.9	665,937.8	0.00	1.00
11/06/2021 11:00	0	1.6	0.0	14.7	29.0	665,717.0	0.00	1.00
11/06/2021 12:00	0	1.5	0.0	14.8	30.7	668,997.5	0.00	1.00
11/06/2021 13:00	0	1.6	0.0	14.8	29.8	669,446.5	0.00	1.00
11/06/2021 14:00	0	1.6	0.0	14.8	30.1	668,548.5	0.00	1.00
11/06/2021 15:00	0	1.4	0.0	14.7	23.2	763,564.5	0.00	1.00
11/06/2021 16:00	0	1.6	0.0	14.5	17.0	889,911.9	0.00	1.00
11/06/2021 17:00	0	1.6	0.0	14.4	15.4	996,730.3	0.00	1.00
11/06/2021 18:00	0	1.7	0.0	14.5	20.4	795,122.0	0.00	1.00
11/06/2021 19:00	0	1.6	0.0	14.5	15.7	1,059,806.1	0.00	1.00
11/06/2021 20:00	0	1.7	0.0	14.3	15.2	948,637.6	0.00	1.00
11/06/2021 21:00	0	1.7	0.0	14.4	21.7	869,689.8	0.00	1.00
11/06/2021 22:00	0	1.6	0.0	14.6	24.6	679,712.7	0.00	1.00
11/06/2021 23:00	0	1.6	0.0	14.6	26.2	677,104.3	0.00	1.00
Average/Sum#:	1	1.6	13.5	14.6	23.0	781,047.1	0.00 #	24.00 #
Minimum:	1	1.4	12.3	14.3	15.1	665,717.0	0.00	1.00
Maximum:	1	1.7	14.6	14.8	30.7	1,059,806.1	0.00	1.00
%SI	91.67	0.00	91.67	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/07/2021 00:00	0	1.5	0.0	14.8	35.3	672,589.4	0.00	1.00
11/07/2021 01:00	0	1.5	0.0	14.8	34.7	672,589.4	0.00	1.00
11/07/2021 02:00	0	1.5	0.0	14.8	34.1	675,058.9	0.00	1.00
11/07/2021 03:00	0	1.4	0.0	0.0	35.9	196,961.2	0.00	1.00
11/07/2021 04:00	0	1.3	0.0	0.0	38.4	196,830.2	0.00	1.00
11/07/2021 05:00	0	1.2	0.0	14.8	37.9	681,120.3	0.00	1.00
11/07/2021 06:00	-1	0.9	10.8	14.5	19.5	888,414.1	0.00	1.00
11/07/2021 07:00	1	1.9	12.8	14.4	22.6	939,003.8	0.00	1.00
11/07/2021 08:00	2	1.5	22.1	14.9	39.6	686,081.6	0.00	1.00
11/07/2021 09:00	2	1.5	21.1	14.8	36.1	674,385.4	0.00	1.00
11/07/2021 10:00	2	1.5	20.0	14.8	34.1	670,569.0	0.00	1.00
11/07/2021 11:00	2	1.5	20.0	14.8	34.0	664,283.1	0.00	1.00
11/07/2021 12:00	2	1.5	20.0	14.8	33.8	662,711.6	0.00	1.00
11/07/2021 13:00	1	1.5	19.7	14.8	32.4	662,487.1	0.00	1.00
11/07/2021 14:00	1	1.5	17.5	14.7	27.2	663,950.0	0.00	1.00
11/07/2021 15:00	1	1.3	13.3	14.6	20.9	850,564.7	0.00	1.00
11/07/2021 16:00	1	1.5	11.6	14.5	18.7	873,863.9	0.00	1.00
11/07/2021 17:00	1	1.7	13.1	14.3	22.1	760,860.5	0.00	1.00
11/07/2021 18:00	1	1.4	14.0	14.5	22.5	740,773.0	0.00	1.00
11/07/2021 19:00	1	1.7	10.8	14.3	18.0	846,345.8	0.00	1.00
11/07/2021 20:00	2	1.6	15.7	14.5	27.7	695,196.8	0.00	1.00
11/07/2021 21:00	1	1.5	16.7	14.6	28.0	670,148.5	0.00	1.00
11/07/2021 22:00	1	1.6	16.9	14.6	28.0	671,017.9	0.00	1.00
11/07/2021 23:00	2	1.5	21.3	14.9	39.4	677,636.8	0.00	1.00
Average/Sum#:	1	1.5	16.5	14.7	30.0	727,256.9	0.00 #	24.00 #
Minimum:	-1	0.9	10.8	14.3	18.0	662,487.1	0.00	1.00
Maximum:	2	1.9	22.1	14.9	39.6	939,003.8	0.00	1.00
%SI	25.00	0.00	25.00	8.33	0.00	8.33	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/08/2021 00:00	2	1.4	21.0	14.8	36.8	672,813.9	0.00	1.00
11/08/2021 01:00	1	1.6	17.6	14.6	28.2	675,365.3	0.00	1.00
11/08/2021 02:00	0	1.5	14.6	14.5	23.4	745,694.4	0.00	1.00
11/08/2021 03:00	0	1.6	9.9	14.4	15.4	1,018,219.7	0.00	1.00
11/08/2021 04:00	0	1.6	9.9	14.4	18.5	1,025,804.2	0.00	1.00
11/08/2021 05:00	0	1.6	10.3	14.4	20.2	1,052,350.0	0.00	1.00
11/08/2021 06:00	0	1.6	10.5	14.4	20.5	1,043,080.0	0.00	1.00
11/08/2021 07:00	2	1.7	15.7	14.5	32.0	816,091.3	0.00	1.00
11/08/2021 08:00	2	1.3	21.5	14.8	39.1	671,017.9	0.00	1.00
11/08/2021 09:00	1	1.5	20.0	14.8	32.6	670,120.0	0.00	1.00
11/08/2021 10:00	2	1.5	20.1	14.8	34.6	665,181.1	0.00	1.00
11/08/2021 11:00	1	1.5	18.9	14.8	31.1	664,956.6	0.00	1.00
11/08/2021 12:00	1	1.5	18.4	14.7	29.9	653,127.1	0.00	1.00
11/08/2021 13:00	1	1.5	18.0	14.8	29.4	662,711.6	0.00	1.00
11/08/2021 14:00	1	1.5	18.5	14.8	30.7	661,140.1	0.00	1.00
11/08/2021 15:00	0	1.4	11.9	14.5	15.7	872,152.2	0.00	1.00
11/08/2021 16:00	0	1.7	10.3	14.3	18.5	1,031,633.0	0.00	1.00
11/08/2021 17:00	1	1.7	10.7	14.2	21.8	1,057,318.3	0.00	1.00
11/08/2021 18:00	1	1.7	10.7	14.2	22.1	1,057,318.3	0.00	1.00
11/08/2021 19:00	0	1.7	10.2	14.3	20.3	1,043,044.9	0.00	1.00
11/08/2021 20:00	0	1.7	9.2	14.4	17.1	1,007,475.0	0.00	1.00
11/08/2021 21:00	1	1.7	10.5	14.4	20.6	940,267.9	0.00	1.00
11/08/2021 22:00	1	1.6	11.8	14.5	20.9	837,916.5	0.00	1.00
11/08/2021 23:00	1	1.6	15.3	14.6	23.8	676,886.9	0.00	1.00
Average/Sum#:	1	1.6	14.4	14.5	25.1	842,570.3	0.00 #	24.00 #
Minimum:	0	1.3	9.2	14.2	15.4	653,127.1	0.00	1.00
Maximum:	2	1.7	21.5	14.8	39.1	1,057,318.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/09/2021 00:00	1	1.6	14.8	14.6	23.4	675,365.3	0.00	1.00
11/09/2021 01:00	1	1.6	15.2	14.6	24.6	673,191.6	0.00	1.00
11/09/2021 02:00	1	1.6	16.4	14.6	26.6	663,192.7	0.00	1.00
11/09/2021 03:00	1	1.5	18.8	14.7	31.5	659,532.5	0.00	1.00
11/09/2021 04:00	1	1.7	15.1	14.6	23.2	671,235.3	0.00	1.00
11/09/2021 05:00	1	1.5	13.6	14.5	20.5	716,166.2	0.00	1.00
11/09/2021 06:00	1	1.6	14.3	14.5	23.7	703,755.7	0.00	1.00
11/09/2021 07:00	1	1.7	14.5	14.6	26.8	826,871.5	0.00	1.00
11/09/2021 08:00	1	1.6	17.4	14.7	28.7	668,809.2	0.00	1.00
11/09/2021 09:00	1	1.6	18.6	14.7	30.0	659,090.7	0.00	1.00
11/09/2021 10:00	1	1.6	15.8	14.6	26.1	671,017.9	0.00	1.00
11/09/2021 11:00	1	1.5	17.9	14.7	28.9	666,600.5	0.00	1.00
11/09/2021 12:00	2	1.6	18.3	14.7	30.5	662,845.6	0.00	1.00
11/09/2021 13:00	1	1.6	17.3	14.7	27.0	663,066.5	0.00	1.00
11/09/2021 14:00	1	1.6	15.1	14.6	22.2	678,625.9	0.00	1.00
11/09/2021 15:00	1	1.5	13.8	14.6	21.0	764,921.3	0.00	1.00
11/09/2021 16:00	1	1.6	12.1	14.5	19.0	770,515.2	0.00	1.00
11/09/2021 17:00	0	1.6	9.4	14.4	13.9	878,959.8	0.00	1.00
11/09/2021 18:00	0	1.7	9.0	14.5	16.3	1,067,937.0	0.00	1.00
11/09/2021 19:00	0	1.7	8.9	14.5	16.6	1,045,469.9	0.00	1.00
11/09/2021 20:00	0	1.6	8.9	14.4	16.1	1,012,952.7	0.00	1.00
11/09/2021 21:00	1	1.7	13.1	14.5	22.7	764,737.9	0.00	1.00
11/09/2021 22:00	1	1.6	14.5	14.6	23.0	679,495.3	0.00	1.00
11/09/2021 23:00	1	1.6	15.9	14.7	27.8	680,736.4	0.00	1.00
Average/Sum#:	1	1.6	14.5	14.6	23.8	746,878.9	0.00 #	24.00 #
Minimum:	0	1.5	8.9	14.4	13.9	659,090.7	0.00	1.00
Maximum:	2	1.7	18.8	14.7	31.5	1,067,937.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/10/2021 00:00	1	1.6	17.6	14.7	28.2	666,379.6	0.00	1.00
11/10/2021 01:00	1	1.6	18.5	14.8	30.6	671,466.9	0.00	1.00
11/10/2021 02:00	1	1.5	19.6	14.8	33.1	671,242.4	0.00	1.00
11/10/2021 03:00	2	1.6	19.7	14.8	33.4	670,793.5	0.00	1.00
11/10/2021 04:00	1	1.6	19.4	14.8	32.5	670,569.0	0.00	1.00
11/10/2021 05:00	0	1.5	13.1	14.6	17.1	837,305.2	0.00	1.00
11/10/2021 06:00	1	1.5	10.8	14.4	17.0	868,847.1	0.00	1.00
11/10/2021 07:00	1	1.8	12.7	14.5	24.8	880,925.0	0.00	1.00
11/10/2021 08:00	1	1.5	19.2	14.8	31.6	670,793.5	0.00	1.00
11/10/2021 09:00	1	1.6	17.2	14.7	28.7	671,901.4	0.00	1.00
11/10/2021 10:00	1	1.6	16.3	14.7	25.6	679,411.2	0.00	1.00
11/10/2021 11:00	1	1.5	18.8	14.8	30.9	671,466.9	0.00	1.00
11/10/2021 12:00	1	1.6	18.8	14.8	30.9	671,242.4	0.00	1.00
11/10/2021 13:00	1	1.6	18.5	14.8	29.9	671,017.9	0.00	1.00
11/10/2021 14:00	1	1.6	18.0	14.7	28.6	659,974.2	0.00	1.00
11/10/2021 15:00	1	1.6	17.1	14.7	26.3	662,403.8	0.00	1.00
11/10/2021 16:00	1	1.6	15.2	14.6	22.0	667,540.0	0.00	1.00
11/10/2021 17:00	1	1.6	14.0	14.6	21.2	677,104.3	0.00	1.00
11/10/2021 18:00	1	1.6	14.6	14.6	22.4	676,669.5	0.00	1.00
11/10/2021 19:00	1	1.6	14.5	14.6	22.0	680,799.6	0.00	1.00
11/10/2021 20:00	1	1.6	14.5	14.6	22.0	684,712.2	0.00	1.00
11/10/2021 21:00	1	1.5	14.5	14.6	25.0	733,837.6	0.00	1.00
11/10/2021 22:00	1	1.6	14.7	14.6	21.2	682,973.2	0.00	1.00
11/10/2021 23:00	1	1.6	15.3	14.6	24.5	677,756.4	0.00	1.00
Average/Sum#:	1	1.6	16.4	14.7	26.2	699,047.2	0.00 #	24.00 #
Minimum:	0	1.5	10.8	14.4	17.0	659,974.2	0.00	1.00
Maximum:	2	1.8	19.7	14.8	33.4	880,925.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/11/2021 00:00	1	1.5	17.5	14.7	28.9	677,423.3	0.00	1.00
11/11/2021 01:00	1	1.6	15.6	14.6	23.0	678,625.9	0.00	1.00
11/11/2021 02:00	2	1.5	20.8	14.8	36.3	671,242.4	0.00	1.00
11/11/2021 03:00	2	1.5	20.1	14.8	34.4	673,038.4	0.00	1.00
11/11/2021 04:00	1	1.6	16.8	14.6	24.4	675,800.1	0.00	1.00
11/11/2021 05:00	1	1.6	16.7	14.6	26.5	682,973.2	0.00	1.00
11/11/2021 06:00	1	1.6	16.3	14.6	25.6	681,886.4	0.00	1.00
11/11/2021 07:00	1	1.6	16.8	14.6	28.6	679,712.7	0.00	1.00
11/11/2021 08:00	1	1.6	16.0	14.6	23.0	675,582.7	0.00	1.00
11/11/2021 09:00	1	1.6	16.3	14.6	25.7	677,973.8	0.00	1.00
11/11/2021 10:00	1	1.6	16.0	14.6	24.7	675,148.0	0.00	1.00
11/11/2021 11:00	2	1.6	19.2	14.8	33.2	672,364.9	0.00	1.00
11/11/2021 12:00	1	1.5	18.2	14.8	28.7	674,160.9	0.00	1.00
11/11/2021 13:00	1	1.6	16.6	14.7	25.5	665,937.8	0.00	1.00
11/11/2021 14:00	1	1.6	16.2	14.7	23.9	663,950.0	0.00	1.00
11/11/2021 15:00	0	1.4	12.6	14.6	17.3	743,184.4	0.00	1.00
11/11/2021 16:00	0	1.6	10.4	14.4	14.8	857,470.3	0.00	1.00
11/11/2021 17:00	0	1.7	9.4	14.2	16.8	1,056,296.3	0.00	1.00
11/11/2021 18:00	0	1.7	9.3	14.2	17.8	1,052,821.6	0.00	1.00
11/11/2021 19:00	0	1.7	9.3	14.2	18.3	1,047,916.2	0.00	1.00
11/11/2021 20:00	0	1.7	9.3	14.2	18.6	1,044,237.2	0.00	1.00
11/11/2021 21:00	0	1.7	9.4	14.2	18.8	1,048,325.0	0.00	1.00
11/11/2021 22:00	1	1.8	11.1	14.3	21.1	907,969.9	0.00	1.00
11/11/2021 23:00	1	1.6	14.4	14.5	22.1	689,847.5	0.00	1.00
Average/Sum#:	1	1.6	14.8	14.5	24.1	773,912.0	0.00 #	24.00 #
Minimum:	0	1.4	9.3	14.2	14.8	663,950.0	0.00	1.00
Maximum:	2	1.8	20.8	14.8	36.3	1,056,296.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/12/2021 00:00	2	1.6	18.7	14.7	32.4	667,042.2	0.00	1.00
11/12/2021 01:00	2	1.6	19.6	14.8	33.0	670,120.0	0.00	1.00
11/12/2021 02:00	1	1.5	20.3	14.8	33.0	670,344.5	0.00	1.00
11/12/2021 03:00	2	1.6	20.3	14.8	34.3	671,017.9	0.00	1.00
11/12/2021 04:00	1	1.5	19.9	14.8	32.3	675,283.4	0.00	1.00
11/12/2021 05:00	1	1.6	15.9	14.6	23.2	680,364.8	0.00	1.00
11/12/2021 06:00	1	1.6	15.5	14.6	24.5	682,538.5	0.00	1.00
11/12/2021 07:00	2	1.6	18.9	14.8	32.6	682,691.7	0.00	1.00
11/12/2021 08:00	1	1.5	18.6	14.7	30.8	670,355.3	0.00	1.00
11/12/2021 09:00	1	1.6	18.9	14.8	31.3	670,569.0	0.00	1.00
11/12/2021 10:00	1	1.6	18.9	14.8	31.0	670,344.5	0.00	1.00
11/12/2021 11:00	1	1.6	18.6	14.8	30.7	671,017.9	0.00	1.00
11/12/2021 12:00	1	1.6	18.8	14.8	30.8	670,344.5	0.00	1.00
11/12/2021 13:00	1	1.6	18.4	14.8	29.9	669,895.5	0.00	1.00
11/12/2021 14:00	1	1.5	17.3	14.7	26.0	667,483.9	0.00	1.00
11/12/2021 15:00	1	1.5	13.8	14.6	20.2	718,404.4	0.00	1.00
11/12/2021 16:00	1	1.7	15.5	14.6	24.2	667,974.8	0.00	1.00
11/12/2021 17:00	1	1.7	15.1	14.6	25.6	673,843.7	0.00	1.00
11/12/2021 18:00	1	1.5	18.4	14.8	30.5	673,038.4	0.00	1.00
11/12/2021 19:00	1	1.6	14.2	14.6	20.0	680,147.4	0.00	1.00
11/12/2021 20:00	1	1.6	14.5	14.6	22.5	679,495.3	0.00	1.00
11/12/2021 21:00	1	1.3	12.1	14.4	19.6	737,803.7	0.00	1.00
11/12/2021 22:00	1	1.7	16.6	14.7	28.2	676,539.8	0.00	1.00
11/12/2021 23:00	1	1.5	19.3	14.8	31.8	671,915.9	0.00	1.00
Average/Sum#:	1	1.6	17.4	14.7	28.3	677,857.4	0.00 #	24.00 #
Minimum:	1	1.3	12.1	14.4	19.6	667,042.2	0.00	1.00
Maximum:	2	1.7	20.3	14.8	34.3	737,803.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/13/2021 00:00	1	1.6	18.4	14.7	30.7	666,600.5	0.00	1.00
11/13/2021 01:00	1	1.6	18.7	14.7	31.1	665,496.1	0.00	1.00
11/13/2021 02:00	2	1.5	15.2	14.6	25.2	679,712.7	0.00	1.00
11/13/2021 03:00	2	1.4	15.3	14.6	22.3	679,060.6	0.00	1.00
11/13/2021 04:00	0	1.3	13.6	14.5	18.9	707,821.2	0.00	1.00
11/13/2021 05:00	0	1.4	10.7	14.5	13.9	831,925.3	0.00	1.00
11/13/2021 06:00	0	1.7	8.4	14.4	14.1	1,058,670.4	0.00	1.00
11/13/2021 07:00	0	1.7	8.5	14.4	15.8	1,057,827.7	0.00	1.00
11/13/2021 08:00	0	1.7	8.5	14.4	16.6	1,057,827.7	0.00	1.00
11/13/2021 09:00	0	1.6	8.5	14.4	16.7	1,057,406.3	0.00	1.00
11/13/2021 10:00	1	1.7	11.2	14.4	22.4	850,307.2	0.00	1.00
11/13/2021 11:00	1	1.5	15.8	14.6	25.5	704,492.8	0.00	1.00
11/13/2021 12:00	1	1.5	17.6	14.7	26.8	673,005.8	0.00	1.00
11/13/2021 13:00	2	1.7	17.9	14.7	30.7	665,937.8	0.00	1.00
11/13/2021 14:00	1	1.6	17.6	14.7	27.6	663,287.3	0.00	1.00
11/13/2021 15:00	0	1.6	13.9	14.5	18.3	699,476.3	0.00	1.00
11/13/2021 16:00	0	1.5	8.1	14.5	11.6	1,026,426.4	0.00	1.00
11/13/2021 17:00	1	1.7	12.0	14.4	20.6	729,165.8	0.00	1.00
11/13/2021 18:00	1	1.6	11.8	14.4	18.1	738,014.4	0.00	1.00
11/13/2021 19:00	0	1.5	7.9	14.3	10.5	913,364.6	0.00	1.00
11/13/2021 20:00	1	1.8	9.1	14.3	15.3	883,071.2	0.00	1.00
11/13/2021 21:00	1	1.7	13.6	14.5	22.2	717,450.0	0.00	1.00
11/13/2021 22:00	1	1.6	15.1	14.6	24.0	682,103.8	0.00	1.00
11/13/2021 23:00	2	1.6	18.6	14.8	32.4	677,977.3	0.00	1.00
Average/Sum#:	1	1.6	13.2	14.5	21.3	795,267.9	0.00 #	24.00 #
Minimum:	0	1.3	7.9	14.3	10.5	663,287.3	0.00	1.00
Maximum:	2	1.8	18.7	14.8	32.4	1,058,670.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/14/2021 00:00	2	1.6	19.7	14.8	33.4	670,344.5	0.00	1.00
11/14/2021 01:00	2	1.6	19.5	14.8	33.1	670,344.5	0.00	1.00
11/14/2021 02:00	1	1.5	20.4	14.8	33.6	670,569.0	0.00	1.00
11/14/2021 03:00	2	1.6	20.2	14.8	34.0	669,671.0	0.00	1.00
11/14/2021 04:00	1	1.6	19.6	14.8	32.3	672,364.9	0.00	1.00
11/14/2021 05:00	2	1.6	19.8	14.8	33.8	670,120.0	0.00	1.00
11/14/2021 06:00	2	1.6	19.3	14.8	32.8	674,609.9	0.00	1.00
11/14/2021 07:00	1	1.6	18.2	14.7	29.7	669,913.6	0.00	1.00
11/14/2021 08:00	2	1.6	18.8	14.7	31.7	665,496.1	0.00	1.00
11/14/2021 09:00	1	1.6	18.5	14.8	30.3	676,405.8	0.00	1.00
11/14/2021 10:00	1	1.6	18.5	14.8	30.5	676,181.4	0.00	1.00
11/14/2021 11:00	1	1.6	18.2	14.7	29.9	664,833.5	0.00	1.00
11/14/2021 12:00	1	1.6	18.0	14.7	29.5	664,833.5	0.00	1.00
11/14/2021 13:00	2	1.6	18.8	14.8	31.6	671,691.4	0.00	1.00
11/14/2021 14:00	1	1.6	19.1	14.8	32.0	669,671.0	0.00	1.00
11/14/2021 15:00	1	1.4	15.0	14.6	20.8	707,101.2	0.00	1.00
11/14/2021 16:00	1	1.6	17.4	14.7	29.0	666,158.7	0.00	1.00
11/14/2021 17:00	2	1.6	18.1	14.8	31.7	677,079.3	0.00	1.00
11/14/2021 18:00	1	1.6	18.3	14.8	30.0	674,160.9	0.00	1.00
11/14/2021 19:00	1	1.6	17.0	14.7	27.7	673,668.4	0.00	1.00
11/14/2021 20:00	1	1.6	14.2	14.6	19.8	693,624.3	0.00	1.00
11/14/2021 21:00	1	1.7	15.5	14.6	25.9	677,104.3	0.00	1.00
11/14/2021 22:00	1	1.6	18.0	14.7	29.8	670,134.4	0.00	1.00
11/14/2021 23:00	2	1.6	19.8	14.8	33.8	671,017.9	0.00	1.00
Average/Sum#:	1	1.6	18.3	14.7	30.3	673,629.1	0.00 #	24.00 #
Minimum:	1	1.4	14.2	14.6	19.8	664,833.5	0.00	1.00
Maximum:	2	1.7	20.4	14.8	34.0	707,101.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/15/2021 00:00	1	1.6	19.1	14.8	31.8	672,589.4	0.00	1.00
11/15/2021 01:00	2	1.6	19.5	14.8	32.7	670,120.0	0.00	1.00
11/15/2021 02:00	1	1.6	20.0	14.8	32.1	670,344.5	0.00	1.00
11/15/2021 03:00	1	1.6	19.2	14.8	31.7	673,711.9	0.00	1.00
11/15/2021 04:00	1	1.6	18.5	14.7	30.9	668,367.4	0.00	1.00
11/15/2021 05:00	1	1.6	15.6	14.6	22.0	675,582.7	0.00	1.00
11/15/2021 06:00	1	1.5	12.7	14.5	19.2	732,000.1	0.00	1.00
11/15/2021 07:00	1	1.5	13.3	14.5	22.4	746,978.2	0.00	1.00
11/15/2021 08:00	1	1.5	17.6	14.7	27.7	673,226.7	0.00	1.00
11/15/2021 09:00	1	1.6	15.0	14.6	22.6	680,364.8	0.00	1.00
11/15/2021 10:00	1	1.6	15.0	14.6	23.5	678,625.9	0.00	1.00
11/15/2021 11:00	1	1.7	16.3	14.7	27.4	678,748.6	0.00	1.00
11/15/2021 12:00	2	1.5	19.3	14.8	32.6	668,773.0	0.00	1.00
11/15/2021 13:00	1	1.6	16.6	14.7	24.6	673,889.3	0.00	1.00
11/15/2021 14:00	0	1.4	11.3	14.5	15.8	816,091.3	0.00	1.00
11/15/2021 15:00	1	1.5	11.8	14.5	18.5	778,432.2	0.00	1.00
11/15/2021 16:00	1	1.7	12.5	14.5	18.3	705,681.5	0.00	1.00
11/15/2021 17:00	1	1.7	14.8	14.6	24.8	674,713.2	0.00	1.00
11/15/2021 18:00	1	1.6	14.2	14.6	21.8	682,755.9	0.00	1.00
11/15/2021 19:00	0	1.6	9.4	14.4	13.7	834,927.5	0.00	1.00
11/15/2021 20:00	1	1.6	14.4	14.6	23.0	679,060.6	0.00	1.00
11/15/2021 21:00	1	1.5	12.5	14.5	18.8	723,869.2	0.00	1.00
11/15/2021 22:00	1	1.7	15.3	14.6	25.9	673,191.6	0.00	1.00
11/15/2021 23:00	1	1.5	19.0	14.8	31.9	669,671.0	0.00	1.00
Average/Sum#:	1	1.6	15.5	14.6	24.7	700,071.5	0.00 #	24.00 #
Minimum:	0	1.4	9.4	14.4	13.7	668,367.4	0.00	1.00
Maximum:	2	1.7	20.0	14.8	32.7	834,927.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/16/2021 00:00	1	1.7	14.6	14.6	21.2	675,800.1	0.00	1.00
11/16/2021 01:00	1	1.6	14.3	14.6	21.5	679,495.3	0.00	1.00
11/16/2021 02:00	2	1.6	17.9	14.7	30.8	671,901.4	0.00	1.00
11/16/2021 03:00	2	1.6	18.8	14.8	28.2	672,813.9	0.00	1.00
11/16/2021 04:00	1	1.6	15.2	14.6	21.8	674,061.1	0.00	1.00
11/16/2021 05:00	0	1.4	9.8	14.5	12.9	903,606.1	0.00	1.00
11/16/2021 06:00	0	1.7	8.5	14.4	14.5	1,062,673.3	0.00	1.00
11/16/2021 07:00	0	1.7	8.6	14.4	15.9	1,062,462.6	0.00	1.00
11/16/2021 08:00	1	1.8	11.0	14.4	21.6	875,588.9	0.00	1.00
11/16/2021 09:00	0	1.3	11.5	14.5	17.3	809,244.2	0.00	1.00
11/16/2021 10:00	2	1.3	16.7	14.7	31.6	677,202.4	0.00	1.00
11/16/2021 11:00	1	1.4	16.9	14.7	28.3	674,551.9	0.00	1.00
11/16/2021 12:00	1	1.4	17.7	14.7	28.3	665,937.8	0.00	1.00
11/16/2021 13:00	1	1.6	16.8	14.7	26.1	666,158.7	0.00	1.00
11/16/2021 14:00	1	1.6	16.7	14.7	26.3	664,391.7	0.00	1.00
11/16/2021 15:00	0	1.5	13.4	14.6	18.3	720,360.7	0.00	1.00
11/16/2021 16:00	1	1.7	13.4	14.6	21.0	680,364.8	0.00	1.00
11/16/2021 17:00	0	1.4	9.9	14.4	12.3	818,705.1	0.00	1.00
11/16/2021 18:00	0	1.8	8.5	14.3	11.9	864,397.3	0.00	1.00
11/16/2021 19:00	1	1.4	11.0	14.4	17.7	764,349.5	0.00	1.00
11/16/2021 20:00	0	1.7	8.1	14.4	13.1	988,092.4	0.00	1.00
11/16/2021 21:00	0	1.7	8.4	14.4	14.8	1,002,418.6	0.00	1.00
11/16/2021 22:00	1	1.8	10.2	14.4	19.5	905,084.2	0.00	1.00
11/16/2021 23:00	0	1.6	9.6	14.2	12.1	785,681.7	0.00	1.00
Average/Sum#:	1	1.6	12.8	14.5	20.3	790,222.7	0.00 #	24.00 #
Minimum:	0	1.3	8.1	14.2	11.9	664,391.7	0.00	1.00
Maximum:	2	1.8	18.8	14.8	31.6	1,062,673.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/17/2021 00:00	0	1.7	9.2	14.3	18.2	1,048,439.6	0.00	1.00
11/17/2021 01:00	1	1.8	11.1	14.3	21.7	899,877.8	0.00	1.00
11/17/2021 02:00	1	1.6	16.2	14.6	24.7	678,625.9	0.00	1.00
11/17/2021 03:00	1	1.6	16.0	14.6	25.2	681,234.3	0.00	1.00
11/17/2021 04:00	0	1.4	11.8	14.5	16.8	814,593.5	0.00	1.00
11/17/2021 05:00	1	1.6	11.8	14.5	18.7	821,012.7	0.00	1.00
11/17/2021 06:00	0	1.7	8.4	14.4	14.0	1,022,433.3	0.00	1.00
11/17/2021 07:00	1	1.7	11.5	14.5	22.2	870,012.4	0.00	1.00
11/17/2021 08:00	1	1.4	16.1	14.6	27.3	673,191.6	0.00	1.00
11/17/2021 09:00	1	1.6	14.7	14.6	20.8	679,930.1	0.00	1.00
11/17/2021 10:00	1	1.6	15.3	14.6	25.1	676,669.5	0.00	1.00
11/17/2021 11:00	2	1.3	18.6	14.8	33.8	673,936.4	0.00	1.00
11/17/2021 12:00	2	1.4	19.1	14.8	33.8	670,344.5	0.00	1.00
11/17/2021 13:00	2	1.3	19.4	14.8	34.0	668,997.5	0.00	1.00
11/17/2021 14:00	2	1.4	19.1	14.8	33.1	668,997.5	0.00	1.00
11/17/2021 15:00	0	1.2	13.6	14.6	19.2	785,354.0	0.00	1.00
11/17/2021 16:00	0	1.4	10.6	14.5	16.6	878,999.3	0.00	1.00
11/17/2021 17:00	0	1.5	8.1	14.4	13.6	997,783.7	0.00	1.00
11/17/2021 18:00	0	1.4	8.4	14.5	16.3	1,058,950.2	0.00	1.00
11/17/2021 19:00	0	1.4	8.4	14.4	17.1	1,046,029.5	0.00	1.00
11/17/2021 20:00	0	1.4	8.4	14.4	16.7	1,030,228.5	0.00	1.00
11/17/2021 21:00	0	1.5	8.9	14.3	15.9	927,473.8	0.00	1.00
11/17/2021 22:00	1	1.5	14.7	14.5	26.4	695,624.8	0.00	1.00
11/17/2021 23:00	1	1.4	16.1	14.6	27.0	683,408.0	0.00	1.00
Average/Sum#:	1	1.5	13.1	14.5	22.4	818,839.5	0.00 #	24.00 #
Minimum:	0	1.2	8.1	14.3	13.6	668,997.5	0.00	1.00
Maximum:	2	1.8	19.4	14.8	34.0	1,058,950.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/18/2021 00:00	1	1.4	16.2	14.6	26.9	681,886.4	0.00	1.00
11/18/2021 01:00	1	1.4	16.0	14.6	26.7	681,886.4	0.00	1.00
11/18/2021 02:00	1	1.5	17.0	14.6	26.5	681,669.0	0.00	1.00
11/18/2021 03:00	1	1.6	16.8	14.6	26.9	681,669.0	0.00	1.00
11/18/2021 04:00	1	1.6	16.6	14.6	26.5	681,669.0	0.00	1.00
11/18/2021 05:00	1	1.4	13.3	14.5	19.9	770,301.2	0.00	1.00
11/18/2021 06:00	0	1.7	8.2	14.4	12.4	1,008,949.7	0.00	1.00
11/18/2021 07:00	1	1.8	9.8	14.3	18.7	909,007.3	0.00	1.00
11/18/2021 08:00	1	1.5	10.5	14.4	19.4	832,610.0	0.00	1.00
11/18/2021 09:00	2	1.3	16.6	14.6	31.5	683,408.0	0.00	1.00
11/18/2021 10:00	2	1.2	18.9	14.8	33.5	675,507.9	0.00	1.00
11/18/2021 11:00	2	1.3	17.9	14.7	31.2	665,717.0	0.00	1.00
11/18/2021 12:00	2	1.2	17.7	14.8	30.9	676,405.8	0.00	1.00
11/18/2021 13:00	1	1.4	14.6	14.6	20.8	689,929.0	0.00	1.00
11/18/2021 14:00	0	1.5	12.5	14.5	16.7	718,305.9	0.00	1.00
11/18/2021 15:00	0	1.3	9.0	14.5	15.8	954,531.6	0.00	1.00
11/18/2021 16:00	0	1.3	8.0	14.4	14.6	995,676.9	0.00	1.00
11/18/2021 17:00	0	1.3	8.2	14.4	15.8	1,005,157.5	0.00	1.00
11/18/2021 18:00	0	1.5	8.5	14.5	15.9	1,080,561.4	0.00	1.00
11/18/2021 19:00	0	1.7	8.3	14.4	15.4	1,034,231.4	0.00	1.00
11/18/2021 20:00	1	1.7	10.1	14.4	19.5	876,853.0	0.00	1.00
11/18/2021 21:00	0	1.3	9.6	14.3	14.7	782,439.3	0.00	1.00
11/18/2021 22:00	1	1.4	12.3	14.5	21.1	746,122.3	0.00	1.00
11/18/2021 23:00	1	1.4	13.0	14.5	21.0	717,664.0	0.00	1.00
Average/Sum#:	1	1.4	12.9	14.5	21.8	801,340.0	0.00 #	24.00 #
Minimum:	0	1.2	8.0	14.3	12.4	665,717.0	0.00	1.00
Maximum:	2	1.8	18.9	14.8	33.5	1,080,561.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/19/2021 00:00	1	1.3	14.9	14.6	26.9	721,664.9	0.00	1.00
11/19/2021 01:00	1	1.4	15.3	14.6	23.3	674,495.9	0.00	1.00
11/19/2021 02:00	1	1.5	15.5	14.6	23.5	677,539.0	0.00	1.00
11/19/2021 03:00	0	1.5	12.0	14.5	19.9	800,899.3	0.00	1.00
11/19/2021 04:00	1	1.6	15.3	14.6	24.4	676,017.4	0.00	1.00
11/19/2021 05:00	1	1.6	15.4	14.6	24.2	675,365.3	0.00	1.00
11/19/2021 06:00	1	1.5	14.4	14.6	22.2	701,884.3	0.00	1.00
11/19/2021 07:00	0	1.5	9.9	14.4	14.9	887,176.3	0.00	1.00
11/19/2021 08:00	1	1.8	12.8	14.4	24.0	747,073.7	0.00	1.00
11/19/2021 09:00	2	1.2	18.1	14.7	32.6	665,717.0	0.00	1.00
11/19/2021 10:00	2	1.2	17.3	14.7	30.3	668,588.3	0.00	1.00
11/19/2021 11:00	1	1.3	16.2	14.7	27.7	672,784.9	0.00	1.00
11/19/2021 12:00	0	1.3	13.3	14.6	18.5	689,929.0	0.00	1.00
11/19/2021 13:00	0	1.1	8.3	14.5	12.8	970,365.6	0.00	1.00
11/19/2021 14:00	0	1.3	9.3	14.5	16.2	922,007.8	0.00	1.00
11/19/2021 15:00	1	1.3	10.8	14.4	17.7	771,723.3	0.00	1.00
11/19/2021 16:00	1	1.4	13.7	14.6	24.1	687,538.0	0.00	1.00
11/19/2021 17:00	1	1.3	11.9	14.5	20.1	730,074.4	0.00	1.00
11/19/2021 18:00	1	1.3	13.4	14.5	22.1	696,052.7	0.00	1.00
11/19/2021 19:00	1	1.3	14.4	14.6	24.1	681,886.4	0.00	1.00
11/19/2021 20:00	1	1.3	10.9	14.4	17.9	765,192.2	0.00	1.00
11/19/2021 21:00	1	1.3	11.8	14.4	20.1	732,115.3	0.00	1.00
11/19/2021 22:00	1	1.2	12.5	14.5	21.5	752,113.5	0.00	1.00
11/19/2021 23:00	2	1.3	18.1	14.7	33.5	668,809.2	0.00	1.00
Average/Sum#:	1	1.4	13.6	14.6	22.6	734,875.6	0.00 #	24.00 #
Minimum:	0	1.1	8.3	14.4	12.8	665,717.0	0.00	1.00
Maximum:	2	1.8	18.1	14.7	33.5	970,365.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/20/2021 00:00	2	1.3	19.7	14.8	36.2	671,017.9	0.00	1.00
11/20/2021 01:00	2	1.3	19.2	14.8	34.6	674,609.9	0.00	1.00
11/20/2021 02:00	2	1.3	20.0	14.8	35.2	674,834.4	0.00	1.00
11/20/2021 03:00	2	1.2	19.8	14.8	35.9	678,426.3	0.00	1.00
11/20/2021 04:00	1	1.3	16.1	14.6	25.1	681,886.4	0.00	1.00
11/20/2021 05:00	2	1.2	19.3	14.8	35.3	684,263.2	0.00	1.00
11/20/2021 06:00	1	1.5	16.0	14.6	24.1	693,406.9	0.00	1.00
11/20/2021 07:00	1	1.5	13.2	14.5	23.9	820,370.8	0.00	1.00
11/20/2021 08:00	2	1.3	20.5	14.9	37.6	680,603.9	0.00	1.00
11/20/2021 09:00	2	1.3	20.8	14.9	38.2	679,919.2	0.00	1.00
11/20/2021 10:00	2	1.3	20.4	14.8	36.5	669,446.5	0.00	1.00
11/20/2021 11:00	2	1.4	19.9	14.8	35.3	667,875.0	0.00	1.00
11/20/2021 12:00	2	1.3	19.2	14.8	33.0	667,650.5	0.00	1.00
11/20/2021 13:00	2	1.4	18.7	14.8	31.9	666,079.0	0.00	1.00
11/20/2021 14:00	1	1.4	17.9	14.8	29.8	665,405.6	0.00	1.00
11/20/2021 15:00	0	1.1	12.6	14.6	18.1	773,833.5	0.00	1.00
11/20/2021 16:00	1	1.3	12.1	14.6	18.6	775,137.7	0.00	1.00
11/20/2021 17:00	1	1.4	14.0	14.6	23.2	695,363.3	0.00	1.00
11/20/2021 18:00	1	1.4	14.8	14.7	24.7	683,828.7	0.00	1.00
11/20/2021 19:00	1	1.3	12.6	14.5	18.4	732,856.0	0.00	1.00
11/20/2021 20:00	1	1.4	10.9	14.4	17.4	774,883.5	0.00	1.00
11/20/2021 21:00	0	1.4	7.9	14.4	12.0	980,507.9	0.00	1.00
11/20/2021 22:00	1	1.6	11.1	14.4	21.5	838,719.8	0.00	1.00
11/20/2021 23:00	2	1.3	16.9	14.6	29.9	678,843.2	0.00	1.00
Average/Sum#:	1	1.3	16.4	14.7	28.2	717,073.7	0.00 #	24.00 #
Minimum:	0	1.1	7.9	14.4	12.0	665,405.6	0.00	1.00
Maximum:	2	1.6	20.8	14.9	38.2	980,507.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/21/2021 00:00	1	1.4	12.3	14.5	20.0	795,550.0	0.00	1.00
11/21/2021 01:00	1	1.4	16.4	14.6	27.5	682,973.2	0.00	1.00
11/21/2021 02:00	1	1.2	20.3	14.8	39.0	679,099.8	0.00	1.00
11/21/2021 03:00	1	1.5	16.7	14.6	26.0	681,669.0	0.00	1.00
11/21/2021 04:00	1	1.4	16.9	14.6	28.6	683,408.0	0.00	1.00
11/21/2021 05:00	0	1.3	8.8	14.3	11.4	941,998.0	0.00	1.00
11/21/2021 06:00	0	1.5	8.7	14.3	15.2	965,029.2	0.00	1.00
11/21/2021 07:00	0	1.5	8.9	14.3	16.7	966,274.1	0.00	1.00
11/21/2021 08:00	0	1.4	8.4	14.4	16.3	1,031,913.9	0.00	1.00
11/21/2021 09:00	1	1.7	11.7	14.5	23.2	852,038.7	0.00	1.00
11/21/2021 10:00	0	1.1	9.3	14.4	13.9	837,877.0	0.00	1.00
11/21/2021 11:00	1	1.5	12.7	14.5	21.9	732,000.1	0.00	1.00
11/21/2021 12:00	2	1.3	18.9	14.8	34.7	671,466.9	0.00	1.00
11/21/2021 13:00	2	1.3	19.0	14.8	32.9	670,344.5	0.00	1.00
11/21/2021 14:00	2	1.4	18.3	14.8	31.2	670,120.0	0.00	1.00
11/21/2021 15:00	0	1.1	12.5	14.6	18.8	834,696.8	0.00	1.00
11/21/2021 16:00	1	1.3	11.2	14.5	16.8	778,004.2	0.00	1.00
11/21/2021 17:00	1	1.6	14.3	14.7	24.6	685,374.8	0.00	1.00
11/21/2021 18:00	1	1.4	14.8	14.6	24.9	676,669.5	0.00	1.00
11/21/2021 19:00	0	1.2	10.9	14.5	16.8	827,431.9	0.00	1.00
11/21/2021 20:00	0	1.4	8.1	14.5	14.6	1,068,792.9	0.00	1.00
11/21/2021 21:00	1	1.6	10.4	14.4	20.9	871,586.0	0.00	1.00
11/21/2021 22:00	1	1.4	9.7	14.4	15.5	847,568.4	0.00	1.00
11/21/2021 23:00	1	1.4	16.2	14.6	28.0	679,495.3	0.00	1.00
Average/Sum#:	1	1.4	13.1	14.5	22.5	797,140.9	0.00 #	24.00 #
Minimum:	0	1.1	8.1	14.3	11.4	670,120.0	0.00	1.00
Maximum:	2	1.7	20.3	14.8	39.0	1,068,792.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/22/2021 00:00	1	1.4	15.8	14.6	26.2	682,538.5	0.00	1.00
11/22/2021 01:00	1	1.4	15.8	14.6	26.2	682,755.9	0.00	1.00
11/22/2021 02:00	1	1.4	16.8	14.6	27.6	682,973.2	0.00	1.00
11/22/2021 03:00	1	1.4	16.6	14.6	27.7	683,190.6	0.00	1.00
11/22/2021 04:00	1	1.4	16.9	14.6	28.7	682,755.9	0.00	1.00
11/22/2021 05:00	1	1.4	16.7	14.6	28.5	689,059.6	0.00	1.00
11/22/2021 06:00	1	1.2	12.9	14.5	20.4	806,034.6	0.00	1.00
11/22/2021 07:00	1	1.6	14.5	14.5	26.4	805,392.7	0.00	1.00
11/22/2021 08:00	1	1.4	17.5	14.6	29.4	684,277.5	0.00	1.00
11/22/2021 09:00	2	1.4	19.9	14.8	38.7	678,426.3	0.00	1.00
11/22/2021 10:00	2	1.4	19.7	14.8	35.3	672,140.4	0.00	1.00
11/22/2021 11:00	1	1.4	18.4	14.8	30.9	671,466.9	0.00	1.00
11/22/2021 12:00	1	1.4	15.3	14.7	22.7	676,981.6	0.00	1.00
11/22/2021 13:00	1	1.4	13.6	14.6	21.6	677,104.3	0.00	1.00
11/22/2021 14:00	0	1.2	9.8	14.5	14.2	899,326.7	0.00	1.00
11/22/2021 15:00	0	1.4	8.0	14.5	14.1	1,080,561.4	0.00	1.00
11/22/2021 16:00	1	1.3	9.3	14.4	15.9	869,057.8	0.00	1.00
11/22/2021 17:00	1	1.5	12.4	14.5	21.9	721,087.5	0.00	1.00
11/22/2021 18:00	0	1.3	7.5	14.4	11.3	978,822.4	0.00	1.00
11/22/2021 19:00	0	1.5	7.7	14.3	14.1	953,824.8	0.00	1.00
11/22/2021 20:00	0	1.4	8.0	14.3	15.0	970,423.9	0.00	1.00
11/22/2021 21:00	0	1.4	7.8	14.4	14.4	977,558.3	0.00	1.00
11/22/2021 22:00	0	1.5	8.0	14.4	15.2	986,617.6	0.00	1.00
11/22/2021 23:00	1	1.6	12.3	14.5	24.1	823,580.4	0.00	1.00
Average/Sum#:	1	1.4	13.4	14.5	22.9	793,165.0	0.00 #	24.00 #
Minimum:	0	1.2	7.5	14.3	11.3	671,466.9	0.00	1.00
Maximum:	2	1.6	19.9	14.8	38.7	1,080,561.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/23/2021 00:00	1	1.4	16.3	14.6	27.0	679,712.7	0.00	1.00
11/23/2021 01:00	1	1.4	15.7	14.6	25.8	682,755.9	0.00	1.00
11/23/2021 02:00	1	1.4	16.0	14.6	25.8	684,060.1	0.00	1.00
11/23/2021 03:00	1	1.5	16.3	14.6	27.7	679,060.6	0.00	1.00
11/23/2021 04:00	2	1.4	19.3	14.8	33.1	682,018.2	0.00	1.00
11/23/2021 05:00	2	1.3	19.5	14.8	34.5	680,446.8	0.00	1.00
11/23/2021 06:00	1	1.4	17.8	14.7	29.1	693,326.3	0.00	1.00
11/23/2021 07:00	2	1.4	14.6	14.6	28.5	790,570.9	0.00	1.00
11/23/2021 08:00	2	1.4	19.7	14.8	35.1	683,140.7	0.00	1.00
11/23/2021 09:00	2	1.3	20.6	14.9	36.6	682,886.3	0.00	1.00
11/23/2021 10:00	2	1.3	19.7	14.8	34.8	669,671.0	0.00	1.00
11/23/2021 11:00	2	1.4	18.9	14.8	32.7	669,671.0	0.00	1.00
11/23/2021 12:00	1	1.4	18.0	14.7	30.3	659,090.7	0.00	1.00
11/23/2021 13:00	1	1.4	17.6	14.7	29.2	658,428.1	0.00	1.00
11/23/2021 14:00	1	1.4	17.4	14.7	28.8	659,532.5	0.00	1.00
11/23/2021 15:00	1	1.2	13.4	14.6	19.4	744,488.7	0.00	1.00
11/23/2021 16:00	1	1.4	12.6	14.5	19.8	717,236.0	0.00	1.00
11/23/2021 17:00	1	1.5	14.4	14.6	24.0	678,191.1	0.00	1.00
11/23/2021 18:00	1	1.4	14.9	14.6	24.9	677,973.8	0.00	1.00
11/23/2021 19:00	1	1.4	15.1	14.6	25.0	678,843.2	0.00	1.00
11/23/2021 20:00	2	1.4	18.2	14.7	34.2	674,772.8	0.00	1.00
11/23/2021 21:00	1	1.4	17.2	14.7	29.8	682,282.6	0.00	1.00
11/23/2021 22:00	1	1.4	16.0	14.6	24.6	681,451.7	0.00	1.00
11/23/2021 23:00	2	1.4	19.5	14.8	37.3	685,610.2	0.00	1.00
Average/Sum#:	1	1.4	17.0	14.7	29.1	686,467.6	0.00 #	24.00 #
Minimum:	1	1.2	12.6	14.5	19.4	658,428.1	0.00	1.00
Maximum:	2	1.5	20.6	14.9	37.3	790,570.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/24/2021 00:00	1	1.5	16.5	14.6	23.9	682,973.2	0.00	1.00
11/24/2021 01:00	1	1.6	17.0	14.6	27.7	682,321.1	0.00	1.00
11/24/2021 02:00	2	1.7	21.1	14.9	39.0	690,646.4	0.00	1.00
11/24/2021 03:00	2	1.7	21.3	14.8	35.7	679,548.8	0.00	1.00
11/24/2021 04:00	1	1.6	20.1	14.8	33.3	685,385.7	0.00	1.00
11/24/2021 05:00	1	1.7	19.2	14.7	31.7	680,957.3	0.00	1.00
11/24/2021 06:00	1	1.6	15.9	14.5	25.1	722,585.3	0.00	1.00
11/24/2021 07:00	2	1.6	14.1	14.5	30.0	802,611.1	0.00	1.00
11/24/2021 08:00	2	0.7	16.9	14.6	22.7	678,843.2	0.00	1.00
11/24/2021 09:00	2	1.3	15.5	14.6	26.3	701,884.3	0.00	1.00
11/24/2021 10:00	1	1.6	16.2	14.6	25.3	677,104.3	0.00	1.00
11/24/2021 11:00	1	1.6	15.7	14.7	24.2	686,258.3	0.00	1.00
11/24/2021 12:00	1	1.6	15.5	14.7	24.2	685,153.9	0.00	1.00
11/24/2021 13:00	1	1.6	15.4	14.7	24.1	684,712.2	0.00	1.00
11/24/2021 14:00	1	1.6	14.9	14.7	22.9	686,037.4	0.00	1.00
11/24/2021 15:00	0	1.4	12.4	14.6	18.3	764,486.6	0.00	1.00
11/24/2021 16:00	1	1.4	12.1	14.5	17.7	749,331.9	0.00	1.00
11/24/2021 17:00	1	1.7	15.1	14.7	25.9	688,908.8	0.00	1.00
11/24/2021 18:00	1	1.6	15.8	14.6	25.0	675,800.1	0.00	1.00
11/24/2021 19:00	1	1.6	15.5	14.6	24.3	684,060.1	0.00	1.00
11/24/2021 20:00	1	1.6	15.2	14.6	23.9	697,971.7	0.00	1.00
11/24/2021 21:00	1	1.5	14.2	14.5	22.2	714,668.4	0.00	1.00
11/24/2021 22:00	1	1.6	16.0	14.6	25.8	683,190.6	0.00	1.00
11/24/2021 23:00	1	1.6	16.3	14.6	26.0	685,146.9	0.00	1.00
Average/Sum#:	1	1.5	16.2	14.6	26.1	698,774.5	0.00 #	24.00 #
Minimum:	0	0.7	12.1	14.5	17.7	675,800.1	0.00	1.00
Maximum:	2	1.7	21.3	14.9	39.0	802,611.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/25/2021 00:00	1	1.6	16.7	14.6	27.0	686,016.4	0.00	1.00
11/25/2021 01:00	1	1.6	16.9	14.6	27.4	685,799.0	0.00	1.00
11/25/2021 02:00	1	1.5	16.7	14.6	26.0	687,538.0	0.00	1.00
11/25/2021 03:00	1	1.6	16.7	14.6	27.1	687,103.3	0.00	1.00
11/25/2021 04:00	1	1.6	16.9	14.6	27.5	688,624.8	0.00	1.00
11/25/2021 05:00	1	1.6	16.8	14.6	27.3	687,755.4	0.00	1.00
11/25/2021 06:00	1	1.6	16.3	14.6	25.8	697,319.6	0.00	1.00
11/25/2021 07:00	1	1.5	14.0	14.5	26.0	770,301.2	0.00	1.00
11/25/2021 08:00	1	1.4	16.0	14.6	23.7	703,405.9	0.00	1.00
11/25/2021 09:00	1	1.6	16.9	14.6	26.8	676,886.9	0.00	1.00
11/25/2021 10:00	1	1.6	15.8	14.6	25.0	676,886.9	0.00	1.00
11/25/2021 11:00	1	1.6	14.8	14.6	23.0	687,972.7	0.00	1.00
11/25/2021 12:00	1	1.6	15.2	14.6	23.8	673,626.4	0.00	1.00
11/25/2021 13:00	1	1.6	15.0	14.6	23.5	674,713.2	0.00	1.00
11/25/2021 14:00	1	1.6	15.0	14.7	23.7	684,270.4	0.00	1.00
11/25/2021 15:00	1	1.5	14.0	14.6	21.0	698,623.8	0.00	1.00
11/25/2021 16:00	1	1.6	13.5	14.6	19.8	698,623.8	0.00	1.00
11/25/2021 17:00	1	1.7	15.3	14.6	26.0	672,974.3	0.00	1.00
11/25/2021 18:00	1	1.6	15.4	14.6	23.9	680,582.2	0.00	1.00
11/25/2021 19:00	1	1.6	16.0	14.6	26.5	672,756.9	0.00	1.00
11/25/2021 20:00	1	1.6	16.5	14.6	26.9	672,756.9	0.00	1.00
11/25/2021 21:00	1	1.6	16.3	14.6	26.3	674,930.6	0.00	1.00
11/25/2021 22:00	1	1.6	16.4	14.6	26.4	673,409.0	0.00	1.00
11/25/2021 23:00	1	1.6	16.4	14.6	26.6	675,148.0	0.00	1.00
Average/Sum#:	1	1.6	15.8	14.6	25.3	687,001.1	0.00 #	24.00 #
Minimum:	1	1.4	13.5	14.5	19.8	672,756.9	0.00	1.00
Maximum:	1	1.7	16.9	14.7	27.5	770,301.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/26/2021 00:00	1	1.6	16.4	14.6	26.5	674,061.1	0.00	1.00
11/26/2021 01:00	1	1.6	16.4	14.6	26.7	674,713.2	0.00	1.00
11/26/2021 02:00	1	1.6	17.1	14.6	26.9	675,148.0	0.00	1.00
11/26/2021 03:00	1	1.6	16.8	14.6	27.2	675,582.7	0.00	1.00
11/26/2021 04:00	1	1.6	16.9	14.6	27.0	675,582.7	0.00	1.00
11/26/2021 05:00	1	1.6	16.8	14.6	27.5	673,843.7	0.00	1.00
11/26/2021 06:00	1	1.6	17.0	14.6	28.0	674,495.9	0.00	1.00
11/26/2021 07:00	1	1.6	16.9	14.6	27.8	676,017.4	0.00	1.00
11/26/2021 08:00	1	1.6	17.0	14.6	27.4	674,061.1	0.00	1.00
11/26/2021 09:00	1	1.6	16.5	14.6	26.5	674,278.5	0.00	1.00
11/26/2021 10:00	1	1.6	16.4	14.6	26.3	674,495.9	0.00	1.00
11/26/2021 11:00	1	1.6	16.1	14.6	25.4	672,104.8	0.00	1.00
11/26/2021 12:00	1	1.6	15.6	14.6	24.4	670,583.2	0.00	1.00
11/26/2021 13:00	1	1.6	15.1	14.7	23.5	679,852.9	0.00	1.00
11/26/2021 14:00	1	1.6	14.9	14.7	23.0	678,748.6	0.00	1.00
11/26/2021 15:00	1	1.4	12.1	14.6	18.7	792,961.9	0.00	1.00
11/26/2021 16:00	1	1.6	14.4	14.7	23.2	691,559.3	0.00	1.00
11/26/2021 17:00	1	1.6	15.2	14.7	24.4	681,178.2	0.00	1.00
11/26/2021 18:00	1	1.6	15.5	14.6	24.4	669,279.0	0.00	1.00
11/26/2021 19:00	1	1.6	15.7	14.6	24.7	669,713.7	0.00	1.00
11/26/2021 20:00	1	1.6	15.8	14.6	25.0	672,756.9	0.00	1.00
11/26/2021 21:00	1	1.6	15.5	14.6	24.2	674,930.6	0.00	1.00
11/26/2021 22:00	1	1.6	15.7	14.6	24.9	673,626.4	0.00	1.00
11/26/2021 23:00	1	1.6	15.7	14.6	24.7	676,886.9	0.00	1.00
Average/Sum#:	1	1.6	15.9	14.6	25.3	680,269.3	0.00 #	24.00 #
Minimum:	1	1.4	12.1	14.6	18.7	669,279.0	0.00	1.00
Maximum:	1	1.6	17.1	14.7	28.0	792,961.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/27/2021 00:00	1	1.6	16.2	14.6	26.1	672,974.3	0.00	1.00
11/27/2021 01:00	1	1.6	16.0	14.6	25.3	676,017.4	0.00	1.00
11/27/2021 02:00	1	1.6	16.6	14.6	25.7	673,191.6	0.00	1.00
11/27/2021 03:00	1	1.6	16.9	14.6	27.0	674,713.2	0.00	1.00
11/27/2021 04:00	1	1.6	17.0	14.6	27.6	673,191.6	0.00	1.00
11/27/2021 05:00	1	1.6	15.1	14.5	22.1	708,463.1	0.00	1.00
11/27/2021 06:00	1	1.6	15.9	14.5	26.8	684,498.2	0.00	1.00
11/27/2021 07:00	1	1.6	12.2	14.4	20.5	799,954.5	0.00	1.00
11/27/2021 08:00	1	1.6	16.7	14.6	26.7	672,756.9	0.00	1.00
11/27/2021 09:00	1	1.4	13.9	14.5	21.3	730,074.4	0.00	1.00
11/27/2021 10:00	0	1.7	9.9	14.4	14.7	838,930.4	0.00	1.00
11/27/2021 11:00	1	1.6	15.0	14.6	23.8	672,104.8	0.00	1.00
11/27/2021 12:00	1	1.6	14.5	14.6	22.7	671,887.4	0.00	1.00
11/27/2021 13:00	1	1.6	14.3	14.7	22.1	681,619.9	0.00	1.00
11/27/2021 14:00	1	1.6	14.1	14.7	21.9	680,957.3	0.00	1.00
11/27/2021 15:00	1	1.4	11.9	14.6	17.8	773,398.7	0.00	1.00
11/27/2021 16:00	1	1.4	10.7	14.5	16.6	796,619.8	0.00	1.00
11/27/2021 17:00	1	1.7	14.4	14.6	23.6	682,103.8	0.00	1.00
11/27/2021 18:00	1	1.6	14.9	14.6	23.6	672,322.2	0.00	1.00
11/27/2021 19:00	1	1.6	14.9	14.6	23.5	672,756.9	0.00	1.00
11/27/2021 20:00	1	1.6	15.1	14.6	23.7	674,713.2	0.00	1.00
11/27/2021 21:00	1	1.6	13.2	14.5	18.7	704,397.7	0.00	1.00
11/27/2021 22:00	1	1.6	15.6	14.6	26.0	674,061.1	0.00	1.00
11/27/2021 23:00	1	1.6	15.8	14.6	25.2	674,930.6	0.00	1.00
Average/Sum#:	1	1.6	14.6	14.6	23.0	701,526.6	0.00 #	24.00 #
Minimum:	0	1.4	9.9	14.4	14.7	671,887.4	0.00	1.00
Maximum:	1	1.7	17.0	14.7	27.6	838,930.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/28/2021 00:00	1	1.6	15.8	14.6	25.2	674,713.2	0.00	1.00
11/28/2021 01:00	1	1.6	16.1	14.6	25.9	674,930.6	0.00	1.00
11/28/2021 02:00	1	1.6	16.8	14.6	26.2	676,017.4	0.00	1.00
11/28/2021 03:00	1	1.6	16.8	14.6	27.0	676,452.2	0.00	1.00
11/28/2021 04:00	1	1.6	16.9	14.6	27.2	676,669.5	0.00	1.00
11/28/2021 05:00	1	1.6	16.7	14.6	27.0	676,452.2	0.00	1.00
11/28/2021 06:00	1	1.6	16.7	14.6	27.3	677,104.3	0.00	1.00
11/28/2021 07:00	1	1.5	14.8	14.5	23.4	704,825.6	0.00	1.00
11/28/2021 08:00	1	1.6	16.6	14.6	27.2	677,104.3	0.00	1.00
11/28/2021 09:00	1	1.6	15.9	14.6	25.2	675,800.1	0.00	1.00
11/28/2021 10:00	1	1.6	15.1	14.6	23.7	674,713.2	0.00	1.00
11/28/2021 11:00	1	1.6	14.5	14.6	22.4	672,974.3	0.00	1.00
11/28/2021 12:00	1	1.6	14.1	14.6	21.8	672,539.5	0.00	1.00
11/28/2021 13:00	1	1.6	13.9	14.6	21.2	671,235.3	0.00	1.00
11/28/2021 14:00	1	1.6	13.7	14.7	20.8	681,399.1	0.00	1.00
11/28/2021 15:00	1	1.6	13.5	14.6	20.6	673,409.0	0.00	1.00
11/28/2021 16:00	1	1.5	12.3	14.6	19.0	703,623.3	0.00	1.00
11/28/2021 17:00	1	1.4	14.0	14.6	22.9	671,887.4	0.00	1.00
11/28/2021 18:00	1	1.6	14.4	14.6	22.3	672,539.5	0.00	1.00
11/28/2021 19:00	1	1.6	14.7	14.6	23.1	673,626.4	0.00	1.00
11/28/2021 20:00	1	1.6	15.0	14.6	23.9	674,061.1	0.00	1.00
11/28/2021 21:00	1	1.6	15.3	14.6	24.3	674,713.2	0.00	1.00
11/28/2021 22:00	1	1.6	15.6	14.6	24.8	674,930.6	0.00	1.00
11/28/2021 23:00	1	1.6	15.8	14.6	25.0	675,148.0	0.00	1.00
Average/Sum#:	1	1.6	15.2	14.6	24.1	677,369.6	0.00 #	24.00 #
Minimum:	1	1.4	12.3	14.5	19.0	671,235.3	0.00	1.00
Maximum:	1	1.6	16.9	14.7	27.3	704,825.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/29/2021 00:00	1	1.6	15.8	14.6	25.0	675,148.0	0.00	1.00
11/29/2021 01:00	1	1.6	15.8	14.6	25.2	674,930.6	0.00	1.00
11/29/2021 02:00	1	1.6	16.6	14.6	25.7	675,365.3	0.00	1.00
11/29/2021 03:00	1	1.6	16.6	14.6	26.4	675,582.7	0.00	1.00
11/29/2021 04:00	1	1.6	16.6	14.6	26.7	676,886.9	0.00	1.00
11/29/2021 05:00	1	1.6	16.2	14.6	25.5	690,798.5	0.00	1.00
11/29/2021 06:00	0	1.5	11.1	14.4	14.8	808,592.4	0.00	1.00
11/29/2021 07:00	1	1.7	12.5	14.5	22.7	826,790.0	0.00	1.00
11/29/2021 08:00	1	1.6	16.8	14.6	27.7	676,886.9	0.00	1.00
11/29/2021 09:00	1	1.6	16.0	14.6	25.3	675,800.1	0.00	1.00
11/29/2021 10:00	1	1.6	15.1	14.6	23.8	675,148.0	0.00	1.00
11/29/2021 11:00	1	1.6	14.5	14.6	22.5	674,061.1	0.00	1.00
11/29/2021 12:00	1	1.6	13.8	14.6	21.1	672,539.5	0.00	1.00
11/29/2021 13:00	1	1.6	13.5	14.6	20.6	671,452.7	0.00	1.00
11/29/2021 14:00	1	1.6	13.3	14.6	20.0	670,583.2	0.00	1.00
11/29/2021 15:00	0	1.5	11.2	14.6	15.4	749,705.5	0.00	1.00
11/29/2021 16:00	0	1.5	8.8	14.4	12.3	867,372.3	0.00	1.00
11/29/2021 17:00	0	1.7	7.6	14.3	11.0	887,428.5	0.00	1.00
11/29/2021 18:00	1	1.5	10.7	14.4	16.5	742,438.7	0.00	1.00
11/29/2021 19:00	0	1.7	8.3	14.3	12.5	875,394.2	0.00	1.00
11/29/2021 20:00	0	1.7	8.1	14.4	14.8	1,024,329.4	0.00	1.00
11/29/2021 21:00	1	1.8	11.8	14.4	21.7	778,675.8	0.00	1.00
11/29/2021 22:00	1	1.6	14.4	14.5	21.6	694,554.9	0.00	1.00
11/29/2021 23:00	1	1.6	15.9	14.6	25.6	674,930.6	0.00	1.00
Average/Sum#:	1	1.6	13.4	14.5	21.0	738,141.5	0.00 #	24.00 #
Minimum:	0	1.5	7.6	14.3	11.0	670,583.2	0.00	1.00
Maximum:	1	1.8	16.8	14.6	27.7	1,024,329.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/30/2021 00:00	0	1.5	10.1	14.4	13.5	884,648.2	0.00	1.00
11/30/2021 01:00	1	1.7	14.0	14.5	23.9	719,375.7	0.00	1.00
11/30/2021 02:00	1	1.6	16.3	14.6	25.9	674,495.9	0.00	1.00
11/30/2021 03:00	1	1.6	16.3	14.6	26.0	674,278.5	0.00	1.00
11/30/2021 04:00	1	1.6	16.0	14.6	25.0	676,886.9	0.00	1.00
11/30/2021 05:00	1	1.5	14.1	14.5	21.8	730,716.3	0.00	1.00
11/30/2021 06:00	0	1.6	8.6	14.4	12.5	987,671.0	0.00	1.00
11/30/2021 07:00	0	1.8	9.5	14.4	17.4	985,564.2	0.00	1.00
11/30/2021 08:00	2	1.6	15.5	14.5	27.1	684,070.3	0.00	1.00
11/30/2021 09:00	1	1.5	16.1	14.6	26.6	674,495.9	0.00	1.00
11/30/2021 10:00	1	1.5	15.3	14.6	24.6	673,191.6	0.00	1.00
11/30/2021 11:00	1	1.5	14.5	14.6	22.8	672,104.8	0.00	1.00
11/30/2021 12:00	1	1.5	14.1	14.6	22.1	671,887.4	0.00	1.00
11/30/2021 13:00	1	1.5	13.7	14.6	21.3	671,017.9	0.00	1.00
11/30/2021 14:00	1	1.5	13.2	14.6	20.3	670,365.8	0.00	1.00
11/30/2021 15:00	0	1.4	11.0	14.5	16.2	787,205.0	0.00	1.00
11/30/2021 16:00	0	1.4	9.0	14.4	15.2	915,828.9	0.00	1.00
11/30/2021 17:00	0	1.7	9.9	13.9	19.6	1,027,263.9	0.00	1.00
11/30/2021 18:00	1	2.1	13.4	12.4	31.5	1,076,850.9	0.00	1.00
11/30/2021 19:00	2	2.0	13.3	12.4	32.7	1,072,501.0	0.00	1.00
11/30/2021 20:00	1	1.7	10.2	13.9	22.3	1,060,717.0	0.00	1.00
11/30/2021 21:00	1	1.9	12.8	12.8	28.8	1,072,377.6	0.00	1.00
11/30/2021 22:00	0	1.6	9.2	14.3	19.4	1,061,096.4	0.00	1.00
11/30/2021 23:00	1	1.7	10.6	14.3	21.2	896,765.5	0.00	1.00
Average/Sum#:	1	1.6	12.8	14.2	22.4	834,224.0	0.00 #	24.00 #
Minimum:	0	1.4	8.6	12.4	12.5	670,365.8	0.00	1.00
Maximum:	2	2.1	16.3	14.6	32.7	1,076,850.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/01/2021 00:00	1	1.5	16.1	14.6	26.6	674,713.2	0.00	1.00
12/01/2021 01:00	1	1.5	15.9	14.6	25.9	674,930.6	0.00	1.00
12/01/2021 02:00	1	1.5	16.7	14.6	26.7	675,582.7	0.00	1.00
12/01/2021 03:00	1	1.6	16.7	14.6	26.6	676,017.4	0.00	1.00
12/01/2021 04:00	1	1.6	16.4	14.6	26.4	675,582.7	0.00	1.00
12/01/2021 05:00	1	1.6	16.3	14.6	26.3	676,234.8	0.00	1.00
12/01/2021 06:00	1	1.6	16.2	14.6	26.3	676,234.8	0.00	1.00
12/01/2021 07:00	1	1.6	16.2	14.6	26.5	676,234.8	0.00	1.00
12/01/2021 08:00	1	1.6	16.1	14.6	25.6	675,800.1	0.00	1.00
12/01/2021 09:00	1	1.6	15.2	14.6	23.6	674,495.9	0.00	1.00
12/01/2021 10:00	1	1.6	14.3	14.6	21.9	672,974.3	0.00	1.00
12/01/2021 11:00	1	1.6	13.5	14.6	20.5	671,670.1	0.00	1.00
12/01/2021 12:00	1	1.6	13.2	14.6	20.1	671,235.3	0.00	1.00
12/01/2021 13:00	1	1.6	12.9	14.6	19.5	670,148.5	0.00	1.00
12/01/2021 14:00	1	1.6	12.7	14.6	19.0	669,931.1	0.00	1.00
12/01/2021 15:00	1	1.5	11.2	14.6	16.4	728,620.7	0.00	1.00
12/01/2021 16:00	0	1.4	9.2	14.5	12.9	835,348.9	0.00	1.00
12/01/2021 17:00	0	1.7	7.9	14.4	11.6	911,615.3	0.00	1.00
12/01/2021 18:00	0	1.6	8.0	14.4	13.7	981,350.6	0.00	1.00
12/01/2021 19:00	0	1.6	8.2	14.5	15.4	1,034,985.3	0.00	1.00
12/01/2021 20:00	0	1.7	7.9	14.4	14.1	974,398.1	0.00	1.00
12/01/2021 21:00	0	1.7	8.1	14.4	15.2	1,012,531.3	0.00	1.00
12/01/2021 22:00	1	1.5	12.8	14.5	23.6	718,305.9	0.00	1.00
12/01/2021 23:00	1	1.3	15.0	14.6	25.0	673,843.7	0.00	1.00
Average/Sum#:	1	1.6	13.2	14.6	21.2	749,282.8	0.00 #	24.00 #
Minimum:	0	1.3	7.9	14.4	11.6	669,931.1	0.00	1.00
Maximum:	1	1.7	16.7	14.6	26.7	1,034,985.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/02/2021 00:00	1	1.3	14.6	14.6	24.7	685,581.7	0.00	1.00
12/02/2021 01:00	1	1.2	13.8	14.5	21.9	712,742.6	0.00	1.00
12/02/2021 02:00	0	1.2	13.8	14.5	23.9	691,345.3	0.00	1.00
12/02/2021 03:00	0	1.5	8.7	14.3	11.6	910,667.2	0.00	1.00
12/02/2021 04:00	0	1.7	8.5	14.4	14.4	1,000,733.2	0.00	1.00
12/02/2021 05:00	0	1.7	8.9	14.3	17.0	1,009,846.7	0.00	1.00
12/02/2021 06:00	1	1.7	9.9	14.0	21.6	1,057,235.3	0.00	1.00
12/02/2021 07:00	1	1.7	10.0	14.1	21.5	1,064,526.1	0.00	1.00
12/02/2021 08:00	1	1.6	11.4	14.4	23.9	913,300.7	0.00	1.00
12/02/2021 09:00	1	1.4	16.5	14.6	27.8	675,148.0	0.00	1.00
12/02/2021 10:00	1	1.4	15.7	14.6	25.7	673,626.4	0.00	1.00
12/02/2021 11:00	1	1.4	14.5	14.6	23.2	672,539.5	0.00	1.00
12/02/2021 12:00	1	1.4	13.9	14.6	22.1	671,235.3	0.00	1.00
12/02/2021 13:00	1	1.4	13.4	14.6	20.6	670,365.8	0.00	1.00
12/02/2021 14:00	1	1.6	13.3	14.6	19.8	669,279.0	0.00	1.00
12/02/2021 15:00	0	1.4	11.3	14.6	16.1	763,182.4	0.00	1.00
12/02/2021 16:00	0	1.7	9.5	14.3	14.1	852,362.9	0.00	1.00
12/02/2021 17:00	1	2.0	11.4	13.3	22.6	1,064,727.5	0.00	1.00
12/02/2021 18:00	1	1.8	9.8	13.9	20.3	1,037,828.1	0.00	1.00
12/02/2021 19:00	1	1.7	9.6	14.0	20.3	1,049,892.0	0.00	1.00
12/02/2021 20:00	1	1.8	10.1	13.8	21.5	1,062,750.5	0.00	1.00
12/02/2021 21:00	1	1.8	10.1	13.9	21.9	1,075,976.3	0.00	1.00
12/02/2021 22:00	1	1.8	11.1	14.2	22.4	893,600.5	0.00	1.00
12/02/2021 23:00	1	1.6	15.4	14.6	24.2	673,626.4	0.00	1.00
Average/Sum#:	1	1.6	11.9	14.3	21.0	856,338.3	0.00 #	24.00 #
Minimum:	0	1.2	8.5	13.3	11.6	669,279.0	0.00	1.00
Maximum:	1	2.0	16.5	14.6	27.8	1,075,976.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/03/2021 00:00	1	1.6	15.6	14.6	25.0	673,626.4	0.00	1.00
12/03/2021 01:00	1	1.6	15.7	14.6	25.4	673,843.7	0.00	1.00
12/03/2021 02:00	1	1.6	16.4	14.6	25.8	674,061.1	0.00	1.00
12/03/2021 03:00	1	1.6	16.4	14.6	26.4	673,843.7	0.00	1.00
12/03/2021 04:00	1	1.6	16.2	14.6	25.8	674,495.9	0.00	1.00
12/03/2021 05:00	1	1.5	15.5	14.5	23.9	686,637.9	0.00	1.00
12/03/2021 06:00	1	1.6	15.2	14.5	24.7	694,341.0	0.00	1.00
12/03/2021 07:00	1	1.6	12.8	14.5	20.9	785,279.3	0.00	1.00
12/03/2021 08:00	1	1.6	15.5	14.6	24.6	687,538.0	0.00	1.00
12/03/2021 09:00	0	1.5	10.9	14.4	15.2	845,250.9	0.00	1.00
12/03/2021 10:00	0	1.7	8.4	14.4	14.8	1,040,130.5	0.00	1.00
12/03/2021 11:00	1	1.6	10.8	14.4	18.2	859,577.2	0.00	1.00
12/03/2021 12:00	1	1.8	11.6	14.4	20.2	774,883.5	0.00	1.00
12/03/2021 13:00	1	1.5	15.4	14.6	24.7	674,061.1	0.00	1.00
12/03/2021 14:00	1	1.6	15.3	14.6	24.0	673,409.0	0.00	1.00
12/03/2021 15:00	0	1.5	11.1	14.5	15.9	847,331.3	0.00	1.00
12/03/2021 16:00	0	1.7	9.5	14.1	16.5	931,007.2	0.00	1.00
12/03/2021 17:00	1	1.8	10.0	14.0	20.5	1,072,914.2	0.00	1.00
12/03/2021 18:00	1	1.8	10.1	14.0	21.3	1,071,723.4	0.00	1.00
12/03/2021 19:00	1	1.8	10.1	14.0	21.6	1,071,128.0	0.00	1.00
12/03/2021 20:00	1	1.8	10.0	14.0	21.7	1,071,525.0	0.00	1.00
12/03/2021 21:00	1	1.8	10.0	14.0	21.6	1,071,525.0	0.00	1.00
12/03/2021 22:00	1	1.8	10.1	14.0	21.8	1,073,311.2	0.00	1.00
12/03/2021 23:00	1	1.6	11.3	14.2	23.9	901,571.8	0.00	1.00
Average/Sum#:	1	1.7	12.7	14.4	21.9	841,792.3	0.00 #	24.00 #
Minimum:	0	1.5	8.4	14.0	14.8	673,409.0	0.00	1.00
Maximum:	1	1.8	16.4	14.6	26.4	1,073,311.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/04/2021 00:00	1	1.3	15.5	14.6	26.5	674,061.1	0.00	1.00
12/04/2021 01:00	1	1.3	15.6	14.6	26.5	675,365.3	0.00	1.00
12/04/2021 02:00	1	1.3	16.1	14.6	26.6	678,191.1	0.00	1.00
12/04/2021 03:00	1	1.4	13.3	14.5	17.9	712,528.6	0.00	1.00
12/04/2021 04:00	1	1.1	11.5	14.5	18.4	807,960.4	0.00	1.00
12/04/2021 05:00	1	1.5	12.1	14.5	18.4	774,366.7	0.00	1.00
12/04/2021 06:00	1	1.7	12.2	14.4	20.2	738,646.4	0.00	1.00
12/04/2021 07:00	1	1.6	11.2	14.4	19.4	825,657.6	0.00	1.00
12/04/2021 08:00	1	1.4	13.2	14.5	22.3	752,969.4	0.00	1.00
12/04/2021 09:00	0	1.3	9.8	14.4	13.9	916,882.3	0.00	1.00
12/04/2021 10:00	1	1.6	13.2	14.5	23.8	766,021.8	0.00	1.00
12/04/2021 11:00	0	1.6	9.3	14.4	15.4	943,217.4	0.00	1.00
12/04/2021 12:00	1	1.5	16.1	14.6	27.9	675,800.1	0.00	1.00
12/04/2021 13:00	1	1.3	14.1	14.5	22.5	726,008.9	0.00	1.00
12/04/2021 14:00	1	1.5	14.4	14.5	23.6	692,629.2	0.00	1.00
12/04/2021 15:00	1	1.3	12.4	14.5	19.1	786,777.1	0.00	1.00
12/04/2021 16:00	0	1.5	9.4	14.4	15.7	939,425.1	0.00	1.00
12/04/2021 17:00	0	1.6	9.2	14.3	18.4	1,050,099.5	0.00	1.00
12/04/2021 18:00	1	1.7	9.9	14.1	21.3	1,074,192.6	0.00	1.00
12/04/2021 19:00	1	1.7	9.9	14.1	21.5	1,075,199.5	0.00	1.00
12/04/2021 20:00	1	1.7	9.9	14.1	21.6	1,076,005.1	0.00	1.00
12/04/2021 21:00	1	1.7	9.9	14.1	21.7	1,074,998.1	0.00	1.00
12/04/2021 22:00	1	1.4	14.2	14.5	25.9	709,961.0	0.00	1.00
12/04/2021 23:00	1	1.7	15.9	14.6	25.6	675,582.7	0.00	1.00
Average/Sum#:	1	1.5	12.4	14.4	21.4	825,939.5	0.00 #	24.00 #
Minimum:	0	1.1	9.2	14.1	13.9	674,061.1	0.00	1.00
Maximum:	1	1.7	16.1	14.6	27.9	1,076,005.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/05/2021 00:00	1	1.6	15.9	14.6	26.0	676,452.2	0.00	1.00
12/05/2021 01:00	1	1.6	16.0	14.6	26.1	676,669.5	0.00	1.00
12/05/2021 02:00	1	1.6	16.8	14.6	26.6	676,669.5	0.00	1.00
12/05/2021 03:00	1	1.6	16.7	14.6	27.1	677,321.6	0.00	1.00
12/05/2021 04:00	1	1.6	16.6	14.6	26.9	681,016.9	0.00	1.00
12/05/2021 05:00	1	1.6	16.3	14.6	26.5	679,278.0	0.00	1.00
12/05/2021 06:00	0	1.4	12.2	14.5	17.6	795,336.0	0.00	1.00
12/05/2021 07:00	1	1.7	13.4	14.5	23.8	761,956.3	0.00	1.00
12/05/2021 08:00	0	1.4	9.7	14.4	13.7	909,297.8	0.00	1.00
12/05/2021 09:00	0	1.5	8.5	14.4	16.9	1,053,403.4	0.00	1.00
12/05/2021 10:00	0	1.5	8.7	14.4	17.6	1,050,664.5	0.00	1.00
12/05/2021 11:00	0	1.5	8.7	14.4	16.8	1,004,946.8	0.00	1.00
12/05/2021 12:00	2	1.6	15.9	14.6	28.7	681,016.9	0.00	1.00
12/05/2021 13:00	0	1.3	11.3	14.5	16.6	839,628.3	0.00	1.00
12/05/2021 14:00	1	1.6	13.3	14.5	23.4	735,423.7	0.00	1.00
12/05/2021 15:00	1	1.3	14.4	14.5	23.3	704,397.7	0.00	1.00
12/05/2021 16:00	1	1.3	12.4	14.5	20.4	793,624.2	0.00	1.00
12/05/2021 17:00	0	1.6	9.6	14.3	13.7	810,242.8	0.00	1.00
12/05/2021 18:00	0	1.5	8.3	14.4	15.3	1,001,365.2	0.00	1.00
12/05/2021 19:00	0	1.5	8.7	14.4	17.6	1,056,563.6	0.00	1.00
12/05/2021 20:00	0	1.5	8.7	14.4	18.2	1,057,406.3	0.00	1.00
12/05/2021 21:00	0	1.5	8.7	14.4	17.2	1,013,374.0	0.00	1.00
12/05/2021 22:00	0	1.5	8.7	14.4	17.6	1,024,118.8	0.00	1.00
12/05/2021 23:00	1	1.5	9.6	14.3	17.7	851,740.5	0.00	1.00
Average/Sum#:	1	1.5	12.0	14.5	20.6	842,163.1	0.00 #	24.00 #
Minimum:	0	1.3	8.3	14.3	13.7	676,452.2	0.00	1.00
Maximum:	2	1.7	16.8	14.6	28.7	1,057,406.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/06/2021 00:00	1	1.6	13.6	14.5	24.8	768,589.4	0.00	1.00
12/06/2021 01:00	1	1.5	16.9	14.6	28.5	681,669.0	0.00	1.00
12/06/2021 02:00	1	1.4	17.2	14.6	28.2	678,843.2	0.00	1.00
12/06/2021 03:00	1	1.5	16.7	14.6	27.8	681,669.0	0.00	1.00
12/06/2021 04:00	1	1.5	16.4	14.6	27.1	680,364.8	0.00	1.00
12/06/2021 05:00	0	1.3	11.8	14.5	17.5	854,606.4	0.00	1.00
12/06/2021 06:00	0	1.7	8.7	14.4	14.7	1,043,712.1	0.00	1.00
12/06/2021 07:00	0	1.7	8.8	14.4	17.1	1,057,827.7	0.00	1.00
12/06/2021 08:00	0	1.7	8.8	14.4	17.2	1,047,715.0	0.00	1.00
12/06/2021 09:00	0	1.7	8.7	14.4	17.6	1,056,774.3	0.00	1.00
12/06/2021 10:00	0	1.7	8.7	14.4	17.7	1,056,984.9	0.00	1.00
12/06/2021 11:00	0	1.7	8.7	14.4	17.7	1,055,720.9	0.00	1.00
12/06/2021 12:00	0	1.7	8.7	14.4	17.8	1,054,878.1	0.00	1.00
12/06/2021 13:00	0	1.6	8.7	14.4	17.7	1,055,720.9	0.00	1.00
12/06/2021 14:00	0	1.7	8.7	14.4	17.8	1,055,299.5	0.00	1.00
12/06/2021 15:00	0	1.7	8.7	14.4	17.8	1,055,510.2	0.00	1.00
12/06/2021 16:00	1	1.8	9.9	14.1	21.6	1,049,019.4	0.00	1.00
12/06/2021 17:00	1	1.8	10.3	14.0	22.6	1,074,303.5	0.00	1.00
12/06/2021 18:00	1	1.8	10.5	13.9	23.1	1,084,584.1	0.00	1.00
12/06/2021 19:00	1	1.7	10.1	14.1	22.6	1,088,491.0	0.00	1.00
12/06/2021 20:00	1	1.8	10.3	14.0	22.8	1,088,593.2	0.00	1.00
12/06/2021 21:00	1	1.7	10.2	14.1	22.6	1,094,331.2	0.00	1.00
12/06/2021 22:00	1	1.7	9.7	14.2	20.5	1,063,654.4	0.00	1.00
12/06/2021 23:00	0	1.7	8.5	14.4	17.5	1,047,925.7	0.00	1.00
Average/Sum#:	1	1.7	10.8	14.3	20.8	978,199.5	0.00 #	24.00 #
Minimum:	0	1.3	8.5	13.9	14.7	678,843.2	0.00	1.00
Maximum:	1	1.8	17.2	14.6	28.5	1,094,331.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/07/2021 00:00	1	1.7	9.1	14.3	18.2	934,943.4	0.00	1.00
12/07/2021 01:00	1	1.3	12.6	14.4	23.6	753,183.4	0.00	1.00
12/07/2021 02:00	1	1.3	16.2	14.6	25.9	676,669.5	0.00	1.00
12/07/2021 03:00	1	1.3	15.9	14.6	26.7	676,886.9	0.00	1.00
12/07/2021 04:00	0	1.2	10.7	14.4	13.6	792,580.7	0.00	1.00
12/07/2021 05:00	1	1.7	15.6	14.6	26.2	677,973.8	0.00	1.00
12/07/2021 06:00	0	1.5	11.4	14.5	15.4	816,947.2	0.00	1.00
12/07/2021 07:00	0	1.7	8.6	14.4	15.8	1,054,035.4	0.00	1.00
12/07/2021 08:00	0	1.7	8.7	14.4	17.0	1,051,085.9	0.00	1.00
12/07/2021 09:00	0	1.6	8.7	14.4	17.3	1,050,664.5	0.00	1.00
12/07/2021 10:00	1	1.7	10.2	14.4	19.6	906,769.6	0.00	1.00
12/07/2021 11:00	1	1.6	10.1	14.4	15.8	798,690.4	0.00	1.00
12/07/2021 12:00	0	1.5	8.0	14.4	12.2	965,970.9	0.00	1.00
12/07/2021 13:00	0	1.7	8.6	14.5	17.3	1,069,434.9	0.00	1.00
12/07/2021 14:00	0	1.6	8.6	14.5	17.4	1,065,797.3	0.00	1.00
12/07/2021 15:00	0	1.7	8.5	14.4	16.7	1,022,854.7	0.00	1.00
12/07/2021 16:00	1	1.7	9.7	14.1	20.7	1,042,776.4	0.00	1.00
12/07/2021 17:00	1	1.8	10.2	14.0	22.4	1,072,318.8	0.00	1.00
12/07/2021 18:00	1	1.8	10.6	13.8	23.7	1,082,809.6	0.00	1.00
12/07/2021 19:00	1	1.9	11.5	13.5	24.9	1,088,692.4	0.00	1.00
12/07/2021 20:00	1	1.8	10.2	14.0	22.8	1,084,028.4	0.00	1.00
12/07/2021 21:00	1	1.8	10.2	14.0	22.5	1,085,020.7	0.00	1.00
12/07/2021 22:00	1	1.8	10.2	13.9	22.6	1,070,498.6	0.00	1.00
12/07/2021 23:00	1	1.7	9.8	14.1	20.5	1,038,345.9	0.00	1.00
Average/Sum#:	1	1.6	10.6	14.3	20.0	953,290.8	0.00 #	24.00 #
Minimum:	0	1.2	8.0	13.5	12.2	676,669.5	0.00	1.00
Maximum:	1	1.9	16.2	14.6	26.7	1,088,692.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/08/2021 00:00	1	1.8	9.7	14.4	18.1	902,977.4	0.00	1.00
12/08/2021 01:00	1	1.7	10.3	14.4	18.2	830,924.6	0.00	1.00
12/08/2021 02:00	1	1.6	16.5	14.6	25.5	675,148.0	0.00	1.00
12/08/2021 03:00	1	1.6	15.9	14.6	25.1	680,582.2	0.00	1.00
12/08/2021 04:00	1	1.6	14.9	14.5	23.4	676,581.2	0.00	1.00
12/08/2021 05:00	1	1.6	15.1	14.5	23.9	674,013.6	0.00	1.00
12/08/2021 06:00	0	1.5	9.3	14.4	13.8	970,816.5	0.00	1.00
12/08/2021 07:00	0	1.7	9.3	14.4	16.7	984,089.4	0.00	1.00
12/08/2021 08:00	1	1.7	14.0	14.5	23.7	724,725.1	0.00	1.00
12/08/2021 09:00	1	1.6	16.3	14.6	25.9	675,582.7	0.00	1.00
12/08/2021 10:00	1	1.6	16.0	14.6	24.8	676,669.5	0.00	1.00
12/08/2021 11:00	0	1.5	10.5	14.2	16.6	959,619.0	0.00	1.00
12/08/2021 12:00	0	1.7	9.4	14.3	15.9	958,597.1	0.00	1.00
12/08/2021 13:00	1	1.7	15.2	14.6	25.8	683,842.7	0.00	1.00
12/08/2021 14:00	1	1.6	15.3	14.6	23.9	674,930.6	0.00	1.00
12/08/2021 15:00	1	1.5	14.1	14.5	20.4	689,419.6	0.00	1.00
12/08/2021 16:00	1	1.5	11.1	14.5	16.9	842,410.0	0.00	1.00
12/08/2021 17:00	0	1.7	8.7	14.4	15.5	1,046,240.2	0.00	1.00
12/08/2021 18:00	0	1.7	8.5	14.4	15.4	1,008,739.1	0.00	1.00
12/08/2021 19:00	0	1.7	8.7	14.4	17.3	1,050,664.5	0.00	1.00
12/08/2021 20:00	0	1.7	8.6	14.4	16.0	1,010,003.2	0.00	1.00
12/08/2021 21:00	1	1.8	10.6	14.4	19.2	857,891.7	0.00	1.00
12/08/2021 22:00	1	1.6	15.2	14.6	23.9	671,887.4	0.00	1.00
12/08/2021 23:00	1	1.6	14.9	14.6	23.5	672,974.3	0.00	1.00
Average/Sum#:	1	1.6	12.4	14.5	20.4	816,638.7	0.00 #	24.00 #
Minimum:	0	1.5	8.5	14.2	13.8	671,887.4	0.00	1.00
Maximum:	1	1.8	16.5	14.6	25.9	1,050,664.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/09/2021 00:00	1	1.6	14.5	14.5	22.2	666,738.5	0.00	1.00
12/09/2021 01:00	1	1.6	14.4	14.5	22.0	665,882.6	0.00	1.00
12/09/2021 02:00	1	1.6	15.2	14.5	22.8	665,240.7	0.00	1.00
12/09/2021 03:00	1	1.6	14.8	14.5	22.4	666,952.5	0.00	1.00
12/09/2021 04:00	1	1.6	14.7	14.5	22.7	667,166.4	0.00	1.00
12/09/2021 05:00	1	1.6	15.0	14.5	23.2	667,808.4	0.00	1.00
12/09/2021 06:00	0	1.4	10.3	14.4	13.9	853,046.1	0.00	1.00
12/09/2021 07:00	1	1.8	11.4	14.4	19.2	753,815.5	0.00	1.00
12/09/2021 08:00	1	1.6	13.6	14.5	20.4	699,476.3	0.00	1.00
12/09/2021 09:00	0	1.6	9.5	14.3	11.7	859,210.1	0.00	1.00
12/09/2021 10:00	1	1.5	11.7	14.4	18.5	762,242.7	0.00	1.00
12/09/2021 11:00	1	1.7	14.9	14.6	25.1	673,409.0	0.00	1.00
12/09/2021 12:00	1	1.6	14.3	14.5	21.9	681,288.6	0.00	1.00
12/09/2021 13:00	1	1.6	15.2	14.6	23.9	670,800.6	0.00	1.00
12/09/2021 14:00	1	1.6	15.3	14.6	24.2	670,365.8	0.00	1.00
12/09/2021 15:00	1	1.5	14.1	14.6	21.2	695,363.3	0.00	1.00
12/09/2021 16:00	0	1.5	10.5	14.5	16.0	903,820.1	0.00	1.00
12/09/2021 17:00	0	1.7	9.4	14.4	14.5	883,173.4	0.00	1.00
12/09/2021 18:00	1	1.5	11.5	14.4	18.0	749,601.8	0.00	1.00
12/09/2021 19:00	0	1.7	9.8	14.3	14.8	827,464.3	0.00	1.00
12/09/2021 20:00	0	1.7	8.5	14.3	14.3	942,413.0	0.00	1.00
12/09/2021 21:00	1	1.7	9.6	14.3	17.8	878,714.0	0.00	1.00
12/09/2021 22:00	1	1.7	13.8	14.5	23.3	757,890.8	0.00	1.00
12/09/2021 23:00	1	1.6	17.1	14.6	28.5	676,234.8	0.00	1.00
Average/Sum#:	1	1.6	12.9	14.5	20.1	747,421.6	0.00 #	24.00 #
Minimum:	0	1.4	8.5	14.3	11.7	665,240.7	0.00	1.00
Maximum:	1	1.8	17.1	14.6	28.5	942,413.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/10/2021 00:00	1	1.6	16.7	14.6	27.3	687,320.6	0.00	1.00
12/10/2021 01:00	1	1.6	17.3	14.6	28.7	680,799.6	0.00	1.00
12/10/2021 02:00	1	1.6	17.9	14.6	28.6	679,930.1	0.00	1.00
12/10/2021 03:00	1	1.6	17.5	14.6	28.7	681,234.3	0.00	1.00
12/10/2021 04:00	1	1.6	17.2	14.6	28.3	678,625.9	0.00	1.00
12/10/2021 05:00	1	1.4	14.4	14.5	21.6	739,275.2	0.00	1.00
12/10/2021 06:00	1	1.5	11.4	14.4	18.5	884,648.2	0.00	1.00
12/10/2021 07:00	0	1.7	9.4	14.4	17.5	1,038,023.7	0.00	1.00
12/10/2021 08:00	1	1.7	14.4	14.5	26.7	775,222.6	0.00	1.00
12/10/2021 09:00	1	1.6	16.9	14.7	28.4	689,571.4	0.00	1.00
12/10/2021 10:00	1	1.5	14.6	14.5	22.2	738,205.3	0.00	1.00
12/10/2021 11:00	0	1.7	8.8	14.4	14.7	1,008,107.0	0.00	1.00
12/10/2021 12:00	1	1.7	11.9	14.4	23.3	797,847.7	0.00	1.00
12/10/2021 13:00	1	1.5	15.9	14.6	24.5	685,364.3	0.00	1.00
12/10/2021 14:00	1	1.6	16.4	14.6	27.0	674,713.2	0.00	1.00
12/10/2021 15:00	0	1.4	12.4	14.6	18.7	849,695.2	0.00	1.00
12/10/2021 16:00	0	1.7	9.1	14.5	16.8	1,040,334.6	0.00	1.00
12/10/2021 17:00	0	1.6	9.5	14.5	19.1	1,067,509.1	0.00	1.00
12/10/2021 18:00	0	1.6	9.4	14.5	19.3	1,069,434.9	0.00	1.00
12/10/2021 19:00	0	1.7	9.4	14.4	19.3	1,053,192.7	0.00	1.00
12/10/2021 20:00	0	1.7	9.4	14.4	19.2	1,057,195.6	0.00	1.00
12/10/2021 21:00	0	1.7	9.4	14.4	19.2	1,054,667.5	0.00	1.00
12/10/2021 22:00	0	1.7	9.4	14.4	19.3	1,055,299.5	0.00	1.00
12/10/2021 23:00	0	1.7	9.5	14.4	19.5	1,052,560.6	0.00	1.00
Average/Sum#:	1	1.6	12.8	14.5	22.4	864,115.8	0.00 #	24.00 #
Minimum:	0	1.4	8.8	14.4	14.7	674,713.2	0.00	1.00
Maximum:	1	1.7	17.9	14.7	28.7	1,069,434.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/11/2021 00:00	2	1.4	12.8	14.4	27.8	803,957.5	0.00	1.00
12/11/2021 01:00	1	1.5	16.9	14.6	25.3	683,842.7	0.00	1.00
12/11/2021 02:00	1	1.6	17.5	14.6	27.8	684,060.1	0.00	1.00
12/11/2021 03:00	1	1.6	17.1	14.6	28.0	682,321.1	0.00	1.00
12/11/2021 04:00	1	1.6	17.2	14.6	28.1	682,538.5	0.00	1.00
12/11/2021 05:00	1	1.6	17.3	14.6	28.6	684,494.8	0.00	1.00
12/11/2021 06:00	1	1.6	14.0	14.4	20.0	727,691.0	0.00	1.00
12/11/2021 07:00	1	1.7	13.9	14.5	23.9	766,877.7	0.00	1.00
12/11/2021 08:00	1	1.6	16.9	14.6	28.3	678,625.9	0.00	1.00
12/11/2021 09:00	1	1.6	16.9	14.6	27.5	678,625.9	0.00	1.00
12/11/2021 10:00	1	1.6	16.6	14.6	27.0	676,886.9	0.00	1.00
12/11/2021 11:00	1	1.6	16.4	14.6	26.6	676,234.8	0.00	1.00
12/11/2021 12:00	1	1.6	15.9	14.6	25.2	675,800.1	0.00	1.00
12/11/2021 13:00	1	1.6	15.3	14.6	24.0	674,930.6	0.00	1.00
12/11/2021 14:00	1	1.6	15.1	14.6	23.7	674,278.5	0.00	1.00
12/11/2021 15:00	1	1.6	15.0	14.6	23.5	676,452.2	0.00	1.00
12/11/2021 16:00	0	1.5	10.7	14.5	15.8	899,112.7	0.00	1.00
12/11/2021 17:00	0	1.7	8.8	14.4	14.8	977,137.0	0.00	1.00
12/11/2021 18:00	0	1.7	9.1	14.4	16.0	952,487.3	0.00	1.00
12/11/2021 19:00	0	1.7	8.7	14.5	17.0	1,064,085.5	0.00	1.00
12/11/2021 20:00	0	1.6	8.9	14.4	17.5	1,045,397.5	0.00	1.00
12/11/2021 21:00	0	1.6	9.0	14.4	18.4	1,057,617.0	0.00	1.00
12/11/2021 22:00	0	1.6	9.0	14.4	18.3	1,058,038.3	0.00	1.00
12/11/2021 23:00	1	1.7	10.9	14.4	19.5	839,562.5	0.00	1.00
Average/Sum#:	1	1.6	13.7	14.5	23.0	792,544.0	0.00 #	24.00 #
Minimum:	0	1.4	8.7	14.4	14.8	674,278.5	0.00	1.00
Maximum:	2	1.7	17.5	14.6	28.6	1,064,085.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/12/2021 00:00	1	1.7	10.1	14.4	17.0	875,167.5	0.00	1.00
12/12/2021 01:00	1	1.6	15.6	14.6	24.9	678,408.5	0.00	1.00
12/12/2021 02:00	1	1.6	15.4	14.6	23.5	685,581.7	0.00	1.00
12/12/2021 03:00	0	1.5	8.6	14.4	11.7	969,973.8	0.00	1.00
12/12/2021 04:00	1	1.7	11.1	14.3	16.8	758,370.6	0.00	1.00
12/12/2021 05:00	1	1.7	15.2	14.6	26.0	681,016.9	0.00	1.00
12/12/2021 06:00	1	1.6	11.9	14.4	17.8	771,723.3	0.00	1.00
12/12/2021 07:00	1	1.6	13.0	14.5	21.3	746,336.3	0.00	1.00
12/12/2021 08:00	1	1.5	12.9	14.5	20.7	744,196.6	0.00	1.00
12/12/2021 09:00	1	1.6	14.3	14.5	21.9	685,354.1	0.00	1.00
12/12/2021 10:00	1	1.6	15.3	14.6	24.4	676,234.8	0.00	1.00
12/12/2021 11:00	1	1.6	15.3	14.6	23.9	675,582.7	0.00	1.00
12/12/2021 12:00	1	1.6	15.3	14.6	24.2	674,930.6	0.00	1.00
12/12/2021 13:00	1	1.6	15.5	14.6	24.4	674,278.5	0.00	1.00
12/12/2021 14:00	1	1.6	14.7	14.6	22.0	686,451.1	0.00	1.00
12/12/2021 15:00	1	1.5	13.1	14.5	19.8	732,856.0	0.00	1.00
12/12/2021 16:00	1	1.5	10.5	14.5	17.0	896,331.1	0.00	1.00
12/12/2021 17:00	0	1.7	8.5	14.3	14.0	948,430.1	0.00	1.00
12/12/2021 18:00	0	1.7	8.4	14.3	14.8	948,845.1	0.00	1.00
12/12/2021 19:00	0	1.7	8.9	14.4	17.5	1,035,495.5	0.00	1.00
12/12/2021 20:00	0	1.7	8.7	14.4	16.3	992,306.0	0.00	1.00
12/12/2021 21:00	0	1.7	8.4	14.3	14.4	911,082.2	0.00	1.00
12/12/2021 22:00	1	1.5	11.4	14.4	22.9	834,927.5	0.00	1.00
12/12/2021 23:00	1	1.6	15.4	14.6	23.8	674,930.6	0.00	1.00
Average/Sum#:	1	1.6	12.4	14.5	20.0	789,950.5	0.00 #	24.00 #
Minimum:	0	1.5	8.4	14.3	11.7	674,278.5	0.00	1.00
Maximum:	1	1.7	15.6	14.6	26.0	1,035,495.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/13/2021 00:00	1	1.6	15.1	14.6	23.7	676,669.5	0.00	1.00
12/13/2021 01:00	1	1.6	14.8	14.5	23.3	667,808.4	0.00	1.00
12/13/2021 02:00	1	1.6	15.3	14.5	23.3	667,380.4	0.00	1.00
12/13/2021 03:00	1	1.6	15.4	14.5	24.0	664,598.8	0.00	1.00
12/13/2021 04:00	1	1.6	15.1	14.6	23.4	674,061.1	0.00	1.00
12/13/2021 05:00	1	1.6	15.1	14.6	23.5	673,843.7	0.00	1.00
12/13/2021 06:00	0	1.5	11.2	14.5	16.7	877,715.4	0.00	1.00
12/13/2021 07:00	0	1.7	8.9	14.4	15.6	1,026,014.9	0.00	1.00
12/13/2021 08:00	0	1.7	8.9	14.4	16.4	1,004,525.5	0.00	1.00
12/13/2021 09:00	0	1.7	8.8	14.4	17.1	1,023,697.4	0.00	1.00
12/13/2021 10:00	1	1.8	11.1	14.4	21.5	880,645.2	0.00	1.00
12/13/2021 11:00	1	1.6	12.2	14.4	17.6	724,320.2	0.00	1.00
12/13/2021 12:00	0	1.5	9.2	14.4	17.2	1,036,548.9	0.00	1.00
12/13/2021 13:00	0	1.6	9.6	14.4	19.6	1,064,780.1	0.00	1.00
12/13/2021 14:00	0	1.7	9.0	14.4	17.9	1,051,296.6	0.00	1.00
12/13/2021 15:00	0	1.7	9.0	14.4	18.1	1,052,771.3	0.00	1.00
12/13/2021 16:00	1	1.8	10.8	13.8	22.7	1,014,531.3	0.00	1.00
12/13/2021 17:00	1	1.8	11.2	13.7	24.0	1,063,586.3	0.00	1.00
12/13/2021 18:00	1	1.8	10.8	13.9	23.3	1,071,281.1	0.00	1.00
12/13/2021 19:00	1	1.8	10.8	13.9	23.2	1,071,672.4	0.00	1.00
12/13/2021 20:00	1	1.8	10.8	13.8	23.2	1,056,385.5	0.00	1.00
12/13/2021 21:00	1	1.8	10.8	13.9	23.8	1,072,063.7	0.00	1.00
12/13/2021 22:00	1	1.8	11.9	14.2	24.0	904,433.3	0.00	1.00
12/13/2021 23:00	1	1.6	15.9	14.5	25.1	665,454.7	0.00	1.00
Average/Sum#:	1	1.7	11.7	14.3	21.2	903,586.9	0.00 #	24.00 #
Minimum:	0	1.5	8.8	13.7	15.6	664,598.8	0.00	1.00
Maximum:	1	1.8	15.9	14.6	25.1	1,072,063.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/14/2021 00:00	1	1.6	15.7	14.5	25.1	667,166.4	0.00	1.00
12/14/2021 01:00	1	1.6	15.9	14.5	25.4	666,952.5	0.00	1.00
12/14/2021 02:00	1	1.6	16.7	14.5	25.6	666,310.6	0.00	1.00
12/14/2021 03:00	1	1.6	16.6	14.5	26.2	665,026.7	0.00	1.00
12/14/2021 04:00	1	1.6	16.7	14.5	26.5	663,742.9	0.00	1.00
12/14/2021 05:00	1	1.4	13.4	14.4	19.4	766,667.0	0.00	1.00
12/14/2021 06:00	0	1.7	9.9	14.3	15.4	911,704.7	0.00	1.00
12/14/2021 07:00	1	1.7	15.1	14.4	25.1	697,563.7	0.00	1.00
12/14/2021 08:00	1	1.7	16.5	14.5	27.4	671,873.8	0.00	1.00
12/14/2021 09:00	1	1.6	16.9	14.6	26.9	675,800.1	0.00	1.00
12/14/2021 10:00	1	1.6	16.6	14.6	26.6	675,148.0	0.00	1.00
12/14/2021 11:00	1	1.6	16.7	14.6	26.7	674,930.6	0.00	1.00
12/14/2021 12:00	1	1.6	16.4	14.6	26.2	673,409.0	0.00	1.00
12/14/2021 13:00	1	1.6	16.5	14.6	26.2	673,191.6	0.00	1.00
12/14/2021 14:00	1	1.6	16.2	14.6	25.8	672,974.3	0.00	1.00
12/14/2021 15:00	1	1.6	16.1	14.6	25.5	674,713.2	0.00	1.00
12/14/2021 16:00	1	1.5	13.9	14.5	20.9	742,912.7	0.00	1.00
12/14/2021 17:00	0	1.7	8.8	14.4	13.7	1,002,629.3	0.00	1.00
12/14/2021 18:00	0	1.7	9.2	14.4	16.5	977,769.0	0.00	1.00
12/14/2021 19:00	0	1.7	9.2	14.4	17.6	1,012,531.3	0.00	1.00
12/14/2021 20:00	0	1.7	9.4	14.4	19.3	1,055,088.8	0.00	1.00
12/14/2021 21:00	0	1.7	9.5	14.4	19.3	1,051,717.9	0.00	1.00
12/14/2021 22:00	1	1.7	9.4	14.3	17.6	947,807.7	0.00	1.00
12/14/2021 23:00	2	1.5	16.9	14.6	31.3	678,191.1	0.00	1.00
Average/Sum#:	1	1.6	14.1	14.5	23.2	773,576.0	0.00 #	24.00 #
Minimum:	0	1.4	8.8	14.3	13.7	663,742.9	0.00	1.00
Maximum:	2	1.7	16.9	14.6	31.3	1,055,088.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/15/2021 00:00	1	1.4	16.1	14.5	25.6	690,917.4	0.00	1.00
12/15/2021 01:00	1	1.7	17.0	14.6	28.2	677,539.0	0.00	1.00
12/15/2021 02:00	1	1.6	17.9	14.6	28.9	678,408.5	0.00	1.00
12/15/2021 03:00	1	1.6	17.9	14.6	29.3	678,191.1	0.00	1.00
12/15/2021 04:00	0	1.5	12.6	14.5	18.6	879,641.2	0.00	1.00
12/15/2021 05:00	0	1.7	9.5	14.4	17.7	1,057,406.3	0.00	1.00
12/15/2021 06:00	0	1.7	9.5	14.4	18.8	1,055,088.8	0.00	1.00
12/15/2021 07:00	1	1.7	10.4	14.4	20.5	965,970.9	0.00	1.00
12/15/2021 08:00	1	1.7	16.1	14.5	28.0	703,327.8	0.00	1.00
12/15/2021 09:00	1	1.5	17.3	14.6	29.3	680,582.2	0.00	1.00
12/15/2021 10:00	1	1.5	17.1	14.6	28.8	680,147.4	0.00	1.00
12/15/2021 11:00	1	1.5	15.0	14.5	24.1	700,546.2	0.00	1.00
12/15/2021 12:00	0	1.4	11.5	14.5	14.7	923,077.6	0.00	1.00
12/15/2021 13:00	1	1.8	12.5	14.5	23.5	866,374.9	0.00	1.00
12/15/2021 14:00	1	1.6	16.5	14.6	26.9	674,930.6	0.00	1.00
12/15/2021 15:00	1	1.4	13.7	14.5	21.0	760,030.5	0.00	1.00
12/15/2021 16:00	1	1.5	10.1	14.4	17.5	919,410.5	0.00	1.00
12/15/2021 17:00	0	1.7	9.2	14.5	17.8	1,070,504.7	0.00	1.00
12/15/2021 18:00	0	1.7	9.3	14.5	18.3	1,058,950.2	0.00	1.00
12/15/2021 19:00	0	1.7	9.2	14.4	18.9	1,047,083.0	0.00	1.00
12/15/2021 20:00	0	1.6	9.4	14.4	19.4	1,059,723.8	0.00	1.00
12/15/2021 21:00	0	1.7	9.2	14.4	18.1	1,017,587.7	0.00	1.00
12/15/2021 22:00	0	1.7	9.1	14.4	17.6	984,510.8	0.00	1.00
12/15/2021 23:00	1	1.7	9.4	14.3	18.6	943,450.4	0.00	1.00
Average/Sum#:	1	1.6	12.7	14.5	22.1	865,558.4	0.00 #	24.00 #
Minimum:	0	1.4	9.1	14.3	14.7	674,930.6	0.00	1.00
Maximum:	1	1.8	17.9	14.6	29.3	1,070,504.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/16/2021 00:00	0	1.7	8.8	14.3	16.0	954,032.3	0.00	1.00
12/16/2021 01:00	1	1.8	11.6	14.3	22.0	831,614.1	0.00	1.00
12/16/2021 02:00	1	1.5	17.1	14.6	27.9	676,669.5	0.00	1.00
12/16/2021 03:00	1	1.6	17.0	14.6	27.6	677,539.0	0.00	1.00
12/16/2021 04:00	0	1.6	12.0	14.3	18.9	923,116.5	0.00	1.00
12/16/2021 05:00	1	1.7	11.0	14.1	23.3	1,087,081.3	0.00	1.00
12/16/2021 06:00	1	1.8	11.1	14.0	24.4	1,085,219.2	0.00	1.00
12/16/2021 07:00	1	1.8	11.1	14.0	24.8	1,089,585.5	0.00	1.00
12/16/2021 08:00	1	1.7	10.8	14.1	24.2	1,083,859.1	0.00	1.00
12/16/2021 09:00	1	1.7	10.1	14.2	22.1	1,057,931.4	0.00	1.00
12/16/2021 10:00	1	1.7	10.6	14.1	24.0	1,085,873.0	0.00	1.00
12/16/2021 11:00	1	1.7	11.6	14.3	23.6	903,197.6	0.00	1.00
12/16/2021 12:00	1	1.6	16.0	14.6	26.0	674,713.2	0.00	1.00
12/16/2021 13:00	1	1.6	15.4	14.6	24.8	688,842.2	0.00	1.00
12/16/2021 14:00	1	1.6	12.1	14.5	21.2	803,894.9	0.00	1.00
12/16/2021 15:00	0	1.5	11.6	14.2	19.9	941,836.9	0.00	1.00
12/16/2021 16:00	1	1.6	10.7	14.1	24.5	1,089,900.7	0.00	1.00
12/16/2021 17:00	1	1.6	10.6	14.2	25.0	1,091,247.3	0.00	1.00
12/16/2021 18:00	1	1.6	10.7	14.2	25.0	1,089,407.8	0.00	1.00
12/16/2021 19:00	1	1.7	10.9	14.1	24.6	1,094,935.3	0.00	1.00
12/16/2021 20:00	1	1.7	10.7	14.2	25.2	1,091,656.1	0.00	1.00
12/16/2021 21:00	1	2.0	13.6	13.0	32.5	1,110,793.9	0.00	1.00
12/16/2021 22:00	1	1.8	11.4	13.9	26.6	1,087,518.6	0.00	1.00
12/16/2021 23:00	1	1.7	13.1	14.4	25.7	821,022.6	0.00	1.00
Average/Sum#:	1	1.7	12.1	14.2	24.2	960,062.0	0.00 #	24.00 #
Minimum:	0	1.5	8.8	13.0	16.0	674,713.2	0.00	1.00
Maximum:	1	2.0	17.1	14.6	32.5	1,110,793.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/17/2021 00:00	1	1.6	16.8	14.6	28.1	678,191.1	0.00	1.00
12/17/2021 01:00	2	1.6	16.9	14.6	29.1	686,016.4	0.00	1.00
12/17/2021 02:00	1	1.6	16.9	14.6	27.6	688,407.5	0.00	1.00
12/17/2021 03:00	1	1.6	17.1	14.6	28.8	687,972.7	0.00	1.00
12/17/2021 04:00	0	1.6	12.0	14.3	19.7	933,491.0	0.00	1.00
12/17/2021 05:00	1	1.7	11.0	14.2	24.3	1,099,422.9	0.00	1.00
12/17/2021 06:00	1	1.7	11.4	14.0	26.9	1,096,531.8	0.00	1.00
12/17/2021 07:00	1	1.8	11.5	14.0	26.7	1,097,722.6	0.00	1.00
12/17/2021 08:00	1	1.6	12.7	14.3	28.4	923,946.5	0.00	1.00
12/17/2021 09:00	1	1.5	17.1	14.6	28.7	686,016.4	0.00	1.00
12/17/2021 10:00	1	1.6	17.2	14.6	29.3	686,668.5	0.00	1.00
12/17/2021 11:00	1	1.6	17.0	14.6	29.0	681,234.3	0.00	1.00
12/17/2021 12:00	1	1.6	16.8	14.6	28.3	680,799.6	0.00	1.00
12/17/2021 13:00	1	1.6	16.8	14.6	28.7	680,364.8	0.00	1.00
12/17/2021 14:00	1	1.6	16.8	14.6	28.2	678,191.1	0.00	1.00
12/17/2021 15:00	0	1.6	11.8	14.3	18.6	906,517.4	0.00	1.00
12/17/2021 16:00	1	1.8	10.7	14.1	23.0	1,103,796.3	0.00	1.00
12/17/2021 17:00	1	1.7	10.6	14.2	24.0	1,093,291.2	0.00	1.00
12/17/2021 18:00	1	1.7	10.3	14.2	23.6	1,077,961.8	0.00	1.00
12/17/2021 19:00	1	1.7	10.1	14.2	23.1	1,076,326.7	0.00	1.00
12/17/2021 20:00	1	1.7	10.2	14.2	23.6	1,080,210.1	0.00	1.00
12/17/2021 21:00	1	1.7	10.2	14.2	23.7	1,077,144.3	0.00	1.00
12/17/2021 22:00	1	1.7	10.3	14.2	24.0	1,078,779.4	0.00	1.00
12/17/2021 23:00	1	1.7	11.9	14.3	25.4	932,038.5	0.00	1.00
Average/Sum#:	1	1.7	13.5	14.4	25.9	892,126.8	0.00 #	24.00 #
Minimum:	0	1.5	10.1	14.0	18.6	678,191.1	0.00	1.00
Maximum:	2	1.8	17.2	14.6	29.3	1,103,796.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/18/2021 00:00	0	1.5	9.6	14.3	15.3	903,197.6	0.00	1.00
12/18/2021 01:00	1	1.7	8.4	14.3	16.6	953,409.9	0.00	1.00
12/18/2021 02:00	1	1.8	10.1	14.3	19.5	914,609.5	0.00	1.00
12/18/2021 03:00	1	1.5	13.6	14.2	23.8	749,300.0	0.00	1.00
12/18/2021 04:00	1	1.6	11.3	14.3	18.2	873,941.7	0.00	1.00
12/18/2021 05:00	1	1.8	11.3	14.3	22.3	931,623.6	0.00	1.00
12/18/2021 06:00	1	1.7	10.6	14.2	24.3	1,086,955.1	0.00	1.00
12/18/2021 07:00	1	1.7	12.1	14.3	25.5	888,258.5	0.00	1.00
12/18/2021 08:00	1	1.6	15.3	14.5	27.0	725,794.9	0.00	1.00
12/18/2021 09:00	1	1.4	16.2	14.6	28.4	722,317.0	0.00	1.00
12/18/2021 10:00	0	1.5	8.8	14.4	15.6	1,050,243.2	0.00	1.00
12/18/2021 11:00	1	1.6	13.0	14.5	26.3	834,065.0	0.00	1.00
12/18/2021 12:00	2	1.5	17.0	14.6	29.7	680,147.4	0.00	1.00
12/18/2021 13:00	2	1.5	17.0	14.6	29.8	681,234.3	0.00	1.00
12/18/2021 14:00	1	1.5	16.8	14.6	29.1	679,930.1	0.00	1.00
12/18/2021 15:00	1	1.4	15.1	14.5	25.2	730,074.4	0.00	1.00
12/18/2021 16:00	1	1.6	11.4	14.3	20.3	945,110.3	0.00	1.00
12/18/2021 17:00	1	1.6	10.6	14.2	23.8	1,089,816.5	0.00	1.00
12/18/2021 18:00	1	1.6	10.5	14.2	24.5	1,088,794.6	0.00	1.00
12/18/2021 19:00	1	1.6	10.5	14.2	24.5	1,089,612.1	0.00	1.00
12/18/2021 20:00	1	1.6	10.5	14.2	24.8	1,089,816.5	0.00	1.00
12/18/2021 21:00	1	1.6	10.5	14.2	25.1	1,094,313.2	0.00	1.00
12/18/2021 22:00	1	1.6	10.6	14.2	25.1	1,093,086.8	0.00	1.00
12/18/2021 23:00	1	1.5	13.4	14.4	26.8	828,817.8	0.00	1.00
Average/Sum#:	1	1.6	12.3	14.4	23.8	905,186.3	0.00 #	24.00 #
Minimum:	0	1.4	8.4	14.2	15.3	679,930.1	0.00	1.00
Maximum:	2	1.8	17.0	14.6	29.8	1,094,313.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/19/2021 00:00	0	1.5	8.9	14.3	14.2	950,297.5	0.00	1.00
12/19/2021 01:00	1	1.6	8.3	14.3	16.4	946,562.7	0.00	1.00
12/19/2021 02:00	0	1.7	9.4	14.3	18.5	908,384.8	0.00	1.00
12/19/2021 03:00	1	1.4	17.0	14.6	32.2	681,016.9	0.00	1.00
12/19/2021 04:00	2	1.4	17.4	14.6	31.0	677,539.0	0.00	1.00
12/19/2021 05:00	0	1.4	12.0	14.3	19.9	904,442.6	0.00	1.00
12/19/2021 06:00	1	1.5	11.3	14.3	24.1	945,110.3	0.00	1.00
12/19/2021 07:00	2	1.4	14.3	14.5	26.2	741,200.9	0.00	1.00
12/19/2021 08:00	2	1.4	16.9	14.6	29.9	678,843.2	0.00	1.00
12/19/2021 09:00	0	1.3	10.9	14.4	17.8	920,042.5	0.00	1.00
12/19/2021 10:00	0	1.4	8.8	14.4	17.3	1,015,691.5	0.00	1.00
12/19/2021 11:00	2	1.5	14.8	14.5	28.9	735,209.7	0.00	1.00
12/19/2021 12:00	2	1.4	17.1	14.6	30.3	677,104.3	0.00	1.00
12/19/2021 13:00	1	1.4	16.5	14.6	27.9	686,451.1	0.00	1.00
12/19/2021 14:00	1	1.4	13.6	14.4	21.5	759,925.2	0.00	1.00
12/19/2021 15:00	1	1.5	11.8	14.2	22.8	937,749.1	0.00	1.00
12/19/2021 16:00	1	1.5	10.4	14.2	23.6	1,095,743.9	0.00	1.00
12/19/2021 17:00	1	1.5	10.4	14.2	24.5	1,096,357.1	0.00	1.00
12/19/2021 18:00	1	1.5	10.4	14.2	24.6	1,084,298.0	0.00	1.00
12/19/2021 19:00	1	1.6	10.4	14.2	24.6	1,080,618.9	0.00	1.00
12/19/2021 20:00	1	1.6	10.5	14.2	25.0	1,098,605.4	0.00	1.00
12/19/2021 21:00	1	1.6	10.4	14.2	25.0	1,092,269.2	0.00	1.00
12/19/2021 22:00	1	1.6	9.6	14.2	20.6	1,007,037.9	0.00	1.00
12/19/2021 23:00	1	1.6	10.1	14.3	20.4	883,071.2	0.00	1.00
Average/Sum#:	1	1.5	12.1	14.4	23.6	900,148.9	0.00 #	24.00 #
Minimum:	0	1.3	8.3	14.2	14.2	677,104.3	0.00	1.00
Maximum:	2	1.7	17.4	14.6	32.2	1,098,605.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/20/2021 00:00	1	1.5	14.8	14.5	26.2	740,773.0	0.00	1.00
12/20/2021 01:00	1	1.6	11.5	14.3	19.8	852,570.4	0.00	1.00
12/20/2021 02:00	0	1.3	10.9	14.3	18.7	869,584.5	0.00	1.00
12/20/2021 03:00	1	1.5	13.0	14.2	23.3	795,083.7	0.00	1.00
12/20/2021 04:00	1	1.6	14.4	14.4	25.6	728,744.5	0.00	1.00
12/20/2021 05:00	1	1.6	11.2	14.1	22.2	1,013,374.0	0.00	1.00
12/20/2021 06:00	1	1.8	11.3	14.1	25.5	1,104,199.1	0.00	1.00
12/20/2021 07:00	1	1.7	10.7	14.1	24.1	1,057,679.0	0.00	1.00
12/20/2021 08:00	1	1.6	12.1	14.4	26.3	878,327.7	0.00	1.00
12/20/2021 09:00	1	1.4	15.5	14.5	25.2	724,725.1	0.00	1.00
12/20/2021 10:00	2	1.5	17.0	14.6	30.9	687,320.6	0.00	1.00
12/20/2021 11:00	1	1.5	13.4	14.4	22.4	766,667.0	0.00	1.00
12/20/2021 12:00	0	1.6	9.2	14.4	15.3	1,023,276.0	0.00	1.00
12/20/2021 13:00	0	1.7	9.2	14.4	19.0	1,058,038.3	0.00	1.00
12/20/2021 14:00	1	1.9	12.4	13.4	29.2	1,042,405.8	0.00	1.00
12/20/2021 15:00	1	2.0	13.5	13.1	31.1	1,105,371.3	0.00	1.00
12/20/2021 16:00	1	1.8	11.8	13.7	28.0	1,094,017.9	0.00	1.00
12/20/2021 17:00	1	2.0	13.6	13.0	32.2	1,102,993.3	0.00	1.00
12/20/2021 18:00	1	1.9	12.3	13.5	28.7	1,108,308.5	0.00	1.00
12/20/2021 19:00	1	1.9	12.6	13.3	30.2	1,105,449.8	0.00	1.00
12/20/2021 20:00	1	2.1	14.1	12.9	33.6	1,108,891.4	0.00	1.00
12/20/2021 21:00	1	1.9	12.7	13.4	30.2	1,116,719.9	0.00	1.00
12/20/2021 22:00	1	1.9	12.3	13.5	28.8	1,097,390.1	0.00	1.00
12/20/2021 23:00	1	1.8	11.3	13.8	26.1	1,065,836.5	0.00	1.00
Average/Sum#:	1	1.7	12.5	13.9	25.9	968,656.1	0.00 #	24.00 #
Minimum:	0	1.3	9.2	12.9	15.3	687,320.6	0.00	1.00
Maximum:	2	2.1	17.0	14.6	33.6	1,116,719.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/21/2021 00:00	1	1.7	9.4	14.4	20.4	1,056,142.2	0.00	1.00
12/21/2021 01:00	1	1.7	9.4	14.3	20.0	1,033,707.9	0.00	1.00
12/21/2021 02:00	0	1.7	9.7	14.3	20.3	1,033,292.9	0.00	1.00
12/21/2021 03:00	0	1.7	9.2	14.3	18.5	982,043.3	0.00	1.00
12/21/2021 04:00	1	1.7	8.9	14.3	16.7	926,851.3	0.00	1.00
12/21/2021 05:00	1	1.7	10.3	14.3	20.1	930,586.1	0.00	1.00
12/21/2021 06:00	1	1.7	9.0	14.4	18.3	1,016,534.3	0.00	1.00
12/21/2021 07:00	1	1.7	9.7	14.3	21.6	1,056,531.7	0.00	1.00
12/21/2021 08:00	2	2.1	14.8	12.6	35.9	1,111,708.6	0.00	1.00
12/21/2021 09:00	2	2.1	14.8	12.6	36.2	1,108,078.8	0.00	1.00
12/21/2021 10:00	1	1.7	10.4	14.2	24.0	1,081,232.1	0.00	1.00
12/21/2021 11:00	1	1.7	10.6	14.3	21.6	905,272.5	0.00	1.00
12/21/2021 12:00	0	1.5	11.5	14.5	18.2	884,990.5	0.00	1.00
12/21/2021 13:00	1	1.7	8.8	14.4	18.1	1,025,804.2	0.00	1.00
12/21/2021 14:00	1	1.7	9.9	14.2	22.1	1,057,113.9	0.00	1.00
12/21/2021 15:00	1	1.7	10.5	14.1	24.0	1,086,477.1	0.00	1.00
12/21/2021 16:00	1	1.7	10.7	14.1	24.5	1,097,553.4	0.00	1.00
12/21/2021 17:00	1	1.7	10.4	14.2	23.8	1,096,561.5	0.00	1.00
12/21/2021 18:00	1	1.7	10.4	14.1	24.0	1,081,039.7	0.00	1.00
12/21/2021 19:00	1	1.7	10.5	14.1	24.1	1,081,039.7	0.00	1.00
12/21/2021 20:00	1	1.7	10.4	14.2	23.9	1,096,357.1	0.00	1.00
12/21/2021 21:00	1	1.7	10.4	14.1	23.9	1,082,650.8	0.00	1.00
12/21/2021 22:00	1	1.7	10.4	14.1	24.1	1,086,678.5	0.00	1.00
12/21/2021 23:00	1	1.8	12.0	14.3	25.7	922,494.1	0.00	1.00
Average/Sum#:	1	1.7	10.5	14.1	22.9	1,035,030.9	0.00 #	24.00 #
Minimum:	0	1.5	8.8	12.6	16.7	884,990.5	0.00	1.00
Maximum:	2	2.1	14.8	14.5	36.2	1,111,708.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/22/2021 00:00	1	1.6	16.3	14.6	27.0	681,451.7	0.00	1.00
12/22/2021 01:00	1	1.6	16.5	14.6	28.2	681,669.0	0.00	1.00
12/22/2021 02:00	1	1.6	17.0	14.6	27.7	681,234.3	0.00	1.00
12/22/2021 03:00	1	1.6	16.7	14.6	27.5	680,364.8	0.00	1.00
12/22/2021 04:00	1	1.6	16.6	14.6	27.7	682,973.2	0.00	1.00
12/22/2021 05:00	0	1.7	10.0	14.1	16.8	1,021,026.7	0.00	1.00
12/22/2021 06:00	1	1.7	10.1	14.1	22.5	1,082,449.4	0.00	1.00
12/22/2021 07:00	1	1.7	10.1	14.1	23.2	1,081,241.1	0.00	1.00
12/22/2021 08:00	1	1.7	10.0	14.1	23.4	1,085,873.0	0.00	1.00
12/22/2021 09:00	1	1.7	10.0	14.1	23.4	1,087,081.3	0.00	1.00
12/22/2021 10:00	1	1.8	11.0	14.2	23.5	937,749.1	0.00	1.00
12/22/2021 11:00	1	1.6	15.9	14.6	26.3	679,495.3	0.00	1.00
12/22/2021 12:00	1	1.6	15.6	14.5	25.6	671,231.9	0.00	1.00
12/22/2021 13:00	0	1.6	11.4	14.2	18.2	914,857.2	0.00	1.00
12/22/2021 14:00	1	1.8	10.7	13.9	22.6	1,080,475.8	0.00	1.00
12/22/2021 15:00	1	1.8	10.6	13.9	23.1	1,073,237.5	0.00	1.00
12/22/2021 16:00	1	1.8	10.6	13.9	23.0	1,069,716.1	0.00	1.00
12/22/2021 17:00	1	1.8	10.6	13.9	23.1	1,071,085.5	0.00	1.00
12/22/2021 18:00	1	1.8	10.6	13.9	23.3	1,070,889.9	0.00	1.00
12/22/2021 19:00	1	1.8	10.5	14.0	22.8	1,067,357.2	0.00	1.00
12/22/2021 20:00	1	1.7	14.4	14.5	24.3	682,144.5	0.00	1.00
12/22/2021 21:00	1	1.6	14.0	14.5	22.0	683,642.3	0.00	1.00
12/22/2021 22:00	1	1.6	12.0	14.4	19.1	740,753.3	0.00	1.00
12/22/2021 23:00	1	1.6	13.2	14.5	20.3	688,777.7	0.00	1.00
Average/Sum#:	1	1.7	12.7	14.3	23.5	883,199.1	0.00 #	24.00 #
Minimum:	0	1.6	10.0	13.9	16.8	671,231.9	0.00	1.00
Maximum:	1	1.8	17.0	14.6	28.2	1,087,081.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/23/2021 00:00	0	1.6	8.2	14.3	10.9	860,247.5	0.00	1.00
12/23/2021 01:00	1	1.7	11.9	14.4	20.4	712,100.7	0.00	1.00
12/23/2021 02:00	1	1.5	14.3	14.5	21.5	677,223.2	0.00	1.00
12/23/2021 03:00	1	1.6	14.1	14.5	22.1	668,236.3	0.00	1.00
12/23/2021 04:00	1	1.6	14.1	14.5	21.6	666,524.5	0.00	1.00
12/23/2021 05:00	1	1.6	13.8	14.5	21.6	667,808.4	0.00	1.00
12/23/2021 06:00	1	1.6	13.9	14.5	21.9	669,734.1	0.00	1.00
12/23/2021 07:00	1	1.6	14.1	14.5	22.0	668,664.2	0.00	1.00
12/23/2021 08:00	1	1.6	13.9	14.5	21.5	668,450.3	0.00	1.00
12/23/2021 09:00	1	1.6	14.0	14.5	22.0	668,236.3	0.00	1.00
12/23/2021 10:00	1	1.6	14.0	14.5	21.6	669,306.2	0.00	1.00
12/23/2021 11:00	1	1.6	13.8	14.5	21.3	668,022.3	0.00	1.00
12/23/2021 12:00	1	1.6	13.8	14.5	21.4	666,524.5	0.00	1.00
12/23/2021 13:00	1	1.6	13.7	14.5	21.1	667,166.4	0.00	1.00
12/23/2021 14:00	1	1.6	13.4	14.6	20.5	677,321.6	0.00	1.00
12/23/2021 15:00	1	1.6	13.4	14.6	20.6	677,539.0	0.00	1.00
12/23/2021 16:00	1	1.6	13.6	14.5	21.1	666,524.5	0.00	1.00
12/23/2021 17:00	1	1.6	13.5	14.6	20.6	678,191.1	0.00	1.00
12/23/2021 18:00	1	1.6	13.7	14.5	21.5	668,878.2	0.00	1.00
12/23/2021 19:00	1	1.6	13.7	14.5	21.1	664,812.7	0.00	1.00
12/23/2021 20:00	1	1.6	14.1	14.5	22.0	665,026.7	0.00	1.00
12/23/2021 21:00	1	1.6	14.4	14.5	22.6	664,170.8	0.00	1.00
12/23/2021 22:00	1	1.6	14.4	14.5	22.5	663,528.9	0.00	1.00
12/23/2021 23:00	1	1.6	14.4	14.5	22.5	666,096.6	0.00	1.00
Average/Sum#:	1	1.6	13.6	14.5	21.1	678,764.0	0.00 #	24.00 #
Minimum:	0	1.5	8.2	14.3	10.9	663,528.9	0.00	1.00
Maximum:	1	1.7	14.4	14.6	22.6	860,247.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/24/2021 00:00	1	1.6	14.1	14.5	21.8	667,594.4	0.00	1.00
12/24/2021 01:00	1	1.6	14.0	14.5	21.7	668,878.2	0.00	1.00
12/24/2021 02:00	1	1.6	14.2	14.5	21.2	668,450.3	0.00	1.00
12/24/2021 03:00	1	1.6	14.1	14.5	21.8	667,808.4	0.00	1.00
12/24/2021 04:00	1	1.6	14.1	14.5	21.5	667,380.4	0.00	1.00
12/24/2021 05:00	1	1.6	14.1	14.5	21.8	668,022.3	0.00	1.00
12/24/2021 06:00	1	1.6	14.1	14.5	21.8	668,022.3	0.00	1.00
12/24/2021 07:00	1	1.6	14.0	14.5	21.7	668,450.3	0.00	1.00
12/24/2021 08:00	1	1.6	13.7	14.5	21.4	678,721.0	0.00	1.00
12/24/2021 09:00	1	1.6	14.3	14.5	22.3	667,594.4	0.00	1.00
12/24/2021 10:00	1	1.6	14.9	14.6	24.3	679,495.3	0.00	1.00
12/24/2021 11:00	1	1.6	15.2	14.6	23.9	677,973.8	0.00	1.00
12/24/2021 12:00	1	1.6	15.1	14.6	24.1	677,756.4	0.00	1.00
12/24/2021 13:00	1	1.6	15.2	14.6	24.1	677,104.3	0.00	1.00
12/24/2021 14:00	1	1.6	15.0	14.6	23.8	676,017.4	0.00	1.00
12/24/2021 15:00	1	1.6	15.0	14.6	23.8	676,452.2	0.00	1.00
12/24/2021 16:00	1	1.6	14.8	14.6	23.3	679,060.6	0.00	1.00
12/24/2021 17:00	1	1.6	14.9	14.6	24.0	678,191.1	0.00	1.00
12/24/2021 18:00	1	1.6	15.2	14.6	24.3	677,756.4	0.00	1.00
12/24/2021 19:00	1	1.6	15.5	14.6	24.8	677,321.6	0.00	1.00
12/24/2021 20:00	1	1.6	15.8	14.6	25.5	676,669.5	0.00	1.00
12/24/2021 21:00	1	1.6	15.8	14.6	25.4	677,104.3	0.00	1.00
12/24/2021 22:00	1	1.6	15.9	14.6	25.8	676,234.8	0.00	1.00
12/24/2021 23:00	1	1.6	15.8	14.6	25.5	676,452.2	0.00	1.00
Average/Sum#:	1	1.6	14.8	14.6	23.3	673,938.0	0.00 #	24.00 #
Minimum:	1	1.6	13.7	14.5	21.2	667,380.4	0.00	1.00
Maximum:	1	1.6	15.9	14.6	25.8	679,495.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/25/2021 00:00	1	1.6	15.8	14.6	25.4	677,321.6	0.00	1.00
12/25/2021 01:00	1	1.6	15.7	14.6	25.4	677,539.0	0.00	1.00
12/25/2021 02:00	1	1.6	16.7	14.6	26.3	677,104.3	0.00	1.00
12/25/2021 03:00	1	1.6	16.5	14.6	26.7	676,886.9	0.00	1.00
12/25/2021 04:00	1	1.6	16.3	14.6	25.9	676,669.5	0.00	1.00
12/25/2021 05:00	1	1.6	15.8	14.6	25.2	677,539.0	0.00	1.00
12/25/2021 06:00	1	1.6	15.5	14.6	24.6	676,669.5	0.00	1.00
12/25/2021 07:00	1	1.6	15.7	14.6	25.2	678,408.5	0.00	1.00
12/25/2021 08:00	1	1.6	15.7	14.6	25.3	677,973.8	0.00	1.00
12/25/2021 09:00	1	1.6	15.8	14.6	25.6	678,191.1	0.00	1.00
12/25/2021 10:00	1	1.6	15.6	14.6	25.1	680,582.2	0.00	1.00
12/25/2021 11:00	1	1.6	15.3	14.5	24.5	671,017.9	0.00	1.00
12/25/2021 12:00	1	1.6	15.2	14.5	24.1	671,445.9	0.00	1.00
12/25/2021 13:00	1	1.6	14.9	14.5	23.5	673,157.7	0.00	1.00
12/25/2021 14:00	1	1.6	14.4	14.5	22.6	672,943.7	0.00	1.00
12/25/2021 15:00	1	1.5	13.4	14.5	20.3	699,048.4	0.00	1.00
12/25/2021 16:00	1	1.7	14.7	14.5	23.7	671,017.9	0.00	1.00
12/25/2021 17:00	1	1.6	14.9	14.5	23.8	670,376.0	0.00	1.00
12/25/2021 18:00	1	1.6	15.3	14.5	24.5	668,878.2	0.00	1.00
12/25/2021 19:00	1	1.6	15.3	14.5	24.6	667,380.4	0.00	1.00
12/25/2021 20:00	1	1.6	15.7	14.5	25.4	670,376.0	0.00	1.00
12/25/2021 21:00	1	1.6	16.3	14.5	26.8	669,092.2	0.00	1.00
12/25/2021 22:00	1	1.6	16.6	14.6	27.0	678,191.1	0.00	1.00
12/25/2021 23:00	1	1.6	16.6	14.6	27.4	677,539.0	0.00	1.00
Average/Sum#:	1	1.6	15.6	14.6	25.0	675,639.6	0.00 #	24.00 #
Minimum:	1	1.5	13.4	14.5	20.3	667,380.4	0.00	1.00
Maximum:	1	1.7	16.7	14.6	27.4	699,048.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/26/2021 00:00	1	1.6	16.9	14.6	27.8	677,321.6	0.00	1.00
12/26/2021 01:00	1	1.6	17.0	14.6	28.1	677,539.0	0.00	1.00
12/26/2021 02:00	1	1.6	17.6	14.6	28.3	678,191.1	0.00	1.00
12/26/2021 03:00	2	1.6	17.6	14.5	28.9	672,301.8	0.00	1.00
12/26/2021 04:00	1	1.6	17.3	14.6	28.5	682,755.9	0.00	1.00
12/26/2021 05:00	1	1.6	17.5	14.6	29.3	685,581.7	0.00	1.00
12/26/2021 06:00	1	1.6	17.5	14.5	29.0	675,511.4	0.00	1.00
12/26/2021 07:00	1	1.6	16.5	14.6	27.1	695,363.3	0.00	1.00
12/26/2021 08:00	1	1.6	17.3	14.6	29.2	679,060.6	0.00	1.00
12/26/2021 09:00	1	1.6	17.3	14.6	29.0	682,103.8	0.00	1.00
12/26/2021 10:00	1	1.6	17.1	14.6	28.4	682,538.5	0.00	1.00
12/26/2021 11:00	1	1.6	16.1	14.6	26.1	696,450.1	0.00	1.00
12/26/2021 12:00	1	1.6	16.2	14.6	26.8	685,799.0	0.00	1.00
12/26/2021 13:00	1	1.5	14.4	14.5	22.0	723,441.2	0.00	1.00
12/26/2021 14:00	1	1.4	15.7	14.5	26.5	693,057.1	0.00	1.00
12/26/2021 15:00	1	1.6	15.5	14.5	25.9	694,768.9	0.00	1.00
12/26/2021 16:00	2	0.9	11.2	14.4	31.1	931,629.9	0.00	1.00
12/26/2021 17:00	0	1.4	10.7	14.1	16.0	1,098,358.9	0.00	1.00
12/26/2021 18:00	1	1.8	13.4	14.4	25.3	825,446.9	0.00	1.00
12/26/2021 19:00	1	1.6	16.5	14.5	27.7	676,795.2	0.00	1.00
12/26/2021 20:00	1	1.6	15.8	14.5	25.9	691,987.3	0.00	1.00
12/26/2021 21:00	0	1.6	8.3	14.4	11.9	990,831.2	0.00	1.00
12/26/2021 22:00	1	1.8	14.2	14.5	25.7	749,545.9	0.00	1.00
12/26/2021 23:00	1	1.6	16.6	14.6	27.9	682,755.9	0.00	1.00
Average/Sum#:	1	1.6	15.6	14.5	26.4	734,547.3	0.00 #	24.00 #
Minimum:	0	0.9	8.3	14.1	11.9	672,301.8	0.00	1.00
Maximum:	2	1.8	17.6	14.6	31.1	1,098,358.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/27/2021 00:00	1	1.6	15.8	14.5	25.4	677,223.2	0.00	1.00
12/27/2021 01:00	1	1.6	15.4	14.5	25.4	673,799.6	0.00	1.00
12/27/2021 02:00	1	1.6	16.1	14.5	25.6	674,655.5	0.00	1.00
12/27/2021 03:00	1	1.6	15.9	14.5	25.8	672,729.7	0.00	1.00
12/27/2021 04:00	1	1.6	15.7	14.5	24.9	669,520.1	0.00	1.00
12/27/2021 05:00	0	1.6	11.2	14.2	17.4	920,375.8	0.00	1.00
12/27/2021 06:00	1	1.8	10.4	14.0	21.1	1,082,043.7	0.00	1.00
12/27/2021 07:00	1	1.8	10.3	14.0	22.2	1,081,845.3	0.00	1.00
12/27/2021 08:00	1	1.8	10.4	14.0	22.7	1,090,974.8	0.00	1.00
12/27/2021 09:00	1	1.7	9.5	14.1	18.7	998,672.9	0.00	1.00
12/27/2021 10:00	1	1.6	10.4	14.4	18.1	817,651.7	0.00	1.00
12/27/2021 11:00	0	1.7	8.8	14.4	15.8	1,003,050.7	0.00	1.00
12/27/2021 12:00	2	1.7	15.3	14.6	26.8	676,017.4	0.00	1.00
12/27/2021 13:00	1	1.5	14.1	14.6	22.4	716,448.1	0.00	1.00
12/27/2021 14:00	0	1.6	9.1	14.4	14.2	952,276.6	0.00	1.00
12/27/2021 15:00	1	1.7	10.1	14.2	20.7	1,038,718.6	0.00	1.00
12/27/2021 16:00	1	1.8	11.0	14.0	23.8	1,085,219.2	0.00	1.00
12/27/2021 17:00	1	1.8	11.0	13.9	24.0	1,084,192.8	0.00	1.00
12/27/2021 18:00	1	1.8	11.1	13.8	24.5	1,081,073.8	0.00	1.00
12/27/2021 19:00	1	1.8	11.1	13.8	24.7	1,088,788.8	0.00	1.00
12/27/2021 20:00	1	1.8	11.2	13.8	24.7	1,089,946.1	0.00	1.00
12/27/2021 21:00	1	1.7	10.7	14.1	24.2	1,093,727.0	0.00	1.00
12/27/2021 22:00	1	1.7	10.2	14.2	20.2	989,460.2	0.00	1.00
12/27/2021 23:00	1	1.7	12.7	14.4	23.2	792,791.4	0.00	1.00
Average/Sum#:	1	1.7	12.0	14.2	22.4	918,800.1	0.00 #	24.00 #
Minimum:	0	1.5	8.8	13.8	14.2	669,520.1	0.00	1.00
Maximum:	2	1.8	16.1	14.6	26.8	1,093,727.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/28/2021 00:00	1	1.7	15.6	14.5	25.9	697,122.6	0.00	1.00
12/28/2021 01:00	1	1.6	16.8	14.5	27.9	674,655.5	0.00	1.00
12/28/2021 02:00	1	1.6	17.1	14.5	27.5	675,297.4	0.00	1.00
12/28/2021 03:00	1	1.6	16.0	14.4	25.5	682,394.7	0.00	1.00
12/28/2021 04:00	1	1.7	16.6	14.5	27.9	675,083.4	0.00	1.00
12/28/2021 05:00	0	1.5	9.5	14.4	12.5	912,458.0	0.00	1.00
12/28/2021 06:00	0	1.7	9.5	14.3	15.6	880,373.9	0.00	1.00
12/28/2021 07:00	2	1.5	15.8	14.5	29.7	693,485.1	0.00	1.00
12/28/2021 08:00	1	1.5	13.3	14.5	24.3	789,986.7	0.00	1.00
12/28/2021 09:00	1	1.5	12.6	14.4	19.9	762,032.0	0.00	1.00
12/28/2021 10:00	2	1.4	17.2	14.6	30.7	679,930.1	0.00	1.00
12/28/2021 11:00	2	1.4	17.2	14.6	29.9	679,060.6	0.00	1.00
12/28/2021 12:00	1	1.5	17.0	14.6	27.7	680,147.4	0.00	1.00
12/28/2021 13:00	1	1.6	17.0	14.6	27.9	677,104.3	0.00	1.00
12/28/2021 14:00	1	1.6	16.9	14.6	27.6	677,321.6	0.00	1.00
12/28/2021 15:00	1	1.4	13.6	14.5	20.5	782,283.7	0.00	1.00
12/28/2021 16:00	1	1.4	11.5	14.5	19.9	877,073.5	0.00	1.00
12/28/2021 17:00	0	1.7	9.4	14.4	17.5	1,061,409.2	0.00	1.00
12/28/2021 18:00	0	1.7	8.9	14.4	16.3	995,044.8	0.00	1.00
12/28/2021 19:00	1	1.6	10.4	14.3	20.9	890,955.8	0.00	1.00
12/28/2021 20:00	1	1.7	10.3	14.4	18.2	885,701.6	0.00	1.00
12/28/2021 21:00	1	1.4	14.6	14.5	24.3	715,738.2	0.00	1.00
12/28/2021 22:00	1	1.6	15.3	14.5	24.5	682,358.5	0.00	1.00
12/28/2021 23:00	1	1.6	15.7	14.5	25.6	677,865.1	0.00	1.00
Average/Sum#:	1	1.6	14.1	14.5	23.7	766,870.2	0.00 #	24.00 #
Minimum:	0	1.4	8.9	14.3	12.5	674,655.5	0.00	1.00
Maximum:	2	1.7	17.2	14.6	30.7	1,061,409.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOX, Ppm	Unit CT2 NOX, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/29/2021 00:00	1	1.6	15.6	14.5	24.7	679,576.9	0.00	1.00
12/29/2021 01:00	1	1.6	15.6	14.5	25.9	677,865.1	0.00	1.00
12/29/2021 02:00	1	1.5	17.0	14.5	27.3	671,017.9	0.00	1.00
12/29/2021 03:00	1	1.6	16.8	14.5	27.6	670,162.1	0.00	1.00
12/29/2021 04:00	1	1.6	16.6	14.5	26.9	670,162.1	0.00	1.00
12/29/2021 05:00	1	1.6	16.1	14.5	26.0	674,869.5	0.00	1.00
12/29/2021 06:00	1	1.5	15.3	14.5	23.9	696,052.7	0.00	1.00
12/29/2021 07:00	2	1.7	16.2	14.5	27.3	670,590.0	0.00	1.00
12/29/2021 08:00	1	1.6	16.8	14.5	27.7	670,376.0	0.00	1.00
12/29/2021 09:00	1	1.6	16.6	14.5	27.2	668,022.3	0.00	1.00
12/29/2021 10:00	1	1.6	16.4	14.6	27.0	677,973.8	0.00	1.00
12/29/2021 11:00	1	1.6	16.3	14.6	26.9	679,712.7	0.00	1.00
12/29/2021 12:00	1	1.6	16.1	14.5	26.5	671,231.9	0.00	1.00
12/29/2021 13:00	1	1.5	14.8	14.5	23.6	702,044.0	0.00	1.00
12/29/2021 14:00	0	1.6	10.3	14.3	14.2	833,274.0	0.00	1.00
12/29/2021 15:00	1	1.5	10.6	14.4	18.0	865,054.8	0.00	1.00
12/29/2021 16:00	1	1.6	11.3	14.4	19.5	854,310.1	0.00	1.00
12/29/2021 17:00	0	1.6	8.9	14.4	17.1	1,043,290.7	0.00	1.00
12/29/2021 18:00	0	1.6	8.9	14.4	18.2	1,048,347.0	0.00	1.00
12/29/2021 19:00	0	1.6	9.1	14.4	19.1	1,062,041.3	0.00	1.00
12/29/2021 20:00	0	1.6	9.1	14.4	19.2	1,062,673.3	0.00	1.00
12/29/2021 21:00	1	1.7	12.8	14.4	24.5	794,055.5	0.00	1.00
12/29/2021 22:00	1	1.6	16.2	14.5	26.5	678,507.0	0.00	1.00
12/29/2021 23:00	1	1.6	16.5	14.6	28.0	681,451.7	0.00	1.00
Average/Sum#:	1	1.6	14.2	14.5	23.9	766,777.6	0.00 #	24.00 #
Minimum:	0	1.5	8.9	14.3	14.2	668,022.3	0.00	1.00
Maximum:	2	1.7	17.0	14.6	28.0	1,062,673.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/30/2021 00:00	1	1.6	16.7	14.6	28.2	680,364.8	0.00	1.00
12/30/2021 01:00	1	1.6	16.6	14.6	27.8	679,278.0	0.00	1.00
12/30/2021 02:00	1	1.5	17.2	14.6	28.1	680,147.4	0.00	1.00
12/30/2021 03:00	1	1.6	17.1	14.6	28.6	679,278.0	0.00	1.00
12/30/2021 04:00	1	1.6	17.0	14.6	28.5	681,016.9	0.00	1.00
12/30/2021 05:00	0	1.6	10.3	14.1	15.9	1,002,297.8	0.00	1.00
12/30/2021 06:00	1	1.7	10.9	14.1	22.8	1,083,859.1	0.00	1.00
12/30/2021 07:00	1	1.7	10.8	14.1	23.6	1,082,852.2	0.00	1.00
12/30/2021 08:00	1	1.7	10.8	14.1	23.7	1,079,227.2	0.00	1.00
12/30/2021 09:00	1	1.7	10.7	14.1	23.7	1,079,831.4	0.00	1.00
12/30/2021 10:00	2	1.5	14.9	14.5	28.4	714,240.4	0.00	1.00
12/30/2021 11:00	1	1.3	16.0	14.6	28.0	679,712.7	0.00	1.00
12/30/2021 12:00	1	1.3	15.7	14.6	27.5	680,364.8	0.00	1.00
12/30/2021 13:00	1	1.3	15.6	14.6	27.0	679,712.7	0.00	1.00
12/30/2021 14:00	1	1.6	15.2	14.6	22.8	682,103.8	0.00	1.00
12/30/2021 15:00	1	1.6	14.7	14.6	23.1	682,755.9	0.00	1.00
12/30/2021 16:00	0	1.6	11.2	14.2	17.9	915,470.4	0.00	1.00
12/30/2021 17:00	1	1.8	10.8	14.0	22.1	1,074,700.4	0.00	1.00
12/30/2021 18:00	1	1.8	10.9	14.0	23.2	1,076,685.1	0.00	1.00
12/30/2021 19:00	1	1.8	10.9	14.0	23.6	1,077,479.0	0.00	1.00
12/30/2021 20:00	1	1.7	10.9	14.0	23.8	1,078,669.8	0.00	1.00
12/30/2021 21:00	1	1.8	10.8	14.1	23.8	1,094,935.3	0.00	1.00
12/30/2021 22:00	1	1.6	12.0	14.3	23.2	855,060.3	0.00	1.00
12/30/2021 23:00	1	1.5	15.9	14.5	26.9	675,083.4	0.00	1.00
Average/Sum#:	1	1.6	13.5	14.3	24.7	862,297.0	0.00 #	24.00 #
Minimum:	0	1.3	10.3	14.0	15.9	675,083.4	0.00	1.00
Maximum:	2	1.8	17.2	14.6	28.6	1,094,935.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:17 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT2 NH3Slip, Ppmvdc	Unit CT2 NOx, Ppm	Unit CT2 NOx, _SCR, Ppm	Unit CT2 O2, Dry, Pct	Unit CT2 NH3Inj, LbPerHr	Unit CT2 ExhaustFlow, LbPerHr	Unit CT2 SUSD, Hr	Unit CT2 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/31/2021 00:00	1	1.5	16.3	14.6	27.8	682,538.5	0.00	1.00
12/31/2021 01:00	1	1.5	16.1	14.6	26.5	681,234.3	0.00	1.00
12/31/2021 02:00	1	1.5	16.7	14.6	27.0	680,582.2	0.00	1.00
12/31/2021 03:00	1	1.6	16.7	14.6	27.8	681,451.7	0.00	1.00
12/31/2021 04:00	1	1.6	16.6	14.6	27.3	681,669.0	0.00	1.00
12/31/2021 05:00	1	1.6	16.5	14.6	27.6	680,582.2	0.00	1.00
12/31/2021 06:00	1	1.6	16.7	14.6	27.9	681,451.7	0.00	1.00
12/31/2021 07:00	1	1.6	16.6	14.5	27.7	671,873.8	0.00	1.00
12/31/2021 08:00	1	1.6	16.4	14.5	27.0	674,441.5	0.00	1.00
12/31/2021 09:00	1	1.6	16.1	14.5	26.9	676,367.3	0.00	1.00
12/31/2021 10:00	1	1.6	16.3	14.6	27.0	682,755.9	0.00	1.00
12/31/2021 11:00	1	1.6	16.4	14.6	27.1	676,886.9	0.00	1.00
12/31/2021 12:00	1	1.6	16.1	14.6	26.3	676,452.2	0.00	1.00
12/31/2021 13:00	1	1.6	15.7	14.6	25.9	676,234.8	0.00	1.00
12/31/2021 14:00	1	1.6	16.0	14.6	26.1	675,365.3	0.00	1.00
12/31/2021 15:00	1	1.6	15.8	14.6	25.8	675,582.7	0.00	1.00
12/31/2021 16:00	1	1.4	12.8	14.5	19.2	782,711.6	0.00	1.00
12/31/2021 17:00	0	1.7	9.0	14.3	13.0	838,876.2	0.00	1.00
12/31/2021 18:00	0	1.6	8.8	14.3	14.8	911,704.7	0.00	1.00
12/31/2021 19:00	0	1.6	8.9	14.4	17.8	1,031,703.3	0.00	1.00
12/31/2021 20:00	0	1.6	8.7	14.3	16.0	932,038.5	0.00	1.00
12/31/2021 21:00	0	1.6	9.0	14.4	18.4	1,031,913.9	0.00	1.00
12/31/2021 22:00	1	1.6	9.8	14.3	18.1	877,884.0	0.00	1.00
12/31/2021 23:00	2	1.6	15.2	14.5	27.9	707,821.2	0.00	1.00
Average/Sum#:	1	1.6	14.3	14.5	24.0	748,755.1	0.00 #	24.00 #
Minimum:	0	1.4	8.7	14.3	13.0	671,873.8	0.00	1.00
Maximum:	2	1.7	16.7	14.6	27.9	1,031,913.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

AQ-55

AQ-55 The emissions rates from each gas turbine and heat recovery steam generator exhaust during startup and shutdown shall not exceed the following:

Turbine emissions limitations during Startup and Shutdown		
Pollutant	Max Lbs/ Hr (worst case turbine)	Pounds per Startup or Shutdown (both turbines combined)
NO_x	37.1	122.8
CO	89.5	204.8

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

Monthly Summary By Day Report



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 09:11 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr	Unit CT1 NOX_SUSD, LbPerHr	Unit CT2 CO_SUSD, LbPerHr	Unit CT2 NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
10/01/2021	0.0	0.0	0.0	0.0
10/02/2021	0.0	0.0	0.0	0.0
10/03/2021	0.0	0.0	0.0	0.0
10/04/2021	0.0	0.0	0.0	0.0
10/05/2021	0.0	0.0	0.0	0.0
10/06/2021	0.0	0.0	0.0	0.0
10/07/2021	0.0	0.0	0.0	0.0
10/08/2021	0.0	0.0	0.0	0.0
10/09/2021	0.0	0.0	0.0	0.0
10/10/2021	0.0	0.0	0.0	0.0
10/11/2021	0.0	0.0	0.0	0.0
10/12/2021	0.0	0.0	0.0	0.0
10/13/2021	0.0	0.0	0.0	0.0
10/14/2021	11.8	1.5	0.0	0.0
10/15/2021	0.0	0.0	0.0	0.0
10/16/2021	0.0	0.0	0.0	0.0
10/17/2021	0.0	0.0	0.0	0.0
10/18/2021	0.0	0.0	0.0	0.0
10/19/2021	0.0	0.0	0.0	0.0
10/20/2021	50.5	11.5	0.0	0.0
10/21/2021	0.0	0.0	0.0	0.0
10/22/2021	0.0	0.0	0.0	0.0
10/23/2021	0.0	0.0	0.0	0.0
10/24/2021	0.0	0.0	0.0	0.0
10/25/2021	0.0	0.0	0.0	0.0
10/26/2021	0.0	0.0	0.0	0.0
10/27/2021	0.0	0.0	0.0	0.0
10/28/2021	0.0	0.0	0.0	0.0
10/29/2021	0.0	0.0	0.0	0.0
10/30/2021	0.0	0.0	0.0	0.0
10/31/2021	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	62.3 *	13.0 *	0.0 *	0.0 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	50.5	11.5	0.0	0.0
Oct 2021 - Oct 2021	62.3	13.0	0.0	0.0
QTD:	62.3 *	13.0 *	0.0 *	0.0 *
YTD 2021:	1,302.3 *	224.4 *	2,463.4 *	525.9 *

Monthly Summary By Day Report



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 09:11 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr	Unit CT1 NOX_SUSD, LbPerHr	Unit CT2 CO_SUSD, LbPerHr	Unit CT2 NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
11/01/2021	0.0	0.0	0.0	0.0
11/02/2021	0.0	0.0	0.0	0.0
11/03/2021	0.0	0.0	0.0	0.0
11/04/2021	0.0	0.0	0.0	0.0
11/05/2021	0.0	0.0	0.0	0.0
11/06/2021	0.0	0.0	0.0	0.0
11/07/2021	0.0	0.0	0.0	0.0
11/08/2021	0.0	0.0	0.0	0.0
11/09/2021	0.0	0.0	0.0	0.0
11/10/2021	0.0	0.0	0.0	0.0
11/11/2021	0.0	0.0	0.0	0.0
11/12/2021	0.0	0.0	0.0	0.0
11/13/2021	0.0	0.0	0.0	0.0
11/14/2021	0.0	0.0	0.0	0.0
11/15/2021	0.0	0.0	0.0	0.0
11/16/2021	0.0	0.0	0.0	0.0
11/17/2021	0.0	0.0	0.0	0.0
11/18/2021	0.0	0.0	0.0	0.0
11/19/2021	57.3	6.5	0.0	0.0
11/20/2021	0.0	0.0	0.0	0.0
11/21/2021	0.0	0.0	0.0	0.0
11/22/2021	0.0	0.0	0.0	0.0
11/23/2021	0.0	0.0	0.0	0.0
11/24/2021	0.0	0.0	0.0	0.0
11/25/2021	0.0	0.0	0.0	0.0
11/26/2021	0.0	0.0	0.0	0.0
11/27/2021	0.0	0.0	0.0	0.0
11/28/2021	0.0	0.0	0.0	0.0
11/29/2021	0.0	0.0	0.0	0.0
11/30/2021	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	57.3 *	6.5 *	0.0 *	0.0 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	57.3	6.5	0.0	0.0
Oct 2021 - Nov 2021	119.6	19.5	0.0	0.0
QTD:	119.6 *	19.5 *	0.0 *	0.0 *
YTD 2021:	1,359.6 *	230.9 *	2,463.4 *	525.9 *

Monthly Summary By Day Report



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 09:11 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr	Unit CT1 NOX_SUSD, LbPerHr	Unit CT2 CO_SUSD, LbPerHr	Unit CT2 NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
12/01/2021	0.0	0.0	0.0	0.0
12/02/2021	0.0	0.0	0.0	0.0
12/03/2021	0.0	0.0	0.0	0.0
12/04/2021	0.0	0.0	0.0	0.0
12/05/2021	0.0	0.0	0.0	0.0
12/06/2021	0.0	0.0	0.0	0.0
12/07/2021	0.0	0.0	0.0	0.0
12/08/2021	0.0	0.0	0.0	0.0
12/09/2021	0.0	0.0	0.0	0.0
12/10/2021	0.0	0.0	0.0	0.0
12/11/2021	0.0	0.0	0.0	0.0
12/12/2021	0.0	0.0	0.0	0.0
12/13/2021	0.0	0.0	0.0	0.0
12/14/2021	0.0	0.0	0.0	0.0
12/15/2021	0.0	0.0	0.0	0.0
12/16/2021	0.0	0.0	0.0	0.0
12/17/2021	0.0	0.0	0.0	0.0
12/18/2021	0.0	0.0	0.0	0.0
12/19/2021	0.0	0.0	0.0	0.0
12/20/2021	0.0	0.0	0.0	0.0
12/21/2021	0.0	0.0	0.0	0.0
12/22/2021	0.0	0.0	0.0	0.0
12/23/2021	0.0	0.0	0.0	0.0
12/24/2021	0.0	0.0	0.0	0.0
12/25/2021	0.0	0.0	0.0	0.0
12/26/2021	0.0	0.0	0.0	0.0
12/27/2021	0.0	0.0	0.0	0.0
12/28/2021	0.0	0.0	0.0	0.0
12/29/2021	0.0	0.0	0.0	0.0
12/30/2021	0.0	0.0	0.0	0.0
12/31/2021	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	0.0 *	0.0 *	0.0 *	0.0 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	0.0	0.0	0.0	0.0
Oct 2021 - Dec 2021	119.6	19.5	0.0	0.0
QTD:	119.6 *	19.5 *	0.0 *	0.0 *
YTD 2021:	1,359.6 *	230.9 *	2,463.4 *	525.9 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:12 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
10/01/2021	31.14	95.43	10.69	21.43	35.67
10/02/2021	31.78	97.53	10.92	21.89	36.49
10/03/2021	34.65	95.47	10.47	20.87	34.84
10/04/2021	42.63	120.31	13.02	26.07	43.46
10/05/2021	27.06	91.83	10.30	20.63	34.39
10/06/2021	28.47	98.15	10.75	21.54	35.87
10/07/2021	24.82	95.33	10.40	20.78	34.59
10/08/2021	22.44	90.56	9.84	19.69	32.78
10/09/2021	19.16	83.76	9.05	18.14	30.18
10/10/2021	20.10	83.78	9.06	18.15	30.18
10/11/2021	35.42	115.46	12.41	24.80	41.36
10/12/2021	32.76	113.00	12.21	24.46	40.75
10/13/2021	35.65	115.97	12.52	25.08	41.77
10/14/2021	43.28	95.07	9.98	19.96	33.28
10/15/2021	41.50	67.51	7.22	14.53	24.27
10/16/2021	39.83	68.11	7.32	14.70	24.53
10/17/2021	39.39	68.86	7.44	14.91	24.88
10/18/2021	40.80	63.27	6.79	13.74	22.82
10/19/2021	37.83	60.82	6.59	13.21	22.03
10/20/2021	70.65	59.18	5.39	10.79	18.03
10/21/2021	32.60	107.48	11.65	23.38	38.93
10/22/2021	24.50	92.09	9.95	19.95	33.24
10/23/2021	28.55	99.92	10.73	21.54	35.88
10/24/2021	28.76	103.19	11.05	22.11	36.82
10/25/2021	25.98	96.04	10.37	20.67	34.51
10/26/2021	22.52	89.10	9.55	19.08	31.81
10/27/2021	22.68	92.98	9.96	19.87	33.15
10/28/2021	24.69	92.24	9.96	19.94	33.22
10/29/2021	27.29	92.31	10.00	20.00	33.30
10/30/2021	17.56	79.86	8.59	17.24	28.66
10/31/2021	16.39	78.68	8.39	16.85	28.06
Monthly Avg/Sum*:	970.88 *	2,803.29 *	302.57 *	606.00 *	1,009.75 *
Daily Min:	16.39	59.18	5.39	10.79	18.03
Daily Max:	70.65	120.31	13.02	26.07	43.46
Oct 2021 - Oct 2021	970.88	2,803.29	302.57	606.00	1,009.75
QTD:	970.88 *	2,803.29 *	302.57 *	606.00 *	1,009.75 *
YTD 2021:	9,666.48 *	18,740.02 *	1,944.32 *	3,891.10 *	6,487.29 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:12 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
11/01/2021	28.41	99.20	10.77	21.49	35.84
11/02/2021	23.49	93.52	10.04	20.10	33.48
11/03/2021	27.27	98.14	10.55	21.10	35.20
11/04/2021	18.58	82.26	9.18	18.39	30.60
11/05/2021	23.32	91.25	9.83	19.78	32.95
11/06/2021	23.80	93.67	10.06	20.15	33.57
11/07/2021	18.76	81.39	9.16	18.28	30.51
11/08/2021	32.51	99.29	10.91	21.84	36.41
11/09/2021	20.76	89.36	9.60	19.14	31.91
11/10/2021	17.13	82.62	8.88	17.66	29.45
11/11/2021	33.97	92.96	10.08	20.18	33.60
11/12/2021	16.91	79.41	8.54	17.03	28.36
11/13/2021	26.38	94.87	10.31	20.61	34.33
11/14/2021	15.50	79.31	8.45	16.77	28.00
11/15/2021	20.13	82.35	8.90	17.84	29.67
11/16/2021	25.97	93.14	10.22	20.51	34.10
11/17/2021	30.31	91.61	10.59	21.22	35.34
11/18/2021	28.17	86.86	10.39	20.80	34.59
11/19/2021	79.61	67.97	8.00	16.01	26.64
11/20/2021	18.53	73.79	9.04	18.14	30.20
11/21/2021	28.32	83.94	10.32	20.62	34.40
11/22/2021	26.92	83.63	10.24	20.51	34.16
11/23/2021	17.37	71.45	8.63	17.31	28.84
11/24/2021	18.86	81.07	8.86	17.77	29.57
11/25/2021	21.62	80.43	8.75	17.56	29.23
11/26/2021	22.63	79.33	8.70	17.28	28.87
11/27/2021	22.88	82.60	9.02	18.05	30.05
11/28/2021	22.16	78.92	8.68	17.36	28.92
11/29/2021	27.54	88.61	9.58	19.12	31.89
11/30/2021	31.88	101.30	11.52	23.02	38.41
Monthly Avg/Sum*:	769.69 *	2,584.25 *	287.80 *	575.64 *	959.09 *
Daily Min:	15.50	67.97	8.00	16.01	26.64
Daily Max:	79.61	101.30	11.52	23.02	38.41
Oct 2021 - Nov 2021	1,740.57	5,387.54	590.37	1,181.64	1,968.84
QTD:	1,740.57 *	5,387.54 *	590.37 *	1,181.64 *	1,968.84 *
YTD 2021:	10,436.17 *	21,324.27 *	2,232.12 *	4,466.74 *	7,446.38 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:12 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
12/01/2021	27.64	87.64	9.68	19.36	32.27
12/02/2021	45.56	102.79	11.60	23.18	38.64
12/03/2021	40.38	104.30	11.24	22.49	37.45
12/04/2021	39.54	94.06	10.90	21.80	36.32
12/05/2021	31.56	94.48	10.98	22.01	36.62
12/06/2021	47.16	120.73	13.04	26.12	43.50
12/07/2021	45.31	117.03	12.86	25.72	42.85
12/08/2021	32.93	99.40	10.64	21.30	35.55
12/09/2021	27.55	90.20	9.76	19.53	32.53
12/10/2021	33.18	104.62	11.22	22.43	37.41
12/11/2021	28.48	95.52	10.25	20.54	34.20
12/12/2021	29.29	94.92	10.29	20.63	34.32
12/13/2021	39.59	112.51	12.17	24.32	40.56
12/14/2021	27.99	93.84	10.08	20.17	33.56
12/15/2021	29.09	103.71	11.26	22.56	37.57
12/16/2021	52.58	119.63	13.11	26.25	43.77
12/17/2021	50.49	109.96	11.94	23.87	39.86
12/18/2021	49.72	108.92	12.07	24.19	40.30
12/19/2021	45.78	101.63	12.00	23.99	40.01
12/20/2021	45.18	121.48	13.79	27.62	46.05
12/21/2021	57.28	131.55	14.32	28.59	47.65
12/22/2021	50.49	110.20	11.96	24.02	39.94
12/23/2021	20.42	80.10	8.80	17.64	29.37
12/24/2021	19.18	79.17	8.65	17.31	28.84
12/25/2021	19.43	80.13	8.66	17.41	28.96
12/26/2021	25.14	87.08	9.49	19.04	31.70
12/27/2021	48.45	116.39	12.51	25.06	41.73
12/28/2021	26.27	91.78	9.98	19.98	33.30
12/29/2021	25.32	90.79	9.98	20.01	33.32
12/30/2021	50.85	105.13	11.55	23.22	38.63
12/31/2021	25.48	86.45	9.70	19.49	32.39
Monthly Avg/Sum*:	1,137.31 *	3,136.14 *	344.48 *	689.85 *	1,149.17 *
Daily Min:	19.18	79.17	8.65	17.31	28.84
Daily Max:	57.28	131.55	14.32	28.59	47.65
Oct 2021 - Dec 2021	2,877.88	8,523.68	934.85	1,871.49	3,118.01
QTD:	2,877.88 *	8,523.68 *	934.85 *	1,871.49 *	3,118.01 *
YTD 2021:	11,573.48 *	24,460.41 *	2,576.60 *	5,156.59 *	8,595.55 *

Startup / Shutdown Events

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 09:13 **Location:** Roseville, CA

Unit offline

Tag Name: CT1_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
10/14/2021 22:00	10/20/2021 21:00	144
11/19/2021 01:00	11/19/2021 06:00	6

Startup / Shutdown Events

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 09:13 **Location:** Roseville, CA

Operating Time Summary

Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	150.00 Hour(s)
Offline Percentage:	6.79 %
Total Online:	2,058.00 Hour(s)
Online Percentage:	93.21 %

Startup / Shutdown Events

CT1



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 09:13 **Location:** Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	10/14/2021 21:00	10/14/2021 21:13	Shutdown	14
2	10/20/2021 22:49	10/20/2021 23:52	cold Startup	64
3	11/19/2021 00:10	11/19/2021 00:17	Shutdown	8
4	11/19/2021 07:55	11/19/2021 08:39	cold Startup	45

Startup / Shutdown Events

CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:13 Location: Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	2	109	0.09
Warm Startup	0		0.00
Shutdown	2	22	0.02
Total Process Events:	4	131	0.11

Total Report Time:	2,207.98 Hour(s)
Total Operating Time:	2,054.80 Hour(s)
Total Startup Time:	109 Minute(s)
Total Shutdown Time:	22 Minute(s)
Total Startup/Shutdown Time:	131 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	0.11 %

Startup / Shutdown Events

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 09:15 **Location:** Roseville, CA

No source downtime records found.

Startup / Shutdown Events

CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 09:15 **Location:** Roseville, CA

No startup/shutdown events found.

CT1 SUSD EVENT 1

CT1_GasFlow_CT_scfh_1M				CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/14/21 20:55	412112.5			0.6			1.66			0.62			2.64			0		
10/14/21 20:56	412728.6			0.7			1.54			0.7			2.46			0		
10/14/21 20:57	411650.4			0.7			1.45			0.7			2.31			0		
10/14/21 20:58	404641.9			0.7			1.36			0.69			2.13			0		
10/14/21 20:59	401869.3			0.7			1.36			0.69			2.11			0		
10/14/21 21:00	399019.8			0.7			1.36			0.68			2.1			1		
10/14/21 21:01	384078.7			0.7			1.36			0.65			2.02			1		
10/14/21 21:02	365286.8			0.7			1.43			0.61			2.02			1		
10/14/21 21:03	344723.5			0.8			1.85			0.64			2.46			1		
10/14/21 21:04	320848.5			0.8			2.29			0.6			2.84			1		
10/14/21 21:05	298051.8			0.9			2.29			0.62			2.64			1		
10/14/21 21:06	275948.2			0.8			2.32			0.52			2.48			1		
10/14/21 21:07	253998.7			0.7			2.67			0.44			2.62			1		
10/14/21 21:08	230585.8			0.6			4.84			0.31			4.31			1		
10/14/21 21:09	210330.6			0.4			8.9			0.2			7.23			1		
10/14/21 21:10	185377.4			1.6			21.52			0.71			15.42			1		
10/14/21 21:11	164198			1.8			24.65			0.71			15.64			1		
10/14/21 21:12	147716.6			653.7			27.44			226.82			15.67			1		
10/14/21 21:13	94036.5			1695.2			26.97			374.14			9.8			1		
10/14/21 21:14	17713.7			0			31.32			97.38			2.15			0		
10/14/21 21:15	17559.6			0			0.5			0			0			0		
10/14/21 21:16	18021.7			0			0.2			0			0			0		
10/14/21 21:17	18560.8			0			0.2			0			0			0		
10/14/21 21:18	18868.9			0			0.1			0			0			0		

CT1 SUSD EVENT 2

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/20/21 22:44	0			0			0			0			0			0		
10/20/21 22:45	0			0			0			0			0			0		
10/20/21 22:46	0			0			0			0			0			0		
10/20/21 22:47	0			0			0			0			0			0		
10/20/21 22:48	4543.9			0			0			0			0			0		
10/20/21 22:49	11629.4			0.1			0			0			0			1		
10/20/21 22:50	25646.3			0.1			0			0			0			1		
10/20/21 22:51	37352.7			82.6			29.5			7.25			4.26			1		
10/20/21 22:52	49367.2			1219			12.25			141.35			2.34			1		
10/20/21 22:53	61458.7			996			16.59			143.8			3.94			1		
10/20/21 22:54	80712.7			579.8			21.43			109.92			6.69			1		
10/20/21 22:55	124457.8			400.6			24.72			117.12			11.9			1		
10/20/21 22:56	142864.6			269.7			33.04			90.51			18.25			1		
10/20/21 22:57	148794.9			455.7			39.73			159.22			22.85			1		
10/20/21 22:58	160655.3			1927.8			30.61			727.14			19			1		
10/20/21 22:59	178908.1			1836.1			30.71			771.46			21.24			1		
10/20/21 23:00	201242.7			1211.7			37.42			572.56			29.1			1		
10/20/21 23:01	222807.2			256.4			43.91			134.15			37.8			1		
10/20/21 23:02	244140.6			27			49.04			15.5			46.27			1		
10/20/21 23:03	267091.4			3.5			73.31			2.19			75.68			1		
10/20/21 23:04	277411.5			2.5			60.9			1.63			65.29			1		
10/20/21 23:05	288347.8			2.3			28.95			1.56			32.26			1		
10/20/21 23:06	300285.3			2.1			16.36			1.51			18.98			1		
10/20/21 23:07	299823.2			2			11.97			1.4			13.87			1		
10/20/21 23:08	300439.3			1.9			9.63			1.35			11.18			1		
10/20/21 23:09	300054.2			1.8			8.76			1.28			10.16			1		
10/20/21 23:10	302980.8			1.7			7.66			1.19			8.97			1		
10/20/21 23:11	320001.4			1.5			6.69			1.12			8.28			1		
10/20/21 23:12	324853.4			1.4			6.16			1.06			7.73			1		
10/20/21 23:13	325469.5			1.3			6.07			0.98			7.64			1		
10/20/21 23:14	325392.5			1.3			5.9			0.98			7.42			1		
10/20/21 23:15	319308.2			1.3			5.81			0.98			7.17			1		
10/20/21 23:16	305522.4			1.2			5.64			0.87			6.66			1		
10/20/21 23:17	314841.3			1.2			4.93			0.91			6			1		
10/20/21 23:18	316997.8			1.1			5.11			0.85			6.26			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/20/21 23:19	318923.2			1.1			5.46			0.79			6.73			1		
10/20/21 23:20	319077.2			1.1			5.46			0.79			6.73			1		
10/20/21 23:21	317305.8			1			5.47			0.78			6.7			1		
10/20/21 23:22	315842.5			1			5.55			0.77			6.78			1		
10/20/21 23:23	315765.5			1.1			5.64			0.78			6.88			1		
10/20/21 23:24	315765.5			1			5.55			0.72			6.77			1		
10/20/21 23:25	315149.3			1			5.55			0.72			6.76			1		
10/20/21 23:26	320540.5			1			5.64			0.73			6.98			1		
10/20/21 23:27	318230			1.1			5.64			0.79			6.93			1		
10/20/21 23:28	307216.7			1			5.99			0.75			7.11			1		
10/20/21 23:29	309219.1			1.1			5.37			0.77			6.42			1		
10/20/21 23:30	307601.8			1.1			5.27			0.77			6.27			1		
10/20/21 23:31	298051.8			1			5.55			0.68			6.39			1		
10/20/21 23:32	292506.7			1			5.27			0.68			5.96			1		
10/20/21 23:33	288039.8			1			5.36			0.68			5.96			1		
10/20/21 23:34	284805.1			0.9			5.54			0.61			6.09			1		
10/20/21 23:35	284497			0.8			6.08			0.55			6.69			1		
10/20/21 23:36	284574			0.8			6.27			0.55			6.89			1		
10/20/21 23:37	284497			0.7			6.36			0.49			6.99			1		
10/20/21 23:38	284574			0.7			6.36			0.49			6.99			1		
10/20/21 23:39	284574			0.7			5.53			0.49			6.08			1		
10/20/21 23:40	284420			0.7			3.78			0.49			4.16			1		
10/20/21 23:41	284343			0.7			3.5			0.49			3.85			1		
10/20/21 23:42	284266			0.7			3.32			0.49			3.65			1		
10/20/21 23:43	285344.2			0.7			3.04			0.49			3.35			1		
10/20/21 23:44	286576.4			0.7			2.95			0.5			3.27			1		
10/20/21 23:45	284651			0.7			2.81			0.49			3.1			1		
10/20/21 23:46	283726.8			0.7			2.63			0.48			2.89			1		
10/20/21 23:47	283418.8			0.7			2.49			0.49			2.73			1		
10/20/21 23:48	283649.8			0.7			2.3			0.49			2.53			1		
10/20/21 23:49	283803.8			0.7			2.12			0.49			2.33			1		
10/20/21 23:50	283572.8			0.7			2.03			0.49			2.22			1		
10/20/21 23:51	283880.9			0.7			1.94			0.49			2.12			1		
10/20/21 23:52	283187.7			0.7			1.94			0.49			2.12			1		
10/20/21 23:53	283341.8			0.7			1.84			0.49			2.02			0		
10/20/21 23:54	281108.3			0.7			1.84			0.49			2			0		
10/20/21 23:55	280800.3			0.7			1.75			0.49			1.9			0		
10/20/21 23:56	280800.3			0.7			1.75			0.49			1.9			0		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/20/21 23:57	280184.1			0.7			1.75			0.49			1.9			0		

CT1 SUSD EVENT 3

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/19/21 0:05	263548.7			0.5			1.84			0.3			1.87			0		
11/19/21 0:06	263240.6			0.5			1.84			0.3			1.87			0		
11/19/21 0:07	263394.6			0.5			1.84			0.3			1.87			0		
11/19/21 0:08	263779.7			0.5			1.84			0.3			1.87			0		
11/19/21 0:09	266013.2			0.5			1.74			0.3			1.79			0		
11/19/21 0:10	263856.7			0.5			1.74			0.3			1.77			1		
11/19/21 0:11	242754.3			0.5			1.71			0.27			1.6			1		
11/19/21 0:12	221806			0.5			4.7			0.26			4.02			1		
11/19/21 0:13	196082.7			0.5			10.05			0.25			7.6			1		
11/19/21 0:14	173440			7.1			11.31			2.9			7.57			1		
11/19/21 0:15	155880.3			513.7			14.47	X		187.67			8.7	X		1		
11/19/21 0:16	137165.5			1491.1			16.11			479.31			8.52			1		
11/19/21 0:17	35735.4			1947			18.44			163			2.54			1		
11/19/21 0:18	17251.6			0			24.91			149.24			1.66			0		
11/19/21 0:19	17405.6			0			0.1			0			0			0		
11/19/21 0:20	17713.7			0			0.1			0			0			0		
11/19/21 0:21	17790.7			0			0.1			0			0			0		
11/19/21 0:22	18021.7			0			0.1			0			0			0		

CT1 SUSD EVENT 4

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/19/21 7:50	0			0			0			0			0			0		
11/19/21 7:51	0			0			0			0			0			0		
11/19/21 7:52	0			0			0			0			0			0		
11/19/21 7:53	0			0			0			0			0			0		
11/19/21 7:54	0			0			0			0			0			0		
11/19/21 7:55	0			0.1			0			0			0			1		
11/19/21 7:56	11398.4			0.1			0			0			0			1		
11/19/21 7:57	27340.7			1.3			0.1			0			0			1		
11/19/21 7:58	40895.5			1246.5			6.44			119.42			1.01			1		
11/19/21 7:59	54296.3			1080.8			7.38			137.66			1.55			1		
11/19/21 8:00	68775.3			618.6			10.25			99.69			2.72			1		
11/19/21 8:01	104048.6			422.3			12.92			102.94			5.18			1		
11/19/21 8:02	140169.1			300.6			19.24			98.79			10.4			1		
11/19/21 8:03	151952.5			208.3			15.26			74.19			8.94			1		
11/19/21 8:04	167201.7			1603.3			26			628.43			16.77			1		
11/19/21 8:05	186070.6			1733.4			27.48			755.86			19.72			1		
11/19/21 8:06	207481			711.2			28.17			345.8			22.54			1		
11/19/21 8:07	229122.5			112.4			28.98			60.34			25.61			1		
11/19/21 8:08	248761.6			9.8			29.03			5.71			27.86			1		
11/19/21 8:09	275024			2			29.07			1.31			30.83			1		
11/19/21 8:10	299438.1			1.6			14.12			1.15			16.31			1		
11/19/21 8:11	318692.1			1.5			9.48			1.14			11.65			1		
11/19/21 8:12	326239.7			1.5			7.25			1.16			9.12			1		
11/19/21 8:13	326701.8			1.6			7			1.23			8.82			1		
11/19/21 8:14	326547.7			1.5			6.91			1.16			8.71			1		
11/19/21 8:15	324314.3			1.5			6.41			1.11			8.02			1		
11/19/21 8:16	323159			1.3			6.16			0.97			7.67			1		
11/19/21 8:17	322003.8			1.2			5.73			0.9			7.11			1		
11/19/21 8:18	321695.7			1.2			5.64			0.9			7			1		
11/19/21 8:19	321387.7			1.1			5.64			0.85			6.99			1		
11/19/21 8:20	321387.7			1			5.47			0.78			6.78			1		
11/19/21 8:21	320540.5			1			5.47			0.78			6.76			1		
11/19/21 8:22	320001.4			1			5.47			0.72			6.75			1		
11/19/21 8:23	320848.5			1			5.47			0.72			6.76			1		
11/19/21 8:24	322619.9			1			5.47			0.72			6.8			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/19/21 8:25	322696.9			1			5.55			0.72			6.91			1		
11/19/21 8:26	322851			1			5.64			0.72			7.02			1		
11/19/21 8:27	322388.9			1			5.73			0.72			7.12			1		
11/19/21 8:28	321310.6			1			5.29			0.72			6.56			1		
11/19/21 8:29	319462.3			1			3.56			0.71			4.38			1		
11/19/21 8:30	317382.8			1			2.99			0.72			3.67			1		
11/19/21 8:31	316689.7			0.9			2.91			0.65			3.55			1		
11/19/21 8:32	316150.6			0.9			2.82			0.65			3.44			1		
11/19/21 8:33	315688.5			0.9			2.73			0.65			3.32			1		
11/19/21 8:34	317305.8			0.9			2.64			0.65			3.23			1		
11/19/21 8:35	308603			0.9			2.55			0.64			3.04			1		
11/19/21 8:36	300670.3			0.9			2.29			0.62			2.66			1		
11/19/21 8:37	296665.5			0.9			1.79			0.62			2.05			1		
11/19/21 8:38	291043.3			0.9			1.7			0.61			1.91			1		
11/19/21 8:39	285652.3			0.8			1.72			0.55			1.9			1		
11/19/21 8:40	281493.4			0.7			1.72			0.48			1.87			0		
11/19/21 8:41	275563.2			0.7			1.84			0.48			1.96			0		
11/19/21 8:42	271327.3			0.7			2.03			0.47			2.12			0		
11/19/21 8:43	267168.4			0.6			2.21			0.4			2.28			0		
11/19/21 8:44	266706.3			0.7			2.53			0.41			2.6			0		

AQ-57

AQ-57 The emissions rates from each gas turbine and heat recovery steam generator exhaust during startup and shutdown or excursions shall not exceed the following:

Combustion Turbine emissions limitations per Turbine excluding Startup and Shutdown	
Pollutant	Pounds/Hour
CO	6.2 3hr rolling
NOX	5.1 1 hour rolling
PM-10	4.7
SOX	1.0
VOC	1.8

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6

AQ-57 If the Alstom GX100 turbines are selected for the Project, emission rates from each gas turbine and heat recovery steam generator exhaust, except during startup and/or shutdown, or excursions shall not exceed the following:

Alstom GTX100 - COMBUSTION TURBINE EMISSION LIMITATIONS PER TURBINE EXCLUDING STARTUP AND SHUTDOWN	
POLLUTANT	POUNDS/HOUR
Carbon Monoxide (CO)	6.2 (three-hour rolling average)
Nitrogen Oxides (NOx)	5.1 (one-hour average)
PM10	4.7
Sulfur Oxides (SOx)	1.0
Volatile Organic Compounds (VOCs)	1.8

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emission limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

AQ57 CT1 HOURLY EMISSIONS

Date/Time	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/01/21 0:00	0.7			1.3			1			0.39			0.19344			0.64		
10/01/21 1:00	0.6			1.6			3			0.35			0.17502			0.58		
10/01/21 2:00	0.6			1.5			3			0.34			0.17112			0.57		
10/01/21 3:00	0.6			1.5			2			0.35			0.17532			0.58		
10/01/21 4:00	0.7			1.2			1			0.45			0.22512			0.75		
10/01/21 5:00	0.8			1.6			1			0.48			0.24144			0.8		
10/01/21 6:00	0.7			1.6			3			0.4			0.19884			0.66		
10/01/21 7:00	0.7			1.3			3			0.38			0.1905			0.64		
10/01/21 8:00	0.7			1.5			2			0.34			0.16938			0.56		
10/01/21 9:00	0.5			1.5			3			0.33			0.16584			0.55		
10/01/21 10:00	0.6			1.5			1			0.35			0.17466			0.58		
10/01/21 11:00	0.6			1.5			1			0.37			0.18588			0.62		
10/01/21 12:00	0.6			1.3			1			0.45			0.22362			0.75		
10/01/21 13:00	1.1			1.5			1			0.59			0.29724			0.99		
10/01/21 14:00	1			1.5			1			0.53			0.26742			0.89		
10/01/21 15:00	0.6			1.2			2			0.43			0.21666			0.72		
10/01/21 16:00	0.6			1.3			0			0.5			0.24996			0.83		
10/01/21 17:00	0.6			1.5			1			0.52			0.26202			0.87		
10/01/21 18:00	0.7			1.5			1			0.5			0.24894			0.83		
10/01/21 19:00	0.7			1.5			1			0.48			0.23838			0.79		
10/01/21 20:00	0.8			1.5			1			0.53			0.26538			0.88		
10/01/21 21:00	0.8			1.5			1			0.52			0.25782			0.86		
10/01/21 22:00	0.8			1.6			2			0.4			0.19794			0.66		
10/01/21 23:00	0.7			1.5			2			0.35			0.17502			0.58		
10/02/21 0:00	0.7			1.5			1			0.43			0.21576			0.72		
10/02/21 1:00	0.7			1.5			2			0.38			0.19086			0.64		
10/02/21 2:00	0.7			1.4			2			0.39			0.19488			0.65		
10/02/21 3:00	0.7			1.5			2			0.38			0.1893			0.63		
10/02/21 4:00	0.7			1.1			1			0.41			0.20376			0.68		
10/02/21 5:00	0.7			1.4			2			0.38			0.18852			0.63		
10/02/21 6:00	0.8			1.5			1			0.53			0.26286			0.88		
10/02/21 7:00	0.8			1.7			2			0.43			0.21276			0.71		
10/02/21 8:00	0.6			1.5			3			0.33			0.16572			0.55		
10/02/21 9:00	0.5			1.5			3			0.33			0.16536			0.55		
10/02/21 10:00	0.5			1.5			2			0.33			0.16488			0.55		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/02/21 11:00	0.6			1.5			1			0.34			0.16998			0.57		
10/02/21 12:00	0.6			1.5			1			0.35			0.17394			0.58		
10/02/21 13:00	0.6			1.3			0			0.47			0.23526			0.78		
10/02/21 14:00	0.7			1.4			0			0.48			0.2412			0.8		
10/02/21 15:00	0.6			1.4			1			0.44			0.21882			0.73		
10/02/21 16:00	0.6			1.4			0			0.49			0.24306			0.81		
10/02/21 17:00	0.6			1.5			0			0.54			0.26862			0.9		
10/02/21 18:00	0.7			1.5			1			0.54			0.27132			0.9		
10/02/21 19:00	0.7			1.5			1			0.54			0.27108			0.9		
10/02/21 20:00	0.8			1.5			1			0.54			0.2712			0.9		
10/02/21 21:00	0.8			1.5			1			0.52			0.261			0.87		
10/02/21 22:00	0.8			1.5			1			0.51			0.2529			0.84		
10/02/21 23:00	0.8			1.5			1			0.48			0.23856			0.8		
10/03/21 0:00	0.7			1.6			2			0.4			0.1998			0.67		
10/03/21 1:00	0.6			1.5			2			0.34			0.17166			0.57		
10/03/21 2:00	0.7			1.5			2			0.34			0.17136			0.57		
10/03/21 3:00	0.6			1.5			2			0.34			0.17238			0.57		
10/03/21 4:00	0.6			1.5			2			0.34			0.17184			0.57		
10/03/21 5:00	0.7			1.5			3			0.34			0.17214			0.57		
10/03/21 6:00	0.7			1.5			3			0.35			0.17508			0.58		
10/03/21 7:00	0.7			1.6			4			0.33			0.16638			0.55		
10/03/21 8:00	0.6			1.4			3			0.33			0.16632			0.55		
10/03/21 9:00	0.6			1.5			3			0.33			0.16506			0.55		
10/03/21 10:00	0.5			1.5			3			0.33			0.16434			0.55		
10/03/21 11:00	0.5			1.4			2			0.34			0.16776			0.56		
10/03/21 12:00	0.6			1.6			1			0.34			0.17148			0.57		
10/03/21 13:00	0.6			1.4			1			0.37			0.1872			0.62		
10/03/21 14:00	0.7			1.4			1			0.43			0.2172			0.72		
10/03/21 15:00	0.6			1.4			0			0.48			0.23868			0.8		
10/03/21 16:00	0.7			1.5			1			0.56			0.28008			0.93		
10/03/21 17:00	1.2			1.5			1			0.59			0.29466			0.98		
10/03/21 18:00	1.3			1.5			1			0.58			0.29172			0.97		
10/03/21 19:00	1.4			1.5			1			0.58			0.2895			0.97		
10/03/21 20:00	1.4			1.5			1			0.59			0.29358			0.98		
10/03/21 21:00	1.4			1.5			1			0.59			0.29514			0.98		
10/03/21 22:00	1.2			1.6			2			0.48			0.23808			0.79		
10/03/21 23:00	0.8			1.4			2			0.37			0.18624			0.62		
10/04/21 0:00	0.7			1.5			2			0.35			0.17562			0.59		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/04/21 1:00	0.7			1.3			1			0.39			0.1935			0.65		
10/04/21 2:00	0.7			1.5			2			0.36			0.1812			0.6		
10/04/21 3:00	0.7			1.4			0			0.53			0.26406			0.88		
10/04/21 4:00	0.7			1.5			1			0.52			0.25854			0.86		
10/04/21 5:00	0.8			1.5			1			0.54			0.26754			0.89		
10/04/21 6:00	0.7			1.5			1			0.54			0.26964			0.9		
10/04/21 7:00	0.8			1.5			1			0.52			0.2604			0.87		
10/04/21 8:00	0.7			1.5			1			0.54			0.27042			0.9		
10/04/21 9:00	0.8			1.5			1			0.49			0.24672			0.82		
10/04/21 10:00	0.7			1.5			1			0.52			0.2616			0.87		
10/04/21 11:00	0.6			1.5			1			0.53			0.26496			0.88		
10/04/21 12:00	0.6			1.5			1			0.54			0.27168			0.91		
10/04/21 13:00	0.6			1.5			1			0.54			0.27138			0.9		
10/04/21 14:00	0.6			1.5			1			0.54			0.27228			0.91		
10/04/21 15:00	0.8			1.6			1			0.55			0.27564			0.92		
10/04/21 16:00	0.4			1.5			2			0.7			0.34758			1.16		
10/04/21 17:00	0.6			1.5			2			0.65			0.32568			1.09		
10/04/21 18:00	0.9			1.5			2			0.63			0.31338			1.04		
10/04/21 19:00	1.2			1.5			1			0.6			0.30234			1.01		
10/04/21 20:00	1.5			1.5			1			0.58			0.29106			0.97		
10/04/21 21:00	1.5			1.5			1			0.59			0.2931			0.98		
10/04/21 22:00	1.1			1.6			2			0.47			0.2364			0.79		
10/04/21 23:00	0.8			1.5			2			0.37			0.18288			0.61		
10/05/21 0:00	0.7			1.5			2			0.36			0.17814			0.59		
10/05/21 1:00	0.7			1.5			1			0.37			0.18696			0.62		
10/05/21 2:00	0.7			1.4			2			0.34			0.17142			0.57		
10/05/21 3:00	0.7			1.4			2			0.35			0.17622			0.59		
10/05/21 4:00	0.7			1.4			1			0.44			0.21894			0.73		
10/05/21 5:00	0.7			1.4			2			0.41			0.20466			0.68		
10/05/21 6:00	0.7			1.6			1			0.43			0.2163			0.72		
10/05/21 7:00	0.7			1.6			1			0.48			0.2415			0.81		
10/05/21 8:00	0.6			1.5			3			0.34			0.17118			0.57		
10/05/21 9:00	0.6			1.4			2			0.36			0.1794			0.6		
10/05/21 10:00	0.6			1.4			0			0.53			0.2667			0.89		
10/05/21 11:00	0.5			1.6			2			0.35			0.17634			0.59		
10/05/21 12:00	0.5			1.5			2			0.34			0.1719			0.57		
10/05/21 13:00	0.5			1.4			2			0.36			0.18144			0.6		
10/05/21 14:00	0.6			1.4			1			0.42			0.21078			0.7		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/05/21 15:00	0.6			1.4			1			0.43			0.21504			0.72		
10/05/21 16:00	0.6			1.4			1			0.46			0.22974			0.77		
10/05/21 17:00	0.6			1.5			1			0.44			0.22248			0.74		
10/05/21 18:00	0.6			1.5			1			0.48			0.23958			0.8		
10/05/21 19:00	0.6			1.5			2			0.38			0.18966			0.63		
10/05/21 20:00	0.6			1.4			2			0.4			0.19902			0.66		
10/05/21 21:00	0.7			1.3			0			0.46			0.22818			0.76		
10/05/21 22:00	0.6			1.5			1			0.5			0.25044			0.83		
10/05/21 23:00	0.6			1.5			1			0.5			0.24948			0.83		
10/06/21 0:00	0.6			1.7			3			0.35			0.17364			0.58		
10/06/21 1:00	0.6			1.5			2			0.35			0.17328			0.58		
10/06/21 2:00	0.5			1.5			3			0.35			0.17268			0.58		
10/06/21 3:00	0.6			1.5			3			0.35			0.17268			0.58		
10/06/21 4:00	0.6			1.5			3			0.35			0.1731			0.58		
10/06/21 5:00	0.6			1.4			2			0.4			0.20142			0.67		
10/06/21 6:00	0.6			1.7			2			0.45			0.22284			0.74		
10/06/21 7:00	0.5			1.5			3			0.35			0.17556			0.59		
10/06/21 8:00	0.5			1.3			2			0.4			0.19944			0.66		
10/06/21 9:00	0.6			1.4			0			0.52			0.26202			0.87		
10/06/21 10:00	0.7			1.5			1			0.45			0.22656			0.76		
10/06/21 11:00	1.1			1.5			1			0.54			0.27174			0.91		
10/06/21 12:00	1.3			1.5			1			0.55			0.273			0.91		
10/06/21 13:00	0.8			1.5			1			0.48			0.23976			0.8		
10/06/21 14:00	0.6			1.5			1			0.55			0.27402			0.91		
10/06/21 15:00	0.6			1.4			1			0.46			0.22788			0.76		
10/06/21 16:00	0.6			1.5			1			0.49			0.24684			0.82		
10/06/21 17:00	0.6			1.6			2			0.37			0.18306			0.61		
10/06/21 18:00	0.7			1.5			1			0.4			0.19752			0.66		
10/06/21 19:00	0.6			1.5			2			0.39			0.19254			0.64		
10/06/21 20:00	0.7			1.4			0			0.5			0.24918			0.83		
10/06/21 21:00	0.6			1.5			1			0.55			0.2736			0.91		
10/06/21 22:00	0.6			1.7			2			0.45			0.22362			0.75		
10/06/21 23:00	0.5			1.5			3			0.35			0.17274			0.58		
10/07/21 0:00	0.6			1.5			3			0.35			0.1725			0.58		
10/07/21 1:00	0.6			1.5			3			0.35			0.17256			0.58		
10/07/21 2:00	0.6			1.5			2			0.35			0.1725			0.58		
10/07/21 3:00	0.7			1.2			1			0.43			0.21594			0.72		
10/07/21 4:00	0.7			1.6			1			0.48			0.23868			0.8		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/07/21 5:00	0.7			1.5			1			0.53			0.264			0.88		
10/07/21 6:00	0.6			1.5			1			0.56			0.2787			0.93		
10/07/21 7:00	0.6			1.5			1			0.54			0.27198			0.91		
10/07/21 8:00	0.7			1.5			1			0.49			0.24492			0.82		
10/07/21 9:00	0.6			1.5			1			0.55			0.27312			0.91		
10/07/21 10:00	0.6			1.7			2			0.42			0.20802			0.69		
10/07/21 11:00	0.6			1.4			1			0.38			0.1893			0.63		
10/07/21 12:00	0.5			1.5			2			0.34			0.17208			0.57		
10/07/21 13:00	0.5			1.5			2			0.34			0.17142			0.57		
10/07/21 14:00	0.5			1.5			2			0.34			0.16848			0.56		
10/07/21 15:00	0.5			1.5			2			0.34			0.17214			0.57		
10/07/21 16:00	0.5			1.4			2			0.41			0.2073			0.69		
10/07/21 17:00	0.6			1.5			0			0.54			0.27216			0.91		
10/07/21 18:00	0.6			1.6			2			0.42			0.20934			0.7		
10/07/21 19:00	0.5			1.5			2			0.35			0.1737			0.58		
10/07/21 20:00	0.6			1.5			2			0.36			0.17964			0.6		
10/07/21 21:00	0.6			1.5			2			0.35			0.1734			0.58		
10/07/21 22:00	0.6			1.5			2			0.35			0.17634			0.59		
10/07/21 23:00	0.7			1.5			1			0.44			0.21966			0.73		
10/08/21 0:00	0.6			1.6			3			0.35			0.17322			0.58		
10/08/21 1:00	0.6			1.5			3			0.35			0.17292			0.58		
10/08/21 2:00	0.6			1.5			3			0.34			0.17244			0.57		
10/08/21 3:00	0.6			1.5			3			0.35			0.17484			0.58		
10/08/21 4:00	0.6			1.5			2			0.37			0.18282			0.61		
10/08/21 5:00	0.5			1.7			4			0.34			0.16788			0.56		
10/08/21 6:00	0.6			1.5			3			0.36			0.18132			0.6		
10/08/21 7:00	0.6			1.5			1			0.56			0.27852			0.93		
10/08/21 8:00	0.7			1.5			2			0.43			0.21354			0.71		
10/08/21 9:00	0.6			1.5			1			0.55			0.27438			0.91		
10/08/21 10:00	0.6			1.6			3			0.36			0.1791			0.6		
10/08/21 11:00	0.7			1.3			1			0.48			0.23916			0.8		
10/08/21 12:00	0.7			1.5			1			0.46			0.23238			0.77		
10/08/21 13:00	0.7			1.5			1			0.48			0.24006			0.8		
10/08/21 14:00	0.6			1.5			1			0.55			0.2739			0.91		
10/08/21 15:00	0.5			1.7			3			0.35			0.1734			0.58		
10/08/21 16:00	0.5			1.3			2			0.41			0.20352			0.68		
10/08/21 17:00	0.5			1.7			3			0.35			0.17394			0.58		
10/08/21 18:00	0.5			1.5			3			0.34			0.17118			0.57		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/08/21 19:00	0.5			1.5			3			0.34			0.16956			0.57		
10/08/21 20:00	0.5			1.6			3			0.34			0.17088			0.57		
10/08/21 21:00	0.6			1.5			2			0.34			0.17232			0.57		
10/08/21 22:00	0.6			1.5			3			0.35			0.1755			0.59		
10/08/21 23:00	0.5			1.6			3			0.34			0.17028			0.57		
10/09/21 0:00	0.5			1.6			4			0.34			0.16848			0.56		
10/09/21 1:00	0.4			1.5			4			0.33			0.16512			0.55		
10/09/21 2:00	0.4			1.5			4			0.33			0.16584			0.55		
10/09/21 3:00	0.4			1.5			5			0.33			0.16536			0.55		
10/09/21 4:00	0.5			1.5			3			0.35			0.17364			0.58		
10/09/21 5:00	0.7			1.4			2			0.41			0.20628			0.69		
10/09/21 6:00	0.7			1.6			3			0.41			0.20484			0.68		
10/09/21 7:00	0.8			1.6			2			0.48			0.23994			0.8		
10/09/21 8:00	0.6			1.7			2			0.39			0.19578			0.65		
10/09/21 9:00	0.4			1.6			4			0.34			0.16836			0.56		
10/09/21 10:00	0.4			1.5			4			0.33			0.16602			0.55		
10/09/21 11:00	0.4			1.5			3			0.33			0.16596			0.55		
10/09/21 12:00	0.4			1.5			3			0.33			0.16596			0.55		
10/09/21 13:00	0.5			1.5			3			0.33			0.16584			0.55		
10/09/21 14:00	0.4			1.5			3			0.33			0.16578			0.55		
10/09/21 15:00	0.5			1.4			2			0.34			0.1713			0.57		
10/09/21 16:00	0.6			1.4			1			0.43			0.21264			0.71		
10/09/21 17:00	0.7			1.5			1			0.51			0.25308			0.84		
10/09/21 18:00	0.6			1.6			2			0.37			0.18564			0.62		
10/09/21 19:00	0.5			1.5			3			0.34			0.17106			0.57		
10/09/21 20:00	0.5			1.6			3			0.34			0.168			0.56		
10/09/21 21:00	0.6			1.5			3			0.34			0.17184			0.57		
10/09/21 22:00	0.6			1.6			3			0.34			0.17124			0.57		
10/09/21 23:00	0.6			1.5			3			0.35			0.17292			0.58		
10/10/21 0:00	0.6			1.5			3			0.35			0.17316			0.58		
10/10/21 1:00	0.6			1.6			3			0.34			0.17238			0.57		
10/10/21 2:00	0.6			1.5			2			0.35			0.17622			0.59		
10/10/21 3:00	0.6			1.5			3			0.35			0.17448			0.58		
10/10/21 4:00	0.6			1.5			3			0.35			0.1746			0.58		
10/10/21 5:00	0.7			1.4			2			0.44			0.22008			0.73		
10/10/21 6:00	0.7			1.6			2			0.47			0.23418			0.78		
10/10/21 7:00	0.7			1.6			2			0.43			0.21552			0.72		
10/10/21 8:00	0.5			1.6			4			0.34			0.17088			0.57		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/10/21 9:00	0.4			1.5			4			0.33			0.16608			0.55		
10/10/21 10:00	0.5			1.5			3			0.34			0.16842			0.56		
10/10/21 11:00	0.5			1.5			3			0.33			0.16656			0.56		
10/10/21 12:00	0.5			1.5			3			0.33			0.1665			0.56		
10/10/21 13:00	0.5			1.5			3			0.33			0.16704			0.56		
10/10/21 14:00	0.5			1.5			3			0.34			0.16878			0.56		
10/10/21 15:00	0.5			1.4			1			0.36			0.18204			0.61		
10/10/21 16:00	0.6			1.4			1			0.44			0.21828			0.73		
10/10/21 17:00	0.6			1.6			2			0.36			0.18084			0.6		
10/10/21 18:00	0.5			1.5			3			0.34			0.16782			0.56		
10/10/21 19:00	0.6			1.4			1			0.37			0.18252			0.61		
10/10/21 20:00	0.6			1.6			1			0.43			0.21402			0.71		
10/10/21 21:00	0.6			1.5			2			0.34			0.1716			0.57		
10/10/21 22:00	0.5			1.5			3			0.34			0.16824			0.56		
10/10/21 23:00	0.4			1.5			3			0.33			0.16632			0.55		
10/11/21 0:00	0.5			1.5			3			0.35			0.17472			0.58		
10/11/21 1:00	0.4			1.6			4			0.33			0.1659			0.55		
10/11/21 2:00	0.5			1.5			2			0.34			0.17034			0.57		
10/11/21 3:00	0.5			1.5			3			0.35			0.1737			0.58		
10/11/21 4:00	0.6			1.4			1			0.49			0.24366			0.81		
10/11/21 5:00	0.6			1.5			1			0.48			0.24174			0.81		
10/11/21 6:00	0.6			1.5			1			0.52			0.26082			0.87		
10/11/21 7:00	0.6			1.5			1			0.55			0.27438			0.91		
10/11/21 8:00	0.5			1.5			3			0.67			0.33636			1.12		
10/11/21 9:00	0.8			1.5			2			0.64			0.32136			1.07		
10/11/21 10:00	0.5			1.5			2			0.7			0.3519			1.17		
10/11/21 11:00	1.3			1.5			2			0.6			0.29766			0.99		
10/11/21 12:00	1			1.5			2			0.64			0.32106			1.07		
10/11/21 13:00	1			1.5			2			0.65			0.324			1.08		
10/11/21 14:00	1.1			1.5			2			0.63			0.31572			1.05		
10/11/21 15:00	0.9			1.5			1			0.5			0.25212			0.84		
10/11/21 16:00	0.6			1.5			1			0.54			0.26838			0.89		
10/11/21 17:00	0.6			1.5			1			0.53			0.26514			0.88		
10/11/21 18:00	0.6			1.6			3			0.41			0.20628			0.69		
10/11/21 19:00	0.6			1.5			3			0.37			0.183			0.61		
10/11/21 20:00	0.6			1.6			2			0.47			0.23634			0.79		
10/11/21 21:00	0.6			1.6			2			0.41			0.20466			0.68		
10/11/21 22:00	0.5			1.7			3			0.37			0.1857			0.62		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/11/21 23:00	0.6			1.6			3			0.37			0.18294			0.61		
10/12/21 0:00	0.5			1.5			3			0.35			0.17448			0.58		
10/12/21 1:00	0.5			1.6			4			0.34			0.17154			0.57		
10/12/21 2:00	0.4			1.8			5			0.34			0.16944			0.56		
10/12/21 3:00	0.5			1.5			3			0.34			0.16968			0.57		
10/12/21 4:00	0.4			1.7			4			0.34			0.16992			0.57		
10/12/21 5:00	0.6			1.4			2			0.46			0.22974			0.77		
10/12/21 6:00	0.6			1.5			1			0.56			0.2811			0.94		
10/12/21 7:00	0.6			1.5			2			0.55			0.27696			0.92		
10/12/21 8:00	0.6			1.5			2			0.56			0.27912			0.93		
10/12/21 9:00	0.6			1.5			1			0.56			0.27936			0.93		
10/12/21 10:00	0.6			1.5			1			0.56			0.27984			0.93		
10/12/21 11:00	0.6			1.5			1			0.56			0.27966			0.93		
10/12/21 12:00	0.6			1.5			1			0.55			0.27306			0.91		
10/12/21 13:00	0.7			1.5			2			0.42			0.20826			0.69		
10/12/21 14:00	0.6			1.5			1			0.55			0.27654			0.92		
10/12/21 15:00	0.6			1.5			1			0.55			0.27576			0.92		
10/12/21 16:00	0.7			1.5			1			0.52			0.25956			0.87		
10/12/21 17:00	0.6			1.5			1			0.54			0.27132			0.9		
10/12/21 18:00	0.6			1.5			1			0.55			0.27426			0.91		
10/12/21 19:00	0.7			1.5			1			0.5			0.24762			0.83		
10/12/21 20:00	0.6			1.5			2			0.51			0.2556			0.85		
10/12/21 21:00	0.6			1.5			1			0.54			0.26802			0.89		
10/12/21 22:00	0.6			1.5			2			0.55			0.27474			0.92		
10/12/21 23:00	0.7			1.5			2			0.47			0.234			0.78		
10/13/21 0:00	0.7			1.5			1			0.56			0.2778			0.93		
10/13/21 1:00	0.7			1.6			3			0.38			0.1887			0.63		
10/13/21 2:00	0.6			1.5			3			0.35			0.17442			0.58		
10/13/21 3:00	0.7			1.4			2			0.42			0.21204			0.71		
10/13/21 4:00	0.7			1.5			1			0.56			0.27774			0.93		
10/13/21 5:00	0.7			1.5			1			0.53			0.26292			0.88		
10/13/21 6:00	0.7			1.5			1			0.51			0.2571			0.86		
10/13/21 7:00	0.7			1.5			1			0.56			0.27792			0.93		
10/13/21 8:00	0.6			1.5			1			0.56			0.2784			0.93		
10/13/21 9:00	0.6			1.5			1			0.56			0.27876			0.93		
10/13/21 10:00	0.6			1.5			1			0.55			0.27744			0.92		
10/13/21 11:00	0.6			1.5			1			0.56			0.27846			0.93		
10/13/21 12:00	0.6			1.5			1			0.56			0.27792			0.93		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/13/21 13:00	0.6			1.5			1			0.56			0.27846			0.93		
10/13/21 14:00	0.6			1.5			1			0.55			0.27306			0.91		
10/13/21 15:00	0.7			1.5			1			0.49			0.2454			0.82		
10/13/21 16:00	0.5			1.5			2			0.41			0.2067			0.69		
10/13/21 17:00	0.6			1.6			1			0.55			0.27474			0.92		
10/13/21 18:00	0.7			1.5			1			0.5			0.25176			0.84		
10/13/21 19:00	0.7			1.6			2			0.47			0.23604			0.79		
10/13/21 20:00	0.7			1.5			1			0.52			0.2583			0.86		
10/13/21 21:00	0.8			1.6			2			0.5			0.25206			0.84		
10/13/21 22:00	0.6			1.6			1			0.52			0.2619			0.87		
10/13/21 23:00	0.6			1.7			5			0.34			0.16896			0.56		
10/14/21 0:00	0.8			1.5			4			0.35			0.17286			0.58		
10/14/21 1:00	0.7			1.7			4			0.34			0.17082			0.57		
10/14/21 2:00	0.7			1.7			4			0.35			0.1734			0.58		
10/14/21 3:00	0.6			1.5			4			0.35			0.17376			0.58		
10/14/21 4:00	0.6			1.7			4			0.34			0.17232			0.57		
10/14/21 5:00	0.7			1.4			1			0.51			0.25746			0.86		
10/14/21 6:00	0.8			1.5			2			0.56			0.27834			0.93		
10/14/21 7:00	0.7			1.6			3			0.41			0.20706			0.69		
10/14/21 8:00	0.6			1.7			5			0.34			0.17202			0.57		
10/14/21 9:00	0.5			1.6			3			0.34			0.17202			0.57		
10/14/21 10:00	0.5			1.5			4			0.33			0.1674			0.56		
10/14/21 11:00	0.5			1.5			3			0.34			0.16824			0.56		
10/14/21 12:00	0.5			1.6			3			0.34			0.1686			0.56		
10/14/21 13:00	0.5			1.5			2			0.35			0.1731			0.58		
10/14/21 14:00	0.5			1.5			2			0.35			0.17418			0.58		
10/14/21 15:00	0.6			1.5			2			0.37			0.18498			0.62		
10/14/21 16:00	0.6			1.5			2			0.44			0.22224			0.74		
10/14/21 17:00	0.6			1.5			1			0.55			0.27456			0.92		
10/14/21 18:00	0.7			1.5			1			0.52			0.25938			0.86		
10/14/21 19:00	0.6			1.5			1			0.56			0.27966			0.93		
10/14/21 20:00	0.6			1.5			2			0.56			0.27864			0.93		
10/14/21 21:00	0			0			0	X		0.33			0.16518			0.55		
10/14/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/14/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/15/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/15/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/16/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/16/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/17/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/18/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/18/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/19/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/21 22:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/19/21 23:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/21 0:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/21 7:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/21 8:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/21 9:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/21 10:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/21 11:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/21 12:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/21 13:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/21 14:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/21 15:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/21 16:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/21 17:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/21 18:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/21 19:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/21 20:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/21 21:00	0	X		0	X		0	X		0	X		0	X		0	X	
10/20/21 22:00	0			0			0	X		0.12			0.0585			0.2		
10/20/21 23:00	0.7			1.8			4			0.37			0.1845			0.62		
10/21/21 0:00	0.8			1.5			3			0.35			0.17652			0.59		
10/21/21 1:00	0.6			1.5			3			0.35			0.17442			0.58		
10/21/21 2:00	0.6			1.5			3			0.35			0.17466			0.58		
10/21/21 3:00	0.7			1.4			2			0.42			0.2079			0.69		
10/21/21 4:00	0.7			1.5			2			0.44			0.21894			0.73		
10/21/21 5:00	0.7			1.5			2			0.5			0.24996			0.83		
10/21/21 6:00	0.7			1.5			2			0.51			0.25302			0.84		
10/21/21 7:00	0.7			1.5			2			0.49			0.24684			0.82		
10/21/21 8:00	0.6			1.5			2			0.54			0.26838			0.89		
10/21/21 9:00	0.7			1.5			2			0.57			0.28296			0.94		
10/21/21 10:00	0.7			1.5			2			0.56			0.28134			0.94		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/21/21 11:00	0.7			1.6			2			0.5			0.24786			0.83		
10/21/21 12:00	0.6			1.4			1			0.36			0.17772			0.59		
10/21/21 13:00	0.6			1.5			1			0.51			0.25656			0.86		
10/21/21 14:00	0.7			1.5			1			0.48			0.23802			0.79		
10/21/21 15:00	0.5			1.4			2			0.4			0.19938			0.66		
10/21/21 16:00	0.6			1.4			1			0.53			0.2625			0.88		
10/21/21 17:00	0.6			1.5			1			0.56			0.2796			0.93		
10/21/21 18:00	0.6			1.5			1			0.56			0.27786			0.93		
10/21/21 19:00	0.6			1.5			2			0.56			0.28002			0.93		
10/21/21 20:00	0.6			1.5			1			0.55			0.27666			0.92		
10/21/21 21:00	0.6			1.5			2			0.5			0.25152			0.84		
10/21/21 22:00	0.6			1.6			3			0.36			0.18072			0.6		
10/21/21 23:00	0.5			1.5			4			0.33			0.1662			0.55		
10/22/21 0:00	0.5			1.5			4			0.33			0.16602			0.55		
10/22/21 1:00	0.5			1.5			4			0.33			0.16614			0.55		
10/22/21 2:00	0.5			1.5			4			0.33			0.16614			0.55		
10/22/21 3:00	0.6			1.5			3			0.34			0.17238			0.57		
10/22/21 4:00	0.5			1.5			3			0.35			0.1734			0.58		
10/22/21 5:00	0.5			1.5			3			0.34			0.1719			0.57		
10/22/21 6:00	0.4			1.7			6			0.34			0.17148			0.57		
10/22/21 7:00	0.6			1.1			0			0.43			0.21546			0.72		
10/22/21 8:00	0.6			1.5			2			0.55			0.27294			0.91		
10/22/21 9:00	0.6			1.5			2			0.54			0.27018			0.9		
10/22/21 10:00	0.6			1.5			2			0.56			0.2808			0.94		
10/22/21 11:00	0.6			1.5			2			0.55			0.27684			0.92		
10/22/21 12:00	0.6			1.5			2			0.41			0.20286			0.68		
10/22/21 13:00	0.6			1.5			2			0.39			0.19464			0.65		
10/22/21 14:00	0.6			1.5			2			0.39			0.19434			0.65		
10/22/21 15:00	0.6			1.5			2			0.39			0.19434			0.65		
10/22/21 16:00	0.6			1.5			2			0.43			0.21552			0.72		
10/22/21 17:00	0.6			1.6			2			0.49			0.24474			0.82		
10/22/21 18:00	0.4			1.5			4			0.34			0.16824			0.56		
10/22/21 19:00	0.6			1.5			3			0.36			0.17796			0.59		
10/22/21 20:00	0.6			1.5			3			0.35			0.17436			0.58		
10/22/21 21:00	0.5			1.6			4			0.34			0.17076			0.57		
10/22/21 22:00	0.5			1.6			4			0.34			0.17076			0.57		
10/22/21 23:00	0.6			1.4			2			0.38			0.18912			0.63		
10/23/21 0:00	0.7			1.7			3			0.38			0.19206			0.64		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/23/21 1:00	0.5			1.6			5			0.33			0.16662			0.56		
10/23/21 2:00	0.6			1.3			3			0.34			0.17238			0.57		
10/23/21 3:00	0.6			1.5			3			0.35			0.17316			0.58		
10/23/21 4:00	0.6			1.6			3			0.35			0.17472			0.58		
10/23/21 5:00	0.6			1.4			2			0.42			0.20766			0.69		
10/23/21 6:00	0.7			1.6			2			0.46			0.22836			0.76		
10/23/21 7:00	0.7			1.7			3			0.43			0.21312			0.71		
10/23/21 8:00	0.7			1.4			2			0.53			0.26496			0.88		
10/23/21 9:00	0.7			1.6			2			0.47			0.23322			0.78		
10/23/21 10:00	0.6			1.6			3			0.38			0.18948			0.63		
10/23/21 11:00	0.6			1.6			2			0.38			0.189			0.63		
10/23/21 12:00	0.6			1.4			1			0.55			0.27546			0.92		
10/23/21 13:00	0.7			1.6			2			0.44			0.21882			0.73		
10/23/21 14:00	0.6			1.5			2			0.56			0.2802			0.93		
10/23/21 15:00	0.6			1.5			2			0.54			0.2724			0.91		
10/23/21 16:00	0.6			1.5			2			0.56			0.2802			0.93		
10/23/21 17:00	0.6			1.5			2			0.56			0.27864			0.93		
10/23/21 18:00	0.6			1.8			4			0.36			0.17814			0.59		
10/23/21 19:00	0.7			1.5			3			0.37			0.18504			0.62		
10/23/21 20:00	0.6			1.5			3			0.35			0.17454			0.58		
10/23/21 21:00	0.6			1.5			3			0.35			0.17484			0.58		
10/23/21 22:00	0.6			1.5			3			0.37			0.18474			0.62		
10/23/21 23:00	0.7			1.5			1			0.54			0.27078			0.9		
10/24/21 0:00	0.7			1.6			2			0.47			0.2352			0.78		
10/24/21 1:00	0.5			1.7			5			0.34			0.16896			0.56		
10/24/21 2:00	0.5			1.4			4			0.34			0.16782			0.56		
10/24/21 3:00	0.5			1.6			5			0.34			0.16794			0.56		
10/24/21 4:00	0.5			1.5			5			0.33			0.16572			0.55		
10/24/21 5:00	0.6			1.5			3			0.34			0.1713			0.57		
10/24/21 6:00	0.6			1.6			4			0.34			0.1707			0.57		
10/24/21 7:00	0.6			1.4			2			0.47			0.23664			0.79		
10/24/21 8:00	0.6			1.5			2			0.56			0.27882			0.93		
10/24/21 9:00	0.6			1.5			2			0.56			0.2796			0.93		
10/24/21 10:00	0.7			1.5			2			0.55			0.273			0.91		
10/24/21 11:00	0.7			1.5			2			0.56			0.27996			0.93		
10/24/21 12:00	0.7			1.5			2			0.55			0.27294			0.91		
10/24/21 13:00	0.7			1.5			2			0.56			0.27882			0.93		
10/24/21 14:00	0.7			1.5			2			0.44			0.21774			0.73		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/24/21 15:00	0.7			1.5			2			0.51			0.25446			0.85		
10/24/21 16:00	0.6			1.5			2			0.48			0.23964			0.8		
10/24/21 17:00	0.6			1.5			2			0.54			0.2685			0.9		
10/24/21 18:00	0.6			1.6			3			0.43			0.21342			0.71		
10/24/21 19:00	0.6			1.6			2			0.48			0.23922			0.8		
10/24/21 20:00	0.6			1.5			3			0.37			0.18654			0.62		
10/24/21 21:00	0.6			1.5			3			0.39			0.19422			0.65		
10/24/21 22:00	0.6			1.6			3			0.35			0.17742			0.59		
10/24/21 23:00	0.5			1.5			3			0.35			0.17592			0.59		
10/25/21 0:00	0.7			1.4			3			0.39			0.19632			0.65		
10/25/21 1:00	0.6			1.6			3			0.36			0.17826			0.59		
10/25/21 2:00	0.6			1.5			3			0.35			0.17604			0.59		
10/25/21 3:00	0.6			1.5			3			0.36			0.17802			0.59		
10/25/21 4:00	0.7			1.4			1			0.52			0.25986			0.87		
10/25/21 5:00	0.6			1.5			2			0.55			0.2727			0.91		
10/25/21 6:00	0.6			1.5			2			0.52			0.25986			0.87		
10/25/21 7:00	0.7			1.5			2			0.51			0.25488			0.85		
10/25/21 8:00	0.6			1.5			2			0.54			0.2706			0.9		
10/25/21 9:00	0.6			1.7			3			0.42			0.21096			0.7		
10/25/21 10:00	0.5			1.5			4			0.34			0.16896			0.56		
10/25/21 11:00	0.5			1.5			4			0.33			0.16668			0.56		
10/25/21 12:00	0.5			1.5			4			0.33			0.16716			0.56		
10/25/21 13:00	0.5			1.5			3			0.34			0.16932			0.56		
10/25/21 14:00	0.5			1.5			3			0.34			0.16884			0.56		
10/25/21 15:00	0.5			1.5			3			0.33			0.16698			0.56		
10/25/21 16:00	0.6			1.3			1			0.47			0.23382			0.78		
10/25/21 17:00	0.6			1.5			2			0.45			0.22302			0.74		
10/25/21 18:00	0.7			1.7			3			0.44			0.21798			0.73		
10/25/21 19:00	0.7			1.4			2			0.5			0.24798			0.83		
10/25/21 20:00	0.7			1.5			2			0.54			0.27066			0.9		
10/25/21 21:00	0.7			1.7			4			0.36			0.1818			0.61		
10/25/21 22:00	0.5			1.6			5			0.34			0.16836			0.56		
10/25/21 23:00	0.6			1.6			4			0.34			0.17244			0.57		
10/26/21 0:00	0.5			1.5			5			0.34			0.16782			0.56		
10/26/21 1:00	0.5			1.6			4			0.34			0.16974			0.57		
10/26/21 2:00	0.5			1.7			5			0.34			0.17004			0.57		
10/26/21 3:00	0.6			1.7			4			0.35			0.17322			0.58		
10/26/21 4:00	0.5			1.5			5			0.34			0.1689			0.56		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/26/21 5:00	0.6			1.4			1			0.47			0.2349			0.78		
10/26/21 6:00	0.6			1.7			4			0.36			0.18126			0.6		
10/26/21 7:00	0.6			1.4			3			0.4			0.2004			0.67		
10/26/21 8:00	0.6			1.7			4			0.35			0.17472			0.58		
10/26/21 9:00	0.5			1.5			3			0.35			0.17412			0.58		
10/26/21 10:00	0.5			1.5			3			0.35			0.17412			0.58		
10/26/21 11:00	0.6			1.6			3			0.36			0.18144			0.6		
10/26/21 12:00	0.5			1.5			3			0.35			0.17406			0.58		
10/26/21 13:00	0.5			1.6			4			0.34			0.17118			0.57		
10/26/21 14:00	0.6			1.5			2			0.37			0.1851			0.62		
10/26/21 15:00	0.5			1.6			3			0.34			0.17232			0.57		
10/26/21 16:00	0.6			1.5			2			0.38			0.19224			0.64		
10/26/21 17:00	0.5			1.7			4			0.35			0.17706			0.59		
10/26/21 18:00	0.6			1.4			1			0.45			0.22392			0.75		
10/26/21 19:00	0.7			1.5			2			0.45			0.22746			0.76		
10/26/21 20:00	0.7			1.5			2			0.49			0.24294			0.81		
10/26/21 21:00	0.7			1.6			2			0.48			0.23928			0.8		
10/26/21 22:00	0.7			1.5			2			0.49			0.24738			0.82		
10/26/21 23:00	0.6			1.6			4			0.35			0.17538			0.58		
10/27/21 0:00	0.6			1.5			4			0.35			0.17484			0.58		
10/27/21 1:00	0.5			1.6			5			0.34			0.16992			0.57		
10/27/21 2:00	0.5			1.5			4			0.34			0.168			0.56		
10/27/21 3:00	0.6			1.5			4			0.34			0.171			0.57		
10/27/21 4:00	0.6			1.6			4			0.35			0.17262			0.58		
10/27/21 5:00	0.6			1.5			3			0.41			0.20424			0.68		
10/27/21 6:00	0.7			1.6			2			0.52			0.25752			0.86		
10/27/21 7:00	0.6			1.8			4			0.37			0.18678			0.62		
10/27/21 8:00	0.4			1.5			5			0.33			0.1665			0.56		
10/27/21 9:00	0.4			1.5			4			0.33			0.16662			0.56		
10/27/21 10:00	0.4			1.5			4			0.33			0.16644			0.55		
10/27/21 11:00	0.4			1.5			4			0.33			0.1665			0.56		
10/27/21 12:00	0.4			1.5			4			0.33			0.16638			0.55		
10/27/21 13:00	0.5			1.5			3			0.33			0.16704			0.56		
10/27/21 14:00	0.5			1.5			3			0.33			0.16662			0.56		
10/27/21 15:00	0.5			1.3			2			0.37			0.18312			0.61		
10/27/21 16:00	0.6			1.4			0			0.52			0.2577			0.86		
10/27/21 17:00	0.6			1.5			1			0.56			0.27954			0.93		
10/27/21 18:00	0.7			1.5			2			0.52			0.25782			0.86		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/27/21 19:00	0.6			1.5			2			0.54			0.26898			0.9		
10/27/21 20:00	0.7			1.5			2			0.49			0.24714			0.82		
10/27/21 21:00	0.7			1.5			2			0.5			0.25242			0.84		
10/27/21 22:00	0.6			1.7			4			0.37			0.18486			0.62		
10/27/21 23:00	0.6			1.5			4			0.35			0.17538			0.58		
10/28/21 0:00	0.6			1.5			4			0.35			0.17514			0.58		
10/28/21 1:00	0.6			1.5			4			0.35			0.17484			0.58		
10/28/21 2:00	0.6			1.5			3			0.35			0.1749			0.58		
10/28/21 3:00	0.6			1.5			4			0.35			0.17502			0.58		
10/28/21 4:00	0.6			1.4			3			0.38			0.19122			0.64		
10/28/21 5:00	0.7			1.6			2			0.46			0.22902			0.76		
10/28/21 6:00	0.8			1.6			2			0.47			0.2337			0.78		
10/28/21 7:00	0.6			1.7			4			0.35			0.17304			0.58		
10/28/21 8:00	0.5			1.5			4			0.34			0.16776			0.56		
10/28/21 9:00	0.5			1.5			4			0.33			0.16662			0.56		
10/28/21 10:00	0.5			1.5			3			0.34			0.17058			0.57		
10/28/21 11:00	0.6			1.6			2			0.35			0.17322			0.58		
10/28/21 12:00	0.6			1.5			2			0.35			0.174			0.58		
10/28/21 13:00	0.5			1.5			3			0.33			0.16644			0.55		
10/28/21 14:00	0.5			1.5			2			0.34			0.16764			0.56		
10/28/21 15:00	0.5			1.5			2			0.34			0.16986			0.57		
10/28/21 16:00	0.6			1.4			1			0.5			0.25068			0.84		
10/28/21 17:00	0.6			1.5			1			0.56			0.27966			0.93		
10/28/21 18:00	0.8			1.5			1			0.53			0.26538			0.88		
10/28/21 19:00	0.7			1.5			2			0.55			0.27504			0.92		
10/28/21 20:00	0.7			1.5			2			0.53			0.26388			0.88		
10/28/21 21:00	0.7			1.7			2			0.47			0.23406			0.78		
10/28/21 22:00	0.6			1.5			3			0.35			0.17448			0.58		
10/28/21 23:00	0.6			1.6			4			0.34			0.17184			0.57		
10/29/21 0:00	0.6			1.6			4			0.34			0.17016			0.57		
10/29/21 1:00	0.6			1.6			4			0.34			0.16968			0.57		
10/29/21 2:00	0.6			1.4			4			0.33			0.1674			0.56		
10/29/21 3:00	0.6			1.6			3			0.35			0.17496			0.58		
10/29/21 4:00	0.6			1.5			4			0.35			0.17484			0.58		
10/29/21 5:00	0.7			1.4			3			0.42			0.21078			0.7		
10/29/21 6:00	0.8			1.8			3			0.46			0.23016			0.77		
10/29/21 7:00	0.8			1.8			5			0.34			0.16998			0.57		
10/29/21 8:00	0.7			1.5			5			0.33			0.16626			0.55		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/29/21 9:00	0.6			1.5			4			0.33			0.16632			0.55		
10/29/21 10:00	0.5			1.5			3			0.34			0.16758			0.56		
10/29/21 11:00	0.5			1.5			3			0.33			0.16662			0.56		
10/29/21 12:00	0.5			1.5			3			0.33			0.16644			0.55		
10/29/21 13:00	0.5			1.4			2			0.34			0.16908			0.56		
10/29/21 14:00	0.5			1.6			2			0.33			0.16656			0.56		
10/29/21 15:00	0.6			1.3			1			0.42			0.20814			0.69		
10/29/21 16:00	0.7			1.4			0			0.53			0.2667			0.89		
10/29/21 17:00	0.7			1.5			1			0.54			0.27204			0.91		
10/29/21 18:00	0.8			1.5			2			0.47			0.23334			0.78		
10/29/21 19:00	0.8			1.5			1			0.55			0.27288			0.91		
10/29/21 20:00	0.8			1.5			2			0.52			0.25956			0.87		
10/29/21 21:00	0.8			1.6			2			0.46			0.23166			0.77		
10/29/21 22:00	0.8			1.5			1			0.45			0.22554			0.75		
10/29/21 23:00	0.7			1.6			3			0.4			0.20082			0.67		
10/30/21 0:00	0.7			1.5			2			0.38			0.1893			0.63		
10/30/21 1:00	0.6			1.5			3			0.34			0.17184			0.57		
10/30/21 2:00	0.5			1.4			3			0.34			0.16794			0.56		
10/30/21 3:00	0.6			1.6			3			0.35			0.17268			0.58		
10/30/21 4:00	0.6			1.5			3			0.34			0.17226			0.57		
10/30/21 5:00	0.6			1.4			2			0.39			0.19338			0.64		
10/30/21 6:00	0.5			1.7			4			0.34			0.1704			0.57		
10/30/21 7:00	0.5			1.5			4			0.34			0.16758			0.56		
10/30/21 8:00	0.5			1.5			4			0.33			0.16644			0.55		
10/30/21 9:00	0.5			1.5			4			0.33			0.16596			0.55		
10/30/21 10:00	0.5			1.5			4			0.33			0.16626			0.55		
10/30/21 11:00	0.5			1.5			3			0.33			0.16638			0.55		
10/30/21 12:00	0.5			1.5			3			0.33			0.16632			0.55		
10/30/21 13:00	0.5			1.5			3			0.33			0.16638			0.55		
10/30/21 14:00	0.4			1.5			3			0.33			0.16626			0.55		
10/30/21 15:00	0.5			1.3			2			0.41			0.20424			0.68		
10/30/21 16:00	0.5			1.5			3			0.37			0.1839			0.61		
10/30/21 17:00	0.5			1.6			2			0.35			0.17556			0.59		
10/30/21 18:00	0.5			1.5			4			0.33			0.16704			0.56		
10/30/21 19:00	0.5			1.6			3			0.34			0.17136			0.57		
10/30/21 20:00	0.5			1.4			4			0.34			0.1692			0.56		
10/30/21 21:00	0.5			1.6			4			0.34			0.16836			0.56		
10/30/21 22:00	0.5			1.5			4			0.34			0.16788			0.56		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/30/21 23:00	0.6			1.6			3			0.34			0.17238			0.57		
10/31/21 0:00	0.5			1.5			4			0.34			0.16884			0.56		
10/31/21 1:00	0.5			1.5			4			0.34			0.16896			0.56		
10/31/21 2:00	0.5			1.5			4			0.34			0.16878			0.56		
10/31/21 3:00	0.6			1.5			4			0.34			0.1689			0.56		
10/31/21 4:00	0.5			1.5			4			0.34			0.16872			0.56		
10/31/21 5:00	0.6			1.5			3			0.35			0.17412			0.58		
10/31/21 6:00	0.6			1.6			3			0.37			0.18294			0.61		
10/31/21 7:00	0.5			1.8			4			0.34			0.16926			0.56		
10/31/21 8:00	0.5			1.6			4			0.34			0.16848			0.56		
10/31/21 9:00	0.5			1.6			4			0.34			0.1701			0.57		
10/31/21 10:00	0.4			1.5			4			0.33			0.16626			0.55		
10/31/21 11:00	0.4			1.5			4			0.33			0.16596			0.55		
10/31/21 12:00	0.4			1.5			4			0.33			0.16614			0.55		
10/31/21 13:00	0.4			1.5			3			0.33			0.16644			0.55		
10/31/21 14:00	0.4			1.5			3			0.33			0.16626			0.55		
10/31/21 15:00	0.5			1.4			3			0.36			0.1812			0.6		
10/31/21 16:00	0.4			1.5			3			0.33			0.16674			0.56		
10/31/21 17:00	0.4			1.5			4			0.33			0.16614			0.55		
10/31/21 18:00	0.4			1.5			4			0.33			0.16602			0.55		
10/31/21 19:00	0.5			1.5			5			0.33			0.16548			0.55		
10/31/21 20:00	0.6			1.5			5			0.33			0.16542			0.55		
10/31/21 21:00	0.6			1.5			5			0.33			0.16566			0.55		
10/31/21 22:00	0.6			1.5			4			0.33			0.16638			0.55		
10/31/21 23:00	0.6			1.6			4			0.34			0.1686			0.56		
11/01/21 0:00	0.5			1.6			4			0.33			0.16716			0.56		
11/01/21 1:00	0.6			1.5			4			0.34			0.1701			0.57		
11/01/21 2:00	0.5			1.5			4			0.33			0.16644			0.55		
11/01/21 3:00	0.6			1.5			3			0.35			0.17268			0.58		
11/01/21 4:00	0.6			1.5			3			0.4			0.198			0.66		
11/01/21 5:00	0.6			1.7			4			0.34			0.1713			0.57		
11/01/21 6:00	0.7			1.4			1			0.52			0.25998			0.87		
11/01/21 7:00	0.7			1.6			3			0.41			0.2049			0.68		
11/01/21 8:00	0.6			1.5			3			0.35			0.17262			0.58		
11/01/21 9:00	0.7			1.4			1			0.43			0.21306			0.71		
11/01/21 10:00	0.7			1.6			2			0.37			0.18342			0.61		
11/01/21 11:00	0.7			1.4			1			0.43			0.21564			0.72		
11/01/21 12:00	0.7			1.5			2			0.46			0.23082			0.77		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/01/21 13:00	0.7			1.5			1			0.56			0.27822			0.93		
11/01/21 14:00	0.7			1.5			2			0.48			0.23922			0.8		
11/01/21 15:00	0.7			1.5			3			0.38			0.19062			0.64		
11/01/21 16:00	0.7			1.5			2			0.42			0.2106			0.7		
11/01/21 17:00	0.7			1.5			1			0.53			0.26652			0.89		
11/01/21 18:00	0.7			1.5			2			0.52			0.2595			0.87		
11/01/21 19:00	0.7			1.5			2			0.54			0.27024			0.9		
11/01/21 20:00	0.6			1.5			2			0.54			0.27168			0.91		
11/01/21 21:00	0.7			1.5			2			0.52			0.26238			0.87		
11/01/21 22:00	0.7			1.6			3			0.43			0.21648			0.72		
11/01/21 23:00	0.6			1.5			3			0.35			0.17652			0.59		
11/02/21 0:00	0.6			1.5			3			0.35			0.17598			0.59		
11/02/21 1:00	0.6			1.6			4			0.35			0.1737			0.58		
11/02/21 2:00	0.5			1.4			4			0.34			0.16776			0.56		
11/02/21 3:00	0.6			1.5			3			0.34			0.17232			0.57		
11/02/21 4:00	0.6			1.6			3			0.34			0.17244			0.57		
11/02/21 5:00	0.6			1.4			3			0.36			0.18192			0.61		
11/02/21 6:00	0.7			1.5			1			0.47			0.23676			0.79		
11/02/21 7:00	0.6			1.8			4			0.37			0.18462			0.62		
11/02/21 8:00	0.5			1.5			5			0.33			0.16578			0.55		
11/02/21 9:00	0.5			1.5			4			0.34			0.16794			0.56		
11/02/21 10:00	0.5			1.5			3			0.34			0.16866			0.56		
11/02/21 11:00	0.5			1.5			3			0.34			0.16908			0.56		
11/02/21 12:00	0.5			1.5			3			0.34			0.16932			0.56		
11/02/21 13:00	0.5			1.5			3			0.33			0.16566			0.55		
11/02/21 14:00	0.5			1.5			3			0.33			0.16584			0.55		
11/02/21 15:00	0.5			1.5			2			0.34			0.16878			0.56		
11/02/21 16:00	0.6			1.4			1			0.45			0.2262			0.75		
11/02/21 17:00	0.6			1.5			1			0.54			0.26856			0.9		
11/02/21 18:00	0.6			1.5			2			0.51			0.25638			0.85		
11/02/21 19:00	0.6			1.5			1			0.56			0.279			0.93		
11/02/21 20:00	0.6			1.5			2			0.55			0.27486			0.92		
11/02/21 21:00	0.7			1.5			2			0.5			0.24822			0.83		
11/02/21 22:00	0.7			1.5			2			0.52			0.25992			0.87		
11/02/21 23:00	0.8			1.5			2			0.44			0.22056			0.74		
11/03/21 0:00	0.8			1.5			2			0.43			0.21462			0.72		
11/03/21 1:00	0.8			1.5			3			0.42			0.2088			0.7		
11/03/21 2:00	0.8			1.5			3			0.42			0.2085			0.7		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/03/21 3:00	0.9			1.5			3			0.43			0.21288			0.71		
11/03/21 4:00	0.8			1.5			2			0.45			0.22746			0.76		
11/03/21 5:00	0.7			1.5			2			0.5			0.252			0.84		
11/03/21 6:00	0.8			1.5			2			0.5			0.252			0.84		
11/03/21 7:00	0.7			1.8			4			0.39			0.19344			0.64		
11/03/21 8:00	0.6			1.6			4			0.34			0.16944			0.56		
11/03/21 9:00	0.5			1.5			4			0.33			0.16536			0.55		
11/03/21 10:00	0.5			1.5			4			0.33			0.16686			0.56		
11/03/21 11:00	0.5			1.5			3			0.33			0.1668			0.56		
11/03/21 12:00	0.5			1.5			3			0.34			0.16848			0.56		
11/03/21 13:00	0.5			1.5			2			0.34			0.16986			0.57		
11/03/21 14:00	0.5			1.5			2			0.34			0.16926			0.56		
11/03/21 15:00	0.6			1.3			2			0.4			0.20172			0.67		
11/03/21 16:00	0.6			1.5			1			0.45			0.22452			0.75		
11/03/21 17:00	0.6			1.5			1			0.55			0.27474			0.92		
11/03/21 18:00	0.6			1.5			1			0.52			0.26088			0.87		
11/03/21 19:00	0.6			1.5			2			0.54			0.27168			0.91		
11/03/21 20:00	0.7			1.5			2			0.54			0.27066			0.9		
11/03/21 21:00	0.8			1.5			2			0.5			0.25032			0.83		
11/03/21 22:00	0.7			1.6			3			0.42			0.20976			0.7		
11/03/21 23:00	0.6			1.5			3			0.35			0.17358			0.58		
11/04/21 0:00	0.6			1.6			4			0.34			0.1713			0.57		
11/04/21 1:00	0.5			1.5			4			0.33			0.16614			0.55		
11/04/21 2:00	0.6			1.6			3			0.35			0.17364			0.58		
11/04/21 3:00	0.8			1.2			1			0.46			0.22896			0.76		
11/04/21 4:00	0.7			1.5			3			0.4			0.19884			0.66		
11/04/21 5:00	0.7			1.6			2			0.5			0.252			0.84		
11/04/21 6:00	0.6			1.5			2			0.53			0.26274			0.88		
11/04/21 7:00	0.5			1.8			4			0.38			0.1899			0.63		
11/04/21 8:00	0.5			1.5			3			0.34			0.1716			0.57		
11/04/21 9:00	0.6			1.5			2			0.43			0.21504			0.72		
11/04/21 10:00	0.4			1.4			5			0.33			0.16572			0.55		
11/04/21 11:00	0.4			1.5			3			0.33			0.1665			0.56		
11/04/21 12:00	0.4			1.5			4			0.33			0.16596			0.55		
11/04/21 13:00	0.4			1.5			3			0.34			0.16776			0.56		
11/04/21 14:00	0.4			1.6			4			0.33			0.16584			0.55		
11/04/21 15:00	0.5			1.3			2			0.41			0.2043			0.68		
11/04/21 16:00	0.6			1.6			2			0.36			0.1821			0.61		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/04/21 17:00	0.5			1.6			3			0.34			0.1692			0.56		
11/04/21 18:00	0.5			1.5			3			0.34			0.17124			0.57		
11/04/21 19:00	0.6			1.6			4			0.34			0.17094			0.57		
11/04/21 20:00	0.6			1.6			4			0.34			0.16944			0.56		
11/04/21 21:00	0.6			1.5			5			0.33			0.16518			0.55		
11/04/21 22:00	0.5			1.5			5			0.33			0.16548			0.55		
11/04/21 23:00	0.5			1.5			5			0.33			0.16482			0.55		
11/05/21 0:00	0.5			1.5			5			0.33			0.16488			0.55		
11/05/21 1:00	0.4			1.6			5			0.33			0.16452			0.55		
11/05/21 2:00	0.5			1.5			5			0.33			0.16524			0.55		
11/05/21 3:00	0.6			1.5			3			0.34			0.17052			0.57		
11/05/21 4:00	0.6			1.5			3			0.37			0.18666			0.62		
11/05/21 5:00	0.7			1.6			2			0.47			0.23616			0.79		
11/05/21 6:00	0.7			1.5			2			0.5			0.25002			0.83		
11/05/21 7:00	0.7			1.8			3			0.43			0.21384			0.71		
11/05/21 8:00	0.6			1.6			5			0.34			0.16962			0.57		
11/05/21 9:00	0.6			1.6			6			0.33			0.1647			0.55		
11/05/21 10:00	0.5			1.5			4			0.33			0.16494			0.55		
11/05/21 11:00	0.5			1.5			4			0.33			0.16542			0.55		
11/05/21 12:00	0.4			1.5			4			0.33			0.16566			0.55		
11/05/21 13:00	0.4			1.5			4			0.33			0.16584			0.55		
11/05/21 14:00	0.6			1.3			2			0.39			0.19542			0.65		
11/05/21 15:00	0.6			1.5			1			0.5			0.2475			0.83		
11/05/21 16:00	0.7			1.5			2			0.45			0.22518			0.75		
11/05/21 17:00	0.7			1.5			2			0.46			0.22812			0.76		
11/05/21 18:00	0.6			1.6			3			0.39			0.19458			0.65		
11/05/21 19:00	0.7			1.4			1			0.44			0.2187			0.73		
11/05/21 20:00	0.7			1.6			2			0.45			0.22464			0.75		
11/05/21 21:00	0.7			1.6			2			0.49			0.24684			0.82		
11/05/21 22:00	0.7			1.6			3			0.4			0.19968			0.67		
11/05/21 23:00	0.7			1.5			2			0.45			0.22662			0.76		
11/06/21 0:00	0.6			1.6			4			0.36			0.17766			0.59		
11/06/21 1:00	0.8			1.4			2			0.42			0.21144			0.7		
11/06/21 2:00	0.6			1.7			4			0.36			0.18072			0.6		
11/06/21 3:00	0.6			1.5			4			0.35			0.17454			0.58		
11/06/21 4:00	0.7			1.4			3			0.38			0.18966			0.63		
11/06/21 5:00	0.8			1.5			2			0.46			0.23028			0.77		
11/06/21 6:00	0.7			1.5			2			0.52			0.26046			0.87		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/06/21 7:00	0.6			1.7			3			0.43			0.21612			0.72		
11/06/21 8:00	0.6			1.7			3			0.4			0.20184			0.67		
11/06/21 9:00	0.5			1.6			5			0.34			0.1704			0.57		
11/06/21 10:00	0.5			1.5			4			0.34			0.16806			0.56		
11/06/21 11:00	0.5			1.5			4			0.34			0.16812			0.56		
11/06/21 12:00	0.5			1.5			5			0.33			0.16554			0.55		
11/06/21 13:00	0.5			1.5			5			0.33			0.16548			0.55		
11/06/21 14:00	0.4			1.5			5			0.33			0.1653			0.55		
11/06/21 15:00	0.5			1.3			3			0.38			0.19182			0.64		
11/06/21 16:00	0.6			1.5			1			0.46			0.23142			0.77		
11/06/21 17:00	0.6			1.5			1			0.53			0.2631			0.88		
11/06/21 18:00	0.6			1.6			3			0.41			0.20724			0.69		
11/06/21 19:00	0.6			1.5			1			0.55			0.27516			0.92		
11/06/21 20:00	0.7			1.5			2			0.51			0.2544			0.85		
11/06/21 21:00	0.7			1.7			3			0.46			0.22974			0.77		
11/06/21 22:00	0.6			1.5			4			0.35			0.17418			0.58		
11/06/21 23:00	0.6			1.5			4			0.35			0.17364			0.58		
11/07/21 0:00	0.4			1.6			6			0.33			0.16668			0.56		
11/07/21 1:00	0.4			1.5			6			0.33			0.16608			0.55		
11/07/21 2:00	0.5			1.4			5			0.33			0.16698			0.56		
11/07/21 3:00	0.5			1.6			6			0.34			0.16752			0.56		
11/07/21 4:00	0.4			1.5			6			0.34			0.16764			0.56		
11/07/21 5:00	0.4			1.5			5			0.34			0.16824			0.56		
11/07/21 6:00	0.6			1.5			2			0.46			0.2304			0.77		
11/07/21 7:00	0.7			1.9			3			0.5			0.2475			0.83		
11/07/21 8:00	0.4			2			6			0.33			0.16668			0.56		
11/07/21 9:00	0.4			1.6			6			0.33			0.16668			0.56		
11/07/21 10:00	0.4			1.5			5			0.33			0.1659			0.55		
11/07/21 11:00	0.4			1.5			5			0.33			0.16524			0.55		
11/07/21 12:00	0.4			1.5			5			0.33			0.16392			0.55		
11/07/21 13:00	0.4			1.5			5			0.33			0.1641			0.55		
11/07/21 14:00	0.5			1.5			3			0.33			0.1674			0.56		
11/07/21 15:00	0.6			1.3			2			0.44			0.21762			0.73		
11/07/21 16:00	0.7			1.5			2			0.45			0.22728			0.76		
11/07/21 17:00	0.7			1.7			3			0.41			0.20418			0.68		
11/07/21 18:00	0.6			1.5			3			0.39			0.19266			0.64		
11/07/21 19:00	0.7			1.6			2			0.45			0.22662			0.76		
11/07/21 20:00	0.7			1.8			5			0.36			0.18036			0.6		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/07/21 21:00	0.8			1.5			5			0.34			0.1713			0.57		
11/07/21 22:00	0.7			1.5			5			0.34			0.17148			0.57		
11/07/21 23:00	0.5			1.7			6			0.33			0.16524			0.55		
11/08/21 0:00	0.5			1.6			6			0.33			0.1665			0.56		
11/08/21 1:00	0.6			1.5			4			0.34			0.17238			0.57		
11/08/21 2:00	0.7			1.4			2			0.39			0.19314			0.64		
11/08/21 3:00	0.8			1.6			2			0.54			0.26838			0.89		
11/08/21 4:00	0.8			1.5			2			0.54			0.27012			0.9		
11/08/21 5:00	0.7			1.5			2			0.55			0.27714			0.92		
11/08/21 6:00	0.7			1.5			2			0.55			0.27462			0.92		
11/08/21 7:00	0.6			1.9			5			0.42			0.21198			0.71		
11/08/21 8:00	0.5			1.6			6			0.33			0.16572			0.55		
11/08/21 9:00	0.5			1.4			6			0.33			0.16578			0.55		
11/08/21 10:00	0.5			1.3			6			0.33			0.16458			0.55		
11/08/21 11:00	0.5			1.4			4			0.33			0.16494			0.55		
11/08/21 12:00	0.5			1.4			4			0.33			0.16488			0.55		
11/08/21 13:00	0.5			1.4			4			0.33			0.165			0.55		
11/08/21 14:00	0.5			1.4			4			0.33			0.16482			0.55		
11/08/21 15:00	0.6			1.3			1			0.45			0.22746			0.76		
11/08/21 16:00	1			1.6			1			0.55			0.27558			0.92		
11/08/21 17:00	1.3			1.5			2			0.58			0.28956			0.97		
11/08/21 18:00	1.3			1.5			2			0.58			0.2892			0.96		
11/08/21 19:00	1.2			1.5			2			0.56			0.28026			0.93		
11/08/21 20:00	0.7			1.5			2			0.53			0.26496			0.88		
11/08/21 21:00	0.7			1.6			2			0.5			0.2481			0.83		
11/08/21 22:00	0.7			1.6			3			0.44			0.21768			0.73		
11/08/21 23:00	0.6			1.5			4			0.35			0.17322			0.58		
11/09/21 0:00	0.6			1.5			4			0.35			0.17292			0.58		
11/09/21 1:00	0.6			1.5			4			0.35			0.17256			0.58		
11/09/21 2:00	0.5			1.5			4			0.34			0.17016			0.57		
11/09/21 3:00	0.5			1.5			4			0.33			0.16614			0.55		
11/09/21 4:00	0.6			1.5			3			0.34			0.1722			0.57		
11/09/21 5:00	0.6			1.4			3			0.37			0.18624			0.62		
11/09/21 6:00	0.6			1.6			3			0.37			0.18282			0.61		
11/09/21 7:00	0.6			1.8			3			0.42			0.21156			0.71		
11/09/21 8:00	0.5			1.6			4			0.34			0.16896			0.56		
11/09/21 9:00	0.5			1.5			5			0.33			0.16644			0.55		
11/09/21 10:00	0.5			1.6			4			0.34			0.17148			0.57		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/09/21 11:00	0.5			1.6			5			0.34			0.16818			0.56		
11/09/21 12:00	0.5			1.5			4			0.34			0.16776			0.56		
11/09/21 13:00	0.5			1.5			4			0.34			0.16806			0.56		
11/09/21 14:00	0.5			1.5			3			0.35			0.17442			0.58		
11/09/21 15:00	0.6			1.5			3			0.39			0.19572			0.65		
11/09/21 16:00	0.6			1.5			2			0.4			0.20076			0.67		
11/09/21 17:00	0.7			1.5			2			0.46			0.2322			0.77		
11/09/21 18:00	0.6			1.5			2			0.55			0.27732			0.92		
11/09/21 19:00	0.6			1.5			2			0.54			0.2715			0.91		
11/09/21 20:00	0.7			1.5			2			0.53			0.2673			0.89		
11/09/21 21:00	0.6			1.7			3			0.4			0.19902			0.66		
11/09/21 22:00	0.6			1.5			4			0.35			0.17442			0.58		
11/09/21 23:00	0.6			1.6			4			0.34			0.1722			0.57		
11/10/21 0:00	0.5			1.7			5			0.34			0.16794			0.56		
11/10/21 1:00	0.5			1.5			5			0.33			0.1665			0.56		
11/10/21 2:00	0.4			1.5			5			0.33			0.16656			0.56		
11/10/21 3:00	0.5			1.5			5			0.33			0.16608			0.55		
11/10/21 4:00	0.4			1.5			5			0.33			0.16608			0.55		
11/10/21 5:00	0.6			1.3			2			0.43			0.21402			0.71		
11/10/21 6:00	0.7			1.5			2			0.46			0.22914			0.76		
11/10/21 7:00	0.6			1.8			3			0.46			0.22914			0.76		
11/10/21 8:00	0.4			1.5			5			0.33			0.1659			0.55		
11/10/21 9:00	0.5			1.6			4			0.34			0.16962			0.57		
11/10/21 10:00	0.5			1.6			3			0.34			0.17166			0.57		
11/10/21 11:00	0.4			1.5			4			0.33			0.16704			0.56		
11/10/21 12:00	0.4			1.6			4			0.33			0.16656			0.56		
11/10/21 13:00	0.4			1.5			4			0.33			0.1665			0.56		
11/10/21 14:00	0.4			1.5			4			0.33			0.16626			0.55		
11/10/21 15:00	0.4			1.5			4			0.33			0.16704			0.56		
11/10/21 16:00	0.5			1.5			2			0.34			0.17118			0.57		
11/10/21 17:00	0.5			1.6			3			0.35			0.1743			0.58		
11/10/21 18:00	0.6			1.5			3			0.35			0.17394			0.58		
11/10/21 19:00	0.6			1.5			3			0.35			0.17412			0.58		
11/10/21 20:00	0.6			1.5			3			0.35			0.17514			0.58		
11/10/21 21:00	0.6			1.8			3			0.38			0.18798			0.63		
11/10/21 22:00	0.6			1.6			3			0.35			0.17526			0.58		
11/10/21 23:00	0.6			1.5			4			0.35			0.17406			0.58		
11/11/21 0:00	0.5			1.7			4			0.34			0.1707			0.57		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/11/21 1:00	0.6			1.5			4			0.35			0.17406			0.58		
11/11/21 2:00	0.5			1.7			6			0.33			0.16566			0.55		
11/11/21 3:00	0.7			1.7			5			0.33			0.1665			0.56		
11/11/21 4:00	0.6			1.5			4			0.35			0.17292			0.58		
11/11/21 5:00	0.6			1.5			4			0.35			0.17478			0.58		
11/11/21 6:00	0.6			1.5			4			0.35			0.17388			0.58		
11/11/21 7:00	0.6			1.6			5			0.35			0.1734			0.58		
11/11/21 8:00	0.6			1.5			4			0.35			0.1734			0.58		
11/11/21 9:00	0.5			1.5			4			0.35			0.174			0.58		
11/11/21 10:00	0.5			1.5			4			0.35			0.17364			0.58		
11/11/21 11:00	0.4			1.6			5			0.33			0.16698			0.56		
11/11/21 12:00	0.4			1.5			4			0.33			0.1674			0.56		
11/11/21 13:00	0.5			1.5			3			0.34			0.16818			0.56		
11/11/21 14:00	0.5			1.5			3			0.34			0.16776			0.56		
11/11/21 15:00	0.6			1.3			2			0.38			0.19074			0.64		
11/11/21 16:00	0.9			1.5			1			0.46			0.2286			0.76		
11/11/21 17:00	1.5			1.5			2			0.58			0.29064			0.97		
11/11/21 18:00	1.5			1.5			2			0.58			0.29142			0.97		
11/11/21 19:00	1.5			1.5			2			0.58			0.2922			0.97		
11/11/21 20:00	1.6			1.5			2			0.59			0.2928			0.98		
11/11/21 21:00	1.6			1.5			2			0.59			0.29322			0.98		
11/11/21 22:00	1.2			1.6			3			0.49			0.24456			0.82		
11/11/21 23:00	0.6			1.5			3			0.36			0.17988			0.6		
11/12/21 0:00	0.5			1.6			5			0.34			0.16812			0.56		
11/12/21 1:00	0.5			1.5			5			0.33			0.16596			0.55		
11/12/21 2:00	0.5			1.5			5			0.33			0.16578			0.55		
11/12/21 3:00	0.6			1.6			6			0.33			0.16566			0.55		
11/12/21 4:00	0.5			1.5			6			0.33			0.16662			0.56		
11/12/21 5:00	0.6			1.5			3			0.35			0.174			0.58		
11/12/21 6:00	0.6			1.5			4			0.35			0.1743			0.58		
11/12/21 7:00	0.5			1.7			5			0.34			0.1686			0.56		
11/12/21 8:00	0.5			1.6			5			0.34			0.1686			0.56		
11/12/21 9:00	0.5			1.5			5			0.33			0.1662			0.55		
11/12/21 10:00	0.4			1.5			4			0.33			0.16644			0.55		
11/12/21 11:00	0.4			1.5			4			0.33			0.16662			0.56		
11/12/21 12:00	0.4			1.6			4			0.33			0.16638			0.55		
11/12/21 13:00	0.4			1.5			4			0.33			0.16632			0.55		
11/12/21 14:00	0.5			1.5			3			0.34			0.16854			0.56		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/12/21 15:00	0.6			1.5			2			0.37			0.18426			0.61		
11/12/21 16:00	0.5			1.7			3			0.34			0.17148			0.57		
11/12/21 17:00	0.6			1.6			4			0.35			0.17274			0.58		
11/12/21 18:00	0.5			1.6			5			0.33			0.16662			0.56		
11/12/21 19:00	0.6			1.5			3			0.35			0.17388			0.58		
11/12/21 20:00	0.6			1.5			3			0.35			0.1746			0.58		
11/12/21 21:00	0.7			1.5			3			0.39			0.195			0.65		
11/12/21 22:00	0.6			1.7			5			0.34			0.17064			0.57		
11/12/21 23:00	0.5			1.6			5			0.33			0.16644			0.55		
11/13/21 0:00	0.5			1.6			5			0.34			0.16794			0.56		
11/13/21 1:00	0.5			1.6			5			0.33			0.16746			0.56		
11/13/21 2:00	0.6			1.5			3			0.35			0.17418			0.58		
11/13/21 3:00	0.6			1.5			4			0.35			0.17448			0.58		
11/13/21 4:00	0.7			1.6			3			0.37			0.18444			0.61		
11/13/21 5:00	0.7			1.4			2			0.43			0.21618			0.72		
11/13/21 6:00	0.7			1.5			2			0.56			0.27942			0.93		
11/13/21 7:00	0.7			1.5			2			0.56			0.2793			0.93		
11/13/21 8:00	0.7			1.5			2			0.56			0.279			0.93		
11/13/21 9:00	0.7			1.5			2			0.56			0.27918			0.93		
11/13/21 10:00	0.7			1.6			3			0.45			0.22482			0.75		
11/13/21 11:00	0.6			1.6			3			0.36			0.18102			0.6		
11/13/21 12:00	0.5			1.4			4			0.34			0.17016			0.57		
11/13/21 13:00	0.5			1.6			4			0.34			0.16818			0.56		
11/13/21 14:00	0.5			1.5			4			0.33			0.1674			0.56		
11/13/21 15:00	0.6			1.4			2			0.36			0.1824			0.61		
11/13/21 16:00	0.7			1.5			1			0.53			0.2664			0.89		
11/13/21 17:00	0.7			1.6			3			0.39			0.1929			0.64		
11/13/21 18:00	0.7			1.5			3			0.39			0.19494			0.65		
11/13/21 19:00	0.8			1.4			2			0.49			0.24456			0.82		
11/13/21 20:00	0.8			1.5			2			0.47			0.237			0.79		
11/13/21 21:00	0.7			1.7			4			0.37			0.18696			0.62		
11/13/21 22:00	0.6			1.5			4			0.35			0.17508			0.58		
11/13/21 23:00	0.5			1.7			5			0.34			0.168			0.56		
11/14/21 0:00	0.4			1.5			5			0.33			0.1662			0.55		
11/14/21 1:00	0.4			1.5			5			0.33			0.16614			0.55		
11/14/21 2:00	0.4			1.5			5			0.33			0.16596			0.55		
11/14/21 3:00	0.5			1.6			5			0.33			0.1659			0.55		
11/14/21 4:00	0.4			1.5			5			0.33			0.16638			0.55		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/14/21 5:00	0.4			1.5			5			0.33			0.1659			0.55		
11/14/21 6:00	0.5			1.5			5			0.33			0.1668			0.56		
11/14/21 7:00	0.5			1.6			4			0.34			0.16848			0.56		
11/14/21 8:00	0.5			1.5			5			0.34			0.16758			0.56		
11/14/21 9:00	0.5			1.5			5			0.33			0.16704			0.56		
11/14/21 10:00	0.4			1.5			5			0.33			0.16704			0.56		
11/14/21 11:00	0.5			1.5			5			0.33			0.16704			0.56		
11/14/21 12:00	0.4			1.5			4			0.33			0.16704			0.56		
11/14/21 13:00	0.5			1.5			5			0.33			0.16674			0.56		
11/14/21 14:00	0.5			1.5			5			0.33			0.16602			0.55		
11/14/21 15:00	0.6			1.3			3			0.36			0.18072			0.6		
11/14/21 16:00	0.5			1.6			4			0.34			0.16794			0.56		
11/14/21 17:00	0.5			1.6			5			0.34			0.16782			0.56		
11/14/21 18:00	0.5			1.5			5			0.33			0.16722			0.56		
11/14/21 19:00	0.5			1.7			4			0.34			0.1698			0.57		
11/14/21 20:00	0.6			1.5			3			0.36			0.17778			0.59		
11/14/21 21:00	0.6			1.6			4			0.35			0.17346			0.58		
11/14/21 22:00	0.5			1.7			5			0.34			0.16896			0.56		
11/14/21 23:00	0.5			1.6			6			0.33			0.16614			0.55		
11/15/21 0:00	0.5			1.5			5			0.33			0.16626			0.55		
11/15/21 1:00	0.5			1.5			5			0.33			0.1659			0.55		
11/15/21 2:00	0.5			1.5			5			0.33			0.16614			0.55		
11/15/21 3:00	0.6			1.6			5			0.33			0.16644			0.55		
11/15/21 4:00	0.5			1.6			4			0.34			0.16824			0.56		
11/15/21 5:00	0.6			1.5			3			0.35			0.17328			0.58		
11/15/21 6:00	0.7			1.5			3			0.38			0.19086			0.64		
11/15/21 7:00	0.7			1.6			3			0.39			0.19416			0.65		
11/15/21 8:00	0.5			1.6			4			0.34			0.16962			0.57		
11/15/21 9:00	0.6			1.5			3			0.35			0.17436			0.58		
11/15/21 10:00	0.6			1.5			4			0.35			0.17424			0.58		
11/15/21 11:00	0.5			1.6			4			0.34			0.17124			0.57		
11/15/21 12:00	0.5			1.6			5			0.33			0.16554			0.55		
11/15/21 13:00	0.5			1.5			4			0.34			0.16986			0.57		
11/15/21 14:00	0.6			1.4			2			0.43			0.21252			0.71		
11/15/21 15:00	0.7			1.5			2			0.41			0.20286			0.68		
11/15/21 16:00	0.7			1.5			2			0.37			0.18414			0.61		
11/15/21 17:00	0.6			1.6			4			0.35			0.1734			0.58		
11/15/21 18:00	0.7			1.5			3			0.35			0.17514			0.58		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/15/21 19:00	0.8			1.6			2			0.44			0.22038			0.73		
11/15/21 20:00	0.6			1.5			3			0.35			0.17436			0.58		
11/15/21 21:00	0.7			1.5			3			0.38			0.18858			0.63		
11/15/21 22:00	0.6			1.5			4			0.34			0.17232			0.57		
11/15/21 23:00	0.6			1.6			5			0.33			0.16578			0.55		
11/16/21 0:00	0.6			1.5			3			0.35			0.17328			0.58		
11/16/21 1:00	0.6			1.5			3			0.35			0.17412			0.58		
11/16/21 2:00	0.5			1.7			5			0.34			0.16908			0.56		
11/16/21 3:00	0.5			1.6			5			0.33			0.16662			0.56		
11/16/21 4:00	0.6			1.5			3			0.35			0.17274			0.58		
11/16/21 5:00	0.7			1.4			1			0.47			0.2346			0.78		
11/16/21 6:00	0.7			1.5			1			0.56			0.28002			0.93		
11/16/21 7:00	0.7			1.5			2			0.56			0.2802			0.93		
11/16/21 8:00	0.7			1.7			3			0.46			0.23154			0.77		
11/16/21 9:00	0.7			1.2			3			0.42			0.2106			0.7		
11/16/21 10:00	0.6			1.6			5			0.34			0.17076			0.57		
11/16/21 11:00	0.5			1.6			4			0.34			0.16998			0.57		
11/16/21 12:00	0.5			1.5			4			0.34			0.16782			0.56		
11/16/21 13:00	0.5			1.5			4			0.34			0.168			0.56		
11/16/21 14:00	0.5			1.5			4			0.34			0.1677			0.56		
11/16/21 15:00	0.6			1.4			3			0.37			0.1842			0.61		
11/16/21 16:00	0.6			1.6			3			0.35			0.17424			0.58		
11/16/21 17:00	0.7			1.4			2			0.43			0.21612			0.72		
11/16/21 18:00	0.8			1.6			2			0.46			0.23208			0.77		
11/16/21 19:00	0.8			1.5			3			0.4			0.20178			0.67		
11/16/21 20:00	0.8			1.5			2			0.52			0.26064			0.87		
11/16/21 21:00	0.8			1.5			2			0.53			0.26472			0.88		
11/16/21 22:00	0.8			1.6			2			0.48			0.2391			0.8		
11/16/21 23:00	0.9			1.5			2			0.43			0.2136			0.71		
11/17/21 0:00	1.5			1.5			2			0.57			0.2835			0.95		
11/17/21 1:00	1.4			1.6			3			0.49			0.24624			0.82		
11/17/21 2:00	0.6			1.5			4			0.35			0.17388			0.58		
11/17/21 3:00	0.6			1.5			4			0.35			0.17478			0.58		
11/17/21 4:00	0.7			1.4			3			0.42			0.2118			0.71		
11/17/21 5:00	0.7			1.6			3			0.43			0.21342			0.71		
11/17/21 6:00	0.7			1.5			2			0.54			0.26958			0.9		
11/17/21 7:00	0.7			1.7			3			0.45			0.2262			0.75		
11/17/21 8:00	0.6			1.5			4			0.35			0.17274			0.58		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/17/21 9:00	0.6			1.5			4			0.35			0.17388			0.58		
11/17/21 10:00	0.6			1.5			4			0.35			0.1731			0.58		
11/17/21 11:00	0.5			1.5			5			0.33			0.16722			0.56		
11/17/21 12:00	0.5			1.3			5			0.33			0.16638			0.55		
11/17/21 13:00	0.5			1.4			5			0.33			0.16596			0.55		
11/17/21 14:00	0.5			1.3			5			0.33			0.16608			0.55		
11/17/21 15:00	0.6			1.2			3			0.4			0.20118			0.67		
11/17/21 16:00	0.7			1.4			2			0.46			0.22818			0.76		
11/17/21 17:00	0.7			1.3			2			0.53			0.26316			0.88		
11/17/21 18:00	0.7			1.3			2			0.55			0.27504			0.92		
11/17/21 19:00	0.8			1.3			2			0.55			0.27564			0.92		
11/17/21 20:00	0.8			1.3			2			0.54			0.27132			0.9		
11/17/21 21:00	0.9			1.3			2			0.5			0.24858			0.83		
11/17/21 22:00	0.7			1.6			4			0.36			0.18066			0.6		
11/17/21 23:00	0.6			1.3			5			0.35			0.17472			0.58		
11/18/21 0:00	0.6			1.3			5			0.35			0.17424			0.58		
11/18/21 1:00	0.6			1.3			5			0.35			0.17442			0.58		
11/18/21 2:00	0.6			1.4			4			0.35			0.17442			0.58		
11/18/21 3:00	0.6			1.5			4			0.35			0.1743			0.58		
11/18/21 4:00	0.6			1.5			4			0.35			0.17406			0.58		
11/18/21 5:00	0.6			1.4			3			0.4			0.19938			0.66		
11/18/21 6:00	0.9			1.6			2			0.53			0.26544			0.88		
11/18/21 7:00	0.8			1.6			3			0.49			0.24372			0.81		
11/18/21 8:00	0.8			1.4			3			0.44			0.21978			0.73		
11/18/21 9:00	0.6			1.5			5			0.35			0.17508			0.58		
11/18/21 10:00	0.5			1.3			6			0.34			0.16758			0.56		
11/18/21 11:00	0.5			1.2			5			0.34			0.16818			0.56		
11/18/21 12:00	0.5			1.2			5			0.34			0.168			0.56		
11/18/21 13:00	0.6			1.3			3			0.35			0.17712			0.59		
11/18/21 14:00	0.7			1.4			2			0.37			0.18744			0.62		
11/18/21 15:00	0.7			1.2			2			0.5			0.24804			0.83		
11/18/21 16:00	0.8			1.2			2			0.53			0.2628			0.88		
11/18/21 17:00	0.9			1.2			2			0.53			0.26538			0.88		
11/18/21 18:00	0.7			1.4			1			0.56			0.28104			0.94		
11/18/21 19:00	0.7			1.5			2			0.55			0.273			0.91		
11/18/21 20:00	0.7			1.6			3			0.46			0.23184			0.77		
11/18/21 21:00	1			1.3			3			0.42			0.20958			0.7		
11/18/21 22:00	0.7			1.5			3			0.39			0.19404			0.65		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/18/21 23:00	0.7			1.4			3			0.37			0.18672			0.62		
11/19/21 0:00	0.5			1.8			5			0.28			0.14184			0.47		
11/19/21 1:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/21 2:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/21 3:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/21 4:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/21 5:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/21 6:00	0	X		0	X		0	X		0	X		0	X		0	X	
11/19/21 7:00	0			0			0	X		0.03			0.0168			0.06		
11/19/21 8:00	0.6			2.1			6			0.35			0.1743			0.58		
11/19/21 9:00	0.5			1.3			5			0.34			0.16782			0.56		
11/19/21 10:00	0.5			1.3			5			0.34			0.1686			0.56		
11/19/21 11:00	0.6			1.3			4			0.34			0.17016			0.57		
11/19/21 12:00	0.6			1.2			3			0.36			0.17784			0.59		
11/19/21 13:00	0.7			1.1			1			0.51			0.25302			0.84		
11/19/21 14:00	0.6			1.2			2			0.48			0.24096			0.8		
11/19/21 15:00	0.6			1.2			3			0.41			0.20472			0.68		
11/19/21 16:00	0.5			1.4			4			0.35			0.17652			0.59		
11/19/21 17:00	0.6			1.3			3			0.38			0.1902			0.63		
11/19/21 18:00	0.6			1.2			4			0.36			0.1815			0.61		
11/19/21 19:00	0.5			1.2			4			0.35			0.17514			0.58		
11/19/21 20:00	0.6			1.3			3			0.41			0.20268			0.68		
11/19/21 21:00	0.6			1.3			3			0.39			0.1938			0.65		
11/19/21 22:00	0.6			1.3			3			0.39			0.19602			0.65		
11/19/21 23:00	0.4			1.4			6			0.34			0.1686			0.56		
11/20/21 0:00	0.4			1.4			6			0.33			0.16614			0.55		
11/20/21 1:00	0.4			1.3			6			0.33			0.16716			0.56		
11/20/21 2:00	0.4			1.3			6			0.33			0.16722			0.56		
11/20/21 3:00	0.5			1.3			6			0.34			0.1677			0.56		
11/20/21 4:00	0.6			1.2			5			0.35			0.17484			0.58		
11/20/21 5:00	0.4			1.4			6			0.34			0.16944			0.56		
11/20/21 6:00	0.6			1.5			4			0.35			0.17724			0.59		
11/20/21 7:00	0.6			1.8			3			0.43			0.21318			0.71		
11/20/21 8:00	0.4			1.7			6			0.33			0.16578			0.55		
11/20/21 9:00	0.4			1.6			6			0.33			0.16536			0.55		
11/20/21 10:00	0.4			1.4			6			0.33			0.1656			0.55		
11/20/21 11:00	0.4			1.4			6			0.33			0.16536			0.55		
11/20/21 12:00	0.4			1.3			5			0.33			0.16536			0.55		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/20/21 13:00	0.4			1.3			5			0.33			0.16518			0.55		
11/20/21 14:00	0.4			1.3			5			0.33			0.16536			0.55		
11/20/21 15:00	0.5			1.1			2			0.4			0.19842			0.66		
11/20/21 16:00	0.5			1.3			2			0.4			0.19902			0.66		
11/20/21 17:00	0.5			1.4			3			0.36			0.17922			0.6		
11/20/21 18:00	0.5			1.3			4			0.35			0.17304			0.58		
11/20/21 19:00	0.6			1.2			3			0.38			0.19104			0.64		
11/20/21 20:00	0.7			1.4			3			0.41			0.20454			0.68		
11/20/21 21:00	0.8			1.3			2			0.52			0.25854			0.86		
11/20/21 22:00	0.8			1.6			3			0.44			0.22116			0.74		
11/20/21 23:00	0.6			1.5			5			0.35			0.17376			0.58		
11/21/21 0:00	0.7			1.5			3			0.41			0.2061			0.69		
11/21/21 1:00	0.7			1.5			5			0.35			0.1749			0.58		
11/21/21 2:00	0.5			1.5			6			0.34			0.16794			0.56		
11/21/21 3:00	0.6			1.5			5			0.35			0.17442			0.58		
11/21/21 4:00	0.6			1.3			5			0.35			0.17454			0.58		
11/21/21 5:00	0.7			1.2			1			0.5			0.25194			0.84		
11/21/21 6:00	0.8			1.3			2			0.52			0.25794			0.86		
11/21/21 7:00	0.7			1.3			2			0.52			0.25854			0.86		
11/21/21 8:00	0.7			1.3			2			0.54			0.27228			0.91		
11/21/21 9:00	0.7			1.6			3			0.44			0.22152			0.74		
11/21/21 10:00	0.7			1.3			2			0.44			0.22146			0.74		
11/21/21 11:00	0.6			1.5			3			0.38			0.19104			0.64		
11/21/21 12:00	0.4			1.4			5			0.33			0.16692			0.56		
11/21/21 13:00	0.4			1.3			5			0.33			0.16656			0.56		
11/21/21 14:00	0.4			1.3			4			0.33			0.1665			0.56		
11/21/21 15:00	0.6			1.1			2			0.43			0.21456			0.72		
11/21/21 16:00	0.7			1.4			2			0.41			0.20286			0.68		
11/21/21 17:00	0.6			1.5			4			0.35			0.17316			0.58		
11/21/21 18:00	0.6			1.3			4			0.35			0.17322			0.58		
11/21/21 19:00	0.9			1.2			2			0.43			0.21486			0.72		
11/21/21 20:00	1.2			1.4			2			0.55			0.27714			0.92		
11/21/21 21:00	1.1			1.5			3			0.46			0.22998			0.77		
11/21/21 22:00	0.9			1.4			3			0.45			0.22362			0.75		
11/21/21 23:00	0.6			1.5			5			0.35			0.17412			0.58		
11/22/21 0:00	0.6			1.3			5			0.35			0.17502			0.58		
11/22/21 1:00	0.6			1.3			5			0.35			0.17508			0.58		
11/22/21 2:00	0.6			1.3			5			0.35			0.17472			0.58		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/22/21 3:00	0.6			1.4			5			0.35			0.17496			0.58		
11/22/21 4:00	0.6			1.3			5			0.35			0.17472			0.58		
11/22/21 5:00	0.7			1.3			5			0.35			0.17616			0.59		
11/22/21 6:00	0.9			1.2			3			0.42			0.2085			0.7		
11/22/21 7:00	0.8			1.7			4			0.42			0.20892			0.7		
11/22/21 8:00	0.8			1.7			5			0.35			0.17478			0.58		
11/22/21 9:00	0.5			1.6			6			0.34			0.168			0.56		
11/22/21 10:00	0.4			1.3			5			0.33			0.16668			0.56		
11/22/21 11:00	0.5			1.3			5			0.33			0.16668			0.56		
11/22/21 12:00	0.5			1.3			3			0.34			0.17154			0.57		
11/22/21 13:00	0.6			1.3			3			0.35			0.17424			0.58		
11/22/21 14:00	0.6			1.2			1			0.47			0.23406			0.78		
11/22/21 15:00	0.6			1.3			1			0.56			0.28098			0.94		
11/22/21 16:00	0.7			1.3			2			0.46			0.22998			0.77		
11/22/21 17:00	0.7			1.5			4			0.38			0.18792			0.63		
11/22/21 18:00	0.8			1.3			2			0.52			0.25788			0.86		
11/22/21 19:00	0.8			1.3			2			0.51			0.25572			0.85		
11/22/21 20:00	0.8			1.3			2			0.52			0.25974			0.87		
11/22/21 21:00	0.8			1.3			2			0.52			0.25758			0.86		
11/22/21 22:00	0.8			1.3			2			0.52			0.26034			0.87		
11/22/21 23:00	0.7			1.6			4			0.43			0.21408			0.71		
11/23/21 0:00	0.6			1.4			5			0.35			0.17382			0.58		
11/23/21 1:00	0.6			1.3			4			0.35			0.1752			0.58		
11/23/21 2:00	0.6			1.3			4			0.35			0.17568			0.59		
11/23/21 3:00	0.6			1.4			5			0.35			0.1737			0.58		
11/23/21 4:00	0.5			1.4			5			0.34			0.16866			0.56		
11/23/21 5:00	0.5			1.4			6			0.34			0.16812			0.56		
11/23/21 6:00	0.5			1.3			4			0.35			0.17436			0.58		
11/23/21 7:00	0.6			1.7			4			0.4			0.20178			0.67		
11/23/21 8:00	0.5			1.6			6			0.34			0.16884			0.56		
11/23/21 9:00	0.5			1.5			6			0.33			0.16626			0.55		
11/23/21 10:00	0.5			1.3			6			0.33			0.16596			0.55		
11/23/21 11:00	0.5			1.3			5			0.33			0.1659			0.55		
11/23/21 12:00	0.5			1.3			5			0.33			0.16596			0.55		
11/23/21 13:00	0.5			1.3			4			0.33			0.1659			0.55		
11/23/21 14:00	0.5			1.3			4			0.33			0.16614			0.55		
11/23/21 15:00	0.6			1.2			3			0.38			0.19074			0.64		
11/23/21 16:00	0.6			1.3			3			0.37			0.18702			0.62		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/23/21 17:00	0.6			1.4			4			0.35			0.17436			0.58		
11/23/21 18:00	0.6			1.3			4			0.35			0.17418			0.58		
11/23/21 19:00	0.6			1.3			4			0.35			0.1743			0.58		
11/23/21 20:00	0.5			1.5			5			0.34			0.16998			0.57		
11/23/21 21:00	0.5			1.4			5			0.34			0.17172			0.57		
11/23/21 22:00	0.6			1.3			5			0.35			0.17424			0.58		
11/23/21 23:00	0.5			1.5			6			0.34			0.16968			0.57		
11/24/21 0:00	0.6			1.4			4			0.35			0.17466			0.58		
11/24/21 1:00	0.6			1.5			5			0.35			0.17448			0.58		
11/24/21 2:00	0.4			1.8			6			0.34			0.16758			0.56		
11/24/21 3:00	0.4			1.6			6			0.34			0.16752			0.56		
11/24/21 4:00	0.4			1.6			5			0.34			0.16926			0.56		
11/24/21 5:00	0.4			1.7			5			0.34			0.17088			0.57		
11/24/21 6:00	0.6			1.6			4			0.37			0.18696			0.62		
11/24/21 7:00	0.6			1.8			4			0.42			0.20844			0.69		
11/24/21 8:00	0.5			1.5			5			0.35			0.17328			0.58		
11/24/21 9:00	0.6			1.5			4			0.36			0.17946			0.6		
11/24/21 10:00	0.5			1.6			4			0.35			0.1734			0.58		
11/24/21 11:00	0.5			1.5			4			0.35			0.17316			0.58		
11/24/21 12:00	0.5			1.5			3			0.35			0.1731			0.58		
11/24/21 13:00	0.5			1.5			3			0.35			0.17292			0.58		
11/24/21 14:00	0.5			1.5			3			0.35			0.17334			0.58		
11/24/21 15:00	0.6			1.4			2			0.39			0.19614			0.65		
11/24/21 16:00	0.7			1.5			2			0.39			0.19548			0.65		
11/24/21 17:00	0.6			1.6			4			0.35			0.1746			0.58		
11/24/21 18:00	0.6			1.5			3			0.35			0.17436			0.58		
11/24/21 19:00	0.6			1.5			4			0.35			0.17556			0.59		
11/24/21 20:00	0.6			1.5			4			0.36			0.17808			0.59		
11/24/21 21:00	0.7			1.6			3			0.37			0.18516			0.62		
11/24/21 22:00	0.6			1.5			4			0.35			0.17424			0.58		
11/24/21 23:00	0.6			1.5			4			0.35			0.17442			0.58		
11/25/21 0:00	0.6			1.5			5			0.35			0.1743			0.58		
11/25/21 1:00	0.6			1.5			5			0.35			0.17436			0.58		
11/25/21 2:00	0.6			1.5			4			0.35			0.1743			0.58		
11/25/21 3:00	0.6			1.6			5			0.35			0.17442			0.58		
11/25/21 4:00	0.6			1.5			5			0.35			0.1743			0.58		
11/25/21 5:00	0.6			1.5			5			0.35			0.17412			0.58		
11/25/21 6:00	0.6			1.5			4			0.35			0.17682			0.59		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/25/21 7:00	0.7			1.7			3			0.4			0.20136			0.67		
11/25/21 8:00	0.6			1.7			4			0.36			0.17994			0.6		
11/25/21 9:00	0.6			1.5			5			0.35			0.17328			0.58		
11/25/21 10:00	0.6			1.5			4			0.35			0.17382			0.58		
11/25/21 11:00	0.6			1.5			3			0.35			0.1767			0.59		
11/25/21 12:00	0.6			1.5			3			0.35			0.17316			0.58		
11/25/21 13:00	0.6			1.5			3			0.35			0.17322			0.58		
11/25/21 14:00	0.6			1.5			3			0.35			0.1731			0.58		
11/25/21 15:00	0.6			1.4			3			0.36			0.17952			0.6		
11/25/21 16:00	0.7			1.5			3			0.36			0.17946			0.6		
11/25/21 17:00	0.6			1.6			4			0.35			0.17286			0.58		
11/25/21 18:00	0.6			1.5			4			0.35			0.17418			0.58		
11/25/21 19:00	0.7			1.5			4			0.35			0.17268			0.58		
11/25/21 20:00	0.7			1.5			4			0.35			0.17256			0.58		
11/25/21 21:00	0.7			1.5			4			0.35			0.17268			0.58		
11/25/21 22:00	0.7			1.5			4			0.34			0.17196			0.57		
11/25/21 23:00	0.7			1.5			4			0.35			0.1734			0.58		
11/26/21 0:00	0.7			1.5			4			0.34			0.17226			0.57		
11/26/21 1:00	0.7			1.5			5			0.34			0.17196			0.57		
11/26/21 2:00	0.7			1.5			4			0.34			0.17244			0.57		
11/26/21 3:00	0.7			1.5			5			0.35			0.1725			0.58		
11/26/21 4:00	0.7			1.5			5			0.35			0.17274			0.58		
11/26/21 5:00	0.7			1.5			5			0.34			0.17226			0.57		
11/26/21 6:00	0.8			1.5			5			0.34			0.17202			0.57		
11/26/21 7:00	0.7			1.5			5			0.35			0.17256			0.58		
11/26/21 8:00	0.7			1.5			5			0.34			0.17244			0.57		
11/26/21 9:00	0.7			1.5			4			0.34			0.17244			0.57		
11/26/21 10:00	0.7			1.5			4			0.35			0.17274			0.58		
11/26/21 11:00	0.6			1.5			4			0.34			0.1722			0.57		
11/26/21 12:00	0.6			1.5			4			0.34			0.17214			0.57		
11/26/21 13:00	0.6			1.5			3			0.34			0.17202			0.57		
11/26/21 14:00	0.6			1.5			3			0.34			0.17196			0.57		
11/26/21 15:00	0.6			1.3			2			0.41			0.2037			0.68		
11/26/21 16:00	0.6			1.5			3			0.35			0.17508			0.58		
11/26/21 17:00	0.6			1.5			4			0.34			0.17172			0.57		
11/26/21 18:00	0.6			1.5			4			0.34			0.17166			0.57		
11/26/21 19:00	0.7			1.5			4			0.34			0.17172			0.57		
11/26/21 20:00	0.7			1.5			4			0.35			0.17256			0.58		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/26/21 21:00	0.6			1.5			4			0.35			0.17304			0.58		
11/26/21 22:00	0.6			1.5			4			0.35			0.17286			0.58		
11/26/21 23:00	0.6			1.5			4			0.35			0.17292			0.58		
11/27/21 0:00	0.6			1.5			4			0.34			0.17178			0.57		
11/27/21 1:00	0.6			1.5			4			0.35			0.17268			0.58		
11/27/21 2:00	0.6			1.5			4			0.34			0.17184			0.57		
11/27/21 3:00	0.6			1.6			5			0.35			0.17256			0.58		
11/27/21 4:00	0.6			1.5			5			0.34			0.1722			0.57		
11/27/21 5:00	0.7			1.4			4			0.37			0.18426			0.61		
11/27/21 6:00	0.7			1.6			4			0.36			0.17766			0.59		
11/27/21 7:00	0.8			1.8			3			0.42			0.21054			0.7		
11/27/21 8:00	0.6			1.6			5			0.34			0.17202			0.57		
11/27/21 9:00	0.6			1.4			3			0.38			0.18966			0.63		
11/27/21 10:00	0.7			1.6			1			0.44			0.22176			0.74		
11/27/21 11:00	0.6			1.5			4			0.35			0.17268			0.58		
11/27/21 12:00	0.6			1.5			3			0.35			0.17268			0.58		
11/27/21 13:00	0.6			1.5			3			0.35			0.17262			0.58		
11/27/21 14:00	0.6			1.5			3			0.35			0.17274			0.58		
11/27/21 15:00	0.6			1.3			2			0.4			0.1986			0.66		
11/27/21 16:00	0.7			1.4			2			0.42			0.20784			0.69		
11/27/21 17:00	0.6			1.7			4			0.35			0.17568			0.59		
11/27/21 18:00	0.6			1.5			4			0.34			0.17238			0.57		
11/27/21 19:00	0.6			1.5			4			0.35			0.17274			0.58		
11/27/21 20:00	0.6			1.5			4			0.35			0.1734			0.58		
11/27/21 21:00	0.8			1.5			3			0.37			0.18324			0.61		
11/27/21 22:00	0.6			1.6			4			0.35			0.17256			0.58		
11/27/21 23:00	0.6			1.5			4			0.35			0.17316			0.58		
11/28/21 0:00	0.6			1.5			4			0.35			0.17274			0.58		
11/28/21 1:00	0.6			1.5			5			0.35			0.17262			0.58		
11/28/21 2:00	0.6			1.5			4			0.35			0.17274			0.58		
11/28/21 3:00	0.6			1.5			5			0.35			0.17298			0.58		
11/28/21 4:00	0.7			1.5			5			0.35			0.17298			0.58		
11/28/21 5:00	0.6			1.5			5			0.35			0.17292			0.58		
11/28/21 6:00	0.6			1.5			4			0.35			0.17286			0.58		
11/28/21 7:00	0.7			1.6			4			0.37			0.18276			0.61		
11/28/21 8:00	0.6			1.6			5			0.35			0.17304			0.58		
11/28/21 9:00	0.6			1.5			4			0.35			0.17322			0.58		
11/28/21 10:00	0.6			1.5			4			0.35			0.1731			0.58		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/28/21 11:00	0.6			1.5			3			0.35			0.17286			0.58		
11/28/21 12:00	0.6			1.5			3			0.35			0.17286			0.58		
11/28/21 13:00	0.6			1.5			3			0.35			0.1728			0.58		
11/28/21 14:00	0.6			1.5			3			0.35			0.17268			0.58		
11/28/21 15:00	0.6			1.5			3			0.35			0.1737			0.58		
11/28/21 16:00	0.6			1.4			3			0.36			0.1812			0.6		
11/28/21 17:00	0.6			1.4			3			0.35			0.1728			0.58		
11/28/21 18:00	0.7			1.5			3			0.35			0.17274			0.58		
11/28/21 19:00	0.6			1.5			4			0.35			0.17304			0.58		
11/28/21 20:00	0.8			1.5			4			0.35			0.17268			0.58		
11/28/21 21:00	0.6			1.5			4			0.35			0.17274			0.58		
11/28/21 22:00	0.6			1.5			4			0.35			0.17286			0.58		
11/28/21 23:00	0.6			1.5			4			0.35			0.1728			0.58		
11/29/21 0:00	0.6			1.5			4			0.35			0.17298			0.58		
11/29/21 1:00	0.6			1.5			4			0.35			0.17298			0.58		
11/29/21 2:00	0.6			1.5			4			0.35			0.17304			0.58		
11/29/21 3:00	0.6			1.5			5			0.35			0.17304			0.58		
11/29/21 4:00	0.6			1.5			5			0.35			0.1728			0.58		
11/29/21 5:00	0.6			1.5			4			0.35			0.17682			0.59		
11/29/21 6:00	0.8			1.4			2			0.43			0.21276			0.71		
11/29/21 7:00	1			1.8			3			0.43			0.21468			0.72		
11/29/21 8:00	0.8			1.7			5			0.35			0.17316			0.58		
11/29/21 9:00	0.6			1.5			4			0.35			0.17322			0.58		
11/29/21 10:00	0.6			1.5			4			0.35			0.1731			0.58		
11/29/21 11:00	0.6			1.5			3			0.35			0.17298			0.58		
11/29/21 12:00	0.6			1.5			3			0.35			0.17286			0.58		
11/29/21 13:00	0.6			1.5			3			0.35			0.17274			0.58		
11/29/21 14:00	0.6			1.5			3			0.35			0.17274			0.58		
11/29/21 15:00	0.6			1.3			2			0.39			0.19278			0.64		
11/29/21 16:00	0.7			1.4			1			0.46			0.2295			0.77		
11/29/21 17:00	0.8			1.6			1			0.48			0.23832			0.79		
11/29/21 18:00	0.7			1.5			2			0.39			0.19638			0.65		
11/29/21 19:00	1			1.6			2			0.47			0.2343			0.78		
11/29/21 20:00	0.8			1.5			2			0.54			0.27036			0.9		
11/29/21 21:00	0.8			1.7			3			0.41			0.20586			0.69		
11/29/21 22:00	0.7			1.6			4			0.36			0.18066			0.6		
11/29/21 23:00	0.6			1.5			4			0.35			0.17268			0.58		
11/30/21 0:00	0.7			1.4			2			0.47			0.23334			0.78		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/30/21 1:00	0.7			1.8			4			0.37			0.18738			0.62		
11/30/21 2:00	0.6			1.5			4			0.35			0.17274			0.58		
11/30/21 3:00	0.6			1.5			4			0.35			0.17268			0.58		
11/30/21 4:00	0.6			1.5			4			0.35			0.1734			0.58		
11/30/21 5:00	0.6			1.4			4			0.38			0.18984			0.63		
11/30/21 6:00	0.7			1.5			1			0.52			0.26004			0.87		
11/30/21 7:00	0.7			1.6			2			0.52			0.25974			0.87		
11/30/21 8:00	0.6			1.8			4			0.36			0.17784			0.59		
11/30/21 9:00	0.6			1.4			0		X	0.35			0.1731			0.58		
11/30/21 10:00	0.6			1.1			0		X	0.35			0.17256			0.58		
11/30/21 11:00	0.6			1.3			2			0.35			0.17286			0.58		
11/30/21 12:00	0.6			1.4			3			0.35			0.17286			0.58		
11/30/21 13:00	0.6			1.4			3			0.35			0.17262			0.58		
11/30/21 14:00	0.6			1.4			3			0.35			0.17256			0.58		
11/30/21 15:00	0.6			1.3			2			0.41			0.2058			0.69		
11/30/21 16:00	0.7			1.3			1			0.48			0.24228			0.81		
11/30/21 17:00	0.8			1.5			2			0.58			0.29106			0.97		
11/30/21 18:00	0.3			1.4			4			0.76			0.38052			1.27		
11/30/21 19:00	0.3			1.4			4			0.76			0.37824			1.26		
11/30/21 20:00	1.2			1.4			3			0.6			0.29772			0.99		
11/30/21 21:00	0.5			1.4			4			0.72			0.35874			1.2		
11/30/21 22:00	1.2			1.4			3			0.59			0.2937			0.98		
11/30/21 23:00	1.2			1.6			3			0.48			0.24186			0.81		
12/01/21 0:00	0.6			1.6			5			0.35			0.17268			0.58		
12/01/21 1:00	0.6			1.5			5			0.35			0.17262			0.58		
12/01/21 2:00	0.6			1.4			5			0.35			0.17292			0.58		
12/01/21 3:00	0.7			1.5			5			0.35			0.17316			0.58		
12/01/21 4:00	0.6			1.5			5			0.35			0.17286			0.58		
12/01/21 5:00	0.6			1.5			5			0.35			0.17268			0.58		
12/01/21 6:00	0.9			1.6			5			0.35			0.17268			0.58		
12/01/21 7:00	0.8			1.6			5			0.35			0.17286			0.58		
12/01/21 8:00	0.7			1.5			5			0.35			0.17304			0.58		
12/01/21 9:00	0.6			1.5			4			0.35			0.17274			0.58		
12/01/21 10:00	0.6			1.5			3			0.35			0.17298			0.58		
12/01/21 11:00	0.6			1.5			3			0.35			0.1728			0.58		
12/01/21 12:00	0.6			1.5			3			0.35			0.17286			0.58		
12/01/21 13:00	0.6			1.5			3			0.35			0.17274			0.58		
12/01/21 14:00	0.6			1.5			3			0.35			0.17268			0.58		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/01/21 15:00	0.6			1.4			2			0.38			0.18762			0.63		
12/01/21 16:00	0.7			1.4			1			0.44			0.2175			0.73		
12/01/21 17:00	0.8			1.6			1			0.48			0.24114			0.8		
12/01/21 18:00	0.8			1.5			2			0.52			0.25896			0.86		
12/01/21 19:00	0.8			1.5			2			0.54			0.26862			0.9		
12/01/21 20:00	0.9			1.5			2			0.51			0.25716			0.86		
12/01/21 21:00	0.9			1.5			2			0.53			0.26706			0.89		
12/01/21 22:00	0.7			1.5			4			0.37			0.18732			0.62		
12/01/21 23:00	0.6			1.3			4			0.35			0.17292			0.58		
12/02/21 0:00	0.6			1.3			4			0.35			0.17556			0.59		
12/02/21 1:00	0.7			1.2			4			0.37			0.18534			0.62		
12/02/21 2:00	0.6			1.5			4			0.36			0.17982			0.6		
12/02/21 3:00	0.9			1.3			2			0.49			0.24378			0.81		
12/02/21 4:00	0.8			1.5			2			0.53			0.26352			0.88		
12/02/21 5:00	1.3			1.5			2			0.55			0.27408			0.91		
12/02/21 6:00	1.6			1.5			3			0.61			0.30432			1.01		
12/02/21 7:00	1.2			1.5			3			0.59			0.29394			0.98		
12/02/21 8:00	1.1			1.6			3			0.48			0.24138			0.8		
12/02/21 9:00	0.7			1.6			5			0.35			0.17298			0.58		
12/02/21 10:00	0.6			1.3			5			0.35			0.17298			0.58		
12/02/21 11:00	0.6			1.3			4			0.35			0.17292			0.58		
12/02/21 12:00	0.6			1.3			3			0.35			0.17268			0.58		
12/02/21 13:00	0.6			1.3			3			0.35			0.17268			0.58		
12/02/21 14:00	0.6			1.5			3			0.35			0.17268			0.58		
12/02/21 15:00	0.6			1.4			2			0.39			0.19638			0.65		
12/02/21 16:00	0.9			1.5			1			0.46			0.22956			0.77		
12/02/21 17:00	0.7			1.5			2			0.67			0.33702			1.12		
12/02/21 18:00	1.3			1.5			2			0.6			0.29952			1		
12/02/21 19:00	1.5			1.5			2			0.59			0.29622			0.99		
12/02/21 20:00	1.3			1.5			2			0.62			0.3087			1.03		
12/02/21 21:00	1.3			1.5			2			0.62			0.3075			1.03		
12/02/21 22:00	1.1			1.6			3			0.49			0.24354			0.81		
12/02/21 23:00	0.7			1.6			4			0.35			0.17256			0.58		
12/03/21 0:00	0.6			1.5			4			0.35			0.1725			0.58		
12/03/21 1:00	0.6			1.5			4			0.35			0.17268			0.58		
12/03/21 2:00	0.6			1.5			4			0.35			0.17262			0.58		
12/03/21 3:00	0.6			1.5			5			0.35			0.17256			0.58		
12/03/21 4:00	0.6			1.5			4			0.35			0.1725			0.58		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/03/21 5:00	0.6			1.5			4			0.36			0.17838			0.59		
12/03/21 6:00	0.6			1.6			4			0.36			0.18018			0.6		
12/03/21 7:00	0.7			1.8			3			0.41			0.20376			0.68		
12/03/21 8:00	0.6			1.6			4			0.35			0.17604			0.59		
12/03/21 9:00	0.7			1.4			2			0.45			0.22296			0.74		
12/03/21 10:00	0.8			1.5			2			0.55			0.27462			0.92		
12/03/21 11:00	0.7			1.6			2			0.45			0.22722			0.76		
12/03/21 12:00	0.7			1.7			3			0.41			0.20508			0.68		
12/03/21 13:00	0.6			1.5			4			0.35			0.17328			0.58		
12/03/21 14:00	0.6			1.5			4			0.35			0.17316			0.58		
12/03/21 15:00	0.6			1.4			2			0.44			0.22038			0.73		
12/03/21 16:00	1			1.6			2			0.51			0.25542			0.85		
12/03/21 17:00	1.3			1.5			2			0.61			0.30282			1.01		
12/03/21 18:00	1.4			1.5			2			0.6			0.30162			1.01		
12/03/21 19:00	1.4			1.5			2			0.6			0.30108			1		
12/03/21 20:00	1.5			1.5			2			0.6			0.30108			1		
12/03/21 21:00	1.5			1.5			2			0.6			0.30102			1		
12/03/21 22:00	1.5			1.5			2			0.6			0.30084			1		
12/03/21 23:00	1.2			1.5			3			0.49			0.2451			0.82		
12/04/21 0:00	0.6			1.4			4			0.35			0.17268			0.58		
12/04/21 1:00	0.6			1.3			4			0.35			0.17286			0.58		
12/04/21 2:00	0.6			1.2			4			0.35			0.17364			0.58		
12/04/21 3:00	0.7			1.3			4			0.37			0.1854			0.62		
12/04/21 4:00	0.7			1.3			3			0.42			0.21			0.7		
12/04/21 5:00	0.7			1.7			3			0.4			0.20118			0.67		
12/04/21 6:00	0.8			1.8			3			0.39			0.19446			0.65		
12/04/21 7:00	0.9			1.7			3			0.44			0.21792			0.73		
12/04/21 8:00	0.8			1.7			4			0.39			0.1956			0.65		
12/04/21 9:00	0.7			1.4			2			0.48			0.2418			0.81		
12/04/21 10:00	0.7			1.7			4			0.4			0.1995			0.67		
12/04/21 11:00	0.7			1.5			2			0.5			0.24906			0.83		
12/04/21 12:00	0.6			1.6			5			0.35			0.1734			0.58		
12/04/21 13:00	0.6			1.2			4			0.38			0.18894			0.63		
12/04/21 14:00	0.7			1.6			4			0.36			0.18042			0.6		
12/04/21 15:00	0.7			1.3			3			0.41			0.20466			0.68		
12/04/21 16:00	0.7			1.4			2			0.5			0.2478			0.83		
12/04/21 17:00	1.2			1.3			2			0.56			0.28164			0.94		
12/04/21 18:00	1.5			1.5			2			0.6			0.29778			0.99		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/04/21 19:00	1.5			1.5			2			0.6			0.29784			0.99		
12/04/21 20:00	1.5			1.5			2			0.6			0.29826			0.99		
12/04/21 21:00	1.5			1.5			2			0.6			0.2982			0.99		
12/04/21 22:00	0.7			1.6			4			0.37			0.18504			0.62		
12/04/21 23:00	0.6			1.5			5			0.35			0.17328			0.58		
12/05/21 0:00	0.6			1.5			5			0.35			0.17334			0.58		
12/05/21 1:00	0.6			1.5			5			0.35			0.17334			0.58		
12/05/21 2:00	0.6			1.5			4			0.35			0.1731			0.58		
12/05/21 3:00	0.6			1.6			5			0.35			0.17292			0.58		
12/05/21 4:00	0.6			1.5			5			0.35			0.17382			0.58		
12/05/21 5:00	0.6			1.5			5			0.35			0.17352			0.58		
12/05/21 6:00	0.7			1.4			3			0.41			0.20592			0.69		
12/05/21 7:00	0.7			1.9			4			0.4			0.19764			0.66		
12/05/21 8:00	0.8			1.3			2			0.48			0.23958			0.8		
12/05/21 9:00	0.7			1.4			2			0.56			0.27792			0.93		
12/05/21 10:00	0.7			1.4			2			0.56			0.2775			0.93		
12/05/21 11:00	0.7			1.4			2			0.53			0.26574			0.89		
12/05/21 12:00	0.6			1.7			5			0.35			0.17478			0.58		
12/05/21 13:00	0.7			1.3			3			0.44			0.21816			0.73		
12/05/21 14:00	0.7			1.7			4			0.38			0.19176			0.64		
12/05/21 15:00	0.7			1.3			4			0.37			0.18324			0.61		
12/05/21 16:00	0.7			1.4			3			0.41			0.20604			0.69		
12/05/21 17:00	0.9			1.5			2			0.43			0.21672			0.72		
12/05/21 18:00	0.8			1.3			2			0.53			0.26376			0.88		
12/05/21 19:00	0.8			1.4			2			0.56			0.2784			0.93		
12/05/21 20:00	0.8			1.3			2			0.56			0.27894			0.93		
12/05/21 21:00	0.8			1.4			2			0.53			0.26718			0.89		
12/05/21 22:00	0.8			1.4			2			0.54			0.27006			0.9		
12/05/21 23:00	0.9			1.4			3			0.46			0.228			0.76		
12/06/21 0:00	0.7			1.7			4			0.4			0.19968			0.67		
12/06/21 1:00	0.6			1.6			5			0.35			0.17424			0.58		
12/06/21 2:00	0.6			1.5			5			0.35			0.17376			0.58		
12/06/21 3:00	0.6			1.4			5			0.35			0.1746			0.58		
12/06/21 4:00	0.6			1.4			5			0.35			0.17454			0.58		
12/06/21 5:00	0.7			1.2			3			0.44			0.22188			0.74		
12/06/21 6:00	0.7			1.5			2			0.55			0.27522			0.92		
12/06/21 7:00	0.7			1.5			2			0.56			0.27894			0.93		
12/06/21 8:00	0.7			1.5			2			0.55			0.27636			0.92		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/06/21 9:00	0.7			1.5			2			0.56			0.27876			0.93		
12/06/21 10:00	0.8			1.5			2			0.56			0.27864			0.93		
12/06/21 11:00	0.7			1.5			2			0.56			0.2787			0.93		
12/06/21 12:00	0.7			1.5			2			0.56			0.27858			0.93		
12/06/21 13:00	0.7			1.5			2			0.56			0.27852			0.93		
12/06/21 14:00	0.7			1.5			2			0.56			0.27816			0.93		
12/06/21 15:00	0.7			1.5			2			0.56			0.27828			0.93		
12/06/21 16:00	1.1			1.5			2			0.58			0.29046			0.97		
12/06/21 17:00	1.4			1.5			2			0.6			0.30234			1.01		
12/06/21 18:00	1.3			1.5			3			0.62			0.31062			1.04		
12/06/21 19:00	1.5			1.5			2			0.61			0.30252			1.01		
12/06/21 20:00	1.3			1.5			2			0.61			0.30696			1.02		
12/06/21 21:00	1.4			1.5			2			0.61			0.3036			1.01		
12/06/21 22:00	1.4			1.5			2			0.58			0.28998			0.97		
12/06/21 23:00	0.8			1.5			2			0.55			0.2763			0.92		
12/07/21 0:00	0.8			1.5			2			0.5			0.25032			0.83		
12/07/21 1:00	0.7			1.4			4			0.4			0.19908			0.66		
12/07/21 2:00	0.6			1.4			5			0.35			0.17364			0.58		
12/07/21 3:00	0.6			1.3			5			0.35			0.17346			0.58		
12/07/21 4:00	0.8			1.3			2			0.42			0.2091			0.7		
12/07/21 5:00	0.6			1.8			4			0.35			0.17382			0.58		
12/07/21 6:00	0.7			1.4			3			0.42			0.21216			0.71		
12/07/21 7:00	0.7			1.5			2			0.56			0.27786			0.93		
12/07/21 8:00	0.7			1.5			2			0.55			0.27738			0.92		
12/07/21 9:00	0.7			1.5			2			0.55			0.27732			0.92		
12/07/21 10:00	0.7			1.7			3			0.48			0.23976			0.8		
12/07/21 11:00	0.8			1.6			3			0.42			0.2109			0.7		
12/07/21 12:00	0.7			1.4			2			0.51			0.255			0.85		
12/07/21 13:00	0.7			1.5			2			0.56			0.27822			0.93		
12/07/21 14:00	0.7			1.5			2			0.55			0.27714			0.92		
12/07/21 15:00	0.7			1.5			2			0.54			0.27006			0.9		
12/07/21 16:00	1			1.5			2			0.57			0.2859			0.95		
12/07/21 17:00	1.4			1.5			2			0.6			0.30108			1		
12/07/21 18:00	1.2			1.5			2			0.63			0.31452			1.05		
12/07/21 19:00	0.8			1.5			3			0.66			0.33018			1.1		
12/07/21 20:00	1.3			1.5			2			0.61			0.30492			1.02		
12/07/21 21:00	1.3			1.5			2			0.61			0.30588			1.02		
12/07/21 22:00	1.3			1.5			2			0.61			0.30594			1.02		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/07/21 23:00	1.3			1.5			2			0.58			0.28758			0.96		
12/08/21 0:00	0.8			1.6			2			0.48			0.23814			0.79		
12/08/21 1:00	0.8			1.6			3			0.44			0.21924			0.73		
12/08/21 2:00	0.6			1.6			5			0.35			0.1731			0.58		
12/08/21 3:00	0.7			1.5			4			0.35			0.17472			0.58		
12/08/21 4:00	0.6			1.5			4			0.35			0.17622			0.59		
12/08/21 5:00	0.6			1.5			4			0.35			0.17586			0.59		
12/08/21 6:00	0.8			1.4			2			0.51			0.25584			0.85		
12/08/21 7:00	0.9			1.6			2			0.52			0.25956			0.87		
12/08/21 8:00	0.7			1.8			4			0.38			0.18864			0.63		
12/08/21 9:00	0.6			1.5			5			0.35			0.17316			0.58		
12/08/21 10:00	0.6			1.5			4			0.35			0.17328			0.58		
12/08/21 11:00	1.1			1.4			2			0.52			0.26028			0.87		
12/08/21 12:00	1.1			1.5			2			0.51			0.25734			0.86		
12/08/21 13:00	0.6			1.7			4			0.35			0.17556			0.59		
12/08/21 14:00	0.6			1.5			4			0.35			0.17328			0.58		
12/08/21 15:00	0.7			1.4			3			0.36			0.17952			0.6		
12/08/21 16:00	0.7			1.5			2			0.44			0.21858			0.73		
12/08/21 17:00	0.7			1.5			2			0.55			0.27594			0.92		
12/08/21 18:00	0.8			1.5			2			0.53			0.26604			0.89		
12/08/21 19:00	0.7			1.5			2			0.55			0.2772			0.92		
12/08/21 20:00	0.8			1.5			2			0.53			0.26646			0.89		
12/08/21 21:00	0.8			1.7			3			0.45			0.2265			0.76		
12/08/21 22:00	0.6			1.5			4			0.34			0.17238			0.57		
12/08/21 23:00	0.6			1.5			4			0.34			0.17244			0.57		
12/09/21 0:00	0.6			1.5			4			0.35			0.17358			0.58		
12/09/21 1:00	0.6			1.5			4			0.35			0.1737			0.58		
12/09/21 2:00	0.6			1.5			4			0.35			0.17298			0.58		
12/09/21 3:00	0.6			1.5			4			0.35			0.17346			0.58		
12/09/21 4:00	0.6			1.5			4			0.35			0.17382			0.58		
12/09/21 5:00	0.6			1.5			4			0.35			0.17358			0.58		
12/09/21 6:00	0.7			1.4			2			0.45			0.22446			0.75		
12/09/21 7:00	0.8			1.8			3			0.4			0.19902			0.66		
12/09/21 8:00	0.7			1.6			4			0.36			0.18192			0.61		
12/09/21 9:00	0.8			1.4			2			0.46			0.23004			0.77		
12/09/21 10:00	0.7			1.6			3			0.4			0.20136			0.67		
12/09/21 11:00	0.6			1.8			4			0.35			0.17292			0.58		
12/09/21 12:00	0.6			1.5			4			0.36			0.17754			0.59		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/09/21 13:00	0.6			1.5			4			0.34			0.17232			0.57		
12/09/21 14:00	0.6			1.5			4			0.34			0.17214			0.57		
12/09/21 15:00	0.6			1.4			3			0.36			0.1782			0.59		
12/09/21 16:00	0.7			1.5			2			0.47			0.23442			0.78		
12/09/21 17:00	0.8			1.6			2			0.47			0.23292			0.78		
12/09/21 18:00	0.8			1.7			3			0.4			0.19788			0.66		
12/09/21 19:00	0.8			1.6			3			0.44			0.22146			0.74		
12/09/21 20:00	0.8			1.5			2			0.5			0.252			0.84		
12/09/21 21:00	0.8			1.6			3			0.47			0.23508			0.78		
12/09/21 22:00	0.8			1.7			3			0.4			0.19938			0.66		
12/09/21 23:00	0.6			1.8			5			0.35			0.17286			0.58		
12/10/21 0:00	0.6			1.6			5			0.35			0.17568			0.59		
12/10/21 1:00	0.6			1.6			5			0.35			0.17376			0.58		
12/10/21 2:00	0.6			1.5			5			0.35			0.17358			0.58		
12/10/21 3:00	0.7			1.6			5			0.35			0.17364			0.58		
12/10/21 4:00	0.7			1.5			5			0.35			0.17322			0.58		
12/10/21 5:00	0.7			1.4			4			0.38			0.19158			0.64		
12/10/21 6:00	0.7			1.6			3			0.46			0.23232			0.77		
12/10/21 7:00	0.8			1.5			2			0.55			0.2736			0.91		
12/10/21 8:00	0.7			1.8			4			0.4			0.20154			0.67		
12/10/21 9:00	0.6			1.7			5			0.35			0.17322			0.58		
12/10/21 10:00	0.6			1.5			4			0.38			0.1914			0.64		
12/10/21 11:00	0.7			1.5			2			0.53			0.26592			0.89		
12/10/21 12:00	0.7			1.6			4			0.42			0.21072			0.7		
12/10/21 13:00	0.6			1.6			4			0.35			0.17538			0.58		
12/10/21 14:00	0.6			1.5			5			0.35			0.17286			0.58		
12/10/21 15:00	0.6			1.4			3			0.43			0.2172			0.72		
12/10/21 16:00	0.7			1.5			2			0.54			0.26988			0.9		
12/10/21 17:00	0.7			1.5			2			0.56			0.27774			0.93		
12/10/21 18:00	0.7			1.5			2			0.56			0.27768			0.93		
12/10/21 19:00	0.8			1.5			2			0.56			0.27822			0.93		
12/10/21 20:00	0.9			1.5			3			0.56			0.27882			0.93		
12/10/21 21:00	0.8			1.5			2			0.56			0.27864			0.93		
12/10/21 22:00	0.8			1.5			2			0.56			0.27846			0.93		
12/10/21 23:00	0.8			1.5			2			0.56			0.27888			0.93		
12/11/21 0:00	0.8			1.6			4			0.42			0.2118			0.71		
12/11/21 1:00	0.6			1.6			5			0.35			0.17424			0.58		
12/11/21 2:00	0.6			1.5			5			0.35			0.17424			0.58		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/11/21 3:00	0.6			1.6			5			0.35			0.17388			0.58		
12/11/21 4:00	0.6			1.6			5			0.35			0.17406			0.58		
12/11/21 5:00	0.6			1.6			5			0.35			0.1746			0.58		
12/11/21 6:00	0.7			1.5			4			0.38			0.19152			0.64		
12/11/21 7:00	0.6			1.8			4			0.4			0.19902			0.66		
12/11/21 8:00	0.5			1.7			5			0.35			0.1734			0.58		
12/11/21 9:00	0.6			1.5			5			0.35			0.17364			0.58		
12/11/21 10:00	0.6			1.5			5			0.35			0.17358			0.58		
12/11/21 11:00	0.6			1.5			4			0.35			0.1737			0.58		
12/11/21 12:00	0.6			1.5			4			0.35			0.17352			0.58		
12/11/21 13:00	0.6			1.5			3			0.35			0.17346			0.58		
12/11/21 14:00	0.6			1.5			3			0.35			0.17322			0.58		
12/11/21 15:00	0.6			1.5			4			0.35			0.1737			0.58		
12/11/21 16:00	0.7			1.4			2			0.47			0.23376			0.78		
12/11/21 17:00	0.8			1.5			2			0.52			0.25782			0.86		
12/11/21 18:00	0.8			1.6			3			0.5			0.25176			0.84		
12/11/21 19:00	0.8			1.4			2			0.55			0.27672			0.92		
12/11/21 20:00	0.8			1.5			2			0.55			0.27636			0.92		
12/11/21 21:00	0.8			1.5			2			0.56			0.27978			0.93		
12/11/21 22:00	0.8			1.5			2			0.56			0.2799			0.93		
12/11/21 23:00	0.8			1.6			3			0.44			0.22212			0.74		
12/12/21 0:00	0.8			1.6			3			0.46			0.23124			0.77		
12/12/21 1:00	0.6			1.5			4			0.35			0.17406			0.58		
12/12/21 2:00	0.6			1.5			3			0.35			0.17568			0.59		
12/12/21 3:00	0.8			1.5			2			0.51			0.25596			0.85		
12/12/21 4:00	0.9			1.6			3			0.41			0.20328			0.68		
12/12/21 5:00	0.6			1.6			4			0.35			0.17448			0.58		
12/12/21 6:00	0.7			1.5			3			0.41			0.2037			0.68		
12/12/21 7:00	0.7			1.6			4			0.39			0.19392			0.65		
12/12/21 8:00	0.7			1.6			3			0.39			0.19338			0.64		
12/12/21 9:00	0.6			1.5			4			0.36			0.17844			0.59		
12/12/21 10:00	0.6			1.5			4			0.35			0.17352			0.58		
12/12/21 11:00	0.6			1.5			4			0.35			0.17328			0.58		
12/12/21 12:00	0.6			1.5			4			0.35			0.17286			0.58		
12/12/21 13:00	0.6			1.5			4			0.35			0.17298			0.58		
12/12/21 14:00	0.6			1.4			4			0.35			0.17562			0.59		
12/12/21 15:00	0.7			1.5			3			0.38			0.19032			0.63		
12/12/21 16:00	0.7			1.6			2			0.46			0.23244			0.77		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/12/21 17:00	0.8			1.5			2			0.51			0.2541			0.85		
12/12/21 18:00	0.7			1.5			2			0.51			0.25416			0.85		
12/12/21 19:00	0.7			1.5			2			0.55			0.27342			0.91		
12/12/21 20:00	0.7			1.5			2			0.52			0.26226			0.87		
12/12/21 21:00	0.7			1.5			3			0.49			0.24402			0.81		
12/12/21 22:00	0.7			1.5			3			0.44			0.22032			0.73		
12/12/21 23:00	0.6			1.5			4			0.35			0.17274			0.58		
12/13/21 0:00	0.6			1.5			4			0.35			0.1731			0.58		
12/13/21 1:00	0.6			1.5			4			0.35			0.17364			0.58		
12/13/21 2:00	0.6			1.5			4			0.35			0.17358			0.58		
12/13/21 3:00	0.6			1.6			4			0.35			0.17274			0.58		
12/13/21 4:00	0.6			1.5			4			0.35			0.17256			0.58		
12/13/21 5:00	0.6			1.5			4			0.35			0.17256			0.58		
12/13/21 6:00	0.7			1.4			2			0.46			0.22776			0.76		
12/13/21 7:00	0.7			1.5			2			0.54			0.2706			0.9		
12/13/21 8:00	0.7			1.5			2			0.53			0.26508			0.88		
12/13/21 9:00	0.7			1.5			2			0.54			0.27018			0.9		
12/13/21 10:00	0.7			1.7			3			0.47			0.23268			0.78		
12/13/21 11:00	0.7			1.6			3			0.38			0.1911			0.64		
12/13/21 12:00	0.7			1.5			2			0.55			0.27378			0.91		
12/13/21 13:00	0.7			1.5			2			0.56			0.2811			0.94		
12/13/21 14:00	0.7			1.5			2			0.56			0.27774			0.93		
12/13/21 15:00	0.7			1.5			2			0.56			0.2778			0.93		
12/13/21 16:00	0.8			1.5			3			0.57			0.28632			0.95		
12/13/21 17:00	1.1			1.5			3			0.63			0.31362			1.05		
12/13/21 18:00	1.2			1.5			3			0.61			0.30648			1.02		
12/13/21 19:00	1.2			1.5			3			0.61			0.30648			1.02		
12/13/21 20:00	1.2			1.5			3			0.61			0.30642			1.02		
12/13/21 21:00	1.2			1.5			3			0.61			0.30648			1.02		
12/13/21 22:00	1.1			1.7			3			0.49			0.2463			0.82		
12/13/21 23:00	0.6			1.7			5			0.35			0.17304			0.58		
12/14/21 0:00	0.6			1.6			5			0.35			0.17364			0.58		
12/14/21 1:00	0.6			1.5			4			0.35			0.17328			0.58		
12/14/21 2:00	0.6			1.5			4			0.35			0.17304			0.58		
12/14/21 3:00	0.6			1.6			5			0.35			0.17268			0.58		
12/14/21 4:00	0.6			1.6			5			0.34			0.17208			0.57		
12/14/21 5:00	0.7			1.4			3			0.4			0.20214			0.67		
12/14/21 6:00	0.8			1.6			3			0.49			0.24384			0.81		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/14/21 7:00	0.7			1.8			4			0.37			0.18402			0.61		
12/14/21 8:00	0.6			1.8			5			0.35			0.17454			0.58		
12/14/21 9:00	0.6			1.6			5			0.35			0.17304			0.58		
12/14/21 10:00	0.6			1.5			5			0.35			0.17316			0.58		
12/14/21 11:00	0.6			1.5			5			0.35			0.17298			0.58		
12/14/21 12:00	0.6			1.5			5			0.35			0.17268			0.58		
12/14/21 13:00	0.6			1.5			4			0.35			0.17286			0.58		
12/14/21 14:00	0.6			1.5			5			0.34			0.17244			0.57		
12/14/21 15:00	0.6			1.5			4			0.35			0.1728			0.58		
12/14/21 16:00	0.6			1.4			3			0.39			0.19302			0.64		
12/14/21 17:00	0.7			1.6			2			0.53			0.264			0.88		
12/14/21 18:00	0.8			1.5			2			0.52			0.25758			0.86		
12/14/21 19:00	0.8			1.5			2			0.53			0.2664			0.89		
12/14/21 20:00	0.8			1.5			2			0.56			0.27768			0.93		
12/14/21 21:00	0.8			1.5			2			0.55			0.2772			0.92		
12/14/21 22:00	0.8			1.5			2			0.51			0.25374			0.85		
12/14/21 23:00	0.6			1.8			5			0.35			0.17328			0.58		
12/15/21 0:00	0.6			1.5			4			0.36			0.17946			0.6		
12/15/21 1:00	0.6			1.6			5			0.35			0.17334			0.58		
12/15/21 2:00	0.6			1.5			5			0.35			0.17352			0.58		
12/15/21 3:00	0.6			1.6			5			0.35			0.17352			0.58		
12/15/21 4:00	0.7			1.4			3			0.45			0.22746			0.76		
12/15/21 5:00	0.7			1.5			2			0.56			0.27846			0.93		
12/15/21 6:00	0.7			1.5			2			0.56			0.27804			0.93		
12/15/21 7:00	0.7			1.6			2			0.51			0.25494			0.85		
12/15/21 8:00	0.6			1.7			4			0.37			0.18312			0.61		
12/15/21 9:00	0.6			1.6			5			0.35			0.1746			0.58		
12/15/21 10:00	0.6			1.4			5			0.35			0.17436			0.58		
12/15/21 11:00	0.6			1.2			3			0.37			0.1827			0.61		
12/15/21 12:00	0.6			1.4			2			0.48			0.23964			0.8		
12/15/21 13:00	0.6			1.7			3			0.45			0.22578			0.75		
12/15/21 14:00	0.5			1.5			5			0.35			0.17328			0.58		
12/15/21 15:00	0.6			1.4			3			0.4			0.19782			0.66		
12/15/21 16:00	0.7			1.5			2			0.48			0.24222			0.81		
12/15/21 17:00	0.6			1.5			2			0.56			0.27768			0.93		
12/15/21 18:00	0.6			1.5			2			0.55			0.27474			0.92		
12/15/21 19:00	0.6			1.5			2			0.55			0.27576			0.92		
12/15/21 20:00	0.6			1.5			2			0.56			0.27942			0.93		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/15/21 21:00	0.6			1.5			2			0.54			0.26814			0.89		
12/15/21 22:00	0.6			1.5			2			0.52			0.25926			0.86		
12/15/21 23:00	0.7			1.5			2			0.5			0.25242			0.84		
12/16/21 0:00	0.7			1.5			3			0.51			0.25518			0.85		
12/16/21 1:00	0.7			1.7			3			0.45			0.22284			0.74		
12/16/21 2:00	0.5			1.6			5			0.35			0.17316			0.58		
12/16/21 3:00	0.6			1.5			5			0.35			0.17322			0.58		
12/16/21 4:00	0.9			1.4			2			0.49			0.24606			0.82		
12/16/21 5:00	1.5			1.5			2			0.6			0.3012			1		
12/16/21 6:00	1.3			1.5			3			0.61			0.30474			1.02		
12/16/21 7:00	1.2			1.5			3			0.61			0.3054			1.02		
12/16/21 8:00	1.3			1.5			3			0.6			0.29934			1		
12/16/21 9:00	1.2			1.5			2			0.57			0.28716			0.96		
12/16/21 10:00	1.4			1.5			3			0.6			0.30078			1		
12/16/21 11:00	0.9			1.6			3			0.49			0.24276			0.81		
12/16/21 12:00	0.5			1.5			4			0.35			0.17364			0.58		
12/16/21 13:00	0.5			1.5			4			0.35			0.17706			0.59		
12/16/21 14:00	0.6			1.6			3			0.42			0.2094			0.7		
12/16/21 15:00	0.8			1.1			3			0.51			0.25494			0.85		
12/16/21 16:00	1.3			1.4			3			0.6			0.30168			1.01		
12/16/21 17:00	1.4			1.4			3			0.6			0.29772			0.99		
12/16/21 18:00	1.4			1.4			3			0.6			0.29862			1		
12/16/21 19:00	1.2			1.5			3			0.61			0.3042			1.01		
12/16/21 20:00	1.5			1.5			3			0.6			0.30198			1.01		
12/16/21 21:00	0.5			1.5			4			0.72			0.36192			1.21		
12/16/21 22:00	1.2			1.5			3			0.63			0.31464			1.05		
12/16/21 23:00	0.9			1.7			4			0.44			0.21978			0.73		
12/17/21 0:00	0.5			1.5			4			0.35			0.17352			0.58		
12/17/21 1:00	0.6			1.6			5			0.35			0.17538			0.58		
12/17/21 2:00	0.6			1.5			5			0.35			0.17604			0.59		
12/17/21 3:00	0.6			1.5			5			0.35			0.17562			0.59		
12/17/21 4:00	1.1			1.4			3			0.5			0.25098			0.84		
12/17/21 5:00	1.6			1.4			3			0.6			0.30102			1		
12/17/21 6:00	1.4			1.4			3			0.62			0.3102			1.03		
12/17/21 7:00	1.2			1.4			3			0.62			0.30828			1.03		
12/17/21 8:00	1.1			1.5			4			0.5			0.2499			0.83		
12/17/21 9:00	0.6			1.7			5			0.35			0.17538			0.58		
12/17/21 10:00	0.5			1.6			5			0.35			0.1758			0.59		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/17/21 11:00	0.5			1.6			5			0.35			0.17454			0.58		
12/17/21 12:00	0.5			1.6			5			0.35			0.17442			0.58		
12/17/21 13:00	0.5			1.5			5			0.35			0.17442			0.58		
12/17/21 14:00	0.5			1.6			5			0.35			0.17388			0.58		
12/17/21 15:00	0.9			1.4			2			0.48			0.24222			0.81		
12/17/21 16:00	1.4			1.5			2			0.61			0.30528			1.02		
12/17/21 17:00	1.5			1.5			3			0.6			0.30114			1		
12/17/21 18:00	1.5			1.5			3			0.6			0.30156			1.01		
12/17/21 19:00	1.5			1.5			3			0.6			0.30204			1.01		
12/17/21 20:00	1.5			1.5			3			0.6			0.3021			1.01		
12/17/21 21:00	1.5			1.5			3			0.6			0.30156			1.01		
12/17/21 22:00	1.6			1.5			3			0.6			0.3021			1.01		
12/17/21 23:00	1.2			1.6			3			0.51			0.25314			0.84		
12/18/21 0:00	0.7			1.5			3			0.48			0.24162			0.81		
12/18/21 1:00	0.9			1.5			3			0.51			0.25518			0.85		
12/18/21 2:00	0.9			1.6			3			0.49			0.24486			0.82		
12/18/21 3:00	0.9			1.5			4			0.41			0.20298			0.68		
12/18/21 4:00	0.8			1.5			3			0.47			0.2334			0.78		
12/18/21 5:00	1			1.6			3			0.5			0.24966			0.83		
12/18/21 6:00	1.5			1.5			3			0.6			0.3024			1.01		
12/18/21 7:00	0.9			1.7			3			0.48			0.24006			0.8		
12/18/21 8:00	0.6			1.8			4			0.38			0.18828			0.63		
12/18/21 9:00	0.6			1.7			5			0.37			0.18426			0.61		
12/18/21 10:00	0.6			1.4			2			0.55			0.27708			0.92		
12/18/21 11:00	0.6			1.7			4			0.43			0.21702			0.72		
12/18/21 12:00	0.5			1.7			5			0.35			0.17412			0.58		
12/18/21 13:00	0.5			1.6			5			0.35			0.17466			0.58		
12/18/21 14:00	0.5			1.6			5			0.35			0.17424			0.58		
12/18/21 15:00	0.5			1.4			4			0.38			0.18984			0.63		
12/18/21 16:00	1			1.5			3			0.51			0.25296			0.84		
12/18/21 17:00	1.5			1.4			3			0.6			0.3009			1		
12/18/21 18:00	1.5			1.4			3			0.6			0.30132			1		
12/18/21 19:00	1.6			1.4			3			0.6			0.3012			1		
12/18/21 20:00	1.6			1.4			3			0.6			0.3012			1		
12/18/21 21:00	1.6			1.4			3			0.61			0.30252			1.01		
12/18/21 22:00	1.5			1.4			3			0.6			0.30234			1.01		
12/18/21 23:00	0.9			1.6			4			0.44			0.2211			0.74		
12/19/21 0:00	0.7			1.3			3			0.51			0.25434			0.85		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/19/21 1:00	0.7			1.3			3			0.51			0.25368			0.85		
12/19/21 2:00	0.7			1.6			3			0.49			0.24336			0.81		
12/19/21 3:00	0.6			1.7			5			0.35			0.1743			0.58		
12/19/21 4:00	0.5			1.6			5			0.35			0.17322			0.58		
12/19/21 5:00	0.9			1.3			3			0.48			0.24216			0.81		
12/19/21 6:00	1.2			1.4			3			0.51			0.2565			0.86		
12/19/21 7:00	0.6			1.6			4			0.39			0.19284			0.64		
12/19/21 8:00	0.5			1.6			5			0.35			0.17382			0.58		
12/19/21 9:00	0.7			1.3			3			0.49			0.24258			0.81		
12/19/21 10:00	0.7			1.3			2			0.54			0.26814			0.89		
12/19/21 11:00	0.6			1.7			4			0.38			0.19116			0.64		
12/19/21 12:00	0.5			1.6			5			0.35			0.1737			0.58		
12/19/21 13:00	0.5			1.4			5			0.35			0.17634			0.59		
12/19/21 14:00	0.6			1.3			3			0.4			0.20064			0.67		
12/19/21 15:00	0.8			1.4			3			0.5			0.25026			0.83		
12/19/21 16:00	1.6			1.3			3			0.6			0.29964			1		
12/19/21 17:00	1.6			1.3			3			0.6			0.30186			1.01		
12/19/21 18:00	1.6			1.3			3			0.6			0.30048			1		
12/19/21 19:00	1.4			1.4			3			0.6			0.30162			1.01		
12/19/21 20:00	1.3			1.4			3			0.6			0.30084			1		
12/19/21 21:00	1.4			1.4			3			0.6			0.30102			1		
12/19/21 22:00	1.3			1.4			3			0.55			0.27504			0.92		
12/19/21 23:00	0.9			1.5			3			0.47			0.23622			0.79		
12/20/21 0:00	0.7			1.7			4			0.38			0.192			0.64		
12/20/21 1:00	0.9			1.3			3			0.46			0.22788			0.76		
12/20/21 2:00	0.8			1.3			3			0.46			0.23232			0.77		
12/20/21 3:00	0.9			1.5			4			0.43			0.2157			0.72		
12/20/21 4:00	0.9			1.6			4			0.38			0.1917			0.64		
12/20/21 5:00	1.2			1.3			3			0.55			0.27684			0.92		
12/20/21 6:00	1.4			1.5			3			0.62			0.30774			1.03		
12/20/21 7:00	1.2			1.5			3			0.58			0.29232			0.97		
12/20/21 8:00	0.7			1.6			4			0.46			0.23154			0.77		
12/20/21 9:00	0.7			1.6			4			0.38			0.18756			0.63		
12/20/21 10:00	0.6			1.9			5			0.35			0.17526			0.58		
12/20/21 11:00	0.7			1.4			4			0.4			0.20214			0.67		
12/20/21 12:00	0.7			1.1			2			0.54			0.26988			0.9		
12/20/21 13:00	0.6			1.1			2			0.56			0.27912			0.93		
12/20/21 14:00	0.8			1.3			3			0.62			0.31062			1.04		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/20/21 15:00	0.5			1.4			3			0.71			0.3555			1.19		
12/20/21 16:00	1.1			1.4			3			0.64			0.3201			1.07		
12/20/21 17:00	0.5			1.4			4			0.72			0.35892			1.2		
12/20/21 18:00	0.8			1.4			3			0.67			0.33624			1.12		
12/20/21 19:00	0.7			1.4			3			0.69			0.34458			1.15		
12/20/21 20:00	0.4			1.4			4			0.73			0.3657			1.22		
12/20/21 21:00	0.7			1.4			3			0.69			0.34332			1.14		
12/20/21 22:00	0.8			1.4			3			0.65			0.32706			1.09		
12/20/21 23:00	1.1			1.4			3			0.61			0.3033			1.01		
12/21/21 0:00	0.7			1.4			3			0.56			0.2781			0.93		
12/21/21 1:00	0.7			1.4			3			0.55			0.27654			0.92		
12/21/21 2:00	0.8			1.4			3			0.55			0.27666			0.92		
12/21/21 3:00	0.9			1.4			3			0.53			0.26268			0.88		
12/21/21 4:00	0.8			1.4			3			0.5			0.24816			0.83		
12/21/21 5:00	0.8			1.5			3			0.5			0.249			0.83		
12/21/21 6:00	0.7			1.5			2			0.54			0.26808			0.89		
12/21/21 7:00	0.9			1.5			3			0.57			0.28344			0.94		
12/21/21 8:00	0.4			1.5			4			0.76			0.38166			1.27		
12/21/21 9:00	0.3			1.5			4			0.76			0.38058			1.27		
12/21/21 10:00	1.6			1.5			3			0.6			0.29838			0.99		
12/21/21 11:00	0.8			1.7			3			0.49			0.2442			0.81		
12/21/21 12:00	0.6			1.6			3			0.46			0.2298			0.77		
12/21/21 13:00	0.6			1.5			2			0.54			0.27108			0.9		
12/21/21 14:00	1			1.5			2			0.57			0.28728			0.96		
12/21/21 15:00	1.5			1.5			3			0.6			0.30192			1.01		
12/21/21 16:00	1.3			1.5			3			0.61			0.30456			1.02		
12/21/21 17:00	1.5			1.5			3			0.6			0.30048			1		
12/21/21 18:00	1.4			1.5			3			0.6			0.3003			1		
12/21/21 19:00	1.3			1.5			3			0.6			0.30024			1		
12/21/21 20:00	1.3			1.5			3			0.6			0.30132			1		
12/21/21 21:00	1.4			1.5			3			0.6			0.3012			1		
12/21/21 22:00	1.5			1.5			3			0.6			0.30108			1		
12/21/21 23:00	1.1			1.7			3			0.5			0.24888			0.83		
12/22/21 0:00	0.5			1.7			5			0.35			0.17448			0.58		
12/22/21 1:00	0.5			1.6			5			0.35			0.1743			0.58		
12/22/21 2:00	0.5			1.6			5			0.35			0.17412			0.58		
12/22/21 3:00	0.6			1.6			5			0.35			0.17412			0.58		
12/22/21 4:00	0.5			1.6			5			0.35			0.17478			0.58		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/22/21 5:00	1.3			1.4			2			0.56			0.27834			0.93		
12/22/21 6:00	1.6			1.4			3			0.6			0.30024			1		
12/22/21 7:00	1.6			1.4			3			0.6			0.30048			1		
12/22/21 8:00	1.6			1.4			3			0.6			0.30078			1		
12/22/21 9:00	1.6			1.4			3			0.6			0.30144			1		
12/22/21 10:00	1.2			1.5			3			0.51			0.25608			0.85		
12/22/21 11:00	0.6			1.7			5			0.35			0.17442			0.58		
12/22/21 12:00	0.6			1.5			5			0.35			0.17514			0.58		
12/22/21 13:00	0.9			1.4			2			0.5			0.24792			0.83		
12/22/21 14:00	1.3			1.5			3			0.62			0.30906			1.03		
12/22/21 15:00	1.3			1.5			3			0.61			0.30714			1.02		
12/22/21 16:00	1.3			1.5			3			0.61			0.3063			1.02		
12/22/21 17:00	1.2			1.5			3			0.61			0.30678			1.02		
12/22/21 18:00	1.2			1.5			3			0.61			0.30648			1.02		
12/22/21 19:00	1.3			1.5			3			0.6			0.30078			1		
12/22/21 20:00	0.7			1.7			4			0.36			0.17814			0.59		
12/22/21 21:00	0.6			1.5			4			0.36			0.17832			0.59		
12/22/21 22:00	0.7			1.6			3			0.39			0.19578			0.65		
12/22/21 23:00	0.6			1.5			3			0.36			0.17958			0.6		
12/23/21 0:00	0.7			1.5			2			0.46			0.23034			0.77		
12/23/21 1:00	0.7			1.5			3			0.38			0.18828			0.63		
12/23/21 2:00	0.6			1.4			4			0.35			0.17652			0.59		
12/23/21 3:00	0.6			1.6			4			0.35			0.17412			0.58		
12/23/21 4:00	0.6			1.5			4			0.35			0.17352			0.58		
12/23/21 5:00	0.6			1.5			4			0.35			0.17388			0.58		
12/23/21 6:00	0.6			1.5			4			0.35			0.17454			0.58		
12/23/21 7:00	0.6			1.5			4			0.35			0.17412			0.58		
12/23/21 8:00	0.6			1.5			4			0.35			0.17412			0.58		
12/23/21 9:00	0.6			1.5			4			0.35			0.17412			0.58		
12/23/21 10:00	0.6			1.5			3			0.35			0.17484			0.58		
12/23/21 11:00	0.6			1.5			3			0.35			0.17448			0.58		
12/23/21 12:00	0.6			1.5			3			0.35			0.17406			0.58		
12/23/21 13:00	0.6			1.5			3			0.35			0.17442			0.58		
12/23/21 14:00	0.6			1.5			3			0.35			0.17442			0.58		
12/23/21 15:00	0.6			1.5			3			0.35			0.17424			0.58		
12/23/21 16:00	0.6			1.5			3			0.35			0.17406			0.58		
12/23/21 17:00	0.6			1.5			3			0.35			0.17418			0.58		
12/23/21 18:00	0.6			1.5			3			0.35			0.17478			0.58		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/23/21 19:00	0.6			1.5			4			0.35			0.1734			0.58		
12/23/21 20:00	0.6			1.5			4			0.35			0.1737			0.58		
12/23/21 21:00	0.6			1.5			4			0.35			0.17316			0.58		
12/23/21 22:00	0.6			1.5			4			0.35			0.17286			0.58		
12/23/21 23:00	0.6			1.5			4			0.35			0.17376			0.58		
12/24/21 0:00	0.6			1.5			4			0.35			0.17406			0.58		
12/24/21 1:00	0.6			1.5			4			0.35			0.17406			0.58		
12/24/21 2:00	0.6			1.5			4			0.35			0.17382			0.58		
12/24/21 3:00	0.6			1.6			4			0.35			0.17418			0.58		
12/24/21 4:00	0.6			1.5			4			0.35			0.17418			0.58		
12/24/21 5:00	0.6			1.5			4			0.35			0.17424			0.58		
12/24/21 6:00	0.6			1.5			4			0.35			0.1743			0.58		
12/24/21 7:00	0.6			1.5			4			0.35			0.1743			0.58		
12/24/21 8:00	0.6			1.5			4			0.35			0.177			0.59		
12/24/21 9:00	0.6			1.5			4			0.35			0.17436			0.58		
12/24/21 10:00	0.5			1.5			4			0.35			0.17454			0.58		
12/24/21 11:00	0.5			1.5			4			0.35			0.17412			0.58		
12/24/21 12:00	0.5			1.5			4			0.35			0.17412			0.58		
12/24/21 13:00	0.5			1.5			4			0.35			0.174			0.58		
12/24/21 14:00	0.5			1.5			4			0.35			0.17412			0.58		
12/24/21 15:00	0.5			1.5			4			0.35			0.17406			0.58		
12/24/21 16:00	0.5			1.5			4			0.35			0.17442			0.58		
12/24/21 17:00	0.5			1.5			4			0.35			0.17418			0.58		
12/24/21 18:00	0.6			1.5			4			0.35			0.17364			0.58		
12/24/21 19:00	0.6			1.5			4			0.35			0.17358			0.58		
12/24/21 20:00	0.6			1.5			4			0.35			0.1734			0.58		
12/24/21 21:00	0.6			1.5			4			0.35			0.17364			0.58		
12/24/21 22:00	0.6			1.5			4			0.35			0.17334			0.58		
12/24/21 23:00	0.6			1.5			4			0.35			0.17352			0.58		
12/25/21 0:00	0.6			1.5			4			0.35			0.17376			0.58		
12/25/21 1:00	0.6			1.5			4			0.35			0.17376			0.58		
12/25/21 2:00	0.6			1.5			4			0.35			0.17358			0.58		
12/25/21 3:00	0.6			1.6			5			0.35			0.1734			0.58		
12/25/21 4:00	0.6			1.5			4			0.35			0.17358			0.58		
12/25/21 5:00	0.6			1.5			4			0.35			0.1737			0.58		
12/25/21 6:00	0.6			1.5			4			0.35			0.17346			0.58		
12/25/21 7:00	0.6			1.5			4			0.35			0.174			0.58		
12/25/21 8:00	0.6			1.5			4			0.35			0.17358			0.58		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/25/21 9:00	0.5			1.5			4			0.35			0.1734			0.58		
12/25/21 10:00	0.6			1.5			4			0.35			0.17412			0.58		
12/25/21 11:00	0.6			1.5			4			0.35			0.17436			0.58		
12/25/21 12:00	0.6			1.6			4			0.35			0.1746			0.58		
12/25/21 13:00	0.6			1.5			4			0.35			0.17514			0.58		
12/25/21 14:00	0.6			1.5			4			0.35			0.17526			0.58		
12/25/21 15:00	0.6			1.4			4			0.36			0.18174			0.61		
12/25/21 16:00	0.6			1.7			4			0.35			0.17436			0.58		
12/25/21 17:00	0.6			1.6			4			0.35			0.17466			0.58		
12/25/21 18:00	0.6			1.6			4			0.35			0.17424			0.58		
12/25/21 19:00	0.6			1.6			4			0.35			0.17418			0.58		
12/25/21 20:00	0.6			1.6			4			0.35			0.17454			0.58		
12/25/21 21:00	0.5			1.6			5			0.35			0.17424			0.58		
12/25/21 22:00	0.5			1.6			5			0.35			0.17376			0.58		
12/25/21 23:00	0.5			1.6			5			0.35			0.17328			0.58		
12/26/21 0:00	0.5			1.6			5			0.35			0.17316			0.58		
12/26/21 1:00	0.5			1.6			5			0.35			0.17322			0.58		
12/26/21 2:00	0.5			1.5			5			0.35			0.17328			0.58		
12/26/21 3:00	0.6			1.6			5			0.35			0.17454			0.58		
12/26/21 4:00	0.5			1.5			5			0.35			0.1746			0.58		
12/26/21 5:00	0.5			1.5			5			0.35			0.17514			0.58		
12/26/21 6:00	0.6			1.5			5			0.35			0.17538			0.58		
12/26/21 7:00	0.5			1.6			4			0.35			0.17742			0.59		
12/26/21 8:00	0.5			1.6			5			0.35			0.17376			0.58		
12/26/21 9:00	0.5			1.6			5			0.35			0.17454			0.58		
12/26/21 10:00	0.5			1.6			5			0.35			0.17478			0.58		
12/26/21 11:00	0.6			1.5			4			0.36			0.17832			0.59		
12/26/21 12:00	0.6			1.5			5			0.35			0.17586			0.59		
12/26/21 13:00	0.6			1.5			4			0.38			0.18804			0.63		
12/26/21 14:00	0.6			1.6			4			0.36			0.18036			0.6		
12/26/21 15:00	0.6			1.6			4			0.36			0.18078			0.6		
12/26/21 16:00	0.8			1			4			0.49			0.2454			0.82		
12/26/21 17:00	1.5			1.4			2			0.61			0.3039			1.01		
12/26/21 18:00	0.9			1.8			4			0.44			0.21786			0.73		
12/26/21 19:00	0.6			1.7			5			0.35			0.1761			0.59		
12/26/21 20:00	0.6			1.5			5			0.36			0.18			0.6		
12/26/21 21:00	0.7			1.5			2			0.52			0.261			0.87		
12/26/21 22:00	0.6			1.9			4			0.39			0.19512			0.65		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/26/21 23:00	0.6			1.7			5			0.35			0.17502			0.58		
12/27/21 0:00	0.6			1.6			5			0.35			0.1761			0.59		
12/27/21 1:00	0.6			1.6			5			0.35			0.17502			0.58		
12/27/21 2:00	0.6			1.6			5			0.35			0.17508			0.58		
12/27/21 3:00	0.6			1.6			5			0.35			0.17484			0.58		
12/27/21 4:00	0.6			1.6			5			0.35			0.17376			0.58		
12/27/21 5:00	0.9			1.5			3			0.49			0.24738			0.82		
12/27/21 6:00	1.3			1.5			3			0.61			0.30414			1.01		
12/27/21 7:00	1.3			1.5			3			0.61			0.30402			1.01		
12/27/21 8:00	1.3			1.5			3			0.61			0.30678			1.02		
12/27/21 9:00	1			1.5			3			0.55			0.2763			0.92		
12/27/21 10:00	0.7			1.5			3			0.43			0.21612			0.72		
12/27/21 11:00	0.7			1.6			2			0.53			0.26568			0.89		
12/27/21 12:00	0.5			1.6			4			0.35			0.17376			0.58		
12/27/21 13:00	0.5			1.4			4			0.37			0.18372			0.61		
12/27/21 14:00	0.7			1.5			2			0.5			0.25158			0.84		
12/27/21 15:00	0.9			1.5			2			0.57			0.28386			0.95		
12/27/21 16:00	1.1			1.5			2			0.61			0.30618			1.02		
12/27/21 17:00	1.2			1.5			3			0.62			0.3096			1.03		
12/27/21 18:00	1.3			1.5			3			0.63			0.31278			1.04		
12/27/21 19:00	1.2			1.5			3			0.63			0.3156			1.05		
12/27/21 20:00	1.2			1.5			3			0.63			0.3168			1.06		
12/27/21 21:00	1.5			1.5			3			0.61			0.30294			1.01		
12/27/21 22:00	1.2			1.5			3			0.54			0.26886			0.9		
12/27/21 23:00	0.7			1.7			4			0.42			0.20934			0.7		
12/28/21 0:00	0.6			1.7			4			0.36			0.18096			0.6		
12/28/21 1:00	0.6			1.6			5			0.35			0.17526			0.58		
12/28/21 2:00	0.6			1.5			5			0.35			0.17556			0.59		
12/28/21 3:00	0.7			1.5			4			0.36			0.18018			0.6		
12/28/21 4:00	0.6			1.7			5			0.35			0.1755			0.59		
12/28/21 5:00	0.7			1.4			2			0.48			0.2403			0.8		
12/28/21 6:00	0.8			1.5			3			0.47			0.23544			0.78		
12/28/21 7:00	0.6			1.9			5			0.36			0.17994			0.6		
12/28/21 8:00	0.7			1.6			4			0.41			0.20484			0.68		
12/28/21 9:00	0.7			1.5			4			0.4			0.20088			0.67		
12/28/21 10:00	0.6			1.7			5			0.35			0.17412			0.58		
12/28/21 11:00	0.6			1.6			5			0.35			0.17394			0.58		
12/28/21 12:00	0.6			1.5			5			0.35			0.1743			0.58		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/28/21 13:00	0.5			1.5			5			0.35			0.17376			0.58		
12/28/21 14:00	0.5			1.5			5			0.35			0.17364			0.58		
12/28/21 15:00	0.6			1.3			3			0.41			0.2034			0.68		
12/28/21 16:00	0.6			1.6			3			0.46			0.22788			0.76		
12/28/21 17:00	0.6			1.5			2			0.56			0.28026			0.93		
12/28/21 18:00	0.7			1.5			2			0.53			0.26256			0.88		
12/28/21 19:00	0.8			1.4			3			0.48			0.2385			0.8		
12/28/21 20:00	0.7			1.6			3			0.47			0.23346			0.78		
12/28/21 21:00	0.7			1.6			4			0.37			0.18618			0.62		
12/28/21 22:00	0.6			1.5			4			0.35			0.17748			0.59		
12/28/21 23:00	0.6			1.5			4			0.35			0.17652			0.59		
12/29/21 0:00	0.6			1.5			5			0.35			0.17694			0.59		
12/29/21 1:00	0.6			1.5			4			0.35			0.17646			0.59		
12/29/21 2:00	0.6			1.4			5			0.35			0.174			0.58		
12/29/21 3:00	0.6			1.5			5			0.35			0.17364			0.58		
12/29/21 4:00	0.5			1.5			5			0.35			0.17388			0.58		
12/29/21 5:00	0.5			1.5			5			0.35			0.17526			0.58		
12/29/21 6:00	0.6			1.4			4			0.36			0.1806			0.6		
12/29/21 7:00	0.6			1.7			5			0.35			0.17418			0.58		
12/29/21 8:00	0.6			1.6			5			0.35			0.17406			0.58		
12/29/21 9:00	0.6			1.6			5			0.35			0.17358			0.58		
12/29/21 10:00	0.6			1.6			5			0.35			0.1734			0.58		
12/29/21 11:00	0.5			1.5			5			0.35			0.1737			0.58		
12/29/21 12:00	0.6			1.5			5			0.35			0.17412			0.58		
12/29/21 13:00	0.6			1.5			4			0.36			0.18234			0.61		
12/29/21 14:00	0.7			1.4			3			0.45			0.22332			0.74		
12/29/21 15:00	0.7			1.5			3			0.46			0.22818			0.76		
12/29/21 16:00	0.7			1.6			3			0.45			0.22548			0.75		
12/29/21 17:00	0.7			1.4			2			0.55			0.27522			0.92		
12/29/21 18:00	0.7			1.4			3			0.55			0.27666			0.92		
12/29/21 19:00	0.7			1.4			3			0.56			0.28014			0.93		
12/29/21 20:00	0.7			1.4			3			0.56			0.28038			0.93		
12/29/21 21:00	0.7			1.7			4			0.42			0.20952			0.7		
12/29/21 22:00	0.6			1.7			5			0.35			0.1764			0.59		
12/29/21 23:00	0.6			1.6			5			0.35			0.17436			0.58		
12/30/21 0:00	0.5			1.6			5			0.35			0.174			0.58		
12/30/21 1:00	0.6			1.6			5			0.35			0.17412			0.58		
12/30/21 2:00	0.6			1.5			5			0.35			0.17394			0.58		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/30/21 3:00	0.6			1.5			5			0.35			0.17364			0.58		
12/30/21 4:00	0.6			1.6			5			0.35			0.1743			0.58		
12/30/21 5:00	1.2			1.4			2			0.55			0.27516			0.92		
12/30/21 6:00	1.6			1.5			3			0.6			0.30012			1		
12/30/21 7:00	1.6			1.5			3			0.6			0.29964			1		
12/30/21 8:00	1.6			1.5			3			0.6			0.29994			1		
12/30/21 9:00	1.6			1.5			3			0.6			0.30036			1		
12/30/21 10:00	0.7			1.7			4			0.37			0.18666			0.62		
12/30/21 11:00	0.6			1.5			5			0.35			0.1746			0.58		
12/30/21 12:00	0.6			1.4			5			0.35			0.17478			0.58		
12/30/21 13:00	0.6			1.4			5			0.35			0.17478			0.58		
12/30/21 14:00	0.6			1.5			4			0.35			0.17514			0.58		
12/30/21 15:00	0.6			1.5			4			0.35			0.17544			0.58		
12/30/21 16:00	0.9			1.4			2			0.5			0.2481			0.83		
12/30/21 17:00	1.5			1.5			2			0.61			0.30312			1.01		
12/30/21 18:00	1.7			1.5			3			0.61			0.303			1.01		
12/30/21 19:00	1.5			1.5			3			0.61			0.30408			1.01		
12/30/21 20:00	1.7			1.5			3			0.61			0.30432			1.01		
12/30/21 21:00	1.6			1.5			3			0.61			0.3033			1.01		
12/30/21 22:00	1			1.5			4			0.46			0.22938			0.76		
12/30/21 23:00	0.6			1.6			4			0.35			0.17568			0.59		
12/31/21 0:00	0.6			1.6			5			0.35			0.1746			0.58		
12/31/21 1:00	0.6			1.6			5			0.35			0.17376			0.58		
12/31/21 2:00	0.6			1.5			5			0.35			0.174			0.58		
12/31/21 3:00	0.6			1.5			5			0.35			0.1743			0.58		
12/31/21 4:00	0.6			1.6			5			0.35			0.1743			0.58		
12/31/21 5:00	0.6			1.6			5			0.35			0.17382			0.58		
12/31/21 6:00	0.6			1.6			5			0.35			0.17418			0.58		
12/31/21 7:00	0.6			1.6			5			0.35			0.1746			0.58		
12/31/21 8:00	0.6			1.5			5			0.35			0.17538			0.58		
12/31/21 9:00	0.6			1.6			5			0.35			0.17592			0.59		
12/31/21 10:00	0.6			1.5			5			0.35			0.17472			0.58		
12/31/21 11:00	0.6			1.4			5			0.35			0.17328			0.58		
12/31/21 12:00	0.6			1.3			5			0.35			0.17328			0.58		
12/31/21 13:00	0.5			1.3			5			0.35			0.17322			0.58		
12/31/21 14:00	0.5			1.4			5			0.35			0.17298			0.58		
12/31/21 15:00	0.5			1.3			5			0.35			0.17298			0.58		
12/31/21 16:00	0.6			1.2			3			0.41			0.20346			0.68		

	CT1_CO_Ppmvdc_1H			CT1_NOx_Ppmvdc_1H			CT1_NH3Slip_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT1_SO2_LbPerHr_1H			CT1_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/31/21 17:00	0.8			1.4			2			0.45			0.2247			0.75		
12/31/21 18:00	0.7			1.3			2			0.49			0.24402			0.81		
12/31/21 19:00	0.7			1.3			2			0.54			0.2721			0.91		
12/31/21 20:00	0.7			1.3			3			0.5			0.2493			0.83		
12/31/21 21:00	0.6			1.4			2			0.54			0.27204			0.91		
12/31/21 22:00	0.8			1.4			3			0.47			0.23502			0.78		
12/31/21 23:00	0.7			1.7			4			0.37			0.1836			0.61		

AQ57 CT2 HOURLY EMISSIONS

Date/Time	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/01/21 0:00	0.9			0			1.3			0.39			0.20874			0.7		
10/01/21 1:00	0.8			1			1.6			0.35			0.18894			0.63		
10/01/21 2:00	0.7			1			1.5			0.34			0.18444			0.61		
10/01/21 3:00	0.7			0			1.5			0.35			0.18906			0.63		
10/01/21 4:00	0.7			0			1			0.45			0.24288			0.81		
10/01/21 5:00	0.8			0			1.5			0.48			0.26064			0.87		
10/01/21 6:00	0.8			1			1.4			0.4			0.21396			0.71		
10/01/21 7:00	0.8			1			1.1			0.38			0.20568			0.69		
10/01/21 8:00	0.7			1			1.5			0.34			0.18222			0.61		
10/01/21 9:00	0.6			1			1.5			0.33			0.17772			0.59		
10/01/21 10:00	0.7			0			1.5			0.35			0.18684			0.62		
10/01/21 11:00	0.8			0			1.5			0.37			0.19878			0.66		
10/01/21 12:00	0.8			0			1.4			0.45			0.23862			0.8		
10/01/21 13:00	1.2			0			1.5			0.59			0.31356			1.05		
10/01/21 14:00	1.2			0			1.5			0.53			0.2844			0.95		
10/01/21 15:00	0.8			0			1.2			0.43			0.23082			0.77		
10/01/21 16:00	0.8			0			1.4			0.5			0.26604			0.89		
10/01/21 17:00	0.8			0			1.5			0.52			0.2808			0.94		
10/01/21 18:00	0.8			0			1.5			0.5			0.26718			0.89		
10/01/21 19:00	0.9			0			1.5			0.48			0.25614			0.85		
10/01/21 20:00	1			0			1.5			0.53			0.28644			0.95		
10/01/21 21:00	0.9			0			1.5			0.52			0.27756			0.93		
10/01/21 22:00	0.9			1			1.6			0.4			0.21264			0.71		
10/01/21 23:00	0.8			0			1.5			0.35			0.18834			0.63		
10/02/21 0:00	0.9			0			1.5			0.43			0.23262			0.78		
10/02/21 1:00	0.9			0			1.4			0.38			0.20574			0.69		
10/02/21 2:00	0.9			0			1.4			0.39			0.21006			0.7		
10/02/21 3:00	0.9			0			1.4			0.38			0.2034			0.68		
10/02/21 4:00	0.9			0			1.1			0.41			0.21942			0.73		
10/02/21 5:00	0.8			0			1.2			0.38			0.20304			0.68		
10/02/21 6:00	1			0			1.4			0.53			0.28458			0.95		
10/02/21 7:00	1			1			1.7			0.43			0.22998			0.77		
10/02/21 8:00	0.7			1			1.5			0.33			0.1779			0.59		
10/02/21 9:00	0.7			1			1.5			0.33			0.17724			0.59		
10/02/21 10:00	0.6			1			1.5			0.33			0.17628			0.59		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/02/21 11:00	0.7			0			1.5			0.34			0.18174			0.61		
10/02/21 12:00	0.7			0			1.5			0.35			0.18564			0.62		
10/02/21 13:00	0.8			0			1.4			0.47			0.25086			0.84		
10/02/21 14:00	0.8			0			1.5			0.48			0.25746			0.86		
10/02/21 15:00	0.8			0			1.4			0.44			0.23346			0.78		
10/02/21 16:00	0.8			0			1.5			0.49			0.2604			0.87		
10/02/21 17:00	0.8			0			1.5			0.54			0.2892			0.96		
10/02/21 18:00	0.8			0			1.5			0.54			0.29268			0.98		
10/02/21 19:00	0.9			0			1.5			0.54			0.29244			0.97		
10/02/21 20:00	0.9			0			1.5			0.54			0.29238			0.97		
10/02/21 21:00	0.9			0			1.5			0.52			0.2808			0.94		
10/02/21 22:00	1			0			1.5			0.51			0.27252			0.91		
10/02/21 23:00	1			0			1.5			0.48			0.2571			0.86		
10/03/21 0:00	0.9			0			1.5			0.4			0.21498			0.72		
10/03/21 1:00	0.8			0			1.5			0.34			0.18456			0.62		
10/03/21 2:00	0.8			1			1.5			0.34			0.18432			0.61		
10/03/21 3:00	0.7			1			1.5			0.34			0.18486			0.62		
10/03/21 4:00	0.7			1			1.5			0.34			0.18468			0.62		
10/03/21 5:00	0.7			1			1.5			0.34			0.18474			0.62		
10/03/21 6:00	0.8			1			1.5			0.35			0.18876			0.63		
10/03/21 7:00	0.8			1			1.5			0.33			0.17946			0.6		
10/03/21 8:00	0.8			1			1.5			0.33			0.17868			0.6		
10/03/21 9:00	0.7			1			1.5			0.33			0.17682			0.59		
10/03/21 10:00	0.6			1			1.5			0.33			0.1758			0.59		
10/03/21 11:00	0.7			0			1.5			0.34			0.17916			0.6		
10/03/21 12:00	0.7			0			1.5			0.34			0.18276			0.61		
10/03/21 13:00	0.8			0			1.4			0.37			0.19968			0.67		
10/03/21 14:00	0.8			0			1.3			0.43			0.23172			0.77		
10/03/21 15:00	0.8			0			1.4			0.48			0.25488			0.85		
10/03/21 16:00	0.8			0			1.5			0.56			0.3015			1.01		
10/03/21 17:00	1.1			0			1.5			0.59			0.31176			1.04		
10/03/21 18:00	1.2			0			1.5			0.58			0.3105			1.04		
10/03/21 19:00	1.3			0			1.5			0.58			0.30846			1.03		
10/03/21 20:00	1.3			0			1.5			0.59			0.31242			1.04		
10/03/21 21:00	1.3			0			1.5			0.59			0.31374			1.05		
10/03/21 22:00	1.2			1			1.6			0.48			0.25512			0.85		
10/03/21 23:00	0.9			0			1.3			0.37			0.19992			0.67		
10/04/21 0:00	0.8			0			1.5			0.35			0.18888			0.63		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/04/21 1:00	0.9			0			1.3			0.39			0.20826			0.69		
10/04/21 2:00	0.9			1			1.5			0.36			0.19542			0.65		
10/04/21 3:00	0.9			0			1.4			0.53			0.28512			0.95		
10/04/21 4:00	0.9			0			1.5			0.52			0.279			0.93		
10/04/21 5:00	0.9			0			1.5			0.54			0.28878			0.96		
10/04/21 6:00	0.9			0			1.5			0.54			0.2913			0.97		
10/04/21 7:00	0.9			0			1.5			0.52			0.28068			0.94		
10/04/21 8:00	0.9			0			1.5			0.54			0.29154			0.97		
10/04/21 9:00	0.9			0			1.5			0.49			0.26532			0.88		
10/04/21 10:00	0.9			0			1.5			0.52			0.28128			0.94		
10/04/21 11:00	0.8			0			1.5			0.53			0.28422			0.95		
10/04/21 12:00	0.8			0			1.5			0.54			0.29166			0.97		
10/04/21 13:00	0.8			0			1.5			0.54			0.2916			0.97		
10/04/21 14:00	0.8			0			1.5			0.54			0.29136			0.97		
10/04/21 15:00	1.1			0			1.5			0.55			0.29448			0.98		
10/04/21 16:00	0.5			1			1.5			0.7			0.36396			1.21		
10/04/21 17:00	0.7			0			1.5			0.65			0.3426			1.14		
10/04/21 18:00	1			0			1.5			0.63			0.33138			1.1		
10/04/21 19:00	1.2			0			1.5			0.6			0.32106			1.07		
10/04/21 20:00	1.3			0			1.5			0.58			0.3108			1.04		
10/04/21 21:00	1.4			0			1.5			0.59			0.31398			1.05		
10/04/21 22:00	1.2			1			1.6			0.47			0.2541			0.85		
10/04/21 23:00	0.9			0			1.4			0.37			0.19614			0.65		
10/05/21 0:00	0.8			0			1.5			0.36			0.19086			0.64		
10/05/21 1:00	0.8			0			1.5			0.37			0.2007			0.67		
10/05/21 2:00	0.8			1			1.5			0.34			0.1842			0.61		
10/05/21 3:00	0.9			0			1.4			0.35			0.18924			0.63		
10/05/21 4:00	0.9			0			1.3			0.44			0.23562			0.79		
10/05/21 5:00	0.8			0			1.3			0.41			0.22008			0.73		
10/05/21 6:00	0.8			1			1.5			0.43			0.23268			0.78		
10/05/21 7:00	0.9			0			1.5			0.48			0.26022			0.87		
10/05/21 8:00	0.7			1			1.4			0.34			0.18336			0.61		
10/05/21 9:00	0.7			0			1.5			0.36			0.1923			0.64		
10/05/21 10:00	0.7			0			1.4			0.53			0.28698			0.96		
10/05/21 11:00	0.7			1			1.6			0.35			0.18762			0.63		
10/05/21 12:00	0.6			0			1.5			0.34			0.1827			0.61		
10/05/21 13:00	0.7			0			1.4			0.36			0.1935			0.65		
10/05/21 14:00	0.7			0			1.2			0.42			0.22536			0.75		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/05/21 15:00	0.7			0			1.4			0.43			0.23016			0.77		
10/05/21 16:00	0.7			0			1.4			0.46			0.24618			0.82		
10/05/21 17:00	0.7			0			1.6			0.44			0.23832			0.79		
10/05/21 18:00	0.7			0			1.5			0.48			0.25752			0.86		
10/05/21 19:00	0.7			0			1.5			0.38			0.20322			0.68		
10/05/21 20:00	0.7			0			1.3			0.4			0.21384			0.71		
10/05/21 21:00	0.8			0			1.3			0.46			0.24588			0.82		
10/05/21 22:00	0.8			0			1.5			0.5			0.27			0.9		
10/05/21 23:00	0.8			0			1.5			0.5			0.26904			0.9		
10/06/21 0:00	0.6			1			1.7			0.35			0.18654			0.62		
10/06/21 1:00	0.6			1			1.5			0.35			0.18618			0.62		
10/06/21 2:00	0.6			0			1.5			0.35			0.18558			0.62		
10/06/21 3:00	0.6			1			1.5			0.35			0.1857			0.62		
10/06/21 4:00	0.6			1			1.5			0.35			0.18588			0.62		
10/06/21 5:00	0.7			0			1.3			0.4			0.21684			0.72		
10/06/21 6:00	0.7			1			1.6			0.45			0.24012			0.8		
10/06/21 7:00	0.6			1			1.3			0.35			0.18912			0.63		
10/06/21 8:00	0.6			0			1.3			0.4			0.21462			0.72		
10/06/21 9:00	0.7			0			1.4			0.52			0.28206			0.94		
10/06/21 10:00	0.8			0			1.5			0.45			0.2436			0.81		
10/06/21 11:00	1.3			0			1.5			0.54			0.29982			1		
10/06/21 12:00	1.3			0			1.5			0.55			0.29574			0.99		
10/06/21 13:00	0.9			0			1.4			0.48			0.25818			0.86		
10/06/21 14:00	0.7			0			1.5			0.55			0.29304			0.98		
10/06/21 15:00	0.7			0			1.4			0.46			0.24384			0.81		
10/06/21 16:00	0.8			0			1.5			0.49			0.26526			0.88		
10/06/21 17:00	0.7			1			1.6			0.37			0.19572			0.65		
10/06/21 18:00	0.8			0			1.5			0.4			0.21204			0.71		
10/06/21 19:00	0.7			0			1.4			0.39			0.20688			0.69		
10/06/21 20:00	0.8			0			1.3			0.5			0.26898			0.9		
10/06/21 21:00	0.7			0			1.5			0.55			0.29526			0.98		
10/06/21 22:00	0.7			1			1.6			0.45			0.24066			0.8		
10/06/21 23:00	0.7			1			1.5			0.35			0.18594			0.62		
10/07/21 0:00	0.7			1			1.5			0.35			0.18594			0.62		
10/07/21 1:00	0.7			1			1.5			0.35			0.18594			0.62		
10/07/21 2:00	0.7			1			1.5			0.35			0.186			0.62		
10/07/21 3:00	0.8			0			1.1			0.43			0.23328			0.78		
10/07/21 4:00	0.8			0			1.5			0.48			0.25782			0.86		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/07/21 5:00	0.8			0			1.5			0.53			0.28518			0.95		
10/07/21 6:00	0.7			0			1.5			0.56			0.30072			1		
10/07/21 7:00	0.7			0			1.5			0.54			0.29316			0.98		
10/07/21 8:00	0.8			0			1.5			0.49			0.2643			0.88		
10/07/21 9:00	0.7			0			1.5			0.55			0.2943			0.98		
10/07/21 10:00	0.7			1			1.6			0.42			0.22302			0.74		
10/07/21 11:00	0.7			0			1.4			0.38			0.20256			0.68		
10/07/21 12:00	0.6			1			1.5			0.34			0.18408			0.61		
10/07/21 13:00	0.6			0			1.5			0.34			0.183			0.61		
10/07/21 14:00	0.6			1			1.5			0.34			0.17988			0.6		
10/07/21 15:00	0.6			1			1.5			0.34			0.18384			0.61		
10/07/21 16:00	0.6			0			1.4			0.41			0.22248			0.74		
10/07/21 17:00	0.7			0			1.5			0.54			0.2937			0.98		
10/07/21 18:00	0.7			1			1.6			0.42			0.22476			0.75		
10/07/21 19:00	0.6			1			1.5			0.35			0.1863			0.62		
10/07/21 20:00	0.7			1			1.5			0.36			0.19314			0.64		
10/07/21 21:00	0.6			1			1.5			0.35			0.18624			0.62		
10/07/21 22:00	0.6			1			1.5			0.35			0.18954			0.63		
10/07/21 23:00	0.8			0			1.5			0.44			0.23712			0.79		
10/08/21 0:00	0.6			1			1.5			0.35			0.18624			0.62		
10/08/21 1:00	0.6			1			1.5			0.35			0.18606			0.62		
10/08/21 2:00	0.6			1			1.4			0.34			0.18564			0.62		
10/08/21 3:00	0.7			1			1.5			0.35			0.18816			0.63		
10/08/21 4:00	0.7			0			1.4			0.37			0.19716			0.66		
10/08/21 5:00	0.6			1			1.6			0.34			0.18114			0.6		
10/08/21 6:00	0.7			1			1.4			0.36			0.19566			0.65		
10/08/21 7:00	0.7			0			1.4			0.56			0.30126			1		
10/08/21 8:00	0.8			0			1.5			0.43			0.23022			0.77		
10/08/21 9:00	0.7			0			1.5			0.55			0.29616			0.99		
10/08/21 10:00	0.7			1			1.6			0.36			0.1923			0.64		
10/08/21 11:00	0.7			0			1.2			0.48			0.25758			0.86		
10/08/21 12:00	0.8			0			1.5			0.46			0.2502			0.83		
10/08/21 13:00	0.8			0			1.5			0.48			0.25866			0.86		
10/08/21 14:00	0.7			0			1.5			0.55			0.29496			0.98		
10/08/21 15:00	0.6			1			1.7			0.35			0.18552			0.62		
10/08/21 16:00	0.6			0			1.3			0.41			0.21864			0.73		
10/08/21 17:00	0.6			1			1.7			0.35			0.18636			0.62		
10/08/21 18:00	0.6			1			1.5			0.34			0.1839			0.61		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/08/21 19:00	0.5			1			1.5			0.34			0.18252			0.61		
10/08/21 20:00	0.6			1			1.5			0.34			0.18414			0.61		
10/08/21 21:00	0.6			1			1.5			0.34			0.1857			0.62		
10/08/21 22:00	0.6			1			1.5			0.35			0.18918			0.63		
10/08/21 23:00	0.5			1			1.5			0.34			0.1836			0.61		
10/09/21 0:00	0.5			1			1.5			0.34			0.18228			0.61		
10/09/21 1:00	0.5			1			1.5			0.33			0.17874			0.6		
10/09/21 2:00	0.5			1			1.5			0.33			0.1794			0.6		
10/09/21 3:00	0.5			1			1.5			0.33			0.17952			0.6		
10/09/21 4:00	0.6			1			1.5			0.35			0.18792			0.63		
10/09/21 5:00	0.8			0			1.2			0.41			0.22302			0.74		
10/09/21 6:00	0.8			0			1.4			0.41			0.22182			0.74		
10/09/21 7:00	0.8			0			1.5			0.48			0.25968			0.87		
10/09/21 8:00	0.7			1			1.6			0.39			0.21126			0.7		
10/09/21 9:00	0.5			1			1.5			0.34			0.18186			0.61		
10/09/21 10:00	0.5			1			1.5			0.33			0.1791			0.6		
10/09/21 11:00	0.5			1			1.5			0.33			0.17904			0.6		
10/09/21 12:00	0.5			1			1.5			0.33			0.17844			0.59		
10/09/21 13:00	0.5			1			1.5			0.33			0.17808			0.59		
10/09/21 14:00	0.5			1			1.5			0.33			0.17784			0.59		
10/09/21 15:00	0.6			0			1.4			0.34			0.18366			0.61		
10/09/21 16:00	0.6			0			1.3			0.43			0.22764			0.76		
10/09/21 17:00	0.7			0			1.5			0.51			0.27078			0.9		
10/09/21 18:00	0.7			1			1.6			0.37			0.1989			0.66		
10/09/21 19:00	0.6			1			1.4			0.34			0.18384			0.61		
10/09/21 20:00	0.5			1			1.6			0.34			0.18066			0.6		
10/09/21 21:00	0.7			1			1.5			0.34			0.18516			0.62		
10/09/21 22:00	0.8			1			1.5			0.34			0.18462			0.62		
10/09/21 23:00	0.7			0			1.5			0.35			0.1866			0.62		
10/10/21 0:00	0.7			1			1.5			0.35			0.18654			0.62		
10/10/21 1:00	0.6			1			1.5			0.34			0.186			0.62		
10/10/21 2:00	0.7			1			1.6			0.35			0.18996			0.63		
10/10/21 3:00	0.7			1			1.5			0.35			0.18858			0.63		
10/10/21 4:00	0.7			1			1.5			0.35			0.18852			0.63		
10/10/21 5:00	0.8			0			1.4			0.44			0.23754			0.79		
10/10/21 6:00	0.8			0			1.5			0.47			0.2532			0.84		
10/10/21 7:00	0.8			1			1.6			0.43			0.23298			0.78		
10/10/21 8:00	0.6			1			1.5			0.34			0.18408			0.61		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/10/21 9:00	0.5			1			1.5			0.33			0.17886			0.6		
10/10/21 10:00	0.6			1			1.5			0.34			0.18066			0.6		
10/10/21 11:00	0.6			1			1.5			0.33			0.17838			0.59		
10/10/21 12:00	0.5			1			1.5			0.33			0.17826			0.59		
10/10/21 13:00	0.5			1			1.5			0.33			0.17874			0.6		
10/10/21 14:00	0.6			1			1.5			0.34			0.18054			0.6		
10/10/21 15:00	0.6			0			1.5			0.36			0.19464			0.65		
10/10/21 16:00	0.7			0			1.4			0.44			0.23358			0.78		
10/10/21 17:00	0.7			1			1.6			0.36			0.1932			0.64		
10/10/21 18:00	0.6			1			1.5			0.34			0.18018			0.6		
10/10/21 19:00	0.7			0			1.5			0.37			0.19578			0.65		
10/10/21 20:00	0.7			0			1.5			0.43			0.22992			0.77		
10/10/21 21:00	0.7			1			1.5			0.34			0.18438			0.61		
10/10/21 22:00	0.6			1			1.5			0.34			0.18084			0.6		
10/10/21 23:00	0.6			1			1.5			0.33			0.17922			0.6		
10/11/21 0:00	0.6			0			1.5			0.35			0.18888			0.63		
10/11/21 1:00	0.5			1			1.5			0.33			0.1794			0.6		
10/11/21 2:00	0.6			0			1.5			0.34			0.18426			0.61		
10/11/21 3:00	0.6			0			1.5			0.35			0.1875			0.63		
10/11/21 4:00	0.8			0			1.4			0.49			0.2637			0.88		
10/11/21 5:00	0.8			0			1.5			0.48			0.26148			0.87		
10/11/21 6:00	0.8			0			1.5			0.52			0.28212			0.94		
10/11/21 7:00	0.8			0			1.5			0.55			0.29676			0.99		
10/11/21 8:00	0.7			1			1.5			0.67			0.3891			1.3		
10/11/21 9:00	0.8			1			1.5			0.64			0.36204			1.21		
10/11/21 10:00	0.6			1			1.5			0.7			0.37314			1.24		
10/11/21 11:00	1.8			0			1.5			0.6			0.31974			1.07		
10/11/21 12:00	1.1			0			1.5			0.64			0.34224			1.14		
10/11/21 13:00	1			0			1.5			0.65			0.34494			1.15		
10/11/21 14:00	1.2			0			1.5			0.63			0.3369			1.12		
10/11/21 15:00	1			0			1.5			0.5			0.27144			0.9		
10/11/21 16:00	0.7			0			1.5			0.54			0.2895			0.97		
10/11/21 17:00	0.8			0			1.5			0.53			0.2862			0.95		
10/11/21 18:00	0.7			1			1.5			0.41			0.22224			0.74		
10/11/21 19:00	0.7			1			1.5			0.37			0.19734			0.66		
10/11/21 20:00	0.8			0			1.5			0.47			0.25554			0.85		
10/11/21 21:00	0.8			1			1.4			0.41			0.2214			0.74		
10/11/21 22:00	0.7			1			1.5			0.37			0.20082			0.67		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/11/21 23:00	0.8			1			1.5			0.37			0.19776			0.66		
10/12/21 0:00	0.7			1			1.5			0.35			0.18804			0.63		
10/12/21 1:00	0.6			1			1.5			0.34			0.18558			0.62		
10/12/21 2:00	0.6			1			1.9			0.34			0.18354			0.61		
10/12/21 3:00	0.6			1			1.5			0.34			0.1839			0.61		
10/12/21 4:00	0.6			1			1.5			0.34			0.18432			0.61		
10/12/21 5:00	0.8			0			1.4			0.46			0.24924			0.83		
10/12/21 6:00	0.8			0			1.5			0.56			0.30444			1.01		
10/12/21 7:00	0.8			0			1.5			0.55			0.29994			1		
10/12/21 8:00	0.8			0			1.5			0.56			0.30222			1.01		
10/12/21 9:00	0.8			0			1.5			0.56			0.30216			1.01		
10/12/21 10:00	0.8			0			1.5			0.56			0.30246			1.01		
10/12/21 11:00	0.8			0			1.5			0.56			0.30048			1		
10/12/21 12:00	0.8			0			1.5			0.55			0.29292			0.98		
10/12/21 13:00	0.8			0			1.5			0.42			0.22398			0.75		
10/12/21 14:00	0.8			0			1.5			0.55			0.29562			0.99		
10/12/21 15:00	0.8			0			1.5			0.55			0.29478			0.98		
10/12/21 16:00	0.8			0			1.5			0.52			0.27972			0.93		
10/12/21 17:00	0.8			0			1.5			0.54			0.2934			0.98		
10/12/21 18:00	0.8			0			1.5			0.55			0.29664			0.99		
10/12/21 19:00	0.8			0			1.5			0.5			0.2673			0.89		
10/12/21 20:00	0.8			0			1.6			0.51			0.27546			0.92		
10/12/21 21:00	0.8			0			1.4			0.54			0.28956			0.97		
10/12/21 22:00	0.9			0			1.5			0.55			0.29724			0.99		
10/12/21 23:00	0.9			0			1.4			0.47			0.25284			0.84		
10/13/21 0:00	0.8			0			1.6			0.56			0.30012			1		
10/13/21 1:00	0.8			1			1.5			0.38			0.20364			0.68		
10/13/21 2:00	0.7			1			1.5			0.35			0.18834			0.63		
10/13/21 3:00	0.8			0			1.4			0.42			0.22932			0.76		
10/13/21 4:00	0.8			0			1.5			0.56			0.30006			1		
10/13/21 5:00	0.9			0			1.5			0.53			0.28416			0.95		
10/13/21 6:00	0.9			0			1.5			0.51			0.27768			0.93		
10/13/21 7:00	0.8			0			1.5			0.56			0.30024			1		
10/13/21 8:00	0.8			0			1.5			0.56			0.30048			1		
10/13/21 9:00	0.8			0			1.5			0.56			0.30054			1		
10/13/21 10:00	0.8			0			1.5			0.55			0.29844			0.99		
10/13/21 11:00	0.8			0			1.5			0.56			0.29802			0.99		
10/13/21 12:00	0.8			0			1.5			0.56			0.29628			0.99		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/13/21 13:00	0.8			0			1.5			0.56			0.30006			1		
10/13/21 14:00	0.8			0			1.5			0.55			0.29424			0.98		
10/13/21 15:00	0.9			0			1.6			0.49			0.26388			0.88		
10/13/21 16:00	0.7			0			1.4			0.41			0.22212			0.74		
10/13/21 17:00	0.8			0			1.5			0.55			0.29622			0.99		
10/13/21 18:00	0.9			0			1.5			0.5			0.2712			0.9		
10/13/21 19:00	0.8			0			1.5			0.47			0.25422			0.85		
10/13/21 20:00	0.9			0			1.5			0.52			0.27918			0.93		
10/13/21 21:00	1			0			1.5			0.5			0.27228			0.91		
10/13/21 22:00	0.8			0			1.6			0.52			0.28272			0.94		
10/13/21 23:00	0.7			1			1.5			0.34			0.1827			0.61		
10/14/21 0:00	0.9			1			1.6			0.35			0.1869			0.62		
10/14/21 1:00	0.9			2			1.5			0.34			0.18486			0.62		
10/14/21 2:00	0.8			1			1.7			0.35			0.18756			0.63		
10/14/21 3:00	0.7			1			1.5			0.35			0.1878			0.63		
10/14/21 4:00	0.7			1			1.5			0.34			0.1866			0.62		
10/14/21 5:00	1			0			1.4			0.51			0.27894			0.93		
10/14/21 6:00	1			0			1.5			0.56			0.3015			1.01		
10/14/21 7:00	0.9			1			1.5			0.41			0.22374			0.75		
10/14/21 8:00	0.7			2			1.6			0.34			0.18576			0.62		
10/14/21 9:00	0.7			1			1.5			0.34			0.18564			0.62		
10/14/21 10:00	0.6			1			1.5			0.33			0.18054			0.6		
10/14/21 11:00	0.6			1			1.5			0.34			0.18078			0.6		
10/14/21 12:00	0.6			1			1.5			0.34			0.18108			0.6		
10/14/21 13:00	0.7			1			1.5			0.35			0.1857			0.62		
10/14/21 14:00	0.7			1			1.5			0.35			0.18672			0.62		
10/14/21 15:00	0.7			1			1.5			0.37			0.1986			0.66		
10/14/21 16:00	0.7			0			1.4			0.44			0.23802			0.79		
10/14/21 17:00	0.8			0			1.5			0.55			0.29412			0.98		
10/14/21 18:00	0.9			0			1.5			0.52			0.27972			0.93		
10/14/21 19:00	0.8			0			1.5			0.56			0.30156			1.01		
10/14/21 20:00	0.9			0			1.5			0.56			0.30336			1.01		
10/14/21 21:00	0.9			1			1.5			0.33			0.37476			1.25		
10/14/21 22:00	1.3			1			1.5			0	X		0.32226			1.07		
10/14/21 23:00	1.4			1			1.5			0	X		0.30492			1.02		
10/15/21 0:00	1.4			1			1.5			0	X		0.30204			1.01		
10/15/21 1:00	1.5			1			1.5			0	X		0.30396			1.01		
10/15/21 2:00	1.7			0			1.4			0	X		0.3048			1.02		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/15/21 3:00	1.6			1			1.5			0	X		0.30492			1.02		
10/15/21 4:00	1.5			1			1.5			0	X		0.30468			1.02		
10/15/21 5:00	1.6			1			1.5			0	X		0.30486			1.02		
10/15/21 6:00	1.6			1			1.5			0	X		0.30414			1.01		
10/15/21 7:00	1.7			1			1.5			0	X		0.3039			1.01		
10/15/21 8:00	1.5			1			1.5			0	X		0.30198			1.01		
10/15/21 9:00	1.4			1			1.5			0	X		0.30186			1.01		
10/15/21 10:00	1.4			1			1.5			0	X		0.3027			1.01		
10/15/21 11:00	1.4			1			1.5			0	X		0.30198			1.01		
10/15/21 12:00	1.4			1			1.5			0	X		0.3015			1.01		
10/15/21 13:00	1.4			1			1.5			0	X		0.30168			1.01		
10/15/21 14:00	1.4			1			1.5			0	X		0.3012			1		
10/15/21 15:00	1.4			1			1.5			0	X		0.30006			1		
10/15/21 16:00	1.3			1			1.5			0	X		0.31374			1.05		
10/15/21 17:00	1.4			0			1.5			0	X		0.30888			1.03		
10/15/21 18:00	1.5			1			1.5			0	X		0.30024			1		
10/15/21 19:00	1.6			1			1.5			0	X		0.3			1		
10/15/21 20:00	1.7			1			1.5			0	X		0.30102			1		
10/15/21 21:00	1.7			1			1.5			0	X		0.30186			1.01		
10/15/21 22:00	1.7			1			1.5			0	X		0.3012			1		
10/15/21 23:00	1.7			1			1.5			0	X		0.3009			1		
10/16/21 0:00	2			1			1.5			0	X		0.3015			1.01		
10/16/21 1:00	1.9			1			1.5			0	X		0.30066			1		
10/16/21 2:00	1.8			0			1.5			0	X		0.3009			1		
10/16/21 3:00	2.1			1			1.5			0	X		0.30156			1.01		
10/16/21 4:00	2.3			1			1.5			0	X		0.30408			1.01		
10/16/21 5:00	1.6			1			1.5			0	X		0.30342			1.01		
10/16/21 6:00	1.8			1			1.5			0	X		0.30366			1.01		
10/16/21 7:00	1.6			1			1.5			0	X		0.30396			1.01		
10/16/21 8:00	1.5			1			1.5			0	X		0.30312			1.01		
10/16/21 9:00	1.4			1			1.5			0	X		0.3048			1.02		
10/16/21 10:00	1.2			1			1.5			0	X		0.30822			1.03		
10/16/21 11:00	1.1			1			1.5			0	X		0.31098			1.04		
10/16/21 12:00	1.1			1			1.5			0	X		0.31146			1.04		
10/16/21 13:00	1.1			1			1.5			0	X		0.31122			1.04		
10/16/21 14:00	1			1			1.5			0	X		0.31188			1.04		
10/16/21 15:00	1			1			1.5			0	X		0.31242			1.04		
10/16/21 16:00	1.1			1			1.5			0	X		0.31158			1.04		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/16/21 17:00	1.1			1			1.5			0	X		0.30978			1.03		
10/16/21 18:00	1.2			1			1.5			0	X		0.3099			1.03		
10/16/21 19:00	1.2			1			1.5			0	X		0.31068			1.04		
10/16/21 20:00	1.3			1			1.5			0	X		0.30822			1.03		
10/16/21 21:00	1.4			1			1.5			0	X		0.30606			1.02		
10/16/21 22:00	1.4			1			1.5			0	X		0.3048			1.02		
10/16/21 23:00	1.5			1			1.5			0	X		0.30012			1		
10/17/21 0:00	1.5			1			1.5			0	X		0.29802			0.99		
10/17/21 1:00	1.5			1			1.5			0	X		0.29832			0.99		
10/17/21 2:00	1.5			1			1.5			0	X		0.2988			1		
10/17/21 3:00	1.5			1			1.5			0	X		0.29892			1		
10/17/21 4:00	1.5			1			1.5			0	X		0.29964			1		
10/17/21 5:00	1.5			1			1.5			0	X		0.30096			1		
10/17/21 6:00	1.5			1			1.5			0	X		0.30168			1.01		
10/17/21 7:00	1.1			1			1.5			0	X		0.33984			1.13		
10/17/21 8:00	0.4			2			1.5			0	X		0.4107			1.37		
10/17/21 9:00	0.9			1			1.5			0	X		0.36156			1.21		
10/17/21 10:00	1.6			0			1.5			0	X		0.30558			1.02		
10/17/21 11:00	1.5			1			1.5			0	X		0.30672			1.02		
10/17/21 12:00	1.5			1			1.5			0	X		0.30258			1.01		
10/17/21 13:00	1.5			1			1.5			0	X		0.30072			1		
10/17/21 14:00	1.5			1			1.5			0	X		0.3009			1		
10/17/21 15:00	1.5			1			1.5			0	X		0.30162			1.01		
10/17/21 16:00	1.5			1			1.5			0	X		0.3096			1.03		
10/17/21 17:00	1.6			1			1.5			0	X		0.30174			1.01		
10/17/21 18:00	1.5			1			1.5			0	X		0.30222			1.01		
10/17/21 19:00	1.6			1			1.5			0	X		0.3027			1.01		
10/17/21 20:00	1.6			1			1.5			0	X		0.30234			1.01		
10/17/21 21:00	1.6			1			1.5			0	X		0.30318			1.01		
10/17/21 22:00	1.6			1			1.5			0	X		0.30462			1.02		
10/17/21 23:00	1.6			1			1.5			0	X		0.30456			1.02		
10/18/21 0:00	1.6			1			1.5			0	X		0.30414			1.01		
10/18/21 1:00	1.6			1			1.5			0	X		0.3042			1.01		
10/18/21 2:00	1.6			1			1.5			0	X		0.30438			1.01		
10/18/21 3:00	1.6			1			1.5			0	X		0.30468			1.02		
10/18/21 4:00	1.6			1			1.5			0	X		0.30444			1.01		
10/18/21 5:00	1.6			1			1.5			0	X		0.30432			1.01		
10/18/21 6:00	1.6			1			1.5			0	X		0.30474			1.02		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/18/21 7:00	1.3			1			1.4			0	X		0.26028			0.87		
10/18/21 8:00	1.4			0			1.4			0	X		0.26232			0.87		
10/18/21 9:00	1.8			1			1.5			0	X		0.30372			1.01		
10/18/21 10:00	1.8			1			1.5			0	X		0.30336			1.01		
10/18/21 11:00	1.8			1			1.5			0	X		0.30324			1.01		
10/18/21 12:00	1.8			1			1.5			0	X		0.303			1.01		
10/18/21 13:00	1.7			1			1.5			0	X		0.30384			1.01		
10/18/21 14:00	1.4			1			1.5			0	X		0.312			1.04		
10/18/21 15:00	1.5			1			1.5			0	X		0.3012			1		
10/18/21 16:00	1.1			1			1.5			0	X		0.22926			0.76		
10/18/21 17:00	1.8			1			1.5			0	X		0.30486			1.02		
10/18/21 18:00	1.9			1			1.5			0	X		0.30366			1.01		
10/18/21 19:00	2.1			1			1.5			0	X		0.3042			1.01		
10/18/21 20:00	1.9			1			1.5			0	X		0.30444			1.01		
10/18/21 21:00	1.5			1			1.5			0	X		0.25332			0.84		
10/18/21 22:00	0.8			1			1.5			0	X		0.18708			0.62		
10/18/21 23:00	0.8			1			1.5			0	X		0.18774			0.63		
10/19/21 0:00	0.8			1			1.5			0	X		0.1863			0.62		
10/19/21 1:00	0.9			1			1.5			0	X		0.1857			0.62		
10/19/21 2:00	0.9			1			1.5			0	X		0.1869			0.62		
10/19/21 3:00	2.4			0			1.3			0	X		0.25164			0.84		
10/19/21 4:00	2.2			0			1.5			0	X		0.30474			1.02		
10/19/21 5:00	2			1			1.5			0	X		0.3042			1.01		
10/19/21 6:00	1.9			1			1.5			0	X		0.30426			1.01		
10/19/21 7:00	1.9			1			1.5			0	X		0.30456			1.02		
10/19/21 8:00	1.9			1			1.5			0	X		0.30486			1.02		
10/19/21 9:00	1.8			1			1.5			0	X		0.30678			1.02		
10/19/21 10:00	1.6			1			1.5			0	X		0.30732			1.02		
10/19/21 11:00	1.4			1			1.5			0	X		0.3006			1		
10/19/21 12:00	1.4			1			1.5			0	X		0.29946			1		
10/19/21 13:00	1.2			1			1.5			0	X		0.25878			0.86		
10/19/21 14:00	1.5			1			1.5			0	X		0.3099			1.03		
10/19/21 15:00	1.4			1			1.5			0	X		0.31062			1.04		
10/19/21 16:00	1.3			1			1.5			0	X		0.31878			1.06		
10/19/21 17:00	1.4			1			1.5			0	X		0.31218			1.04		
10/19/21 18:00	1.5			1			1.5			0	X		0.30048			1		
10/19/21 19:00	1.5			1			1.5			0	X		0.29916			1		
10/19/21 20:00	1.5			1			1.5			0	X		0.30066			1		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/19/21 21:00	1.4			1			1.5			0	X		0.28458			0.95		
10/19/21 22:00	0.8			1			1.5			0	X		0.18414			0.61		
10/19/21 23:00	0.8			1			1.5			0	X		0.18462			0.62		
10/20/21 0:00	0.8			1			1.5			0	X		0.18456			0.62		
10/20/21 1:00	0.7			1			1.5			0	X		0.1848			0.62		
10/20/21 2:00	0.7			1			1.5			0	X		0.1848			0.62		
10/20/21 3:00	0.7			1			1.5			0	X		0.18498			0.62		
10/20/21 4:00	1.4			0			1.4			0	X		0.24996			0.83		
10/20/21 5:00	1.8			0			1.5			0	X		0.3033			1.01		
10/20/21 6:00	1.4			1			1.5			0	X		0.2541			0.85		
10/20/21 7:00	0.7			1			1.5			0	X		0.18606			0.62		
10/20/21 8:00	0.7			1			1.5			0	X		0.18582			0.62		
10/20/21 9:00	0.8			1			1.5			0	X		0.22374			0.75		
10/20/21 10:00	0.7			1			1.5			0	X		0.18696			0.62		
10/20/21 11:00	0.9			0			1.4			0	X		0.2508			0.84		
10/20/21 12:00	0.9			1			1.6			0	X		0.24042			0.8		
10/20/21 13:00	0.7			1			1.5			0	X		0.18462			0.62		
10/20/21 14:00	0.7			1			1.5			0	X		0.18552			0.62		
10/20/21 15:00	0.8			0			1.4			0	X		0.22524			0.75		
10/20/21 16:00	0.8			1			1.5			0	X		0.24618			0.82		
10/20/21 17:00	0.9			0			1.5			0	X		0.28512			0.95		
10/20/21 18:00	0.8			1			1.6			0	X		0.19128			0.64		
10/20/21 19:00	0.7			1			1.5			0	X		0.1857			0.62		
10/20/21 20:00	0.8			1			1.5			0	X		0.19068			0.64		
10/20/21 21:00	0.8			1			1.5			0	X		0.19764			0.66		
10/20/21 22:00	1.1			0			1.4			0.12			0.28404			0.95		
10/20/21 23:00	1			1			1.6			0.37			0.20298			0.68		
10/21/21 0:00	0.7			1			1.5			0.35			0.18924			0.63		
10/21/21 1:00	0.7			1			1.5			0.35			0.18696			0.62		
10/21/21 2:00	0.7			1			1.5			0.35			0.18714			0.62		
10/21/21 3:00	0.9			0			1.2			0.42			0.22368			0.75		
10/21/21 4:00	0.8			1			1.5			0.44			0.23592			0.79		
10/21/21 5:00	0.9			0			1.5			0.5			0.26904			0.9		
10/21/21 6:00	0.9			1			1.5			0.51			0.27216			0.91		
10/21/21 7:00	0.9			0			1.4			0.49			0.26616			0.89		
10/21/21 8:00	0.9			0			1.5			0.54			0.28968			0.97		
10/21/21 9:00	0.8			0			1.5			0.57			0.30516			1.02		
10/21/21 10:00	0.8			0			1.5			0.56			0.3033			1.01		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/21/21 11:00	0.9			1			1.6			0.5			0.26604			0.89		
10/21/21 12:00	0.7			0			1.4			0.36			0.18996			0.63		
10/21/21 13:00	0.8			0			1.5			0.51			0.2757			0.92		
10/21/21 14:00	0.9			0			1.4			0.48			0.25536			0.85		
10/21/21 15:00	0.7			1			1.4			0.4			0.21336			0.71		
10/21/21 16:00	0.8			0			1.5			0.53			0.28098			0.94		
10/21/21 17:00	0.8			0			1.5			0.56			0.29958			1		
10/21/21 18:00	0.8			0			1.5			0.56			0.29898			1		
10/21/21 19:00	0.8			0			1.5			0.56			0.3012			1		
10/21/21 20:00	0.8			0			1.5			0.55			0.29784			0.99		
10/21/21 21:00	0.9			1			1.6			0.5			0.27066			0.9		
10/21/21 22:00	0.8			1			1.5			0.36			0.1941			0.65		
10/21/21 23:00	0.6			1			1.5			0.33			0.17874			0.6		
10/22/21 0:00	0.6			1			1.5			0.33			0.17886			0.6		
10/22/21 1:00	0.6			1			1.5			0.33			0.17874			0.6		
10/22/21 2:00	0.6			1			1.5			0.33			0.17862			0.6		
10/22/21 3:00	0.7			1			1.5			0.34			0.18504			0.62		
10/22/21 4:00	0.7			1			1.5			0.35			0.18684			0.62		
10/22/21 5:00	0.7			1			1.5			0.34			0.18528			0.62		
10/22/21 6:00	0.7			1			1.4			0.34			0.18498			0.62		
10/22/21 7:00	0.9			0			1.5			0.43			0.23238			0.77		
10/22/21 8:00	0.9			0			1.3			0.55			0.29502			0.98		
10/22/21 9:00	0.8			0			1.5			0.54			0.29124			0.97		
10/22/21 10:00	0.8			0			1.5			0.56			0.30258			1.01		
10/22/21 11:00	0.8			0			1.5			0.55			0.29838			0.99		
10/22/21 12:00	0.9			1			1.6			0.41			0.21786			0.73		
10/22/21 13:00	0.8			1			1.5			0.39			0.20904			0.7		
10/22/21 14:00	0.8			1			1.5			0.39			0.20874			0.7		
10/22/21 15:00	0.8			1			1.5			0.39			0.2088			0.7		
10/22/21 16:00	0.8			0			1.4			0.43			0.23214			0.77		
10/22/21 17:00	0.8			1			1.6			0.49			0.26346			0.88		
10/22/21 18:00	0.6			1			1.5			0.34			0.18054			0.6		
10/22/21 19:00	0.7			1			1.5			0.36			0.19098			0.64		
10/22/21 20:00	0.7			1			1.5			0.35			0.18732			0.62		
10/22/21 21:00	0.7			1			1.5			0.34			0.18408			0.61		
10/22/21 22:00	0.7			1			1.5			0.34			0.18372			0.61		
10/22/21 23:00	0.8			0			1.5			0.38			0.20394			0.68		
10/23/21 0:00	0.8			1			1.5			0.38			0.20682			0.69		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/23/21 1:00	0.6			2			1.5			0.33			0.17952			0.6		
10/23/21 2:00	0.7			1			1.4			0.34			0.18546			0.62		
10/23/21 3:00	0.7			1			1.5			0.35			0.18654			0.62		
10/23/21 4:00	0.7			1			1.5			0.35			0.18828			0.63		
10/23/21 5:00	0.8			0			1.4			0.42			0.22422			0.75		
10/23/21 6:00	0.9			1			1.5			0.46			0.24648			0.82		
10/23/21 7:00	0.8			1			1.6			0.43			0.22974			0.77		
10/23/21 8:00	0.8			0			1.4			0.53			0.28632			0.95		
10/23/21 9:00	0.9			1			1.6			0.47			0.25104			0.84		
10/23/21 10:00	0.8			1			1.5			0.38			0.20382			0.68		
10/23/21 11:00	0.8			1			1.5			0.38			0.20304			0.68		
10/23/21 12:00	0.8			0			1.5			0.55			0.29682			0.99		
10/23/21 13:00	0.9			1			1.4			0.44			0.23622			0.79		
10/23/21 14:00	0.8			0			1.5			0.56			0.30282			1.01		
10/23/21 15:00	0.8			0			1.5			0.54			0.29424			0.98		
10/23/21 16:00	0.8			0			1.5			0.56			0.3021			1.01		
10/23/21 17:00	0.8			0			1.5			0.56			0.30024			1		
10/23/21 18:00	0.7			1			1.6			0.36			0.1917			0.64		
10/23/21 19:00	0.8			1			1.5			0.37			0.1992			0.66		
10/23/21 20:00	0.7			1			1.5			0.35			0.18786			0.63		
10/23/21 21:00	0.7			1			1.5			0.35			0.1884			0.63		
10/23/21 22:00	0.7			1			1.5			0.37			0.19902			0.66		
10/23/21 23:00	0.8			0			1.5			0.54			0.29286			0.98		
10/24/21 0:00	0.9			1			1.5			0.47			0.25422			0.85		
10/24/21 1:00	0.6			1			1.6			0.34			0.1824			0.61		
10/24/21 2:00	0.6			1			1.5			0.34			0.18072			0.6		
10/24/21 3:00	0.6			2			1.6			0.34			0.18138			0.6		
10/24/21 4:00	0.6			1			1.5			0.33			0.17886			0.6		
10/24/21 5:00	0.7			1			1.5			0.34			0.18438			0.61		
10/24/21 6:00	0.7			1			1.5			0.34			0.18426			0.61		
10/24/21 7:00	0.8			0			1.4			0.47			0.25554			0.85		
10/24/21 8:00	0.8			0			1.5			0.56			0.30114			1		
10/24/21 9:00	0.8			0			1.5			0.56			0.30192			1.01		
10/24/21 10:00	0.8			0			1.5			0.55			0.29466			0.98		
10/24/21 11:00	0.8			0			1.5			0.56			0.30174			1.01		
10/24/21 12:00	0.8			0			1.5			0.55			0.29418			0.98		
10/24/21 13:00	0.8			0			1.5			0.56			0.30048			1		
10/24/21 14:00	0.8			1			1.5			0.44			0.2346			0.78		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/24/21 15:00	0.8			0			1.5			0.51			0.27444			0.91		
10/24/21 16:00	0.8			1			1.5			0.48			0.25836			0.86		
10/24/21 17:00	0.8			0			1.5			0.54			0.28974			0.97		
10/24/21 18:00	0.8			1			1.5			0.43			0.23028			0.77		
10/24/21 19:00	0.8			1			1.5			0.48			0.25806			0.86		
10/24/21 20:00	0.7			1			1.5			0.37			0.20118			0.67		
10/24/21 21:00	0.8			1			1.5			0.39			0.20964			0.7		
10/24/21 22:00	0.7			1			1.6			0.35			0.19134			0.64		
10/24/21 23:00	0.6			1			1.5			0.35			0.19002			0.63		
10/25/21 0:00	0.8			1			1.5			0.39			0.21192			0.71		
10/25/21 1:00	0.7			1			1.5			0.36			0.192			0.64		
10/25/21 2:00	0.6			1			1.5			0.35			0.19002			0.63		
10/25/21 3:00	0.7			1			1.5			0.36			0.19206			0.64		
10/25/21 4:00	0.8			0			1.5			0.52			0.2814			0.94		
10/25/21 5:00	0.8			0			1.5			0.55			0.2949			0.98		
10/25/21 6:00	0.8			0			1.5			0.52			0.2805			0.94		
10/25/21 7:00	0.9			0			1.5			0.51			0.27492			0.92		
10/25/21 8:00	0.8			0			1.5			0.54			0.29184			0.97		
10/25/21 9:00	0.8			1			1.6			0.42			0.22698			0.76		
10/25/21 10:00	0.6			1			1.5			0.34			0.18174			0.61		
10/25/21 11:00	0.6			1			1.5			0.33			0.17898			0.6		
10/25/21 12:00	0.6			1			1.5			0.33			0.1791			0.6		
10/25/21 13:00	0.6			1			1.5			0.34			0.18156			0.61		
10/25/21 14:00	0.6			1			1.5			0.34			0.18108			0.6		
10/25/21 15:00	0.6			1			1.5			0.33			0.17922			0.6		
10/25/21 16:00	0.7			0			1.4			0.47			0.2523			0.84		
10/25/21 17:00	0.8			0			1.5			0.45			0.24018			0.8		
10/25/21 18:00	0.9			1			1.6			0.44			0.2346			0.78		
10/25/21 19:00	0.9			0			1.4			0.5			0.26814			0.89		
10/25/21 20:00	0.8			0			1.6			0.54			0.29226			0.97		
10/25/21 21:00	0.8			1			1.5			0.36			0.19572			0.65		
10/25/21 22:00	0.6			1			1.5			0.34			0.1815			0.61		
10/25/21 23:00	0.6			1			1.5			0.34			0.18564			0.62		
10/26/21 0:00	0.6			1			1.5			0.34			0.18096			0.6		
10/26/21 1:00	0.6			1			1.5			0.34			0.183			0.61		
10/26/21 2:00	0.6			2			1.7			0.34			0.18324			0.61		
10/26/21 3:00	0.6			2			1.6			0.35			0.18666			0.62		
10/26/21 4:00	0.5			1			1.5			0.34			0.18192			0.61		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/26/21 5:00	0.8			0			1.4			0.47			0.25374			0.85		
10/26/21 6:00	0.7			1			1.6			0.36			0.1953			0.65		
10/26/21 7:00	0.8			1			1.4			0.4			0.21624			0.72		
10/26/21 8:00	0.7			1			1.5			0.35			0.18822			0.63		
10/26/21 9:00	0.6			1			1.5			0.35			0.1872			0.62		
10/26/21 10:00	0.6			1			1.5			0.35			0.18678			0.62		
10/26/21 11:00	0.7			1			1.6			0.36			0.19476			0.65		
10/26/21 12:00	0.6			1			1.5			0.35			0.18636			0.62		
10/26/21 13:00	0.6			1			1.5			0.34			0.18354			0.61		
10/26/21 14:00	0.7			0			1.5			0.37			0.19854			0.66		
10/26/21 15:00	0.6			1			1.5			0.34			0.18486			0.62		
10/26/21 16:00	0.7			1			1.5			0.38			0.20664			0.69		
10/26/21 17:00	0.6			1			1.5			0.35			0.19026			0.63		
10/26/21 18:00	0.8			0			1.4			0.45			0.24144			0.8		
10/26/21 19:00	0.8			0			1.4			0.45			0.24522			0.82		
10/26/21 20:00	0.9			0			1.5			0.49			0.26244			0.87		
10/26/21 21:00	0.8			1			1.4			0.48			0.25842			0.86		
10/26/21 22:00	0.9			0			1.5			0.49			0.267			0.89		
10/26/21 23:00	0.7			1			1.5			0.35			0.1884			0.63		
10/27/21 0:00	0.7			1			1.5			0.35			0.18792			0.63		
10/27/21 1:00	0.6			1			1.5			0.34			0.18324			0.61		
10/27/21 2:00	0.6			1			1.5			0.34			0.18114			0.6		
10/27/21 3:00	0.6			1			1.5			0.34			0.18474			0.62		
10/27/21 4:00	0.6			1			1.5			0.35			0.18606			0.62		
10/27/21 5:00	0.7			1			1.4			0.41			0.22086			0.74		
10/27/21 6:00	0.8			1			1.6			0.52			0.27798			0.93		
10/27/21 7:00	0.7			2			1.4			0.37			0.20172			0.67		
10/27/21 8:00	0.5			1			1.5			0.33			0.1794			0.6		
10/27/21 9:00	0.5			1			1.5			0.33			0.17934			0.6		
10/27/21 10:00	0.5			1			1.5			0.33			0.17934			0.6		
10/27/21 11:00	0.5			1			1.5			0.33			0.17922			0.6		
10/27/21 12:00	0.5			1			1.5			0.33			0.17904			0.6		
10/27/21 13:00	0.6			1			1.5			0.33			0.1794			0.6		
10/27/21 14:00	0.5			1			1.5			0.33			0.17916			0.6		
10/27/21 15:00	0.6			1			1.4			0.37			0.19668			0.66		
10/27/21 16:00	0.7			0			1.5			0.52			0.27756			0.93		
10/27/21 17:00	0.7			0			1.5			0.56			0.30252			1.01		
10/27/21 18:00	0.8			0			1.5			0.52			0.27816			0.93		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/27/21 19:00	0.8			0			1.5			0.54			0.29028			0.97		
10/27/21 20:00	0.8			0			1.5			0.49			0.26664			0.89		
10/27/21 21:00	0.8			0			1.5			0.5			0.2724			0.91		
10/27/21 22:00	0.7			1			1.6			0.37			0.19854			0.66		
10/27/21 23:00	0.6			1			1.5			0.35			0.18816			0.63		
10/28/21 0:00	0.7			1			1.5			0.35			0.18804			0.63		
10/28/21 1:00	0.7			1			1.5			0.35			0.18822			0.63		
10/28/21 2:00	0.7			1			1.5			0.35			0.18834			0.63		
10/28/21 3:00	0.7			1			1.5			0.35			0.18828			0.63		
10/28/21 4:00	0.8			1			1.4			0.38			0.20604			0.69		
10/28/21 5:00	0.8			1			1.5			0.46			0.24762			0.83		
10/28/21 6:00	0.8			1			1.6			0.47			0.25254			0.84		
10/28/21 7:00	0.6			2			1.6			0.35			0.18666			0.62		
10/28/21 8:00	0.5			1			1.5			0.34			0.18054			0.6		
10/28/21 9:00	0.6			1			1.5			0.33			0.17916			0.6		
10/28/21 10:00	0.6			1			1.5			0.34			0.18288			0.61		
10/28/21 11:00	0.6			1			1.5			0.35			0.18564			0.62		
10/28/21 12:00	0.6			1			1.5			0.35			0.18612			0.62		
10/28/21 13:00	0.5			1			1.5			0.33			0.17808			0.59		
10/28/21 14:00	0.6			1			1.5			0.34			0.17934			0.6		
10/28/21 15:00	0.6			1			1.5			0.34			0.18162			0.61		
10/28/21 16:00	0.7			0			1.4			0.5			0.26892			0.9		
10/28/21 17:00	0.8			0			1.5			0.56			0.30084			1		
10/28/21 18:00	0.9			0			1.5			0.53			0.28674			0.96		
10/28/21 19:00	0.8			0			1.5			0.55			0.2973			0.99		
10/28/21 20:00	0.8			0			1.5			0.53			0.28464			0.95		
10/28/21 21:00	0.9			1			1.6			0.47			0.25218			0.84		
10/28/21 22:00	0.7			1			1.5			0.35			0.1872			0.62		
10/28/21 23:00	0.7			1			1.5			0.34			0.18456			0.62		
10/29/21 0:00	0.7			1			1.5			0.34			0.18324			0.61		
10/29/21 1:00	0.7			1			1.5			0.34			0.18294			0.61		
10/29/21 2:00	0.7			1			1.5			0.33			0.1806			0.6		
10/29/21 3:00	0.7			1			1.5			0.35			0.18828			0.63		
10/29/21 4:00	0.7			1			1.5			0.35			0.18834			0.63		
10/29/21 5:00	0.8			1			1.4			0.42			0.22794			0.76		
10/29/21 6:00	0.9			1			1.5			0.46			0.24888			0.83		
10/29/21 7:00	0.9			1			1.5			0.34			0.18378			0.61		
10/29/21 8:00	0.7			1			1.5			0.33			0.17928			0.6		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/29/21 9:00	0.7			1			1.5			0.33			0.17988			0.6		
10/29/21 10:00	0.6			1			1.5			0.34			0.17946			0.6		
10/29/21 11:00	0.6			1			1.5			0.33			0.17922			0.6		
10/29/21 12:00	0.6			1			1.5			0.33			0.1782			0.59		
10/29/21 13:00	0.6			1			1.5			0.34			0.18108			0.6		
10/29/21 14:00	0.6			1			1.5			0.33			0.1782			0.59		
10/29/21 15:00	0.9			0			1.4			0.42			0.22506			0.75		
10/29/21 16:00	0.9			0			1.5			0.53			0.28998			0.97		
10/29/21 17:00	0.8			0			1.5			0.54			0.29352			0.98		
10/29/21 18:00	0.9			1			1.4			0.47			0.25218			0.84		
10/29/21 19:00	0.9			0			1.5			0.55			0.29454			0.98		
10/29/21 20:00	0.9			0			1.5			0.52			0.28002			0.93		
10/29/21 21:00	0.9			1			1.6			0.46			0.24978			0.83		
10/29/21 22:00	1			0			1.5			0.45			0.24354			0.81		
10/29/21 23:00	0.8			1			1.5			0.4			0.21624			0.72		
10/30/21 0:00	0.8			1			1.5			0.38			0.20406			0.68		
10/30/21 1:00	0.7			1			1.6			0.34			0.18474			0.62		
10/30/21 2:00	0.6			1			1.4			0.34			0.18066			0.6		
10/30/21 3:00	0.7			1			1.5			0.35			0.1857			0.62		
10/30/21 4:00	0.7			1			1.5			0.34			0.18528			0.62		
10/30/21 5:00	0.7			0			1.4			0.39			0.2085			0.7		
10/30/21 6:00	0.6			2			1.5			0.34			0.18348			0.61		
10/30/21 7:00	0.6			1			1.5			0.34			0.1806			0.6		
10/30/21 8:00	0.6			1			1.5			0.33			0.17904			0.6		
10/30/21 9:00	0.5			1			1.5			0.33			0.17868			0.6		
10/30/21 10:00	0.5			1			1.5			0.33			0.1785			0.6		
10/30/21 11:00	0.5			1			1.5			0.33			0.17838			0.59		
10/30/21 12:00	0.5			1			1.5			0.33			0.17808			0.59		
10/30/21 13:00	0.5			1			1.5			0.33			0.17784			0.59		
10/30/21 14:00	0.5			1			1.5			0.33			0.17796			0.59		
10/30/21 15:00	0.6			0			1.4			0.41			0.22008			0.73		
10/30/21 16:00	0.6			1			1.5			0.37			0.19764			0.66		
10/30/21 17:00	0.6			1			1.6			0.35			0.18858			0.63		
10/30/21 18:00	0.5			1			1.5			0.33			0.17928			0.6		
10/30/21 19:00	0.6			1			1.5			0.34			0.18396			0.61		
10/30/21 20:00	0.6			1			1.5			0.34			0.18174			0.61		
10/30/21 21:00	0.6			1			1.6			0.34			0.18084			0.6		
10/30/21 22:00	0.6			1			1.5			0.34			0.18084			0.6		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
10/30/21 23:00	0.6			1			1.5			0.34			0.18546			0.62		
10/31/21 0:00	0.6			1			1.5			0.34			0.1818			0.61		
10/31/21 1:00	0.6			1			1.5			0.34			0.18198			0.61		
10/31/21 2:00	0.6			1			1.5			0.34			0.18186			0.61		
10/31/21 3:00	0.6			1			1.5			0.34			0.18192			0.61		
10/31/21 4:00	0.6			1			1.5			0.34			0.18198			0.61		
10/31/21 5:00	0.6			1			1.5			0.35			0.18774			0.63		
10/31/21 6:00	0.7			1			1.6			0.37			0.19752			0.66		
10/31/21 7:00	0.6			1			1.5			0.34			0.18276			0.61		
10/31/21 8:00	0.6			1			1.5			0.34			0.18162			0.61		
10/31/21 9:00	0.6			1			1.5			0.34			0.18306			0.61		
10/31/21 10:00	0.5			1			1.5			0.33			0.1788			0.6		
10/31/21 11:00	0.5			1			1.5			0.33			0.17862			0.6		
10/31/21 12:00	0.5			1			1.5			0.33			0.17844			0.59		
10/31/21 13:00	0.5			1			1.5			0.33			0.17856			0.6		
10/31/21 14:00	0.5			1			1.5			0.33			0.17838			0.59		
10/31/21 15:00	0.6			1			1.4			0.36			0.19476			0.65		
10/31/21 16:00	0.5			1			1.6			0.33			0.17928			0.6		
10/31/21 17:00	0.5			1			1.5			0.33			0.17862			0.6		
10/31/21 18:00	0.5			1			1.5			0.33			0.17862			0.6		
10/31/21 19:00	0.6			1			1.5			0.33			0.17886			0.6		
10/31/21 20:00	0.7			1			1.5			0.33			0.17886			0.6		
10/31/21 21:00	0.7			1			1.5			0.33			0.17886			0.6		
10/31/21 22:00	0.7			1			1.5			0.33			0.17952			0.6		
10/31/21 23:00	0.7			1			1.5			0.34			0.18228			0.61		
11/01/21 0:00	0.6			1			1.5			0.33			0.18066			0.6		
11/01/21 1:00	0.7			1			1.5			0.34			0.18318			0.61		
11/01/21 2:00	0.6			1			1.5			0.33			0.17916			0.6		
11/01/21 3:00	0.7			0			1.5			0.35			0.18594			0.62		
11/01/21 4:00	0.8			1			1.4			0.4			0.21378			0.71		
11/01/21 5:00	0.7			1			1.6			0.34			0.18474			0.62		
11/01/21 6:00	0.8			0			1.3			0.52			0.28104			0.94		
11/01/21 7:00	0.7			1			1.6			0.41			0.2211			0.74		
11/01/21 8:00	0.6			1			1.5			0.35			0.18546			0.62		
11/01/21 9:00	0.8			1			1.4			0.43			0.22968			0.77		
11/01/21 10:00	0.7			1			1.6			0.37			0.19746			0.66		
11/01/21 11:00	0.9			0			1.3			0.43			0.23304			0.78		
11/01/21 12:00	0.8			1			1.5			0.46			0.24912			0.83		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/01/21 13:00	0.8			0			1.5			0.56			0.30078			1		
11/01/21 14:00	0.8			1			1.4			0.48			0.25848			0.86		
11/01/21 15:00	0.8			1			1.5			0.38			0.2052			0.68		
11/01/21 16:00	0.8			1			1.5			0.42			0.22716			0.76		
11/01/21 17:00	0.8			0			1.5			0.53			0.28758			0.96		
11/01/21 18:00	0.8			0			1.5			0.52			0.28032			0.93		
11/01/21 19:00	0.8			0			1.5			0.54			0.29166			0.97		
11/01/21 20:00	0.8			0			1.5			0.54			0.29394			0.98		
11/01/21 21:00	0.8			1			1.5			0.52			0.28326			0.94		
11/01/21 22:00	0.7			1			1.5			0.43			0.23304			0.78		
11/01/21 23:00	0.7			1			1.5			0.35			0.18972			0.63		
11/02/21 0:00	0.7			1			1.5			0.35			0.18894			0.63		
11/02/21 1:00	0.6			1			1.6			0.35			0.18678			0.62		
11/02/21 2:00	0.6			1			1.4			0.34			0.18054			0.6		
11/02/21 3:00	0.7			1			1.5			0.34			0.18552			0.62		
11/02/21 4:00	0.6			1			1.5			0.34			0.18546			0.62		
11/02/21 5:00	0.7			1			1.5			0.36			0.1959			0.65		
11/02/21 6:00	0.8			0			1.5			0.47			0.25572			0.85		
11/02/21 7:00	0.7			1			1.5			0.37			0.19884			0.66		
11/02/21 8:00	0.6			2			1.5			0.33			0.1785			0.6		
11/02/21 9:00	0.6			1			1.5			0.34			0.18066			0.6		
11/02/21 10:00	0.6			1			1.5			0.34			0.18108			0.6		
11/02/21 11:00	0.5			1			1.5			0.34			0.18132			0.6		
11/02/21 12:00	0.5			1			1.5			0.34			0.18156			0.61		
11/02/21 13:00	0.5			1			1.5			0.33			0.17784			0.59		
11/02/21 14:00	0.5			1			1.5			0.33			0.17784			0.59		
11/02/21 15:00	0.5			1			1.5			0.34			0.18108			0.6		
11/02/21 16:00	0.7			0			1.4			0.45			0.24426			0.81		
11/02/21 17:00	0.7			0			1.5			0.54			0.2901			0.97		
11/02/21 18:00	0.8			0			1.5			0.51			0.27702			0.92		
11/02/21 19:00	0.7			0			1.5			0.56			0.30132			1		
11/02/21 20:00	0.7			0			1.5			0.55			0.29682			0.99		
11/02/21 21:00	0.8			1			1.5			0.5			0.26772			0.89		
11/02/21 22:00	0.8			0			1.5			0.52			0.28068			0.94		
11/02/21 23:00	0.9			1			1.5			0.44			0.23802			0.79		
11/03/21 0:00	0.9			1			1.5			0.43			0.23166			0.77		
11/03/21 1:00	0.9			1			1.5			0.42			0.22518			0.75		
11/03/21 2:00	1			1			1.5			0.42			0.22542			0.75		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/03/21 3:00	1			1			1.5			0.43			0.22956			0.77		
11/03/21 4:00	0.9			1			1.5			0.45			0.246			0.82		
11/03/21 5:00	0.9			0			1.5			0.5			0.27306			0.91		
11/03/21 6:00	0.9			1			1.5			0.5			0.2724			0.91		
11/03/21 7:00	0.7			2			1.6			0.39			0.20808			0.69		
11/03/21 8:00	0.6			1			1.5			0.34			0.18264			0.61		
11/03/21 9:00	0.5			1			1.5			0.33			0.17844			0.59		
11/03/21 10:00	0.5			1			1.5			0.33			0.1791			0.6		
11/03/21 11:00	0.5			1			1.5			0.33			0.17898			0.6		
11/03/21 12:00	0.5			1			1.5			0.34			0.18078			0.6		
11/03/21 13:00	0.5			1			1.5			0.34			0.1821			0.61		
11/03/21 14:00	0.5			1			1.6			0.34			0.18114			0.6		
11/03/21 15:00	0.6			0			1.4			0.4			0.21606			0.72		
11/03/21 16:00	0.7			0			1.5			0.45			0.24048			0.8		
11/03/21 17:00	0.7			0			1.5			0.55			0.2949			0.98		
11/03/21 18:00	0.7			0			1.5			0.52			0.28122			0.94		
11/03/21 19:00	0.7			0			1.5			0.54			0.29292			0.98		
11/03/21 20:00	0.7			0			1.5			0.54			0.29214			0.97		
11/03/21 21:00	0.8			0			1.5			0.5			0.2703			0.9		
11/03/21 22:00	0.7			1			1.5			0.42			0.2259			0.75		
11/03/21 23:00	0.6			1			1.5			0.35			0.18624			0.62		
11/04/21 0:00	0.6			1			1.5			0.34			0.18396			0.61		
11/04/21 1:00	0.5			1			1.5			0.33			0.17856			0.6		
11/04/21 2:00	0.6			1			1.7			0.35			0.1869			0.62		
11/04/21 3:00	0.8			0			1.2			0.46			0.2475			0.83		
11/04/21 4:00	0.7			1			1.5			0.4			0.21462			0.72		
11/04/21 5:00	0.8			0			1.5			0.5			0.2721			0.91		
11/04/21 6:00	0.7			0			1.5			0.53			0.28332			0.94		
11/04/21 7:00	0	X		0	X		0	X		0.38			0.20412			0.68		
11/04/21 8:00	0.5			3			1.8			0.34			0.18402			0.61		
11/04/21 9:00	0.6			1			1.2			0.43			0.23154			0.77		
11/04/21 10:00	0.5			2			1.5			0.33			0.1779			0.59		
11/04/21 11:00	0.5			1			1.5			0.33			0.1785			0.6		
11/04/21 12:00	0.5			1			1.5			0.33			0.17778			0.59		
11/04/21 13:00	0.5			1			1.5			0.34			0.17946			0.6		
11/04/21 14:00	0.5			1			1.5			0.33			0.17748			0.59		
11/04/21 15:00	0.6			0			1.3			0.41			0.2196			0.73		
11/04/21 16:00	0.6			1			1.6			0.36			0.19524			0.65		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/04/21 17:00	0.5			1			1.5			0.34			0.1818			0.61		
11/04/21 18:00	0.6			1			1.5			0.34			0.1842			0.61		
11/04/21 19:00	0.6			1			1.5			0.34			0.1842			0.61		
11/04/21 20:00	0.7			1			1.5			0.34			0.1827			0.61		
11/04/21 21:00	0.6			1			1.5			0.33			0.1785			0.6		
11/04/21 22:00	0.5			2			1.5			0.33			0.17886			0.6		
11/04/21 23:00	0.5			2			1.5			0.33			0.17826			0.59		
11/05/21 0:00	0.4			2			1.5			0.33			0.17808			0.59		
11/05/21 1:00	0.5			2			1.5			0.33			0.17808			0.59		
11/05/21 2:00	0.5			1			1.5			0.33			0.17904			0.6		
11/05/21 3:00	0.6			1			1.5			0.34			0.18426			0.61		
11/05/21 4:00	0.7			1			1.5			0.37			0.2016			0.67		
11/05/21 5:00	0.7			1			1.4			0.47			0.25542			0.85		
11/05/21 6:00	0.8			0			1.5			0.5			0.27036			0.9		
11/05/21 7:00	0.7			1			1.5			0.43			0.23076			0.77		
11/05/21 8:00	0.7			2			1.5			0.34			0.18282			0.61		
11/05/21 9:00	0.6			2			1.4			0.33			0.17778			0.59		
11/05/21 10:00	0.5			1			1.5			0.33			0.17772			0.59		
11/05/21 11:00	0.5			1			1.5			0.33			0.17778			0.59		
11/05/21 12:00	0.5			1			1.5			0.33			0.17814			0.59		
11/05/21 13:00	0.5			1			1.5			0.33			0.1782			0.59		
11/05/21 14:00	0.6			0			1.3			0.39			0.2103			0.7		
11/05/21 15:00	0.7			0			1.5			0.5			0.26628			0.89		
11/05/21 16:00	0.7			1			1.5			0.45			0.2415			0.81		
11/05/21 17:00	0.8			1			1.5			0.46			0.246			0.82		
11/05/21 18:00	0.7			1			1.4			0.39			0.2091			0.7		
11/05/21 19:00	0.8			1			1.4			0.44			0.23562			0.79		
11/05/21 20:00	0.7			1			1.4			0.45			0.24216			0.81		
11/05/21 21:00	0.7			1			1.6			0.49			0.26646			0.89		
11/05/21 22:00	0.7			1			1.4			0.4			0.21528			0.72		
11/05/21 23:00	0.8			1			1.5			0.45			0.24456			0.82		
11/06/21 0:00	0.6			1			1.4			0.36			0.19098			0.64		
11/06/21 1:00	0.9			1			1.5			0.42			0.22818			0.76		
11/06/21 2:00	0.7			0		X	1.5			0.36			0.19458			0.65		
11/06/21 3:00	0.6			0		X	1.5			0.35			0.18744			0.62		
11/06/21 4:00	0.7			0		X	1.5			0.38			0.20442			0.68		
11/06/21 5:00	0.8			0		X	1.4			0.46			0.249			0.83		
11/06/21 6:00	0.7			0		X	1.5			0.52			0.28152			0.94		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/06/21 7:00	0.7			0	X		1.6			0.43			0.23304			0.78		
11/06/21 8:00	0.7			0	X		1.6			0.4			0.2172			0.72		
11/06/21 9:00	0.5			0	X		1.4			0.34			0.1833			0.61		
11/06/21 10:00	0.5			0	X		1.5			0.34			0.1809			0.6		
11/06/21 11:00	0.5			0	X		1.5			0.34			0.18084			0.6		
11/06/21 12:00	0.5			0	X		1.5			0.33			0.1788			0.6		
11/06/21 13:00	0.5			0	X		1.5			0.33			0.17892			0.6		
11/06/21 14:00	0.5			0	X		1.5			0.33			0.17868			0.6		
11/06/21 15:00	0.6			0	X		1.3			0.38			0.20742			0.69		
11/06/21 16:00	0.7			0	X		1.5			0.46			0.24954			0.83		
11/06/21 17:00	0.7			0	X		1.5			0.53			0.28386			0.95		
11/06/21 18:00	0.7			0	X		1.5			0.41			0.22296			0.74		
11/06/21 19:00	0.7			0	X		1.5			0.55			0.29718			0.99		
11/06/21 20:00	0.8			0	X		1.5			0.51			0.27432			0.91		
11/06/21 21:00	0.8			0	X		1.6			0.46			0.24768			0.83		
11/06/21 22:00	0.6			0	X		1.5			0.35			0.18762			0.63		
11/06/21 23:00	0.6			0	X		1.5			0.35			0.1869			0.62		
11/07/21 0:00	0.4			0	X		1.5			0.33			0.17976			0.6		
11/07/21 1:00	0.4			0	X		1.5			0.33			0.17976			0.6		
11/07/21 2:00	0.5			0	X		1.5			0.33			0.18042			0.6		
11/07/21 3:00	0	X		0	X		0	X		0.34			0.18036			0.6		
11/07/21 4:00	0	X		0	X		0	X		0.34			0.18024			0.6		
11/07/21 5:00	0.5			0	X		1.2			0.34			0.18204			0.61		
11/07/21 6:00	0.7			-1			0.9			0.46			0.24912			0.83		
11/07/21 7:00	0.8			1			1.7			0.5			0.26742			0.89		
11/07/21 8:00	0.4			2			1.4			0.33			0.18036			0.6		
11/07/21 9:00	0.4			2			1.5			0.33			0.18024			0.6		
11/07/21 10:00	0.4			2			1.5			0.33			0.17922			0.6		
11/07/21 11:00	0.4			2			1.5			0.33			0.17754			0.59		
11/07/21 12:00	0.5			2			1.5			0.33			0.17712			0.59		
11/07/21 13:00	0.5			1			1.4			0.33			0.17706			0.59		
11/07/21 14:00	0.5			1			1.5			0.33			0.18036			0.6		
11/07/21 15:00	0.7			1			1.2			0.44			0.23478			0.78		
11/07/21 16:00	0.7			1			1.4			0.45			0.24504			0.82		
11/07/21 17:00	0.8			1			1.5			0.41			0.22002			0.73		
11/07/21 18:00	0.7			1			1.3			0.39			0.20772			0.69		
11/07/21 19:00	0.8			1			1.5			0.45			0.24474			0.82		
11/07/21 20:00	0.8			2			1.5			0.36			0.19494			0.65		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/07/21 21:00	0.8			1			1.4			0.34			0.18498			0.62		
11/07/21 22:00	0.7			1			1.5			0.34			0.18522			0.62		
11/07/21 23:00	0.5			2			1.5			0.33			0.17814			0.59		
11/08/21 0:00	0.6			2			1.4			0.33			0.17982			0.6		
11/08/21 1:00	0.7			1			1.5			0.34			0.18642			0.62		
11/08/21 2:00	0.8			0			1.4			0.39			0.2091			0.7		
11/08/21 3:00	0.9			0			1.5			0.54			0.28998			0.97		
11/08/21 4:00	0.8			0			1.5			0.54			0.29214			0.97		
11/08/21 5:00	0.8			0			1.5			0.55			0.2997			1		
11/08/21 6:00	0.8			0			1.4			0.55			0.29706			0.99		
11/08/21 7:00	0.8			2			1.5			0.42			0.22884			0.76		
11/08/21 8:00	0.6			2			1.2			0.33			0.17934			0.6		
11/08/21 9:00	0.5			1			1.4			0.33			0.1791			0.6		
11/08/21 10:00	0.6			2			1.4			0.33			0.17778			0.59		
11/08/21 11:00	0.5			1			1.4			0.33			0.17772			0.59		
11/08/21 12:00	0.5			1			1.4			0.33			0.17742			0.59		
11/08/21 13:00	0.5			1			1.4			0.33			0.17712			0.59		
11/08/21 14:00	0.5			1			1.4			0.33			0.1767			0.59		
11/08/21 15:00	0.7			0			1.3			0.45			0.24456			0.82		
11/08/21 16:00	1.2			0			1.5			0.55			0.29832			0.99		
11/08/21 17:00	1.5			1			1.5			0.58			0.31038			1.03		
11/08/21 18:00	1.4			1			1.5			0.58			0.31038			1.03		
11/08/21 19:00	1.3			0			1.5			0.56			0.30162			1.01		
11/08/21 20:00	0.8			0			1.5			0.53			0.28692			0.96		
11/08/21 21:00	0.8			1			1.5			0.5			0.26778			0.89		
11/08/21 22:00	0.7			1			1.5			0.44			0.23496			0.78		
11/08/21 23:00	0.6			1			1.5			0.35			0.18684			0.62		
11/09/21 0:00	0.6			1			1.5			0.35			0.18642			0.62		
11/09/21 1:00	0.6			1			1.5			0.35			0.18582			0.62		
11/09/21 2:00	0.6			1			1.5			0.34			0.18306			0.61		
11/09/21 3:00	0.5			1			1.4			0.33			0.17916			0.6		
11/09/21 4:00	0.6			1			1.6			0.34			0.18528			0.62		
11/09/21 5:00	0.6			1			1.4			0.37			0.20082			0.67		
11/09/21 6:00	0.7			1			1.5			0.37			0.19734			0.66		
11/09/21 7:00	0.6			1			1.6			0.42			0.22824			0.76		
11/09/21 8:00	0.5			1			1.5			0.34			0.18168			0.61		
11/09/21 9:00	0.5			1			1.5			0.33			0.17904			0.6		
11/09/21 10:00	0.6			1			1.5			0.34			0.18522			0.62		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/09/21 11:00	0.5			1			1.5			0.34			0.18108			0.6		
11/09/21 12:00	0.5			2			1.5			0.34			0.18006			0.6		
11/09/21 13:00	0.5			1			1.5			0.34			0.18012			0.6		
11/09/21 14:00	0.6			1			1.5			0.35			0.18732			0.62		
11/09/21 15:00	0.6			1			1.4			0.39			0.21114			0.7		
11/09/21 16:00	0.6			1			1.4			0.4			0.21606			0.72		
11/09/21 17:00	0.7			0			1.5			0.46			0.25032			0.83		
11/09/21 18:00	0.7			0			1.5			0.55			0.29946			1		
11/09/21 19:00	0.7			0			1.5			0.54			0.29316			0.98		
11/09/21 20:00	0.7			0			1.5			0.53			0.28848			0.96		
11/09/21 21:00	0.6			1			1.6			0.4			0.21444			0.71		
11/09/21 22:00	0.6			1			1.5			0.35			0.18756			0.63		
11/09/21 23:00	0.6			1			1.5			0.34			0.18492			0.62		
11/10/21 0:00	0.6			1			1.5			0.34			0.18102			0.6		
11/10/21 1:00	0.5			1			1.5			0.33			0.17946			0.6		
11/10/21 2:00	0.5			1			1.5			0.33			0.1794			0.6		
11/10/21 3:00	0.5			2			1.5			0.33			0.17928			0.6		
11/10/21 4:00	0.5			1			1.5			0.33			0.17922			0.6		
11/10/21 5:00	0.6			0			1.4			0.43			0.23112			0.77		
11/10/21 6:00	0.7			1			1.4			0.46			0.24744			0.82		
11/10/21 7:00	0.7			1			1.6			0.46			0.24702			0.82		
11/10/21 8:00	0.5			1			1.5			0.33			0.17928			0.6		
11/10/21 9:00	0.5			1			1.6			0.34			0.18252			0.61		
11/10/21 10:00	0.5			1			1.5			0.34			0.18456			0.62		
11/10/21 11:00	0.5			1			1.5			0.33			0.17946			0.6		
11/10/21 12:00	0.5			1			1.5			0.33			0.1794			0.6		
11/10/21 13:00	0.5			1			1.5			0.33			0.17934			0.6		
11/10/21 14:00	0.5			1			1.5			0.33			0.17928			0.6		
11/10/21 15:00	0.5			1			1.5			0.33			0.17994			0.6		
11/10/21 16:00	0.6			1			1.5			0.34			0.18426			0.61		
11/10/21 17:00	0.6			1			1.5			0.35			0.1869			0.62		
11/10/21 18:00	0.6			1			1.5			0.35			0.18678			0.62		
11/10/21 19:00	0.6			1			1.5			0.35			0.18792			0.63		
11/10/21 20:00	0.6			1			1.5			0.35			0.189			0.63		
11/10/21 21:00	0.7			1			1.4			0.38			0.20256			0.68		
11/10/21 22:00	0.6			1			1.5			0.35			0.18852			0.63		
11/10/21 23:00	0.6			1			1.5			0.35			0.18708			0.62		
11/11/21 0:00	0.6			1			1.5			0.34			0.18402			0.61		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/11/21 1:00	0.6			1			1.5			0.35			0.18732			0.62		
11/11/21 2:00	0.6			2			1.5			0.33			0.1794			0.6		
11/11/21 3:00	0.7			2			1.5			0.33			0.17988			0.6		
11/11/21 4:00	0.7			1			1.5			0.35			0.18654			0.62		
11/11/21 5:00	0.7			1			1.5			0.35			0.18852			0.63		
11/11/21 6:00	0.7			1			1.5			0.35			0.18822			0.63		
11/11/21 7:00	0.7			1			1.5			0.35			0.18762			0.63		
11/11/21 8:00	0.6			1			1.5			0.35			0.18648			0.62		
11/11/21 9:00	0.6			1			1.5			0.35			0.18714			0.62		
11/11/21 10:00	0.6			1			1.5			0.35			0.18636			0.62		
11/11/21 11:00	0.5			2			1.5			0.33			0.1797			0.6		
11/11/21 12:00	0.5			1			1.5			0.33			0.18018			0.6		
11/11/21 13:00	0.5			1			1.5			0.34			0.1809			0.6		
11/11/21 14:00	0.5			1			1.5			0.34			0.18036			0.6		
11/11/21 15:00	0.6			0			1.3			0.38			0.20514			0.68		
11/11/21 16:00	1.1			0			1.4			0.46			0.2442			0.81		
11/11/21 17:00	1.8			0			1.5			0.58			0.31008			1.03		
11/11/21 18:00	1.4			0			1.5			0.58			0.30906			1.03		
11/11/21 19:00	1.4			0			1.5			0.58			0.30762			1.03		
11/11/21 20:00	1.5			0			1.5			0.59			0.30654			1.02		
11/11/21 21:00	1.5			0			1.5			0.59			0.30774			1.03		
11/11/21 22:00	1.3			1			1.6			0.49			0.26256			0.88		
11/11/21 23:00	0.7			1			1.5			0.36			0.19344			0.64		
11/12/21 0:00	0.6			2			1.5			0.34			0.1812			0.6		
11/12/21 1:00	0.5			2			1.5			0.33			0.1791			0.6		
11/12/21 2:00	0.5			1			1.5			0.33			0.17916			0.6		
11/12/21 3:00	0.6			2			1.5			0.33			0.17934			0.6		
11/12/21 4:00	0.5			1			1.5			0.33			0.18048			0.6		
11/12/21 5:00	0.7			1			1.5			0.35			0.1878			0.63		
11/12/21 6:00	0.7			1			1.5			0.35			0.1884			0.63		
11/12/21 7:00	0.6			2			1.5			0.34			0.18246			0.61		
11/12/21 8:00	0.6			1			1.5			0.34			0.1821			0.61		
11/12/21 9:00	0.5			1			1.5			0.33			0.17922			0.6		
11/12/21 10:00	0.5			1			1.5			0.33			0.17916			0.6		
11/12/21 11:00	0.5			1			1.5			0.33			0.17934			0.6		
11/12/21 12:00	0.5			1			1.5			0.33			0.17916			0.6		
11/12/21 13:00	0.5			1			1.5			0.33			0.17904			0.6		
11/12/21 14:00	0.5			1			1.5			0.34			0.18132			0.6		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/12/21 15:00	0.6			1			1.4			0.37			0.1983			0.66		
11/12/21 16:00	0.6			1			1.6			0.34			0.18438			0.61		
11/12/21 17:00	0.6			1			1.6			0.35			0.186			0.62		
11/12/21 18:00	0.6			1			1.5			0.33			0.17988			0.6		
11/12/21 19:00	0.7			1			1.5			0.35			0.18774			0.63		
11/12/21 20:00	0.7			1			1.5			0.35			0.18756			0.63		
11/12/21 21:00	0.7			1			1.2			0.39			0.21012			0.7		
11/12/21 22:00	0.6			1			1.6			0.34			0.18378			0.61		
11/12/21 23:00	0.5			1			1.5			0.33			0.17958			0.6		
11/13/21 0:00	0.6			1			1.5			0.34			0.18108			0.6		
11/13/21 1:00	0.6			1			1.5			0.33			0.18078			0.6		
11/13/21 2:00	0.7			2			1.4			0.35			0.18762			0.63		
11/13/21 3:00	0.7			2			1.3			0.35			0.18744			0.62		
11/13/21 4:00	0.8			0			1.2			0.37			0.19848			0.66		
11/13/21 5:00	0.8			0			1.3			0.43			0.23328			0.78		
11/13/21 6:00	0.8			0			1.5			0.56			0.3015			1.01		
11/13/21 7:00	0.8			0			1.5			0.56			0.30126			1		
11/13/21 8:00	0.8			0			1.5			0.56			0.30126			1		
11/13/21 9:00	0.8			0			1.5			0.56			0.30114			1		
11/13/21 10:00	0.8			1			1.5			0.45			0.24216			0.81		
11/13/21 11:00	0.6			1			1.4			0.36			0.19446			0.65		
11/13/21 12:00	0.5			1			1.5			0.34			0.18282			0.61		
11/13/21 13:00	0.5			2			1.6			0.34			0.1809			0.6		
11/13/21 14:00	0.5			1			1.5			0.33			0.18018			0.6		
11/13/21 15:00	0.7			0			1.5			0.36			0.19614			0.65		
11/13/21 16:00	0.7			0			1.4			0.53			0.28782			0.96		
11/13/21 17:00	0.8			1			1.6			0.39			0.20766			0.69		
11/13/21 18:00	0.8			1			1.4			0.39			0.21018			0.7		
11/13/21 19:00	0.9			0			1.3			0.49			0.26412			0.88		
11/13/21 20:00	0.8			1			1.6			0.47			0.25536			0.85		
11/13/21 21:00	0.7			1			1.6			0.37			0.20118			0.67		
11/13/21 22:00	0.6			1			1.5			0.35			0.18828			0.63		
11/13/21 23:00	0.5			2			1.5			0.34			0.1812			0.6		
11/14/21 0:00	0.5			2			1.5			0.33			0.17916			0.6		
11/14/21 1:00	0.5			2			1.5			0.33			0.17916			0.6		
11/14/21 2:00	0.5			1			1.5			0.33			0.17922			0.6		
11/14/21 3:00	0.5			2			1.5			0.33			0.17898			0.6		
11/14/21 4:00	0.5			1			1.5			0.33			0.1797			0.6		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/14/21 5:00	0.5			2			1.5			0.33			0.1791			0.6		
11/14/21 6:00	0.5			2			1.5			0.33			0.1803			0.6		
11/14/21 7:00	0.6			1			1.5			0.34			0.18198			0.61		
11/14/21 8:00	0.5			2			1.5			0.34			0.18078			0.6		
11/14/21 9:00	0.5			1			1.5			0.33			0.18078			0.6		
11/14/21 10:00	0.5			1			1.5			0.33			0.18072			0.6		
11/14/21 11:00	0.5			1			1.5			0.33			0.1806			0.6		
11/14/21 12:00	0.5			1			1.5			0.33			0.1806			0.6		
11/14/21 13:00	0.5			2			1.5			0.33			0.17952			0.6		
11/14/21 14:00	0.5			1			1.5			0.33			0.17898			0.6		
11/14/21 15:00	0.6			1			1.3			0.36			0.19518			0.65		
11/14/21 16:00	0.6			1			1.6			0.34			0.18096			0.6		
11/14/21 17:00	0.5			2			1.6			0.34			0.18096			0.6		
11/14/21 18:00	0.5			1			1.5			0.33			0.18018			0.6		
11/14/21 19:00	0.6			1			1.5			0.34			0.183			0.61		
11/14/21 20:00	0.7			1			1.4			0.36			0.19146			0.64		
11/14/21 21:00	0.7			1			1.6			0.35			0.1869			0.62		
11/14/21 22:00	0.6			1			1.5			0.34			0.18204			0.61		
11/14/21 23:00	0.5			2			1.5			0.33			0.17934			0.6		
11/15/21 0:00	0.6			1			1.5			0.33			0.17976			0.6		
11/15/21 1:00	0.5			2			1.5			0.33			0.1791			0.6		
11/15/21 2:00	0.5			1			1.6			0.33			0.17916			0.6		
11/15/21 3:00	0.6			1			1.5			0.33			0.18006			0.6		
11/15/21 4:00	0.6			1			1.5			0.34			0.18156			0.61		
11/15/21 5:00	0.7			1			1.5			0.35			0.18648			0.62		
11/15/21 6:00	0.7			1			1.4			0.38			0.20526			0.68		
11/15/21 7:00	0.7			1			1.4			0.39			0.20946			0.7		
11/15/21 8:00	0.6			1			1.4			0.34			0.18288			0.61		
11/15/21 9:00	0.6			1			1.5			0.35			0.1878			0.63		
11/15/21 10:00	0.6			1			1.5			0.35			0.18732			0.62		
11/15/21 11:00	0.6			1			1.6			0.34			0.18438			0.61		
11/15/21 12:00	0.5			2			1.5			0.33			0.17874			0.6		
11/15/21 13:00	0.6			1			1.5			0.34			0.18306			0.61		
11/15/21 14:00	0.7			0			1.3			0.43			0.22884			0.76		
11/15/21 15:00	0.7			1			1.4			0.41			0.21828			0.73		
11/15/21 16:00	0.7			1			1.5			0.37			0.19788			0.66		
11/15/21 17:00	0.7			1			1.6			0.35			0.18624			0.62		
11/15/21 18:00	0.7			1			1.5			0.35			0.18846			0.63		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/15/21 19:00	0.9			0			1.5			0.44			0.23778			0.79		
11/15/21 20:00	0.6			1			1.5			0.35			0.18744			0.62		
11/15/21 21:00	0.8			1			1.4			0.38			0.20298			0.68		
11/15/21 22:00	0.7			1			1.6			0.34			0.18582			0.62		
11/15/21 23:00	0.6			1			1.5			0.33			0.17898			0.6		
11/16/21 0:00	0.7			1			1.6			0.35			0.18654			0.62		
11/16/21 1:00	0.6			1			1.5			0.35			0.18756			0.63		
11/16/21 2:00	0.6			2			1.6			0.34			0.18252			0.61		
11/16/21 3:00	0.5			2			1.5			0.33			0.17982			0.6		
11/16/21 4:00	0.6			1			1.5			0.35			0.18606			0.62		
11/16/21 5:00	0.7			0			1.3			0.47			0.25338			0.84		
11/16/21 6:00	0.7			0			1.5			0.56			0.30264			1.01		
11/16/21 7:00	0.7			0			1.5			0.56			0.30258			1.01		
11/16/21 8:00	0.7			1			1.6			0.46			0.24936			0.83		
11/16/21 9:00	0.7			0			1.2			0.42			0.22692			0.76		
11/16/21 10:00	0.6			2			1.3			0.34			0.18396			0.61		
11/16/21 11:00	0.6			1			1.4			0.34			0.18324			0.61		
11/16/21 12:00	0.5			1			1.4			0.34			0.1809			0.6		
11/16/21 13:00	0.6			1			1.5			0.34			0.18096			0.6		
11/16/21 14:00	0.6			1			1.5			0.34			0.18048			0.6		
11/16/21 15:00	0.7			0			1.4			0.37			0.19884			0.66		
11/16/21 16:00	0.7			1			1.6			0.35			0.1878			0.63		
11/16/21 17:00	0.8			0			1.3			0.43			0.23316			0.78		
11/16/21 18:00	0.9			0			1.6			0.46			0.24996			0.83		
11/16/21 19:00	0.8			1			1.3			0.4			0.21768			0.73		
11/16/21 20:00	0.8			0			1.5			0.52			0.2814			0.94		
11/16/21 21:00	0.8			0			1.5			0.53			0.28548			0.95		
11/16/21 22:00	0.8			1			1.6			0.48			0.25776			0.86		
11/16/21 23:00	0.9			0			1.4			0.43			0.23064			0.77		
11/17/21 0:00	1.9			0			1.5			0.57			0.30318			1.01		
11/17/21 1:00	1.4			1			1.6			0.49			0.26022			0.87		
11/17/21 2:00	0.7			1			1.5			0.35			0.18732			0.62		
11/17/21 3:00	0.7			1			1.5			0.35			0.18804			0.63		
11/17/21 4:00	0.8			0			1.3			0.42			0.22842			0.76		
11/17/21 5:00	0.7			1			1.5			0.43			0.23022			0.77		
11/17/21 6:00	0.8			0			1.5			0.54			0.29118			0.97		
11/17/21 7:00	0.8			1			1.6			0.45			0.24396			0.81		
11/17/21 8:00	0.6			1			1.3			0.35			0.18582			0.62		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/17/21 9:00	0.7			1			1.5			0.35			0.18768			0.63		
11/17/21 10:00	0.6			1			1.5			0.35			0.18678			0.62		
11/17/21 11:00	0.5			2			1.3			0.33			0.18012			0.6		
11/17/21 12:00	0.5			2			1.3			0.33			0.17916			0.6		
11/17/21 13:00	0.5			2			1.3			0.33			0.1788			0.6		
11/17/21 14:00	0.5			2			1.3			0.33			0.1788			0.6		
11/17/21 15:00	0.6			0			1.2			0.4			0.21678			0.72		
11/17/21 16:00	0.7			0			1.3			0.46			0.24648			0.82		
11/17/21 17:00	0.7			0			1.3			0.53			0.28416			0.95		
11/17/21 18:00	0.7			0			1.3			0.55			0.29694			0.99		
11/17/21 19:00	0.8			0			1.3			0.55			0.2979			0.99		
11/17/21 20:00	0.8			0			1.3			0.54			0.2934			0.98		
11/17/21 21:00	0.9			0			1.3			0.5			0.2682			0.89		
11/17/21 22:00	0.8			1			1.4			0.36			0.19506			0.65		
11/17/21 23:00	0.7			1			1.3			0.35			0.18864			0.63		
11/18/21 0:00	0.7			1			1.3			0.35			0.18822			0.63		
11/18/21 1:00	0.7			1			1.3			0.35			0.18822			0.63		
11/18/21 2:00	0.7			1			1.4			0.35			0.18816			0.63		
11/18/21 3:00	0.7			1			1.5			0.35			0.18816			0.63		
11/18/21 4:00	0.7			1			1.5			0.35			0.18816			0.63		
11/18/21 5:00	0.7			1			1.3			0.4			0.216			0.72		
11/18/21 6:00	0.9			0			1.5			0.53			0.28734			0.96		
11/18/21 7:00	0.9			1			1.6			0.49			0.26286			0.88		
11/18/21 8:00	0.9			1			1.3			0.44			0.23712			0.79		
11/18/21 9:00	0.7			2			1.2			0.35			0.18864			0.63		
11/18/21 10:00	0.5			2			1.2			0.34			0.18054			0.6		
11/18/21 11:00	0.5			2			1.2			0.34			0.18084			0.6		
11/18/21 12:00	0.5			2			1.2			0.34			0.18078			0.6		
11/18/21 13:00	0.7			1			1.3			0.35			0.19044			0.63		
11/18/21 14:00	0.7			0			1.4			0.37			0.20142			0.67		
11/18/21 15:00	0.7			0			1.2			0.5			0.26766			0.89		
11/18/21 16:00	0.8			0			1.2			0.53			0.28356			0.95		
11/18/21 17:00	0.9			0			1.2			0.53			0.28626			0.95		
11/18/21 18:00	0.7			0			1.4			0.56			0.303			1.01		
11/18/21 19:00	0.7			0			1.5			0.55			0.29454			0.98		
11/18/21 20:00	0.8			1			1.6			0.46			0.24972			0.83		
11/18/21 21:00	1			0			1.1			0.42			0.22626			0.75		
11/18/21 22:00	0.8			1			1.3			0.39			0.20922			0.7		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/18/21 23:00	0.8			1			1.2			0.37			0.20124			0.67		
11/19/21 0:00	0.7			1			1.2			0.28			0.1992			0.66		
11/19/21 1:00	0.7			1			1.3			0	X		0.18618			0.62		
11/19/21 2:00	0.7			1			1.4			0	X		0.18702			0.62		
11/19/21 3:00	0.8			0			1.4			0	X		0.22458			0.75		
11/19/21 4:00	0.7			1			1.5			0	X		0.1866			0.62		
11/19/21 5:00	0.7			1			1.5			0	X		0.18642			0.62		
11/19/21 6:00	0.7			1			1.4			0	X		0.19374			0.65		
11/19/21 7:00	0.8			0			1.3			0.03			0.25266			0.84		
11/19/21 8:00	0.8			1			1.7			0.35			0.21276			0.71		
11/19/21 9:00	0.6			2			1.2			0.34			0.18084			0.6		
11/19/21 10:00	0.6			2			1.2			0.34			0.18162			0.61		
11/19/21 11:00	0.6			1			1.2			0.34			0.18276			0.61		
11/19/21 12:00	0.6			0			1.2			0.36			0.19044			0.63		
11/19/21 13:00	0.7			0			1			0.51			0.2721			0.91		
11/19/21 14:00	0.7			0			1.2			0.48			0.25854			0.86		
11/19/21 15:00	0.7			1			1.2			0.41			0.21978			0.73		
11/19/21 16:00	0.6			1			1.3			0.35			0.18978			0.63		
11/19/21 17:00	0.7			1			1.2			0.38			0.20472			0.68		
11/19/21 18:00	0.6			1			1.2			0.36			0.19518			0.65		
11/19/21 19:00	0.6			1			1.2			0.35			0.18822			0.63		
11/19/21 20:00	0.7			1			1.2			0.41			0.21792			0.73		
11/19/21 21:00	0.7			1			1.2			0.39			0.2085			0.7		
11/19/21 22:00	0.7			1			1.1			0.39			0.2109			0.7		
11/19/21 23:00	0.5			2			1.2			0.34			0.18168			0.61		
11/20/21 0:00	0.4			2			1.2			0.33			0.17934			0.6		
11/20/21 1:00	0.5			2			1.2			0.33			0.1803			0.6		
11/20/21 2:00	0.5			2			1.2			0.33			0.18036			0.6		
11/20/21 3:00	0.5			2			1.2			0.34			0.18132			0.6		
11/20/21 4:00	0.6			1			1.2			0.35			0.18822			0.63		
11/20/21 5:00	0.5			2			1.2			0.34			0.18288			0.61		
11/20/21 6:00	0.6			1			1.4			0.35			0.1914			0.64		
11/20/21 7:00	0.7			1			1.4			0.43			0.23004			0.77		
11/20/21 8:00	0.4			2			1.3			0.33			0.17892			0.6		
11/20/21 9:00	0.4			2			1.3			0.33			0.17874			0.6		
11/20/21 10:00	0.4			2			1.3			0.33			0.17892			0.6		
11/20/21 11:00	0.5			2			1.3			0.33			0.1785			0.6		
11/20/21 12:00	0.5			2			1.3			0.33			0.17844			0.59		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/20/21 13:00	0.5			2			1.3			0.33			0.17802			0.59		
11/20/21 14:00	0.5			1			1.3			0.33			0.17784			0.59		
11/20/21 15:00	0.6			0			1			0.4			0.2136			0.71		
11/20/21 16:00	0.6			1			1.2			0.4			0.21396			0.71		
11/20/21 17:00	0.6			1			1.3			0.36			0.19194			0.64		
11/20/21 18:00	0.6			1			1.3			0.35			0.18576			0.62		
11/20/21 19:00	0.7			1			1.2			0.38			0.2055			0.69		
11/20/21 20:00	0.8			1			1.3			0.41			0.22068			0.74		
11/20/21 21:00	0.8			0			1.3			0.52			0.27924			0.93		
11/20/21 22:00	0.9			1			1.5			0.44			0.23886			0.8		
11/20/21 23:00	0.7			2			1.2			0.35			0.18738			0.62		
11/21/21 0:00	0.8			1			1.3			0.41			0.22308			0.74		
11/21/21 1:00	0.7			1			1.3			0.35			0.18852			0.63		
11/21/21 2:00	0.6			1			1.2			0.34			0.1815			0.61		
11/21/21 3:00	0.7			1			1.4			0.35			0.18816			0.63		
11/21/21 4:00	0.7			1			1.3			0.35			0.18864			0.63		
11/21/21 5:00	0.8			0			1.1			0.5			0.2724			0.91		
11/21/21 6:00	0.8			0			1.3			0.52			0.27906			0.93		
11/21/21 7:00	0.8			0			1.3			0.52			0.27942			0.93		
11/21/21 8:00	0.7			0			1.3			0.54			0.29388			0.98		
11/21/21 9:00	0.7			1			1.5			0.44			0.23892			0.8		
11/21/21 10:00	0.8			0			1			0.44			0.23862			0.8		
11/21/21 11:00	0.7			1			1.4			0.38			0.20526			0.68		
11/21/21 12:00	0.5			2			1.3			0.33			0.17946			0.6		
11/21/21 13:00	0.5			2			1.3			0.33			0.17916			0.6		
11/21/21 14:00	0.5			2			1.3			0.33			0.1791			0.6		
11/21/21 15:00	0.6			0			1.1			0.43			0.2304			0.77		
11/21/21 16:00	0.7			1			1.2			0.41			0.21816			0.73		
11/21/21 17:00	0.6			1			1.5			0.35			0.18618			0.62		
11/21/21 18:00	0.6			1			1.3			0.35			0.18678			0.62		
11/21/21 19:00	0.9			0			1.1			0.43			0.23202			0.77		
11/21/21 20:00	1.3			0			1.3			0.55			0.2997			1		
11/21/21 21:00	1.2			1			1.4			0.46			0.24822			0.83		
11/21/21 22:00	1			1			1.3			0.45			0.24138			0.8		
11/21/21 23:00	0.7			1			1.3			0.35			0.18756			0.63		
11/22/21 0:00	0.7			1			1.3			0.35			0.1884			0.63		
11/22/21 1:00	0.7			1			1.3			0.35			0.18846			0.63		
11/22/21 2:00	0.6			1			1.3			0.35			0.18852			0.63		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/22/21 3:00	0.6			1			1.3			0.35			0.18858			0.63		
11/22/21 4:00	0.7			1			1.3			0.35			0.18846			0.63		
11/22/21 5:00	0.7			1			1.3			0.35			0.1902			0.63		
11/22/21 6:00	0.9			1			1.1			0.42			0.22602			0.75		
11/22/21 7:00	0.9			1			1.4			0.42			0.22584			0.75		
11/22/21 8:00	0.9			1			1.4			0.35			0.18888			0.63		
11/22/21 9:00	0.5			2			1.3			0.34			0.18132			0.6		
11/22/21 10:00	0.5			2			1.3			0.33			0.17964			0.6		
11/22/21 11:00	0.5			1			1.3			0.33			0.17946			0.6		
11/22/21 12:00	0.6			1			1.3			0.34			0.1839			0.61		
11/22/21 13:00	0.6			1			1.3			0.35			0.1869			0.62		
11/22/21 14:00	0.7			0			1.1			0.47			0.25218			0.84		
11/22/21 15:00	0.7			0			1.3			0.56			0.303			1.01		
11/22/21 16:00	0.7			1			1.2			0.46			0.2475			0.83		
11/22/21 17:00	0.7			1			1.4			0.38			0.2022			0.67		
11/22/21 18:00	0.8			0			1.2			0.52			0.27876			0.93		
11/22/21 19:00	0.9			0			1.3			0.51			0.27582			0.92		
11/22/21 20:00	0.9			0			1.3			0.52			0.28062			0.94		
11/22/21 21:00	0.9			0			1.3			0.52			0.2784			0.93		
11/22/21 22:00	0.8			0			1.3			0.52			0.28098			0.94		
11/22/21 23:00	0.8			1			1.4			0.43			0.23094			0.77		
11/23/21 0:00	0.7			1			1.3			0.35			0.18762			0.63		
11/23/21 1:00	0.6			1			1.3			0.35			0.18846			0.63		
11/23/21 2:00	0.6			1			1.3			0.35			0.18882			0.63		
11/23/21 3:00	0.6			1			1.4			0.35			0.18744			0.62		
11/23/21 4:00	0.5			2			1.3			0.34			0.18228			0.61		
11/23/21 5:00	0.5			2			1.2			0.34			0.18186			0.61		
11/23/21 6:00	0.6			1			1.3			0.35			0.18834			0.63		
11/23/21 7:00	0.7			2			1.4			0.4			0.21822			0.73		
11/23/21 8:00	0.6			2			1.3			0.34			0.18258			0.61		
11/23/21 9:00	0.5			2			1.3			0.33			0.17952			0.6		
11/23/21 10:00	0.5			2			1.3			0.33			0.17898			0.6		
11/23/21 11:00	0.5			2			1.3			0.33			0.17898			0.6		
11/23/21 12:00	0.5			1			1.3			0.33			0.17904			0.6		
11/23/21 13:00	0.6			1			1.3			0.33			0.17886			0.6		
11/23/21 14:00	0.5			1			1.3			0.33			0.17916			0.6		
11/23/21 15:00	0.6			1			1.1			0.38			0.2055			0.69		
11/23/21 16:00	0.7			1			1.3			0.37			0.20112			0.67		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/23/21 17:00	0.6			1			1.4			0.35			0.1872			0.62		
11/23/21 18:00	0.6			1			1.3			0.35			0.18714			0.62		
11/23/21 19:00	0.6			1			1.3			0.35			0.18738			0.62		
11/23/21 20:00	0.6			2			1.3			0.34			0.1833			0.61		
11/23/21 21:00	0.6			1			1.3			0.34			0.18534			0.62		
11/23/21 22:00	0.6			1			1.3			0.35			0.1881			0.63		
11/23/21 23:00	0.5			2			1.3			0.34			0.18324			0.61		
11/24/21 0:00	0.6			1			1.4			0.35			0.18852			0.63		
11/24/21 1:00	0.6			1			1.5			0.35			0.18834			0.63		
11/24/21 2:00	0.5			2			1.7			0.34			0.18156			0.61		
11/24/21 3:00	0.5			2			1.6			0.34			0.18162			0.61		
11/24/21 4:00	0.5			1			1.5			0.34			0.18318			0.61		
11/24/21 5:00	0.5			1			1.7			0.34			0.18498			0.62		
11/24/21 6:00	0.7			1			1.5			0.37			0.20262			0.68		
11/24/21 7:00	0.7			2			1.5			0.42			0.22506			0.75		
11/24/21 8:00	0.6			2			0.7			0.35			0.18738			0.62		
11/24/21 9:00	0.7			2			1.2			0.36			0.19374			0.65		
11/24/21 10:00	0.6			1			1.5			0.35			0.1869			0.62		
11/24/21 11:00	0.6			1			1.5			0.35			0.18642			0.62		
11/24/21 12:00	0.6			1			1.5			0.35			0.18612			0.62		
11/24/21 13:00	0.6			1			1.5			0.35			0.186			0.62		
11/24/21 14:00	0.6			1			1.5			0.35			0.18636			0.62		
11/24/21 15:00	0.7			0			1.3			0.39			0.21102			0.7		
11/24/21 16:00	0.8			1			1.3			0.39			0.21012			0.7		
11/24/21 17:00	0.7			1			1.6			0.35			0.18714			0.62		
11/24/21 18:00	0.7			1			1.5			0.35			0.18654			0.62		
11/24/21 19:00	0.7			1			1.5			0.35			0.18882			0.63		
11/24/21 20:00	0.7			1			1.5			0.36			0.19266			0.64		
11/24/21 21:00	0.8			1			1.4			0.37			0.2004			0.67		
11/24/21 22:00	0.7			1			1.5			0.35			0.18858			0.63		
11/24/21 23:00	0.7			1			1.5			0.35			0.18912			0.63		
11/25/21 0:00	0.7			1			1.5			0.35			0.18936			0.63		
11/25/21 1:00	0.7			1			1.5			0.35			0.1893			0.63		
11/25/21 2:00	0.7			1			1.4			0.35			0.18978			0.63		
11/25/21 3:00	0.7			1			1.5			0.35			0.18966			0.63		
11/25/21 4:00	0.7			1			1.5			0.35			0.19008			0.63		
11/25/21 5:00	0.7			1			1.5			0.35			0.18984			0.63		
11/25/21 6:00	0.7			1			1.5			0.35			0.19248			0.64		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/25/21 7:00	0.8			1			1.4			0.4			0.216			0.72		
11/25/21 8:00	0.7			1			1.4			0.36			0.19416			0.65		
11/25/21 9:00	0.7			1			1.5			0.35			0.18684			0.62		
11/25/21 10:00	0.7			1			1.5			0.35			0.18684			0.62		
11/25/21 11:00	0.7			1			1.5			0.35			0.1899			0.63		
11/25/21 12:00	0.7			1			1.5			0.35			0.18594			0.62		
11/25/21 13:00	0.7			1			1.5			0.35			0.18624			0.62		
11/25/21 14:00	0.7			1			1.5			0.35			0.18588			0.62		
11/25/21 15:00	0.7			1			1.4			0.36			0.19284			0.64		
11/25/21 16:00	0.7			1			1.5			0.36			0.19284			0.64		
11/25/21 17:00	0.7			1			1.6			0.35			0.18576			0.62		
11/25/21 18:00	0.7			1			1.5			0.35			0.18786			0.63		
11/25/21 19:00	0.8			1			1.5			0.35			0.1857			0.62		
11/25/21 20:00	0.7			1			1.5			0.35			0.1857			0.62		
11/25/21 21:00	0.8			1			1.5			0.35			0.1863			0.62		
11/25/21 22:00	0.8			1			1.5			0.34			0.18588			0.62		
11/25/21 23:00	0.8			1			1.5			0.35			0.18636			0.62		
11/26/21 0:00	0.8			1			1.5			0.34			0.18606			0.62		
11/26/21 1:00	0.8			1			1.5			0.34			0.18624			0.62		
11/26/21 2:00	0.8			1			1.5			0.34			0.18636			0.62		
11/26/21 3:00	0.7			1			1.5			0.35			0.18648			0.62		
11/26/21 4:00	0.7			1			1.5			0.35			0.18648			0.62		
11/26/21 5:00	0.8			1			1.5			0.34			0.186			0.62		
11/26/21 6:00	1			1			1.5			0.34			0.18618			0.62		
11/26/21 7:00	0.8			1			1.5			0.35			0.1866			0.62		
11/26/21 8:00	0.7			1			1.5			0.34			0.18606			0.62		
11/26/21 9:00	0.8			1			1.5			0.34			0.18612			0.62		
11/26/21 10:00	0.7			1			1.5			0.35			0.18618			0.62		
11/26/21 11:00	0.7			1			1.5			0.34			0.18552			0.62		
11/26/21 12:00	0.7			1			1.5			0.34			0.1851			0.62		
11/26/21 13:00	0.7			1			1.5			0.34			0.18468			0.62		
11/26/21 14:00	0.7			1			1.5			0.34			0.18438			0.61		
11/26/21 15:00	0.7			1			1.3			0.41			0.21888			0.73		
11/26/21 16:00	0.7			1			1.5			0.35			0.18786			0.63		
11/26/21 17:00	0.7			1			1.5			0.34			0.18504			0.62		
11/26/21 18:00	0.7			1			1.5			0.34			0.18474			0.62		
11/26/21 19:00	0.7			1			1.5			0.34			0.18486			0.62		
11/26/21 20:00	0.7			1			1.5			0.35			0.1857			0.62		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/26/21 21:00	0.7			1			1.5			0.35			0.1863			0.62		
11/26/21 22:00	0.7			1			1.5			0.35			0.18594			0.62		
11/26/21 23:00	0.7			1			1.5			0.35			0.18684			0.62		
11/27/21 0:00	0.7			1			1.5			0.34			0.18576			0.62		
11/27/21 1:00	0.7			1			1.5			0.35			0.1866			0.62		
11/27/21 2:00	0.7			1			1.5			0.34			0.18582			0.62		
11/27/21 3:00	0.7			1			1.5			0.35			0.18624			0.62		
11/27/21 4:00	0.7			1			1.5			0.34			0.18582			0.62		
11/27/21 5:00	0.8			1			1.5			0.37			0.19866			0.66		
11/27/21 6:00	0.8			1			1.4			0.36			0.19194			0.64		
11/27/21 7:00	0.8			1			1.4			0.42			0.22782			0.76		
11/27/21 8:00	0.7			1			1.5			0.34			0.1857			0.62		
11/27/21 9:00	0.7			1			1.3			0.38			0.20472			0.68		
11/27/21 10:00	0.9			0			1.6			0.44			0.23892			0.8		
11/27/21 11:00	0.7			1			1.5			0.35			0.18552			0.62		
11/27/21 12:00	0.7			1			1.5			0.35			0.18546			0.62		
11/27/21 13:00	0.7			1			1.5			0.35			0.18516			0.62		
11/27/21 14:00	0.7			1			1.5			0.35			0.18498			0.62		
11/27/21 15:00	0.7			1			1.3			0.4			0.21348			0.71		
11/27/21 16:00	0.8			1			1.3			0.42			0.22338			0.74		
11/27/21 17:00	0.7			1			1.6			0.35			0.18828			0.63		
11/27/21 18:00	0.7			1			1.5			0.34			0.18558			0.62		
11/27/21 19:00	0.7			1			1.5			0.35			0.1857			0.62		
11/27/21 20:00	0.7			1			1.5			0.35			0.18624			0.62		
11/27/21 21:00	0.8			1			1.5			0.37			0.19752			0.66		
11/27/21 22:00	0.7			1			1.5			0.35			0.18606			0.62		
11/27/21 23:00	0.7			1			1.5			0.35			0.1863			0.62		
11/28/21 0:00	0.7			1			1.5			0.35			0.18624			0.62		
11/28/21 1:00	0.7			1			1.5			0.35			0.1863			0.62		
11/28/21 2:00	0.7			1			1.5			0.35			0.1866			0.62		
11/28/21 3:00	0.7			1			1.5			0.35			0.18672			0.62		
11/28/21 4:00	0.8			1			1.5			0.35			0.18678			0.62		
11/28/21 5:00	0.7			1			1.5			0.35			0.18672			0.62		
11/28/21 6:00	0.7			1			1.5			0.35			0.1869			0.62		
11/28/21 7:00	0.8			1			1.4			0.37			0.19764			0.66		
11/28/21 8:00	0.7			1			1.5			0.35			0.1869			0.62		
11/28/21 9:00	0.7			1			1.5			0.35			0.18654			0.62		
11/28/21 10:00	0.7			1			1.5			0.35			0.18624			0.62		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/28/21 11:00	0.7			1			1.5			0.35			0.18576			0.62		
11/28/21 12:00	0.7			1			1.5			0.35			0.18564			0.62		
11/28/21 13:00	0.7			1			1.5			0.35			0.18528			0.62		
11/28/21 14:00	0.7			1			1.5			0.35			0.1851			0.62		
11/28/21 15:00	0.7			1			1.5			0.35			0.18588			0.62		
11/28/21 16:00	0.7			1			1.4			0.36			0.19422			0.65		
11/28/21 17:00	0.7			1			1.4			0.35			0.18546			0.62		
11/28/21 18:00	0.7			1			1.5			0.35			0.18564			0.62		
11/28/21 19:00	0.7			1			1.5			0.35			0.18594			0.62		
11/28/21 20:00	1			1			1.5			0.35			0.18606			0.62		
11/28/21 21:00	0.8			1			1.5			0.35			0.18624			0.62		
11/28/21 22:00	0.8			1			1.5			0.35			0.1863			0.62		
11/28/21 23:00	0.7			1			1.5			0.35			0.18636			0.62		
11/29/21 0:00	0.7			1			1.5			0.35			0.18636			0.62		
11/29/21 1:00	0.7			1			1.5			0.35			0.1863			0.62		
11/29/21 2:00	0.7			1			1.5			0.35			0.18642			0.62		
11/29/21 3:00	0.7			1			1.5			0.35			0.18648			0.62		
11/29/21 4:00	0.7			1			1.5			0.35			0.18684			0.62		
11/29/21 5:00	0.7			1			1.5			0.35			0.19068			0.64		
11/29/21 6:00	0.9			0			1.3			0.43			0.23028			0.77		
11/29/21 7:00	1.1			1			1.6			0.43			0.23184			0.77		
11/29/21 8:00	1			1			1.5			0.35			0.18684			0.62		
11/29/21 9:00	0.7			1			1.5			0.35			0.18654			0.62		
11/29/21 10:00	0.7			1			1.5			0.35			0.18636			0.62		
11/29/21 11:00	0.7			1			1.5			0.35			0.18606			0.62		
11/29/21 12:00	0.7			1			1.5			0.35			0.18564			0.62		
11/29/21 13:00	0.7			1			1.5			0.35			0.18534			0.62		
11/29/21 14:00	0.7			1			1.5			0.35			0.1851			0.62		
11/29/21 15:00	0.7			0			1.4			0.39			0.20694			0.69		
11/29/21 16:00	0.8			0			1.3			0.46			0.24702			0.82		
11/29/21 17:00	0.9			0			1.5			0.48			0.25662			0.86		
11/29/21 18:00	0.9			1			1.3			0.39			0.21144			0.7		
11/29/21 19:00	1.2			0			1.5			0.47			0.25314			0.84		
11/29/21 20:00	1			0			1.5			0.54			0.29172			0.97		
11/29/21 21:00	0.9			1			1.6			0.41			0.22176			0.74		
11/29/21 22:00	0.8			1			1.5			0.36			0.19476			0.65		
11/29/21 23:00	0.7			1			1.5			0.35			0.1863			0.62		
11/30/21 0:00	0.8			0			1.4			0.47			0.25194			0.84		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
11/30/21 1:00	0.8			1			1.5			0.37			0.20172			0.67		
11/30/21 2:00	0.7			1			1.5			0.35			0.18618			0.62		
11/30/21 3:00	0.7			1			1.5			0.35			0.18612			0.62		
11/30/21 4:00	0.7			1			1.5			0.35			0.18684			0.62		
11/30/21 5:00	0.7			1			1.3			0.38			0.2049			0.68		
11/30/21 6:00	0.9			0			1.5			0.52			0.28128			0.94		
11/30/21 7:00	0.9			0			1.6			0.52			0.28068			0.94		
11/30/21 8:00	0.8			2			1.5			0.36			0.19182			0.64		
11/30/21 9:00	0.7			1			1.4			0.35			0.18618			0.62		
11/30/21 10:00	0.7			1			1.4			0.35			0.18582			0.62		
11/30/21 11:00	0.7			1			1.4			0.35			0.18552			0.62		
11/30/21 12:00	0.7			1			1.4			0.35			0.18546			0.62		
11/30/21 13:00	0.7			1			1.4			0.35			0.18522			0.62		
11/30/21 14:00	0.7			1			1.4			0.35			0.18504			0.62		
11/30/21 15:00	0.8			0			1.3			0.41			0.22074			0.74		
11/30/21 16:00	0.8			0			1.3			0.48			0.26082			0.87		
11/30/21 17:00	0.9			0			1.4			0.58			0.31506			1.05		
11/30/21 18:00	0.4			1			1.4			0.76			0.40104			1.34		
11/30/21 19:00	0.4			2			1.4			0.76			0.39942			1.33		
11/30/21 20:00	1.6			1			1.4			0.6			0.32532			1.08		
11/30/21 21:00	0.6			1			1.4			0.72			0.38058			1.27		
11/30/21 22:00	1.5			0			1.4			0.59			0.30684			1.02		
11/30/21 23:00	1.9			1			1.5			0.48			0.25932			0.86		
12/01/21 0:00	0.7			1			1.4			0.35			0.18624			0.62		
12/01/21 1:00	0.7			1			1.4			0.35			0.1863			0.62		
12/01/21 2:00	0.7			1			1.4			0.35			0.18648			0.62		
12/01/21 3:00	0.8			1			1.5			0.35			0.1866			0.62		
12/01/21 4:00	0.8			1			1.5			0.35			0.18648			0.62		
12/01/21 5:00	0.8			1			1.5			0.35			0.18666			0.62		
12/01/21 6:00	1			1			1.5			0.35			0.18666			0.62		
12/01/21 7:00	1			1			1.5			0.35			0.18666			0.62		
12/01/21 8:00	0.8			1			1.5			0.35			0.18654			0.62		
12/01/21 9:00	0.7			1			1.5			0.35			0.18618			0.62		
12/01/21 10:00	0.7			1			1.5			0.35			0.18576			0.62		
12/01/21 11:00	0.7			1			1.5			0.35			0.1854			0.62		
12/01/21 12:00	0.7			1			1.5			0.35			0.18528			0.62		
12/01/21 13:00	0.7			1			1.5			0.35			0.18498			0.62		
12/01/21 14:00	0.7			1			1.5			0.35			0.18492			0.62		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/01/21 15:00	0.7			1			1.4			0.38			0.20112			0.67		
12/01/21 16:00	0.8			0			1.3			0.44			0.23424			0.78		
12/01/21 17:00	0.9			0			1.5			0.48			0.25962			0.87		
12/01/21 18:00	0.9			0			1.5			0.52			0.27948			0.93		
12/01/21 19:00	0.8			0			1.5			0.54			0.29022			0.97		
12/01/21 20:00	1			0			1.5			0.51			0.2775			0.93		
12/01/21 21:00	0.9			0			1.5			0.53			0.28836			0.96		
12/01/21 22:00	0.8			1			1.4			0.37			0.20142			0.67		
12/01/21 23:00	0.7			1			1.2			0.35			0.186			0.62		
12/02/21 0:00	0.7			1			1.2			0.35			0.18924			0.63		
12/02/21 1:00	0.8			1			1.1			0.37			0.19986			0.67		
12/02/21 2:00	0.8			0			1.1			0.36			0.19386			0.65		
12/02/21 3:00	1			0			1.3			0.49			0.26334			0.88		
12/02/21 4:00	0.9			0			1.5			0.53			0.285			0.95		
12/02/21 5:00	1.7			0			1.5			0.55			0.29202			0.97		
12/02/21 6:00	1.7			1			1.5			0.61			0.31962			1.07		
12/02/21 7:00	1.5			1			1.5			0.59			0.31716			1.06		
12/02/21 8:00	1.4			1			1.5			0.48			0.2601			0.87		
12/02/21 9:00	0.8			1			1.3			0.35			0.18636			0.62		
12/02/21 10:00	0.7			1			1.3			0.35			0.18594			0.62		
12/02/21 11:00	0.7			1			1.3			0.35			0.18564			0.62		
12/02/21 12:00	0.7			1			1.3			0.35			0.18528			0.62		
12/02/21 13:00	0.7			1			1.3			0.35			0.18504			0.62		
12/02/21 14:00	0.7			1			1.5			0.35			0.18474			0.62		
12/02/21 15:00	0.7			0			1.3			0.39			0.21066			0.7		
12/02/21 16:00	1.1			0			1.5			0.46			0.24648			0.82		
12/02/21 17:00	0.8			1			1.5			0.67			0.35454			1.18		
12/02/21 18:00	1.4			1			1.5			0.6			0.3183			1.06		
12/02/21 19:00	1.7			1			1.5			0.59			0.3174			1.06		
12/02/21 20:00	1.3			1			1.5			0.62			0.3306			1.1		
12/02/21 21:00	1.3			1			1.5			0.62			0.33			1.1		
12/02/21 22:00	1.2			1			1.6			0.49			0.26232			0.87		
12/02/21 23:00	0.7			1			1.5			0.35			0.18594			0.62		
12/03/21 0:00	0.7			1			1.5			0.35			0.18594			0.62		
12/03/21 1:00	0.7			1			1.5			0.35			0.186			0.62		
12/03/21 2:00	0.7			1			1.5			0.35			0.18606			0.62		
12/03/21 3:00	0.7			1			1.5			0.35			0.186			0.62		
12/03/21 4:00	0.7			1			1.5			0.35			0.18618			0.62		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/03/21 5:00	0.7			1			1.4			0.36			0.19254			0.64		
12/03/21 6:00	0.7			1			1.5			0.36			0.1947			0.65		
12/03/21 7:00	0.8			1			1.5			0.41			0.2202			0.73		
12/03/21 8:00	0.7			1			1.5			0.35			0.18978			0.63		
12/03/21 9:00	0.8			0			1.3			0.45			0.24072			0.8		
12/03/21 10:00	0.9			0			1.5			0.55			0.29622			0.99		
12/03/21 11:00	0.8			1			1.4			0.45			0.2448			0.82		
12/03/21 12:00	0.8			1			1.7			0.41			0.22068			0.74		
12/03/21 13:00	0.7			1			1.4			0.35			0.18606			0.62		
12/03/21 14:00	0.7			1			1.5			0.35			0.18588			0.62		
12/03/21 15:00	0.7			0			1.3			0.44			0.2376			0.79		
12/03/21 16:00	1.1			0			1.5			0.51			0.27738			0.92		
12/03/21 17:00	1.2			1			1.5			0.61			0.32436			1.08		
12/03/21 18:00	1.3			1			1.5			0.6			0.324			1.08		
12/03/21 19:00	1.4			1			1.5			0.6			0.32382			1.08		
12/03/21 20:00	1.4			1			1.5			0.6			0.32394			1.08		
12/03/21 21:00	1.4			1			1.5			0.6			0.32394			1.08		
12/03/21 22:00	1.3			1			1.5			0.6			0.32448			1.08		
12/03/21 23:00	1.1			1			1.4			0.49			0.26466			0.88		
12/04/21 0:00	0.7			1			1.2			0.35			0.18606			0.62		
12/04/21 1:00	0.7			1			1.2			0.35			0.18642			0.62		
12/04/21 2:00	0.7			1			1.2			0.35			0.1872			0.62		
12/04/21 3:00	0.8			1			1.3			0.37			0.1998			0.67		
12/04/21 4:00	0.8			1			1.1			0.42			0.22656			0.76		
12/04/21 5:00	0.8			1			1.4			0.4			0.21714			0.72		
12/04/21 6:00	0.9			1			1.5			0.39			0.21036			0.7		
12/04/21 7:00	1			1			1.5			0.44			0.23514			0.78		
12/04/21 8:00	0.9			1			1.3			0.39			0.21114			0.7		
12/04/21 9:00	0.8			0			1.2			0.48			0.26112			0.87		
12/04/21 10:00	0.8			1			1.5			0.4			0.2148			0.72		
12/04/21 11:00	0.8			0			1.4			0.5			0.26862			0.9		
12/04/21 12:00	0.7			1			1.4			0.35			0.18654			0.62		
12/04/21 13:00	0.7			1			1.2			0.38			0.20358			0.68		
12/04/21 14:00	0.8			1			1.4			0.36			0.19422			0.65		
12/04/21 15:00	0.8			1			1.2			0.41			0.22062			0.74		
12/04/21 16:00	0.8			0			1.4			0.5			0.26754			0.89		
12/04/21 17:00	1.6			0			1.4			0.56			0.30366			1.01		
12/04/21 18:00	1.8			1			1.5			0.6			0.32004			1.07		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/04/21 19:00	1.8			1			1.5			0.6			0.32034			1.07		
12/04/21 20:00	1.7			1			1.5			0.6			0.32058			1.07		
12/04/21 21:00	1.6			1			1.5			0.6			0.32028			1.07		
12/04/21 22:00	0.8			1			1.3			0.37			0.19908			0.66		
12/04/21 23:00	0.7			1			1.5			0.35			0.18648			0.62		
12/05/21 0:00	0.7			1			1.5			0.35			0.18672			0.62		
12/05/21 1:00	0.7			1			1.5			0.35			0.18678			0.62		
12/05/21 2:00	0.7			1			1.5			0.35			0.18678			0.62		
12/05/21 3:00	0.7			1			1.5			0.35			0.18696			0.62		
12/05/21 4:00	0.7			1			1.5			0.35			0.18798			0.63		
12/05/21 5:00	0.7			1			1.5			0.35			0.1875			0.63		
12/05/21 6:00	0.8			0			1.3			0.41			0.22302			0.74		
12/05/21 7:00	0.8			1			1.6			0.4			0.21366			0.71		
12/05/21 8:00	0.9			0			1.3			0.48			0.25896			0.86		
12/05/21 9:00	0.8			0			1.4			0.56			0.3			1		
12/05/21 10:00	0.8			0			1.4			0.56			0.29922			1		
12/05/21 11:00	0.8			0			1.3			0.53			0.2862			0.95		
12/05/21 12:00	0.7			2			1.5			0.35			0.18798			0.63		
12/05/21 13:00	0.8			0			1.2			0.44			0.23544			0.78		
12/05/21 14:00	0.8			1			1.5			0.38			0.20622			0.69		
12/05/21 15:00	0.8			1			1.2			0.37			0.19752			0.66		
12/05/21 16:00	0.8			1			1.2			0.41			0.22254			0.74		
12/05/21 17:00	0.9			0			1.4			0.43			0.2343			0.78		
12/05/21 18:00	0.9			0			1.4			0.53			0.28518			0.95		
12/05/21 19:00	0.9			0			1.4			0.56			0.3009			1		
12/05/21 20:00	0.9			0			1.4			0.56			0.30114			1		
12/05/21 21:00	0.9			0			1.4			0.53			0.2886			0.96		
12/05/21 22:00	0.9			0			1.4			0.54			0.29166			0.97		
12/05/21 23:00	1			1			1.4			0.46			0.2463			0.82		
12/06/21 0:00	0.8			1			1.4			0.4			0.21552			0.72		
12/06/21 1:00	0.7			1			1.4			0.35			0.18816			0.63		
12/06/21 2:00	0.7			1			1.3			0.35			0.18738			0.62		
12/06/21 3:00	0.7			1			1.4			0.35			0.18816			0.63		
12/06/21 4:00	0.7			1			1.4			0.35			0.1878			0.63		
12/06/21 5:00	0.8			0			1.2			0.44			0.23964			0.8		
12/06/21 6:00	0.8			0			1.5			0.55			0.29724			0.99		
12/06/21 7:00	0.8			0			1.5			0.56			0.30126			1		
12/06/21 8:00	0.9			0			1.5			0.55			0.29838			0.99		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/06/21 9:00	0.8			0			1.5			0.56			0.30096			1		
12/06/21 10:00	0.9			0			1.5			0.56			0.30102			1		
12/06/21 11:00	0.8			0			1.5			0.56			0.30066			1		
12/06/21 12:00	0.8			0			1.5			0.56			0.30042			1		
12/06/21 13:00	0.8			0			1.5			0.56			0.30066			1		
12/06/21 14:00	0.8			0			1.5			0.56			0.30054			1		
12/06/21 15:00	0.8			0			1.5			0.56			0.3006			1		
12/06/21 16:00	1.4			1			1.5			0.58			0.31254			1.04		
12/06/21 17:00	1.4			1			1.5			0.6			0.32478			1.08		
12/06/21 18:00	1.3			1			1.5			0.62			0.33264			1.11		
12/06/21 19:00	1.4			1			1.5			0.61			0.3243			1.08		
12/06/21 20:00	1.4			1			1.5			0.61			0.3291			1.1		
12/06/21 21:00	1.4			1			1.5			0.61			0.32604			1.09		
12/06/21 22:00	1.4			1			1.5			0.58			0.31224			1.04		
12/06/21 23:00	0.9			0			1.5			0.55			0.29844			0.99		
12/07/21 0:00	0.9			1			1.5			0.5			0.27036			0.9		
12/07/21 1:00	0.9			1			1.2			0.4			0.2145			0.72		
12/07/21 2:00	0.7			1			1.2			0.35			0.18678			0.62		
12/07/21 3:00	0.7			1			1.2			0.35			0.18684			0.62		
12/07/21 4:00	0.9			0			1.1			0.42			0.22572			0.75		
12/07/21 5:00	0.7			1			1.6			0.35			0.18714			0.62		
12/07/21 6:00	0.8			0			1.4			0.42			0.22908			0.76		
12/07/21 7:00	0.8			0			1.5			0.56			0.30018			1		
12/07/21 8:00	0.8			0			1.5			0.55			0.29934			1		
12/07/21 9:00	0.8			0			1.5			0.55			0.29922			1		
12/07/21 10:00	0.8			1			1.6			0.48			0.25824			0.86		
12/07/21 11:00	0.9			1			1.4			0.42			0.22746			0.76		
12/07/21 12:00	0.9			0			1.4			0.51			0.2751			0.92		
12/07/21 13:00	0.8			0			1.5			0.56			0.29988			1		
12/07/21 14:00	0.8			0			1.5			0.55			0.29886			1		
12/07/21 15:00	0.8			0			1.5			0.54			0.2913			0.97		
12/07/21 16:00	1.2			1			1.5			0.57			0.31068			1.04		
12/07/21 17:00	1.4			1			1.5			0.6			0.32418			1.08		
12/07/21 18:00	1.2			1			1.5			0.63			0.33684			1.12		
12/07/21 19:00	0.9			1			1.5			0.66			0.35298			1.18		
12/07/21 20:00	1.3			1			1.5			0.61			0.32772			1.09		
12/07/21 21:00	1.3			1			1.5			0.61			0.32802			1.09		
12/07/21 22:00	1.3			1			1.5			0.61			0.32832			1.09		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/07/21 23:00	1.3			1			1.5			0.58			0.30936			1.03		
12/08/21 0:00	0.9			1			1.6			0.48			0.25716			0.86		
12/08/21 1:00	0.9			1			1.5			0.44			0.23664			0.79		
12/08/21 2:00	0.7			1			1.5			0.35			0.18636			0.62		
12/08/21 3:00	0.7			1			1.5			0.35			0.18786			0.63		
12/08/21 4:00	0.7			1			1.5			0.35			0.18972			0.63		
12/08/21 5:00	0.7			1			1.5			0.35			0.189			0.63		
12/08/21 6:00	0.9			0			1.4			0.51			0.27648			0.92		
12/08/21 7:00	1			0			1.6			0.52			0.28026			0.93		
12/08/21 8:00	0.8			1			1.5			0.38			0.20322			0.68		
12/08/21 9:00	0.8			1			1.5			0.35			0.18648			0.62		
12/08/21 10:00	0.8			1			1.5			0.35			0.18678			0.62		
12/08/21 11:00	1.3			0			1.4			0.52			0.2817			0.94		
12/08/21 12:00	1.2			0			1.5			0.51			0.2772			0.92		
12/08/21 13:00	0.7			1			1.6			0.35			0.18876			0.63		
12/08/21 14:00	0.7			1			1.5			0.35			0.1863			0.62		
12/08/21 15:00	0.8			1			1.4			0.36			0.19332			0.64		
12/08/21 16:00	0.8			1			1.4			0.44			0.23622			0.79		
12/08/21 17:00	0.9			0			1.5			0.55			0.29796			0.99		
12/08/21 18:00	0.9			0			1.5			0.53			0.28728			0.96		
12/08/21 19:00	0.9			0			1.5			0.55			0.29922			1		
12/08/21 20:00	0.9			0			1.5			0.53			0.28764			0.96		
12/08/21 21:00	0.9			1			1.6			0.45			0.24432			0.81		
12/08/21 22:00	0.7			1			1.5			0.34			0.18546			0.62		
12/08/21 23:00	0.7			1			1.5			0.34			0.18576			0.62		
12/09/21 0:00	0.7			1			1.5			0.35			0.18696			0.62		
12/09/21 1:00	0.7			1			1.5			0.35			0.18672			0.62		
12/09/21 2:00	0.7			1			1.5			0.35			0.18654			0.62		
12/09/21 3:00	0.7			1			1.5			0.35			0.18702			0.62		
12/09/21 4:00	0.6			1			1.5			0.35			0.18708			0.62		
12/09/21 5:00	0.6			1			1.5			0.35			0.18726			0.62		
12/09/21 6:00	0.9			0			1.3			0.45			0.24294			0.81		
12/09/21 7:00	0.9			1			1.6			0.4			0.21468			0.72		
12/09/21 8:00	0.8			1			1.4			0.36			0.19614			0.65		
12/09/21 9:00	0.9			0			1.4			0.46			0.24846			0.83		
12/09/21 10:00	0.8			1			1.4			0.4			0.21708			0.72		
12/09/21 11:00	0.7			1			1.6			0.35			0.18588			0.62		
12/09/21 12:00	0.8			1			1.5			0.36			0.19104			0.64		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/09/21 13:00	0.7			1			1.5			0.34			0.18516			0.62		
12/09/21 14:00	0.7			1			1.5			0.34			0.18504			0.62		
12/09/21 15:00	0.8			1			1.4			0.36			0.19194			0.64		
12/09/21 16:00	0.8			0			1.4			0.47			0.25344			0.84		
12/09/21 17:00	0.9			0			1.5			0.47			0.25152			0.84		
12/09/21 18:00	0.9			1			1.4			0.4			0.21348			0.71		
12/09/21 19:00	1			0			1.5			0.44			0.23928			0.8		
12/09/21 20:00	0.9			0			1.5			0.5			0.27252			0.91		
12/09/21 21:00	1			1			1.6			0.47			0.2541			0.85		
12/09/21 22:00	0.9			1			1.5			0.4			0.21252			0.71		
12/09/21 23:00	0.7			1			1.5			0.35			0.18666			0.62		
12/10/21 0:00	0.7			1			1.5			0.35			0.18972			0.63		
12/10/21 1:00	0.7			1			1.5			0.35			0.18792			0.63		
12/10/21 2:00	0.7			1			1.5			0.35			0.18768			0.63		
12/10/21 3:00	0.8			1			1.5			0.35			0.18804			0.63		
12/10/21 4:00	0.8			1			1.5			0.35			0.18732			0.62		
12/10/21 5:00	0.8			1			1.3			0.38			0.2073			0.69		
12/10/21 6:00	0.9			1			1.4			0.46			0.25194			0.84		
12/10/21 7:00	1			0			1.5			0.55			0.29562			0.99		
12/10/21 8:00	0.8			1			1.5			0.4			0.21738			0.72		
12/10/21 9:00	0.7			1			1.5			0.35			0.18732			0.62		
12/10/21 10:00	0.8			1			1.4			0.38			0.207			0.69		
12/10/21 11:00	0.9			0			1.5			0.53			0.2871			0.96		
12/10/21 12:00	0.9			1			1.5			0.42			0.22722			0.76		
12/10/21 13:00	0.7			1			1.4			0.35			0.18918			0.63		
12/10/21 14:00	0.7			1			1.5			0.35			0.18624			0.62		
12/10/21 15:00	0.8			0			1.3			0.43			0.23454			0.78		
12/10/21 16:00	0.9			0			1.5			0.54			0.29172			0.97		
12/10/21 17:00	0.8			0			1.5			0.56			0.29934			1		
12/10/21 18:00	0.9			0			1.5			0.56			0.29988			1		
12/10/21 19:00	1			0			1.5			0.56			0.29994			1		
12/10/21 20:00	1			0			1.5			0.56			0.30108			1		
12/10/21 21:00	1			0			1.5			0.56			0.30036			1		
12/10/21 22:00	1			0			1.5			0.56			0.30054			1		
12/10/21 23:00	1			0			1.5			0.56			0.29976			1		
12/11/21 0:00	1			2			1.3			0.42			0.22896			0.76		
12/11/21 1:00	0.7			1			1.4			0.35			0.18876			0.63		
12/11/21 2:00	0.7			1			1.5			0.35			0.18882			0.63		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/11/21 3:00	0.7			1			1.5			0.35			0.18834			0.63		
12/11/21 4:00	0.7			1			1.5			0.35			0.1884			0.63		
12/11/21 5:00	0.7			1			1.5			0.35			0.18894			0.63		
12/11/21 6:00	0.9			1			1.5			0.38			0.20724			0.69		
12/11/21 7:00	0.8			1			1.5			0.4			0.21504			0.72		
12/11/21 8:00	0.7			1			1.5			0.35			0.18732			0.62		
12/11/21 9:00	0.7			1			1.5			0.35			0.18732			0.62		
12/11/21 10:00	0.7			1			1.5			0.35			0.18684			0.62		
12/11/21 11:00	0.7			1			1.5			0.35			0.18666			0.62		
12/11/21 12:00	0.7			1			1.5			0.35			0.18654			0.62		
12/11/21 13:00	0.7			1			1.5			0.35			0.1863			0.62		
12/11/21 14:00	0.7			1			1.5			0.35			0.18612			0.62		
12/11/21 15:00	0.7			1			1.5			0.35			0.18672			0.62		
12/11/21 16:00	0.8			0			1.4			0.47			0.25212			0.84		
12/11/21 17:00	0.9			0			1.5			0.52			0.27828			0.93		
12/11/21 18:00	1			0			1.5			0.5			0.27126			0.9		
12/11/21 19:00	0.9			0			1.5			0.55			0.29838			0.99		
12/11/21 20:00	0.9			0			1.5			0.55			0.29772			0.99		
12/11/21 21:00	0.9			0			1.5			0.56			0.3012			1		
12/11/21 22:00	0.9			0			1.5			0.56			0.30132			1		
12/11/21 23:00	0.9			1			1.5			0.44			0.2391			0.8		
12/12/21 0:00	0.9			1			1.6			0.46			0.24924			0.83		
12/12/21 1:00	0.7			1			1.5			0.35			0.18726			0.62		
12/12/21 2:00	0.7			1			1.5			0.35			0.18924			0.63		
12/12/21 3:00	1			0			1.4			0.51			0.27624			0.92		
12/12/21 4:00	1			1			1.5			0.41			0.2193			0.73		
12/12/21 5:00	0.7			1			1.6			0.35			0.18798			0.63		
12/12/21 6:00	0.9			1			1.4			0.41			0.21978			0.73		
12/12/21 7:00	0.8			1			1.5			0.39			0.20928			0.7		
12/12/21 8:00	0.8			1			1.4			0.39			0.20868			0.7		
12/12/21 9:00	0.8			1			1.5			0.36			0.19218			0.64		
12/12/21 10:00	0.7			1			1.5			0.35			0.18666			0.62		
12/12/21 11:00	0.7			1			1.5			0.35			0.18648			0.62		
12/12/21 12:00	0.7			1			1.5			0.35			0.1863			0.62		
12/12/21 13:00	0.7			1			1.5			0.35			0.18612			0.62		
12/12/21 14:00	0.7			1			1.5			0.35			0.18948			0.63		
12/12/21 15:00	0.8			1			1.4			0.38			0.2055			0.69		
12/12/21 16:00	0.8			1			1.4			0.46			0.25134			0.84		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/12/21 17:00	0.9			0			1.5			0.51			0.27426			0.91		
12/12/21 18:00	0.9			0			1.5			0.51			0.27438			0.91		
12/12/21 19:00	0.8			0			1.5			0.55			0.2949			0.98		
12/12/21 20:00	0.9			0			1.5			0.52			0.2826			0.94		
12/12/21 21:00	0.9			0			1.5			0.49			0.26346			0.88		
12/12/21 22:00	0.8			1			1.4			0.44			0.23778			0.79		
12/12/21 23:00	0.7			1			1.5			0.35			0.1863			0.62		
12/13/21 0:00	0.7			1			1.5			0.35			0.18678			0.62		
12/13/21 1:00	0.7			1			1.5			0.35			0.18726			0.62		
12/13/21 2:00	0.7			1			1.5			0.35			0.18714			0.62		
12/13/21 3:00	0.7			1			1.5			0.35			0.18636			0.62		
12/13/21 4:00	0.7			1			1.5			0.35			0.18606			0.62		
12/13/21 5:00	0.7			1			1.5			0.35			0.186			0.62		
12/13/21 6:00	0.8			0			1.4			0.46			0.24612			0.82		
12/13/21 7:00	0.8			0			1.5			0.54			0.2922			0.97		
12/13/21 8:00	0.9			0			1.5			0.53			0.28608			0.95		
12/13/21 9:00	0.8			0			1.5			0.54			0.29154			0.97		
12/13/21 10:00	0.8			1			1.6			0.47			0.2508			0.84		
12/13/21 11:00	0.8			1			1.5			0.38			0.20628			0.69		
12/13/21 12:00	0.8			0			1.4			0.55			0.2952			0.98		
12/13/21 13:00	0.8			0			1.5			0.56			0.30324			1.01		
12/13/21 14:00	0.8			0			1.5			0.56			0.2994			1		
12/13/21 15:00	0.8			0			1.5			0.56			0.29982			1		
12/13/21 16:00	1			1			1.5			0.57			0.3156			1.05		
12/13/21 17:00	1.1			1			1.5			0.63			0.33552			1.12		
12/13/21 18:00	1.3			1			1.5			0.61			0.32856			1.1		
12/13/21 19:00	1.2			1			1.5			0.61			0.32868			1.1		
12/13/21 20:00	1.2			1			1.5			0.61			0.32862			1.1		
12/13/21 21:00	1.3			1			1.5			0.61			0.3288			1.1		
12/13/21 22:00	1.2			1			1.6			0.49			0.2655			0.89		
12/13/21 23:00	0.7			1			1.5			0.35			0.1866			0.62		
12/14/21 0:00	0.7			1			1.5			0.35			0.18708			0.62		
12/14/21 1:00	0.7			1			1.5			0.35			0.18702			0.62		
12/14/21 2:00	0.7			1			1.5			0.35			0.18684			0.62		
12/14/21 3:00	0.7			1			1.5			0.35			0.18648			0.62		
12/14/21 4:00	0.7			1			1.5			0.34			0.18612			0.62		
12/14/21 5:00	0.8			1			1.3			0.4			0.21834			0.73		
12/14/21 6:00	0.9			0			1.5			0.49			0.26364			0.88		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/14/21 7:00	0.8			1			1.5			0.37			0.19866			0.66		
12/14/21 8:00	0.7			1			1.6			0.35			0.1884			0.63		
12/14/21 9:00	0.7			1			1.5			0.35			0.18654			0.62		
12/14/21 10:00	0.7			1			1.5			0.35			0.18636			0.62		
12/14/21 11:00	0.7			1			1.5			0.35			0.1863			0.62		
12/14/21 12:00	0.7			1			1.5			0.35			0.18588			0.62		
12/14/21 13:00	0.7			1			1.5			0.35			0.18582			0.62		
12/14/21 14:00	0.7			1			1.5			0.34			0.18576			0.62		
12/14/21 15:00	0.7			1			1.5			0.35			0.18624			0.62		
12/14/21 16:00	0.7			1			1.4			0.39			0.20832			0.69		
12/14/21 17:00	0.9			0			1.5			0.53			0.28554			0.95		
12/14/21 18:00	0.9			0			1.5			0.52			0.27846			0.93		
12/14/21 19:00	0.9			0			1.5			0.53			0.28836			0.96		
12/14/21 20:00	1			0			1.5			0.56			0.30048			1		
12/14/21 21:00	1			0			1.5			0.55			0.29952			1		
12/14/21 22:00	1			1			1.5			0.51			0.27408			0.91		
12/14/21 23:00	0.7			2			1.4			0.35			0.1872			0.62		
12/15/21 0:00	0.8			1			1.3			0.36			0.19374			0.65		
12/15/21 1:00	0.7			1			1.6			0.35			0.18702			0.62		
12/15/21 2:00	0.7			1			1.5			0.35			0.18726			0.62		
12/15/21 3:00	0.7			1			1.5			0.35			0.1872			0.62		
12/15/21 4:00	0.8			0			1.4			0.45			0.24666			0.82		
12/15/21 5:00	0.9			0			1.5			0.56			0.30114			1		
12/15/21 6:00	0.9			0			1.5			0.56			0.30048			1		
12/15/21 7:00	0.9			1			1.5			0.51			0.2751			0.92		
12/15/21 8:00	0.8			1			1.5			0.37			0.19722			0.66		
12/15/21 9:00	0.7			1			1.4			0.35			0.18786			0.63		
12/15/21 10:00	0.7			1			1.4			0.35			0.18774			0.63		
12/15/21 11:00	0.8			1			1.4			0.37			0.19644			0.65		
12/15/21 12:00	0.8			0			1.2			0.48			0.25884			0.86		
12/15/21 13:00	0.7			1			1.6			0.45			0.24294			0.81		
12/15/21 14:00	0.6			1			1.5			0.35			0.1863			0.62		
12/15/21 15:00	0.7			1			1.3			0.4			0.21312			0.71		
12/15/21 16:00	0.7			1			1.3			0.48			0.26184			0.87		
12/15/21 17:00	0.7			0			1.5			0.56			0.30018			1		
12/15/21 18:00	0.7			0			1.5			0.55			0.29694			0.99		
12/15/21 19:00	0.7			0			1.5			0.55			0.2982			0.99		
12/15/21 20:00	0.7			0			1.5			0.56			0.3018			1.01		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/15/21 21:00	0.7			0			1.5			0.54			0.2898			0.97		
12/15/21 22:00	0.7			0			1.5			0.52			0.28038			0.93		
12/15/21 23:00	0.8			1			1.5			0.5			0.27282			0.91		
12/16/21 0:00	0.8			0			1.5			0.51			0.27588			0.92		
12/16/21 1:00	0.8			1			1.6			0.45			0.24048			0.8		
12/16/21 2:00	0.6			1			1.4			0.35			0.18678			0.62		
12/16/21 3:00	0.6			1			1.5			0.35			0.18702			0.62		
12/16/21 4:00	1			0			1.4			0.49			0.26694			0.89		
12/16/21 5:00	1.5			1			1.5			0.6			0.32388			1.08		
12/16/21 6:00	1.3			1			1.5			0.61			0.32808			1.09		
12/16/21 7:00	1.3			1			1.5			0.61			0.3294			1.1		
12/16/21 8:00	1.3			1			1.5			0.6			0.32292			1.08		
12/16/21 9:00	1.4			1			1.5			0.57			0.31056			1.04		
12/16/21 10:00	1.5			1			1.5			0.6			0.32352			1.08		
12/16/21 11:00	1.1			1			1.6			0.49			0.26118			0.87		
12/16/21 12:00	0.6			1			1.5			0.35			0.18624			0.62		
12/16/21 13:00	0.6			1			1.5			0.35			0.19014			0.63		
12/16/21 14:00	0.7			1			1.4			0.42			0.22542			0.75		
12/16/21 15:00	1			0			1.3			0.51			0.27648			0.92		
12/16/21 16:00	1.3			1			1.4			0.6			0.32472			1.08		
12/16/21 17:00	1.4			1			1.4			0.6			0.32034			1.07		
12/16/21 18:00	1.4			1			1.4			0.6			0.3198			1.07		
12/16/21 19:00	1.3			1			1.5			0.61			0.32622			1.09		
12/16/21 20:00	1.4			1			1.5			0.6			0.32046			1.07		
12/16/21 21:00	0.6			1			1.5			0.72			0.38448			1.28		
12/16/21 22:00	1.2			1			1.5			0.63			0.33354			1.11		
12/16/21 23:00	1			1			1.5			0.44			0.23382			0.78		
12/17/21 0:00	0.6			1			1.5			0.35			0.1872			0.62		
12/17/21 1:00	0.6			2			1.5			0.35			0.18936			0.63		
12/17/21 2:00	0.7			1			1.5			0.35			0.19002			0.63		
12/17/21 3:00	0.7			1			1.5			0.35			0.1899			0.63		
12/17/21 4:00	1.3			0			1.4			0.5			0.26994			0.9		
12/17/21 5:00	1.8			1			1.5			0.6			0.32274			1.08		
12/17/21 6:00	1.6			1			1.5			0.62			0.3315			1.11		
12/17/21 7:00	1.5			1			1.5			0.62			0.33186			1.11		
12/17/21 8:00	1.4			1			1.5			0.5			0.26718			0.89		
12/17/21 9:00	0.6			1			1.4			0.35			0.18936			0.63		
12/17/21 10:00	0.6			1			1.5			0.35			0.18954			0.63		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/17/21 11:00	0.6			1			1.5			0.35			0.18804			0.63		
12/17/21 12:00	0.6			1			1.5			0.35			0.18792			0.63		
12/17/21 13:00	0.6			1			1.5			0.35			0.1878			0.63		
12/17/21 14:00	0.6			1			1.5			0.35			0.1872			0.62		
12/17/21 15:00	1			0			1.5			0.48			0.26214			0.87		
12/17/21 16:00	1.3			1			1.5			0.61			0.32886			1.1		
12/17/21 17:00	1.5			1			1.5			0.6			0.32094			1.07		
12/17/21 18:00	1.5			1			1.5			0.6			0.31644			1.05		
12/17/21 19:00	1.4			1			1.5			0.6			0.31596			1.05		
12/17/21 20:00	1.4			1			1.5			0.6			0.3171			1.06		
12/17/21 21:00	1.4			1			1.5			0.6			0.3162			1.05		
12/17/21 22:00	1.5			1			1.5			0.6			0.31668			1.06		
12/17/21 23:00	1.2			1			1.5			0.51			0.26952			0.9		
12/18/21 0:00	0.9			0			1.4			0.48			0.26118			0.87		
12/18/21 1:00	1			1			1.5			0.51			0.2757			0.92		
12/18/21 2:00	1			1			1.6			0.49			0.26448			0.88		
12/18/21 3:00	1			1			1.3			0.41			0.21996			0.73		
12/18/21 4:00	0.9			1			1.5			0.47			0.25272			0.84		
12/18/21 5:00	1.2			1			1.6			0.5			0.2694			0.9		
12/18/21 6:00	1.5			1			1.5			0.6			0.31908			1.06		
12/18/21 7:00	1			1			1.6			0.48			0.25686			0.86		
12/18/21 8:00	0.7			1			1.5			0.38			0.20352			0.68		
12/18/21 9:00	0.7			1			1.3			0.37			0.19938			0.66		
12/18/21 10:00	0.8			0			1.4			0.55			0.2991			1		
12/18/21 11:00	0.7			1			1.5			0.43			0.23388			0.78		
12/18/21 12:00	0.6			2			1.4			0.35			0.18774			0.63		
12/18/21 13:00	0.6			2			1.4			0.35			0.18804			0.63		
12/18/21 14:00	0.6			1			1.4			0.35			0.18768			0.63		
12/18/21 15:00	0.6			1			1.3			0.38			0.20472			0.68		
12/18/21 16:00	1.3			1			1.4			0.51			0.2733			0.91		
12/18/21 17:00	1.8			1			1.4			0.6			0.31992			1.07		
12/18/21 18:00	1.8			1			1.4			0.6			0.31962			1.07		
12/18/21 19:00	1.8			1			1.4			0.6			0.31986			1.07		
12/18/21 20:00	1.8			1			1.4			0.6			0.31992			1.07		
12/18/21 21:00	1.7			1			1.4			0.61			0.32124			1.07		
12/18/21 22:00	1.7			1			1.4			0.6			0.32088			1.07		
12/18/21 23:00	1.1			1			1.4			0.44			0.23604			0.79		
12/19/21 0:00	0.8			0			1.4			0.51			0.2748			0.92		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/19/21 1:00	0.8			1			1.4			0.51			0.27372			0.91		
12/19/21 2:00	0.9			0			1.5			0.49			0.26268			0.88		
12/19/21 3:00	0.6			1			1.3			0.35			0.18798			0.63		
12/19/21 4:00	0.6			2			1.3			0.35			0.18702			0.62		
12/19/21 5:00	1.2			0			1.3			0.48			0.26154			0.87		
12/19/21 6:00	1.2			1			1.3			0.51			0.2733			0.91		
12/19/21 7:00	0.7			2			1.3			0.39			0.20784			0.69		
12/19/21 8:00	0.7			2			1.3			0.35			0.18738			0.62		
12/19/21 9:00	0.8			0			1.2			0.49			0.26202			0.87		
12/19/21 10:00	0.8			0			1.3			0.54			0.28926			0.96		
12/19/21 11:00	0.8			2			1.3			0.38			0.20616			0.69		
12/19/21 12:00	0.7			2			1.3			0.35			0.1869			0.62		
12/19/21 13:00	0.7			1			1.3			0.35			0.18948			0.63		
12/19/21 14:00	0.7			1			1.3			0.4			0.21642			0.72		
12/19/21 15:00	1			1			1.3			0.5			0.27528			0.92		
12/19/21 16:00	1.4			1			1.3			0.6			0.32166			1.07		
12/19/21 17:00	1.5			1			1.3			0.6			0.32184			1.07		
12/19/21 18:00	1.5			1			1.3			0.6			0.3183			1.06		
12/19/21 19:00	1.6			1			1.4			0.6			0.31722			1.06		
12/19/21 20:00	1.4			1			1.4			0.6			0.3225			1.08		
12/19/21 21:00	1.5			1			1.4			0.6			0.32064			1.07		
12/19/21 22:00	1.4			1			1.4			0.55			0.29562			0.99		
12/19/21 23:00	1			1			1.4			0.47			0.25536			0.85		
12/20/21 0:00	0.8			1			1.3			0.38			0.20772			0.69		
12/20/21 1:00	1			1			1.4			0.46			0.24654			0.82		
12/20/21 2:00	1			0			1.2			0.46			0.25146			0.84		
12/20/21 3:00	1.1			1			1.3			0.43			0.2334			0.78		
12/20/21 4:00	1.1			1			1.4			0.38			0.20754			0.69		
12/20/21 5:00	1.5			1			1.4			0.55			0.30192			1.01		
12/20/21 6:00	1.5			1			1.5			0.62			0.32898			1.1		
12/20/21 7:00	1.3			1			1.5			0.58			0.31512			1.05		
12/20/21 8:00	0.9			1			1.4			0.46			0.25014			0.83		
12/20/21 9:00	0.9			1			1.3			0.38			0.20322			0.68		
12/20/21 10:00	0.7			2			1.4			0.35			0.18972			0.63		
12/20/21 11:00	0.8			1			1.4			0.4			0.21834			0.73		
12/20/21 12:00	0.8			0			1.5			0.54			0.29142			0.97		
12/20/21 13:00	0.8			0			1.5			0.56			0.30132			1		
12/20/21 14:00	1			1			1.5			0.62			0.34254			1.14		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/20/21 15:00	0.6			1			1.5			0.71			0.37776			1.26		
12/20/21 16:00	1.3			1			1.5			0.64			0.34512			1.15		
12/20/21 17:00	0.6			1			1.5			0.72			0.38178			1.27		
12/20/21 18:00	1			1			1.5			0.67			0.35934			1.2		
12/20/21 19:00	0.9			1			1.5			0.69			0.3681			1.23		
12/20/21 20:00	0.5			1			1.5			0.73			0.38868			1.3		
12/20/21 21:00	0.9			1			1.5			0.69			0.36696			1.22		
12/20/21 22:00	1			1			1.5			0.65			0.3558			1.19		
12/20/21 23:00	1.1			1			1.5			0.61			0.33156			1.11		
12/21/21 0:00	0.9			1			1.5			0.56			0.30078			1		
12/21/21 1:00	0.9			1			1.5			0.55			0.29892			1		
12/21/21 2:00	1			0			1.5			0.55			0.2988			1		
12/21/21 3:00	1			0			1.5			0.53			0.28398			0.95		
12/21/21 4:00	1			1			1.5			0.5			0.26802			0.89		
12/21/21 5:00	1			1			1.5			0.5			0.2691			0.9		
12/21/21 6:00	0.8			1			1.5			0.54			0.2895			0.97		
12/21/21 7:00	1.3			1			1.6			0.57			0.30552			1.02		
12/21/21 8:00	0.5			2			1.5			0.76			0.40428			1.35		
12/21/21 9:00	0.5			2			1.5			0.76			0.40296			1.34		
12/21/21 10:00	1.9			1			1.5			0.6			0.3174			1.06		
12/21/21 11:00	0.9			1			1.6			0.49			0.26178			0.87		
12/21/21 12:00	0.8			0			1.4			0.46			0.24816			0.83		
12/21/21 13:00	0.8			1			1.5			0.54			0.29214			0.97		
12/21/21 14:00	1.3			1			1.5			0.57			0.31032			1.03		
12/21/21 15:00	1.7			1			1.5			0.6			0.3237			1.08		
12/21/21 16:00	1.4			1			1.5			0.61			0.327			1.09		
12/21/21 17:00	1.5			1			1.5			0.6			0.3219			1.07		
12/21/21 18:00	1.5			1			1.5			0.6			0.32208			1.07		
12/21/21 19:00	1.5			1			1.5			0.6			0.32208			1.07		
12/21/21 20:00	1.5			1			1.5			0.6			0.32184			1.07		
12/21/21 21:00	1.6			1			1.5			0.6			0.32256			1.08		
12/21/21 22:00	1.5			1			1.5			0.6			0.32376			1.08		
12/21/21 23:00	1.2			1			1.6			0.5			0.26676			0.89		
12/22/21 0:00	0.7			1			1.5			0.35			0.1881			0.63		
12/22/21 1:00	0.7			1			1.5			0.35			0.18816			0.63		
12/22/21 2:00	0.7			1			1.5			0.35			0.18804			0.63		
12/22/21 3:00	0.7			1			1.5			0.35			0.1878			0.63		
12/22/21 4:00	0.7			1			1.5			0.35			0.18852			0.63		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/22/21 5:00	1.4			0			1.4			0.56			0.3042			1.01		
12/22/21 6:00	1.6			1			1.5			0.6			0.3225			1.08		
12/22/21 7:00	1.6			1			1.5			0.6			0.32214			1.07		
12/22/21 8:00	1.6			1			1.5			0.6			0.32352			1.08		
12/22/21 9:00	1.6			1			1.5			0.6			0.32388			1.08		
12/22/21 10:00	1.3			1			1.6			0.51			0.27528			0.92		
12/22/21 11:00	0.7			1			1.5			0.35			0.18756			0.63		
12/22/21 12:00	0.7			1			1.5			0.35			0.18822			0.63		
12/22/21 13:00	1.1			0			1.4			0.5			0.26856			0.9		
12/22/21 14:00	1.4			1			1.5			0.62			0.33138			1.1		
12/22/21 15:00	1.3			1			1.5			0.61			0.32916			1.1		
12/22/21 16:00	1.3			1			1.5			0.61			0.32808			1.09		
12/22/21 17:00	1.3			1			1.5			0.61			0.3285			1.1		
12/22/21 18:00	1.3			1			1.5			0.61			0.32844			1.09		
12/22/21 19:00	1.4			1			1.5			0.6			0.32268			1.08		
12/22/21 20:00	0.8			1			1.5			0.36			0.19128			0.64		
12/22/21 21:00	0.8			1			1.5			0.36			0.1917			0.64		
12/22/21 22:00	0.7			1			1.4			0.39			0.21096			0.7		
12/22/21 23:00	0.7			1			1.5			0.36			0.19314			0.64		
12/23/21 0:00	0.9			0			1.4			0.46			0.24876			0.83		
12/23/21 1:00	0.8			1			1.5			0.38			0.2028			0.68		
12/23/21 2:00	0.6			1			1.4			0.35			0.1899			0.63		
12/23/21 3:00	0.6			1			1.5			0.35			0.18738			0.62		
12/23/21 4:00	0.6			1			1.5			0.35			0.1869			0.62		
12/23/21 5:00	0.6			1			1.5			0.35			0.18726			0.62		
12/23/21 6:00	0.6			1			1.5			0.35			0.1878			0.63		
12/23/21 7:00	0.6			1			1.5			0.35			0.1875			0.63		
12/23/21 8:00	0.6			1			1.5			0.35			0.18744			0.62		
12/23/21 9:00	0.6			1			1.5			0.35			0.18738			0.62		
12/23/21 10:00	0.6			1			1.5			0.35			0.18768			0.63		
12/23/21 11:00	0.6			1			1.5			0.35			0.18732			0.62		
12/23/21 12:00	0.6			1			1.5			0.35			0.1869			0.62		
12/23/21 13:00	0.6			1			1.5			0.35			0.18708			0.62		
12/23/21 14:00	0.7			1			1.5			0.35			0.18696			0.62		
12/23/21 15:00	0.7			1			1.5			0.35			0.18702			0.62		
12/23/21 16:00	0.7			1			1.5			0.35			0.1869			0.62		
12/23/21 17:00	0.7			1			1.5			0.35			0.1872			0.62		
12/23/21 18:00	0.6			1			1.5			0.35			0.18756			0.63		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/23/21 19:00	0.6			1			1.5			0.35			0.18642			0.62		
12/23/21 20:00	0.6			1			1.5			0.35			0.18648			0.62		
12/23/21 21:00	0.6			1			1.5			0.35			0.18624			0.62		
12/23/21 22:00	0.6			1			1.5			0.35			0.18606			0.62		
12/23/21 23:00	0.6			1			1.5			0.35			0.18678			0.62		
12/24/21 0:00	0.6			1			1.5			0.35			0.1872			0.62		
12/24/21 1:00	0.6			1			1.5			0.35			0.18756			0.63		
12/24/21 2:00	0.6			1			1.5			0.35			0.18744			0.62		
12/24/21 3:00	0.6			1			1.5			0.35			0.18726			0.62		
12/24/21 4:00	0.6			1			1.5			0.35			0.18714			0.62		
12/24/21 5:00	0.6			1			1.5			0.35			0.18732			0.62		
12/24/21 6:00	0.6			1			1.5			0.35			0.18732			0.62		
12/24/21 7:00	0.6			1			1.5			0.35			0.18744			0.62		
12/24/21 8:00	0.6			1			1.5			0.35			0.19032			0.63		
12/24/21 9:00	0.6			1			1.5			0.35			0.1872			0.62		
12/24/21 10:00	0.7			1			1.5			0.35			0.18756			0.63		
12/24/21 11:00	0.7			1			1.5			0.35			0.18714			0.62		
12/24/21 12:00	0.7			1			1.5			0.35			0.18708			0.62		
12/24/21 13:00	0.7			1			1.5			0.35			0.1869			0.62		
12/24/21 14:00	0.7			1			1.5			0.35			0.1866			0.62		
12/24/21 15:00	0.7			1			1.5			0.35			0.18672			0.62		
12/24/21 16:00	0.7			1			1.5			0.35			0.18744			0.62		
12/24/21 17:00	0.7			1			1.5			0.35			0.1872			0.62		
12/24/21 18:00	0.7			1			1.5			0.35			0.18708			0.62		
12/24/21 19:00	0.7			1			1.5			0.35			0.18696			0.62		
12/24/21 20:00	0.7			1			1.5			0.35			0.18678			0.62		
12/24/21 21:00	0.7			1			1.5			0.35			0.1869			0.62		
12/24/21 22:00	0.7			1			1.5			0.35			0.18666			0.62		
12/24/21 23:00	0.7			1			1.5			0.35			0.18672			0.62		
12/25/21 0:00	0.7			1			1.5			0.35			0.18696			0.62		
12/25/21 1:00	0.7			1			1.5			0.35			0.18702			0.62		
12/25/21 2:00	0.7			1			1.5			0.35			0.1869			0.62		
12/25/21 3:00	0.7			1			1.5			0.35			0.18684			0.62		
12/25/21 4:00	0.7			1			1.5			0.35			0.18678			0.62		
12/25/21 5:00	0.7			1			1.5			0.35			0.18702			0.62		
12/25/21 6:00	0.7			1			1.5			0.35			0.18678			0.62		
12/25/21 7:00	0.7			1			1.5			0.35			0.18726			0.62		
12/25/21 8:00	0.7			1			1.5			0.35			0.18714			0.62		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/25/21 9:00	0.7			1			1.5			0.35			0.1872			0.62		
12/25/21 10:00	0.7			1			1.5			0.35			0.18786			0.63		
12/25/21 11:00	0.6			1			1.5			0.35			0.18816			0.63		
12/25/21 12:00	0.6			1			1.5			0.35			0.18828			0.63		
12/25/21 13:00	0.6			1			1.5			0.35			0.18876			0.63		
12/25/21 14:00	0.6			1			1.5			0.35			0.1887			0.63		
12/25/21 15:00	0.7			1			1.4			0.36			0.19602			0.65		
12/25/21 16:00	0.6			1			1.6			0.35			0.18816			0.63		
12/25/21 17:00	0.6			1			1.5			0.35			0.18798			0.63		
12/25/21 18:00	0.6			1			1.5			0.35			0.18756			0.63		
12/25/21 19:00	0.6			1			1.5			0.35			0.18714			0.62		
12/25/21 20:00	0.6			1			1.5			0.35			0.18798			0.63		
12/25/21 21:00	0.6			1			1.5			0.35			0.18762			0.63		
12/25/21 22:00	0.7			1			1.5			0.35			0.1872			0.62		
12/25/21 23:00	0.7			1			1.5			0.35			0.18702			0.62		
12/26/21 0:00	0.7			1			1.5			0.35			0.18696			0.62		
12/26/21 1:00	0.7			1			1.5			0.35			0.18702			0.62		
12/26/21 2:00	0.7			1			1.5			0.35			0.1872			0.62		
12/26/21 3:00	0.6			2			1.5			0.35			0.18852			0.63		
12/26/21 4:00	0.7			1			1.5			0.35			0.18846			0.63		
12/26/21 5:00	0.7			1			1.5			0.35			0.18924			0.63		
12/26/21 6:00	0.6			1			1.5			0.35			0.18942			0.63		
12/26/21 7:00	0.7			1			1.5			0.35			0.19194			0.64		
12/26/21 8:00	0.7			1			1.5			0.35			0.18744			0.62		
12/26/21 9:00	0.7			1			1.5			0.35			0.18828			0.63		
12/26/21 10:00	0.7			1			1.5			0.35			0.1884			0.63		
12/26/21 11:00	0.7			1			1.5			0.36			0.19224			0.64		
12/26/21 12:00	0.7			1			1.5			0.35			0.1893			0.63		
12/26/21 13:00	0.8			1			1.4			0.38			0.20286			0.68		
12/26/21 14:00	0.7			1			1.3			0.36			0.19434			0.65		
12/26/21 15:00	0.7			1			1.5			0.36			0.19482			0.65		
12/26/21 16:00	1			2			0.8			0.49			0.26532			0.88		
12/26/21 17:00	1.5			0			1.3			0.61			0.32724			1.09		
12/26/21 18:00	1			1			1.6			0.44			0.23508			0.78		
12/26/21 19:00	0.6			1			1.5			0.35			0.18978			0.63		
12/26/21 20:00	0.7			1			1.4			0.36			0.19404			0.65		
12/26/21 21:00	0.8			0			1.4			0.52			0.28218			0.94		
12/26/21 22:00	0.8			1			1.6			0.39			0.21018			0.7		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/26/21 23:00	0.7			1			1.5			0.35			0.18846			0.63		
12/27/21 0:00	0.6			1			1.5			0.35			0.1899			0.63		
12/27/21 1:00	0.6			1			1.5			0.35			0.18894			0.63		
12/27/21 2:00	0.6			1			1.5			0.35			0.18918			0.63		
12/27/21 3:00	0.6			1			1.5			0.35			0.18864			0.63		
12/27/21 4:00	0.6			1			1.5			0.35			0.18774			0.63		
12/27/21 5:00	1.1			0			1.4			0.49			0.27018			0.9		
12/27/21 6:00	1.6			1			1.5			0.61			0.32712			1.09		
12/27/21 7:00	1.5			1			1.5			0.61			0.32706			1.09		
12/27/21 8:00	1.4			1			1.5			0.61			0.32982			1.1		
12/27/21 9:00	1.2			1			1.5			0.55			0.29754			0.99		
12/27/21 10:00	0.8			1			1.4			0.43			0.23286			0.78		
12/27/21 11:00	0.8			0			1.5			0.53			0.28566			0.95		
12/27/21 12:00	0.7			2			1.6			0.35			0.1866			0.62		
12/27/21 13:00	0.7			1			1.4			0.37			0.19776			0.66		
12/27/21 14:00	0.8			0			1.5			0.5			0.2712			0.9		
12/27/21 15:00	1.2			1			1.5			0.57			0.30492			1.02		
12/27/21 16:00	1.2			1			1.5			0.61			0.32808			1.09		
12/27/21 17:00	1.2			1			1.5			0.62			0.33252			1.11		
12/27/21 18:00	1.3			1			1.5			0.63			0.3363			1.12		
12/27/21 19:00	1.2			1			1.5			0.63			0.3387			1.13		
12/27/21 20:00	1.2			1			1.5			0.63			0.33906			1.13		
12/27/21 21:00	1.5			1			1.5			0.61			0.32586			1.09		
12/27/21 22:00	1.4			1			1.5			0.54			0.29046			0.97		
12/27/21 23:00	0.8			1			1.5			0.42			0.22578			0.75		
12/28/21 0:00	0.7			1			1.5			0.36			0.19548			0.65		
12/28/21 1:00	0.6			1			1.5			0.35			0.18918			0.63		
12/28/21 2:00	0.7			1			1.5			0.35			0.18936			0.63		
12/28/21 3:00	0.8			1			1.5			0.36			0.19434			0.65		
12/28/21 4:00	0.7			1			1.5			0.35			0.1893			0.63		
12/28/21 5:00	0.9			0			1.4			0.48			0.25986			0.87		
12/28/21 6:00	0.9			0			1.5			0.47			0.25458			0.85		
12/28/21 7:00	0.8			2			1.4			0.36			0.19446			0.65		
12/28/21 8:00	0.8			1			1.3			0.41			0.22152			0.74		
12/28/21 9:00	0.9			1			1.4			0.4			0.21702			0.72		
12/28/21 10:00	0.7			2			1.3			0.35			0.18768			0.63		
12/28/21 11:00	0.7			2			1.3			0.35			0.18744			0.62		
12/28/21 12:00	0.7			1			1.4			0.35			0.18774			0.63		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/28/21 13:00	0.7			1			1.5			0.35			0.1869			0.62		
12/28/21 14:00	0.7			1			1.5			0.35			0.18696			0.62		
12/28/21 15:00	0.7			1			1.3			0.41			0.21936			0.73		
12/28/21 16:00	0.8			1			1.3			0.46			0.24594			0.82		
12/28/21 17:00	0.8			0			1.5			0.56			0.30228			1.01		
12/28/21 18:00	0.9			0			1.5			0.53			0.28338			0.94		
12/28/21 19:00	0.9			1			1.4			0.48			0.25764			0.86		
12/28/21 20:00	0.9			1			1.5			0.47			0.25224			0.84		
12/28/21 21:00	0.8			1			1.3			0.37			0.2007			0.67		
12/28/21 22:00	0.7			1			1.5			0.35			0.19134			0.64		
12/28/21 23:00	0.7			1			1.5			0.35			0.19008			0.63		
12/29/21 0:00	0.7			1			1.5			0.35			0.19056			0.64		
12/29/21 1:00	0.7			1			1.5			0.35			0.19008			0.63		
12/29/21 2:00	0.6			1			1.4			0.35			0.18816			0.63		
12/29/21 3:00	0.7			1			1.5			0.35			0.18792			0.63		
12/29/21 4:00	0.6			1			1.5			0.35			0.18792			0.63		
12/29/21 5:00	0.7			1			1.5			0.35			0.18924			0.63		
12/29/21 6:00	0.7			1			1.4			0.36			0.19518			0.65		
12/29/21 7:00	0.7			2			1.5			0.35			0.18804			0.63		
12/29/21 8:00	0.6			1			1.4			0.35			0.18798			0.63		
12/29/21 9:00	0.6			1			1.5			0.35			0.18732			0.62		
12/29/21 10:00	0.7			1			1.5			0.35			0.18714			0.62		
12/29/21 11:00	0.7			1			1.5			0.35			0.18762			0.63		
12/29/21 12:00	0.7			1			1.5			0.35			0.18822			0.63		
12/29/21 13:00	0.7			1			1.4			0.36			0.19686			0.66		
12/29/21 14:00	0.8			0			1.4			0.45			0.24096			0.8		
12/29/21 15:00	0.8			1			1.3			0.46			0.24636			0.82		
12/29/21 16:00	0.8			1			1.4			0.45			0.2433			0.81		
12/29/21 17:00	0.8			0			1.5			0.55			0.29712			0.99		
12/29/21 18:00	0.8			0			1.5			0.55			0.29856			1		
12/29/21 19:00	0.8			0			1.5			0.56			0.30246			1.01		
12/29/21 20:00	0.8			0			1.5			0.56			0.30264			1.01		
12/29/21 21:00	0.8			1			1.5			0.42			0.22614			0.75		
12/29/21 22:00	0.7			1			1.4			0.35			0.19026			0.63		
12/29/21 23:00	0.7			1			1.5			0.35			0.1881			0.63		
12/30/21 0:00	0.7			1			1.5			0.35			0.1878			0.63		
12/30/21 1:00	0.7			1			1.5			0.35			0.1875			0.63		
12/30/21 2:00	0.7			1			1.4			0.35			0.18774			0.63		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/30/21 3:00	0.7			1			1.5			0.35			0.1875			0.63		
12/30/21 4:00	0.7			1			1.5			0.35			0.18798			0.63		
12/30/21 5:00	1.5			0			1.3			0.55			0.29862			1		
12/30/21 6:00	1.6			1			1.5			0.6			0.32292			1.08		
12/30/21 7:00	1.5			1			1.5			0.6			0.32262			1.08		
12/30/21 8:00	1.6			1			1.5			0.6			0.32154			1.07		
12/30/21 9:00	1.5			1			1.5			0.6			0.32172			1.07		
12/30/21 10:00	0.8			2			1.3			0.37			0.20028			0.67		
12/30/21 11:00	0.7			1			1.2			0.35			0.18762			0.63		
12/30/21 12:00	0.7			1			1.2			0.35			0.1878			0.63		
12/30/21 13:00	0.7			1			1.2			0.35			0.18762			0.63		
12/30/21 14:00	0.7			1			1.5			0.35			0.18828			0.63		
12/30/21 15:00	0.7			1			1.5			0.35			0.18846			0.63		
12/30/21 16:00	1.1			0			1.4			0.5			0.26874			0.9		
12/30/21 17:00	1.6			1			1.5			0.61			0.3249			1.08		
12/30/21 18:00	1.6			1			1.5			0.61			0.3255			1.09		
12/30/21 19:00	1.6			1			1.5			0.61			0.32574			1.09		
12/30/21 20:00	1.7			1			1.5			0.61			0.3261			1.09		
12/30/21 21:00	1.6			1			1.5			0.61			0.32622			1.09		
12/30/21 22:00	1.2			1			1.5			0.46			0.24726			0.82		
12/30/21 23:00	0.7			1			1.4			0.35			0.1893			0.63		
12/31/21 0:00	0.7			1			1.4			0.35			0.1884			0.63		
12/31/21 1:00	0.7			1			1.4			0.35			0.18804			0.63		
12/31/21 2:00	0.7			1			1.4			0.35			0.18786			0.63		
12/31/21 3:00	0.7			1			1.5			0.35			0.1881			0.63		
12/31/21 4:00	0.7			1			1.5			0.35			0.18816			0.63		
12/31/21 5:00	0.7			1			1.5			0.35			0.18786			0.63		
12/31/21 6:00	0.7			1			1.5			0.35			0.1881			0.63		
12/31/21 7:00	0.7			1			1.5			0.35			0.1884			0.63		
12/31/21 8:00	0.7			1			1.5			0.35			0.18912			0.63		
12/31/21 9:00	0.7			1			1.5			0.35			0.18966			0.63		
12/31/21 10:00	0.7			1			1.5			0.35			0.18846			0.63		
12/31/21 11:00	0.7			1			1.5			0.35			0.18684			0.62		
12/31/21 12:00	0.7			1			1.5			0.35			0.18672			0.62		
12/31/21 13:00	0.7			1			1.4			0.35			0.18666			0.62		
12/31/21 14:00	0.7			1			1.5			0.35			0.18642			0.62		
12/31/21 15:00	0.7			1			1.5			0.35			0.18648			0.62		
12/31/21 16:00	0.7			1			1.3			0.41			0.21948			0.73		

	CT2_CO_Ppmvdc_1H			CT2_NH3Slip_Ppmvdc_1H			CT2_NOx_Ppmvdc_1H			CT1_PM10_LbPerHr_1H			CT2_SO2_LbPerHr_1H			CT2_VOC_LbPerHr_1H		
Date/Time	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod	Value	SI	Mod
12/31/21 17:00	0.9			0			1.5			0.45			0.24258			0.81		
12/31/21 18:00	0.9			0			1.4			0.49			0.26364			0.88		
12/31/21 19:00	0.8			0			1.5			0.54			0.29382			0.98		
12/31/21 20:00	0.9			0			1.4			0.5			0.26952			0.9		
12/31/21 21:00	0.8			0			1.5			0.54			0.29388			0.98		
12/31/21 22:00	1			1			1.5			0.47			0.25386			0.85		
12/31/21 23:00	0.9			2			1.5			0.37			0.19848			0.66		

AQ-59

AQ-59 The Daily Emissions shall not exceed the following rates:

POLLUTANT	TWO TURBINES	AUX BOILER	COOLING TOWER	EMERGENCY DIESEL GENERATOR	DIESEL FIRE PUMP
NOX	406.0	16.8	-	4.31	1.72
CO	629.5	52.8	-	0.84	0.09
VOC	223.1	7.2	-	0.16	0.05
PM-10	226.8	14.4	16.3	0.14	0.03
SO2	47.1	1.92	-	0.10	0.19

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6

Monthly Summary By Day Report

Unit CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:16 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
10/01/2021	13.86	46.15	5.4	10.33	17.18
10/02/2021	13.68	47.15	5.5	10.56	17.57
10/03/2021	15.90	46.32	5.4	10.07	16.79
10/04/2021	19.17	58.22	6.6	12.59	21.00
10/05/2021	11.81	44.60	5.0	9.93	16.57
10/06/2021	12.78	47.76	5.3	10.40	17.28
10/07/2021	11.13	46.19	5.3	10.01	16.68
10/08/2021	10.15	44.12	5.1	9.49	15.79
10/09/2021	8.62	40.56	4.9	8.72	14.51
10/10/2021	9.03	40.55	4.8	8.73	14.55
10/11/2021	15.37	55.81	6.1	11.91	19.84
10/12/2021	13.62	54.24	6.3	11.77	19.59
10/13/2021	15.21	56.16	6.5	12.07	20.12
10/14/2021	25.02	42.39	4.8	8.68	14.47
10/15/2021	0.00	0.00	0.0	0.00	0.00
10/16/2021	0.00	0.00	0.0	0.00	0.00
10/17/2021	0.00	0.00	0.0	0.00	0.00
10/18/2021	0.00	0.00	0.0	0.00	0.00
10/19/2021	0.00	0.00	0.0	0.00	0.00
10/20/2021	52.32	11.47	0.2	0.39	0.66
10/21/2021	13.88	51.89	6.0	11.28	18.74
10/22/2021	10.10	44.29	5.2	9.60	16.00
10/23/2021	12.32	48.93	5.5	10.37	17.25
10/24/2021	12.38	49.74	5.6	10.65	17.72
10/25/2021	11.26	46.53	5.4	9.97	16.60
10/26/2021	9.79	43.46	4.8	9.19	15.32
10/27/2021	10.16	44.99	5.4	9.55	15.94
10/28/2021	11.17	44.69	5.3	9.61	15.99
10/29/2021	12.11	44.78	5.2	9.60	16.03
10/30/2021	7.83	38.69	4.8	8.29	13.79
10/31/2021	7.14	38.03	4.8	8.10	13.45
Monthly Avg/Sum*:	365.81 *	1,177.71 *	135.2 *	251.86 *	419.43 *
Daily Min:	7.14	11.47	0.2	0.39	0.66
Daily Max:	52.32	58.22	6.6	12.59	21.00
Oct 2021 - Oct 2021	365.81	1,177.71	135.2	251.86	419.43
QTD:	365.81 *	1,177.71 *	135.2 *	251.86 *	419.43 *
YTD 2021:	3,803.47 *	8,869.36 *	987.2 *	1,869.39 *	3,115.51 *

Monthly Summary By Day Report

Unit CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:16 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
11/01/2021	12.68	48.08	5.5	10.33	17.25
11/02/2021	10.57	45.06	5.3	9.68	16.13
11/03/2021	12.54	47.59	5.5	10.16	16.96
11/04/2021	8.76	40.64	5.0	8.84	14.73
11/05/2021	10.75	44.43	4.9	9.51	15.86
11/06/2021	11.02	45.67	5.2	9.69	16.15
11/07/2021	8.86	42.67	4.8	8.79	14.69
11/08/2021	14.79	48.39	5.7	10.51	17.52
11/09/2021	9.72	43.60	5.1	9.21	15.35
11/10/2021	7.81	40.43	4.8	8.49	14.17
11/11/2021	15.98	45.33	5.3	9.75	16.25
11/12/2021	7.68	38.89	4.8	8.18	13.62
11/13/2021	12.11	46.61	5.3	9.92	16.53
11/14/2021	7.11	38.48	4.8	8.06	13.46
11/15/2021	9.25	40.33	4.8	8.58	14.27
11/16/2021	12.16	45.27	5.2	9.86	16.40
11/17/2021	14.14	44.88	5.4	10.21	17.01
11/18/2021	13.19	42.45	5.3	10.01	16.63
11/19/2021	67.36	29.79	3.3	6.18	10.27
11/20/2021	8.56	37.07	4.9	8.72	14.52
11/21/2021	13.00	41.77	5.3	9.91	16.56
11/22/2021	12.50	41.22	5.4	9.87	16.44
11/23/2021	8.16	35.18	4.8	8.32	13.85
11/24/2021	8.30	40.05	4.8	8.57	14.22
11/25/2021	9.36	39.03	4.8	8.47	14.08
11/26/2021	10.03	38.13	4.8	8.32	13.88
11/27/2021	10.10	40.33	4.8	8.71	14.47
11/28/2021	9.69	38.08	4.8	8.43	13.97
11/29/2021	12.19	43.32	4.9	9.26	15.38
11/30/2021	13.72	48.94	5.9	11.15	18.56
Monthly Avg/Sum*:	382.09 *	1,261.71 *	151.2 *	275.69 *	459.18 *
Daily Min:	7.11	29.79	3.3	6.18	10.27
Daily Max:	67.36	48.94	5.9	11.15	18.56
Oct 2021 - Nov 2021	747.90	2,439.42	286.4	527.55	878.61
QTD:	747.90 *	2,439.42 *	286.4 *	527.55 *	878.61 *
YTD 2021:	4,185.56 *	10,131.07 *	1,138.4 *	2,145.08 *	3,574.69 *

Monthly Summary By Day Report

Unit CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:16 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
12/01/2021	12.41	42.63	5.2	9.37	15.57
12/02/2021	20.54	50.35	5.7	11.22	18.66
12/03/2021	19.15	50.90	5.6	10.84	18.04
12/04/2021	17.58	46.76	5.3	10.52	17.49
12/05/2021	14.12	46.11	5.6	10.60	17.64
12/06/2021	21.68	58.50	6.6	12.58	20.96
12/07/2021	20.79	57.09	6.4	12.38	20.63
12/08/2021	14.49	48.29	5.6	10.25	17.12
12/09/2021	11.99	44.41	4.9	9.42	15.66
12/10/2021	14.17	51.24	5.8	10.81	18.00
12/11/2021	12.39	46.98	5.4	9.90	16.47
12/12/2021	12.70	46.31	5.3	9.94	16.52
12/13/2021	17.61	54.34	6.1	11.73	19.53
12/14/2021	11.94	45.85	5.4	9.73	16.16
12/15/2021	12.72	50.34	5.8	10.87	18.08
12/16/2021	24.49	57.92	6.4	12.66	21.11
12/17/2021	23.58	53.48	6.0	11.54	19.28
12/18/2021	22.34	54.04	5.8	11.66	19.43
12/19/2021	20.90	50.32	6.0	11.57	19.30
12/20/2021	19.72	57.31	6.6	13.28	22.16
12/21/2021	25.35	63.24	6.9	13.79	22.97
12/22/2021	23.21	53.07	6.0	11.55	19.21
12/23/2021	9.03	38.72	4.8	8.54	14.17
12/24/2021	8.23	38.07	4.8	8.40	13.93
12/25/2021	8.41	38.97	4.8	8.41	13.95
12/26/2021	11.02	43.54	5.0	9.17	15.25
12/27/2021	22.02	56.70	6.2	12.06	20.09
12/28/2021	11.17	46.04	5.0	9.62	16.02
12/29/2021	11.13	44.29	5.2	9.62	16.01
12/30/2021	23.93	51.65	5.8	11.18	18.57
12/31/2021	10.85	41.24	5.0	9.37	15.57
Monthly Avg/Sum*:	509.66 *	1,528.70 *	175.0 *	332.58 *	553.55 *
Daily Min:	8.23	38.07	4.8	8.40	13.93
Daily Max:	25.35	63.24	6.9	13.79	22.97
Oct 2021 - Dec 2021	1,257.56	3,968.12	461.4	860.13	1,432.16
QTD:	1,257.56 *	3,968.12 *	461.4 *	860.13 *	1,432.16 *
YTD 2021:	4,695.22 *	11,659.77 *	1,313.4 *	2,477.66 *	4,128.24 *

Monthly Summary By Day Report

Unit CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:18 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
10/01/2021	17.28	49.28	5.7	11.10	18.49
10/02/2021	18.10	50.38	5.9	11.33	18.92
10/03/2021	18.75	49.15	5.6	10.80	18.05
10/04/2021	23.46	62.09	6.9	13.48	22.46
10/05/2021	15.25	47.23	5.3	10.70	17.82
10/06/2021	15.69	50.39	5.6	11.14	18.59
10/07/2021	13.69	49.14	5.5	10.77	17.91
10/08/2021	12.29	46.44	5.4	10.20	16.99
10/09/2021	10.54	43.20	5.0	9.42	15.67
10/10/2021	11.07	43.23	4.9	9.42	15.63
10/11/2021	20.05	59.65	6.6	12.89	21.52
10/12/2021	19.14	58.76	6.5	12.69	21.16
10/13/2021	20.44	59.81	6.7	13.01	21.65
10/14/2021	18.26	52.68	5.8	11.28	18.81
10/15/2021	41.50	67.51	7.2	14.53	24.27
10/16/2021	39.83	68.11	7.2	14.70	24.53
10/17/2021	39.39	68.86	7.4	14.91	24.88
10/18/2021	40.80	63.27	6.9	13.74	22.82
10/19/2021	37.83	60.82	6.7	13.21	22.03
10/20/2021	18.33	47.71	5.4	10.40	17.37
10/21/2021	18.72	55.59	6.3	12.10	20.19
10/22/2021	14.40	47.80	5.3	10.35	17.24
10/23/2021	16.23	50.99	5.6	11.17	18.63
10/24/2021	16.38	53.45	6.0	11.46	19.10
10/25/2021	14.72	49.51	5.6	10.70	17.91
10/26/2021	12.73	45.64	5.2	9.89	16.49
10/27/2021	12.52	47.99	5.5	10.32	17.21
10/28/2021	13.52	47.55	5.5	10.33	17.23
10/29/2021	15.18	47.53	5.3	10.40	17.27
10/30/2021	9.73	41.17	4.8	8.95	14.87
10/31/2021	9.25	40.65	4.8	8.75	14.61
Monthly Avg/Sum*:	605.07 *	1,625.58 *	182.1 *	354.14 *	590.32 *
Daily Min:	9.25	40.65	4.8	8.75	14.61
Daily Max:	41.50	68.86	7.4	14.91	24.88
Oct 2021 - Oct 2021	605.07	1,625.58	182.1	354.14	590.32
QTD:	605.07 *	1,625.58 *	182.1 *	354.14 *	590.32 *
YTD 2021:	5,793.25 *	9,870.66 *	1,027.3 *	2,021.71 *	3,371.78 *

Monthly Summary By Day Report

Unit CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:18 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
11/01/2021	15.73	51.12	5.6	11.16	18.59
11/02/2021	12.92	48.46	5.5	10.42	17.35
11/03/2021	14.73	50.55	5.5	10.94	18.24
11/04/2021	9.82	41.62	5.0	9.55	15.87
11/05/2021	12.57	46.82	5.2	10.27	17.09
11/06/2021	12.78	48.00	5.2	10.46	17.42
11/07/2021	9.73	37.87	4.9	9.49	15.82
11/08/2021	17.72	50.90	5.8	11.33	18.89
11/09/2021	11.04	45.76	5.2	9.93	16.56
11/10/2021	9.32	42.19	4.8	9.17	15.28
11/11/2021	17.99	47.63	5.4	10.43	17.35
11/12/2021	9.23	40.52	4.8	8.85	14.74
11/13/2021	14.27	48.26	5.5	10.69	17.80
11/14/2021	8.39	40.83	4.8	8.71	14.54
11/15/2021	10.88	42.02	4.8	9.26	15.40
11/16/2021	13.81	47.87	5.5	10.65	17.70
11/17/2021	16.17	46.73	5.6	11.01	18.33
11/18/2021	14.98	44.41	5.5	10.79	17.96
11/19/2021	12.25	38.18	5.1	9.83	16.37
11/20/2021	9.97	36.72	4.9	9.42	15.68
11/21/2021	15.32	42.17	5.3	10.71	17.84
11/22/2021	14.42	42.41	5.5	10.64	17.72
11/23/2021	9.21	36.27	4.8	8.99	14.99
11/24/2021	10.56	41.02	4.8	9.20	15.35
11/25/2021	12.26	41.40	4.8	9.09	15.15
11/26/2021	12.60	41.20	4.8	8.96	14.99
11/27/2021	12.78	42.27	4.8	9.34	15.58
11/28/2021	12.47	40.84	4.8	8.93	14.95
11/29/2021	15.35	45.29	5.1	9.86	16.51
11/30/2021	18.16	52.36	6.2	11.87	19.85
Monthly Avg/Sum*:	387.43 *	1,321.69 *	155.5 *	299.95 *	499.91 *
Daily Min:	8.39	36.27	4.8	8.71	14.54
Daily Max:	18.16	52.36	6.2	11.87	19.85
Oct 2021 - Nov 2021	992.50	2,947.27	337.6	654.09	1,090.23
QTD:	992.50 *	2,947.27 *	337.6 *	654.09 *	1,090.23 *
YTD 2021:	6,180.68 *	11,192.35 *	1,182.8 *	2,321.66 *	3,871.69 *

Monthly Summary By Day Report

Unit CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:18 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
12/01/2021	15.23	45.01	5.3	9.99	16.70
12/02/2021	25.02	52.44	6.1	11.96	19.98
12/03/2021	21.23	53.40	5.7	11.65	19.41
12/04/2021	21.96	47.30	5.6	11.28	18.83
12/05/2021	17.44	48.37	5.7	11.41	18.98
12/06/2021	25.48	62.23	6.6	13.54	22.54
12/07/2021	24.52	59.94	6.6	13.34	22.22
12/08/2021	18.44	51.11	5.7	11.05	18.43
12/09/2021	15.56	45.79	5.2	10.11	16.87
12/10/2021	19.01	53.38	5.9	11.62	19.41
12/11/2021	16.09	48.54	5.5	10.64	17.73
12/12/2021	16.59	48.61	5.5	10.69	17.80
12/13/2021	21.98	58.17	6.3	12.59	21.03
12/14/2021	16.05	47.99	5.5	10.44	17.40
12/15/2021	16.37	53.37	6.0	11.69	19.49
12/16/2021	28.09	61.71	6.6	13.59	22.66
12/17/2021	26.91	56.48	6.2	12.33	20.58
12/18/2021	27.38	54.88	6.3	12.53	20.87
12/19/2021	24.88	51.31	6.4	12.42	20.71
12/20/2021	25.46	64.17	7.2	14.34	23.89
12/21/2021	31.93	68.31	7.3	14.80	24.68
12/22/2021	27.28	57.13	6.1	12.47	20.73
12/23/2021	11.39	41.38	4.8	9.10	15.20
12/24/2021	10.95	41.10	4.8	8.91	14.91
12/25/2021	11.02	41.16	4.8	9.00	15.01
12/26/2021	14.12	43.54	5.1	9.87	16.45
12/27/2021	26.43	59.69	6.3	13.00	21.64
12/28/2021	15.10	45.74	5.4	10.36	17.28
12/29/2021	14.19	46.50	5.2	10.39	17.31
12/30/2021	26.92	53.48	5.9	12.04	20.06
12/31/2021	14.63	45.21	5.3	10.12	16.82
Monthly Avg/Sum*:	627.65 *	1,607.44 *	180.9 *	357.27 *	595.62 *
Daily Min:	10.95	41.10	4.8	8.91	14.91
Daily Max:	31.93	68.31	7.3	14.80	24.68
Oct 2021 - Dec 2021	1,620.15	4,554.71	518.5	1,011.36	1,685.85
QTD:	1,620.15 *	4,554.71 *	518.5 *	1,011.36 *	1,685.85 *
YTD 2021:	6,808.33 *	12,799.79 *	1,363.7 *	2,678.93 *	4,467.31 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:12 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
10/01/2021	31.14	95.43	10.69	21.43	35.67
10/02/2021	31.78	97.53	10.92	21.89	36.49
10/03/2021	34.65	95.47	10.47	20.87	34.84
10/04/2021	42.63	120.31	13.02	26.07	43.46
10/05/2021	27.06	91.83	10.30	20.63	34.39
10/06/2021	28.47	98.15	10.75	21.54	35.87
10/07/2021	24.82	95.33	10.40	20.78	34.59
10/08/2021	22.44	90.56	9.84	19.69	32.78
10/09/2021	19.16	83.76	9.05	18.14	30.18
10/10/2021	20.10	83.78	9.06	18.15	30.18
10/11/2021	35.42	115.46	12.41	24.80	41.36
10/12/2021	32.76	113.00	12.21	24.46	40.75
10/13/2021	35.65	115.97	12.52	25.08	41.77
10/14/2021	43.28	95.07	9.98	19.96	33.28
10/15/2021	41.50	67.51	7.22	14.53	24.27
10/16/2021	39.83	68.11	7.32	14.70	24.53
10/17/2021	39.39	68.86	7.44	14.91	24.88
10/18/2021	40.80	63.27	6.79	13.74	22.82
10/19/2021	37.83	60.82	6.59	13.21	22.03
10/20/2021	70.65	59.18	5.39	10.79	18.03
10/21/2021	32.60	107.48	11.65	23.38	38.93
10/22/2021	24.50	92.09	9.95	19.95	33.24
10/23/2021	28.55	99.92	10.73	21.54	35.88
10/24/2021	28.76	103.19	11.05	22.11	36.82
10/25/2021	25.98	96.04	10.37	20.67	34.51
10/26/2021	22.52	89.10	9.55	19.08	31.81
10/27/2021	22.68	92.98	9.96	19.87	33.15
10/28/2021	24.69	92.24	9.96	19.94	33.22
10/29/2021	27.29	92.31	10.00	20.00	33.30
10/30/2021	17.56	79.86	8.59	17.24	28.66
10/31/2021	16.39	78.68	8.39	16.85	28.06
Monthly Avg/Sum*:	970.88 *	2,803.29 *	302.57 *	606.00 *	1,009.75 *
Daily Min:	16.39	59.18	5.39	10.79	18.03
Daily Max:	70.65	120.31	13.02	26.07	43.46
Oct 2021 - Oct 2021	970.88	2,803.29	302.57	606.00	1,009.75
QTD:	970.88 *	2,803.29 *	302.57 *	606.00 *	1,009.75 *
YTD 2021:	9,666.48 *	18,740.02 *	1,944.32 *	3,891.10 *	6,487.29 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:12 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
11/01/2021	28.41	99.20	10.77	21.49	35.84
11/02/2021	23.49	93.52	10.04	20.10	33.48
11/03/2021	27.27	98.14	10.55	21.10	35.20
11/04/2021	18.58	82.26	9.18	18.39	30.60
11/05/2021	23.32	91.25	9.83	19.78	32.95
11/06/2021	23.80	93.67	10.06	20.15	33.57
11/07/2021	18.76	81.39	9.16	18.28	30.51
11/08/2021	32.51	99.29	10.91	21.84	36.41
11/09/2021	20.76	89.36	9.60	19.14	31.91
11/10/2021	17.13	82.62	8.88	17.66	29.45
11/11/2021	33.97	92.96	10.08	20.18	33.60
11/12/2021	16.91	79.41	8.54	17.03	28.36
11/13/2021	26.38	94.87	10.31	20.61	34.33
11/14/2021	15.50	79.31	8.45	16.77	28.00
11/15/2021	20.13	82.35	8.90	17.84	29.67
11/16/2021	25.97	93.14	10.22	20.51	34.10
11/17/2021	30.31	91.61	10.59	21.22	35.34
11/18/2021	28.17	86.86	10.39	20.80	34.59
11/19/2021	79.61	67.97	8.00	16.01	26.64
11/20/2021	18.53	73.79	9.04	18.14	30.20
11/21/2021	28.32	83.94	10.32	20.62	34.40
11/22/2021	26.92	83.63	10.24	20.51	34.16
11/23/2021	17.37	71.45	8.63	17.31	28.84
11/24/2021	18.86	81.07	8.86	17.77	29.57
11/25/2021	21.62	80.43	8.75	17.56	29.23
11/26/2021	22.63	79.33	8.70	17.28	28.87
11/27/2021	22.88	82.60	9.02	18.05	30.05
11/28/2021	22.16	78.92	8.68	17.36	28.92
11/29/2021	27.54	88.61	9.58	19.12	31.89
11/30/2021	31.88	101.30	11.52	23.02	38.41
Monthly Avg/Sum*:	769.69 *	2,584.25 *	287.80 *	575.64 *	959.09 *
Daily Min:	15.50	67.97	8.00	16.01	26.64
Daily Max:	79.61	101.30	11.52	23.02	38.41
Oct 2021 - Nov 2021	1,740.57	5,387.54	590.37	1,181.64	1,968.84
QTD:	1,740.57 *	5,387.54 *	590.37 *	1,181.64 *	1,968.84 *
YTD 2021:	10,436.17 *	21,324.27 *	2,232.12 *	4,466.74 *	7,446.38 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:12 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
12/01/2021	27.64	87.64	9.68	19.36	32.27
12/02/2021	45.56	102.79	11.60	23.18	38.64
12/03/2021	40.38	104.30	11.24	22.49	37.45
12/04/2021	39.54	94.06	10.90	21.80	36.32
12/05/2021	31.56	94.48	10.98	22.01	36.62
12/06/2021	47.16	120.73	13.04	26.12	43.50
12/07/2021	45.31	117.03	12.86	25.72	42.85
12/08/2021	32.93	99.40	10.64	21.30	35.55
12/09/2021	27.55	90.20	9.76	19.53	32.53
12/10/2021	33.18	104.62	11.22	22.43	37.41
12/11/2021	28.48	95.52	10.25	20.54	34.20
12/12/2021	29.29	94.92	10.29	20.63	34.32
12/13/2021	39.59	112.51	12.17	24.32	40.56
12/14/2021	27.99	93.84	10.08	20.17	33.56
12/15/2021	29.09	103.71	11.26	22.56	37.57
12/16/2021	52.58	119.63	13.11	26.25	43.77
12/17/2021	50.49	109.96	11.94	23.87	39.86
12/18/2021	49.72	108.92	12.07	24.19	40.30
12/19/2021	45.78	101.63	12.00	23.99	40.01
12/20/2021	45.18	121.48	13.79	27.62	46.05
12/21/2021	57.28	131.55	14.32	28.59	47.65
12/22/2021	50.49	110.20	11.96	24.02	39.94
12/23/2021	20.42	80.10	8.80	17.64	29.37
12/24/2021	19.18	79.17	8.65	17.31	28.84
12/25/2021	19.43	80.13	8.66	17.41	28.96
12/26/2021	25.14	87.08	9.49	19.04	31.70
12/27/2021	48.45	116.39	12.51	25.06	41.73
12/28/2021	26.27	91.78	9.98	19.98	33.30
12/29/2021	25.32	90.79	9.98	20.01	33.32
12/30/2021	50.85	105.13	11.55	23.22	38.63
12/31/2021	25.48	86.45	9.70	19.49	32.39
Monthly Avg/Sum*:	1,137.31 *	3,136.14 *	344.48 *	689.85 *	1,149.17 *
Daily Min:	19.18	79.17	8.65	17.31	28.84
Daily Max:	57.28	131.55	14.32	28.59	47.65
Oct 2021 - Dec 2021	2,877.88	8,523.68	934.85	1,871.49	3,118.01
QTD:	2,877.88 *	8,523.68 *	934.85 *	1,871.49 *	3,118.01 *
YTD 2021:	11,573.48 *	24,460.41 *	2,576.60 *	5,156.59 *	8,595.55 *

AQ-60

AQ-60 If the Alstom GTX100 turbine are selected, the quarterly emissions shall not exceed the levels shown below:

Alstom GTX100 Gas Turbines					
Pollutant	Quarter 1 (lbs/quarter) Two turbines	Quarter 2 (lbs/quarter) Two Turbines	Quarter 3 (lbs/quarter) Two turbines	Quarter 4 (lbs/quarter) Two Turbines	Tons/ Year Two Turbines
NO _x	15,399	12,965	17,496	15,422	30.64
CO	26,787	32,590	28,175	29,862	58.71
VOCs	5,791	7,306	6,630	6,848	13.29
PM ₁₀	16,300	13,692	17,789	17,569	32.67
SO _x	3,385	2,843	3,694	3,648	6.78

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emission limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

Monthly Summary By Day Report

Unit CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:16 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
10/01/2021	13.86	46.15	5.4	10.33	17.18
10/02/2021	13.68	47.15	5.5	10.56	17.57
10/03/2021	15.90	46.32	5.4	10.07	16.79
10/04/2021	19.17	58.22	6.6	12.59	21.00
10/05/2021	11.81	44.60	5.0	9.93	16.57
10/06/2021	12.78	47.76	5.3	10.40	17.28
10/07/2021	11.13	46.19	5.3	10.01	16.68
10/08/2021	10.15	44.12	5.1	9.49	15.79
10/09/2021	8.62	40.56	4.9	8.72	14.51
10/10/2021	9.03	40.55	4.8	8.73	14.55
10/11/2021	15.37	55.81	6.1	11.91	19.84
10/12/2021	13.62	54.24	6.3	11.77	19.59
10/13/2021	15.21	56.16	6.5	12.07	20.12
10/14/2021	25.02	42.39	4.8	8.68	14.47
10/15/2021	0.00	0.00	0.0	0.00	0.00
10/16/2021	0.00	0.00	0.0	0.00	0.00
10/17/2021	0.00	0.00	0.0	0.00	0.00
10/18/2021	0.00	0.00	0.0	0.00	0.00
10/19/2021	0.00	0.00	0.0	0.00	0.00
10/20/2021	52.32	11.47	0.2	0.39	0.66
10/21/2021	13.88	51.89	6.0	11.28	18.74
10/22/2021	10.10	44.29	5.2	9.60	16.00
10/23/2021	12.32	48.93	5.5	10.37	17.25
10/24/2021	12.38	49.74	5.6	10.65	17.72
10/25/2021	11.26	46.53	5.4	9.97	16.60
10/26/2021	9.79	43.46	4.8	9.19	15.32
10/27/2021	10.16	44.99	5.4	9.55	15.94
10/28/2021	11.17	44.69	5.3	9.61	15.99
10/29/2021	12.11	44.78	5.2	9.60	16.03
10/30/2021	7.83	38.69	4.8	8.29	13.79
10/31/2021	7.14	38.03	4.8	8.10	13.45
Monthly Avg/Sum*:	365.81 *	1,177.71 *	135.2 *	251.86 *	419.43 *
Daily Min:	7.14	11.47	0.2	0.39	0.66
Daily Max:	52.32	58.22	6.6	12.59	21.00
Oct 2021 - Oct 2021	365.81	1,177.71	135.2	251.86	419.43
QTD:	365.81 *	1,177.71 *	135.2 *	251.86 *	419.43 *
YTD 2021:	3,803.47 *	8,869.36 *	987.2 *	1,869.39 *	3,115.51 *

Monthly Summary By Day Report

Unit CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:16 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
11/01/2021	12.68	48.08	5.5	10.33	17.25
11/02/2021	10.57	45.06	5.3	9.68	16.13
11/03/2021	12.54	47.59	5.5	10.16	16.96
11/04/2021	8.76	40.64	5.0	8.84	14.73
11/05/2021	10.75	44.43	4.9	9.51	15.86
11/06/2021	11.02	45.67	5.2	9.69	16.15
11/07/2021	8.86	42.67	4.8	8.79	14.69
11/08/2021	14.79	48.39	5.7	10.51	17.52
11/09/2021	9.72	43.60	5.1	9.21	15.35
11/10/2021	7.81	40.43	4.8	8.49	14.17
11/11/2021	15.98	45.33	5.3	9.75	16.25
11/12/2021	7.68	38.89	4.8	8.18	13.62
11/13/2021	12.11	46.61	5.3	9.92	16.53
11/14/2021	7.11	38.48	4.8	8.06	13.46
11/15/2021	9.25	40.33	4.8	8.58	14.27
11/16/2021	12.16	45.27	5.2	9.86	16.40
11/17/2021	14.14	44.88	5.4	10.21	17.01
11/18/2021	13.19	42.45	5.3	10.01	16.63
11/19/2021	67.36	29.79	3.3	6.18	10.27
11/20/2021	8.56	37.07	4.9	8.72	14.52
11/21/2021	13.00	41.77	5.3	9.91	16.56
11/22/2021	12.50	41.22	5.4	9.87	16.44
11/23/2021	8.16	35.18	4.8	8.32	13.85
11/24/2021	8.30	40.05	4.8	8.57	14.22
11/25/2021	9.36	39.03	4.8	8.47	14.08
11/26/2021	10.03	38.13	4.8	8.32	13.88
11/27/2021	10.10	40.33	4.8	8.71	14.47
11/28/2021	9.69	38.08	4.8	8.43	13.97
11/29/2021	12.19	43.32	4.9	9.26	15.38
11/30/2021	13.72	48.94	5.9	11.15	18.56
Monthly Avg/Sum*:	382.09 *	1,261.71 *	151.2 *	275.69 *	459.18 *
Daily Min:	7.11	29.79	3.3	6.18	10.27
Daily Max:	67.36	48.94	5.9	11.15	18.56
Oct 2021 - Nov 2021	747.90	2,439.42	286.4	527.55	878.61
QTD:	747.90 *	2,439.42 *	286.4 *	527.55 *	878.61 *
YTD 2021:	4,185.56 *	10,131.07 *	1,138.4 *	2,145.08 *	3,574.69 *

Monthly Summary By Day Report

Unit CT1



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:16 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT1 PM10, Lb 1 Hour(s)	Unit CT1 VOC, Lb 1 Hour(s)
12/01/2021	12.41	42.63	5.2	9.37	15.57
12/02/2021	20.54	50.35	5.7	11.22	18.66
12/03/2021	19.15	50.90	5.6	10.84	18.04
12/04/2021	17.58	46.76	5.3	10.52	17.49
12/05/2021	14.12	46.11	5.6	10.60	17.64
12/06/2021	21.68	58.50	6.6	12.58	20.96
12/07/2021	20.79	57.09	6.4	12.38	20.63
12/08/2021	14.49	48.29	5.6	10.25	17.12
12/09/2021	11.99	44.41	4.9	9.42	15.66
12/10/2021	14.17	51.24	5.8	10.81	18.00
12/11/2021	12.39	46.98	5.4	9.90	16.47
12/12/2021	12.70	46.31	5.3	9.94	16.52
12/13/2021	17.61	54.34	6.1	11.73	19.53
12/14/2021	11.94	45.85	5.4	9.73	16.16
12/15/2021	12.72	50.34	5.8	10.87	18.08
12/16/2021	24.49	57.92	6.4	12.66	21.11
12/17/2021	23.58	53.48	6.0	11.54	19.28
12/18/2021	22.34	54.04	5.8	11.66	19.43
12/19/2021	20.90	50.32	6.0	11.57	19.30
12/20/2021	19.72	57.31	6.6	13.28	22.16
12/21/2021	25.35	63.24	6.9	13.79	22.97
12/22/2021	23.21	53.07	6.0	11.55	19.21
12/23/2021	9.03	38.72	4.8	8.54	14.17
12/24/2021	8.23	38.07	4.8	8.40	13.93
12/25/2021	8.41	38.97	4.8	8.41	13.95
12/26/2021	11.02	43.54	5.0	9.17	15.25
12/27/2021	22.02	56.70	6.2	12.06	20.09
12/28/2021	11.17	46.04	5.0	9.62	16.02
12/29/2021	11.13	44.29	5.2	9.62	16.01
12/30/2021	23.93	51.65	5.8	11.18	18.57
12/31/2021	10.85	41.24	5.0	9.37	15.57
Monthly Avg/Sum*:	509.66 *	1,528.70 *	175.0 *	332.58 *	553.55 *
Daily Min:	8.23	38.07	4.8	8.40	13.93
Daily Max:	25.35	63.24	6.9	13.79	22.97
Oct 2021 - Dec 2021	1,257.56	3,968.12	461.4	860.13	1,432.16
QTD:	1,257.56 *	3,968.12 *	461.4 *	860.13 *	1,432.16 *
YTD 2021:	4,695.22 *	11,659.77 *	1,313.4 *	2,477.66 *	4,128.24 *

Monthly Summary By Day Report

Unit CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:18 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
10/01/2021	17.28	49.28	5.7	11.10	18.49
10/02/2021	18.10	50.38	5.9	11.33	18.92
10/03/2021	18.75	49.15	5.6	10.80	18.05
10/04/2021	23.46	62.09	6.9	13.48	22.46
10/05/2021	15.25	47.23	5.3	10.70	17.82
10/06/2021	15.69	50.39	5.6	11.14	18.59
10/07/2021	13.69	49.14	5.5	10.77	17.91
10/08/2021	12.29	46.44	5.4	10.20	16.99
10/09/2021	10.54	43.20	5.0	9.42	15.67
10/10/2021	11.07	43.23	4.9	9.42	15.63
10/11/2021	20.05	59.65	6.6	12.89	21.52
10/12/2021	19.14	58.76	6.5	12.69	21.16
10/13/2021	20.44	59.81	6.7	13.01	21.65
10/14/2021	18.26	52.68	5.8	11.28	18.81
10/15/2021	41.50	67.51	7.2	14.53	24.27
10/16/2021	39.83	68.11	7.2	14.70	24.53
10/17/2021	39.39	68.86	7.4	14.91	24.88
10/18/2021	40.80	63.27	6.9	13.74	22.82
10/19/2021	37.83	60.82	6.7	13.21	22.03
10/20/2021	18.33	47.71	5.4	10.40	17.37
10/21/2021	18.72	55.59	6.3	12.10	20.19
10/22/2021	14.40	47.80	5.3	10.35	17.24
10/23/2021	16.23	50.99	5.6	11.17	18.63
10/24/2021	16.38	53.45	6.0	11.46	19.10
10/25/2021	14.72	49.51	5.6	10.70	17.91
10/26/2021	12.73	45.64	5.2	9.89	16.49
10/27/2021	12.52	47.99	5.5	10.32	17.21
10/28/2021	13.52	47.55	5.5	10.33	17.23
10/29/2021	15.18	47.53	5.3	10.40	17.27
10/30/2021	9.73	41.17	4.8	8.95	14.87
10/31/2021	9.25	40.65	4.8	8.75	14.61
Monthly Avg/Sum*:	605.07 *	1,625.58 *	182.1 *	354.14 *	590.32 *
Daily Min:	9.25	40.65	4.8	8.75	14.61
Daily Max:	41.50	68.86	7.4	14.91	24.88
Oct 2021 - Oct 2021	605.07	1,625.58	182.1	354.14	590.32
QTD:	605.07 *	1,625.58 *	182.1 *	354.14 *	590.32 *
YTD 2021:	5,793.25 *	9,870.66 *	1,027.3 *	2,021.71 *	3,371.78 *

Monthly Summary By Day Report

Unit CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 12:18 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
11/01/2021	15.73	51.12	5.6	11.16	18.59
11/02/2021	12.92	48.46	5.5	10.42	17.35
11/03/2021	14.73	50.55	5.5	10.94	18.24
11/04/2021	9.82	41.62	5.0	9.55	15.87
11/05/2021	12.57	46.82	5.2	10.27	17.09
11/06/2021	12.78	48.00	5.2	10.46	17.42
11/07/2021	9.73	37.87	4.9	9.49	15.82
11/08/2021	17.72	50.90	5.8	11.33	18.89
11/09/2021	11.04	45.76	5.2	9.93	16.56
11/10/2021	9.32	42.19	4.8	9.17	15.28
11/11/2021	17.99	47.63	5.4	10.43	17.35
11/12/2021	9.23	40.52	4.8	8.85	14.74
11/13/2021	14.27	48.26	5.5	10.69	17.80
11/14/2021	8.39	40.83	4.8	8.71	14.54
11/15/2021	10.88	42.02	4.8	9.26	15.40
11/16/2021	13.81	47.87	5.5	10.65	17.70
11/17/2021	16.17	46.73	5.6	11.01	18.33
11/18/2021	14.98	44.41	5.5	10.79	17.96
11/19/2021	12.25	38.18	5.1	9.83	16.37
11/20/2021	9.97	36.72	4.9	9.42	15.68
11/21/2021	15.32	42.17	5.3	10.71	17.84
11/22/2021	14.42	42.41	5.5	10.64	17.72
11/23/2021	9.21	36.27	4.8	8.99	14.99
11/24/2021	10.56	41.02	4.8	9.20	15.35
11/25/2021	12.26	41.40	4.8	9.09	15.15
11/26/2021	12.60	41.20	4.8	8.96	14.99
11/27/2021	12.78	42.27	4.8	9.34	15.58
11/28/2021	12.47	40.84	4.8	8.93	14.95
11/29/2021	15.35	45.29	5.1	9.86	16.51
11/30/2021	18.16	52.36	6.2	11.87	19.85
Monthly Avg/Sum*:	387.43 *	1,321.69 *	155.5 *	299.95 *	499.91 *
Daily Min:	8.39	36.27	4.8	8.71	14.54
Daily Max:	18.16	52.36	6.2	11.87	19.85
Oct 2021 - Nov 2021	992.50	2,947.27	337.6	654.09	1,090.23
QTD:	992.50 *	2,947.27 *	337.6 *	654.09 *	1,090.23 *
YTD 2021:	6,180.68 *	11,192.35 *	1,182.8 *	2,321.66 *	3,871.69 *

Monthly Summary By Day Report

Unit CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 12:18 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
12/01/2021	15.23	45.01	5.3	9.99	16.70
12/02/2021	25.02	52.44	6.1	11.96	19.98
12/03/2021	21.23	53.40	5.7	11.65	19.41
12/04/2021	21.96	47.30	5.6	11.28	18.83
12/05/2021	17.44	48.37	5.7	11.41	18.98
12/06/2021	25.48	62.23	6.6	13.54	22.54
12/07/2021	24.52	59.94	6.6	13.34	22.22
12/08/2021	18.44	51.11	5.7	11.05	18.43
12/09/2021	15.56	45.79	5.2	10.11	16.87
12/10/2021	19.01	53.38	5.9	11.62	19.41
12/11/2021	16.09	48.54	5.5	10.64	17.73
12/12/2021	16.59	48.61	5.5	10.69	17.80
12/13/2021	21.98	58.17	6.3	12.59	21.03
12/14/2021	16.05	47.99	5.5	10.44	17.40
12/15/2021	16.37	53.37	6.0	11.69	19.49
12/16/2021	28.09	61.71	6.6	13.59	22.66
12/17/2021	26.91	56.48	6.2	12.33	20.58
12/18/2021	27.38	54.88	6.3	12.53	20.87
12/19/2021	24.88	51.31	6.4	12.42	20.71
12/20/2021	25.46	64.17	7.2	14.34	23.89
12/21/2021	31.93	68.31	7.3	14.80	24.68
12/22/2021	27.28	57.13	6.1	12.47	20.73
12/23/2021	11.39	41.38	4.8	9.10	15.20
12/24/2021	10.95	41.10	4.8	8.91	14.91
12/25/2021	11.02	41.16	4.8	9.00	15.01
12/26/2021	14.12	43.54	5.1	9.87	16.45
12/27/2021	26.43	59.69	6.3	13.00	21.64
12/28/2021	15.10	45.74	5.4	10.36	17.28
12/29/2021	14.19	46.50	5.2	10.39	17.31
12/30/2021	26.92	53.48	5.9	12.04	20.06
12/31/2021	14.63	45.21	5.3	10.12	16.82
Monthly Avg/Sum*:	627.65 *	1,607.44 *	180.9 *	357.27 *	595.62 *
Daily Min:	10.95	41.10	4.8	8.91	14.91
Daily Max:	31.93	68.31	7.3	14.80	24.68
Oct 2021 - Dec 2021	1,620.15	4,554.71	518.5	1,011.36	1,685.85
QTD:	1,620.15 *	4,554.71 *	518.5 *	1,011.36 *	1,685.85 *
YTD 2021:	6,808.33 *	12,799.79 *	1,363.7 *	2,678.93 *	4,467.31 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:12 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
10/01/2021	31.14	95.43	10.69	21.43	35.67
10/02/2021	31.78	97.53	10.92	21.89	36.49
10/03/2021	34.65	95.47	10.47	20.87	34.84
10/04/2021	42.63	120.31	13.02	26.07	43.46
10/05/2021	27.06	91.83	10.30	20.63	34.39
10/06/2021	28.47	98.15	10.75	21.54	35.87
10/07/2021	24.82	95.33	10.40	20.78	34.59
10/08/2021	22.44	90.56	9.84	19.69	32.78
10/09/2021	19.16	83.76	9.05	18.14	30.18
10/10/2021	20.10	83.78	9.06	18.15	30.18
10/11/2021	35.42	115.46	12.41	24.80	41.36
10/12/2021	32.76	113.00	12.21	24.46	40.75
10/13/2021	35.65	115.97	12.52	25.08	41.77
10/14/2021	43.28	95.07	9.98	19.96	33.28
10/15/2021	41.50	67.51	7.22	14.53	24.27
10/16/2021	39.83	68.11	7.32	14.70	24.53
10/17/2021	39.39	68.86	7.44	14.91	24.88
10/18/2021	40.80	63.27	6.79	13.74	22.82
10/19/2021	37.83	60.82	6.59	13.21	22.03
10/20/2021	70.65	59.18	5.39	10.79	18.03
10/21/2021	32.60	107.48	11.65	23.38	38.93
10/22/2021	24.50	92.09	9.95	19.95	33.24
10/23/2021	28.55	99.92	10.73	21.54	35.88
10/24/2021	28.76	103.19	11.05	22.11	36.82
10/25/2021	25.98	96.04	10.37	20.67	34.51
10/26/2021	22.52	89.10	9.55	19.08	31.81
10/27/2021	22.68	92.98	9.96	19.87	33.15
10/28/2021	24.69	92.24	9.96	19.94	33.22
10/29/2021	27.29	92.31	10.00	20.00	33.30
10/30/2021	17.56	79.86	8.59	17.24	28.66
10/31/2021	16.39	78.68	8.39	16.85	28.06
Monthly Avg/Sum*:	970.88 *	2,803.29 *	302.57 *	606.00 *	1,009.75 *
Daily Min:	16.39	59.18	5.39	10.79	18.03
Daily Max:	70.65	120.31	13.02	26.07	43.46
Oct 2021 - Oct 2021	970.88	2,803.29	302.57	606.00	1,009.75
QTD:	970.88 *	2,803.29 *	302.57 *	606.00 *	1,009.75 *
YTD 2021:	9,666.48 *	18,740.02 *	1,944.32 *	3,891.10 *	6,487.29 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:12 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
11/01/2021	28.41	99.20	10.77	21.49	35.84
11/02/2021	23.49	93.52	10.04	20.10	33.48
11/03/2021	27.27	98.14	10.55	21.10	35.20
11/04/2021	18.58	82.26	9.18	18.39	30.60
11/05/2021	23.32	91.25	9.83	19.78	32.95
11/06/2021	23.80	93.67	10.06	20.15	33.57
11/07/2021	18.76	81.39	9.16	18.28	30.51
11/08/2021	32.51	99.29	10.91	21.84	36.41
11/09/2021	20.76	89.36	9.60	19.14	31.91
11/10/2021	17.13	82.62	8.88	17.66	29.45
11/11/2021	33.97	92.96	10.08	20.18	33.60
11/12/2021	16.91	79.41	8.54	17.03	28.36
11/13/2021	26.38	94.87	10.31	20.61	34.33
11/14/2021	15.50	79.31	8.45	16.77	28.00
11/15/2021	20.13	82.35	8.90	17.84	29.67
11/16/2021	25.97	93.14	10.22	20.51	34.10
11/17/2021	30.31	91.61	10.59	21.22	35.34
11/18/2021	28.17	86.86	10.39	20.80	34.59
11/19/2021	79.61	67.97	8.00	16.01	26.64
11/20/2021	18.53	73.79	9.04	18.14	30.20
11/21/2021	28.32	83.94	10.32	20.62	34.40
11/22/2021	26.92	83.63	10.24	20.51	34.16
11/23/2021	17.37	71.45	8.63	17.31	28.84
11/24/2021	18.86	81.07	8.86	17.77	29.57
11/25/2021	21.62	80.43	8.75	17.56	29.23
11/26/2021	22.63	79.33	8.70	17.28	28.87
11/27/2021	22.88	82.60	9.02	18.05	30.05
11/28/2021	22.16	78.92	8.68	17.36	28.92
11/29/2021	27.54	88.61	9.58	19.12	31.89
11/30/2021	31.88	101.30	11.52	23.02	38.41
Monthly Avg/Sum*:	769.69 *	2,584.25 *	287.80 *	575.64 *	959.09 *
Daily Min:	15.50	67.97	8.00	16.01	26.64
Daily Max:	79.61	101.30	11.52	23.02	38.41
Oct 2021 - Nov 2021	1,740.57	5,387.54	590.37	1,181.64	1,968.84
QTD:	1,740.57 *	5,387.54 *	590.37 *	1,181.64 *	1,968.84 *
YTD 2021:	10,436.17 *	21,324.27 *	2,232.12 *	4,466.74 *	7,446.38 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:12 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
12/01/2021	27.64	87.64	9.68	19.36	32.27
12/02/2021	45.56	102.79	11.60	23.18	38.64
12/03/2021	40.38	104.30	11.24	22.49	37.45
12/04/2021	39.54	94.06	10.90	21.80	36.32
12/05/2021	31.56	94.48	10.98	22.01	36.62
12/06/2021	47.16	120.73	13.04	26.12	43.50
12/07/2021	45.31	117.03	12.86	25.72	42.85
12/08/2021	32.93	99.40	10.64	21.30	35.55
12/09/2021	27.55	90.20	9.76	19.53	32.53
12/10/2021	33.18	104.62	11.22	22.43	37.41
12/11/2021	28.48	95.52	10.25	20.54	34.20
12/12/2021	29.29	94.92	10.29	20.63	34.32
12/13/2021	39.59	112.51	12.17	24.32	40.56
12/14/2021	27.99	93.84	10.08	20.17	33.56
12/15/2021	29.09	103.71	11.26	22.56	37.57
12/16/2021	52.58	119.63	13.11	26.25	43.77
12/17/2021	50.49	109.96	11.94	23.87	39.86
12/18/2021	49.72	108.92	12.07	24.19	40.30
12/19/2021	45.78	101.63	12.00	23.99	40.01
12/20/2021	45.18	121.48	13.79	27.62	46.05
12/21/2021	57.28	131.55	14.32	28.59	47.65
12/22/2021	50.49	110.20	11.96	24.02	39.94
12/23/2021	20.42	80.10	8.80	17.64	29.37
12/24/2021	19.18	79.17	8.65	17.31	28.84
12/25/2021	19.43	80.13	8.66	17.41	28.96
12/26/2021	25.14	87.08	9.49	19.04	31.70
12/27/2021	48.45	116.39	12.51	25.06	41.73
12/28/2021	26.27	91.78	9.98	19.98	33.30
12/29/2021	25.32	90.79	9.98	20.01	33.32
12/30/2021	50.85	105.13	11.55	23.22	38.63
12/31/2021	25.48	86.45	9.70	19.49	32.39
Monthly Avg/Sum*:	1,137.31 *	3,136.14 *	344.48 *	689.85 *	1,149.17 *
Daily Min:	19.18	79.17	8.65	17.31	28.84
Daily Max:	57.28	131.55	14.32	28.59	47.65
Oct 2021 - Dec 2021	2,877.88	8,523.68	934.85	1,871.49	3,118.01
QTD:	2,877.88 *	8,523.68 *	934.85 *	1,871.49 *	3,118.01 *
YTD 2021:	11,573.48 *	24,460.41 *	2,576.60 *	5,156.59 *	8,595.55 *

AQ-63

AQ-63 The Total Facility Emissions shall not exceed the following quarterly emissions rates.

POLLUTANT	Q1 (LBS)	Q2 (LBS)	Q3 (LBS)	Q4 (LBS)	TONS/YEAR
NOX	15546	13412	17646	15572	31.09
CO	27121	33872	28515	30202	59.86
VOC	5832	7455	6672	6890	13.42
PM-10	17854	15513	19378	19158	35.95
SO2	3400	2893	3709	3663	6.83

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6

Replace the dates with the ones you need

10/1/2021 0:00
12/31/2021 0:00

1D

TOWER AVG.

519-AIT-9504-1

3101

10/1/21 0:00	3356.3
10/2/21 0:00	3484.5
10/3/21 0:00	3190.3
10/4/21 0:00	3598.1
10/5/21 0:00	3328.6
10/6/21 0:00	3771.1
10/7/21 0:00	3092.6
10/8/21 0:00	2826.3
10/9/21 0:00	3324.1
10/10/21 0:00	3470.6
10/11/21 0:00	3660.6
10/12/21 0:00	3193.1
10/13/21 0:00	3454.3
10/14/21 0:00	3216.1
10/15/21 0:00	3436.9
10/16/21 0:00	3701.2
10/17/21 0:00	3542.7
10/18/21 0:00	3600.4
10/19/21 0:00	3073.0
10/20/21 0:00	2698.4
10/21/21 0:00	1876.6
10/22/21 0:00	2388.4
10/23/21 0:00	2441.6
10/24/21 0:00	2434.7
10/25/21 0:00	2303.8
10/26/21 0:00	2745.8
10/27/21 0:00	2456.4
10/28/21 0:00	2594.6
10/29/21 0:00	2753.3
10/30/21 0:00	2520.7
10/31/21 0:00	3033.7
11/1/21 0:00	2605.9
11/2/21 0:00	2676.6
11/3/21 0:00	2989.7
11/4/21 0:00	2703.3
11/5/21 0:00	3050.8
11/6/21 0:00	2798.5
11/7/21 0:00	2914.1
11/8/21 0:00	3248.3
11/9/21 0:00	3157.5
11/10/21 0:00	3486.7
11/11/21 0:00	3294.9
11/12/21 0:00	3075.8
11/13/21 0:00	3469.7
11/14/21 0:00	3256.6
11/15/21 0:00	3285.8
11/16/21 0:00	3207.8
11/17/21 0:00	2992.7
11/18/21 0:00	3543.6

11/19/21 0:00	3043.7
11/20/21 0:00	3108.1
11/21/21 0:00	2912.3
11/22/21 0:00	3013.0
11/23/21 0:00	3551.4
11/24/21 0:00	3184.5
11/25/21 0:00	3470.5
11/26/21 0:00	2726.0
11/27/21 0:00	3242.7
11/28/21 0:00	3670.0
11/29/21 0:00	3303.4
11/30/21 0:00	3120.1
12/1/21 0:00	3374.5
12/2/21 0:00	3067.6
12/3/21 0:00	3273.9
12/4/21 0:00	2819.0
12/5/21 0:00	2964.8
12/6/21 0:00	2997.2
12/7/21 0:00	3117.3
12/8/21 0:00	3052.6
12/9/21 0:00	3274.9
12/10/21 0:00	3317.5
12/11/21 0:00	3162.5
12/12/21 0:00	3622.3
12/13/21 0:00	3442.1
12/14/21 0:00	3330.8
12/15/21 0:00	3244.1
12/16/21 0:00	3326.2
12/17/21 0:00	3317.4
12/18/21 0:00	3477.7
12/19/21 0:00	2867.9
12/20/21 0:00	3489.3
12/21/21 0:00	2841.5
12/22/21 0:00	3643.2
12/23/21 0:00	3141.6
12/24/21 0:00	3502.0
12/25/21 0:00	2831.6
12/26/21 0:00	2375.9
12/27/21 0:00	2457.7
12/28/21 0:00	2463.4
12/29/21 0:00	2648.4

Resize to show all values

ROSEVILLE ENERGY PARK COOLING TOWER EMISSIONS

POLLUTANT	LBS PER DAY	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4
PM-10	16.3	1471	1487	1504	1504

Whereas compliance with the PM-10 emission limit shall be demonstrated as;
Cooling tower recirculation rate * total dissolved solids of blowdown * design drift rate

<u>Circ pump flow rate</u>	53814	Gallons per minute
	* 8.33	Pounds per gallon
	* 1440	Minutes per day
	64,550,969	Pounds per day

<u>Total dissolved solids</u>	3101	Average daily conductivity umhos
	0.00000064	Conversion to TDS ppm
	0.00198464	

<u>Design drift rate</u>	0.005%
--------------------------	---------------

PM-10 pounds per day	6.41
----------------------	-------------

92	Days in quarter
----	-----------------

PM-10 pounds this quarter	589	4Q21
---------------------------	------------	-------------

fill only these

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:12 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
10/01/2021	31.14	95.43	10.69	21.43	35.67
10/02/2021	31.78	97.53	10.92	21.89	36.49
10/03/2021	34.65	95.47	10.47	20.87	34.84
10/04/2021	42.63	120.31	13.02	26.07	43.46
10/05/2021	27.06	91.83	10.30	20.63	34.39
10/06/2021	28.47	98.15	10.75	21.54	35.87
10/07/2021	24.82	95.33	10.40	20.78	34.59
10/08/2021	22.44	90.56	9.84	19.69	32.78
10/09/2021	19.16	83.76	9.05	18.14	30.18
10/10/2021	20.10	83.78	9.06	18.15	30.18
10/11/2021	35.42	115.46	12.41	24.80	41.36
10/12/2021	32.76	113.00	12.21	24.46	40.75
10/13/2021	35.65	115.97	12.52	25.08	41.77
10/14/2021	43.28	95.07	9.98	19.96	33.28
10/15/2021	41.50	67.51	7.22	14.53	24.27
10/16/2021	39.83	68.11	7.32	14.70	24.53
10/17/2021	39.39	68.86	7.44	14.91	24.88
10/18/2021	40.80	63.27	6.79	13.74	22.82
10/19/2021	37.83	60.82	6.59	13.21	22.03
10/20/2021	70.65	59.18	5.39	10.79	18.03
10/21/2021	32.60	107.48	11.65	23.38	38.93
10/22/2021	24.50	92.09	9.95	19.95	33.24
10/23/2021	28.55	99.92	10.73	21.54	35.88
10/24/2021	28.76	103.19	11.05	22.11	36.82
10/25/2021	25.98	96.04	10.37	20.67	34.51
10/26/2021	22.52	89.10	9.55	19.08	31.81
10/27/2021	22.68	92.98	9.96	19.87	33.15
10/28/2021	24.69	92.24	9.96	19.94	33.22
10/29/2021	27.29	92.31	10.00	20.00	33.30
10/30/2021	17.56	79.86	8.59	17.24	28.66
10/31/2021	16.39	78.68	8.39	16.85	28.06
Monthly Avg/Sum*:	970.88 *	2,803.29 *	302.57 *	606.00 *	1,009.75 *
Daily Min:	16.39	59.18	5.39	10.79	18.03
Daily Max:	70.65	120.31	13.02	26.07	43.46
Oct 2021 - Oct 2021	970.88	2,803.29	302.57	606.00	1,009.75
QTD:	970.88 *	2,803.29 *	302.57 *	606.00 *	1,009.75 *
YTD 2021:	9,666.48 *	18,740.02 *	1,944.32 *	3,891.10 *	6,487.29 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2021 00:00 **To:** 12/31/2021 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/04/2022 09:12 **Location:** Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
11/01/2021	28.41	99.20	10.77	21.49	35.84
11/02/2021	23.49	93.52	10.04	20.10	33.48
11/03/2021	27.27	98.14	10.55	21.10	35.20
11/04/2021	18.58	82.26	9.18	18.39	30.60
11/05/2021	23.32	91.25	9.83	19.78	32.95
11/06/2021	23.80	93.67	10.06	20.15	33.57
11/07/2021	18.76	81.39	9.16	18.28	30.51
11/08/2021	32.51	99.29	10.91	21.84	36.41
11/09/2021	20.76	89.36	9.60	19.14	31.91
11/10/2021	17.13	82.62	8.88	17.66	29.45
11/11/2021	33.97	92.96	10.08	20.18	33.60
11/12/2021	16.91	79.41	8.54	17.03	28.36
11/13/2021	26.38	94.87	10.31	20.61	34.33
11/14/2021	15.50	79.31	8.45	16.77	28.00
11/15/2021	20.13	82.35	8.90	17.84	29.67
11/16/2021	25.97	93.14	10.22	20.51	34.10
11/17/2021	30.31	91.61	10.59	21.22	35.34
11/18/2021	28.17	86.86	10.39	20.80	34.59
11/19/2021	79.61	67.97	8.00	16.01	26.64
11/20/2021	18.53	73.79	9.04	18.14	30.20
11/21/2021	28.32	83.94	10.32	20.62	34.40
11/22/2021	26.92	83.63	10.24	20.51	34.16
11/23/2021	17.37	71.45	8.63	17.31	28.84
11/24/2021	18.86	81.07	8.86	17.77	29.57
11/25/2021	21.62	80.43	8.75	17.56	29.23
11/26/2021	22.63	79.33	8.70	17.28	28.87
11/27/2021	22.88	82.60	9.02	18.05	30.05
11/28/2021	22.16	78.92	8.68	17.36	28.92
11/29/2021	27.54	88.61	9.58	19.12	31.89
11/30/2021	31.88	101.30	11.52	23.02	38.41
Monthly Avg/Sum*:	769.69 *	2,584.25 *	287.80 *	575.64 *	959.09 *
Daily Min:	15.50	67.97	8.00	16.01	26.64
Daily Max:	79.61	101.30	11.52	23.02	38.41
Oct 2021 - Nov 2021	1,740.57	5,387.54	590.37	1,181.64	1,968.84
QTD:	1,740.57 *	5,387.54 *	590.37 *	1,181.64 *	1,968.84 *
YTD 2021:	10,436.17 *	21,324.27 *	2,232.12 *	4,466.74 *	7,446.38 *

Monthly Summary By Day Report

Units CT1 and CT2



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:12 Location: Roseville, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
12/01/2021	27.64	87.64	9.68	19.36	32.27
12/02/2021	45.56	102.79	11.60	23.18	38.64
12/03/2021	40.38	104.30	11.24	22.49	37.45
12/04/2021	39.54	94.06	10.90	21.80	36.32
12/05/2021	31.56	94.48	10.98	22.01	36.62
12/06/2021	47.16	120.73	13.04	26.12	43.50
12/07/2021	45.31	117.03	12.86	25.72	42.85
12/08/2021	32.93	99.40	10.64	21.30	35.55
12/09/2021	27.55	90.20	9.76	19.53	32.53
12/10/2021	33.18	104.62	11.22	22.43	37.41
12/11/2021	28.48	95.52	10.25	20.54	34.20
12/12/2021	29.29	94.92	10.29	20.63	34.32
12/13/2021	39.59	112.51	12.17	24.32	40.56
12/14/2021	27.99	93.84	10.08	20.17	33.56
12/15/2021	29.09	103.71	11.26	22.56	37.57
12/16/2021	52.58	119.63	13.11	26.25	43.77
12/17/2021	50.49	109.96	11.94	23.87	39.86
12/18/2021	49.72	108.92	12.07	24.19	40.30
12/19/2021	45.78	101.63	12.00	23.99	40.01
12/20/2021	45.18	121.48	13.79	27.62	46.05
12/21/2021	57.28	131.55	14.32	28.59	47.65
12/22/2021	50.49	110.20	11.96	24.02	39.94
12/23/2021	20.42	80.10	8.80	17.64	29.37
12/24/2021	19.18	79.17	8.65	17.31	28.84
12/25/2021	19.43	80.13	8.66	17.41	28.96
12/26/2021	25.14	87.08	9.49	19.04	31.70
12/27/2021	48.45	116.39	12.51	25.06	41.73
12/28/2021	26.27	91.78	9.98	19.98	33.30
12/29/2021	25.32	90.79	9.98	20.01	33.32
12/30/2021	50.85	105.13	11.55	23.22	38.63
12/31/2021	25.48	86.45	9.70	19.49	32.39
Monthly Avg/Sum*:	1,137.31 *	3,136.14 *	344.48 *	689.85 *	1,149.17 *
Daily Min:	19.18	79.17	8.65	17.31	28.84
Daily Max:	57.28	131.55	14.32	28.59	47.65
Oct 2021 - Dec 2021	2,877.88	8,523.68	934.85	1,871.49	3,118.01
QTD:	2,877.88 *	8,523.68 *	934.85 *	1,871.49 *	3,118.01 *
YTD 2021:	11,573.48 *	24,460.41 *	2,576.60 *	5,156.59 *	8,595.55 *

Tons 12 Month Rolling Summary

CT1 and CT2 Combined



From: 10/01/2021 00:00 To: 12/31/2021 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/04/2022 09:58 Location: Roseville, CA

* = Excess Emission

Date	Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2	
	CO, Ton		NOx, Ton		PM10, Ton		SO2, Ton		VOC, Ton	
	1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)	
	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum
Oct 2021	0.4854	5.2065	1.4017	10.1188	0.3030	2.0868	0.1514	1.0431	0.5047	3.4782
Nov 2021	0.3852	5.2713	1.2922	10.6823	0.2880	2.2353	0.1440	1.1173	0.4796	3.7254
Dec 2021	0.5686	5.7875	1.5683	12.2309	0.3450	2.5791	0.1722	1.2889	0.5749	4.2983
Sum/Avg	5.7875		12.2309		2.5791		1.2889		4.2983	
Limit Value										

AQ68

AQ68 A water sample analysis of cooling tower water shall be performed within 180 days of initial operation and annually thereafter.

Verification: The Project owner shall submit to the CPM and the PCAPCD the initial and annual cooling tower water sample analysis for approval no later than 60 days following the date of test performance.

The Cooling Tower Water Analysis was reported with the 2Q21 QAQR.

AQ-69

AQ-69 No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

In regards to AQ-69 of Roseville Energy Park's 4Q21 QAQR, there were no violations of PCAPCD's Rule 205 for nuisance.

AQ-70

AQ-70 PM-10 emission rates from the cooling tower shall not exceed the following limits

Cooling Tower Emissions Limitations					
Pollutant	Lbs/day	Quarter 1	Quarter 2	Quarter 3	Quarter 4
PM 10	16.3	1471	1487	1504	1504

Verification: the Project owner shall include all the necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly air Quality Report required in condition of Certification AQ-SC6.

Replace the dates with the ones you need

10/1/2021 0:00
12/31/2021 0:00

1D

TOWER AVG.

519-AIT-9504-1

3101

10/1/21 0:00	3356.3
10/2/21 0:00	3484.5
10/3/21 0:00	3190.3
10/4/21 0:00	3598.1
10/5/21 0:00	3328.6
10/6/21 0:00	3771.1
10/7/21 0:00	3092.6
10/8/21 0:00	2826.3
10/9/21 0:00	3324.1
10/10/21 0:00	3470.6
10/11/21 0:00	3660.6
10/12/21 0:00	3193.1
10/13/21 0:00	3454.3
10/14/21 0:00	3216.1
10/15/21 0:00	3436.9
10/16/21 0:00	3701.2
10/17/21 0:00	3542.7
10/18/21 0:00	3600.4
10/19/21 0:00	3073.0
10/20/21 0:00	2698.4
10/21/21 0:00	1876.6
10/22/21 0:00	2388.4
10/23/21 0:00	2441.6
10/24/21 0:00	2434.7
10/25/21 0:00	2303.8
10/26/21 0:00	2745.8
10/27/21 0:00	2456.4
10/28/21 0:00	2594.6
10/29/21 0:00	2753.3
10/30/21 0:00	2520.7
10/31/21 0:00	3033.7
11/1/21 0:00	2605.9
11/2/21 0:00	2676.6
11/3/21 0:00	2989.7
11/4/21 0:00	2703.3
11/5/21 0:00	3050.8
11/6/21 0:00	2798.5
11/7/21 0:00	2914.1
11/8/21 0:00	3248.3
11/9/21 0:00	3157.5
11/10/21 0:00	3486.7
11/11/21 0:00	3294.9
11/12/21 0:00	3075.8
11/13/21 0:00	3469.7
11/14/21 0:00	3256.6
11/15/21 0:00	3285.8
11/16/21 0:00	3207.8
11/17/21 0:00	2992.7
11/18/21 0:00	3543.6

11/19/21 0:00	3043.7
11/20/21 0:00	3108.1
11/21/21 0:00	2912.3
11/22/21 0:00	3013.0
11/23/21 0:00	3551.4
11/24/21 0:00	3184.5
11/25/21 0:00	3470.5
11/26/21 0:00	2726.0
11/27/21 0:00	3242.7
11/28/21 0:00	3670.0
11/29/21 0:00	3303.4
11/30/21 0:00	3120.1
12/1/21 0:00	3374.5
12/2/21 0:00	3067.6
12/3/21 0:00	3273.9
12/4/21 0:00	2819.0
12/5/21 0:00	2964.8
12/6/21 0:00	2997.2
12/7/21 0:00	3117.3
12/8/21 0:00	3052.6
12/9/21 0:00	3274.9
12/10/21 0:00	3317.5
12/11/21 0:00	3162.5
12/12/21 0:00	3622.3
12/13/21 0:00	3442.1
12/14/21 0:00	3330.8
12/15/21 0:00	3244.1
12/16/21 0:00	3326.2
12/17/21 0:00	3317.4
12/18/21 0:00	3477.7
12/19/21 0:00	2867.9
12/20/21 0:00	3489.3
12/21/21 0:00	2841.5
12/22/21 0:00	3643.2
12/23/21 0:00	3141.6
12/24/21 0:00	3502.0
12/25/21 0:00	2831.6
12/26/21 0:00	2375.9
12/27/21 0:00	2457.7
12/28/21 0:00	2463.4
12/29/21 0:00	2648.4

Resize to show all values

ROSEVILLE ENERGY PARK COOLING TOWER EMISSIONS

POLLUTANT	LBS PER DAY	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4
PM-10	16.3	1471	1487	1504	1504

Whereas compliance with the PM-10 emission limit shall be demonstrated as;
 Cooling tower recirculation rate * total dissolved solids of blowdown * design drift rate

<u>Circ pump flow rate</u>	53814	Gallons per minute
	* 8.33	Pounds per gallon
	* 1440	Minutes per day
	64,550,969	Pounds per day

<u>Total dissolved solids</u>	3101	Average daily conductivity umhos
	0.00000064	Conversion to TDS ppm
	0.00198464	

<u>Design drift rate</u>	0.005%
--------------------------	---------------

PM-10 pounds per day	6.41
----------------------	-------------

92	Days in quarter
----	-----------------

PM-10 pounds this quarter	589	4Q21
---------------------------	------------	-------------

fill only these

AQ-71

AQ-71 Compliance with the cooling tower PM-10 emission limit shall be demonstrated as follows: $PM-10 = \text{cooling water recirculation rate} * \text{total dissolved solids concentration in the blow down water} * \text{design drift rate}$.

Verification: the Project owner shall include all the necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly air Quality Report required in condition of Certification AQ-SC6.

Replace the dates with the ones you need

10/1/2021 0:00
12/31/2021 0:00

1D

TOWER AVG.

519-AIT-9504-1

3101

10/1/21 0:00	3356.3
10/2/21 0:00	3484.5
10/3/21 0:00	3190.3
10/4/21 0:00	3598.1
10/5/21 0:00	3328.6
10/6/21 0:00	3771.1
10/7/21 0:00	3092.6
10/8/21 0:00	2826.3
10/9/21 0:00	3324.1
10/10/21 0:00	3470.6
10/11/21 0:00	3660.6
10/12/21 0:00	3193.1
10/13/21 0:00	3454.3
10/14/21 0:00	3216.1
10/15/21 0:00	3436.9
10/16/21 0:00	3701.2
10/17/21 0:00	3542.7
10/18/21 0:00	3600.4
10/19/21 0:00	3073.0
10/20/21 0:00	2698.4
10/21/21 0:00	1876.6
10/22/21 0:00	2388.4
10/23/21 0:00	2441.6
10/24/21 0:00	2434.7
10/25/21 0:00	2303.8
10/26/21 0:00	2745.8
10/27/21 0:00	2456.4
10/28/21 0:00	2594.6
10/29/21 0:00	2753.3
10/30/21 0:00	2520.7
10/31/21 0:00	3033.7
11/1/21 0:00	2605.9
11/2/21 0:00	2676.6
11/3/21 0:00	2989.7
11/4/21 0:00	2703.3
11/5/21 0:00	3050.8
11/6/21 0:00	2798.5
11/7/21 0:00	2914.1
11/8/21 0:00	3248.3
11/9/21 0:00	3157.5
11/10/21 0:00	3486.7
11/11/21 0:00	3294.9
11/12/21 0:00	3075.8
11/13/21 0:00	3469.7
11/14/21 0:00	3256.6
11/15/21 0:00	3285.8
11/16/21 0:00	3207.8
11/17/21 0:00	2992.7
11/18/21 0:00	3543.6

11/19/21 0:00	3043.7
11/20/21 0:00	3108.1
11/21/21 0:00	2912.3
11/22/21 0:00	3013.0
11/23/21 0:00	3551.4
11/24/21 0:00	3184.5
11/25/21 0:00	3470.5
11/26/21 0:00	2726.0
11/27/21 0:00	3242.7
11/28/21 0:00	3670.0
11/29/21 0:00	3303.4
11/30/21 0:00	3120.1
12/1/21 0:00	3374.5
12/2/21 0:00	3067.6
12/3/21 0:00	3273.9
12/4/21 0:00	2819.0
12/5/21 0:00	2964.8
12/6/21 0:00	2997.2
12/7/21 0:00	3117.3
12/8/21 0:00	3052.6
12/9/21 0:00	3274.9
12/10/21 0:00	3317.5
12/11/21 0:00	3162.5
12/12/21 0:00	3622.3
12/13/21 0:00	3442.1
12/14/21 0:00	3330.8
12/15/21 0:00	3244.1
12/16/21 0:00	3326.2
12/17/21 0:00	3317.4
12/18/21 0:00	3477.7
12/19/21 0:00	2867.9
12/20/21 0:00	3489.3
12/21/21 0:00	2841.5
12/22/21 0:00	3643.2
12/23/21 0:00	3141.6
12/24/21 0:00	3502.0
12/25/21 0:00	2831.6
12/26/21 0:00	2375.9
12/27/21 0:00	2457.7
12/28/21 0:00	2463.4
12/29/21 0:00	2648.4

Resize to show all values

ROSEVILLE ENERGY PARK COOLING TOWER EMISSIONS

POLLUTANT	LBS PER DAY	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4
PM-10	16.3	1471	1487	1504	1504

Whereas compliance with the PM-10 emission limit shall be demonstrated as;
Cooling tower recirculation rate * total dissolved solids of blowdown * design drift rate

<u>Circ pump flow rate</u>	53814	Gallons per minute
	* 8.33	Pounds per gallon
	* 1440	Minutes per day
	64,550,969	Pounds per day

<u>Total dissolved solids</u>	3101	Average daily conductivity umhos
	0.00000064	Conversion to TDS ppm
	0.00198464	

<u>Design drift rate</u>	0.005%
--------------------------	---------------

PM-10 pounds per day	6.41
----------------------	-------------

92	Days in quarter
----	-----------------

PM-10 pounds this quarter	589	4Q21
---------------------------	------------	-------------

fill only these

AQ-86

AQ-86 Operation for maintenance and testing of the emergency diesel engine and generator shall be limited to 50 hours per year.

Verification: The Project owner shall include all necessary operational data to demonstrate compliance with the limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

6 DATE	TECH	TIME START-STOP	RUNTIME TOTAL HRS.	RUNTIME YTD MINUTES
12/24/18	E.O.	13:37 - 14:07 Bi-Weekly Test	97	805
1/6/19	AAB	1241 - 1311 Bi-Weekly Test	97	30
1-20-19	Ry	0825 - 0555 Bi-Weekly Test	98	60
1-29-19	Ry	1013 - 1043 Bi-Weekly Test	98	90
2-17-19	Ry	1035 - 1105 Bi-Weekly Test	99	120
3-11-19	E.O.	0724 - 0730 OUTAGE / BLACK PLANT	99	126
4-29-19	ME	0920 - 0950 TEST / Warm oil for Spring	99	156
4/29/2019	ME	1202 - 1206 Post Maint Priming/TEST	99	160
7-18-19	RL	1311 - 1347 TEST-INTELLIGENT REPAIR	100	195
8-22-19	RL	DIESEL DELIVERY 16.0 GALS		
9-20-19	AS	1026 - 1029 TEST RUN	100	198
9-20-19	AS	1416 - 1421 TEST RUN	100	203
9-20-19	AS	1424 - 1434 TEST RUN	100	213
10-10-19	ME	1100 - 1124 TEST run / Trouble Shooting	100	237
10-10-19	ME	1134 - 1144 TEST run / Trouble Shooting	101	245
10-10-19	ME	1150 - 1158 TEST run / Trouble Shooting	101	253
10-10-19	ME	1206 - 1207 TEST run / Trouble Shooting	101	254
10-13-19	AAB	0942 - 0947 WEEKLY TEST RUN	101	259
10-27-19	Ry	Bi-Weekly Test	102	289
11-3-19	BP	Bi-Weekly Test - Failed	102	304
11-10-19	AAB	Bi-Weekly Test FAILED AFTER 5 MINS SHUTDOWN	102	309
11-24-19	ZHR	Bi-Weekly Test Run - Successful	103	339
12-8-19	AAB	Bi-Weekly Test Run	103	369
12-29-19	BP	Bi-Weekly Test 1439 - 1509	104	399
1/04/20	ZH	Bi-Weekly Test 14:16 - 14:49	104	33
1/6/20	BH	Troubleshooting with CEO / CAT 13:04	104	63
1/6/20	AS	1447 - 1453 TEST RUN	105	69
1/6/20	AS	1512 - 1518 TEST RUN	105	75
1/7/20	AS	1110 - 1112 TEST RUN	105	77
1/7/20	AS	1114 - 1127 TEST RUN	105	90
1/7/20	AS	1153 - 1309 TEST RUN	106	166
1/7/20	AS	1317 - 1330 TEST RUN	106	179
01-19-2020	Ry	1355 - 1425 Bi-Weekly Test	107	209
2-9-20	DWN	1038 - 1108 Bi-Weekly Test	107	239
2-11-2020	AAB	1140 - 1142 PLACER COUNTY TEST	107	241
7-25-2020	AAB	1304 - 1334 Bi-Weekly Test	108	271

DATE	TECH	TIME START S/D	RUNTIME TOTAL HRS.	RUNTIME 7 YTD minutes
8-26-2016	KDS	01:00 01:30	108	301
4-13-2020	RC	1538 - BLUEWATER TEST - 1610	109	333
10/4/20	DB	1323 - 1400 - Test Run	109	370
10/22/20	AS	DIESEL DELIVERY 64 GALS		
11/1/2020	KDS	13:01 13:31 Bi-Weekly Test	110	400
11/29/20	AS	1444 1514 BIWEEKLY TEST RUN	110	430
12-20-2020	AAB	1650 - 1720 Bi-Weekly Test Run	111	460
2021				
1-9-21	DWN	14:00 - 14:30 Bi-Weekly Test	111	30
2-3-21	L/A	Diesel Filled 35.5 gallons		60 AAB
3-28-2021	AAB	1319 - 1349 Bi-Weekly Test Run	112	60
4-25-2021	AAB	1320 - 1350 Bi-Weekly Test Run	112	90
5-23-2021	AAB	1435 - 1505 Bi-Weekly Test Run	113	120
6-14-2021	KDS	1034 - 1104 Bi-Weekly Test Run	113	150
6-28-2021	CD & POWER	10:50 - 11:00 ANN. SVC	114	160
6/20/2021	C/C	0952 - 0528 Bi-Weekly Test Run	114	196
8-19-21	ZH	1139 Bi-Weekly Test Run	115	229
9-01-2021	Ry	1338 Bi-Weekly Test Run ^{Amarel} / PCAPED	115	255
9-5-21	AS	1608 Bi-Weekly Test Run 1638	115	265
10-3-21	KDS	1405 Bi-Weekly Test Run 1435	116	285
10-30-21	ZHR	1319 Bi-Weekly Test Run	1349	116 325
11/21/21	DE	1045 Bi-Weekly Test Run	1115	117 355
12/24/21	DE	1354 Bi-Weekly Test Run	1424	117 385

AQ-87

AQ-87 Operation for other than maintenance and testing purposes shall be limited to involuntary interruptions of electrical power. Operation shall not exceed 24 hours without prior authorization by the Air Pollution Control Officer.

Verification: The Project owner shall include all necessary operational data to demonstrate compliance with the limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

Date	Time Start	Reason	Time Stop	Initials	Total Hours	VRD Hours
8/7/21	1519	Weekly Test Run	1549	ZKR	212.1	12.8
8-21-21	1131	Weekly Test Run	1201	JM	212.6	12.8
9-2-21	0902	Weekly Test Run	0932	LH	213.1	13.3
9-12-2021	1628	WEEKLY TEST RUN	1658	KAB	213.6	13.8
9-19-21	1150	Weekly Test Run	1220	DWN	214.1	14.8 *
9-25-21	1239	Weekly Test Run	1309	JM	214.6	15.3
10-3-21	1410	Weekly Test Run	1440	KRO	215.1	15.8
10-11-2021	1640	WEEKLY TEST RUN	1710	KAB	215.6	16.3
10-16-21	1307	Weekly Test Run	1330	JM	216.1	16.8
10-24-21	1553	WEEKLY TEST RUN	1623	RL	216.6	17.3
10-31-21	1351	Weekly Test Run	1421	KRO	217.1	17.8
11-7-2021	1354	WEEKLY TEST RUN	1424	KAB	217.6	18.3
11-14-2021	1444	WEEKLY TEST RUN	1514	KAB	218.1	18.8
11-21/21	1203	Weekly Test Run	1233	DE	218.6	19.3
11/24/21	09:46	Fill Diesel TANK	09:48	LH	80 gallons	
11/28/21	1347	Weekly Test Run	1417	DE	219.1	19.8
12/5/2021	1445	WEEKLY TEST RUN	1515	KAB	219.6	20.3
12-12-21	1150	Weekly Test Run	1220	DWN	220.1	20.8
12-19-21	1553	WEEKLY TEST RUN	1623	RL	220.6	21.3
12-26-21	1514	Weekly Test Run	1544	LH	221.1	21.8
1-2-2022	1547	WEEKLY TEST RUN	1617	KAB	221.6	22.3
2022 Starting Hours 221.1						
1-2-22	1547	Weekly Test Run	1617	KAB	221.6	0.5

2020: 199.3

AQ-88

AQ-88 The Sulfur content of the Diesel fuel used shall not exceed 15 ppm by weight.

Verification: The Project owner shall include a summary of diesel fuel purchase records showing amounts delivered, date delivered and fuel type with the Quarterly Air Quality Report as required in Condition of Certification AQ-SC6.



P.O. BOX 401
WEST SACRAMENTO, CA 95691-0401

01 Sacramento 916-371-2570	06 Williams 530-473-2811
03 Dixon 707-678-2061	09 Isleton 916-777-5546
04 Fairfield 707-428-6780	11 Marysville 530-743-4647
05 Stockton 209-455-8255	14 Lincoln 916-948-2179
08 Woodland 530-861-1200	

REMIT TO: P.O. BOX 401
WEST SACRAMENTO, CA 95691-0401
HAZARDOUS MATERIAL EMERGENCY
CALL 1-800-456-7745

Scan here to sign up for Online Bill Pay →



ACCOUNT: 23464 FOR 26628
INVOICE: 84369
WH: 11
DATE: 11-30-21



48.582967.S21

ROSEVILLE ENERGY PARK
CITY OF ROSEVILLE
5120 PHILLIP RD
ROSEVILLE, CA 95747

RAMOS OIL INC.
PO BOX 401
WEST SACRAMENTO, CA 95691-0401



DO NOT ATTACH WITH STAPLE OR PAPERCLIP
PLEASE DETACH AT PERFORATION AND RETURN UPPER PORTION WITH YOUR PAYMENT

CUST. PURCHASE ORDER NUMBER		SALESMAN		TERMS		DEL. ZONE		DUE DATE	
P10602308		JOSH GRAVES		Net 30 Days		0		12-30-21	
DELIVERY DATE		DRIVER		TRUCK NUMBER		TERMINAL		B/L NUMBER	
11-30-21		162 JOSE DUV		15154					
NO. OF PKGS	BULK OR SIZE	PRODUCT DELIVERED		ORDERED	DELIVERED	TAXES		PRICE	AMOUNT
		NA1993. RED DYED DIESEL COMBUSTIBLE, 3 PGIII #2D 15ppm sulfur (maxium) dyed Diesel fuel non taxable use only, penalty for taxable use.							
	BULK	DSL #2 DYED CARB ULTRA LOW		50	50	T		4.11000	205.50
		REC CA OIL SPILL TAX			50			0.00000	0.00
		L.U.S.T. TAX			50			0.00100	0.05
		FED OIL SPILL TAX			50			0.00214	0.11
		AB 32 DSL IMPLEMENTATION FEE			50			0.00400	0.20
1	EACH	LABOR		1	1	T		75.00000	75.00
		ENVIRONMENTAL SURCHARGE				T		0.00850	0.43
Ship to:						SALES TAX		→ 20.39	
ROSEVILLE ENERGY PARK #2 2155 NICHOLS RD ROCKLIN, CA 95677						TOTAL		→ 301.68	
CUSTOMER AGREES TO PAY FINANCE CHARGE ON PAST DUE BALANCE OF 1.5% PER MONTH OR THE MAXIMUM RATE ALLOWED IN CUSTOMER'S STATE OF RESIDENCE WHICHEVER IS LESS AND FURTHER AGREES TO PAY REASONABLE ATTORNEY'S FEES AND COSTS IF COLLECTION IS REQUIRED. VENUE FOR PURPOSES OF ENDORSEMENT OF THIS OBLIGATION SHALL BE YOLO COUNTY									
ALL CLAIMS FOR ENVIRONMENTAL DAMAGE DURING DELIVERY OF ANY RAMOS OIL PRODUCT MUST BE MADE WITHIN 15 DAYS FOLLOWING DELIVERY						ERRORS IN PRICE, EXTENSION AND ADDITION SUBJECT TO CORRECTION.			
DELIVERED BY (SIGNATURE IN FULL)		RECEIVED IN GOOD ORDER		TOTAL		→		301.68	
X		X							

AQ-89

AQ-89 Records of operation and maintenance shall be kept by the owner or Operator for a period of five years and shall be made available to the PCAPCD upon request. Information required for reporting to the PCAPCD includes, but is not limited to:

1. The hours of operation the engine was run for maintenance and testing;
2. The hours of operation the engine was run during interruption of electrical power; and
3. Records of the sulfur content of the diesel used.

VERIFICATION: The Project owner shall include these records as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

6 DATE	TECH	TIME START-STOP	RUNTIME TOTAL HRS.	RUNTIME YTD MINUTES
12/24/18	E.O.	13:37 - 14:07 Bi-Weekly Test	97	805
1/6/19	AAB	1241 - 1311 Bi-Weekly Test	97	30
1-20-19	Ry	0825 - 0555 Bi-Weekly Test	98	60
1-29-19	Ry	1013 - 1043 Bi-Weekly Test	98	90
2-17-19	Ry	1035 - 1105 Bi-Weekly Test	99	120
3-11-19	E.O.	0724 - 0730 OUTAGE / BLACK PLANT	99	126
4-29-19	ME	0920 - 0950 TEST / Warm oil for Spring	99	156
4/29/2019	ME	1202 - 1206 Post Maint Prime/Test	99	160
7-18-19	RL	1311 - 1347 TEST-INTELLIGENT REPAIR	100	195
8-22-19	RL	DIESEL DELIVERY 16.0 GALS		
9-20-19	AS	1026 - 1029 TEST RUN	100	198
9-20-19	AS	1416 - 1421 TEST RUN	100	203
9-20-19	AS	1424 - 1434 TEST RUN	100	213
10-10-19	ME	1100 - 1124 TEST run / Trouble Shooting	100	237
10-10-19	ME	1134 - 1144 TEST run / Trouble Shooting	101	245
10-10-19	ME	1150 - 1158 TEST run / Trouble Shooting	101	253
10-10-19	ME	1206 - 1207 TEST run / Trouble Shooting	101	254
10-13-19	AAB	0942 - 0947 WEEKLY TEST RUN	101	259
10-27-19	Ry	Bi-Weekly Test	102	289
11-3-19	BP	Bi-Weekly Test - Failed	102	304
11-10-19	AAB	Bi-Weekly Test FAILED AFTER 5 MINS SHUTDOWN	102	309
11-24-19	ZUR	Bi-Weekly Test Run - Successful	103	339
12-8-19	AAB	Bi-Weekly Test Run	103	369
12-29-19	BP	Bi-Weekly Test 1439 - 1509	104	399
1/04/20	ZH	Bi-Weekly Test 14:16 - 14:49	104	33
1/6/20	BH	Troubleshoot with CEO / CAT 13:04	104	63
1/6/20	AS	1447 - 1453 TEST RUN	105	69
1/6/20	AS	1512 - 1518 TEST RUN	105	75
1/7/20	AS	1110 - 1112 TEST RUN	105	77
1/7/20	AS	1114 - 1127 TEST RUN	105	90
1/7/20	AS	1153 - 1309 TEST RUN	106	166
1/7/20	AS	1317 - 1330 TEST RUN	106	179
01-19-2020	Ry	1355 - 1425 Bi-Weekly Test	107	209
2-9-20	DWN	1038 - 1108 Bi-Weekly Test	107	239
2-11-2020	AAB	1140 - 1142 PLACER COUNTY TEST	107	241
7-25-2020	AAB	1304 - 1334 Bi-Weekly Test	108	271

DATE	TECH	TIME START S/D	RUNTIME TOTAL HRS.	RUNTIME 7 YTD minutes
8-26-2016	KDS	01:00 01:30	108	301
4-13-2020	RC	1538 - BLUEWATER TEST - 1610	109	333
10/4/20	DB	1323 - 1400 - Test Run	109	370
10/22/20	AS	DIESEL DELIVERY 64 GALS		
11/1/2020	KDS	13:01 13:31 Bi-Weekly Test	110	400
11/29/20	AS	1444 1514 BIWEEKLY TEST RUN	110	430
12-20-2020	AAB	1650 - 1720 Bi-Weekly Test Run	111	460
2021				
1-9-21	DWN	14:00 - 14:30 Bi-Weekly Test	111	30
2-3-21	L/A	Diesel Filled 35.5 gallons		60 AAB
3-28-2021	AAB	1319 - 1349 Bi-Weekly Test Run	112	60
4-25-2021	AAB	1320 - 1350 Bi-Weekly Test Run	112	90
5-23-2021	AAB	1435 - 1505 Bi-Weekly Test Run	113	120
6-14-2021	KDS	1034 - 1104 Bi-Weekly Test Run	113	150
6-28-2021	CD & POWER	10:50 - 11:00 ANN. SVC	114	160
6/20/2021	C/C	0952 - 0528 Bi-Weekly Test Run	114	196
8-19-21	ZUR	1139 Bi-Weekly Test Run	115	229
9-01-2021	Ry	1338 Bi-Weekly Test Run ^{Amarel} / PEAPED	115	255
9-5-21	AS	1608 Bi-Weekly Test Run 1638	115	265
10-3-21	KDS	1405 Bi-Weekly Test Run 1435	116	285
10-30-21	ZUR	1319 Bi-Weekly Test Run	1349	116 325
11/21/21	DE	1045 Bi-Weekly Test Run	1115	117 355
12/24/21	DE	1354 Bi-Weekly Test Run	1424	117 385



P.O. BOX 401
WEST SACRAMENTO, CA 95691-0401

01 Sacramento 916-371-2570 06 Williams 530-473-2811
03 Dixon 707-678-2061 09 Isleton 916-777-5546
04 Fairfield 707-428-6780 11 Marysville 530-743-4647
05 Stockton 209-455-8255 14 Lincoln 916-545-2179
08 Woodland 530-861-1200

REMIT TO: P.O. BOX 401
WEST SACRAMENTO, CA 95691-0401
HAZARDOUS MATERIAL EMERGENCY
CALL 1-800-456-7745

Scan here to sign up for Online Bill Pay →



ACCOUNT: 23464 FOR 26628
INVOICE: 84369
WH: 11
DATE: 11-30-21



48.582967.S21

ROSEVILLE ENERGY PARK
CITY OF ROSEVILLE
5120 PHILLIP RD
ROSEVILLE, CA 95747

RAMOS OIL INC.
PO BOX 401
WEST SACRAMENTO, CA 95691-0401



DO NOT ATTACH WITH STAPLE OR PAPERCLIP
PLEASE DETACH AT PERFORATION AND RETURN UPPER PORTION WITH YOUR PAYMENT

CUST. PURCHASE ORDER NUMBER		SALESMAN		TERMS		DEL. ZONE		DUE DATE	
P10602308		JOSH GRAVES		Net 30 Days		0		12-30-21	
DELIVERY DATE		DRIVER		TRUCK NUMBER		TERMINAL		B/L NUMBER	
11-30-21		162 JOSE DUV		15154					
NO. OF PKGS	BULK OR SIZE	PRODUCT DELIVERED		ORDERED	DELIVERED	TAXES		PRICE	AMOUNT
		NA1993. RED DYED DIESEL COMBUSTIBLE, 3 PGIII #2D 15ppm sulfur (maxium) dyed Diesel fuel non taxable use only, penalty for taxable use.							
	BULK	DSL #2 DYED CARB ULTRA LOW		50	50	T		4.11000	205.50
		REC CA OIL SPILL TAX			50			0.00000	0.00
		L.U.S.T. TAX			50			0.00100	0.05
		FED OIL SPILL TAX			50			0.00214	0.11
		AB 32 DSL IMPLEMENTATION FEE			50			0.00400	0.20
1	EACH	LABOR		1	1	T		75.00000	75.00
		ENVIRONMENTAL SURCHARGE				T		0.00850	0.43
Ship to:				SALES TAX →				20.39	
ROSEVILLE ENERGY PARK #2 2155 NICHOLS RD ROCKLIN, CA 95677				TOTAL →				301.68	
CUSTOMER AGREES TO PAY FINANCE CHARGE ON PAST DUE BALANCE OF 1.5% PER MONTH OR THE MAXIMUM RATE ALLOWED IN CUSTOMER'S STATE OF RESIDENCE WHICHEVER IS LESS AND FURTHER AGREES TO PAY REASONABLE ATTORNEY'S FEES AND COSTS IF COLLECTION IS REQUIRED. VENUE FOR PURPOSES OF ENDORSEMENT OF THIS OBLIGATION SHALL BE YOLO COUNTY									
ALL CLAIMS FOR ENVIRONMENTAL DAMAGE DURING DELIVERY OF ANY RAMOS OIL PRODUCT MUST BE MADE WITHIN 15 DAYS FOLLOWING DELIVERY									
ERRORS IN PRICE, EXTENSION AND ADDITION SUBJECT TO CORRECTION.									
DELIVERED BY (SIGNATURE IN FULL) X				RECEIVED IN GOOD ORDER X				TOTAL → 301.68	

AQ-90

AQ-90 No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6.

In regards to AQ-90 of Roseville Energy Park's 4Q21 QAQR, there were no violations of PCAPCD's Rule 205 for nuisance.

AQ-91

AQ-91 Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited and is in violation of PCAPCD Rule 202, Visible Emissions.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6.

In regards to AQ-91 of Roseville Energy Park's 4Q21 QAQR, there were no violations of PCAPCD's Rule 202 for opacity from the diesel fire pump.

AQ-99

AQ-99 Operation for maintenance and testing of the emergency diesel engine and generator shall be limited to 50 hours per year.

Verification: The Project shall include all necessary operational data to demonstrate compliance with the limits provided as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

6 DATE	TECH	TIME START-STOP	RUNTIME TOTAL HRS.	RUNTIME YTD MINUTES
12/24/18	E.O.	13:37 - 14:07 Bi-Weekly Test	97	805
1/6/19	HAB	1241 - 1311 Bi-Weekly Test	97	30
1-20-19	Ry	0825 - 0555 Bi-Weekly Test	98	60
1-29-19	Ry	1013 - 1043 Bi-Weekly Test	98	90
2-17-19	Ry	1035 - 1105 Bi-Weekly Test	99	120
3-11-19	E.O.	0724 - 0730 OUTAGE / BLACK PLANT	99	126
4-29-19	ME	0920 - 0950 TEST / Warm oil for Spring	99	156
4/29/2019	ME	1202 - 1206 Post Maint Prime/Test	99	160
7-18-19	RL	1311 - 1347 TEST-INTELLIGENCE REPAIR	100	195
8-22-19	RL	DIESEL DELIVERY 16.0 GALS		
9-20-19	AS	1026 - 1029 TEST RUN	100	198
9-20-19	AS	1416 - 1421 TEST RUN	100	203
9-20-19	AS	1424 - 1434 TEST RUN	100	213
10-10-19	ME	1100 - 1124 TEST run / Trouble Shooting	100	237
10-10-19	ME	1134 - 1144 TEST run / Trouble Shooting	101	245
10-10-19	ME	1150 - 1158 TEST run / Trouble Shooting	101	253
10-10-19	ME	1206 - 1207 TEST run / Trouble Shooting	101	254
10-13-19	HAB	0942 - 0947 WEEKLY TEST RUN	101	259
10-27-19	Ry	Bi-Weekly Test	102	289
11-3-19	BP	Bi-Weekly Test - Failed	102	304
11-10-19	HAB	Bi-Weekly Test FAILED AFTER 5 MIN ^{SHUT DOWN}	102	309
11-24-19	ZHR	Bi-Weekly Test Run - Successful	103	339
12-8-19	HAB	Bi-Weekly Test Run	103	369
12-29-19	BP	Bi-Weekly Test 1439 - 1509	104	399
1/04/20	ZH	Bi-Weekly Test 1416 - 14:49	104	33
1/6/20	BH	Troubleshoot with CEO / CAT 13:04	104	63
1/6/20	AS	1447 - 1453 TEST RUN	105	69
1/6/20	AS	1512 - 1518 TEST RUN	105	75
1/7/20	AS	1110 - 1112 TEST RUN	105	77
1/7/20	AS	1114 - 1127 TEST RUN	105	90
1/7/20	AS	1153 - 1309 TEST RUN	106	166
1/7/20	AS	1317 - 1330 TEST RUN	106	179
01-19-2020	Ry	1355 - 1425 Bi-Weekly Test	107	209
2-9-20	DWN	1038 - 1108 Bi-Weekly Test	107	239
2-11-2020	HAB	1140 - 1142 PLACER COUNTY TEST	107	241
7-25-2020	HAB	1304 - 1334 Bi-Weekly Test	108	271

DATE	TECH	TIME START S/D	RUNTIME TOTAL HRS.	RUNTIME 7 YTD minutes
8-26-2016	KDS	01:00 01:30	108	301
4-13-2020	RC	1538 - BLUEWATER TEST - 1610	109	333
10/4/20	DB	1323 - 1400 - Test Run	109	370
10/22/20	AS	DIESEL DELIVERY 64 GALS		
11/1/2020	KDS	13:01 13:31 Bi-Weekly Test	110	400
11/29/20	AS	1444 1514 BIWEEKLY TEST RUN	110	430
12-20-2020	HAB	1650 - 1720 Bi-Weekly Test Run	111	460
2021				
1-9-21	DWN	14:00 - 14:30 Bi-Weekly Test	111	30
2-3-21	LIA	Diesel Filled 35.5 gallons		60 HAB
3-28-2021	HAB	1319 - 1349 Bi-Weekly Test Run	112	60
4-25-2021	HAB	1320 - 1350 Bi-Weekly Test Run	112	90
5-23-2021	HAB	1435 - 1505 Bi-Weekly Test Run	113	120
6-14-2021	KDS	1034 - 1104 Bi-Weekly Test Run	113	150
6-28-2021	CD & POWER	10:50 - 11:00 ANN. SVC	114	160
6/20/2021	CYC	0952 - 0528 Bi-Weekly Test Run	114	196
8-19-21	ZH	1139 Bi-Weekly Test Run	115	229
9-01-2021	Ry	1338 Bi-Weekly Test Run ^{Amarel} / PEAPED	115	255
9-5-21	AS	1608 Bi-Weekly Test Run 1638	115	265
10-3-21	KDS	1405 Bi-Weekly Test Run 1435	116	285
10-30-21	ZHR	1319 Bi-Weekly Test Run	1349	116 325
11/21/21	DE	1045 Bi-Weekly Test Run	1115	117 355
12/24/21	DE	1354 Bi-Weekly Test Run	1424	117 385

AQ-100

AQ-100 In regards to the Emergency diesel Generator; Operation for other than maintenance and testing purposes shall be limited to involuntary interruptions of electrical power. Operation shall not exceed 24 hours without prior authorization by the Air Pollution Control Officer.

6 DATE	TECH	TIME START-STOP	RUNTIME TOTAL HRS.	RUNTIME YTD MINUTES
12/24/18	E.O.	13:37 - 14:07 Bi-Weekly Test	97	805
1/6/19	AAB	1241 - 1311 Bi-Weekly Test	97	30
1-20-19	Ry	0825 - 0555 Bi-Weekly Test	98	60
1-29-19	Ry	1013 - 1043 Bi-Weekly Test	98	90
2-17-19	Ry	1035 - 1105 Bi-Weekly Test	99	120
3-11-19	E.O.	0724 - 0730 OUTAGE / BLACK PLANT	99	126
4-29-19	ME	0920 - 0950 TEST / Warm oil for Spring	99	156
4/29/2019	ME	1202 - 1206 Post Maint Priming/TEST	99	160
7-18-19	RL	1311 - 1347 TEST-INTELLIGENT REPAIR	100	195
8-22-19	RL	DIESEL DELIVERY 16.0 GALS		
9-20-19	AS	1026 - 1029 TEST RUN	100	198
9-20-19	AS	1416 - 1421 TEST RUN	100	203
9-20-19	AS	1424 - 1434 TEST RUN	100	213
10-10-19	ME	1100 - 1124 TEST run / Trouble Shooting	100	237
10-10-19	ME	1134 - 1144 TEST run / Trouble Shooting	101	245
10-10-19	ME	1150 - 1158 TEST run / Trouble Shooting	101	253
10-10-19	ME	1206 - 1207 TEST run / Trouble Shooting	101	254
10-13-19	AAB	0942 - 0947 WEEKLY TEST RUN	101	259
10-27-19	Ry	Bi-Weekly Test	102	289
11-3-19	BP	Bi-Weekly Test - Failed	102	304
11-10-19	AAB	BI-WEEKLY TEST FAILED AFTER 5 MINS SHUTDOWN	102	309
11-24-19	ZUR	Bi-Weekly Test Run - Successful	103	339
12-8-19	AAB	BI-WEEKLY TEST RUN	103	369
12-29-19	BP	Bi-weekly test 1439 - 1509	104	399
1/04/20	ZH	Bi-Weekly Test 14:16 - 14:49	104	33
1/6/20	BH	Troubleshoot with CEO / CAT 13:04	104	63
1/6/20	AS	1447 - 1453 TEST RUN	105	69
1/6/20	AS	1512 - 1518 TEST RUN	105	75
1/7/20	AS	1110 - 1112 TEST RUN	105	77
1/7/20	AS	1114 - 1127 TEST RUN	105	90
1/7/20	AS	1153 - 1309 TEST RUN	106	166
1/7/20	AS	1317 - 1330 TEST RUN	106	179
01-19-2020	Ry	1355 - 1425 Bi-Weekly Test	107	209
2-9-20	DWN	1038 - 1108 Bi-Weekly Test	107	239
2-11-2020	AAB	1140 - 1142 PLACER COUNTY TEST	107	241
7-25-2020	AAB	1304 - 1334 BI-WEEKLY TEST	108	271

DATE	TECH	TIME START S/D	RUNTIME TOTAL HRS.	RUNTIME 7 YTD minutes
8-26-2016	KDS	01:00 01:30	108	301
4-13-2020	RC	1538 - BLUEWATER TEST - 1610	109	333
10/4/20	DB	1323 - 1400 - Test Run	109	370
10/22/20	AS	DIESEL DELIVERY 64 GALS		
11/1/2020	KDS	13:01 13:31 Bi-Weekly test	110	400
11/29/20	AS	1444 1514 BIWEEKLY TEST RUN	110	430
12-20-2020	AAB	1650 - 1720 BI-WEEKLY TEST RUN 111	111	460
2021				
1-9-21	DWN	14:00 - 14:30 Bi-Weekly Test	111	30
2-3-21	LIA	Diesel Filled 35.5 gallons		60 AAB
3-28-2021	AAB	1319 - 1349 BI-WEEKLY TEST RUN	112	60
4-25-2021	AAB	1320 - 1350 BI-WEEKLY TEST RUN	112	90
5-23-2021	AAB	1435 - 1505 BI-WEEKLY TEST RUN	113	120
6-14-2021	KDS	1034 - 1104 Bi-Weekly Test Run	113	150
6-28-2021	CD & POWER	10:50 - 11:00 ANN. SVC	114	160
6/20/2021	CYC	0952 - 0528 Bi-Weekly Test Run	114	196
8-19-21	ZUR	1139 Bi-Weekly Test Run	115	229
9-01-2021	Ry	1338 Bi-Weekly test Run ^{Amarel} / PCAPED	115	255
9-5-21	AS	1608 BI-WEEKLY TEST RUN 1638	115	265
10-3-21	KDS	1405 Bi-Weekly Test Run 1435	116	285
10-30-21	ZUR	1319 Bi-Weekly Test Run	1349	116 325
11/21/21	DE	1045 BI-WEEKLY TEST RUN	1115	117 355
12/24/21	DE	1354 BI-WEEKLY TEST RUN	1424	117 385

AQ-101

AQ-101 The sulfur content of the diesel used shall not exceed 15ppm by weight

Verification: The Project owner shall include a summary of diesel fuel purchase records showing amounts delivered, date delivered and fuel type with the Quarterly Air Quality Report in Condition of Certification AQ-SC6



P.O. BOX 401
WEST SACRAMENTO, CA 95691-0401

01 Sacramento 916-371-2570 06 Williams 530-473-2811
03 Dixon 707-678-2061 09 Isleton 916-777-5546
04 Fairfield 707-428-6780 11 Marysville 530-743-4647
05 Stockton 209-455-8255 14 Lincoln 916-545-2179
08 Woodland 530-861-1200

REMIT TO: P.O. BOX 401
WEST SACRAMENTO, CA 95691-0401
HAZARDOUS MATERIAL EMERGENCY
CALL 1-800-456-7745

Scan here to sign up for Online Bill Pay →



ACCOUNT: 23464 FOR 26628
INVOICE: 84369
WH: 11
DATE: 11-30-21



48.582967.S21

ROSEVILLE ENERGY PARK
CITY OF ROSEVILLE
5120 PHILLIP RD
ROSEVILLE, CA 95747

RAMOS OIL INC.
PO BOX 401
WEST SACRAMENTO, CA 95691-0401



DO NOT ATTACH WITH STAPLE OR PAPERCLIP
PLEASE DETACH AT PERFORATION AND RETURN UPPER PORTION WITH YOUR PAYMENT

CUST. PURCHASE ORDER NUMBER		SALESMAN		TERMS		DEL. ZONE		DUE DATE	
P10602308		JOSH GRAVES		Net 30 Days		0		12-30-21	
DELIVERY DATE		DRIVER		TRUCK NUMBER		TERMINAL		B/L NUMBER	
11-30-21		162 JOSE DUV		15154					
NO. OF PKGS	BULK OR SIZE	PRODUCT DELIVERED	ORDERED	DELIVERED	TAXES		PRICE	AMOUNT	
		NA1993. RED DYED DIESEL COMBUSTIBLE, 3 PGIII #2D 15ppm sulfur (maxium) dyed Diesel fuel non taxable use only, penalty for taxable use.							
	BULK	DSL #2 DYED CARB ULTRA LOW	50	50		T	4.11000	205.50	
		REC CA OIL SPILL TAX		50			0.00000	0.00	
		L.U.S.T. TAX		50			0.00100	0.05	
		FED OIL SPILL TAX		50			0.00214	0.11	
		AB 32 DSL IMPLEMENTATION FEE		50			0.00400	0.20	
1	EACH	LABOR	1	1		T	75.00000	75.00	
		ENVIRONMENTAL SURCHARGE				T	0.00850	0.43	
Ship to: ROSEVILLE ENERGY PARK #2 2155 NICHOLS RD ROCKLIN, CA 95677					SALES TAX →			20.39	
					TOTAL →			301.68	
CUSTOMER AGREES TO PAY FINANCE CHARGE ON PAST DUE BALANCE OF 1.5% PER MONTH OR THE MAXIMUM RATE ALLOWED IN CUSTOMER'S STATE OF RESIDENCE WHICHEVER IS LESS AND FURTHER AGREES TO PAY REASONABLE ATTORNEY'S FEES AND COSTS IF COLLECTION IS REQUIRED. VENUE FOR PURPOSES OF ENDORSEMENT OF THIS OBLIGATION SHALL BE YOLO COUNTY									
ALL CLAIMS FOR ENVIRONMENTAL DAMAGE DURING DELIVERY OF ANY RAMOS OIL PRODUCT MUST BE MADE WITHIN 15 DAYS FOLLOWING DELIVERY					ERRORS IN PRICE, EXTENSION AND ADDITION SUBJECT TO CORRECTION.				
DELIVERED BY (SIGNATURE IN FULL) X			RECEIVED IN GOOD ORDER X		TOTAL →			301.68	

AQ-102

AQ-102 Records of operation and maintenance shall be kept by the owner or operator for a period of five years and shall be made available to the PCAPCD by request. Information required for reporting to the PCAPCD includes, but is not limited to:

- A. Hours of operation the engine was run for maintenance and testing
- B. Hours of operation the engine was run during interruption of electrical power
- C. Records of sulfur content of the diesel fuel used

Verification: The Project owner shall include these records as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

6 DATE	TECH	TIME START-STOP	RUNTIME TOTAL HRS.	RUNTIME YTD MINUTES
12/24/18	E.O.	13:37 - 14:07 Bi-Weekly Test	97	805
1/6/19	HAB	1241 - 1311 Bi-Weekly Test	97	30
1-20-19	Ry	0825 - 0555 Bi-Weekly Test	98	60
1-29-19	Ry	1013 - 1043 Bi-Weekly Test	98	90
2-17-19	Ry	1035 - 1105 Bi-Weekly Test	99	120
3-11-19	E.O.	0724 - 0730 OUTAGE / BLACK PLANT	99	126
4-29-19	ME	0920 - 0950 TEST / Warm oil for Spring	99	156
4/29/2019	ME	1202 - 1206 Post Maint Prime/Test	99	160
7-18-19	RL	1311 - 1347 TEST-INTELLIGENCE REPAIR	100	195
8-22-19	RL	DIESEL DELIVERY 16.0 GALS		
9-20-19	AS	1026 - 1029 TEST RUN	100	198
9-20-19	AS	1416 - 1421 TEST RUN	100	203
9-20-19	AS	1424 - 1434 TEST RUN	100	213
10-10-19	ME	1100 - 1124 TEST run / Trouble Shooting	100	237
10-10-19	ME	1134 - 1144 TEST run / Trouble Shooting	101	245
10-10-19	ME	1150 - 1158 TEST run / Trouble Shooting	101	253
10-10-19	ME	1206 - 1207 TEST run / Trouble Shooting	101	254
10-13-19	HAB	0942 - 0947 WEEKLY TEST RUN	101	259
10-27-19	Ry	Bi-Weekly Test	102	289
11-3-19	BP	Bi-Weekly Test - Failed	102	304
11-10-19	HAB	Bi-Weekly Test FAILED AFTER 5 MIN ^{SHUT DOWN}	102	309
11-24-19	ZHR	Bi-Weekly Test Run - Successful	103	339
12-8-19	HAB	Bi-Weekly Test Run	103	369
12-29-19	BP	Bi-Weekly Test 1439 - 1509	104	399
1/04/20	ZH	Bi-Weekly Test 1416 - 14:49	104	33
1/6/20	BH	Troubleshoot with CEO / CAT 13:04	104	63
1/6/20	AS	1447 - 1453 TEST RUN	105	69
1/6/20	AS	1512 - 1518 TEST RUN	105	75
1/7/20	AS	1110 - 1112 TEST RUN	105	77
1/7/20	AS	1114 - 1127 TEST RUN	105	90
1/7/20	AS	1153 - 1309 TEST RUN	106	166
1/7/20	AS	1317 - 1330 TEST RUN	106	179
01-19-2020	Ry	1355 - 1425 Bi-Weekly Test	107	209
2-9-20	DWN	1038 - 1108 Bi-Weekly Test	107	239
2-11-2020	HAB	1140 - 1142 PLACER COUNTY TEST	107	241
7-25-2020	HAB	1304 - 1334 Bi-Weekly Test	108	271

DATE	TECH	TIME START S/D	RUNTIME TOTAL HRS.	RUNTIME 7 YTD minutes
8-26-2016	KD	01:00 01:30	108	301
4-13-2020	RC	1538 - BLUEWATER TEST - 1610	109	333
10/4/20	DB	1323 - 1400 - Test Run	109	370
10/22/20	AS	DIESEL DELIVERY 64 GALS		
11/1/2020	KD	13:01 13:31 Bi-Weekly Test	110	400
11/29/20	AS	1444 1514 BIWEEKLY TEST RUN	110	430
12-20-2020	HAB	1650 - 1720 Bi-Weekly Test Run	111	460
2021				
1-9-21	DWN	14:00 - 14:30 Bi-Weekly Test	111	30
2-3-21	L/A	Diesel Filled 35.5 gallons		60 HAB
3-28-2021	HAB	1319 - 1349 Bi-Weekly Test Run	112	60
4-25-2021	HAB	1320 - 1350 Bi-Weekly Test Run	112	90
5-23-2021	HAB	1435 - 1505 Bi-Weekly Test Run	113	120
6-14-2021	KRA	1034 - 1104 Bi-Weekly Test Run	113	150
6-28-2021	CD & POWER	10:50 - 11:00 ANN. SVC	114	160
6/20/2021	C/C	0952 - 0528 Bi-Weekly Test Run	114	196
8-19-21	ZH	1139 Bi-Weekly Test Run	115	229
9-01-2021	Ry	1338 Bi-Weekly Test Run ^{Amarel} / PEAPED	115	255
9-5-21	AS	1608 Bi-Weekly Test Run 1638	115	265
10-3-21	KD	1405 Bi-Weekly Test Run 1435	116	285
10-30-21	ZHR	1319 Bi-Weekly Test Run	1349	116 325
11/21/21	DE	1045 Bi-Weekly Test Run	1115	117 355
12/24/21	DE	1354 Bi-Weekly Test Run	1424	117 385



P.O. BOX 401
WEST SACRAMENTO, CA 95691-0401

01 Sacramento 916-371-2570 08 Williams 530-473-2811
03 Dixon 707-678-2061 09 Isleton 916-777-5546
04 Fairfield 707-428-6780 11 Marysville 530-743-4647
05 Stockton 209-455-8255 14 Lincoln 916-545-2179
06 Woodland 530-861-1200

REMIT TO: P.O. BOX 401
WEST SACRAMENTO, CA 95691-0401
HAZARDOUS MATERIAL EMERGENCY
CALL 1-800-456-7745

Scan here to sign up for Online Bill Pay →



ACCOUNT: 23464 FOR 26628
INVOICE: 84369
WH: 11
DATE: 11-30-21



48.582967.S21

ROSEVILLE ENERGY PARK
CITY OF ROSEVILLE
5120 PHILLIP RD
ROSEVILLE, CA 95747

RAMOS OIL INC.
PO BOX 401
WEST SACRAMENTO, CA 95691-0401



DO NOT ATTACH WITH STAPLE OR PAPERCLIP
PLEASE DETACH AT PERFORATION AND RETURN UPPER PORTION WITH YOUR PAYMENT

CUST. PURCHASE ORDER NUMBER		SALESMAN		TERMS		DEL. ZONE		DUE DATE	
P10602308		JOSH GRAVES		Net 30 Days		0		12-30-21	
DELIVERY DATE		DRIVER		TRUCK NUMBER		TERMINAL		B/L NUMBER	
11-30-21		162 JOSE DUV		15154					
NO. OF PKGS	BULK OR SIZE	PRODUCT DELIVERED	ORDERED	DELIVERED	TAXES		PRICE	AMOUNT	
		NA1993. RED DYED DIESEL COMBUSTIBLE, 3 PGIII #2D 15ppm sulfur (maxium) dyed Diesel fuel non taxable use only, penalty for taxable use.							
	BULK	DSL #2 DYED CARB ULTRA LOW	50	50		T	4.11000	205.50	
		REC CA OIL SPILL TAX		50			0.00000	0.00	
		L.U.S.T. TAX		50			0.00100	0.05	
		FED OIL SPILL TAX		50			0.00214	0.11	
		AB 32 DSL IMPLEMENTATION FEE		50			0.00400	0.20	
1	EACH	LABOR	1	1		T	75.00000	75.00	
		ENVIRONMENTAL SURCHARGE				T	0.00850	0.43	
Ship to: ROSEVILLE ENERGY PARK #2 2155 NICHOLS RD ROCKLIN, CA 95677					SALES TAX →			20.39	
					TOTAL →			301.68	
CUSTOMER AGREES TO PAY FINANCE CHARGE ON PAST DUE BALANCE OF 1.5% PER MONTH OR THE MAXIMUM RATE ALLOWED IN CUSTOMER'S STATE OF RESIDENCE WHICHEVER IS LESS AND FURTHER AGREES TO PAY REASONABLE ATTORNEY'S FEES AND COSTS IF COLLECTION IS REQUIRED. VENUE FOR PURPOSES OF ENDORSEMENT OF THIS OBLIGATION SHALL BE YOLO COUNTY									
ALL CLAIMS FOR ENVIRONMENTAL DAMAGE DURING DELIVERY OF ANY RAMOS OIL PRODUCT MUST BE MADE WITHIN 15 DAYS FOLLOWING DELIVERY					ERRORS IN PRICE, EXTENSION AND ADDITION SUBJECT TO CORRECTION.				
DELIVERED BY (SIGNATURE IN FULL) X			RECEIVED IN GOOD ORDER X		TOTAL →			301.68	

AQ-103

AQ-103 No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6.

In regards to AQ-103 of Roseville Energy Park's 4Q21 QAQR, there were no violations of PCAPCD's Rule 205 for nuisance.

AQ-104

AQ-104 Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited and is in violation of PCAPCD Rule 202, Visible Emissions.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite opacity complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

In regards to AQ-104 of Roseville Energy Park's 4Q21 QAQR, there were no violations of PCAPCD's Rule 202 for opacity from stack emissions of the emergency diesel generator.