

DOCKETED

Docket Number:	01-AFC-25C
Project Title:	Malburg Generating Station-Compliance
TN #:	242896
Document Title:	Malburg Generating Station Quarterly Compliance Report Q1 2022
Description:	N/A
Filer:	Elyse Engel
Organization:	Jacobs Engineering Group Inc.
Submitter Role:	Applicant
Submission Date:	4/29/2022 1:32:46 PM
Docketed Date:	4/29/2022



4305 Santa Fe Avenue, Vernon, California 90058
Telephone (323) 583-8811

April 29, 2022

Dr. Anwar Ali
Compliance Project Manager
Siting, Transmission and Environmental Protection Division
Compliance Monitoring and Enforcement Office
California Energy Commission
715 P Street
Sacramento, CA 95814
anwar.ali@energy.ca.gov

Subject: 2022 Q1 Compliance Report
January 1, 2022 through March 31, 2022
Malburg Generating Station (01-AFC-25C)

Dr. Ali,

Attached please find the Quarterly Compliance Report for the Malburg Generating Station (01-AFC-25C), covering the operational period of January 1, 2022 through March 31, 2022. This report addresses all quarterly requirements identified in the Final Commission Decision for the Malburg Generating Station (TN #28746), as most recently amended on June 20, 2019 by the Errata to Staff Analysis of Petition to Amend the Final Commission Decision (TN #228444).

If you have any questions or need more information, please contact Matt Richards, Utilities Operations Manager, at MRichards@cityofvernon.org or (323) 583-8811 x378.

Sincerely,


Rich Olsen
Assistant General Manager of Generation & Operations
City of Vernon, Public Utilities Department

Enclosure: MGS 2022 Q1 Compliance Report

Exclusively Industrial


Malburg Generating Station Quarterly Compliance Report (First Quarter 2022)

Submitted to
California Energy Commission

Submitted by
City of Vernon, Public Utilities Department

April 29, 2022

Document no: PPS0429221225SJC
Revision no: 0



Contents

Acronyms and Abbreviations.....	v
1. Introduction	1
1.1 Project Location and Description.....	1
1.2 Organization of the Quarterly Compliance Report	1
2. Required Quarterly Compliance Report Documentation.....	1

Appendices

A	MGS Emission Calculations
B	Cooling Tower Blowdown Reports
C	Operation Logs
D	Diesel Fuel Oil Purchase Records
E	Excess Emission Reports

Table

2-1	Required Quarterly Compliance Report Documentation	1
-----	--	---

Acronyms and Abbreviations

CEC	California Energy Commission
CEMS	continuous emissions monitoring system
CO	carbon monoxide
COC	Conditions of Certification
CTG	combustion turbine generator
DAHS	data acquisition and handling system
gr/scf	grains per standard cubic foot
HRSG	heat recovery steam generator
lb/day	pounds per day
lb/hr	pounds per hour
MGS	Malburg Generating Station
NH ₃	ammonia
NO _x	nitrogen oxides
PM ₁₀	particulate matter with an aerodynamic diameter less than or equal to 10 microns
PM _{2.5}	particulate matter with an aerodynamic diameter less than or equal to 2.5 microns
ppm	parts per million
ppmv	parts per million by volume
ppmw	parts per million by weight
QCR	Quarterly Compliance Report
SCAQMD	South Coast Air Quality Management District
SO _x	sulfur oxides
STG	steam turbine generator
TDS	total dissolved solids
VOC	volatile organic compound

1. Introduction

This Quarterly Compliance Report (QCR) has been prepared to meet the California Energy Commission's (CEC) quarterly reporting requirements for the Malburg Generating Station (MGS). This QCR fulfills various Conditions of Certification (COC) described in the CEC's Final Commission Decision for the MGS (TN #28746), as most recently amended on June 20, 2019 by the Errata to Staff Analysis of Petition to Amend the Final Commission Decision (TN #228444).

1.1 Project Location and Description

The MGS is located at 4963 S Soto Street in Vernon, California. The property is approximately 3.4 acres in size, located in an industrial land use area near the geographic center of metropolitan Los Angeles County. MGS consists of two Siemens SGT-800 frame type natural gas combustion turbine generators (CTGs), two heat recovery steam generators (HRSGs), a steam turbine generator (STG), a cooling tower, a diesel-fired emergency firewater pump, and support equipment.

The commissioning of MGS was completed in October 2005 and the power plant began commercial operation on October 17, 2005.

1.2 Organization of the Quarterly Compliance Report

A summary of the compliance demonstration for each applicable COC is provided in Section 2 and includes references to Appendices and Tables as appropriate.

2. Required Quarterly Compliance Report Documentation

COC requirements associated with this QCR are summarized in the table below.

Table 2-1. Required Quarterly Compliance Report Documentation

Condition of Certification	Response
AQ-C6	The weekly total dissolved solids (TDS) results for the first quarter of 2022 are provided in Appendix A, Table 2; the weekly sample reports collected for the same period are provided in Appendix B. Note that TDS was not sampled during the third week of January 2022 due to lack of sampler availability.
AQ-C7	Daily particulate matter with aerodynamic diameter less than or equal to 10 microns (PM ₁₀) emissions from cooling tower operation during the first quarter of 2022 are provided in Appendix A, Tables 3 through 5. As shown, emissions were below the specified limit of 6.2 pounds per day (lb/day).
AQ-C8	Testing times for the diesel-fired emergency firewater pump during the first quarter of 2022 are provided in Appendix C, Table 2. MGS refrained from testing the diesel-fired emergency firewater pump in the same hour the CTGs were either started or shutdown.
AQ-C9	The CTG startup and shutdown details for the first quarter of 2022, including the duration and date of occurrence, are provided in Appendix C, Table 1.
AQ-C11	All ammonia (NH ₃), nitrogen oxides (NO _x), sulfur oxides (SO _x), carbon monoxide (CO), PM ₁₀ , and volatile organic compound (VOC) emissions from MGS operation during the first quarter of 2022 are provided in Appendix A, Table 1.
AQ-2	Low sulfur diesel fuel was last purchased on March 24, 2021. The fuel purchase record is provided in Appendix D and demonstrates that the fuel does not contain sulfur compounds in excess of 15 parts per million by weight (ppmw).
AQ-3	See the response for COC AQ-2.

Malburg Generating Station Quarterly Compliance Report(First Quarter 2022)

Condition of Certification	Response
AQ-5	Monthly emissions of CO, PM ₁₀ , particulate matter with an aerodynamic diameter less than or equal to 2.5 microns (PM _{2.5}), VOC, and SO _x from CTG and duct burner operation during the first quarter of 2022 are presented in Appendix A, Tables 7 through 9. Fuel usage for each turbine-duct burner pair is provided in Appendix A, Table 6. As shown, emissions were below the monthly limits specified in Condition A63.4 of the site's Title V Permit.
AQ-6	See the response for COC AQ-C9.
AQ-9	See the response for COC AQ-C 11. Additionally, quarterly NO _x excess emission reports from the data acquisition and handling system (DAHS) are provided in Appendix E. As demonstrated in these reports, there were no incidents in which the maximum corrected NO _x emissions concentration for both CTGs exceeded the emission concentration limit of 2.0 parts per million by volume (ppmv). All continuous emissions monitoring system (CEMS) data for MGS' CTGs are stored electronically onsite.
AQ-10	See the response for COC AQ-C 11. Additionally, quarterly CO excess emission reports from the DAHS are provided in Appendix E. As demonstrated in these reports, there were no incidents in which the maximum corrected CO emissions concentration for both CTGs exceeded the emission concentration limit of 2.0 ppmv. All CEMS data for MGS' CTGs are stored electronically onsite.
AQ-11	See the response for COC AQ-C 11. Additionally, quarterly VOC excess emission reports from the DAHS are provided in Appendix E. As demonstrated in these reports, there were no incidents in which the maximum corrected VOC emissions concentration for both CTGs exceeded the emission concentration limit of 2.0 ppmv.
AQ-12	See the response for COC AQ-C 11. Additionally, compliance with the specified limit of 5 parts per million (ppm) is primarily demonstrated through annual source testing. The most recent NH ₃ compliance source test, performed on February 8 and 9, 2022 with results submitted to the CEC on March 24, 2022, indicated compliance with the emission limits for both CTGs (1.7 ppm for CTG 1 and 1.6 ppm for CTG 2). NH ₃ emissions are also calculated via the CEMS on an hourly basis and confirmed to comply with the NH ₃ concentration limit of 5 ppm. Note that MGS did experience an exceedance of this 5 ppm limit on March 18, 2022. Verbal notification to the South Coast Air Quality Management District (SCAQMD) was made on April 22, 2022. An excess emissions report will be filed with the SCAQMD by May 3, 2022, as required, and included with the 2 nd Quarter Quarterly Compliance Report.
AQ-13	See the response for COC AQ-C 11. Additionally, the most recent triennial compliance source test, performed in August 2019, indicated compliance with the Rule 475 particulate matter emission limits of 5 kilograms per hour (11 pounds per hour [lb/hr]) or 23 milligrams per cubic meter (0.01 grain per standard cubic foot [gr/scf]) for both CTGs (0.69 lb/hr and 0.0003 gr/scf for CTG1 and 1.15 lb/hr and 0.0005 gr/scf for CTG2).
AQ-14	See the response for COC AQ-2.
AQ-15	Quarterly hours of operation for the diesel-fired emergency firewater pump are provided in Appendix A, Table 10. As shown, the first quarter 2022 hours for maintenance and testing do not exceed 50 hours and the total operational hours do not exceed 200 hours.
AQ-27	See the response for COC AQ-5. As shown, fuel consumption per turbine-duct burner pair does not exceed the specified limit of 405 million cubic feet per month.
AQ-36	See the responses for COC AQ-5 and AQ-6.

Appendix A

MGS Emission Calculations



Malburg Generating Station
 Quarterly Compliance Report
 Appendix A, Table 1

Reporting Period: **Quarter 1 2022**

Table 1. Quarterly Emissions - January 1, 2022 through March 31, 2022

Source	Quarterly Emissions (lb/quarter)					
	NOx	CO	VOC	SOx	PM ₁₀ /PM _{2.5}	NH ₃
CTG 1 & Duct Burner	4,452	1,573	971	177	3,784	5,737
CTG 2 & Duct Burner	3,975	1,383	835	152	3,259	4,935
Cooling Tower	--	--	--	--	119	--
Diesel Firewater Pump	36.2	1.05	0.26	0.02	0.24	--
Total	8,464	2,957	1,806	329	7,162	10,672

**Malburg Generating Station
Quarterly Compliance Report
Appendix A, Table 2**

Reporting Period: Quarter 1 2022

Table 2. Cooling Tower Total Dissolved Solids (TDS) Sampling Results ^{1, 2}

Sampling Period		TDS (ppm)
Start Date	End Date	
12/26/2021	1/1/2022	4,480
1/2/2022	1/8/2022	4,240
1/9/2022	1/15/2022	4,170
1/16/2022	1/22/2022	4,170
1/23/2022	1/29/2022	4,170
1/30/2022	2/5/2022	4,120
2/6/2022	2/12/2022	4,180
2/13/2022	2/19/2022	3,840
2/20/2022	2/26/2022	3,830
2/27/2022	3/5/2022	4,050
3/6/2022	3/12/2022	3,960
3/13/2022	3/19/2022	3,980
3/20/2022	3/26/2022	4,090
3/27/2022	4/2/2022	4,140

¹ Sampling results taken from Positive Lab's Weekly Cooling Tower Blowdown Reports, as provided in Appendix B of the QCR.

² The sample to be collected the third week of January (1/16/22 - 1/22/22) was not collected due to lack of sampler availability. A letter from Positive Lab noting this is included in Appendix B of the QCR. Sample concentrations for this week were assumed to be an average of the weeks before and after.

**Malburg Generating Station
Quarterly Compliance Report
Appendix A, Table 3**

Reporting Period: January 2022

Cooling Tower Total Dissolved Solids (TDS) Sampling Results

Data Source: Positive Lab's Weekly Cooling Tower Blowdown Reports, as provided in Appendix B of the QCR

Sample Date	Period Start Date	End Date	TDS (ppm)
12/28/2021	12/26/2021	1/1/2022	4,480
1/5/2022	1/2/2022	1/8/2022	4,240
1/10/2022	1/9/2022	1/15/2022	4,170
N/A ¹	1/16/2022	1/22/2022	4,170
1/25/2022	1/23/2022	1/29/2022	4,170
2/2/2022	1/30/2022	2/5/2022	4,120

¹ The sample to be collected the third week of January (1/16/22 - 1/22/22) was not collected due to lack of sampler availability. A letter from Positive Lab noting this is included in Appendix B of the QCR. Sample concentrations for this week were assumed to be an average of the weeks before and after.

Methodology (per Condition of Certification [COC] AQ-C7)

PM_{10} Emissions (lb/day) = Circulation Rate (gal/day) x Density of Water (lb/gal) x Total Dissolved Solids (ppm) / 1,000,000 x Drift Factor (%) / 100 x Correction Factor

Constants

Parameter	Value
Circulation Rate per Pump (gal/min) ¹	13,500
Number of Pumps	2
Total Circulation Rate (gal/min)	27,000
Water Density	8.334
Drift Factor (%) ²	0.0005
Correction Factor (unitless) ³	0.2

¹ Source: M3-10 Main Circulating Water System P&ID.

² Per COC AQ-C4.

³ Source: SPX Cooling Technologies' Cooling Tower Drift Mass Distribution.

Cooling Tower Daily PM₁₀ Emissions

Date	Circulation Rate (gal/day) ¹	TDS (ppm)	PM ₁₀ Emissions (lb/day)	Above 6.2 lb/day PM ₁₀ Limit? ²
1/1/2022	38,880,000	4,480	1.45	No
1/2/2022	38,880,000	4,240	1.37	No
1/3/2022	38,880,000	4,240	1.37	No
1/4/2022	38,880,000	4,240	1.37	No
1/5/2022	38,880,000	4,240	1.37	No
1/6/2022	38,880,000	4,240	1.37	No
1/7/2022	38,880,000	4,240	1.37	No
1/8/2022	38,880,000	4,240	1.37	No
1/9/2022	38,880,000	4,170	1.35	No
1/10/2022	38,880,000	4,170	1.35	No
1/11/2022	38,880,000	4,170	1.35	No
1/12/2022	38,880,000	4,170	1.35	No
1/13/2022	38,880,000	4,170	1.35	No
1/14/2022	38,880,000	4,170	1.35	No
1/15/2022	38,880,000	4,170	1.35	No
1/16/2022	38,880,000	4,170	1.35	No
1/17/2022	38,880,000	4,170	1.35	No
1/18/2022	38,880,000	4,170	1.35	No
1/19/2022	38,880,000	4,170	1.35	No
1/20/2022	38,880,000	4,170	1.35	No
1/21/2022	38,880,000	4,170	1.35	No
1/22/2022	38,880,000	4,170	1.35	No
1/23/2022	38,880,000	4,170	1.35	No
1/24/2022	38,880,000	4,170	1.35	No
1/25/2022	38,880,000	4,170	1.35	No
1/26/2022	38,880,000	4,170	1.35	No
1/27/2022	38,880,000	4,170	1.35	No
1/28/2022	38,880,000	4,170	1.35	No
1/29/2022	38,880,000	4,170	1.35	No
1/30/2022	38,880,000	4,120	1.33	No
1/31/2022	38,880,000	4,120	1.33	No

¹ Maximum daily circulation rate conservatively used to estimate PM₁₀ emissions when the cooling tower is operated for any part of the day. Circulation rate is zero for days the cooling tower is not operated at all.

² Daily emissions limit established in COC AQ-C7.

**Malburg Generating Station
Quarterly Compliance Report
Appendix A, Table 4**

Reporting Period: **February 2022**

Cooling Tower Total Dissolved Solids (TDS) Sampling Results

Data Source: Positive Lab's Weekly Cooling Tower Blowdown Reports, as provided in Appendix B of the QCR

Sample Date	Period Start Date	End Date	TDS (ppm)
2/2/2022	1/30/2022	2/5/2022	4,120
2/7/2022	2/6/2022	2/12/2022	4,180
2/15/2022	2/13/2022	2/19/2022	3,840
2/22/2022	2/20/2022	2/26/2022	3,830
2/28/2022	2/27/2022	3/5/2022	4,050

Methodology (per Condition of Certification [COC] AQ-C7)

PM_{10} Emissions (lb/day) = Circulation Rate (gal/day) x Density of Water (lb/gal) x Total Dissolved Solids (ppm) / 1,000,000
x Drift Factor (%) / 100 x Correction Factor

Constants

Parameter	Value
Circulation Rate per Pump (gal/min) ¹	13,500
Number of Pumps	2
Total Circulation Rate (gal/min)	27,000
Water Density (lb/gal)	8.334
Drift Factor (%) ²	0.0005
Correction Factor (unitless) ³	0.2

¹ Source: M3-10 Main Circulating Water System P&ID.

² Per COC AQ-C4.

³ Source: SPX Cooling Technologies' Cooling Tower Drift Mass Distribution.

Cooling Tower Daily PM₁₀ Emissions

Date	Circulation Rate (gal/day) ¹	TDS (ppm)	PM ₁₀ Emissions (lb/day)	Above 6.2 lb/day PM ₁₀ Limit? ²
2/1/2022	38,880,000	4,120	1.33	No
2/2/2022	38,880,000	4,120	1.33	No
2/3/2022	38,880,000	4,120	1.33	No
2/4/2022	38,880,000	4,120	1.33	No
2/5/2022	38,880,000	4,120	1.33	No
2/6/2022	38,880,000	4,180	1.35	No
2/7/2022	38,880,000	4,180	1.35	No
2/8/2022	38,880,000	4,180	1.35	No
2/9/2022	38,880,000	4,180	1.35	No
2/10/2022	38,880,000	4,180	1.35	No
2/11/2022	38,880,000	4,180	1.35	No
2/12/2022	38,880,000	4,180	1.35	No
2/13/2022	38,880,000	3,840	1.24	No
2/14/2022	38,880,000	3,840	1.24	No
2/15/2022	38,880,000	3,840	1.24	No
2/16/2022	38,880,000	3,840	1.24	No
2/17/2022	38,880,000	3,840	1.24	No
2/18/2022	38,880,000	3,840	1.24	No
2/19/2022	38,880,000	3,840	1.24	No
2/20/2022	38,880,000	3,830	1.24	No
2/21/2022	38,880,000	3,830	1.24	No
2/22/2022	38,880,000	3,830	1.24	No
2/23/2022	38,880,000	3,830	1.24	No
2/24/2022	38,880,000	3,830	1.24	No
2/25/2022	38,880,000	3,830	1.24	No
2/26/2022	38,880,000	3,830	1.24	No
2/27/2022	38,880,000	4,050	1.31	No
2/28/2022	38,880,000	4,050	1.31	No

¹ Maximum daily circulation rate conservatively used to estimate PM₁₀ emissions when the cooling tower is operated for any part of the day. Circulation rate is zero for days the cooling tower is not operated at all.

² Daily emissions limit established in COC AQ-C7.

**Malburg Generating Station
Quarterly Compliance Report
Appendix A, Table 5**

Reporting Period: **March 2022**

Cooling Tower Total Dissolved Solids (TDS) Sampling Results

Data Source: Positive Lab's Weekly Cooling Tower Blowdown Reports, as provided in Appendix B of the QCR

Sample Date	Period Start Date	End Date	TDS (ppm)
2/28/2022	2/27/2022	3/5/2022	4,050
3/8/2022	3/6/2022	3/12/2022	3,960
3/14/2022	3/13/2022	3/19/2022	3,980
3/22/2022	3/20/2022	3/26/2022	4,090
3/28/2022	3/27/2022	4/2/2022	4,140

Methodology (per Condition of Certification [COC] AQ-C7)

PM_{10} Emissions (lb/day) = Circulation Rate (gal/day) x Density of Water (lb/gal) x Total Dissolved Solids (ppm) / 1,000,000 x Drift Factor (%) / 100 x Correction Factor

Constants

Parameter	Value
Circulation Rate per Pump (gal/min) ¹	13,500
Number of Pumps	2
Total Circulation Rate (gal/min)	27,000
Water Density (lb/gal)	8.334
Drift Factor (%) ²	0.0005
Correction Factor (unitless) ³	0.2

¹ Source: M3-10 Main Circulating Water System P&ID.

² Per COC AQ-C4.

³ Source: SPX Cooling Technologies' Cooling Tower Drift Mass Distribution.

Cooling Tower Daily PM₁₀ Emissions

Date	Circulation Rate (gal/day) ¹	TDS (ppm)	PM ₁₀ Emissions (lb/day)	Above 6.2 lb/day PM ₁₀ Limit? ²
3/1/2022	38,880,000	4,050	1.31	No
3/2/2022	38,880,000	4,050	1.31	No
3/3/2022	38,880,000	4,050	1.31	No
3/4/2022	38,880,000	4,050	1.31	No
3/5/2022	38,880,000	4,050	1.31	No
3/6/2022	38,880,000	3,960	1.28	No
3/7/2022	38,880,000	3,960	1.28	No
3/8/2022	38,880,000	3,960	1.28	No
3/9/2022	38,880,000	3,960	1.28	No
3/10/2022	38,880,000	3,960	1.28	No
3/11/2022	38,880,000	3,960	1.28	No
3/12/2022	38,880,000	3,960	1.28	No
3/13/2022	38,880,000	3,980	1.29	No
3/14/2022	38,880,000	3,980	1.29	No
3/15/2022	38,880,000	3,980	1.29	No
3/16/2022	38,880,000	3,980	1.29	No
3/17/2022	38,880,000	3,980	1.29	No
3/18/2022	38,880,000	3,980	1.29	No
3/19/2022	38,880,000	3,980	1.29	No
3/20/2022	38,880,000	4,090	1.33	No
3/21/2022	38,880,000	4,090	1.33	No
3/22/2022	38,880,000	4,090	1.33	No
3/23/2022	38,880,000	4,090	1.33	No
3/24/2022	38,880,000	4,090	1.33	No
3/25/2022	38,880,000	4,090	1.33	No
3/26/2022	38,880,000	4,090	1.33	No
3/27/2022	38,880,000	4,140	1.34	No
3/28/2022	38,880,000	4,140	1.34	No
3/29/2022	38,880,000	4,140	1.34	No
3/30/2022	38,880,000	4,140	1.34	No
3/31/2022	38,880,000	4,140	1.34	No

¹ Maximum daily circulation rate conservatively used to estimate PM₁₀ emissions when the cooling tower is operated for any part of the day. Circulation rate is zero for days the cooling tower is not operated at all.

² Daily emissions limit established in COC AQ-C7.

**Malburg Generating Station
Quarterly Compliance Report
Appendix A, Tables 6, 7, 8, & 9**

Reporting Period: **Quarter 1 2022**

Table 6. Monthly Turbine-Duct Burner Fuel Flow

Source	January	Above 405	February	Above 405	March	Above 405
	Fuel Flow (MMscf/month) ¹	MMscf/month Limit? ²	Fuel Flow (MMscf/month) ¹	MMscf/month Limit? ²	Fuel Flow (MMscf/month) ¹	MMscf/month Limit? ²
CTG 1	230		194		204	
CTG 1 Duct Burner	0.01		0.42		0.87	
Total CTG 1 & Duct Burner	230	No	194	No	204	No
CTG 2	194		185		163	
CTG 2 Duct Burner	0.02		0.31		0.00	
Total CTG 2 & Duct Burner	194	No	185	No	163	No

¹ Fuel flow data obtained from 'U1/U2_MonthlySummary_MassEmissionsAndFuel' and 'All_12MonthSummary_GasUsage' RegPerfect Reports.

² Monthly fuel flow limit is per Condition of Certification (COC) AQ-27.

Table 7. Monthly Emissions - January 2022

Source	Monthly Emissions (lb/month) ¹					
	NO _x ²	CO	VOC	SO _x	PM ₁₀ /PM _{2.5}	NH ₃ ³
CTG 1 & Duct Burner	1,591	537	355	65.0	1,386	2,097
CTG 2 & Duct Burner	1,409	528	299	54.4	1,168	1,768
Monthly Emission Limits ⁴	N/A	7,633	3,236	227	4,876	N/A
Exceeds Limit?	N/A	No	No	No	No	N/A

¹ Unless otherwise noted, monthly emissions data obtained from 'U1/U2_MonthlySummary_MassEmissionsAndFuel' RegPerfect Report.

² Monthly NO_x emissions are as submitted to SCAQMD, based on the 'U1_U2MonthlyRECLAIMNOxSummaryByDay' RegPerfect Report.

³ Monthly NH₃ emissions are calculated using monthly fuel usage and default emission factors from the SCAQMD's AER AB 2588 Quadrennial Air Toxics Emission Inventory Procedures - June 2020. The emission factors are 9.1 lbs/MMscf and 18.0 lbs/MMscf for the CTGs and Duct Burners, respectively.

⁴ Monthly emission limits are per COC AQ-5.

Table 8. Monthly Emissions - February 2022

Source	Monthly Emissions (lb/month) ¹					
	NO _x ²	CO	VOC	SO _x	PM ₁₀ /PM _{2.5}	NH ₃ ³
CTG 1 & Duct Burner	1,395	497	300	54.8	1,169	1,772
CTG 2 & Duct Burner	1,349	444	285	51.9	1,113	1,687
Monthly Emission Limits ⁴	N/A	7,633	3,236	227	4,876	N/A
Exceeds Limit?	N/A	No	No	No	No	N/A

¹ Unless otherwise noted, monthly emissions data obtained from 'U1/U2_MonthlySummary_MassEmissionsAndFuel' RegPerfect Report.

² Monthly NO_x emissions are as submitted to SCAQMD, based on the 'U1_U2MonthlyRECLAIMNOxSummaryByDay' RegPerfect Report.

³ Monthly NH₃ emissions are calculated using monthly fuel usage and default emission factors from the SCAQMD's AER AB 2588 Quadrennial Air Toxics Emission Inventory Procedures - June 2020. The emission factors are 9.1 lbs/MMscf and 18.0 lbs/MMscf for the CTGs and Duct Burners, respectively.

⁴ Monthly emission limits are per COC AQ-5.

Table 9. Monthly Emissions - March 2022

Source	Monthly Emissions (lb/month) ¹					
	NO _x ²	CO	VOC	SO _x	PM ₁₀ /PM _{2.5}	NH ₃ ³
CTG 1 & Duct Burner	1,467	539	315	57.1	1,230	1,869
CTG 2 & Duct Burner	1,217	411	250	45.4	978	1,480
Monthly Emission Limits ⁴	N/A	7,633	3,236	227	4,876	N/A
Exceeds Limit?	N/A	No	No	No	No	N/A

¹ Unless otherwise noted, monthly emissions data obtained from 'U1/U2_MonthlySummary_MassEmissionsAndFuel' RegPerfect Report.

² Monthly NO_x emissions are as submitted to SCAQMD, based on the 'U1_U2MonthlyRECLAIMNOxSummaryByDay' RegPerfect Report.

³ Monthly NH₃ emissions are calculated using monthly fuel usage and default emission factors from the SCAQMD's AER AB 2588 Quadrennial Air Toxics Emission Inventory Procedures - June 2020. The emission factors are 9.1 lbs/MMscf and 18.0 lbs/MMscf for the CTGs and Duct Burners, respectively.

⁴ Monthly emission limits are per COC AQ-5.

**Malburg Generating Station
Quarterly Compliance Report
Appendix A, Table 10**

Reporting Period: Quarter 1 2022

Methodology

Emissions (lb/month) = Fuel Usage (gal/month) / 1,000 (gal/Mgal) x Emission Factor (lb/Mgal)

Emission Factors

Pollutant	Emission Factor (lb/Mgal)	Reference
NOx	469	Emission factor provided in the facility's Title V Permit.
CO	13.62	Emission factor converted from the factor provided in the facility's Title V Permit (0.4 g/bhp-hr), based on the unit's power rating (173 hp) and maximum fuel throughput (11.2 gal/hr).
VOC	3.41	Emission factor converted from the factor provided in the facility's Title V Permit (0.1 g/bhp-hr), based on the unit's power rating (173 hp) and maximum fuel throughput (11.2 gal/hr).
SOx	0.21	Default for Diesel/Distillate Oil, ICES given in the SCAQMD's Combustion Default Emission Factors - January 2022.
PM ₁₀ /PM _{2.5}	3.065	Emission factor converted from the factor provided in the facility's Title V Permit (0.09 g/bhp-hr), based on the unit's power rating (173 hp) and maximum fuel throughput (11.2 gal/hr).

Table 10. Monthly Diesel Fire Pump Hours of Operation, Fuel Usage, and Emissions

Month	Monthly Hours of Operation ¹			Fuel Usage (gal/month) ²	Monthly Emissions (lb/month)				
	Maintenance	Testing	Emergency		NOx	CO	VOC	SOx	PM ₁₀ /PM _{2.5}
January	0.0	2.5	0.0	28.0	13.1	0.38	0.10	0.01	0.09
February	0.0	2.0	0.0	22.4	10.5	0.31	0.08	0.00	0.07
March	0.0	2.4	0.0	26.9	12.6	0.37	0.09	0.01	0.08
Total	0.0	6.9	0.0	77.3	36.2	1.05	0.26	0.02	0.24
Annual Limit for Maintenance and Testing ³			50						
Total Annual Limit ³			200						
Exceeds Limits?			No						

¹ Monthly hours of operation calculated from Device 385/403 run timer readings.

² Fuel usage (gal/month) calculated by multiplying the hours of operation by the unit's maximum fuel throughput (11.2 gal/hour).

³ Annual limits for hours of operation are per Condition of Certification (COC) AQ-15.

Appendix B

Cooling Tower Blowdown Reports





781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

January 04, 2022

Tom Barnhart
Colorado Energy Management
4963 Soto St.
Vernon, CA 90058

Report No.: 2112481
Project Name: Malburg Generating Station Weekly

Dear Tom Barnhart,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on December 28, 2021.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

A handwritten signature in blue ink, appearing to read 'D. Sanchy', is written over a horizontal line. Below the line, the text 'Project Manager' is printed.

Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

Colorado Energy Management
 4963 Soto St.
 Vernon, CA 90058

File #:74548
 Report Date: 01/04/22
 Submitted: 12/28/21
PLS Report No.: 2112481

Attn: Tom Barnhart Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2112481-01) Sampled: 12/28/21 07:50 Received: 12/28/21 07:50											
Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch	
Total Dissolved Solids	4480		1	mg/L	5.0	- SM 2540C	12/29/21	12/30/21	vc	BA20326	

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier	
Batch BA20326 - -											
Blank											
Total Dissolved Solids	ND	5.0	mg/L								
LCS											
Total Dissolved Solids	48.0	5.0	mg/L	50.00		96.0	80-120				
Duplicate											
Source: 2112494-02		Prepared: 12/29/21 Analyzed: 12/30/21									
Total Dissolved Solids	50.0	5.0	mg/L		48.0			4.08	5		

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the detection limit
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Fick Owen Parker

Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

DATE: _____ PAGE: _____ OF _____ ②

FILE NO.: _____ LAB NO.: 211249001

CLIENT NAME: COLORADO ENERGY MGMT. PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. AIRBILL NO: _____

ADDRESS: 2715 E. 50th ST. VERNON CA 90058 ANALYSES REQUESTED COOLER TEMP: 1.5°C - 2.2°C

PROJECT MANAGER TOM BARNHART PHONE NO: 1-702-413-2525 FAX NO: PRESERVED: _____

SAMPLER NAME: JOHN BARIE SIGNATURE: REMARKS: _____

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS									SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE										
	<u>12/28/21</u>	<u>6750</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X									

Relinquished by (Signature & Name): <i>[Signature]</i>	Received by (Signature & Name): <i>[Signature]</i> J. Gutierrez	Date: <u>12/28/21</u>	Time: <u>1035</u>	SAMPLE DISPOSITION 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION:

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

January 11, 2022

Tom Barnhart
Colorado Energy Management
4963 Soto St.
Vernon, CA 90058

Report No.: 2201040
Project Name: Malburg Generating Station Weekly

Dear Tom Barnhart,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on January 05, 2022.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

Colorado Energy Management
 4963 Soto St.
 Vernon, CA 90058

File #: 74548
 Report Date: 01/11/22
 Submitted: 01/05/22
PLS Report No.: 2201040

Attn: Tom Barnhart Phone: (323) 476-3626 FAX: (323) 476-3640

Project: Malburg Generating Station Weekly

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	4240		1	mg/L	5.0	-	SM 2540C	01/05/22	01/06/22	vc BA20620

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
Batch BA20620 - -										
Blank										
Total Dissolved Solids	ND	5.0	mg/L							
LCS										
Total Dissolved Solids	48.0	5.0	mg/L	50.00		96.0	80-120			
Duplicate										
Source: 2201011-01										
Total Dissolved Solids	1590	5.0	mg/L		1550			2.81	5	

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the detection limit
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Rick Owen Paslier

 Authorized Signature(s)



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

January 17, 2022

Tom Barnhart
Colorado Energy Management
4963 Soto St.
Vernon, CA 90058

Report No.: 2201071
Project Name: Malburg Generating Station Weekly

Dear Tom Barnhart,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on January 10, 2022.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.



Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

Colorado Energy Management
 4963 Soto St.
 Vernon, CA 90058

File #:74548
 Report Date: 01/17/22
 Submitted: 01/10/22
PLS Report No.: 2201071

Attn: Tom Barnhart Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	4170		1	mg/L	5.0	- SM 2540C	01/13/22	01/14/22	vc	BA21402

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
Batch BA21402 - -										
Blank										
Total Dissolved Solids	ND	5.0	mg/L							
LCS										
Total Dissolved Solids	50.0	5.0	mg/L	50.00		100	80-120			
Duplicate										
Source: 2201071-01 Prepared: 01/13/22 Analyzed: 01/14/22										
Total Dissolved Solids	4360	5.0	mg/L		4170			4.45	5	

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the detection limit
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Rick Owen Parlier

Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST
 781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

DATE: 1/10/22 PAGE 1 OF 1
 LOG BOOK NO. _____ FILE NO. _____ LAB NO. 2201071

CLIENT NAME: Colorado Energy MGMT Project Name/No. Malburg Generating Station Weekly P.O. NO. _____
 ADDRESS: _____ ANALYSES REQUESTED: _____ AIRBILL NO: _____
 #67CF = -0.5° C
 COOLER TEMP: 2.5°/2°C

PROJECT MANAGER: Tom Barnhart PHONE NO: _____ FAX NO: _____ PRESERVATIVE: _____

SAMPLER NAME: Luis Gutierrez (Printed) (Signature) [Signature] REMARKS: _____

TAT (Analytical Turn Around Time): 0 = Same Day; 1 = 1 Day; 2 = 2 Days; 3 = 3 Days; N = Normal (5-7 Working Days)

CONTAINER TYPES: B = Brass, E = Encore, G = Glass, P = Plastic, V = VOA Vial, O = Other:

UST Project: Y N - Global ID# _____

SAMPLE NO.	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		REMARKS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE	
1	1/10/22	10:00 Am	Cooling Tower Blowdown	X				N	1	P	X
2											
3											
4											
5											
6											
7											
8											
9											
10											

Relinquished By: (Signature and Printed Name) _____ Received By: (Signature and Printed Name) Guadalupe Tenorio Date: 1/10/22 Time: 2:13
 Relinquished By: (Signature and Printed Name) _____ Received By: (Signature and Printed Name) _____ Date: _____ Time: _____
 Relinquished By: (Signature and Printed Name) _____ Received By: (Signature and Printed Name) _____ Date: _____ Time: _____

SAMPLE DISPOSITION:
 1. Samples returned to client? YES NO
 2. Samples will not be stored over 30 days, unless additional storage time is requested.
 3. Storage time requested: _____ days
 By _____ Date _____

SPECIAL INSTRUCTIONS: _____

PRESERVATIVE: 1-HNO₃, 2-H₂SO₄, 3-HCL, 4-Zinc Acetate, 5-NaOH, 6-NH₄ Buffer, 7-Other



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

April 19, 2022

Mr. Matt Richards
City of Vernon
4963 Soto Street
Vernon, CA 90058

RE: Malburg Generation Station Missed Weekly Sampling January 2022

Hello Mr. Richards:

We did not take the Weekly samples at your facility in January 2022. Our main sampling Technician was out with COVID during this time, and the replacement Technician, that was covering for him during this time, was not aware of the required weekly sampling. When our main technician returned from being out, he continued the weekly sampling. We apologize for missing this sampling, we were short staffed during this time, with other staff members out as well with COVID.

Sincerely,

A handwritten signature in black ink that reads "John Schmidt". The signature is written in a cursive style with a large, looped initial "J".

John Schmidt
Lab Manager, V. P.



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

January 31, 2022

Matt Richards
City of Vernon
4963 Soto St.
Vernon, CA 90058

Report No.: 2201239
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on January 25, 2022.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

City of Vernon
 4963 Soto St.
 Vernon, CA 90058

File #:74548
 Report Date: 01/31/22
 Submitted: 01/25/22
PLS Report No.: 2201239

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2201239-01) Sampled: 01/25/22 08:50 Received: 01/25/22 08:50										
Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	4170		1	mg/L	5.0	SM 2540C	01/27/22	01/28/22	vc	BA22811

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	RPD	RPD	Qualifier	
Batch BA22811 - -										
Blank										
Total Dissolved Solids	ND	5.0	mg/L							
LCS										
Total Dissolved Solids	52.0	5.0	mg/L	50.00		104	80-120			
Duplicate Source: 2201241-07										
Total Dissolved Solids	695	5.0	mg/L		706			1.57	5	
Duplicate Source: 2201246-01										
Total Dissolved Solids	1120	5.0	mg/L		1160			4.13	5	

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the detection limit
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Rick Owen Parker

Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

DATE: 1-24-22 PAGE: 1 OF 1

FILE NO.: _____ LAB NO.: 1201239

CLIENT NAME: CITY OF VERNON PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. AIRBILL NO: 416

ADDRESS: 40103 5th St 2715 E. 50th ST. VERNON CA 90058 ANALYSES REQUESTED COOLER TEMP: 1.2°C - 2.2°C

PROJECT MANAGER MATT RICHARDS PHONE NO: FAX NO: PRESERVED: _____

SAMPLER NAME: JOHN BARIE SIGNATURE: REMARKS: _____

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: _____

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS	ANALYSES REQUESTED						SAMPLE CONDITIONS/ CONTAINER/COMMENTS	
				WATER	SOIL	SLUDGE	OTHER		#	TYPE									
	<u>1-24-22</u>	<u>0850</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X								

Relinquished by (Signature & Name): <u>J. Barie</u>	Received by (Signature & Name): <u>Guadalupe Tanaka</u>	Date: <u>1-24-22</u>	Time: <u>1:58</u>	SAMPLE DISPOSITION 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date: <u>1-24-22</u>	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION:

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

February 10, 2022

Matt Richards
City of Vernon
4963 Soto St.
Vernon, CA 90058

Report No.: 2202015
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on February 02, 2022.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

A handwritten signature in blue ink, appearing to read "D Sanchez", is written over a horizontal line. Below the line, the text "Project Manager" is printed in a black, sans-serif font.

Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

City of Vernon
 4963 Soto St.
 Vernon, CA 90058

File #:74548
 Report Date: 02/10/22
 Submitted: 02/02/22
PLS Report No.: 2202015

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2202015-01) Sampled: 02/02/22 08:55 Received: 02/02/22

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	4120	R1	1	mg/L	5.0	- SM 2540C	02/10/22	02/10/22	dd	BB21035

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	Limit	RPD	Limit	Qualifier
Batch BB21035 - -										
Blank										
Prepared & Analyzed: 02/10/22										
Total Dissolved Solids	ND	5.0	mg/L							
LCS										
Prepared & Analyzed: 02/10/22										
Total Dissolved Solids	49.0	5.0	mg/L	50.00		98.0	80-120			
Duplicate										
Source: 2202015-01 Prepared & Analyzed: 02/10/22										
Total Dissolved Solids	3990	5.0	mg/L		4120			3.41	5	

Notes and Definitions

- R1 Sample Analyzed Past Holding Time.
- NA Not Applicable
- ND Analyte NOT DETECTED at or above the detection limit
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Rick Owen Parlier
 Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

DATE: 2-2-22 PAGE: 1 OF 1

FILE NO.: _____ LAB NO.: U01015

CLIENT NAME: CITY OF VERNON PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. AIRBILL NO: 462

ADDRESS: 4963 SOTO ST. VERNON CA 90058 ANALYSES REQUESTED COOLER TEMP: 15°C - 20°C

PROJECT MANAGER MATT RICHARDS PHONE NO: FAX NO: PRESERVED: _____

SAMPLER NAME: JOHN BARIE SIGNATURE: [Signature] REMARKS: _____

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: _____

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS	ANALYSES REQUESTED						SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE								
	2-1-22	0855	COOLING TOWER BLOWDOWN	X				N	1	P	X							

Relinquished by (Signature & Name): <u>[Signature]</u> <u>John Barie</u>	Received by (Signature & Name): <u>Arrived at the lab</u>	Date: <u>2-2-22</u>	Time: <u>1245</u>	SAMPLE DISPOSITION 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION:

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER



781 East Washington Blvd., Los Angeles, CA 90021
[213] 745-5312 FAX [213] 745-6372

February 14, 2022

Matt Richards
City of Vernon
4963 Soto St.
Vernon, CA 90058

Report No.: 2202046
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on February 07, 2022.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

City of Vernon
 4963 Soto St.
 Vernon, CA 90058

File #:74548
 Report Date: 02/14/22
 Submitted: 02/07/22
PLS Report No.: 2202046

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2202046-01) Sampled: 02/07/22 10:40 Received: 02/07/22

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	4180		1	mg/L	5.0	SM 2540C	02/09/22	02/10/22	dd	BB21027

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
Batch BB21027 - -										
Blank										
Prepared: 02/09/22 Analyzed: 02/10/22										
Total Dissolved Solids	ND	5.0	mg/L							
LCS										
Prepared: 02/09/22 Analyzed: 02/10/22										
Total Dissolved Solids	47.0	5.0	mg/L	50.00		94.0	80-120			
Duplicate										
Source: 2202046-01 Prepared: 02/09/22 Analyzed: 02/10/22										
Total Dissolved Solids	4200	5.0	mg/L		4180			0.310	5	

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the detection limit
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Fik Owen Parker

 Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

DATE: 2-7-22 PAGE: 1 OF 1

FILE NO.: _____ LAB NO.: 1202040

CLIENT NAME: CITY OF VERNON PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. AIRBILL NO: #46

ADDRESS: 4963 SOTO ST. VERNON CA 90058 ANALYSES REQUESTED COOLER TEMP: 1.1°C -24°C

PROJECT MANAGER MATT RICHARDS PHONE NO: FAX NO: PRESERVED: _____

SAMPLER NAME: JOHN BARIE SIGNATURE: [Signature] REMARKS: _____

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS								SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE									
	<u>2-7-22</u>	<u>1240</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X								

Relinquished by (Signature & Name): <u>[Signature]</u> <u>Jana Diaz</u>	Received by (Signature & Name): <u>Arrived at the lab</u>	Date: <u>2-7-22</u>	Time: <u>11:5</u>	SAMPLE DISPOSITION 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days. By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION:

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

February 21, 2022

Matt Richards
City of Vernon
4963 Soto St.
Vernon, CA 90058

Report No.: 2202125
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on February 15, 2022.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

City of Vernon
 4963 Soto St.
 Vernon, CA 90058

File #:74548
 Report Date: 02/21/22
 Submitted: 02/15/22
PLS Report No.: 2202125

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2202125-01) Sampled: 02/15/22 08:25 Received: 02/15/22											
Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch	
Total Dissolved Solids	3840		1	mg/L	5.0	- SM 2540C	02/17/22	02/18/22	vc	BB22128	

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier	
Batch BB22128 - -											
Blank											
Total Dissolved Solids	ND	5.0	mg/L								
LCS											
Total Dissolved Solids	48.0	5.0	mg/L	50.00		96.0	80-120				
Duplicate Source: 2202146-08											
Total Dissolved Solids	4520	5.0	mg/L		4360			3.72	5		
Duplicate Source: 2202160-08											
Total Dissolved Solids	5420	5.0	mg/L		5200			4.05	5		

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the detection limit
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Rick Owen Parker

 Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

DATE: 2-15-22 PAGE: 1 OF

FILE NO.: LAB NO.: 1202129

CLIENT NAME: CITY OF VERNON PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. AIRBILL NO: 766

ADDRESS: 4963 SOTO ST. VERNON CA 90058 ANALYSES REQUESTED COOLER TEMP: 2.0°C - 2.4°C

PROJECT MANAGER MATT RICHARDS PHONE NO: FAX NO: PRESERVED:

SAMPLER NAME: JOHN BARIE SIGNATURE: [Signature] REMARKS:

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS										SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE											
	<u>2/15/22</u>	<u>2:05</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X										

Relinquished by (Signature & Name): <u>[Signature]</u>	Received by (Signature & Name): Arrived at the lab	Date:	Time:	SAMPLE DISPOSITION 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION:

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

March 01, 2022

Matt Richards
City of Vernon
4963 Soto St.
Vernon, CA 90058

Report No.: 2202202
Project Name: Malburg Generating Station Weekly


Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on February 22, 2022.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

City of Vernon
 4963 Soto St.
 Vernon, CA 90058

File #:74548
 Report Date: 03/01/22
 Submitted: 02/22/22
PLS Report No.: 2202202

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2202202-01) Sampled: 02/22/22 08:20 Received: 02/22/22											
Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch	
Total Dissolved Solids	3830		1	mg/L	5.0	- SM 2540C	02/28/22	03/01/22	vc	BC20119	

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	Limits	RPD	RPD Limit	Qualifier	
Batch BC20119 - -											
Blank											
Prepared: 02/28/22 Analyzed: 03/01/22											
Total Dissolved Solids	ND	5.0	mg/L								
LCS											
Prepared: 02/28/22 Analyzed: 03/01/22											
Total Dissolved Solids	48.0	5.0	mg/L	50.00		96.0	80-120				
Duplicate											
Source: 2202202-01 Prepared: 02/28/22 Analyzed: 03/01/22											
Total Dissolved Solids	3990	5.0	mg/L		3830			4.17	5		

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the detection limit
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit


 Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

DATE: 2-22-22 PAGE: 1 OF 1

FILE NO.: _____ LAB NO.: 100202

CLIENT NAME: CITY OF VERNON PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. AIRBILL NO:

ADDRESS: 4963 SOTO ST. VERNON CA 90058 ANALYSES REQUESTED COOLER TEMP: ^{65%} 1.3% ~~2.2%~~ #66

PROJECT MANAGER MATT RICHARDS PHONE NO: FAX NO: PRESERVED: _____

SAMPLER NAME: JOHN BARIE SIGNATURE: *[Signature]* REMARKS: _____

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS								SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE									
	<u>2/22/22</u>	<u>10:20</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X								

Relinquished by (Signature & Name): <i>[Signature]</i>	Received by (Signature & Name): Arrived at the lab	Date:	Time:	SAMPLE DISPOSITION 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days. By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION:

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

March 07, 2022

Matt Richards
City of Vernon
4963 Soto St.
Vernon, CA 90058

Report No.: 2202267
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on February 28, 2022.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

A handwritten signature in blue ink, appearing to read "D Sanchez", is written over a horizontal line. Below the line, the text "Project Manager" is printed in a black, sans-serif font.

Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

City of Vernon
 4963 Soto St.
 Vernon, CA 90058

File #:74548
 Report Date: 03/07/22
 Submitted: 02/28/22
PLS Report No.: 2202267

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2202267-01) Sampled: 02/28/22 08:30 Received: 02/28/22											
Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch	
Total Dissolved Solids	4050		1	mg/L	5.0	- SM 2540C	03/03/22	03/04/22	vc	BC20728	

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier	
Batch BC20728 - -											
Blank											
Total Dissolved Solids	ND	5.0	mg/L								
LCS											
Total Dissolved Solids	49.0	5.0	mg/L	50.00		98.0	80-120				
Duplicate Source: 2202267-01											
Total Dissolved Solids	4070	5.0	mg/L		4050			0.574	5		

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the detection limit
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Rick Owen Parker

Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

DATE: 2-28-22 PAGE: 1 OF 1

FILE NO.: _____ LAB NO.: 200201

CLIENT NAME: CITY OF VERNON PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. _____ AIRBILL NO: _____

ADDRESS: 4963 SOTO ST. VERNON CA 90058 ANALYSES REQUESTED: _____ COOLER TEMP: 12°C - 24°C

PROJECT MANAGER MATT RICHARDS PHONE NO: _____ FAX NO: _____ PRESERVED: _____

SAMPLER NAME: JOHN BARIE SIGNATURE: [Signature] REMARKS: _____

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS								SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE									
	<u>2/28/22</u>	<u>0830</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X								

Relinquished by (Signature & Name): <u>[Signature]</u>	Received by (Signature & Name): <u>[Signature]</u>	Date: <u>2/28/22</u>	Time: <u>0830</u>	SAMPLE DISPOSITION 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days. By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION: Arrived at the lab 2/28/22 11am

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

March 14, 2022

Matt Richards
City of Vernon
4963 Soto St.
Vernon, CA 90058

Report No.: 2203065
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on March 08, 2022.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

City of Vernon
 4963 Soto St.
 Vernon, CA 90058

File #:74548
 Report Date: 03/14/22
 Submitted: 03/08/22
PLS Report No.: 2203065

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2203065-01) Sampled: 03/08/22 08:30 Received: 03/08/22

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	3960		1	mg/L	5.0	- SM 2540C	03/10/22	03/11/22	vc	BC21115

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
---------	--------	-----	-------	-------------	---------------	------	-------------	-----	-----------	-----------

Batch BC21115 - -

Blank	Prepared: 03/10/22 Analyzed: 03/11/22									
Total Dissolved Solids	ND	5.0	mg/L							
LCS	Prepared: 03/10/22 Analyzed: 03/11/22									
Total Dissolved Solids	47.0	5.0	mg/L	50.00		94.0	80-120			
Duplicate	Source: 2203065-01 Prepared: 03/10/22 Analyzed: 03/11/22									
Total Dissolved Solids	4110	5.0	mg/L		3960			3.64	5	

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the detection limit
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Rick Owen Parker

Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

DATE: 3-8-22 PAGE: 1 OF 1

FILE NO.: _____ LAB NO.: 22030105

CLIENT NAME: CITY OF VERNON PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. AIRBILL NO:

ADDRESS: 4963 SOTO ST. VERNON CA 90058 ANALYSES REQUESTED COOLER TEMP: 1.2°C - 2°C

PROJECT MANAGER MATT RICHARDS PHONE NO: FAX NO: PRESERVED: _____

SAMPLER NAME: JOHN BARIE SIGNATURE: REMARKS: _____

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS									SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE										
	<u>3-8-22</u>	<u>0830</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X									

Relinquished by (Signature & Name): <u>MA</u>	Received by (Signature & Name): <u>JJ TenBore</u>	Date: <u>3-8-22</u>	Time: <u>0830</u>	SAMPLE DISPOSITION 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days. By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION: Arrived at the lab 3-8-22 1030

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

March 21, 2022

Matt Richards
City of Vernon
4963 Soto St.
Vernon, CA 90058

Report No.: 2203099
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on March 14, 2022.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

City of Vernon
 4963 Soto St.
 Vernon, CA 90058

File #:74548
 Report Date: 03/21/22
 Submitted: 03/14/22
PLS Report No.: 2203099

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2203099-01) Sampled: 03/14/22 09:15 Received: 03/14/22										
Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	3980		1	mg/L	5.0	- SM 2540C	03/17/22	03/18/22	vc	BC21820

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
Batch BC21820 - -										
Blank										
Total Dissolved Solids	ND	5.0	mg/L							
LCS										
Total Dissolved Solids	46.0	5.0	mg/L	50.00		92.0	80-120			
Duplicate										
Source: 2203099-01		Prepared: 03/17/22 Analyzed: 03/18/22								
Total Dissolved Solids	4080	5.0	mg/L		3980			2.36	5	

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the detection limit
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Rick Owen Parker

 Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

DATE: 3-14-22 PAGE: 1 OF 1

FILE NO.: _____ LAB NO.: 2203099

CLIENT NAME: **CITY OF VERNON** PROJECT NAME/NO. **MALBURG GENERATING STATION WEEKLY** P.O.NO. _____ AIRBILL NO: _____

ADDRESS: **4963 SOTO ST. VERNON CA 90058** ANALYSES REQUESTED _____ COOLER TEMP: 1.1°C - 2°C

PROJECT MANAGER **MATT RICHARDS** PHONE NO: _____ FAX NO: _____ PRESERVED: _____

SAMPLER NAME: **JOHN BARIE** SIGNATURE: [Signature] REMARKS: _____

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: **Y N** GLOBAL ID#: _____

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS								SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE									
	<u>3-14-22</u>	<u>0915</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X								

Relinquished by (Signature & Name): <u>MA</u>	Received by (Signature & Name): <u>[Signature]</u>	Date: <u>3-14-22</u>	Time: <u>0915</u>	SAMPLE DISPOSITION 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION: Arrived at the lab 3-14-22 1150

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

March 28, 2022

Matt Richards
City of Vernon
4963 Soto St.
Vernon, CA 90058

Report No.: 2203186
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on March 22, 2022.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

A handwritten signature in black ink, appearing to read "John Schmidt", is written over a horizontal line.

Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

City of Vernon
 4963 Soto St.
 Vernon, CA 90058

File #:74548
 Report Date: 03/28/22
 Submitted: 03/22/22
PLS Report No.: 2203186

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2203186-01) Sampled: 03/22/22 08:50 Received: 03/22/22											
Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch	
Total Dissolved Solids	4090		1	mg/L	5.0	- SM 2540C	03/24/22	03/25/22	vc	BC22514	

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC Limits	RPD	RPD Limit	Qualifier	
Batch BC22514 - -										
Blank Prepared: 03/24/22 Analyzed: 03/25/22										
Total Dissolved Solids	ND	5.0	mg/L							
LCS Prepared: 03/24/22 Analyzed: 03/25/22										
Total Dissolved Solids	47.0	5.0	mg/L	50.00		94.0 80-120				
Duplicate Source: 2203186-01 Prepared: 03/24/22 Analyzed: 03/25/22										
Total Dissolved Solids	3960	5.0	mg/L		4090		3.23	5		

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the detection limit
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

DATE: _____ PAGE: _____ OF _____

FILE NO.: _____ LAB NO.: 2009180

CLIENT NAME: CITY OF VERNON PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. AIRBILL NO:

ADDRESS: 4963 SOTO ST. VERNON CA 90058 ANALYSES REQUESTED COOLER TEMP: 1.22 1.22 1.22

PROJECT MANAGER MATT RICHARDS PHONE NO: FAX NO: PRESERVED: _____

SAMPLER NAME: JOHN BARIE SIGNATURE: [Signature] REMARKS: _____

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS	ANALYSES REQUESTED								SAMPLE CONDITIONS/ CONTAINER/COMMENTS							
				WATER	SOIL	SLUDGE	OTHER		#	TYPE																	
	3-22-02	0850	COOLING TOWER BLOWDOWN	X				N	1	P	X																

Relinquished by (Signature & Name): <u>LA</u>	Received by (Signature & Name): <u>[Signature]</u>	Date: <u>3-22-02</u>	Time: <u>0850</u>	SAMPLE DISPOSITION 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION:
 Arrived at the lab 3-22-02 1025

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

April 04, 2022

Matt Richards
City of Vernon
4963 Soto St.
Vernon, CA 90058

Report No.: 2203249
Project Name: Malburg Generating Station

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on March 28, 2022.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

City of Vernon
 4963 Soto St.
 Vernon, CA 90058

File #:74548
 Report Date: 04/04/22
 Submitted: 03/28/22
PLS Report No.: 2203249

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station

Sample ID: Cooling Tower Blowdown Water (2203249-01) Sampled: 03/28/22 07:35 Received: 03/28/22											
Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch	
Total Dissolved Solids	4140		1	mg/L	5.0	- SM 2540C	03/31/22	04/01/22	vc	BD20426	

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier	
Batch BD20426 - -											
Blank											
Total Dissolved Solids	ND	5.0	mg/L								
LCS											
Total Dissolved Solids	49.0	5.0	mg/L	50.00		98.0	80-120				
Duplicate											
Source: 2203249-01		Prepared: 03/31/22 Analyzed: 04/01/22									
Total Dissolved Solids	3950	5.0	mg/L		4140			4.78	5		

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the detection limit
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138


 Authorized Signature(s)

Appendix C

Operation Logs



Malburg Generating Station
Appendix C, Table 1
Combustion Turbine Generator (CTG) Startup and Shutdown Events
During Quarter 1, 2022

CGT 1

Date	Event Type ¹	Event Start	Event End	Duration (hrs:min)
2/4/2022	Shutdown	20:56	21:06	0:10
2/7/2022	Cold Start	15:03	16:48	1:45
3/11/2022	Shutdown	22:01	22:09	0:08
3/14/2022	Cold Start	14:34	16:01	1:27
3/31/2022	Shutdown	00:01	00:08	0:07

CGT 2

Date	Event Type ¹	Event Start	Event End	Duration (hrs:min)
1/14/2022	Shutdown	22:00	22:09	0:09
1/18/2022	Cold Start	14:41	16:13	1:32
2/6/2022	Trip	12:59	12:59	0:00
2/6/2022	Hot Start	16:33	17:52	1:19
2/19/2022	Shutdown	0:01	0:09	0:08
2/22/2022	Cold Start	14:45	16:27	1:42
3/16/2022	Shutdown	00:00	00:08	0:08
3/22/2022	Cold Start	15:36	17:10	1:34
3/26/2022	Shutdown	00:00	00:08	0:08
3/28/2022	Cold Start	14:30	16:19	1:49

¹ A startup event is defined as initiation of the first start command to the time at which the system becomes emissions compliant.

Malburg Generating Station
Appendix C, Table 2
Diesel Firewater Pump Testing Times
During Quarter 1, 2022

Date	Time (hh:mm)	Start Hours	End Hours	Event Type	Hours of Operation
1/2/2022	20:25	330.8	331.3	Testing	0.50
1/9/2022	20:12	331.3	331.8	Testing	0.50
1/16/2022	23:24	331.8	332.3	Testing	0.50
1/23/2022	19:10	332.3	332.8	Testing	0.50
1/30/2022	19:16	332.8	333.3	Testing	0.50
2/6/2022	23:11	333.3	333.8	Testing	0.50
2/13/2022	23:13	333.8	334.3	Testing	0.50
2/20/2022	19:08	334.3	334.8	Testing	0.50
2/27/2022	23:56	334.8	335.3	Testing	0.50
3/6/2022	20:30	335.3	335.7	Testing	0.40
3/13/2022	21:15	335.7	336.3	Testing	0.60
3/20/2022	19:41	336.3	336.8	Testing	0.50
3/27/2022	20:04	336.8	337.7	Testing	0.90

Appendix D

Diesel Fuel Oil Purchase Records



Invoice



SC Commercial, LLC, DBA SC Fuels
 1800 West Katella Ave, Suite 400
 P.O. Box 4159, Orange, CA 92863-4159

PLEASE REMIT ALL PAYMENTS TO:
P.O. BOX 14237
ORANGE, CA 92863-1237

Ph: (800) 659-5823 Credit Inquiries: (888) SCFUELS Ext.6017

INVOICE: 1837355-IN

INVOICE DATE: 3/29/2021

DUE DATE: 4/28/2021

SHIP DATE: 3/29/2021

SHIP VIA: 924

ORDER DATE: 3/24/2021

ORDER NUMBER: 1837355

CUSTOMER PO: MGS21780

TERMS: N30

SALEPERSON: Todd Cripps
 714-938-5714

ACCT NO (Bill-to): 01-0001084
 COLORADO ENERGY MANAGEMENT LLC
 ATTN: ACCOUNTS PAYABLE
 4963 S. SOTO STREET
 VERNON, CA 90058
 (323) 476-3622

ACCT NO (Ship-to) 01-0001084 1L
 COLORADO ENERGY MGMT-VERNON
 4963 SOTO STREET
 VERNON, CA 90058

ITEM CODE	ITEM DESCRIPTION	QUANTITY ORDERED	QUANTITY DELIVERED	PACKAGE DESCRIPTION	EXTENDED QTY	UNIT PRICE	EXT PRICE
CH253090981D05 5	CH GST 2300 ISO 32 253090981	2	2.00	55 G DR	110.00	18.58000	2,043.80
		Whse: 101					
422D055	DYED CARB ULS DIESEL NON TAXABLE USE ONLY - PENALTY FOR TAXABLE USE 15 PPM OR LESS SULFUR - MAY CONTAIN UP TO 5% BIODIESEL	2	2.00	55 G DR	110.00	3.95000	434.50
		Whse: 101					
Federal Lust						0.00100	0.11
Federal Oil Spill						0.00214	0.24
CA - AB 32 - DSL						0.00828	0.91
						<hr/> 3.96142	<hr/> 435.76
DRUMDEPOSITC 001	DRUM DEPOSIT FEE	4	4.00	MISC CHRG	4.00	25.00000	100.00
		Whse: 101					
/FUELCHLUBE	FUEL SURCHARGE LUBES						9.92
/RCFLUBE	REG COMPLIANCE FEE LUBES						12.95
MSRTNDRMC001	RETURN DRUM	0	-4.00	MISC CHRG	4.00-	15.00000	60.00-
		Whse: 101					

Save time, pay online! View invoices, make payments and more.
 Sign up for the Customer Portal today. Email: creditinquiries@scfuels.com or Call 888-SCFuels
 Ext. 6017 or login to Customer Portal: <https://customerportal.scfuels.com>
 24-hour Emergency Response Call CHEMTREC: 800-424-9300

Net Invoice: 2,542.43
 Less Discount: 0.00
 Freight: 0.00
 Sales Tax: 256.52
Invoice Total: 2,798.95

- IN THE EVENT THAT THE ABOVE CHARGES ARE NOT PAID WHEN DUE, SC COMMERCIAL, LLC, DBA SC FUELS RESERVES THE RIGHT TO REFUSE FURTHER
 - CHARGES TO THE ACCOUNT. A SERVICE CHARGE OF 1.5% PER MONTH(A.P.R. 18%) WILL APPLY TO ALL PAST DUE INVOICES.
 - ERRORS IN PRICE, EXTENSION, AND ADDITION SUBJECT TO CORRECTION.
 - It is the purchaser's responsibility to verify that all applicable taxes are being charged in accordance with federal and state laws.
 - Prices shown on this invoice reflect discounts received for Payment by Cash, Check, or Electronic Funds Transfer (EFT). Payment by other means is subject to a 3% surcharge.

Parts

PO 21780

partial



SALES ORDER / DELIVERY TICKET

ORDER NUMBER: 1837355

SC Commercial, LLC, DBA SC Fuels
1800 West Katella Ave., Suite 400
P.O. Box 14237, Orange, CA 92863-4159

DATE: 3/24/2021
TERMS: N30
SALES REP: Todd Cripps
PHONE: 714-938-5714

Ph: (800) 659-5823 Credit Inquiries: (888) SCFUELS Ext. 6017

PO#: MGS21780

PLEASE REMIT ALL PAYMENTS TO:
P.O. BOX 14237
ORANGE, CA 92863-1237

SHIP DATE: 3/29/2021

ROM:
SHIP VIA:
WHSE: 101

ACCT NO (Bill-to): 01-0001084
COLORADO ENERGY MANAGEMENT LLC
ATTN: ACCOUNTS PAYABLE
4963 S. SOTO STREET
VERNON, CA 90058
(323) 476-3622

ACCT NO (Ship-to) 01-0001084 1L
COLORADO ENERGY MGMT-VERNON
4963 SOTO STREET
VERNON, CA 90058
(323) 476-3632

HM	ITEM CODE	ITEM DESCRIPTION	QTY ORDERED	QTY DEL	PACKAGE DESC	EXTENDED QTY
	CH253090981D055	CH GST 2300 ISO 32 253090981	2.00	2	55 G DR	110.00 GALS
X	NA1993, DIESEL FUEL, 3 PG III / CARGO TANK					
	422D055	DYED CARB ULS DIESEL NON TAXABLE USE ONLY - PENALTY FOR TAXABLE USE 15 PPM OR LESS SULFUR - MAY CONTAIN UP TO 5% BIODIESEL	2.00	2	55 G DR	110.00 GALS
	DRUMDEPOSITC001	DRUM DEPOSIT FEE	4.00	4	MISC CHRG	4.00 EACH
	/FUELCHLUBE	FUEL SURCHARGE LUBES				
	/RCFLUBE	REG COMPLIANCE FEE LUBES				

4 empty
Drums

Rec'd by [Signature] Date 3-29-21
Print Name [Signature]
Driver's Signature [Signature]

Received in INFOR
3/29/21
M. Gordon

ARRIVED DESTINATION	1032 AM	DATE	3/29/21	COMPLETED UNLOADING	AM	DATE	3/29/21
	PM				PM		
				DRUM CREDIT			

TRUCK # 091	B/L #	FOR COMPANY USE ONLY RT <input type="checkbox"/> TF <input type="checkbox"/> OP <input type="checkbox"/>
D.O.T. HAZARDOUS MATERIALS PLACARD PROVIDED BY SHIPPER <input type="checkbox"/> CARRIER <input type="checkbox"/>		
THIS IS TO CERTIFY THAT THE ABOVE NAMED MATERIALS ARE PROPERLY CLASSIFIED, DESCRIBED, PACKAGED, MARKED AND LABELED AND ARE IN PROPER CONDITION FOR TRANSPORTATION ACCORDING TO APPLICABLE REGULATIONS OF THE DEPARTMENT OF TRANSPORTATION		

Appendix E

Excess Emission Reports



Startup/Shutdown Excess Emissions Report

U1 CO Startup/Shutdown



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** Malburg Generating Station

Generated: 04/28/2022 12:55 **Location:** Vernon, California

Tag Name: U1_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,005.13 Hours

Non-Operating Time: 154.87 Hours Report Time: 2,160.00 Hours

Unit Operation

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description

No excess emissions were found in the reporting period.

Startup/Shutdown Excess Emissions Report

U1 CO Startup/Shutdown



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** Malburg Generating Station

Generated: 04/28/2022 12:55 **Location:** Vernon, California

Tag Name: U1_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,005.13 Hours

Non-Operating Time: 154.87 Hours Report Time: 2,160.00 Hours

No invalid events were found in the reporting period.

Startup/Shutdown Excess Emissions Report

U1 NOx Startup/Shutdown



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** Malburg Generating Station

Generated: 04/28/2022 12:58 **Location:** Vernon, California

Tag Name: U1_NOXRECLM_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,005.13 Hours

Non-Operating Time: 154.87 Hours Report Time: 2,160.00 Hours

Unit Operation

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description

No excess emissions were found in the reporting period.

Startup/Shutdown Excess Emissions Report

U1 NOx Startup/Shutdown



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** Malburg Generating Station

Generated: 04/28/2022 12:58 **Location:** Vernon, California

Tag Name: U1_NOXRECLM_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,005.13 Hours

Non-Operating Time: 154.87 Hours Report Time: 2,160.00 Hours

No invalid events were found in the reporting period.

Startup/Shutdown Excess Emissions Report

U1 VOC Startup/Shutdown



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** Malburg Generating Station

Generated: 04/28/2022 12:59 **Location:** Vernon, California

Tag Name: U1_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,005.13 Hours

Non-Operating Time: 154.87 Hours Report Time: 2,160.00 Hours

Unit Operation

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description

No excess emissions were found in the reporting period.

Startup/Shutdown Excess Emissions Report

U1 VOC Startup/Shutdown



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** Malburg Generating Station

Generated: 04/28/2022 12:59 **Location:** Vernon, California

Tag Name: U1_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,005.13 Hours

Non-Operating Time: 154.87 Hours Report Time: 2,160.00 Hours

No invalid events were found in the reporting period.

Excess Emission Report

Unit 1 - CO ppmvdc 1-hour during Normal Operation

From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: Malburg Generating Station
Generated: 04/28/2022 12:57 Location: Vernon, California



Tag Name: U1_CONormal_Ppmvdc_1H

Total Operating Time: 2,009.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 151.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,009.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

Unit 1 - NOx ppmvdc 1-hour during Normal Operation

From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: Malburg Generating Station
Generated: 04/28/2022 12:56 Location: Vernon, California



Tag Name: U1_NOxNormal_Ppmvdc_1H

Total Operating Time: 2,009.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 151.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,009.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

Unit 1 - VOC ppmvdc 1-hour during Normal Operation

From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: Malburg Generating Station
Generated: 04/28/2022 12:56 Location: Vernon, California



Tag Name: U1_VOCNormal_Ppmvdc_1H

Total Operating Time: 2,009.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 151.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,009.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Quad K Excess Emissions Report

U1 NOX 4-Hour Events

From: 01/01/2022 00:00 To: 03/31/2022 23:59
Generated: 04/28/2022 12:57

Facility Name: Malburg Generating Station
Location: Vernon, California



Tag Name: U1_NOx4H_Ppmvdc_1H

Total Operating Time: 2,009.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 151.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,009.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Startup/Shutdown Event Report

U2 CO Startup/Shutdown Events



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** Malburg Generating Station

Generated: 04/28/2022 12:59 **Location:** Vernon, California

Tag Name: U2_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,758.45 Hours

Non-Operating Time: 401.55 Hours Report Time: 2,160.00 Hours

Unit Operation

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description

No excess emissions were found in the reporting period.

Startup/Shutdown Event Report

U2 CO Startup/Shutdown Events



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** Malburg Generating Station

Generated: 04/28/2022 12:59 **Location:** Vernon, California

Tag Name: U2_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,758.45 Hours

Non-Operating Time: 401.55 Hours Report Time: 2,160.00 Hours

Invalid Event Period		Reason	Action
Begin/End	Duration in Minute(s)	Code - Description	Code - Description
01/03/2022 14:31 01/03/2022 14:31	1		

Total CMS Downtime	1 Minute(s)
Total Downtime as a percentage of operating time	0.00 %
Total Availability as a percentage of operating time	100.00 %

Startup/Shutdown Excess Emissions Report

U2 NOx Startup/Shutdown



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** Malburg Generating Station

Generated: 04/28/2022 13:02 **Location:** Vernon, California

Tag Name: U2_NOXRECLM_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,758.45 Hours

Non-Operating Time: 401.55 Hours Report Time: 2,160.00 Hours

Unit Operation

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description

No excess emissions were found in the reporting period.

Startup/Shutdown Excess Emissions Report

U2 NOx Startup/Shutdown



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** Malburg Generating Station

Generated: 04/28/2022 13:02 **Location:** Vernon, California

Tag Name: U2_NOXRECLM_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,758.45 Hours

Non-Operating Time: 401.55 Hours Report Time: 2,160.00 Hours

Invalid Event Period		Reason	Action
Begin/End	Duration in Minute(s)	Code - Description	Code - Description
01/03/2022 14:31 01/03/2022 14:31	1		

Total CMS Downtime	1 Minute(s)
Total Downtime as a percentage of operating time	0.00 %
Total Availability as a percentage of operating time	100.00 %

Startup/Shutdown Event Report

U2 VOC Startup/Shutdown Events



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** Malburg Generating Station

Generated: 04/28/2022 13:02 **Location:** Vernon, California

Tag Name: U2_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,758.45 Hours

Non-Operating Time: 401.55 Hours Report Time: 2,160.00 Hours

Unit Operation

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description

No excess emissions were found in the reporting period.

Startup/Shutdown Event Report

U2 VOC Startup/Shutdown Events



From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** Malburg Generating Station

Generated: 04/28/2022 13:02 **Location:** Vernon, California

Tag Name: U2_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,758.45 Hours

Non-Operating Time: 401.55 Hours Report Time: 2,160.00 Hours

No invalid events were found in the reporting period.

Excess Emission Report

Unit 2 - CO ppmvdc 1-hour during Normal Operation

From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: Malburg Generating Station
Generated: 04/28/2022 13:01 Location: Vernon, California



Tag Name: U2_CONormal_Ppmvdc_1H

Total Operating Time: 1,766.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 394.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,766.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

Unit 2 - NOx ppmvdc 1-hour during Normal Operation

From: 01/01/2022 00:00 To: 03/31/2022 23:59 Facility Name: Malburg Generating Station
Generated: 04/28/2022 13:00 Location: Vernon, California



Tag Name: U2_NOxNormal_Ppmvdc_1H

Total Operating Time: 1,766.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 394.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,766.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

Unit 2 - VOC ppmvdc 1-hour during Normal Operation

From: 01/01/2022 00:00 **To:** 03/31/2022 23:59 **Facility Name:** Malburg Generating Station
Generated: 04/28/2022 13:00 **Location:** Vernon, California



Tag Name: U2_VOCNormal_Ppmvdc_1H

Total Operating Time: 1,766.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 394.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,766.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Quad K Excess Emissions Report

U2 NOX 4-Hour Events

From: 01/01/2022 00:00 To: 03/31/2022 23:59
Generated: 04/28/2022 13:01

Facility Name: Malburg Generating Station
Location: Vernon, California



Tag Name: U2_NOx4H_Ppmvdc_1H

Total Operating Time: 1,766.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 394.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,766.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %