

DOCKETED	
Docket Number:	08-AFC-07C
Project Title:	GWF Tracy (Compliance)
TN #:	242939
Document Title:	QUARTERLY AIR QUALITY REPORT- Q1 2022
Description:	N/A
Filer:	Anwar Ali
Organization:	MRP San Joaquin Energy LLC
Submitter Role:	Applicant
Submission Date:	5/5/2022 6:40:45 PM
Docketed Date:	5/6/2022

MRP San Joaquin Energy, LLC

April 28, 2022

Mr. Anwar Ali
Compliance Project Manager
California Energy Commission
1516 Ninth Street
Sacramento, CA. 95814

Reference: MRP- San Joaquin Energy, LLC. Tracy Combined Cycle Power Plant
Facility No. 08-AFC-07

Subject: CEC Conditions of Certification AQ-16 – AQ-170
Quarterly Compliance Report First Quarter 2022

Dear Mr. Ali,

Enclosed please find the Quarterly Compliance Report for the first quarter of 2022 as required per the Conditions of Certification as set forth in the California Energy Commission's Final Decision for MRP- San Joaquin Energy, LLC - Tracy Combined Cycle Power Plant Project (No. 08-AFC-07).

If you have any questions regarding this report, please contact Taylor Leach at (209) 275-7079 or e-mail: Taylor.Leach@naes.com.

Sincerely,



Claude Couvillion
Vice President of Operations

**MRP-San Joaquin Energy Inc.
Tracy Power Plant**

Quarterly Air Compliance Report

First Quarter 2022

This report documents compliance with the California Energy Commission's Conditions of Certification.

Attached are summaries of relevant permit conditions and compliance status as required documentation.

Attachment 1: Summary table identifying each condition, compliance status, reference to compliance documents.

Attachment 2: Rolling Year Emissions Mass Summary

Attachment 3: Breakdown/Deviation Reports filed this quarter

Attachment 4: Breakdown follow up reports filed this quarter

Attachment 5: Daily Emissions Report for this quarter

Attachment 6: Gas Sulfur content 12 month rolling average

Attachment 7: Startup and shutdown summaries

Attachment 8: Fuel usage

Attachment 9: Fuel sulfur analysis completed this quarter

Attachment 10: CEMs Operations Reports

Attachment 11: Emergency Generator Run Log

Attachment 12: Aux Boiler Run Log

Attachment 13: Emergency Fire Pump Run Log

Attachment 14: Aux Boiler Compliance

Attachment 15: Dust Suppression Control Measures

**ATTACHMENT 1
COMPLIANCE SUMMARY**

COMPLIANCE SUMMARY

Condition Number	Permit Condition	Status	Document
AQ- SC9,16,41, 73	Annual Total Mass Emissions	In Compliance	A-2, A-16 – Submitted Q4 yearly
AQ-20	Report Breakdowns	In Compliance	A-3
AQ-21	Breakdown Follow up Reporting	In Compliance	A-4
AQ-26,38,39,73	Ammonia Slip	In Compliance	A-5
AQ-29,52,53,54,132,144,145	Fuel Sulfur	In Compliance	A-6, A-8, A-9
AQ-30,31,40,63,73,74	Emissions Rates	In compliance	A-2, A-5
AQ-32,33	Startup and Shutdown Mass Emissions	In Compliance	A-2, A-7
AQ-34,35,36,74	Startup and Shutdown Time	In Compliance	A-7
AQ-44,73	Annual Fuel Usage	In Compliance	A-8
AQ-59	CEMs Audits	In Compliance	Results submitted separately
AQ-60	CEMs Annual RATA	In Compliance	Results submitted separately
AQ-70	CEMs Operation/Downtime	In Compliance	A-10
AQ-71	Formula if CEMs is not operating properly	In Compliance	Formula Provided in the ACC submitted to the CEC annually
AQ-72	Records if CEMs is not working properly	In Compliance	Same as above
AQ-75	All Records Five Years	In Compliance	All Attachments
AQ-110,111,113,115,116,117,118	Emergency Diesel Generator	In Compliance	A-11
AQ-131,149,150,151	Aux Boiler	In Compliance	A-12
AQ-133	Aux Boiler Emissions	In compliance	A-14
AQ-166,167,168,169,170	Emergency Fire Pump	In Compliance	A-13
AQ-101	Dust Suppression	I-C	A-15

ATTACHMENT 2
ROLLING YEAR EMISSIONS MASS SUMMARY

TRACY COMBINED CYCLE POWER PLANT

Tracy, CA

Unit 1 - Annual Mass Emissions

March 2022 12-Month Rolling

ROLLING ANNUAL LBS LIMIT: CO = 74,598 NOx = 88,881 PM10= 32,250 SOx = 7,084 VOC = 15,145

Month	CO lbs		NOx lbs		PM lbs		SO2 lbs		VOC lbs	
	Monthly Total	12-Mont h Rolling Total	Monthly Total	12-Mont h Rolling Total	Monthly Total	12-Mont h Rolling Total	Monthly Total	12-Mont h Rolling Total	Monthly Total	12-Mont h Rolling Total
Apr 2021	286	8259	1019	26777	170	5160	48	1894	7	284
May 2021	222	8256	1095	27025	136	5168	40	1857	6	277
Jun 2021	568	8519	2246	27688	554	5573	165	1936	21	283
Jul 2021	1039	9235	3796	29369	1061	6464	307	2144	39	304
Aug 2021	829	9022	3500	29024	825	6771	239	2073	31	283
Sep 2021	254	8727	1566	28234	341	6866	99	2025	80	338
Oct 2021	325	8331	1083	26089	222	6531	64	1914	54	365
Nov 2021	327	8023	1610	25230	203	6303	62	1847	16	363
Dec 2021	871	8415	4133	27117	709	6489	211	1906	106	449
Jan 2022	224	7629	1349	26479	148	6066	45	1784	16	442
Feb 2022	227	6607	1087	25091	136	5366	41	1580	19	428
Mar 2022	301	5473	2056	24540	188	4693	56	1377	25	420

TRACY COMBINED CYCLE POWER PLANT

Tracy, CA

Unit 2 - Annual Mass Emissions

March 2022 12-Month Rolling

ROLLING ANNUAL LBS LIMIT: CO = 74,598 NOx = 88,881 PM10= 32,250 SOx = 7,084 VOC = 15,145

Month	CO lbs		NOx lbs		PM lbs		SO2 lbs		VOC lbs	
	Monthly Total	12-Month Rolling Total	Monthly Total	12-Month Rolling Total	Monthly Total	12-Month Rolling Total	Monthly Total	12-Month Rolling Total	Monthly Total	12-Month Rolling Total
Apr 2021	318	2542	4549	38879	709	7746	209	2304	397	2377
May 2021	249	2637	3110	39041	393	7388	118	2194	233	2546
Jun 2021	199	2716	3694	39621	681	7528	200	2234	507	3000
Jul 2021	232	2836	4312	39421	1105	7769	322	2301	1060	3974
Aug 2021	316	2877	4570	39310	1124	7670	331	2265	870	4697
Sep 2021	189	2724	3281	38394	268	7245	140	2200	80	4693
Oct 2021	215	2640	2185	35364	199	6579	116	2064	50	4258
Nov 2021	161	2524	1387	33228	90	6134	55	1959	29	4024
Dec 2021	243	2594	3213	33808	308	5869	183	1975	83	3628
Jan 2022	109	2647	1346	34743	68	5912	41	2008	21	3643
Feb 2022	93	2415	748	32987	53	5112	32	1780	15	3396
Mar 2022	86	2410	972	33367	39	5037	23	1770	11	3356

ATTACHMENT 3
BREAKDOWN/DEVIATION REPORTS FILED THIS QUARTER

No Breakdowns/Deviations occurred during the first quarter of 2022.

ATTACHMENT 4
BREAKDOWN FOLLOW UP REPORTS FILED THIS QUARTER

No Breakdowns/Deviations occurred during the first quarter of 2022.

ATTACHMENT 5
DAILY EMISSIONS REPORTS FOR THIS QUARTER

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 January 1, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 January 2, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
January 3, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.37	Startup
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
05	1.4	3.43	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Startup
06	1.5	5.28	8.10	NSD	NSD	3.90	0.1	0.12	9.40	Off	1.00	Normal
07	1.5	5.26	8.10	1.1	2.19	3.90	0.2	0.23	9.40	Off	1.00	Normal
08	1.5	2.62	8.10	1.2	2.12	3.90	0.2	0.23	9.40	Off	0.78	Shutdown
09	N/A	N/A	8.10	NSD	NSD	3.90	0.2	0.23	9.40	Off	0.00	Down
10	N/A	N/A	8.10	NSD	NSD	3.90	0.2	0.23	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.23	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.23	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.23	9.40	Off	0.22	Startup
14	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.23	9.40	Off	1.00	Startup
15	1.5	3.66	8.10	NSD	NSD	3.90	0.2	0.23	9.40	Off	1.00	Startup
16	1.5	5.16	8.10	NSD	NSD	3.90	0.3	0.35	9.40	Off	1.00	Normal
17	1.5	5.37	8.10	0.9	1.72	3.90	0.3	0.47	9.40	Off	1.00	Normal
18	1.5	5.40	8.10	1.0	2.11	3.90	0.4	0.59	9.40	Off	1.00	Normal
19	1.5	5.30	8.10	1.0	2.08	3.90	0.5	0.66	9.40	Off	1.00	Normal
20	1.5	5.28	8.10	0.9	2.05	3.90	0.5	0.78	9.40	Off	1.00	Normal
21	1.5	5.28	8.10	1.0	2.08	3.90	0.6	0.90	9.40	Off	1.00	Normal
22	1.5	5.30	8.10	1.0	2.11	3.90	0.7	1.02	9.40	Off	1.00	Normal
23	N/A	N/A	8.10	NSD	NSD	3.90	0.7	1.02	9.40	Off	0.28	Shutdown

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
January 4, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	NSD	NSD	3.90	0.7	1.02	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.7	1.02	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.7	1.02	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.7	1.02	9.40	Off	0.30	Startup
04	N/A	N/A	8.10	N/A	N/A	3.90	0.7	1.02	9.40	Off	1.00	Startup
05	1.4	3.37	8.10	NSD	NSD	3.90	0.7	1.02	9.40	Off	1.00	Startup
06	1.5	5.29	8.10	NSD	NSD	3.90	0.7	1.02	9.40	Off	1.00	Normal
07	1.5	5.17	8.10	1.2	2.24	3.90	0.6	0.90	9.40	Off	1.00	Shutdown
08	N/A	N/A	8.10	NSD	NSD	3.90	0.6	0.90	9.40	Off	0.27	Shutdown
09	N/A	N/A	8.10	NSD	NSD	3.90	0.6	0.90	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.6	0.90	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.6	0.90	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.6	0.90	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.6	0.90	9.40	Off	0.15	Startup
14	N/A	N/A	8.10	N/A	N/A	3.90	0.6	0.90	9.40	Off	1.00	Startup
15	1.5	3.99	8.10	NSD	NSD	3.90	0.6	0.90	9.40	Off	1.00	Startup
16	1.6	5.72	8.47	NSD	NSD	4.25	0.6	0.82	9.40	On	1.00	Normal
17	1.4	5.23	10.30	0.8	1.59	6.00	0.5	0.79	9.40	On	1.00	Normal
18	1.5	5.46	10.30	0.9	1.97	6.00	0.5	0.75	9.40	On	1.00	Normal
19	1.5	5.34	10.08	0.9	2.03	6.00	0.5	0.75	9.40	On	1.00	Normal
20	1.5	5.41	8.10	1.0	2.26	6.00	0.5	0.75	9.40	Off	1.00	Normal
21	1.5	5.32	8.10	1.1	2.39	5.79	0.5	0.71	9.40	Off	1.00	Normal
22	1.5	5.43	8.10	1.1	2.48	3.90	0.5	0.67	9.40	Off	1.00	Normal
23	N/A	N/A	8.10	NSD	NSD	3.90	0.5	0.67	9.40	Off	0.28	Shutdown

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 January 5, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	NSD	NSD	3.90	0.5	0.67	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.67	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.67	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.67	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.67	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.67	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.56	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.56	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.56	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.56	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.56	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.56	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.56	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.56	9.40	Off	0.40	Startup
14	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.56	9.40	Off	1.00	Startup
15	1.5	3.90	8.10	NSD	NSD	3.90	0.4	0.56	9.40	Off	1.00	Startup
16	1.4	5.40	8.83	NSD	NSD	4.60	0.4	0.60	9.40	On	1.00	Normal
17	1.5	5.28	10.30	0.8	1.66	6.00	0.3	0.56	9.40	On	1.00	Normal
18	1.5	5.34	10.30	0.9	2.02	6.00	0.3	0.52	9.40	On	1.00	Normal
19	1.5	5.45	10.30	1.0	2.11	6.00	0.3	0.48	9.40	On	1.00	Normal
20	1.5	5.45	10.30	1.0	2.14	6.00	0.3	0.40	9.40	On	1.00	Normal
21	1.5	5.47	10.30	1.0	2.11	6.00	0.2	0.36	9.40	On	1.00	Normal
22	1.4	5.19	10.30	1.0	2.12	6.00	0.2	0.32	9.40	On	1.00	Normal
23	N/A	N/A	8.10	NSD	NSD	6.00	0.2	0.32	9.40	Off	0.27	Shutdown

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
January 6, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	NSD	NSD	6.00	0.2	0.32	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.32	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.32	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.32	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.32	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.32	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.32	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.32	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.32	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.32	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.32	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.32	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.32	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.32	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.32	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.32	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.24	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.16	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.08	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
January 7, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
January 8, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 January 9, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 January 10, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.20	Startup
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
05	1.5	1.16	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Startup
06	1.5	5.13	8.10	NSD	NSD	3.90	0.1	0.15	9.40	Off	1.00	Normal
07	1.5	5.12	8.10	1.3	2.05	3.90	0.2	0.27	9.40	Off	1.00	Normal
08	1.5	4.50	8.10	1.2	2.35	3.90	0.2	0.33	9.40	Off	1.00	Normal
09	N/A	N/A	8.10	NSD	NSD	3.90	0.2	0.33	9.40	Off	0.23	Shutdown
10	N/A	N/A	8.10	NSD	NSD	3.90	0.2	0.33	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.33	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.33	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.33	9.40	Off	0.32	Startup
14	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.33	9.40	Off	1.00	Startup
15	1.5	3.85	8.10	NSD	NSD	3.90	0.2	0.33	9.40	Off	1.00	Startup
16	1.5	4.99	8.10	NSD	NSD	3.90	0.3	0.37	9.40	Off	1.00	Normal
17	1.5	5.45	8.91	0.9	1.64	4.67	0.3	0.41	9.40	On	1.00	Normal
18	1.5	5.58	10.30	0.9	1.97	6.00	0.3	0.45	9.40	On	1.00	Normal
19	1.5	5.48	10.30	0.9	2.00	6.00	0.3	0.49	9.40	On	1.00	Normal
20	1.5	5.46	10.30	0.8	1.86	6.00	0.4	0.53	9.40	On	1.00	Normal
21	1.5	5.55	10.30	0.8	1.82	6.00	0.4	0.57	9.40	On	1.00	Normal
22	1.5	5.38	9.27	0.8	1.85	6.00	0.4	0.61	9.40	On	1.00	Normal
23	N/A	N/A	8.10	NSD	NSD	6.00	0.4	0.61	9.40	Off	0.27	Shutdown

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 January 11, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	NSD	NSD	5.02	0.4	0.61	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.61	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.61	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.61	9.40	Off	0.20	Startup
04	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.61	9.40	Off	1.00	Startup
05	1.5	3.18	8.10	NSD	NSD	3.90	0.4	0.61	9.40	Off	1.00	Startup
06	Maint	Maint	8.10	Maint	Maint	3.90	0.3	0.48	9.40	Off	1.00	Normal
07	1.5	5.12	8.10	Maint	Maint	3.90	0.3	0.48	9.40	Off	1.00	Normal
08	1.5	1.28	8.10	Maint	Maint	3.90	0.3	0.41	9.40	Off	0.52	Shutdown
09	N/A	N/A	8.10	NSD	NSD	3.90	0.3	0.41	9.40	Off	0.00	Down
10	N/A	N/A	8.10	NSD	NSD	3.90	0.3	0.41	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.41	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.41	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.41	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.41	9.40	Off	0.27	Startup
15	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.41	9.40	Off	1.00	Startup
16	1.6	4.79	8.28	NSD	NSD	4.08	0.3	0.37	9.40	On	1.00	Startup
17	1.5	5.31	10.30	NSD	NSD	6.00	0.3	0.37	9.40	On	1.00	Normal
18	1.5	5.29	10.30	0.9	1.93	6.00	0.3	0.37	9.40	On	1.00	Normal
19	1.5	5.49	10.30	0.9	2.03	6.00	0.3	0.37	9.40	On	1.00	Normal
20	1.5	5.25	8.47	1.0	2.07	6.00	0.3	0.37	9.40	On	1.00	Normal
21	1.5	1.34	8.10	1.0	1.57	6.00	0.2	0.33	9.40	Off	0.53	Shutdown
22	N/A	N/A	8.10	NSD	NSD	4.25	0.2	0.28	9.40	Off	0.00	Down
23	N/A	N/A	8.10	NSD	NSD	3.90	0.2	0.28	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
January 12, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.28	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.28	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.28	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.28	9.40	Off	0.22	Startup
04	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.28	9.40	Off	1.00	Startup
05	1.5	4.14	8.10	NSD	NSD	3.90	0.2	0.28	9.40	Off	1.00	Startup
06	1.5	5.28	8.10	NSD	NSD	3.90	0.3	0.39	9.40	Off	1.00	Normal
07	1.5	5.26	8.10	1.2	2.37	3.90	0.3	0.39	9.40	Off	1.00	Normal
08	1.5	1.31	8.10	1.4	2.14	3.90	0.3	0.39	9.40	Off	0.52	Shutdown
09	N/A	N/A	8.10	NSD	NSD	3.90	0.3	0.39	9.40	Off	0.00	Down
10	N/A	N/A	8.10	NSD	NSD	3.90	0.3	0.39	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.39	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.39	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.39	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.39	9.40	Off	0.20	Startup
15	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.39	9.40	Off	1.00	Startup
16	1.5	4.29	8.10	NSD	NSD	3.90	0.3	0.39	9.40	Off	1.00	Startup
17	1.5	5.39	8.10	NSD	NSD	3.90	0.3	0.39	9.40	Off	1.00	Normal
18	1.5	5.27	8.10	1.1	2.22	3.90	0.3	0.39	9.40	Off	1.00	Normal
19	1.5	5.35	8.10	1.2	2.52	3.90	0.3	0.39	9.40	Off	1.00	Normal
20	1.5	5.26	8.10	1.2	2.52	3.90	0.3	0.39	9.40	Off	1.00	Normal
21	1.5	5.27	8.10	1.2	2.55	3.90	0.3	0.42	9.40	Off	1.00	Normal
22	N/A	N/A	8.10	NSD	NSD	3.90	0.3	0.42	9.40	Off	0.28	Shutdown
23	N/A	N/A	8.10	NSD	NSD	3.90	0.3	0.42	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 January 13, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.42	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.42	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.42	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.42	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.42	9.40	Off	0.20	Startup
05	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.42	9.40	Off	1.00	Startup
06	1.5	4.03	8.10	NSD	NSD	3.90	0.2	0.31	9.40	Off	1.00	Startup
07	1.5	5.23	8.10	NSD	NSD	3.90	0.2	0.31	9.40	Off	1.00	Normal
08	1.5	5.25	8.10	1.2	2.48	3.90	0.3	0.39	9.40	Off	1.00	Normal
09	1.5	2.74	8.10	1.4	2.44	3.90	0.3	0.39	9.40	Off	0.82	Shutdown
10	N/A	N/A	8.10	NSD	NSD	3.90	0.3	0.39	9.40	Off	0.00	Down
11	N/A	N/A	8.10	NSD	NSD	3.90	0.3	0.39	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.39	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.39	9.40	Off	0.22	Startup
14	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.39	9.40	Off	1.00	Startup
15	1.5	3.59	8.10	NSD	NSD	3.90	0.3	0.39	9.40	Off	1.00	Startup
16	1.5	5.09	8.10	NSD	NSD	3.90	0.3	0.46	9.40	Off	1.00	Normal
17	1.5	5.39	8.10	1.0	1.97	3.90	0.3	0.46	9.40	Off	1.00	Normal
18	1.5	5.39	8.10	1.2	2.57	3.90	0.3	0.46	9.40	Off	1.00	Normal
19	1.5	5.39	8.10	1.3	2.76	3.90	0.3	0.47	9.40	Off	1.00	Normal
20	1.5	5.26	8.10	1.3	2.77	3.90	0.3	0.43	9.40	Off	1.00	Shutdown
21	N/A	N/A	8.10	NSD	NSD	3.90	0.3	0.39	9.40	Off	0.27	Shutdown
22	N/A	N/A	8.10	NSD	NSD	3.90	0.3	0.39	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.39	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 January 14, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.39	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.39	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.39	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.39	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.39	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.39	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.39	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.27	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.08	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 January 15, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 January 16, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 January 17, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 January 18, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 January 19, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 January 20, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 January 21, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 January 22, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 January 23, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 January 24, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 January 25, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 January 26, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 January 27, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 January 28, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
January 29, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 January 30, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 January 31, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
February 1, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 February 2, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
February 3, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	<i>ppm @ 15% O2</i>	<i>lbs</i>	<i>ppm @ 15% O2</i>	<i>lbs</i>	<i>ppm @ 15% O2</i>	<i>lbs</i>
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.93	Startup
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
05	1.5	4.86	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Startup
06	1.5	5.36	10.23	NSD	NSD	5.93	0.1	0.12	9.40	On	1.00	Normal
07	1.5	4.66	9.64	0.9	1.86	5.93	0.1	0.19	9.40	On	1.00	Normal
08	N/A	N/A	8.10	NSD	NSD	5.93	0.1	0.19	9.40	Off	0.22	Shutdown
09	N/A	N/A	8.10	NSD	NSD	5.37	0.1	0.19	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.18	Startup
15	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	1.00	Startup
16	1.5	4.21	8.10	NSD	NSD	3.90	0.1	0.19	9.40	Off	1.00	Startup
17	1.5	5.33	8.10	NSD	NSD	3.90	0.2	0.27	9.40	Off	1.00	Normal
18	1.5	5.39	8.10	1.1	2.13	3.90	0.2	0.34	9.40	Off	1.00	Normal
19	1.5	5.38	8.10	1.1	2.28	3.90	0.3	0.42	9.40	Off	1.00	Normal
20	1.5	5.29	8.10	1.0	2.21	3.90	0.3	0.54	9.40	Off	1.00	Normal
21	1.5	5.18	8.10	1.0	2.21	3.90	0.4	0.66	9.40	Off	1.00	Normal
22	1.5	5.37	8.10	1.1	2.24	3.90	0.5	0.77	9.40	Off	1.00	Normal
23	1.5	5.29	8.10	1.1	2.30	3.90	0.6	0.89	9.40	Off	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 February 4, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.5	5.37	8.10	1.1	2.40	3.90	0.6	1.01	9.40	Off	1.00	Normal
01	1.5	5.27	8.10	1.2	2.46	3.90	0.7	1.13	9.40	Off	1.00	Normal
02	1.5	4.57	8.10	1.1	2.16	3.90	0.8	1.19	9.40	Off	1.00	Normal
03	1.4	4.19	8.10	0.9	1.71	3.90	0.9	1.29	9.40	Off	1.00	Normal
04	1.3	4.27	8.10	0.8	1.50	3.90	1.0	1.47	9.40	Off	1.00	Normal
05	1.1	4.04	8.10	0.9	1.87	3.90	1.2	1.67	9.40	Off	1.00	Normal
06	1.1	4.04	8.10	1.1	2.42	3.90	1.2	1.75	9.40	Off	1.00	Normal
07	1.4	4.80	8.10	1.2	2.69	3.90	1.2	1.76	9.40	Off	1.00	Normal
08	N/A	N/A	8.10	NSD	NSD	3.90	1.2	1.76	9.40	Off	0.28	Shutdown
09	N/A	N/A	8.10	NSD	NSD	3.90	1.2	1.76	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	1.2	1.76	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	1.2	1.76	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	1.2	1.76	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	1.2	1.76	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	1.2	1.76	9.40	Off	0.27	Startup
15	N/A	N/A	8.10	N/A	N/A	3.90	1.2	1.76	9.40	Off	1.00	Startup
16	1.5	3.46	8.10	NSD	NSD	3.90	1.2	1.76	9.40	Off	1.00	Startup
17	1.5	5.36	8.10	NSD	NSD	3.90	1.3	1.79	9.40	Off	1.00	Normal
18	1.5	5.38	8.10	1.2	2.25	3.90	1.3	1.83	9.40	Off	1.00	Normal
19	1.5	5.37	8.10	1.2	2.62	3.90	1.3	1.87	9.40	Off	1.00	Normal
20	1.5	5.27	8.10	1.2	2.56	3.90	1.3	1.87	9.40	Off	1.00	Normal
21	1.5	5.25	8.10	1.2	2.52	3.90	1.4	1.87	9.40	Off	1.00	Normal
22	1.5	5.26	8.10	1.2	2.45	3.90	1.4	1.87	9.40	Off	1.00	Normal
23	N/A	N/A	8.10	NSD	NSD	3.90	1.3	1.75	9.40	Off	0.28	Shutdown

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
February 5, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	NSD	NSD	3.90	1.2	1.64	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	1.1	1.52	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	1.1	1.45	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	1.0	1.35	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.8	1.17	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.7	0.98	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.78	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.70	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.70	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.70	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.70	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.70	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.70	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.70	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.70	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.70	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.70	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.59	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.47	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.35	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.23	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 February 6, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 February 7, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 February 8, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 February 9, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 February 10, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 February 11, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
February 12, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
February 13, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 February 14, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 February 15, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.70	Startup
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
09	1.5	4.10	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Startup
10	1.5	5.54	8.10	NSD	NSD	3.90	0.1	0.12	9.40	Off	1.00	Normal
11	1.5	4.54	8.10	0.6	1.20	3.90	0.1	0.16	9.40	Off	1.00	Normal
12	1.5	4.57	8.10	0.7	1.35	3.90	0.2	0.26	9.40	Off	1.00	Normal
13	N/A	N/A	8.10	NSD	NSD	3.90	0.2	0.26	9.40	Off	0.23	Shutdown
14	N/A	N/A	8.10	NSD	NSD	3.90	0.2	0.26	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.26	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.26	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.26	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.26	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.26	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.26	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.26	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.26	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.26	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
February 16, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.26	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.26	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.26	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.26	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.26	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.26	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.26	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.26	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.26	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.26	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.13	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.10	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 February 17, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 February 18, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 February 19, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 February 20, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 February 21, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 February 22, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 February 23, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.95	Startup
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
23	1.5	1.00	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Startup

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
February 24, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @15% O2	lbs	ppm @15% O2	lbs	ppm @15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.4	5.08	8.61	NSD	NSD	4.39	0.1	0.08	9.40	On	1.00	Normal
01	1.6	7.14	10.30	0.8	1.17	6.00	0.3	0.54	9.40	On	1.00	Normal
02	1.5	6.98	10.30	0.6	1.38	6.00	0.6	0.94	9.40	On	1.00	Normal
03	1.5	6.82	10.30	0.4	1.08	6.00	0.8	1.35	9.40	On	1.00	Normal
04	1.5	6.75	10.30	0.4	1.11	6.00	1.0	1.75	9.40	On	1.00	Normal
05	1.6	7.24	10.30	0.4	1.19	6.00	1.2	2.10	9.40	On	1.00	Normal
06	1.7	7.71	10.30	0.4	1.23	6.00	1.4	2.44	9.40	On	1.00	Normal
07	1.6	6.42	10.30	0.6	1.48	6.00	1.5	2.57	9.40	On	1.00	Normal
08	1.6	3.21	9.24	0.7	1.41	6.00	1.5	2.57	9.40	On	0.80	Shutdown
09	N/A	N/A	8.10	NSD	NSD	6.00	1.5	2.57	9.40	Off	0.00	Down
10	N/A	N/A	8.10	NSD	NSD	4.99	1.5	2.57	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	1.5	2.57	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	1.5	2.57	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	1.5	2.57	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	1.5	2.57	9.40	Off	0.15	Startup
15	N/A	N/A	8.10	N/A	N/A	3.90	1.5	2.57	9.40	Off	1.00	Startup
16	1.7	4.20	8.10	NSD	NSD	3.90	1.5	2.57	9.40	Off	1.00	Startup
17	1.7	6.03	8.10	NSD	NSD	3.90	1.6	2.69	9.40	Off	1.00	Normal
18	1.7	5.98	8.10	0.9	1.71	3.90	1.6	2.77	9.40	Off	1.00	Normal
19	1.6	5.84	8.28	1.0	2.11	4.08	1.6	2.81	9.40	On	1.00	Normal
20	1.5	5.59	10.30	1.0	2.14	6.00	1.7	2.89	9.40	On	1.00	Normal
21	1.5	5.54	10.30	1.0	2.16	6.00	1.7	2.97	9.40	On	1.00	Normal
22	1.5	5.32	10.30	0.9	2.04	6.00	1.8	3.05	9.40	On	1.00	Normal
23	1.5	5.32	10.30	0.9	2.06	6.00	1.8	3.13	9.40	On	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 February 25, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.5	5.34	10.30	1.0	2.08	6.00	1.8	3.13	9.40	On	1.00	Normal
01	1.5	5.32	10.30	1.0	2.10	6.00	1.6	2.75	9.40	On	1.00	Normal
02	1.5	5.41	10.30	1.0	2.07	6.00	1.4	2.42	9.40	On	1.00	Normal
03	1.5	5.42	10.30	1.0	2.06	6.00	1.2	2.10	9.40	On	1.00	Normal
04	1.5	5.45	10.30	1.0	2.16	6.00	1.1	1.78	9.40	On	1.00	Normal
05	1.5	5.44	10.30	1.0	2.23	6.00	0.9	1.51	9.40	On	1.00	Normal
06	1.5	5.33	10.30	1.0	2.27	6.00	0.8	1.24	9.40	On	1.00	Normal
07	1.5	5.31	10.08	1.1	2.26	6.00	0.7	1.19	9.40	On	1.00	Normal
08	N/A	N/A	8.10	NSD	NSD	6.00	0.7	1.19	9.40	Off	0.28	Shutdown
09	N/A	N/A	8.10	NSD	NSD	5.79	0.7	1.19	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.7	1.19	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.7	1.19	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.7	1.19	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.7	1.19	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.7	1.19	9.40	Off	0.25	Startup
15	N/A	N/A	8.10	N/A	N/A	3.90	0.7	1.19	9.40	Off	1.00	Startup
16	1.5	4.50	8.10	NSD	NSD	3.90	0.7	1.19	9.40	Off	1.00	Startup
17	1.5	5.30	8.10	NSD	NSD	3.90	0.7	1.19	9.40	Off	1.00	Normal
18	1.5	5.27	8.10	0.9	1.91	3.90	0.8	1.23	9.40	Off	1.00	Normal
19	1.5	5.43	8.72	1.0	2.15	4.50	0.8	1.22	9.40	On	1.00	Normal
20	1.5	5.57	10.30	1.0	2.14	6.00	0.8	1.23	9.40	On	1.00	Normal
21	1.5	5.57	10.30	1.0	2.07	6.00	0.8	1.23	9.40	On	1.00	Normal
22	1.5	5.48	10.30	0.9	1.99	6.00	0.8	1.23	9.40	On	1.00	Normal
23	1.5	5.57	10.30	0.9	1.99	6.00	0.8	1.23	9.40	On	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 February 26, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.5	5.30	9.31	0.9	2.03	6.00	0.8	1.15	9.40	On	1.00	Shutdown
01	N/A	N/A	8.10	NSD	NSD	6.00	0.7	1.07	9.40	Off	0.27	Shutdown
02	N/A	N/A	8.10	NSD	NSD	5.06	0.7	0.99	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.6	0.92	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.6	0.84	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.76	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.68	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.60	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.60	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.60	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.60	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.60	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.60	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.60	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.60	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.60	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.60	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.48	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.36	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.33	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.24	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.16	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.08	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 February 27, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 February 28, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 March 1, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.62	Startup
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
16	1.4	4.05	8.10	NSD	NSD	3.90	0.1	0.13	9.40	Off	1.00	Normal
17	1.5	4.91	8.10	NSD	NSD	3.90	0.2	0.20	9.40	Off	1.00	Normal
18	1.5	5.16	8.10	0.9	1.82	3.90	0.3	0.28	9.40	Off	1.00	Normal
19	1.5	5.08	8.10	1.2	2.38	3.90	0.3	0.36	9.40	Off	1.00	Normal
20	1.5	5.09	8.10	1.2	2.56	3.90	0.4	0.43	9.40	Off	1.00	Normal
21	1.5	4.87	8.10	1.3	2.60	3.90	0.4	0.43	9.40	Off	1.00	Shutdown
22	N/A	N/A	8.10	NSD	NSD	3.90	0.4	0.43	9.40	Off	0.27	Shutdown
23	N/A	N/A	8.10	NSD	NSD	3.90	0.4	0.43	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 March 2, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.43	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.43	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.43	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.43	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.43	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.43	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.43	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.43	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.43	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.43	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.43	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.43	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.43	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.43	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.43	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.43	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.31	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.23	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.15	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.08	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 March 3, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 March 4, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 March 5, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 March 6, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 March 7, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 March 8, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 March 9, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 March 10, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 March 11, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 March 12, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 March 13, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
March 14, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.87	Startup
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
04	1.5	4.00	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Startup
05	1.5	5.02	8.10	NSD	NSD	3.90	0.1	0.11	9.40	Off	1.00	Normal
06	1.5	4.96	8.10	1.0	2.06	3.90	0.2	0.23	9.40	Off	1.00	Normal
07	1.5	4.96	8.10	1.3	2.74	3.90	0.3	0.34	9.40	Off	1.00	Normal
08	N/A	N/A	8.10	NSD	NSD	3.90	0.3	0.34	9.40	Off	0.27	Shutdown
09	N/A	N/A	8.10	NSD	NSD	3.90	0.3	0.34	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.34	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.34	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.34	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.34	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.34	9.40	Off	0.05	Startup
15	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.34	9.40	Off	1.00	Startup
16	1.2	0.31	8.10	NSD	NSD	3.90	0.3	0.34	9.40	Off	1.00	Startup
17	1.4	4.61	9.71	NSD	NSD	5.44	0.3	0.38	9.40	On	1.00	Normal
18	1.5	5.33	10.30	1.0	1.47	6.00	0.4	0.42	9.40	On	1.00	Normal
19	1.5	5.34	10.30	1.0	2.14	6.00	0.4	0.46	9.40	On	1.00	Normal
20	1.5	5.22	10.30	1.0	2.19	6.00	0.4	0.50	9.40	On	1.00	Normal
21	1.5	5.29	9.49	1.0	2.18	6.00	0.5	0.54	9.40	On	1.00	Normal
22	N/A	N/A	8.10	NSD	NSD	6.00	0.5	0.54	9.40	Off	0.28	Shutdown
23	N/A	N/A	8.10	NSD	NSD	5.23	0.5	0.54	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
March 15, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.54	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.54	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.54	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.54	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.54	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.42	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.31	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.20	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.20	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.20	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.20	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.20	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.20	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.20	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.20	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.20	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.20	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.16	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.08	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 March 16, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 March 17, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 March 18, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 March 19, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.52	Startup
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
12	1.5	3.55	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Startup
13	1.5	4.31	8.10	NSD	NSD	3.90	0.1	0.07	9.40	Off	1.00	Normal
14	1.5	5.13	9.02	1.0	1.74	4.78	0.1	0.14	9.40	On	1.00	Normal
15	1.6	7.37	10.30	0.7	1.54	6.00	0.4	0.50	9.40	On	1.00	Normal
16	1.6	7.17	10.30	0.6	1.37	6.00	0.6	0.86	9.40	On	1.00	Normal
17	1.6	6.20	10.30	0.4	1.02	6.00	0.7	0.99	9.40	On	1.00	Normal
18	1.5	5.20	10.30	0.7	1.49	6.00	0.7	1.03	9.40	On	1.00	Normal
19	1.5	5.55	10.30	0.9	1.92	6.00	0.8	1.19	9.40	On	1.00	Normal
20	1.5	5.98	10.30	0.9	2.00	6.00	1.0	1.42	9.40	On	1.00	Normal
21	1.5	5.27	10.30	0.9	2.06	6.00	1.0	1.50	9.40	On	1.00	Normal
22	1.5	5.30	10.30	1.0	2.24	6.00	1.1	1.57	9.40	On	1.00	Normal
23	1.5	5.13	8.76	1.2	2.56	6.00	1.1	1.61	9.40	On	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 March 20, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	<i>ppm @ 15% O2</i>	<i>lbs</i>	<i>ppm @ 15% O2</i>	<i>lbs</i>	<i>ppm @ 15% O2</i>	<i>lbs</i>
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.5	5.00	8.10	1.2	2.50	6.00	1.1	1.65	9.40	Off	1.00	Normal
01	1.5	4.63	8.10	1.1	2.25	4.53	1.2	1.72	9.40	Off	1.00	Normal
02	1.5	4.42	8.10	0.9	1.80	3.90	1.3	1.79	9.40	Off	1.00	Normal
03	1.5	4.42	8.10	0.8	1.47	3.90	1.3	1.86	9.40	Off	1.00	Normal
04	1.5	4.83	8.10	0.9	1.58	3.90	1.4	1.97	9.40	Off	1.00	Normal
05	1.5	4.69	8.10	0.9	1.79	3.90	1.5	2.04	9.40	Off	1.00	Normal
06	1.5	4.75	8.10	1.0	1.97	3.90	1.5	2.15	9.40	Off	1.00	Normal
07	1.5	4.27	8.10	0.8	1.62	3.90	1.6	2.21	9.40	Off	1.00	Normal
08	1.5	4.53	8.10	0.8	1.46	3.90	1.7	2.28	9.40	Off	1.00	Normal
09	1.5	4.36	8.10	0.7	1.30	3.90	1.7	2.35	9.40	Off	1.00	Normal
10	1.5	4.30	8.10	0.8	1.38	3.90	1.8	2.41	9.40	Off	1.00	Normal
11	1.5	4.41	8.10	0.8	1.36	3.90	1.9	2.48	9.40	Off	1.00	Normal
12	1.5	4.40	8.10	0.8	1.39	3.90	1.9	2.54	9.40	Off	1.00	Normal
13	1.5	4.41	8.10	0.8	1.44	3.90	1.9	2.54	9.40	Off	1.00	Normal
14	1.5	4.41	8.10	0.8	1.47	3.90	1.9	2.53	9.40	Off	1.00	Normal
15	1.5	4.39	8.10	0.8	1.47	3.90	1.7	2.24	9.40	Off	1.00	Normal
16	1.5	4.61	8.10	0.9	1.68	3.90	1.6	1.99	9.40	Off	1.00	Normal
17	1.5	4.41	8.10	1.0	1.75	3.90	1.6	1.93	9.40	Off	1.00	Normal
18	1.5	5.12	8.10	1.2	2.27	3.90	1.6	2.00	9.40	Off	1.00	Normal
19	1.5	5.11	8.10	1.3	2.58	3.90	1.6	1.91	9.40	Off	1.00	Normal
20	1.5	1.30	8.10	1.5	2.27	3.90	1.4	1.69	9.40	Off	0.53	Shutdown
21	N/A	N/A	8.10	NSD	NSD	3.90	1.4	1.61	9.40	Off	0.00	Down
22	N/A	N/A	8.10	NSD	NSD	3.90	1.3	1.53	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	1.3	1.49	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 March 21, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	1.2	1.46	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	1.2	1.38	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	1.1	1.32	9.40	Off	0.12	Startup
03	N/A	N/A	8.10	N/A	N/A	3.90	1.1	1.25	9.40	Off	1.00	Startup
04	1.5	3.49	8.10	NSD	NSD	3.90	1.0	1.14	9.40	Off	1.00	Startup
05	1.5	5.02	8.10	NSD	NSD	3.90	1.0	1.18	9.40	Off	1.00	Normal
06	1.5	5.17	8.10	0.9	1.69	3.90	1.0	1.15	9.40	Off	1.00	Normal
07	N/A	N/A	8.10	NSD	NSD	3.90	0.9	1.09	9.40	Off	0.27	Shutdown
08	N/A	N/A	8.10	NSD	NSD	3.90	0.9	1.02	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.8	0.95	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.7	0.89	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.7	0.82	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.6	0.76	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.6	0.69	9.40	Off	0.05	Startup
14	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.63	9.40	Off	1.00	Startup
15	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.56	9.40	Off	1.00	Startup
16	1.5	3.66	8.10	NSD	NSD	3.90	0.4	0.46	9.40	Off	1.00	Startup
17	1.5	4.96	9.27	NSD	NSD	5.02	0.3	0.43	9.40	On	1.00	Normal
18	1.5	5.48	10.30	1.0	1.89	6.00	0.3	0.39	9.40	On	1.00	Normal
19	1.5	5.29	10.30	1.0	2.23	6.00	0.3	0.40	9.40	On	1.00	Normal
20	1.5	5.47	10.30	1.1	2.29	6.00	0.3	0.48	9.40	On	1.00	Normal
21	1.5	2.65	8.87	1.0	1.87	6.00	0.3	0.48	9.40	On	0.77	Shutdown
22	N/A	N/A	8.10	NSD	NSD	6.00	0.3	0.48	9.40	Off	0.00	Down
23	N/A	N/A	8.10	NSD	NSD	4.64	0.3	0.48	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 March 22, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.48	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.48	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.48	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.48	9.40	Off	0.23	Startup
04	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.48	9.40	Off	1.00	Startup
05	1.8	4.81	8.10	NSD	NSD	3.90	0.2	0.36	9.40	Off	1.00	Startup
06	1.5	4.67	8.10	NSD	NSD	3.90	0.3	0.35	9.40	Off	1.00	Normal
07	1.5	0.08	8.10	1.1	1.18	3.90	0.3	0.35	9.40	Off	0.25	Shutdown
08	N/A	N/A	8.10	NSD	NSD	3.90	0.3	0.35	9.40	Off	0.00	Down
09	N/A	N/A	8.10	NSD	NSD	3.90	0.3	0.35	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.35	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.35	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.35	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.35	9.40	Off	0.13	Startup
14	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.35	9.40	Off	1.00	Startup
15	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.35	9.40	Off	1.00	Startup
16	1.5	2.95	8.10	NSD	NSD	3.90	0.3	0.35	9.40	Off	1.00	Startup
17	1.5	5.09	9.82	NSD	NSD	5.55	0.3	0.35	9.40	On	1.00	Normal
18	1.5	5.53	10.30	0.9	1.64	6.00	0.3	0.31	9.40	On	1.00	Normal
19	1.5	5.43	10.30	0.9	1.91	6.00	0.3	0.31	9.40	On	1.00	Normal
20	1.5	5.45	10.30	0.8	1.85	6.00	0.3	0.32	9.40	On	1.00	Normal
21	1.5	2.69	8.98	0.8	1.53	6.00	0.3	0.32	9.40	On	0.78	Shutdown
22	N/A	N/A	8.10	NSD	NSD	6.00	0.3	0.32	9.40	Off	0.00	Down
23	N/A	N/A	8.10	NSD	NSD	4.74	0.3	0.32	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 March 23, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.32	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.32	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.32	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.32	9.40	Off	0.27	Startup
04	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.32	9.40	Off	1.00	Startup
05	1.4	3.24	8.10	NSD	NSD	3.90	0.3	0.32	9.40	Off	1.00	Startup
06	1.5	4.65	8.10	NSD	NSD	3.90	0.3	0.32	9.40	Off	1.00	Normal
07	1.4	0.08	8.10	1.3	1.27	3.90	0.3	0.32	9.40	Off	0.27	Shutdown
08	N/A	N/A	8.10	NSD	NSD	3.90	0.3	0.32	9.40	Off	0.00	Down
09	N/A	N/A	8.10	NSD	NSD	3.90	0.3	0.32	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.32	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.32	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.32	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.32	9.40	Off	0.17	Startup
14	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.32	9.40	Off	1.00	Startup
15	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.32	9.40	Off	1.00	Startup
16	1.5	3.38	8.10	NSD	NSD	3.90	0.3	0.32	9.40	Off	1.00	Startup
17	1.5	5.56	10.26	NSD	NSD	5.97	0.3	0.32	9.40	On	1.00	Normal
18	1.5	5.45	10.30	0.9	1.66	6.00	0.3	0.36	9.40	On	1.00	Normal
19	1.5	5.67	10.30	0.9	1.90	6.00	0.3	0.32	9.40	On	1.00	Normal
20	1.5	5.66	10.30	0.8	1.84	6.00	0.3	0.32	9.40	On	1.00	Normal
21	1.5	2.67	9.09	0.9	1.57	6.00	0.3	0.32	9.40	On	0.78	Shutdown
22	N/A	N/A	8.10	NSD	NSD	6.00	0.3	0.32	9.40	Off	0.00	Down
23	N/A	N/A	8.10	NSD	NSD	4.85	0.3	0.32	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
March 24, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.32	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.32	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.32	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.32	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.32	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.32	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.25	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.25	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.25	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.25	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.25	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.25	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.25	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.25	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.25	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.25	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.25	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.21	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.13	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.09	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
March 25, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.57	Startup
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
23	1.5	2.91	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Startup

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 March 26, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.5	4.28	8.10	NSD	NSD	3.90	0.1	0.07	9.40	Off	1.00	Normal
01	1.5	4.35	8.10	0.6	0.95	3.90	0.2	0.13	9.40	Off	1.00	Normal
02	1.5	4.26	8.10	0.6	1.11	3.90	0.2	0.19	9.40	Off	1.00	Normal
03	1.5	4.36	8.10	0.7	1.19	3.90	0.3	0.26	9.40	Off	1.00	Normal
04	1.5	4.50	8.10	0.8	1.40	3.90	0.4	0.36	9.40	Off	1.00	Normal
05	1.5	5.02	8.10	1.0	1.93	3.90	0.5	0.44	9.40	Off	1.00	Normal
06	1.5	5.03	8.10	1.2	2.40	3.90	0.5	0.55	9.40	Off	1.00	Normal
07	N/A	N/A	8.10	NSD	NSD	3.90	0.5	0.55	9.40	Off	0.27	Shutdown
08	N/A	N/A	8.10	NSD	NSD	3.90	0.5	0.55	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.55	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.55	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.55	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.55	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.55	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.55	9.40	Off	0.55	Startup
15	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.55	9.40	Off	1.00	Startup
16	1.5	3.64	8.10	NSD	NSD	3.90	0.5	0.55	9.40	Off	1.00	Startup
17	1.4	4.93	9.93	NSD	NSD	5.65	0.6	0.63	9.40	On	1.00	Normal
18	1.5	5.43	10.30	1.0	1.84	6.00	0.7	0.71	9.40	On	1.00	Normal
19	1.5	5.41	10.30	1.0	2.05	6.00	0.7	0.79	9.40	On	1.00	Normal
20	1.5	5.22	10.30	1.0	2.09	6.00	0.8	0.87	9.40	On	1.00	Normal
21	1.5	5.31	10.30	1.0	2.15	6.00	0.8	0.95	9.40	On	1.00	Normal
22	1.5	5.29	10.30	1.0	2.18	6.00	0.8	1.03	9.40	On	1.00	Normal
23	1.5	1.29	8.21	1.1	1.68	6.00	0.8	1.03	9.40	On	0.53	Shutdown

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 March 27, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	NSD	NSD	6.00	0.8	0.97	9.40	Off	0.00	Down
01	N/A	N/A	8.10	NSD	NSD	4.01	0.7	0.90	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.6	0.84	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.77	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.67	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.60	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.48	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.48	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.48	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.48	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.48	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.48	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.48	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.48	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.48	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.48	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.48	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.40	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.32	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.24	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.16	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.08	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 March 28, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 March 29, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.12	Startup
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
08	1.5	1.80	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Startup
09	1.5	4.21	8.10	NSD	NSD	3.90	0.1	0.10	9.40	Off	1.00	Normal
10	1.5	2.15	8.10	0.6	0.69	3.90	0.1	0.10	9.40	Off	0.77	Shutdown
11	N/A	N/A	8.10	NSD	NSD	3.90	0.1	0.10	9.40	Off	0.00	Down
12	N/A	N/A	8.10	NSD	NSD	3.90	0.1	0.10	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.10	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.10	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.10	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.10	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.10	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.10	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.10	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.10	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.10	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.10	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.10	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1 Daily Emission Compliance Report
 March 30, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.10	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.10	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.10	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.10	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.10	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.10	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.10	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.10	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.10	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 1 Daily Emission Compliance Report
March 31, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1- Monthly Mass Emissions Report
 January - 2022

Day	CO lbs (Limit 1,071.60 lbs)	NOx lbs (Limit 814.90 lbs)	CT Gas Flow kscf	DB Gas Flow kscf	Total Flow kscf	Load (MW)
01	Down	Down	Down	Down	Down	Down
02	Down	Down	Down	Down	Down	Down
03	50.3	199.9	11962.7	Down	11963	1005
04	27.8	191.3	11301.7	225.9	11528	944
05	17.9	122.6	7827.8	400.8	8229	652
06	Down	Down	Down	Down	Down	Down
07	Down	Down	Down	Down	Down	Down
08	Down	Down	Down	Down	Down	Down
09	Down	Down	Down	Down	Down	Down
10	52.9	291.2	11968.5	252.2	12221	961
11	20.0	169.6	8838.0	248.7	9087	722
12	27.3	183.8	9767.7	Down	9768	812
13	27.8	190.6	9947.4	Down	9947	824
14	Down	Down	Down	Down	Down	Down
15	Down	Down	Down	Down	Down	Down
16	Down	Down	Down	Down	Down	Down
17	Down	Down	Down	Down	Down	Down
18	Down	Down	Down	Down	Down	Down
19	Down	Down	Down	Down	Down	Down
20	Down	Down	Down	Down	Down	Down
21	Down	Down	Down	Down	Down	Down
22	Down	Down	Down	Down	Down	Down
23	Down	Down	Down	Down	Down	Down
24	Down	Down	Down	Down	Down	Down
25	Down	Down	Down	Down	Down	Down
26	Down	Down	Down	Down	Down	Down
27	Down	Down	Down	Down	Down	Down
28	Down	Down	Down	Down	Down	Down
29	Down	Down	Down	Down	Down	Down
30	Down	Down	Down	Down	Down	Down
31	Down	Down	Down	Down	Down	Down
Monthly Avg	32.0	192.7	10230.5	281.9	10392	846
Monthly Total	224	1349	71613.8	1127.6	72743	5920

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1- Monthly Mass Emissions Report
 February - 2022

Day	CO lbs (Limit 1,071.60 lbs)	NOx lbs (Limit 814.90 lbs)	CT Gas Flow kscf	DB Gas Flow kscf	Total Flow kscf	Load (MW)
01	Down	Down	Down	Down	Down	Down
02	Down	Down	Down	Down	Down	Down
03	54.8	291.0	11827.3	88.4	11916	970
04	38.1	137.5	14235.1	Down	14235	1212
05	Down	Down	Down	Down	Down	Down
06	Down	Down	Down	Down	Down	Down
07	Down	Down	Down	Down	Down	Down
08	Down	Down	Down	Down	Down	Down
09	Down	Down	Down	Down	Down	Down
10	Down	Down	Down	Down	Down	Down
11	Down	Down	Down	Down	Down	Down
12	Down	Down	Down	Down	Down	Down
13	Down	Down	Down	Down	Down	Down
14	Down	Down	Down	Down	Down	Down
15	35.3	176.1	4769.1	Down	4769	367
16	Down	Down	Down	Down	Down	Down
17	Down	Down	Down	Down	Down	Down
18	Down	Down	Down	Down	Down	Down
19	Down	Down	Down	Down	Down	Down
20	Down	Down	Down	Down	Down	Down
21	Down	Down	Down	Down	Down	Down
22	Down	Down	Down	Down	Down	Down
23	29.3	161.5	1418.0	Down	1418	82
24	30.6	157.1	15652.1	1887.6	17540	1348
25	35.1	155.9	15001.8	632.7	15635	1287
26	3.3	7.7	1037.4	28.6	1066	88
27	Down	Down	Down	Down	Down	Down
28	Down	Down	Down	Down	Down	Down
Monthly Avg	32.4	155.3	9134.4	659.3	9511	765
Monthly Total	227	1087	63940.8	2637.3	66579	5354

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 1- Monthly Mass Emissions Report
 March - 2022

Day	CO lbs (Limit 1,071.60 lbs)	NOx lbs (Limit 814.90 lbs)	CT Gas Flow kscf	DB Gas Flow kscf	Total Flow kscf	Load (MW)
01	27.7	197.6	6600.4	Down	6600	527
02	Down	Down	Down	Down	Down	Down
03	Down	Down	Down	Down	Down	Down
04	Down	Down	Down	Down	Down	Down
05	Down	Down	Down	Down	Down	Down
06	Down	Down	Down	Down	Down	Down
07	Down	Down	Down	Down	Down	Down
08	Down	Down	Down	Down	Down	Down
09	Down	Down	Down	Down	Down	Down
10	Down	Down	Down	Down	Down	Down
11	Down	Down	Down	Down	Down	Down
12	Down	Down	Down	Down	Down	Down
13	Down	Down	Down	Down	Down	Down
14	50.6	331.5	10517.2	217.6	10735	837
15	Down	Down	Down	Down	Down	Down
16	Down	Down	Down	Down	Down	Down
17	Down	Down	Down	Down	Down	Down
18	Down	Down	Down	Down	Down	Down
19	47.3	207.8	11942.6	962.5	12905	994
20	37.4	94.8	16635.6	Down	16636	1371
21	22.1	230.6	9279.4	192.9	9472	747
22	19.1	251.6	8514.8	265.2	8780	682
23	19.8	229.5	8495.4	287.6	8783	676
24	Down	Down	Down	Down	Down	Down
25	20.7	175.4	1975.4	Down	1975	128
26	30.7	182.9	13046.1	339.2	13385	1078
27	Down	Down	Down	Down	Down	Down
28	Down	Down	Down	Down	Down	Down
29	25.9	154.2	2777.0	Down	2777	190
30	Down	Down	Down	Down	Down	Down
31	Down	Down	Down	Down	Down	Down
Monthly Avg	30.1	205.6	8978.4	377.5	9205	723
Monthly Total	301	2056	89783.9	2265.0	92048	7230

Tracy Combined Cycle Power Plant
 Tracy, CA
Turbine 1- Monthly Operations Report
 January - 2022

Day	CT Gas Flow kscf	CT Heat Input mmBtu	CT Gas On-Time	DB Gas Flow kscf	DB Heat Input mmBtu	DB Gas On-Time	Total Heat Input mmBtu	Steam Flow To CTG klbs	Steam Flow To CTG On-Time	NH3 Flow lbs	NH3 Flow On-Time	CT Megawatt Hours	Turbine On-Time
01	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
02	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
03	11962.7	12489.0	14.65	Down	Down	0.00	12489	4232.9	14.35	537.0	13.87	1005	14.7
04	11301.7	11798.9	14.00	225.9	235.9	3.07	12035	4227.1	14.00	513.4	13.78	944	14.0
05	7827.8	8172.4	9.67	400.8	418.4	6.33	8591	3041.1	9.44	325.4	9.20	652	9.7
06	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
07	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
08	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
09	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
10	11968.5	12495.0	16.02	252.2	263.3	4.90	12758	4468.1	15.72	536.6	15.29	961	16.0
11	8838.0	9226.6	11.52	248.7	259.7	3.25	9486	3377.2	11.52	401.6	11.17	722	11.5
12	9767.7	10197.7	12.22	Down	Down	0.00	10198	3485.8	12.05	413.4	11.65	812	12.2
13	9947.4	10384.9	12.51	Down	Down	0.00	10385	3596.5	12.51	421.3	12.10	824	12.5
14	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
15	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
16	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
17	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
18	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
19	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
20	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
21	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
22	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
23	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
24	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
25	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
26	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
27	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
28	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
29	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
30	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
31	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
Average Total	10230.5 71613.8	10680.6 74765	90.6	281.9 1127.6	294.3 1177	17.6	10849 75942	3775.5 26428.7	89.6	449.8 3148.7	87.1	846 5920	91

Tracy Combined Cycle Power Plant
 Tracy, CA
Turbine 1- Monthly Operations Report
 February - 2022

Day	CT Gas Flow kscf	CT Heat Input mmBtu	CT Gas On-Time	DB Gas Flow kscf	DB Heat Input mmBtu	DB Gas On-Time	Total Heat Input mmBtu	Steam Flow To CTG klbs	Steam Flow To CTG On-Time	NH3 Flow lbs	NH3 Flow On-Time	CT Megawatt Hours	Turbine On-Time
01	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
02	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
03	11827.3	12347.5	15.33	88.4	92.2	1.67	12440	4299.1	15.03	554.9	14.49	970	15.3
04	14235.1	14861.6	16.83	Down	Down	0.00	14862	5081.1	16.81	681.0	16.59	1212	16.8
05	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
06	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
07	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
08	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
09	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
10	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
11	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
12	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
13	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
14	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
15	4769.1	4978.8	6.93	Down	Down	0.00	4979	1701.2	6.63	216.7	6.21	367	6.9
16	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
17	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
18	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
19	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
20	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
21	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
22	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
23	1418.0	1480.5	2.95	Down	Down	0.00	1481	507.2	2.60	69.4	2.32	82	3.0
24	15652.1	16340.8	17.95	1887.6	1970.3	11.83	18311	6808.5	17.95	1050.2	17.77	1348	18.0
25	15001.8	15661.7	17.53	632.7	660.7	12.18	16322	5653.6	17.53	769.3	17.35	1287	17.5
26	1037.4	1083.0	1.27	28.6	29.9	0.55	1113	390.7	1.27	53.9	1.27	88	1.3
27	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
28	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
Average Total	9134.4 63940.8	9536.3 66754	78.8	659.3 2637.3	688.3 2753	26.2	9930 69508	3491.6 24441.4	77.8	485.1 3395.4	76.0	765 5354	79

Tracy Combined Cycle Power Plant
 Tracy, CA
Turbine 1- Monthly Operations Report
 March - 2022

Day	CT Gas Flow kscf	CT Heat Input mmBtu	CT Gas On-Time	DB Gas Flow kscf	DB Heat Input mmBtu	DB Gas On-Time	Total Heat Input mmBtu	Steam Flow To CTG klbs	Steam Flow To CTG On-Time	NH3 Flow lbs	NH3 Flow On-Time	CT Megawatt Hours	Turbine On-Time
01	6600.4	6732.2	8.89	Down	Down	0.00	6732	2420.6	8.60	286.2	8.20	527	8.9
02	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
03	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
04	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
05	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
06	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
07	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
08	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
09	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
10	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
11	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
12	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
13	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
14	10517.2	10727.5	14.47	217.6	222.1	4.36	10950	3935.9	14.17	493.7	13.77	837	14.5
15	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
16	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
17	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
18	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
19	11942.6	12181.2	14.52	962.5	981.9	8.72	13163	4986.7	14.23	677.3	13.90	994	14.5
20	16635.6	16967.9	20.53	Down	Down	0.00	16968	6007.4	20.53	715.8	20.43	1371	20.5
21	9279.4	9465.0	12.21	192.9	196.8	3.88	9662	3482.3	12.04	417.3	11.70	747	12.2
22	8514.8	8685.0	11.39	265.2	270.6	4.18	8956	3274.7	11.21	373.5	11.01	682	11.4
23	8495.4	8665.5	11.49	287.6	293.4	4.43	8959	3285.3	11.32	391.5	11.13	676	11.5
24	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
25	1975.4	2014.8	3.57	Down	Down	0.00	2015	717.2	3.28	79.9	2.97	128	3.6
26	13046.1	13306.9	16.35	339.2	346.0	5.88	13653	4929.3	16.33	585.7	16.02	1078	16.4
27	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
28	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
29	2777.0	2832.5	4.89	Down	Down	0.00	2833	1024.2	4.62	120.1	4.17	190	4.9
30	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
31	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
Average Total	8978.4 89783.9	9157.9 91579	118.3	377.5 2265.0	385.1 2311	31.5	9389 93891	3406.4 34063.6	116.3	414.1 4141.0	113.3	723 7230	118

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 January 1, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.92	Startup
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
January 2, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.5	4.68	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Startup
01	1.5	5.01	8.10	NSD	NSD	3.90	0.0	0.04	9.40	Off	1.00	Normal
02	N/A	N/A	8.10	NSD	NSD	3.90	0.0	0.04	9.40	Off	0.25	Shutdown
03	N/A	N/A	8.10	NSD	NSD	3.90	0.0	0.04	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.90	Startup
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	1.00	Startup
22	1.5	3.10	8.10	NSD	NSD	3.90	0.0	0.04	9.40	Off	1.00	Startup
23	1.5	5.12	8.10	NSD	NSD	3.90	0.1	0.15	9.40	Off	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
January 3, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	NSD	NSD	3.90	0.1	0.15	9.40	Off	0.25	Shutdown
01	N/A	N/A	8.10	NSD	NSD	3.90	0.1	0.11	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.11	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.11	9.40	Off	0.33	Startup
04	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.11	9.40	Off	1.00	Startup
05	1.3	3.59	8.10	NSD	NSD	3.90	0.1	0.11	9.40	Off	1.00	Startup
06	1.4	4.97	8.10	NSD	NSD	3.90	0.1	0.11	9.40	Off	1.00	Normal
07	1.5	5.24	8.10	0.4	0.69	3.90	0.1	0.19	9.40	Off	1.00	Normal
08	1.5	2.61	8.10	0.4	0.64	3.90	0.1	0.19	9.40	Off	0.77	Shutdown
09	N/A	N/A	8.10	NSD	NSD	3.90	0.1	0.19	9.40	Off	0.00	Down
10	N/A	N/A	8.10	NSD	NSD	3.90	0.1	0.19	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.20	Startup
14	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	1.00	Startup
15	1.5	3.82	8.10	NSD	NSD	3.90	0.1	0.19	9.40	Off	1.00	Startup
16	1.5	5.15	8.10	NSD	NSD	3.90	0.2	0.31	9.40	Off	1.00	Normal
17	1.5	5.26	8.10	0.2	0.47	3.90	0.2	0.39	9.40	Off	1.00	Normal
18	1.5	5.29	8.10	0.3	0.57	3.90	0.3	0.46	9.40	Off	1.00	Normal
19	1.5	5.10	8.10	0.3	0.58	3.90	0.3	0.58	9.40	Off	1.00	Normal
20	1.5	5.27	8.10	0.3	0.58	3.90	0.4	0.66	9.40	Off	1.00	Normal
21	1.5	5.27	8.10	0.3	0.57	3.90	0.4	0.74	9.40	Off	1.00	Normal
22	1.5	5.29	8.10	0.3	0.57	3.90	0.5	0.82	9.40	Off	1.00	Normal
23	N/A	N/A	8.10	NSD	NSD	3.90	0.4	0.70	9.40	Off	0.27	Shutdown

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
January 4, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	NSD	NSD	3.90	0.4	0.70	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.70	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.70	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.70	9.40	Off	0.27	Startup
04	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.70	9.40	Off	1.00	Startup
05	1.3	3.23	8.10	NSD	NSD	3.90	0.4	0.70	9.40	Off	1.00	Startup
06	1.5	5.28	8.10	NSD	NSD	3.90	0.4	0.74	9.40	Off	1.00	Normal
07	1.5	5.16	8.10	0.3	0.64	3.90	0.4	0.66	9.40	Off	1.00	Shutdown
08	N/A	N/A	8.10	NSD	NSD	3.90	0.4	0.66	9.40	Off	0.25	Shutdown
09	N/A	N/A	8.10	NSD	NSD	3.90	0.4	0.66	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.66	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.66	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.66	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.66	9.40	Off	0.15	Startup
14	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.66	9.40	Off	1.00	Startup
15	1.5	3.99	8.10	NSD	NSD	3.90	0.4	0.66	9.40	Off	1.00	Startup
16	1.5	5.43	8.50	NSD	NSD	4.29	0.4	0.59	9.40	On	1.00	Normal
17	1.4	5.09	10.30	0.2	0.45	6.00	0.3	0.55	9.40	On	1.00	Normal
18	1.5	5.44	10.30	0.3	0.55	6.00	0.3	0.51	9.40	On	1.00	Normal
19	1.5	5.41	10.15	0.3	0.58	6.00	0.3	0.43	9.40	On	1.00	Normal
20	1.4	5.11	8.10	0.3	0.65	6.00	0.3	0.43	9.40	Off	1.00	Normal
21	1.5	5.32	8.10	0.3	0.71	5.86	0.3	0.43	9.40	Off	1.00	Normal
22	1.5	5.33	8.10	0.3	0.74	3.90	0.2	0.43	9.40	Off	1.00	Normal
23	N/A	N/A	8.10	NSD	NSD	3.90	0.2	0.43	9.40	Off	0.27	Shutdown

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 January 5, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	NSD	NSD	3.90	0.2	0.43	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.43	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.43	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.43	9.40	Off	0.18	Startup
04	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.43	9.40	Off	1.00	Startup
05	1.4	3.74	8.10	NSD	NSD	3.90	0.2	0.43	9.40	Off	1.00	Startup
06	1.5	5.15	8.10	NSD	NSD	3.90	0.3	0.51	9.40	Off	1.00	Normal
07	1.5	4.55	8.10	0.2	0.44	3.90	0.3	0.51	9.40	Off	1.00	Shutdown
08	N/A	N/A	8.10	NSD	NSD	3.90	0.3	0.51	9.40	Off	0.22	Shutdown
09	N/A	N/A	8.10	NSD	NSD	3.90	0.3	0.51	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.51	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.51	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.51	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.51	9.40	Off	0.27	Startup
14	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.51	9.40	Off	1.00	Startup
15	1.5	3.88	8.10	NSD	NSD	3.90	0.3	0.51	9.40	Off	1.00	Startup
16	1.4	5.29	8.87	NSD	NSD	4.64	0.3	0.55	9.40	On	1.00	Normal
17	1.4	5.26	10.30	0.2	0.45	6.00	0.3	0.55	9.40	On	1.00	Normal
18	1.5	5.43	10.30	0.2	0.53	6.00	0.3	0.55	9.40	On	1.00	Normal
19	1.5	5.43	10.30	0.2	0.56	6.00	0.3	0.55	9.40	On	1.00	Normal
20	1.5	5.44	10.30	0.3	0.59	6.00	0.3	0.52	9.40	On	1.00	Normal
21	1.5	5.32	10.30	0.3	0.56	6.00	0.3	0.48	9.40	On	1.00	Normal
22	1.5	5.42	10.30	0.3	0.56	6.00	0.3	0.44	9.40	On	1.00	Normal
23	N/A	N/A	8.10	NSD	NSD	6.00	0.3	0.44	9.40	Off	0.25	Shutdown

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 January 6, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	NSD	NSD	6.00	0.3	0.44	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.44	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.44	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.44	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.44	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.44	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.33	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.33	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.33	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.33	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.33	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.33	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.33	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.33	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.33	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.33	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.24	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.16	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.08	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 January 7, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 January 8, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 January 9, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 January 10, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.30	Startup
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
15	1.5	3.62	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Startup
16	1.5	4.90	8.10	NSD	NSD	3.90	0.1	0.11	9.40	Off	1.00	Normal
17	1.5	5.24	8.10	0.3	0.48	3.90	0.1	0.19	9.40	Off	1.00	Normal
18	1.5	5.18	8.10	0.3	0.55	3.90	0.1	0.22	9.40	Off	1.00	Normal
19	1.5	5.17	8.10	0.3	0.56	3.90	0.2	0.30	9.40	Off	1.00	Normal
20	1.5	5.15	8.10	0.3	0.53	3.90	0.2	0.38	9.40	Off	1.00	Normal
21	1.5	5.15	8.10	0.2	0.50	3.90	0.2	0.45	9.40	Off	1.00	Normal
22	1.5	5.21	8.10	0.2	0.50	3.90	0.2	0.53	9.40	Off	1.00	Normal
23	N/A	N/A	8.10	NSD	NSD	3.90	0.2	0.53	9.40	Off	0.27	Shutdown

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 January 11, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	NSD	NSD	3.90	0.2	0.53	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.53	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.53	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.53	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.53	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.53	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.53	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.53	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.53	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.53	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.53	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.53	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.53	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.53	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.53	9.40	Off	0.27	Startup
15	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.53	9.40	Off	1.00	Startup
16	1.5	4.57	8.25	NSD	NSD	4.04	0.2	0.42	9.40	On	1.00	Startup
17	1.5	5.26	10.30	NSD	NSD	6.00	0.2	0.38	9.40	On	1.00	Normal
18	1.5	5.38	10.30	0.2	0.49	6.00	0.2	0.39	9.40	On	1.00	Normal
19	1.5	5.38	10.30	0.2	0.52	6.00	0.2	0.35	9.40	On	1.00	Normal
20	1.5	5.24	8.50	0.3	0.55	6.00	0.2	0.31	9.40	On	1.00	Normal
21	1.5	1.31	8.10	0.3	0.44	6.00	0.1	0.24	9.40	Off	0.52	Shutdown
22	N/A	N/A	8.10	NSD	NSD	4.29	0.1	0.16	9.40	Off	0.00	Down
23	N/A	N/A	8.10	NSD	NSD	3.90	0.1	0.16	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 January 12, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.16	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.16	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.16	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.16	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.16	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.16	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.16	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.16	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.16	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.16	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.16	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.16	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.16	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.16	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.16	9.40	Off	0.20	Startup
15	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.16	9.40	Off	1.00	Startup
16	1.5	4.27	8.10	NSD	NSD	3.90	0.1	0.16	9.40	Off	1.00	Startup
17	1.5	5.19	8.10	NSD	NSD	3.90	0.1	0.20	9.40	Off	1.00	Normal
18	1.5	5.27	8.10	0.3	0.55	3.90	0.1	0.20	9.40	Off	1.00	Normal
19	1.5	5.25	8.10	0.3	0.70	3.90	0.1	0.23	9.40	Off	1.00	Normal
20	1.5	5.25	8.10	0.3	0.76	3.90	0.1	0.27	9.40	Off	1.00	Normal
21	1.5	5.26	8.10	0.3	0.76	3.90	0.2	0.35	9.40	Off	1.00	Normal
22	N/A	N/A	8.10	NSD	NSD	3.90	0.2	0.35	9.40	Off	0.27	Shutdown
23	N/A	N/A	8.10	NSD	NSD	3.90	0.2	0.35	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
January 13, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.35	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.35	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.35	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.35	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.35	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.35	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.35	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.35	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.35	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.35	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.35	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.35	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.35	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.35	9.40	Off	0.20	Startup
14	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.35	9.40	Off	1.00	Startup
15	1.5	3.52	8.10	NSD	NSD	3.90	0.2	0.35	9.40	Off	1.00	Startup
16	Maint	Maint	8.10	Maint	Maint	3.90	0.2	0.37	9.40	Off	1.00	Normal
17	1.5	5.19	8.10	Maint	Maint	3.90	0.1	0.33	9.40	Off	1.00	Normal
18	1.5	5.29	8.10	Maint	Maint	3.90	0.1	0.33	9.40	Off	1.00	Normal
19	1.5	5.28	8.10	0.4	0.77	3.90	0.1	0.29	9.40	Off	1.00	Normal
20	1.5	5.16	8.10	0.4	0.79	3.90	0.1	0.20	9.40	Off	1.00	Shutdown
21	N/A	N/A	8.10	NSD	NSD	3.90	0.1	0.12	9.40	Off	0.25	Shutdown
22	N/A	N/A	8.10	NSD	NSD	3.90	0.1	0.12	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
January 14, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.08	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 January 15, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
January 16, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 January 17, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 January 18, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 January 19, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 January 20, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 January 21, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 January 22, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 January 23, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
January 24, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
January 25, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 January 26, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
January 27, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 January 28, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 January 29, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 January 30, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 January 31, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
February 1, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 February 2, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
February 3, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.18	Startup
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
16	1.5	4.13	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Startup
17	1.5	5.33	8.10	NSD	NSD	3.90	0.1	0.12	9.40	Off	1.00	Normal
18	1.5	5.29	8.10	0.3	0.55	3.90	0.1	0.20	9.40	Off	1.00	Normal
19	1.5	5.28	8.10	0.3	0.61	3.90	0.1	0.28	9.40	Off	1.00	Normal
20	1.5	5.28	8.10	0.3	0.58	3.90	0.2	0.35	9.40	Off	1.00	Normal
21	1.5	5.27	8.10	0.3	0.58	3.90	0.2	0.43	9.40	Off	1.00	Normal
22	1.5	5.26	8.10	0.3	0.57	3.90	0.3	0.51	9.40	Off	1.00	Normal
23	1.5	5.28	8.10	0.3	0.57	3.90	0.3	0.59	9.40	Off	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 February 4, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.5	5.27	8.10	0.3	0.64	3.90	0.4	0.67	9.40	Off	1.00	Normal
01	1.5	5.26	8.10	0.3	0.67	3.90	0.4	0.74	9.40	Off	1.00	Normal
02	1.5	4.55	8.10	0.3	0.62	3.90	0.4	0.81	9.40	Off	1.00	Normal
03	1.5	4.42	8.10	0.2	0.47	3.90	0.5	0.88	9.40	Off	1.00	Normal
04	1.5	4.97	8.10	0.2	0.42	3.90	0.5	0.98	9.40	Off	1.00	Normal
05	1.5	5.37	8.10	0.3	0.51	3.90	0.6	1.06	9.40	Off	1.00	Normal
06	1.5	5.27	8.10	0.3	0.66	3.90	0.6	1.14	9.40	Off	1.00	Normal
07	1.5	5.26	8.10	0.4	0.74	3.90	0.7	1.22	9.40	Off	1.00	Normal
08	N/A	N/A	8.10	NSD	NSD	3.90	0.7	1.22	9.40	Off	0.27	Shutdown
09	N/A	N/A	8.10	NSD	NSD	3.90	0.7	1.22	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.7	1.22	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.7	1.22	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.7	1.22	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.7	1.22	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.7	1.22	9.40	Off	0.25	Startup
15	N/A	N/A	8.10	N/A	N/A	3.90	0.7	1.22	9.40	Off	1.00	Startup
16	1.4	3.41	8.10	NSD	NSD	3.90	0.7	1.22	9.40	Off	1.00	Startup
17	1.5	5.26	8.10	NSD	NSD	3.90	0.7	1.22	9.40	Off	1.00	Normal
18	1.5	5.27	8.10	0.4	0.70	3.90	0.7	1.26	9.40	Off	1.00	Normal
19	1.5	5.27	8.10	0.4	0.80	3.90	0.7	1.26	9.40	Off	1.00	Normal
20	1.5	5.26	8.10	0.4	0.77	3.90	0.7	1.29	9.40	Off	1.00	Normal
21	1.5	5.25	8.10	0.3	0.74	3.90	0.7	1.29	9.40	Off	1.00	Normal
22	1.5	5.25	8.10	0.3	0.70	3.90	0.7	1.29	9.40	Off	1.00	Normal
23	N/A	N/A	8.10	NSD	NSD	3.90	0.7	1.22	9.40	Off	0.27	Shutdown

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 February 5, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	NSD	NSD	3.90	0.7	1.14	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.6	1.06	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.6	0.99	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.93	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.82	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.74	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.66	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.58	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.58	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.58	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.58	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.58	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.58	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.58	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.58	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.58	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.58	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.47	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.35	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.27	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.16	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.08	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 February 6, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 February 7, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 February 8, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 February 9, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 February 10, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 February 11, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
February 12, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 February 13, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
February 14, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 February 15, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.68	Startup
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
09	1.5	3.89	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Startup
10	1.5	5.40	8.10	NSD	NSD	3.90	0.1	0.16	9.40	Off	1.00	Normal
11	1.5	4.50	8.10	0.2	0.36	3.90	0.1	0.16	9.40	Off	1.00	Normal
12	1.5	4.46	8.10	0.2	0.38	3.90	0.1	0.20	9.40	Off	1.00	Normal
13	N/A	N/A	8.10	NSD	NSD	3.90	0.1	0.20	9.40	Off	0.22	Shutdown
14	N/A	N/A	8.10	NSD	NSD	3.90	0.1	0.20	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 February 16, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.03	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.03	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 February 17, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 February 18, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 February 19, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 February 20, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 February 21, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 February 22, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 February 23, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 February 24, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.15	Startup
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
16	1.5	4.04	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Startup
17	1.5	5.35	8.10	NSD	NSD	3.90	0.1	0.12	9.40	Off	1.00	Normal
18	1.5	5.30	8.10	0.2	0.48	3.90	0.1	0.20	9.40	Off	1.00	Normal
19	1.5	5.44	8.28	0.3	0.59	4.08	0.1	0.24	9.40	On	1.00	Normal
20	1.4	5.15	10.30	0.3	0.62	6.00	0.2	0.28	9.40	On	1.00	Normal
21	1.4	5.20	10.30	0.3	0.63	6.00	0.2	0.36	9.40	On	1.00	Normal
22	1.4	5.28	10.30	0.2	0.56	6.00	0.3	0.40	9.40	On	1.00	Normal
23	1.5	5.39	10.30	0.2	0.56	6.00	0.3	0.44	9.40	On	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 February 25, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.5	5.41	10.30	0.2	0.52	6.00	0.3	0.48	9.40	On	1.00	Normal
01	1.5	5.39	10.30	0.2	0.52	6.00	0.4	0.52	9.40	On	1.00	Normal
02	1.5	5.39	10.30	0.2	0.49	6.00	0.4	0.56	9.40	On	1.00	Normal
03	1.5	5.39	10.30	0.2	0.49	6.00	0.4	0.60	9.40	On	1.00	Normal
04	1.5	5.41	10.30	0.2	0.49	6.00	0.5	0.64	9.40	On	1.00	Normal
05	1.5	5.40	10.30	0.2	0.49	6.00	0.5	0.68	9.40	On	1.00	Normal
06	1.5	5.39	10.30	0.2	0.49	6.00	0.5	0.72	9.40	On	1.00	Normal
07	1.5	5.25	10.01	0.2	0.52	6.00	0.6	0.76	9.40	On	1.00	Normal
08	N/A	N/A	8.10	NSD	NSD	6.00	0.6	0.76	9.40	Off	0.25	Shutdown
09	N/A	N/A	8.10	NSD	NSD	5.72	0.6	0.76	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.6	0.76	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.6	0.76	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.6	0.76	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.6	0.76	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.6	0.76	9.40	Off	0.25	Startup
15	N/A	N/A	8.10	N/A	N/A	3.90	0.6	0.76	9.40	Off	1.00	Startup
16	1.5	4.58	8.10	NSD	NSD	3.90	0.6	0.76	9.40	Off	1.00	Startup
17	1.5	5.29	8.10	NSD	NSD	3.90	0.5	0.72	9.40	Off	1.00	Normal
18	1.5	5.26	8.10	0.2	0.52	3.90	0.6	0.72	9.40	Off	1.00	Normal
19	1.5	5.24	8.10	0.3	0.57	3.90	0.6	0.76	9.40	Off	1.00	Normal
20	1.5	5.17	8.10	0.3	0.57	3.90	0.6	0.79	9.40	Off	1.00	Normal
21	1.5	5.17	8.10	0.3	0.56	3.90	0.6	0.79	9.40	Off	1.00	Normal
22	1.5	5.17	8.10	0.3	0.56	3.90	0.6	0.82	9.40	Off	1.00	Normal
23	1.5	5.17	8.10	0.3	0.56	3.90	0.6	0.86	9.40	Off	1.00	Normal

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
February 26, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.5	5.12	8.10	0.3	0.56	3.90	0.6	0.82	9.40	Off	1.00	Shutdown
01	N/A	N/A	8.10	NSD	NSD	3.90	0.5	0.78	9.40	Off	0.27	Shutdown
02	N/A	N/A	8.10	NSD	NSD	3.90	0.5	0.74	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.5	0.70	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.66	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.4	0.62	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.58	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.54	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.54	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.54	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.54	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.54	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.54	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.54	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.54	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.54	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.54	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.3	0.46	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.38	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.31	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.23	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.15	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.08	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
February 27, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 February 28, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 March 1, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 March 2, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
March 3, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 March 4, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 March 5, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 March 6, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 March 7, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 March 8, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 March 9, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
March 10, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 March 11, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 March 12, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 March 13, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
March 14, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	<i>ppm @ 15% O2</i>	<i>lbs</i>	<i>ppm @ 15% O2</i>	<i>lbs</i>	<i>ppm @ 15% O2</i>	<i>lbs</i>
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.05	Startup
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
16	0.9	0.73	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Startup
17	1.0	3.24	9.42	NSD	NSD	5.16	0.0	0.08	9.40	On	1.00	Normal
18	1.5	5.41	10.30	0.3	0.42	6.00	0.1	0.08	9.40	On	1.00	Normal
19	1.5	5.33	10.30	0.3	0.54	6.00	0.1	0.12	9.40	On	1.00	Normal
20	1.5	5.31	10.30	0.2	0.51	6.00	0.1	0.16	9.40	On	1.00	Normal
21	1.5	5.05	9.46	0.2	0.51	6.00	0.1	0.20	9.40	On	1.00	Normal
22	N/A	N/A	8.10	NSD	NSD	6.00	0.1	0.20	9.40	Off	0.27	Shutdown
23	N/A	N/A	8.10	NSD	NSD	5.20	0.1	0.20	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
March 15, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.08	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 March 16, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 March 17, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
March 18, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
March 19, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.93	Startup

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 March 20, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	1.5	4.13	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Startup
01	1.4	4.54	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Normal
02	1.5	4.33	8.10	0.2	0.45	3.90	0.0	0.03	9.40	Off	1.00	Normal
03	1.5	4.33	8.10	0.2	0.40	3.90	0.1	0.07	9.40	Off	1.00	Normal
04	1.5	4.73	8.10	0.2	0.44	3.90	0.1	0.14	9.40	Off	1.00	Normal
05	1.4	4.59	8.10	0.3	0.49	3.90	0.1	0.14	9.40	Off	1.00	Normal
06	1.5	0.78	8.10	0.2	0.38	3.90	0.1	0.14	9.40	Off	0.42	Shutdown
07	N/A	N/A	8.10	NSD	NSD	3.90	0.1	0.14	9.40	Off	0.00	Down
08	N/A	N/A	8.10	NSD	NSD	3.90	0.1	0.14	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.14	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.14	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.14	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.14	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.14	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.14	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.14	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.14	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.14	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.14	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.14	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.14	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.14	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.14	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.14	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 March 21, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.14	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.14	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.11	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.07	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.07	Startup
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
16	1.5	3.66	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Startup
17	1.4	4.56	8.10	NSD	NSD	3.90	0.1	0.07	9.40	Off	1.00	Normal
18	1.5	5.11	8.10	0.2	0.41	3.90	0.1	0.11	9.40	Off	1.00	Normal
19	1.5	5.10	8.10	0.2	0.45	3.90	0.1	0.15	9.40	Off	1.00	Normal
20	1.5	5.08	8.10	0.2	0.46	3.90	0.1	0.19	9.40	Off	1.00	Normal
21	1.5	2.60	8.10	0.2	0.38	3.90	0.1	0.19	9.40	Off	0.77	Shutdown
22	N/A	N/A	8.10	NSD	NSD	3.90	0.1	0.19	9.40	Off	0.00	Down
23	N/A	N/A	8.10	NSD	NSD	3.90	0.1	0.19	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 March 22, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	0.13	Startup
14	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	1.00	Startup
15	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.19	9.40	Off	1.00	Startup
16	1.5	2.99	8.10	NSD	NSD	3.90	0.1	0.19	9.40	Off	1.00	Startup
17	1.4	4.79	8.10	NSD	NSD	3.90	0.1	0.15	9.40	Off	1.00	Normal
18	1.5	5.08	8.10	0.2	0.40	3.90	0.1	0.11	9.40	Off	1.00	Normal
19	1.5	5.07	8.10	0.3	0.52	3.90	0.1	0.08	9.40	Off	1.00	Normal
20	1.5	5.06	8.10	0.3	0.55	3.90	0.1	0.04	9.40	Off	1.00	Normal
21	1.5	2.53	8.10	0.3	0.44	3.90	0.1	0.04	9.40	Off	0.77	Shutdown
22	N/A	N/A	8.10	NSD	NSD	3.90	0.1	0.04	9.40	Off	0.00	Down
23	N/A	N/A	8.10	NSD	NSD	3.90	0.1	0.04	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 March 23, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.04	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.04	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.04	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.04	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.04	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.04	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.04	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.04	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.04	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.04	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.04	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.04	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.04	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.04	9.40	Off	0.17	Startup
14	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.04	9.40	Off	1.00	Startup
15	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.04	9.40	Off	1.00	Startup
16	1.5	3.52	8.10	NSD	NSD	3.90	0.1	0.04	9.40	Off	1.00	Startup
17	1.4	5.22	9.38	NSD	NSD	5.13	0.0	0.04	9.40	On	1.00	Normal
18	1.5	5.36	10.30	0.2	0.39	6.00	0.1	0.04	9.40	On	1.00	Normal
19	1.5	5.51	10.30	0.2	0.50	6.00	0.1	0.08	9.40	On	1.00	Normal
20	1.5	5.42	10.30	0.2	0.50	6.00	0.1	0.08	9.40	On	1.00	Normal
21	1.5	2.66	9.09	0.2	0.43	6.00	0.1	0.08	9.40	On	0.77	Shutdown
22	N/A	N/A	8.10	NSD	NSD	6.00	0.1	0.08	9.40	Off	0.00	Down
23	N/A	N/A	8.10	NSD	NSD	4.85	0.1	0.08	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 March 24, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.08	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.08	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.08	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.08	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.08	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.08	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.08	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.08	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.08	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.08	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.08	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.08	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.08	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.08	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.08	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.08	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.08	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 March 25, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 March 26, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.82	Startup
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	1.00	Startup
16	1.5	3.22	8.10	NSD	NSD	3.90	0.0	0.00	9.40	Off	1.00	Startup
17	1.4	4.84	9.90	NSD	NSD	5.62	0.0	0.04	9.40	On	1.00	Normal
18	1.5	5.34	10.30	0.2	0.42	6.00	0.1	0.08	9.40	On	1.00	Normal
19	1.5	5.34	10.30	0.2	0.48	6.00	0.1	0.12	9.40	On	1.00	Normal
20	1.5	5.27	10.30	0.2	0.48	6.00	0.1	0.16	9.40	On	1.00	Normal
21	1.5	5.37	10.30	0.2	0.49	6.00	0.1	0.20	9.40	On	1.00	Normal
22	1.5	5.26	10.30	0.2	0.49	6.00	0.2	0.24	9.40	On	1.00	Normal
23	1.5	1.31	8.25	0.2	0.37	6.00	0.2	0.24	9.40	On	0.52	Shutdown

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
Tracy, CA
Unit 2 Daily Emission Compliance Report
March 27, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	NSD	NSD	6.00	0.2	0.24	9.40	Off	0.00	Down
01	N/A	N/A	8.10	NSD	NSD	4.04	0.2	0.24	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.24	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.24	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.24	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.24	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.24	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.24	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.24	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.24	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.24	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.24	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.24	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.24	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.24	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.24	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.2	0.24	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.20	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.16	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.12	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.1	0.08	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.04	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 March 28, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 March 29, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 March 30, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Unit 2 Daily Emission Compliance Report
 March 31, 2022

EMISSION LIMITS (NORMAL OPERATION)

	NOx (1 Hr)		CO (3 Hr Ring Avg)		NH3 (24 Hr Ring Avg)	
	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs	ppm @ 15% O2	lbs
w/o DB	2.0	8.10	2.0	3.90	5.0	9.40
w/ DB	2.0	10.30	2.0	6.00	5.0	9.40

Hour	Normal Op NOx ppm @ 15% O2	Normal Op NOx lbs	Normal Op NOx lbs Limit*	Normal Op CO ppm @ 15% O2 3-Hr Ring	Normal Op CO lbs 3-Hr Ring	Normal Op CO lbs 3-Hr Ring Limit**	Normal Op NH3 ppm @ 15% O2 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring	Normal Ops NH3 lbs 24-Hr Ring Limit	DB Gas On (Y/N)	Operating Hour	Process Status
00	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
01	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
02	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
03	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
04	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
05	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
06	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
07	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
08	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
09	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
10	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
11	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
12	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
13	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
14	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
15	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
16	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
17	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
18	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
19	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
20	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
21	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
22	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down
23	N/A	N/A	8.10	N/A	N/A	3.90	0.0	0.00	9.40	Off	0.00	Down

* 1 hour average weighted limit, that is, the limit is calculated by averaging the limit for each minute in an hour.

** Maximum of the 3 rolling hour limits. For each of those 3 hours, the limit is 1-hr average weighted limit.

Tracy Combined Cycle Power Plant
 Tracy, CA
Turbine 2- Monthly Mass Emissions Report
 January - 2022

Daily Emission Limits		12 Month Rolling Emission Limits	
NOx lbs - 814.9	CO lbs - 1071.6	NOx lbs - 88,881	CO lbs - 74,598
SOx lbs - 58.7	PM lbs - 132	SOx lbs - 7,084	PM lbs - 32,250
VOC lbs - 78.6		VOC lbs - 15,145	

Day	NOx lbs	SOx lbs	CO lbs	PM lbs	NH3 Slip lbs	VOC lbs	Turbine On-Time
01	179.5	0.6	27.6	1.4	91.2	0.8	2.9
02	127.8	2.2	10.6	4.6	59.4	1.7	6.2
03	192.0	5.8	11.4	12.3	101.8	4.0	14.8
04	181.9	5.5	9.5	11.7	87.1	3.4	13.9
05	207.0	5.5	8.1	11.6	103.9	3.1	13.9
06	Down	Down	Down	Down	Down	0.0	0.0
07	Down	Down	Down	Down	Down	0.0	0.0
08	Down	Down	Down	Down	Down	0.0	0.0
09	Down	Down	Down	Down	Down	0.0	0.0
10	125.4	3.8	25.9	8.0	55.8	2.6	9.6
11	102.2	2.7	4.5	5.7	45.6	1.5	6.8
12	118.7	3.0	6.2	6.3	67.6	2.0	7.5
13	111.7	2.9	5.3	6.2	60.4	2.0	7.5
14	Down	Down	Down	Down	Down	0.0	0.0
15	Down	Down	Down	Down	Down	0.0	0.0
16	Down	Down	Down	Down	Down	0.0	0.0
17	Down	Down	Down	Down	Down	0.0	0.0
18	Down	Down	Down	Down	Down	0.0	0.0
19	Down	Down	Down	Down	Down	0.0	0.0
20	Down	Down	Down	Down	Down	0.0	0.0
21	Down	Down	Down	Down	Down	0.0	0.0
22	Down	Down	Down	Down	Down	0.0	0.0
23	Down	Down	Down	Down	Down	0.0	0.0
24	Down	Down	Down	Down	Down	0.0	0.0
25	Down	Down	Down	Down	Down	0.0	0.0
26	Down	Down	Down	Down	Down	0.0	0.0
27	Down	Down	Down	Down	Down	0.0	0.0
28	Down	Down	Down	Down	Down	0.0	0.0
29	Down	Down	Down	Down	Down	0.0	0.0
30	Down	Down	Down	Down	Down	0.0	0.0
31	Down	Down	Down	Down	Down	0.0	0.0
Total	1346	32	109	68	672.8	21	83
12-Mo Ring	34743	1611	2647	5912	13727	3643	

Tracy Combined Cycle Power Plant
 Tracy, CA
Turbine 2- Monthly Mass Emissions Report
 February - 2022

Daily Emission Limits		12 Month Rolling Emission Limits	
NOx lbs - 814.9	CO lbs - 1071.6	NOx lbs - 88,881	CO lbs - 74,598
SOx lbs - 58.7	PM lbs - 132	SOx lbs - 7,084	PM lbs - 32,250
VOC lbs - 78.6		VOC lbs - 15,145	

Day	NOx lbs	SOx lbs	CO lbs	PM lbs	NH3 Slip lbs	VOC lbs	Turbine On-Time
01	Down	Down	Down	Down	Down	0.0	0.0
02	Down	Down	Down	Down	Down	0.0	0.0
03	126.7	3.8	20.0	8.1	72.7	2.5	9.2
04	141.3	6.8	12.4	14.5	64.1	4.5	16.8
05	Down	Down	Down	Down	Down	0.0	0.0
06	Down	Down	Down	Down	Down	0.0	0.0
07	Down	Down	Down	Down	Down	0.0	0.0
08	Down	Down	Down	Down	Down	0.0	0.0
09	Down	Down	Down	Down	Down	0.0	0.0
10	Down	Down	Down	Down	Down	0.0	0.0
11	Down	Down	Down	Down	Down	0.0	0.0
12	Down	Down	Down	Down	Down	0.0	0.0
13	Down	Down	Down	Down	Down	0.0	0.0
14	Down	Down	Down	Down	Down	0.0	0.0
15	190.2	2.3	26.9	4.9	75.2	1.9	6.9
16	Down	Down	Down	Down	Down	0.0	0.0
17	Down	Down	Down	Down	Down	0.0	0.0
18	Down	Down	Down	Down	Down	0.0	0.0
19	Down	Down	Down	Down	Down	0.0	0.0
20	Down	Down	Down	Down	Down	0.0	0.0
21	Down	Down	Down	Down	Down	0.0	0.0
22	Down	Down	Down	Down	Down	0.0	0.0
23	Down	Down	Down	Down	Down	0.0	0.0
24	126.1	3.9	22.5	8.2	69.1	2.0	9.2
25	156.5	7.4	9.6	15.8	64.7	3.9	17.5
26	7.2	0.5	1.3	1.1	1.9	0.3	1.3
27	Down	Down	Down	Down	Down	0.0	0.0
28	Down	Down	Down	Down	Down	0.0	0.0
Total	748	25	93	53	347.7	15	61
12-Mo Ring	32987	1436	2415	5112	13826	3396	

Tracy Combined Cycle Power Plant
 Tracy, CA
Turbine 2- Monthly Mass Emissions Report
 March - 2022

Daily Emission Limits		12 Month Rolling Emission Limits	
NOx lbs - 814.9	CO lbs - 1071.6	NOx lbs - 88,881	CO lbs - 74,598
SOx lbs - 58.7	PM lbs - 132	SOx lbs - 7,084	PM lbs - 32,250
VOC lbs - 78.6		VOC lbs - 15,145	

Day	NOx lbs	SOx lbs	CO lbs	PM lbs	NH3 Slip lbs	VOC lbs	Turbine On-Time
01	Down	Down	Down	Down	Down	0.0	0.0
02	Down	Down	Down	Down	Down	0.0	0.0
03	Down	Down	Down	Down	Down	0.0	0.0
04	Down	Down	Down	Down	Down	0.0	0.0
05	Down	Down	Down	Down	Down	0.0	0.0
06	Down	Down	Down	Down	Down	0.0	0.0
07	Down	Down	Down	Down	Down	0.0	0.0
08	Down	Down	Down	Down	Down	0.0	0.0
09	Down	Down	Down	Down	Down	0.0	0.0
10	Down	Down	Down	Down	Down	0.0	0.0
11	Down	Down	Down	Down	Down	0.0	0.0
12	Down	Down	Down	Down	Down	0.0	0.0
13	Down	Down	Down	Down	Down	0.0	0.0
14	159.7	2.9	14.8	6.0	91.4	1.5	7.3
15	Down	Down	Down	Down	Down	0.0	0.0
16	Down	Down	Down	Down	Down	0.0	0.0
17	Down	Down	Down	Down	Down	0.0	0.0
18	Down	Down	Down	Down	Down	0.0	0.0
19	50.7	0.3	23.1	0.6	33.4	0.3	0.9
20	30.6	2.5	3.8	5.4	7.5	1.7	6.4
21	179.9	2.9	15.2	6.1	98.9	2.1	7.8
22	199.3	3.0	4.5	6.2	110.1	2.1	7.9
23	168.2	3.0	4.3	6.5	88.1	1.7	7.9
24	Down	Down	Down	Down	Down	0.0	0.0
25	Down	Down	Down	Down	Down	0.0	0.0
26	183.1	3.7	20.0	8.0	99.1	1.9	9.3
27	Down	Down	Down	Down	Down	0.0	0.0
28	Down	Down	Down	Down	Down	0.0	0.0
29	Down	Down	Down	Down	Down	0.0	0.0
30	Down	Down	Down	Down	Down	0.0	0.0
31	Down	Down	Down	Down	Down	0.0	0.0
Total	972	18	86	39	528.5	11	48
12-Mo Ring	33367	1427	2410	5037	14205	3356	

Tracy Combined Cycle Power Plant
 Tracy, CA
Turbine 2- Monthly Operations Report
 January - 2022

Day	CT Gas Flow kscf	CT Heat Input mmBtu	CT Gas On-Time	DB Gas Flow kscf	DB Heat Input mmBtu	DB Gas On-Time	Total Heat Input mmBtu	Steam Flow To CTG klbs	Steam Flow To CTG On-Time	NH3 Flow lbs	NH3 Flow On-Time	CT Megawatt Hours	Turbine On-Time
01	1348.7	1408.1	2.92	Down	Down	0.00	1408	514.0	2.70	50.7	2.15	74	2.9
02	4512.7	4711.2	6.15	Down	Down	0.00	4711	1752.1	5.98	185.0	5.52	362	6.2
03	12025.7	12554.7	14.82	Down	Down	0.00	12555	4641.3	14.67	498.3	14.48	1012	14.8
04	11265.9	11761.5	13.94	214.6	224.1	3.11	11986	4499.3	13.77	464.0	13.53	945	13.9
05	10925.2	11405.7	13.92	477.6	498.6	6.35	11904	4573.6	13.75	466.7	13.55	898	13.9
06	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
07	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
08	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
09	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
10	7816.5	8160.2	9.57	Down	Down	0.00	8160	2949.5	9.29	290.9	8.92	655	9.6
11	5324.3	5558.6	6.79	238.4	249.0	3.25	5808	2213.1	6.52	229.4	6.30	441	6.8
12	6160.1	6431.3	7.47	Down	Down	0.00	6431	2334.2	7.25	231.3	6.92	519	7.5
13	6044.3	6310.3	7.45	Down	Down	0.00	6310	2302.7	7.22	225.9	6.93	504	7.5
14	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
15	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
16	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
17	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
18	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
19	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
20	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
21	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
22	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
23	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
24	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
25	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
26	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
27	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
28	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
29	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
30	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
31	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
Average	7269.3	7589.1		310.2	323.9		7697	2864.4		293.6		601	
Total	65423.4	68302	83.0	930.6	972	12.7	69273	25779.8	81.2	2642.2	78.3	5410	83

Tracy Combined Cycle Power Plant
 Tracy, CA
Turbine 2- Monthly Operations Report
 February - 2022

Day	CT Gas Flow kscf	CT Heat Input mmBtu	CT Gas On-Time	DB Gas Flow kscf	DB Heat Input mmBtu	DB Gas On-Time	Total Heat Input mmBtu	Steam Flow To CTG klbs	Steam Flow To CTG On-Time	NH3 Flow lbs	NH3 Flow On-Time	CT Megawatt Hours	Turbine On-Time
01	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
02	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
03	7938.3	8287.5	9.18	Down	Down	0.00	8288	2976.5	8.92	323.7	8.60	682	9.2
04	14202.4	14827.2	16.79	Down	Down	0.00	14827	5463.6	16.62	592.7	16.64	1214	16.8
05	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
06	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
07	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
08	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
09	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
10	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
11	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
12	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
13	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
14	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
15	4839.3	5052.2	6.90	Down	Down	0.00	5052	1881.1	6.64	205.6	6.14	374	6.9
16	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
17	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
18	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
19	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
20	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
21	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
22	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
23	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
24	7736.8	8077.3	9.15	268.6	280.4	4.08	8358	3086.8	8.85	360.0	8.57	659	9.2
25	14958.7	15616.6	17.50	505.4	527.3	7.87	16144	6035.4	17.38	695.1	17.28	1285	17.5
26	1034.9	1080.4	1.27	Down	Down	0.00	1080	400.4	1.27	46.1	1.27	88	1.3
27	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
28	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
Average Total	8451.7 50710.4	8823.5 52941	60.8	387.0 774.0	403.9 808	12.0	8958 53749	3307.3 19843.8	59.7	370.5 2223.2	58.5	717 4302	61

Tracy Combined Cycle Power Plant
 Tracy, CA
Turbine 2- Monthly Operations Report
 March - 2022

Day	CT Gas Flow kscf	CT Heat Input mmBtu	CT Gas On-Time	DB Gas Flow kscf	DB Heat Input mmBtu	DB Gas On-Time	Total Heat Input mmBtu	Steam Flow To CTG klbs	Steam Flow To CTG On-Time	NH3 Flow lbs	NH3 Flow On-Time	CT Megawatt Hours	Turbine On-Time
01	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
02	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
03	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
04	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
05	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
06	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
07	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
08	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
09	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
10	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
11	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
12	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
13	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
14	5629.4	5741.9	7.32	275.5	281.1	4.22	6023	2323.3	7.04	248.1	6.66	460	7.3
15	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
16	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
17	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
18	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
19	536.8	547.6	0.93	Down	Down	0.00	548	150.0	0.60	7.4	0.25	37	0.9
20	5259.3	5364.3	6.42	Down	Down	0.00	5364	2060.7	6.42	210.7	6.35	440	6.4
21	5963.6	6082.7	7.84	Down	Down	0.00	6083	2286.8	7.54	211.8	7.22	481	7.8
22	6116.6	6238.9	7.90	Down	Down	0.00	6239	2371.3	7.59	214.5	7.49	497	7.9
23	6047.1	6167.8	7.94	289.8	295.6	4.03	6463	2540.5	7.64	256.3	7.54	488	7.9
24	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
25	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
26	7414.1	7562.2	9.34	382.3	390.0	5.89	7952	3089.5	9.05	303.4	8.65	613	9.3
27	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
28	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
29	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
30	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
31	Down	Down	0.00	Down	Down	0.00	Down	Down	0.00	Down	0.00	Down	0.0
Average	5281.0	5386.5		315.9	322.2		5525	2117.4		207.5		431	
Total	36966.9	37705	47.7	947.6	967	14.1	38672	14822.1	45.9	1452.2	44.2	3016	48

ATTACHMENT 6
GAS SULFUR CONTENT 12 MONTH ROLLING AVERAGE

FUEL SULFUR - Tracy Combined Cycle Power Plant

Daily Average Limit = 0.66 gr/100scf

12-Month Rolling Average Limit = 0.25 gr/100scf

Units = gr/100 scf

Sample No	1	2	3	Daily Average
Jan-22	0.19	0.18	0.18	0.18
Feb-22	0.13	0.13	0.15	0.13
Mar-22	0.17	0.16	0.17	0.17
Apr-21	0.13	0.13	0.14	0.13
May-21	0.13	0.12	0.12	0.12
Jun-21	0.16	0.17	0.16	0.16
Jul-21	0.20	0.22	0.16	0.19
Aug-21	0.19	0.18	0.21	0.19
Sep-21	0.18	0.16	0.20	0.18
Oct-21	0.21	0.22	0.20	0.21
Nov-21	0.16	0.18	0.18	0.17
Dec-21	0.17	0.14	0.14	0.15

12 Month Rolling Average

0.17

Note: Three samples are collected in triplicate once per month to increase the chances that at least one of the samples will reach the lab in good condition. When more than one samples are analyzed, the results are averaged for reporting the daily results. Results of the average of the daily are averaged over a 12-month period to obtain the 12-month rolling average.

ATTACHMENT 7
STARTUP AND SHUTDOWN SUMMARIES

Events

Tracy Combined Cycle Power Plant
for 1/1/2022 thru 3/31/2022

Limits

Turbine 1: NOx lbs/Startup Event	390.5	Turbine 1: PM lbs/Shutdown Event	3.0	Turbine 2: CO lbs/Startup Event	562.5
Turbine 1: NOx lbs/Shutdown Event	104.0	Turbine 1: VOC lbs/Startup Event	10.5	Turbine 2: CO lbs/Shutdown Event	148.0
Turbine 1: SOx lbs/Startup Event	4.1	Turbine 1: VOC lbs/Shutdown Event	2.6	Turbine 2: PM lbs/Startup Event	11.0
Turbine 1: SOx lbs/Shutdown Event	1.1	Turbine 2: NOx lbs/Startup Event	390.5	Turbine 2: PM lbs/Shutdown Event	3.0
Turbine 1: CO lbs/Startup Event	562.5	Turbine 2: NOx lbs/Shutdown Event	104.0	Turbine 2: VOC lbs/Startup Event	10.5
Turbine 1: CO lbs/Shutdown Event	148.0	Turbine 2: SOx lbs/Startup Event	4.1	Turbine 2: VOC lbs/Shutdown Event	2.6
Turbine 1: PM lbs/Startup Event	11.0	Turbine 2: SOx lbs/Shutdown Event	1.1		

Parameter	Start	End	Duration	NOx lbs	SOx lbs	CO lbs	PM lbs	VOC lbs
		1/2/2022						
Turbine 2 Startup Event	1/1/2022 9:05 PM	12:03 AM	2:59	176.90	0.20	21.40	1.80	0.00
Turbine 2 Shutdown Event	1/2/2022 2:00 AM	2:14 AM	0:15	1.40	0.10	0.90	0.10	0.00
Turbine 2 Startup Event	1/2/2022 8:06 PM	10:15 PM	2:10	104.90	0.30	5.60	1.40	0.00
Turbine 2 Shutdown Event	1/3/2022 12:00 AM	12:14 AM	0:15	1.40	0.10	1.00	0.10	0.00
Turbine 1 Startup Event	1/3/2022 3:38 AM	5:16 AM	1:39	64.40	0.40	19.90	2.10	0.00
Turbine 2 Startup Event	1/3/2022 3:40 AM	5:09 AM	1:30	57.80	0.20	1.10	0.80	0.00
Turbine 1 Shutdown Event	1/3/2022 8:30 AM	8:46 AM	0:17	1.90	0.10	0.90	0.30	0.00
Turbine 2 Shutdown Event	1/3/2022 8:30 AM	8:45 AM	0:16	1.50	0.10	0.60	0.10	0.00
Turbine 1 Startup Event	1/3/2022 1:47 PM	3:09 PM	1:23	67.50	0.30	0.90	1.70	0.00
Turbine 2 Startup Event	1/3/2022 1:48 PM	3:07 PM	1:20	65.90	0.20	0.50	0.70	0.00
Turbine 1 Shutdown Event	1/3/2022 11:00 PM	11:16 PM	0:17	1.80	0.10	0.90	0.30	0.00
Turbine 2 Shutdown Event	1/3/2022 11:00 PM	11:15 PM	0:16	1.50	0.10	0.50	0.10	0.00
Turbine 1 Startup Event	1/4/2022 3:42 AM	5:17 AM	1:36	65.30	0.30	1.90	2.10	0.00
Turbine 2 Startup Event	1/4/2022 3:44 AM	5:14 AM	1:31	56.70	0.30	0.60	0.90	0.00
Turbine 1 Shutdown Event	1/4/2022 7:59 AM	8:15 AM	0:17	1.90	0.10	1.00	0.30	0.00
Turbine 2 Shutdown Event	1/4/2022 7:59 AM	8:14 AM	0:16	1.60	0.10	0.60	0.10	0.00
Turbine 1 Startup Event	1/4/2022 1:51 PM	3:05 PM	1:15	59.00	0.20	0.90	1.60	0.00
Turbine 2 Startup Event	1/4/2022 1:51 PM	3:04 PM	1:14	59.70	0.20	0.50	0.70	0.00

Parameter	Start	End	Duration	NOx lbs	SOx lbs	CO lbs	PM lbs	VOC lbs
Turbine 1 Shutdown Event	1/4/2022 11:00 PM	11:16 PM	0:17	1.20	0.10	0.90	0.30	0.00
Turbine 2 Shutdown Event	1/4/2022 11:00 PM	11:15 PM	0:16	1.60	0.10	0.50	0.10	0.00
Turbine 2 Startup Event	1/5/2022 3:49 AM	5:06 AM	1:18	68.40	0.20	0.50	0.70	0.00
Turbine 2 Shutdown Event	1/5/2022 7:59 AM	8:12 AM	0:14	1.10	0.00	0.50	0.10	0.00
Turbine 1 Startup Event	1/5/2022 1:36 PM	3:06 PM	1:31	76.20	0.20	1.30	1.90	0.00
Turbine 2 Startup Event	1/5/2022 1:44 PM	3:06 PM	1:23	73.00	0.20	0.60	0.80	0.00
Turbine 1 Shutdown Event	1/5/2022 11:00 PM	11:15 PM	0:16	1.60	0.10	0.90	0.20	0.00
Turbine 2 Shutdown Event	1/5/2022 11:00 PM	11:14 PM	0:15	1.50	0.10	0.50	0.10	0.00
Turbine 1 Startup Event	1/10/2022 2:48 AM	5:45 AM	2:58	159.90	0.20	25.30	2.20	0.00
Turbine 1 Shutdown Event	1/10/2022 9:00 AM	9:13 AM	0:14	1.40	0.00	1.00	0.20	0.00
Turbine 1 Startup Event	1/10/2022 1:41 PM	3:07 PM	1:27	63.10	0.20	1.50	1.80	0.00
Turbine 2 Startup Event	1/10/2022 1:42 PM	3:10 PM	1:29	81.70	0.30	16.10	0.80	0.00
Turbine 1 Shutdown Event	1/10/2022 11:00 PM	11:15 PM	0:16	1.80	0.10	0.80	0.30	0.00
Turbine 2 Shutdown Event	1/10/2022 11:00 PM	11:15 PM	0:16	1.50	0.10	0.50	0.10	0.00
Turbine 1 Startup Event	1/11/2022 3:48 AM	5:15 AM	1:28	61.10	0.30	1.00	1.90	0.00
Turbine 1 Shutdown Event	1/11/2022 8:15 AM	8:30 AM	0:16	1.50	0.10	1.00	0.20	0.00
Turbine 1 Startup Event	1/11/2022 2:44 PM	4:04 PM	1:21	61.70	0.20	1.20	1.60	0.00
Turbine 2 Startup Event	1/11/2022 2:44 PM	4:05 PM	1:22	70.50	0.20	0.50	0.80	0.00
Turbine 1 Shutdown Event	1/11/2022 9:15 PM	9:31 PM	0:17	1.60	0.10	0.90	0.30	0.00
Turbine 2 Shutdown Event	1/11/2022 9:15 PM	9:30 PM	0:16	1.50	0.10	0.50	0.10	0.00
Turbine 1 Startup Event	1/12/2022 3:47 AM	5:09 AM	1:23	66.40	0.30	1.10	1.80	0.00
Turbine 1 Shutdown Event	1/12/2022 8:15 AM	8:30 AM	0:16	1.40	0.10	1.00	0.20	0.00
Turbine 1 Startup Event	1/12/2022 2:48 PM	4:08 PM	1:21	62.50	0.20	1.70	1.50	0.00
Turbine 2 Startup Event	1/12/2022 2:48 PM	4:09 PM	1:22	84.90	0.20	1.10	0.80	0.00
Turbine 1 Shutdown Event	1/12/2022 10:00 PM	10:16 PM	0:17	1.70	0.10	1.10	0.30	0.00
Turbine 2 Shutdown Event	1/12/2022 10:00 PM	10:15 PM	0:16	1.60	0.10	0.60	0.10	0.00
Turbine 1 Startup Event	1/13/2022 4:48 AM	6:11 AM	1:24	70.40	0.20	0.90	1.70	0.00

Parameter	Start	End	Duration	NOx lbs	SOx lbs	CO lbs	PM lbs	VOC lbs
Turbine 1 Shutdown Event	1/13/2022 9:31 AM	9:48 AM	0:18	1.70	0.10	1.10	0.30	0.00
Turbine 1 Startup Event	1/13/2022 1:47 PM	3:10 PM	1:24	64.50	0.20	1.10	1.60	0.00
Turbine 2 Startup Event	1/13/2022 1:48 PM	3:10 PM	1:23	84.00	0.20	0.80	0.80	0.00
Turbine 1 Shutdown Event	1/13/2022 8:59 PM	9:15 PM	0:17	1.60	0.10	1.10	0.30	0.00
Turbine 2 Shutdown Event	1/13/2022 8:59 PM	9:14 PM	0:16	1.60	0.10	0.60	0.10	0.00
Turbine 1 Startup Event	2/3/2022 2:04 AM	5:03 AM	3:00	170.40	0.20	25.10	2.70	0.00
Turbine 1 Shutdown Event	2/3/2022 8:00 AM	8:12 AM	0:13	1.20	0.00	0.90	0.20	0.00
Turbine 1 Startup Event	2/3/2022 2:49 PM	4:09 PM	1:21	56.90	0.30	1.30	1.70	0.00
Turbine 2 Startup Event	2/3/2022 2:49 PM	4:09 PM	1:21	80.70	0.30	12.30	0.70	0.00
Turbine 1 Shutdown Event	2/4/2022 8:00 AM	8:16 AM	0:17	1.20	0.10	1.00	0.30	0.00
Turbine 2 Shutdown Event	2/4/2022 8:00 AM	8:15 AM	0:16	1.50	0.10	0.50	0.10	0.00
Turbine 1 Startup Event	2/4/2022 2:44 PM	4:17 PM	1:34	61.20	0.30	2.00	2.00	0.00
Turbine 2 Startup Event	2/4/2022 2:45 PM	4:16 PM	1:32	61.60	0.30	1.00	0.80	0.00
Turbine 1 Shutdown Event	2/4/2022 11:00 PM	11:16 PM	0:17	1.90	0.10	1.00	0.30	0.00
Turbine 2 Shutdown Event	2/4/2022 11:00 PM	11:15 PM	0:16	1.50	0.10	0.70	0.10	0.00
Turbine 1 Startup Event	2/15/2022 6:18 AM	9:16 AM	2:59	152.40	0.30	26.40	2.80	0.00
Turbine 2 Startup Event	2/15/2022 6:19 AM	9:17 AM	2:59	166.80	0.30	19.90	2.00	0.00
Turbine 1 Shutdown Event	2/15/2022 1:00 PM	1:13 PM	0:14	1.70	0.00	0.80	0.20	0.00
Turbine 2 Shutdown Event	2/15/2022 1:00 PM	1:12 PM	0:13	1.30	0.00	0.80	0.10	0.00
Turbine 1 Startup Event	2/23/2022 9:03 PM	11:48 PM	2:46	153.70	0.10	24.70	2.60	0.00
Turbine 1 Shutdown Event	2/24/2022 8:31 AM	8:47 AM	0:17	1.40	0.00	1.20	0.20	0.00
Turbine 1 Startup Event	2/24/2022 2:51 PM	4:15 PM	1:25	54.70	0.20	1.40	1.60	0.00
Turbine 2 Startup Event	2/24/2022 2:51 PM	4:11 PM	1:21	83.60	0.20	16.90	0.70	0.00
Turbine 1 Shutdown Event	2/25/2022 8:00 AM	8:16 AM	0:17	1.90	0.10	0.90	0.30	0.00
Turbine 2 Shutdown Event	2/25/2022 8:00 AM	8:14 AM	0:15	1.50	0.10	0.50	0.10	0.00
Turbine 1 Startup Event	2/25/2022 2:45 PM	4:06 PM	1:22	66.30	0.20	1.40	1.70	0.00
Turbine 2 Startup Event	2/25/2022 2:45 PM	4:05 PM	1:21	69.40	0.20	0.50	0.70	0.00

Parameter	Start	End	Duration	NOx lbs	SOx lbs	CO lbs	PM lbs	VOC lbs
Turbine 1 Shutdown Event	2/26/2022 12:59 AM	1:15 AM	0:17	2.00	0.10	0.90	0.30	0.00
Turbine 2 Shutdown Event	2/26/2022 12:59 AM	1:15 AM	0:17	1.70	0.10	0.50	0.10	0.00
Turbine 1 Startup Event	3/1/2022 1:23 PM	3:59 PM	2:37	164.50	0.10	11.20	3.10	0.00
Turbine 1 Shutdown Event	3/1/2022 9:59 PM	10:15 PM	0:17	1.40	0.10	1.10	0.30	0.00
Turbine 1 Startup Event	3/14/2022 1:08 AM	4:07 AM	3:00	148.20	0.30	21.50	2.80	0.00
Turbine 1 Shutdown Event	3/14/2022 8:00 AM	8:15 AM	0:16	1.50	0.10	1.10	0.30	0.00
Turbine 1 Startup Event	3/14/2022 2:57 PM	4:54 PM	1:58	121.40	0.20	1.10	2.30	0.00
Turbine 2 Startup Event	3/14/2022 2:57 PM	4:44 PM	1:48	124.10	0.10	9.80	1.00	0.00
Turbine 1 Shutdown Event	3/14/2022 10:00 PM	10:16 PM	0:17	1.80	0.10	0.90	0.30	0.00
Turbine 2 Shutdown Event	3/14/2022 10:00 PM	10:15 PM	0:16	1.50	0.10	0.50	0.10	0.00
Turbine 1 Startup Event	3/19/2022 9:29 AM	12:13 PM	2:45	139.60	0.30	22.20	3.40	0.00
Turbine 2 Startup Event	3/19/2022 11:04 PM	3/20/2022 12:08 AM	1:05	47.40	0.30	15.40	0.70	0.00
Turbine 2 Shutdown Event	3/20/2022 6:11 AM	6:24 AM	0:14	1.40	0.00	0.50	0.10	0.00
Turbine 1 Shutdown Event	3/20/2022 8:15 PM	8:31 PM	0:17	1.50	0.10	1.10	0.30	0.00
Turbine 1 Startup Event	3/21/2022 2:53 AM	4:10 AM	1:18	55.50	0.30	1.10	1.70	0.00
Turbine 1 Shutdown Event	3/21/2022 7:00 AM	7:15 AM	0:16	1.50	0.10	1.00	0.30	0.00
Turbine 2 Startup Event	3/21/2022 1:56 PM	4:10 PM	2:15	147.00	0.30	10.60	1.30	0.00
Turbine 1 Startup Event	3/21/2022 1:57 PM	4:10 PM	2:14	121.30	0.30	1.90	2.80	0.00
Turbine 1 Shutdown Event	3/21/2022 9:30 PM	9:45 PM	0:16	1.60	0.10	0.90	0.30	0.00
Turbine 2 Shutdown Event	3/21/2022 9:30 PM	9:45 PM	0:16	1.50	0.10	0.50	0.10	0.00
Turbine 1 Startup Event	3/22/2022 3:46 AM	5:10 AM	1:25	52.60	0.30	1.60	1.80	0.00
Turbine 1 Shutdown Event	3/22/2022 7:01 AM	7:14 AM	0:14	1.30	0.00	0.80	0.20	0.00
Turbine 1 Startup Event	3/22/2022 1:52 PM	4:20 PM	2:29	147.50	0.40	2.10	3.10	0.00
Turbine 2 Startup Event	3/22/2022 1:52 PM	4:19 PM	2:28	163.50	0.40	0.80	1.40	0.00
Turbine 1 Shutdown Event	3/22/2022 9:30 PM	9:46 PM	0:17	1.50	0.10	0.90	0.30	0.00
Turbine 2 Shutdown Event	3/22/2022 9:30 PM	9:45 PM	0:16	1.40	0.10	0.50	0.10	0.00
Turbine 1 Startup Event	3/23/2022 3:44 AM	5:18 AM	1:35	59.00	0.30	1.60	2.10	0.00

Parameter	Start	End	Duration	NOx lbs	SOx lbs	CO lbs	PM lbs	VOC lbs
Turbine 1 Shutdown Event	3/23/2022 7:01 AM	7:15 AM	0:15	1.30	0.00	1.00	0.20	0.00
Turbine 1 Startup Event	3/23/2022 1:50 PM	4:14 PM	2:25	122.80	0.30	1.70	3.00	0.00
Turbine 2 Startup Event	3/23/2022 1:50 PM	4:12 PM	2:23	133.30	0.30	0.50	1.40	0.00
Turbine 1 Shutdown Event	3/23/2022 9:30 PM	9:46 PM	0:17	1.70	0.10	0.90	0.30	0.00
Turbine 2 Shutdown Event	3/23/2022 9:30 PM	9:45 PM	0:16	1.40	0.10	0.60	0.10	0.00
Turbine 1 Startup Event	3/25/2022 8:26 PM	11:19 PM	2:54	169.80	0.30	17.90	3.60	0.00
Turbine 1 Shutdown Event	3/26/2022 7:00 AM	7:15 AM	0:16	1.50	0.10	1.10	0.20	0.00
Turbine 2 Startup Event	3/26/2022 2:11 PM	4:14 PM	2:04	138.80	0.30	11.90	1.20	0.00
Turbine 1 Startup Event	3/26/2022 2:27 PM	4:08 PM	1:42	104.90	0.30	1.00	2.10	0.00
Turbine 1 Shutdown Event	3/26/2022 11:15 PM	11:31 PM	0:17	1.50	0.10	0.90	0.30	0.00
Turbine 2 Shutdown Event	3/26/2022 11:15 PM	11:30 PM	0:16	1.40	0.10	0.50	0.10	0.00
Turbine 1 Startup Event	3/29/2022 5:53 AM	8:33 AM	2:41	141.70	0.20	22.30	2.80	0.00
Turbine 1 Shutdown Event	3/29/2022 10:30 AM	10:45 AM	0:16	1.30	0.00	1.00	0.20	0.00
Total (112 Events)			118:14	5492.70	18.70	442.50	107.20	0.00

**ATTACHMENT 8
FUEL USAGE**

TRACY COMBINED CYCLE POWER PLANT

Tracy, CA

12 Month Rolling - Combined Annual Gas Usage

March 2022 12-Month Rolling

Limit - 20,454 MMscf/year

Month	Unit 1 - Total Gas Flow kscf Monthly Total	Unit 2 - Total Gas Flow kscf Monthly Total	Total Gas Plant (U1+U2) Flow kscf Monthly Total	Total Plant Gas Flow mmscf Monthly Total	Total Plant Gas Flow mmscf 12 Month Rolling
Apr 2021	83252	347531	430783	431	6837
May 2021	66848	192567	259415	259	6614
Jun 2021	271533	333783	605316	605	6813
Jul 2021	520101	541671	1061772	1062	7292
Aug 2021	404398	550759	955157	955	7160
Sep 2021	166941	234374	401315	401	6991
Oct 2021	108985	195394	304379	304	6572
Nov 2021	99220	87650	186870	187	6298
Dec 2021	347487	301622	649109	649	6421
Jan 2022	72743	66356	139099	139	6275
Feb 2022	66579	51483	118062	118	5580
Mar 2022	92048	37915	129963	130	5241

ATTACHMENT 9
FUEL SULFUR ANALYSIS COMPLETED THIS QUARTER



ZALCO LABORATORIES, INC.

Analytical & Consulting Services

4309 Armour Avenue
Bakersfield, California 93308

(661) 395-0539
FAX (661) 395-3069

January 26, 2022

Randy Shepard
San Joaquin Energy Inc.
14950 W. Shulte Road
Tracy, CA 95377

TEL: (209) 248-6841
FAX:

Project ID: Master
RE: 2201500

Dear Randy Shepard:

Zalco Laboratories, Inc. received 3 samples on 1/19/2022 for the analyses presented in the following report.

We appreciate your business and look forward to serving you in the future . Please feel free to call our office if you have any questions regarding these test results.

Sincerely,

A handwritten signature in black ink, appearing to read "Juan Magana", is written over a printed name and title.

Juan Magana
Project Manager

CC:

NSS: Non Sufficient Sample H: Exceeds Analysis Hold Time TTLC: Total Threshold Limit Concentration STLC: Soluble Threshold Limit Concentration TCLP: Toxicity Characteristic
Leaching Procedure MCL: Maximum Contaminant Level *: See Case Narrative

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Note: Samples analyzed for regulatory purposes should be put on ice immediately after sampling and received by the laboratory at temperatures between 0-6°C.
Microbiological analysis requires samples to be at least 4-10°C when received at the laboratory. For additional information regarding the limitations of the method(s) referred to, please call us at 661-395-0539.



ZALCO LABORATORIES, INC.

Analytical & Consulting Services

4309 Armour Avenue
Bakersfield, California 93308

(661) 395-0539
FAX (661) 395-3069

San Joaquin Energy Inc. 14950 W. Shulte Road Tracy, CA 95377	Project: Master Project #: Master Attention: Randy Shepard	Work Order No.: 2201500 Reported: 01/26/2022 Received: 01/19/22 14:50
--	--	---

Lab Sample ID: 2201500-01 Client Sample ID: Natural Gas	Collected By: Tom Teixeira Date Collected: 1/18/2022 5:40:00AM
--	---

Analyte	Results	PQL	Units	Flag	Method	Date Prepared	Date Analyzed	Init.
Gas & Air Testing								
Sulfur	0.189	0.060	gr/100 scf		ASTM D3246-11	1/20/22	1/20/22	MO
Total Sulfur/Hydrogen Sulfide by ASTM D3246								
Total Sulfur	3.17	1.00	ppm		ASTM D 3246/M	1/20/22	1/20/22	MO

NSS: Non Sufficient Sample H: Exceeds Analysis Hold Time TTLC: Total Threshold Limit Concentration STLC: Soluble Threshold Limit Concentration TCLP: Toxicity Characteristic Leaching Procedure MCL: Maximum Contaminant Level *: See Case Narrative

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Note: Samples analyzed for regulatory purposes should be put on ice immediately after sampling and received by the laboratory at temperatures between 0-6°C. Microbiological analysis requires samples to be at least 4-10°C when received at the laboratory. For additional information regarding the limitations of the method(s) referred to, please call us at 661-395-0539.



ZALCO LABORATORIES, INC.

Analytical & Consulting Services

4309 Armour Avenue
Bakersfield, California 93308

(661) 395-0539
FAX (661) 395-3069

San Joaquin Energy Inc. 14950 W. Shulte Road Tracy, CA 95377	Project: Master Project #: Master Attention: Randy Shepard	Work Order No.: 2201500 Reported: 01/26/2022 Received: 01/19/22 14:50
--	--	---

Lab Sample ID: 2201500-02 Client Sample ID: Natural Gas	Collected By: Tom Teixeira Date Collected: 1/18/2022 5:42:00AM
--	---

Analyte	Results	PQL	Units	Flag	Method	Date Prepared	Date Analyzed	Init.
Gas & Air Testing								
Sulfur	0.182	0.060	gr/100 scf		ASTM D3246-11	1/20/22	1/20/22	MO
Total Sulfur/Hydrogen Sulfide by ASTM D3246								
Total Sulfur	3.05	1.00	ppm		ASTM D 3246/M	1/20/22	1/20/22	MO

NSS: Non Sufficient Sample H: Exceeds Analysis Hold Time TTLC: Total Threshold Limit Concentration STLC: Soluble Threshold Limit Concentration TCLP: Toxicity Characteristic Leaching Procedure MCL: Maximum Contaminant Level *: See Case Narrative

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Note: Samples analyzed for regulatory purposes should be put on ice immediately after sampling and received by the laboratory at temperatures between 0-6°C. Microbiological analysis requires samples to be at least 4-10°C when received at the laboratory. For additional information regarding the limitations of the method(s) referred to, please call us at 661-395-0539.



ZALCO LABORATORIES, INC.

Analytical & Consulting Services

4309 Armour Avenue
Bakersfield, California 93308


(661) 395-0539
FAX (661) 395-3069

San Joaquin Energy Inc. 14950 W. Shulte Road Tracy, CA 95377	Project: Master Project #: Master Attention: Randy Shepard	Work Order No.: 2201500 Reported: 01/26/2022 Received: 01/19/22 14:50
--	--	---

Lab Sample ID: 2201500-03 Client Sample ID: Natural Gas	Collected By: Tom Teixeira Date Collected: 1/18/2022 5:44:00AM
--	---

Analyte	Results	PQL	Units	Flag	Method	Date Prepared	Date Analyzed	Init.
Gas & Air Testing								
Sulfur	0.179	0.060	gr/100 scf		ASTM D3246-11	1/20/22	1/20/22	MO
Total Sulfur/Hydrogen Sulfide by ASTM D3246								
Total Sulfur	2.99	1.00	ppm		ASTM D 3246/M	1/20/22	1/20/22	MO

NSS: Non Sufficient Sample H: Exceeds Analysis Hold Time TTLC: Total Threshold Limit Concentration STLC: Soluble Threshold Limit Concentration TCLP: Toxicity Characteristic Leaching Procedure MCL: Maximum Contaminant Level *: See Case Narrative
 The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.
 Note: Samples analyzed for regulatory purposes should be put on ice immediately after sampling and received by the laboratory at temperatures between 0-6°C. Microbiological analysis requires samples to be at least 4-10°C when received at the laboratory. For additional information regarding the limitations of the method(s) referred to, please call us at 661-395-0539.



ZALCO LABORATORIES, INC. CHAIN OF CUSTODY, ID# **2201500**
 4309 Armour Avenue, Bakersfield, CA 93308 (661) 395-0539 FAX (661) 395-3069 www.zalcolabs.com
 2186 Eastman Avenue, Suite 103, Ventura, CA 93003 (805) 477-0114 Fax (805) 477-0125

Page 1 of 1
 Zalco Lab # _____
 Client PO # _____

REPORT INFO

Client: MRP San Joaquin Energy LLC
 Address: 14950 W. SHULTE RD.
 City, State, Zip: TRACY, CA 95377

INVOICE INFO

Invoice To: Same as Client
 Address:
 City, State, Zip:

Attention:
 Phone:
 Fax:

Phone: Taylor.Leach@naes.com
 Resulis: U
 Fax: Wayne.Toumbs@naes.com
 Resulis: U
 Email: Randy.shepard@naes.com
 Resulis: X

Attention:
 Phone:
 Fax:

SAMPLED BY: Tom Teixeira
 EMPLOYED BY: MRP San Joaquin Energy LLC

Attention:
 Phone:
 Fax:

Phone: Taylor.Leach@naes.com
 Resulis: U
 Fax: Wayne.Toumbs@naes.com
 Resulis: U
 Email: Randy.shepard@naes.com
 Resulis: X

Attention:
 Phone:
 Fax:

SAMPLED BY: Tom Teixeira
 EMPLOYED BY: MRP San Joaquin Energy LLC

Attention:
 Phone:
 Fax:

Sample No.	Sample Description	Date	Sample Time	Type*
1	NATURAL GAS	1/18/22	05:40	G
2	NATURAL GAS	1/18/22	05:42	G
3	NATURAL GAS	1/18/22	05:44	G

#	ANALYSIS	RES
	TOTAL SULFUR ASTM D3	

County _____
 Send Copy to County? Yes No X
 Attention To: _____
 Send Copy to State of CA? Yes No X
 Rush By: _____ working days
 Turnaround Time: _____ working days
 Routine: 5 working days X
 COMMENTS:
 QUOTE ID: _____
 PROJECT ID: _____

RELINQUISHED BY: Signature	PRINT	COMPANY	Date	Time	RECEIVED BY: Signature	PRINT
<i>Wayne Toumbs</i>	Wayne Toumbs	San Joaquin Energy	1/18/22	0800	<i>AM 11/19/22 14:50 Zalco</i>	Zalco

NOTE: Samples are discarded 30 days after results unless other arrangements are made. Hazardous samples will be returned to client or disposed of at the client's expense.
 *Sample Type Key: AD-Aqueous; BS-Biosolid; DW-Drinking Water; GW-Ground Water; G-Gas; LPG-Liquid Petroleum Gas; OL-Oil; O-Other; P-Petroleum; S-Soil/Solid; ST-Storm Water; WW-Wastewater
 *Sample No.: FOR OFFICE USE ONLY



ZALCO LABORATORIES, INC.

Analytical & Consulting Services

4309 Armour Avenue
Bakersfield, California 93308

(661) 395-0539
FAX (661) 395-3069

February 9, 2022

Randy Shepard
San Joaquin Energy Inc.
14950 W. Shulte Road
Tracy, CA 95377

TEL: (209) 248-6841
FAX:

Project ID: Master
RE: 2202047

Dear Randy Shepard:

Zalco Laboratories, Inc. received 3 samples on 2/2/2022 for the analyses presented in the following report.

We appreciate your business and look forward to serving you in the future. Please feel free to call our office if you have any questions regarding these test results.

Sincerely,


Juan Magaña
Project Manager
CC:

NSS: Non Sufficient Sample H: Exceeds Analysis Hold Time TTL: Total Threshold Limit Concentration STLC: Soluble Threshold Limit Concentration TCLP: Toxicity Characteristic
Leaching Procedure MCL: Maximum Contaminant Level *; See Case Narrative
The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Note: Samples analyzed for regulatory purposes should be put on ice immediately after sampling and received by the laboratory at temperatures between 0-6°C.
Microbiological analysis requires samples to be at least 4-10°C when received at the laboratory. For additional information regarding the limitations of the method(s) referred to, please call us at 661-395-0539.



ZALCO LABORATORIES, INC.

Analytical & Consulting Services

4309 Armour Avenue
Bakersfield, California 93308

(661) 395-0539
FAX (661) 395-3069

San Joaquin Energy Inc. 14950 W. Shulte Road Tracy, CA 95377	Project: Master Project #: Master Attention: Randy Shepard	Work Order No.: 2202047 Reported: 02/09/2022 Received: 02/02/22 14:45
--	--	---

Lab Sample ID: 2202047-01 Client Sample ID: Natural Gas	Collected By: Tom Teixeira Date Collected: 2/1/2022 6:30:00AM
--	--

Analyte	Results	PQL	Units	Flag	Method	Date Prepared	Date Analyzed	Init.
Gas & Air Testing								
Sulfur	0.126	0.060	gr/100 scf		ASTM D3246-11	2/3/22	2/3/22	MO
Total Sulfur/Hydrogen Sulfide by ASTM D3246								
Total Sulfur	2.11	1.00	ppm		ASTM D 3246/M	2/3/22	2/3/22	MO

NSS: Non Sufficient Sample H: Exceeds Analysis Hold Time TTLC: Total Threshold Limit Concentration STLC: Soluble Threshold Limit Concentration TCLP: Toxicity Characteristic Leaching Procedure MCL: Maximum Contaminant Level *: See Case Narrative

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Note: Samples analyzed for regulatory purposes should be put on ice immediately after sampling and received by the laboratory at temperatures between 0-6°C. Microbiological analysis requires samples to be at least 4-10°C when received at the laboratory. For additional information regarding the limitations of the method(s) referred to, please call us at 661-395-0539.



ZALCO LABORATORIES, INC.

Analytical & Consulting Services

4309 Armour Avenue
Bakersfield, California 93308

(661) 395-0539
FAX (661) 395-3069

San Joaquin Energy Inc. 14950 W. Shulte Road Tracy, CA 95377	Project: Master Project #: Master Attention: Randy Shepard	Work Order No.: 2202047 Reported: 02/09/2022 Received: 02/02/22 14:45
--	--	--

Lab Sample ID: 2202047-02	Collected By: Tom Teixeira
Client Sample ID: Natural Gas	Date Collected: 2/2/2022 6:32:00AM

Analyte	Results	PQL	Units	Flag	Method	Date Prepared	Date Analyzed	Init.
Gas & Air Testing								
Sulfur	0.126	0.060	gr/100 scf		ASTM D3246-11	2/3/22	2/3/22	MO
Total Sulfur/Hydrogen Sulfide by ASTM D3246								
Total Sulfur	2.11	1.00	ppm		ASTM D 3246/M	2/3/22	2/3/22	MO

NSS: Non Sufficient Sample H: Exceeds Analysis Hold Time TTL: Total Threshold Limit Concentration STLC: Soluble Threshold Limit Concentration TCLP: Toxicity Characteristic Leaching Procedure MCL: Maximum Contaminant Level *: See Case Narrative
 The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Note: Samples analyzed for regulatory purposes should be put on ice immediately after sampling and received by the laboratory at temperatures between 0-6°C. Microbiological analysis requires samples to be at least 4-10°C when received at the laboratory. For additional information regarding the limitations of the method(s) referred to, please call us at 661-395-0539.



ZALCO LABORATORIES, INC.

Analytical & Consulting Services

4309 Armour Avenue
Bakersfield, California 93308

(661) 395-0539
FAX (661) 395-3069

San Joaquin Energy Inc. 14950 W. Shulte Road Tracy, CA 95377	Project: Master Project #: Master Attention: Randy Shepard	Work Order No.: 2202047 Reported: 02/09/2022 Received: 02/02/22 14:45
--	--	--

Lab Sample ID: 2202047-03	Collected By: Tom Teixeira
Client Sample ID: Natural Gas	Date Collected: 2/2/2022 6:34:00AM

Analyte	Results	PQL	Units	Flag	Method	Date Prepared	Date Analyzed	Init.
Gas & Air Testing								
Sulfur	0.147	0.060	gr/100 scf		ASTM D3246-11	2/3/22	2/3/22	MO
Total Sulfur/Hydrogen Sulfide by ASTM D3246								
Total Sulfur	2.46	1.00	ppm		ASTM D 3246/M	2/3/22	2/3/22	MO

NSS: Non Sufficient Sample H: Exceeds Analysis Hold Time TTL: Total Threshold Limit Concentration STLC: Soluble Threshold Limit Concentration TCLP: Toxicity Characteristic Leaching Procedure MCL: Maximum Contaminant Level *: See Case Narrative
The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Note: Samples analyzed for regulatory purposes should be put on ice immediately after sampling and received by the laboratory at temperatures between 0-6°C. Microbiological analysis requires samples to be at least 4-10°C when received at the laboratory. For additional information regarding the limitations of the method(s) referred to, please call us at 661-395-0539.



ZALCO LABORATORIES, INC. CHAIN OF CUSTODY, ID#
 4309 Armour Avenue, Bakersfield, CA 93308 (661) 395-0539 FAX (661) 395-3069 www.zalcolabs.com
 2186 Eastman Avenue, Suite 103, Ventura, CA 93003 (805) 477-0114 Fax (805) 477-0125

REPORT INFO

Client: MRP San Joaquin Energy LLC
 Address: 14950 W. SHULTE RD.
 City, State, Zip: TRACY, CA 95377

INVOICE INFO

Invoice To: Same as Client
 Address:
 City, State, Zip:
 Attention:
 Phone:
 Fax:
 Email:

Phone: Taylor.Leach@naes.com
 Resulfite
 Fax: Wayne.Toumbs@naes.com
 Results
 Email: Randy.shepard@naes.com
 Resulfite

Phone:
 Fax:
 Email:

SAMPLED BY: Tom Teixeira

EMPLOYED BY: MRP San Joaquin Energy LLC

ANALYSIS

220947

Sample No.	Sample Description	Date	Sample Time	Type*
1	NATURAL GAS	2/1/22	06:30	G
2	NATURAL GAS	2/1/22	06:32	G
3	NATURAL GAS	2/1/22	06:34	G

#	TEST	RESULT	TEMP (C)
	TOTAL SULFUR ASTM D3		

RELINQUISHED BY: Signature <i>Wayne Toumbs</i>	PRINT Wayne Toumbs	COMPANY San Joaquin Energy	Date 2/1/22	Time 0800	RECEIVED BY: Signature <i>MCA 2/2/22</i>	PRINT Zalco
---	-----------------------	-------------------------------	----------------	--------------	---	----------------

NOTE: Samples are discarded 30 days after results unless other arrangements are made. Hazardous samples will be returned to client or disposed of at the client's expense.

* Sample Type Key: AD-Aqueous; BS-Biosolid; DW-Drinking Water; GW-Ground Water; G-Gas; LPG-Liquid Petroleum Gas; OL-Oil; O-Other; P-Petroleum; S-Soil/Solid; ST-Storm Water; WW-Wastewater


* Sample No.: FOR OFFICE USE ONLY

Zalco Lab #
 Client PO #

PROJECT ID:
 QUOTE ID:

COMMENTS:
 Turnaround Time:
 Routine 5 working days
 Rush By working days

Send Copy to State of CA?
 Yes No
 Attention To:
 Send Copy to County?
 Yes No
 County



ZALCO LABORATORIES, INC.

Analytical & Consulting Services

4309 Armour Avenue
Bakersfield, California 93308

(661) 395-0539
FAX (661) 395-3069

March 14, 2022

Randy Shepard
San Joaquin Energy Inc.
14950 W. Shulte Road
Tracy, CA 95377

TEL: (209) 248-6841
FAX:


Project ID: Master
RE: 2203140

Dear Randy Shepard:

Zalco Laboratories, Inc. received 3 samples on 3/8/2022 for the analyses presented in the following report.

We appreciate your business and look forward to serving you in the future. Please feel free to call our office if you have any questions regarding these test results.


Sincerely,


Juan Magana
Project Manager

CC:

NSS: Non Sufficient Sample H: Exceeds Analysis Hold Time TTLC: Total Threshold Limit Concentration STLC: Soluble Threshold Limit Concentration TCLP: Toxicity Characteristic Leaching Procedure MCL: Maximum Contaminant Level *: See Case Narrative
The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Note: Samples analyzed for regulatory purposes should be put on ice immediately after sampling and received by the laboratory at temperatures between 0-6°C. Microbiological analysis requires samples to be at least 4-10°C when received at the laboratory. For additional information regarding the limitations of the method(s) referred to, please call us at 661-395-0539.



ZALCO LABORATORIES, INC.
Analytical & Consulting Services

4309 Armour Avenue
Bakersfield, California 93308

(661) 395-0539
FAX (661) 395-3069


San Joaquin Energy Inc. 14950 W. Shulte Road Tracy, CA 95377	Project: Master Project #: Master Attention: Randy Shepard	Work Order No.: 2203140 Reported: 03/14/2022 Received: 03/08/22 12:53
--	--	--

Lab Sample ID: 2203140-01	Collected By: Tom Teixeira
Client Sample ID: Natural Gas	Date Collected: 3/7/2022 6:30:00AM

Analyte	Results	PQL	Units	Flag	Method	Date Prepared	Date Analyzed	Init.
Gas & Air Testing								
Sulfur	0.170	0.060	gr/100 scf		ASTM D3246-11	3/9/22	3/9/22	MO
Total Sulfur/Hydrogen Sulfide by ASTM D3246								
Total Sulfur	2.81	1.00	ppm		ASTM D 3246/M	3/9/22	3/9/22	MO

NSS: Non Sufficient Sample H: Exceeds Analysis Hold Time TTLC: Total Threshold Limit Concentration STLC: Soluble Threshold Limit Concentration TCLP: Toxicity Characteristic Leaching Procedure MCL: Maximum Contaminant Level *: See Case Narrative
The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Note: Samples analyzed for regulatory purposes should be put on ice immediately after sampling and received by the laboratory at temperatures between 0-6°C. Microbiological analysis requires samples to be at least 4-10°C when received at the laboratory. For additional information regarding the limitations of the method(s) referred to, please call us at 661-395-0539.



ZALCO LABORATORIES, INC.
Analytical & Consulting Services

4309 Armour Avenue
Bakersfield, California 93308

(661) 395-0539
FAX (661) 395-3069


San Joaquin Energy Inc. 14950 W. Shulte Road Tracy, CA 95377	Project: Master Project #: Master Attention: Randy Shepard	Work Order No.: 2203140 Reported: 03/14/2022 Received: 03/08/22 12:53
--	--	--

Lab Sample ID: 2203140-02	Collected By: Tom Teixeira
Client Sample ID: Natural Gas	Date Collected: 3/7/2022 6:32:00AM

Analyte	Results	PQL	Units	Flag	Method	Date Prepared	Date Analyzed	Init.
Gas & Air Testing								
Sulfur	0.160	0.060	gr/100 scf		ASTM D3246-11	3/9/22	3/9/22	MO
Total Sulfur/Hydrogen Sulfide by ASTM D3246								
Total Sulfur	2.64	1.00	ppm		ASTM D 3246/M	3/9/22	3/9/22	MO

NSS: Non Sufficient Sample H: Exceeds Analysis Hold Time TTL: Total Threshold Limit Concentration STLC: Soluble Threshold Limit Concentration TCLP: Toxicity Characteristic Leaching Procedure MCL: Maximum Contaminant Level *: See Case Narrative
The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Note: Samples analyzed for regulatory purposes should be put on ice immediately after sampling and received by the laboratory at temperatures between 0-6°C. Microbiological analysis requires samples to be at least 4-10°C when received at the laboratory. For additional information regarding the limitations of the method(s) referred to, please call us at 661-395-0539.



ZALCO LABORATORIES, INC.
Analytical & Consulting Services

4309 Armour Avenue
Bakersfield, California 93308

(661) 395-0539
FAX (661) 395-3069

San Joaquin Energy Inc. 14950 W. Shulte Road Tracy, CA 95377	Project: Master Project #: Master Attention: Randy Shepard	Work Order No.: 2203140 Reported: 03/14/2022 Received: 03/08/22 12:53
--	--	--

Lab Sample ID: 2203140-03	Collected By: Tom Teixeira
Client Sample ID: Natural Gas	Date Collected: 3/7/2022 6:34:00AM

Analyte	Results	PQL	Units	Flag	Method	Date Prepared	Date Analyzed	Init.
Gas & Air Testing								
Sulfur	0.165	0.060	gr/100 scf		ASTM D3246-11	3/9/22	3/9/22	MO
Total Sulfur/Hydrogen Sulfide by ASTM D3246								
Total Sulfur	2.73	1.00	ppm		ASTM D 3246/M	3/9/22	3/9/22	MO

NSS: Non Sufficient Sample H: Exceeds Analysis Hold Time TTLC: Total Threshold Limit Concentration STLC: Soluble Threshold Limit Concentration TCLP: Toxicity Characteristic Leaching Procedure MCL: Maximum Contaminant Level *: See Case Narrative
The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Note: Samples analyzed for regulatory purposes should be put on ice immediately after sampling and received by the laboratory at temperatures between 0-6°C. Microbiological analysis requires samples to be at least 4-10°C when received at the laboratory. For additional information regarding the limitations of the method(s) referred to, please call us at 661-395-0539.



ZALCO LABORATORIES, INC.

CHAIN OF CUSTODY, ID# 2203140

4309 Armour Avenue, Bakersfield, CA 93308 (661) 395-0539 FAX (661) 395-3069 www.zalcolabs.com
2186 Eastman Avenue, Suite 103, Ventura, CA 93003 (805) 477-0114 Fax (805) 477-0125

Zalco Lab #

Client PO #

PROJECT ID:

QUOTE ID:

COMMENTS: Turnaround Time: Routine 5 working days X
Rush By working days
Send Copy to State of CA? Yes No X
Attention To:
Send Copy to County? Yes No X
County

REPORT INFO: Client: MRP San Joaquin Energy LLC, Address: 14950 W. SHULTE RD., City, State, Zip: TRACY, CA 95377
INVOICE INFO: Invoice To: Same as Client, Address:
ANALYSIS: TOTAL SULFUR ASTM D3

Table with columns: Sample No., Sample Description, Date, Sample Time, Type, and Analysis results. Contains 3 rows of sample data.

Signature table with columns: RELINQUISHED By: Signature, PRINT, COMPANY, Date, Time, RECEIVED By: Signature, PRINT. Includes handwritten signatures and dates.

NOTE: Samples are discarded 30 days after results unless other arrangements are made. Hazardous samples will be returned to client or disposed of at the client's expense.
*Sample Type Key: AO-Aqueous; BS-Biosolid; DW-Drinking Water; GW-Ground Water; G-Gas; LPG-Liquid Petroleum Gas; OL-Oil; O-Other; P-Petroleum; S-Soil/Solid; ST-Storm Water; WW-Wastewater
*Sample No.: FOR OFFICE USE ONLY

ATTACHMENT 10
CEMS OPERATIONS REPORTS

MRP San Joaquin Energy, LLC

April 25, 2022

San Joaquin Valley Air Pollution Control District
Northern Region
4800 Enterprise Way
Modesto, California 95356-9322
Attention: Compliance Division

Subject: First Quarter 2022 Emissions Monitoring (CEMS) Report- Tracy Combined Cycle
Power Plant
Facility ID No. N-4597

To whom it may concern,

Enclosed please find the Continuous Emissions Monitoring (CEMS) Report for the first quarter of 2022, as required per condition 50 of Permit to Operate No. N-4597-1-11 and N-4597-2-11 issued on March 5, 2021, for the MRP- San Joaquin Energy, LLC facility located at 14950 W. Schulte Road, Tracy, California.

If you have any questions regarding the enclosed information, please feel free to contact Taylor Leach at (209) 505-5918 or e-mail: Taylor.Leach@naes.com.


Respectfully,



Claude Couvillion
Vice President of Operations

CERTIFICATION:

I declare, under penalty of perjury under the laws of the state of California, that, based on information and belief formed after reasonable inquiry, all information provided in this report is true, accurate, and complete:



Signature of Responsible Official

4/25/2022

Date:

Claude Couvillion

Name of Responsible Official (please print)

Vice President of Operations

Title of Responsible Official (please print)



Northern Region

Central Region

Southern Region

QUARTERLY CEMS EXCESS EMISSION AND DOWNTIME SUMMARY

1st JAN - MAR 2022

3rd JUL - SEPT 2022

2nd APR - JUN 2022

4th OCT - DEC 2022

Facility Name: MRP-San Joaquin Energy- TCCPP Permit #: N-4597-1-11

Location: 14950 W. Schulte Rd. City: Tracy

AIRS #: 06 077 N4597 NSPS Source?: Yes No

Process Equipment Description: Electrical Power Generating System #1

Pollutants Monitored: NO_x SO_x CO Opacity O₂ CO₂ NH₃
 Other: Inlet NO_x, O₂

Total Hours Process Equipment Operated During Quarter: 287.8

CEM Unit Information				
Pollutant	Manufacturer / Model	Serial #	Date Installed	Total Hours CEMS Operated During Qtr
NO _x	Horiba/ENDA - 7420-CL	P-4702-NOX-S	7/17/2017	329
SO _x				
CO	Horiba/ENDA - 7420-CL	P-4702-CO	7/17/2017	329
Opacity				
O ₂	Horiba/ENDA - 7420-CL	P-4702-O2-S	7/17/2017	329
CO ₂				
Other	Horiba/ENDA - 7420-CL	P-4702-NOX-I P-4702-O2-I	7/17/2017	329

Date of Last Performance Specification Test								
Pollutant	NO _x	SO _x	CO	Opacity	O ₂	CO ₂	NH ₃	Other
Date	1/12/22		1/12/22		1/12/22			1/12/22
Type	<input type="checkbox"/> RATA	<input type="checkbox"/> RATA	<input type="checkbox"/> RATA	<input type="checkbox"/> RATA	<input type="checkbox"/> RATA	<input type="checkbox"/> RATA	<input type="checkbox"/> RATA	<input type="checkbox"/> RATA
	<input checked="" type="checkbox"/> CGA	<input type="checkbox"/> CGA	<input checked="" type="checkbox"/> CGA	<input type="checkbox"/> CGA	<input checked="" type="checkbox"/> CGA	<input type="checkbox"/> CGA	<input type="checkbox"/> CGA	<input checked="" type="checkbox"/> CGA
	<input type="checkbox"/> Linearity	<input type="checkbox"/> Linearity	<input type="checkbox"/> Linearity	<input type="checkbox"/> Linearity	<input type="checkbox"/> Linearity	<input type="checkbox"/> Linearity	<input type="checkbox"/> Linearity	<input type="checkbox"/> Linearity

Emission Limits (From Operating Permits)						
Pollutant	ppm @ 15 O ₂ % DB Off	lb/hr DB Off	ppm@ 15 O ₂ % DB on	lb/hr DB on	lb/day	ppm @ O ₂
NO _x	2.0	8.10	2.0	10.30	814.9	
SO _x						
CO	2.0	3.90	2.0	6.00	1071.6	
VOC						
O ₂						
PM10						
NH ₃ (24 hr avg)	5	9.40	5	9.40		
Other						

Excess Emissions Information (Report in Hours)								
Pollutant	Start-Up / Shutdown	Process Problems	Breakdown	Other Known	Other Unknown	Total Hrs Excess	Total Op Hrs for Qtr	% Excess
NO _x	0	0	0	0	0	0	329	0.0 %
SO _x								
CO	0	0	0	0	0	0	329	0.0 %
Opacity								
O ₂								
CO ₂								
NH ₃	0	0	0	0	0	0	329	0.0 %
Other								

Include a summary of all dates, times, and excess emissions that occurred during the reporting period or submit copies of all related breakdown reports and Title V deviations.

Excess emissions caused by a startup after shutdown due to a malfunction should be reported as an excess emission due to an equipment breakdown. The source is not however, exempt from emission limits. All exceedances are to be reported in whole hour increments.

CEM Downtime Information (Report in Hours)								
Pollutant	Monitor Malfunction	Non-Monitor Malfunction	Q/A - Cal	Other	Unknown	Total Hrs Downtime	Total Hrs	% Downtime
NO _x	0	0	1	0	0	1	329	0.3%
SO _x								
CO	0	0	1	0	0	1	329	0.3%
Opacity								
1O ₂	0	0	1	0	0	1	329	0.3%
CO ₂								
NH ₃								
Other	0	0	1	0	0	1	329	0.3%

Include a summary of all downtime dates, times, duration, and activities that occurred during the reporting period or submit copies of all related breakdown reports and Title V deviations.

Non-CEM malfunctions are incidents that result in the CEM system being down but are not associated with a malfunction of the CEM system, i.e. plant power failure.

*Reports must be submitted within 30 days of the end of the quarter for which
the report was generated.*

**Please send the completed summary report to the District office
serving your facility**

Northern Region Office

Serving San Joaquin, Stanislaus, and Merced Counties
4800 Enterprise Way
Modesto CA 95356-8718
209-557-6400 ◆ FAX 209-557-6475

Central Region Office

Serving Madera, Fresno, and Kings Counties
1990 E. Gettysburg Avenue
Fresno CA 93276-0244
559-230-6000 ◆ FAX 559-230-6062

Southern Region Office

Serving Tulare and Kern Counties
34946 Flyover Court
Bakersfield CA 93308
661-392-5540 ◆ FAX 661-392-5586



Northern Region

Central Region

Southern Region

QUARTERLY CEMS EXCESS EMISSION AND DOWNTIME SUMMARY

1st JAN - MAR 2022

3rd JUL - SEPT 2022

2nd APR - JUN 2022

4th OCT - DEC 2022

Facility Name: MRP-San Joaquin Energy- TCCPP Permit #: N-4597-2-11

Location: 14950 W. Schulte Rd. City: Tracy

AIRS #: 06 077 N4597 NSPS Source?: Yes No

Process Equipment Description: Electrical Power Generating System #2

Pollutants Monitored: NO_x SO_x CO Opacity O₂ CO₂ NH₃
 Other: Inlet NO_x, O₂

Total Hours Process Equipment Operated During Quarter: 191.5

CEM Unit Information				
Pollutant	Manufacturer / Model	Serial #	Date Installed	Total Hours CEMS Operated During Qtr
NO _x	Horiba/ENDA - 7420-CL	P-4702-NOX-S	7/17/2017	221
SO _x				
CO	Horiba/ENDA - 7420-CL	P-4702-CO	7/17/2017	221
Opacity				
O ₂	Horiba/ENDA - 7420-CL	P-4702-O2-S	7/17/2017	221
CO ₂				
Other	Horiba/ENDA - 7420-CL	P-4702-NOX-I P-4702-O2-I	7/17/2017	221

Date of Last Performance Specification Test								
Pollutant	NO _x	SO _x	CO	Opacity	O ₂	CO ₂	NH ₃	Other
Date	1/13/22		1/11/22		1/13/22			1/11/22
Type	<input type="checkbox"/> RATA	<input type="checkbox"/> RATA	<input type="checkbox"/> RATA	<input type="checkbox"/> RATA	<input type="checkbox"/> RATA	<input type="checkbox"/> RATA	<input type="checkbox"/> RATA	<input type="checkbox"/> RATA
	<input type="checkbox"/> CGA	<input type="checkbox"/> CGA	<input checked="" type="checkbox"/> CGA	<input type="checkbox"/> CGA	<input type="checkbox"/> CGA	<input type="checkbox"/> CGA	<input type="checkbox"/> CGA	<input checked="" type="checkbox"/> CGA
	<input checked="" type="checkbox"/> Linearity	<input type="checkbox"/> Linearity	<input type="checkbox"/> Linearity	<input type="checkbox"/> Linearity	<input checked="" type="checkbox"/> Linearity	<input type="checkbox"/> Linearity	<input type="checkbox"/> Linearity	<input type="checkbox"/> Linearity

Emission Limits (From Operating Permits)						
Pollutant	ppm @ 15 O ₂ % DB Off	lb/hr DB Off	ppm@ 15 O ₂ % DB on	lb/hr DB on	lb/day	ppm @ O ₂
NO _x	2.0	8.10	2.0	10.30	814.9	
SO _x						
CO	2.0	3.90	2.0	6.00	1071.6	
VOC						
O ₂						
PM10						
NH ₃ (24 hr avg)	5	9.40	5	9.40		
Other						

Excess Emissions Information (Report in Hours)								
Pollutant	Start-Up / Shutdown	Process Problems	Breakdown	Other Known	Other Unknown	Total Hrs Excess	Total Op Hrs for Qtr	% Excess
NO _x	0	0	0	0	0	0	221	0.0 %
SO _x								
CO	0	0	0	0	0	0	221	0.0 %
Opacity								
O ₂								
CO ₂								
NH ₃	0	0	0	0	0	0	221	0.0 %
Other								

Include a summary of all dates, times, and excess emissions that occurred during the reporting period or submit copies of all related breakdown reports and Title V deviations.

Excess emissions caused by a startup after shutdown due to a malfunction should be reported as an excess emission due to an equipment breakdown. The source is not however, exempt from emission limits. All exceedances are to be reported in whole hour increments.

CEM Downtime Information (Report in Hours)								
Pollutant	Monitor Malfunction	Non-Monitor Malfunction	Q/A - Cal	Other	Unknown	Total Hrs Downtime	Total Hrs	% Downtime
NO _x	0	0	1	0	0	0	221	0.5%
SO _x								
CO	0	0	1	0	0	0	221	0.5%
Opacity								
O ₂	0	0	1	0	0	0	221	0.5%
CO ₂								
NH ₃								
Other	0	0	1	0	0	0	221	0.5%

Include a summary of all downtime dates, times, duration, and activities that occurred during the reporting period or submit copies of all related breakdown reports and Title V deviations.

Non-CEM malfunctions are incidents that result in the CEM system being down but are not associated with a malfunction of the CEM system, i.e. plant power failure.

*Reports must be submitted within 30 days of the end of the quarter for which
the report was generated.*

**Please send the completed summary report to the District office
serving your facility**

Northern Region Office

Serving San Joaquin, Stanislaus, and Merced Counties
4800 Enterprise Way
Modesto CA 95356-8718
209-557-6400 ◆ FAX 209-557-6475

Central Region Office

Serving Madera, Fresno, and Kings Counties
1990 E. Gettysburg Avenue
Fresno CA 93276-0244
559-230-6000 ◆ FAX 559-230-6062

Southern Region Office

Serving Tulare and Kern Counties
34946 Flyover Court
Bakersfield CA 93308
661-392-5540 ◆ FAX 661-392-5586

Turbine 1 NOx/H CGA

Tracy Combined Cycle Power Plant

Test Information

Test Date: 1/11/2022

Analyzer and Monitor Information

Range: High
 Instrument Span: 100 ppm
 Manufacturer: HORIBA
 Model: ENDA-7420CL
 Serial Number: P-4702-NOX-S

Run Number	Time	Reference Gas	CEMS Response	Cylinder Information	
Low Gas					
1	8:38 AM	25.34	24.95	Allowable Reference Values: 20-30 ppm (20-30% of span) Cylinder ID: EB0083064 Expiration Date: 4/28/2023 EPA Vendor ID: B72020 Cylinder contains: CO,NO,BALN	
2	8:44 AM	25.34	25.08		
3	8:50 AM	25.34	25.13		
Mean (ppm)		25.34	25.05		
Difference of means (Cm-Ca) (ppm)		-0.3	Limit 5		Passed
CEMS Accuracy (%)		-1.1	Limit 15		Passed
Mid Gas					
1	8:41 AM	54.29	54.34		
2	8:47 AM	54.29	54.43		
3	8:53 AM	54.29	54.44		
Mean (ppm)		54.29	54.40		
Difference of means (Cm-Ca) (ppm)		0.1	Limit 5	Passed	
CEMS Accuracy (%)		0.2	Limit 15	Passed	

CEMS Accuracy Determination (%)

$$\text{Accuracy (\%)} = ((Cm - Ca) / Ca) * 100$$

Ca = Reference gas value

Cm = Mean of actual CEMS responses

Turbine 1 NOx/H Linearity

Tracy Combined Cycle Power Plant

Test Information

Test Date: 1/11/2022
 Test Reason:
 Grace Period: No
 Aborted: No
 Unit online during QA test

Analyzer and Monitor Information

Range: High
 Instrument Span: 100 ppm
 Component ID: 200
 Manufacturer: HORIBA
 Model: ENDA-7420CL
 Serial Number: P-4702-NOX-S

Run Number	Time	Reference Gas	CEMS Response	Cylinder Information
------------	------	---------------	---------------	----------------------

Low Gas

1	6:37 AM	25.34	24.85
2	6:46 AM	25.34	25.22
3	6:55 AM	25.34	25.24

Mean (ppm)	25.34	25.10	
Difference of means (R-A) (ppm)	0.2	Limit 5	Passed
Linearity Error (%)	0.9	Limit 5.0	Passed

Allowable Reference Values:
 20-30 ppm (20-30% of span)
 Cylinder ID: EB0083064
 Expiration Date: 4/28/2023
 EPA Vendor ID: B72020
 Cylinder contains: CO,NO,BALN

Mid Gas

1	6:40 AM	54.29	54.25
2	6:49 AM	54.29	54.47
3	6:58 AM	54.29	54.57

Mean (ppm)	54.29	54.43	
Difference of means (R-A) (ppm)	0.1	Limit 5	Passed
Linearity Error (%)	0.3	Limit 5.0	Passed

Allowable Reference Values:
 50-60 ppm (50-60% of span)
 Cylinder ID: ALM022636
 Expiration Date: 8/27/2026
 EPA Vendor ID: B72018
 Cylinder contains: CO,NO,BALN

High Gas

1	6:43 AM	91.55	92.47
2	6:52 AM	91.55	92.68
3	7:01 AM	91.55	92.85

Mean (ppm)	91.55	92.67	
Difference of means (R-A) (ppm)	1.1	Limit 5	Passed
Linearity Error (%)	1.2	Limit 5.0	Passed

Allowable Reference Values:
 80-100 ppm (80-100% of span)
 Cylinder ID: CC349448
 Expiration Date: 2/11/2027
 EPA Vendor ID: B72019
 Cylinder contains: CO,NO,BALN

Linearity Error (LE) Determination

$$LE (\%) = (|R-A| / R) * 100$$

R = Reference gas value

A = Mean of actual CEMS responses

Turbine 1 CO/H CGA

Tracy Combined Cycle Power Plant

Test Information

Test Date: 1/11/2022

Analyzer and Monitor Information

Range: High
 Instrument Span: 200 ppm
 Manufacturer: HORIBA
 Model: ENDA-7420CL
 Serial Number: P-4702-CO

Run Number	Time	Reference Gas	CEMS Response	Cylinder Information
------------	------	---------------	---------------	----------------------

Low Gas

1	8:38 AM	45.160	46.390
2	8:44 AM	45.160	46.417
3	8:50 AM	45.160	46.423

Mean (ppm)	45.160	46.410	
Difference of means (Cm-Ca) (ppm)	1.3	<i>Limit 5</i>	<i>Passed</i>
CEMS Accuracy (%)	2.8	<i>Limit 15</i>	<i>Passed</i>

Allowable Reference Values:
 40-60 ppm (20-30% of span)
 Cylinder ID: EB0083064
 Expiration Date: 4/28/2023
 EPA Vendor ID: B72020
 Cylinder contains: CO,NO,BALN

Mid Gas

1	8:41 AM	110.400	111.688
2	8:47 AM	110.400	111.708
3	8:53 AM	110.400	111.626

Mean (ppm)	110.400	111.674	
Difference of means (Cm-Ca) (ppm)	1.3	<i>Limit 5</i>	<i>Passed</i>
CEMS Accuracy (%)	1.2	<i>Limit 15</i>	<i>Passed</i>

Allowable Reference Values:
 100-120 ppm (50-60% of span)
 Cylinder ID: ALM022636
 Expiration Date: 8/27/2026
 EPA Vendor ID: B72018
 Cylinder contains: CO,NO,BALN

CEMS Accuracy Determination (%)

$$\text{Accuracy (\%)} = ((Cm - Ca) / Ca) * 100$$

Ca = Reference gas value

Cm = Mean of actual CEMS responses

Turbine 1 O2 Linearity

Tracy Combined Cycle Power Plant

Test Information

Test Date: 1/11/2022
Test Reason:
Grace Period: No
Aborted: No
Unit online during QA test

Analyzer and Monitor Information

Range: Single Scale
Instrument Span: 25 %O2
Component ID: 210
Manufacturer: HORIBA
Model: ENDA-7420CL
Serial Number: P-4702-O2-S

Run Number	Time	Reference Gas	CEMS Response	Cylinder Information
Low Gas				
1	5:54 AM	6.494	6.550	
2	6:03 AM	6.494	6.549	
3	6:12 AM	6.494	6.575	
Mean (%O2)		6.494	6.558	
Difference of means (R-A) (%O2)		0.1	<i>Limit 0.5</i>	<i>Passed</i>
Linearity Error (%)		1.0	<i>Limit 5.0</i>	<i>Passed</i>
Allowable Reference Values: 5-7.5 %O2 (20-30% of span) Cylinder ID: CC4213 Expiration Date: 4/17/2023 EPA Vendor ID: B32015 Cylinder contains: O2,BALN				
Mid Gas				
1	5:57 AM	13.560	13.564	
2	6:06 AM	13.560	13.551	
3	6:15 AM	13.560	13.582	
Mean (%O2)		13.560	13.566	
Difference of means (R-A) (%O2)		0.0	<i>Limit 0.5</i>	<i>Passed</i>
Linearity Error (%)		0.0	<i>Limit 5.0</i>	<i>Passed</i>
Allowable Reference Values: 12.5-15 %O2 (50-60% of span) Cylinder ID: CC00524 Expiration Date: 4/24/2028 EPA Vendor ID: B72020 Cylinder contains: O2,BALN				
High Gas				
1	6:00 AM	22.020	22.037	
2	6:09 AM	22.020	22.024	
3	6:18 AM	22.020	22.021	
Mean (%O2)		22.020	22.027	
Difference of means (R-A) (%O2)		0.0	<i>Limit 0.5</i>	<i>Passed</i>
Linearity Error (%)		0.0	<i>Limit 5.0</i>	<i>Passed</i>
Allowable Reference Values: 20-25 %O2 (80-100% of span) Cylinder ID: EB0086797 Expiration Date: 6/18/2027 EPA Vendor ID: B72019 Cylinder contains: O2,BALN				

Linearity Error (LE) Determination

$$LE (\%) = (|R-A| / R) * 100$$

R = Reference gas value

A = Mean of actual CEMS responses

Turbine 1 NOx/L CGA

Tracy Combined Cycle Power Plant

Test Information

Test Date: 1/12/2022

Analyzer and Monitor Information

Range: Low
 Instrument Span: 10 ppm
 Manufacturer: HORIBA
 Model: ENDA-7420CL
 Serial Number: P-7402-NOX-S

Run Number	Time	Reference Gas	CEMS Response	Cylinder Information
Low Gas				
1	9:29 AM	2.434	2.438	
2	9:35 AM	2.434	2.471	
3	9:41 AM	2.434	2.471	
	Mean (ppm)	2.434	2.460	
	Difference of means (Cm-Ca) (ppm)	0.0	Limit 5	Passed
	CEMS Accuracy (%)	1.1	Limit 15	Passed
Mid Gas				
1	9:32 AM	5.551	5.648	
2	9:38 AM	5.551	5.600	
3	9:44 AM	5.551	5.642	
	Mean (ppm)	5.551	5.630	
	Difference of means (Cm-Ca) (ppm)	0.1	Limit 5	Passed
	CEMS Accuracy (%)	1.4	Limit 15	Passed

Allowable Reference Values:
 2-3 ppm (20-30% of span)
 Cylinder ID: CC435039
 Expiration Date: 9/3/2022
 EPA Vendor ID: B32019
 Cylinder contains: CO,NO,BALN

Allowable Reference Values:
 5-6 ppm (50-60% of span)
 Cylinder ID: EB0098553
 Expiration Date: 8/6/2022
 EPA Vendor ID: B72019
 Cylinder contains: CO,NO,BALN

CEMS Accuracy Determination (%)
 $Accuracy\ (\%) = ((Cm - Ca) / Ca) * 100$
 Ca = Reference gas value
 Cm = Mean of actual CEMS responses

Turbine 1 Inlet NOx CGA

Tracy Combined Cycle Power Plant

Test Information

Test Date: 1/12/2022

Analyzer and Monitor Information

Range: Single Scale
Instrument Span: 20 ppm
Manufacturer: HORIBA
Model: ENDA-7420CL
Serial Number: P-4702-O2-I

Run Number	Time	Reference Gas	CEMS Response	Cylinder Information
Low Gas				
1	9:57 AM	5.551	5.246	
2	10:03 AM	5.551	5.256	
3	10:09 AM	5.551	5.272	
	Mean (ppm)	5.551	5.258	
	Difference of means (Cm-Ca) (ppm)	-0.3	Limit 5	Passed
	CEMS Accuracy (%)	-5.3	Limit 15	Passed
Mid Gas				
1	10:00 AM	11.210	10.968	
2	10:06 AM	11.210	11.024	
3	10:12 AM	11.210	10.989	
	Mean (ppm)	11.210	10.994	
	Difference of means (Cm-Ca) (ppm)	-0.2	Limit 5	Passed
	CEMS Accuracy (%)	-1.9	Limit 15	Passed

Allowable Reference Values:
4-6 ppm (20-30% of span)
Cylinder ID: EB0098553
Expiration Date: 8/6/2022
EPA Vendor ID: B72019
Cylinder contains: CO,NO,BALN

Allowable Reference Values:
10-12 ppm (50-60% of span)
Cylinder ID: C436849
Expiration Date: 10/31/2022
EPA Vendor ID: B72019
Cylinder contains: NO,BALN

CEMS Accuracy Determination (%)

$$\text{Accuracy (\%)} = ((Cm - Ca) / Ca) * 100$$

Ca = Reference gas value

Cm = Mean of actual CEMS responses

Turbine 1 CO/L CGA

Tracy Combined Cycle Power Plant

Test Information

Test Date: 1/12/2022

Analyzer and Monitor Information

Range: Low
 Instrument Span: 20 ppm
 Manufacturer: HORIBA
 Model: ENDA-7420CL
 Serial Number: P-4702-CO

Run Number	Time	Reference Gas	CEMS Response	Cylinder Information
------------	------	---------------	---------------	----------------------

Low Gas

1	9:29 AM	4.966	4.979
2	9:35 AM	4.966	5.104
3	9:41 AM	4.966	5.079

Mean (ppm)	4.966	5.054	
Difference of means (Cm-Ca) (ppm)	0.1	<i>Limit 5</i>	<i>Passed</i>
CEMS Accuracy (%)	1.8	<i>Limit 15</i>	<i>Passed</i>

Allowable Reference Values:
 4-6 ppm (20-30% of span)
 Cylinder ID: CC435039
 Expiration Date: 9/3/2022
 EPA Vendor ID: B32019
 Cylinder contains: CO,NO,BALN

Mid Gas

1	9:32 AM	10.820	11.116
2	9:38 AM	10.820	11.166
3	9:44 AM	10.820	11.139

Mean (ppm)	10.820	11.140	
Difference of means (Cm-Ca) (ppm)	0.3	<i>Limit 5</i>	<i>Passed</i>
CEMS Accuracy (%)	3.0	<i>Limit 15</i>	<i>Passed</i>

Allowable Reference Values:
 10-12 ppm (50-60% of span)
 Cylinder ID: EB098553
 Expiration Date: 8/6/2022
 EPA Vendor ID: B72019
 Cylinder contains: CO,NO,BALN

CEMS Accuracy Determination (%)

$$\text{Accuracy (\%)} = ((Cm - Ca) / Ca) * 100$$

Ca = Reference gas value

Cm = Mean of actual CEMS responses

Turbine 1 O2 CGA

Tracy Combined Cycle Power Plant

Test Information

Test Date: 1/12/2022

Analyzer and Monitor Information

Range: Single Scale
 Instrument Span: 25 %O2
 Manufacturer: HORIBA
 Model: ENDA-7420CL
 Serial Number: P-4702-O2-S

Run Number	Time	Reference Gas	CEMS Response	Cylinder Information
------------	------	---------------	---------------	----------------------

Low Gas

1	9:02 AM	5.154	5.220
2	9:08 AM	5.154	5.140
3	9:14 AM	5.154	5.210

Mean (%O2)	5.154	5.190
Difference of means (Cm-Ca) (%O2)	0.0	
CEMS Accuracy (%)	0.7	Limit 15

Allowable Reference Values:
 4-6 %O2
 Cylinder ID: CC408418
 Expiration Date: 9/11/2026
 EPA Vendor ID: B72018
 Cylinder contains: O2,BALN

Mid Gas

1	9:05 AM	9.983	9.979
2	9:11 AM	9.983	10.002
3	9:17 AM	9.983	10.008

Mean (%O2)	9.983	9.996
Difference of means (Cm-Ca) (%O2)	0.0	
CEMS Accuracy (%)	0.1	Limit 15

Allowable Reference Values:
 8-12 %O2
 Cylinder ID: CC454203
 Expiration Date: 10/10/2022
 EPA Vendor ID: B32014
 Cylinder contains: O2,BALN

CEMS Accuracy Determination (%)
 $Accuracy\ (\%) = ((Cm - Ca) / Ca) * 100$
Ca = Reference gas value
Cm = Mean of actual CEMS responses

Turbine 1 Inlet O2 CGA

Tracy Combined Cycle Power Plant

Test Information

Test Date: 1/12/2022

Analyzer and Monitor Information

Range: Single Scale
 Instrument Span: 25 %O2
 Manufacturer: HORIBA
 Model: ENDA-7420CL
 Serial Number: P-4702-O2-I

Run Number	Time	Reference Gas	CEMS Response	Cylinder Information
------------	------	---------------	---------------	----------------------

Low Gas

1	8:40 AM	5.154	5.199	
2	8:46 AM	5.154	5.174	
3	8:52 AM	5.154	5.155	

Allowable Reference Values:
4-6 %O2

Mean (%O2) 5.154 5.176

Difference of means (Cm-Ca) (%O2) 0.0

CEMS Accuracy (%) 0.4 *Limit 15* *Passed*

Cylinder ID: CC408418
 Expiration Date: 9/11/2026
 EPA Vendor ID: B72018
 Cylinder contains: O2,BALN

Mid Gas

1	8:43 AM	9.983	10.009	
2	8:49 AM	9.983	9.989	
3	8:55 AM	9.983	9.989	

Allowable Reference Values:
8-12 %O2

Mean (%O2) 9.983 9.996

Difference of means (Cm-Ca) (%O2) 0.0

CEMS Accuracy (%) 0.1 *Limit 15* *Passed*

Cylinder ID: CC454203
 Expiration Date: 10/10/2022
 EPA Vendor ID: B32014
 Cylinder contains: O2,BALN

CEMS Accuracy Determination (%)

$$\text{Accuracy (\%)} = ((Cm - Ca) / Ca) * 100$$

Ca = Reference gas value

Cm = Mean of actual CEMS responses

Turbine 2 NOx/H CGA

Tracy Combined Cycle Power Plant

Test Information

Test Date: 1/11/2022

Analyzer and Monitor Information

Range: High
 Instrument Span: 100 ppm
 Manufacturer: HORIBA
 Model: ENDA-7420CL
 Serial Number: P-4701-NOX-S

Run Number	Time	Reference Gas	CEMS Response	Cylinder Information
Low Gas				
1	9:25 AM	25.49	24.25	
2	9:31 AM	25.49	24.82	
3	9:37 AM	25.49	24.98	
	Mean (ppm)	25.49	24.68	
	Difference of means (Cm-Ca) (ppm)	-0.8	Limit 5	Passed
	CEMS Accuracy (%)	-3.2	Limit 15	Passed
Mid Gas				
1	9:28 AM	54.29	53.46	
2	9:34 AM	54.29	53.87	
3	9:40 AM	54.29	54.15	
	Mean (ppm)	54.29	53.83	
	Difference of means (Cm-Ca) (ppm)	-0.5	Limit 5	Passed
	CEMS Accuracy (%)	-0.9	Limit 15	Passed

Allowable Reference Values:
 20-30 ppm (20-30% of span)
 Cylinder ID: EB0094257
 Expiration Date: 2/12/2022
 EPA Vendor ID: B72019
 Cylinder contains: CO,NO,BALN

Allowable Reference Values:
 50-60 ppm (50-60% of span)
 Cylinder ID: ALM0022636
 Expiration Date: 8/27/2026
 EPA Vendor ID: B72018
 Cylinder contains: CO,NO,BALN

CEMS Accuracy Determination (%)
 $Accuracy\ (\%) = ((Cm - Ca) / Ca) * 100$
Ca = Reference gas value
Cm = Mean of actual CEMS responses

Turbine 2 NOx/L CGA

Tracy Combined Cycle Power Plant

Test Information

Test Date: 1/11/2022

Analyzer and Monitor Information

Range: Low
 Instrument Span: 10 ppm
 Manufacturer: HORIBA
 Model: ENDA-7420CL
 Serial Number: P-4701-NOX-S

Run Number	Time	Reference Gas	CEMS Response	Cylinder Information
Low Gas				
1	10:32 AM	2.434	2.484	
2	10:38 AM	2.434	2.491	
3	10:44 AM	2.434	2.489	
	Mean (ppm)	2.434	2.488	
	Difference of means (Cm-Ca) (ppm)	0.1	Limit 5	Passed
	CEMS Accuracy (%)	2.2	Limit 15	Passed
Mid Gas				
1	10:35 AM	5.551	5.727	
2	10:41 AM	5.551	5.721	
3	10:47 AM	5.551	5.721	
	Mean (ppm)	5.551	5.723	
	Difference of means (Cm-Ca) (ppm)	0.2	Limit 5	Passed
	CEMS Accuracy (%)	3.1	Limit 15	Passed

Allowable Reference Values:
 2-3 ppm (20-30% of span)
 Cylinder ID: CC435039
 Expiration Date: 9/3/2022
 EPA Vendor ID: B32019
 Cylinder contains: CO,NO,BALN

Allowable Reference Values:
 5-6 ppm (50-60% of span)
 Cylinder ID: EBOO9855
 Expiration Date: 8/6/2022
 EPA Vendor ID: B72019
 Cylinder contains: CO,NO,BALN

CEMS Accuracy Determination (%)
 $Accuracy (\%) = ((Cm - Ca) / Ca) * 100$
 Ca = Reference gas value
 Cm = Mean of actual CEMS responses

Turbine 2 Inlet NOx CGA

Tracy Combined Cycle Power Plant

Test Information

Test Date: 1/11/2022

Analyzer and Monitor Information

Range: Single Scale
 Instrument Span: 20 ppm
 Manufacturer: HORIBA
 Model: ENDA-7420CL
 Serial Number: P-4701-O2-I

Run Number	Time	Reference Gas	CEMS Response	Cylinder Information
------------	------	---------------	---------------	----------------------

Low Gas

1	10:59 AM	5.551	5.224
2	11:05 AM	5.551	5.207
3	11:11 AM	5.551	5.203

Mean (ppm)	5.551	5.211	
Difference of means (Cm-Ca) (ppm)	-0.3	Limit 5	Passed
CEMS Accuracy (%)	-6.1	Limit 15	Passed

Allowable Reference Values:
 4-6 ppm (20-30% of span)
 Cylinder ID: EB0098553
 Expiration Date: 8/6/2022
 EPA Vendor ID: B72019
 Cylinder contains: CO,NO,BALN

Mid Gas

1	11:02 AM	11.210	10.794
2	11:08 AM	11.210	10.797
3	11:14 AM	11.210	10.842

Mean (ppm)	11.210	10.811	
Difference of means (Cm-Ca) (ppm)	-0.4	Limit 5	Passed
CEMS Accuracy (%)	-3.6	Limit 15	Passed

Allowable Reference Values:
 10-12 ppm (50-60% of span)
 Cylinder ID: CC436849
 Expiration Date: 10/31/2022
 EPA Vendor ID: B72019
 Cylinder contains: NO,BALN

CEMS Accuracy Determination (%)

$$\text{Accuracy (\%)} = ((Cm - Ca) / Ca) * 100$$

Ca = Reference gas value

Cm = Mean of actual CEMS responses

Turbine 2 CO/H CGA

Tracy Combined Cycle Power Plant

Test Information

Test Date: 1/11/2022

Analyzer and Monitor Information

Range: High
 Instrument Span: 200 ppm
 Manufacturer: HORIBA
 Model: ENDA-7420CL
 Serial Number: P-4701-CO

Run Number	Time	Reference Gas	CEMS Response	Cylinder Information	
Low Gas					
1	9:25 AM	45.160	46.528	Allowable Reference Values: 40-60 ppm (20-30% of span) Cylinder ID: EB0083064 Expiration Date: 4/28/2023 EPA Vendor ID: B72020 Cylinder contains: CO,NO,BALN	
2	9:31 AM	45.160	46.787		
3	9:37 AM	45.160	46.837		
Mean (ppm)		45.160	46.717		
Difference of means (Cm-Ca) (ppm)		1.6	Limit 5 Passed		
CEMS Accuracy (%)		3.4	Limit 15 Passed		
Mid Gas					
1	9:28 AM	110.400	112.603		
2	9:34 AM	110.400	112.727		
3	9:40 AM	110.400	112.773		
Mean (ppm)		110.400	112.701		
Difference of means (Cm-Ca) (ppm)		2.3	Limit 5 Passed		
CEMS Accuracy (%)		2.1	Limit 15 Passed		

CEMS Accuracy Determination (%)
 $Accuracy\ (\%) = ((Cm - Ca) / Ca) * 100$
 Ca = Reference gas value
 Cm = Mean of actual CEMS responses

Turbine 2 CO/L CGA

Tracy Combined Cycle Power Plant

Test Information

Test Date: 1/11/2022

Analyzer and Monitor Information

Range: Low
 Instrument Span: 20 ppm
 Manufacturer: HORIBA
 Model: ENDA-7420CL
 Serial Number: P-4701-CO

Run Number	Time	Reference Gas	CEMS Response		Cylinder Information	
Low Gas						
1	10:32 AM	4.966	4.970		Allowable Reference Values: 4-6 ppm (20-30% of span) Cylinder ID: CC435039 Expiration Date: 9/3/2022 EPA Vendor ID: B32019 Cylinder contains: CO,NO,BALN	
2	10:38 AM	4.966	4.957			
3	10:44 AM	4.966	4.994			
Mean (ppm)		4.966	4.974			
Difference of means (Cm-Ca) (ppm)		0.0	Limit 5	Passed		
CEMS Accuracy (%)		0.2	Limit 15	Passed		
Mid Gas						
1	10:35 AM	10.820	11.008			
2	10:41 AM	10.820	11.045			
3	10:47 AM	10.820	11.050			
Mean (ppm)		10.820	11.034			
Difference of means (Cm-Ca) (ppm)		0.2	Limit 5	Passed		
CEMS Accuracy (%)		2.0	Limit 15	Passed		

CEMS Accuracy Determination (%)
 $Accuracy\ (\%) = ((Cm - Ca) / Ca) * 100$
 Ca = Reference gas value
 Cm = Mean of actual CEMS responses

Turbine 2 O2 CGA

Tracy Combined Cycle Power Plant

Test Information

Test Date: 1/11/2022

Analyzer and Monitor Information

Range: Single Scale
 Instrument Span: 25 %O2
 Manufacturer: HORIBA
 Model: ENDA-7420CL
 Serial Number: P-4701-O2-S

Run Number	Time	Reference Gas	CEMS Response	Cylinder Information
------------	------	---------------	---------------	----------------------

Low Gas

1	1:27 PM	5.154	5.168	
2	1:33 PM	5.154	5.174	
3	1:39 PM	5.154	5.173	

Allowable Reference Values:
4-6 %O2

Mean (%O2)		5.154	5.172	
Difference of means (Cm-Ca) (%O2)		0.0		
CEMS Accuracy (%)		0.3	Limit 15	Passed

Cylinder ID: CC408418
 Expiration Date: 9/11/2026
 EPA Vendor ID: B72018
 Cylinder contains: O2,BALN

Mid Gas

1	1:30 PM	9.983	10.029	
2	1:36 PM	9.983	10.021	
3	1:42 PM	9.983	10.013	

Allowable Reference Values:
8-12 %O2

Mean (%O2)		9.983	10.021	
Difference of means (Cm-Ca) (%O2)		0.0		
CEMS Accuracy (%)		0.4	Limit 15	Passed

Cylinder ID: CC454203
 Expiration Date: 10/10/2022
 EPA Vendor ID: B32014
 Cylinder contains: O2,BALN

CEMS Accuracy Determination (%)

$$\text{Accuracy (\%)} = ((Cm - Ca) / Ca) * 100$$

Ca = Reference gas value

Cm = Mean of actual CEMS responses

Turbine 2 Inlet O2 CGA

Tracy Combined Cycle Power Plant

Test Information

Test Date: 1/11/2022

Analyzer and Monitor Information

Range: Single Scale
 Instrument Span: 25 %O2
 Manufacturer: HORIBA
 Model: ENDA-7420CL
 Serial Number: P-4701-O2-I

Run Number	Time	Reference Gas	CEMS Response	Cylinder Information
Low Gas				
1	1:07 PM	5.154	5.175	
2	1:13 PM	5.154	5.170	
3	1:19 PM	5.154	5.103	
	Mean (%O2)	5.154	5.149	
	Difference of means (Cm-Ca) (%O2)	0.0		
	CEMS Accuracy (%)	-0.1	Limit 15	Passed
				Allowable Reference Values: 4-6 %O2
				Cylinder ID: CC408418
				Expiration Date: 9/11/2026
				EPA Vendor ID: B72018
				Cylinder contains: O2,BALN

Mid Gas

1	1:10 PM	9.983	10.018	
2	1:16 PM	9.983	9.959	
3	1:22 PM	9.983	9.945	
	Mean (%O2)	9.983	9.974	
	Difference of means (Cm-Ca) (%O2)	0.0		
	CEMS Accuracy (%)	-0.1	Limit 15	Passed
				Allowable Reference Values: 8-12 %O2
				Cylinder ID: CC454203
				Expiration Date: 10/10/2022
				EPA Vendor ID: B32014
				Cylinder contains: O2,BALN

CEMS Accuracy Determination (%)

$$Accuracy (\%) = ((Cm - Ca) / Ca) * 100$$

Ca = Reference gas value

Cm = Mean of actual CEMS responses

Turbine 2 NOx/H Linearity

Tracy Combined Cycle Power Plant

Test Information

Test Date: 1/13/2022
 Test Reason:
 Grace Period: No
 Aborted: No
 Unit online during QA test

Analyzer and Monitor Information

Range: High
 Instrument Span: 100 ppm
 Component ID: 200
 Manufacturer: HORIBA
 Model: ENDA-7420CL
 Serial Number: P-4701-NOX-S

Run Number	Time	Reference Gas	CEMS Response	Cylinder Information
Low Gas				
1	3:55 PM	25.34	24.36	
2	4:04 PM	25.34	24.87	
3	4:13 PM	25.34	24.96	
Mean (ppm)		25.34	24.73	
Difference of means (R-A) (ppm)		0.6	Limit 5	Passed
Linearity Error (%)		2.4	Limit 5.0	Passed
Allowable Reference Values: 20-30 ppm (20-30% of span) Cylinder ID: EB0083064 Expiration Date: 4/28/2023 EPA Vendor ID: B72020 Cylinder contains: CO,NO,BALN				
Mid Gas				
1	3:58 PM	54.29	53.34	
2	4:07 PM	54.29	53.70	
3	4:16 PM	54.29	53.99	
Mean (ppm)		54.29	53.68	
Difference of means (R-A) (ppm)		0.6	Limit 5	Passed
Linearity Error (%)		1.1	Limit 5.0	Passed
Allowable Reference Values: 50-60 ppm (50-60% of span) Cylinder ID: ALM22636 Expiration Date: 8/27/2026 EPA Vendor ID: B72018 Cylinder contains: CO,NO,BALN				
High Gas				
1	4:01 PM	91.55	91.23	
2	4:10 PM	91.55	91.50	
3	4:19 PM	91.55	91.76	
Mean (ppm)		91.55	91.50	
Difference of means (R-A) (ppm)		0.1	Limit 5	Passed
Linearity Error (%)		0.1	Limit 5.0	Passed
Allowable Reference Values: 80-100 ppm (80-100% of span) Cylinder ID: CC349448 Expiration Date: 2/11/2027 EPA Vendor ID: B72019 Cylinder contains: CO,NO,BALN				

Linearity Error (LE) Determination

$$LE (\%) = (|R-A| / R) * 100$$

R = Reference gas value

A = Mean of actual CEMS responses

Turbine 2 O2 Linearity

Tracy Combined Cycle Power Plant

Test Information

Test Date: 1/13/2022
Test Reason:
Grace Period: No
Aborted: No
Unit online during QA test

Analyzer and Monitor Information

Range: Single Scale
Instrument Span: 25 %O2
Component ID: 210
Manufacturer: HORIBA
Model: ENDA-7420CL
Serial Number: P-4701-O2-S

Run Number	Time	Reference Gas	CEMS Response	Cylinder Information
Low Gas				
1	4:36 PM	6.494	6.486	
2	4:45 PM	6.494	6.583	
3	4:54 PM	6.494	6.507	
Mean (%O2)		6.494	6.525	
Difference of means (R-A) (%O2)		0.0	Limit 0.5	Passed
Linearity Error (%)		0.5	Limit 5.0	Passed
Allowable Reference Values: 5-7.5 %O2 (20-30% of span) Cylinder ID: CC4213 Expiration Date: 4/17/2023 EPA Vendor ID: B32015 Cylinder contains: O2,BALN				
Mid Gas				
1	4:39 PM	13.560	13.542	
2	4:48 PM	13.560	13.549	
3	4:57 PM	13.560	13.545	
Mean (%O2)		13.560	13.545	
Difference of means (R-A) (%O2)		0.0	Limit 0.5	Passed
Linearity Error (%)		0.1	Limit 5.0	Passed
Allowable Reference Values: 12.5-15 %O2 (50-60% of span) Cylinder ID: CC400524 Expiration Date: 4/24/2028 EPA Vendor ID: B72020 Cylinder contains: O2,BALN				
High Gas				
1	4:42 PM	22.020	22.060	
2	4:51 PM	22.020	22.005	
3	5:00 PM	22.020	22.046	
Mean (%O2)		22.020	22.037	
Difference of means (R-A) (%O2)		0.0	Limit 0.5	Passed
Linearity Error (%)		0.1	Limit 5.0	Passed
Allowable Reference Values: 20-25 %O2 (80-100% of span) Cylinder ID: EB0086797 Expiration Date: 6/18/2027 EPA Vendor ID: B72019 Cylinder contains: O2,BALN				

Linearity Error (LE) Determination

$$LE (\%) = (|R-A| / R) * 100$$

R = Reference gas value

A = Mean of actual CEMS responses

ATTACHMENT 11
EMERGENCY GENERATOR RUN LOG

**ATTACHMENT 12
AUX BOILER RUN LOG**

Tracy Combined Cycle Power Plant
 Tracy, CA
Aux Boiler & Steam Turbine- Monthly Operations
 January - 2022

Day	Aux Boiler							Steam Turbine	
	O2%	Gas Flow kscf	Heat Input mmBtu	Recirc Flow lbs	Recirc Flow On-Time	Master Demand %	Boiler On-Time	Megawatt Hours	STG On-Time
01	4.0	387.8	404.8	214286.5	24.00	Down	24.0	37	2.2
02	4.0	368.5	384.4	206036.7	24.00	Down	24.0	193	5.3
03	4.2	89.6	93.6	50065.7	6.10	20.9	6.2	1076	13.2
04	8.0	17.5	18.3	8896.7	1.27	18.1	1.4	1067	12.6
05	4.5	17.8	18.7	9057.1	1.30	17.9	1.5	954	12.5
06	4.0	269.3	281.1	148445.0	16.37	Down	16.4	Down	0.0
07	4.0	442.5	462.1	245307.2	24.00	Down	24.0	Down	0.0
08	4.0	436.8	455.9	240252.6	24.00	Down	24.0	Down	0.0
09	4.0	375.1	391.1	217188.8	24.00	Down	24.0	Down	0.0
10	4.0	182.3	190.2	102601.3	11.97	25.2	12.0	904	14.2
11	4.3	86.3	90.0	48567.9	6.33	21.7	6.5	683	9.8
12	4.4	17.1	17.8	8445.6	1.23	18.2	1.4	711	10.6
13	4.7	16.4	17.1	7735.1	1.17	17.7	1.3	712	10.8
14	5.8	255.9	267.1	127776.2	13.12	Down	14.4	Down	0.0
15	4.0	421.6	440.1	238675.5	24.00	Down	24.0	Down	0.0
16	4.0	385.2	401.8	220283.7	24.00	Down	24.0	Down	0.0
17	4.0	377.0	393.6	216914.9	24.00	Down	24.0	Down	0.0
18	4.0	373.5	390.0	213320.9	23.85	Down	23.9	Down	0.0
19	4.0	350.1	365.0	207477.3	23.82	Down	23.9	Down	0.0
20	4.0	349.2	365.2	215519.1	24.00	Down	24.0	Down	0.0
21	4.0	349.6	364.8	220079.8	24.00	Down	24.0	Down	0.0
22	4.0	349.5	365.3	215791.3	24.00	Down	24.0	Down	0.0
23	4.0	350.7	365.5	214430.2	24.00	Down	24.0	Down	0.0
24	4.0	350.2	366.3	215084.6	24.00	Down	24.0	Down	0.0
25	4.0	354.0	369.5	217751.8	24.00	Down	24.0	Down	0.0
26	4.0	345.7	360.9	212906.5	24.00	Down	24.0	Down	0.0
27	4.0	341.4	356.0	211950.1	24.00	Down	24.0	Down	0.0
28	4.0	339.4	354.5	210575.5	24.00	Down	24.0	Down	0.0
29	4.0	338.9	353.5	210192.0	24.00	Down	24.0	Down	0.0
30	4.0	338.9	353.3	210127.4	24.00	Down	24.0	Down	0.0
31	4.0	334.7	349.6	204624.1	23.65	Down	23.7	Down	0.0
Average Total	4.3	290.7 9012.5	9407	170657.0 5290367.1	586.2	20.0	589	704 6337	91

Tracy Combined Cycle Power Plant
 Tracy, CA
Aux Boiler & Steam Turbine- Monthly Operations
 February - 2022

Day	Aux Boiler							Steam Turbine	
	O2%	Gas Flow kscf	Heat Input mmBtu	Recirc Flow lbs	Recirc Flow On-Time	Master Demand %	Boiler On-Time	Megawatt Hours	STG On-Time
01	4.0	344.8	359.5	210191.7	24.00	Down	24.0	Down	0.0
02	4.0	345.5	361.0	209005.7	24.00	Down	24.0	Down	0.0
03	4.0	237.4	247.7	148571.8	16.63	27.9	16.6	882	13.6
04	4.8	15.8	16.6	7929.2	1.03	18.0	1.3	1353	15.9
05	4.1	211.3	220.4	128426.1	14.67	Down	14.8	Down	0.0
06	4.0	349.9	365.5	214763.4	24.00	Down	24.0	Down	0.0
07	4.0	332.8	347.6	205179.1	24.00	Down	24.0	Down	0.0
08	4.0	320.7	334.7	200834.4	24.00	Down	24.0	Down	0.0
09	4.0	321.6	335.4	202560.1	24.00	Down	24.0	Down	0.0
10	4.0	334.7	349.5	209912.8	23.85	Down	23.9	Down	0.0
11	4.0	339.2	353.8	204041.3	23.83	Down	23.9	Down	0.0
12	4.0	335.9	350.8	202040.3	23.68	Down	23.7	Down	0.0
13	4.0	338.0	352.6	211901.0	24.00	Down	24.0	Down	0.0
14	4.0	341.1	355.9	213640.8	24.00	Down	24.0	Down	0.0
15	4.1	148.2	154.8	83628.6	9.98	23.1	10.5	381	6.1
16	4.0	345.5	360.6	209415.0	24.00	Down	24.0	Down	0.0
17	4.0	332.8	347.2	200049.5	24.00	Down	24.0	Down	0.0
18	4.0	339.7	355.0	206219.3	24.00	Down	24.0	Down	0.0
19	4.0	340.8	355.8	206679.2	24.00	Down	24.0	Down	0.0
20	4.0	351.1	366.6	211556.6	23.85	Down	23.9	Down	0.0
21	4.0	355.0	370.6	214212.3	24.00	Down	24.0	Down	0.0
22	4.0	356.2	371.4	212128.1	24.00	Down	24.0	Down	0.0
23	4.0	352.4	368.0	212103.0	24.00	35.0	24.0	30	2.1
24	4.0	239.8	250.4	148443.5	16.52	28.7	16.5	1323	17.0
25	4.4	22.1	23.1	10769.2	1.55	17.9	1.8	1542	16.7
26	4.0	171.7	179.2	104264.1	11.67	17.0	11.8	102	1.2
27	4.0	358.3	374.3	217834.1	24.00	Down	24.0	Down	0.0
28	4.0	352.3	367.8	218312.4	24.00	Down	24.0	Down	0.0
Average Total	4.1	294.1 8234.6	8596	179450.5 5024612.6	575.3	23.9	577	802 5613	73

Tracy Combined Cycle Power Plant
 Tracy, CA
Aux Boiler & Steam Turbine- Monthly Operations
 March - 2022

Day	Aux Boiler							Steam Turbine	
	O2%	Gas Flow kscf	Heat Input mmBtu	Recirc Flow lbs	Recirc Flow On-Time	Master Demand %	Boiler On-Time	Megawatt Hours	STG On-Time
01	4.0	364.0	378.2	216370.2	24.00	39.5	24.0	272	8.0
02	4.0	367.0	381.8	220769.8	24.00	Down	24.0	Down	0.0
03	4.0	373.7	388.1	221801.5	24.00	Down	24.0	Down	0.0
04	4.0	367.2	381.4	217134.9	24.00	Down	24.0	Down	0.0
05	4.0	371.5	385.8	219014.6	24.00	Down	24.0	Down	0.0
06	4.0	372.4	386.8	219917.1	24.00	Down	24.0	Down	0.0
07	4.0	370.4	384.6	220968.5	24.00	Down	24.0	Down	0.0
08	4.0	362.5	376.0	222275.5	23.87	Down	23.9	Down	0.0
09	4.0	360.0	373.6	218993.6	24.00	Down	24.0	Down	0.0
10	4.0	360.8	374.8	219687.7	24.00	Down	24.0	Down	0.0
11	4.0	357.9	372.1	219220.5	24.00	Down	24.0	Down	0.0
12	4.0	361.0	374.5	217746.6	24.00	Down	24.0	Down	0.0
13	4.0	364.6	379.0	204705.8	24.00	Down	24.0	Down	0.0
14	4.0	253.6	263.4	150257.0	16.87	29.8	16.9	753	12.6
15	4.0	244.2	253.5	148033.8	16.73	Down	16.8	Down	0.0
16	4.0	355.4	369.1	216271.1	24.00	Down	24.0	Down	0.0
17	4.0	355.5	369.6	216173.2	24.00	Down	24.0	Down	0.0
18	4.0	358.4	372.3	218811.1	24.00	Down	24.0	Down	0.0
19	4.0	344.3	357.6	204300.4	23.27	35.8	23.3	635	13.7
20	9.3	7.4	7.7	3577.8	0.51	17.4	0.9	1042	20.4
21	6.9	27.0	28.2	14067.2	1.77	17.5	2.5	680	10.4
22	9.3	16.7	17.4	8424.0	1.12	17.0	1.7	643	9.7
23	7.2	16.8	17.3	8648.2	1.12	17.0	1.7	704	9.8
24	5.1	171.5	178.1	108174.9	13.07	Down	13.6	Down	0.0
25	4.0	370.0	384.3	225916.2	24.00	36.4	24.0	60	2.7
26	4.0	231.7	240.7	141728.1	15.40	27.8	15.4	1022	15.6
27	4.9	208.4	216.7	120091.8	14.28	Down	14.7	Down	0.0
28	4.0	363.2	377.3	206331.9	24.00	Down	24.0	Down	0.0
29	4.0	365.2	379.3	211524.3	24.00	38.0	24.0	105	3.9
30	4.0	354.0	367.9	208820.1	24.00	Down	24.0	Down	0.0
31	4.0	319.0	331.4	186179.3	21.00	Down	21.0	Down	0.0
Average Total	4.6	294.0 9115.3	9469	175352.8 5435936.7	605.0	27.6	608	592 5916	107

Tracy Combined Cycle Power Plant
Tracy, CA
Aux Boiler Operating Time
2022

Limit- 4000 Hr

Month	Aux Boiler Operating Time (Hrs)
Jan	589
Feb	577
Mar	608
Apr	0
May	Inval
Jun	Inval
Jul	Inval
Aug	Inval
Sep	Inval
Oct	Inval
Nov	Inval
Dec	Inval
Year-To-Month Total	1774

ATTACHMENT 13
EMERGENCY FIRE PUMP RUN LOG

Tracy Diesel Fire pump Run Log - 2022

Meter Begin 43.5 Meter End 45.3

Date	Test/Maint Run Time (min)	Emergency Run Time (min)	Total run time Control panel (Hrs: Min)	Total Engine Run Time (HRs)	Total Engine Starts	Comments
1/4/2021	2	0	45:17	43.5	534	Weekly Test
1/11/2022	2	0	45:18	43.5	535	Weekly Test
1/18/2022	5	0	45:23	43.6	536	Weekly Test
1/25/2022	27	0	45:50	44.0	537	Monthly Test
2/1/2022	5	0	45:55	44.1	538	Weekly Test
2/8/2022	31	0	46:26	44.6	539	Jorgensen Quarterly
2/15/2022	2	0	46:28	44.6	540	Weekly Test
2/23/2022	2	0	46:30	44.6	541	Weekly Test
3/1/2022	2	0	46:32	44.7	542	Weekly Test
3/8/2022	5	0	46:37	44.8	543	Weekly Test
3/15/2022	5	0	46:39	44.8	544	Weekly Test
3/22/2022	5	0	46:44	44.9	545	Weekly Test
3/29/2022	30	0	47:11	45.3	546	Monthly Test
Total Time	121	0	121		11	

Total Hours **0.00** **0.00** **0.00**
 Test/Maint Run Time Emergency Run Time Total Run Time

Run Times Per Reason:	Time (Min)	No. of Starts	Time (Hours)
Weekly Reliability Test Run	0	0	0.00
Emergency Run	0	0	0

**ATTACHMENT 14
AUX BOILER COMPLIANCE**

April 2, 2020

Mr. Claude Couvillion
Mrp San Joaquin Energy, LLC
14950 W. Schulte Rd
Tracy, CA 95377

RE: DETERMINATION OF COMPLIANCE EMISSION TESTING

Dear Mr. Couvillion,

District staff have received the test report submitted for the permitted equipment listed below for compliance determination with permitted emission limits. Review of the test result(s) reveal the equipment appears to be **operating in full compliance** with permitted emission limits.

If the permitted equipment has annual source testing requirements, then the next required test must be conducted within thirty days (+/- 30) of the next test date as shown below. If an ATC has been issued for modifications to the permitted equipment then the testing requirements must follow the ATC.

Permit Number	Unit ID	Test Date	Next Test Date
N-4597-5-1	Boiler	1/31/2020	1/18/2023

If the equipment is under dormant status, you must contact the District before restarting unit. If you have any questions please call this office at (209) 557-6400.

Sincerely,



Lisa D Middleton
Supervising Air Quality Inspector

ATTACHMENT 15
DUST SUPPRESSION CONTROL MEASURES

Construction of a temporary laydown yard was performed from 3/1 – 3/3. Additional dust suppression measures included speed limit signs, water trucks, and gravel. No construction related complaints were received. The laydown yard was less than 1 acre in size and did not require any SWPPP or SJVAPCD permits. The removal of the laydown yard will occur in Q2 2022.