DOCKETED	
Docket Number:	01-AFC-25C
Project Title:	Malburg Generating Station-Compliance
TN #:	244258
Document Title:	Malburg Generating Station Quarterly Compliance Report Q2 2022
Description:	N/A
Filer:	Elyse Engel
Organization:	Jacobs Engineering Group Inc.
Submitter Role:	Applicant
Submission Date:	7/29/2022 3:20:24 PM
Docketed Date:	7/29/2022



4305 Santa Fe Avenue, Vernon, California 90058 Telephone (323) 583-8811

July 29, 2022

Dr. Anwar Ali Compliance Project Manager Siting, Transmission and Environmental Protection Division Compliance Monitoring and Enforcement Office California Energy Commission 715 P Street Sacramento, CA 95814 anwar.ali@energy.ca.gov

Subject: 2022 Q2 Compliance Report April 1, 2022 through June 30, 2022 Malburg Generating Station (01-AFC-25C)

Dr. Ali,

Attached please find the Quarterly Compliance Report for the Malburg Generating Station (01-AFC-25C), covering the operational period of April 1, 2022 through June 30, 2022. This report addresses all quarterly requirements identified in the Final Commission Decision for the Malburg Generating Station (TN #28746), as most recently amended on June 20, 2019 by the Errata to Staff Analysis of Petition to Amend the Final Commission Decision (TN #228444).

If you have any questions or need more information, please contact Matt Richards, Utilities Operations Manager, at <u>MRichards@cityofvernon.org</u> or (323) 583-8811 x378.

Sincerety, **Rich Olsen**

Assistant General Manager of Generation & Operations City of Vernon, Public Utilities Department

Enclosure: MGS 2022 Q2 Compliance Report

Exclusively Industrial

Malburg Generating Station Quarterly Compliance Report (Second Quarter 2022)

Submitted to California Energy Commission

Submitted by City of Vernon, Public Utilities Department

July 29, 2022

Document no: PPS0429221225SJC Revision no: 0



Contents

Acror	nyms a	nd Abbreviationsv
1.	Introd	luction1
	1.1	Project Location and Description1
	1.2	Organization of the Quarterly Compliance Report1
2.	Requi	red Quarterly Compliance Report Documentation1

Appendices

- MGS Emission Calculations А
- Cooling Tower Blowdown Reports Operation Logs В
- C
- Diesel Fuel Oil Purchase Records D
- Excess Emission Reports Е
- F Exceedance Reports

Table

2-1	Required Quarterly Compliance Report Documentation	1
-----	--	---

Acronyms and Abbreviations

CEC	California Energy Commission
CEMS	continuous emissions monitoring system
СО	carbon monoxide
СОС	Conditions of Certification
CTG	combustion turbine generator
DAHS	data acquisition and handling system
gr/scf	grains per standard cubic foot
HRSG	heat recovery steam generator
lb/day	pounds per day
lb/hr	pounds per hour
MGS	Malburg Generating Station
NH ₃	ammonia
NOx	nitrogen oxides
PM10	particulate matter with an aerodynamic diameter less than or equal to 10 microns
PM _{2.5}	particulate matter with an aerodynamic diameter less than or equal to 2.5 microns
ppm	parts per million
ppmv	parts per million by volume
ppmw	parts per million by weight
QCR	Quarterly Compliance Report
SCAQMD	South Coast Air Quality Management District
SOx	sulfur oxides
STG	steam turbine generator
TDS	total dissolved solids
VOC	volatile organic compound

1. Introduction

This Quarterly Compliance Report (QCR) has been prepared to meet the California Energy Commission's (CEC) quarterly reporting requirements for the Malburg Generating Station (MGS). This QCR fulfills various Conditions of Certification (COC) described in the CEC's Final Commission Decision for the MGS (TN #28746), as most recently amended on June 20, 2019 by the Errata to Staff Analysis of Petition to Amend the Final Commission Decision (TN #228444).

1.1 Project Location and Description

The MGS is located at 4963 S Soto Street in Vernon, California. The property is approximately 3.4 acres in size, located in an industrial land use area near the geographic center of metropolitan Los Angeles County. MGS consists of two Siemens SGT-800 frame type natural gas combustion turbine generators (CTGs), two associated natural gas combustion duct burners, two heat recovery steam generators (HRSGs), a steam turbine generator (STG), a cooling tower, a diesel-fired emergency firewater pump, and support equipment.

The commissioning of MGS was completed in October 2005 and the power plant began commercial operation on October 17, 2005.

1.2 Organization of the Quarterly Compliance Report

A summary of the compliance demonstration for each applicable COC is provided in Section 2 and includes references to Appendices and Tables as appropriate.

2. Required Quarterly Compliance Report Documentation

COC requirements associated with this QCR are summarized in the table below.

Condition of Certification	Response
AQ-C6	The weekly total dissolved solids (TDS) results for the second quarter of 2022 are provided in Appendix A, Table 2; the weekly sample reports collected for the same period are provided in Appendix B. Note that TDS was not sampled during the month of May because MGS experienced an outage during this time.
AQ-C7	Daily particulate matter with aerodynamic diameter less than or equal to 10 microns (PM_{10}) emissions from cooling tower operation during the second quarter of 2022 are provided in Appendix A, Tables 3 through 5. As shown, emissions were below the specified limit of 6.2 pounds per day (lb/day). Note that the cooling tower blowdown was not sampled during the month of May because MGS experienced an outage during this time.
AQ-C8	Testing times for the diesel-fired emergency firewater pump during the second quarter of 2022 are provided in Appendix C, Table 2. MGS refrained from testing the diesel-fired emergency firewater pump in the same hour the CTGs were either started or shutdown.
AQ-C9	The CTG startup and shutdown details for the second quarter of 2022, including the duration and date of occurrence, are provided in Appendix C, Table 1.
AQ-C11	All ammonia (NH ₃), nitrogen oxides (NOx), sulfur oxides (SOx), carbon monoxide (CO), PM_{10} , and volatile organic compound (VOC) emissions from MGS operation during the second quarter of 2022 are provided in Appendix A, Table 1.
AQ-2	Low sulfur diesel fuel was last purchased on April 11, 2022. The fuel purchase record is provided in Appendix D and demonstrates that the fuel does not contain sulfur compounds in excess of 15 parts per million by weight (ppmw).

Table 2-1. Required	l Quarterly	Compliance	Report	Documentation
---------------------	-------------	------------	--------	---------------

Condition of	Response
Certification	
AQ-3	See the response for COC AQ-2.
AQ-5	Monthly emissions of CO, PM_{10} , particulate matter with an aerodynamic diameter less than or equal to 2.5 microns ($PM_{2.5}$), VOC, and SOx from CTG and duct burner operation during the second quarter of 2022 are presented in Appendix A, Tables 7 through 9. Fuel usage for each turbine-duct burner pair is provided in Appendix A, Table 6. As shown, emissions were below the monthly limits specified in Condition A63.4 of the site's Title V Permit.
AQ-6	See the response for COC AQ-C9.
AQ-9	See the response for COC AQ-C11. Additionally, quarterly NOx excess emission reports from the data acquisition and handling system (DAHS) are provided in Appendix E. As demonstrated in these reports, there were no incidents in which the maximum corrected NOx emissions concentration for both CTGs exceeded the emission concentration limit of 2.0 parts per million by volume (ppmv). All continuous emissions monitoring system (CEMS) data for MGS' CTGs are stored electronically onsite.
AQ-10	See the response for COC AQ-C11. Additionally, quarterly CO excess emission reports from the DAHS are provided in Appendix E. As demonstrated in these reports, there were no incidents in which the maximum corrected CO emissions concentration for both CTGs exceeded the emission concentration limit of 2.0 ppmv. All CEMS data for MGS' CTGs are stored electronically onsite.
AQ-11	See the response for COC AQ-C11. Additionally, quarterly VOC excess emission reports from the DAHS are provided in Appendix E. As demonstrated in these reports, there were no incidents in which the maximum corrected VOC emissions concentration for both CTGs exceeded the emission concentration limit of 2.0 ppmv. All CEMS data for MGS' CTGs are stored electronically onsite.
AQ-12	See the response for COC AQ-C11. Additionally, compliance with the specified limit of 5 parts per million (ppm) is primarily demonstrated through annual source testing. The most recent NH ₃ compliance source test, performed on February 8 and 9, 2022 with results submitted to the CEC on March 24, 2022, indicated compliance with the emission limits for both CTGs (1.7 ppm for CTG 1 and 1.6 ppm for CTG 2). NH ₃ emissions are also calculated via the CEMS on an hourly basis and confirmed to comply with the NH ₃ concentration limit of 5 ppm. Note that MGS did experience an exceedance of this 5 ppm limit both on March 18, 2022 and May 26, 2022. Although the first event occurred during the first quarter of 2022, MGS submitted a Form 500-N for the deviation event to South Coast Air Quality Management District (SCAQMD) on May 2, 2022. MGS submitted a Form 500-N for the second deviation event to SCAQMD on June 9, 2022, following verbal notification on May 27, 2022. The submitted Form 500-N's are included in Appendix F.
AQ-13	See the response for COC AQ-C11. Additionally, the most recent triennial compliance source test, performed in August 2019, indicated compliance with the Rule 475 particulate matter emission limits of 5 kilograms per hour (11 pounds per hour [lb/hr]) or 23 milligrams per cubic meter (0.01 grain per standard cubic foot [gr/scf]) for both CTGs (0.69 lb/hr and 0.0003 gr/scf for CTG1 and 1.15 lb/hr and 0.0005 gr/scf for CTG2).
AQ-14	See the response for COC AQ-2.
AQ-15	Quarterly hours of operation for the diesel-fired emergency firewater pump are provided in Appendix A, Table 10. As shown, the second quarter 2022 hours for maintenance and testing do not exceed 50 hours and the total operational hours do not exceed 200 hours.
AQ-27	See the response for COC AQ-5. As shown, fuel consumption per turbine-duct burner pair does not exceed the specified limit of 405 million cubic feet per month.
AQ-36	See the responses for COC AQ-5 and AQ-6.

Malburg Generating Station Quarterly Compliance Report (Second Quarter 2022)

Appendix A MGS Emission Calculations

Reporting Period: Quarter 2 2022

Table 1. Quarterly Emissions - April 1, 2022 through June 30, 2022

Sourco	Quarterly Emissions (lb/quarter)						
Jource	NOx	CO	VOC	SOx	PM ₁₀ /PM _{2.5}	NH ₃	
CTG 1 & Duct Burner	2,414	1,091	476	85	1,859	2,839	
CTG 2 & Duct Burner	2,048	879	387	69	1,512	2,315	
Cooling Tower					88		
Diesel Firewater Pump	24.7	0.72	0.18	0.01	0.16		
Total	4,486	1,971	864	155	3,460	5,154	

Reporting Period: Quarter 2 2022

Table 2 Cooling	Tower Total	Dissolved So	lids (TDS)	Samnling	Results	1, 2
Tuble 2. cooling	Tower rotat	D133000Cu 20		Sampang	nesuus	

Sampling Period		
Start Date	End Date	
3/27/2022	4/2/2022	4,140
4/3/2022	4/9/2022	5,750
4/10/2022	4/16/2022	4,110
4/17/2022	4/23/2022	4,120
4/24/2022	4/30/2022	4,220
5/1/2022	5/7/2022	
5/8/2022	5/14/2022	
5/15/2022	5/21/2022	
5/22/2022	5/28/2022	
5/29/2022	6/4/2022	1,970
6/5/2022	6/11/2022	4,410
6/12/2022	6/18/2022	4,830
6/19/2022	6/25/2022	3,940
6/26/2022	7/2/2022	4,020

¹ Sampling results taken from Positive Lab's Weekly Cooling Tower Blowdown Reports, as provided in Appendix B of the QCR.

² MGS experienced an outage for the majority of May 2022; therefore, Cooling Tower Blowdown Reports were not prepared during that time.

Reporting Period: April 2022

Cooling Tower Total Dissolved Solids (TDS) Sampling Results

Data Source: Positive Lab's Weekly Cooling Tower Blowdown Reports, as provided in Appendix B of the QCR

Sample Date	Period Start Date	End Date	TDS (ppm)
3/28/2022	3/27/2022	4/2/2022	4,140
4/5/2022	4/3/2022	4/9/2022	5,750
4/11/2022	4/10/2022	4/16/2022	4,110
4/19/2022	4/17/2022	4/23/2022	4,120
4/25/2022	4/24/2022	4/30/2022	4,220

Methodology (per Condition of Certification [COC] AQ-C7)

0.0005

PM₁₀ Emissions (lb/day) = Circulation Rate (gal/day) x Density of Water (lb/gal) x Total Dissolved Solids (ppm) / 1,000,000 x Drift Factor (%) / 100 x Correction Factor

Constants		
Parameter	Value	
Circulation Rate per		12 500
Pump (gal/min) ¹		15,500
Number of Pumps		2
Total Circulation Rate		27.000
(gal/min)		27,000
Water Density		0 22/
		0.334

 (unitless)³
 0.2

 ¹ Source: M3-10 Main Circulating Water System

P&ID.

(lb/gal)

² Per COC AQ-C4.

Drift Factor (%)²

Correction Factor

³ Source: SPX Cooling Technologies' Cooling

Tower Drift Mass Distribution.

	Circulation Rate		PM ₁₀ Emissions	Above 6.2 lb/day PM ₁₀ Limit?
Date	(gal/day) ¹	TDS (ppm)	(lb/day)	2
4/1/2022	38,880,000	4,140	1.34	No
4/2/2022	38,880,000	4,140	1.34	No
4/3/2022	38,880,000	5,750	1.86	No
4/4/2022	38,880,000	5,750	1.86	No
4/5/2022	38,880,000	5,750	1.86	No
4/6/2022	38,880,000	5,750	1.86	No
4/7/2022	38,880,000	5,750	1.86	No
4/8/2022	38,880,000	5,750	1.86	No
4/9/2022	38,880,000	5,750	1.86	No
4/10/2022	38,880,000	4,110	1.33	No
4/11/2022	38,880,000	4,110	1.33	No
4/12/2022	38,880,000	4,110	1.33	No
4/13/2022	38,880,000	4,110	1.33	No
4/14/2022	38,880,000	4,110	1.33	No
4/15/2022	38,880,000	4,110	1.33	No
4/16/2022	38,880,000	4,110	1.33	No
4/17/2022	38,880,000	4,120	1.33	No
4/18/2022	38,880,000	4,120	1.33	No
4/19/2022	38,880,000	4,120	1.33	No
4/20/2022	38,880,000	4,120	1.33	No
4/21/2022	38,880,000	4,120	1.33	No
4/22/2022	38,880,000	4,120	1.33	No
4/23/2022	38,880,000	4,120	1.33	No
4/24/2022	38,880,000	4,220	1.37	No
4/25/2022	38,880,000	4,220	1.37	No
4/26/2022	38,880,000	4,220	1.37	No
4/27/2022	38,880,000	4,220	1.37	No
4/28/2022	38,880,000	4,220	1.37	No
4/29/2022	38,880,000	4,220	1.37	No
4/30/2022	38,880,000	4,220	1.37	No

Cooling Tower Daily PM₁₀ Emissions

¹ Maximum daily circulation rate conservatively used to estimate PM ₁₀ emissions when the cooling tower is operated for any part of the day. Circulation rate is zero for days the cooling tower is not operated at all.

² Daily emissions limit established in COC AQ-C7.

Reporting Period: May 2022

Cooling Tower Total Dissolved Solids (TDS) Sampling Results

Data Source: Positive Lab's Weekly Cooling Tower Blowdown Reports, as provided in Appendix B of the QCR

Sample Date ¹	Period Start Date	End Date	TDS (ppm)
	5/1/2022	5/7/2022	
	5/8/2022	5/14/2022	
	5/15/2022	5/21/2022	
	5/22/2022	5/28/2022	
6/2/2022	5/29/2022	6/4/2022	1,970

¹ MGS experienced an outage for the majority of May 2022; therefore, Cooling Tower Blowdown Reports were not prepared during that time.

Methodology (per Condition of Certification [COC] AQ-C7)

PM₁₀ Emissions (lb/day) = Circulation Rate (gal/day) x Density of Water (lb/gal) x Total Dissolved Solids (ppm) / 1,000,000 x Drift Factor (%) / 100 x Correction Factor

Constants			
Parameter	Value		
Circulation Rate per Pump	12 500		
(gal/min) ¹	13,500		
Number of Pumps	2		
Total Circulation Rate	27.000		
(gal/min)	27,000		
Water Density (lb/gal)	8.334		
Drift Factor (%) ²	0.0005		
Correction Factor	0.2		
(unitless) ³	0.2		

¹ Source: M3-10 Main Circulating Water System P&ID.

² Per COC AQ-C4.

³ Source: SPX Cooling Technologies' Cooling Tower Drift Mass Distribution.

Cooling Tower Daily PM₁₀ Emissions

Dete	Circulation Rate		PM ₁₀ Emissions	Above 6.2 lb/day PM ₁₀
Date	(gal/day) ¹	TDS (ppm) [–]	(lb/day)	Limit? ³
5/1/2022	0		0.00	No
5/2/2022	0		0.00	No
5/3/2022	0		0.00	No
5/4/2022	0		0.00	No
5/5/2022	0		0.00	No
5/6/2022	0		0.00	No
5/7/2022	0		0.00	No
5/8/2022	0		0.00	No
5/9/2022	0		0.00	No
5/10/2022	0		0.00	No
5/11/2022	0		0.00	No
5/12/2022	0		0.00	No
5/13/2022	0		0.00	No
5/14/2022	0		0.00	No
5/15/2022	0		0.00	No
5/16/2022	0		0.00	No
5/17/2022	0		0.00	No
5/18/2022	0		0.00	No
5/19/2022	0		0.00	No
5/20/2022	0		0.00	No
5/21/2022	0		0.00	No
5/22/2022	0		0.00	No
5/23/2022	38,880,000	1,970	0.64	No
5/24/2022	38,880,000	1,970	0.64	No
5/25/2022	0		0.00	No
5/26/2022	38,880,000	1,970	0.64	No
5/27/2022	38,880,000	1,970	0.64	No
5/28/2022	38,880,000	1,970	0.64	No
5/29/2022	38,880,000	1,970	0.64	No
5/30/2022	38,880,000	1,970	0.64	No
5/31/2022	38,880,000	1,970	0.64	No

¹ Maximum daily circulation rate conservatively used to estimate PM₁₀ emissions when the cooling tower is operated for any part of the day. Circulation rate is zero for days the cooling tower is not operated at all.

² MGS experienced an outage for the majority of May 2022; therefore, Cooling Tower Blowdown Reports were not prepared during that time. For days that the station operated in May, sample results were assumed to be best represented by the results sampled on June 2, 2022.

³ Daily emissions limit established in COC AQ-C7.

Reporting Period: June 2022

Cooling Tower Total Dissolved Solids (TDS) Sampling Results

Data Source: Positive Lab's Weekly Cooling Tower Blowdown Reports, as provided in Appendix B of the QCR

Sample Date	Period Start Date	End Date	TDS (ppm)
6/2/2022	5/29/2022	6/4/2022	1,970
6/7/2022	6/5/2022	6/11/2022	4,410
6/14/2022	6/12/2022	6/18/2022	4,830
6/21/2022	6/19/2022	6/25/2022	3,940
6/28/2022	6/26/2022	7/2/2022	4,020

Methodology (per Condition of Certification [COC] AQ-C7)

PM₁₀ Emissions (lb/day) = Circulation Rate (gal/day) x Density of Water (lb/gal) x Total Dissolved Solids (ppm) / 1,000,000 x Drift Factor (%) / 100 x Correction Factor

Constants

Parameter	Value		
Circulation Rate per Pump	12 500		
(gal/min) ¹	15,500		
Number of Pumps	2		
Total Circulation Rate	27.000		
(gal/min)	27,000		
Water Density (lb/gal)	8.334		
Drift Factor (%) ²	0.0005		
Correction Factor	0.2		
(unitless) ³	0.2		

¹ Source: M3-10 Main Circulating Water System P&ID.

² Per COC AQ-C4.

³ Source: SPX Cooling Technologies' Cooling Tower Drift Mass Distribution.

Cooling Tower Daily PM₁₀ Emissions

Dete	Circulation Rate		PM ₁₀ Emissions	Above 6.2 lb/day PM ₁₀
Date	(gal/day) ¹	TDS (ppm)	(lb/day)	Limit? ²
6/1/2022	38,880,000	1,970	0.64	No
6/2/2022	38,880,000	1,970	0.64	No
6/3/2022	38,880,000	1,970	0.64	No
6/4/2022	38,880,000	1,970	0.64	No
6/5/2022	38,880,000	4,410	1.43	No
6/6/2022	38,880,000	4,410	1.43	No
6/7/2022	38,880,000	4,410	1.43	No
6/8/2022	38,880,000	4,410	1.43	No
6/9/2022	38,880,000	4,410	1.43	No
6/10/2022	38,880,000	4,410	1.43	No
6/11/2022	38,880,000	4,410	1.43	No
6/12/2022	38,880,000	4,830	1.57	No
6/13/2022	38,880,000	4,830	1.57	No
6/14/2022	38,880,000	4,830	1.57	No
6/15/2022	38,880,000	4,830	1.57	No
6/16/2022	38,880,000	4,830	1.57	No
6/17/2022	38,880,000	4,830	1.57	No
6/18/2022	38,880,000	4,830	1.57	No
6/19/2022	38,880,000	3,940	1.28	No
6/20/2022	38,880,000	3,940	1.28	No
6/21/2022	38,880,000	3,940	1.28	No
6/22/2022	38,880,000	3,940	1.28	No
6/23/2022	38,880,000	3,940	1.28	No
6/24/2022	38,880,000	3,940	1.28	No
6/25/2022	38,880,000	3,940	1.28	No
6/26/2022	38,880,000	4,020	1.30	No
6/27/2022	38,880,000	4,020	1.30	No
6/28/2022	38,880,000	4,020	1.30	No
6/29/2022	38,880,000	4,020	1.30	No
6/30/2022	38,880,000	4,020	1.30	No

¹ Maximum daily circulation rate conservatively used to estimate PM₁₀ emissions when the cooling tower is operated for any part of the day. Circulation rate is zero for days the cooling tower is not operated at all.

² Daily emissions limit established in COC AQ-C7.

Reporting Period: Quarter 2 2022

Table 6. Monthly Turbine-Duct Burner Fuel Flow

	April		May		June	
Source	Fuel Flow (MMscf/month) ¹	Above 405 MMscf/month Limit? ²	Fuel Flow (MMscf/month) ¹	Above 405 MMscf/month Limit? ²	Fuel Flow (MMscf/month) ¹	Above 405 MMscf/month Limit? ²
CTG 1	113		20		173	
CTG 1 Duct Burner	1.41		0.00		1.52	
Total CTG 1 & Duct Burner	115	No	20	No	175	No
CTG 2	140		10		98	
CTG 2 Duct Burner	1.35		0.00		1.62	
Total CTG 2 & Duct Burner	141	No	10	No	100	No

¹ Fuel flow data obtained from 'U1/U2_MonthlySummary_MassEmissionsAndFuel' and 'All_12MonthSummary_GasUsage' RegPerfect Reports.

² Monthly fuel flow limit is per Condition of Certification (COC) AQ-27.

Table 7. Monthly Emissions - April 2022

Source	Monthly Emissions (lb/month) ¹							
Source	NOx ²	СО	VOC	SOx	PM ₁₀ /PM _{2.5}	NH ₃ ³		
CTG 1 & Duct Burner	867	363	177	31.5	691	1,058		
CTG 2 & Duct Burner	1,033	338	218	38.6	850	1,298		
Monthly Emission Limits ⁴	N/A	7,633	3,236	227	4,876	N/A		
Exceeds Limit?	N/A	No	No	No	No	N/A		

¹ Unless otherwise noted, monthly emissions data obtained from 'U1/U2_MonthlySummary_MassEmissionsAndFuel' RegPerfect Report. ² Monthly NOx emissions are as submitted to SCAQMD, based on the 'U1_U2MonthlyRECLAIMNOxSummaryByDay' RegPerfect Report.

³ Monthly NH₃ emissions are calculated using monthly fuel usage and default emission factors from the SCAQMD's AER AB 2588 Quadrennial Air Toxics Emission Inventory Procedures - June 2020. The emission factors are 9.1 lbs/MMscf and 18.0 lbs/MMscf for the CTGs and Duct Burners, respectively. ⁴ Monthly emission limits are per COC AQ-5.

Table 8. Monthly Emissions - May 2022

Sourco	Monthly Emissions (lb/month) ¹						
Source	NOx ²	CO	VOC	SOx	PM ₁₀ /PM _{2.5}	NH ₃ ³	
CTG 1 & Duct Burner	320	316	30	5.4	118	178	
CTG 2 & Duct Burner	233	202	16	2.9	62	93	
Monthly Emission Limits ⁴	N/A	7,633	3,236	227	4,876	N/A	
Exceeds Limit?	N/A	No	No	No	No	N/A	

¹ Unless otherwise noted, monthly emissions data obtained from 'U1/U2_MonthlySummary_MassEmissionsAndFuel' RegPerfect Report. ² Monthly NOx emissions are as submitted to SCAQMD, based on the 'U1_U2MonthlyRECLAIMNOxSummaryByDay' RegPerfect Report.

³ Monthly NH₃ emissions are calculated using monthly fuel usage and default emission factors from the SCAQMD's AER AB 2588 Quadrennial Air Toxics Emission Inventory Procedures - June 2020. The emission factors are 9.1 lbs/MMscf and 18.0 lbs/MMscf for the CTGs and Duct Burners, respectively. ⁴ Monthly emission limits are per COC AQ-5.

Table 9. Monthly Emissions - June 2022

Source	Monthly Emissions (lb/month) ¹						
Jource	NOx ²	СО	VOC	SOx	PM ₁₀ /PM _{2.5}	NH ₃ ³	
CTG 1 & Duct Burner	1,227	412	269	48.6	1,051	1,604	
CTG 2 & Duct Burner	782	339	154	27.8	601	924	
Monthly Emission Limits ⁴	N/A	7,633	3,236	227	4,876	N/A	
Exceeds Limit?	N/A	No	No	No	No	N/A	

¹ Unless otherwise noted, monthly emissions data obtained from 'U1/U2_MonthlySummary_MassEmissionsAndFuel' RegPerfect Report. ² Monthly NOx emissions are as submitted to SCAQMD, based on the 'U1_U2MonthlyRECLAIMNOxSummaryByDay' RegPerfect Report.

³ Monthly NH₃ emissions are calculated using monthly fuel usage and default emission factors from the SCAQMD's AER AB 2588 Quadrennial Air Toxics Emission Inventory Procedures - June 2020. The emission factors are 9.1 lbs/MMscf and 18.0 lbs/MMscf for the CTGs and Duct Burners, respectively. ⁴ Monthly emission limits are per COC AQ-5.

Reporting Period: Quarter 2 2022

Methodology

Emissions (lb/month) = Fuel Usage (gal/month) / 1,000 (gal/Mgal) x Emission Factor (lb/Mgal)

Emission Factors

Pollutant	Emission Factor (lb/Mgal)	Reference
NOx	469	Emission factor provided in the facility's Title V Permit.
со	13.62	Emission factor converted from the factor provided in the facility's Title V Permit (0.4 g/bhp-hr), based on the unit's power rating (173 hp) and maximum fuel throughput (11.2 gal/hr).
VOC	3.41	Emission factor converted from the factor provided in the facility's Title V Permit (0.1 g/bhp-hr), based on the unit's power rating (173 hp) and maximum fuel throughput (11.2 gal/hr).
SOx	0.21	Default for Diesel/Distillate Oil, ICEs given in the SCAQMD's Combustion Default Emission Factors - January 2022.
PM ₁₀ /PM _{2.5}	3.065	Emission factor converted from the factor provided in the facility's Title V Permit (0.09 g/bhp-hr), based on the unit's power rating (173 hp) and maximum fuel throughput (11.2 gal/hr).

Table 10. Monthly Diesel Fire Pump Hours of Operation, Fuel Usage, and Emissions

Month	Monthly Hours o	f Operation ¹		Fuel Usage	Monthly En	nissions (l	b/month)		
Morren	Maintenance	Testing	Emergency	(gal/month) ²	NOx	СО	VOC	SOx	PM ₁₀ /PM _{2.5}
January	0.0	2.5	0.0	28.0	13.1	0.38	0.10	0.01	0.09
February	0.0	2.0	0.0	22.4	10.5	0.31	0.08	0.00	0.07
March	0.0	2.0	0.0	22.4	10.5	0.31	0.08	0.00	0.07
April	0.0	1.9	0.0	21.3	10.0	0.29	0.07	0.00	0.07
May	0.0	1.2	0.0	13.4	6.3	0.18	0.05	0.00	0.04
June	0.0	1.6	0.0	17.9	8.4	0.24	0.06	0.00	0.05
Q1 Total	0.0	6.5	0.0	72.8	34.1	0.99	0.25	0.02	0.22
Q2 Total	0.0	4.7	0.0	52.6	24.7	0.72	0.18	0.01	0.16
Annual Limit	for Maintenance and	l Testing ³	50						

Total Annual Limit 3200Exceeds Limits?No

¹ Monthly hours of operation calculated from Device 385/403 run timer readings.

² Fuel usage (gal/month) calculated by multiplying the hours of operation by the unit's maximum fuel throughput (11.2 gal/hour).

³ Annual limits for hours of operation are per Condition of Certification (COC) AQ-15.

Appendix B Cooling Tower Blowdown Reports



781 East Washington Blvd., Los Angeles, CA 90021 (213) 745-5312 FAX (213) 745-6372

April 04, 2022

Matt Richards City of Vernon 4963 Soto St. Vernon, CA 90058

Report No.: 2203249 Project Name: Malburg Generating Station

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on March 28, 2022.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

Project Manager



Certificate of Analysis

Page 2 of 2

City of Vernon 4963 Soto St. Vernon, CA 90058

Attn: Matt Richards

File #:74548 Report Date: 04/04/22 Submitted: 03/28/22 PLS Report No.: 2203249

Phone: (323) 476-3626 FAX:(323) 476-3640

Prepared: 03/31/22 Analyzed: 04/01/22

Project: Malburg Generating Station

Analyte	Results	Flag	D.F.	Units	PQL	Pre	p/Test Met	hod	Prepared	Analy	/zed	By	Batch
Total Dissolved Solids	4140		1	mg/L	5.0	-	SM	2540C	03/31/22	04/0	1/22	VC	BD20426
			Q	uality (Contro	ol Data	E						
						Spike	Source		%REC		RPD		
Analyte	Resi	ult	PQL		Jnits	Level	Result	%REC	Limits	RPD	Limit	Q	ualifier
Batch BD20426													
Blank	Prep	ared: 03	/31/22	Analyzed:	04/01/	22							
Total Dissolved Solids	NC)	5.0	n	ng/L								
LCS	Prec	ared: 03	/31/22	Analyzed	04/01/	22							

Total Dissolved Soli	lds	49.0	5.0	mg/L	50.00	98.0	80-120		
uplicate	Source: 2203249-01	Prepared: 03	/31/22 Ana	alyzed: 04/01/	22				
Total Dissolved Soli	lds	3950	5.0	mg/L		4140	4.	78	5

Notes and Definitions

Not Applicable NA

D

ND Analyte NOT DETECTED at or above the detection limit

NR Not Reported

MDL Method Detection Limit

PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Fick Owen Par la

Authorized Signature(s)

ah.i.				[213] 74	5-5312	FAX (213) 745-63	72	_				F	DA LE NO	TE: <u>)</u>			NO.: 203249
CLIENT	NAME:	CITY OF	VERNON	PROJE	CT N.	AME/NC).	MALBUI	RG GENEI	ATING ST	TATION	WEEKL	<u>v P</u>	.0.NO.				OBSERV. TEMP: 1000
ADDRES	S:	4963 SOT	O ST. VERNON CA 90058									AN	ALYS	ES RE	QUES	STED	1	THERMOID: 66 BY
PROJ <u>EC</u>	T MANA	GER	MATT RICHARDS	PHONE	NO:			FAX N	NO:									PRESERVED:
SAMPLI	R NAME	E:	JOHN BARIE	SIGNA	TURE	:	r		_									REMARKS:
ГАТ (Tu	rn-Aroun	d-Time):	0=Same Day; 1=24 Hour; 2=	48Hour;	(ETC.	.) N=Nor	mal		_									
CONTA	NER TY	PES: B=B	rass; E=Encore/Easy Draw; I	Persic	; G=G	lass; V=	VOA V	'ial; ()=Othe	er								
UST PRO	DJECT:	Y N	GLOBAL ID#:															
SAMPLE	DATE	TIME	SAMPLE DESCRIPTION		MA I	TRIX		ТАТ	CONT	AINER								SAMPLE CONDITIONS/
TD	SAMPLED	SAMPLED		WATER	SOIL	SLUDGE	OTHER		#	TYPE	TDS						ļ	CONTAINER/COMMENTS
	32222	0735	COOLING TOWER BLOWDOWN	x				N	1	Р	X							
						_												
Relinquis	hed by (Si	ignature&	Name):	Receive	d by (S IS N	Signature	& Name	e):	·		Date: مرر-ک	R2	т 5 л	ime:	_	SAM	IPLE	DISPOSITION
Relinquis	MA John Bre linquished by (Signature & Name): Received by (Signature & Name):										Date:		T	ime:		2. San	nples v additi	vill not be stored over 30 days, onal storage time is requested
Relinquis	hed by (S	ignature&	Name):	Receive	d by (S	Signature	& Name	e):			Date:		Т	ime:		3. Stor By:	age tit	me requested:days,

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER



781 East Washington Blvd., Los Angeles, CA 90021 (213) 745-5312 FAX (213) 745-6372

April 11, 2022

Matt Richards City of Vernon 4963 Soto St. Vernon, CA 90058

Report No.: 2204046 Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on April 05, 2022.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

Project Manage



781 East Washington Blvd., Los Angeles, CA 90021 [213] 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

Report Date: 04/11/22

PLS Report No.: 2204046

Submitted: 04/05/22

File #:74548

City of Vernon 4963 Soto St. Vernon, CA 90058

Attn: Matt Richards

FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower	Blowdown Wa	ter (220	4046-0	1) Sam	pled: 04	4/05/22	08:50 Received	: 04/05/22			
Analyte	Results	Flag	D,F,	Units	PQL	Prep	/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	5750		1	mg/L	5.0	-	SM 2540C	04/07/22	04/08/22	VC	BD20806
			Q	uality (Contro	ol Data					

					Calles	Courses				nen	
Analyte		Result	P∩I	l Inite	spike	Result	%RFC	- WREC	RPD) imit	Qualifier
		, neadle	• ~~	- Anno				Contraction of the second s	- IN P		
Batch BD2080	6							-9.9			
Blank		Prepared: 0	04/07/22 Ana	alyzed: 04/08	3/22						
Total Dissolve	d Solids	ND	5.0	mg/L							
LCS		Prepared: 0	04/07/22 Ana	alyzed: 04/08	3/22	dente a concernant					
Total Dissolve	d Solids	47.0	5.0	mg/L	50.00		94.0	80-120			
Duplicate	Source: 2204064-01	Prepared: 0	04/07/22 Ana	alyzed: 04/08	3/22						
Total Dissolve	d Solids	675	5.0	mg/L		670			0.743	5	
Duplicate	Source: 2204046-01	Prepared: 0	04/07/22 Ana	alyzed: 04/08	/22						
Total Dissolver	d Salids	5830	5.0	ma/l		5750			1 44	5	

Notes and Definitions

NA Not Applicable

ND Analyte NOT DETECTED at or above the detection limit

NR Not Reported

MDL Method Detection Limit

PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Phone: (323) 476-3626

Fick Owen U.

Authorized Signature(s)

		-	<u></u>			GTOD	X7 A B			VCT	C DI		T O'	P				
	<u>P</u>	OS		AIIN Of Ishington B	IVd., La	S I OD Is Angeles	9 X A.F 5, CA 90(ND A 121	INAL	- 1 9 1	3 KI	νųυ	F 21	l r	ነልፐፑ፥ '	457.	21	PAGE: (OF/
		AB SI	ERVICE	(213) 74	5-5312	FAX (213	3) 745-63	72					F	L FILE N	10.:		LAE	3 NO. 2204044
CLIENT	NAME:	CITY OF	F VERNON	PROJE	CT N	AME/NO).	MALBU	RG GENER	RATING S	TATION	WEEKLY	e I	P.O.N	0.			
ADDRES	SS:	4963 SOT	FO ST. VERNON CA 90058									AN	ALYS	SES R	EQUE	STED		SERV. TEMP: <u>1.1</u> °C RREC. TEMP:2.4 °C
PROJEC	CT MANA	GER	MATT RICHARDS	PHONE	NO:			FAX N	NO:								Тн	ERMOIR: 66 BY
SAMPL	ER NAMI	2:	JOHN BARIE	SIGNA	TURE	: 												REMARKS:
TAT (Tu	irn-Aroun	d-Time):	0=Same Day; 1=24 Hour; 2	=48Hour;	(ETC	.) N=Nor	mal											
CONTA	INER TY	PES: B=B	crass; E=Encore/Easy Draw;	P=Plastic	G=G	ilass; V=	-VOA V	/ial; ()=Othe	er								
UST PR	PROJECT: Y N GLOBAL ID#:																	
SAMPLE	DATE	TIME	SAMPLE DESCRIPTION		MA	ATRIX	AINER								SAMPLE CONDITIONS/			
IJD.	SAMPLED	SAMPLED		WATER	WATER SOIL SLUDGE OTHER # TY X N 1 N												_	CONTAINER/COMMENTS
	45021	0850	COOLING TOWER BLOWDOWN	X N 1 P							X						_	
							ļ										_	
							<u> </u>										_	
								<u> </u>									_	
								<u> </u>		┇								
														L.				
Relinqui	shed by (S	ignature&	Name):	Receive	d by (S	Signature	& Nam	e):		1	Date:		-	Time:		SA	MPLE	DISPOSITION
/ [*]	14		J.	-Jor	-9 BZ	1rd				~	. 2.5					1. S	amples 1	returned to client? Yes No
Relinqui	shed by (S	ignature&	Name):	Receive	d by (S	Signature	& Nam	e):			Date:		-	Time:		2. 5	amples v	will not be stored over 30 days,
											,,					unl	ess addit	ional storage time is requested
Relinqui	shed by (S	ignature&	Name):	Receive	d by (Signature	& Nam	e):			Date			Time:		3. 5	storage ti	me requested:days,
																By:		Date:
SPECIA	L INSTR	UCTION	: Arrived at the tab $\hat{b}(-)$ -	fin														
		4 10100	Allived at the kap -1512		N	10 1014	DUPP											
PRESE	KVAIIVE	1-HNU3	2-H2SU4 3-HCL 4- ZINC AC	EIAIE 5	-inaOl	1 ט-NH4	ROFFE	=K /-	UTHE	ĸ								

vite #SSEnder



781 East Washington Blvd., Los Angeles, CA 90021 (213) 745-5312 FAX (213) 745-6372

April 15, 2022

Matt Richards City of Vernon 4963 Soto St. Vernon, CA 90058

Report No.: 2204116 Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on April 11, 2022.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

Project Manager



Certificate of Analysis

Page 2 of 2

City of Vernon 4963 Soto St. Vernon, CA 90058

Attn: Matt Richards

File #:74548 Report Date: 04/15/22 Submitted: 04/11/22 **PLS Report No.: 2204116**

Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: C	ooling Tower Blowdov	vn Wat	ter (220)4116-0)1) San	npled: 0	4/11/22	09:35 R	eceived:	04/11/22				
Analyte	R	esults	Flag	D.F.	Units	PQL	Prep	p/Test Met	hod	Prepared	Analy	yzed	Ву	Batch
Total Dissolv	ed Solids	4110		1	mg/L	5.0	-	SM	2540C	04/13/22	04/1	4/22	VC	BD21419
				Q	uality	Contro	ol Data	ł						
							Spike	Source		%REC		RPD		
Analyte		Resi	ılt	PQL		Units	Level	Result	%REC	Limits	RPD	Limit	Q	ualifier
Batch BD21419	Jatch BD21419													
Blank		Prep	ared: 04	/13/22	Analyzed	; 04/14/	22							
Total Dissolved	Solids	ND	1	5.0	-	ng/L								
LCS		Prep	ared: 04	/13/22	Analyzed	: 04/14/	22							
Total Dissolved	Solids	50.0	0	5.0	1	mg/L	50.00		100	80-120				
Duplicate	Source: 2204086-01	Prep	ared: 04	/13/22	Analyzed	: 04/14/	22							
Total Dissolved	Solids	508	0	5.0	I	mg/L		5060			0.474	5		

Notes and Definitions

 NA
 Not Applicable

 ND
 Analyte NOT DETECTED at or above the detection limit

NR Not Reported

MDL Method Detection Limit

PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Pick Owen Partic

Authorized Signature(s)

				IN OF	CU	STOD	YAN	ND A	NAI	JYSI	S RI	EQU	EST	۲				
			781 East Was	hington B (213) 74	lvd., Lo 5-5312	s Angeles FAX (213	;, CA 900 1) 745-63	121 172				-		D.	ате: <u>-/</u>	1112	- P	
DEGELS P				(,									F	ILE N	0.:		LAB	NO.: WEFILL
CLIENT	NAME:	CITY OF	VERNON	PROJE	CT N.	AME/NC)	MALBU	RG GENEI	RATING S	TATION	WEEKLY	r P	. <u>O.NC</u>).		_OB	SERV. TEMP: 1.4.20 °C
ADDRES	SS:	4963 SOT	FO ST. VERNON CA 90058									AN	ALYS	ES RI	QUES	TED		ERMOID: 64 BY: $\overline{4}$
PROJEC	T MANA	GER	MATT RICHARDS	PHONE	NO:			FAX	NO:									PRESERVED:
SAMPLI	ER NAMI	E:	JOHN BARIE	SIGNA	TURE	: ~F												REMARKS:
TAT (Tu	rn-Aroun	nd-Time):	0=Same Day; 1=24 Hour; 2=	48Hour;	(ETC.) N=Nor	mal											
CONTA	INER TY	PES: B=B	Brass; E=Encore/Easy Draw; P	=Plastic;	G=G	lass; V=	VOA V	vial; ()=Oth	er								
UST PR	OJECT:	Y N	GLOBAL ID#:															
SAMPLE	DATE	TIME	SAMPLE DESCRIPTION		MA	TRIX		TAT	CONT	AINER								SAMPLE CONDITIONS/
ID	SAMPLED	SAMPLED		WATER	SOIL	SLUDGE	OTHER		#	TYPE	TDS					_		CONTAINER/COMMENTS
	4.11.22	2932	COOLING TOWER BLOWDOWN	x				N	1	Р	x							
Relinquis	ihed by (S MA	ignature&	Name):	Receive	d by (S Tich	Signature 1Batu	& Nam	e):		C	Date:	22	ן 2	Time:		SAN	IPLE	DISPOSITION eturned to client? Yes No
Relinquis	shed by (S	ignature&	Name):	Receive	d by (S	Signature	& Nam	e):			Date:]	Time:		2, Sau	nples w s additio	rill not be stored over 30 days, onal storage time is requested
Relinquis	shed by (S	ignature&	Name):	Receive	d by (S	Signature	& Nam	e):			Date		1	Time:		3. Sto	rage tin	ne requested:days,
		-														By:		Date:
SPECIA	L INSTR	UCTION	Arrived at the lab U_{11}	- 1210														

PRESERVATIVE 1-HN03 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER



781 East Washington Blvd., Los Angeles, CA 90021 (213) 745-5312 FAX (213) 745-6372

April 25, 2022

Matt Richards City of Vernon 4963 Soto St. Vernon, CA 90058

Report No.: 2204190 Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on April 19, 2022.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

Project Manager



Certificate of Analysis

Page 2 of 2

Report Date: 04/25/22

PLS Report No.: 2204190

Submitted: 04/19/22

File #:74548

City of Vernon 4963 Soto St. Vernon, CA 90058

Attn: Matt Richards

Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: 0	Cooling Tower Blowdow	n Wat	er (220	4190-0)1) San	ipled: 0	4/19/22	08:25 R	eceived:	04/19/22				
Analyte	Re	sults	Flag	D.F.	Units	PQL	Prej	p/Test Met	hod	Prepared	Ana	lyzed	Ву	Batch
Total Dissol	ved Solids 4	120		1	mg/L	5.0	-	SM	2540C	04/20/22	04/2	21/22	VC	BD22203
				Q	uality	Contro	ol Data							
							Spike	Source		%REC		RPD		
Analyte		Resu	llt	PQL	1	Units	Level	Result	%REC	Limits	RPD	Limit	Q	ualifier
Batch BD2220	3													
Blank		Prep	ared: 04/	20/22	Analyzed	: 04/21/	22							
Total Dissolve	d Solids	ND		5.0	i	mg/L								
LCS		Prep	ared: 04/	20/22	Analyzed	: 04/21/	22							
Total Dissolve	d Solids	48.0)	5.0	ł	mg/L	50.00		96.0	80-120				
Duplicate	Source: 2204190-01	Prep	ared: 04/	20/22	Analyzed	:04/21/	22					*		
Total Dissolve	d Solids	4030)	5.0	4	mg/L		4120			2.41	5		
Duplicate	Source: 2204182-03	Prep	ared: 04/	20/22	Analyzed	: 04/21/	22				Laine	0007007-00711- 7		Providence 4
Total Dissolve	d Solids	445		5.0	1	mg/L		458			2.88	5		

Notes and Definitions

NA Not Applicable

ND Analyte NOT DETECTED at or above the detection limit

NR Not Reported

MDL. Method Detection Limit

PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Fick Owen Parlin

Authorized Signature(s)

						amon	37 4 3		BT A T	AZCHE	an	-							
		OS AB SI	ERVICE CHA	NIN OF shington B (213) 74	° CU Ivd., Lo 5-5312	STOD is Angeles FAX (213	Y AN 5, CA 900 8) 745-63	ND A 021 072	INAI	LYSI	8 KI	εQU	JES.	FILE	DATE	: <u>!(</u> -)	9.22	P LAB	NO:: 7104[9])
CLIENT	NAME:	CITY OI	FVERNON	PROJE	CT N	AME/NO).	MALBU	RG GENEI	RATING ST	TATION	WEEKL	 х	P.O.N	NO.				AIRBILL NO:
ADDRE	SS:	4963 SO	TO ST. VERNON CA 90058									AN	ALY	SES I	REQU	EST	ED	OBS	ERV. TEMP: <u>/, ૐ²</u> °C
PROJEC	T MANA	GER	MATT RICHARDS	PHONE	NO:			FAX N	NO:									COR	REC. TEMP: 1.62 °C
SAMPLI	ER NAMI	E:	JOHN BARIE	SIGNA'	- FURE	: K	/												REMARKS:
TAT (Tu	ırn-Aroun	nd-Time):	0=Same Day; 1=24 Hour; 2=	=48Hour;	(ETC.	.) N=Nor	mal												
CONTA	INER TY	PES: B=B	Brass; E=Encore/Easy Draw;	P=Plastic	G=G	lass; V=	VOA V	/ial; ()=Othe	er									
UST PR	ROJECT: Y N GLOBAL ID#: E DATE TIME SAMPLE DESCRIPTION MATRIX TAT CO																		
SAMPLE	DATE	TIME	SAMPLE DESCRIPTION		MA	TRIX	1	TAT	CONT	AINER									SAMPLE CONDITIONS/
<u>ID</u>	SAMPLED	SAMPLED		WATER SOIL SLUDGE OTHER # TYPE Y N 1 P															CONTAINER/COMMENTS
	419.2	0625	COOLING TOWER BLOWDOWN	X N 1 P X													<u> </u>		
		<u> </u>															<u> </u>	ļ	
									<u> </u>								<u> </u>	<u> </u>	
				_			ļ												
							 										<u> </u>		
ļ			<u></u>			ļ													
<u> </u>											<u> </u>						<u> </u>		
Relinquis	shed by (S MA	ignature&	Name):	Receive	d by (S Em	Signature	& Nam	e):		L	Date:	22		Time ∇S	25		SAM	IPLE	DISPOSITION eturned to client? Yes No
Relinqui	shed by (S	ignature&	Name):	Received by (Signature & Name):							Date:			Time	:		2. San unless	nples w additic	ill not be stored over 30 days,
Relinqui	shed by (S	ignature&	Name):	Receive	d by (S	Signature	& Nam	e):			Date			Time	:		3. Stor	rage tin	ne requested:days,
																	By:		Date:
SPECIA	L INSTR	UCTION	: Arrived at the lab C_{1}	2 112	υ														

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER



781 East Washington Blvd., Los Angeles, CA 90021 (213) 745-5312 FAX (213) 745-6372

April 28, 2022

Matt Richards City of Vernon 4963 Soto St. Vernon, CA 90058

Report No.: 2204263 Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on April 25, 2022.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

Project Manager



Cortificato	of Analysis	
Certificate	UI AIIAIYSIS	

Page 2 of 2

City of Vernon	
4963 Soto St.	
Vernon, CA 90058	

Attn: Matt Richards

File #:74548 Report Date: 04/28/22 Submitted: 04/25/22 **PLS Report No.: 2204263**

Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

Analyte	Results	Flag	D.F.	Units	PQL	Prep/	Test Method	Prepared	Analyzed	Ву	Batch
Total Dissolved Solids	4220	4220 1 mg/L 5.0 -					SM 2540C	04/25/22	04/26/22	VC	BD22533
			Qı	uality (Contro	ol Data					

Analyte		Result	POI	Linits	Spike Level	Source	%RFC	%REC	RPD	RPD Limit	Qualifier
Batch BD22533	• -	1,000,015		onico							******
Blank	Prepared: 04	4/25/22	Analyzed: 04/26	/22							
Total Dissolved S	Solids	ND	5.0	mg/L							
LCS		Prepared: 04	4/25/22	Analyzed: 04/26	/22						
Total Dissolved S	Solids	51.0	5.0	mg/L	50.00		102	80-120			
Duplicate	Source: 2204238-12	Prepared: 04	4/25/22	Analyzed: 04/26	/22						
Total Dissolved S	788	5.0	mg/L		800			1.57	5		
Duplicate	Source: 2204263-01	Prepared: 04	4/25/22	Analyzed: 04/26	/22						
Total Dissolved S	4190	5.0	mg/L		4220			0.516	5		

Notes and Definitions

NA Not Applicable

ND Analyte NOT DETECTED at or above the detection limit

NR Not Reported

MDL Method Detection Limit

PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Pick Owen Tarlie

Authorized Signature(s)

			CHA 781 East Was ERVICE	IN OF shington B (213) 74	F CU Ivd., Lo 5-5312	STOD os Angeles FAX (213	Y AN 5, CA 900 8) 745-63	ND A 121 172	NAI	LYSI	S RI	EQUI	EST	DAT E NO.	е: <u>Ц</u>	25-2	7 P LAB	PAGE: OF NO.: M.OYUN	
CLIENT NAME: CITY OF VERNON PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO.												AIRBILL NO:							
ADDRESS: 4963 SOTO ST. VERNON CA 90058											ANALYSES REQUESTED							OBSERVED TEMP //3*C	
PROJEC	T MANA	GER	PHONE NO: FAX NO:												CORRECTED TEMP:				
SAMPLI	ER NAMI		JOHN BARIE	SIGNA	TURE	: 77												THERMO ID:66	
TAT (Tu	rn-Aroun	d-Time):	0=Same Day: 1=24 Hour: 2=	48Hour:	ÆTC.	.) N=Nor	mal												
CONTAI	NER TY	PES: B=B	Brass: E=Encore/Easy Draw: H	P=Plastic	: G=G	lass: V=	 -VOA V	/ial: ()=Oth	er									
UST PRO	DIECT	V N	GLOBAL ID#:		, <u> </u>														
SAMPLE	DATE	TIME	SAMPLE DESCRIPTION		_	TAT	CONT	AINER								SAMPLE CONDITIONS/			
ID	SAMPLED	SAMPLED		WATER	SOIL	SLUDGE	OTHER		#	TYPE	TDS							CONTAINER/COMMENTS	
	40502	2810	COOLING TOWER BLOWDOWN	X				N	1	Р	х								
																1			
										1									
																	1		
*														-	-				
		****																*	
Relinquis	hed by (Si	gnature&	Name):	Receive	d by (S	Signature	& Nam	e):			Date: Time:					SAMPLE DISPOSITION			
(VA-			レフ	m	Broz				L	25-22 (02/2			1. Samples returned to client? Yes No		
Relinquis	hed by (Si	ignature&	Name):	Receive	d by (S	Signature	& Nam	e):			Date: Time:				2. Samples will not be stored over 30 days,				
															unless	unless additional storage time is requested			
Relinquished by (Signature& Name):				Receive	d by (S	Signature	& Nam	e):			Date: Time:				3. Storage time requested:days,				
																By:		Date:	
SPECIA	L INSTR	UCTION:	Arrived at the lab 4.25'2) -NaOF	16-NH4	BUFFF	R 7-		R									


781 East Washington Blvd., Los Angeles, CA 90021 (213) 745-5312 FAX (213) 745-6372

June 10, 2022

Matt Richards City of Vernon 4963 Soto St. Vernon, CA 90058

Report No.: 2206034 Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on June 02, 2022.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

Project Manager



Certificate of Analysis

Page 2 of 2

Report Date: 06/10/22

PLS Report No.: 2206034

Submitted: 06/02/22

File #:74548

City of Vernon 4963 Soto St. Vernon, CA 90058

Attn: Matt Richards

Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower	Blowdown Wa	ter (22(56034-(J1) Sam	pled: 0	6/02/22 (08:30 Received	: 06/02/22			
Analyte	Results	Flag	D.F.	Units	PQL	Prep	Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	1970		1	mg/L	5.0		SM 2540C	06/07/22	06/08/22	VC	BF20824
			Q	uality (Contro	ol Data					
						Spike	Source	%RFC	RPI	2	
		48,58,80				Shire		/UI \	· · · ·		

Allalyte		- Kesuit	РОГ	Units	Level	Result	WREC	Limits	KPD	LIMIC	Quaimer
Batch BF20824	4										
Blank		Prepared: 00	07/22 Ana	lyzed: 06/08	3/22						
Total Dissolve	d Solids	ND	5.0	mg/L							
LCS		Prepared: 00	5/07/22 Ana	lyzed: 06/08	3/22						
Total Dissolve	d Solids	50.0	5.0	mg/L	50.00		100	80-120			
Duplicate	Source: 2206034-01	Prepared: 06	/07/22 Ana	lyzed: 06/08	3/22						
Total Dissolve	d Solids	1970	5.0	mg/L		1970			0.167	5	
Duplicate	Source: 2206078-04	Prepared: 06	/07/22 Ana	lyzed: 06/08	3/22						
Total Dissolve	d Solids	450	5.0	mg/L		460			2.20	5	

Notes and Definitions

NA Not Applicable

ND Analyte NOT DETECTED at or above the detection limit

NR Not Reported

MDL. Method Detection Limit

PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Pick Owen Parlies

Authorized Signature(s)

									_									
			TIVE 781 East Was	IN OF hington B (213) 74	7 CU Ivd., Lo 5-5312	STOD Is Angeles FAX (21:)Y AI 5, CA 90(3) 745-63	ND A 121 172	ANAI	LYSI	S RI	EQU	EST	D.	ате <u>/-</u> -	<u>Lin</u>	F	PAGE: OF
													F	ILE NO).:		LAB	NO.: CWW94
CLIENT	NAME:	CITY OI	F VERNON	PROJE	CT N	AME/NO	D	MALBU	RG GENE	RATING S	TATION	WEEKLY	P	.0.NO				AIRBILL NO:
ADDRE	5S:	4963 SO	TO ST. VERNON CA 90058									AN	ALYS	ES RE	QUES	TED_		OBSERVED TEMP 1.9°C
PROJEC	T MANA	AGER	MATT RICHARDS	PHONE	<u>NO:</u>			FAX	NO:									CORRECTED TEMP: /.) °C
SAMPL	ER NAM	E:	JOHN BARIE	SIGNA	TURE	:J-												THERMO ID:
TAT (Tu	Irn-Arou	nd-Time):	0=Same Day; 1=24 Hour; 2=	48Hour;	(ETC	.) N=Nor	mal											
CONTA	INER TY	PES: B=E	Brass; E=Encore/Easy Draw; P	=Plastic	; G=G	lass; V=	=VOA V	Vial; (0=Oth	er								
UST PR	OJECT:	Y N	GLOBAL ID#:															
SAMPLE	AMPLE DATE TIME SAMPLE DESCRIPTION MATRIX TAT CONTAINER																SAMPLE CONDITIONS/	
Ð	SAMPLED	SAMPLED		WATER	SOIL	SLUDGE	OTHER		#	TYPE	TDS							CONTAINER/COMMENTS
	62-22	0230	COOLING TOWER BLOWDOWN	X			1	N	1	P	x							
																	Ι	
				<u> </u>														
									<u> </u>							1	1	
								<u> </u>					-			1		
								<u> </u>								+		
 							<u> </u>		1							1	1	
Relinqui	shed by (S	ignature&	Name).	Receive	L d hv (S	Signature	& Nam	e).			Date:		 Т	ime:		SAN	J IPLE	DISPOSITION
1	A A			5-	AT.	n Roce	<i>y</i>				(1-Z	2	-	084	~	1 San	nnies re	eturned to client? Yes No
Pelinqui	had by (S	ionoturo fr	Nome);	Pacaiva	$\frac{1}{2}$	Signature	& Nam	<i>م)</i> ،		[Date:		т	'ime	<u>v </u>	2 Son	nples u	ill not be stored over 30 days
Kennqui	sileu by (S	ngnatureœ	, ivanic).	Receive	u 0y (c	Signature	oc Indili				Date.		1	mic.		عمد . عدا الست	upies w	nik hot be stored over 50 days,
							0.21				D -4-							onal storage time is requested
Relinqui	elinquished by (Signature& Name): Received						& Nam	e):			Date:		I	ime:		5. Sto	rage tin	ne requested:days,
<u> </u>																By:		Date:
SPECIA	L INSTR	UCTION	: Arrived at the lab 6.0 20	1														
			0200	- 1035														

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER



781 East Washington Blvd., Los Angeles, CA 90021 (213) 745-5312 FAX (213) 745-6372

June 14, 2022

Matt Richards City of Vernon 4963 Soto St. Vernon, CA 90058

Report No.: 2206081 Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on June 07, 2022.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

Project Manager



Certificate of Analysis

Page 2 of 2

Report Date: 06/14/22

PLS Report No.: 2206081

Submitted: 06/07/22

File #:74548

City of Vernon 4963 Soto St. Vernon, CA 90058

Attn: Matt Richards

Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower I	Blowdown Wa	ter (220	6081-0)1) Sam	pled: 00	5/07/22 0	7:55 Received	: 06/07/22			
Anaiyte	Results	Flag	D.F.	Units	PQL	Prep/	Test Method	Prepared	Analyzed	Ву	Batch
Total Dissolved Solids	4410		1	mg/L	5.0	-	SM 2540C	06/08/22	06/09/22	VC	BF21332
			Q	uality (Contro	ol Data					

					Spike	Source		%REC		RPD	
Analyte		Result	PQL	Units	Level	Result	%REC	Limits	RPD	Limit	Qualifier
Batch BF21332 -	•										
Blank		Prepared: 0	6/08/22 A	nałyzed: 06/09,	/22						
Total Dissolved	Solids	5.0	5.0	mg/L							
LCS		Prepared: 0	6/08/22 A	nalyzed: 06/09	/22						04/44
Total Dissolved S	Solids	49.0	5.0	mg/L	50.00		98.0	80-120			
Duplicate	Source: 2206089-09	Prepared: 0	6/08/22 A	nalyzed: 06/09/	/22						
Total Dissolved S	Solids	905	5.0	mg/L		930			2,72	5	
Duplicate	Source: 2206081-01	Prepared: 0	6/08/22 A	nalyzed: 06/09,	/22						
Total Dissolved S	Solids	4340	5.0	mg/L		4410			1.60	5	

Notes and Definitions

NA Not Applicable

ND Analyte NOT DETECTED at or above the detection limit

NR Not Reported

MDL Method Detection Limit

PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Rick Oven Tailies

Authorized Signature(s)

5.5

		\cap		IN OF	r CU	STOD	Y AI	ND A	NAI	LYSI	S RI	EQU	EST					
Mk.I			THE VE 781 East Was ERVICE	hington B (213) 74	lvd., Lo 5-5312	is Angeles FAX (213	s, CA 90(3) 745-63	121 172						DA	ге: <u>6</u>	<u>7-22</u>	P/	$AGE: \underline{(} OF \underline{/} \\ OF \underline$
CLIENT	NAME:	CITY OI	F VERNON	PROJE	CT N	AME/NO).	MALBU	RG GENEI	RATING S	TATION	WEEKLY	<u> </u>	0.NO.	*		LAD	AIRBILL NO:
ADDRES	SS:	4963 SO	TO ST. VERNON CA 90058									AN	ALYS	ES RE(DUES	ſED		OBSERVED TEMP 1.1%
PROJEC	CT MANA	GER	MATT RICHARDS	PHONE	NO:			FAX	NO:						Ì			CORRECTED TEMP: 11
SAMPLI	ER NAMI	E:	JOHN BARIE	SIGNA	TURE	: 7-	-											THERMO ID: 126
TAT (Tu	ırn-Arour	nd-Time):	0=Same Day; 1=24 Hour; 2=	48Hour;	(ETC	.) N=Nor	mal	P	-									
CONTA	INER TY	PES: B=E	Brass; E=Encore/Easy Draw; P	-Plastic	; G=G	lass; V=	=VOA V	Vial; ()=Oth	er								
UST PR	OJECT:	Y N	GLOBAL ID#:															
SAMPLE	DATE	TIME	SAMPLE DESCRIPTION	<u> </u>	MA	TRIX	1	TAT	CONT	AINER								SAMPLE CONDITIONS/
ID	SAMPLED	SAMPLED		WATER	SOIL	SLUDGE	OTHER	ļ	#	TYPE	TDS					<u> </u>		CONTAINER/COMMENTS
<u> </u>	6722	0755	COOLING TOWER BLOWDOWN	X				N	1	P	_X				_			
			ļ	ļ	ļ	<u> </u>												
ļ			·		ļ		<u> </u>			<u> </u>	L							
<u> </u>					-						ļ						L	
<u> </u>	ļ				-		<u> </u>			<u> </u>								
		ļ	·····	<u> </u>	ļ		<u> </u>			 						_		
Relinquis	shed by (S MA	ignature&	Name):	Receive	d by (S	Signature	& Nam	e):		Ŀ	Date:	22	т С	ime: ・フケア		SAM	IPLE I	DISPOSITION urned to client? Yes No
Relinquis	elinquished by (Signature& Name):				d by (S	Signature	& Nam	e):			Date:		Т	ime:		2. Sam	nples wil additior	ll not be stored over 30 days, nal storage time is requested
Relinquis	shed by (S	ignature&	Name):	Receive	d by (\$	Signature	& Nam	e):			Date:		Т	ime:		3. Stor	rage time	e requested:days,
SPECIA PRESE	L INSTR	UCTION	: Arrived at the lab 6-7-2 2-H2SO4 3-HCL 4- ZINC ACE	- ^ン ~ሪ, TATE 5	Ĵ≂⊃ -NaOł	+ 6-NH4	BUFF	ER 7-	OTHE	R								



781 East Washington Blvd., Los Angeles, CA 90021 (213) 745-5312 FAX (213) 745-6372

June 20, 2022

Matt Richards City of Vernon 4963 Soto St. Vernon, CA 90058

Report No.: 2206176 Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on June 14, 2022.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

Project Manager



Certificate of Analysis

Page 2 of 2

City of Vernon 4963 Soto St. Vernon, CA 90058 File #:74548 Report Date: 06/20/22 Submitted: 06/14/22 PLS Report No.: 2206176

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

Analyte	Results	Flag	D.F.	Units	PQL	Prep/	Test Method	Prepared	Analyzed	Ву	Batch
Total Dissolved Solids	4830		1	mg/L	5.0	-	SM 2540C	06/14/22	06/15/22	VC	BF21523
			Q	uality (Contro	ol Data					

Analyte		Result	PQL	Units	Level	Result	%REC	Limits	RPD	Limit	Qualifier
Batch BF21523											
Blank		Prepared: 0	6/14/22 An	alyzed: 06/15	5/22				tinnia stair		
Total Dissolved	Solids	ND	5.0	mg/L							
LCS		Prepared: 0	6/14/22 Ana	alyzed: 06/15	5/22						
Total Dissolved	Solids	60.0	5.0	mg/L	50.00		120	80-120			
Duplicate	Source: 2206127-04	Prepared: 0	6/14/22 Ana	alyzed: 06/15	5/22						
Total Dissolved	Solids	900	5.0	mg/L		926			2.85	5	
Duplicate	Source: 2206176-01	Prepared: 0	6/14/22 Ana	alyzed: 06/15	5/22						
Total Dissolved	Solids	4930	5.0	mg/L		4830			1.98	5	

Notes and Definitions

NA Not Applicable

ND Analyte NOT DETECTED at or above the detection limit

NR Not Reported

MDL Method Detection Limit

PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Rick Owen Part

Authorized Signature(s)

		n		IN OF	r CU	STOD	Y AN	ND A	NAI	YSI	S RI	EQU	EST					
			781 East Was	hington B (213) 74	lvd., Lo 5-5312	IS Angeles FAX (213), CA 900 1) 745-63	121 172						DAT	E. /	7.22	P	PAGE: / OF /
<u> 16.16.21.2</u>		~ D 31	er v i 🤍 e										FI	LE NO.:			LAB	NO.: WULTIE
<u>CLIENT</u>	NAME:	CITY OF	VERNON	PROJE	CT N	AME/NC).	MALBU	RG GENEI	RATING S	TATION	WEEKLY	P.	D.NO.				AIRBILL NO:
ADDRE	SS:	4963 SOT	TO ST. VERNON CA 90058									ANA	LYSE	S REQ	UEST	ED	<u></u>	OBSERVED TEMP 1.D°C
PROJEC	<u>T MANA</u>	GER	MATT RICHARDS	PHONE	NO:			FAX	NO:									CORRECTED TEMP
SAMPL	ER NAMI	l:	JOHN BARIE	SIGNA	TURE	4							_					THERMO ID: <u>66</u>
TAT (Tu	rn-Aroun	<u>d-</u> Time):	0=Same Day; 1=24 Hour; 2=	48Hour;	(ETC	.) N=Nor	mal											
CONTA	INER TY	<u>PES: B=B</u>	Brass; E=Encore/Easy Draw; P	=Plastic	; G=G	lass; V=	VOA V	/ial; ()=Othe	er				-				
UST PR	T PROJECT: Y N GLOBAL ID#:																	
SAMPLE DATE TIME SAMPLE DESCRIPTION MATRIX TAT CONTAINER																	SAMPLE CONDITIONS/	
ID	SAMPLED	SAMPLED		WATER SOIL SLUDGE OTHER						TYPE	1.DS				1		<u> </u>	CONTAINER/COMMENTS
	6-14.22	0745	COOLING TOWER BLOWDOWN	x				N	1	Р	X					ļ		
								L							-			
Relinquis	hed by (Si	gnature&	Name):	Receive	d by (S	lignature	& Nam	e):			Date:		Ti	ne:		SAM	IPLE	DISPOSITION
N	A			$\tilde{\overline{z}}$	Sin	Barr				6	142	2	D	745		1. Sam	nples re	eturned to client? Yes No
Relinquis	hed by (Si	gnature&	Name):	Receive	d by (S	Signature	& Nam	e):			Date:	-	Ti	ne:		2. San	nples w	rill not be stored over 30 days,
																unless	additic	onal storage time is requested
Relinquis	nquished by (Signature & Name): Received by (Signature & Name):									Date:		Ti	ne:		3. Stor	age tin	ne requested:days,	
	By:Date:																	
SPECIA	LINSTR	UCTION:																
			Arrived at the lab 67422	, GGY	ว้													
PRESE	RVATIVE	1-HNO3	2-H2SO4 3-HCL 4- ZINC ACE	TATE 5-	NaOF	6-NH4	BUFFE	R 7- (OTHE	2								



781 East Washington Blvd., Los Angeles, CA 90021 (213) 745-5312 FAX (213) 745-6372

June 29, 2022

Matt Richards City of Vernon 4963 Soto St. Vernon, CA 90058

Report No.: 2206257 Project Name: Malburg Generating Station

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on June 21, 2022.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

Project Manager



Page 2 of 2

File #:74548 Report Date: 06/29/22 Submitted: 06/21/22 **PLS Report No.: 2206257**

Attn: Matt Richards

Vernon, CA 90058

City of Vernon

4963 Soto St.

Phone: (323) 476-3626 FAX:(323) 476-3640

Project:	Malburg	Generating	Station
----------	---------	------------	---------

Sample ID: Co	aling Tower Blowdow	vn Wat	ter (220	6257-0	1) Sam	pled: 0	6/21/22	08:45 R	eceived:	06/21/22				
Analyte	R	esults	Flag	D.F.	Units	PQL	Pre	p/Test Met	hod	Prepared	Anai	yzed	Ву	Batch
Total Dissolve	d Solids	3940		1	mg/L	5.0	-	SM	2540C	06/27/22	06/2	8/22	VC	BF22826
				Qı	uality	Contro	ol Data	1						
							Spike	Source		%REC		RPD		
Analyte		Resi	ılt	PQL	- 1	Jnits	Level	Result	%REC	Limits	RPD	Limit	Q	ualifier
Batch BF22826 -													d.C.C. Soci-	
Blank		Prep	ared: 06	/27/22	Analyzed	: 06/28/	22							
Total Dissolved S	Solids	ND	1	5.0	r	ng/L								
LCS		Prep	ared: 06	/27/22	Analyzed	: 06/28/	22							
Total Dissolved S	Solids	57.0	C	5.0	r	ng/L	50.00		114	80-120				
Duplicate Source: 2206257-01 Prepared: 06/27/22 Analyzed: 06/28/2														
Total Dissolved S	Solids	394	0	5.0	1	ng/L		3940			0.127	5		

Notes and Definitions

NA Not Applicable

ND Analyte NOT DETECTED at or above the detection limit

NR Not Reported

MDL Method Detection Limit

PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Fick Owen Tax li

Authorized Signature(s)

				INC		GTOP	X7 4 3			NOT	ים מ		TRO	T					
ak.t		OS AB SI	TIVE CHA 781 East Was	LIN OF hington B (213) 74	- CU Ivd., Lo 5-5312	STOD is Angeles FAX (213	Y AF 5, CA 900 8) 745-63	ND A 121 172	ANAI		2 KI	ĿQI)ES	I FILE	DATE NO.:	<u>:62</u>	1.22	F LAB	PAGE: <u> </u> 0 ¢ NO.: <i>UDUUST</i>
CLIENT	'NAME:	CITY OF	F VERNON	PROJE	CT N	AME/NO).	MALBU	RG GENEI	RATING S	TATION	WEEKL	Y	P.O.N	10.		(1)		AIRBILL NO:
ADDRE	SS:	4963 SO	TO ST. VERNON CA 90058									ANALYSES REQUESTED					OBSERVED TEMP2-12		
PROJEC	T MANA	GER	MATT RICHARDS	PHONE	NO:			FAX	NO:							CORRECTED TEMP			
SAMPL	ER NAMI	E:	JOHN BARIE	SIGNA	ΓURE	: 7~													THERMO ID.66
TAT (Tı	- Irn-Arour	ıd-Time):	0=Same Day; 1=24 Hour; 2=	48Hour;	(ETC	.) N=Nor	mal												
CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other																			
UST PROJECT: Y N GLOBAL ID#:																			
SAMPLE	DATE	TIME	SAMPLE DESCRIPTION		MA	TRIX		TAT	CONT	AINER	s								SAMPLE CONDITIONS/
1D	SAMPLED	SAMPLED		WATER	SOIL	SLUDGE	OTHER		#	TYPE	TD								CONTAINER/COMMENTS
	64.27	245	COOLING TOWER BLOWDOWN	X				N	1	<u>P</u>	X								
	_																		
										<u> </u>							ļ		
	ļ																		
Relinqui	shed by (S	ignature&	Name):	Receive	d by (S	Signature	& Nam	e):			Date:			Time			SAM	PLE	DISPOSITION
	MA			J~_	Je	mber	$\overline{\mathcal{X}}$			6	521	22		084	5		1. Sam	ples re	sturned to client? Yes No
Relinqui	shed by (S	ignature&	Name):	Receive	d by (S	Signature	& Nam	e):			Date:			Time	:		2. Sam	iples w	ill not be stored over 30 days,
																	unless	additio	onal storage time is requested
Relinqui	Relinquished by (Signature& Name):			Receive	d by (S	Signature	& Nam	e):			Date:			Time	:		3. Stor	age tin	ne requested:days,
																	By:		Date:
SPECIA	L INSTR	UCTION	: Arrived at the lab																
			- unived at the lab 6'4-22	12/0															
DOFOE		4 10100	A LIAGO (A LIO) (TING LOF		M-OI	10 1014	DUCEE		ATUE	0									

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER



781 East Washington Blvd., Los Angeles, CA 90021 (213) 745-5312 FAX (213) 745-6372

July 07, 2022

Matt Richards City of Vernon 4963 Soto St. Vernon, CA 90058

Report No.: 2206335 Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on June 28, 2022.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

Aller



Certificate of Analysis

Page 2 of 2

City of Vernon 4963 Soto St. Vernon, CA 90058

Attn: Matt Richards

File #:74548 Report Date: 07/07/22 Submitted: 06/28/22 PLS Report No.: 2206335

Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower I	Blowdown Wa	ter (220	J6335-C	J1) Sam	pled: 0/	5/28/22 (09:35 Received	: 06/28/22			
Analyte	Results	Flag	D.F.	Units	PQL.	Prep,	/Test Method	Prepared	Analyzed	Ву	Batch
Total Dissolved Solids	4020		1	mg/L	5.0	*	SM 2540C	06/29/22	06/30/22	VC	BG20526
			Q	uality (Contro	ol Data					

					Spike	Source		%REC		RPD	
Analyte		Result	PQL	Units	Level	Result	%REC	Limits	RPD	Limit	Qualifier
Batch BG20526	••										
Blank	<u>terrene and an electric product and an electric statements and an electric statements and an electric statement</u>	Prepared: ()6/29/22	Analyzed: 06/30	1/22		<u></u>				
Total Dissolved	Solids	ND	5.0	mg/L							
LCS		Prepared: (16/29/22	Analyzed: 06/30	1/22						
Total Dissolved	Solids	60.0	5.0	mg/L	50.00		120	80-120			
Duplicate	Source: 2206335-01	Prepared: (76/29/22	Analyzed: 06/30	1/22						
Total Dissolved	Solids	3970	5.0	mg/L	<u></u>	4020			1.04	5	

Notes and Definitions

NA Not Applicable

ND Analyte NOT DETECTED at or above the detection limit

NR Not Reported

MDL Method Detection Limit

PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Rick Dwen lan

Authorized Signature(s)

		ne		IN OI	F CU	STOI)Y Al	ND A	NAJ	LYSI	S RI	EQI	JES	T				,	
			IIVE 781 East War ERVICE	shington B (213) 74	lvd., Lo 5-5312	is Angele FAX (21:	s, CA 900 3) 745-63)21 72						I	DATE:_	62	<u>6</u> 2	ZPA	AGE: _ OF
CLIENC	NAME.			PROFE			<u> </u>							FILEN	<u>10.:</u>		L		NO.: /////99
UDDDD	NAME:		VERION	PROJE	CIN	AWIE/IN	J.	MALBU	RG GENE	RATING S	TATION	WEEKL	.Y 	<u>r.u.n</u>	U.	CTE			AIRBILL NO:
ADDRE	55:	4963 50	10 ST. VEKNON CA 90058											SES R	EQUE				JESERVED TEMP $(2, \mathcal{G}^{2})$
PROJEC	T MANA	<u>IGER</u>	MATTRICHARDS	PHONE	NO:			FAX	<u>NO:</u>										CORRECTED TEMPS: $\frac{1}{6}$
SAMPL	SAMPLER NAME: JOHN BARIE SIGNATURE: 75-										11	THERMO ID:							
TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal																			
CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other																			
UST PR	UST PROJECT: Y N GLOBAL ID#:												ŀ						
SAMPLE	DATE	LIME	SAMPLE DESCRIPTION					IAI		TYPE	DS							Ĩ	SAMPLE CONDITIONS/
	5-76271	SAMPLED		WALLK	SOIL	SLUDGE	UIHER		#	D									CONTAINER/COMMENTS
	5000	<u>10155</u>	COOLING TOWER BLOWDOWN		<u> </u>			N .										+	44
 											<u> </u>					+			
	<u> </u>						1												
								<u> </u>											
		<u> </u>						<u> </u>											
														-+					
																_			
Relinqui	shed by (S	ignature&	Name):	Receive	d by (S	Signature	& Nam	e):		60	Date:	~	~~~	Time:		S	SAMP	PLE I	DISPOSITION
/			d	5~40	21/05	1K				00	5R	0	930			1	. Sampl	les retu	arned to client? Yes No
Relinqui	shed by (S	ignature&	Name):	Receive	d by (S	Signature	& Nam	e):			Date:			Time:		2	. Sampl	les will	I not be stored over 30 days,
																u	nless ac	ddition	al storage time is requested
Relinqui	Relinquished by (Signature& Name):				d by (Signature	& Nam	e):			Date:			Time:		3	3. Storage time requested:days,		
																E	y:		Date:
SPECIA	SPECIAL INSTRUCTION:																		
			Arrived at the lab 6 28	12 /00=	ر 														
PRESE	PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER																		

Appendix C Operation Logs

Malburg Generating Station Appendix C, Table 1 Combustion Turbine Generator (CTG) Startup and Shutdown Events During Quarter 2, 2022

CGI 1											
Date	Event Type ¹	Event Start	Event End	Duration (hrs:min)							
4/6/2022	Cold Start	12:44	14:01	1:17							
4/20/2022	Shutdown	23:00	23:08	0:08							
4/30/2022	Cold Start	16:35	17:49	1:14							
4/30/2022	Shutdown	21:53	22:02	0:09							
5/23/2022	Cold Start	10:48	10:55	0:07							
5/23/2022	Shutdown	12:49	12:49	0:00							
5/23/2022	Hot Start	17:40	17:47	0:07							
5/23/2022	Shutdown	21:05	21:09	0:04							
5/24/2022	Warm Start	8:51	8:57	0:06							
5/24/2022	Shutdown	18:21	18:29	0:08							
5/27/2022	Cold Start	15:22	16:26	1:04							
5/28/2022	Shutdown	14:43	14:51	0:08							
5/30/2022	Cold Start	23:59	1:21	0:36							
6/23/2022	Shutdown	13:23	13:31	0:08							

CGT 2

Date	Event Type ¹	Event Start	Event End	Duration (hrs:min)
4/9/2022	Shutdown	00:02	00:10	0:08
4/20/2022	Cold Start	16:01	17:29	1:28
4/30/2022	Shutdown	21:53	22:02	0:09
5/24/2022	Cold Start	16:37	16:44	0:07
5/24/2022	Trip	18:22	18:22	0:00
5/26/2022	Warm Start	14:05	15:25	1:20
5/26/2022	Shutdown	21:18	21:26	0:08
5/28/2022	Warm Start	12:13	13:39	1:26
5/29/2022	Shutdown	02:00	02:08	0:08
5/30/2022	Warm Start	12:14	13:29	1:15
5/30/2022	Shutdown	19:42	19:50	0:08
6/5/2022	Cold Start	20:04	21:17	1:13
6/8/2022	Trip	10:15	10:15	0:00
6/8/2022	Hot Start	14:58	15:39	0:41
6/10/2022	Shutdown	22:01	22:09	0:08
6/23/2022	Cold Start	11:38	12:52	1:14

¹ A startup event is defined as initiation of combustion until the system becomes emissions compliant, for consistency with the Title V Permit definitions.

Malburg Generating Station Appendix C, Table 2 Diesel Firewater Pump Testing Times During Quarter 2, 2022

Date	Time (hh:mm)	Start Hours	End Hours	Event Type	Hours of Operation
4/3/2022	19:28	337.3	337.8	Testing	0.50
4/10/2022	20:46	337.8	338.3	Testing	0.50
4/17/2022	19:57	338.3	338.7	Testing	0.40
4/24/2022	20:21	338.7	339.2	Testing	0.50
5/22/2022	20:47	339.2	339.9	Testing	0.70
5/29/2022	21:34	339.9	340.4	Testing	0.50
6/7/2022	13:30	340.4	340.9	Testing	0.50
6/19/2022	23:41	340.9	341.5	Testing	0.60
6/26/2022	20:32	341.5	342	Testing	0.50

Appendix D Diesel Fuel Oil Purchase Records



SC Commercial, LLC, DBA SC Fuels 1800 West Katella Ave, Suite 400 P.O. Box 4159, Orange, CA 92863-4159

PLEASE REMIT ALL PAYMENTS TO: P.O. BOX 14237

ORANGE, CA 92863-1237

Ph: (800) 659-5823 Credit Inquiries: (888) SCFUELS Ext.6017

ACCT NO (Bill-to): 01-0001045

CITY OF VERNON 4305 SANTA FE AVE ATTN: DEPARTMENT D VERNON, CA 90058 (323) 583-8811

ACCT NO (Ship-to)

o) 01-0001045 103L

CITY OF VERNON-SOTO ST-L 4963 SOTO ST VERNON, CA 90058

ITEM CODE		ITEM DESCRIPTION	QUANTITY ORDERED	QUANTIT DELIVERI	Y PACKAGE ED DESCRIPTION	EXTENDED QTY	UNIT PRICE	EXT PRICE
CH277210983D40 0	CH MEROPA 277210983	150	1 Whse:	1.00 101	400 LB DR	400.00	3.39000	1,356.00
\$	3.39 PER TC							
422D055	DYED CARB NON TAXAB PENALTY FC 15 PPM OR CONTAIN UF TO/ \$4.35 PEF	ULS DIESEL LE USE ONLY - DR TAXABLE USE LESS SULFUR - MAY P TO 5% BIODIESEL R TC	2 Whse:	2.00 101	55 G DR	110.00	4.35000	478.50
Federal Lust							0.00100	0.11
Federal Oil Spill							0.00214	0.24
CA - AB 32 - DSL							0.00828	0.91
							4.36142	479.76
CH273204981D05 5	CH REGAL F 273204981 FORMERLY BACKORDERI	8&O ISO 150 - 273213981 ED ON 2104708	0 Whse:	0.00 101	55 G DR	0.00	0.00000	0.00
/FUELC	HLUBE	FUEL SURCHARGE LUBES						9.92
/RCFLU	JBE	REG COMPLIANCE FEE LUBE	S					12.95
DRUMDEPOSITC 001	DRUM DEPO	DSIT FEE	3 Whse:	3.00 101	MISC CHRG	3.00	25.00000	75.00
MSRTNDRMC001	RETURN DR	UM	0 Whse:	-2.00 101	MISC CHRG	2.00-	15.00000	30.00-

Save time, hav onlined. View invoices, make have not more	Net Invoice:	1,903.63
Sign up for the Customer Portal today. Email: creditinguiries@scfuels.com or Call 888-SCFuels	Less Discount:	0.00
Ext. 6017 or login to Customer Portal: https://customerportal.scfuels.com	Freight:	0.00
24-hour Emergency Response Call CHEMTREC: 800-424-9300	Sales Tax:	190.52
	Invoice Total:	2,094.15

- IN THE EVENT THAT THE ABOVE CHARGES ARE NOT PAID WHEN DUE, SC COMMERCIAL, LLC, DBA SC FUELS RESERVES THE RIGHT TO REFUSE FURTHER

- CHARGES TO THE ACCOUNT. A SERVICE CHARGE OF 1.5% PER MONTH{A.P.R. 18%} WILL APPLY TO ALL PAST DUE INVOICES.

- ERRORS IN PRICE, EXTENSION, AND ADDITION SUBJECT TO CORRECTION.

- It is the purchaser's responsibility to verify that all applicable taxes are being charged in accordance with fedral and state laws. - Prices shown on this invoice reflect discounts received for Payment by Cash, Check, or Electronic Funds Transfer (EFT). Payment by other means is subject to a 3% surcharge.

www.scfuels.com

Page 1 of 1

DUE DATE: 5/11/2022 SHIP DATE: 4/11/2022

INVOICE DATE: 4/11/2022

SHIP VIA: 924

ORDER DATE: 4/1/2022 ORDER NUMBER: 2100721 CUSTOMER PO: 055.0002948

TERMS: N30

SALEPERSON: Todd Cripps

714-938-5714

ver. SCF20220420

Appendix E Excess Emission Reports

U1 CO Startup/Shutdown

From:	04/01/2022 00:00) то: 06,	/30/2022 23:	59 Facility Name	: Malburg	Generating S	Station
Generated:	07/08/2022 13:21			Location:	Vernon,	California	
Tag Name:	U1_CO_LbPerHr_1M	1		<pre>SI = SampleInvalid, *</pre>	= Excess Emission		
Total Operat	ting Time:	956.15	Hours				
Non-Operatin	g Time: 1,227.85 н	ours	Report Time:	2,184.00 Hours			

 Unit Operation

 Event Period
 Action

 Duration in Minute(s)
 Lb/Event
 Limit
 Code - Description
 Code - Description

No excess emissions were found in the reporting period.



Startup/Shutdown Excess Emissions Report U1 CO Startup/Shutdown



From:04/01/2022 00:00To:06/30/2022 23:59Facility Name:Malburg Generating StationGenerated:07/08/2022 13:21Location:Vernon, CaliforniaTag Name:U1_C0_LbPerHr_1MSI = SampleInvalid, * = Excess EmissionTotal Operating Time:956.15HoursNon-Operating Time:1,227.85HoursReport Time:2,184.00Hours

No invalid events were found in the reporting period.

U1 NOx Startup/Shutdown

From:	04/01/2022 00:0	ОО то: Об	/30/2022 23:	59 Facility Name:	Malburg	Generating	Station
Generated:	07/08/2022 13:2	27		Location:	Vernon,	California	
Tag Name:	U1_NOXRECLM_Lb	PerHr_1M		<pre>SI = SampleInvalid, * =</pre>	Excess Emission		
Total Operat	ing Time:	956.15	Hours				
Non-Operatin	g Time: 1,227.85	Hours	Report Time:	2,184.00 Hours			

	Unit Operation											
	Event Period			Reason	Action							
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description							

No excess emissions were found in the reporting period.



U1 NOx Startup/Shutdown

From:04/01/2022 00:00To:06/30/2022 23:59Facility Name:Malburg Generating StationGenerated:07/08/2022 13:27Location:Vernon, CaliforniaTag Name:U1_NOXRECLM_LbPerHr_1MSI = SampleInvalid, * = Excess EmissionTotal Operating Time:956.15HoursNon-Operating Time:1,227.85HoursReport Time:2,184.00Hours

No invalid events were found in the reporting period.



2

U1 VOC Startup/Shutdown



Unit Operation							
	Event Period		Reason	Action			
Begin/End	Duration in Minute(s) Lb/	/Event Limi [.]	Code - Description	Code - Description			

No excess emissions were found in the reporting period.





U1 VOC Startup/Shutdown

From:04/01/2022 00:00To:06/30/2022 23:59Facility Name:Malburg Generating StationGenerated:07/08/2022 13:30Location:Vernon, CaliforniaTag Name:U1_VOC_LbPerHr_1MSI = SampleInvalid, * = Excess EmissionTotal Operating Time:956.15HoursNon-Operating Time:1,227.85HoursReport Time:2,184.00Hours

No invalid events were found in the reporting period.

Unit 1 - CO ppmvdc 1-hour during Normal Operation

 From:
 04/01/2022
 00:00
 To:
 06/30/2022
 23:59
 Facility Name:

 Generated:
 07/08/2022
 13:38
 Location:

Malburg Generating Station Vernon, California



Tag Name:U1_CONormal_Ppmvdc_1HTotal Operating Time:965.00 Hour(s)Non-Operating Time:1,219.00 Hour(s)Report Time:2,184.00 Hour(s)Report Time:2,184.00 Hour(s)

No Exclusions Allowed

Total Operating Time:	965.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Unit 1 - NOx ppmvdc 1-hour during Normal Operation

 From:
 04/01/2022 00:00
 To:
 06/30/2022 23:59
 Facility Name:

 Generated:
 07/08/2022 13:24
 Location:

Malburg Generating Station Vernon, California



Tag Name:U1_NOxNormal_Ppmvdc_1HTotal Operating Time:965.00 Hour(s)Non-Operating Time:1,219.00 Hour(s)Report Time:2,184.00 Hour(s)Report Time:2,184.00 Hour(s)

No Exclusions Allowed

Total Operating Time:	965.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Unit 1 - VOC ppmvdc 1-hour during Normal Operation

 From:
 04/01/2022
 00:00
 To:
 06/30/2022
 23:59
 Facility Name:

 Generated:
 07/08/2022
 13:25
 Location:

Malburg Generating Station Vernon, California



Tag Name:U1_VOCNormal_Ppmvdc_1HTotal Operating Time:965.00 Hour(s)Non-Operating Time:1,219.00 Hour(s)Report Time:2,184.00 Hour(s)Report Time:2,184.00 Hour(s)

No Exclusions Allowed

Total Operating Time:	965.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Quad K Excess Emissions Report

U1 NOX 4-Hour Events

From:04/01/2022 00:00To:06/30/2022 23:59Generated:07/08/2022 13:26

9 Facility Name: Location:

Malburg Generating Station Vernon, California



Tag Name:U1_NOx4H_Ppmvdc_1HTotal Operating Time:965.00 Hour(s)Non-Operating Time:1,219.00 Hour(s)Report Time:2,184.00 Hour(s)Report Time:2,184.00 Hour(s)

No Exclusions Allowed

Total Operating Time:	965.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Unit 1 - CO ppmvdc 3-hour Rolling during Normal Operation

From:04/01/2022 00:00To: 06/30/2022 23:59Facility Name:Malburg Generating StationGenerated:07/08/2022 13:23Location:Vernon, California



Tag Name:U1_CO_3HrRoll_Ppmvdc_1HTotal Operating Time:965.00 Hour(s)Non-Operating Time:1,219.00 Hour(s)Report Time:2,184.00 Hour(s)Report Time:2,184.00 Hour(s)

No Exclusions Allowed

Total Operating Time:	965.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Startup/Shutdown Event Report

U2 CO Startup/Shutdown Events



Non-Operating Time: 1,417.58 Hours Report Time: 2,184.00 Hours

Unit Operation						
	Event Period			Reason	Action	
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description	

No excess emissions were found in the reporting period.

Startup/Shutdown Event Report

U2 CO Star	/Shutdown rtup/Shutdow	n EVEN In Event	t Report s			S2
From:	04/01/2022 00	:00 то:	06/30/2022 23:59	Facility Name:	Malburg Generating Station	HEOROT
Generated:	07/08/2022 13	:31		Location:	Vernon, California	
Tag Name:	U2_CO_LbPerHr_	_1M		<pre>SI = SampleInvalid, * = E</pre>	Excess Emission	
Total Operation	ting Time: ng Time: 1,417.58	766. ³ Hours	42 Hours Report Time: 2,1	84.00 Hours		

No invalid events were found in the reporting period.



U2 NOx Startup/Shutdown

From:	04/01/2022 00:0	ОО то: Об	/30/2022 23:	59 Facility Name:	Malburg	Generating	Station
Generated:	07/08/2022 13:	35		Location:	Vernon,	California	
Tag Name:	U2_NOXRECLM_Lb	PerHr_1M		SI = SampleInvalid, * =	Excess Emission		
Total Operat	ing Time:	766.42	Hours				
Non-Operatin	g Time: 1,417.58	Hours	Report Time:	2,184.00 Hours			

Unit Operation							
Event Period				Reason	Action		
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description		

No excess emissions were found in the reporting period.



U2 NOx Startup/Shutdown

From:04/01/2022 00:00To:06/30/2022 23:59Facility Name:Malburg Generating StationGenerated:07/08/2022 13:35Location:Vernon, CaliforniaTag Name:U2_NOXRECLM_LbPerHr_1MSI = SampleInvalid, * = Excess EmissionTotal Operating Time:766.42Hours
Report Time: 2,184.00Non-Operating Time:1,417.58Hours
Report Time: 2,184.00

No invalid events were found in the reporting period.


Startup/Shutdown Event Report

U2 VOC Startup/Shutdown Events

From:	04/01/2022 00:00	To:	06/30/2022 23	3:59	Facility Nam	e: Malburg	Generating	Station
Generated:	07/08/2022 13:36				Location:	Vernon,	California	
Tag Name:	U2_VOC_LbPerHr_1M				<pre>SI = SampleInvalid,</pre>	* = Excess Emission		
Total Operating Time:		766.	42 Hours	2 1 0				

Unit Operation Event Period Reason Action Duration in Begin/End Minute(s) Lb/Event Limit Code - Description Code - Description

No excess emissions were found in the reporting period.

Non-Operating Time: 1,417.58 Hours Report Time: 2,184.00 Hours

U2_VOC_ExcessEmissions_SUSD



Startup/Shutdown Event Report

U2 VOC Startup/Shutdown Events 04/01/2022 00:00 To: 06/30/2022 23:59 Facility Name: Malburg Generating Station From: POWER Vernon, California **Generated:** 07/08/2022 13:36 Location: SI = SampleInvalid, * = Excess Emission U2_VOC_LbPerHr_1M Tag Name: Total Operating Time: 766.42 Hours Non-Operating Time: 1,417.58 Hours Report Time: 2,184.00 Hours

No invalid events were found in the reporting period.



Unit 2 - CO ppmvdc 1-hour during Normal Operation

 From:
 04/01/2022
 00:00
 To:
 06/30/2022
 23:59
 Facility Name:

 Generated:
 07/08/2022
 13:39
 Location:

Malburg Generating Station Vernon, California



Tag Name:U2_CONormal_Ppmvdc_1HTotal Operating Time:775.00 Hour(s)Non-Operating Time:1,409.00 Hour(s)Report Time:2,184.00 Hour(s)Report Time:2,184.00 Hour(s)

No Exclusions Allowed

Total Operating Time:	775.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Unit 2 - NOx ppmvdc 1-hour during Normal Operation

 From:
 04/01/2022 00:00
 To:
 06/30/2022 23:59
 Facility Name:

 Generated:
 07/08/2022 13:33
 Location:

Malburg Generating Station Vernon, California



Tag Name:U2_NOxNormal_Ppmvdc_1HTotal Operating Time:775.00 Hour(s)Non-Operating Time:1,409.00 Hour(s)Report Time:2,184.00 Hour(s)Report Time:2,184.00 Hour(s)

No Exclusions Allowed

Total Operating Time:	775.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Unit 2 - VOC ppmvdc 1-hour during Normal Operation

 From:
 04/01/2022 00:00
 To:
 06/30/2022 23:59
 Facility Name:

 Generated:
 07/08/2022 13:33
 Location:

Malburg Generating Station Vernon, California



Tag Name:U2_VOCNormal_Ppmvdc_1HTotal Operating Time:775.00 Hour(s)Non-Operating Time:1,409.00 Hour(s)Report Time:2,184.00 Hour(s)Report Time:2,184.00 Hour(s)

No Exclusions Allowed

Total Operating Time:	775.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Quad K Excess Emissions Report

U2 NOX 4-Hour Events

From:04/01/202200:00To:06/30/202223:59Generated:07/08/202213:34

9 Facility Name: Location:

Malburg Generating Station Vernon, California



Tag Name:U2_NOx4H_Ppmvdc_1HTotal Operating Time:775.00 Hour(s)Non-Operating Time:1,409.00 Hour(s)Report Time:2,184.00 Hour(s)Report Time:2,184.00 Hour(s)

No Exclusions Allowed

Total Operating Time:	775.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Unit 2 - CO ppmvdc 3-hour Rolling during Normal Operation

From:04/01/2022 00:00To: 06/30/2022 23:59Facility Name:Malburg Generating StationGenerated:07/08/2022 13:32Location:Vernon, California



Tag Name:U2_CO_3HrRoll_Ppmvdc_1HTotal Operating Time:775.00 Hour(s)Non-Operating Time:1,409.00 Hour(s)Report Time:2,184.00 Hour(s)Report Time:2,184.00 Hour(s)

No Exclusions Allowed

Total Operating Time:	775.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Appendix F Exceedance Reports



4305 Santa Fe Avenue, Vernon, California 90058 Telephone (323) 583-8811

May 2, 2022

SCAQMD – Compliance & Enforcement P.O. Box 4941 Diamond Bar, CA 91765-0941 Attn: Christian Fielding

Subject: Form 500-N for Deviation Event with Excess Emissions on 03/18/2022 Bicent (California) Malburg LLC, SCAQMD Facility ID 155474

Dear Mr. Fielding:

Attached is Form 500-N for a March 18, 2022 deviation event resulting in excess emissions of ammonia at Bicent (California) Malburg LLC, Facility ID 155474. Supporting documentation is also provided, where warranted.

Please note that this facility was sold to the City of Vernon, Vernon Public Utilities (VPU) on December 14, 2021. Accordingly, a change of ownership application was submitted to the SCAQMD on December 17, 2021. Per direction provided by Ms. Vicky Lee, VPU will continue to use Facility ID 155474 for SCAQMD reporting until a new Facility ID and Title V Permit to Operate are issued.

Please contact Michael Bonfiglio at (323) 583-8811 ext. 307 (email address: <u>MBonfiglio@cityofvernon.org</u>) or Elyse Engel at (702) 354-2648 (email address: <u>Elyse.Engel@jacobs.com</u>) if you have any questions or if you need additional information.

Sincerely,

Abraham Alemy

Abraham Alemu General Manager of Vernon Public Utilities

Encl: Form 500-N Attachment A – Additional Form 500-N Descriptions Attachment B – Ammonia Calculations and Compliance Demonstration

Exclusively Industrial

cc: Todd Dusenberry Lisa Umeda Rich Olsen Matt Richards Michael Bonfiglio Jessica Balandran Elyse Engel Document Control

	South Coast A Form 50 Title V "This written r calling AQMD	tir Quality Management District DO-N Deviations, Emerger report is <u>in addition to</u> requirements to at 1-800-288-7664 (1-800-CUT-SMOG)	verbally report certain types of incidents. Verba	I reports may be made by	SCAQMD- Compliance 8 P Diamond Bar, CA Tel: (9 w	Mail To Enforceme .O. Box 494 91765-094 09) 396-338 ww.aqmd.gr	
Sectio	n I - Operator	Information		The second second			
1. Facil	ity Name (Business	Name of Operator That Appears On Pe	rmit): 2. Val	id AQMD Facility ID (Avail	able On Permit Or Invoice	a Issued By	
Bic	ent (California	a) Malburg LLC	AQ	MD):	155474		
3 Addr		4963 S Soto Street					
(whe	re incident occurred)		Street Address				
		Vernon		CA	90058		
			City	State	Zip		
4. Maili	ng Address:	4305 Santa Fe Avenue					
(if dif	ferent from Item 3)		Street Address				
		Vernon		CA	90058		
5. Prov	ide the name, title,	and phone number of the person to c	City contact for further information:	State	Zip		
	Mic	chael Bonfiglio	Operations Manager	(5)	26) 298-2253		
		Name	Title	(0.	Phone #		
Sectio	on II - Reporting	g of Breakdowns, Deviations,	and Emergencies				
1. This	written notification	is to report a(n):					
Тур	e of Incident	COLUMN AND ST	Verbal Report Due*	Written Report Due			
a. [Emergency under	er Rule 3002(g)	Within 1 hour of discovery	ys from when the emission limit was			
b. Breakdown under: Rule 430 (Non-RECLAIM) Rule 2004 (RECLAIM) Rule 218 (Non-RECLAIM)			For Rules 430 & 2004 - Within 1 hour of discovery. For Rule 218 – Within 24 hours or next busine day for failure/shutdown exceeding 24 hours	For Rules 430 & 200 breakdown is correc start of the breakdow granted. SS For Rule 218 - With	04 - Within 7 calendar days after cted, but no later than 30 days from wn, unless a written extension is n required semi-annual reports.		
c. Deviation with excess emissions [See Title V Permit, Section K, Condition No. 22B]			Within 72 hours of discovery of the deviation o shorter reporting period if required by an applicable State or Federal Regulation.	r Within 14 days of dis	Within 14 days of discovery of the deviation.		
d. [Other Deviation [See Title V Perm	nit, Section K, Condition Nos. 22D & 23	None	With required semi-a	annual monitoring reports.	b.	
2 The	in eldent was first d	caitlin McCarty	-	04/19/2022	02.01	0.44	
2. 110	incluent was inst u	iscovered by:	Name Off	Date	Time	• PM	
3 The	incident was first re	ported by: Operator #4	00	04/22/2022	08:33	• AM	
J. 11101	incluent was instru	Name	of AQMD Staff Person	Date	Time	O PM	
a. (Via Phone						
b. (In Person		Notification Numb	er (Required): 696804	4		
4. Whe	n did the incident a	ctually occur? 03/18/202	2 06:00 O AM				
	Received By:		Assigned By:	Inspector:			
	Date/Time Receive	d:	Date/Time Assigned:	Date/Time R	Date/Time Received Assignment:		
AOMD	Date Delivered To	Team:	Date Reviewed Inspector Report:	Date Inspect	ted Facility:		
USE	Team:	Sector:	Breakdown/Deviation Notification No.	Date Comple	eted Report:		
	Recommended Act Final Action:	tion: Cancel Notification Gra Cancel Notification Gra	ant Relief Issue NOV No	Other: Other:			

© South Coast Air Quality Management District, Form 500-N (2014.07)

5	Has the incident stopped? a Yes on	03/18/2022	07:00	O AM	h O No	
5.	a to, on.	Date	Tin	me 🔇 PM	0.0110	
6.	What was the total duration of the incident?	0	0	1		
-	-	Days	Но	ours		
7.	For equipment with an operating cycle, as define when was the end of the operating cycle during	which the incident occurred?			1000	O AM
8.	Describe the incident and identify each piece of equipment and attach additional pages as neces See Attachment A.	equipment (by permit, application ssary.	, or device number) affe	Date ected. Attach photos	Time (when available) of	C PM the affected
9	The incident may have resulted in a					
0.	a. X Violation of Permit Condition(s):	195.4				
	h Violation of AOMD Rule(s)					
10.	What was the probable cause of the incident? A	Attach additional pages as necess	ary.			
	See Attachment A.					
11.	Did the incident result in excess emissions?	O No O Yes (Complete the fo	llowing and attach calculation	ations.)		
	UVOClbs	NOxlbs	SOx	lbs	H2S	lbs
		PM lbs	X Other: 1	.59 Ibs	NH3	pollutant
12.	For RECLAIM facilities Subject to Rule 2004 (i)(3 when determining compliance with your annual	3) ONLY: If excess emissions of N I allocations?	Ox and/or SOx were rep	ported in Item 11, do	you want these emis	sions to be counted
	a. C Yes, for: NOx SOx	b. O No, for: NOx SO:	¢			
	If box 12(b) above is checked, include all information	on specified in Rule 2004(i)(3)(B) and	(C), as applicable.			
13.	Describe the steps taken to correct the problem avoid future incidents. Include photos of the fail	n (i.e., steps taken to mitigate exce iled equipment if available and atta	ss emissions, equipmer ch additional pages as	nt repairs, etc.) and the necessary.	e preventative mea	sures employed to
	See Attachment A.					
14	Was the facility operating properly prior to the in	incident?				
14.	a. • Yes b. O No, because:					
15.	Did the incident result from operator error, negle	lect or improper operation or main	tenance procedures?			
	a. • Yes b. O No, because:					
16.	Has the facility returned to compliance?					
	a. O No, because:					
	b. • Yes (Attach evidence such as emissions cal	alculations, contemporaneous operati	ng logs or other credible	evidence.)		
Se	ction III - Certification Statement					
Ice	ertify under penalty of law that based on informati	tion and belief formed after reason	able inquiry, the statem	ents and information	in this document ar	nd in all attachments
and	other materials are true, accurate, and complete	θ.				
For	Title V Facilities ONLY: I also certify under	er penalty of law that that I am the	responsible official for	this facility as define	d in AQMD Regulation	on XXX.
1. 5	Signature of Responsible Official:		2. Title of Responsible	Official:		
	Abraham Ale	mu	Genera	al Manager of V	ernon Public	Utilities
3. F	Print Name:		4. Date:	1 1		
	Abraham Alem	nu	5	1/2/202	-2	
5. F	Phone #:		6. Fax #:			
	(323) 583-881	1				
7.	Address of Responsible Official:					
	4305 Santa Fe Ave	enue	Vernon	C	A g	90058
Stre	et #	City		Sta	te Zip	

© South Coast Air Quality Management District, Form 500-N (2014.07)

Attachment A: Additional Form 500-N Descriptions

This attachment presents additional information regarding the ammonia (NH₃) excess emissions event which occurred on March 18, 2022, as prompted by Form 500-N.

8. Describe the incident and identify each piece of equipment (by permit, application, or device number) affected. Attach photos (when available) of the affected equipment and attach additional pages as necessary.

For the hour of 06:00 PM through 07:00 PM on March 18, 2022, the Selective Catalytic Reduction (SCR) System for Gas Turbine No. 1 (Device IDs C33 and D27, respectively) emitted NH₃ at 7.26 parts per million by volume (ppmv). This is in excess of the hourly 5 ppmv limit established in Title V Permit, Section D, Condition No. A195.4. NH₃ emissions returned to compliance with the 07:00 PM to 08:00 PM hour.

10. What was the probable cause of the incident? Attach additional pages as necessary.

On March 18, 2022, the facility was in a 1x1 configuration with only Gas Turbine No. 1 (Device ID D27) operating. At the start of the 06:00 PM hour on March 18, 2022, Gas Turbine No. 1 (Device ID D27) was operating at a load of 20 megawatts (MW) and was quickly brought up to a load of 46 MW. To address a momentary spike of oxides of nitrogen (NO_x) following this load change, the Plant Operator switched the Flow Control Valve (FCV) to Manual with the intent of quickly driving down NO_x by directly controlling the NH₃ flow through the SCR System (Device ID C33). The FCV was inadvertently left in Manual after NO_x emissions had stabilized, which led to an over-injection of NH₃. The FCV was returned to Auto at approximately 07:00 PM, which reduced the fuel flow and brought the NH₃ slip back under 5 ppmv.

11. Did the incident result in excess emissions?

As documented in Form 500-N, the event did result in 1.59 pounds of excess NH_3 emissions. Calculations are provided in Attachment B.

13. Describe the steps taken to correct the problem (i.e., steps taken to mitigate excess emissions, equipment repairs, etc.) and the preventative measures employed to avoid future incidents. Include photos of the failed equipment if available and attach additional pages as necessary.

The problem was corrected by returning the FCV to Auto, as described in response to Item 10 above. To avoid similar incidents in the future, Plant Operators will be receiving refresher training on use of the FCV and the NH₃ control loop will be assessed and retuned for increased responsiveness, if needed.

16. Has the facility returned to compliance?

As documented in Form 500-N, the facility has returned to compliance. Demonstration of this return to compliance is provided in Attachment B.

Attachment B: Ammonia Calculations and Compliance Demonstration

Malburg Generating Station, Facility ID 155474 Gas Turbine No. 1 NH₃ Emission Calculations

Date of Data: March 18, 2022 Submital Date: April 28, 2022

Excess Emissions Mass Determination

Title V Permit Condition No. A195.4: NH₃ concentration will not exceed 5 ppmv averaged over 1 hour.

Calculation Methodology:

 $\begin{array}{l} ppmv_{Exceedance} = ppmv_{NH3} - ppmv_{Limit} \\ \dot{m}_{NH3} = \left(ppmv_{NH3} \ / \ 10^6\right) \times \left(MW_{NH3} \ / \ MW_{flue \ gas}\right) \times \dot{m}_{flue \ gas} \ dry \\ \dot{m}_{Exceedance} = \left(ppmv_{Exceedance} \ / \ 10^6\right) \times \left(MW_{NH3} \ / \ MW_{flue \ gas}\right) \times \dot{m}_{flue \ gas} \ dry \end{array}$

Constants:

ppmv _{Limit}	5	ppmv	
MW flue gas	29.303	lb/lb-mol	
MW NH3	17.03	lb/lb-mol	

		DAH	Calculation of NH ₃ Emissions	Calculation of NH ₃ Emissions Exceedance		
Date	Time	ppmv _{NH3}	ṁ _{flue gas dry} (lb/hr)	NO _x ppmvdc	ḿ _{NH3} (lb/hr)	m _{Exceedance} (lb/hr)
3/18/2022	15:00	2.24	732,455	1.83	N/A	0.00
3/18/2022	16:00	2.94	855,277	1.78	N/A	0.00
3/18/2022	17:00	1.82	1,092,421	1.83	N/A	0.00
3/18/2022	18:00	7.66	1,025,463	1.03	4.565	1.59
3/18/2022	19:00	0.00	974,178	1.78	N/A	0.00
3/18/2022	20:00	1.51	926,573	1.78	N/A	0.00
3/18/2022	21:00	2.39	1,049,610	1.78	N/A	0.00

Return to Compliance

As shown in the table above, the NH_3 concentration returns to below the 5 ppmv limit of Condition No. A195.4 immediately following the 18:00 hour. As shown in the table above, the NO_x concentration does not exceed the 2 ppmvdc limit of Condition No. A99.6 during this time period.



4305 Santa Fe Avenue, Vernon, California 90058 Telephone (323) 583-8811

June 8, 2022

SCAQMD – Compliance & Enforcement P.O. Box 4941 Diamond Bar, CA 91765-0941 Attn: Christian Fielding

Subject:Form 500-N for Deviation Event with Excess Emissions on 05/26/2022Vernon Public Utilities, SCAQMD Facility ID 195802

Dear Mr. Fielding:

Attached is Form 500-N for a May 26, 2022, deviation event resulting in excess emissions of ammonia at Vernon Public Utilities, Facility ID 195802. Supporting documentation is also provided, where warranted.

Please contact Michael Bonfiglio at (323) 583-8811 ext. 307 (email address: <u>MBonfiglio@cityofvernon.org</u>) or Elyse Engel at (702) 354-2648 (email address: <u>Elyse.Engel@jacobs.com</u>) if you have any questions or if you need additional information.

Sincerely,

Abraham Alemu

Abraham Alemu General Manager of Vernon Public Utilities

Encl: Form 500-N

Attachment A – Additional Form 500-N Descriptions Attachment B – Ammonia Calculations and Compliance Demonstration

cc: Todd Dusenberry Lisa Umeda Rich Olsen Matt Richards Michael Bonfiglio Jessica Balandran Elyse Engel

Exclusively Industrial

South C AQN	South Coast A Form 50 Title V "This written r calling AQMD	ir Quality Management District DO-N Deviations, Emergen report is <u>in addition to</u> requirements to v at 1-800-288-7664 (1-800-CUT-SMOG) of	cies & Breakdowns erbally report certain types of incidents. Verbal report AQMD enforcement personnel.	ports may be made by	SCAQMD- Compliance Diamond Bar, Tel:	Mail T & Enforceme P.O. Box 494 CA 91765-094 (909) 396-333 www.aqmd.go	
Sectio	on I - Operator	Information					
1. Faci	lity Name (Business	Name of Operator That Appears On Perr	nit): 2. Valid A	QMD Facility ID (Availa	able On Permit Or Invo	ice Issued By	
Ve	rnon Public U	tilities	AQMD)	·	195802		
3. Addı	ress:	4963 S Soto Street					
(whe	re incident occurred)		Street Address				
		Vernon		CA	90058		
			City	State	Zip		
4. Maili	ing Address:	4305 Santa Fe Avenue					
(if dif	ferent from Item 3)		Street Address	-			
		Vernon	0.1		90058		
5. Prov	ide the name, title,	and phone number of the person to co	ntact for further information:	State	Zip		
	вла	had Danfielia	Operations Manager	(57	01 200 2252		
	IVIIC	Name		(52	Phone #		
Sectio	n II - Reporting	of Breakdowns Deviations	and Emergencies	and the second second			
1 This	written notification	is to report a(n):					
Tvn	e of Incident	is to report a(ii).	Verbal Report Due*	Written Report Due		4	
1) P		- Dula 2002(a)	Within 1 hour of discovery	Within 2 working day	e from when the omice	ion limit was	
a. [Emergency unde	r Rule 3002(g)	within a node of discovery	exceeded.	ad.		
b. [Breakdown unde Rule 430 (M Rule 2004 (F Rule 218 (M (See Rule 2	r: on-RECLAIM) RECLAIM) on-RECLAIM) 18(f)(3)]	For Rules 430 & 2004 - Within 1 hour of discovery. For Rule 218 – Within 24 hours or next business day for failure/shutdown exceeding 24 hours	For Rules 430 & 200 breakdown is correct start of the breakdow granted. For Rule 218 - With r	4 - Within 7 calendar d ed, but no later than 3 n, unless a written ext equired semi-annual n	ays after) days from ension is eports.	
C. [Deviation with ex [See Title V Perm	cess emissions nit, Section K, Condition No. 22B]	Within 72 hours of discovery of the deviation or shorter reporting period if required by an applicable State or Federal Regulation.	Within 14 days of dis	covery of the deviatior		
d. [Other Deviation [See Title V Perm	nit, Section K, Condition Nos. 22D & 23]	None	With required semi-a	nnual monitoring repo	ts.	
		Mark Vooman		05/27/2022	05.49	~	
2. The	incident was first di	iscovered by: Wark Yeaman	0N	00/2/72022 Date			
		Operator #0	Tuno	05/07/0000	02.04	0	
3. The	incident was first re	ported by: Operator #9 Name r	of AOMD Staff Person	Date		O AM	
a. (Via Phone			701655	5	0	
4. Whe	n did the incident a	ctually occur?05/26/2022 Date	2 03:00 C AM Time © PM	(Kequirea).			
	Received By:		Assigned By:	Inspector:		31722	
	Date/Time Receive	d:	Date/Time Assigned:	Date/Time R	e Received Assignment:		
AOMO	Date Delivered To	Team:	Date Reviewed Inspector Report:	Date Inspect	ed Facility:	100	
USE	Team:	Sector:	Breakdown/Deviation Notification No.	Date Comple	ted Report:		
UNIT I	Recommended Act	ion: Cancel Notification Gra	nt Relief Issue NOV No	Other:			
	Final Action:	Cancel Notification Gran	nt Relief Issue NOV No	Other:			

© South Coast Air Quality Management District, Form 500-N (2014.07)

5.	Has the incident stopped? a. (•)	Yes. on: 0	5/26/2022		04:00	O AM	b. O No	
			Date		Time	• PM		
6.	What was the total duration of the in	cident?	0		01	_		
7.	For equipment with an operating cyc	le, as defined in Rule 430	Days (b)(3)(A),		Hours			O AM
	when was the end of the operating c	ycle during which the inc	dent occurred?		Date		Time	O PM
8.	equipment and attach additional pages of the Attachment A.	ich pièce of equipment (b) es as necessary.	y permit, application	, or device number) affected. At	ach photos (wh	ien available) of tr	e affected
9.	The incident may have resulted in a: a. X Violation of Permit Condition(s)	Section D, C	ondition No. A	.195.4				
10.	 b. Violation of AQMD Rule(s): What was the probable cause of the See Attachment A. 	incident? Attach addition	al pages as necess	ary.				
11.	Did the incident result in excess emi	ssions? 🔿 No 💿	Yes (Complete the fo	llowing and attach c	alculations.)			
		NOx	lbs	SOx _		lbs	H2S	lbs
	COlbs	□ PM	lbs	X Other:	0.	060 Ibs NH	-13	pollutant
13. 14. 15. 16.	If box 12(b) above is checked, include a Describe the steps taken to correct to avoid future incidents. Include photo See Attachment A. Was the facility operating properly p a. • Yes b. No, becau Did the incident result from operator a. • Yes b. No, becau Has the facility returned to complian a. • No, because: b. • Yes (Attach evidence such as e	all information specified in F he problem (i.e., steps tal is of the failed equipment rior to the incident? ise: error, neglect or imprope ise: ce?	r operation or maint	(C), as applicable. Is emissions, equip ch additional pages enance procedures ng logs or other cred	oment repairs, s as necessary s? ible evidence.)	etc.) and the pr	reventative measu	res employed to
0.0	b. Tes (Allachievidence such as e	ant acculations, cone						
Ice	rtify under penalty of law that based of	ent on information and belief f	ormed after reasona	ble inquiry, the sta	tements and i	nformation in th	his document and	in all attachments
and	other materials are true, accurate, an	d complete.	ut that that I am the	responsible official	for this facilit	v as defined in		***
1.9	innature of Responsible Official	certify under penalty of la	m that that i an the	2 Title of Respons	ible Official	y as defined in .	A CIMP Regulation	~~~.
1.0	Abraham S	Alemy		Gen	eral Mana	ger of Verr	non Public U	tilities
3. P	rint Name: Abraha	am Alemu		4. Date:	18/2	022		
5. P	hone#:			6. Fax #:				
	(323) 5	583-8811						
7. A	ddress of Responsible Official:	-						
Stree	4305 Santa	Fe Avenue	City	Vern	on	CA State	- <u>90</u>	058
Juci			Oily			ototo		

© South Coast Air Quality Management District, Form 500-N (2014.07)

Attachment A: Additional Form 500-N Descriptions

This attachment presents additional information regarding the ammonia (NH₃) excess emissions event which occurred on May 26, 2022, as prompted by Form 500-N.

8. Describe the incident and identify each piece of equipment (by permit, application, or device number) affected. Attach photos (when available) of the affected equipment and attach additional pages as necessary.

For the hour of 03:00 PM through 03:59 PM on May 26, 2022, the Selective Catalytic Reduction (SCR) System for Gas Turbine No. 2 (Device IDs C41 and D36, respectively) emitted NH_3 at 5.16 parts per million by volume (ppmv). This is in excess of the hourly 5 ppmv limit established in Title V Permit, Section D, Condition No. A195.4. NH_3 emissions returned to compliance with the 04:00 PM to 04:59 PM hour.

10. What was the probable cause of the incident? Attach additional pages as necessary.

On May 26, 2022, the facility initiated a warm start on Gas Turbine No. 2 (Device ID D36) at 01:05 PM. The startup event ended at 02:35 PM with the facility in a 1x1 configuration. Only Gas Turbine No. 2 was operating at this time because the facility was conducting several quality assurance checks (e.g., flame tuning the turbine, vibration analysis, etc.) following replacement of the catalyst in the Selective Catalytic Reduction (SCR) System (Device ID C41). Flame tuning, in particular, requires the turbine to be operating at a load above 20 megawatts (MW) with an active SCR System. The rate at which the load was increased as a part of the tuning process was not consistent with typical load ramping operations. The operating conditions required during flame tuning are similarly not consistent with normal operation and are part of the process of tuning the SCR System with the new catalyst. Results from this exercise have allowed the site to appropriately establish operating parameters consistent with the new catalyst. During the flame tuning, the Plant Operator determined that the NH₃ slip exceeded the limit of 5 ppmv averaged over 1 hour. As a result, tuning was temporarily stopped until the system had stabilized. The NH₃ slip was back under 5 ppmv starting at 04:00 PM and tuning activities resumed.

11. Did the incident result in excess emissions?

As documented in Form 500-N, the event did result in 0.06 pounds of excess NH₃ emissions. Calculations are provided in Attachment B.

13. Describe the steps taken to correct the problem (i.e., steps taken to mitigate excess emissions, equipment repairs, etc.) and the preventative measures employed to avoid future incidents. Include photos of the failed equipment if available and attach additional pages as necessary.

The problem was corrected by ceasing the tuning operations when the exceedance was identified, thereby allowing the SCR System on Gas Turbine No. 2 to stabilize. Further excess emissions were mitigated through continued monitoring of the NH₃ slip concentrations with more gradual system adjustments during the remaining flame tuning and other quality assurance checks. Similar incidents are not expected in the future, as this was a one-time occurrence associated with testing of the new SCR System catalyst.

16. Has the facility returned to compliance?

As documented in Form 500-N, the facility has returned to compliance. Demonstration of this return to compliance is provided in Attachment B.

Attachment B: Ammonia Calculations and Compliance Demonstration

Malburg Generating Station, Facility ID 195802 Gas Turbine No. 2 NH₃ Emission Calculations

Date of Data: May 26, 2022

Excess Emissions Mass Determination

Title V Permit Condition No. A195.4: NH₃ concentration will not exceed 5 ppmv averaged over 1 hour.

Calculation Methodology:

 $\begin{array}{l} ppmv_{Exceedance} = ppmv_{NH3} - ppmv_{Limit} \\ \dot{m}_{NH3} = (ppmv_{NH3} / 10^6) \times (MW_{NH3} / MW_{flue \, gas}) \times \dot{m}_{flue \, gas \, dry} \\ \dot{m}_{Exceedance} = (ppmv_{Exceedance} / 10^6) \times (MW_{NH3} / MW_{flue \, gas}) \times \dot{m}_{flue \, gas \, dry} \end{array}$

Constants:

ppmv _{Limit}	5	ppmv	
MW flue gas	29.303	lb/lb-mol	
MW NH3	17.03	lb/lb-mol	

DAHS Data					Calculation of NH ₃ Emissions	Calculation of NH ₃ Emissions Exceedance
						ṁ _{Exceedance} (lb/hr)
Date	Time	ppmv _{NH3}	ṁ _{flue gas dry} (lb/hr)	NO _X ppmvdc	m _{NH3} (lb/hr)	Methodology
5/26/2022	15:00	5.16	657,313	1.80	1.97	0.06
5/26/2022	16:00	3.96	665,258	1.70	N/A	0.00
5/26/2022	17:00	1.66	725,351	1.70	N/A	0.00
5/26/2022	18:00	1.41	857,601	1.80	N/A	0.00
5/26/2022	19:00	2.76	911,541	1.80	N/A	0.00

Return to Compliance

As shown in the table above, the NH_3 concentration returns to below the 5 ppmv limit of Condition No. A195.4 immediately following the 15:00 hour. As shown in the table above, the NO_x concentration does not exceed the 2 ppmvdc limit of Condition No. A195.5 during this time period.