

DOCKETED

Docket Number:	01-AFC-25C
Project Title:	Malburg Generating Station-Compliance
TN #:	247068
Document Title:	Malburg Generating Station Quarterly Compliance Report Q3 2022
Description:	N/A
Filer:	Elyse Engel
Organization:	Jacobs Engineering Group Inc.
Submitter Role:	Applicant
Submission Date:	10/28/2022 9:13:19 AM
Docketed Date:	10/28/2022



4305 Santa Fe Avenue, Vernon, California 90058
Telephone (323) 583-8811

October 28, 2022

Dr. Anwar Ali
Compliance Project Manager
Siting, Transmission and Environmental Protection Division
Compliance Monitoring and Enforcement Office
California Energy Commission
715 P Street
Sacramento, CA 95814
anwar.ali@energy.ca.gov

Subject: 2022 Q3 Compliance Report
July 1, 2022 through September 30, 2022
Malburg Generating Station (01-AFC-25C)

Dr. Ali,

Attached please find the Quarterly Compliance Report for the Malburg Generating Station (01-AFC-25C), covering the operational period of July 1, 2022 through September 30, 2022. This report addresses all quarterly requirements identified in the Final Commission Decision for the Malburg Generating Station (TN #28746), as most recently amended on June 20, 2019 by the Errata to Staff Analysis of Petition to Amend the Final Commission Decision (TN #228444).

If you have any questions or need more information, please contact Matt Richards, Utilities Operations Manager, at MRichards@cityofvernon.org or (323) 583-8811 x378.

Sincerely,

Rich Olsen
Assistant General Manager of Generation & Operations
City of Vernon, Public Utilities Department

Enclosure: MGS 2022 Q3 Compliance Report

Exclusively Industrial


Malburg Generating Station Quarterly Compliance Report (Third Quarter 2022)

Submitted to
California Energy Commission

Submitted by
City of Vernon, Public Utilities Department

October 28, 2022

Document no: 221013134746644
Revision no: 0



Contents

Acronyms and Abbreviations.....	v
1. Introduction	1
1.1 Project Location and Description.....	1
1.2 Organization of the Quarterly Compliance Report	1
2. Required Quarterly Compliance Report Documentation.....	1

Appendices

A	MGS Emission Calculations
B	Cooling Tower Blowdown Reports
C	Operation Logs
D	Diesel Fuel Oil Purchase Records
E	Excess Emission Reports

Table

2-1	Required Quarterly Compliance Report Documentation	1
-----	--	---

Acronyms and Abbreviations

CEC	California Energy Commission
CEMS	continuous emissions monitoring system
CO	carbon monoxide
COC	Conditions of Certification
CTG	combustion turbine generator
DAHS	data acquisition and handling system
gr/scf	grains per standard cubic foot
HRSG	heat recovery steam generator
lb/day	pounds per day
lb/hr	pounds per hour
MGS	Malburg Generating Station
NH ₃	ammonia
NO _x	nitrogen oxides
PM ₁₀	particulate matter with an aerodynamic diameter less than or equal to 10 microns
PM _{2.5}	particulate matter with an aerodynamic diameter less than or equal to 2.5 microns
ppm	parts per million
ppmv	parts per million by volume
ppmw	parts per million by weight
QCR	Quarterly Compliance Report
SCAQMD	South Coast Air Quality Management District
SO _x	sulfur oxides
STG	steam turbine generator
TDS	total dissolved solids
VOC	volatile organic compound

1. Introduction

This Quarterly Compliance Report (QCR) has been prepared to meet the California Energy Commission's (CEC) quarterly reporting requirements for the Malburg Generating Station (MGS). This QCR fulfills various Conditions of Certification (COC) described in the CEC's Final Commission Decision for the MGS (TN #28746), as most recently amended on June 20, 2019 by the Errata to Staff Analysis of Petition to Amend the Final Commission Decision (TN #228444).

1.1 Project Location and Description

The MGS is located at 4963 S Soto Street in Vernon, California. The property is approximately 3.4 acres in size, located in an industrial land use area near the geographic center of metropolitan Los Angeles County. MGS consists of two Siemens SGT-800 frame type natural gas combustion turbine generators (CTGs), two associated natural gas combustion duct burners, two heat recovery steam generators (HRSGs), a steam turbine generator (STG), a cooling tower, a diesel-fired emergency firewater pump, and support equipment.

The commissioning of MGS was completed in October 2005 and the power plant began commercial operation on October 17, 2005.

1.2 Organization of the Quarterly Compliance Report

A summary of the compliance demonstration for each applicable COC is provided in Section 2 and includes references to Appendices and Tables as appropriate.

2. Required Quarterly Compliance Report Documentation

COC requirements associated with this QCR are summarized in the table below.

Table 2-1. Required Quarterly Compliance Report Documentation

Condition of Certification	Response
AQ-C6	The weekly total dissolved solids (TDS) results for the third quarter of 2022 are provided in Appendix A, Table 2; the weekly sample reports collected for the same period are provided in Appendix B.
AQ-C7	Daily particulate matter with aerodynamic diameter less than or equal to 10 microns (PM ₁₀) emissions from cooling tower operation during the third quarter of 2022 are provided in Appendix A, Tables 3 through 5. As shown, emissions were below the specified limit of 6.2 pounds per day (lb/day).
AQ-C8	Testing times for the diesel-fired emergency firewater pump during the third quarter of 2022 are provided in Appendix C, Table 2. MGS refrained from testing the diesel-fired emergency firewater pump in the same hour the CTGs were either started or shutdown.
AQ-C9	The CTG startup and shutdown details for the third quarter of 2022, including the duration and date of occurrence, are provided in Appendix C, Table 1.
AQ-C11	All ammonia (NH ₃), nitrogen oxides (NO _x), sulfur oxides (SO _x), carbon monoxide (CO), PM ₁₀ , and volatile organic compound (VOC) emissions from MGS operation during the third quarter of 2022 are provided in Appendix A, Table 1.
AQ-2	Low sulfur diesel fuel was last purchased on April 11, 2022 (second quarter). The fuel purchase record is provided in Appendix D and demonstrates that the fuel does not contain sulfur compounds in excess of 15 parts per million by weight (ppmw).
AQ-3	See the response for COC AQ-2.

Malburg Generating Station Quarterly Compliance Report (Third Quarter 2022)

Condition of Certification	Response
AQ-5	Monthly emissions of CO, PM ₁₀ , particulate matter with an aerodynamic diameter less than or equal to 2.5 microns (PM _{2.5}), VOC, and SO _x from CTG and duct burner operation during the third quarter of 2022 are presented in Appendix A, Tables 7 through 9. Fuel usage for each turbine-duct burner pair is provided in Appendix A, Table 6. As shown, emissions were below the monthly limits specified in Condition A63.4 of the site's Title V Permit.
AQ-6	See the response for COC AQ-C9.
AQ-9	See the response for COC AQ-C11. Additionally, quarterly NO _x excess emission reports from the data acquisition and handling system (DAHS) are provided in Appendix E. As demonstrated in these reports, there were no incidents in which the maximum corrected NO _x emissions concentration for both CTGs exceeded the emission concentration limit of 2.0 parts per million by volume (ppmv). All continuous emissions monitoring system (CEMS) data for MGS' CTGs are stored electronically onsite.
AQ-10	See the response for COC AQ-C11. Additionally, quarterly CO excess emission reports from the DAHS are provided in Appendix E. As demonstrated in these reports, there were no incidents in which the maximum corrected CO emissions concentration for both CTGs exceeded the emission concentration limit of 2.0 ppmv. All CEMS data for MGS' CTGs are stored electronically onsite.
AQ-11	See the response for COC AQ-C11. Additionally, quarterly VOC excess emission reports from the DAHS are provided in Appendix E. As demonstrated in these reports, there were no incidents in which the maximum corrected VOC emissions concentration for both CTGs exceeded the emission concentration limit of 2.0 ppmv. All CEMS data for MGS' CTGs are stored electronically onsite.
AQ-12	See the response for COC AQ-C11. Additionally, compliance with the specified limit of 5 parts per million (ppm) is primarily demonstrated through annual or quarterly source testing. The most recent NH ₃ compliance source test, performed on July 29 and 30, 2022 with results submitted to the CEC on September 21, 2022, indicated compliance with the emission limits for both CTGs (0.6 ppm for CTG 1 and 0.5 ppm for CTG 2). NH ₃ emissions are also calculated via the CEMS on an hourly basis and confirmed to comply with the NH ₃ concentration limit of 5 ppm.
AQ-13	See the response for COC AQ-C11. Additionally, the most recent triennial compliance source test, performed in July 2022, indicated compliance with the Rule 475 particulate matter emission limits of 5 kilograms per hour (11 pounds per hour [lb/hr]) or 23 milligrams per cubic meter (0.01 grain per standard cubic foot [gr/scf]) for both CTGs (0.67 lb/hr and 0.0003 gr/scf for CTG1 and 1.83 lb/hr and 0.0007 gr/scf for CTG2).
AQ-14	See the response for COC AQ-2.
AQ-15	Quarterly hours of operation for the diesel-fired emergency firewater pump are provided in Appendix A, Table 10. As shown, the third quarter 2022 hours for maintenance and testing do not exceed 50 hours and the total operational hours do not exceed 200 hours.
AQ-27	See the response for COC AQ-5. As shown, fuel consumption per turbine-duct burner pair does not exceed the specified limit of 405 million cubic feet per month.
AQ-36	See the responses for COC AQ-5 and AQ-6.

Appendix A

MGS Emission Calculations



Malburg Generating Station
 Quarterly Compliance Report
 Appendix A, Table 1

Reporting Period: **Quarter 3 2022**

Table 1. Quarterly Emissions - July 1, 2022 through September 30, 2022

Source	Quarterly Emissions (lb/quarter)					
	NOx	CO	VOC	SOx	PM ₁₀ /PM _{2.5}	NH ₃
CTG 1 & Duct Burner	3,604	1,264	779	143	3,048	4,708
CTG 2 & Duct Burner	4,818	1,492	1,047	190	4,090	6,299
Cooling Tower	--	--	--	--	125	--
Diesel Firewater Pump	34.7	1.01	0.25	0.02	0.23	--
Total	8,456	2,756	1,826	333	7,263	11,007

Malburg Generating Station
 Quarterly Compliance Report
 Appendix A, Table 2

Reporting Period: **Quarter 3 2022**

Table 2. Cooling Tower Total Dissolved Solids (TDS) Sampling Results ¹

Sampling Period		TDS (ppm)
Start Date	End Date	
6/26/2022	7/2/2022	4,020
7/3/2022	7/9/2022	4,140
7/10/2022	7/16/2022	4,570
7/17/2022	7/23/2022	4,380
7/24/2022	7/30/2022	4,470
7/31/2022	8/6/2022	3,980
8/7/2022	8/13/2022	4,420
8/14/2022	8/20/2022	4,100
8/21/2022	8/27/2022	4,020
8/28/2022	9/3/2022	4,040
9/4/2022	9/10/2022	4,480
9/11/2022	9/17/2022	3,970
9/18/2022	9/24/2022	4,070
9/25/2022	10/1/2022	4,080

¹ Sampling results taken from Positive Lab's Weekly Cooling Tower Blowdown Reports, as provided in Appendix B of the QCR.

**Malburg Generating Station
Quarterly Compliance Report
Appendix A, Table 3**

Reporting Period: July 2022

Cooling Tower Total Dissolved Solids (TDS) Sampling Results

Data Source: Positive Lab's Weekly Cooling Tower Blowdown Reports, as provided in Appendix B of the QCR

Sample Date	Period Start Date	End Date	TDS (ppm)
6/28/2022	6/26/2022	7/2/2022	4,020
7/7/2022	7/3/2022	7/9/2022	4,140
7/11/2022	7/10/2022	7/16/2022	4,570
7/19/2022	7/17/2022	7/23/2022	4,380
7/25/2022	7/24/2022	7/30/2022	4,470
8/3/2022	7/31/2022	8/6/2022	3,980

Methodology (per Condition of Certification [COC] AQ-C7)

PM_{10} Emissions (lb/day) = Circulation Rate (gal/day) x Density of Water (lb/gal) x Total Dissolved Solids (ppm) / 1,000,000 x Drift Factor (%) / 100 x Correction Factor

Constants

Parameter	Value
Circulation Rate per Pump (gal/min) ¹	13,500
Number of Pumps	2
Total Circulation Rate (gal/min)	27,000
Water Density (lb/gal)	8.334
Drift Factor (%) ²	0.0005
Correction Factor (unitless) ³	0.2

¹ Source: M3-10 Main Circulating Water System P&ID.

² Per COC AQ-C4.

³ Source: SPX Cooling Technologies' Cooling Tower Drift Mass Distribution.

Cooling Tower Daily PM₁₀ Emissions

Date	Circulation Rate (gal/day) ¹	TDS (ppm)	PM ₁₀ Emissions (lb/day)	Above 6.2 lb/day PM ₁₀ Limit? ²
7/1/2022	38,880,000	4,020	1.30	No
7/2/2022	38,880,000	4,020	1.30	No
7/3/2022	38,880,000	4,140	1.34	No
7/4/2022	38,880,000	4,140	1.34	No
7/5/2022	38,880,000	4,140	1.34	No
7/6/2022	38,880,000	4,140	1.34	No
7/7/2022	38,880,000	4,140	1.34	No
7/8/2022	38,880,000	4,140	1.34	No
7/9/2022	38,880,000	4,140	1.34	No
7/10/2022	38,880,000	4,570	1.48	No
7/11/2022	38,880,000	4,570	1.48	No
7/12/2022	38,880,000	4,570	1.48	No
7/13/2022	38,880,000	4,570	1.48	No
7/14/2022	38,880,000	4,570	1.48	No
7/15/2022	38,880,000	4,570	1.48	No
7/16/2022	38,880,000	4,570	1.48	No
7/17/2022	38,880,000	4,380	1.42	No
7/18/2022	38,880,000	4,380	1.42	No
7/19/2022	38,880,000	4,380	1.42	No
7/20/2022	38,880,000	4,380	1.42	No
7/21/2022	38,880,000	4,380	1.42	No
7/22/2022	38,880,000	4,380	1.42	No
7/23/2022	38,880,000	4,380	1.42	No
7/24/2022	38,880,000	4,470	1.45	No
7/25/2022	38,880,000	4,470	1.45	No
7/26/2022	38,880,000	4,470	1.45	No
7/27/2022	38,880,000	4,470	1.45	No
7/28/2022	38,880,000	4,470	1.45	No
7/29/2022	38,880,000	4,470	1.45	No
7/30/2022	38,880,000	4,470	1.45	No
7/31/2022	38,880,000	3,980	1.29	No

¹ Maximum daily circulation rate conservatively used to estimate PM₁₀ emissions when the cooling tower is operated for any part of the day. Circulation rate is zero for days the cooling tower is not operated at all.

² Daily emissions limit established in COC AQ-C7.

**Malburg Generating Station
Quarterly Compliance Report
Appendix A, Table 4**

Reporting Period: **August 2022**

Cooling Tower Total Dissolved Solids (TDS) Sampling Results

Data Source: Positive Lab's Weekly Cooling Tower Blowdown Reports, as provided in Appendix B of the QCR

Sample Date	Period Start Date	End Date	TDS (ppm)
8/3/2022	7/31/2022	8/6/2022	3,980
8/8/2022	8/7/2022	8/13/2022	4,420
8/15/2022	8/14/2022	8/20/2022	4,100
8/23/2022	8/21/2022	8/27/2022	4,020
8/29/2022	8/28/2022	9/3/2022	4,040

Methodology (per Condition of Certification [COC] AQ-C7)

PM_{10} Emissions (lb/day) = Circulation Rate (gal/day) x Density of Water (lb/gal) x Total Dissolved Solids (ppm) / 1,000,000
x Drift Factor (%) / 100 x Correction Factor

Constants

Parameter	Value
Circulation Rate per Pump (gal/min) ¹	13,500
Number of Pumps	2
Total Circulation Rate (gal/min)	27,000
Water Density (lb/gal)	8.334
Drift Factor (%) ²	0.0005
Correction Factor (unitless) ³	0.2

¹ Source: M3-10 Main Circulating Water System P&ID.

² Per COC AQ-C4.

³ Source: SPX Cooling Technologies' Cooling Tower Drift Mass Distribution.

Cooling Tower Daily PM₁₀ Emissions

Date	Circulation Rate (gal/day) ¹	TDS (ppm)	PM ₁₀ Emissions (lb/day)	Above 6.2 lb/day PM ₁₀ Limit? ²
8/1/2022	38,880,000	3,980	1.29	No
8/2/2022	38,880,000	3,980	1.29	No
8/3/2022	38,880,000	3,980	1.29	No
8/4/2022	38,880,000	3,980	1.29	No
8/5/2022	38,880,000	3,980	1.29	No
8/6/2022	38,880,000	3,980	1.29	No
8/7/2022	38,880,000	4,420	1.43	No
8/8/2022	38,880,000	4,420	1.43	No
8/9/2022	38,880,000	4,420	1.43	No
8/10/2022	38,880,000	4,420	1.43	No
8/11/2022	38,880,000	4,420	1.43	No
8/12/2022	38,880,000	4,420	1.43	No
8/13/2022	38,880,000	4,420	1.43	No
8/14/2022	38,880,000	4,100	1.33	No
8/15/2022	38,880,000	4,100	1.33	No
8/16/2022	38,880,000	4,100	1.33	No
8/17/2022	38,880,000	4,100	1.33	No
8/18/2022	38,880,000	4,100	1.33	No
8/19/2022	38,880,000	4,100	1.33	No
8/20/2022	38,880,000	4,100	1.33	No
8/21/2022	38,880,000	4,020	1.30	No
8/22/2022	38,880,000	4,020	1.30	No
8/23/2022	38,880,000	4,020	1.30	No
8/24/2022	38,880,000	4,020	1.30	No
8/25/2022	38,880,000	4,020	1.30	No
8/26/2022	38,880,000	4,020	1.30	No
8/27/2022	38,880,000	4,020	1.30	No
8/28/2022	38,880,000	4,040	1.31	No
8/29/2022	38,880,000	4,040	1.31	No
8/30/2022	38,880,000	4,040	1.31	No
8/31/2022	38,880,000	4,040	1.31	No

¹ Maximum daily circulation rate conservatively used to estimate PM₁₀ emissions when the cooling tower is operated for any part of the day. Circulation rate is zero for days the cooling tower is not operated at all.

² Daily emissions limit established in COC AQ-C7.

**Malburg Generating Station
Quarterly Compliance Report
Appendix A, Table 5**

Reporting Period: **September 2022**

Cooling Tower Total Dissolved Solids (TDS) Sampling Results

Data Source: Positive Lab's Weekly Cooling Tower Blowdown Reports, as provided in Appendix B of the QCR

Sample Date	Period Start Date	End Date	TDS (ppm)
8/29/2022	8/28/2022	9/3/2022	4,040
9/7/2022	9/4/2022	9/10/2022	4,480
9/13/2022	9/11/2022	9/17/2022	3,970
9/20/2022	9/18/2022	9/24/2022	4,070
9/27/2022	9/25/2022	10/1/2022	4,080

Methodology (per Condition of Certification [COC] AQ-C7)

PM_{10} Emissions (lb/day) = Circulation Rate (gal/day) x Density of Water (lb/gal) x Total Dissolved Solids (ppm) / 1,000,000 x Drift Factor (%) / 100 x Correction Factor

Constants

Parameter	Value
Circulation Rate per Pump (gal/min) ¹	13,500
Number of Pumps	2
Total Circulation Rate (gal/min)	27,000
Water Density (lb/gal)	8.334
Drift Factor (%) ²	0.0005
Correction Factor (unitless) ³	0.2

¹ Source: M3-10 Main Circulating Water System P&ID.

² Per COC AQ-C4.

³ Source: SPX Cooling Technologies' Cooling Tower Drift Mass Distribution.

Cooling Tower Daily PM₁₀ Emissions

Date	Circulation Rate (gal/day) ¹	TDS (ppm)	PM ₁₀ Emissions (lb/day)	Above 6.2 lb/day PM ₁₀ Limit? ²
9/1/2022	38,880,000	4,040	1.31	No
9/2/2022	38,880,000	4,040	1.31	No
9/3/2022	38,880,000	4,040	1.31	No
9/4/2022	38,880,000	4,480	1.45	No
9/5/2022	38,880,000	4,480	1.45	No
9/6/2022	38,880,000	4,480	1.45	No
9/7/2022	38,880,000	4,480	1.45	No
9/8/2022	38,880,000	4,480	1.45	No
9/9/2022	38,880,000	4,480	1.45	No
9/10/2022	38,880,000	4,480	1.45	No
9/11/2022	38,880,000	3,970	1.29	No
9/12/2022	38,880,000	3,970	1.29	No
9/13/2022	38,880,000	3,970	1.29	No
9/14/2022	38,880,000	3,970	1.29	No
9/15/2022	38,880,000	3,970	1.29	No
9/16/2022	38,880,000	3,970	1.29	No
9/17/2022	38,880,000	3,970	1.29	No
9/18/2022	38,880,000	4,070	1.32	No
9/19/2022	38,880,000	4,070	1.32	No
9/20/2022	38,880,000	4,070	1.32	No
9/21/2022	38,880,000	4,070	1.32	No
9/22/2022	38,880,000	4,070	1.32	No
9/23/2022	38,880,000	4,070	1.32	No
9/24/2022	38,880,000	4,070	1.32	No
9/25/2022	38,880,000	4,080	1.32	No
9/26/2022	38,880,000	4,080	1.32	No
9/27/2022	38,880,000	4,080	1.32	No
9/28/2022	38,880,000	4,080	1.32	No
9/29/2022	38,880,000	4,080	1.32	No
9/30/2022	38,880,000	4,080	1.32	No

¹ Maximum daily circulation rate conservatively used to estimate PM₁₀ emissions when the cooling tower is operated for any part of the day. Circulation rate is zero for days the cooling tower is not operated at all.

² Daily emissions limit established in COC AQ-C7.

**Malburg Generating Station
Quarterly Compliance Report
Appendix A, Tables 6, 7, 8, & 9**

Reporting Period: **Quarter 3 2022**

Table 6. Monthly Turbine-Duct Burner Fuel Flow

Source	July		August		September	
	Fuel Flow (MMscf/month) ¹	Above 405 MMscf/month Limit? ²	Fuel Flow (MMscf/month) ¹	Above 405 MMscf/month Limit? ²	Fuel Flow (MMscf/month) ¹	Above 405 MMscf/month Limit? ²
CTG 1	139.6		205		152	
CTG 1 Duct Burner	3.40		3.71		3.63	
Total CTG 1 & Duct Burner	143	No	208	No	155	No
CTG 2	225		214		229	
CTG 2 Duct Burner	4.17		3.77		4.55	
Total CTG 2 & Duct Burner	229	No	217	No	233	No

¹ Fuel flow data obtained from 'U1/U2_MonthlySummary_MassEmissionsAndFuel' and 'ALL_12MonthSummary_GasUsage' RegPerfect Reports.

² Monthly fuel flow limit is per Condition of Certification (COC) AQ-27.

Table 7. Monthly Emissions - July 2022

Source	Monthly Emissions (lb/month) ¹					
	NO _x ²	CO	VOC	SO _x	PM ₁₀ /PM _{2.5}	NH ₃ ³
CTG 1 & Duct Burner	1,019	380	220	40	860	1,331
CTG 2 & Duct Burner	1,626	517	354	64	1,379	2,124
Monthly Emission Limits ⁴	N/A	7,633	3,236	227	4,876	N/A
Exceeds Limit?	N/A	No	No	No	No	N/A

¹ Unless otherwise noted, monthly emissions data obtained from 'U1/U2_MonthlySummary_MassEmissionsAndFuel' RegPerfect Report.

² Monthly NO_x emissions are as submitted to SCAQMD, based on the 'U1_U2MonthlyRECLAIMNOxSummaryByDay' RegPerfect Report.

³ Monthly NH₃ emissions are calculated using monthly fuel usage and default emission factors from the SCAQMD's AER AB 2588 Quadrennial Air Toxics Emission Inventory Procedures - June 2020. The emission factors are 9.1 lbs/MMscf and 18.0 lbs/MMscf for the CTGs and Duct Burners, respectively.

⁴ Monthly emission limits are per COC AQ-5.

Table 8. Monthly Emissions - August 2022

Source	Monthly Emissions (lb/month) ¹					
	NO _x ²	CO	VOC	SO _x	PM ₁₀ /PM _{2.5}	NH ₃ ³
CTG 1 & Duct Burner	1,478	515	321	59	1,254	1,930
CTG 2 & Duct Burner	1,557	495	335	61	1,308	2,013
Monthly Emission Limits ⁴	N/A	7,633	3,236	227	4,876	N/A
Exceeds Limit?	N/A	No	No	No	No	N/A

¹ Unless otherwise noted, monthly emissions data obtained from 'U1/U2_MonthlySummary_MassEmissionsAndFuel' RegPerfect Report.

² Monthly NO_x emissions are as submitted to SCAQMD, based on the 'U1_U2MonthlyRECLAIMNOxSummaryByDay' RegPerfect Report.

³ Monthly NH₃ emissions are calculated using monthly fuel usage and default emission factors from the SCAQMD's AER AB 2588 Quadrennial Air Toxics Emission Inventory Procedures - June 2020. The emission factors are 9.1 lbs/MMscf and 18.0 lbs/MMscf for the CTGs and Duct Burners, respectively.

⁴ Monthly emission limits are per COC AQ-5.

Table 9. Monthly Emissions - September 2022

Source	Monthly Emissions (lb/month) ¹					
	NOx ²	CO	VOC	SOx	PM ₁₀ /PM _{2.5}	NH ₃ ³
CTG 1 & Duct Burner	1,107	369	239	43.9	934	1,446
CTG 2 & Duct Burner	1,635	479	359	65.1	1,402	2,162
Monthly Emission Limits ⁴	N/A	7,633	3,236	227	4,876	N/A
Exceeds Limit?	N/A	No	No	No	No	N/A

¹ Unless otherwise noted, monthly emissions data obtained from 'U1/U2_MonthlySummary_MassEmissionsAndFuel' RegPerfect Report.

² Monthly NOx emissions are as submitted to SCAQMD, based on the 'U1_U2MonthlyRECLAIMNOxSummaryByDay' RegPerfect Report.

³ Monthly NH₃ emissions are calculated using monthly fuel usage and default emission factors from the SCAQMD's AER AB 2588 Quadrennial Air Toxics Emission Inventory Procedures - June 2020. The emission factors are 9.1 lbs/MMscf and 18.0 lbs/MMscf for the CTGs and Duct Burners, respectively.

⁴ Monthly emission limits are per COC AQ-5.

Malburg Generating Station
 Quarterly Compliance Report
 Appendix A, Table 10

Reporting Period: **Quarter 3 2022**

Methodology

Emissions (lb/month) = Fuel Usage (gal/month) / 1,000 (gal/Mgal) x Emission Factor (lb/Mgal)

Emission Factors

Pollutant	Emission Factor (lb/Mgal)	Reference
NOx	469	Emission factor provided in the facility's Title V Permit.
CO	13.62	Emission factor converted from the factor provided in the facility's Title V Permit (0.4 g/bhp-hr), based on the unit's power rating (173 hp) and maximum fuel throughput (11.2 gal/hr).
VOC	3.41	Emission factor converted from the factor provided in the facility's Title V Permit (0.1 g/bhp-hr), based on the unit's power rating (173 hp) and maximum fuel throughput (11.2 gal/hr).
SOx	0.21	Default for Diesel/Distillate Oil, ICEs given in the SCAQMD's Combustion Default Emission Factors - January 2022.
PM ₁₀ /PM _{2.5}	3.065	Emission factor converted from the factor provided in the facility's Title V Permit (0.09 g/bhp-hr), based on the unit's power rating (173 hp) and maximum fuel throughput (11.2 gal/hr).

Table 10. Monthly Diesel Fire Pump Hours of Operation, Fuel Usage, and Emissions

Month	Monthly Hours of Operation ¹			Fuel Usage (gal/month) ²	Monthly Emissions (lb/month)				
	Maintenance	Testing	Emergency		NOx	CO	VOC	SOx	PM ₁₀ /PM _{2.5}
January	0.0	2.5	0.0	28.0	13.1	0.38	0.10	0.01	0.09
February	0.0	2.0	0.0	22.4	10.5	0.31	0.08	0.00	0.07
March	0.0	2.0	0.0	22.4	10.5	0.31	0.08	0.00	0.07
April	0.0	1.9	0.0	21.3	10.0	0.29	0.07	0.00	0.07
May	0.0	1.2	0.0	13.4	6.3	0.18	0.05	0.00	0.04
June	0.0	1.6	0.0	17.9	8.4	0.24	0.06	0.00	0.05
July	0.5	2.0	0.0	28.0	13.1	0.38	0.10	0.01	0.09
August	0.0	2.0	0.0	22.4	10.5	0.31	0.08	0.00	0.07
September	0.0	2.1	0.0	23.5	11.0	0.32	0.08	0.00	0.07
Q1 Total	0.0	6.5	0.0	72.8	34.1	0.99	0.25	0.02	0.22
Q2 Total	0.0	4.7	0.0	52.6	24.7	0.72	0.18	0.01	0.16
Q3 Total	0.5	6.1	0.0	73.9	34.7	1.0	0.25	0.02	0.23
Annual Limit for Maintenance and Testing ³			50						
Total Annual Limit ³			200						
Exceeds Limits?			No						

¹ Monthly hours of operation calculated from Device 385/403 run timer readings.

² Fuel usage (gal/month) calculated by multiplying the hours of operation by the unit's maximum fuel throughput (11.2 gal/hour).

³ Annual limits for hours of operation are per Condition of Certification (COC) AQ-15.

Appendix B

Cooling Tower Blowdown Reports





781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

July 07, 2022

Matt Richards
City of Vernon
4963 Soto St.
Vernon, CA 90058

Report No.: 2206335
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on June 28, 2022.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.



Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

City of Vernon
 4963 Soto St.
 Vernon, CA 90058

File #:74548
 Report Date: 07/07/22
 Submitted: 06/28/22
PLS Report No.: 2206335

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2206335-01) Sampled: 06/28/22 09:35 Received: 06/28/22											
Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch	
Total Dissolved Solids	4020		1	mg/L	5.0	- SM 2540C	06/29/22	06/30/22	vc	BG20526	

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier	
Batch BG20526 - -											
Blank											
Prepared: 06/29/22 Analyzed: 06/30/22											
Total Dissolved Solids	ND	5.0	mg/L								
LCS											
Prepared: 06/29/22 Analyzed: 06/30/22											
Total Dissolved Solids	60.0	5.0	mg/L	50.00		120	80-120				
Duplicate											
Source: 2206335-01 Prepared: 06/29/22 Analyzed: 06/30/22											
Total Dissolved Solids	3970	5.0	mg/L		4020			1.04	5		

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the detection limit
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Rick Owen Parker

Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021
 [213] 745-5312 FAX [213] 745-6372

DATE: 6-28-22 PAGE: 1 OF 1

FILE NO.: _____ LAB NO.: 1106995

CLIENT NAME: CITY OF VERNON PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. AIRBILL NO:

ADDRESS: 4963 SOTO ST. VERNON CA 90058 ANALYSES REQUESTED

PROJECT MANAGER MATT RICHARDS PHONE NO: FAX NO: OBSERVED TEMP 1.1²

SAMPLER NAME: JOHN BARIE SIGNATURE: [Signature] CORRECTED TEMP 0.9²

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal THERMO ID: 66

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS											SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE												
	<u>6-28-22</u>	<u>0935</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X											

Relinquished by (Signature & Name): <u>[Signature]</u>	Received by (Signature & Name): <u>[Signature]</u>	Date: <u>6-28-22</u>	Time: <u>0935</u>	SAMPLE DISPOSITION 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION:
 Arrived at the lab 6-28-22 1005

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

July 14, 2022

Matt Richards
City of Vernon
4963 Soto St.
Vernon, CA 90058

Report No.: 2207048
Project Name: Malburg Generating Station Weekly


Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on July 07, 2022.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

City of Vernon
 4963 Soto St.
 Vernon, CA 90058

File #:74548
 Report Date: 07/14/22
 Submitted: 07/07/22
PLS Report No.: 2207048

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2207048-01) Sampled: 07/07/22 09:25 Received: 07/07/22

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	4140		1	mg/L	5.0	SM 2540C	07/11/22	07/12/22	vc	BG21326

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
Batch BG21326 - -										
Blank										
Total Dissolved Solids	ND	5.0	mg/L							
LCS										
Total Dissolved Solids	52.0	5.0	mg/L	50.00		104	80-120			
Duplicate Source: 2207046-01										
Total Dissolved Solids	1070	5.0	mg/L		1060			1.72	5	

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the detection limit
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Pick Owen Parkin

 Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

DATE: 7-7-22 PAGE: 1 OF 1

FILE NO.: _____ LAB NO.: 2207048

CLIENT NAME: CITY OF VERNON PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. AIRBILL NO:

ADDRESS: 4963 SOTO ST. VERNON CA 90058 ANALYSES REQUESTED OBSERVED TEMP 22.2

PROJECT MANAGER MATT RICHARDS PHONE NO: FAX NO: CORRECTED TEMP: 20.2

SAMPLER NAME: JOHN BARIE SIGNATURE: [Signature] THERMO ID: 61

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: --- -- -- -- -- -- -- -- -- -- --

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS								SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE									
	<u>7-7-22</u>	<u>0925</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X								

Relinquished by (Signature & Name): <u>[Signature]</u>	Received by (Signature & Name): <u>[Signature]</u>	Date: <u>7-7-22</u>	Time: <u>0925</u>	SAMPLE DISPOSITION 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days. By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION: Arrived at the lab 7-7-22 1130

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

July 18, 2022

Matt Richards
City of Vernon
4963 Soto St.
Vernon, CA 90058

Report No.: 2207073
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on July 11, 2022.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

A handwritten signature in black ink that reads "John Schwedt".

Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

City of Vernon
 4963 Soto St.
 Vernon, CA 90058

File #:74548
 Report Date: 07/18/22
 Submitted: 07/11/22
PLS Report No.: 2207073

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2207073-01) Sampled: 07/08/22 08:50 Received: 07/11/22											
Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch	
Total Dissolved Solids	4570		1	mg/L	5.0	- SM 2540C	07/14/22	07/15/22	vc	BG21819	

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier	
Batch BG21819 --											
Blank											
Total Dissolved Solids	ND	5.0	mg/L								
LCS											
Total Dissolved Solids	56.0	5.0	mg/L	50.00		112	80-120				
Duplicate Source: 2207073-01											
Total Dissolved Solids	4810	5.0	mg/L		4570			5.05	5		

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the detection limit
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

DATE: 7-11-22 PAGE: 1 OF 1

FILE NO.: _____ LAB NO.: 2207073

CLIENT NAME: CITY OF VERNON PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. AIRBILL NO:

ADDRESS: 4963 SOTO ST. VERNON CA 90058 ANALYSES REQUESTED OBSERVED TEMP 0.9°C

PROJECT MANAGER MATT RICHARDS PHONE NO: FAX NO: CORRECTED TEMP: 0.7°C

SAMPLER NAME: JOHN BARIE SIGNATURE: *[Signature]* THERMO ID: 66

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS										SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE											
	7-11-22	0850	COOLING TOWER BLOWDOWN	X				N	1	P	X										

Relinquished by (Signature & Name): <i>[Signature]</i>	Received by (Signature & Name): <i>[Signature]</i>	Date: <u>7-11-22</u>	Time: <u>0850</u>	SAMPLE DISPOSITION 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days. By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION: Arrived at the lab 7-11-22/0850

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

July 27, 2022

Matt Richards
City of Vernon
4963 Soto St.
Vernon, CA 90058

Report No.: 2207149
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on July 19, 2022.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

City of Vernon
 4963 Soto St.
 Vernon, CA 90058

File #:74548
 Report Date: 07/27/22
 Submitted: 07/19/22
PLS Report No.: 2207149

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2207149-01) Sampled: 07/19/22 07:35 Received: 07/19/22

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	4380		1	mg/L	5.0	SM 2540C	07/25/22	07/26/22	vc	BG22645

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	Limits	RPD	Limit	Qualifier
---------	--------	-----	-------	-------------	---------------	------	--------	-----	-------	-----------

Batch BG22645 - -

Blank		Prepared: 07/25/22 Analyzed: 07/26/22	
Total Dissolved Solids	ND	5.0	mg/L

LCS		Prepared: 07/25/22 Analyzed: 07/26/22	
Total Dissolved Solids	60.0	5.0	mg/L 50.00
			120 80-120

Duplicate		Source: 2207149-01 Prepared: 07/25/22 Analyzed: 07/26/22	
Total Dissolved Solids	4210	5.0	mg/L 4380
			3.99 5

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the detection limit
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Rich Owen Parlin

 Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

DATE: 7-19-22 PAGE: 1 OF 1

FILE NO.: _____ LAB NO.: 2207149

CLIENT NAME: CITY OF VERNON PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. AIRBILL NO:

ADDRESS: 4963 SOTO ST. VERNON CA 90058 ANALYSES REQUESTED OBSERVED TEMP 1.4°C

PROJECT MANAGER MATT RICHARDS PHONE NO: FAX NO: CORRECTED TEMP: 1.2°C

SAMPLER NAME: JOHN BARIE SIGNATURE: *[Signature]* THERMO ID: 66

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS									SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE										
	<u>7-19-22</u>	<u>0735</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X									

Relinquished by (Signature & Name): <i>[Signature]</i>	Received by (Signature & Name): <i>[Signature]</i> John Barie	Date: <u>7-19-22</u>	Time: <u>0735</u>	SAMPLE DISPOSITION 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION: Arrived at the lab 7-19-22 0900

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

July 29, 2022

Matt Richards
City of Vernon
4963 Soto St.
Vernon, CA 90058

Report No.: 2207207
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on July 25, 2022.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

A handwritten signature in black ink, appearing to read 'Jan Schmidt', is written over a horizontal line.

Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

City of Vernon
 4963 Soto St.
 Vernon, CA 90058

File #:74548
 Report Date: 07/29/22
 Submitted: 07/25/22
PLS Report No.: 2207207

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2207207-01) Sampled: 07/25/22 07:35 Received: 07/25/22											
Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch	
Total Dissolved Solids	4470		1	mg/L	5.0	- SM 2540C	07/25/22	07/26/22	vc	BG22645	

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier	
Batch BG22645 - -											
Blank Prepared: 07/25/22 Analyzed: 07/26/22											
Total Dissolved Solids	ND	5.0	mg/L								
LCS Prepared: 07/25/22 Analyzed: 07/26/22											
Total Dissolved Solids	60.0	5.0	mg/L	50.00		120	80-120				
Duplicate Source: 2207149-01 Prepared: 07/25/22 Analyzed: 07/26/22											
Total Dissolved Solids	4210	5.0	mg/L		4380			3.99	5		

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the detection limit
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Fick Owen Parker

Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

DATE: 7-25-22 PAGE: 1 OF 1

FILE NO.: _____ LAB NO.: 2207207

CLIENT NAME: CITY OF VERNON PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. AIRBILL NO:

ADDRESS: 4963 SOTO ST. VERNON CA 90058 ANALYSES REQUESTED OBSERVED TEMP 10°C

PROJECT MANAGER MATT RICHARDS PHONE NO: FAX NO: CORRECTED TEMP: 0.8°C

SAMPLER NAME: JOHN BARIE SIGNATURE: [Signature] THERMO ID: 66

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS								SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE									
	<u>7/25/22</u>	<u>0735</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X								

Relinquished by (Signature & Name): <u>[Signature]</u>	Received by (Signature & Name): <u>[Signature]</u>	Date: <u>7-25-22</u>	Time: <u>0735</u>	SAMPLE DISPOSITION 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION: Arrived at the lab 7-25-22 0920

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

August 09, 2022

Matt Richards
City of Vernon
4963 Soto St.
Vernon, CA 90058

Report No.: 2208033
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on August 03, 2022.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

City of Vernon
 4963 Soto St.
 Vernon, CA 90058

File #: 74548
 Report Date: 08/09/22
 Submitted: 08/03/22
PLS Report No.: 2208033

Attn: Matt Richards Phone: (323) 476-3626 FAX: (323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2208033-01) Sampled: 08/03/22 08:25 Received: 08/03/22

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	3980		1	mg/L	5.0	- SM 2540C	08/04/22	08/05/22	vc	BH20832

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
Batch BH20832 - -										
Blank										
Prepared: 08/04/22 Analyzed: 08/05/22										
Total Dissolved Solids	ND	5.0	mg/L							
LCS										
Prepared: 08/04/22 Analyzed: 08/05/22										
Total Dissolved Solids	45.0	5.0	mg/L	50.00		90.0	80-120			
Duplicate										
Source: 2208033-01 Prepared: 08/04/22 Analyzed: 08/05/22										
Total Dissolved Solids	4020	5.0	mg/L		3980			1.13	5	

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the detection limit
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Pick Owen Parlier

Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021
 [213] 745-5312 FAX [213] 745-6372

DATE: 8-3-22 PAGE: 1 OF 1

FILE NO.: _____ LAB NO.: 204033

CLIENT NAME: CITY OF VERNON PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. AIRBILL NO:

ADDRESS: 4963 SOTO ST. VERNON CA 90058 ANALYSES REQUESTED

PROJECT MANAGER MATT RICHARDS PHONE NO: FAX NO: OBSERVED TEMP: 1.5°C

SAMPLER NAME: JOHN BARIE SIGNATURE: *Jr* THERMO ID: 66

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS										SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE											
	<u>8-3-22</u>	<u>0825</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X										

Relinquished by (Signature & Name): <i>MA</i>	Received by (Signature & Name): <i>John Barie</i>	Date: <u>8-3-22</u>	Time: <u>0825</u>	SAMPLE DISPOSITION 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION: Arrived at the lab 8-3-22 1130

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

August 15, 2022

Matt Richards
City of Vernon
4963 Soto St.
Vernon, CA 90058

Report No.: 2208070
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on August 08, 2022.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

City of Vernon
 4963 Soto St.
 Vernon, CA 90058

File #:74548
 Report Date: 08/15/22
 Submitted: 08/08/22
PLS Report No.: 2208070

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2208070-01) Sampled: 08/08/22 10:25 Received: 08/08/22										
Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	4420		1	mg/L	5.0	SM 2540C	08/11/22	08/12/22	vc	BH21531

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
Batch BH21531 - -										
Blank										
Total Dissolved Solids	ND	5.0	mg/L							
LCS										
Total Dissolved Solids	53.0	5.0	mg/L	50.00		106	80-120			
Duplicate										
Source: 2208070-01		Prepared: 08/11/22 Analyzed: 08/12/22								
Total Dissolved Solids	4380	5.0	mg/L		4420			0.796	5	

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the detection limit
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Pick Owen Parlier

 Authorized Signature(s)



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

August 22, 2022

Matt Richards
City of Vernon
4963 Soto St.
Vernon, CA 90058

Report No.: 2208135
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on August 15, 2022.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

City of Vernon
 4963 Soto St.
 Vernon, CA 90058

File #:74548
 Report Date: 08/22/22
 Submitted: 08/15/22
PLS Report No.: 2208135

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2208135-01) Sampled: 08/15/22 08:45 Received: 08/15/22

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	4100		1	mg/L	5.0	SM 2540C	08/17/22	08/18/22	vc	BH21906

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
Batch BH21906 - -										
Blank										
Total Dissolved Solids	ND	5.0	mg/L							
LCS										
Total Dissolved Solids	48.0	5.0	mg/L				80-120			
Duplicate Source: 2208109-18										
Total Dissolved Solids	2640	5.0	mg/L		2520			4.49	5	
Duplicate Source: 2208135-01										
Total Dissolved Solids	4090	5.0	mg/L		4100			0.326	5	

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the detection limit
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Rick Owen Parker

 Authorized Signature(s)



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

August 31, 2022

Matt Richards
City of Vernon
4963 Soto St.
Vernon, CA 90058

Report No.: 2208238
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on August 23, 2022.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.



Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

City of Vernon
 4963 Soto St.
 Vernon, CA 90058

File #: 74548
 Report Date: 08/31/22
 Submitted: 08/23/22
PLS Report No.: 2208238

Attn: Matt Richards Phone: (323) 476-3626 FAX: (323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2208238-01) Sampled: 08/23/22 08:10 Received: 08/23/22										
Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	4020		1	mg/L	5.0	SM 2540C	08/29/22	08/30/22	vc	BH23030

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	RPD	RPD	Qualifier	
Batch BH23030 - -										
Blank										
Total Dissolved Solids	ND	5.0	mg/L							
LCS										
Total Dissolved Solids	41.0	5.0	mg/L	50.00		82.0	80-120			
Duplicate Source: 2208238-01										
Total Dissolved Solids	4050	5.0	mg/L		4020		0.825	5		
Duplicate Source: 2208277-03										
Total Dissolved Solids	5420	5.0	mg/L		5560		2.48	5		

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the detection limit
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Rick Owen Parker

Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021
[213] 745-5312 FAX [213] 745-6372

DATE: 8-23-22 PAGE: 1 OF 1

FILE NO.: _____ LAB NO.: 1208228

CLIENT NAME: CITY OF VERNON PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. _____ AIRBILL NO: _____

ADDRESS: 4963 SOTO ST. VERNON CA 90058 ANALYSES REQUESTED

PROJECT MANAGER MATT RICHARDS PHONE NO: _____ FAX NO: _____ OBSERVED TEMP: 2.3°C

SAMPLER NAME: JOHN BARIE SIGNATURE: *[Signature]* CORRECTED TEMP: 2.1°C

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal THERMO ID: 66

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS								SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE									
	<u>8/23/22</u>	<u>BD</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X								

Relinquished by (Signature & Name): <i>[Signature]</i>	Received by (Signature & Name): <i>[Signature]</i>	Date: <u>8-23-22</u>	Time: <u>0810</u>	SAMPLE DISPOSITION 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days. By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION: Arrived at the lab 8-23-22 1065

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

September 06, 2022

Matt Richards
City of Vernon
4963 Soto St.
Vernon, CA 90058

Report No.: 2208307
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on August 29, 2022.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.

A handwritten signature in blue ink, appearing to be 'James...', is written over a horizontal line.

Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

City of Vernon
 4963 Soto St.
 Vernon, CA 90058

File #:74548
 Report Date: 09/06/22
 Submitted: 08/29/22
PLS Report No.: 2208307

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2208307-01) Sampled: 08/29/22 08:40 Received: 08/29/22										
Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	4040		1	mg/L	5.0	- SM 2540C	08/29/22	08/30/22	vc	BH23030

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
Batch BH23030 --										
Blank										
Total Dissolved Solids	ND	5.0	mg/L							
LCS										
Total Dissolved Solids	41.0	5.0	mg/L	50.00		82.0	80-120			
Duplicate Source: 2208238-01 Prepared: 08/29/22 Analyzed: 08/30/22										
Total Dissolved Solids	4050	5.0	mg/L		4020			0.825	5	
Duplicate Source: 2208277-03 Prepared: 08/29/22 Analyzed: 08/30/22										
Total Dissolved Solids	5420	5.0	mg/L		5560			2.48	5	

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the detection limit
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Rick Owen Partier

 Authorized Signature(s)



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

September 14, 2022

Matt Richards
City of Vernon
4963 Soto St.
Vernon, CA 90058

Report No.: 2209050
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on September 07, 2022.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.



Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

City of Vernon
 4963 Soto St.
 Vernon, CA 90058

File #:74548
 Report Date: 09/14/22
 Submitted: 09/07/22
PLS Report No.: 2209050

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2209050-01) Sampled: 09/07/22 09:35 Received: 09/07/22

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	4480		1	mg/L	5.0	- SM 2540C	09/12/22	09/13/22	vc	BI21419

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
---------	--------	-----	-------	-------------	---------------	------	-------------	-----	-----------	-----------

Batch BI21419 --

Blank		Prepared: 09/12/22 Analyzed: 09/13/22	
Total Dissolved Solids	ND	5.0	mg/L
LCS		Prepared: 09/12/22 Analyzed: 09/13/22	
Total Dissolved Solids	60.0	5.0	mg/L 50.00
			120 80-120
Duplicate		Source: 2209050-01 Prepared: 09/12/22 Analyzed: 09/13/22	
Total Dissolved Solids	4590	5.0	mg/L 4480
			2.61 5

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the detection limit
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Reek Owen Parker

 Authorized Signature(s)



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

September 20, 2022

Matt Richards
City of Vernon
4963 Soto St.
Vernon, CA 90058

Report No.: 2209127
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on September 13, 2022.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

City of Vernon
 4963 Soto St.
 Vernon, CA 90058

File #:74548
 Report Date: 09/20/22
 Submitted: 09/13/22
PLS Report No.: 2209127

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2209127-01) Sampled: 09/13/22 09:00 Received: 09/13/22											
Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch	
Total Dissolved Solids	3970		1	mg/L	5.0	- SM 2540C	09/19/22	09/20/22	vc	BI22033	

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier	
Batch BI22033 - -											
Blank Prepared: 09/19/22 Analyzed: 09/20/22											
Total Dissolved Solids	ND	5.0	mg/L								
LCS Prepared: 09/19/22 Analyzed: 09/20/22											
Total Dissolved Solids	42.0	5.0	mg/L	50.00		84.0	80-120				
Duplicate Source: 2209127-01 Prepared: 09/19/22 Analyzed: 09/20/22											
Total Dissolved Solids	4150	5.0	mg/L		3970			4.35	5		

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the reported limit(s)
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Fick Owen Parker

 Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021
[213] 745-5312 FAX [213] 745-6372

DATE: 9-13-22 PAGE: 1 OF 1

FILE NO.: _____ LAB NO.: 2021127

CLIENT NAME: CITY OF VERNON PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. AIRBILL NO:

ADDRESS: 4963 SOTO ST. VERNON CA 90058 ANALYSES REQUESTED OBSERVED TEMP: 1.3°C

PROJECT MANAGER MATT RICHARDS PHONE NO: FAX NO: CORRECTED TEMP: 1.1°C

SAMPLER NAME: JOHN BARIE SIGNATURE: [Signature] THERMO ID: 60

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS									SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE										
	<u>9-13-22</u>	<u>8:00</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X									

Relinquished by (Signature & Name): <u>[Signature]</u>	Received by (Signature & Name): <u>[Signature]</u>	Date: <u>9-13-22</u>	Time: <u>8:00</u>	SAMPLE DISPOSITION 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION: Arrived at the lab 9-13-22 1035

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

September 27, 2022

Matt Richards
City of Vernon
4963 Soto St.
Vernon, CA 90058

Report No.: 2209183
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on September 20, 2022.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

City of Vernon
 4963 Soto St.
 Vernon, CA 90058

File #:74548
 Report Date: 09/27/22
 Submitted: 09/20/22
PLS Report No.: 2209183

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2209183-01) Sampled: 09/20/22 08:55 Received: 09/20/22

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	4070		1	mg/L	5.0	- SM 2540C	09/26/22	09/27/22	vc	BI22723

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
Batch BI22723 --										
Blank	Prepared: 09/26/22 Analyzed: 09/27/22									
Total Dissolved Solids	ND	5.0	mg/L							
LCS	Prepared: 09/26/22 Analyzed: 09/27/22									
Total Dissolved Solids	40.0	5.0	mg/L	50.00		80.0	80-120			
Duplicate	Source: 2209183-01 Prepared: 09/26/22 Analyzed: 09/27/22									
Total Dissolved Solids	4070	5.0	mg/L		4070			0.0819	5	
Duplicate	Source: 2209184-01 Prepared: 09/26/22 Analyzed: 09/27/22									
Total Dissolved Solids	1890	5.0	mg/L		1820			3.87	5	

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the reported limit(s)
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Rick Owen Parlin
 Authorized Signature(s)



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

October 05, 2022

Matt Richards
City of Vernon
4963 Soto St.
Vernon, CA 90058

Report No.: 2209247
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on September 27, 2022.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. The laboratory report may not be produced, except in full, without the written approval of the laboratory.

The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) is provided on final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

City of Vernon
 4963 Soto St.
 Vernon, CA 90058

File #:74548
 Report Date: 10/05/22
 Submitted: 09/27/22
PLS Report No.: 2209247

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2209247-01) Sampled: 09/27/22 09:25 Received: 09/27/22

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	4080		1	mg/L	5.0	SM 2540C	10/03/22	10/04/22	vc	BJ20442

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
Batch BJ20442 - -										
Blank										
Prepared: 10/03/22 Analyzed: 10/04/22										
Total Dissolved Solids	ND	5.0	mg/L							
LCS										
Prepared: 10/03/22 Analyzed: 10/04/22										
Total Dissolved Solids	56.0	5.0	mg/L	50.00		112	80-120			
Duplicate										
Source: 2209247-01 Prepared: 10/03/22 Analyzed: 10/04/22										
Total Dissolved Solids	4240	5.0	mg/L		4080			3.72	5	

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the reported limit(s)
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, Mobile Lab No. 2534, LACSD No. 10138

Rick Owen Parlier

 Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

DATE: 9-27-22 PAGE: 1 OF 1

FILE NO.: _____ LAB NO.: _____

CLIENT NAME: CITY OF VERNON PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. AIRBILL NO:

ADDRESS: 4963 SOTO ST. VERNON CA 90058 ANALYSES REQUESTED OBSERVED TEMP 1.0°C

PROJECT MANAGER MATT RICHARDS PHONE NO: FAX NO: CORRECTED TEMP: 0.8°C

SAMPLER NAME: JOHN BARIE SIGNATURE: [Signature] THERMO ID: 66

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS	ANALYSES REQUESTED						SAMPLE CONDITIONS/ CONTAINER/COMMENTS	
				WATER	SOIL	SLUDGE	OTHER		#	TYPE									
	<u>9/27/22</u>	<u>0925</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X								

Relinquished by (Signature & Name): <u>MA</u>	Received by (Signature & Name): <u>[Signature]</u> John Barie	Date: <u>9/27/22</u>	Time: <u>0925</u>	SAMPLE DISPOSITION 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION: Arrived at the lab 9-27-22 10am

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER

Appendix C

Operation Logs



Malburg Generating Station
Appendix C, Table 1
Combustion Turbine Generator (CTG) Startup and Shutdown Events
During Quarter 3, 2022

CGT 1

Date	Event Type ¹	Event Start	Event End	Duration (hrs:min)
7/14/2022	Cold Start	15:59	17:18	1:19
8/20/2022	Shutdown	0:01	0:09	0:08
8/24/2022	Cold Start	14:00	15:06	1:06
9/16/2022	Trip / Shutdown	13:29	13:29	0:00
9/26/2022	Cold Start	14:43	16:00	1:17

CGT 2

Date	Event Type ¹	Event Start	Event End	Duration (hrs:min)
7/15/2022	Shutdown	23:07	23:15	0:08
7/18/2022	Cold Start	15:43	16:54	1:11
8/27/2022	Shutdown	00:01	00:09	0:08
8/30/2022	Cold Start	13:58	15:04	1:06
9/30/2022	Shutdown	21:01	21:09	0:08

¹ A startup event is defined as initiation of combustion until the system becomes emissions compliant, for consistency with the Title V Permit definitions.

Malburg Generating Station
Appendix C, Table 2
Diesel Firewater Pump Testing Times
During Quarter 3, 2022

Date	Time (hh:mm)	Start Hours	End Hours	Event Type	Hours of Operation
7/3/2022	22:11	342	342	Testing	0.0
7/6/2022	10:16	342	342.5	Maintenance	0.5
7/10/2022	21:18	342.5	343	Testing	0.5
7/17/2022	20:45	343	343.5	Testing	0.5
7/24/2022	19:26	343.5	344	Testing	0.5
7/31/2022	22:18	344	344.5	Testing	0.5
8/7/2022	20:14	344.5	345	Testing	0.5
8/14/2022	19:45	345	345.5	Testing	0.5
8/21/2022	23:17	345.5	346	Testing	0.5
8/28/2022	23:48	346	346.5	Testing	0.5
9/4/2022	23:21	346.5	347.1	Testing	0.6
9/11/2022	21:16	347.1	347.6	Testing	0.5
9/18/2022	17:50	347.6	348.1	Testing	0.5
9/25/2022	22:19	348.1	348.6	Testing	0.5

Appendix D

Diesel Fuel Oil Purchase Records



Invoice



SC Commercial, LLC, DBA SC Fuels
 1800 West Katella Ave, Suite 400
 P.O. Box 4159, Orange, CA 92863-4159

PLEASE REMIT ALL PAYMENTS TO:

P.O. BOX 14237
ORANGE, CA 92863-1237

Ph: (800) 659-5823 Credit Inquiries: (888) SCFUELS Ext.6017

INVOICE: 2100721-IN

INVOICE DATE: 4/11/2022

DUE DATE: 5/11/2022

SHIP DATE: 4/11/2022

SHIP VIA: 924

ORDER DATE: 4/1/2022

ORDER NUMBER: 2100721

CUSTOMER PO: 055.0002948

TERMS: N30

SALEPERSON: Todd Cripps
714-938-5714

ACCT NO (Bill-to): 01-0001045

CITY OF VERNON
 4305 SANTA FE AVE
 ATTN: DEPARTMENT D
 VERNON, CA 90058
 (323) 583-8811

ACCT NO (Ship-to) 01-0001045 103L

CITY OF VERNON-SOTO ST-L
 4963 SOTO ST
 VERNON, CA 90058

ITEM CODE	ITEM DESCRIPTION	QUANTITY ORDERED	QUANTITY DELIVERED	PACKAGE DESCRIPTION	EXTENDED QTY	UNIT PRICE	EXT PRICE
CH277210983D40 0	CH MEROPA 150 277210983	1	1.00	400 LB DR	400.00	3.39000	1,356.00
	Whse: 101						
	\$3.39 PER TC						
422D055	DYED CARB ULS DIESEL NON TAXABLE USE ONLY - PENALTY FOR TAXABLE USE 15 PPM OR LESS SULFUR - MAY CONTAIN UP TO 5% BIODIESEL MTO/ \$4.35 PER TC	2	2.00	55 G DR	110.00	4.35000	478.50
	Whse: 101						
	Federal Lust					0.00100	0.11
	Federal Oil Spill					0.00214	0.24
	CA - AB 32 - DSL					0.00828	0.91
						4.36142	479.76
CH273204981D05 5	CH REGAL R&O ISO 150 273204981 FORMERLY - 273213981 1 BACKORDERED ON 2104708	0	0.00	55 G DR	0.00	0.00000	0.00
	Whse: 101						
	/FUELCHLUBE FUEL SURCHARGE LUBES						9.92
	/RCFLUBE REG COMPLIANCE FEE LUBES						12.95
DRUMDEPOSITC 001	DRUM DEPOSIT FEE	3	3.00	MISC CHRG	3.00	25.00000	75.00
	Whse: 101						
MSRTNDRMC001	RETURN DRUM	0	-2.00	MISC CHRG	2.00-	15.00000	30.00-
	Whse: 101						

Save time, pay online! View invoices, make payments and more.
 Sign up for the Customer Portal today. Email: creditinquiries@scfuels.com or Call 888-SCFuels
 Ext. 6017 or login to Customer Portal: <https://customerportal.scfuels.com>
 24-hour Emergency Response Call CHEMTREC: 800-424-9300

Net Invoice: 1,903.63
 Less Discount: 0.00
 Freight: 0.00
 Sales Tax: 190.52
Invoice Total: 2,094.15

- IN THE EVENT THAT THE ABOVE CHARGES ARE NOT PAID WHEN DUE, SC COMMERCIAL, LLC, DBA SC FUELS RESERVES THE RIGHT TO REFUSE FURTHER CHARGES TO THE ACCOUNT. A SERVICE CHARGE OF 1.5% PER MONTH(A.P.R. 18%) WILL APPLY TO ALL PAST DUE INVOICES.
 - ERRORS IN PRICE, EXTENSION, AND ADDITION SUBJECT TO CORRECTION.
 - It is the purchaser's responsibility to verify that all applicable taxes are being charged in accordance with federal and state laws.
 - Prices shown on this invoice reflect discounts received for Payment by Cash, Check, or Electronic Funds Transfer (EFT). Payment by other means is subject to a 3% surcharge.

Appendix E

Excess Emission Reports



Startup/Shutdown Excess Emissions Report

U1 CO Startup/Shutdown



From: 07/01/2022 00:00 **To:** 09/30/2022 23:59 **Facility Name:** Malburg Generating Station

Generated: 10/20/2022 05:08 **Location:** Vernon, California

Tag Name: U1_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,529.98 Hours

Non-Operating Time: 678.02 Hours Report Time: 2,208.00 Hours

Unit Operation

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description

No excess emissions were found in the reporting period.

Startup/Shutdown Excess Emissions Report

U1 CO Startup/Shutdown



From: 07/01/2022 00:00 **To:** 09/30/2022 23:59 **Facility Name:** Malburg Generating Station

Generated: 10/20/2022 05:08 **Location:** Vernon, California

Tag Name: U1_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,529.98 Hours

Non-Operating Time: 678.02 Hours Report Time: 2,208.00 Hours

No invalid events were found in the reporting period.

Startup/Shutdown Excess Emissions Report

U1 NOx Startup/Shutdown



From: 07/01/2022 00:00 **To:** 09/30/2022 23:59 **Facility Name:** Malburg Generating Station

Generated: 10/20/2022 05:09 **Location:** Vernon, California

Tag Name: U1_NOXRECLM_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,529.98 Hours

Non-Operating Time: 678.02 Hours Report Time: 2,208.00 Hours

Unit Operation

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description

No excess emissions were found in the reporting period.

Startup/Shutdown Excess Emissions Report

U1 NOx Startup/Shutdown



From: 07/01/2022 00:00 **To:** 09/30/2022 23:59 **Facility Name:** Malburg Generating Station

Generated: 10/20/2022 05:09 **Location:** Vernon, California

Tag Name: U1_NOXRECLM_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,529.98 Hours

Non-Operating Time: 678.02 Hours Report Time: 2,208.00 Hours

No invalid events were found in the reporting period.

Startup/Shutdown Excess Emissions Report

U1 VOC Startup/Shutdown



From: 07/01/2022 00:00 **To:** 09/30/2022 23:59 **Facility Name:** Malburg Generating Station

Generated: 10/20/2022 05:11 **Location:** Vernon, California

Tag Name: U1_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,529.98 Hours

Non-Operating Time: 678.02 Hours Report Time: 2,208.00 Hours

Unit Operation

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description

No excess emissions were found in the reporting period.

Startup/Shutdown Excess Emissions Report

U1 VOC Startup/Shutdown



From: 07/01/2022 00:00 **To:** 09/30/2022 23:59 **Facility Name:** Malburg Generating Station

Generated: 10/20/2022 05:11 **Location:** Vernon, California

Tag Name: U1_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,529.98 Hours

Non-Operating Time: 678.02 Hours Report Time: 2,208.00 Hours

No invalid events were found in the reporting period.

Excess Emission Report

Unit 1 - CO ppmvdc 1-hour during Normal Operation

From: 07/01/2022 00:00 To: 09/30/2022 23:59 Facility Name: Malburg Generating Station
Generated: 10/20/2022 05:12 Location: Vernon, California



Tag Name: U1_CONormal_Ppmvdc_1H

Total Operating Time: 1,534.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 674.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,534.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



Unit 1 - NOx ppmvdc 1-hour during Normal Operation

From: 07/01/2022 00:00 To: 09/30/2022 23:59 Facility Name: Malburg Generating Station
Generated: 10/20/2022 10:47 Location: Vernon, California

Tag Name: U1_NOxNormal_Ppmvdc_1H

Total Operating Time: 1,534.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 674.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,534.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

Unit 1 - VOC ppmvdc 1-hour during Normal Operation

From: 07/01/2022 00:00 To: 09/30/2022 23:59 Facility Name: Malburg Generating Station
Generated: 10/20/2022 05:15 Location: Vernon, California



Tag Name: U1_VOCNormal_Ppmvdc_1H

Total Operating Time: 1,534.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 674.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,534.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Quad K Excess Emissions Report

U1 NOX 4-Hour Events

From: 07/01/2022 00:00 To: 09/30/2022 23:59
Generated: 10/20/2022 05:16

Facility Name: Malburg Generating Station
Location: Vernon, California



Tag Name: U1_NOx4H_Ppmvdc_1H

Total Operating Time: 1,534.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 674.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,534.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

Unit 1 - CO ppmvdc 3-hour Rolling during Normal Operation

From: 07/01/2022 00:00 To: 09/30/2022 23:59 Facility Name: Malburg Generating Station
Generated: 10/20/2022 05:36 Location: Vernon, California



Tag Name: U1_CO_3HrRoll_Ppmvdc_1H

Total Operating Time: 1,534.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 674.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,534.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Startup/Shutdown Event Report

U2 CO Startup/Shutdown Events



From: 07/01/2022 00:00 **To:** 09/30/2022 23:59 **Facility Name:** Malburg Generating Station

Generated: 10/20/2022 05:18 **Location:** Vernon, California

Tag Name: U2_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,053.93 Hours

Non-Operating Time: 154.07 Hours Report Time: 2,208.00 Hours

Unit Operation

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description

No excess emissions were found in the reporting period.

Startup/Shutdown Event Report

U2 CO Startup/Shutdown Events



From: 07/01/2022 00:00 **To:** 09/30/2022 23:59 **Facility Name:** Malburg Generating Station

Generated: 10/20/2022 05:18

Location: Vernon, California

Tag Name: U2_CO_LbPerHr_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,053.93 Hours

Non-Operating Time: 154.07 Hours

Report Time: 2,208.00 Hours

No invalid events were found in the reporting period.

Startup/Shutdown Excess Emissions Report

U2 NOx Startup/Shutdown



From: 07/01/2022 00:00 **To:** 09/30/2022 23:59 **Facility Name:** Malburg Generating Station

Generated: 10/20/2022 05:20 **Location:** Vernon, California

Tag Name: U2_NOXRECLM_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,053.93 Hours

Non-Operating Time: 154.07 Hours Report Time: 2,208.00 Hours

Unit Operation

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description

No excess emissions were found in the reporting period.

Startup/Shutdown Excess Emissions Report

U2 NOx Startup/Shutdown



From: 07/01/2022 00:00 **To:** 09/30/2022 23:59 **Facility Name:** Malburg Generating Station

Generated: 10/20/2022 05:20 **Location:** Vernon, California

Tag Name: U2_NOXRECLM_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,053.93 Hours

Non-Operating Time: 154.07 Hours Report Time: 2,208.00 Hours

No invalid events were found in the reporting period.

Startup/Shutdown Event Report

U2 VOC Startup/Shutdown Events



From: 07/01/2022 00:00 **To:** 09/30/2022 23:59 **Facility Name:** Malburg Generating Station

Generated: 10/20/2022 05:22 **Location:** Vernon, California

Tag Name: U2_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,053.93 Hours

Non-Operating Time: 154.07 Hours Report Time: 2,208.00 Hours

Unit Operation

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description

No excess emissions were found in the reporting period.

Startup/Shutdown Event Report

U2 VOC Startup/Shutdown Events



From: 07/01/2022 00:00 **To:** 09/30/2022 23:59 **Facility Name:** Malburg Generating Station

Generated: 10/20/2022 05:22

Location: Vernon, California

Tag Name: U2_VOC_LbPerHr_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 2,053.93 Hours

Non-Operating Time: 154.07 Hours

Report Time: 2,208.00 Hours

No invalid events were found in the reporting period.

Excess Emission Report

Unit 2 - CO ppmvdc 1-hour during Normal Operation

From: 07/01/2022 00:00 To: 09/30/2022 23:59 Facility Name: Malburg Generating Station
Generated: 10/20/2022 05:28 Location: Vernon, California



Tag Name: U2_CONormal_Ppmvdc_1H

Total Operating Time: 2,058.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 150.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,058.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

Unit 2 - NOx ppmvdc 1-hour during Normal Operation

From: 07/01/2022 00:00 To: 09/30/2022 23:59 Facility Name: Malburg Generating Station
Generated: 10/20/2022 05:30 Location: Vernon, California



Tag Name: U2_NOxNormal_Ppmvdc_1H

Total Operating Time: 2,058.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 150.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,058.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

Unit 2 - VOC ppmvdc 1-hour during Normal Operation

From: 07/01/2022 00:00 To: 09/30/2022 23:59 Facility Name: Malburg Generating Station
Generated: 10/20/2022 05:32 Location: Vernon, California



Tag Name: U2_VOCNormal_Ppmvdc_1H

Total Operating Time: 2,058.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 150.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,058.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Quad K Excess Emissions Report

U2 NOX 4-Hour Events

From: 07/01/2022 00:00 To: 09/30/2022 23:59
Generated: 10/20/2022 05:33

Facility Name: Malburg Generating Station
Location: Vernon, California



Tag Name: U2_NOx4H_Ppmvdc_1H

Total Operating Time: 2,058.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 150.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,058.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

Unit 2 - CO ppmvdc 3-hour Rolling during Normal Operation

From: 07/01/2022 00:00 To: 09/30/2022 23:59 Facility Name: Malburg Generating Station
Generated: 10/20/2022 05:37 Location: Vernon, California



Tag Name: U2_CO_3HrRoll_Ppmvdc_1H

Total Operating Time: 2,058.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 150.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,058.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %